

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0374	.7621	.8383		.9145	
2	.8573	.9431	.7621	.8478		.905	
3	.8573	.9431	.7621	.9431		.905	
4	.9431	.9431	.7621	1.0374		.9955	
5	.9431	1.0374	.8383	1.0269		.9221	
6	1.0288	1.1317	.9145	1.1203		1.1317	.9717
9	.9431	1.0374	.9145	1.0374		1.0374	
10			.8383	.7621	.8383	1.0269	.7621
11		.7621				.8573	.7621
12			.7621		.7621	.8573	
13	.5335					.7621	
14		.6859			.7621	.8573	.7621
15	.5335	.7621	.6859		.7621	.8573	
16	.7621	.7621		1.0288	.7621	.9431	.7621
17		.7621	.8488			.9431	.7621
18	.8383	.8383	1.0374	.9907	1.0374		.7621
19	1.0374	.9145	1.1317		1.1317		1.1145
20	1.0374	.9145	1.226				1.1145
21	1.1317	.9145	1.1203		1.1317		1.1488
22	1.1317	.9145	1.1203		1.226		1.1488
23	1.1317	.8383	1.1317		1.0526		1.1145
24	.9431	1.0374	.8383	.9221		1.0374	1.0059
Max	1.1317	1.1317	1.226	1.1203	1.226	1.1317	1.1488
Min	.5335	.6859	.6859	.7621	.7621	.7621	.7621
Avg	.9174	.9042	.9143	.9595	.9466	.9346	.9378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 202 / 11KV AKLUJ URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.226	1.0669	2.1195		1.267	
2		1.1317	.9145	2.2634		1.1336	
3	1.1145	1.1317	.9145	2.2634		1.267	
4	1.1145	1.1317	.9145	2.2862		1.1336	
5	1.2003	1.226	.9907	2.452		1.267	
6	1.2003	1.226	1.0669	2.5463		1.267	1.2146
9	1.286	1.4146	1.1431	2.7349		1.448	
10			1.2193		1.1431	1.267	1.3717
11		1.0669				1.2003	1.3717
12			1.1431		1.0669	1.286	
13	1.0669		1.1431			1.1431	
14		.9907			1.2193	1.286	1.2955
15	1.0669	1.0669	1.0669		1.1431	1.286	
16	1.0669	1.1431			1.1431	1.3717	1.3717
17		1.0669	1.4146			1.3717	1.2955
18	1.3203	1.0669	2.7349		1.4146		1.2955
19	1.5089	1.2955	2.894		1.6975		1.7147
20	1.6032	1.3717	2.9864				1.7147
21	1.6975	1.3717	3.0807		1.7918		1.6289
22	1.6975	1.3717	3.2065		1.7375		1.6289
23	1.4937	1.2193	2.5149		1.6461		1.6289
24	1.286	1.4146	1.1431	2.5463			1.2955
Max	1.6975	1.4146	3.2065	2.7349	1.7918	1.448	1.7147
Min	1.0669	.9907	.9145	2.1195	1.0669	1.1336	1.2146
Avg	1.3131	1.2070	1.6610	2.4015	1.4003	1.2663	1.4483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 203 / 11KV DIVISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0374	.6859	.763		.724	
2	.8573	.9431	.6859	.763		.724	
3	.7716	.7545	.6859	.8488		.6859	
4	.8573	.7545	.6859	.8488		.724	
5	.8573	.6783	.7621	.8488		.8145	
6	.8573	.8488		.7545		.7287	.8097
8	1.8861						
9	.8573	1.0374	.8383			.9955	
10			.8383		.8383	1.086	.8383
11		.7621				1.0288	
12			.8383			1.0288	
13	.7621		.7621				
14		.8383			.7621	1.0288	.8383
15	.7621	.8383	.7621		.8383	1.0288	
16	.8383	.9145		1.286	.8383	1.0288	.8383
17		.8383	1.1317			1.0288	.7621
18	.8478	.8383	1.0974		1.1317		.8383
19	1.0174	.9907	1.226		1.3203		1.2003
20	1.1317	.9145	1.2136				1.2003
21	1.0374	.9145	1.0059		1.0974		1.0631
22	1.0374	.9145	1.0374		1.0374		1.0288
23	.8573	.8383	1.0374		1.0059		1.0288
24	.8573	.9431	.7621	.9431		.905	.905
Max	1.8861	1.0374	1.226	1.286	1.3203	1.086	1.2003
Min	.7621	.6783	.6859	.7545	.7621	.6859	.7621
Avg	.9417	.8737	.8920	.882	.9855	.9040	.9459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 204 / 11KV BAGEWADI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9427		.3052		.3258	
2		1.9805		.3086		.3258	
3		1.9805		.3772		.2429	
4		2.0748		.3772		.362	
5		2.0748		.362		.3563	
6		2.1691					
9		2.5463					
10					1.3717	1.7556	.9907
11							1.9052
14							2.0576
15	.1829	.1829	.2286		2.0576		
16	.1829	.2286			2.21		1.9814
17		.2286	.2829				1.9814
18			.2829		.2452		.1981
19			.3395		.3772		
20			.3772		.3795		
21			.3772		.3658		
22			.3772		.3658		
23			.3772		.3658		
24		1.7918		.3395		.3258	
Max	.1829	2.5463	.3772	.3772	2.21	1.7556	2.0576
Min	.1829	.1829	.2286	.3052	.2452	.2429	.1981
Avg	.1829	1.5637	.3303	.3450	.8598	.5277	1.5191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 206 / 11 KV MIDC

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4715	.381	.5281		.543	
2	.4115	.4715	.381	.5281		.4858	
3	.4115	.4715	.381	.5601		.4858	
4	.4287	.4715	.381	.5601		.4858	
5	.4458	.4715	.381	.5975		.5344	
6	.4458	.5281	.4572	.6036		.543	.4858
9	.3601	.4715	.381	.3658		.9955	
10			.4572	.3048	.442	.543	.503
11						.6173	.6097
12			.6097		.5487	.7545	
13	.6401		.6859				
14		.7164			.5792	.7545	.6401
15	.7164	.6859	.7164		.4877	.7545	
16	.6859	.7164		.6344	.4877	.7202	.6859
17		.7164	.6036			.6173	.6401
18	.5658	.4877	.5658		.5658		
19	.6036	.503	.543		.6602		.5487
20	.6036	.503	.6535		.5853		.5658
21	.5658	.503	.6602		.5853		.6001
22	.5658	.503	.6224		.6036		.6001
23	.5144	.4572	.5658		.5487		.5658
24	.4287	.4715	.381	.5658		.543	.4858
Max	.7164	.7164	.7164	.6344	.6602	.9955	.6859
Min	.3601	.4572	.381	.3048	.442	.4858	.4858
Avg	.5190	.5345	.5162	.5248	.5540	.6252	.5776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 207 / DR INAMDAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.036	.0472	.0366	.0352		.0372	
2	.0377	.0434	.0366	.0373		.0416	
3	.036	.0415	.0366	.0377		.038	
4	.0377	.0377	.0366	.0377		.0416	
5	.0394	.0358	.0366	.0373		.0452	
6	.0412	.034	.0335	.0355		.0356	.0356
7	.036	.049	.0305	.0434		.0486	.0405
8	.0309	.0321	.0305	.0472		.0507	
9	.0326		.0305			.0452	
10			.0457	.0335	.0533	.0452	.0381
11		.0457					.0564
12			.0564		.0457	.06	
13	.0412		.0564			.0457	
14		.0564			.0488	.0617	.0564
15	.0412	.0594	.0594		.0457	.0634	
16	.0442	.0564		.0772	.0564	.0669	.0533
17		.0594	.0509			.0669	.0564
18	.0509	.0549	.0579		.0543		.0564
19	.049	.0533	.0604		.0579		
20	.0509	.0533	.0566				.0497
21	.0472	.0488	.049		.0476		.0497
22	.0434	.0488	.0434		.0421		.0463
23	.0415	.0396	.0396		.0439		.0583
24	.0446	.0453	.0366	.0377		.0434	.0434
Max	.0509	.0594	.0604	.0772	.0579	.0669	.0583
Min	.0309	.0321	.0305	.0335	.0421	.0356	.0356
Avg	.0411	.0471	.0438	.0418	.0496	.0492	.0493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 201 / 11 KV WAGHOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1581	.1715	2.4577	2.5301	2.4806	2.6216
2	.1638	.1581	.1715	2.4291	2.5301	2.4806	2.6216
3	.1638	.1581	.1715	2.4291	2.5301	2.4806	2.6216
4	.1966	.1581	.2058	2.5101	2.6092	2.4806	2.6216
5	.2294	.1898	.2401	2.4291	2.8464	2.4806	2.7854
6	.2458	.1898	.2572	2.672	2.8464	2.4806	2.9492
7				2.753	2.9254	2.7206	2.9492
8				2.753	3.3208	2.5606	3.1131
9					3.2808	2.6726	3.1131
10	1.6804	2.372	2.451				
11	2.6406	2.8464	2.8464				
12	2.5606	2.6882	2.8464				
13	2.4806	2.6882	2.8464				
15	2.4006						
16	2.4806	2.7673	2.8464				
17	2.4006	2.6882	2.6882				
18	.1265	.1372	.0983				
19	.1581	.2229	.1966	.1265	.1715	.2543	.1581
20	.1898	.2572	.2622	.1581	.1715	.2543	.1898
21	.1898	.2572	.2622	.1581	.1715	.2543	.1898
22	.1581	.2058	.2622	.1581	.1715	.2374	.1581
23	.1581	.1715	.1966		.1715	.1696	.1581
24	.1966	.1581	.1715	2.4577	2.6882	2.7206	2.4577
Max	2.6406	2.8464	2.8464	2.753	3.3208	2.7206	3.1131
Min	.1265	.1372	.0983	.1265	.1715	.1696	.1581
Avg	.9492	.9722	1.0101	1.8070	1.931	1.7819	1.9139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 202 / 11KV SANGAM-Lawang-
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.426	.3601	2.5911	2.8673	2.7686	2.8673
2	.2949	.426	.3601	2.5911	2.8673	2.6406	2.8673
3	.3277	.426	.3601	2.5911	2.8673	2.6406	2.8673
4	.3277	.4424	.3772	2.672	2.9492	2.6406	2.8673
5	.3277	.4588	.3772	2.5911	2.9607	2.6406	2.9492
6	.3277	.4588	.3772	2.753	2.9607	2.6406	3.195
7				2.915	3.2007	2.7206	3.2769
8					3.1207	2.7206	3.1131
9					3.0407	2.5606	
10	1.7604	2.7854	2.4577				
11	2.8006	3.1131	3.195				
12		2.7854	3.1131				
13		2.6216	2.9492				
14		2.9959	2.9492				
15	2.7206						
16		2.915	3.1131				
17		2.8464	3.195				
18	.1638	.2229	.1311				
19	.426	.4287	.2785	.3605	.4115	.407	.5735
20	.4915	.463	.2949	.3605	.4287	.3932	.6882
21	.4915	.4458	.2949	.3441		.3277	.6882
22	.4588	.4458	.2785	.2949	.3429	.3277	.6226
23	.4915	.4115	.2622		.2743	.2543	.6554
24	.2949	.4588	.3429	2.4291	2.6216	2.6406	2.6216
Max	2.8006	3.1131	3.195	2.915	3.2007	2.7686	3.2769
Min	.1638	.2229	.1311	.2949	.2743	.2543	.5735
Avg	.7500	1.2789	1.2534	1.8745	2.2081	1.8883	2.1324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 203 / 11 KV LAWANG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4577	2.753	2.4806	.3932	.3887	.4115	.3932
2	2.4577	2.6406	2.4806	.3932	.3887	.4115	.3932
3	2.4577	2.6406	2.5606	.3932	.421	.4115	.3932
4	2.4577	2.7206	2.6406	.4096	.421	.4287	.426
5	2.5396	2.7206	2.8006		.3887	.4287	.4588
6	2.7854	2.8807	3.0407		.3841	.4458	
7	2.7854	3.0407	3.2007				
8	2.8673	3.0407	3.2007				
9	3.1131	3.0407	3.2007	3.0312			
10					2.9492	2.5606	2.5606
11				2.8807	3.4008	3.3608	3.3608
12				2.8006		3.5208	2.8807
13						3.5208	
14					3.4332	3.6008	3.0407
15					3.5627		3.2808
16					3.2388	3.6008	
17					3.1579	3.6008	
18		.1029				.0983	
19	.1619	.12	.2949	.2915	.3429	.2622	.1296
20	.1619	.1372	.4096	.3887	.4287	.3605	.1619
21	.1296	.1715	.4096	.3887	.4287	.3932	.1943
22	.1296	.1543	.4096	.3563	.4115	.3932	.1619
23	.1296	.1372	.3932		.4115	.3932	.0972
24	2.2939	2.672	2.4006	.3932	.3563	.4115	.3932
Max	3.1131	3.0407	3.2007	3.0312	3.5627	3.6008	3.3608
Min	.1296	.1029	.2949	.2915	.3429	.0983	.0972
Avg	1.7952	1.8108	1.9949	1.0100	1.3619	1.4308	1.1454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 204 / GAOTHAN (LAWANG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4508	.5144	.4858	.5258	.5792	.5243
2	.4858	.4681	.5144	.4858	.5258	.5792	.5243
3	.5182	.4681	.5487	.5182	.5434	.5792	.5344
4	.583	.5201	.6001	.583	.5784	.6878	.583
5	.6226	.6516	.6344	.5668	.6415	.7602	.6478
6	.6478	.6274	.7545	.6802			
7	.6478	.6274	.703				
8	.5735	.6443	.6001	.6154			
9	.5182	.4161	.4973	.4858		.5611	.5182
10	.4706	.4334	.4207	.4801	.4858	.4161	.4287
11	.4887	.3467	.4733	.3944	.4858	.5201	.4458
12	.4163	.3772	.4382	.3772		.4161	.4458
13	.4525	.3772	.3856	.3601		.3814	.4287
14		.3086	.4207	.3772	.4534	.3814	.4115
15	.4525		.4207	.3772	.4858	.4161	.4115
16	.4706	.3086	.4382	.4287	.5182	.5201	.4458
17		.362	.3856	.4973	.4858	.4854	
18	.5258	.4525	.421	.5258		.4534	.5959
19	.5258	.724	.5668	.6135	.724	.6554	.6661
20	.6135	.7602	.6478	.6661	.7602	.6478	.7537
21	.631	.724	.6154	.6836	.724	.6154	.7362
22	.5609	.6878	.583	.6485	.6335	.583	.7186
23	.5609	.5792	.5182		.5973	.5506	.5895
24	.4534	.4681	.4973	.4858	.5609	.5249	.0324
Max	.6478	.7602	.7545	.6836	.7602	.7602	.7537
Min	.4163	.3086	.3856	.3601	.4534	.3814	.0324
Avg	.5321	.5123	.5250	.5153	.5723	.5388	.5221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 205 / J K SANGAM

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.13		1.9204	.1867			
2	2.13		2.0005	.1867			
3	2.13		2.0005	.1867			
4	2.13		2.0805	.2241			
5	2.2119		2.1605				
6	2.3758		2.4006				
7	2.7035		2.5606				
8	2.7854		2.6406				
9	2.7035		2.5606	2.7035			
10				2.4806	2.2672	2.5149	2.3205
11				2.2405	2.834	2.9172	2.8807
12				2.2405	2.9959	2.8502	2.5606
13						2.8502	2.5606
14						2.8166	2.5606
15					2.915	2.8502	
16					2.834		
17					2.753	3.0178	
18		.1029				.112	.1341
19		.1715	.2801	.1677	.1715	.3361	.2347
20		.2058	.2987	.2347	.2058	.3361	.2683
21		.1715	.2801	.3018	.1715	.3361	.2347
22		.1715	.2241	.2347	.2058	.3361	.1844
23		.1715	.2241		.2058	.3361	.2012
24	2.2405		1.9204	.2241	.1677	.1715	.3361
Max	2.7854	.2058	2.6406	2.7035	2.9959	3.0178	2.8807
Min	2.13	.1029	.2241	.1677	.1677	.112	.1341
Avg	2.3541	.1658	1.5702	.8933	1.4773	1.5558	1.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 206 / Vajrai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	2.7673	2.7046	.1781	.1265	.1543	.1619
2	2.5911	2.7041	2.7206	.1781	.1423	.1543	.1619
3	2.6235	2.6566	2.8006	.1619	.1423	.1543	.1781
4	2.7206	2.7515	2.9927	.1781	.1265	.1543	.1781
5	2.8502	2.9571	3.1207		.1265	.1715	.1781
6	3.2874	3.0994	3.2167		.1265	.1715	
7	3.2388	3.2417	3.5208				
8	3.4008	3.2259	3.3608				
9	3.3198	3.305	3.2808	2.915			
10				3.0361	2.9959	2.7199	2.8327
11				2.6406	3.2388	.3321	3.3608
12				2.8006	3.1579	.3163	3.0407
13						.3163	2.9607
14					3.2712	3.0203	
15					3.2874	2.9729	2.8807
16					3.1903	3.131	2.5926
17					3.0769		
18		.1372				.1296	.1107
19	.1581	.1543	.1457	.1265	.1543	.1619	.1581
20	.1739	.1886	.2105	.1581	.1886	.1943	.1739
21	.1739	.1715	.1943	.1619	.1715	.1943	.1898
22	.1739	.1715	.1781	.1581	.1543	.1943	.1898
23	.1581	.1715	.1781		.1543	.1802	.1581
24	2.5587	2.5459	2.7526	.1781	.1265	.1715	.1781
Max	3.4008	3.305	3.5208	3.0361	3.2874	3.131	3.3608
Min	.1581	.1372	.1457	.1265	.1265	.1296	.1107
Avg	2.0013	1.8906	2.0918	.9901	1.2610	.7498	1.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 207 / 11 KV CANAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5426	.2401	3.0864	3.4252	3.0887	3.3065
2	.5316	.5256	.2401	3.0864	3.3573	3.0727	3.3436
3	.5487	.5426	.2401	3.086	3.2386	3.1207	3.3265
4	.5658	.5426	.2572	3.1722	3.1708	3.2007	3.2922
5	.5658	.5596	.2743	3.2236	3.0521	3.4408	3.2579
6	.5596	.5765	.2915	3.5322	3.7982	3.6008	3.3951
7				3.7723	3.7982	3.5208	3.4294
8				3.6008	3.5947		3.4252
9					3.4591		3.3065
10	2.8006	3.3913					
11	3.7609	3.6117	3.6965				
12	3.5048	3.6965	3.7473				
13	3.4728	3.6456	3.6286				
14	3.3208	3.4421	3.5947				
16	3.4789	3.7813	3.6965				
17	3.3208	3.5528	3.7982				
18	.4458	.4458	.2915				
19	.5144	.5316	.2915	.2915	.2915	.3086	.2915
20	.5658	.583	.3086	.3258	.3258	.3258	.3258
21	.5487	.5658	.3086	.3086	.3258	.3429	.3258
22	.5487	.5658	.3086	.3258	.3258	.3429	.3258
23	.5658	.5658	.3086		.3258	.3258	.3086
24	.5316	.5426	.2401	3.0521	3.476	2.8647	3.1722
Max	3.7609	3.7813	3.7982	3.7723	3.7982	3.6008	3.4294
Min	.4458	.4458	.2401	.2915	.2915	.3086	.2915
Avg	1.5342	1.6106	1.3559	2.3741	2.3977	2.1197	2.3222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 202 / VIZORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	1.3717	1.2003	1.4582	2.4777	1.4737	1.7833
2	.3561	1.4918	1.2517	1.7004	2.1862	1.587	2.0233
3	.3052	1.6289	1.5261	1.7004	2.0317	1.7004	2.1262
4	.3563	1.6975	1.6289	1.8023	2.2348	1.7814	2.2977
5	.3887	1.8861	1.9719	2.1472	2.1136	1.8515	2.1948
6	.3768	2.0062	2.0233	1.8842	2.1365	1.7976	2.1605
7	.3401	2.0576	2.0576	2.2891	2.0809	1.9109	2.2119
8		2.0405	2.0576	2.1956	2.0405	1.749	2.1262
9		2.0062	2.0243	2.0081	1.9719	1.7368	2.0062
10	1.3765						
11	1.9919						
12	2.1376						
13	1.9595						
14	1.8947						
15	1.8785						
16	1.8623	.168			.2134	.1524	.1829
17	1.8122	.1475	.1943		.1829	.1781	.1966
18	.2134	.1524	.2241	.2915	.3174	.1943	.2204
19	.2591	.2286	.2987	.3441	.3734	.2753	.2458
20	.2896	.2591	.3734	.3725	.4481	.3401	.285
21	.3048	.2896	.3391	.4049	.3547	.3725	.2515
22	.3048	.2896	.3734	.4049	.3734	.3563	.3605
23	.2896	.3048	.3277	2.6882	.4108	.3932	.373
24	.3768	1.286	1.286	1.2955	2.6882	1.3765	1.3889
Max	2.1376	2.0576	2.0576	2.6882	2.6882	1.9109	2.2977
Min	.2134	.1475	.1943	.2915	.1829	.1524	.1829
Avg	.8855	1.0729	1.1270	1.4367	1.3687	1.0682	1.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 205 / EXPRESS FEEDER WATER NON SHEDDABLE WATER SUPPLY AND
 SUPPLY Feeder KV- 11 / UTILITY
 OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.4287	.2743	.5041	.426	.3361	.4115
2	.5243	.3944	.2572	.5415	.426	.3052	.4458
3	.5571	.3429	.2572	.5601	.4424	.3222	.4801
4		.4287	.3429	.5788	.5304	.39	.5144
5	.5898	.6001	.6001	.6161	.5079	.4108	.5658
6	.6226	.7202	.6859	.5788	.5407	.3921	.5144
7	.6882	.7716	.703	.6348	.5735	.4294	.583
8	.6226	.7716	.7373	.6722	.4458	.4294	.5487
9	.6554	.7545	.7125	.4294	.3772	.3547	.463
10	.7842	.763	.8097	.6344	.4115	.3429	.4287
11	.7122	.7095	.7125	.5487	.3601	.4287	.4801
12	.6478	.5975		.4973	.3944	.3944	.4287
13	.6316	.5256	.6882	.5144	.4115	.3772	.3772
14	.6062	.4917	.6478	.5487	.4115	.3944	.463
15	.6226	.547	.5992	.583	.3772	.4287	.5144
16	.7282	.2054	.639	.5487	.4115	.3258	.463
17	.6783	.3547	.7537	.4801	.4287	.3441	.5898
18	.5487	.3258	.6226	.5182	.5415	.3277	.6062
19	.4801	.4115	.0934	.5571	.4108	.3077	.5571
20	.4801	.3944	.4294	.5407	.4294	.3605	.5243
21	.463	.3772	.4668	.5243	.3921	.3768	.4752
22	.463	.3429	.5228	.4915	.3734	.3932	.4752
23	.4458	.3086	.5228	.4534	.3547	.3605	.4938
24	.4534	.4458	.2915	.5228	.3239	.3174	.3429
Max	.7842	.7716	.8097	.6722	.5735	.4294	.6062
Min	.4458	.2054	.0934	.4294	.3239	.3052	.3429
Avg	.5868	.5006	.5378	.5450	.4293	.3687	.4894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 201 / 11KV YESHWANTNAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3601	.4287		.4115
2	.3048	.3601	.4287		.3944
3	.3048	.3772	.3429		.3944
4	.3048	.3772	.463		.4115
5	.3353	.3944	.463		.4287
6	.381	.4115	.4801		.4458
7			.4458		
8			.4115		
9	.381				
10		.463	.5144		
11		.4801	.5487		
12		.4801	.3772		
13		.463	.3772		
14		.4458			
15		.4458			
17		.4115			
18	.3944	.4287			.2915
19	.3258	.4801		.4801	.2743
20	.3429	.4973		.4973	
21	.3429	.4801		.4973	
22	.3258	.4458		.463	
23	.3258	.4115		.4458	
24	.3353		.3944		.4287
Max	.3944	.4973	.5487	.4973	.4458
Min	.3048	.3601	.3429	.4458	.2743
Avg	.3375	.4323	.4366	.4767	.3868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 202 / 11KV GRAMIN

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1862	.3086	.2915		.2915
2	2.1862	.2915	.3086		.3086
3	2.3482	.3258	.3429		.3258
4	2.4291	.3429	.3601		.3429
5	2.9959	.3601	.3772		.3772
6	3.2388	.3772	.3944		.3944
7	3.5627				
8	3.6437				
9	3.6437				
10		2.572	2.8635		
11		3.1722	3.8066		
12		3.4294	3.7037		
13		3.6008	***		
14		3.6866			
15		3.6008			
17		3.4294			
18	.3429	3.3436		3.4294	.3086
19	.3601	.3086		.2572	.3429
20	.3944	.3429		.3086	
21	.3944	.3429		.3429	
22		.3258		.3429	
23	.3429	.3086		.3429	
24	2.2672		.2915		.3086
Max	3.6437	3.6866	35.4939	3.4294	.3944
Min	.3429	.2915	.2915	.2572	.2915
Avg	2.0224	1.6037	4.3849	.8373	.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 203 / 11 KV CHOUDESHWARWADI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.7147	2.1434		2.2291
2	.1524	1.8861	2.3148		2.3148
3	.1524	2.0576	2.4863		2.3148
4	.1524	2.1434	2.572		2.4006
5	.1829	2.2291	2.572		2.4863
6	.1829	2.4006	2.6578		2.572
7		2.4863	2.6578		2.6578
8		2.572	2.7435		
9		2.572			2.6578
14		.1715			
15		.1715			
17		.1715			
18	.1715	.1715			.1715
19	.1715	.1715		.1715	.1715
20	.1715	.1715		.1715	
21		.1715		.1715	
22	.1715	.1715		.1715	
23	.1715	.1715		.1715	
24	.1524		2.0576		2.0576
Max	.1829	2.572	2.7435	.1715	2.6578
Min	.1524	.1715	2.0576	.1715	.1715
Avg	.1654	1.2003	2.4672	.1715	2.0031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 205 / GIRZANI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18
HR	Load (MW)
1	1.6194
2	1.7004
3	1.7004
4	2.0243
5	2.3482
6	2.5101
7	2.753
8	2.834
9	2.8178
24	1.6194
Max	2.834
Min	1.6194
Avg	2.1927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 206 / 11 kV MAHARSHINAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.2003	.9431		.9431
2	.9145	1.286	.9431		.9431
3	.9145	1.1145	1.0288		.8573
4	.9907	1.0288	1.2003		.9431
5	1.0669	1.0288	1.286		1.0288
6	1.1431	1.1145	1.286		1.1145
7			1.2003		
8		1.2003	1.2003		
10		1.286	1.2003		
11		1.286	1.307		
12		1.2003	1.286		
13		1.286	1.2003		
14		1.286			
15		1.2003			
17		1.1145			
18	1.286	1.286		1.286	1.3717
19	1.2003	1.3717		1.286	1.286
20	1.2003	1.286		1.2003	
21	1.1145	1.2003		1.2003	
22	1.1145	1.2003		1.2003	
23	1.2003	1.1145		1.1145	
24	.9907		1.0288		1.0288
Max	1.286	1.3717	1.307	1.286	1.3717
Min	.9145	1.0288	.9431	1.1145	.8573
Avg	1.0808	1.2046	1.1623	1.2146	1.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 207 / Deshmukh Mala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.286	1.0288		.9431
2	.1524	1.2517	1.1145		1.0288
3	.1372	1.286	1.1145		1.1145
4	.1372	1.3717	1.2003		1.286
5	.1829	1.3717	1.286		1.3717
6	.1981	1.3889	1.4575		1.4575
7		1.4575	1.5432		1.5432
8		1.5432	1.6289		
9					1.5432
14		.1543			
15		.1715			
17		.1543			
18	.12	.1715			.1372
19	.1543	.1715		.1715	.1543
20	.1886	.1886		.1715	
21	.1886	.1886		.1715	
22	.2058	.1886		.1715	
23	.1886	.1886		.1715	
24	.1524		.9431		.9431
Max	.2058	1.5432	1.6289	.1715	1.5432
Min	.12	.1543	.9431	.1715	.1372
Avg	.1660	.7373	1.2574	.1715	1.0475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 201 / 11 KV CHAKORE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	1.1584	1.1584	1.2193	1.1736	1.1584	1.1584
2	.4572	1.2193	1.2193	1.2803	1.2041	1.2193	1.2193
3	.4572	1.2803	1.2346	1.3413	1.2955	1.2803	1.2803
4	.5335	1.3717	1.387	1.4632	1.4022	1.3717	1.3413
5	.5792	1.5546	1.5546	1.5851	1.5546	1.5546	1.5699
6	.6097	1.7985	1.7985	1.768	1.7833	1.768	1.7985
7	.4725	2.0729	2.0881	2.0729	2.0576	2.0119	1.9966
8		2.0729	2.2253	2.3167	2.1795	2.2253	1.9966
9		1.9204	2.0271	2.0424	1.9357	1.9509	1.7071
10	2.0119						
11	2.1186						
12	1.9357						
13	1.829						
14	1.7985						
15	1.768	.1677	.1829		.1677	.1829	.2134
16	1.7833		.2134		.2743	.2591	
17	1.7985	.3353	.3048		.3048	.3048	.2439
18	.2439	.3353	.3353	.3506	.3353	.3506	.3963
19	.4572	.4572	.4572	.4572	.4877	.4877	.4572
20	.4572	.4877	.5182	.4877	.4877	.4877	.4725
21	.4268	.4877	.4877	.4877	.4572	.4725	.4572
22	.4268	.4725	.4572	.4725	.4268	.4572	.4725
23	.4572	.4572	.5182	.4572	.4268	.442	.4725
24	.4572	1.1279	1.1431	1.1888	1.1584	1.0974	1.1126
Max	2.1186	2.0729	2.2253	2.3167	2.1795	2.2253	1.9966
Min	.2439	.1677	.1829	.3506	.1677	.1829	.2134
Avg	.9789	1.0432	1.0164	1.1869	1.0059	1.0043	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 202 / 11 KV KONDBAVI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4327	.4268	.3963	.4268	.3963	.4268	.3963
2	1.6289	.4572	.3963	.4268	.3963	.4268	.3963
3	1.6461	.4268	.4572	.4572	.3963	.4572	.4115
4	1.5699	.4572	.4877	.4572	.4572	.4877	.4572
5	1.7528	.4877	.5335	.4877	.4877	.4572	.4877
6	2.0424	.5182	.5639	.4572	.5639	.4877	.5487
7	2.3777	.5182	.5182	.4877	.5487	.5487	.503
8	2.3015						
9	2.0576						
10		1.6461	1.8442		2.1643	1.7375	1.6004
11		1.7528	1.9052		2.271	2.1338	1.9204
12		1.8595	1.9814		2.1491	1.8595	1.7528
13		1.7528	1.9509		1.9966	1.4632	1.6613
14		1.5089	2.0119		1.829	1.6461	1.5851
15	.1829	1.5699	2.1186		1.8138	1.4937	1.6156
16	.2896		2.0576		1.8442	1.6461	1.6613
17	.3658	1.8595	1.7375		1.9509	1.7985	1.9204
18	.3963	.2439	.2743	2.3015	.2439	.2743	.381
19	.4877	.4572	.4877	.4725	.4572	.4725	.4268
20	.4572	.4725	.4572	.4877	.4572	.4877	.4572
21	.4572	.4877	.4572	.4725	.4268	.4725	.4725
22	.4268	.4725	.3963	.4572	.4572	.4572	.4572
23	.4268	.4572	.4268	.4268	.4268	.4268	.442
24	1.2955	.4268	.4115	.3963	.4115	.4268	.3963
Max	2.3777	1.8595	2.1186	2.3015	2.271	2.1338	1.9204
Min	.1829	.2439	.2743	.3963	.2439	.2743	.381
Avg	1.1366	.8695	.9942	.5868	1.0066	.9131	.9069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 204 / vaibhav agrotech ht
consumer Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0051	.0069	.0017	.0017	.0017	.0017	.0017
2	.0069	.0051	.0017	.0017	.0017	.0017	.0017
3	.0051	.0069	.0017	.0017	.0017	.0017	.0017
4	.0069	.0051	.0017	.0017	.0017	.0017	.0017
5	.0051	.0051	.0017	.0017	.0017	.0017	.0017
6	.0051	.0051	.0017	.0017	.0017	.0017	.0017
7	.0051	.0051	.0017	.0017	.0017	.0017	.0017
8	.0069	.0051	.0017	.0017	.0017	.0017	.0017
9	.0051	.0034	.0017	.0017	.0017	.0017	.0034
10	.0051	.0034	.0017		.0017	.0017	.0051
11	.0069	.0017	.0017		.0017	.0017	.0051
12	.0069	.0017	.0017		.0017	.0017	.0069
13	.0051	.0017	.0017		.0017	.0017	.0069
14	.0069	.0017	.0017		.0017	.0017	.0034
15	.0051	.0017	.0017		.0017	.0017	.0069
16	.0069		.0017		.0017	.0017	.0069
17	.0051	.0017	.0017		.0017	.0034	.0051
18	.0069	.0017	.0017	.0017	.0017	.0017	.0034
19	.0069	.0017	.0017	.0017	.0017	.0017	.0069
20	.0069	.0017	.0017	.0017	.0017	.0017	.0069
21	.0069	.0017	.0017	.0017	.0017	.0017	.0086
22	.0069	.0017	.0017	.0017	.0017	.0015	.0069
23	.0069	.0017	.0015	.0017	.0017	.0017	.0051
24	.0051	.0069	.0017	.0017	.0017	.0017	.0017
Max	.0069	.0069	.0017	.0017	.0017	.0034	.0086
Min	.0051	.0017	.0015	.0017	.0017	.0015	.0017
Avg	.0061	.0034	.0017	.0017	.0017	.0018	.0043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 201 / 11KV KHANDALI NAGTHANA SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.7087	.6859	.583	.6024	.6859	.6344
2	.4287	.7087	.6859	.583	.6024	.703	.6344
3	.4458	.7619	.6516	.6001	.6733	.7202	.6173
4	.4801	.7973	.703	.6516	.7619	.7202	.6516
5	.4973	.7973	.7202	.7202	.9036	.7373	.6859
6	.6001	.8505	.7373	.7716	.9745	.7888	.8916
7		.9036	.8916	.9431	.9745	.8745	.9774
8		.8859	.8745	.8859	.9431	.8745	.9774
9		.7973	.8328	.815	.8573	.8059	1.0631
10	.6024						
11	.9922						
12	.9391						
13	.9036						
14	.9214						
15	.9036	.1949	.2126		.2401	.1772	.2303
16	.9568	.3012	.2915		.3258	.2126	.3898
17	.9745	.3429	.2915		.3429	.3086	.3898
18	.2658	.3429	.3429		.3944	.4458	.3898
19	.4607	.3601	.4801	.443	.4115	.5658	.5493
20	.4961	.3772	.4973	.6024	.4115	.5658	.5847
21	.5316	.4287	.4287	.5316	.4287	.5658	.567
22	.4784	.4801	.3772	.4784		.5144	.567
23	.443	.4801	.3601	.443	.3944	.4801	.5316
24	.4287	.691	.5144	.5487	.5316	.6859	.583
Max	.9922	.9036	.8916	.9431	.9745	.8745	1.0631
Min	.2658	.1949	.2126	.443	.2401	.1772	.2303
Avg	.6276	.5900	.5568	.6400	.5986	.6017	.6271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 202 / 11KV DATTANAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	2.0814	2.2291	1.9719	2.4006		2.0748
2	.4287	2.2081	2.3148	1.989	2.4348		2.0576
3	.4287	2.371	2.3663	1.989	2.4863		2.0576
4	.4458	2.6787	2.3148	2.0233	2.5377		2.1262
5	.5144	2.8054	2.4006	2.1434	2.5549		2.2291
6	.6687	2.8959	2.4348	2.452	2.7092		2.572
7		2.9683	2.7263	2.8635	2.6749		2.915
8		2.7938	2.7435	2.9321	2.4006		2.915
9		2.7221	2.8654	2.6244	2.7092		2.955
10	2.1491						
11	2.9371						
12	2.9012						
13	2.8654						
14	2.7759						
15	2.7759	.2686	.2865		.2743	.2686	.2658
16	2.6968	.3582	.3772		.3944	.394	.4887
17	2.9502	.3944	.3601		.3944	.4458	.5068
18	.4163	.4801	.4287		.5144	.5144	.5249
19	.4887	.4801	.4973	.5249	.4801	.5316	.5973
20	.5068	.463	.5316		.4287	.5316	.543
21	.5249	.4287	.4973	.5611	.4115	.5144	.5249
22	.4887	.4115	.4801	.5249	.3944	.4801	.5249
23	.4525	.3944	.4287	.5249	2.4348	.4458	.5068
24	.4115	2.0814	1.8861	1.9547	1.989		2.0405
Max	2.9502	2.9683	2.8654	2.9321	2.7092	.5316	2.955
Min	.4115	.2686	.2865	.5249	.2743	.2686	.2658
Avg	1.3447	1.5413	1.4826	1.7914	1.6118	.4585	1.4961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 203 / 11KV BHOSALE WASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8595	.2743	.3353	.3506	.2743	.3201	.3601
2	1.8595	.2286	.3506	.3658	.2743	.3048	.3772
3	1.829	.2286	.3201	.3506	.3048	.3201	.3772
4	1.8747	.2896	.3506	.381	.3353	.381	.3944
5	1.9052	.3353	.3658	.3963	.3353	.4115	.4115
6	2.1643	.3658	.3658	.442	.3963	.4268	.4801
7	2.2862						
8	2.3472						
9	2.2862						
10			1.7985	2.3472	2.1948	1.9509	2.5034
11			2.3167	2.5606	2.3929	2.6578	2.6406
12			2.4387	2.4691	2.3167	2.7092	2.572
13			2.3167		2.2862	2.6063	2.4177
14		2.2253	2.2558		2.2558	2.5892	2.4863
15	.1219	2.2558	2.271		2.2405	2.452	2.5892
16	.1981	2.2253	2.2405		2.0729	2.5206	2.7435
17	.2286	2.1795	2.3015		2.3472	2.572	2.7778
18	.2743	.2591	.2134		.2743	.2572	.1715
19	.3658	.2743	.2896	.381	.2591	.3772	.3772
20	.3658	.2591	.381	.3963	.2743	.4115	.4287
21	.3506	.2896	.3658	.381	.2915	.4115	.4115
22	.3506	.3048	.3506	.3506	.2743	.3944	.3944
23	.3353	.3048	.3506	.3201	.2743	.3772	.3772
24	1.829	.3048	.3201	.3506	.3048	.2896	.3601
Max	2.3472	2.2558	2.4387	2.5606	2.3929	2.7092	2.7778
Min	.1219	.2286	.2134	.3201	.2591	.2572	.1715
Avg	1.2017	.7414	1.0618	.7895	1.0467	1.1781	1.2215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 204 / 11KV ITI KHADALI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0129				.0154
8	.0148	.0148			
9		.0166	.0148	.012	
10			.0166		
11			.0111		
12			.0148		
13				.0103	
14	.0148				
15	.0148				
17	.012				
18					.0154
20	.1543				
Max	.1543	.0166	.0166	.012	.0154
Min	.012	.0148	.0111	.0103	.0154
Avg	.0373	.0157	.0143	.0112	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 201 / BABULGOAN FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3286	.2858	.3001	.3637	.3725	.3001	.407
2	.3001	.2858	.3429	.3681	.3725	.3144	.407
3	.3429	.3241	.3572	.3795	.3521	.2858	.373
4	.3572	.3549	.4287	.4111	.3563	.3429	.3978
5	.362	.3612	.4144	.4428	.3725	.3572	.4475
6	.3572	.3612	.4515	.4744	.3521	.3858	.503
10	.9568	.9878	1.3927	1.4922	1.3117	1.4413	1.5091
11	1.085	1.1888	1.4746	1.4752	1.4661	1.668	1.7072
12	1.1336	1.2654			1.5684	1.6194	1.6032
13	1.1279		1.4198		1.5546	1.6032	1.5524
14	1.2342	1.3077	1.531		1.5384	1.587	1.5384
15	1.3117	1.4022	1.5708		1.5708	1.6032	1.5223
16	1.2308	1.4413	1.4784		1.5708	1.6356	1.5769
17	1.2029	1.3923	1.6032		1.6032	1.6518	1.4918
18	.2972	.2315	.1898	.3563	.1572		.2812
19	.3086	.3658	.4111	.3841	.2972	.3572	.3125
20	.2932	.3715	.3953	.4534	.4001	.4001	.3163
21	.2858	.3429	.3795	.4001	.4144	.3715	.3563
22	.3144	.3001	.3953	.4049	.3858	.3715	.3521
23	.3418	.3572	.3795	.4049	.3429	.4024	.3841
24	.3429	.3001	.3286	.3479	.3887	.3286	.4191
Max	1.3117	1.4413	1.6032	1.4922	1.6032	1.668	1.7072
Min	.2858	.2315	.1898	.3479	.1572	.2858	.2812
Avg	.6436	.6614	.7622	.5439	.7975	.8514	.8313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 202 / WAFEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.2193	1.3117	1.4255	1.4752		1.3283
2	1.2654	1.2003	1.3279	1.3426	1.4922	1.3117	1.3283
3	1.25	1.3765	1.2955	1.406	1.4922		1.3123
4	1.2651	1.3117	1.4575	1.4413	1.4752	1.4089	1.3763
5	1.2963	1.3565	1.4737	1.4737	1.5261	1.4737	1.6004
6	1.3603	1.4575	1.4842	1.5238	1.6108	1.5223	1.5971
7	1.4575	1.6204	1.6975	1.7004	1.6907	1.7652	1.6604
8	1.6032	1.6518	1.7814	1.7814	1.7652	1.7341	1.8724
9	1.6164	1.668	1.8138	1.7126	1.6964	1.7004	1.8991
10				1.6164			
15	.1429	.1			.1286	.0857	
16	.1353	.1143			.1572	.1	.1562
17	.1429	.1286	.1107		.1286	.0857	.1698
18	.1572	.1143	.1423	.2267	.1429		
19	.1715	.2143	.2372	.2267	.1715	.1715	.1943
20	.2143	.2134	.2372	.2881	.2	.2286	.2267
21	.2143	.1858	.253	.2915	.1858	.2	.2591
22	.1572	.1715	.2214	.3239	.2	.1858	.2881
23	.1677	.1572	.1898	.3201	.1715	.1943	.2915
24	1.1498	1.2041	1.166	1.3927	1.4255	1.2955	1.2963
Max	1.6164	1.668	1.8138	1.7814	1.7652	1.7652	1.8991
Min	.1353	.1	.1107	.2267	.1286	.0857	.1562
Avg	.7920	.8140	.9530	1.0878	.9019	.8415	.9916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 201 / 11KV JAMBHUD
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.5068	2.3282	2.4177	2.5072	2.2744	1.5402
2	.5068	.5068	2.364	2.4177	2.5968	2.2923	1.6118
3	.5068	.4706	2.4356	2.4177	2.5968	2.2923	1.6476
4	.543	.4706	2.5072	2.4177	2.5072	2.3282	1.6118
5	.543	.5792	2.8654	2.5072	2.6326	2.3819	1.7013
6	.543	.543		2.5968	2.7759	2.5072	1.7193
7	.543	.5068	2.9729	2.8921	2.9371	2.7759	2.1491
8	.5792	.4706	3.0803	3.0148	3.0087	2.8654	2.2923
9	.8954	.2534	2.8654	3.0445	2.8746	2.6863	1.2536
10	2.5072	2.4188	.2686	.2865	.1448	.2172	.2149
11	3.0087	2.8045	.362	.3582	.1086		.2865
12	3.1341	3.0674	.362	.3582	.0905		.2865
13	3.0803	2.9797	.362	.394	.0905		.3224
14	3.0087	2.9447	.362	.394	.1086		.3224
15	3.0445	2.9447	.362	.3582	.0905		.3582
16	3.0445		.5068	.5014	.0905		.3582
17	3.0803	.2865	.4525		.0895		.362
18	.2172	.4298	.4525			.4525	.2715
19	.362	.4477	.4525	.543	.394	.4525	.2715
20	.3982	.4477	.543	.6516	.4477	.4525	.362
21	.4344	.4477	.4525	.6516	.5014	.543	.362
22	.4344	.5014	.362	.543	.4477	.543	.362
23	.4887	.5014	.362	.4344	.3582	.4525	.2715
24	.4525	.543	2.2923	2.3282	2.364	2.2386	1.4327
Max	3.1341	3.0674	3.0803	3.0445	3.0087	2.8654	2.2923
Min	.2172	.2534	.2686	.2865	.0895	.2172	.2149
Avg	1.3254	1.0901	1.2771	1.4331	1.2941	1.6327	.8905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 202 / 11KV KONDARPATTA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7004	1.7004					
2	1.7004	1.7004					
3	1.7004	1.7004					
4	1.7814	1.7328					
5	1.8623	1.8623					
6	1.9433	2.0567					
7	2.3482	2.1376					
8	2.3482	2.2348					
9	2.3482	2.3158					
10			1.7004	1.8623	2.0243	1.7814	1.7814
11			2.4291	2.2672	2.4291	2.2348	2.4291
12				2.4453	2.5911	2.2024	2.5911
13			2.2672	2.4291	2.5587	2.3482	2.5101
14			2.2996	2.3482	2.5101	2.3967	2.1052
15			2.2672	2.3805	2.0243	2.3482	2.1862
16			2.3482	2.3482	2.0243	2.2348	2.2672
17			2.4291			2.2024	2.2996
24	1.6194	1.587					
Max	2.3482	2.3158	2.4291	2.4453	2.5911	2.3967	2.5911
Min	1.6194	1.587	1.7004	1.8623	2.0243	1.7814	1.7814
Avg	1.9352	1.9028	2.2487	2.2973	2.3088	2.2186	2.2712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 203 / NEWARE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7814	1.7814	2.0233		1.9662
2			1.8623	1.7814	2.0576		1.8842
3			1.8623	1.7814	2.0576		1.8023
4			1.7814	1.7814	1.8947		1.8023
5			1.7004	1.7814	1.9433		1.917
6			1.8623	1.9433	2.0243		1.8842
7			2.0243	2.1052	2.0243		1.9662
8			2.2186	2.1862	2.0243		1.9662
9			2.1052	2.1052	2.0405	2.1376	1.9109
10	1.9757	2.0243					
11	2.0729	2.1052					
12	2.2024	2.1052					
13	2.1376	2.1376					
14	2.0081	2.1862					
15	2.1376	2.1052					
16	2.1862	2.1862					
17	2.251	2.17					
24			1.7652	1.7328	2.0062		1.9662
Max	2.251	2.1862	2.2186	2.1862	2.0576	2.1376	1.9662
Min	1.9757	2.0243	1.7004	1.7328	1.8947	2.1376	1.8023
Avg	2.1214	2.1275	1.8963	1.8980	2.0096	2.1376	1.9066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 204 / 11KV NADURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0243	1.9757					
2	2.0729	1.9757					
3	2.0729	1.9919					
4	2.0729	1.9919					
5	2.1052	2.0891					
6	2.0243	2.2024					
7	2.1052	2.2996					
8	2.1052	2.2672					
9	2.1376	2.2672					
10			1.8138	1.7814	2.0243	1.8947	2.0243
11			2.2672	2.2672	2.2672	2.5749	2.672
12			2.2672	2.3482	2.4291	2.7044	2.3482
13			2.4291	2.3805	2.1862	2.5911	2.4291
14			2.3158	2.3482	2.3967	2.5587	2.4777
15			2.3967	2.3805	2.1052	2.5101	2.5587
16			2.3482	2.1052	2.0729	1.2955	2.5101
17			2.3482			1.247	2.5425
24	2.0243	1.8461					
Max	2.1376	2.2996	2.4291	2.3805	2.4291	2.7044	2.672
Min	2.0243	1.8461	1.8138	1.7814	2.0243	1.247	2.0243
Avg	2.0745	2.0907	2.2733	2.2302	2.2117	2.1721	2.4453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 205 / NEWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.7468	.7922	.7095	.7468	.7545	.7468
2	.7468	.8402	.7922	.7468	.7468	.7545	.7842
3	.7842	.8962	.8488	.7468	.8029	.8488	.8029
4	.8402	.9335	.9242	.8402	.8775	.9054	.8402
5	.9709	1.0829	1.0185	.9335	.9149	.9808	.8962
6	1.0269	.8962	.9431	.9709	1.0269	1.0374	1.0456
7	.7468	.6535	.7356	.7468	.7655	.6979	.7842
8	.5601	.6535	.6413	.5975	.6348	.5658	.5601
9	.4715	.5544	.5228	.5093	.5121	.5228	.5281
10	.4715	.4108		.4904	.4572	.3734	.4715
11	.4715	.4024		.4527	.3658	.4481	.4338
12	.4527	.4207		.4527	.3658	.4854	.3772
13	.4715	.439	.4668	.4904	.3658	.4854	.3772
14	.4338	.439	.4668	.4527	.3658	.4294	.3772
15	.4527	.439	.4668	.4527	.3658	.4481	.415
16	.4715	.4207	.4668	.415	.3658	.4854	.4715
17	.4668	.4338	.4572		.415	.4755	.4572
18	.5041	.3206	.5175			.462	.4668
19	.7842	.679	.6535	.6602	.6036	.6468	.7095
20	.8402	.7545	.7468	.9431	.7545	.7095	.7842
21	.8775	.7545	.7842	.9054	.7167	.7095	.7468
22	.8402	.7167	.7095	.7922	.7167	.7468	.7095
23	.7842	.7167	.7095	.7167	.6979	.7468	.6535
24	.6908	.7468	.7545	.6908	.7095	.6979	.7468
Max	1.0269	1.0829	1.0185	.9709	1.0269	1.0374	1.0456
Min	.4338	.3206	.4572	.415	.3658	.3734	.3772
Avg	.6605	.6396	.6866	.6689	.6215	.6424	.6328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 201 / 11KV SHRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	1.6004	1.6004	1.6004
2	.1524	.1524	.2286	.1524	1.7528	1.9052	1.7985
3	.2286	.1524	.2286	.1524	1.829	1.9814	1.829
4	.2286	.2286	.2286	.3048	1.9814	1.9814	1.9509
5	.2286	.3048	.2286	.3048	2.0576	2.1338	1.9509
6	.2286	.3048	.2286	.4572	2.0576	2.271	1.9814
7					1.9814	2.1033	1.9052
8					1.9509	2.0119	1.89
17	1.5242	1.9814	2.2862				
18	1.6766		2.2862				
19	1.6766	1.9814	1.9814	.4268	.4572	.4115	.442
20	1.6766	1.9052	1.829	.4268	.4572	.4268	.4268
21	1.6004	1.829	1.6766	.3658	.4268	.4268	.4268
22	1.5242	1.6766	1.5242	.3353	.4268	.4268	.3658
23	1.5242	1.6766	1.5242	.3201	.4268	.3201	.3048
24	1.5242	1.3717	1.5242	1.448	.2743	.3353	.3201
Max	1.6766	1.9814	2.2862	1.448	2.0576	2.271	1.9814
Min	.1524	.1524	.1524	.1524	.2743	.3201	.3048
Avg	.9962	1.0552	1.1377	.4039	1.2629	1.3097	1.2280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 202 / 11 KV NARALACHIWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.3717		1.3717	.1524	.1829	.1677
2	1.7528	1.3717	2.0576	1.5242	.1524	.1829	.1829
3	1.829	1.5242	2.1338	1.5242	.1524	.2134	.1829
4	1.829	1.5242	2.21	1.6766	.1829	.2134	.2134
5	1.9814	1.6766	2.21	1.829	.2134	.2286	.2286
6	2.0576	1.829	2.2862	1.829	.2286	.2286	.2591
7	2.1338	1.829	2.2862	1.9814			
8	2.2862	1.829	2.3624	1.6766			
9					2.1186	2.0119	1.7985
10					2.1186	2.21	2.0576
11					2.0576	2.2862	2.1186
12					2.0576	2.21	2.1643
13					2.0119	2.1338	2.1338
14					1.9814	2.0576	1.9814
15					1.9509	1.8747	1.6918
16					1.89	1.6766	1.6613
19	.1524	.1524	.1524	.1981	.1524	.1524	.1524
20	.1524	.1524	.1524	.1981	.1829	.1829	.1829
21	.1524	.1524	.1524	.1829	.2286	.2134	.2134
22	.1524	.1524	.1524	.1677	.2286	.2134	.1829
23	.1524	.1524	.1524	.1677	.1829	.1677	.1829
24	.1524	.1524	.1524	.1524	.1524	.1829	.1677
Max	2.2862	1.829	2.3624	1.9814	2.1186	2.2862	2.1643
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.1758	.9907	1.2662	1.0343	.9198	.9412	.8962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 203 / 11KV NIMGAON VILLAGE
AG/SDT Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6859	.4572	.1524	.1524	.1524
2	.6859	.6097	.6859	.4572	.1524	.1524	.1524
3	.6859	.7621	.7621	.6097	.1524	.1524	.1524
4	.7621	.7621	.8383	.6097	.1524	.1524	.1524
5	.7621	.9145	.8383	.7621	.1524	.1524	.1524
6	.8383	.9145	.9907	.7621	.1524	.1524	.1524
7	.9145	.9145		.9145			
8	.9907	.9145	.9145	.9145			
9					.8688	.6859	.6859
10					.884	.7621	.7621
11					.9145	.7621	.8078
12					.9145	.7621	.8383
13					.8383	.7621	.7621
14					.8383	.6859	.6859
15					.7621	.6097	.5335
16					.6859	.6097	.5335
18		.1524					
19	.1067	.1524	.1524	.1524	.1524	.1524	.1524
20	.1219	.1524	.1524	.1524	.1524	.1524	.1524
21	.1219	.1524	.1524	.1524	.1524	.1524	.1524
22	.1067	.1524	.1524	.1524	.1524	.1524	.1524
23	.1067	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.0914	.1524	.1524	.1524	.1524	.1524
Max	.9907	.9145	.9907	.9145	.9145	.7621	.8383
Min	.1067	.0914	.1524	.1524	.1524	.1524	.1524
Avg	.4975	.4938	.5100	.4572	.4268	.3734	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 204 / NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0914	.0762	.0914	.0762	.061	.0762
2	.0914	.0914	.0914	.0914	.0762	.0762	.0762
3	.0914	.0914	.0914	.1067	.0762	.0762	.0762
4	.1067	.1067	.1067	.1219	.1067	.1067	.0914
5	.1067	.1219	.1067	.1372	.1219	.1219	.1219
6	.1219	.1372	.1219	.1524	.1524	.1219	.1372
8	.1067	.1067	.0762	.1067	.0914	.1067	.0914
9	.0914	.0762	.0762	.1067	.0914	.0914	.0914
10	.0914	.0762	.061	.0914	.0914	.061	.0762
11	.0762	.0914	.0762		.0914	.061	.0762
12	.0762	.0762	.061		.0762	.061	.061
13	.061	.061	.061		.0762	.061	.061
14	.061	.0762	.061		.061	.061	.0457
15	.061	.0762	.061		.061	.061	.0457
16	.061	.0762	.061		.061	.061	.061
17	.0762	.0914	.0762		.061	.0762	.061
18	.0914	.0914	.0762		.0762	.0762	.061
19	.0914	.0762	.0914	.1219	.1067	.1067	.1067
20	.1067	.0762	.1219	.1219	.1219	.1067	.1067
21	.1219	.0914	.1067	.1067	.1219	.0914	.0914
22	.1067	.0914	.0914	.0914	.0914	.0762	.0914
23	.0914	.0762	.0914	.0762	.0762	.0762	.0762
24	.0762	.0914	.0762	.0762	.0762	.061	.0762
Max	.1219	.1372	.1219	.1524	.1524	.1219	.1372
Min	.061	.061	.061	.0762	.061	.061	.0457
Avg	.0888	.0888	.0835	.1067	.0888	.0809	.0808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 205 / naganemala
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1067	.1524	.1524	.1524	.1524	.1524
2	.1372	.1067	.1524	.1524	.1524	.1524	.1524
3	.1524	.1219	.1524	.1524	.1524	.1524	.1524
4	.1524	.1219	.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1829	.1829	.1677
6	.1524	.1524	.1524	.1524	.2134	.1981	.1677
9	.7621	.9145	.9145	1.0669			
10	.7621	.9907	.9907	1.1431			
11	.9145	1.0669	1.0669				
12	1.0669	1.0669	1.0669				
13	1.0669	.9907	1.0669				
14	1.0669	.9907	.9907				
15	1.0669	.9145	.9907				
16	1.0669	.9145	.9907				
17			.9907		1.0364	.9755	.9907
18						1.0669	1.1279
19	.1219	.1524	.1524	1.0517	1.0669	.9907	1.0669
20	.1219	.1524	.1524	1.0364	1.0822	.9907	.9145
21	.1219	.1524	.1524	.9907	1.0364	.884	.8383
22	.1067	.1524	.1524	.945	1.0059	.823	.7316
23	.1067	.1524	.1524	.9297	.9755	.7316	.6401
24	.1372	.0914	.1524	.1524	.9297	.9755	.7011
Max	1.0669	1.0669	1.0669	1.1431	1.0822	1.0669	1.1279
Min	.1067	.0914	.1524	.1524	.1524	.1524	.1524
Avg	.4687	.4732	.5189	.5879	.6261	.6020	.5683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 206 / jay khanderaya
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0914	.1067	.0914	.8383	.9145	.9145
2	.1372	.0914	.1067	.0914	.9907	.9907	1.0364
3	.1372	.0914	.1219	.1067	.9907	1.0822	1.0669
4	.1372	.1067	.1219	.1219	1.0364	1.1279	1.1279
5	.1372	.1067	.1219	.1372	1.0822	1.2193	1.0669
6	.1372	.1067	.1219	.1524	1.1279	1.2803	1.0974
7					1.1431	1.0669	1.0669
8					1.1431	.9297	1.0059
17	.9145	1.1431	1.2193				
18		1.2193	1.2955		.1524		
19	1.2193	1.1431	1.2955	.1524	.1524	.1219	.1219
20	1.2193	1.0669	1.2955	.1524	.1219	.1219	.1219
21	1.2193	1.0669	1.2193	.1219	.1219	.1219	.1219
22	1.0669	.9145	1.0669	.1219	.1219	.1219	.1219
23	1.0669	.9145	1.0669	.1219	.1219	.1067	.1067
24	.9907	.9145	.8383	.9145	.1219	.1219	.1067
Max	1.2193	1.2193	1.2955	.9145	1.1431	1.2803	1.1279
Min	.1372	.0914	.1067	.0914	.1219	.1067	.1067
Avg	.6554	.6412	.7142	.1905	.6178	.6663	.6488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 207 / MAULI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1524
2	.1524	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.1524	.1524	.1524	.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1524	.1524	.1524
6	.1524	.1524	.1524	.1524	.1524	.1524	.1524
9	.9145	1.0669	1.1431	1.1431			
10	.9145	1.1431	1.2193	1.2955			
11	1.0669	1.2193	1.5242				
12	1.0669	1.2955	1.6004				
13	1.2193	1.2193	1.5242				
14	1.2193	1.2193	1.5242				
15	1.0669	1.1431	1.3717				
16	1.0669	1.1431	1.2193				
17					1.2955	1.448	1.2955
18					1.5242	1.6004	1.3717
19	.1524	.1524	.1524	1.2193	1.5242	1.6004	1.448
20	.1524	.1524	.1524	1.3717	1.2193	1.5242	1.448
21	.1524	.1524	.1524	1.3717	1.2193	1.2955	1.3717
22	.1524	.1524	.1524	1.2955	1.0669	1.2193	1.3717
23	.1524	.1524	.1524	1.2193	.9145	1.1431	1.1431
24	.1524	.1524	.1524	.1524	1.2193	.9907	1.0669
Max	1.2193	1.2955	1.6004	1.3717	1.5242	1.6004	1.448
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.5182	.5639	.6478	.7131	.7784	.8383	.8165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 208 / KESHAVNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.0914	.1067	.0762	.1219	.1219	.1219
2	.1067	.0762	.1219	.0762	.1219	.1219	.1219
3	.1067	.0762	.1219	.0914	.1219	.1219	.1219
4	.1219	.0914	.1219	.1067	.1219	.1219	.1219
5	.1219	.0914	.1219	.0914	.1219	.1219	.1219
6	.1219	.1067	.1219	.0914	.1524	.1372	.1524
7				.0914			
9	.4572	.6097	.6859	.6097			
10	.4572	.6859	.7621	.7621			
11	.4572	.6859	.7621				
12	.6097	.7621	.7621				
13	.6097	.7621	.7621				
14	.6097	.7621	.7621				
15	.5335	.7316	.6859				
16	.5335	.6401	.6859				
17					.7011	.6859	.823
18					.8383	.7926	.884
19	.0914	.0914	.0914	.7621	.8383	.7621	.8383
20	.1067	.0914	.1067	.7316	.823	.7316	.7621
21		.1067	.1067	.6859	.7621	.7316	.6859
22	.1219	.1067	.0914	.6859	.7621	.7011	.6859
23	.1067	.1067	.0914	.6706	.7316	.7011	.6401
24	.0914	.0914	.1067	.0762	.6554	.7011	.7011
Max	.6097	.7621	.7621	.7621	.8383	.7926	.884
Min	.0914	.0762	.0914	.0762	.1219	.1219	.1219
Avg	.2880	.3384	.3589	.3739	.4910	.4681	.4845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 209 / BALIRAJA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.6097	.9145	.7621	.061	.061	.061
2	.9145	.7621	.9145	.7621	.061	.061	.061
3	.9907	.7621	.9907	.9145	.061	.061	.061
4	.9907	.7621	.9907	.9145	.061		.061
5	1.0669	1.0059	1.0669	1.0669	.0762	.061	.0914
6	1.0669	1.0669	1.1431	1.2193	.0914	.0762	.0914
7		1.0669	1.1431	1.2193			
8	1.2193	.9907	1.2193	1.0669			
9					1.1736	1.0669	1.0669
10					1.1888	1.2193	1.1584
11					1.1888	1.2498	1.2346
12					1.1584	1.2193	1.2193
13					1.1431	1.1888	1.1584
14					1.1584	1.1888	1.1584
15					1.1888	1.1584	1.1279
16					1.1888	1.1888	1.0822
19	.0914	.0762	.0914	.0762	.061	.061	.061
20	.1067	.0762	.0914	.0762	.061	.061	.061
21	.1067	.0762	.0914	.061	.061	.061	.061
22	.0914	.0762	.0762	.061	.061	.061	.061
23	.0914	.0762	.0762	.061	.061	.061	.061
24	.0762	.0762	.0762	.0762	.061	.061	.061
Max	1.2193	1.0669	1.2193	1.2193	1.1888	1.2498	1.2346
Min	.0762	.0762	.0762	.061	.061	.061	.061
Avg	.5944	.5345	.6347	.5955	.5083	.5351	.4999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 201 / BACHERI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							2.6235
17							2.7435
18							.3258
19							.6516
20							.7202
21							.6859
22							.6687
23	.4801	.6001	.5658	.5144	.5316	.5487	.6516
24	1.6461	1.5947	1.5432	1.6461	.463	.583	.5487
Max	1.6461	1.5947	1.5432	1.6461	.5316	.583	2.7435
Min	.4801	.6001	.5658	.5144	.463	.5487	.3258
Avg	1.0631	1.0974	1.0545	1.0803	.4973	.5659	1.0688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 202 / PILIV SECTION GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							.4458
17							.4287
18							.463
19							.703
20							.7716
21							.7373
22							.703
23	.5487	.6687	.5658	.6001	.6687	.5658	.6687
24	.5658	.4801	.5487	.4801	.4973	.5316	.5144
Max	.5658	.6687	.5658	.6001	.6687	.5658	.7716
Min	.5487	.4801	.5487	.4801	.4973	.5316	.4287
Avg	.5573	.5744	.5573	.5401	.583	.5487	.6039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 203 / CHANDAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							3.2579
17							3.0864
18							.1715
19							.3944
20							.4801
21							.4801
22							.463
23	.3429	.4115	.3944	.3772	.4458	.3429	.4287
24	1.6632	1.7147	1.7147	1.8004	.3429	.3772	.3429
Max	1.6632	1.7147	1.7147	1.8004	.4458	.3772	3.2579
Min	.3429	.4115	.3944	.3772	.3429	.3429	.1715
Avg	1.0031	1.0631	1.0546	1.0888	.3944	.3601	1.0117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 204 / KUSMODE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							.1372
17							.12
18							.12
19							.1886
20							.2058
21							.2058
22							.1886
23	.1715	.1886	.1715	.2058	.2229	.1715	.1886
24	.1715	.1543	.1715	.1715	1.9204	1.7147	1.8004
Max	.1715	.1886	.1715	.2058	1.9204	1.7147	1.8004
Min	.1715	.1543	.1715	.1715	.2229	.1715	.12
Avg	.1715	.1715	.1715	.1887	1.0717	.9431	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 205 / SULEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							.0857
17							.0857
18							.1029
19							.12
20							.1372
21							.12
22							.1029
23	.12	.1372	.0857	.12	.1372	.1029	.1029
24	.0857	.0857	.0686	.0857	.7202	.7202	.7716
Max	.12	.1372	.0857	.12	.7202	.7202	.7716
Min	.0857	.0857	.0686	.0857	.1372	.1029	.0857
Avg	.1029	.1115	.0772	.1029	.4287	.4116	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 207 / Sheri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							.1715
17							.1715
18							.2058
19							.2572
20							.3258
21							.3086
22							.3086
23	.2915	.2915	.3086	.2743	.2743	.2572	.2915
24	.2743	.2743	.2743	.2915	1.5261	1.0974	1.286
Max	.2915	.2915	.3086	.2915	1.5261	1.0974	1.286
Min	.2743	.2743	.2743	.2743	.2743	.2572	.1715
Avg	.2829	.2829	.2915	.2829	.9002	.6773	.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 208 / PILIV (URBAN) GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16							.4115
17							.4287
18							.4287
19							.5144
20							.6001
21							.5658
22							.5316
23	.4801	.4973	.4801	.5487	.5487	.5487	.4973
24	.4115	.4287	.4458	.4287	.5144	.4801	.4973
Max	.4801	.4973	.4801	.5487	.5487	.5487	.6001
Min	.4115	.4287	.4458	.4287	.5144	.4801	.4115
Avg	.4458	.463	.4630	.4887	.5316	.5144	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 201 / 11KV KALAMWADI.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	2.21		2.5911	.1524	.2286	.1981
2	.1677	2.1338		2.7435	.1677	.2286	.1981
3	.1981	2.1338		2.8959	.1829	.2439	.2134
4	.2286	2.21		2.9721	.1829	.2591	.2286
5	.2439	2.1338		3.0483	.1981	.2591	.2286
6	.2591	2.1338		3.0483	.2134	.2743	.2439
7		2.4387		3.3532			
8		2.5149		3.2769			
9					3.2769	3.1245	3.2007
10					3.2007	3.0483	3.2007
11					3.1245	3.1245	3.0483
12					3.1245	2.7435	2.8959
13					3.0483	2.5911	2.8959
14					3.1245	2.5911	2.8197
15					3.0483	2.6673	2.6673
16					2.9721	2.5149	2.5149
17	3.0483						
18	2.9721						
19	2.9721	.2591		.2439	.2286	.2743	.2743
20	2.7435	.2439	.2591	.2286	.2439	.2591	.2591
21	2.6673	.1981	.2286	.2134	.2286	.2286	.2286
22	2.4387	.1677	.2134	.1981	.2286	.2286	.2134
23	2.2862	.1372	.1981	.1981	.1981	.2134	.1981
24	2.3624	2.2862	.1677	.2134	.1677	.2134	.2134
Max	3.0483	2.5149	.2591	3.3532	3.2769	3.1245	3.2007
Min	.1524	.1372	.1677	.1981	.1524	.2134	.1981
Avg	1.6243	1.5144	.2134	1.8018	1.3656	1.2658	1.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 202 / 11KV TANDULWADI FEEDER. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.1829	.1524	.2286	.2286	.1524	.1981
2	.9145	.1829	.1829	.2439	.2439	.2134	.2134
3	.9907	.1829	.1981	.3048	.2439	.2439	.2439
4	1.0669	.1981	.2134	.3201	.2591	.2439	.2743
5	1.1431	.2134	.2134	.3506	.3048	.2591	.3201
6	1.2193	.2286	.2439	.3201	.3353	.2896	.3506
7	1.2955						
8	1.3717						
9		1.5242	1.829	1.5242			
10		1.448	1.6766				
11			1.448				
12		1.2193	1.2193				
13		1.0669	1.0669				
14		.9145	1.0669				
15		.8383	1.0669				
16		.9145	.9907				
17					1.829	1.3717	1.829
18					1.6004	1.448	1.7528
19	.2134	.3506	.2743	.3201	1.5242	1.5242	1.448
20		.3048	.2896	.2896	1.3717	1.448	1.3717
21	.2134	.2743	.3048	.2743	1.2955	1.3717	1.2955
22	.1981	.2439	.3201	.2591	1.1431	1.2193	1.2193
23	.1829	.2134	.2743	.2286	.9907	1.0669	1.1431
24	.1829	.1829	.1677	.2591	.2286	.8383	.9907
Max	1.3717	1.5242	1.829	1.5242	1.829	1.5242	1.829
Min	.1829	.1829	.1524	.2286	.2286	.1524	.1981
Avg	.7562	.5623	.6600	.3787	.8285	.8350	.9036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 203 / SALMUKH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.7773	.823	.8078	.7621	.823	.7164
2	.8078	.8078	.8688	.9602	.7164	.884	.7468
3	.8383	.823	.9297	.9907	.6859	.9297	.7773
4	.8688	.884	1.0517	1.0669	.7316	.9602	.823
5	.9602	.945	1.1431	1.1431	.7621	.9907	.884
6	1.0517	1.0059	1.326	1.2498	.7773	.9297	.9145
8	.6097	.7011	.7164	1.0974	.7926	.6249	.6859
9	.5335	.6401	.5182	1.0669	.8535	.8688	.9602
10	.5792	.6554	.4877	.945	.5792	.9145	.9907
11	.5639	.823	.4572		.7621	.8383	.6097
12	.5944	.884	.442		.8383	.7621	.4572
13	.5792	.4572	.4268		.5335	.5335	.7316
14	.4725	.4725	.4877		.5792	.6097	.8078
15	.4877	.6859	.5639		.6097	.8383	.7164
16	.5792	.6097	.6097		.7621	.381	.7926
17	.5944	.6859	.6097		.5335	.6097	.8993
18	.7164	.503	.5487		.7164	.6706	1.0364
19	.7621	.8535	.4877	1.2193	.8688	.7316	1.2346
20	1.0059	.8688	.6859	1.1888	.9755	.823	1.1126
21	1.0669	.823	.7621	1.1279	1.1279	.884	1.0212
22	.9145	.8078	.7468	1.0822	1.0822	.9297	.8688
23	.8383	.7773	.6859	1.0364	.8993	.823	.5944
24	.6859	.7926	.6401	.6097	.8078	.7316	.7621
Max	1.0669	1.0059	1.326	1.2498	1.1279	.9907	1.2346
Min	.4725	.4572	.4268	.6097	.5335	.381	.4572
Avg	.7290	.7515	.6965	1.0395	.7720	.7866	.8323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 204 / Shendechinch
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1829	.2134	.1524	.9145	.9145	.9145
2	.1524	.1829	.2439	.1524	.9907	.9907	.9907
3	.1677	.1981	.2591	.1524	1.0669	1.0669	1.0669
4	.1981	.1981	.2743	.1677	1.1431	1.1431	1.2193
5	.2286	.2286	.2896	.1829	1.2193	1.2193	1.2955
6	.2439	.2439	.3048	.1981	1.2955	1.2955	1.3717
7					1.2955	1.7528	1.448
8					1.2193	1.6004	1.5242
9	1.3717						
10	1.448						
11	1.5242						
12	1.448						
13	1.3717						
14	1.3717						
15	1.2955						
16	1.2193						
17			1.6004				
18		1.5242	1.5242				
19	.2439	1.3717	1.3717	1.448	.2134	.2591	.3048
20	.2439	1.2193	1.3717	1.2193	.2286	.2439	.2743
21	.2286	1.1431	1.2955	1.1431	.2134	.2439	.2439
22	.2286	1.0669	1.2193	1.0669	.1981	.2286	.2134
23	.2134	.9907	1.1431	.9907	.1981	.2134	.1829
24	.1219	.1829	.9145	1.0669	.9907	.1829	.1981
Max	1.5242	1.5242	1.6004	1.448	1.2955	1.7528	1.5242
Min	.1219	.1829	.2134	.1524	.1981	.1829	.1829
Avg	.6729	.6718	.8590	.6617	.7991	.8111	.8034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 205 / FALAWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1677	.1372	.1372	.8383	.8383	.9907
2	.1677	.1524	.1372	.1524	.9145	.9145	1.0669
3	.1829	.1524	.1524	.1677	.9907	.9907	1.2955
4	.1981	.1677	.1677	.1677	1.2193	1.0669	1.3717
5	.2134	.1829	.1981	.1981	1.3717	1.2193	1.5242
6	.2286	.2134	.2134	.1829	1.448	1.2955	1.6004
7					1.448	1.9814	1.6766
8					1.3717	1.6004	1.6004
9	1.3717						
10	1.3717						
11	1.448						
12	1.3717						
13	1.2193						
14	1.0669						
15	1.0669						
16	.9907						
17		1.7528	.9907				
18		1.829	1.0669				
19	.1981	1.5242		1.5242	.1219	.2134	.1981
20	.2134	1.2193	1.6004	1.3717	.1372	.1981	.1829
21	.2134	1.0669	1.3717	1.2955	.1524	.1829	.1677
22	.1981	.9907	1.2955	1.2193	.1524	.1677	.1524
23	.1829	.9145	1.2193	1.1431	.1677	.1524	.1372
24	.1372	.1677	.8383	1.0669	.9145	.1677	.1372
Max	1.448	1.829	1.6004	1.5242	1.448	1.9814	1.6766
Min	.1372	.1524	.1372	.1372	.1219	.1524	.1372
Avg	.6097	.7501	.7222	.7189	.8035	.7849	.8644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 207 / maloli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	.1524	.1524	.1715	.1372	.1524	.1219
2	1.6004	.1524	.1677	.1677	.1543	.1677	.1372
3	1.6766	.1677	.1829	.1829	.1524	.1677	.1524
4	1.7528	.1829	.1829	.1829	.1677	.1829	.1524
5	1.829	.1981	.1981	.1981	.1829	.2401	.1677
6	1.9052	.2134	.2134	.1829	.1981	.2439	.1829
7	1.9052						
8	1.9814						
9		2.21	2.5149	2.4387			
10		2.21	2.4387				
11		2.1338	2.3624				
12		1.9052	2.2862				
13		1.829	2.21				
14		1.2193	2.1338				
15		1.448	2.0576				
16		1.5242	1.9814				
17					1.829	2.1338	1.2193
18					2.8197	1.9814	2.4387
19	.2134	.1829	.1372	.2439	2.5911	1.9052	1.9814
20	.2286	.1677	.1524	.2134	2.4387	1.829	1.829
21	.2134	.1524	.1677	.2134	2.2862	1.7528	1.6766
22	.1981	.1524	.1524	.1829	2.21	1.6766	1.6004
23	.1829	.1372	.1219	.1829	2.0576	1.5242	1.5242
24	.1067	.1524	.1219	.1372	.1677	1.9052	1.6004
Max	1.9814	2.21	2.5149	2.4387	2.8197	2.1338	2.4387
Min	.1067	.1372	.1219	.1372	.1372	.1524	.1219
Avg	1.0941	.8246	.9968	.3614	1.2423	1.1331	1.0560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 201 / BONDLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	1.3717	1.6194	1.5242	.2715	.2715
2	.2715	1.5242	1.6194	1.5242	.2715	.2715
3	.2715	1.5242	1.9433	1.829	.2715	.2715
4	.2715	1.5242	2.1052	1.9814	.2715	.2715
5	.362	1.829	2.4291	2.21	.2715	.362
6	.362	2.4387	2.915	2.5149	.362	.362
7		3.0483	3.2388	3.0483		
8		3.0483	3.1579	2.8197		
9		2.7435	2.9959	2.7435		
10	2.7149				2.3482	1.9433
11	3.0769				3.2388	2.672
12	3.0769				3.2388	2.672
13	3.0769				2.9959	2.672
14	3.0769				2.915	2.2672
15	3.0769				2.753	2.5911
16	2.915				2.753	2.753
17	3.0769				2.753	2.753
19	.543	.381	.362	.381	.543	.4525
20	.543	.381	.4525	.381	.543	.4525
21	.4525	.4572	.362	.3048	.362	.362
22	.362	.3048	.362	.3048	.362	.362
23	.362	.3048	.362	.2286	.2715	.362
24	.2715	1.3717		1.5242	.2715	.2715
Max	3.0769	3.0483	3.2388	3.0483	3.2388	2.753
Min	.2715	.3048	.362	.2286	.2715	.2715
Avg	1.4218	1.4835	1.7089	1.5546	1.3534	1.2198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 202 / VELAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.7621	.905	.7621	.6097	.905
2	.905	.7621	.905	.7621	.6097	.905
3	.9955	.7621	1.086	.9145	.6097	.905
4	1.086	.7621	1.267	.9145	.7621	.905
5	1.267	.9145	1.3575	1.0669	.9145	1.086
6	1.448	1.2193	1.448	1.2193	1.1431	1.267
7	1.2955	1.2193	1.267	1.1431	1.1431	1.267
8	1.1336	1.0669	1.1765	1.0669	.9907	1.267
9	1.1765	.9145	1.086	.9907	.9145	1.086
10	.9955	.9145	1.1765	.9145	.8097	1.086
11	.905	.9145	1.1765	.9145	.9717	1.086
12	.905	.9145	1.086	.8383	.8907	1.086
13	.905	.9145	1.086	.8383	.8097	1.086
14	.6192	.9145	.905	.8383	.8097	1.086
15	.905	.9145	.905	.9145	.905	1.086
16	.905	.9145	1.086	.9145	.905	1.086
17	.905	.9145	1.086	.9145	.905	1.086
18	1.086	.9145	1.1765	.9145	1.086	1.1765
19	1.448	1.2193	1.3575	1.0669	1.448	1.448
20	1.448	1.2193	1.448	.9907	1.448	1.448
21	1.267	1.0669	1.3575	.9145	1.267	1.267
22	1.267	.9907	1.3575	.8383	1.267	1.267
23	1.086	.9145	1.1765	.6859	1.086	1.086
24	.905	.905	.905	.7621	.6097	.905
Max	1.448	1.2193	1.448	1.2193	1.448	1.448
Min	.6192	.7621	.905	.6859	.6097	.905
Avg	1.0735	.9554	1.1576	.9209	.9548	1.1199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 203 / 11 KV NEVARE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	.1524	.1715	.1524	.1524	1.3717	1.6194
2	1.5384	.1524	.1715	.1524	.1524	1.3717	1.6194
3	1.5384	.1524	.1715	.1524	.1524	1.5242	1.6194
4	1.5384	.1524	.1715	.1524	.1524	1.5242	1.6194
5	1.6194	.1524	.1715	.1524	.1524	1.7528	1.9433
6	1.9766	.1524	.1715	.2286	.1524	1.9814	2.1052
7	2.2672				.1524	2.4387	2.2672
8	2.4577					2.5149	2.5911
9	2.4291					2.4387	2.4291
10			1.2955	1.0669	1.9814		
11		2.4387	2.915	2.7435	2.6673		
12		2.5149	2.834		2.5911		
13		2.4387	2.753		2.4387		
14		2.2862	2.5911		2.2862		
15		2.2862	2.5911		2.21		
16		2.4387			2.4387		
17		2.4387	2.672		2.4387		
19	.181	.1524	.1715	.2286	.2286	.181	.2715
20	.181	.1524	.2715	.2286	.2286	.181	.2715
21	.181	.2286	.181	.1524	.1524	.181	.2715
22	.181	.1524	.181	.1524	.1524	.181	.181
23	.181	.1524	.181	.1524	.1524	.181	
24	1.4575	.181	.1715	.181	.1524	1.2955	1.4575
Max	2.4577	2.5149	2.915	2.7435	2.6673	2.5149	2.5911
Min	.181	.1524	.1715	.1524	.1524	.181	.181
Avg	1.2844	.9882	1.0441	.4212	1.0088	1.2746	1.4476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 204 / 11KV NIMGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	1.2193	1.1336	1.2193	1.3717	.1524	.181
2	.181	1.3717	1.2955	1.2193	2.2862	.1524	.181
3	.181	1.3717	1.4575	1.2193	1.5242	.1524	.181
4	.181	1.3717	1.6194	1.6004	1.6766	.1524	.181
5	.181	1.5242	1.7814	1.6004	1.829	.2286	.181
6	.2715	1.9814	2.1052	1.9052	1.9814	.3048	.181
7		2.1338	2.5911	2.7435	2.7435		
8		2.2862	2.5911	2.7435	2.4387		
9		2.2862	2.4291	2.1338	2.2862		
10	1.7814					1.7814	1.6194
11	2.4577					2.753	2.672
12	2.4291					2.753	2.672
13	2.2672					2.5911	2.2672
14	2.1052					2.5911	2.1862
15	2.1052					2.4291	2.2672
16	2.1052					2.2672	2.4291
17	2.2672					2.2672	2.4291
19	.181	.2286	.181	.1524	.2286	.181	.2715
20	.181	.2286	.2715		.2286	.181	.2715
21	.181	.2286	.181		.1524	.181	.2715
22	.181	.1524	.181	.1524	.1524	.181	.181
23	.181	.1524	.181		.1524	.181	.181
24	.181	1.2003	1.1336	1.1336	1.0669	.1524	.181
Max	2.4577	2.2862	2.5911	2.7435	2.7435	2.753	2.672
Min	.181	.1524	.181	.1524	.1524	.1524	.181
Avg	.9890	1.1825	1.2755	1.4853	1.3413	1.0817	1.0493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 205 / TANDULWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	1.0669	1.0526	.9145	.181	.181
2	.181	1.0669	1.1336	1.0669	.181	.181
3	.181	1.0669	1.4575	1.2193	.181	.181
4	.181	1.0669	1.4575	1.3717	.181	.181
5	.181	1.0669	1.5384	1.5242	.181	.181
6	.2715	1.2193	1.6194	1.6766	.362	.181
7		1.829	2.0243	2.1338		
8		1.9814	2.1052	2.1338		
9		1.9814	2.0243	1.9814		
10	1.3765				1.6194	1.1336
11	1.9433				2.2672	2.3482
12	2.1052				2.2672	2.2672
13	1.9433				2.1052	2.2672
14	1.7814				1.9433	2.2672
15	1.7814				1.9433	1.9433
16	1.9433				1.9433	1.8623
17	2.1052				2.1052	1.7814
19	.2715	.2286	.2715	.2286	.2715	.2715
20	.2715	.2286	.2715	.2286	.2715	.2715
21	.2715	.2286	.2715	.2286	.2715	.2715
22	.181	.1524	.181	.1524	.2715	.181
23	.181	.1524	.181	.1524	.181	.181
24	.181	1.0288	1.0526	.9145	.181	.181
Max	2.1052	1.9814	2.1052	2.1338	2.2672	2.3482
Min	.181	.1524	.181	.1524	.181	.181
Avg	.8757	.9577	1.1095	1.0618	.9455	.9157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 206 / BHAKAREWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0526	.1524	.181	.1524	1.0669	1.1336
2	1.1336	.1524	.181	.1524	1.0669	1.1336
3	1.2146	.1524	.181	.1524	1.1431	1.1336
4	1.2955	.1524	.181	.1524	1.1431	1.2955
5	1.4575	.1524	.181	.1524	1.1431	1.4575
6	1.5384	.1524	.181	.1524	1.2193	1.9433
7	1.9433				1.5242	1.9433
8	1.9433				1.5242	1.9433
9	1.6194				1.448	1.9433
10		.9145	1.0526	1.2955		
11		1.829	1.8623	1.6766		
12		1.9052	1.7814	1.3717		
13		1.829	1.6194	1.448		
14		1.6004	1.6194	1.448		
15		1.5242	1.6194	1.5242		
16		1.448	1.7004	1.5242		
17		1.5242	1.6194	1.5242		
19	.2715	.2286	.2715	.2286	.2715	.2715
20	.2715	.2286	.2715	.2286	.2715	.2715
21	.2715	.1524	.2715	.2286	.2715	.2715
22	.181	.1524	.181	.1524	.2715	.181
23	.181	.1524	.181	.1524	.2715	.181
24	.8907	.181	.181	.1524	.9145	1.1336
Max	1.9433	1.9052	1.8623	1.6766	1.5242	1.9433
Min	.181	.1524	.181	.1524	.2715	.181
Avg	1.0177	.7292	.7659	.6935	.9034	1.0825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 207 / UGHDEWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.1524	.181	.0762	1.0526	1.1336
2	.9717	.1524	.181	.0762	1.0526	1.1336
3	.9717	.1524	.181	.0762	1.1336	1.1336
4	.9717	.1524	.181	.0762	1.1336	1.1336
5	1.1336	.1524	.181	.0762	1.2146	1.2955
6	1.2146	.1524	.181	.0762	1.2146	1.2955
7	1.4575				1.3765	1.2955
8	1.2955				1.3765	1.2955
9	1.2955				1.2955	1.2955
10		.9145	.9717	.9907		
11		1.1431	1.3765	1.3717		
12		1.2193	1.3765	1.2193		
13		1.2955	1.2955	1.2193		
14		1.2193	1.2955	1.2193		
15		1.2193	1.2955	1.2193		
16		1.1431	1.2955	1.2955		
17		1.2193	1.3765	1.2955		
19	.181	.1524	.0905	.1524	.181	.0905
20	.181	.1524	.0905	.1524	.181	.0905
21	.181	.1524	.0905	.0762	.181	.0905
22	.181	.1524		.0762	.181	.0905
23	.181	.1524	.0905	.0762	.181	.0905
24	1.0288	.181	.181	.0762	1.0526	1.1145
Max	1.4575	1.2955	1.3765	1.3717	1.3765	1.2955
Min	.181	.1524	.0905	.0762	.181	.0905
Avg	.8145	.5615	.6270	.5449	.8538	.8386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 208 / NAGTHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8623	.1524	.181	.1524	1.6194	1.6194
2	1.8623	.1524	.181	.1524	1.7814	1.6194
3	1.8623	.1524	.181	.1524	1.7814	1.6194
4	1.8623	.1524	.181	.1524	1.7528	1.7814
5	1.9433	.2286	.181	.1524	1.9433	1.9433
6	2.1862	.3048	.181	.1524	2.0243	1.9433
7	2.2672				2.2672	2.4291
8	2.2672				2.2672	2.4291
9	2.2672				2.1862	2.4291
10		1.2193	1.4575			
11		2.1338	2.3482	2.1338		
12		2.21	2.2672	2.1338		
13		2.21	2.2672	2.1338		
14		2.1338	2.2672	2.0576		
15		1.9814	2.2672	2.0576		
16		1.9052	2.2672	2.2862		
17		1.829	2.3482	2.2862		
19	.362	.1524	.2715	.381	.362	.2715
20	.362	.1524	.2715	.381	.362	.2715
21	.2715	.1524	.2715	.3048	.2715	.2715
22	.2715	.1524	.2715	.2286	.181	.2715
23	.2715	.1524	.181	.2286	.181	.2715
24	1.7004	.181	.181	.1524	1.6194	1.6194
Max	2.2672	2.21	2.3482	2.2862	2.2672	2.4291
Min	.2715	.1524	.181	.1524	.181	.2715
Avg	1.4413	.8854	1.0012	.9305	1.3733	1.3860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 201 / SHRIPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.3429	.362		.362	.3429	.362
2	.2629	.3429	.3582		.362	.3429	.3506
3	.2629	.0857	.3582		.362	.3429	.362
4	.3506	.0857	.4477		.4525	.4287	.4572
5	.5258	.4287	.543		.543	.4287	.543
6	.5258	.5144	.5487		.543	.5144	.543
8	.4382	.3429	.362		.4525	.4287	.5373
9	.2572	.3429	.362		.362	.3429	.4525
10	.3429	.2629	.2629	.2572	.3429	.3429	.3429
11	.2572	.1753	.2629		.2572	.2572	.3429
12	.2572	.1753	.2629		.1715	.2572	.2572
13	.2572	.1753	.2629	.2572	.1715	.2572	.2572
14	.1715	.1753	.1753	.2572	.1715	.2572	.2572
15	.1715	.1753	.1753	.2572	.1715	.2572	.2572
16	.1715	.181	.1753	.2572	.1715	.2572	.2572
17	.2572	.2715	.1715	.2715	.2572	.362	.2629
18	.2572	.2715	.2572	.2715	.2572	.4572	
19	.3429	.4525	.3429	.4382	.3429	.543	.5258
20	.3429	.543	.4287	.543	.4287	.543	.5258
21	.3429	.543	.4287	.543	.3429	.5487	.5258
22	.3429	.4525	.3429	.4525	.3429	.5487	.4382
23	.3429	.362	.2572	.362		.4525	.4382
24	.2629	.3429	.362		.362	.3429	.362
Max	.5258	.543	.5487	.543	.543	.5487	.543
Min	.1715	.0857	.1715	.2572	.1715	.2572	.2572
Avg	.3047	.3063	.3265	.3473	.3287	.3851	.3936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 202 / MAHALUNG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.13	1.829	1.8976		.2629	.2572	.2629
2	2.13	1.9814	1.9204		.2629	.2572	.2629
3	2.13	2.1338	1.9204		.2629	.2572	.2629
4	2.13	2.1338	1.9204		.2629	.2572	.2686
5	2.2939	2.2862	1.8976		.2629	.3429	.2629
6	2.4577	2.3624	2.0805		.2629	.3429	.2629
7	2.6216	2.5149	2.4006		.2629	.3429	.2629
8	2.6216	2.5149	2.5301		.2629	.2572	.2629
9	2.2862	2.5911	2.5301		.1753	.2572	.2629
10	.1715	.0876	.0876	.2572	1.9814	1.9814	1.9814
11	.1715	.0876	.0876		2.5911	2.5911	2.915
12	.1715	.1753	.0876		2.5149	2.5911	2.5911
13	.1715	.1753	.0876	.2572	2.5149	2.5911	2.915
14	.1715	.1753	.0876	.2572	2.5149	2.5911	3.0007
15	.1715	.1753	.0876	.2572		2.5911	2.6673
16	.1715	.1753	.0876	.2572		2.5911	3.0007
17	.1715	.1753	.0857	.2629	2.4387	2.7206	2.7035
18	.2572	.2629	.0857	.2629	.2572	.1753	.0876
19	.3429	.2629	.0857	.3506	.3429	.2629	.0876
20	.3429	.2629	.1715	.362	.3429	.3506	.1753
21	.3429	.2629	.0857	.3506	.3429	.3506	.1753
22	.3429	.2629	.0857	.362	.3429	.2629	.1753
23	.3429	.1753	.0857	.2629	.2572	.2629	.0876
24	1.9662	1.829	1.9204		.2629	.3429	.2629
Max	2.6216	2.5911	2.5301	.362	2.5911	2.7206	3.0007
Min	.1715	.0876	.0857	.2572	.1753	.1753	.0876
Avg	1.0880	1.0372	.9299	.2917	.8629	1.0345	1.0499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 203 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0876		.8002	1.0288	.8697
2	.0876	.0857	.0876		.8802	.9145	.8802
3	.0876	.0857	.0876		.8697	.7621	.8697
4	.0876	.0857	.0905		.8697	1.0288	.8697
5	.0876	.0857	.0876		.8802	.9907	.9488
6	.0876	.0857	.0876		.8697	1.2003	1.1069
7	.0876	.0857	.0876		1.1203	1.2193	1.3603
8	.0876	.0857	.0876		1.186	1.3717	1.3441
9	.0857	.0857	.0876		1.186	1.4575	1.4232
10	1.1431	1.1469	1.065	1.1431	.0857	.0857	.0857
11	1.3717	1.3108	1.4746	1.4575	.0857	.0857	.0857
12	1.5242	1.4746	1.5565	1.3717	.0857		.0857
13	1.5242	1.4746	1.4746	1.5432	.0857		.0857
14	1.5242	1.4746	1.4746	1.5432	.0857		.0857
15	1.5242	1.2289	1.4746	1.2955			.0857
16	1.5242	1.2651	1.3927	1.3717		.0857	.0857
17	1.3717	1.4232	1.3717	1.2651	.0857	.0876	.0876
18	.0857	.0876	.0857	.0876	.0857	.0876	.0876
19	.0857	.0876	.0857	.0876	.0857	.0876	.0876
20	.0857	.0876	.0857	.0876	.0857	.0876	.0876
21	.0857	.0876	.0857	.0876	.0857	.0876	.0876
22	.0857	.0876	.0857	.0876	.0857	.0876	.0876
23	.0857	.0876	.0857	.0876	.0857	.0876	.0876
24	.0876	.0857	.0876		.8002	.7621	.8697
Max	1.5242	1.4746	1.5565	1.5432	1.186	1.4575	1.4232
Min	.0857	.0857	.0857	.0876	.0857	.0857	.0857
Avg	.5373	.5076	.5282	.8226	.4768	.5803	.4898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 204 / CHAUKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	1.6766	1.7394		.1227	.0857	.0876
2	1.9662	1.6766	1.7394		.1227	.0857	.0876
3	1.9662	1.6766	1.7394		.1227	.0857	.0876
4	1.9662	1.7528	1.7394		.1227	.1715	.0876
5	2.0481	1.7528	1.9204		.1402	.1715	.0876
6	2.0481	1.829	2.0557		.1753	.1715	.1227
7	2.2939	2.1338	2.2929		.1227	.0857	.0876
8	2.2939	1.9814	2.2929		.1402	.0857	.1227
9	2.0576	2.0576	2.1348		.1578	.0857	.1227
10	.0857	.0876	.0876	.0857	2.0576	2.21	2.0576
11	.0857	.0876	.0876	.0857	2.21	2.21	2.3624
12	.0857	.0876	.0876	.0857	2.2862	2.21	2.6578
13	.0857	.0876	.0876	.0857	2.2862	2.21	2.2862
14	.0857	.1753	.0876	.0857	2.1338	2.1338	2.4006
15	.0857	.1753	.0876	.0857	2.0576	2.1338	2.2291
16	.0857	.0876	.0876	.0857	1.9814	2.1338	2.0576
17	.0857	.1227	.0857	.1227	2.0576		2.2939
18	.0857	.1753	.1715	.1227	.0857		.0876
19	.0857	.1753	.1715	.1227	.1715	.1753	.0876
20	.0857	.1753	.1715	.1227	.1715	.1753	.1753
21	.0857	.1578	.1715	.1578	.1715	.1578	.1753
22	.0857	.1578	.1715	.1578	.0857	.1402	.0876
23	.0857	.1578	.1715	.1578	.0857	.1227	.0876
24	1.9662	1.5242	1.5813		.1227	.0857	.0876
Max	2.2939	2.1338	2.2929	.1578	2.2862	2.21	2.6578
Min	.0857	.0876	.0857	.0857	.0857	.0857	.0876
Avg	.9072	.8322	.8735	.1117	.7997	.7785	.8345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 205 / MALEWADI AG/SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0876		1.7604	1.7147	1.8404
2	.0876	.0857	.0876		1.7394	1.5242	1.8404
3		.0857	.0876		1.7394	1.5242	1.8185
4	.0876	.0857	.0876		1.7394	1.6766	1.8404
5	.1753	.1715	.1227		1.7604	2.0576	1.8185
6	.1753	.1715	.1402		1.8404	1.9052	1.8976
7	.1753	.0857	.1402		2.2929	1.9814	2.0557
8	.0876	.0857	.0876		2.2929	2.2291	2.2929
9	.0857	.0762	.0876		1.9766	1.829	2.2929
10	2.1338		1.9662	1.829	.0857	.0857	.0857
11	2.5149		2.3758	2.1338	.0857	.0857	.0857
12	2.5149	2.2939	2.4577	2.4863	.0857	.0857	.0857
13	2.4387	2.2939	2.2119	2.21	.0857	.0857	.0857
14	2.2862	2.2939	2.2119	1.9814	.0857	.0857	.0857
15	2.2862	2.3758	2.2939	1.9814	.0857	.0857	.0857
16	2.2862	2.4006	2.2119	2.3148	.0857	.0857	.0857
17	2.21	2.2929	1.829	1.8976	.0857	.0876	.0876
18	.0857	.0876	.0857	.0876	.0857	.0876	.0876
19	.0857	.0876	.0857	.0876	.0857	.1227	.0876
20	.0857	.1227	.0857	.0876	.0857	.1227	.0876
21	.0857	.1227	.0857	.1402	.0857	.1227	.0876
22	.1715	.1052	.0857	.1402	.0857	.1227	.0876
23	.0857	.0876	.0857	.0876	.0857	.0876	.0876
24	.0876	.0857	.0876		1.7604	1.3717	1.7394
Max	2.5149	2.4006	2.4577	2.4863	2.2929	2.2291	2.2929
Min	.0857	.0762	.0857	.0876	.0857	.0857	.0857
Avg	.8835	.7083	.7954	1.2475	.8376	.7986	.8604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 206 / Borgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.964	1.0288	1.0059		1.0059	1.0288	1.0059
2	.964	1.0288	1.0059		.9955	1.0288	1.0059
3	1.0517	1.0288	1.0059		1.0059	1.0288	1.086
4	1.2269	1.2003	1.1888		1.1888	1.286	1.2803
5	1.4022	1.3717	1.3717		1.3717	1.3717	1.186
6	1.4022	1.286	1.448		1.4632	1.4575	1.4784
8	1.1393	1.1145	1.1888		1.0974	1.2003	1.1888
9	.9431	1.1145	1.0059		.9145	1.1145	1.0974
10	.8573	.8764	.964		.7716	.9431	.8573
11	.8573		.8764	.8573	.8573	.8573	.8573
12	.8573	.8764	.7888	.7716	.8573	.7716	.7716
13	.8573	.7888	.7888	.6859	.7716	.7716	.7716
14	.7716		.7011	.6859	.7716	.7716	.7716
15	.7716	.8764	.7011	.6859	.7716	.7716	.7716
16	.7716	.905	.8764	.6859	.7716	.7716	.7716
17	.7716	.823	.8573	.823	.7716	.823	.8764
18	.8573	.9145	.8573	.823	.9431	.924	.964
19	1.1145	1.0974	1.1145	1.0974	1.286	1.1888	1.3146
20	.8573	1.2803	1.3717	1.2803	1.286	1.3717	1.4022
21	1.286	1.1888	1.286	1.1888	1.2003	1.2803	1.3146
22	1.2003	1.1888	1.2003	1.0974	1.1145	1.1888	1.2269
23	1.0288	1.0974	1.0288	1.1088	1.1145	1.0059	1.1393
24	.964	1.0288	1.0059		1.0059	1.0288	1.0059
Max	1.4022	1.3717	1.448	1.2803	1.4632	1.4575	1.4784
Min	.7716	.7888	.7011	.6859	.7716	.7716	.7716
Avg	.9964	1.0531	1.0278	.9070	1.0147	1.0429	1.0498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 207 / Mundafane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.065	1.0288	.9602			
2	1.065	1.0288	.9488			
3	1.065	1.1145	.9488			
4	1.1393	.9907	.9488			
5	1.1469	1.2003	1.0402			
6	1.1469	1.0669	1.186			
7	1.3108	1.2193	1.2803			
8	1.3108	1.3717	1.2651			
9	1.1431	1.2193	1.186			
10				1.0669	1.0669	1.0669
11				1.2955	1.0669	1.3717
12				1.3717	1.0669	1.3717
13				1.2193	1.2193	1.2193
14				1.1431	1.2193	
15				1.2193	1.2193	1.2193
16				1.2193	1.2193	1.2193
17				1.286	1.2651	1.1469
24	1.065	1.0288	.7907			
Max	1.3108	1.3717	1.2803	1.3717	1.2651	1.3717
Min	1.065	.9907	.7907	1.0669	1.0669	1.0669
Avg	1.1458	1.1269	1.0555	1.2276	1.1679	1.2307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 201 / 11 KV TAMKHEDA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	1.1736	1.2193	.9907	.1067	.1067	.1219
2	.0914	1.1126	1.2498	1.0669	.0914	.0914	.0914
3		1.1126	1.2955	1.1888	.0914	.0914	.0914
4		1.2041	1.3717	1.2955	.1219	.1219	.1219
5	.1524	1.2955	1.448	1.448	.1524	.1524	.1524
6	.1677	1.4327	1.5089	1.5242	.1677	.1829	.1677
7	.1524	1.5394	1.6309	1.6766	.1524	.1677	.1372
8	.1219	1.7528	1.5242	1.6766	.1219	.1677	.1524
9	.1219	1.7528	1.6918	1.7528	.1067	.1372	.1219
10	1.1584	.1372	.1372	.1067	1.2498	1.2651	1.2955
11	1.6156	.1219	.1219	.0762	1.8595	1.5242	1.829
12	1.6461	.0914	.0914	.0914	1.8442	1.89	1.829
13	1.6766	.0914	.1067	.0914	1.7528	1.768	1.6766
14	1.6918	.0914	.1219	.0914	1.8442	1.8442	1.7528
15	1.6766		.1219	.0914	1.829	1.7833	1.7528
16	1.6918	.0914	.1219	.0914		1.829	1.7528
17	1.7071	.0914	.1219	.0914	1.829	1.6613	1.7528
18	.1372	.1067	.1219	.0914	.1067	.0914	.1219
19	.1981	.1524	.1524	.1829	.1524	.1524	.1524
20	.2134	.1524	.1524	.1829	.1677	.1219	.1524
21	.1677	.1219	.1524	.1524	.1524	.1067	.1524
22	.1524	.0914	.1219	.1524	.1372	.1067	.1219
23	.1219	.0914	.1219	.1219	.1219	.0914	.1219
24	.1219	1.1431	1.1279	.9907	.1067	.1219	.1219
Max	1.7071	1.7528	1.6918	1.7528	1.8595	1.89	1.829
Min	.0914	.0914	.0914	.0762	.0914	.0914	.0914
Avg	.6776	.6501	.6598	.6344	.6203	.6490	.6560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 202 / 11 KV TONDLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	1.9814	1.9509	1.9052	.2743	.2591	.2743
2	.2743	2.0271	1.9814	1.9814	.2286	.2286	.2743
3	.2439	2.1186	2.1643	2.0576	.2286	.2134	.2896
4	.3048	2.21	2.2558	2.1338	.3048	.2896	.3048
5	.3506	2.332	2.3167	2.21	.3353	.3048	.3201
6	.3506	2.5301	2.4387	2.2862	.3658	.3201	.3353
7	.3201	2.7435	2.4387	2.6673	.4115	.3353	.3506
8	.2286	2.8349	2.774	2.5911	.3048		.381
9	.1981	2.713	2.7435	2.5911	.3048	.3201	
10	2.0576	.3658	.1524	.2591	2.1643		1.9052
11	2.8197	.3048	.1524	.2134	2.8197	2.1338	2.5911
12	2.8502	.2591	.1524	.3048	2.7282	2.5149	2.5149
13	2.7892	.2591	.0914		2.6978	2.332	2.3624
14	2.7587	.3048	.1524		2.6825	2.2862	2.2862
15	2.7587	.2896	.1829	.2134	2.774	2.2253	2.4387
16	2.7892	.2439	.3048	.2439	2.6673	2.1948	2.3624
17	2.8045	.2591	.3048	.2896	2.6825	2.1491	
18	.3048	.3048	.3048		.2591		.2743
19	.3353	.3963	.3353		.3506	.3201	.381
20	.3506	.3658	.3353	.381	.3658	.3048	.381
21	.3201	.3353	.3048	.381	.3048	.2743	.3658
22	.3048	.3048	.3048	.3353	.2743	.3048	.3353
23	.2591	.2743	.3048	.3048	.2591	.2743	.3658
24	.3048	1.9357	1.829	1.9052	.2896	.2743	.2896
Max	2.8502	2.8349	2.774	2.6673	2.8197	2.5149	2.5911
Min	.1981	.2439	.0914	.2134	.2286	.2134	.2743
Avg	1.0993	1.1539	1.0948	1.2628	1.0866	.9457	.9720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 203 / 11 KV KHALAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0152	.0152	.0152	.061	.0914	.0914
2	.0914	.0152	.0152	.0152	.0762	.0914	.0914
3	.0914	.0152	.0152	.0152	.0762	.0914	.1219
4	.1219	.0152	.0152	.0152	.0914	.1067	.1524
5	.1524	.0152	.0152	.0152	.1524	.1219	.1677
6	.1829	.0152	.0152	.0305	.1677	.1524	.1677
7	.1829	.0305	.0152	.0152	.1829	.1677	.0152
8	.1524	.0152	.0152	.0152	.1981	.1829	.1981
9	.1524	.0152	.0152	.0152	.1981	.1829	.1829
10	.0152	.0762	.1067	.0857	.0152	.0152	.0152
11	.0152	.1829	.1829	.1677	.0152	.0152	.0152
12		.1829	.1829	.1524	.0152	.0152	.0152
13	.0152	.1981	.1677	.1524	.0152	.0152	.0152
14	.0152	.1829	.1677	.1677	.0152	.0152	.0152
15	.0152	.1829	.1677	.1677	.0152	.0152	.0152
16	.0152	.1981	.1524	.1677	.0152	.0152	.0152
17	.0152	.1981	.1524	.1829	.0152	.0152	.0152
18	.0152	.0152	.0152	.1372		.0152	.0152
19	.0152	.0152	.0152	.0152	.0152	.0152	.0152
20	.0152	.0152	.0152	.0152	.0152	.0152	.0152
21	.0152	.0152	.0152	.0152	.0152	.0152	.0152
22	.0152	.0152	.0152	.0152	.0152	.0152	.0152
23	.0152	.0152	.0152	.0152	.0762	.0152	.0152
24	.0762	.0152	.0152	.0152	.061	.0762	.0305
Max	.1829	.1981	.1829	.1829	.1981	.1829	.1981
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0649	.0692	.0635	.0677	.0662	.0616	.0597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 204 / 11 KV SHERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	.1219	.1524	.1219	2.1338	1.9509	2.0119
2	2.2862	.0914	.1524	.1219	2.1338	1.9814	2.1033
3	2.2862	.0914	.1219	.1219	2.2862	2.1795	2.1643
4	2.4387	.1219	.1219	.1219	2.4387	2.3167	2.2862
5	2.5911	.1524	.1524	.1372	2.5911	2.5911	2.4387
6	2.7435	.1829	.1524	.1372	2.5911	2.7435	2.7435
7	3.0483	.1524	.2134	.1677	2.7435	2.9569	3.2312
8	2.8959	.1524	.1829	.1524	2.9721	2.8959	2.8654
9	2.8197	.1524	.1524	.1372	2.9721	3.1093	3.0483
10	.1524	1.829	1.6613	2.21	.0914	.0914	.1067
11	.2134	3.0483	2.4387	2.6673	.0914	.0914	.0914
12	.1981	2.7435	2.8959	2.8197	.0914	.0914	.1067
13	.1829	3.1093	2.9721	2.7435	.0914	.0914	.1067
14	.1829	2.9264	2.7435	2.8959	.0914	.0914	.1067
15	.1829	2.9264	2.7435	2.8959	.0914	.1524	.1219
16	.2134	2.774	2.774	2.8959	.0914	.1829	.1219
17	.2134	3.0483	2.774	2.8959	.1219	.1524	.1524
18	.2439	.1219	.0762		.1524	.1524	.1677
19	.2439	.1829			.1829	.1829	.1677
20	.2286	.1219	.1219	.1829	.1829	.1524	.1524
21	.2286	.1219	.1219	.1524	.1524	.1524	.1524
22	.1829	.1524	.1219	.1219	.1524	.1219	.1372
23	.1524	.1219	.1219	.1219	.1372		.1219
24	1.829	.1524	.1524	.1219	1.829	1.9204	1.9814
Max	3.0483	3.1093	2.9721	2.8959	2.9721	3.1093	3.2312
Min	.1524	.0914	.0762	.1219	.0914	.0914	.0914
Avg	1.1653	1.0250	1.0053	1.0884	1.1006	1.1458	1.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 205 / 11 KV BONDALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2896	.3353	.3048	.2743	.1981	.2439
2	.2134	.2743	.3506	.3048	.2439	.1829	.2743
3	.2286	.2591	.3658	.3048	.2286	.1829	.2743
4	.2667	.3201	.3506	.3353	.2743	.2591	.2896
5	.3353	.381	.381	.3658	.3658	.3353	.3048
6	.3963	.4115	.3658	.381	.3658	.3506	.3201
7	.3048	.3201	.3201	.3048	.3048	.2896	.2743
8	.3048	.3048	.3048	.2286	.2286	.2286	.2896
9	.3048	.3353	.3963	.2743	.3658	.2743	.3353
10	.3048	.3963	.503	.3353	.3658	.381	.4572
11	.2896	.2896	.3048	.2743	.2896	.2743	.4572
12	.2896	.3048	.3048	.2743	.2591	.2286	.3048
13	.2591	.2591	.2286	.2439	.2134	.1829	.3048
14	.2439	.3353	.3048	.2286	.2134	.2134	.3048
15	.2286	.2896	.3048	.2286	.1677	.2134	.2286
16	.2134	.2286	.2286	.1829	.1829	.1981	.2286
17	.1829	.2439	.1524	.1829	.1829	.2134	.2286
18	.2439	.3048	.1829	.2286	.2134	.1981	.2591
19	.2896	.3048	.3048	.2743	.2896	.3201	.3353
20	.3201	.3353	.3506	.3658	.3048	.3658	.381
21	.3506	.3658	.381	.3658	.3658	.3963	.381
22	.381	.4572	.381	.3353	.3963	.4115	.4572
23	.3201	.3658	.3048	.3048	.2743	.2743	.4572
24	.3048	.3048	.3353	.3048	.2743	.2134	.2439
Max	.3963	.4572	.503	.381	.3963	.4115	.4572
Min	.1829	.2286	.1524	.1829	.1677	.1829	.2286
Avg	.2842	.3201	.3226	.2889	.2769	.2661	.3181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 201 / HANUMAN MANDIR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2686		
2	.2896		
3	.2896		
4	.3258		
5	.3258		
6	.362		
7	.362		
8	.3258		
9		.181	
10		.181	
11		.1448	
12		.1267	
13		.1267	
14		.0905	
15		.0905	
16		.0905	
17			.1029
18			.1715
19			.181
20			.2172
21			.2172
22			.2534
23			.2686
24	.2686		
Max	.362	.181	.2686
Min	.2686	.0905	.1029
Avg	.3131	.1290	.2017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 202 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2267		
2	.1943		
3	.1943		
4	.1898		
5	.2187		
6	.2214		
7	.1875		
8	.1898		
9		.1619	
10		1.6604	
11		2.372	
12		2.4036	
13		2.3403	
14		2.2653	
15		1.8976	
16		2.2929	
19			.1581
20			.1898
21			.1898
22			.2214
23			.253
24	.2187		
Max	.2267	2.4036	.253
Min	.1875	.1619	.1581
Avg	.2046	1.9243	.2024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 203 / MIRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8842		
2	1.9662		
3	2.13		
4	2.2119		
5	2.2939		
6	2.2939		
7	2.3758		
8	2.4905		
9		2.4006	
10		.096	
11		.128	
12		.128	
13		.1619	
14		.1619	
15		.1781	
16		.1619	
17			2.1948
18			.1524
19			.1562
20			.1562
21			.1875
22			.1898
23			.2214
24	1.8842		
Max	2.4905	2.4006	2.1948
Min	1.8842	.096	.1524
Avg	2.1701	.4271	.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 204 / 11KV ANUSEWASTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8976		
2	2.0557		
3	2.1348		
4	2.2138		
5	2.2138		
6	2.2929		
7	2.372		
8	2.4985		
9		2.5301	
10		.0949	
11		.125	
12		.1265	
13		.0949	
14		.1423	
15		.2056	
16		.2056	
17			2.5934
18			.1581
19			.1423
20			.1423
21			.1265
22			.1265
23			.1265
24	1.8976		
Max	2.4985	2.5301	2.5934
Min	1.8976	.0949	.1265
Avg	2.1752	.4406	.4879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 205 / 11KV THITWASTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-APR-18
HR	Load (MW)
10	1.781
11	2.0622
12	2.1559
13	2.0622
14	2.0309
15	1.9997
16	1.9997
Max	2.1559
Min	1.781
Avg	2.0131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 201 / MALKHAMBI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	1.6766	1.8861	1.8004	1.5242	1.6766	1.2193
2	.0857	1.6766	1.7528	1.6004	1.6766	1.829	1.5242
3	.0857	1.9052	1.829	1.6004	1.829	2.6673	1.9814
4	.0857	1.9052	2.1434	1.6766	1.829	1.9814	2.0576
5	.0857	1.9814	2.2291	1.7528	1.9814	2.0576	2.0576
6	.0857	1.9814	2.3148	2.0576	1.9814	2.21	2.0576
7	.0857	2.0576	2.4006	2.3148	2.1338	2.21	2.1338
8	.0857	1.9814	2.4006	2.0576	2.1338	2.21	2.21
9	.0857	1.829	1.9814	1.829	2.1338	2.0576	2.1795
10	1.6766	.0762	.0762	.0857	.0857	.0857	.0857
11	1.6766	.0762	.1524	.0857	.0857	.0857	.0857
12	1.6766		.1524	.0857	.0857	.0857	.0857
13	1.829	.0762	.1524	.0857	.0857	.0857	.0857
14	1.829	.0762	.1524	.0857	.0857	.0857	.0857
15	1.9814	.0762	.1524	.0857	.0857	.0857	.0857
16	2.0576	.0762	.1334	.0857	.0857	.0857	.0857
17	2.0576	.0762	.1524	.0857	.0857	.0857	.0857
18	.0857	.0762	.0762	.0857	.0857	.1715	
19	.0857	.0762	.1524	.0857	.0857	.1715	.0857
20	.0857	.0762	.1524	.1715	.0857	.1715	.0857
21	.0857	.0762	.1524	.1715	.0857	.1715	.0857
22	.0857	.0762	.0762	.1715	.0857	.6859	.0857
23	.0857	.0762	.0762	.1715	.0857	.6859	.0857
24	.0857	1.6004	1.6004	1.6004	1.2193	1.6004	
Max	2.0576	2.0576	2.4006	2.3148	2.1338	2.6673	2.21
Min	.0857	.0762	.0762	.0857	.0857	.0857	.0857
Avg	.6732	.8515	.9312	.8264	.8184	.9685	.8425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 202 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0762	.0762	.1715	.0857	.1715
2	.0857	.0857	.0762	.0762	.1715	.0857	.1715
3	.0857	.0857	.1524	.0762	.2572	.0857	.2572
4	.1715	.0857	.2286	.1524	.2572		.2572
5	.2572	.1715	.2286	.1524	.2572	.1715	.2572
6	.2572	.1715	.2286	.2286	.2572	.2572	.2572
7	.2572	.2572	.2286	.1524	.1715	.1715	.1715
8	.1715		.2286	.1524	.1715	.1715	.1715
9	.0857		.1524	.0857	.1715	.0857	.1715
10	.0857		.0762	.0857	.0857	.0857	.0857
11	.0857		.1524	.0857	.0857	.0857	.0857
12	.0857		.1524	.0857	.0857	.0857	.0857
13	.0857		.1524	.0857	.0857	.0857	.0857
14	.0857		.1524	.0857	.0857	.0857	.0857
15	.0857		.1524	.0857	.0857	.0857	.0857
16	.0857		.1524	.0857	.0857	.0857	.0857
17	.0857		.1524	.0857	.0857	.0857	.0857
18	.1715		.1524	.1715	.0857	.1715	.0857
19	.1715		.2286	.1715	.1715	.1715	.1715
20	.2572		.2286	.2572	.2572	.1715	.2572
21	.1715		.2286	.2572	.0857	.1715	.2572
22	.1715		.1524	.1715	.0857	.1715	.1715
23	.0857		.1334	.1715	.0857	.1715	.0857
24	.0857	.0857	.0667	.0762	.1715	1.8004	.1715
Max	.2572	.2572	.2286	.2572	.2572	1.8004	.2572
Min	.0857	.0857	.0667	.0762	.0857	.0857	.0857
Avg	.1357	.1286	.1639	.1298	.1465	.2013	.1572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 203 / MALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	.5144	.4572	.4572	.6001	.6001	.7716
2	2.21	.5144	.4572	.4572	.6001	.6001	.7716
3	2.2862	.5144	.5335	.5335	.6859	.6001	.7716
4	2.4387	.5144	.6097	.4572	.6859	.6859	.8573
5	2.5149	.6001	.6097	.4572	.7716	.6859	.8573
6	2.5911	.6859	.6859	.3048	.7716	.6859	.8573
7	2.5911						
8	2.8197						
9	2.7435						
10	.4287	2.4863	2.6578	.8383	2.5911	2.5149	2.3624
11	.4287	2.2862	3.2579	2.2862	2.6673	2.5911	2.8959
12	.4287	2.3624	3.1722	2.6673	2.6673	2.5911	2.9721
13	.4287	2.7435	3.0864	2.6673	2.7435	2.7435	
14	.4287	2.8292	2.915	2.7435	2.7435	2.7435	2.2862
15	.4287	2.915	2.8292	2.7435	2.8197	2.7435	2.4387
16	.5144	2.915	2.2672	2.7435	2.8197	2.5911	2.4387
17	.5144	2.915	3.0864	2.5911	2.5911	2.5911	
18	.4287	.381	.3048	.4287	.4287	.5144	.6001
19	.5144	.4572	.6859	.6001	.4287	.6859	.6001
20	.6001	.4572	.6097	.6859	.5144	.7716	.6859
21	.6859	.4572	.6097	.6859	.5144	.7716	.6859
22	.6859	.5144	.5335	.6001	.6001		.6859
23	.6001	.5335	.5335	.5144	.6001		.6859
24	2.0576	.5144	.4572	.4572	.6001	.6001	.6859
Max	2.8197	2.915	3.2579	2.7435	2.8197	2.7435	2.9721
Min	.4287	.381	.3048	.3048	.4287	.5144	.6001
Avg	1.3126	1.3386	1.4457	1.2343	1.4021	1.4901	1.3111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 204 / KAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	.0857	.0667	.0762	.0857	.0857	.0857
2	1.7528	.0857	.0667	.0762	.0857	.0857	.0857
3	1.829	.0857	.0762	.0762	.0857	.0857	.0857
4	1.9052	.0857	.0762	.0762	.0857	.0857	.0857
5	1.9814	.0857	.0667	.0667	.0857	.0857	.0857
6	2.4006	.0857	.0667	.1524	.0857	.0857	.0857
7	2.21	.0857	.0667	.1524	.0857	.0857	.0857
8	2.21	.0762	.0667	.1334	.0857	.0857	.0857
9	2.21	.0762	.0667	.1715	.0857	.0857	.0857
10	.0857	1.7528	1.9052	1.9052	1.829	1.9814	1.9052
11	.0857	2.0576	2.3148	1.9814	1.9814	2.0576	2.1338
12	.0857	2.1434	2.0576	1.9814	1.829	2.0576	
13	.0857	1.9814	2.4006	2.1338	1.9052	2.0576	2.21
14	.0857	2.3148	2.1338	2.1338		2.1338	2.2862
15	.0857	2.4006	2.4863	2.1338	2.0576	2.1338	2.2862
16	.0857	2.4863	2.4863	2.1338	2.21	2.0576	2.2862
17	.0857	2.1338	2.4863	1.9814	2.3624	2.0576	
18	.0857	.0762	.0857	.0857	.0857	.1715	
19	.0857	.0762	.1524	.0857	.0857	.1715	.0857
20	.0857	.0762	.1524	.0857	.0857	.1715	.0857
21	.0857	.0762	.1524	.0857	.0857	.1715	.0857
22	.0857	.0762	.0762	.0857	.0857	.0857	.0857
23	.0857	.0762	.0762	.0857	.0857	.0857	.0857
24	1.6766	.0857	.0667	.0762	.0857	.0857	.0857
Max	2.4006	2.4863	2.4863	2.1338	2.3624	2.1338	2.2862
Min	.0857	.0762	.0667	.0667	.0857	.0857	.0857
Avg	.8803	.7736	.8188	.7482	.6759	.7605	.6854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 205 / VITTHALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	1.3717	1.7147	2.1434	1.829	1.9814	1.829
2	.2572	1.3717	1.8004	2.3148	1.829	1.9814	2.1338
3	.2572	1.5242	1.6766	2.4863	2.21	2.1338	2.2862
4	.2572	1.5242	1.9719	2.4863	2.21	2.1338	2.4387
5	.2572	1.6004	1.829	2.572	2.3624	2.5149	2.5911
6	.2572	1.6004	2.2291	2.6578	2.4387	2.5149	2.5911
7		1.6766	2.0576	2.8292	2.5911	2.5911	2.6673
8		2.0576	2.1338	2.8292	2.5911	2.5911	2.6673
9		2.0576	1.9814	2.3624	2.5911	2.5149	2.5911
10	1.9814						
11	1.9814						
12	2.0576						
13	2.0576						
14	1.9052						
15	1.9052						
16	1.9052						
17	1.9814						
18	.0857	.1524		.4287	.3429	.2572	.4287
19	.0857	.2286	.5335	.6001	.3429	.4287	.5144
20	.0857	.2286	.5335	.5144	.4287	.6001	.5144
21	.1715	.2286	.5335	.3429	.4287	.6859	.5144
22	.1715	.2286	.4572	.3429	.3429	.6001	.5144
23	.1715	.2286	.3048	.3429	.3429	.6001	.5144
24	.2572	1.2955	1.3717	1.8861	1.3717	1.829	1.3717
Max	2.0576	2.0576	2.2291	2.8292	2.5911	2.5911	2.6673
Min	.0857	.1524	.3048	.3429	.3429	.2572	.4287
Avg	.8737	1.0860	1.4086	1.6962	1.5158	1.6224	1.6355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 201 / KOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1823	.2105	.2033	.1781		.2012
2	.181	.1658	.2105	.2012			.1991
3	.1991	.1658	.1943	.2195	.1781		.2012
4	.2614	.1989		.2561			.2378
5	.3361	.2321	.2267	.3077			.2715
6	.4108	.2321	.2267	.3982	.2267		.2896
7	.2486	.2486	.2429	.2896			.2172
8			.1943				
9	.2486	.2105	.1781	2.8988		.2534	.2534
10	.2155	.1457	.2507	.1619	.1619	.1448	.181
11	.1989	.1457	.2328		.1619	.1629	.1991
12	.1658	.1457	.2686		.1619	.1448	.181
13	.1658	.1457	.1991			.1433	.1448
14	.1658	.1406	.181		.1296	.1433	.1791
15	.1492	.1619	.1629		.1296	.1433	.1433
16	.1492	.1781	.1629			.1612	.181
17	.1658	.1619	.1629		.1457	.181	.1433
18	.2012	.1781	.1629		.1619	.181	.1791
19	.2652	.2267	.2534	.2753	.2267	.2715	.2195
20	.2818	.2753	.3045	.2591	.2591	.2896	.2743
21	.2818	.2267	.3077	.2753	.2429	.3077	.2926
22		.2267	.2561		.1943	.2743	.2587
23	.1823	.2267	.2195	.2591	.1781	.2195	.2378
24	.1949	.1823	.2105	.2033	.1781		.2012
Max	.4108	.2753	.3077	2.8988	.2591	.3077	.2926
Min	.1492	.1406	.1629	.1619	.1296	.1433	.1433
Avg	.2203	.1915	.2182	.4435	.1822	.2014	.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 202 / Kolegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	1.7375	1.5546	2.0466	.2267	.1943	.2534
2	.1867	1.8823	1.7166	2.1715	.1943	.1943	.2378
3	.1867	1.9547		2.2068		.1943	.2353
4	.2241	2.0995	2.17	2.284	.2267	.1943	.2926
5	.3361	2.3167	2.5101	2.4537			.3801
6	.4294	2.4615	2.9797	2.713			.4656
7		2.809	3.1255	2.8681	.2915		.2896
8	2.2588	3.0769	2.6073	2.8978		.3475	.3258
9	2.5774	2.8502	2.4129		.1943	.2507	.2896
10	.1658	.1943	.1448		2.0891	2.4036	
11	.1989	.1943	.181		2.915		2.4074
12	.1658	.1781	.2353		2.915	2.5301	2.6543
13	.1658	.1943	.2172			2.4684	2.6246
14	.1658	.1781	.2172			2.5465	2.3929
15	.1823	.1457	.2353			2.5617	1.7078
16	.1989	.1619	.2353		2.9797	1.8982	1.8976
17	.2155		.1463		2.8988	1.8027	1.8364
18	.1989	.2105	.1829		.1943	.1086	.1829
19	.2652		.2534		.2591	.2743	.2926
20	.3149		.3258		.2591	.3077	.3258
21	.2984		.2715		.2591	.2743	.2896
22	.2321		.2402		.2267	.2743	.2195
23	.2321	.2591	.2218		.2105	.2743	.2218
24	.1867	1.419	1.3603	1.7833	.2267	.2105	.2715
Max	2.5774	3.0769	3.1255	2.8978	2.9797	2.5617	2.6543
Min	.1658	.1457	.1448	1.7833	.1943	.1086	.1829
Avg	.4162	1.2802	1.0237	2.3805	.9745	.9655	.8737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 203 / Phalawni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2984	.3239	.3881	1.668	1.7652	1.2803
2	.3547	.2984	.3239	.4024		1.9271	1.2803
3	.3547	.2984	.3401	.4024	2.0729	2.1052	1.3603
4	.4108	.3315		.4207		2.4129	1.7236
5	.4854	.3978	.3887	.4572	2.3482	2.7206	2.364
6	.5415	.431		.5068	2.5911	3.0445	2.5143
7	.4641	.4641	.4372			3.2226	2.2531
8	.3315	.3401	.2591	.5068	3.0769	2.7315	2.8241
9	.4641	.2105	.1781	.4534	2.8502	2.6673	2.5737
10	1.6362	1.5546	1.5023	1.587	.2267	.2195	.181
11	2.1864	2.0891	2.4846		.2105	.2172	.1646
12	2.4615	2.6558	2.9502			.2172	.1829
13	2.4036	2.915	2.4846		.1943	.2149	.1829
14	2.3457	2.6882	2.4371			.2172	.2172
15	2.3167	2.4615	2.3611		.1943	.2328	.1991
16	2.2878	2.3472	2.3472		.1943	.2149	.2328
17	2.1719	2.0891				.197	.2149
18	.1989	.2753	.2534		.2591	.3012	.3077
19	.3149		.362	.3239	.2915	.362	.3982
20	.3481	.3239	.4163		.3239	.3982	.3801
21	.3315		.3801			.3475	.3658
22	.2818	.3077	.3881	.3239	.3239	.3292	.3475
23	.2818	.3401	.3881	.3239	.3077	.3109	.3475
24	.3921	.2818	.3239	.3881	1.587		1.2967
Max	2.4615	2.915	2.9502	1.587	3.0769	3.2226	2.8241
Min	.1989	.2105	.1781	.3239	.1943	.197	.1646
Avg	.9891	1.0636	1.0157	.4988	1.1012	1.1468	.9664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 201 / DOMBALWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2515	.2515	.2683	1.8299	1.7328	1.5402
2	.3018	.2515	.2515	.3018	1.8623	1.8299	1.6385
3	.3018	.2515	.2683	.3018	1.7814	1.8623	1.7368
4	.3353	.2683	.2683	.3353	1.9433	1.8623	1.8351
5	.3353	.3018	.3185	.3353	2.1052	2.0567	1.9334
6	.3353	.3185	.3185	.3018	2.3482	2.2996	2.0317
7					2.6235	2.6882	2.3594
8					2.6882	2.8178	2.2283
9					2.7199	2.4453	2.0645
10	1.6194	1.8138	1.749	2.1052			
11	2.3482	2.2996	2.332				
12	2.2996	2.4291	2.5263				
13	2.2348	2.2024	2.332				
14	2.1862	2.2996	2.2996				
15		2.2672	2.2996				
16	1.9109	2.2672	2.332				
17	2.0243	2.3482	2.1376				
18	.1174	.1174					
19	.285	.2347	.2012	.2683	.3018	.2683	.3353
20	.3018	.2515	.3018	.3353	.3353	.3018	.3353
21	.3018	.2347	.3018	.3018	.3353	.2347	.3353
22	.285	.2347	.2683	.3018	.3353	.2683	.3353
23	.2683	.2347	.2683	.285	.3018	.2683	.3353
24	.3018	.2683	.2515	.2683	1.6842	1.6356	1.4586
Max	2.3482	2.4291	2.5263	2.1052	2.7199	2.8178	2.3594
Min	.1174	.1174	.2012	.2683	.3018	.2347	.3353
Avg	.9198	1.0070	1.0639	.4392	1.5464	1.5048	1.3669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 202 / AMBEMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8947	1.8461	1.7814	1.8138	.502	.5197	.5533
2	1.8947	1.8461	1.9433	1.9433	.5197	.5197	.5533
3	2.0405	1.8461	1.9757	2.0729	.5197	.5868	.5533
4	2.0081	1.9433	2.0243	2.2024	.5365	.5868	.5365
5	2.1052	2.1052	2.2672	2.332	.5533	.6371	.5365
6	2.3482	2.1862	2.4291	2.4939	.503	.6371	.5365
7	2.672	2.2996	2.4939	2.5425		.0838	.1017
8	2.7206	2.4615	2.4615	2.4291	.0335	.1006	.1187
9	2.2186	2.2996	2.4453	2.2996	.0335	.0838	
10	.0838	.0671		.0335	2.2119	1.8461	2.3102
11	.1341	.0671	.1006		3.2442	2.8334	3.3036
12		.0671	.0838		3.2065	2.7368	3.4008
13	.0335	.1677	.1341		3.1579	2.5587	3.4494
14	.0335	.0838	.1174		3.1093	2.5263	3.4494
15	.0335	.0671	.1174		3.1093	2.6235	3.1093
16	.0503	.0671	.1509		3.0607	2.5425	2.915
17	.0503	.2012	.1844		3.0121	2.4129	2.915
18	.0503	.3688					
19	.4694	.3856		.5533	.503	.4527	.4191
20	.503	.503		.5197	.4694	.5197	.4694
21	.503	.503	.5365	.5868	.5197	.4024	.4694
22	.503	.5365		.5533	.5197	.5197	.5197
23	.503	.5868	.5365	.5533	.503	.5533	.5197
24	1.7004	1.6194	1.668	1.6842	.5365	.5197	.5533
Max	2.7206	2.4615	2.4939	2.5425	3.2442	2.8334	3.4494
Min	.0335	.0671	.0838	.0335	.0335	.0838	.1017
Avg	1.0676	1.0052	1.2343	1.5384	1.3802	1.1654	1.4224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 203 / KHUDUS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3018	.285	.3521	2.0729	1.9757	1.8187
2	.3018	.3018	.285	.3688	2.1052	1.9757	1.8679
3	.3018	.3018	.3018	.3521	1.9433	2.17	1.917
4	.3018	.3018	.3018	.3353	1.9433	2.251	1.9662
5	.3353	.3185	.3185	.3185	2.1052	2.5425	2.0153
6	.3353	.3185	.285	.3018	2.2672	2.5263	2.13
7					2.7692	2.7206	2.4939
8					2.672	2.6882	2.3967
9					2.7692	2.4777	2.3482
10	1.7004	2.2024	1.8623	2.1052			
11	2.5911	2.9797	2.7854				
12	2.7206	2.915	2.8826				
13	2.7206	2.915	2.2996				
14	2.5101	2.3967	2.3805				
15		2.3967	2.3158				
16	2.4291	2.2672					
17	2.8016	2.2996					
18	.2012	.1509					
19	.2683	.218	.2515	.218	.3353	.218	.2683
20	.285	.2683	.285	.285	.3353	.2683	.3353
21	.285	.2683	.3185	.3018	.3688	.2347	.3353
22	.285	.285	.3185	.285	.3688	.2347	.3353
23	.285	.285	.3185	.2683	.3688	.2347	.3856
24	.3353	.285	.285	.3353	1.8138	1.7166	1.7695
Max	2.8016	2.9797	2.8826	2.1052	2.7692	2.7206	2.4939
Min	.2012	.1509	.2515	.218	.3353	.218	.2683
Avg	1.0665	1.1418	1.0045	.4482	1.6159	1.6156	1.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 204 / ZANJEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7287	1.1336	1.0526	1.0688	.1677	.1677	.1844
2	.7611	1.1336	1.2146	1.1498	.1677	.1677	.1844
3	1.004	1.1336	1.2146	1.2308	.1677	.1677	.1844
4	1.1012	1.2146	1.2146	1.3117	.1677	.1844	.1677
5	1.085	1.2955	1.2955	1.3927	.1677	.1844	.1677
6	1.2308	1.4575	1.5546	1.5546	.1677	.2012	.1677
7	1.6518	1.5384	1.7004	1.6356			
8	1.5546	1.4575	1.6518	1.6356			
9	1.4575	1.4575	1.5061	1.5546			
10					1.326	1.0364	1.326
11					1.9006	1.749	1.8515
12					2.1136	1.749	1.9006
13						1.6032	1.9006
14					2.1136	1.5546	1.9006
15					1.9662	1.3927	1.5402
16					1.8679	1.4575	1.3108
17					1.7204	1.4413	1.5729
18		.0671					
19	.1509	.1341	.1341	.1174	.1677	.1341	.1341
20	.1509	.1677	.1677	.1677	.1677	.1844	.1677
21	.1509	.1677	.1677	.1844	.1844	.1509	.1677
22	.1677	.1677	.1844	.2012	.1844	.1677	.1677
23	.1677	.1677	.1844	.2012	.1844	.1677	.218
24	.5344	.9231	.9231	.9878	.1844	.1677	.1844
Max	1.6518	1.5384	1.7004	1.6356	2.1136	1.749	1.9006
Min	.1509	.0671	.1341	.1174	.1677	.1341	.1341
Avg	.7931	.8511	.9444	.9596	.7941	.7015	.7700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 205 / 11 KV Ranvijay Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.218	.1509	.1509	.1677	.2012	.1677
2	.1677	.2012	.1509	.1509	.1677	.2012	.1677
3	.1677	.2012	.1509	.1509	.1509	.2012	.1677
4	.1677	.2012	.1509	.1677	.1509	.2012	.1677
5	.1509	.2012	.1677	.1677	.1509	.2012	.1677
6	.1509	.218	.1844	.1677	.1509	.2012	.1677
7	.1006	.1677	.1509	.1677	.1677	.2012	.1844
8	.1006	.1677	.1509	.1677	.1677	.1341	.1677
9	.1509	.0671	.1509		.2012	.2012	.1677
10	.2012	.218	.1677	.1677	.1677	.2012	.1677
11	.2012	.218	.1677		.1677	.2012	.1677
12	.2012	.1677	.1677		.1677	.2012	.1677
13	.2012	.1677	.1677		.1677	.1844	.1677
14	.2012	.1677	.1509		.1677	.1677	.1677
15	.2012	.1677	.1509		.1677	.1341	.1677
24	.1677	.218	.1509	.1509	.1677	.1677	.1677
Max	.2012	.218	.1844	.1677	.2012	.2012	.1844
Min	.1006	.0671	.1509	.1509	.1509	.1341	.1677
Avg	.1687	.1855	.1582	.1610	.1656	.1876	.1687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 201 / GARWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.6859	.7621	.3269	.3772	.3715
2	.9259	1.286	.8573	.884	.3567	.3772	.4161
3	1.0288	1.4575	.8573	.9907		.3944	.4458
4	1.2003	1.6118	1.1488	1.1717			
5	1.4575	1.7147	1.286	1.448			
6	1.6289	1.7833	1.4575	1.8747			
7	1.749	1.8004	1.6004	1.9319			
8	2.0233	1.8861	1.6766	1.7185			
9	1.9719	1.749	1.5158	1.5546			
10					1.2003	1.0669	
11					1.7147	1.1248	.8916
12					1.9719	1.1431	1.4842
13					1.9719	1.2193	1.6404
14					2.0576	1.5242	1.9109
15					2.0576	1.7185	1.7747
16					1.8519	1.9433	1.4998
17					1.7147	1.829	1.3279
18	.2229	.2229	.2143	.2	.2743	.2229	.2229
19	.2572	.2058	.1932	.3864	.2915	.2378	.2675
20	.3429	.2229	.1957	.4458	.3086	.2675	.3269
21	.3429	.3086	.2675	.4572	.3429	.2972	.3572
22	.3772	.3429	.2972	.3572	.3429	.3144	.4161
23	.4115	.3772	.2972	.3429	.3601	.3715	.3715
24	.7716	.5487	.4287	.6687	.2972	.3772	.3715
Max	2.0233	1.8861	1.6766	1.9319	2.0576	1.9433	1.9109
Min	.2229	.2058	.1932	.2	.2743	.2229	.2229
Avg	.9731	1.0234	.8112	.9497	1.0260	.8226	.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 202 / CHANDAPURI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3086	.3258	.2715	1.3717	2.0576	1.4118
2	.4287	.3429	.3429	.2858	1.531	2.1434	1.5623
3	.4458	.3429	.3429	.2858	1.6518	2.4006	1.7528
4					1.9528	2.6578	1.9433
5					2.21	2.7435	2.3434
6					2.4691	2.7949	2.5777
7					2.713	2.5777	2.8502
8					2.8121	2.672	2.5006
9					3.1207	2.2653	2.4387
10	2.2634	2.1091	1.829	2.0243			
11	2.4863	2.3148	2.1091				
12	2.915	2.572	2.2862				
13	3.0864	2.8807	2.7206				
14	3.0007	3.0007	2.834				
15	2.7778	3.0521	2.6558				
16	2.6578	2.915	2.4387				
17	2.4863	2.6578	2.3624				
18	.1715	.1372	.2286	.1486	.1715	.1429	
19	.2058	.2058	.1715	.2143	.2058		.2229
20	.2401	.2229	.1858	.2378	.2401		.2972
21	.2401	.2572	.2229	.3144	.2401		.3269
22	.2743	.2915	.2675	.3429	.2401		.3567
23	.2915	.3086	.2715	.3572	.2572	.2286	.2972
24	.3772	.3086	.3258	.2972	1.3108	1.9719	1.406
Max	3.0864	3.0521	2.834	2.0243	3.1207	2.7949	2.8502
Min	.1715	.1372	.1715	.1486	.1715	.1429	.2229
Avg	1.3756	1.3460	1.2178	.4345	1.4061	2.0547	1.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 201 / DASUR PATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.9907	1.2803	1.3717	.0914	.1067	.1067
2	.1219	.9145	1.2955	1.3717	.0914	.1067	.1067
3	.1219	.8383	1.2955	1.448	.0762	.1067	.1067
4	.1524	.9907	1.326	1.5242	.0762	.1372	.0914
5	.1829	1.1888	1.3717	1.5242	.1067	.1543	.1067
6	.1981	1.448	1.4175	1.5546	.1372	.1524	.1219
7	.1829	1.4937	1.7223	1.6766	.1372	.2058	.1219
8	.1372	1.6766	1.7833	1.5546	.1067	.1372	.1067
9	.1219	1.6004	1.7528	1.5242	.1067	.1372	.1067
10	1.2955	.0914	.061	.1219	1.3565	1.3717	1.2803
11	1.6766	.0914	.061	.061	1.7223	1.6004	1.6918
12	1.6461	.0762	.061	.061	1.7223	1.6918	1.5242
13	1.6766	.1067		.0762	1.7528	1.6004	1.6766
14	1.6461	.0762	.0762	.0762	1.6766	1.5394	1.7375
15	1.7528	.0762	.061	.0762	1.4175	1.5242	1.6918
16	1.829	.0762	.0914	.0914	1.7375	1.6004	1.768
17	1.829	.0914	.061	.1067	1.5546	1.5242	1.4937
18	.1219	.1067	.1029	.061	.12	.1219	.1372
19	.1219	.1524	.1715	.1524	.1372	.1372	.1829
20	.1067	.1372	.1715	.1677	.1372	.1524	.2058
21	.1067	.1067	.1372	.1524	.1372	.1372	.1715
22	.1219	.1067	.1029	.1067	.12	.1219	.1372
23	.1219	.1067	.1029	.1067	.12	.1219	.1372
24	.1372	.9907	1.1888	1.2193	.0914	.12	.1067
Max	1.829	1.6766	1.7833	1.6766	1.7528	1.6918	1.768
Min	.1067	.0762	.061	.061	.0762	.1067	.0914
Avg	.6478	.5639	.6824	.6744	.6139	.6087	.6216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 202 / 11 KV NANAWARE WASTI

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1279	.823		.3772	.7926	1.1279	.9907
2	1.1279	.7926	.7316	.3944	.8383	1.1126	1.1431
3	1.1584	.7926	.7164	.3944	.8688	1.1431	1.1431
4	1.2193	.7621	.6859	.4287	.9145	1.1431	1.1888
5	1.2498	.7316	.6554	.5144	1.0364	1.1888	1.2651
6	1.5851	.6859	.381	.5658	1.0974	1.2041	1.3717
7	1.829	.6706		.6516	1.1888	1.3108	1.4022
8	1.89			.4287	1.2193	1.2041	1.3717
9	1.8595			.3429	1.2346	1.2193	1.2955
10	.1372	1.2955	1.2803	.823	.1543	.1829	.1219
11	.3048	1.8595	1.8595	1.2498	.2058	.2286	.1524
12	.381	1.89	1.9052	1.3108	.2572	.2439	.2134
13	.4572	1.9357	1.9204	1.2955	.2591	.2591	.2134
14	.5487	1.9357	1.9509	1.2651	.2743	.2591	.2134
15		1.9357	1.9509	1.2346	.1372	.2743	.1829
16		1.9052		1.2498	.2572	.2743	.2743
17			1.2803	1.2955	.3429	.381	.3048
18		.2286	.5144	.1829	.463	.4572	.4801
19	.9145	.7926	.5144	.3201	.5144	.5639	.5144
20	.9145	.8535	.4973	.381	.5144	.5335	.4801
21	.9297	.7621	.4801	.3353	.4801	.4572	.4458
22	.9145	.7926	.4458	.3201	.4801	.5335	.3772
23	.8383	.8078	.4287	.3048	.4287	.4268	.3429
24	1.0212	.8383	.8383	.3944	.7164	1.1279	.8383
Max	1.89	1.9357	1.9509	1.3108	1.2346	1.3108	1.4022
Min	.1372	.2286	.381	.1829	.1372	.1829	.1219
Avg	1.0204	1.0996	1.0019	.6692	.6115	.7024	.6803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 203 / 11 KV BHIMA NADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8383	.8535	.9907			
2		.7621	.8535	1.0364			
3		.7621	.884	1.0669			
4		.8383	.884	1.0669			
5		.945	.9145	1.0974			
6		1.0364	.9907	1.1584			
7		1.0974	1.1736	1.2193			
8		1.0669	1.1888	1.1584			
9		1.0212	1.2041	1.1888			
10	.884				.9907	.8535	.884
11	.9907				1.1126	1.1431	1.1126
12	1.0974				1.1126	1.1431	1.2193
13	1.1431				1.1279	1.1431	1.1126
14	1.1736				1.1279	1.1584	1.0669
15	1.2193				1.0059	1.1431	.9907
16	1.2193				1.1736	1.1431	1.0517
17	1.2498				1.1888	1.1431	1.0974
24		.8535	.8535	.823			
Max	1.2498	1.0974	1.2041	1.2193	1.1888	1.1584	1.2193
Min	.884	.7621	.8535	.823	.9907	.8535	.884
Avg	1.1222	.9221	.9800	1.0806	1.105	1.1088	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 201 / 11KV JADHAVWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2949	.3052	.2949	1.4091	1.4419	1.5729
2	.2949	.2743	.2785	.2949	1.2498	1.3108	1.5402
3	.3113	.3113	.2949	.2915	.2743	.3052	.2949
4	.3277	.3048	.2949	.2915	.2743	.2949	.2915
5	.3277	.3048	.3277	.3239	.2743	.3113	.3277
6	.3441	.3563	.3441	.3563	.2896	.3113	.3441
7	.2949	.3048	.2949	.3077	.2896	.3222	.3277
11	2.4086	2.2558	2.2283				
12	2.3758	2.2447	2.13				
13	2.2939	2.0645	1.8652				
14	2.13	1.9334	1.9006				
15	2.0243	1.9498	1.9498				
16	1.9433	1.9334	2.0517				
17	1.9109	1.8023	1.9989				
18	1.8623	1.4746	1.7695				
19	.2753	.2622	.2785	2.4453	2.4249		2.5396
20	.3239	.2785	.2785	2.2672	2.2939		2.0972
21	.3239	.2785	.2785	1.9433	2.2611		1.8679
22	.3239	.2458	.2622	1.7004	1.6549		1.9334
23	.2915	.2785	.2622	1.5384	1.6057		1.7204
24	.2915	.2949	.2949	.2785	1.2803	1.6448	1.6385
Max	2.4086	2.2558	2.2283	2.4453	2.4249	1.6448	2.5396
Min	.2753	.2458	.2622	.2785	.2743	.2949	.2915
Avg	.9986	.9261	.9376	.9488	1.1986	.7428	1.2689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 202 / 11KV CHAUR WASTI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.6154	.6226	.6783	.7621	.8192	.7449
2	.5344	.5487	.5735	.6613	.7468	.8192	.7537
3	2.2996	2.1643	2.2939	2.4078	.5792	.8029	.7537
4	2.5263	2.3777	2.5265	2.6452	.5487	.8029	.7865
5	2.7206	2.5606	2.4905	2.9504	.6859	.8192	.8192
6	2.834	2.5758	2.7854	3.3065	.7773	.8192	.852
7	2.6235	2.6216	2.9984		.6859	.7865	.7537
8	2.4615	2.4996	3.2278				
9		2.3167					
10			2.0317				
11						3.4082	3.3425
12					3.1131	3.2769	
13					2.8654	3.3404	3.2769
14					2.8197	3.2047	3.3425
15					2.9492	3.0803	3.0967
16					2.8346	3.1539	3.0476
17					2.7854	3.1369	3.0312
18					2.6543		2.7362
19	.5898	.6062	.7373	.8259	.6718		.8192
20	.5898	.6154	.7537	.8259	.7373		.8097
21	.6226	.6478	.78	.8907	.7537		.8097
22	.6226	.6316	.7373	.8583	.8029		.8259
23	.6478	.6316	.6882	.8097	.8192		.8259
24	.6154	.6554	.6554	.6882	.8356	.8192	.7537
Max	2.834	2.6216	3.2278	3.3065	3.1131	3.4082	3.3425
Min	.5344	.5487	.5735	.6613	.5487	.7865	.7449
Avg	1.4472	1.4712	1.5935	1.4624	1.4714	1.9393	1.6091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 203 / 11KV SIDACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1829		.1781	1.9204	2.3266	2.4577
2	.1943	.1781		.1781	2.1338	2.1464	2.3967
3	.1943	.1781		.1619	.2286	.1966	.1638
4	.1943	.1677		.1619	.2134	.1966	.1943
5	.1943	.1524		.1943	.2134	.2294	.1966
6	.2105	.1524		.1943	.2439	.2458	.2294
7	.1619			.1781	.2286	.2294	.1781
9	2.7692						
10	2.8988						
11	2.7692	2.774	3.0312				
12	2.8988	3.0476	3.0352				
13	2.9473	3.1295	2.7362				
14	2.915	3.1459	2.6282	.2458			
15	2.8988	.6882	2.6658				
16	2.8826	.3605	2.8656				
17	2.7854	2.3967	3.0013				
18	2.6052	2.4453	2.3922	2.3922			
19	.213	.1829	.2294	2.7368	2.8182		2.9165
20	.213	.2105	.2294	2.672	2.6235		2.9492
21	.2294	.2267	.2458	2.6235	2.5587		.2458
22	.2294	.1943	.2458	2.5587	2.5396		.2134
23	.1966		.1966	2.332	2.4905		.2134
24	.1943	.2035		.1943	1.89	2.4249	2.4905
Max	2.9473	3.1459	3.0352	2.7368	2.8182	2.4249	2.9492
Min	.1619	.1524	.1966	.1619	.2134	.1966	.1638
Avg	1.3474	1.0535	1.8079	1.1335	1.5464	.9995	1.1420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 204 / 11KV DEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2944	1.2955	1.2944	1.6712	.1677	.1802	.1619
2	1.278	1.326	1.278	1.6385	.1829	.1966	.1619
3	.1802	.1677	.1802	.1619	.7926	1.278	1.2631
4	.1802	.1677	.1802	.1619	1.0059	1.3108	1.3603
5	.1943	.1829	.1966	.1966	1.2193	1.4091	1.4575
6	.2294	.1981	.2294	.2429	1.4327	1.4582	1.587
7	.1802	.1829	.1802	.1638	1.6221	1.6712	1.7004
8	1.278				1.6766	1.6876	1.8785
9					1.5851	1.7532	1.9109
10					1.4784	1.7204	
19	1.7328	1.8299		.1802	.1966		.1966
20	1.7004	1.7814		.1802	.1802		.1981
21	1.6194	1.4937		.1802	.1802		.2134
22	1.4575	1.5565		.1802	.1638		.1981
23	1.3765	1.4582		.1638	.1638		.1981
24	1.3108	1.3108	1.3108	1.7204	.1524	.1638	.1943
Max	1.7328	1.8299	1.3108	1.7204	1.6766	1.7532	1.9109
Min	.1802	.1677	.1802	.1619	.1524	.1638	.1619
Avg	1.0009	.9963	.6062	.5263	.7625	1.1663	.8453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 205 / 11KV MALSHIRAS URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3108	1.278	1.406	1.3927	1.3565	1.4575
2	1.3375	1.2944	1.2616	1.3375	1.2289	1.3226	1.3889
3	1.3032	1.2452	1.278	1.3717	1.3108	1.4419	1.4403
4	1.3717	1.3565	1.3927	1.4403	1.2803	1.5091	1.4746
5	1.4746	1.4091	1.4746	1.5089	1.4922	1.5261	1.5432
6	1.5947	1.56	1.4419	1.6289	1.4582	1.5939	1.6118
7	1.5261	1.2944	.1311	1.6118	1.491	1.5091	1.6118
8	1.3546	1.1961	1.2548	1.4746	1.3272	1.3395	1.4575
9	1.286	1.2289			1.3435	1.278	1.3375
10	1.3032	1.2452	1.491	1.286	1.3435	1.3395	
11	1.2174	1.1797	1.2289	1.286	1.2616	1.3226	1.3032
12	1.1831	1.1469	1.2125		1.1961	1.2452	
13	1.1317	1.0978	1.1633	1.2517	1.1469	1.1797	1.2689
14	1.0288	1.065	.9995	1.1145	1.1142	1.1305	1.2517
15	1.046	1.1191	1.0322	1.1488	1.065	1.0978	1.2346
16	1.046	1.0814	1.0978		1.0486	1.1305	1.286
17	1.2003	1.153	1.1142		1.153	1.2209	1.3546
18	1.3203	1.1869	1.2289	1.3717	1.2289		1.3889
19	1.406	1.6108	1.3927	1.4918	1.3927		
20	1.5261	1.56	1.5565	1.4575	1.4746		1.6804
21	1.6118	1.4582	1.5074	1.5432	1.5565		1.6461
22	1.6461	1.543	1.5238	1.6289	1.6221		1.6118
23	1.5432	1.5261	1.4746	1.5432	1.5402		1.5432
24	1.4403	1.4243	1.3763	1.4746	1.4752	1.4922	1.5089
Max	1.6461	1.6108	1.5565	1.6289	1.6221	1.5939	1.6804
Min	1.0288	1.065	.1311	1.1145	1.0486	1.0978	1.2346
Avg	1.3446	1.3039	1.2571	1.4189	1.3310	1.3353	1.4477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 206 / 11KV Medad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3658	.3932	.3887	.3048	.3768	.3932
2	.3932	.3506	.3768	.3887	.3506	.4096	.3932
3	1.8023	1.6766	1.8821	1.6518	.3658	.426	.4049
4	1.9006	1.768	2.0517	1.7814	.3963	.4588	.4588
5	1.9433	1.829	2.2382	1.9109	.4268	.4588	.4588
6	1.9757	1.6309	2.2939	2.1862	.4725	.4752	.5243
7	2.4129	1.9204	2.4249	2.4291	.381	.3605	.3563
8	2.3805	1.9052	2.3758	2.332			
9		1.9052		1.9433			
10		1.9204	1.704	1.7814			
11					2.3167	2.8147	2.5587
12					2.4577	2.556	2.556
13					2.3266	1.9826	2.1136
14					2.1792	1.7859	1.7859
15					2.0972	1.8023	1.7166
16					1.704	1.8679	1.7814
17					1.8023	1.917	1.8461
18					1.8515		1.9498
19	.4096	.3963		.3887	.3605		.2949
20	.421	.3963		.3887	.3506		.3113
21	.421	.381		.3887	.3768		.3963
22	.3887	.381		.3887	.3768		.381
23	.3887	.3658		.3239	.3277		.381
24	.3887	.3658	.3932	.3887	.3277	.3277	.4096
Max	2.4129	1.9204	2.4249	2.4291	2.4577	2.8147	2.5587
Min	.3887	.3506	.3768	.3239	.3048	.3277	.2949
Avg	1.1157	1.0974	1.6134	1.1913	1.0263	1.2013	1.0225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 207 / 11KV TARANGFAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4915	.4915	.4915	.4572	.4588	.4534
2		.4752	.4915	.4915	.4915	.4752	.4534
3		1.0159	1.1305	1.1142	1.1012	1.278	1.085
4		1.0364	1.1961	1.1797	1.0974	1.4582	1.1934
5		1.0974	1.278	1.3108	1.2193	1.3565	
6		1.2944	1.3599	1.4582	1.2498	1.3565	1.326
7		1.3763	1.4582	1.6057	1.4022	1.4255	1.3927
8		1.3272	1.3763	1.491	1.3717	1.4243	1.3765
9	1.2125	1.1279		1.3927	1.1961	1.278	1.1012
10		1.0517	1.7532	1.1797	1.1305	1.0486	
11	1.491	1.4022	1.278		1.6108	1.17	1.2955
12	1.5565	1.448	1.3599		1.5074	1.1797	1.3927
13	1.6549	1.5089	1.4582		1.4746	1.278	1.4251
14	1.6057	1.4937	1.5769		1.4419	1.4413	1.3765
15	1.5565	1.4251	1.5074		1.4582	1.4582	
16	1.491	1.3763	1.491		1.5565	1.56	1.1984
17	1.3765	1.3441	1.4582		1.3717	1.6057	1.166
18	1.2793	1.2498	1.278		1.3763		1.1336
19	.3725	.3768	.4424	.3932	.4191		.4424
20	.4858	.4268	.4424	.426	.4359		.4268
21	.5182	.442	.4588	.4588	.4359		.4752
22	.4858	.4268	.4752	.4752	.4694		.4752
23	.4858	.4572	.4752	.4588	.4588		.4588
24		.4915	.4915	.4915	.4588	.4588	.4534
Max	1.6549	1.5089	1.7532	1.6057	1.6108	1.6057	1.4251
Min	.3725	.3768	.4424	.3932	.4191	.4588	.4268
Avg	1.1123	1.0068	1.0751	.9012	1.0497	1.2062	.9572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 208 / 11 KV TARANGFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431	.4534	.4748	.4641	.4268	.4752	.431
2	.0332	.4534	.4752	.4641	.4268	.4588	.431
3	.431	.421	.4588	.4641	.4572	.4752	.431
4	.4641	.426	.4752	.4973	.4877	.4915	.4641
5	.4973	.4858	.4915	.4973	.5182	.5735	.4973
6	.5304	.5506	.5256	.547	.5335	.6226	.6299
7	.4973	.381	.4424	.4475	.442	.5256	.4973
8	.3647	.3353	.3277	.3315	.3963	.4424	.4144
9	.3315	.2743		.2486	.3048	.3605	.3647
10	.2818	.1981		.2818	.2896	.1638	
11	.2486	.2134	.2458		.2286	.1865	.2818
12		.2294	.2458		.2294	.1696	.2486
13	.2321	.213	.2294	.2321	.213	.1696	.2155
14	.2321	.213	.2374	.1989	.2035	.1475	.2155
15	.2652	.2294	.2458	.1989	.1802	.1802	.2155
16	.2818	.2458	.2785	.2486	.213	.1638	.1989
17	.2984	.2743	.3052	.2984	.2294	.1966	.2321
18	.3315	.3201	.3277	.3315	.2785		.2984
19	.431	.4424	.4915	.4641	.4424		.4424
20	.431	.4424	.5243	.4641	.4588		.4572
21	.4475	.4268	.4915	.4807	.4752		.5079
22	.4641	.4588	.4424	.4807	.4858		.4572
23	.4807	.4268	.4424	.4973	.4752		.4752
24	.4641	.4696	.4588	.4475	.4572	.4915	.4475
Max	.5304	.5506	.5256	.547	.5335	.6226	.6299
Min	.0332	.1981	.2294	.1989	.1802	.1475	.1989
Avg	.3683	.3577	.3926	.3903	.3689	.3497	.3850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 209 / 11KV KALE-PANDARE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.3565	1.4582	1.3603	.2439	.2458	.2591
2	1.3272	1.4255	1.4091	1.2308	.2439	.2294	.2591
3	.3401	.3201	.3277	.3239	1.1888	1.3272	1.5384
4	.3401	.3201	.3441	.3239	1.3413	1.3763	1.587
5	.3563	.3353	.3441	.3563	1.3717	1.4582	1.6194
6	.3563	.381	.39	.3887	1.7223	1.6095	1.6518
7	.2753	.3277	.3391	.3239	2.0576	3.0013	1.9989
8					1.8442	1.9662	2.0317
9					1.7985	1.9006	1.9662
10					1.5851	1.8652	
19	2.1792	1.9919	1.9662	.3932	.3077		.3605
20	2.13	1.9334	1.9334	.3605	.2949		.3048
21	2.0481	1.6004	1.8023		.2949		.2743
22	1.7368	1.5089	1.7368	.2785	.2622		.2439
23	1.5729	1.448	1.6385	.2591	.2458		.2439
24	1.4899	1.5074	1.5074	1.5546	.2439	.2458	.2591
Max	2.1792	1.9919	1.9662	1.5546	2.0576	3.0013	2.0317
Min	.2753	.3201	.3277	.2591	.2439	.2294	.2439
Avg	1.2021	1.1120	1.1690	.5961	.9404	1.3841	.9732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 210 / COURT-(GOVT) EXPRESS NON SHEDDABLE WATER SUPPLY AND
 FEEDER Feeder KV- 11 / UTILITY
 OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1475	.1475	.1372	.1296	.1526	.1372
2	.1372	.1372	.1147	.1372	.1296	.1526	.1372
3	.1372	.1372	.1147	.1372	.1296	.1526	.1372
4	.1372	.1372	.1147	.1372	.1372	.1147	.1372
5	.1372	.1475	.1147	.1372	.1296	.1475	.1372
6	.1372	.1372	.1147	.1372	.1296	.1311	.1372
7	.1372	.1372	.1147	.1372	.1372	.1147	.1372
8	.1372	.1372	.1311	.1372	.1296	.1475	.1372
9	.1372	.1372		.1372	.1219	.1475	.1372
10		.1372	.1311	.1372	.1219	.1357	
11		.1372	.1265	.1372	.1219	.1475	.1372
12		.1147	.1357	.1372	.1296	.1475	.1372
13		.1147	.1147	.1372	.1311	.1475	.1372
14		.1147	.1147	.1372	.1372	.1475	.1372
15		.1357	.1311	.1372	.1457	.1357	.1372
16			.1475		.1457	.1526	.1372
17			.1311		.1475	.1357	.1372
18			.1311		.1475		.1372
19		.1457	.1475		.1475		.1372
20		.1475	.1147		.1475		.1372
21		.1457	.1311		.1475		.1372
22		.1457	.1311		.1475		.1372
23		.1457	.1475		.1475		.1372
24	.1372	.1475	.1311	.1372	.1296	.1357	.1372
Max	.1372	.1475	.1475	.1372	.1475	.1526	.1372
Min	.1372	.1147	.1147	.1372	.1219	.1147	.1372
Avg	.1372	.1375	.1275	.1372	.1362	.1415	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 201 / 11KV KANHER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1638	.1875	.1781	1.1174	1.7814	1.4842
2	.1619	.1638	.1875	.1781	1.166	1.8947	1.5623
3	.1781	.1802	.1875	.1943	1.3279	1.9595	1.7185
4	.1781	.1966	.1875	.2105	1.4575	2.0243	1.9528
5	.1781	.213	.1875	.2105	1.9109	2.1052	2.1091
6	.1943	.1966	.1875	.2105	2.0081	2.2186	2.2184
7	.1943	.1966	.2187	.2105	2.2186	2.3482	2.4371
8	.2429	.213	.2187	.2105	2.2024	2.1376	2.0466
9	.1619	.1311	.1718	.2267	.1311	.1875	.1781
10	.1966	.1406		.2294	.1802	.1875	.1457
11	.1475	.1562	.1296		.1802	.1562	.1457
12	.1475	.1406	.1296		.1966	.1562	.0972
13	.1311	.125	.1296		.1966	.125	.1134
14	.1311	.1094	.1296			.1562	.1619
15	.1311	.1094	.1457		.1966	.1562	.1619
16	.1311	.125	.1619		.213	.1718	.1619
17	2.3158	2.234	2.3644		.1802	.1875	
18	2.3482	2.4215	2.5232	.213	.2294	.1406	
19	2.3805	2.1872	2.5069	.213	.213	.1875	
20	2.3482	2.2653	2.4291	.213	.213	.1562	.2458
21	2.2834	2.234	2.3922	.1638	.2294	.1875	.2458
22	2.2186	2.1559	2.2672	.1475	.1966	.1875	.2429
23	2.1214	2.0778	2.2348	.1638	.1966	.1875	.2429
24	1.9919	2.0081	2.0466	2.17	.1638	.1802	.1875
Max	2.3805	2.4215	2.5232	2.17	2.2186	2.3482	2.4371
Min	.1311	.1094	.1296	.1475	.1311	.125	.0972
Avg	.8615	.8394	.9272	.3143	.7098	.7992	.8505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 202 / 11KV ISLAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.6194	1.5384	1.7814	.1475	.1802	.2187
2	1.9757	1.7004	1.6194	1.8138	.1638	.1802	.2187
3	1.9757	1.8623	1.749	1.8138	.1638	.1966	.2187
4	2.1052	2.0405	1.8623	2.0243	.1802	.213	.2187
5	2.1538	2.2672	1.9433	2.0567	.213	.2294	.2343
6	2.2348	2.3967	2.0567	2.1862	.2294	.2622	.25
7	2.2186	2.6235	2.5749	2.3102	.2294	.2622	.2187
8	2.5101	2.5101	2.5749	2.3158	.2294	.1966	.2187
9	2.2024	2.3482	2.4129	2.251	.1802	.1562	.1943
10	.1147	.0972	.0972	.1147	.0983	1.8299	1.4575
11	.1311	.1094	.081		2.672	2.4777	2.3805
12	.1311	.1562	.1296		2.6397	2.5911	2.5101
13	.1147	.125	.1457		2.753	2.6397	2.4453
14	.1147	.125	.1619		2.2996	2.4615	2.2672
15	.1147	.1562	.1619		2.3482	2.4615	2.2996
16	.1147	.1562	.1619		2.3967	2.4939	2.3158
17	.1147	.1562	.1296		2.2996	2.17	2.2672
18	.1311	.1406	.1781	.1147	.0819	.1094	.1475
19	.1475	.1562	.213	.1802	.1802	.1718	.2622
20	.1802	.1875	.213	.2294	.213	.2343	.2785
21	.213	.1718	.1966	.1802	.213	.2031	.2622
22	.213	.1562	.1943	.1638	.213	.2187	.2591
23	.1802	.1406	.1943	.1638	.1966	.2187	.2429
24	1.5223	1.587	.1457	1.6194	.1475	.1802	.2187
Max	2.5101	2.6235	2.5749	2.3158	2.753	2.6397	2.5101
Min	.1147	.0972	.081	.1147	.0819	.1094	.1475
Avg	.9524	.9579	.8640	1.2541	.8537	.9308	.9002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 203 / 11KV MANAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.7773	.9282	1.0526	.2785	.2622	.2343
2	1.004	.8097	1.0082	1.1498	.2622	.2622	.2343
3	1.1012	.9878	1.1203	1.1498	.2622	.2622	.2343
4	1.4575	1.2308	1.4403	1.2631	.2785	.2785	.2343
5	1.5384	1.587	1.7185	1.4575	.2949	.2785	.2656
6	1.8947	2.17	1.9685	1.7652	.2949	.2949	.2968
7	2.17	2.4129	2.0622	2.0081	.2949	.2622	.2656
8	1.6194	1.7004	1.4217	1.4251	.2622	.2458	.2968
9		.1966	.1562	.2105	2.0243	1.906	1.8461
10	.1638	.1562	.1457	.1802	2.1862	1.906	1.8623
11	.1475	.1406	.1134		1.9433	1.8435	1.8138
12	.1475	.1562	.1619		1.7166	1.6248	
13	.1638	.1406	.1619		1.7004	1.4373	1.6194
14	.1638	.1562	.1619		1.7004	1.2654	1.4737
15	.1638	.1562	.1457		1.5708	1.4529	1.4575
16	.1638	.1718	.1457		1.4575	1.4217	1.3927
17	.1802	.1718	.1943		.1475	.125	
18	.1966	.1718	.1966	.213	.1802	.125	
19	.1966	.2031	.2294	.2458	.1966	.2343	
20	.2294	.2343	.2294	.2785	.2785	.2187	.2949
21	.2458	.2343	.2622	.2785	.2458	1.1946	.2785
22	.2458	.2343	.2591	.2622		.2343	.2753
23	.2458	.25	.2429	.2622	.2622	.2343	.2753
24	.2429	.2458	.25	.2105	.2785	.2622	.2343
Max	2.17	2.4129	2.0622	2.0081	2.1862	1.906	1.8623
Min	.1475	.1406	.1134	.1802	.1475	.125	.2343
Avg	.6343	.6123	.6135	.7890	.7877	.7347	.7443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 204 / ISLAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.0679	1.086	.9717	1.0498	1.0631	1.086
2	1.004	1.086	1.086	1.0526	1.086	1.0808	1.086
3	1.1012	1.1041	1.1765	1.1012	1.1222	1.1163	1.1765
4	1.2631	1.2489	1.3575	1.2146	1.2489	1.2048	1.267
5	1.3765	1.3756	1.448	1.3117	1.3756	1.3466	1.448
6	1.3927	1.4661	1.5565	1.4575	1.4661	1.5947	1.5746
7	.9393	1.1946	1.1403	1.0526	1.1765	1.1517	1.1765
9	.8907	1.0136	.9774	.8907	.9412	.9412	.8745
10	.8507	.8507	.7611	.8507	.7796	.8688	.8259
11	.7421	.724	.7935	.7783	.6556	.7602	.7287
12	.6878	.6878	.664	.724	.5847	.7059	.6478
13	.6516	.6154	.6478	.7421	.6201	.724	.583
14	.5792	.6154	.5668	.6878	.5847	.5973	.5668
15	.6154	.6154	.583	.6516	.6024	.6335	.5992
16	.6335	.6516	.5992	.724	.6379	.5992	.6154
17	.6697	.7602	.5992	.7602	.7087	.6878	.6964
18	.7783	.7964	.6718	.8688	.815	.6878	.852
19	1.1946	1.1041	.9012	1.3756		1.1584	1.0526
20	1.2489	1.448	1.065	1.4118	1.3643	1.4118	1.2616
21	1.2127	1.1946	1.0814	1.2489	1.2048	1.4118	1.0978
22	1.1403	1.1946	1.0364	1.086	1.1517	1.1403	1.0526
23	1.1222	1.1584	1.004	1.0679	1.0808	1.086	1.004
24	.9717	1.086	1.086	.9717	1.0136	1.0454	1.086
Max	1.3927	1.4661	1.5565	1.4575	1.4661	1.5947	1.5746
Min	.5792	.6154	.5668	.6516	.5847	.5973	.5668
Avg	.9582	1.0026	.9517	1.0001	.9668	1.0008	.9721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 205 / GORADWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.4915	.5468	.583	.4424	.4915	.5937
2	.5182	.4915	.5468	.583	.4424	.4915	.5937
3	.5506	.5243	.5468	.6154	.4752	.5079	.5937
4	.5668	.5243	.5624	.6154	.4915	.5243	.5937
5	.583	.5571	.6093	.6316	.5079	.5407	.6249
6	.583	.5407	.6249	.6478	.5735	.5407	.6405
7	.502	.5243	.5937	.6316	.6062	.5898	.6562
8	.3887	.4588	.4062	.5182	.5735	.5243	.5468
9	3.2065	3.1093	2.8589	.4534	.4752	.4687	.5344
10	3.1579	3.0933	3.0607	.4588	.4752	.4687	.3887
11	3.1741	2.9683	3.2874		.4752	.4374	
12	3.0283	2.9214	3.3198		.4915	.4687	2.6073
13	2.8178	2.7027	3.2065		.4915	.4843	
14	2.7368	2.7183	2.834		.4915	.2968	
15	2.6558	2.5777	2.6235		.4915	.2812	.2105
16	2.5749	2.4215	2.3644		.3932	.2812	.2429
17	.3277	.25	.2753		3.2874		3.417
18	.4424	.3281	.3768	3.2712	3.2712		3.4818
19	.5243	.4687	.5079	3.2874	.2429		.3932
20	.5079	.4687	.5407	3.1741	3.0769	3.1245	.3768
21	.4915	.4999	.5868	3.1579	3.2712	.4687	.3768
22	.5243	.5312	.5668	3.1093	3.0769	.578	.3887
23	.4915	.5468	.5668	2.9312	2.915	.5937	.4049
24	.502	.5079	.5468	.583	2.5425	2.6397	.5937
Max	3.2065	3.1093	3.3198	3.2874	3.2874	3.1245	3.4818
Min	.3277	.25	.2753	.4534	.2429	.2812	.2105
Avg	1.3073	1.2594	1.3317	1.4854	1.2326	.7049	.8695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 206 / SARGARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.2785	.2812	.2591	1.1012	1.2146	1.1336
2	.2915	.2785	.2812	.2591	1.1336	1.3441	1.2146
3	.3239	.2949	.2968	.2915	1.1336	1.4575	1.2955
4	.3401	.3113	.2968	.3563	1.2308	1.5546	1.4575
5	.3401	.3113	.3437	.3725	1.4413	1.7328	1.7814
6	.3563	.3277	.3749	.3887	1.7814	1.8623	1.9109
7	.2915	.3441	.3437	.3563	2.1214	2.1862	2.0567
8	.2429	.2622	.25	.2267	1.9919	1.8623	1.8299
9	.2105	.2294	.2031	.1943	1.8299	1.7654	1.4251
10	.9878	.9231	1.1822	.1638	.1638	.1094	.1134
11	1.6842	1.9595	1.749		.1475	.125	.1134
12	1.7814	1.8138	1.7814		.1475	.1406	.0972
13	1.7328	1.668	1.749		.1311	.125	.1134
14	1.6518	1.6356	1.7166		.1475	.125	.1457
15	1.6032	1.6194	1.7004		.1475	.125	.1457
16	1.5384	1.5384	1.6842		.1475	.125	.1296
17	1.5708	1.5384	1.6518		.1475	.125	.1457
18	.1966	1.4899	.1802	.1966	.1475	.1406	.1475
19	.2458	.2187	.2458	.213			.2105
20	.2622	.2343	.2458	.2294	.2294	.2656	.2622
21	.2622	.25	.2458	.2622	.2622	.2656	.2785
22	.2622	.2656	.2429	.2622	.2785	.2656	.2753
23	.2785	.2656	.2591	.2622	.2622	.2656	.2591
24	.2753	.2785	.2812	.2591	.9717	1.0202	.2753
Max	1.7814	1.9595	1.7814	.3887	2.1214	2.1862	2.0567
Min	.1966	.2187	.1802	.1638	.1311	.1094	.0972
Avg	.7086	.7640	.7328	.2678	.7433	.7914	.7007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 201 / DESHMUKH PATTA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1981	.2286	.2347	.9431	.7926	.7621
2	.2401	.1981	.2591	.2683	.9945	.8383	.7926
3	.2401	.1981	.2286	.2683	1.0288	.945	.8535
4	.2743	.1981	.2286	.3018	1.1145	1.0364	.945
5	.2743	.1981	.2286	.3185	1.166	1.1888	1.0669
6	.2915	.1981	.2134	.3521	1.4746	1.3108	1.1888
7	.3086	.1981	.2134	.3185	1.8176	1.448	1.4327
8	.2058	.1829	.1829	.2347	1.9204	1.7071	1.5851
9					1.8519	1.4327	1.5242
10	1.1488	.9907					
11	1.5242	1.3717	1.6766	1.406			
12	1.4937	1.4022	1.643				
13	1.4632	1.2955	1.6095				
14	1.4327	1.326	1.5089				
15	1.4022	1.4327	1.4586				
16	1.4022	1.4632	1.4419				
17	1.3717	1.387	1.4251				
18			1.358				
19	.1829	.1677	.2012	.2229	.2134	.2286	.218
20	.2134	.1677	.218	.2401	.2286	.2286	.2347
21	.1981	.1829	.2012	.2401	.2286	.2286	.2347
22	.1981	.1829	.2012	.2572	.1829	.2134	.218
23	.1981	.1829	.2012	.2401	.2134	.1981	.218
24	.2401	.1981	.2012		.9259	.7621	1.0059
Max	1.5242	1.4632	1.6766	1.406	1.9204	1.7071	1.5851
Min	.1829	.1677	.1829	.2229	.1829	.1981	.218
Avg	.6611	.6055	.6877	.3502	.9536	.8373	.8187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 202 / 11KV UMBARE DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0364	1.0212	1.326	.3429	.2896	.3048
2	1.166	1.1431	1.1584	1.4918	.3429	.2896	.3048
3	1.2174	1.2803	1.2803	1.5746	.3429	.3353	.3048
4	1.286	1.4632	1.5089	1.6575	.3258	.3201	.2896
5	1.7147	1.6461	1.6613	1.7404	.3086	.2896	.2896
6	1.9204	2.0271	1.8138	1.989	.3086	.2896	.2591
7	2.4177	2.2862	2.0576	2.1548	.3086	.2896	.2743
8	2.4691	2.0576	2.271	2.3205	.3086	.2591	.2591
9	2.2291	1.829		1.5927			
10				1.5089	.823		1.2955
11					1.5851	1.9052	2.1795
12					2.0119	1.6461	2.0119
13					1.5546	1.5546	1.8442
14					1.5242	1.5242	1.6766
15					1.4632	1.5242	
16					1.4327	1.4937	1.643
17					1.4784	1.5699	1.5089
18							1.4754
19	.2743	.2743	.285	.2915	.2134	.3048	.2321
20	.2896	.2896	.3018	.2915	.2286	.3201	.2984
21	.3048	.2591	.3018	.3086	.2439	.3353	.3149
22	.3201	.2591	.3018	.3258	.2439	.3353	.2984
23	.3201	.2896	.3018	.3086	.2743	.3201	.3315
24	1.1145	.9602	1.2431		.3429	.3048	.3521
Max	2.4691	2.2862	2.271	2.3205	2.0119	1.9052	2.1795
Min	.2743	.2591	.285	.2915	.2134	.2591	.2321
Avg	1.2117	1.1401	1.1077	1.2588	.7277	.7381	.8068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 203 / KHANDOBA WASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.7621	.7316	.9831	.2229	.2134	.2134
2	.9259	.823	.8078	1.065	.2401	.2286	.2134
3	.9431	.884	.8688	1.1469	.2401	.2286	.2134
4	1.046	.945	1.0364	1.2289	.2401	.2134	.2134
5	1.1145	1.0669	1.1584	1.3763	.2572	.2134	.2134
6	1.2174	1.2803	1.2346	1.3763	.2743	.2134	.2134
7	1.3889	1.4937	1.326	1.6712	.2915	.2591	.2286
8	1.8004	1.7071	1.4022	1.5565	.2058	.2591	.1677
9	1.3889	1.4175		1.3279			
10				1.2452	.7716		.884
11					1.1584	1.4175	1.3765
12					1.4022	1.3717	1.3765
13					1.326	1.3108	1.3108
14					1.2803	1.2955	
15					1.2498	1.2803	.9717
16					1.2041	1.2498	1.004
17					1.1279	1.2193	1.2146
19	.1981	.2286	.2321	.2401	.1981	.2286	.2267
20	.2286	.2286	.2321	.2401	.1829	.2286	.3077
21	.2439	.2134	.2321	.2401	.1981	.2286	.2591
22	.2439	.1981	.2321	.2401	.2134	.2134	.2429
23	.2286	.1829	.1966	.2229	.1829	.2134	.213
24	.8745	.7316	.8097		.2229	.1829	.2105
Max	1.8004	1.7071	1.4022	1.6712	1.4022	1.4175	1.3765
Min	.1981	.1829	.1966	.2229	.1829	.1829	.1677
Avg	.8501	.8109	.7500	.9440	.5768	.5843	.5369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 204 / 11KV KACHAREWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.1067	.2134	.2622	.3086	.2743	.1158
2	.2915	.1097	.2439	.2622	.3086	.2743	.1189
3	.3086	.1158	.2439	.2785	.3086	.2743	.1219
4	.3086	.1189	.2439	.2949	.3258	.2439	.125
5	.3429	.128	.2743	.2949	.3429	.2134	.1311
6	.3429	.1417	.2743	.3277	.3429	.2134	.1402
7	.3429	.1478	.2439	.2622	.3601	.2134	.1478
8	.2915	.1417	.1829		.3429	.2439	.1402
9	.2401	.1311	.1829	.2321	.2401	.2134	.1372
10	.2058	.125		.2321	.1886	.1524	.1326
11	.0823	.1829	.2486	.2572	.1524	.0762	.1823
12	.0793	.1829	.2486		.1524	.0716	.1989
13	.0762	.1524	.2486	.2058	.1219	.0686	.2012
14	.0716	.1981	.1341	.2058	.1524	.0655	
15	.0686	.1829	.1326	.2229	.1524	.061	.1492
16	.0655	.2134	.1492	.2401	.1524	.064	.1658
17	.0686	.2134	.1823	.2572	.1219	.0716	.2155
18	.0716	.2134	.2012	.2572	.1524	.0762	.2984
19	.0762	.2134	.2486	.2743	.2439	.096	.2785
20	.0884	.2134	.2984	.2915	.2439	.0991	.3277
21	.0945	.2439	.2818	.3086	.2134	.1021	.3277
22	.0975	.2439	.2818	.3258	.2439	.1067	.3113
23	.1006	.2134	.2818	.2915	.2439	.1097	.2818
24	.2915	.1036	.2785		.2915	.2439	.2818
Max	.3429	.2439	.2984	.3277	.3601	.2743	.3277
Min	.0655	.1036	.1326	.2058	.1219	.061	.1158
Avg	.1791	.1682	.2313	.2659	.2378	.1512	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 205 / KAMALMALA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3353	.3048	.3315	1.989	1.7833	1.5851
2	.3429	.3353	.3353	.3481	2.0233	1.89	1.6766
3	.3601	.3201	.3353	.3647	2.0405	2.0881	1.8595
4	.3601	.3201	.3658	.3812	2.0919	2.21	1.9814
5	.3601	.3048	.3506	.4144	2.3663	2.3472	2.21
6	.3772	.3658	.2896	.4144	3.1722	2.5453	2.6673
7	.3772	.3353	.2591	.3481	3.2407	2.6673	2.8045
8	.3086	.2743	.2286	.2915	2.6406	2.6825	
9					3.0864	2.4691	
10	2.2805	1.1888					
11	2.8197	2.8045	2.5888	2.6063			
12	2.7892	2.713	2.5888				
13	2.7435	2.774	2.5692				
14	2.713	2.8502	2.7349				
15	2.6825	2.713	2.7526				
16	2.6216	2.6825	2.7199				
17	2.5606	2.713	2.7035				
18			2.5888				
19	.2896	.3353	.3239	.3601	.2743	.3048	
20	.3353	.3353	.3401	.3601	.2896	.3048	
21	.3658	.3048	.3401	.3601	.3048	.3353	
22	.3658	.2896	.3401	.3429	.2896	.3353	
23	.3506	.2896	.3239	.3429	.2896	.3353	
24	.3429	.3506	.3077		1.9204	1.6613	.1147
Max	2.8197	2.8502	2.7526	2.6063	3.2407	2.6825	2.8045
Min	.2896	.2743	.2286	.2915	.2743	.3048	.1147
Avg	1.1859	1.1334	1.1678	.5190	1.7346	1.5973	1.8624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 206 / TIRWANDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5487	.5944	.6478	.3772	.3353	.2286
2	.6516	.6097	.6706	.7287	.3601	.2896	.2286
3	.6859	.6554	.7468	.8097	.3601	.3048	.2439
4	.6859	.7164	.823	.8907	.3601	.3353	.2439
5	.7716	.7621		.9069	.3429	.3353	.2439
6	.8745	.823	1.0212	.9069	.3429	.3353	.2591
7	1.0288	.884	1.0517	1.1012	.3429	.3048	.2743
8	1.166	.884	.8383	.9116	.2915	.2896	.2439
9	.9088	.7316		.7865			
10				.663	.5144		.5335
11					.7164	.823	
12					.7773	.7316	.7209
13					.6401	.5944	.663
14					.5335	.5792	.5967
15					.6401	.5639	.5243
16					.5944	.5487	.5571
17					.5639	.5335	.5898
18							.5898
19	.2591	.2591		.3086	.2439	.2439	.2753
20	.2743	.2439	.3277	.3086	.2591	.2439	.3441
21	.3048	.2896	.3277	.3258	.2896	.2439	.3277
22	.3048	.3201	.3277	.3429	.3048	.2286	.3113
23	.3048	.3201	.3113	.3429	.3201	.2286	.3277
24	.583	.4877	.5735		.3772	.3201	.3277
Max	1.166	.884	1.0517	1.1012	.7773	.823	.7209
Min	.2591	.2439	.3113	.3086	.2439	.2286	.2286
Avg	.6269	.5690	.6345	.6655	.4342	.4006	.3934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 201 / 11KV LAXMINAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3506	.3733	.3429	1.6613	1.8858	1.7776
2	.3944	.3506	.3911	.3429	1.6613	1.7833	1.8664
3	.3944	.3506	.4088	.3601	1.6766	1.7833	1.9553
4	.4115	.3506	.4444	.3772	1.7223	2.0538	1.9909
5	.4854	.381	.4622	.4287	1.8442	1.9547	2.0442
6	.4801	.442	.4799	.463	2.0881	2.2634	2.0975
7	.5041	.3658	.4266	.4115	2.3167	2.6063	2.3997
8	.3547	.3506	.3555	.2915	2.4387	2.572	2.5952
9	.2591	.2666	.3086	.2286	2.452	2.3464	2.332
10	1.5851	1.6887	1.8004	1.6461	.1867	.3377	.1715
11	1.9966	1.9553	2.4348		.1715	.3022	.2058
12	2.1033	2.3286	2.452		.1867	.2666	.2229
13	1.7985	2.2219	2.3663		.1715	.2133	.2058
14	1.7833	2.1508	2.1948		.1715	.1422	.1886
15	1.6156	2.0975	2.1434		.1715	.1778	.2058
16	1.6461	2.062	2.1948		.1886	.1778	.2229
17	1.768	2.0264	2.1434		.2058	.1955	.2229
18	.1219	.3555	.12	.1829	.2614	.2133	.2572
19	.2286	.3911	.3429	.3201	.3086	.2311	.3944
20	.3658	.4088	.4115	.3201	.3258	.2666	.4287
21	.3506	.4266	.3944	.3201	.3258	.3022	.4115
22	.3506	.4088	.3601	.3048	.3258	.3022	.3601
23	.3506	.3911	.3258	.3048	.3086	.32	.3601
24	.4294	.3506	.3733	.3429	1.6156	1.6804	1.6887
Max	2.1033	2.3286	2.452	1.6461	2.452	2.6063	2.5952
Min	.1219	.2666	.12	.1829	.1715	.1422	.1715
Avg	.8405	.9363	.9878	.4111	.9494	1.0157	1.0252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 202 / 11KV GIRVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.4575	1.5838	1.2146	.4973	.5658	.559
2	1.4403	1.4575	1.6583	1.2146	.4973	.6722	.5404
3	1.4403	1.4746	1.7701	1.2631	.4973	.6173	.5217
4	1.5432	1.5261	1.8074	1.2955	.4973	.6344	.559
5	1.6118	1.7147	1.8633	1.4899	.5144	.6344	.5963
6	2.0911		1.8819	1.6356	.5316	.7468	.6708
7	2.4006	2.332	2.3291	2.0081	.3772	.5316	.6149
8	2.1434	2.1605	2.4595	1.7652		.4854	.4658
9	1.6975	1.9564	1.7652	1.5604	.3944	.3727	.2915
10	.2401	.3727	.2105	.2401	1.6461	1.6956	1.4575
11	.3429	.3354	.2915		2.452	1.7701	2.17
12	.3086	.2981	.3077		2.6139	1.826	2.0891
13	.3086				2.2977	1.8447	1.9109
14	.3086	.354	.1296		2.2977	1.9006	1.6518
15	.3086	.3727	.1619		2.2291	1.8633	1.6194
16	.3086	.3727	.2915		1.869	1.8633	1.5708
17	.3429	.3913	.3077		1.7318	1.8447	1.5546
18	.3772	.4099	.3239	.3086	.3601	.3913	.2753
19	.4458	.4472	.3887	.463	.4115	.4286	.5182
20	.5316	.5404	.4534	.4973	.5487	.4845	.5992
21	.5316	.559	.4372	.4973	.5144	.5404	.5668
22	.5316	.5217	.421	.4973	.5487	.559	.5344
23	.5316	.5031	.421	.4801	.5658	.5963	.5344
24	1.3717	1.4232	1.5279	1.1822	.4973	.5658	.559
Max	2.4006	2.332	2.4595	2.0081	2.6139	1.9006	2.17
Min	.2401	.2981	.1296	.2401	.3601	.3727	.2753
Avg	.9409	.9537	.9910	1.0361	1.0605	.9765	.9346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 203 / 11KV MANDAVE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.9088	.9808	.9088	.9259	1.0456	.8991
2	.8745	.9088	.9481	.9088	.9259	1.0456	.8827
3	.8745	.9259	.9318	.9602	.9259	1.1016	.85
4	.9431	.9602	.8991	1.0288	.9431	1.0117	.8337
5	1.0117	1.0288	.9481	1.0802	1.0117	1.1389	.9645
6	1.0631	1.0802	.9808	1.1317	1.0802	1.0974	1.0952
7	1.0117	.9602	.9318	1.0631	.9945	1.046	1.0135
8	1.0642	.9088	.85	.8745	.7716	.8573	.9808
9	.9259	.7519	.8059	.7888	.8402	.7683	.8745
10	.8573	.8173	.7716	.7545	.7716	.7356	.1886
11		.8173	.7716	.703		.7193	.823
12	.8573	.801	.7716	.6687	.8059	.6866	.7545
13	.6687	.7846	.6859	.6516	.6859	.6539	.6859
14	.703	.7846	.6173	.583	.6859	.5558	.6687
15	.703	.7683	.6173	.6173	.703	.6539	.6516
16	.703	.7519	.6516	.6344	.703	.6866	.6344
17	.7202	.7683	.6859	.6687	.7545	.7519	.7545
18	.8573	.7519	.7888	.703	.7888	.801	.8573
19	.9945	.9645	1.0288	.8402	1.0117	.9318	1.0802
20	1.0802	1.1116	1.0631	1.1317	1.1488	1.0625	1.1831
21	1.046	1.1606	1.0631	1.0631	1.0974	1.1606	1.1488
22	1.0288	1.1443	1.0288	1.046	1.046	1.0298	1.1145
23	.9431	1.1279	.9259	.9602	1.0117	.9318	.9945
24	.8745		1.0625	.9088	.9088	.9602	.9154
Max	1.0802	1.1606	1.0631	1.1317	1.1488	1.1606	1.1831
Min	.6687	.7519	.6173	.583	.6859	.5558	.1886
Avg	.8991	.9125	.8671	.8616	.8931	.8931	.8687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 204 / 11KV AHILYANAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5716	.2858	.6287	2.3053	2.2405	2.191
2	.4801	.5716	.2858	.6287	2.3053	2.2405	2.2481
3	.4801	.5716	.3048	.6478	2.3243	2.1605	2.3243
4	.5144	.5716	.362	.6478	2.3815	2.2119	2.572
5	.5316	.5716	.5144	.6859	2.6482	2.2977	2.8578
6	.6161	.5716	.6478	.724	3.2579		2.915
7	.5144	.5906	.5906	.6097	3.6008	3.2236	3.4675
8	.4287	.4763	.5525	.5335	3.4294	2.915	3.5818
9		.4001	.4763	.4954	3.3234	3.2007	3.1245
10	2.3243	1.9243	2.0576	1.9814	.2987	.3429	.3048
11		2.9531	3.2007			.3239	.3429
12	3.0674	3.315	3.3532		.2401	.3048	.362
13	2.915	3.3341	3.1817		.3086	.3048	.362
14	2.8197	3.2388	2.8197		.3086	.2858	.362
15	2.8197	3.1436	2.0957		.3258	.3239	.381
16	2.8769	2.9531	2.3624		.3429	.362	.381
17	2.8006	2.7054	2.5911		.3429	.381	.381
18	.2858	.3239	.3239	.3239	.4115	.4191	.4001
19	.4382	.3048	.6097	.5335	.4973	.4763	.4763
20	.5906	.3048	.6668	.6097	.6722	.5144	.4763
21	.5906	.2858	.6668	.6287	.6516	.5525	.6097
22	.5906	.2858	.6668	.6287	.6722	.6097	.6097
23	.5906	.3239	.6478	.6097	.6173	.6478	.5906
24	.5228	.5906	.3048	.6478	2.2672	2.0911	2.0957
Max	3.0674	3.3341	3.3532	1.9814	3.6008	3.2236	3.5818
Min	.2858	.2858	.2858	.3239	.2401	.2858	.3048
Avg	1.2399	1.2868	1.2320	.6803	1.4580	1.2361	1.3924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 205 / 11KV PURANDAWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0117	1.2574	1.3336	1.1812	.3048	.2987	.2858
2	1.1145	1.2574	1.4289	1.1812	.3048	.2987	.2667
3	1.1831	1.2765	1.5623	1.2193	.3048	.2915	.2667
4	1.3817	1.3336	1.6575	1.2955	.3239	.3258	.3048
5	1.475	1.5242	1.7147	1.3717	.381	.3601	.381
6	1.5432	1.5813	1.7909	1.4861	.4572	.3944	.4382
7	1.7147	1.8099	1.9052	1.9243	.4191	.3584	.4001
8	1.4918	1.9433	2.0195	1.848	.3429	.2915	.3239
9	1.848	1.5623	1.7718	1.6956	.2401	.2667	
10	.2096	.3048	.1905	.2286	1.3203	1.4289	
11		.2667	.1905			1.4861	1.7909
12	.2286	.2096	.1905		1.643		1.848
13	.2286	.1905	.1905		1.7924	1.5242	1.8099
14	.2286	.1905	.1905		1.6461		1.7147
15	.2096	.2096	.2096		1.5947	1.5623	1.7147
16	.1905	.2096	.2477		1.6804	1.5623	1.7909
17	.2286	.2096	.2286		1.4746	1.5813	1.7718
18	.2286	.2286	.2096	.1905	.1543	.2477	.2286
19	.3048	.2477	.3239	.3239	.2743	.2477	.3429
20	.362	.2858	.362	.381	.3601	.2858	.362
21	.3239	.3048	.3429	.362	.3258	.2858	.362
22	.3239	.2858	.2667	.362	.3086	.3048	.3429
23	.3048	.2667	.2477	.3239	.2915	.3048	.3048
24	1.0117	1.2193	1.2003	1.1431	.3048	.2743	.2858
Max	1.848	1.9433	2.0195	1.9243	1.7924	1.5813	1.848
Min	.1905	.1905	.1905	.1905	.1543	.2477	.2286
Avg	.7455	.7573	.8240	.9716	.7065	.6355	.7881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 201 / 11KV DAHIGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	.5144	.5144	.5316	1.0288	.8383	1.1145
2	1.1145	.5144	.5144	.5316	1.1145	.8383	1.2003
3	1.1145	.5144	.5144	.5316	1.1145	.8383	1.2003
4	1.166	.5487	.5144	.5316	1.2346	.9556	1.2003
5	1.2517	.6001	.5144	.5316	1.286	1.0898	1.5432
6	1.749	.5658	.5487	.5316	1.3375	1.0898	1.7147
7	2.2634	.5144			1.9719	2.0348	2.1776
8	2.1948	.4287			1.9719	2.1434	2.1776
9	1.749	.3086			1.1145	1.9719	1.6975
10	.2401	1.2071	1.4403	1.5432	.2058		
11	.2374	1.7147	2.0576	1.8176			
12	.2883	1.7147	1.7147	1.5432			
13	.2515	1.7661	1.6804	1.4575			
14	.2515	1.7147	1.6804	1.2003	.1696		
15	.2058	1.6289	1.7147	1.286	.1844		.3429
16	.2572	1.6289	1.6289	1.3717		.3086	.3258
17	.3086	1.6461	1.5604	1.3717			.3772
18	.3429	.3429	.3601	.4287	.2572		.4287
19	.5144	.5144	.3601	.4973	.4748	.6001	.5144
20	.5658	.5658	.3601	.5144	.5935	.6001	.583
21	.5316	.5487	.4287	.5487	.5658	.6001	.583
22	.5365	.5144	.5144	.5487	.5316	.6001	.583
23	.503	.5144	.5658	.5316	.503	.583	.5487
24	1.0288	.503	.5144	.5316	.9431	.8048	1.0288
Max	2.2634	1.7661	2.0576	1.8176	1.9719	2.1434	2.1776
Min	.2058	.3086	.3601	.4287	.1696	.3086	.3258
Avg	.8221	.8764	.9382	.8753	.8738	.9936	1.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 202 / 11KV KALAMBOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	1.5432	1.6289	1.7147	.703	.6203	.5144
2	.6516	1.6289	1.7147	1.7147	.6859	.6203	.5144
3	.6516	1.6289	1.8004	1.8004	.6859	.5647	.5144
4	.6687	1.7147	1.8004	1.8004	.6859	.6706	.5144
5	.6687	1.8861	1.8861	1.8861	.6859	.6706	.5144
6	.6859	2.4006	2.2291	2.572	.7545	.7122	.5144
7		2.572	2.915	3.0864	.6173		.5144
8		2.6578	3.155	2.915	.5144		.5144
9	.4287	2.4006	2.5206	2.7606	.4115	.4287	.5144
10	2.1434	.3353	.3429	.3429	2.1091	2.3148	2.3663
11		.3429	.3429	.3429	3.3913	3.4294	3.4465
12		.3429		.3601	3.3532	3.1036	1.989
13	2.8502	.3429	.5144		3.1855	3.0178	2.0576
14	2.934	.3429			3.2579	3.0007	2.0919
15	1.8004	.3429	.5144		3.1855		2.2291
16	2.8502		.5144	.3772			2.4348
17	2.8826	.4115	.5144	.4115		3.4294	2.1434
18	.3429	.5144	.5144	.5316	.4287	2.9835	2.7263
19		.6001	.5144	.6001	.5868	.3429	.5144
20	.6001	.6001	.5144	.6001	.6706	.3429	.5144
21	.5658	.5487	.5144	.6859	.6859	.5144	.5144
22	.4458	.5487	.5144	.7202	.6344	.5144	.5144
23	.503	.5144	.5144	.6859	.6203	.5144	.5144
24	.6516	1.5089	1.5432	1.7147	.703	.6203	.5144
Max	2.934	2.6578	3.155	3.0864	3.3913	3.4294	3.4465
Min	.3429	.3353	.3429	.3429	.4115	.3429	.5144
Avg	1.2075	1.1187	1.2283	1.3154	1.2980	1.4208	1.2167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 203 / 11KV SHINDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	1.3717		2.572	.5144	.3688	.4115
2	.4458	1.3717		2.572	.5144	.39	.4115
3	.4458	1.3717		3.4294	.5316	.4239	.4115
4	.463	1.5432		3.4294	.5316	.4527	.4115
5	.463	1.8861		3.4294	.5658	.503	.4287
6	.5316	2.4006		3.4294	.6001	.5935	.4287
7		2.915		3.6866	.4801		.4458
8		2.915		3.4294	.3944		.4287
9	.2915	2.8292		3.1379	.3429	.3429	.3772
10	1.8004	.1932		.2572	1.9376	2.572	2.1091
11		.2229	.2401	.2401	3.6046	3.6351	3.4294
12	3.0521			.2401	3.5543		3.7723
13	2.7492		.2058	.2572	3.476		3.7723
14	.2515		.2058	.2572	3.3532		
15	1.8861		.2572	.2572	3.2693		
16	3.0521	.2743	.3429	.3086	3.4294	.3429	
17	3.0521	.3086	.3429	.3429	3.3436	.2915	.8573
18	.2743	.3772	.3944	.3772	.3429	2.572	.8745
19	.4115	.4115	.3944	.4287	.4191	.3429	.1543
20	.5144		.3944	.4458	.5087	.3429	.1543
21	.4801		.4458	.5144	.463	.3944	.1543
22	.4239		.4458	.5144	.4287	.4287	.1543
23	.3856		.4458	.4801	.3856	.3944	.1543
24	.4287	1.2717		1.7147	.4801	.3856	.4115
Max	3.0521	2.915	.4458	3.6866	3.6046	3.6351	3.7723
Min	.2515	.1932	.2058	.2401	.3429	.2915	.1543
Avg	1.0396	1.3540	.3429	1.4896	1.3946	.8210	.9406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 204 / 11KV SHERIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	.3772	.3772	.3601	1.2346	1.3413	1.3717
2	1.4232	.3772	.3772	.3601	1.286	1.1888	1.3717
3	1.5775	.3772	.3772	.3601	1.286	1.2631	1.5432
4	1.6289	.4287	.3772	.4287	1.3717	1.3375	1.5432
5	1.6804	.4801	.4458	.4287	1.4575	1.7147	1.7147
6	1.9719	.5144	.5316	.4287	1.5432	1.9161	1.8861
7	2.3148		.4115	.4287	2.2291	2.2634	2.3834
8	2.1091		.3944	.3429	2.1434	2.3148	2.2291
9	2.0233	.2915	.3258	.2743	1.6289	2.1434	2.1434
10	.2572	1.2717	1.4403	1.5432	.2229		
11	.2204	2.2291	2.1434				
12	.2035	2.1434	2.0576	2.4006	.2204		
13	.2204	2.0576	2.0576	2.2634		.2572	
14	.218	1.7147		1.9719		.2401	
15	.2401	2.1091	2.0576	1.9376		.2915	
16	.2515	2.0576	2.0576	1.9204	.2572		.8402
17	.2713	2.0748	2.1262	1.9204	.3429	.3429	.2572
18	.2915	.2743	.3429	.3601	.3601	.3944	.4115
19	.4287	.4287	.3429	.4287	.4641		.4458
20	.5144	.0514	.3429	.4287	.5304	.4287	.4458
21	.4801	.5144	.3601	.4458	.5487	.4458	.4458
22	.4359	.4458	.3601	.4801	.463	.4458	.4458
23	.4024	.4115	.3601	.4458	.407	.3944	.3944
24	1.3717	.3856	.3772	.3601	1.2346	1.3413	1.3717
Max	2.3148	2.2291	2.1434	2.4006	2.2291	2.3148	2.3834
Min	.2035	.0514	.3258	.2743	.2204	.2401	.2572
Avg	.9150	.9553	.8715	.8834	.9616	1.0561	1.1803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 205 / 11KV DAHIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0288	1.0288	1.1203	1.1203	1.0059	1.1203
2	1.2136	1.0288	1.0288	1.1203	1.1203	1.0059	1.1203
3	1.2136	1.0288	1.0288	1.1203	1.2136	1.0288	1.1203
4	1.307	1.1145	1.0288	1.1203	1.2136	1.0898	1.1203
5	1.4003	1.2003	1.2003	1.307	1.4003	1.2717	1.1203
6	1.4003	1.286	1.3717	1.307	1.4937	1.3565	1.1203
7	1.1203		1.1203	1.2136	1.2136	.9783	1.1203
8	1.0269		1.1203	1.1203	.9335	.9431	1.0269
9	1.0269	.9431	1.0269	1.0269	1.0269	.8573	.9335
10	.9335	.9326	.4668	.9335	.9335	.9335	1.0269
11	.4458	.6859	1.0269	.9335	.8478	.8402	.8573
12	.503	.5144		.8402	.763		.6859
13	.6706	.5144	1.0269	.8402	.6783		
14	.6706	.5144	.9335	.7468	.6783		
15	.6001	.5144	.9335	.7468	.6706		.6859
16	.6859	.6859	.9335	.8402	1.5432	.9431	.7716
17	.7716	.8573	.9335	.9335		1.0269	.7716
18	.8573	.8573	.9335	1.1203	.9431	1.1203	.8573
19	1.2003	1.2003	.9335	1.307	1.1022	1.307	1.2003
20	1.286	1.286	1.0269	1.4003	1.2717	1.307	1.3717
21	1.2003	1.2003	1.1203	1.4003	1.2003	1.307	1.2003
22	1.1145	1.0288	1.1203	1.307	1.1488	1.307	1.0288
23	1.0562	1.0288	1.2136	1.1203	1.073	1.2136	1.0288
24	1.0288	1.0059	1.0288	1.1203	1.1203	1.0059	1.1203
Max	1.4003	1.286	1.3717	1.4003	1.5432	1.3565	1.3717
Min	.4458	.5144	.4668	.7468	.6706	.8402	.6859
Avg	.9939	.9299	1.0255	1.0853	1.0743	1.0924	1.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 206 / 11KV EXPRESS SHIVPRASAD NON SHEDDABLE EXPRESS HV FEEDERS
 MILK Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0686	.0857	.1307	.0934	.0848	.0747
2	.0934	.0514	.0857	.1307	.0934	.0678	.0747
3	.0934	.0514	.0857	.112	.0747	.0838	.0747
4	.0934	.0514	.0857	.112	.0747	.0671	.0747
5	.0934	.0514	.0857	.0934	.0934	.0671	.0747
6	.0934	.0686	.0857	.0934	.0747	.0671	.0686
7	.0934	.0686	.0747	.0747	.0747	.0671	.0747
8	.0934	.0857	.0747	.1307	.0747	.0857	.0747
9	.112	.0857	.0747	.1867	.0747	.0857	.0747
10	.2054	.1677	.1867	.1494	.112	.1494	.2614
11	.1486	.2058	.1867	.2054	.218	.3944	.2915
12	.1696	.2058	.1307	.0934	.2012	.2801	.3601
13	.1341	.2058	.0934	.1494	.1341	.2801	.2572
14	.1341	.1715	.0934	.2054	.1017	.2801	.2058
15	.2572	.1715	.0934	.1867	.1677	.2614	.2058
16	.218	.2229	.0747	.1867	.1372	.2614	.2058
17	.2035	.2401	.0747	.2054		.2614	.2572
18	.2058	.1715	.168	.1867	.1372	.2427	.3258
19	.1372	.1715	.168	.0747	.1677	.2241	.2058
20	.1372	.1715	.168	.1307	.1696	.2241	.2058
21	.12	.1886	.1867	.1307	.1715	.2054	.2058
22	.1174	.1886	.1867	.1494	.1715	.2054	.1372
23	.1187	.1886	.1867	.1494	.2012	.1494	.1372
24	.0934	.0686	.1886	.1307	.1494	.0838	.0747
Max	.2572	.2401	.1886	.2054	.218	.3944	.3601
Min	.0934	.0514	.0747	.0747	.0747	.0671	.0686
Avg	.1358	.1385	.1219	.1416	.1291	.1741	.1668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 207 / 11 KV PIRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2229	.2401		.4287	.503	.6859
2	.5316	.2229	.2401	.2401	.4287	.5144	.6859
3	.5658	.2229	.2401	.2401	.4458	.5426	.8573
4	.6001	.2401	.2401	.2401	.4801	.5498	.8573
5	.6001	.2401	.2401	.2572	.5487	.7716	.9431
6	1.1145	.2572	.2743	.2572	.6001	1.0059	1.0288
7	1.3717	.2743	.2401	.2572	.7716	1.4074	1.0802
8	1.286	.2229	.2058	.2229	.7716	1.406	1.0802
9	1.0288	.1372	.1715	.1715	.8573	1.2003	1.0288
10	.1543	.5596	.6859	.5144	.1543	.1372	.0857
11	.1357	1.1145	.9431	1.046	.1543	.1372	.1029
12	.1187	1.1145		.9945		.1372	.12
13	.1174	1.0802	1.0631	.9431		.1867	.12
14	.1187	1.0288	1.0288	.8573		.1372	.1372
15	.1543	1.0802	1.0288	.7888		.1543	.1543
16	.1189	1.0288	.9431	.7716	.1715	.1715	.1543
17	.1357	1.0288	.9602	.7716	.1715	.1715	.2229
18	.1715	.1715	.12	.2058	.2058	.2572	.2229
19	.2229	.2229	.12	.2401	.2286	.2915	.2743
20	.2743	.2743	.12	.2401	.3391	.2915	.2915
21	.2572	.2572	.1715	.2401	.3086	.2743	.2915
22	.208	.2572	.2572	.2572	.2915	.2572	.2743
23	.2347	.2401	.2915	.2572	.2515	.2572	.2915
24	.5144	.2347	.2401	.2572	.4287	.4694	.6859
Max	1.3717	1.1145	1.0631	1.046	.8573	1.4074	1.0802
Min	.1174	.1372	.12	.1715	.1543	.1372	.0857
Avg	.4396	.4889	.4376	.4466	.4019	.4680	.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 201 / 11KV DHARMपुरी AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	.6173	.583	.5144	1.6632	1.6461	1.9204
2	1.7147	.6344	.583	.5144	1.7833	1.6461	2.0233
3	1.9033	.6516	.6001	.5487	1.9033	1.6804	2.1262
4	2.1948	.6516	.6001	.583	2.0405	1.8519	2.2462
5	2.3148	.6687	.6687	.6859	2.1776	2.2634	2.3663
6	2.3834	.6859	.7545	.8215	2.3148	2.4006	2.4863
7	2.572	.6859	.6859	.6687	2.452	2.452	2.6063
8	2.5892	.5144	.6687	.5658	2.3491	2.2291	2.5034
9	2.4691	.3429	.6344	.4458	2.2291	2.0919	2.4006
10	.4458	1.7318	1.8176	1.9719	.3429	.2915	
11	.4115	2.5549	2.0062	2.5549	.3429	.3429	.3601
12	.3944	2.6406	2.1948	2.4348	.3601	.3601	.3429
13	.3772	2.4177		2.332	.3772	.3086	.3429
14	.3772	2.2634	2.6063	2.2291	.4115	.2915	.3601
15		2.0576	2.4691	2.1948	.4108	.3429	.3429
16		2.2119	2.332	2.2291	.3772	.3772	.3772
17	.3429	2.0576	2.1948	2.0576	.4294	.3601	.3429
18	.5144	.2915	.5316	.2743	.3944	.4115	.4115
19	.5316	.583	.6344		.6001	.4458	.6516
20	.5487	.6344	.6516	.3772	.6516	.4801	.7202
21	.5658	.6516	.6687	.4287	.6859	.5144	.6859
22	.583	.6173	.583	.4973	.6344	.5487	.6344
23	.6001	.6001	.6348	.5487	.6001	.583	.583
24	1.6289	.6173	.583	.5316	1.5432	1.6461	1.8176
Max	2.5892	2.6406	2.6063	2.5549	2.452	2.452	2.6063
Min	.3429	.2915	.5316	.2743	.3429	.2915	.3429
Avg	1.2314	1.1410	1.1168	1.1309	1.1281	1.0652	1.2457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 202 / 11KV NATEPUTE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.1831	1.2174	1.1488	1.1831	1.2517	1.1488
2	1.3375	1.2003	1.2174	1.1488	1.2003	1.2517	1.166
3	1.3717	1.2174	1.286	1.2174	1.2174	1.286	1.2003
4	1.406	1.2346	1.286	1.3817	1.2346	1.286	1.2346
5	1.406	1.2689	1.3375	1.286	1.2689	1.3546	1.2689
6	1.4403	1.3032	1.4746	1.3203	1.3032	1.4575	1.3032
7	1.3546	1.3375	1.4403	1.2689	1.3375	1.3203	
8	1.2003	1.286	1.3717	1.2174	1.2346	1.166	1.2003
9	1.2174	1.2346	1.2346	1.166	1.2323	1.0802	1.0631
10	1.3256	1.2174	1.5089	1.166	1.1317	1.2346	
11	1.2689	1.2174	1.4746	1.1831	1.3032	1.3203	1.3375
12	1.4937	1.2689	1.4403	1.2346	1.3032	1.3032	1.3889
13	1.3443	1.286	1.406	1.2003	1.2689	1.2689	1.3203
14	1.2883	1.2517	1.3717		1.3817	1.2346	1.3032
15	1.3256	1.2689	1.3546	1.2003	1.363	1.286	1.3375
16		1.2517	1.3203	1.2174	1.3256	1.3203	1.3717
17	1.4746	1.1831	1.3032	1.166	1.2517	1.2346	1.2174
18	1.3375	1.2346	1.2689	1.0974	1.286	1.2346	1.1831
19	1.3203	1.3546	1.3203	1.1317	1.3203	1.2517	1.4403
20	1.286	1.3203	1.3546	1.166	1.3717	1.2689	1.5089
21	1.2517	1.3375	1.3375	1.2003	1.3717	1.286	1.4746
22	1.2174	1.3203	1.2689	1.2517	1.286	1.3203	1.4403
23	1.1831	1.3032	1.1831	1.3032	1.2689	1.3375	1.406
24	1.3375	1.166	1.2174	1.1831	1.166	1.2517	1.1317
Max	1.4937	1.3546	1.5089	1.3817	1.3817	1.4575	1.5089
Min	1.1831	1.166	1.1831	1.0974	1.1317	1.0802	1.0631
Avg	1.3272	1.2603	1.3332	1.2111	1.2755	1.2753	1.2930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 203 / 11KV MANDAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.4115	.4115	.3258	1.166	1.1145	1.3032
2	.9431	.4287	.4115	.3258	1.3032	1.1145	1.4232
3	.9945	.4458	.4287	.3734	1.4403	1.2003	1.5432
4	1.166	.463	.4287	.3944	1.5775	1.3375	1.6632
5	1.3203	.4973	.4801	.4668	1.7147	1.8176	1.7833
6	1.3375	.5144	.5658	.4973	1.8519	1.9719	1.9033
7	1.5432	.5144	.5144	.4458	1.989	2.0748	2.0233
8	1.5775	.4287	.5144	.4458	1.6632	1.9719	1.9204
9	1.5432	.3429	.4458	.3258	1.3375	1.9376	1.8176
10	.2743	.9945	1.2689	1.2689	.2229	.2229	
11	.2572	1.5775	1.3717	1.7833	.2572	.2572	.2572
12	.2572	1.6289	1.4746	1.8347	.2743	.2572	.2401
13	.2058	1.6632	1.5775	1.7147	.2743	.2572	.2229
14	.2058	1.6289	1.6804	1.6804	.2614	.2401	.2572
15	.1886	1.5775	1.6975	1.6461	.2058	.2229	.2401
16		1.5947	1.6804	1.6804	.2572	.2572	.2743
17	.3258	1.6632	1.7147	1.6804	.3258	.2743	.2743
18	.3429	.2743	.3258	.2743	.3086	.2743	
19	.3601	.3944	.3944	.2915	.3429	.3086	
20	.3772	.4287	.4115	.3086	.4115	.3429	.5144
21	.3944	.4458	.4115	.3429	.4801	.3772	.5144
22	.3944	.4287	.3772	.3772	.4801	.4115	.4801
23	.4115	.4287	.3921	.4115	.463	.4458	.463
24	.8916	.4115	.4115	.3601	1.0288	1.0974	1.2003
Max	1.5775	1.6632	1.7147	1.8347	1.989	2.0748	2.0233
Min	.1886	.2743	.3258	.2743	.2058	.2229	.2229
Avg	.7067	.7995	.8079	.8023	.8182	.8245	.9676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 204 / 11KV LONAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.5775	1.5432	1.4403	.9259	1.1145	1.046
2	1.1203	1.6118	1.5432	1.5261	1.0117	1.1145	1.1488
3	1.166	1.6632	1.8004	1.9791	1.0802	1.166	1.2517
4	1.3546	1.7318	1.9376	2.0911	1.1145	1.2346	1.3203
5	1.4575	1.7661	2.1434	2.0405	1.1831	1.3889	1.4232
6	1.5089	1.8004	2.3148	2.2291	1.2517		1.5089
7	1.2517	1.8861	2.2119	2.3491	1.3375	1.5432	1.6118
8	1.3375	1.6804	1.9204	2.4348	1.1488	1.5604	1.3889
9	1.3203	1.4746	1.6804	2.0576	.9602	1.1488	1.166
10	1.406	.8916	1.0631	1.3032	1.406	.3601	
11	1.6632		1.0631	1.5261	2.1091	2.1434	2.1605
12	1.7833	1.2003	1.0802	1.4746	2.1091	2.0576	2.3148
13	2.0911	1.3546	1.2346	1.4746	2.0405	2.0233	2.0062
14	1.8347	1.1488	1.0802	1.1831	1.9547	1.9376	1.9719
15	1.749	1.1317	1.046	1.2346	1.869	1.7147	1.9376
16		1.0974	1.0117	1.2003	1.8347	1.2689	1.8347
17	1.5261	1.0117	.9431	1.286	1.7833	1.7147	1.9719
18	.3772	.4801	.5316	.2915	.4115	.4115	
19	.3772	.5487	.583	.3772	.4458	.463	
20	.3772	.5487	.583	.4458	.4973	.5144	.6001
21	.3772	.583	.6001	.4973	.5144	.5487	.6001
22	.3944	.5487	.5487	.5658	.5144	.583	.5658
23	.3772	.5487	.5487	.6173	.4973	.6173	.5487
24	.9945	1.5089	1.406	1.3203	.8573	1.0974	.9431
Max	2.0911	1.8861	2.3148	2.4348	2.1091	2.1434	2.3148
Min	.3772	.4801	.5316	.2915	.4115	.3601	.5487
Avg	1.1684	1.2085	1.2674	1.3727	1.2024	1.2055	1.3962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 205 / 11KV PHADATARI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086	.2743	.2987	.3086	.2915	.3086
2	.2915	.3258	.2743	.2987		.2915	.2915
3	.2915	.3258	.3086	.2915	.2915	.3086	.2915
4	.3086	.3086	.3429	.3734	.3258	.3086	.3258
5	.4115	.3086	.3772	.3944	.3258	.3601	.3258
6	.3944	.3429	.4115	.4668	.3429	.4115	.3429
7	.3429	.3429	.3601	.3258	.3429	.3429	.3429
8	.2229	.2915	.3429	.2614	.2743	.2743	.2915
9	.2058	.2401	.2915	.1715	.2058	.2229	.2401
10	.2241	.1715	.1715	.1715	.2058	.2058	
11	.1867	.1543	.1715	.1886	.1886	.1886	.1715
12	.1543	.1886	.1543	.1715	.1715	.1715	
13	.1372	.1543		.1543	.1372	.1543	.1543
14	.1307	.1715	.1543	.1543	.112	.1715	.1715
15	.12	.1715	.1372	.1715	.1029	.1543	.1543
16	.1886	.1543	.1372	.1886	.12	.1543	.1715
17	.1886	.1715	.1543	.1886	.1543		.1715
18	.1715	.2401	.2229	.1543	.2058	.1715	
19	.1886	.2915	.2915	.1715	.2572	.1886	
20	.2058	.3086	.3086	.2058	.2915	.2058	.463
21	.2229	.3258	.3258	.2401	.3086	.2401	.3772
22	.2401	.3086	.2915	.2743	.3086	.2743	.3429
23	.2743	.3086	.2401	.3086	.3086	.3086	.3086
24	.2915	.3086		.2614	.3086	.2915	.3086
Max	.4115	.3429	.4115	.4668	.3429	.4115	.463
Min	.12	.1543	.1372	.1543	.1029	.1543	.1543
Avg	.2369	.2593	.2611	.2453	.2434	.2475	.2778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 201 / 11KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	2.0119	1.9784	1.7635	.4862	.5506	.6104
2	.6104	1.9433	1.9433	2.0517	.4527	.5506	.6104
3	.6274	2.1795	2.0243	2.2552	.4191	.583	.6443
4	.6613	2.3472	2.1052	2.4078	.3688	.6154	.7316
5	.6984	2.3807	2.3482	2.5095	.4534	.6478	.6613
6	.6443	2.4143	2.7854	2.696	.5197	.6478	.5935
7		2.4981	2.753	3.0521	.57	.6316	.5426
8		2.1963	2.5911	2.6113			
9				2.5434	2.6825	2.5911	2.7873
10	.5087	.3239	.3239	.3052	2.7999	2.4291	
11	.4694	.3563	.39	.4024	2.5911	2.5434	2.5149
12	.4359	.3239	.373	.4024	2.5911	2.5095	2.3472
13	.3856	.3239	.3982	.3856	2.2348	2.3908	2.2466
14	.3856	.3239	.3467	.3353	2.2186	2.3908	2.1376
15	.3688	.3239		.3353	2.2672	2.34	2.1052
16	.3563	.3563	.3561		2.1862	2.3739	2.1795
17	2.7161	.421	.373	.3353	.3239	.3052	.3018
18	2.9843	.4534	.407	.3856	.421	.2883	
19	2.6825	.5506	.4917	.4359	.421	.4748	
20	2.5149	.583	.5596	.4694	.5668	.5596	.6203
21	2.4646	.5182	.5935	.5533	.5344	.5426	.6203
22	2.1795	.5506	.6401	.5197	.5182	.6348	.6036
23	2.079	.5506	.6154	.5365	.5506	.5935	.5868
24	2.3739	2.0119	.5506	.5548	.503	.5182	.5935
Max	2.9843	2.4981	2.7854	3.0521	2.7999	2.5911	2.7873
Min	.3563	.3239	.3239	.3052	.3239	.2883	.3018
Avg	1.2742	1.1279	1.1340	1.2107	1.1600	1.2049	1.2019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 203 / 11KV PALASMANDAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	.57	.4534	.5249	.6783	.5668	.5935
2	2.1195	.5365	.4372	.543	.6706	.5668	.6783
3	2.1195	.503	.421	.591	.7209	.5992	.6783
4	2.3739	.4694	.4372	.6335	.8048	.6154	.763
5	2.5434	.4862	.4534	.6201	.9221	.6478	.9955
6	2.5692	.5365	.4858	.5426	.9724	1.1174	1.2883
7	2.8349	.57	.4858		1.0059	1.1822	1.4003
8	2.2043				.503	.5668	.9326
9	.8383	2.3482	2.2672	2.5434			
10	1.1888	2.4291	2.2996	2.7073		.4049	
11	1.073	2.3482	2.2891	2.3472	.3239	.3018	.3018
12	1.0059	2.1052	2.3405	2.3472	.2915	.3222	.285
13	.9221	2.1052	2.5339	2.3472	.2915	.3561	.2683
14	.8383	1.9595	2.4434	2.1795	.2915	.3561	.2915
15	.7545	2.0243	2.0348	2.0119	.2915	.4108	.2915
16	.6706	2.0243	2.0348		.3239	.3391	.3018
17	.3353	1.166	1.0174	1.0669	2.5911	2.3405	2.5101
18	.3521	1.2955	1.2136	1.0898	2.5425	2.5606	2.5484
19	.4024	1.1336	1.1022	1.0059	2.3482	2.2043	2.5149
20	.4862	1.0526	1.086	.8907	2.1052	2.2043	2.3472
21	.5868	.9717	.9221	.8383	2.0243	2.1195	2.1795
22	.5868	.9717	.9326	.7545	1.9433	2.1195	1.9433
23	.5868	.8097	.8478	.6706	1.9433	2.0348	1.8442
24	.5426	.5506	.6478	.905	.5868	1.9109	1.9281
Max	2.8349	2.4291	2.5339	2.7073	2.5911	2.5606	2.5484
Min	.3353	.4694	.421	.5249	.2915	.3018	.2683
Avg	1.2478	1.2594	1.2690	1.2934	1.0989	1.1238	1.2221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 204 / 11KV FONDSHIRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.788		.6952	.8718	.7611	.7122
2	.6783	.8383		.7969	.9054	.7773	.9335
3	.8139	.8551		.9496	.9054	.8097	1.0056
4	.9156	.8583		1.0004	.9069	.8745	1.1016
5	1.1016	.9221		1.1191	.9724		.9326
6	1.1191	.9389		1.0343	1.0059		.9362
7	1.0269	.9892		.9326	.9724		1.0269
8	.8478	.8215	.7125	.8478	.8551	.6964	.7969
9	.6443	.664	.6706	.7969	.6783	.5506	.7461
10	.5249	.5506	.6478	.6443	.6036		
11	.4862	.5182	.6535	.5365	.5668	.5596	.6706
12	.503	.5182	.5548	.5365	.5344	.5087	.5868
13	.503	.4534	.5601	.502	.4696	.4917	.9724
14	.503	.4049	.4917	.503	.4372	.4917	.4534
15	.503	.4372	.4748	.4862	.4534	.4578	.4696
16	.4862	.4696	.4917		.5182	.5658	.5197
17	.503	.5344	.5426	.5182	.4858	.4917	.5668
18	.6036	.5992	.6443	.6706	.583	.4917	.5868
19	.6706	.7935	.7291	.8383	.7935	.8987	
20	.8383	.9069	.9496	.9393	.8745	1.0004	
21	.8718	.8907	.9835	1.0059	.9717	.9511	1.0059
22	.8551	.8259	.8648	.9221	.9339	.8478	.9389
23	.8383	.8097	.8478	.8551	.8259	.905	.8886
24	.7969	.8048	.7773	.8139	.8383	.7773	.8048
Max	1.1191	.9892	.9835	1.1191	1.0059	1.0004	1.1016
Min	.4862	.4049	.4748	.4862	.4372	.4578	.4534
Avg	.7250	.7164	.6821	.7802	.7485	.6954	.7931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 205 / 11KV TAMSHIDWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6991	.3856	.4372	.4748	.3887	.3725	.4481
2	1.8298	.4359	.4372	.4917	.3856	.4049	.5415
3	2.0452	.4191	.4534	.5596	.3239	.421	.5087
4	2.0517	.4024	.4696	.6274	.3441	.4534	.5426
5	2.1704	.4191	.4858	.6274	.3725	.502	.5426
6	2.4796	.4359	.5182	.5788	.4191	.4858	.4748
7	3.086	.4359	.4372	.5256	.4359	.421	.4239
8	2.6063						
9		2.7496	2.3967	2.5604			
10	.2883	2.2996	2.332	2.3807	.285	.3077	
11	.285	2.3644	2.838	2.2131	.2591	.2515	.2896
12	.2591	2.2552	2.5766	2.146	.2429	.2713	.2012
13	.2515	2.1214	2.1874	2.0454	.2105	.2987	.2012
14	.2515	2.17	2.1026	1.9433	.2105	.2515	.2105
15	.2515	2.17	2.0348	1.9951	.1781	.2801	.2429
16	.2543	2.17	2.0348		.2105	.2204	.2683
17	.2683	.2429	.3353	.218	2.6882	2.2081	2.5652
18	.2753	.2915	.3366	.2591	2.4777	2.2986	2.2862
19	.3353	.3887	.373	.3077	2.17	2.0178	2.3472
20	.4024	.3887	.4854	.3401	2.0243	1.933	2.2298
21	.4359	.3887	.4748	.4191	1.9433	1.7974	2.079
22	.4359	.4049	.4917	.4191	1.8947	1.7126	2.0119
23	.4527	.4372	.4917	.4359	1.8461	1.6787	1.861
24	.4481	.3688	.4696	.4409	.421	1.7004	1.7924
Max	3.086	2.7496	2.838	2.5604	2.6882	2.2986	2.5652
Min	.2515	.2429	.3353	.218	.1781	.2204	.2012
Avg	.9941	1.0498	1.0956	1.0004	.8969	.9222	1.0509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 206 / 11KV KADAMWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1526	.1619	.1526	.6478	.4372	.407
2	.2614	.1341	.1619	.156	.7545	.4696	.4191
3	.2543	.1174	.1457	.1867	.7545	.502	.4748
4	.2801	.1357	.1781	.2204	.8097	.5506	.5197
5	.2987	.1509	.1943	.2427	.8718	.5992	.6104
6	.2614	.1677	.2105	.2241	.8886	.8907	.8987
7		.1696	.1619		.9054	1.1822	1.2437
8					.8215	.9878	.905
9	.9326						
10	.9835	.0972	.0972	.1357	.0838	.1134	
11	.8886	.081	.1017	.1174	.081	.0838	.0671
12	.7773	.0678	.0848	.1174	.1134	.0848	.0671
13	.7377	.081	.0848	.1174	.0648	.1017	.0838
14	.7377	.0648	.0934	.1006	.0648	.0848	.081
15	.7287	.0648	.0838	.1006	.0648	.0886	.081
16	.7545	.081	.0838		.0648	.0678	.0838
17	.1006	.9717	.9892	.9054	.0972	.0848	.0838
18	.1174	.9555	1.0682	.9389	.0972	.1017	.1174
19	.1341	.9231	.9724	.8718	.1296	.1526	.1509
20	.1509	.8097	.7377	.7712	.1943	.1844	.2012
21	.1677	.6964	.6613	.6706	.1781	.1696	.2012
22	.1677	.6802	.6613	.583	.1943	.2012	.2012
23	.1844	.6478	.6516	.5365	.1619	.2241	.1844
24	.1865	.1677	.6316	.6722	.4858	.1619	.1865
Max	.9835	.9717	1.0682	.9389	.9054	1.1822	1.2437
Min	.1006	.0648	.0838	.1006	.0648	.0678	.0671
Avg	.4241	.3372	.3735	.3911	.3709	.3272	.3304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 207 / 11KV CHAVANWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	1.5089	1.2631	1.4043	.5426	.583	.6104
2	.6348	1.5089		1.5261	.503	.583	.6104
3	.5935	1.6956		1.6448	.503	.5992	.6104
4	.6335	1.8442		1.933		.6154	.6535
5	.6722	1.8652		2.1195	.4578	.6316	.5935
6	.6161	1.9433		2.371	.4359	.5506	.4862
7		2.2043		2.0517	.4372	.4858	.5068
8		1.7101	2.0891	1.8482			
9					2.6113	2.2348	2.1874
10	.39	.3239	.3239	.3561	2.4478	2.2672	
11	.3856	.3725	.373	.3521	2.2348	1.6787	2.0243
12	.3856	.2915	.373	.3521	2.0243	1.6108	1.7814
13	.3239	.3887	.39	.3521	1.7004	1.6108	1.7436
14	.4024	.3401	.4294	.3353	1.4899	1.7177	1.587
15	.4191	.3401	.373	.3353	1.5708	1.56	1.5061
16	.4359	.3239	.373		1.587	1.5769	1.6598
17	2.5149	.3887	.4572	.3239	.2915	.2543	.2683
18	2.5316	.4372	.543	.4024	.3887	.2713	
19	2.3472	.4696	.5426	.4359	.4696	.407	
20	1.9281	.5182	.5765	.503	.5182	.5256	.5365
21	1.7101	.5506	.5935	.5365	.5506	.5087	.57
22	1.6766	.5992	.5935	.5506	.5344	.5426	.5868
23	1.3279	.5992	.5935	.5868	.583	.5426	.6036
24	1.7126	1.3413	.5992	.5765	.6036	.5668	.5765
Max	2.5316	2.2043	2.0891	2.371	2.6113	2.2672	2.1874
Min	.3239	.2915	.3239	.3239	.2915	.2543	.2683
Avg	1.0548	.9376	.6169	.9499	1.0221	.9532	.9851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 208 / 11 KV ISHWAR PIND AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.4694	.426	.4578	.2035	.2753	.2883
2	.2543	.4858	.4588	.4917	.1696	.2753	.2987
3	.2515	.5533	.4858	.6443	.1677	.2915	.3052
4	.3045	.6036	.5668	1.0082	.1844	.2915	.3222
5	.3045	.6706	.8097	1.0004	.2012	.3077	.3052
6	.2321	.763	1.0364	1.0343	.2267	.3239	.3547
7		.7621	1.2308	1.3321	.2515	.3077	.3052
8	.2614	.6371	.8907	.8309			
9					.9717	.9717	.7969
10	.2204	.1943	.2105	.1357	.0838	.8097	
11	.218	.1781	.2614	.1677	.7935	.8139	.788
12	.2012	.1844	.1865	.1677	.7935	.7122	.7712
13	.1844	.1943	.2054	.1677	.7287	.6613	.6874
14	.1844	.1781	.181	.1677	.6802	.6535	.6154
15	.1844	.1781	.1865	.1677	.6154	.5788	.5668
16	.1844	.1943	.1865		.6478	.5426	.5344
17	1.0059	.1781	.2241	.1844	.1296	.0934	.1844
18	.9878	.1943	.2054	.1844	.1781	.1267	.218
19	.8551	.3077	.2543	.218	.2429	.1865	.2683
20	.6706	.2915	.2713	.2267	.2591	.2543	.3018
21	.57	.2591	.3052	.2515	.2591	.2987	.3018
22	.4694	.2429	.2883	.2347	.2753	.2713	.285
23	.4191	.2429	.2883	.2347	.2753	.2713	.2683
24	.39	.4024	.2429	.2543	.218	.2591	.2713
Max	1.0059	.763	1.2308	1.3321	.9717	.9717	.7969
Min	.1844	.1781	.181	.1357	.0838	.0934	.1844
Avg	.3897	.3637	.4088	.4347	.3720	.4164	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 209 / 11 KV MARKADWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4917	.1457	.1781	.1696	.1677	.1457	.1341
2	.5533	.1341	1.2955	.181	.1509	.1457	.1677
3	.6443	.1174	1.3765	.2054	.1509	.1619	.181
4	.8059	.081	1.5061	.2035	.1341	.1781	.156
5	.9175	.0972	1.7814	.2035	.1174	.1943	.1214
6	1.0387	.1296	2.2672	.1677	.1526	.1457	.1463
7	1.2127	.1509	2.4615		.1509	.1134	.1494
8	.8775						
9		.8383	.8097	.8215			
10	.1017	.8097	.7773	.7461	.0838	.081	
11	.1006	.8097	.78	.6371	.081	.0848	.1134
12	.1006	.8097	.8215	.6203	.0972	.0848	.1006
13	.0838	.7773	.7455	.6036	.0972	.1017	.0838
14	.0838	.6964	.7265	.57	.081	.0848	.081
15	.0671	.6478	.6443	.5344	.0648	.0914	.081
16	.0671	.5992	.7095		.0648	.0747	.0972
17	.1006	.0648	.0838	.0838	.8583	.7291	.9556
18	.1341	.081	.0678	.1006	.7773	.78	.8215
19	.1341	.1457	.0838	.1134	.7935	.6952	.7712
20	.1509	1.0526	.1017	.1341	.6316	.7095	.7042
21	.1509	.1296	.1696	.1296	.5668	.5935	.6706
22	.1677	.1619	.2035	.1677	.5182	.5256	.5898
23	.1781	.1619	.2012	.1865	.4534	.4917	.5197
24	.1696	.1619	.1619	.1865	.1844	.421	.4578
Max	1.2127	1.0526	2.4615	.8215	.8583	.78	.9556
Min	.0671	.0648	.0678	.0838	.0648	.0747	.081
Avg	.3623	.3828	.7806	.3222	.2899	.3015	.3383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 201 / 11KV KOTHALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	1.6766	2.1605	1.7223	.3944	.4458	
2	.3963	1.829	2.2977	1.7528	.4287	.463	
3	.381	1.9052	2.2977	1.7833	.4458	.4801	
4	.3658	1.9814	2.3663	1.8138	.463		
5	.4801	2.0729	2.3834	1.8595	.4801	.5487	
6	.442	2.1338	2.3834	1.9662	.4973	.4115	
7		2.1338	2.5206	2.1338			
8		2.3167	2.7435	2.2405			
9		2.271	2.3472	2.452			
10	1.9547	.2058	.1829	.2058	2.1605		2.1776
11	2.572	.2401	.1981		2.5377		2.8121
12		.2572	.2286	.2743	2.7092		3.0693
13	2.7606	.2915	.2439	.2743	2.7435		3.035
14	2.8121	.3086		.2915	2.7435		2.9835
15	.2743	.2743	.2591	.3086	2.7263		2.9321
16	2.572	.3086	.2591	.3258	2.6406		2.8978
17		.3429	.1981	.3429	2.692		2.8635
18		.3601	.2896	.3772			.2401
19		.3944	.3506	.4115			.4458
20	.2743	.4115	.381	.4287			.5316
21	.3048	.4801	.3506	.463			.5144
22	.3201	.4458	.3506	.4287			.5144
23	.3353	.4115	.3048	.3944			.4973
24	.5144	1.6004	2.0062	1.6156	.3944	.4458	
Max	2.8121	2.3167	2.7435	2.452	2.7435	.5487	3.0693
Min	.2743	.2058	.1829	.2058	.3944	.4115	.2401
Avg	1.0110	1.0272	1.1784	1.0377	1.6038	.4658	1.8225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 202 / 11KV GURSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.2134	.3429	.2743	1.0974	1.0288	
2	.9945	.1981	.3429	.2743	1.1145	1.0974	
3	1.0288	.2439	.3086	.2896	1.1145	1.166	
4	.945	.2743	.3258	.3201	1.1317	1.1831	
5	1.0364	.2896	.3601	.3506	1.1317	1.2003	
6	1.0974	.3048	.3601	.3658	1.1488	1.2003	
7	1.2346				1.4746	1.4403	
8	1.2803				1.5432	1.5432	
9	1.3413				1.5775		1.5947
10	.2401	1.0974	.9907	1.3375	.2401		.1543
11	.2401	1.2346	1.4327	1.5947	.2401		.1543
12	.2229	1.2689	1.5394	1.7147	.2401		.1715
13	.2401	1.2689	1.4937	1.7147	.2401		.1715
14	.2401	1.3717	1.5089	1.7318	.2229		.1886
15	.2401	1.3717	1.5089	1.7318	.2229		.2058
16	.2401	1.406	1.4327	1.6975	.2229		.2058
17		1.4403	.9755	1.6461	.2229		.2058
18	.2134	.2401	.1524	.1543			.2572
19	.2286	.3086	.2439	.2229			.3086
20	.2591	.3258	.3048	.2915			
21	.2743	.3258	.2896	.3258			.3258
22	.2743	.3258	.2743	.3086			.3086
23	.2591	.3086	.2743	.2743			.2915
24	.9088	.2286	.3772	.2743	1.0974	.9259	
Max	1.3413	1.4403	1.5394	1.7318	1.5775	1.5432	1.5947
Min	.2134	.1981	.1524	.1543	.2229	.9259	.1543
Avg	.6079	.6689	.7066	.8045	.7935	1.1984	.3246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 203 / 11KV SHINDEWADI FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0061	.0061	.0069	.0061	.0069	.0069	
2	.0061	.0061	.0069	.0061	.0069	.0069	
3	.0061	.0061	.0069	.0061	.0069	.0069	
4	.0061	.0061	.0069	.0061	.0069	.0069	
5	.0061	.0061	.0069	.0061	.0069	.0069	
6	.0061	.0061	.0069	.0061	.0069	.0069	
7	.0061	.0061	.0069	.0061	.0069	.0069	
8	.0061	.0061	.0069	.0183	.0069	.0069	
9	.0061	.0061	.0183	.0206	.0069	.0069	.0069
10	.0069	.0069	.0122	.0206	.0069	.0046	.0069
11	.0069	.0069	.0122	.0206	.0069		.0069
12	.0069	.0069	.0183	.0206	.0069		.0069
13	.0069	.0069	.0183	.0206	.0069		.0069
14	.0069	.0069	.0122	.0206	.0069		.0069
15	.0069	.0069	.0183	.0206	.0069		.0069
16	.0069	.0069	.0183	.0206			.0069
17		.0069	.0061	.0206			.0069
18	.0061	.0069	.0061	.0206	.0069		.0069
19	.0061	.0069	.0061	.0206	.0069		.0069
20	.0061	.0017	.0061	.0206	.0069		.0069
21	.0061	.0069	.0061	.0206	.0069		.0069
22	.0061	.0069	.0061	.0206	.0069		.0069
23	.0061	.0069	.0061	.0206	.0069		.0069
24	.0061	.0061	.0069	.0061	.0069	.0154	
Max	.0069	.0069	.0183	.0206	.0069	.0154	.0069
Min	.0061	.0017	.0061	.0061	.0069	.0046	.0069
Avg	.0063	.0064	.0097	.0157	.0069	.0075	.0069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 204 / 11KV DHARMPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.5335	.6173	.5335	.5658
2	.4877	.5182	.6516	.5335	.5144
3	.5182	.5792	.6859	.5639	.4973
4	.5487	.6097	.703	.6097	.6173
5	.6097	.7011	.823	.6859	.7545
6	.7011	.7926	.8573	.7926	.8573
7	.7926	.6097	.7373	.6401	.7888
8	.6097	.4268	.5658	.4725	.6001
9	1.0974	.442	.4725	.5144	
10	.3944	.3944	.3963	.4458	
11	.4458	.4115	.3201		
12	.3658	.4287	.3963	.4458	
13	.3658	.4458	.3506	.4287	
14	.381	.4458		.4115	
15	.3963	.3944	.4458	.3772	
16	.3658	.4287	.4115	.3944	
17	.381		.3963	.4287	
18			.4115	.5144	
19		.6859	.5944	.6516	
20	.5944	.823	.7011	.7202	
21	.6706	.8916		.8059	
22	.6249	.823	.6097	.7373	
23	.6097	.7202	.5639	.6344	
24	.5639	.5792	.6173	.5335	.6001
Max	1.0974	.8916	.8573	.8059	.8573
Min	.3658	.3944	.3201	.3772	.4973
Avg	.5460	.5766	.5604	.5598	.6440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 205 / 11 KV MASUGADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.9145	.9774	.9145	.2915	.2743	
2	.1981	.9907	1.0288	.9297	.2915	.2743	
3	.2572	1.0364	1.0974	.945	.3086		
4	.3086	1.0669	1.2003	.9755	.3086		
5	.3048	1.2346	1.2689	1.0212	.3258		
6	.3772	1.326	1.4918	1.4175	.3601		
7		1.5242	1.8861	1.7071			
8		1.6766	2.0062				
9		1.5851	1.829	1.9033			
10	1.0974	.2058	.1981	.1886	1.5775		1.7147
11	1.6632	.4115	.1981	.2058	2.1605		2.1605
12	1.6118	.3601	.2134	.2229	2.1948		2.2805
13	1.6461	.2572	.2286	.2229	2.2291		2.1948
14	1.6804	.2743	.2286	.2058	2.0748		2.1091
15	1.6118	.2572	.2286	.1886	1.9204		1.9547
16	1.5775	.3086	.2286	.2058	1.8861		
17		.2401	.1981	.2229	1.8176		
18	.1981	.3086	.2591	.2572			
19	.2286	.3258	.2896	.3086			
20	.2743	.3601	.3353	.3601			
21	.2896	.3772	.3658	.3944			
22	.2743		.3658	.3429			
23	.2591	.3601	.3506	.3086			
24	.2572	.9774	.7888	.884	.2915	.2743	
Max	1.6804	1.6766	2.0062	1.9033	2.2291	.2743	2.2805
Min	.1981	.2058	.1981	.1886	.2915	.2743	1.7147
Avg	.7178	.7121	.7193	.6232	1.2026	.2743	2.0691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 206 / 11 KV KARUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.2591	.3429	.3201	1.0288	
2	.9145	.2439	.3601	.3201	1.0974	
3	.9907	.2743	.3772	.3353	1.1317	
4	1.0669	.3048	.4115	.3658	1.166	
5	1.1431	.3658	.4115	.3963	1.2003	
6	1.1888	.3963	.4287	.442	1.2346	
7	1.448				1.4403	
8	1.3717				1.5261	
9	1.0974				1.3889	1.4746
10	.2058	1.2689	1.2498	1.3032	.1715	.2229
11	.1886	1.5947	1.387	1.5604	.2229	.2058
12		1.6118	1.4937	1.7318	.2229	.1715
13		1.6289	1.6156	1.6461	.2058	.1715
14			1.4022	1.5261	.2058	.1543
15			1.3108	1.3717	.2058	.1543
16	.1886		1.2955	1.3717	.1886	.1886
17			1.1431	1.3717	.2058	.2229
18	.2286		.1677	.2058		.2572
19	.2591	.3258	.3048	.3086		.3429
20	.2896	.3601	.3963	.3429		.4115
21	.3048	.4115	.381	.3772		.3944
22	.2896	.3601	.3201	.3429		.3429
23	.2743	.3429	.3048	.3086		.3086
24	.8535	.2743	.3429	.3048	.9602	
Max	1.448	1.6289	1.6156	1.7318	1.5261	1.4746
Min	.1886	.2439	.1677	.2058	.1715	.1543
Avg	.6941	.6265	.7356	.7740	.7669	.3349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 207 / 11 KV MOROCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.2134	.2401	.2439	.7373	
2	.884	.2286	.2401	.2439	.7545	
3	.9145	.2439	.2572	.2439	.7888	
4	.9907	.2439	.2572	.2439	.8059	
5	1.0364	.2591	.2743	.2591	.8402	
6	1.0822	.2591	.2743	.2743	.8573	
7	1.2193				1.0631	
8	1.1888				1.166	
9	1.1431				1.1145	1.2517
10	.1715	1.2174	.8535	1.1488	.1029	.1543
11	.1372	1.4232	.9297	1.2003	.12	.1372
12	.0914	1.4746	1.0364	1.2689	.12	.12
13	.1219	1.4918	1.1584	1.2346	.1029	.12
14	.1219	1.3889	1.1431	1.2003	.1029	.12
15	.1067	1.406	.9907	1.1145	.0857	.1029
16	.1067	1.3375	1.0059	1.1145	.12	.1029
17	.1219	1.2689	.8383	1.1317	.1543	.12
18	.1524	.2401	.1372	.12		.1372
19	.1829	.2743	.2134	.2058		.2401
20	.1981	.2743	.2743	.2572		.2915
21	.2134	.2743	.2743	.2915		.2743
22	.2134	.2743	.2591	.2743		.2572
23	.2134	.2572	.2439	.2572		.2401
24	.823	.1981	.2401	.2439	.7202	
Max	1.2193	1.4918	1.1584	1.2689	1.166	1.2517
Min	.0914	.1981	.1372	.12	.0857	.1029
Avg	.5120	.6785	.5305	.5987	.5420	.2446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 201 / CHIKHARDE FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				1.5775
10				.4801
17	1.869			
19			.5487	
20			.6859	
21		.6001	.6344	
22			.6173	
Max	1.869	.6001	.6859	1.5775
Min	1.869	.6001	.5487	.4801
Avg	1.869	.6001	.6216	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 202 / NARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.6516
10			.5316
19		1.9376	
20		1.7147	
21	1.5432	1.5604	
22		.6344	
Max	1.5432	1.9376	.6516
Min	1.5432	.6344	.5316
Avg	1.5432	1.4618	.5916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 203 / YELAMB FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.4801
10			1.2003
19		.6001	
20		.6859	
21	.6001	.6001	
22		.6001	
Max	.6001	.6859	1.2003
Min	.6001	.6001	.4801
Avg	.6001	.6216	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 204 / forest Feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-APR-18
HR	Load (MW)
10	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 205 / Indapur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
9			.2743
10			.2229
19		.3258	
20		.4801	
21	.3429	.3772	
Max	.3429	.4801	.2743
Min	.3429	.3258	.2229
Avg	.3429	.3944	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 206 / Sawargaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
9			1.7318
10			1.3203
20		.2229	
21	.2058	.1886	
22		.1715	
Max	.2058	.2229	1.7318
Min	.2058	.1715	1.3203
Avg	.2058	.1943	1.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 201 / 11 KV PANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762	.0762	1.0059	1.0059	.9145	1.0059
2	.0943	.0762	.0762	.8383	1.1736	1.0669	1.2574
3	.0943	.0762	.0762	.6706	1.3413	1.2193	1.3413
4	.0943	.0762	.0762	.6706	1.5089	1.2955	1.3413
5	.0943	.0762	.0762	1.0059	1.8861	1.5242	1.4251
6	.0943	.0762	.0762	1.2574	1.9006	1.6766	1.4251
7	.0943	.0762	.0762	1.5927	1.8623	1.6766	1.829
8	.0943	.0762	.0762	1.5089	1.5089	1.6766	1.5242
9	.0943	.0762	.0838				
10	.0762	.0762	.0838				
15				.0943	.0762	.0838	.0762
16				.0943	.0762	.0838	.0762
17	1.5242	1.5242	2.0119	.0943	.0762	.0838	.0762
18	1.829	1.6766	2.0119	.0943	.0762	.0838	.0762
19	1.448	1.5242	1.7604	.0943	.0762	.0838	.0762
20	1.3717	1.3717	1.5089	.0943	.0762	.0943	.0762
21	1.2955	1.3717	1.3413	.0943	.0762	.0838	.0762
22	1.2193	1.2955	1.1736	.0943	.0762	.0838	.0762
23	1.0669	1.2193	1.0059	.0943	.0762	.0838	.0762
24	.8383	1.0669	.0762	1.0059	.0943	.0762	.0838
Max	1.829	1.6766	2.0119	1.5927	1.9006	1.6766	1.829
Min	.0762	.0762	.0762	.0943	.0762	.0762	.0762
Avg	.6399	.6562	.6482	.5781	.7204	.6606	.6622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 202 / 11 KV SAKAT AG FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3048	.3048	.0838	.0943	.0762	.0838
2	.3521	.3048	.3048	.0838	.0943	.0762	.0838
3	.3688	.3048	.3048	.0838	.0943	.0762	.0838
4	.4191	.3048	.3048	.0838	.0943	.0762	.0838
5	.503	.4572	.3048	.0838	.0943	.0762	.0838
6	.6706	.6097	.381	.0838	.0943	.0762	.0838
7	.8383	.7621	.5335	.0838	.0943	.0762	.0762
8	.7545	.7621	.1524	.0943	.0943	.0838	.0762
9				.3353	.8383	.7545	.6097
10				.7545	.6097	.8383	.7621
11					.9145	.8383	.7621
12					.9145	.8383	.6859
13					.8383	.7545	.6859
14					.8383	.7545	.6097
15	.0762	.0762	.0838		.8383	.6706	.6859
16	.0762	.0762	.0838		.7621	.6706	.6859
17	.0762	.0762	.0838		.0762	.0838	.0762
18	.0762	.0762	.0838	.0943	.0762	.0838	.0762
19	.0762	.0762	.0838	.0943	.0762	.0838	.0762
20	.0762	.0762	.0838	.0943	.0762	.0838	
21	.0762	.0762	.0838	.0943	.0762	.0838	.0762
22	.0762	.0762	.0838	.0943	.0762	.0838	.0762
23	.0762	.0762	.0838	.0943	.0762	.0838	.0762
24	.0943	.0762	.0762	.0838	.0943	.0762	.0838
Max	.8383	.7621	.5335	.7545	.9145	.8383	.7621
Min	.0762	.0762	.0762	.0838	.0762	.0762	.0762
Avg	.2771	.2540	.1901	.1424	.3307	.3083	.2906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 203 / 11 KV KALEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762	.0762	.0838		.0762	.0838
2	.0943	.0762	.0762	.0838		.0762	.0838
3	.0943	.0762	.0762	.0838		.0762	.0838
4	.0943	.0762	.0762	.0838		.0762	.0838
5	.0943	.0762	.0762	.0838		.0762	.0838
6	.0943	.0762	.0762	.0838		.0762	.0838
7	.0943	.0762	.0762	.0838		.0762	.0838
8	.0943	.0762	.0762	.0943		.0838	.0762
9	1.9281	2.0576	2.0957	.0943	.0943	.0838	.0762
10	1.829	2.0576	2.5463	.0943	.0762	.0838	.0762
11	1.829	2.21	2.3472				
12	1.829	2.1338	2.5149				
13	1.829	1.9052	2.3472				
14		1.9052	2.0957				
15	2.1338	1.829	2.0454				
16	2.4863	1.9052	2.2634				
17	.0762	.0762			2.3624	2.3472	2.7435
18		.0762	.0838	2.5149	2.2862	2.431	2.6673
19	.0762	.0762	.0838	2.5149	2.1338	2.0957	2.4387
20	.0762	.0762	.0838	2.0957	1.829	2.0119	1.9814
21	.0762	.0762	.0838	2.0119	1.5242	1.7604	1.7528
22	.0762	.0762	.0838	1.9784	1.5242	1.6766	1.6766
23	.0762	.0762	.0838	1.9448	1.5242	1.6766	1.6766
24	.0943	.0762	.0762	.0838		1.2193	1.6766
Max	2.4863	2.21	2.5463	2.5149	2.3624	2.431	2.7435
Min	.0762	.0762	.0762	.0838	.0762	.0762	.0762
Avg	.6896	.7176	.8454	.8243	1.4838	.8891	.9683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 204 / 11 KV OLD GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.1715	.2572	.1677	.415	.1715	.1886
2	.3395	.1715	.2572	.2075	.4527	.1715	.1886
3	.3584	.2572	.2572	.2829	.4904	.2572	.2829
4	.3772	.3429	.3429	.3772	.5093	.3429	.3772
5	.415	.4287	.4287	.4715	.5281	.3429	.4715
6	.3944	.6001	.6001	.6602	.547	.4287	.5658
7	.4715	.5144	.5487	.6036	.5658	.5144	.6036
8	.5658	.5144	.5144	.5658	.5658	.6602	.4287
9	.4715	.463	.5658	.3429	.4904	.4715	.4287
10	.2743	.3429	.3772	.3772	.4458	.3772	.4287
11	.1715	.2572		.2829	.2572	.2829	.2572
12	.1715	.2572	.2829	.3018	.1886	.1886	.1715
13	.1715	.2058	.1886	.3206	.1715	.1886	.1715
14	.1715		.1886	.2263	.1715	.1886	.1715
15	.1715	.2058	.1886	.2452	.1715	.1886	.1715
16	.1715	.2572	.2263	.2641	.1715	.2075	.1715
17	.1715	.2572	.2263	.2829	.2572	.2263	.2572
18	.2572	.2572	.3395	.5658	.4287	.3395	.3429
19	.5144	.5144	.4715	.5658	.463	.5658	.463
20	.5144	.6001	.6036	.6602	.5144	.6036	.6001
21	.4287	.5144	.4715	.5658	.4287	.5281	.4287
22	.3429	.4287	.3772	.4715	.4287	.4191	.3429
23	.2572	.3429	.2829	.415	.2572	.3772	.2572
24	.3772	.1715	.2572	.2263	.3772	.1715	.3772
Max	.5658	.6001	.6036	.6602	.5658	.6602	.6036
Min	.1715	.1715	.1886	.1677	.1715	.1715	.1715
Avg	.3299	.3511	.3589	.3938	.3874	.3422	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 205 / 11 KV NEW PANGAON GAOTHAN SEPARATED GAOTHAN FEEDERS
FEED Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1715	.1715	.1886	.1886	.1715	.1886
2	.1509	.1715	.1715	.1886	.1886	.1715	.1886
3	.1886	.1715	.1715	.2263	.2263	.2058	.2263
4	.2829	.2572	.2572	.2641	.3018	.2743	.2641
5	.3395	.3429	.3086	.3395	.3772	.3429	.3395
8	.2829	.2572	.2743	.3206	.3395	.2829	.2572
9	.2829	.2229	.2829	.2743	.2641	.2641	.2229
10	.2229	.1886	.2263	.2075	.2058	.2263	
11	.1715	.1715	.1886	.1698	.1543	.1698	.1715
12	.12	.1715	.1698	.132		.1698	.1543
13	.12	.1543	.1698	.1509	.1372	.1509	.1372
14	.12		.1698	.1509	.12	.1509	.12
15	.1543	.1543	.1698	.1509	.12	.1698	.12
16	.1543	.1543	.1698	.1698	.1372	.1698	.1372
17	.1715	.1543	.1698	.1698	.1715	.1886	.1715
18	.1886	.1715	.2075	.2641	.1886	.1886	.2572
19	.3429	.2572	.2452	.2829	.2572	.2829	.2915
20	.3429	.2915	.2829	.3584	.3429	.3018	.3429
21	.2572	.3086	.2829	.2829	.2572	.2829	.3429
22	.2229	.2401	.2641	.2263	.2229	.2641	.2572
23	.1886	.2058	.1886	.1886	.1715	.2263	.2229
24	.1886	.1715	.1715	.1886	.1886	.1715	.1886
Max	.3429	.3429	.3086	.3584	.3772	.3429	.3429
Min	.12	.1543	.1698	.132	.12	.1509	.12
Avg	.2120	.2090	.2143	.2225	.2172	.2194	.2191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 207 / 11 KV BARAMATI AGRO EXP. NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0113	.0091	.0171	.0168	.0189	.0091	
2	.0132	.0107	.0171	.0168	.0189	.0091	
3	.0113	.0091	.0171	.0168	.0189	.0091	.0168
4	.0132	.0107	.0171	.0168	.0189	.0091	
5	.0113	.0091	.0171	.0168	.0113	.0091	.0168
6	.0132	.0091	.0171	.0168	.0113	.0091	.0168
7	.0113		.0171	.0168	.0113	.0091	
8	.012	.0091		.0189			.0152
9		.0107		.0189		.0168	.0171
10		.0171	.0168	.0189			.0091
11			.0168	.0113		.0168	
12				.0113		.0168	
13	.0057					.0168	
14	.0091	.0171				.0168	
15	.0091				.0061		
16				.0189			
17	.0122		.0168	.0189		.0168	
18		.0171	.0168	.0189		.0168	
19		.0171	.0168	.0189		.0168	
20	.0107		.0168	.0189	.0091		
21	.0107	.0171	.0168	.0189	.0091		
22	.0107	.0171	.0168	.0189	.0091	.0168	
23	.0107	.0171	.0168	.0189	.0091	.0168	
24	.0113	.0107	.0171	.0168	.0189	.0091	.0168
Max	.0132	.0171	.0171	.0189	.0189	.0168	.0171
Min	.0057	.0091	.0168	.0113	.0061	.0091	.0091
Avg	.011	.013	.0169	.0174	.0131	.0134	.0155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 201 / 11 KV Raleras SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	25-APR-18
HR	Load (MW)	Load (MW)
3	1.7147	
7	1.9814	.0762
8	1.9814	.0762
24	.7716	.0762
Max	1.9814	.0762
Min	.7716	.0762
Avg	1.6123	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 204 / 11 KV VAIRAG Urban Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	25-APR-18
HR	Load (MW)	Load (MW)
3	.7621	
7	.9145	1.0669
8	.9145	.9907
24	.7621	.9145
Max	.9145	1.0669
Min	.7621	.9145
Avg	.8383	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 205 / 11 KV IRLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	25-APR-18
HR	Load (MW)	Load (MW)
7	.061	1.3717
8	.0457	1.5242
24	.0457	.6097
Max	.061	1.5242
Min	.0457	.6097
Avg	.0508	1.1685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 202 / 11 KV SAROLE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0576	2.332	2.1434			
9	2.0919	2.2634	2.3148			
10	2.3148	2.2977	2.3148			
11	2.3148	2.332				
12	2.332	2.2291				
13	2.3148	2.2291				
14	2.3148	2.1948				
15	2.332	2.1605				
16				2.2291	2.1948	2.1434
17				2.4006	2.2634	2.2291
18				2.4006	2.332	2.1262
19				2.4006	2.4006	2.3148
20					2.4006	2.3148
21				2.4006	2.4006	2.3148
22				2.4006	2.332	2.3148
23				2.1948	2.332	2.3148
Max	2.332	2.332	2.3148	2.4006	2.4006	2.3148
Min	2.0576	2.1605	2.1434	2.1948	2.1948	2.1262
Avg	2.2591	2.2548	2.2577	2.3467	2.332	2.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 204 / Rui SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2229	.1715	.1715	.2058	.2058
2	.1715	.2058	.2229	.2058	.1715	.2058	.2058
3	.2058	.2401	.2401	.2058	.2058	.2229	.2058
4	.2401	.2915	.3086	.2401	.2572	.2572	.2743
5	.2743	.3601	.3086	.3086	.3772	.3086	.3086
6	.4801	.4801	.4458	.4458	.4287	.4973	.4801
7	.4287	.4458	.4801	.4801	.4115	.4115	
8	.5487	.5658	.5487	.5487			
9	.4287	.6859	.6173	.583			
10	.5487	.6001		.583	.2058	.1219	.2058
11		.5487	.6001		.1543	.1372	.1715
12	.5658	.5144	.6001		.1372	.1372	.1715
13	.5487	.5144	.5144		.1372	.1372	.1372
14	.5487	.5144	.4801		.1029	.1372	.1372
15	.5144	.5144	.4801		.0857	.1372	.1372
16	.1029	.1372	.1372			.3086	.4115
17	.1372	.1372	.1372			.463	.4801
18	.1886		.1715			.4801	.4458
19	.3429	.3429	.3086	.2743	.4287	.4801	.4115
20	.4115	.3258	.3429	.3429		.4287	.4115
21	.2743	.3429	.3429	.2743	.4287	.4115	.4115
22	.2401	.2401	.2401	.2743	.3429	.4115	.4115
23	.2058	.2058	.2058	.2058	.2743	.4115	.4115
24	.1715	.2058	.1715	.1715	.1715	.2058	.2058
Max	.5658	.6859	.6173	.583	.4287	.4973	.4801
Min	.1029	.1372	.1372	.1715	.0857	.1219	.1372
Avg	.3370	.375	.3534	.3322	.2496	.2963	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 201 / 11 KV MALWANDI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7621		
2			.9907		
3	.6706		.9907	.1006	.1006
4		1.0059	1.0364		
5			1.1584		
6	1.5927		1.2193	.2012	.1006
7			1.5242		
8		1.6766			
9		1.3717	1.1431	.0838	.1174
10	.1006	.0572	.0457	.0838	
11		.0572	.0572		
12		.0572	.0572		
13		.0572	.0572		1.8442
14		.0686	.0572		
15	.0838	.0686	.0572		
16		.0572	.0572		
17		.0914	.0572		1.5089
18	.1341	.1143	.0572		
19		.1715	.0914		
20		.0914	.0914		
21		.1143	.1029		
22	.1677	.1372	.1257		
23	.1341	.1143	.1143	.1677	
24	.3353	.503	.5487	.1509	.1341
Max	1.5927	1.6766	1.5242	.2012	1.8442
Min	.0838	.0572	.0457	.0838	.1006
Avg	.4024	.3230	.4523	.1313	.6343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 202 / 11 KV GULPOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572		
2			.0572		
3	.0671		.0572	.503	.6706
4		.0838	.0572		
5			.0686		
6	.0838		.0686	1.0059	1.5089
7			.0686		
8		.1174			
9		.0686	.0572	1.5089	1.4251
10	.0762	.0572	.0572	.0838	
11		.4115	.6401		
12		1.2193	1.2955		
13		.9145	1.5242		.0838
14		1.2742	1.4632		
15	1.2193	1.2193	.8535		
16		1.3108	1.3717		
17		1.3717	1.4632		.0838
18	1.6766	1.448	1.5242		
19		.0762	.0686		
20		.0686			
21		.08	.08		
22	.1174	.08	.08	.1341	
23	.1006	.0686	.08	.1174	
24	.0671	.0838	.0686	.4191	.4191
Max	1.6766	1.448	1.5242	1.5089	1.5089
Min	.0671	.0572	.0572	.0838	.0838
Avg	.4260	.5530	.5028	.5389	.6986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 203 / 11 KV SURDI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0914		
2			.0914		
3	.1341		.0914	.6706	.6706
4		.1341	.1143		
5			.1372		
6	.2515		.16		2.364
7			.1829		
8		.2515			
9		.1372	.1143	1.3748	2.079
10	.1677	.1029	.1219		
11		1.3108	.8535		
12		1.9662	1.8747	.1677	
13		1.9814	1.829		.1174
14		1.6766	1.829		
15	2.0957	1.7375	1.829		
16		1.9204	1.829		
17		2.1643	1.9204		.1174
18	2.2634	2.21	2.0271		
19		.0914	.0914		
20		.1257	.1372		
21		.1486	.16		
22	.1677	.1029	.1372	.2515	
23	.1677	.0914	.1143	.218	
24	.1341	.1341	.0914	.6036	.5197
Max	2.2634	2.21	2.0271	1.3748	2.364
Min	.1341	.0914	.0914	.1677	.1174
Avg	.6727	.9048	.6882	.5477	.9780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 206 / 11 kV Turk-Pimpri AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686		
2			.08		
3	.1006		.08	.4359	.7545
4		.0838	.08		
5			.08		
6	.1341		.08	.7209	1.4419
7			.08		
8		.0838			
9		.0572	.0457	.8718	1.3748
10	.0838	.0457	.0457	.0838	
11		.5487	.6401		
12		1.2193	1.2498		
13		1.2193	1.2803		.1174
14			1.2803		
15	1.1736		1.2193		
16		1.1584	1.1584		
17		1.2498	1.0974		.0838
18	1.2574	1.3108	1.0669		
19		.0914	.0686		
20		.0686	.08		
21		.0686	.08		
22	.0838	.0686	.08	.1341	
23	.0838	.0686	.08	.1341	
24	.1006	.0838	.0686	.3353	.3353
Max	1.2574	1.3108	1.2803	.8718	1.4419
Min	.0838	.0457	.0457	.0838	.0838
Avg	.3772	.4642	.4387	.3880	.6846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 201 / 11 KV SOUNDARE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9088	.9431	.0514	.0457	.0457	.12
2	.9774	.9774	.9774	.0514	.0457	.061	.12
3	1.0288	1.0631	1.046	.0514	.0305	.0457	.12
4	1.1145	1.1317	1.1145	.0514	.0305	.0457	.12
5	1.2003	1.166	1.1831	.0514	.0305	.0457	.12
6	1.2174	1.5261	1.2346	.0514	.0305	.0457	.12
7	1.7147	1.6289	1.5604	.0343	.0514	.0457	.12
8	1.6118	1.6975	.4973			.0914	.0686
9	.0514	.0857	.0514		1.4918	1.1584	1.0117
10	.0514	.12	.0514		1.6118	1.2803	1.2174
11		.0686	.0857		1.5432	1.3108	1.2689
12			.0686		1.5089	1.3108	1.2517
13			.0686		1.4403	1.406	1.2517
14	.0686		.1372		1.3889	1.3546	1.2689
15	.12	.0514	.0857		1.4575	1.3717	1.2517
16	.1029	.0514	.1543		1.3546	1.406	1.3546
17	.0857	.0514	.0686			.0514	
18	.12	.0514	.0686		.0514	.1372	
19	.1029	.0514	.1372	.061	.0457	.1143	.0686
20	.12	.0514	.0686	.0457	.061	.1715	.0686
21	.12	.0514	.0686	.0457	.061	.1886	.0857
22	.1029	.0514	.0857	.0457	.061	.1715	.0857
23	.12	.0514	.0857	.0457	.061	.1543	.0857
24	.0514	.12	.0514	.0514	.061	.061	.1543
Max	1.7147	1.6975	1.5604	.061	1.6118	1.406	1.3546
Min	.0514	.0514	.0514	.0343	.0305	.0457	.0686
Avg	.5250	.5217	.4122	.0491	.5665	.5031	.5152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 203 / 11 KV KASARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0857	.0514	.0514	.0457	.061	.0514
2	.0514	.1029	.0514	.0514	.0305	.061	
3	.0514	.1029	.0514	.0514	.0305	.0457	.0514
4	.0514	.0686	.0514	.0514	.0305	.0457	.0514
5	.0514		.0514	.0514		.061	.0514
6	.0514	.0514	.0514	.0514	.0305	.0457	.0514
7	.0514	.0686	.0514	.0686	.0514	.0457	.0686
8	.0514	.1029	.0514	.1029	.0686	.0762	.1029
9	2.0919	1.6804	1.9033	.1029	.0686	.0457	.1029
10	2.2462	1.989	1.9719	.1372	.1029	.0457	.0857
11	2.4006	2.1776	2.0919	.1067	.0514	.0457	.0857
12	2.2462		2.2119	.1067	.0514	.0457	.0857
13	2.2634	2.1434	2.2119	.1067	.0514	.0686	.0857
14	2.0405	2.1091	2.2634	.0914	.0686		.0857
15	2.0062	1.8347	2.1605	.0762	.0686	.0686	.0857
16	2.0405	1.9719	2.1776	.0762	.0514	.0686	
17	.0686	.0686	.0514	1.6766		1.5661	2.2291
18	.0857	.0686		1.768	2.3148	2.452	2.572
19	.1029	.0686	.1029	1.7071	1.9052	2.1948	2.1262
20	.1029	.0686	.0857	1.6766	1.7071	2.0233	
21	.1029	.0686	.0857	1.5089	1.6766	1.989	2.0233
22	.1029	.0514	.0857	1.5089	1.6309	1.9204	1.9719
23	.1029	.0514	.0857	1.4937	1.6004	1.869	1.9033
24	.0514	.1029	.0514	.0514	1.4784	1.5394	1.8176
Max	2.4006	2.1776	2.2634	1.768	2.3148	2.452	2.572
Min	.0514	.0514	.0514	.0514	.0305	.0457	.0514
Avg	.7695	.6835	.7805	.5281	.5962	.7124	.7471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 204 / KASARWADI GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3429	.3772	.3429	.4458	.463	.5144
2	.4458	.3086	.3772	.3429	.4458	.463	.5144
3	.4458	.3086	.3772	.3429	.4458	.463	.5144
4	.4458	.3086	.4287	.3429	.4458	.4801	.5144
5	.5144	.3429	.4801	.4287	.4973	.5487	.5144
6	.6001	.4287	.5144	.5144	.6344	.5658	.5144
7	.5144	.3944	.5487	.6001	.4287	.5316	.4287
8	.4973	.4115	.3429	.4287	.5144	.4458	.3429
9	.4287	.3944	.4287	.4287	.3772	.3601	.4287
10	.3772	.3086	.3429	.4287	.3429	.3601	.4287
11	.1715	.3258	.2572	.3601	.3258	.3258	.3429
12	.1715		.2572	.3429	.3086	.2915	.3086
13	.2915	.3086	.2572	.3258	.3429	.3086	.3086
14	.2572	.2915	.2572	.3258	.3601	.2572	.2572
15	.1715		.1715	.3086	.3429	.2572	.2401
16	.1715	.3258	.2572	.3086	.3772	.2572	.3258
17	.2572	.3944	.3429	.2915		.2572	.3429
18	.3258	.4115	.2572	.2915	.4801	.3086	.3258
19	.463	.4801	.4801	.5658	.6344	.5144	.4801
20	.583	.6001	.5144	.5487	.6173	.6516	.6173
21	.4458	.6001	.4287	.5144	.6001	.5144	.5487
22	.4287	.4973	.0857	.5316	.6001	.6516	.5144
23	.4115	.4801	.3429	.5144	.6001	.4287	.4973
24	.5144	.3772	.4287	.3429	.5316	.4115	.5144
Max	.6001	.6001	.5487	.6001	.6344	.6516	.6173
Min	.1715	.2915	.0857	.2915	.3086	.2572	.2401
Avg	.3908	.3928	.3565	.4072	.4652	.4215	.4308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 205 / 11 KV Maruti Technofab NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.1886	.2401	.1886	.0857	.1543
2	.1715	.2058	.1886	.2401	.1886	.0857	.1715
3	.1715	.1886	.2058	.2401	.2058	.0857	.1715
4	.1715	.1715	.2058	.2401	.2058	.0857	.1715
5	.1715	.1715	.1886	.2229	.2058	.0857	.1715
6	.1715	.1886	.1886	.2229	.2058	.0857	.1715
7	.1715	.2058	.2229	.2058	.0857	.1029	.0857
8	.1886	.1886	.2229	.0857	.12	.0857	.12
9	.2229	.2229		.0857	.1886	.2058	.1372
10	.2058	.2401	.2572	.0857	.1886	.2229	
11	.2401	.2572	.2229	.0686	.1886	.2572	.12
12	.2229	.2229	.2743	.0686	.2058	.2572	.1715
13	.2572	.2229	.2229	.0686	.1886	.2915	.2401
14	.2229	.2401	.2229	.0686	.1886	.1543	.2058
15	.2058	.2229	.2058	.0686	.2058	.2058	.12
16	.2229	.2401	.2058	.0686	.2058	.2915	.1372
17	.2058	.2743	.2572	.0686		.2572	.1372
18	.2058	.2572	.12	.061	.0857	.2401	.1372
19		.2401	.2229	.12	.0857	.2743	.2058
20	.1029	.2229	.2229	.12	.0857	.1543	.1715
21	.1543		.2229	.12	.0857	.1372	.1543
22	.1886	.2058	.2058	.1372	.0857	.1372	.1543
23	.2058	.2229	.2058	.1886	.0857	.1543	.1543
24	.1543	.1886	.2229	.2401	.1886	.0857	.1543
Max	.2572	.2743	.2743	.2401	.2058	.2915	.2401
Min	.1029	.1543	.12	.061	.0857	.0857	.0857
Avg	.1916	.2155	.2132	.1390	.1595	.1679	.1573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 203 / Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5541						
9	.6081						
10	.6241						
11	.5921						
12	.5967						
13	.4938						
14	.4843						
15		.7116	.6722		.679		.6401
16		.7842	.8002	.7362	.7562	.7968	.7621
17		.4938	.8036	.7682	.9568	.8749	.8213
18		.6327	.9134	.7682	.9804	.8905	.8393
19		.7042	.7668	.8002	.6401	.8592	.7545
20		.6722	.6653	.7202	.5921	.828	.6415
21		.6327	.661	.6401	.5761	.703	.5937
22		.6401	.6153	.6081	.5441	.703	.5838
Max	.6241	.7842	.9134	.8002	.9804	.8905	.8393
Min	.4843	.4938	.6153	.6081	.5441	.703	.5838
Avg	.5647	.6589	.7372	.7202	.7156	.8079	.7045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 204 / Shelgaon(m)Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.108	.064	.0922	.08	.0646	.0926
2	.0836	.0926	.064	.0769	.08	.064	.0926
3	.08	.0772	.064	.0615	.064	.064	.0926
4	.08	.0772	.064	.0615	.064	.064	.0772
7	1.8724						
8	1.8404						
9	1.8244						
10	1.8084						
11	1.8461						
12	1.8244						
13	1.7604						
14	1.7284						
15		1.5375	1.6004		1.6091	1.5413	1.6821
16		1.5836	1.7604	1.5684	1.6821	1.7071	1.9136
17			1.6451	1.7604	1.821	1.8056	2.032
18		1.7284	1.8142	1.8404	1.8701	1.7284	1.9704
19		1.7924	1.722	1.9204	1.8435	1.5123	1.5721
20	.1543	1.5364	1.5836	1.7604	1.8027	1.4815	1.5259
21	.1389	1.4723	1.5067	1.6004	1.7604	1.4352	1.5259
22	.1235	1.4243	1.476	1.5203	1.3763	1.3889	1.3872
23	.1235	.08	.0922	.08	.096	.108	.0771
24	.0766	.1235	.064	.0615	.064	.064	.108
Max	1.8724	1.7924	1.8142	1.9204	1.8701	1.8056	2.032
Min	.0766	.0772	.064	.0615	.064	.064	.0771
Avg	.9085	.8949	.9658	.9542	1.0152	.9306	1.0107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 205 / DEVGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4251	.6964	.6401	.7117	.8097	.8642	.8162
2	1.4089	.6478	.6401	.7279	.8097	.8322	.8002
3	1.4251	.6154	.6401	.7279	1.0526	.8322	.7682
4	1.4379	.6478	.6462	.7593	1.1336	.8322	.8002
5	1.6194	.7287	.7682	.9047	1.2955	.9602	1.0402
6	1.8724	.8421	1.0562	1.244	1.3765	1.2963	1.2163
7		2.2996	2.3365	2.6042	2.915	1.0883	2.3482
8		2.6235		2.4326	3.0769	.9282	2.5425
9		2.6397					1.7166
10		2.4263			2.834		2.0243
11		2.3454	.7125		2.3482	1.8601	2.1052
12			1.7814			1.9895	1.9109
13		.7279	2.4291		1.0883	2.3967	2.1376
14		.922	2.1376		.9922	1.6822	2.0567
15	.9922						
16	1.0562						
17	1.2955						
18	1.3279						
19	1.2146						
20	1.1012						
21	.8907						
22	.8421						
23	.8002	.7042	.7441	.8097	.9922	.8482	.8907
24	1.6337	.7287	.6882	.7441	.7287	.9122	.8322
Max	1.8724	2.6397	2.4291	2.6042	3.0769	2.3967	2.5425
Min	.8002	.6154	.6401	.7117	.7287	.8322	.7682
Avg	1.2714	1.3064	1.1708	1.1666	1.5324	1.2373	1.5004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 201 / Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2641		.2401	.2587	.3018	.2957
2	.2401	.2641	.2641	.2058	.2587	.3018	.2957
3	.2401	.2641	.2829	.2401	.2614	.3018	.2987
4	.3086	.3395	.3772	.2743	.3734	.3395	.3361
5	.4115	.415	.4527	.3772	.4481	.4527	.4108
6	.4801	.4527	.5847	.4458	.5975	.6036	.5228
7	.4115	.4527		.4115	.5544	.5658	.4854
8	.3429	.4527	.3772	.4108	.4481	.4527	.4024
9	.3429	.3395	.3429	.362	.4024	.3395	.3772
10	.3018	.2715	.2743	.2454		.3018	.2401
11	.2641	.2172	.2401	.2507	.2987	.2126	.2058
12	.1886	.1991	.2058		.2241	.2058	.1886
13	.2263	.1991	.1886	.2103	.2614	.2149	.1715
14	.2263	.1991	.1677	.2103	.2241	.2172	.1715
15	.2263	.1991	.1677	.2103	.2241	.2172	.1715
16	.1886	.1991	.2058	.2481	.1867	.2126	.1886
17	.1886	.181	.1677	.2481	.2263	.2534	.2058
18	.3018	.2172	.2401		.2614	.3224	.2401
19		.3841	.3429	.4298	.3734	.3982	.3772
20	.4904	.4435	.4458	.4755	.4481	.439	.4458
21	.4527	.4066		.4755	.4108	.4344	.3086
22	.3772	.3511		.3696	.3734	.362	.3086
23	.3395			.3326	.3361	.3326	.3086
24	.2401	.2641	.2641	.2743	.2957	.3018	.3326
Max	.4904	.4527	.5847	.4755	.5975	.6036	.5228
Min	.1886	.181	.1677	.2058	.1867	.2058	.1715
Avg	.3042	.3033	.2943	.3158	.3368	.3369	.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 202 / Shripat-Pimpri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432		.2614	.2058	.2614	.2614	.2587
2	1.6461		.2614	.1715	.2614	.2614	.2587
3	1.7833		.2614	.1715	.2614	.2614	.2587
4	1.8861		.2614	.1677	.2534	.1867	.2587
5	1.8595		.2614	.1886	.2534	.1867	.2587
6	2.1338		.2614	.1715	.2534	.1867	
7	2.5911						
8	2.8349						
9	2.8654						
11		2.3967	2.6216	3.0445	2.5873	2.332	1.6461
12		3.0445	2.9264	3.3482	3.5475		2.5911
13		2.753		2.4939	3.4541	3.083	2.6216
14				2.9492	2.0538	3.3303	2.5911
15		3.2712		3.3097	2.8006	2.982	2.5606
16				2.2024	2.8006	2.9835	2.8045
17				3.2487	3.1741	2.9172	2.7435
18		3.1741		3.1131	3.4915	3.0803	2.774
19			.2572	.1791	.2103	.2126	.2229
20			.3086	.2987	.2241	.2614	.2572
21		.2987		.2614	.2614	.2614	.2229
22		.2987		.2587	.2614	.2987	.2058
23				.2587	.2614	.2987	.2058
24	1.2346		.2614	.1829	.2614	.2614	.2957
Max	2.8654	3.2712	2.9264	3.3482	3.5475	3.3303	2.8045
Min	1.2346	.2987	.2572	.1677	.2103	.1867	.2058
Avg	2.0378	2.1767	.7221	1.3113	1.3467	1.2446	1.2124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 203 / Shendri Feeder AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.9145		1.0974	1.1961	1.0288	1.0288
2	.1524	.9145		.9069	1.4449	1.1431	.9739
3	.1829	1.1431		1.2269	1.6857	1.3575	1.587
4	.2134	1.2955	1.3717	1.2803	2.146	1.6004	1.7814
5	.1867	1.5623	1.7528	1.5653	2.3967	1.8671	2.2348
6	.16	1.9528	1.9509	1.8595	2.6558	2.0005	2.3644
7		2.5911	2.4691	2.4387	3.3036	2.6673	2.2497
8		2.4387	1.829	2.5154	2.6566	2.332	4.5096
9		2.2862	2.0729	2.3746	2.5621		
11	1.829						
12	3.0483						
13	2.7435						
14	2.8121						
15	2.8902						
16	2.8121						
17	2.4387						
19			.1143	.1627	.2195	.1734	.1467
20	.1943	.1467	.1829	.2317	.2286	.1947	.1715
21	.1943	.16		.2054	.2	.1947	.2
22	.1619	.16		.1646	.1646	.176	.1734
23	.1619			.1646	.1646	.1486	.1734
24	.1829	.9145	1.0364	.9755	.8901	.9602	.9305
Max	3.0483	2.5911	2.4691	2.5154	3.3036	2.6673	4.5096
Min	.1524	.1467	.1143	.1627	.1646	.1486	.1467
Avg	1.1398	1.2677	1.42	1.1446	1.4610	1.1317	1.3232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 201 / 11 KV Gaudgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6516	.6859	.6097	.5144	.5658	
2	.7716	.6516	.6859	.6097	.5144	.5658	
3	.7716	.6173	.6859	.6097	.5487	.5658	
4	.7716	.6173	.7202	.6097	.583	.6001	
5	.8059	.6173	.7545	.6859	.6516	.6516	
6	.8745	.9431	.9945	.7621	.9259	.8573	
7	1.0631	1.166	1.1145	.8383	.8573	.8916	
8	1.0631	1.0974	1.0288	.8688	.823	.7202	.6401
9	.7545	1.0631	.9145	.9602			.583
10	.4801	.583	.4115	.8573	.5658		.5144
11	.4801	.4801	.4115		1.0288		.6516
12	.4801	.4801	.4115		1.0288		.823
13	.4458	.4801	.4115		1.0288		.8573
14	.4801	.4801			1.0288		.823
15	.4458	.4801	.4115		1.0631		.8916
16	.4801	.4801	.4115		1.0631		.9259
17	.4458	.4458			.9945		.9602
18	.5144	.5144	.5792	.6173	1.0288		.9602
19	.7716	.7888	.6401	.823	.7202		.7202
20	.8573	.8916	.7773	.8916	.8573		.9259
21	.7716	.7888	.6859	.823	.8916		.7545
22	.6516	.6859		.6859	.823		.7202
23	.6173	.6173	.5487	.6173	.7202		.6173
24	.7202	.6173	.6859	.5487	.5487	.5658	
Max	1.0631	1.166	1.1145	.9602	1.0631	.8916	.9602
Min	.4458	.4458	.4115	.5487	.5144	.5658	.5144
Avg	.6787	.6766	.6653	.7305	.8178	.6649	.7730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 202 / 11 KV Raulgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.2003	1.1317	1.0974	.3086	.3429	
2	1.4918	1.2003	1.1317	1.0974	.3086	.3429	
3	1.4918	1.2689	1.166	1.0974	.3429	.3429	
4	1.4918	1.3032	1.2003	1.1431	.3429	.3772	
5	1.5432	1.3032	1.3032	1.2803	.4801	.5487	
6	1.6118	1.6804	1.5775	1.4175	.6859	.6516	
7	2.0919	2.0233	2.0233	1.5242	.5487	.6859	
8	1.7833	1.4403	1.8519	1.5699	.5144	.5487	.5487
9	1.6461	1.7833	1.6766	1.7147	.4801		.4458
10	.3772	.3429	.2896	1.5089	.463		.3429
11	.2743	.2743	.2286		1.7147		1.2003
12	.2401	.2401	.2134		1.8861		1.5432
13	.2401	.2058	.2134		2.0576		1.5089
14	.2401	.2058	.2134		2.0576		1.3717
15	.2058	.2058	.2134		2.0576		1.4575
16	.2058	.2401	.2286		2.0576		1.9547
17	.2401	.2401	.2439		1.7147		1.8004
18	.3086	.2743	.3506	.4458	1.8861		1.6461
19	.5487	.4801	.4572	.583	.5487		.6173
20	.7202	.6516	.5182	.6859	.6859		.6859
21	.5144	.4801	.4572	.4801	.6173		.5144
22	.4115	.4115	.3506	.3772	.5144		.4115
23	.3772	.3772	.3201	.3772	.4115		.3429
24	1.406	1.0631	1.0631	.9755	.3429	.3429	
Max	2.0919	2.0233	2.0233	1.7147	2.0576	.6859	1.9547
Min	.2058	.2058	.2134	.3772	.3086	.3429	.3429
Avg	.8731	.7873	.7676	1.0221	.9595	.4649	1.0245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 203 / 11 KV Bhalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3086	.2743	1.749	1.7147	
2	.3086	.3086	.3086	.2743	1.749	1.7147	
3	.3086	.3086	.3086	.2743	1.7147	1.7147	
4	.3086	.3429	.3429	.2743	1.7147	1.8004	
5	.4287	.4115	.3772	.381	1.7147	2.0233	
6	.583	.5487	.5144	.503	2.1262	2.3148	
7	.5144	.5487	.5144	.4572	2.4348	2.572	
8	.5144	.5144	.4115	.4268	2.2977	2.1434	1.89
9	.3772		.3048	.4287	2.2291		2.0919
10	.3429	.3429	.2439	.3086	.3429		.2743
11	1.7147	1.6461	1.6004				.2401
12	2.2634	2.0233	1.7833		.2572		.2743
13	2.1605	2.1605	1.9509		.2572		.2401
14	2.0919	2.1262	1.9966		.2572		.2401
15	2.1948	2.1948	1.9966		.2229		.2401
16	2.0576	2.2977	1.9966		.2229		.2743
17	1.8176	2.2977	1.9966		.2572		.2743
18	1.8176	1.9719	1.9052	.3772	.3086		.3429
19	.3429	.4115	.3506	.5487	.5144		.4801
20	.5487	.583	.4572	.6516	.6001		.5487
21	.4801	.4801	.3658	.5144	.6001		.4801
22	.4115	.4458	.3201	.3772	.5658		.4115
23	.3429	.3429	.3048	.4115	.5144		.3429
24	.3429	.3086	.3086	.2743	1.7147	1.7147	
Max	2.2634	2.2977	1.9966	.6516	2.4348	2.572	2.0919
Min	.3086	.3086	.2439	.2743	.2229	1.7147	.2401
Avg	.9409	.9967	.8737	.3975	1.0594	1.9681	.5404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 201 / 11 Kv pathari Gaothan

GAOTHAN FEEDER

feeder Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.12	.1715	.1372	.1372	.1372	.1372
2	.1715	.1029	.1715	.1372	.1372	.1372	.1029
3		.1715	.1543	.1372	.1715	.1372	.1029
4	.1886	.2058	.2401	.2058	.2401	.2058	.1715
5	.2743	.2743	.3086	.2915	.2743	.2401	.2743
6	.3944	.4115	.4287	.3944	.4115	.3772	.3429
7	.3429	.3429	.3601	.3429	.2401	.3429	.3086
8	.2743	.2743	.2915	.2743	.2743	.2743	.2401
9	.2572	.2058	.2229	.1886	.2058		.1886
10	.1886	.2058	.1715	.1372		.1372	.1715
11	.1372	.1372	.1372	.1372	.1715	.1372	.1372
12	.1372	.1372	.1372	.1372	.1029	.1029	.12
13	.1372	.1372	.12	.1372	.12	.1029	.12
14	.1372	.1372	.1372	.1372	.1372	.1029	.1372
15	.1372	.1372	.1372	.1372	.1372	.1029	.1372
16	.1372	.1715	.1372	.1372	.1543	.1029	.1543
17	.1372	.1372	.1372	.1372	.1372	.1029	.1543
18	.1372	.1372	.1372	.1372	.1715	.1372	.1715
19	.2058		.2058	.2743	.2401	.2401	.2743
20	.3086	.2915	.2572	.3086	.2743	.3086	.3086
21	.2743	.2572	.2229	.3086	.3086	.2743	.2572
22	.1715	.2229	.2058	.2058	.2058	.1715	.2229
23	.1372	.1886	.1886	.1715	.1715	.1372	.1886
24	.1886	.1372	.1715	.1543	.1372	.1715	.1372
Max	.3944	.4115	.4287	.3944	.4115	.3772	.3429
Min	.1372	.1029	.12	.1372	.1029	.1029	.1029
Avg	.2028	.1976	.2022	.1986	.1983	.1819	.1900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 202 / 11 Kv Dhanore Ag feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3889						
2	1.4403						
3	1.4403						
4	1.5604						
5	1.6804						
6	1.7147						
7	1.8519						
8	1.749						
9	1.6118						
11		1.6289	1.5775		1.8519	1.6118	1.5604
12		1.9033	1.8176		2.0233	1.7147	1.9033
13		2.0405	1.9204		2.1948	1.749	1.8861
14		1.9719	1.8861		2.0576	1.7833	1.8861
15		2.0233	1.8347			2.0233	1.869
16		1.9033	1.749		1.3032	1.989	1.8004
17		1.869	1.7833	1.0117	1.8004	1.7833	1.6804
18		1.869	1.7147		1.8519	1.7147	1.5432
24	1.3032						
Max	1.8519	2.0405	1.9204	1.0117	2.1948	2.0233	1.9033
Min	1.3032	1.6289	1.5775	1.0117	1.3032	1.6118	1.5432
Avg	1.5741	1.9012	1.7854	1.0117	1.8690	1.7961	1.7661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 203 / 11 KV Pimpalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.5144	.7545	.2058	.6859	.6516
2		.4801	.5487	.7202	.2401	.6516	.6859
3		.5144	.5487	.7545	.2401	.6516	.6859
4		.5144	.6173	.7888	.2401	.7545	.7545
5		.5144	.703	.7888	.2401	.8059	.823
6		.6859	.823	.9602	.2401	.9088	.8573
7		.8573	.9945	.9602	.2401		.9259
8		.8916	.9774	.8573	.2401	.9945	1.0288
9		.7545	.8573	.8745	.3086	.9945	.9945
11	.8916						
12	.9259						
13	.9945						
14	1.0288						
15	1.0631						
16	1.0974						
17	1.0974						
18	.9945						
24		.4458	.2915	.6859	.2058	.6516	.6173
Max	1.0974	.8916	.9945	.9602	.3086	.9945	1.0288
Min	.8916	.4458	.2915	.6859	.2058	.6516	.6173
Avg	1.0117	.6139	.6876	.8145	.2401	.7888	.8025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 201 / 11 KV DAM FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3717	1.0974	1.4327	1.2803
2				1.4022	1.2193	1.4937	1.2803
3				1.4327	1.2498	1.4632	1.2803
4				1.4937	1.3717	1.4327	1.2955
5				1.4937	1.4327	1.4937	1.3108
6				1.4937	1.4937	1.5242	1.3413
7				1.5089	1.5242	1.5546	1.448
8				1.4937	1.4632	1.5242	1.2803
9				1.7071	1.4022	1.5242	1.4022
11	1.6156	1.0364	1.5242				
12	1.5242	1.4937	1.9052				
13	1.5242	1.768	1.6766				
14	1.7375	1.6613	1.6918				
15	1.5546	1.6309	1.7071				
16	1.5851	1.6004	1.7071				
17	1.6156	1.5546	1.5242				
18	1.6156	1.5242	1.5242				
24					1.1888	1.3717	1.2803
Max	1.7375	1.768	1.9052	1.7071	1.5242	1.5546	1.448
Min	1.5242	1.0364	1.5242	1.3717	1.0974	1.3717	1.2803
Avg	1.5966	1.5337	1.6576	1.4886	1.3443	1.4815	1.3199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 202 / 11 KV TANDULWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2743	.3353	.0914	.1372	.061	.0762
2	.3353	.3048	.3506	.0914	.1677	.061	.0762
3	.3658	.3963	.3048	.0914	.1524	.0457	.0762
4	.3963	.442	.2896	.1219	.1219	.061	.0914
5	.4268	.5182	.3353	.1219	.0914	.0914	.1067
6	.4877	.5182	.4115	.1219	.1372	.1067	.1372
7	.5335	.4725	.4268	.1372		.1219	.1372
8	.5639	.5487	.3963	.1219	.1219	.1067	.1067
9	.5639	.503		.0762	.0914	.0914	.0762
10	.0762	.0762	.061		.0762	.0914	.0914
11	.0762	.0762	.061		.3201	.2743	.3506
12	.061	.061	.0762		.4268	.4268	.5639
13	.061	.0457	.061		.4572	.4268	.5335
14	.0457	.0457	.061		.5182	.4877	.4877
15	.061	.061	.061		.5944	.4877	.4572
16		.1067	.061		.6249	.4877	.5182
17	.061	.1067	.0914		.5792	.4877	.5487
18	.061	.1219	.0914	.3963	.5487	.4877	.5639
19	.1219	.1219	.1219	.1219	.061	.1067	.1219
20	.0914	.1219	.1219	.1372	.0914	.1219	.1372
21	.0914	.1067	.1219	.1524	.1067	.1219	.061
22	.1219	.1067	.1219	.1067	.0914	.1067	.0762
23	.1219	.0914	.1219	.1219	.0914	.0914	.0762
24	.2896	.2743	.3201	.2896	.0914	.0762	.0914
Max	.5639	.5487	.4268	.3963	.6249	.4877	.5639
Min	.0457	.0457	.061	.0762	.061	.0457	.061
Avg	.2313	.2293	.1915	.1438	.2478	.2096	.2318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274235 / 33/11 KV RATANJAN SUB
STATIONFeeder No / Name : 201 / 11 KV GAVTHAN FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.2058	.2058	.1715	.2058	.2229
2	.1715	.2229	.2058	.2058	.1715	.2229	.2058
3	.2229	.2229	.2229	.2401	.2058	.2401	.2229
4	.2572	.3086	.2401	.2743	.2401	.2743	.2915
5	.3601	.3086	.2743	.3086	.2743	.3086	.3086
6	.3944	.3944	.3258	.3944	.4115	.4115	.3429
7	.3429	.3772	.3772	.3429	.3772	.3429	.3086
8	.3086	.3086	.3086	.2743	.2743	.2915	.2401
9	.3086	.2572	.2572	.2401	.2401	.2572	.2401
10	.2229	.2229	.2743	.1715	.2058	.1715	.2058
11	.2572	.1886	.2572		.1886	.1715	.2058
12	.2572	.2229	.2401		.1886	.1543	.1886
13	.2572	.1543	.2572		.1715	.1543	.2229
14	.2229	.1543	.2058	.12	.1543	.1543	.1715
15	.2058	.1372	.1886	.1543	.1543	.1715	.1886
16	.2058	.1543	.1886	.1715	.1372	.1715	.2229
17	.1886	.1886	.1715	.2058	.1886	.1886	.2058
18	.2058	.1715	.1886	.2401	.1543	.2058	.2229
19	.3086	.3258	.2572	.2915	.3086	.2915	.3086
20	.3601	.3601	.3772	.3601	.3601	.3429	.3429
21	.3429	.3086	.3086	.3086	.3086	.3086	.3258
22	.2743	.2915	.2743	.2572	.2572	.2572	.2915
23	.2572	.2572	.2401	.2401	.2229	.2058	.2401
24	.2058	.2401	.2229	.2229	.2058	.2058	.2058
Max	.3944	.3944	.3772	.3944	.4115	.4115	.3429
Min	.1715	.1372	.1715	.12	.1372	.1543	.1715
Avg	.2643	.2508	.2529	.2490	.2322	.2379	.2472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
stati

Feeder No / Name : 201 / 11KV TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.2437	1.287	1.4708	1.3032	1.434	1.4632
2	1.1946	1.1888	1.1031	1.434	1.267	1.3789	1.3937
3	1.1765	1.1523	1.1031	1.4708	1.1946	1.3237	1.2803
4	1.1222	1.0974	1.1031	1.3789	1.1584	1.287	1.1523
5	1.086	1.0608	1.1031	1.2686	1.1222	1.195	1.0974
6	1.1222	1.086	1.195	1.195	1.1041	1.2134	1.0974
7	1.2308	1.0059	1.1031	1.1583	1.0498	1.1583	1.0425
8	1.0498	1.0425	1.0112	1.1434	1.0136	1.0663	1.0608
9	1.0136	1.0425	1.195	1.0112	.9955	1.0974	1.0974
10	1.0974	1.0059	1.3237	1.1946	1.0847	1.1157	1.4289
11	1.134		1.5627	1.3394	1.287	1.2437	1.5242
12	1.267		1.5995	1.267	1.4708	1.3717	1.6194
13	1.3213		1.5627	1.4842	1.526	1.4632	1.5242
14	1.3575		1.5811	1.5023	1.5811	1.4998	1.5242
15	1.3213		1.6363	1.6289	1.6547	1.4632	1.6194
16	1.3032		1.6731	1.5203	1.6731	1.4998	1.5242
17	1.2445		1.6547	1.5203		1.4815	1.7147
18	1.267		1.7466	1.4842	1.5995	1.5546	1.4289
19	1.4815		1.8753	1.7375	1.8201	1.829	1.9052
20	1.4632		1.8937	1.8099	1.7834	1.8473	2.0005
21	1.4083		1.8017	1.5927	1.6363	1.7375	1.9052
22	1.3717		1.5995	1.4842	1.5995	1.6461	1.7147
23	1.3213		1.5627	1.5384	1.526	1.6095	1.7147
24	1.3937	1.2803	1.3789	1.4892	1.448	1.4708	1.5546
Max	1.4815	1.2803	1.8937	1.8099	1.8201	1.8473	2.0005
Min	1.0136	1.0059	1.0112	1.0112	.9955	1.0663	1.0425
Avg	1.2491	1.1096	1.4440	1.4218	1.3869	1.4161	1.4745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 202 / 11 KV INDUSTRIAL ESTATE SHEDDABLE FEEDER HAVING WEEKLY
NO.02 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5121	.4725	.567	.362	.567	.4207
2	.5792	.4572	.4725	.5292	.3258	.5292	.362
3	.543	.4163	.4725	.5103	.2715	.5481	.3658
4	.5068	.3658	.4725	.5481	.2715	.5103	.4024
5	.5068	.4024	.4725	.4725	.2896	.567	.4572
6	.543	.5487	.4725	.4347	.3077	.5859	.4207
7	.6335	.6219	.4725	.4914	.4706	.5481	.6401
8	.5792	.5853	.4725	.4536	.3982	.5292	.7133
9		.6979	.567	.4158	.4887	.6979	.8048
10	.7865	.7545	.8505	.4344	.7749	.7545	.8573
11	.8596		.9639	.4163	.9072	.8413	.9526
12	1.0059		.945	.4344	.9828	.9145	1.0479
13	.8048		.8883	.1991	.9261	.6767	1.0479
14	.6878		.8127	.2353	.6426	.7133	1.1431
15	.8865		.9072	.2353	.8127	.8488	1.0479
16	.9694		1.0395	.2534	.8505	.8596	1.0479
17	.9054		1.1184	.2896		.9511	.9526
18	.8145		.9072	.3077	.8316	.8048	.8573
19	.7682		.7371	.2715	.7371	.695	.7621
20	.6401		.7182	.3439	.7182	.5853	.7621
21	.6036		.7371	.3439	.6048	.5853	.6668
22	.5853		.6993	.362	.6237	.5487	.5716
23	.5487		.6048	.3982	.5859	.5121	.5716
24	.6154	.5487	.567	.5481	.3982	.6048	.4572
Max	1.0059	.7545	1.1184	.567	.9828	.9511	1.1431
Min	.5068	.3658	.4725	.1991	.2715	.5103	.362
Avg	.6936	.5373	.7018	.3957	.5905	.6658	.7222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 203 / 11 KV BHAGAWANT FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.2378	.3688	.4795	.4525	.4426	.4163
2	.4344	.2195	.2766	.4426	.4344	.4242	.3658
3	.3982	.2195	.2766	.4611	.4163	.4057	.3292
4	.3801	.3109	.2766	.4242	.4163	.4242	.3109
5	.3801	.4024	.3688	.3873	.4163	.4057	.3658
6	.362	.3841	.3688	.3688	.4163	.3688	.4207
7	.362	.3658	.3688	.3504	.3801	.3873	.3841
8	.3439	.3658	.2766	.3135	.362	.3135	.4024
9		.3475	.3688	.2766	.3258	.2926	.3658
10	.3109	.3109	.3135	.2896	.2766	.3109	
11	.3292		.332	.3439	.3135	.3109	.381
12	.3658		.3873	.3077	.3135	.3475	.381
13	.3109		.4057	.3258	.3688	.3109	.381
14	.3475		.3688	.3982	.3873	.3292	.381
15	.3109		.3873	.3801	.3873	.3475	.381
16	.3292		.3688	.362	.3688	.3841	.2858
17	.3658		.332	.362		.3658	.2858
18	.3292		.3873	.3439	.332	.3475	.381
19	.4024		.3688	.3982	.4057	.4207	.4763
20	.4572		.4426	.4344	.4426	.4572	
21	.4207		.4611	.4344	.4611	.4938	.4763
22	.3658		.4795	.4525	.4426	.4572	.4763
23	.3077		.4426	.4887	.4795	.4938	.381
24	.4525	.2743	.3688	.4611	.4525	.4611	.4572
Max	.4572	.4024	.4795	.4887	.4795	.4938	.4763
Min	.3077	.2195	.2766	.2766	.2766	.2926	.2858
Avg	.3696	.3126	.3665	.3869	.3936	.3876	.3857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 203 / 11KV CANCER FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671		1.6804	1.6975		
2	1.6804		1.4784	1.5089		
3	1.4784		1.4784	1.5089		
4	1.4784		1.6804	1.5089		
5	1.6632		1.6804	1.5089		
6	1.6804		1.6632	1.5089		
7	1.5432		1.4784	1.5089		
8	.9145		1.2936	1.5089		1.4784
9	1.1088		1.2936	1.5089		
10	1.4937		1.2803	1.4784		1.2803
11		1.4937	1.2936			1.4784
12		1.4937				1.6632
13		1.1088				
14		1.2936			1.6804	1.4632
15		1.4937			1.6804	1.6804
16			1.2936		1.6804	1.848
17		1.307	1.2936		1.6804	1.6632
18		1.4937			1.6804	1.6804
19		1.4784	1.2936			1.4937
20		1.307				1.1317
21		1.6804				1.307
22		1.6632	1.4632			1.4937
23		1.6632	1.4937			1.6804
24	1.8671		1.6632	1.6975		
Max	1.8671	1.6804	1.6804	1.6975	1.6804	1.848
Min	.9145	1.1088	1.2803	1.4784	1.6804	1.1317
Avg	1.5250	1.4564	1.4589	1.5404	1.6804	1.5244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 204 / 11KV I.T.I. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164		.7164	.724		
2	.7087		.7087	.724		
3	.5258		.5258	.5487		
4	.5316		.5316	.543		
5	.7164		.7087			
6	.7164		.7164	.7468		
7	.7164		.7087	.7316		
8	.5316		.7087	.724		.7164
9	.5258		.7011	.543		.7087
10	.7164		.7011	.7164		.7087
11		.7164	.7011			.7087
12		.7087	.7087			.7011
13		.7087	.7011			
14		.7087	.7011		.7468	.7011
15		.7011	.7011		.7468	.6935
16		.7164	.7087		.7468	.7087
17		.7164	.7087		.7468	.7011
18		.7164	.7087		.7468	.7011
19		.8954	.8859			.905
20		.905				.905
21		.905				.905
22		.8954	.905			.905
23		.8954	.905			.8954
24	.7164		.7164	.724		
Max	.7164	.905	.905	.7468	.7468	.905
Min	.5258	.7011	.5258	.543	.7468	.6935
Avg	.6474	.7838	.7172	.6726	.7468	.7710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 206 / 11KV MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328		2.0328	1.8671		
2	1.829		1.829	1.8671		
3	1.829		1.6461	1.8671		
4	1.829		1.6461	1.8671		
5	2.0328		1.6632	1.8671		
6	2.0328		1.848	1.8671		
7	2.0328		2.0328	2.0538		
8	1.829		1.6461	1.8671		1.829
9			1.448	1.8671		1.6461
10	1.4632		1.4327	2.0538		1.848
11		2.0328	1.848			2.0328
12		2.2405	1.829			2.4272
13		2.2177	1.8671			
14		2.0119	2.0119		2.6139	2.1948
15		2.2177	1.829		2.4006	2.6139
16		2.4272	2.4025		2.6139	2.9569
17		2.2405	2.4025		2.2405	2.5873
18		2.0538	2.3529		2.2405	2.6139
19		2.0119	2.4272			2.2177
20		3.4743				1.829
21		2.0328				1.829
22		2.2405	2.0538			2.0119
23		2.2177	2.0538			2.2177
24	2.2177		2.0119	2.0538		
Max	2.2177	3.4743	2.4272	2.0538	2.6139	2.9569
Min	1.4632	2.0119	1.4327	1.8671	2.2405	1.6461
Avg	1.9128	2.2630	1.9234	1.9180	2.4219	2.1903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 207 / 11KV JAIN MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2177		2.2177	2.0119		
2	2.1948		2.0119	2.0119		
3	1.8099		2.0119	1.829		
4	1.8099		1.8099	1.829		
5	2.0328		1.9909	2.0119		
6	2.0328		2.0119	2.0119		
7	2.0119		2.0119	2.0328		
8	1.9909		1.8099	1.848		1.7909
9	1.8099		1.6289	1.829		1.7909
10	1.7909		1.6289	1.6461		1.8099
11		1.8099	1.6289			1.8099
12		1.8099	1.6289			1.7909
13		1.7909	1.8099			
14		1.97			1.8671	1.949
15		1.97			1.8671	1.97
16		1.9909	1.8099		1.8671	1.97
17			1.8099		1.8671	1.9909
18		1.7909			1.8671	1.97
19		2.4025	2.1719			2.3777
20		2.4025				2.5873
21		2.4025				2.5873
22		2.5873	2.3777			2.8006
23		2.5873	2.5606			2.5606
24	2.3777		2.4025	2.1948		
Max	2.3777	2.5873	2.5606	2.1948	1.8671	2.8006
Min	1.7909	1.7909	1.6289	1.6461	1.8671	1.7909
Avg	2.0072	2.1262	1.9649	1.9324	1.8671	2.1171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 208 / 11KV BHAVANI PETH
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1948		2.2177	2.0328		
2	2.0119		2.0119	1.848		
3	1.6289		1.8099	1.6632		
4	1.6289		1.8099	1.6632		
5	1.6461		1.829	1.6632		
6	1.6461		1.829	1.848		
7	1.6289		1.829	1.6632		
8	1.6289		1.6289	1.6804		1.7909
9	1.6118		1.6118	1.6461		1.5947
10	1.6289		1.829	1.829		1.7718
11		2.0119	1.9909			1.949
12		1.97				1.97
13		1.9909				
14		1.97	.543		2.2405	2.1491
15		2.1719	2.1948		2.2405	2.1491
16		2.1948	2.3777		2.2634	2.1719
17		2.1719	2.3777		2.2405	1.97
18		1.9909	2.1948		2.0538	1.949
19		2.1948	2.3777			2.3529
20		2.4025				2.4025
21		2.1948				2.3777
22		2.2177	2.1719			2.4025
23		2.1948	2.2177			2.3529
24	2.1948		2.1948	2.1948		
Max	2.1948	2.4025	2.3777	2.1948	2.2634	2.4025
Min	1.6118	1.97	.543	1.6461	2.0538	1.5947
Avg	1.7682	2.1290	1.9524	1.7938	2.2077	2.0903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 213 / 11KV BARSHI TEXTILE MILL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRE Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335		.9335	.0206		
2	.9335		.924	.0206		
3	.9335		.9335	.0206		
4	.924		.9335	.0206		
5	.924		.924	.0206		
6	.9335		.9335	.2096		
7	.9335		.924	.7011		
8	.9335		.9335	.9335		.9335
9	.9335		.924	.9431		.9335
10	.924		.9335	.9431		.924
11		.9335	.9431			.9335
12		.924	.9431			.924
13		.9335	.9431			
14		.9335	.9431		.9335	.9335
15		.9335	.724		.9335	.9335
16		.9335	.021		.9335	.9335
17		.9335			.9335	1.1203
18		.9335			.9335	.924
19		.9335	.0206			.9335
20		.9335				.9335
21		.9335				.9335
22		.9335	.0206			.9335
23		.9335	.0229			.9335
24	.9335		.9335	.0229		
Max	.9335	.9335	.9431	.9431	.9335	1.1203
Min	.924	.924	.0206	.0206	.9335	.924
Avg	.9309	.9328	.7406	.3506	.9335	.9441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 403 / Agalgaon

Feeder KV- 33 / INCOMING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0851	1.9753	2.0473	2.3317	2.0851	2.3317	2.3045
2	1.9753	1.8656	1.8198	2.4454	1.9204	2.2748	2.1399
3	1.9753	1.7558	1.8198	2.2748	1.7558	2.2179	1.9547
4	1.9204	1.7558	1.8767	2.1611	1.701	2.1611	1.8656
5	1.9204	1.8656	1.9336	1.9905	1.701	1.9905	1.9204
6	1.9204	2.0302	1.9845	2.0473	1.6461	2.0473	1.9004
7	2.0851	1.9547	1.9336	2.0473	1.8107	1.9336	2.009
8	1.9753	1.9753	1.8767	1.8198	1.701	1.763	2.0851
9		2.0851	2.1042	1.6492	1.8656	2.0302	2.2262
10	2.1948	2.0302	2.2748	1.8107	2.1042	2.1399	2.5149
11	2.3045		2.7298	2.0302	2.7298	2.1948	2.572
12	2.4691		2.7866	2.0302	2.9573	2.4143	2.8578
13	2.4691		2.7298	1.9204	2.7298	2.0851	2.8578
14	2.4143		2.9004	2.0302	2.5592	2.524	2.9721
15	2.552		3.071	2.1399	2.7866	2.6337	2.9721
16	2.2262		3.2416	2.1399	2.7298	2.7435	2.7435
17	2.6063		3.1847	2.1399		2.7984	2.572
18	2.4691		2.6729	2.0851	2.7866	2.6886	
19	2.6337		2.8435	2.3045	2.9573	2.9081	3.0864
20	2.524		2.7866	2.4143	3.0141	2.8532	3.2007
21	2.4143		2.7298	2.3045	2.4454	2.7984	2.9721
22	2.3045		2.616	2.1399	2.3885	2.6337	2.6292
23	2.1948		2.4454	2.2497	2.3317	2.4143	2.572
24	2.3045	2.0851	2.2748	2.3885	2.1719	2.2748	2.4691
Max	2.6337	2.0851	3.2416	2.4454	3.0141	2.9081	3.2007
Min	1.9204	1.7558	1.8198	1.6492	1.6461	1.763	1.8656
Avg	2.2582	1.9435	2.4452	2.1206	2.2991	2.3690	2.4955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 407 / 33KV Atlanta Feeder (T/F

1) Feeder KV- 33 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9383		4.3896	4.3896		
2	4.4353		4.4353	4.225		
3	3.8009		3.8409	3.8809		
4	3.8009		3.8409	3.8809		
5	4.3896		4.3896	4.269		
6	4.3896		4.4353	4.269		
7	4.3896		4.3896	4.313		
8	3.2922		3.8409	4.0889		3.8409
9	3.2579		3.7609	3.8409		3.8409
10	3.7209		3.7209	3.8009		3.8009
11		3.7609	3.638			3.7609
12		3.7609	2.3348			4.2981
13		3.8009				
14		3.8409			12.883	4.2524
15		4.3439	2.5252		12.883	4.2524
16		2.6006	3.8409		21.2849	4.3439
17		3.8009	3.7609		12.883	4.3439
18		3.8409			12.883	4.2524
19		4.784	4.2524			4.8354
20		4.3439				4.3896
21		4.9383				4.8868
22		4.8868	4.7737			4.9383
23		4.8868	4.9383			4.9383
24	4.9383		4.9383	4.5542		
Max	4.9383	4.9383	4.9383	4.5542	21.2849	4.9383
Min	3.2579	2.6006	2.3348	3.8009	12.883	3.7609
Avg	4.1230	4.1223	4.0024	4.1375	14.5634	4.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 408 / 33KV Atlanta Feeder (T/F

2) Feeder KV- 33 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1614		6.1614	4.7611		
2	6.1614		5.6013	4.5931		
3	5.5441		4.9897	4.425		
4	5.5441		5.0412	4.425		
5	5.5441		5.0926	4.425		
6	5.6013		5.0926	4.9228		
7	5.6013		5.0926	5.0926		
8	5.0412		4.481			5.6013
9	5.0926		4.5268	5.0926		5.5441
10	5.5441		4.481	5.9934		6.1614
11		6.5844	5.1029			6.653
12		6.5844	3.1276			5.487
13		6.0985				
14		6.1614			21.2849	6.0985
15		6.653	5.1029		21.2849	7.1331
16		6.7215	5.2126		21.2849	7.6818
17		6.653	5.2126		19.0444	7.1331
18		6.1614			17.9241	7.0588
19		6.0357	5.2126			6.5844
20		6.1614				6.1614
21		6.1614				6.0985
22		6.0985	4.8834			6.7215
23		6.1614	5.1006			6.7215
24	6.7215		6.1614	5.1532		
Max	6.7215	6.7215	6.1614	5.9934	21.2849	7.6818
Min	5.0412	6.0357	3.1276	4.425	17.9241	5.487
Avg	5.6870	6.3258	5.0356	4.8884	20.1646	6.4560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 201 / 11 KV JEUR URBAN GAONTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6135	.7011	.6135	.7011	.7011	.7011	.6135
Max	.6135	.7011	.6135	.7011	.7011	.7011	.6135
Min	.6135	.7011	.6135	.7011	.7011	.7011	.6135
Avg	.6135	.7011	.6135	.7011	.7011	.7011	.6135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 203 / 11 KV DAHIGAON-SHETFAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1753	.1753	.1753	.1753	.1753	.1753	.1753
Max	.1753	.1753	.1753	.1753	.1753	.1753	.1753
Min	.1753	.1753	.1753	.1753	.1753	.1753	.1753
Avg	.1753	.1753	.1753	.1753	.1753	.1753	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 204 / 11 KV DAHIGAON W/S

NON SHEDDABLE WATER SUPPLY AND

EXPRESS Feeder KV- 11 /

UTILITY

OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4382	.3506	.5258	.3506	.3506	.5258	.6135
Max	.4382	.3506	.5258	.3506	.3506	.5258	.6135
Min	.4382	.3506	.5258	.3506	.3506	.5258	.6135
Avg	.4382	.3506	.5258	.3506	.3506	.5258	.6135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 205 / 11 KV PANGARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.6456	3.315	3.1493	2.8178	3.3532	3.6456	3.3913
Max	3.6456	3.315	3.1493	2.8178	3.3532	3.6456	3.3913
Min	3.6456	3.315	3.1493	2.8178	3.3532	3.6456	3.3913
Avg	3.6456	3.315	3.1493	2.8178	3.3532	3.6456	3.3913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 206 / 11 KV WANGI NO-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.1245	3.1245	2.8549	.1562	.1562	.1543	.1658
Max	3.1245	3.1245	2.8549	.1562	.1562	.1543	.1658
Min	3.1245	3.1245	2.8549	.1562	.1562	.1543	.1658
Avg	3.1245	3.1245	2.8549	.1562	.1562	.1543	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 204 / 11 KV KAVITGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.2743
5						.2439
6						.2439
7						.2439
8	2.0576	2.2862	.2439	2.4387	.2439	.2743
9	.2439	.2439	.2439	.2439	.2439	.2743
10	.2439	.2439	.2743	.2439	.2439	.2439
11	.2439	.2743	.1829	.2439	1.9052	
12	.2439	.2439			2.0576	
13	.2439	.2743		.2439	2.0576	
14	.2439	.2743			2.0576	
Max	2.0576	2.2862	.2743	2.4387	2.0576	.2743
Min	.2439	.2439	.1829	.2439	.2439	.2439
Avg	.503	.5487	.2363	.6829	1.2585	.2569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 206 / 11 KV KANDAR VILLAGE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.9052	1.9052	1.9052	.2439	.2439	.2439	.2439
9	.2439	.2439	.2439	.2439	.2439	.2439	.2439
10	.2134	.2439	.2439	.2439	1.829	.2439	.2439
11	.2439	.2439	.2439		1.829	1.9052	.2439
12	.2439	.2439	.2439		1.829	.2439	.2439
13	.2439	.2439	.2439		1.829	.2439	.2439
14	.2439	.2439	.2439		.1829	.2439	.2439
Max	1.9052	1.9052	1.9052	.2439	1.829	1.9052	.2439
Min	.2134	.2439	.2439	.2439	.1829	.2439	.2439
Avg	.4769	.4812	.4812	.2439	1.1410	.4812	.2439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 208 / 11 KV KANDAR BACKWATER AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.2439
7						.2439
8	2.0576	.2439	2.0576	2.0576	2.0576	.1981
9	.2439	.2439	.2439	.2439	.2439	.2439
10	.2439	.2439	.2439	.2439	.2439	.2439
11	.2439	.2439	.2439		2.0576	
12	.2439	.2439	.2439		2.0576	
13	.2439	.2439			2.0576	
14	.2439	.2439			2.21	
Max	2.0576	.2439	2.0576	2.0576	2.21	.2439
Min	.2439	.2439	.2439	.2439	.2439	.1981
Avg	.503	.2439	.6066	.8485	1.5612	.2347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 201 / 11 KV KEM GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18
HR	Load (MW)	Load (MW)
1	.3206	.4527
2	.3206	
3	.3772	.415
4	.4715	
5	.5281	
6	.4338	
7	.3772	
9	.415	
10	.3961	
11	.3772	
12	.415	
13	.4527	
14	.415	
15	.3772	
16	.3772	
24	.3206	.4338
Max	.5281	.4527
Min	.3206	.415
Avg	.3984	.4338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 202 / 11 KV WADSHIVANE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18
HR	Load (MW)	Load (MW)
1	.6859	.8257
2	.7545	.7882
3	2.4291	2.5918
4	2.915	2.8647
5	2.8673	3.0026
6	2.7362	.4884
7	2.7362	.4504
8	2.8967	.4129
9	3.3779	
10	3.2658	
11	.6972	
12	.6619	
13	.7354	
14	.7882	
15	.7506	
16	.7882	
24	.6859	.7844
Max	3.3779	3.0026
Min	.6619	.4129
Avg	1.7513	1.3566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 203 / 11 KV MALAWADI AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18
HR	Load (MW)	Load (MW)
1	1.0402	
2	1.0526	1.1271
3	.3429	.4433
4	.4287	.4412
5	.4287	.4879
6	.4287	.4045
7	.3944	.4367
8		.4504
9	.4879	
10	.4504	
11	1.2774	
12	1.195	
13	1.2463	
14	1.287	
15	1.2126	
16	1.2443	
24	.9831	
Max	1.287	1.1271
Min	.3429	.4045
Avg	.8438	.5416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO

KA

Feeder No / Name : 205 / 11 KV UPALWATE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18
HR	Load (MW)	Load (MW)
1		.4692
2		.4433
3		.4504
4		.4504
5		.526
6		.5072
7		.4285
8		.4371
9	.4316	
10	.4696	
11	2.0831	
12	2.2332	
13	2.4021	
14	2.4771	
15	2.5897	
16	2.5924	
24		.3753
Max	2.5924	.526
Min	.4316	.3753
Avg	1.9099	.4542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 201 / 11 KV UMRAD-KUMBHEJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5144	.5144	.5144	.6001	.6001	.6001	.5144
Max	.5144	.5144	.5144	.6001	.6001	.6001	.5144
Min	.5144	.5144	.5144	.6001	.6001	.6001	.5144
Avg	.5144	.5144	.5144	.6001	.6001	.6001	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 205 / 11 KV BHAIKAVNATH NEW AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.0622	2.079	2.1293	2.0119	.0838	.0838	.0838
Max	2.0622	2.079	2.1293	2.0119	.0838	.0838	.0838
Min	2.0622	2.079	2.1293	2.0119	.0838	.0838	.0838
Avg	2.0622	2.079	2.1293	2.0119	.0838	.0838	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 206 / 11 KV SOGAON NEW AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0838	.0838	.0838	.0838	2.3472	2.3472	2.3472
Max	.0838	.0838	.0838	.0838	2.3472	2.3472	2.3472
Min	.0838	.0838	.0838	.0838	2.3472	2.3472	2.3472
Avg	.0838	.0838	.0838	.0838	2.3472	2.3472	2.3472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 207 / 11 KV POPHALAJ-KUMBHEJ AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0838	.081	.0838	.0838	.0838	.0838	.0838
Max	.0838	.081	.0838	.0838	.0838	.0838	.0838
Min	.0838	.081	.0838	.0838	.0838	.0838	.0838
Avg	.0838	.081	.0838	.0838	.0838	.0838	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 202 / 11 KV YASHOBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.3344	.3464	.2435	3.275		2.915	2.7606
24	.3378	.3344	.3481	.2812	3.2579		2.7778
Max	.3378	.3464	.3481	3.275	3.2579	2.915	2.7778
Min	.3344	.3344	.2435	.2812	3.2579	2.915	2.7606
Avg	.3361	.3404	.2958	1.7781	3.2579	2.915	2.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION
KAVITGAONFeeder No / Name : 203 / 11 KV KOLDHARA AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-APR-18
HR	Load (MW)
23	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 204 / 11 KV SANGAVI NO.2 AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	3.738	3.6351		.0394	.0377	.036	.0189
24	3.7723	3.7723	3.6694		.0377	.0309	.036
Max	3.7723	3.7723	3.6694	.0394	.0377	.036	.036
Min	3.738	3.6351	3.6694	.0394	.0377	.0309	.0189
Avg	3.7552	3.7037	3.6694	.0394	.0377	.0335	.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 202 / 11 KV Ghoti I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2259	.1792	.2662	.2627	.2824	.2627	.2815
2	.2252	.2064	.2447	.2635	.2824	.2447	.2815
3	1.1072	.563	.5041	.7529	.2824	.3042	.3378
4	1.2198	1.0894	1.096	1.1294	.2824	.3378	.3246
5	1.5435	1.6941	1.5951	1.5211	.3012	.4183	.4563
6	1.6941	1.8766	1.92	1.7873	.4329	.4692	.5249
7	1.9329	2.0643	1.8766	2.0155	.4706	.3576	.5067
8	1.8823	1.8954	1.8443	1.9394	.3953	.3953	.3791
9	1.8823	1.7694	2.0268	1.0509	.3388	.3753	.2815
10	1.689	1.8391	1.8823		.3012		.244
11	.2815	.2447	.2472		1.8766	1.6941	
12	.2729	.2192	.1896		1.8447	1.8823	1.7953
13	.2815	.2252	.1882		1.8016	1.92	1.8954
14	.2824	.1955	.1882		1.7882	1.7318	1.9576
15	.2815	.2064	.1882		1.8259	1.8824	2.0141
16	.2801	.2064	.1687		1.8635	1.9414	2.0517
17	.2815	.2252	.1689		1.9576	1.8447	1.9104
18	.2824	.2259	.2071	.3753	2.0329	1.764	1.7159
19	.3753	.3765	.32	.3753	.3232	.3753	.3423
20	.3372	.3576	.3388	.4373	.3388	.3639	.3388
21	.3628	.319	.3566	.3541	.3576	.4129	.3378
22	.2815	.3003	.3765	.3753	.3576	.3765	.3378
23	.2804	.2824	.2824	.3753	.3576	.3083	.3223
24	.2259	.2729	.2824	.2192	.3012	.3003	.2815
Max	1.9329	2.0643	2.0268	2.0155	2.0329	1.9414	2.0517
Min	.2252	.1792	.1687	.2192	.2824	.2447	.244
Avg	.7295	.7014	.6983	.8272	.8499	.8680	.8226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 203 / 11 KV Ghoti II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751	.0753	.0938	.0951	.0753	.1141	.0941
2	.0761	.0751	.0941	.0941	.0751	.1137	.0758
3	.9758	.563	.6023	.6084	.0753	.1314	.1126
4	1.1979	1.126	.8459	.9383	.0761	.1689	.1901
5	1.5013	1.6941	1.3176	1.3136	.1129	.2092	.2252
6	1.7265	1.8766	1.6	1.5764	.2064	.2368	.2447
7	2.0268	1.9705	1.6941	1.807	.2852	.3042	.2662
8	1.8391	1.8766	1.7694	1.6355	.2071	.1882	.1877
9	1.8766	1.807	1.4299	.9195	.1689	.1501	.1501
10	1.6941	1.5006	1.5812		.1318	.0941	.1314
11	.0751	.1129	.1129		1.6941	1.6376	
12	.0728	.1126	.0941		1.7318	1.6376	1.6941
13	.0672	.1129	.1126		1.7453	1.4838	1.5812
14	.0751	.1129	.1126		1.7873	1.6352	1.5951
15	.0751	.0941	.1141		1.8253	1.6565	1.6139
16	.0751	.0753	.0751		1.7882	1.6376	1.6565
17	.0751	.0941	.0751		1.7882	1.6188	1.6542
18	.0751	.0941	.0951	.1129	1.7882	1.4831	1.6352
19	.1126	.1314	.1331	.1711	.1506	.1506	.1314
20	.1877	.1129	.1694	.1689	.1506	.1882	.1274
21	.1877	.1126	.1877	.1456	.1521	.1877	.1501
22	.4706	.0941	.1875	.1331	.1506	.1506	.1521
23	.0938	.0941	.1506	.1141	.1129	.1506	.1331
24	.0753	.0938	.0753	.1126	.0938	.1092	.1318
Max	2.0268	1.9705	1.7694	1.807	1.8253	1.6565	1.6941
Min	.0672	.0751	.0751	.0941	.0751	.0941	.0758
Avg	.6128	.5839	.5301	.6216	.6822	.6432	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 204 / 11 KV Pathurdi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.32	.3803	.3753	.3761	.3412	.3753	.2346
2	.32	.3765	.3765	.3761	.3385	.3378	.3003
3	.319	.4706	.4329	.3765	1.6732	1.0321	1.4998
4	.3378	.4706	.4706	.5647	1.8824	1.5211	1.8195
5	.4879	.5647	.4894	.5647	2.3529	2.5859	2.3872
6	.563	.5647	.563	.64	2.5479	2.7	2.7371
7	.6381	.563	.4889	.6023	2.9364	2.757	2.1919
8	.319	.4706	.4504	.5324	2.8525	3.0422	3.0964
9	.3388	.4141	.4563	.3613	2.4396	3.0401	2.8149
10	.4894	.3566	.3423		2.1206	2.5522	2.4644
11	1.5059	2.5788	2.6353		.3012	.3042	
12	2.8521	2.5574	2.6729		.3012	.3388	
13	2.8235	2.5412	2.6353		.3003	.3042	.3003
14	2.5292	2.5334	2.5976		.3012	.3423	.3232
15	2.8235	2.6353	2.3717		.2635	.3285	.3412
16	2.8235	2.7482	2.4847		.3012	.3765	.3576
17	2.8149	2.6917	2.5223		.3388	.3803	.5459
18	2.8235	2.6273	2.5223	2.6139	.3953	.4129	.5459
19	.5458	.4563	.4141	.4944	.4518	.5271	.5067
20	.5704	.4316	.4329	.4894	.4518	.5647	.4753
21	.563	.4373	.4518	.5082	.4692	.5647	.4185
22	.4692	.4137	.4504	.4706	.4504	.4894	.4329
23	.4706	.3941	.3953	.4329	.4504	.4563	.4329
24	.319	.4706	.3953	.3953	.3753	.4003	.4141
Max	2.8521	2.7482	2.6729	2.6139	2.9364	3.0422	3.0964
Min	.319	.3566	.3423	.3613	.2635	.3042	.2346
Avg	1.1695	1.1729	1.1428	.6124	1.0265	1.0722	1.1200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 215 / DEVICHA MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5144	.5144					.5144
3					.5335	.6097	
4	.5144	.5144					.5144
5			.5335				
6	.6001	.6001		.6097	.6097	.5335	.6001
8		.6001	.5335	.6859	.5335	.5335	.5144
10	.6859	.6668	.6668		.6668	.6668	
11		.7621	.5716		.5716	.5716	.5144
12	.6001	.6668	.7621		.7049	.6668	
13		.8573	.6668		.8573	.8573	.6859
14	.5144	.9526	.5716		.7621	.7621	
15	.5144				.7621		.6859
16	.4572	.8535					
17			.6859		.6859	.6859	
18						.6001	
19			.6001	.8573	.6859	.6001	
20	.4572						
21		.6859	.5144	.6859	.5144	.5144	
22				.6859			
23	.4572	.6097	.4572	.6097	.4572	.5144	.5144
24	.5144	.5144	.4572	.4572	.5335	.4572	.5144
Max	.6859	.9526	.7621	.8573	.8573	.8573	.6859
Min	.4572	.5144	.4572	.4572	.4572	.4572	.5144
Avg	.5300	.6768	.5851	.6559	.6342	.6124	.5620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 216 / Bhavani Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.7716	.823					.8573
3					.8383	.6859	
4	.7716	.823					.8573
5			.7621				
6	.7888	.8573		.6097	.9145	.9145	.8059
8		.8573	.7621	.7621	.8383	.9145	.8745
10	.6859	.9526	.9526		1.0479	1.1431	
11		.8573	1.0669		.9526	1.086	
12	.7716	.7621	.9907	.8383	1.086	1.1431	
13		.9526	.8573	.7621	1.1431	1.0479	
14	.8573	.8573	.7621	.8535	1.2384	.9907	
15	.8573			.7621	.9526		
16	.7621			.6859			
17			.6001	.6097	.8573	.7716	
18				.5335	.7716	.7716	
19	.8383		.6859	.6097		.8573	
20				.7316	.8573		
21		.9145	.7716	.8383		.8573	
22				.8535			
23	.8535	.7621	.6097	.7621		.9774	.9774
24	.8573	.8573	.7621	.6097	.7621	.6097	.9088
Max	.8573	.9526	1.0669	.8535	1.2384	1.1431	.9774
Min	.6859	.7621	.6001	.5335	.7621	.6097	.8059
Avg	.8014	.8564	.7986	.7215	.9431	.9122	.8802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 217 / Karmala Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.166
2	.9431	.9431					1.0288
3			.7621		.7621	.6097	
4	.9431	.8573					.9431
5			.7621				
6	1.0631	.9431		.8383	.9145	.6859	1.0288
7		.1715					
8		1.0288	.8383	.8383	.8383	.6859	1.1145
10	1.0631	1.1431	1.0479		1.0479	.7621	1.0802
11		1.2384	1.1431		.9526	.8573	
12	1.0288	1.1431	1.086		1.1431	.7621	.9431
13		1.0479	1.1431		1.086	.9526	
14	.8573	1.086	1.2384		1.1431	.8573	.7716
15	.9431				1.1812		
16	.8383						.8573
17			1.0288		.8573		
18					.9431		1.1145
19	.7621		1.1145	.9431		1.0288	
20					1.1145	1.1145	
21		.7621	1.1145	1.2174	1.2003	1.1145	
22				1.2174			
23	1.0517	.7621	.9145	.9145		1.2517	1.1831
24	1.1317	.1715	.7621	.9145	.9145	.7621	
Max	1.1317	1.2384	1.2384	1.2174	1.2003	1.2517	1.1831
Min	.7621	.1715	.7621	.8383	.7621	.6097	.7716
Avg	.9659	.8691	.9966	.9834	1.0070	.8803	1.021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 218 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1715	.1715					.6859
3					1.2193		
4	.1715	.1715					.6859
6		.1715			1.2955		1.1145
7	.1715						
8				1.0669	1.2193	1.2955	1.7147
11		.5716	.5716				
12		.8573	1.1431				
13		.7621	1.3336				
14		1.5242	1.5242				
16		1.448	1.448				
19				.1715			
21		.1524		.1715			
22				.1715			
23		.1524	.1524	.1524		.1715	.1715
24	.1715	.1715		.1524	1.0669	1.0669	
Max	.1715	1.5242	1.5242	1.0669	1.2955	1.2955	1.7147
Min	.1715	.1524	.1524	.1524	1.0669	.1715	.1715
Avg	.1715	.5595	1.0288	.3144	1.2003	.8446	.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 220 / 11KV VEET AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
2			1.2003
4			1.3717
6			1.9719
8			2.2291
19	.5144		
21	.8573		
22	.8573		
23		.6859	.8573
24			1.0288
Max	.8573	.6859	2.2291
Min	.5144	.6859	.8573
Avg	.743	.6859	1.4432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 221 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715					.0857
3			.1524		.0762		
4		.2572					.0857
5			.1524				
6		.3429	.1524	.0762	.0762	.0762	.0857
8		.3429	.2286				
11					.1905	.1905	
12					.2858	.1905	
13					.1905	.1905	
14					.1905	.1905	
15					.1905		
16					.1905		
17						.1715	
19	.0762	.0762	.0857	.0857			
20			.0857			.0857	
21			.0857	.0857			
22				.0857			
23	.0762	.0762		.0762		.0857	.0857
24	.1715	.1715	.1524	.0762	.0762	.0762	.0857
Max	.1715	.3429	.2286	.0857	.2858	.1905	.0857
Min	.0762	.0762	.0857	.0762	.0762	.0762	.0857
Avg	.1080	.2055	.1369	.0810	.1630	.1397	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 222 / 11 KV SANGOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.7147					.1715
3			1.6766		.1524		
4	2.0576	1.8861					.1715
5			2.2862				
6		2.3148			.1524	.1524	.1715
7	1.9719						
8		2.8292	2.6673				
10			1.3717				
12					1.9052	3.0483	
13					2.4768	2.6673	
14					2.572	2.8578	
17						2.7435	
18						2.572	
19	.1524	.1524		.1715			
20						.1715	
21				.1715		.1715	
22				.1715			
23	.1524	.1524	.1524	.1524		.1715	.1715
24	1.8861	1.6289	1.3717	.1524	.1524	.1524	.1715
Max	2.0576	2.8292	2.6673	.1715	2.572	3.0483	.1715
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1715
Avg	1.2441	1.5255	1.5877	.1639	1.2352	1.4708	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 223 / 11 KV KARMALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6859	.7716					.6859
3					.7621	1.2193	
4		.8573					.6859
6	1.2003	1.0288		1.2193	.9145	1.2193	.8573
7	.6859						
8		1.2003		1.2193	.9145	1.2193	.7716
9			.5716		1.1431	1.5242	
10	1.2003	.9526	1.2384		1.1431	1.3336	
11	1.0288	1.0479			1.2384		
12		.9526			1.086	1.2384	
13	1.1145	1.0479	.9526		1.0479	1.1431	
14		1.1431	1.0479		1.1431	1.0479	
15	.7716				.9526		
16	.6859	.7621			1.0479		
17			.9431			1.0288	
19	.6097		.8573	.9431		.9431	
21		.9145	.9431	1.2003		1.0288	
22				1.0288			
23	.7468	.7621	.7621	.9145		.8573	.8059
24	.7373	.7716		.6097	.8383	.7621	
Max	1.2003	1.2003	1.2384	1.2193	1.2384	1.5242	.8573
Min	.6097	.7621	.5716	.6097	.7621	.7621	.6859
Avg	.8606	.9394	.9145	1.0193	1.0193	1.1204	.7613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 224 / 11 KV MIDC KARMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0857	.0857					.0857
3					.0762	.1524	
4	.0857	.0857					.0857
6	.0857	.0572		.0762	.1524	.1524	.0857
8		.0857		.0762	.1524	.1524	.0857
9			.0953		.0953	.1905	
10		.0953	.0953		.1905	.1905	.1715
11	.0857	.0953	.0953		.0953	.1905	
12	.1715	.0953	.0953		.0953	.0953	.1715
13	.1715	.0953	.0953		.0953	.0953	
14	.0857	.0953	.0953		.0953	.0953	.0857
15	.0857				.0953		
16	.0762	.0762			.0953		.1715
17			.0857		.0857	.0857	
18						.0857	.0857
19	.0762		.0857	.0857	.0857	.0857	
21		.0762	.0857	.0857	.0857	.0857	
22				.0857			
23	.0762	.0762	.0762	.0762		.0857	.0857
24	.0857	.0857		.0762	.0762	.0762	.0857
Max	.1715	.0953	.0953	.0857	.1905	.1905	.1715
Min	.0762	.0572	.0762	.0762	.0762	.0762	.0857
Avg	.0976	.0850	.0905	.0803	.1048	.1213	.1091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 229 / 11 WADGAON/BOSE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0709	1.2757	1.2048	1.2048	1.2048
2	.0762	.0762	.0709	1.3289	1.258	1.2048	1.3289
3	.0572	.0953	.0709	1.4175	1.3112	1.7364	1.5061
4	.0953	.0953	.0709	1.4175	1.3643	1.6832	1.5061
5	.0953	.1143	.1063	1.4352	1.4352	1.6832	1.6832
6	.1143	.1143	.1063	1.4352	1.4883	1.6832	1.6832
7	.1334	.1334	.124	1.4706	1.5592	1.5592	1.701
8	.1143	.1143	.124	1.4883	1.5061	1.5415	1.2757
9	.0762	.0953					
11			1.2403				
12	1.8099		1.5061				
13	1.7909		1.5238				
14	1.7147		1.5592				
15	1.7528		1.5592				
16	1.7718		1.5592				
17	1.7909		1.5592				
18	.0572		.0532				
19	.0762		.0709	.1063		.0886	.0953
20	.0953			.124	.124	.0886	.1143
21	.0953		.0709	.1063	.0886	.0886	.0953
22	.1143		.0886	.0886	.0709	.0886	.0762
23	.0953		.0709	.0709	.0709	.0709	.0572
24	.0762	.0953	.0709	1.2403	1.1517	1.134	1.134
Max	1.8099	.1334	1.5592	1.4883	1.5592	1.7364	1.701
Min	.0572	.0762	.0532	.0709	.0709	.0709	.0572
Avg	.5491	.1010	.5560	.9290	.9718	.9897	.9615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 230 / 11 KV MANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3436	1.2003	1.5769	2.6578	2.2148	2.5692	2.4806
2	3.4294	1.286	1.5947	2.6223	2.3743	2.5692	2.5692
3	3.4294	1.3717	1.5947	2.6223	2.4983	2.5692	2.9235
4	3.4808	1.4575	1.5947	2.6578	2.6932	3.0121	3.2779
5	3.4294	1.5432	3.2425	2.7818	2.8349	3.1007	3.3665
6	3.4294	1.7147	3.6677	2.7818	2.9235	3.2779	3.3842
7	3.4808	1.8176	3.6677	2.8349	3.2247	3.3133	3.3842
8	3.4122	3.0864	3.5968	2.959	2.9944	3.0653	3.3665
9	.1029	.0686	.0709	.2658	.1417	.2658	.2915
10	.1372			.2658		.2658	.3258
11	2.3663		2.0908	3.0476	3.0476	3.0121	3.0007
12	2.9321		3.0121		3.2779	3.5437	3.1893
13	2.915		3.1893		3.5437	3.5968	3.275
14	2.8292		2.9767		3.6323	3.4019	3.2407
15	2.915		2.9767		3.7209	3.4019	3.2065
16	2.8292		2.9235		3.7209	3.3665	3.2579
17	2.8807		2.8704		3.5614	3.4019	3.4808
18	.2572		.3189	.3012	.3189		
19	.3429		.4252	.4961		.5138	.5487
20	.4287		.4252	.567	.5316	.443	.6001
21	.463		.443	.5316	.5316	.3721	.583
22	.463		.4607	.5138		.3721	.5144
23	.4287		.4961	.4784	.443	.3721	.4801
24	2.0919	1.166	1.5592	2.0908	2.1262	1.9136	1.9136
Max	3.4808	3.0864	3.6677	3.0476	3.7209	3.5968	3.4808
Min	.1029	.0686	.0709	.2658	.1417	.2658	.2915
Avg	2.1591	1.4712	1.9467	1.6931	2.3979	2.2487	2.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 241 / 11KV GFSS Mangi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.443	.2658	.2126	.1772	.2658	.2658
2	.2658	.3544	.2658	.2126	.1772	.2658	.2658
3	.3544	.3544	.2658	.3189	.1772	.2658	.2658
4	.3898	.443	.5316	.4607	.3189	.3544	.2658
5	.4252	.6379	.6379	.4252	.3721	.443	.3544
6	.4607	.7087	.6379	.4252	.443	.443	.3544
7	.6379	.8859	.6379	.4252	.3189	.443	.4075
8	.6379	.7087	.6733	.4252	.2126		.443
9	.4252	.6379	.2126	.4252	.2126	.2126	.3189
10	.3544			.2126		.1772	.4252
11			.4252	.1063	.2126	.1772	.0886
12	.2126		.4252			.1772	.2126
13	.2126		.4252			.1772	.1949
14	.2126		.4252			.1772	.2126
15	.2126		.4252			.1417	.2126
16	.3544		.4607			.1772	.2126
17	.443		.5316			.1772	.2658
18	.443		.6379	.4252			
19	.5316		.8505	.5316		.4252	.4961
20	.7087		.6379	.6379	.443	.443	.6201
21	.7087		.5316	.567	.2126	.443	.2658
22	.5316		.3544	.4252	.2658	.3544	.2126
23	.443		.2126	.3721	.2658	.2658	.1949
24	.4252	.443		.2126	.3189	.2658	.2658
Max	.7087	.8859	.8505	.6379	.443	.443	.6201
Min	.2126	.3544	.2126	.1063	.1772	.1417	.0886
Avg	.4175	.5617	.4760	.3790	.2752	.2851	.2966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 232 / 11 KV MAJARGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18
HR	Load (MW)	Load (MW)
6	1.9814	1.829
12	.0381	.0381
18	.0381	
24	.0381	.0381
Max	1.9814	1.829
Min	.0381	.0381
Avg	.5239	.6351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 233 / 11 KV UMRAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
6	.0381
12	.0381
18	1.829
23	1.5623
24	.0381
Max	1.829
Min	.0381
Avg	.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 235 / 11KV MANJARGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.381	.4191	.2667	.2286	.4572	.4191	.3429
12	.4191		.3048		.2286	.3429	.2667
13				.2667			
14		.3048					
18	.3429		.3429			.3048	.3048
19		.3429		.3429	.381		
23	.3429	.3429	.3429	.3429	.381	.3048	.3429
24	.2667	.3429	.3429	.3429	.3429	.3048	.3048
Max	.4191	.4191	.3429	.3429	.4572	.4191	.3429
Min	.2667	.3048	.2667	.2286	.2286	.3048	.2667
Avg	.3505	.3505	.3200	.3048	.3581	.3353	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 236 / 11kv Sogaon link line ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
1	2.7435
2	2.8578
3	2.8959
4	2.8959
5	2.6673
6	2.8578
24	2.2862
Max	2.8959
Min	2.2862
Avg	2.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 235 / 11 KV KETTUR/PAREWADI POOL SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0305	.0305	.0457	.0305	.0305		.0457
8	2.1948	2.1948	2.0119	.0305	.0305	.0305	.0457
9						.0305	
12	2.2253	2.0119	2.0119				.0305
16	.0305	.0457	.0305		2.1033	2.1491	2.3472
18						2.1491	
20	.0305	.0457	.0305	2.1033	2.1033		2.1948
22		.0457					
24	.0305	.0305	.0457	.0305	.0305	.0305	.0457
Max	2.2253	2.1948	2.0119	2.1033	2.1033	2.1491	2.3472
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.7570	.6293	.6960	.5487	.8596	.8779	.7849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 237 / 11 KV RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0914	.1067	.061	2.774	5.8528	2.6978
8	.061	1.448	.0762	.061	.0914	.1829	.061
12	1.2498	1.2193	.061				
15						.0914	
16	3.155	2.6825	3.2465		1.2193	1.3717	
18						1.2498	
20	.0305	.061		1.2803	1.3717		
22		3.0483					
24	.061	.1067	.1219	2.2558	3.0178	6.1576	3.0483
Max	3.155	3.0483	3.2465	2.2558	3.0178	6.1576	3.0483
Min	.0305	.061	.061	.061	.0914	.0914	.061
Avg	.9115	1.2367	.7225	.9145	1.6948	2.4844	1.9357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 238 / 11 KV GFSS PAREWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8535	.6401	.7011	.6249	.5792	.6097	.6097
8	.7316	.7621	.6859	.7164	.6097	.6097	.6859
12	.6097	.5182	.5335	.5182	.5335		.6097
15						.4268	
16	.5487	.6097	.4572	.4877	.5944	.4268	.4877
18						.5639	
20	.8383	.9145	.7468	.7316	.884		.7926
22		.7316					
24	.5335	.5487	.5792	.5335	.5182	.5487	.5487
Max	.8535	.9145	.7468	.7316	.884	.6097	.7926
Min	.5335	.5182	.4572	.4877	.5182	.4268	.4877
Avg	.6859	.6750	.6173	.6021	.6198	.5309	.6224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 240 / 11KV POMALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.6978	2.6673	2.4996	2.652	1.5851	1.5851	1.5242
7				1.7375			
8				2.8349	3.0178	3.0636	2.6978
12							2.6368
13						2.7892	
16	1.5851	1.7833	1.829				
20	1.7071	1.6461					
22		1.6461					
24	2.8807	2.6978	2.4691	2.7892	1.5851	1.5242	1.6918
Max	2.8807	2.6978	2.4996	2.8349	3.0178	3.0636	2.6978
Min	1.5851	1.6461	1.829	1.7375	1.5851	1.5242	1.5242
Avg	2.2177	2.0881	2.2659	2.5034	2.0627	2.2405	2.1377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 253 / 11 KV JINTI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.829	1.9814
2		1.9814	1.9814
3		2.2862	2.2862
4		2.5911	2.2862
5		2.7435	2.5911
6		2.8959	2.8959
7		3.2769	2.9721
8		.7621	2.9721
9		.6859	3.0483
10		.5335	
11	.4572	.5335	
12	.4572	.5335	
13	.4572	.4572	
14	.4572	.4572	
15	.4572	.4572	
16	.4572	.4572	
17	.4572	.5335	
18	.6097	.6859	
19	.8383	.7621	
20	.9145	.8383	
21		.7621	
22	.6859	.6859	
23	.6859	.6859	
24			1.829
Max	.9145	3.2769	3.0483
Min	.4572	.4572	1.829
Avg	.5779	1.1928	2.4844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 254 / 11 KV KATRAJ AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524
2		.1524	.1524
3		.1524	.1524
4		.1524	.1524
5		.1524	.1524
6		.1524	.1524
7		.1524	.1524
8		.1524	.1524
9		.1524	.1524
10		.1524	
11	.1524		
12	.1524	.1524	
13	.1524	.1524	
14	.1524	.1524	
15	.1524	.1524	
16	.9907	.9907	
17	1.1431	1.0669	
18	1.2193	1.1431	
19	1.2193	1.1431	
20	1.2193	1.1431	
21		1.1431	
22	.1524	1.1431	
23	.1524	.1524	
24			.1524
Max	1.2193	1.1431	.1524
Min	.1524	.1524	.1524
Avg	.5715	.4572	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 256 / 11 KV TAKALI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762
2		.0762	.0762
3		.0762	.0762
4		.0762	.0762
5		.0762	.0762
6		.0762	.0762
7		.0762	.0762
8		.0762	.0762
9		.0762	.0762
10		.0762	
11	.0762	.0762	
12	.0762	.0762	
13	.0762	.0762	
14	.0762	.0762	
15	.0762	.0762	
16	.5335	.4572	
17	.6097	.5335	
18	.6097	.6097	
19	.6859	.5335	
20	.6097	.5335	
21		.5335	
22	.4572	.5335	
23	.0762	.0762	
24			.0762
Max	.6859	.6097	.0762
Min	.0762	.0762	.0762
Avg	.3302	.2154	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 257 / 11KV RAMWADI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.448
2		1.3717	1.448
3		1.448	1.448
4		1.5242	1.5242
5		1.6004	1.5242
6		1.6766	1.6004
7		1.7528	1.6766
8		.0762	1.6766
9		.0762	1.6766
10		.0762	
11	.0762	.0762	
12	.0762	.0762	
13	.0762	.0762	
14	.0762	.0762	
15	.0762	.0762	
16	.0762	.0762	
17	.0762	.0762	
18	.0762	.0762	
19	.0762		
20	.0762	.0762	
21		.0762	
22	.0762		
23	.0762	.0762	
24			1.3717
Max	.0762	1.7528	1.6766
Min	.0762	.0762	1.3717
Avg	.0762	.5625	1.5394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 258 / 11KV NEMATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524
2		.1524	.1524
3		.1524	.1524
4		.1524	.1524
5		.1524	.1524
6		.1524	.1524
7		.1524	.1524
8		2.5911	.1524
9		3.0483	.1524
10		2.9721	
11	2.6673	2.9721	
12	2.5911	3.0483	
13	2.4387	3.2579	
14	2.2862	2.7435	
15	.1524	.1524	
16	.1524	.1524	
17	.1524	.1524	
18		.1524	
19	.1524	.1524	
20	.1524	.1524	
21		.1524	
22	.1524	.1524	
23	.1524	.1524	
24			.1524
Max	2.6673	3.2579	.1524
Min	.1524	.1524	.1524
Avg	1.0046	1.0031	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEAGAON S/S

Feeder No / Name : 201 / 11 KV POTEAGAON/TARATGAON SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.9814	2.5911	2.713	.1829	.1524	.1524	.1524
16		.1524	.1524		.7621	1.9814	1.9814
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1372	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.9814	2.5911	2.713	.1829	.7621	1.9814	1.9814
Min	.1372	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.757	.7621	.7926	.1626	.3048	.6097	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 202 / 11KV Borgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1829	.1829	2.4387	2.6825	2.5911	2.5911
16	.1524	.1524	.1524				
23	2.7435	2.774	2.5911	.1829	.1524	.1524	.1524
24	2.7892	2.6825	2.6825	2.5911	.1829	.1524	.1524
Max	2.7892	2.774	2.6825	2.5911	2.6825	2.5911	2.5911
Min	.1524	.1524	.1524	.1829	.1524	.1524	.1524
Avg	1.4594	1.4480	1.4022	1.7376	1.0059	.9653	.9653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEAGAON S/S

Feeder No / Name : 203 / 11KV Ghargaon/ Padali AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1524	.1524	.1524	.1677	.1524	.1524
16	1.3717	1.3717	1.2193			1.3717	
23	.1524	.1219	.1524	1.1584	1.2193	1.2193	1.0669
24	.1067	.1524	.1219	.1219	1.0669	1.2193	1.2193
Max	1.3717	1.3717	1.2193	1.1584	1.2193	1.3717	1.2193
Min	.1067	.1219	.1219	.1219	.1677	.1524	.1524
Avg	.4458	.4496	.4115	.4776	.8180	.9907	.8129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEAGAON S/S

Feeder No / Name : 204 / MIRGHAVAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.5911	2.1338	2.1338	2.1033	1.7833	1.2498	1.9814
Max	2.5911	2.1338	2.1338	2.1033	1.7833	1.2498	1.9814
Min	2.5911	2.1338	2.1338	2.1033	1.7833	1.2498	1.9814
Avg	2.5911	2.1338	2.1338	2.1033	1.7833	1.2498	1.9814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 242 / 11KV GFSS Potegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2286	.1677	.1829	.1677	.1829	.1981	.1829
16	.0762	.1067	.1372		.1372	.1524	
23	.1829	.1677	.1524	.1829	.1524	.1524	.1524
24	.1524	.1524	.1524	.1372	.1677	.1524	.1524
Max	.2286	.1677	.1829	.1829	.1829	.1981	.1829
Min	.0762	.1067	.1372	.1372	.1372	.1524	.1524
Avg	.1600	.1486	.1562	.1626	.1601	.1638	.1626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 201 / 11KV WASHIMBE/BHAIRVNATH SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.061	.8383	.0914	.4115		.6706
2	.5792	.061	.884		.381		.6401
3	.6097	.061	.884		.381		.6097
4	.5335	.061	.8383		.4268		.5792
5	.5182	.061	.6097	.1219	.4572		.5792
6	.4572	.061	.381	.1219	.4572		.5487
7	1.0974	1.0517	1.0059				
8	1.1584	1.0517	1.0517				
9		1.0517	1.0974				
10		1.0364	1.1126				
11		1.0669	1.1126				
12		1.0517	1.0974				
13		1.0364	1.1126				
14						1.1888	1.1431
15						1.1888	1.1888
16						1.2041	1.1584
17				1.1431			1.1584
18				1.1584			1.1431
19				1.1736			1.0974
20		.3048	.1219	1.1431			1.0669
21		.6097	.1219	.381		.8535	.4572
22		.8383	.1067	.4572		.8535	.5487
23		.8383	.0914	.4572		.7011	.4572
24	.6401	.061	.8383	.0914	.4115		.7011
Max	1.1584	1.0669	1.1126	1.1736	.4572	1.2041	1.1888
Min	.4572	.061	.0914	.0914	.381	.7011	.4572
Avg	.6893	.5758	.7392	.5764	.4180	.9983	.8087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 202 / 11KV Goyegaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0424	2.1033	1.9814	2.0119	.4572		.3658
2	2.0576	2.1033	2.0119		.4572		.3658
3	2.0576	2.0729	1.9814	2.0729	.4572		.381
4	2.0729	2.0424	1.9814	2.0729	.442		.3963
5	1.9814	1.9814	1.9662	2.1033	.4115		.4268
6	1.9357	1.829	1.9509	2.0729	.381		.3658
7				1.9204	2.1795		2.1948
8				1.9204	2.271		2.2253
9				1.9357			2.3167
10				1.8747		2.0119	2.2253
11						2.0424	2.21
12						2.0729	2.1643
13						2.0881	2.1643
20		.2743	.2743	.381			.3048
21		.2743		.4115			.381
22		.2286	.2286	.4877			.4725
23		1.7528	1.9814	.4572		.4268	.4572
24	2.0576	2.0729	1.9509	2.0119	.4268		.3963
Max	2.0729	2.1033	2.0119	2.1033	2.271	2.0881	2.3167
Min	1.9357	.2286	.2286	.381	.381	.4268	.3048
Avg	2.0293	1.5214	1.6308	1.5525	.8315	1.7284	1.1008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 203 / 11KV WASHIMBE /NANGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6097	.381		2.9111		2.5149
2	.4115	.6401	.381	.884	2.9721		2.4387
3	.3658	.6097	.4268	.9145	2.9416		2.4691
4	.3963	.6249	.4268	.9907	2.8959		2.5149
5	.4877	.5944	.4572		3.0026		2.5301
6	.5792	.5944	.4877	.9907	3.0483		2.5301
14		3.0178	2.7435				
15		3.094	2.8197				
16		3.2007	2.8959				
17		3.1855	2.8349				.7621
18		3.1245	2.7892				.823
19		3.0178	2.774	.6401			.8383
20		2.8045	2.4387	.5944			.8993
21		.4268		.6249			.9145
22		.4572	.9907	.6097			.945
23		.4572	.9145	2.8959		2.4387	2.7587
24	.4268	.5792	.381	.9907	2.9264		2.4691
Max	.5792	3.2007	2.8959	2.8959	3.0483	2.4387	2.7587
Min	.3658	.4268	.381	.5944	2.8959	2.4387	.7621
Avg	.4398	1.5905	1.5089	1.0136	2.9569	2.4387	1.8148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 204 / 11kv Jyotiba Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9145	.9907	.8535	1.1126		1.1888
2	.9602	.9145	.9907	.823	1.1431		1.2193
3	1.0212	.8993	.9907	.823	1.2193		1.2498
4	1.0669	.8993	.945	.8535	1.2346		1.2193
5	1.0669	1.0059	.8383	.884	1.1279		1.2955
6	.8993	1.0669	.6097	.9145	1.4175		1.3108
7	2.5911	2.6673	2.5911				
8	2.652	2.6825	2.652				
9		2.652	2.7435				
10		2.6216	2.8045				
11		2.5911	2.8349				
12		2.5301	2.6978				
13		2.5149	2.774				
14							2.4387
15						2.6978	2.5149
16						2.6978	2.5301
17				2.6825			2.5301
18				2.713			2.4387
19				2.6825			2.4539
20		.2743	.7621	2.5911			2.4082
21		.5792					.8078
22		.7316	.823				.884
23		.8383	.884	.9602		1.1279	.9755
24	1.0364	.9907	.9145	.884	1.0669		1.1584
Max	2.652	2.6825	2.8349	2.713	1.4175	2.6978	2.5301
Min	.8993	.2743	.6097	.823	1.0669	1.1279	.8078
Avg	1.3650	1.5208	1.6380	1.4721	1.1888	2.1745	1.6838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 205 / 11kv Washimbe gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1524	.1524	.1829	.1524		.1219
2	.1372	.1524	.1829		.1524		.1067
3	.1524	.1829	.1829	.2134	.1524		.1219
4	.1524	.2439	.2134		.1524		.1372
5	.1981	.2743	.2134	.2743	.1981		.1524
6	.3048	.2743	.3048	.2896	.2439		.1524
7		.2134	.3048	.3048	.2591		.1677
8	.2286	.1981	.2439	.2743	.1981		.1829
9		.1677	.2134	.2439			.1677
10		.2134	.1524	.2439		.1524	.1715
11		.1829	.1524			.1677	.1524
12		.1829	.1372			.1524	.1372
13		.1524	.1372			.1524	.1219
14		.1372	.1219			.1372	.1219
15		.1372	.1219			.1372	.1372
16		.1524	.1219			.1372	.1715
17		.1524	.1372	.1829			.1715
18		.1981	.1829	.2134			.2058
19		.2134	.2134	.2591			.2401
20		.1829	.2439	.2743			.2572
21		.1829		.2134			.2572
22		.1524	.1829	.2134			.1829
23		.1524	.2134	.1829		.1219	.1524
24	.1524	.1524	.1524	.1677	.1829		.1219
Max	.3048	.2743	.3048	.3048	.2591	.1677	.2572
Min	.1372	.1372	.1219	.1677	.1524	.1219	.1067
Avg	.1829	.1835	.1862	.2334	.1880	.1448	.1631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 206 / Kettur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	2.1033	1.9814		.2134		.2439
2	2.1338	2.1338	1.9814	2.0424	.2134		.2439
3	2.1338	2.1643	1.9509	2.0729	.2286		
4	2.1186	2.0729	1.9052	2.1033	.2286		
5	1.9966	1.9814	1.9052	2.0729	.2286		.3048
6	1.9204	1.89	1.9052	2.0424	.1981		.3353
7				2.0119	2.2862		2.1948
8				1.9814	2.3472		2.2253
9				1.9509			2.271
10				1.9357		2.4387	2.3167
11						2.4082	2.2862
12						2.3777	2.2405
13						1.9814	2.1338
20		.2286	.1219	.2286			.2134
21		.2286		.2286			.2286
22		.1829	.0914	.2134			.3048
23		1.829	1.9814	.2134		.2743	.3048
24	2.0576	2.0881	1.9509	2.0119	.1981		.2743
Max	2.1338	2.1643	1.9814	2.1033	2.3472	2.4387	2.3167
Min	1.9204	.1829	.0914	.2134	.1981	.2743	.2134
Avg	2.0663	1.5366	1.5775	1.5078	.6825	1.8961	1.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 201 / 11 KV RAJURI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.6137	1.4632	1.5242	.3978	.4973	.3222	.3391
4	2.0805	1.9616	1.8576	.5243	.5571	.431	.4915
6	2.4615	2.5006	2.5774	.6642	.6802	.6009	.6802
8	2.2291	2.6006	2.4036	.4807	.4973	.3812	.4475
10			.3688	.3561	.3429	.3222	.2915
11				1.5851			
12	.3429	.3391	.3391		2.1434	1.5242	2.143
14	.3258	.3086	.3222		2.2148	1.3717	2.2009
16	.3429	.3086	.3052		2.721	1.4575	2.0561
18		.3258	.2454		.3391	.2058	.2743
19				2.2291			
20	.5243	.4973	.3978	.431	.3688	.431	.4807
22	.426	.4973	.431	.4641	.4191		.3688
24	1.3717	1.2498	1.2803	.3688	.4024	.3601	.3391
Max	2.4615	2.6006	2.5774	2.2291	2.721	1.5242	2.2009
Min	.3258	.3086	.2454	.3561	.3391	.2058	.2743
Avg	1.1718	1.0957	1.0044	.7501	.9320	.6734	.8427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 202 / 11KV KORTI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2743	.3561	.3258	.3086	.3978	.0914	.1463
4	.2126	.431	.431	.431	.4641	.1629	.181
6	.1463	.4915	.5243	.5571	.5344	.2454	.2401
8	.4024	.3978	.431	.431	.4752	.2279	.1991
10	.3688	.3353	.3086	.3688	.3521	.1086	.1448
11				.3086			
12	.3521	.3258	.2915		.3258	.1267	.1267
14	.3521	.3086	.2915		.2883	.1097	.1086
16	.3185	.2915	.3086		.1629	.128	.1267
18	.2743	.2915	.3258		.1991	.2353	.1448
19				.4973			
20	.5243	.431	.3978	.4641	.1991	.2126	.2279
22	.431	.3978	.3978	.4641	.1448	.1448	.1629
24	.3052	.3086	.3258	.2743	.3429	.1267	.1448
Max	.5243	.4915	.5243	.5571	.5344	.2454	.2401
Min	.1463	.2915	.2915	.2743	.1448	.0914	.1086
Avg	.3302	.3639	.3633	.4105	.3239	.16	.1628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 203 / 11 KV GOREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.181	.1646	.181	.5668	.6478	.6874	.6325
4	.1448	.2149	.2401	.7116	.8381	.9755	.7811
6	.2229	.3086	.3222	.9755	1.0669	1.1584	1.1584
8		.2743	.2401	.945	.9145	.7343	1.1584
10	.181	.1646	.1949	.1448	.1448	.1448	.1448
11				.1448			
12	.9217	1.0364	1.0059		.1448	.1448	.1463
14	1.1279	1.0059	.9145		.0543	.1267	.1463
16	1.0623	.9145	.8124		.1448	.1267	.1463
18	.1629	.181	.1629			.1629	.181
19				.2374			
20	.2743	.2401	.1991	.2229	.181	.2229	.2915
22	.2401	.2401	.197			.181	.181
24	.1829	.1448	.181	.3647	.4973	.5182	.1646
Max	1.1279	1.0364	1.0059	.9755	1.0669	1.1584	1.1584
Min	.1448	.1448	.1629	.1448	.0543	.1267	.1448
Avg	.4274	.4075	.3876	.4793	.4634	.4320	.4277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11KV ZARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.0269	.7682					
8			.9593	.362			
12							.7316
13					.8215		
14						.7468	
18				.7947			
23	.4344	.4298	.4344	.4252	.4298	.4477	.3856
24	.3814	.4207	.3761	.4119	.4298	.4031	.4252
Max	1.0269	.7682	.9593	.7947	.8215	.7468	.7316
Min	.3814	.4207	.3761	.362	.4298	.4031	.3856
Avg	.6142	.5396	.5899	.4985	.5604	.5325	.5141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / 11 KV KHADKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					3.2674		3.0247
8						2.9754	
9				1.8858			
12		2.5972					
13			2.2779				
17	2.9235						
23	.2715	.2172	.2534	.3077	.3439	.3224	.3045
24	.3077	.2427	.2353	.1829	1.4784	1.6461	1.7375
Max	2.9235	2.5972	2.2779	1.8858	3.2674	2.9754	3.0247
Min	.2715	.2172	.2353	.1829	.3439	.3224	.3045
Avg	1.1676	1.0190	.9222	.7921	1.6966	1.6480	1.6889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11KV ZARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.2896	.3224	.3189		.3547	
9	.4108						
13				.1509			
15					.4066		
16						.4525	
19							.4572
23	.1949	.2715	.1791	.2033	.2054	.1612	.1734
24	.1991	.1753	.1612	.1612	.1867	.1829	.1595
Max	.4108	.2896	.3224	.3189	.4066	.4525	.4572
Min	.1949	.1753	.1612	.1509	.1867	.1612	.1595
Avg	.2683	.2455	.2209	.2086	.2662	.2878	.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 201 / CHOBE PIMPARI BOGDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4372	.4696	.4858	.0648	.0648	.0972	.0648
2	.2429	.4696	.5182	.081	.0648	.0972	.0648
3	.1619	.4049	.5506	.0648	.081	.0972	.081
4	.1781	.4049	.583	.1086	.081	.1134	.081
5	.1943	.4372	.6154	.081	.081	.1134	.0972
6	.1943	.4534	.6478	.1134	.0972	.0972	.1296
7	.1134	.6154		.1134	.0972	.0972	.0648
8	.1134	.6154	.5668	.0972	.0972	.0972	.0972
9	.081	.583	.5506	.1134	.0972	.1296	.081
10	.1781	.0972	.1296	.1619	.1457	.1134	.1457
11	.1134	.1134	.0972	.421	.4372	.3887	.3887
12	.1296	.1134	.081		.664	.6478	.5506
13	.1296	.1134	.1134		.8097	.3725	.5668
14	.1457	.1134	.1875		.7773	.5668	.583
15	.4858	.1134	.0972		.7611	.6478	.583
16	.5668	.1134	.1296		.7449	.6802	.5992
17	.5506	.1134	.0972		.7449	.664	.6316
18	.5344	.1134	.1134	.4534	.7773	.664	.7287
19	.1619	.1296	.1094	.1781	.1457	.1406	.1296
20	.1134	.1457	.1134	.1619	.1134	.1619	.1619
21	.1296	.1619	.1296	.1457	.1134	.1619	.1619
22	.1296	.1619	.0972	.1296	.0972	.1296	.1619
23	.1134	.1619	.1134	.1296	.1134	.1296	.1134
24	.5992	.3725	.362	.2753	.0648	.1134	.0972
Max	.5992	.6154	.6478	.4534	.8097	.6802	.7287
Min	.081	.0972	.081	.0648	.0648	.0972	.0648
Avg	.2416	.2746	.2821	.1608	.3030	.2717	.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 202 / 11KV Bogewadi AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.1781	.2267	.9878	1.3765	1.4575	1.4449
2	.2267	.1781	.2267	1.0467	1.3765	1.6842	1.8061
3	.2429	.1781	.2267	1.2793	1.6194	1.7166	1.7309
4	.2753	.2105	.2915	1.3441	1.8623	2.0891	2.1674
5	.2591	.2429	.3239	1.3117	2.8016	2.8988	2.3931
6	.2753	.2429	.2915	1.7166	2.9312	2.8988	2.935
7	.3239	.2915		2.0243	3.0607	3.0769	2.95
8	.2915	.2591	.2267	1.9433	3.0769	2.9959	2.8597
9	.2105	.1781	.2105	2.0405	3.1417	1.6194	2.7694
10	.3401	1.4089	.2591		.2753		.2408
11	2.2186	1.4089	1.4413		.2105		.1806
12	2.5749	2.2672	2.3644		.1943		.1656
13	2.8016	2.3158	2.3805		.2267	.1943	.1505
14	2.5749	2.2672	2.3967		.2267	.2105	.1656
15	2.0567	2.1872	1.6518		.1781	.1943	.1505
16	2.2186	2.1872	2.1214		.1619	.2105	.1656
17	2.2672	2.1559	2.2024		.2105	.2429	.1957
18	2.1538	2.2348	2.2348		.2915	.2753	.286
19	.3887	.2591	.3125	.4858	.4062	.3239	.301
20	.3239	.25	.2591	.3887	.3725	.3725	.3311
21	.2429	.2591	.2105	.3749	.3437	.3401	.3311
22	.2105	.2429	.2105	.3239	.3239	.2105	.3161
23	.1943	.2267	.2267	.2429	.2753	.2753	.301
24	.2429	.1466	.2267	.1457	1.2146	.2591	1.2793
Max	2.8016	2.3158	2.3967	2.0405	3.1417	3.0769	2.95
Min	.1943	.1466	.2105	.1457	.1619	.1943	.1505
Avg	.9636	.9074	.8923	1.0437	1.0899	1.1213	1.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 203 / GFSS chobepimpri
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0156	.0181	.0181	.0181	.0181	.0179
2	.0181	.0162	.0181	.0181	.0181	.0181	.0179
3	.0181	.0181	.0181	.0181	.0181	.0181	.0179
4	.0181	.0181	.0181	.0181	.0181	.0362	.0358
5	.0181	.0181	.0181	.0162	.0181	.0181	.0179
6	.0181	.0181	.0181	.0362	.0181	.0181	.0179
7	.0181	.0181		.0181	.0362	.0181	.0179
8	.0181	.0181	.0181		.0181	.0181	.0179
9	.0181	.0175		.0181	.0181	.0181	.0179
10	.0181	.0181	.0181		.0181	.0181	.0125
11	.0181	.0109	.0145		.0181	.0181	.0179
12	.0181	.0109	.0181		.0181	.0181	.0179
13	.0109	.0109	.0145		.0181	.0109	.0125
14	.0109	.0109	.0109		.0181	.0109	.0125
15	.0109	.0109	.0127		.0145	.0127	.0125
16	.0109	.0109	.0181		.0145	.0109	.0143
17	.0109	.0109	.0181		.0181	.0181	.0143
18	.0109	.0109	.0181	.0181	.0181	.0181	.0179
19	.0181	.0181	.0181	.0362	.0181	.0181	.0179
20	.0181	.0181	.0362	.0181	.0181	.0181	.0179
21	.0181	.0181	.0362	.0181	.0362	.0181	.0179
22	.0181	.0181	.0181	.0181	.0181	.0181	.0179
23	.0181	.0181	.0181	.0181	.0181	.0181	.0179
24	.0181	.0162	.0181	.0181	.0181	.0181	.0179
Max	.0181	.0181	.0362	.0362	.0362	.0362	.0358
Min	.0109	.0109	.0109	.0162	.0145	.0109	.0125
Avg	.0163	.0154	.0188	.0204	.0193	.0177	.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 201 / PADSALI AG.(Old Butashte) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2543		.2251
2	.2374		.2412
3	.2374		.4985
4	.2543		.5789
5	.407		.804
6	.5765		1.7205
7	.5935		2.219
8	.4748		2.1225
9	.373		2.0261
10	.3391		1.6401
11	1.6956		.2251
12	1.8143		.193
13	1.6448		.1769
14	1.2378		.2
15	1.6108		.2334
16	1.7804		.193
17	1.8313		.1608
18	1.7635		.2734
19	.4917		.402
20	.4239		.4663
21	.373		.3538
22	.3391		.2573
23	.2543	.3273	.2412
24	.2374		.2251
Max	1.8313	.3273	2.219
Min	.2374	.3273	.1608
Avg	.8019	.3273	.6532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 202 / DHORE WASTI AG FEEDER(OLD SEPARATED AG FEEDERS HAVING SPECIAL
LAUL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1932		.2257
2	.2093		.2821
3	1.2557		.3197
4	1.4972		.3573
5	1.9319		.4137
6	2.2378		.4701
7	2.3504		.3949
8	2.2217		.3573
9	1.9319		.3197
10	2.0124		.2633
11	.483		1.9745
12	.2415		1.9556
13	.2576		2.4634
14	.2667		2.0497
15	.2737		1.9933
16	.2737		2.0309
17			1.1659
18	.2254		2.2189
19	.4025		.2821
20	.4186		.3761
21	.3703		.3197
22	.322		.2445
23	.2898	.2987	.2257
24	.1932		.2257
Max	2.3504	.2987	2.4634
Min	.1932	.2987	.2257
Avg	.8635	.2987	.8721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 203 / GFSS Padsali
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1316		.1
2	.1504		.1
3	.1504		.1167
4	.1504		.1167
5	.188		.1334
6	.2257		.1667
7	.2445		.2
8	.2257		.2
9	.2257		.1667
10	.2068		.15
11	.1504		.15
12	.1504		.1334
13	.1504		.1334
14	.1316		.1167
15	.1504		.1167
16	.1504		.1167
17	.1692		.15
18	.2068		.15
19	.2445		.1834
20	.2068		.2167
21	.188		.2167
22	.1692		.1834
23	.1504	.1276	.15
24	.1316		.1
Max	.2445	.1276	.2167
Min	.1316	.1276	.1
Avg	.1771	.1276	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 204 / New BUTashte AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)
1		1.3748
2		1.3413
3		.1677
4		.2012
5		.2683
6		.3018
7		.3018
8		.2683
9		.2347
10		.2012
11		.1677
12		.1509
13		.1341
14		.2012
15		.1677
16		.1677
17		.1677
18		.1677
19		2.2466
20		1.9113
21		1.8107
22		1.7101
23	.2246	1.5089
24		1.5089
Max	.2246	2.2466
Min	.2246	.1341
Avg	.2246	.6951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 205 / UJANI (M) AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-APR-18	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	3.0769		.7602
2	3.0045		.6516
3	.362		1.6108
4	.3982		1.8099
5	.543		3.1131
6	.6516		3.3846
7	.8326		3.0769
8	.724		3.4027
9	.7964		3.4027
10	.8326		3.4751
11	.905		.724
12	.724		.6516
13	.724		.5792
14	.8145		.6516
15	.8145		.7783
16	.8145		.724
17	.8326		.724
18	.724		.8688
19	3.2579		1.0136
20	.6697		.9774
21	.6516		.9774
22	.6335		.8326
23	.543	3.2819	.7783
24	3.3303		.8688
Max	3.3303	3.2819	3.4751
Min	.362	3.2819	.5792
Avg	1.1109	3.2819	1.4932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 206 / NEW LAUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	24-APR-18	26-APR-18
HR	Load (MW)	Load (MW)
1		.8029
2		.8402
3		.8962
4		.9335
5		.8775
6		.9335
7		.9335
8		.7842
9		.7842
10		.6722
11		3.3608
12		3.1741
13		3.3608
14		.1867
15		.2614
16		3.3608
17		3.3608
18		3.062
19		.7842
20		.8962
21		.8962
22		.8215
23	.6577	.7468
24		.7655
Max	.6577	3.3608
Min	.6577	.1867
Avg	.6577	1.3957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALKHUNTE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	1.267	1.1222	.5068	.4525	.4525	.4706
2	.362	1.267	1.1222	.5068	.4706	.4525	.4706
3	.362	1.267	1.4118	.543	.4887	.4525	.4887
4	.3982	1.6289	1.6651	.6219	.5068	.543	.5304
5	.4344	1.9909	1.8461	.6516	.543	.6516	.5792
6	.4706	2.0814	2.0271	.7133	.5973		.6516
7	.3658	1.9909	2.1538				
8	.3258	1.8099	1.8642				
9	3.276	3.0769	2.8778	2.0814	1.8642		2.2262
10	3.2579	3.457	3.0588	2.2262	2.371	2.19	2.3167
11	3.2579	3.4932	3.0226		2.2262	2.0633	1.9909
12	3.2579	3.2941	2.9864		2.0271	1.9936	1.8099
13	2.8959	2.9321	3.0407		2.0271	1.9547	1.6289
14	2.8054	2.7149	3.0045		2.0668	1.9547	1.6289
15	2.7149	2.8054	2.9683		2.0485	1.8823	1.8099
16	2.7149	2.8054	2.9321		2.0271	1.9004	1.9004
17					3.4932	3.276	3.6199
18					3.5656	3.4389	3.6199
19				3.7828	3.6763	3.5294	3.4389
20	.543	.5792	.5973	3.2373		2.9864	3.0769
21	.543	.543	.543	3.2217	2.914	2.7511	2.7149
22	.543	.5249	.543	3.2036	2.8597	2.6063	2.4434
23	.4525	.4525	.5068	3.0769	2.3529	2.3891	2.3777
24	.3658	.4525	.4163	.5249	2.9447	2.1176	2.2624
Max	3.276	3.4932	3.0588	3.7828	3.6763	3.5294	3.6199
Min	.3258	.4525	.4163	.5068	.4525	.4525	.4706
Avg	1.4147	1.9254	1.8910	1.7784	1.9773	1.9793	1.9117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 202 / 11 KV AMBAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	.8478	1.0174	2.0119	1.8442	1.8233	1.6741
2	1.0774	.8573	1.0288	2.1795	2.0119	1.8442	1.7736
3	1.1869	.8573	1.1145	2.2131	2.2801	1.989	1.9951
4	1.3413	1.1869	1.3395	2.2801	2.6825	2.2377	2.1125
5	1.5927	1.3413	1.4754	2.3739	2.8837	2.6825	2.7831
6	2.0119	1.6766	1.7295	2.4417	2.9835	3.083	2.9172
7	1.6956	1.8233	2.1195	2.6825	3.5803		3.6797
8	1.1022	1.5089	1.8652	2.3807	1.989		3.315
9				1.4754	1.6575		1.4586
10				1.3413	1.5581	1.56	1.5424
11					1.5089		1.5261
12					1.5089	1.3077	1.326
13					1.5089	1.326	1.2717
14					1.3735	1.1603	1.2574
15					1.3413	1.2742	1.3413
16					1.291	1.2929	1.4089
17	3.6466	3.5968	3.722				
18	3.6466	3.514	3.6885				
19	3.315	3.1824	3.3867				
20	2.8178	3.0001	2.713	.7888	.8916	.8478	.6935
21	2.713	2.8509	2.5774	.6859	.78	.78	.7802
22	2.5149	2.652	2.4863	.6173	.6859	.7545	.5144
23	2.5149	2.5434	2.2377	.5487	.6516	.6935	.5144
24	2.5149	2.3739	2.2891	2.1026	.5144	.6516	.6241
Max	3.6466	3.5968	3.722	2.6825	3.5803	3.083	3.6797
Min	1.0774	.8478	1.0174	.5487	.5144	.6516	.5144
Avg	2.1746	2.1133	2.1744	1.7416	1.6918	1.4887	1.6433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 203 / GFSS KURDU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.463	.4115	.463	.4287	.5144	.463
2	.4287	.463	.3772	.463	.463	.5144	.463
3	.4287	.463	.3772	.4801	.4287	.5144	.4801
4	.5144	.5144	.4287	.4801	.5316	.5487	.5487
5	.5487	.5658	.5144	.5144	.583	.583	.6516
6	.6001	.6173	.5658	.5316	.6173	.6001	.703
8				.5487	.5144	.5658	.4973
9	.6173	.6859	.5144	.5316	.6516		.6516
10	.6001	.6001	.6516	.583	.5487	.6859	.6687
11	.6001	.583	.583	.5144	.5144	.6344	.6001
12	.5487	.5144	.4973	.463	.5144	.583	.5487
13	.4287	.463	.4287	.4458	.5144	.5316	.4801
14	.4287	.4287	.4287	.4458	.4115	.4801	.4801
15	.4287	.4115	.4287	.4115	.4287	.4458	.5144
16	.4115	.3944	.4287	.3601	.463	.4458	.463
17	.3772	.4287	.3944	.4801	.5316	.4115	.5144
18	.3772	.4973	.3429	.4801	.6001	.4458	.5144
19	.5487	.583	.6173	.583	.6687	.6001	.6859
20	.6859	.6344	.6687	.6859		.6516	.7202
21	.6516	.6516	.583	.6859	.7373	.6516	.6516
22	.703	.5487	.5487	.6173	.6859	.6344	.6516
23	.6859	.4801	.5658	.5487	.6001	.5487	.6344
24	.4287	.5144	.4458	.463	.4801	.5144	.4801
Max	.703	.6859	.6687	.6859	.7373	.6859	.7202
Min	.3772	.3944	.3429	.3601	.4115	.4115	.463
Avg	.5214	.5230	.4910	.5122	.5417	.5503	.5681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 201 / MAHADEVWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	.8764	.6706	.1524	.1715	.1905	.1524
2	.9145	.8764	.6859	.1829	.1524	.0191	.1524
3	.8954	.8954	.6859	.1829	.1524	.2286	.1524
4	.9335	.8954	.6706	.1829	.1715	.2667	.1905
5	.9335	.9145	.6859	.1829	.1905	.2667	.2286
6	.9526	1.0669	.7316	.2591	.2286	.3048	.3048
7	.3429	.2286		.823	.884	.7926	.945
8	.3048	.1905	.1981	.8383	.8993	.8535	1.3413
9	.3239	.2477	.1524	.8383	.884	.823	1.3565
10	.2477	.1905	.1829	.8688	.823	.823	1.3717
11	.2667	.1715	.1677	.823	.8383	.8078	1.1431
12	.2477	.1524	.1829		.5792	.7621	.1981
13	.2286	.1524	.1524		.5944	.7316	.6554
14	.2477	.1715	.1372		.6097	.7011	.6401
15	.1905	.1524	.1067		.1524	.1143	
16	.2286	.1715	.1219		.1334	.1524	.1334
17	.2286	.1905	.1372		.1715	.1524	.1715
18	.2477	.2286	.1677	.1219	.1715	.1905	.2096
19	.2667	.2477		.1524	.2286	.2286	.2286
20	.2858	.2286	.2134	.2134	.3048	.2477	.2477
21	.2286	.1905	.1829	.1524	.1905	.2286	.2286
22	.2096	.1715	.1524	.1524	.2286	.1905	.1905
23	.8764	.8002	.7011	.1524	.2096	.1905	.2096
24	1.6385	.8764	.6706	.7316	.1715	.1715	.1715
Max	1.6385	1.0669	.7316	.8688	.8993	.8535	1.3717
Min	.1905	.1524	.1067	.1219	.1334	.0191	.1334
Avg	.5358	.4287	.3526	.3895	.3809	.3933	.4619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 203 / Bandhara Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0953	.1143					
7	3.1436	.1524			.1524		
8	3.2388	2.2862	2.4387		.1524	.0953	
9	3.1626	2.7625	2.4844				
10	3.1436	2.9912	2.2253				
11	2.7625	2.9531	2.3777				
12	2.9531	2.9721	2.332				
13	2.7816	2.572	2.3624				
14	2.8959	2.7816	2.2862				
15					1.829	2.1948	
16					2.0271	2.2862	2.21
17					2.21	2.2558	2.4539
18				2.1948	2.3624	2.2558	2.3472
19				2.3015	2.3624	2.1643	2.2405
20				2.3777	2.1948	2.0729	2.2558
21				2.332	2.1795	1.9509	2.1643
22				2.1948	1.9966	1.8595	2.1795
Max	3.2388	2.9912	2.4844	2.3777	2.3624	2.2862	2.4539
Min	.0953	.1143	2.2253	2.1948	.1524	.0953	2.1643
Avg	2.6863	2.1762	2.3581	2.2802	1.7467	1.9039	2.2645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / GFSS Tandulwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751		.072	.1451		.0761	.1448
2	.0751		.072	.1451		.0761	.1448
3	.0751		.072	.1451		.0761	.1448
4	.0751		.072	.1451		.0761	.1448
5	.0751	.1436	.144	.1814		.1523	.1448
6	.1879		.108	.1814	.1696	.1713	.2172
7	.2254		.108	.1814	.2261	.1903	.181
8	.1691			.1814	.1696	.143	.181
9	.1691			.1451	.1696	.143	.1629
10		.072	.072	.0907	.0942	.143	.1448
11		.072	.072		.0754	.143	.1448
12			.072		.0754	.143	.1448
13			.072		.0754	.143	.1448
14			.072		.0754	.143	.1448
15			.072			.143	.1448
16			.072			.143	.1448
17			.072			.143	.1448
18			.072			.143	.1448
19		.108	.144	.1451	.1507	.1787	.1991
20		.162	.18	.1814	.1507	.143	.2172
21		.144	.18	.2177	.1696	.143	.1629
22		.072	.144	.1451	.0754	.143	.1267
23			.144	.0726	.0754	.143	.1267
24	.0751		.072	.1451		.0715	.1448
Max	.2254	.162	.18	.2177	.2261	.1903	.2172
Min	.0751	.072	.072	.0726	.0754	.0715	.1267
Avg	.1202	.1105	.0982	.1531	.1252	.1339	.1561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / Ridhore Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762	1.3663	1.0254	1.5432
2		.0762	.0762	.9867	1.0727	1.5623
3		.0762	.0953	1.556	1.1358	1.5813
4		.0762	.1334	1.6129	1.1989	1.6004
5		.0762	.1524	1.7078	1.262	1.6194
6		.0762	.1524	1.7647	1.3409	1.6575
7		.1143	.1715	1.7647	1.404	1.6956
8		.1334		1.7647	1.3567	1.848
9		.1334		1.7268	1.3724	1.8099
10		.1334				
11	1.3527	1.5242				
12	1.8671	1.9052				.1524
13	1.8671	1.9243				.1524
14	1.8099	1.9433				.1524
15	1.6004	2.0576				.1524
16	1.8099	2.0576				.1524
17	1.8099	1.9243				.1524
18	1.9052	1.9814				.1524
20	.0762					
21	.1143					
22	.0762					
23	.0762					
24		.0762		1.1385	1.0096	1.5242
Max	1.9052	2.0576	.1715	1.7647	1.404	1.848
Min	.0762	.0762	.0762	.9867	1.0096	.1524
Avg	1.1971	.8614	.1225	1.5389	1.2178	1.0299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / Tandulwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.713		2.1888	1.9033	.4949	.4568	.3807
2	1.8272		2.1888	1.9794	.4949	.4568	.3807
3	1.9033		2.2459	2.0936	.4949	.4568	.4187
4	1.9414		2.284	2.1317	.4949	.4568	.4378
5	1.9985		2.322	2.1888	.552	.4758	.4568
6	2.0936		2.3411	2.3791	.7423	.4758	.4568
7	2.322		2.3791	2.4362	.571	.4949	.4568
8	2.4553		2.4743	2.4743	.571	.4568	.4378
9	2.0936		2.5314	2.5123	.4758	.4758	.4187
10		.2094	.1523	.2094	.3807	.3616	.4187
11		.4378	.4758	2.0365	2.1317	2.1507	1.5226
12		.5329	.571	2.0936	2.5504	2.1698	1.5607
13		.5329	.571	2.1317	2.5504	2.1888	1.713
14		.4949	.571	2.284	2.5885	2.2269	1.9223
15		.4758	.571	2.3791	2.7217	2.284	1.9794
16		.5329	.571	2.4362	2.7788	2.4743	2.0936
17		.552	.571	2.4362	2.6456	2.5123	2.3791
18		.552	.571	2.4362	2.6456	2.7598	2.5694
19			.6471	.3616	.1713	.3426	.1713
20			.6281	.4187	.1903	.3807	.3807
21		.3807	.6281	.4758	.4758	.3616	.4187
22		.3997	.5329	.4949		.3426	.3807
23		.3045	.4758	.4949	.4758	.3616	.3807
24	1.6178		1.6939	1.713	.4949	.4568	.3616
Max	2.4553	.552	2.5314	2.5123	2.7788	2.7598	2.5694
Min	1.6178	.2094	.1523	.2094	.1713	.3426	.1713
Avg	1.9966	.4505	1.2578	1.7709	1.2041	1.0659	.9207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 201 / Nimgaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2058	.6859	.8916	1.5946	1.0288
2	.1715	.1886	.2058	.6859	.8402	1.8862	1.0288
3	.2058	.1886	.1886	.8573	.8916	2.0576	1.0117
4	.1886	.2058	.2058	.8573	.9774	2.229	1.0288
5	.2401	.2058	.2058	.9431	1.0288	2.4006	1.1145
6	.3086	.2229	.2915	1.0288	1.0802	2.572	1.3203
7	.2572	.2058	.2572	1.1488	1.406	3.2236	1.6461
8	.2058	.2058	.2058	1.2346	1.4575	3.1208	1.5604
9	.2229	.1715	.2401	1.286	1.4746	1.4575	1.5604
10	.2401	.2058	.2229	.2229	.2401	.2229	.3258
11	1.286	.7773	.9774	.1886	.2743	.2229	.2401
12	1.4403	1.4575	1.4575	.1715	.2572	.2058	.2058
13	1.3546	1.5432	1.2346	.2743	.2229	.2401	.2401
14	1.3375	1.4403	1.2003	.2572	.2058	.2229	.2401
15	1.3889	1.4575	1.2689	.3086	.2058	.2058	.2229
16	1.4746	1.4918	1.286	.2743	.2058	.2572	.2572
17	1.4575	1.6632	.9145	.3086	.2229	.2915	.0686
18	1.406		1.3717	.2401	.2572	.2229	.1543
19	.2401	.3086	.2229	.2915	.3258	.2229	.2058
20	.2743	.2743	.16	.2915	.6172	.2572	.2401
21	.2743	.2572	.3086	.3086	.583	.2743	.3086
22	.2572	.2401	.2915	.2915	.583	.2915	.3086
23	.2229	.2572	.2572	.8573	.4629	.2401	.2915
24	.1886	.2058		.4973	.8573	.8574	1.0117
Max	1.4746	1.6632	1.4575	1.286	1.4746	3.2236	1.6461
Min	.1715	.1715	.16	.1715	.2058	.2058	.0686
Avg	.6173	.5818	.5731	.5630	.6487	1.0324	.6509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 202 / MADHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.6173	.6344	.6173	.6344	.6001	.6687
2	.6859	.5658	.6001	.6001	.6001	.5658	.6344
3	.6173	.5144	.5658	.5658	.6516	.5487	.6001
4	.6516	.5487	.5144	.6173	.6516	.5144	.6001
5	.583	.583	.6001	.6516	.6173	.6001	.6344
6	.6173	.6173	.6687	.6687	.6687	.6344	.6859
7	.6859	.6173	.6344	.6687	.6344	.6173	.7202
8	.6173	.5487	.6173	.6516	.5658	.6173	.6687
9	.6173	.5658	.583	.6344	.6001	.6859	.6344
10	.6344	.583	.6001	.6173	.703	.7545	.6516
11	.6859	.583	.6173		.6516	.7202	.703
12	.7545	.6516	.7202	.7545	.6859	.6859	.7716
13	.7373	.6516	.703	.6859	.7202	.7716	.6859
14	.703	.6516	.7716	.6859	.7373	.7202	.6516
15	.6344	.6687	.7545	.6859	.6859	.7545	.703
16	.6859	.6516	.8059	.703	.6687	.8059	.7202
17	.4458	.7202	.7888	.7545	.6859	.7545	.7545
18	.7202	.7545	.8059	.7373	.7545	.7888	.7888
19	.7716	.823	.8402	.8402	.9088		.8402
20	.8059	.8916	.8573	.8402	.8402	.8916	.8745
21	.7716	.8059	.7888	.8059	.7545	.8573	.8402
22	.7202	.7545	.6859	.7545	.6859	.7545	.7888
23	.6859	.6859	.6173	.6687	.6516	.7202	.7202
24	.6687	.6344	.6516	.583	.6687	.583	.6859
Max	.8059	.8916	.8573	.8402	.9088	.8916	.8745
Min	.4458	.5144	.5144	.5658	.5658	.5144	.6001
Avg	.6752	.6537	.6844	.6866	.6844	.6933	.7095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 203 / JADHAVWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0117	1.1145	1.0631	.2743	.1543	.4802	.1715
2	.9431	1.1145	1.1488	.2743	.1543	.5144	.1715
3	1.0117	1.2346	1.0631	.2572	.1886	.4172	.1715
4	1.0974	1.286	1.2003	.2915	.1715	.4802	.2058
5	1.286	1.3717	1.3546	.2915	.2058	.5144	.2058
6	1.5432	1.8004	1.8347	.2572	.2401	.4802	.2401
7	1.8347	2.0576	1.9033	.2572	.2743	.5486	.2572
8	1.9033	1.7147	1.9204	.2401	.2572	.5144	.2572
9	1.9204	1.7661	1.989	.1886	.1886	.2229	.2229
10	.2572	.1372	.2058	.2058	.2401	.2572	
11	.2743		.1715	1.5089	1.5604	1.9547	1.5432
12	.2915		.2058	2.1434	1.8004	2.332	1.5432
13	.2229	.2058	.1886		2.0405	2.2634	2.1605
14	.2572	.2401	.1715		2.6406	2.2291	2.0919
15	.2058	.2229	.1886		2.2291	2.2291	2.0405
16	.2058	.2229	.2058		1.869	2.3148	2.1262
17	.2229	.2401		2.0062	2.2119	2.0233	2.2462
18		.2058	.2572	2.2291			2.2291
19	.2915	.2572	.3086	.2058	.2401	.2572	.2572
20	.2743	.2915	.4115	.2572	.5486	.2915	.2401
21	.2572	.2572	.4287	.2229	.5486	.2572	.2401
22	.2572	.2572	.4287	.1886	.5144	.2401	.2572
23	.2058	.2229	.2629	.1886	.5144	.1886	.2229
24	.9602	.9259		.3258	.1715	.4802	.1543
Max	1.9204	2.0576	1.989	2.2291	2.6406	2.332	2.2462
Min	.2058	.1372	.1715	.1886	.1543	.1886	.1543
Avg	.7276	.7794	.7688	.5907	.8245	.9344	.8372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 204 / chincholi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2572	.583	.0514	.0171	.0514	.0343
2	.1715	.2229	.6001	.0514	.0171	.0514	.0343
3	.2229	.2229	.5316	.0514	.0343	.0514	.0343
4	.2915	.2572	.4973	.0686	.0343	.0686	.0514
5	.3429	.3429	.4115	.1029	.0514	.0857	.0514
6	.5316	.5658	.4801	.1029	.0514	.0857	.0686
7	.4973	.7373	.9602	.12	.0857	.0857	.0686
8	.6173	.7716	.8573	.0686	.0857	.0857	.0514
9	.5658	.823	.7716	.0514	.0514	.0686	.0343
10	.0686	.0343	.0686	.0343	.0343	.0514	.0514
11	.0514	.0343	.0343	.5144	.6859	.6516	.5144
12	.0343	.0343		.7716	.7716	1.0288	.7545
13	.0343	.0343	.0343		.8573	.9431	.7888
14	.0343	.0343	.0343		1.0288	.8916	.8059
15	.0343	.0343	.0343		.7202	.9602	.8573
16	.0343	.0343	.0343		.7716	.7888	.9602
17	.0343	.0343	.0343	.6516	.8402	.8573	.8402
18	.0343	.0514	.0514	.7888	.9774	.8573	.8573
19	.0514	.0343	.0572	.0343	.0686	.0686	.0514
20	.0514	.0343	.0686	.0686	.1029	.0686	.0514
21	.0514	.0857	.1029	.0343	.1029	.0514	.0686
22	.0514	.0514	.1029	.0343	.0857	.0514	.1029
23	.0514	.0686	.0857	.0343	.0686	.0343	.0857
24	.1886	.2572	.1715	.0514	.0171	.0514	.0343
Max	.6173	.823	.9602	.7888	1.0288	1.0288	.9602
Min	.0343	.0343	.0343	.0343	.0171	.0343	.0343
Avg	.1765	.2108	.2873	.1843	.3151	.3329	.3022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 201 / WAKAV

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.3086	.3258	.3429	.3506	.4287	.3429
2	.823	.3086	.3258	.3429	.3506	.4287	.3429
3	.823	.3086	.3258	.3429	.3506	.4287	.3429
4	.823	.3772	.3258	.3429	.4382	.4287	.3772
5	.8916	.4801	.4458	.3429	.5258	.5487	.4115
6	.9602	.6001	.5658	.4115	.6135	.6516	.4458
7	.9602	.5316	.5144	.4801	.6661	.6001	.3429
8	1.9376	.4458	.4287	.4801	.4908	.5487	.2743
9	6.31	2.8292	3.738		.3506	.3772	.4115
10	5.7956	3.2065	3.0178		.3429	.3772	.3429
11	3.155	3.5151	3.1893		.2743	.2058	.3258
12	3.4122	3.5837	3.6008			.2058	.3086
13	3.0521	3.6008	3.4808		.2401	.2058	.3086
14	2.9664		3.4294		.2229	.2058	.2915
15	3.4294	3.1893			.2229	.2058	.2743
16	3.6351	3.9095	3.5665			.2058	.2572
17	.2915	.2058	.1715	7.8018	3.9266	2.915	3.6008
18	.2915	.3086	.2743	.3155	3.9781	3.2236	3.5665
19	.4287	.463	.3429	.5434	3.9438	3.2579	3.035
20	.5658	.5487	.4458	.5258	3.5151	2.5549	2.7949
21	.4973	.4287	.4115	.5258	3.3265	2.4006	2.6235
22	.4287	.3772	.4115	.4733	3.2922	2.2977	2.4863
23	.3429		.3429	.3856	3.3265	2.2462	2.4006
24	.823	.3086	.3258	.3429	.3681	3.3436	2.2462
Max	6.31	3.9095	3.738	7.8018	3.9781	3.3436	3.6008
Min	.2915	.2058	.1715	.3155	.2229	.2058	.2572
Avg	1.8111	1.3562	1.3046	.8750	1.4144	1.1789	1.1731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 203 / ANGENGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.343	.1715	.1715	.1715		.1372	.1715
2	.343	.1715	.1715	.1715		.1372	.1715
3	.343	.1715	.1715	.1715		.1372	.1715
4	.343	.2058	.1715	.1715		.1372	.1715
5	.5144	.2572	.2572	.1715		.1715	.1715
6	.5144	.3086	.3086	.2058		.3258	.1715
7	.5144	.3086	.2743	.2572		.3086	.1715
8	.4116	.2058	.1715	.2058		.2743	.1715
9	6.0014	2.8121	2.915			.1715	.1715
10	5.487	3.3608	2.8121		.1029	.1372	.1372
11	3.0864	3.3951	2.7435		.1029	.1372	.12
12	3.275	3.4294	2.5034			.1372	.1029
13	3.2579	3.155	2.4691		.0857	.1372	.1029
14	3.2579				.1029	.1372	.1029
15	3.3436	3.2579			.0857	.1372	.1029
16	3.5665	3.3265				.1372	.1029
17	.1029	.0857	.1029	6.3801	3.1207	3.035	3.0864
18	.1029		.1029	.1753	3.1207	3.1722	3.0178
19	.2058	.2401	.1029	.1753	3.0864	3.1722	2.8464
20	.2743	.2572	.1715	.1753	2.915	2.7435	2.452
21	.2058	.2058	.1715	.1753	2.7778	2.8292	2.5206
22	.1715	.1715	.1715		2.6406	2.7435	2.4691
23	.1715	.1715	.1715		2.5034	2.6578	2.1434
24	.343	.1715	.1715	.1715		2.4006	2.6578
Max	6.0014	3.4294	2.915	6.3801	3.1207	3.1722	3.0864
Min	.1029	.0857	.1029	.1715	.0857	.1372	.1029
Avg	1.5075	1.1746	.7765	.6271	1.7204	1.0631	.9795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 204 / KHAIRAO

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.3148	2.572	.2058	.1928	.2058	.2058
2	2.4006	2.3148	2.572	.2058	.1928	.2058	.2058
3	2.4006	2.3148	2.572	.2058	.2103	.2058	.2058
4	2.4863	2.4863	2.572	.2058	.2103	.2058	.2058
5	2.572	2.7435	2.8292	.2058	.2454	.2572	.2401
6	2.8635	2.915	3.2236	.2743	.2804	.2743	.2743
7	2.6578	2.6406	3.4637	.2743	.2804	.2572	.2743
8	2.6578	2.6235	2.7778	.2058	.2279	.2229	.2058
9	.2743	.2229	.1715	3.4979	2.5941	3.3779	3.0178
10	.1715	.1715	.1715		2.9835	3.2579	3.035
11	.1715	.1372	.12		3.1036	3.2579	3.2236
12	.1715	.12	.1029		3.1722	3.2579	3.3951
13	.1372	.12	.12		3.0864	2.8635	3.1722
14	.1372		.12		2.7435	3.0178	3.0693
15	.12	.1372			2.8292	3.0178	3.1207
16	.12	.1372			2.8978	3.2236	3.2579
17	.12	.1029	.1372	.1543	.1543	.2058	.1372
18	.12		.1372	.1753	.1543	.2058	.1543
19	.2058	.2401	.2743	.2804	.2058	.2743	.2572
20	.2915	.2743	.2743	.2629	.2915	.2743	.3258
21	.2401	.2572	.2743	.2454	.2572	.2743	.2915
22	.2229	.2401	.2743	.2454	.2401	.2743	.2572
23	.1886	.2058	.2058	.2103	.2058	.2743	.2229
24	.2743	.1886	.1715	.2058	.1928	.2058	.2743
Max	2.8635	2.915	3.4637	3.4979	3.1722	3.3779	3.3951
Min	.12	.1029	.1029	.1543	.1543	.2058	.1372
Avg	.9752	1.0413	1.1426	.4154	1.1230	1.2124	1.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 205 / KAPASEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.343	.1372	.1372	1.5432	1.5775	1.7147	1.7147
2	.343	.1372	.1372	1.5432	1.5775	1.7147	1.7147
3	.343	.1372	.1372	1.5432	1.5775	1.7147	1.7147
4	.343	.1372	.1372	1.3203	1.7528	1.7147	1.8861
5	.5144	.1715	.2058	.2572	1.9281	1.9071	1.9719
6	.5144	.2058	.2401	.2572	2.1735	2.0576	2.3148
7	.5144	.2743	.2572	.2572	2.0157	2.0576	1.9719
8	.4116	.2058	.1886	.2058	1.8404	2.0576	2.1434
9	.343	.1715	.1715		.1753	.1543	.2058
10	.343	.1029	.1372			.0686	.1372
11	.1372	.0686	.1029		.0857	.1372	.1029
12	.0857	.0857	.1029		.0857	.1372	.0857
13	.0857	.0857	.1029		.0857	.1372	.0857
14	.0857		.1029		.1029	.1372	.1029
15	.0857	.1029			.1029	.1372	.1029
16	.0857	.1029			.1029	.1372	.1029
17	2.4006	2.2805	2.0748	.1905	.0686	.1372	.1029
18	2.4348		2.1605	.0876	.0686	.1715	.1029
19	2.1605	1.9376	1.7147	.1753	.1543	.2572	.1372
20	1.989	1.9719	1.6289	.1753	.2058	.2572	.2058
21	1.9376	1.9719	1.6289	.1227	.1715	.1715	.1372
22	1.8519	1.9719	1.6289	.1052	.1029	.1715	.1029
23	1.7833	1.9719	1.5432	.1052	.1029	.1715	.1029
24	3.6008	1.6804	1.9719	1.5432	.1052	.1029	.1715
Max	3.6008	2.2805	2.1605	1.5432	2.1735	2.0576	2.3148
Min	.0857	.0686	.1029	.0876	.0686	.0686	.0857
Avg	.9474	.7233	.7506	.5895	.7028	.7261	.7259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 206 / kumbhej

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.343	.1372	.1715	1.1145	1.1393	.7202	1.5432
2	.343	.1372	.1715	1.1145	1.1393	.7202	1.5432
3	.343	.1372	.1715	1.1145	1.2269	.7202	1.5432
4	.4116	.1372	.1715	1.2003	1.2269	.7202	1.5432
5	.5144	.1715	.1715	.1715	1.5775	.7545	1.6289
6	.5144	.2058	.1715	.1715	1.7528	.7545	1.6975
7	.5144	.2058	.1715	.2572	1.9281	.7545	1.6975
8	.5144	.2058		.2572	1.8404	.7716	1.8004
9	.343	.1715			.1753	.0857	.1715
10	.343	.1715	.1372		.1715	.0857	.1715
11	.2058	.1372	.12		.1372	.1372	.1372
12	.2058	.12	.12		.12	.1372	.1372
13	.2058	.12	.12		.12	.1715	.12
14	.2058		.12		.12	.1715	.12
15	.2058	.12			.1029	.1715	.1029
16	.1715	.12			.1029	.1715	.1029
17	1.3375	1.1488	1.286	.2427	.1029	.1715	.1029
18	1.3889	.8573	1.286	.1227	.1029	.1715	.1029
19	1.2689	.8573	1.1831	.1928	.1372	.1715	
20	1.166	.9259	1.0802	.1753	.1715	.2572	.2401
21	1.0631	.823	1.0631	.1753	.1715	.2572	.1715
22	1.0974	.7716	1.0631	.1753	.1715	.2572	.1372
23	.9602	.7202	1.1145	.1753	.1029	.2058	.1029
24	2.5378	.9431	.6859	1.1145	.1753	.0857	.1715
Max	2.5378	1.1488	1.286	1.2003	1.9281	.7716	1.8004
Min	.1715	.12	.12	.1227	.1029	.0857	.1029
Avg	.6752	.4063	.5290	.4859	.5840	.3594	.6561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 201 / Uplai(BK)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.12	.1715	.8573	1.286	1.286	1.1145
2	.1715	.12	.1715	.8573	1.286	1.286	1.1145
3	.1715	.12	.1715	.8573	1.3717	1.3717	1.1145
4	.1715	.1715	.1715	1.0288	1.4575	1.5432	1.2003
5	.1715	.2058	.2572	1.3717	1.5432	1.8004	1.5432
6	.1715	.2401	.2572	1.8004	1.5432	1.8861	1.7147
7	.2229	.2572	.2572	2.0576	2.0576	2.1434	1.8004
8	.2058	.2058	.2572	2.0576	1.8861	2.1434	1.9719
9	.1715	.1715	.2058	1.9719	1.7147	1.7147	1.8861
10	.1543	.1715	.1372	.1715	.1715	.1715	.7716
11	1.3717	1.0288	1.3717	.0857	.1372	.1029	.1715
12	2.0576	1.3717	1.8861	.0857	.1029	.1029	.1715
13	1.286	1.9719	1.8004	.0857	.1029	.1029	.1715
14	1.8861	1.9719	1.7147	.0857	.0857	.1029	.1029
15	1.7147	1.8861	1.7147	.0857	.0686	.12	.1029
16	1.8004	1.8861	1.8004	.0857	.0857	.12	.1029
17	2.0576	1.8861	1.8004	.1372	.0857	.12	.1029
18	1.8861	1.9719	1.7147	.1715	.1715	.12	.1029
19	.1715	.2572	.1715	.1715	.1715	.1715	.1029
20	.1715	.2572	.1886	.1715	.1715	.2229	.1029
21	.2572	.2572	.1886	.1715	.2572	.1715	.1372
22	.1543	.2572	.1543	.1715	.2572	.1543	.1715
23	.1372	.1715	.12	.12	.1715	.1715	.1715
24	.1715	.1372	.1372	.7716	.8573	.8573	.8573
Max	2.0576	1.9719	1.8861	2.0576	2.0576	2.1434	1.9719
Min	.1372	.12	.12	.0857	.0686	.1029	.1029
Avg	.7045	.7123	.7009	.6430	.7102	.7495	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 202 / Rophale(KH)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.1145	1.286	.1715	.1715	.2572	.1715
2	1.3717	1.1145	1.6289	.1715	.1715	.2572	.1715
3	1.5432	1.1145	1.8004	.1715	.1715	.2572	.1715
4	1.8861	1.286	1.8861	.1715	.1715	.2572	.1715
5	1.8861	1.5432	1.8861	.1715	.1715	.2572	.1715
6	2.1434	2.2291	2.4006	.1715	.1715	.2572	.1715
7	2.4863	2.6578	2.7435	.2572	.2572	.2572	.1715
8	2.7435	2.6578	2.2291	.1715	.2572	.2572	.1715
9	1.7147	2.572	2.0576	.1715	.1524	.2572	.1715
10	.1715	.2572	.1715	.1715	.1715	.2572	.1715
11	.1715	.1715	.1715	1.8861	1.1145	1.7147	1.8861
12	.1715	.1715	.1715	2.4006	2.572	2.2291	1.9719
13	.1715	.1715	.1715	2.6578	2.572	2.3148	2.0576
14	.1715	.1715	.1715	2.572	2.4006	2.3148	2.2291
15	.1715	.1715	.1715	2.572	2.4006	2.4006	2.2291
16	.1715	.1715	.1715	2.6578	2.4863	2.6578	2.1434
17	.1715	.1715	.1715	2.572	2.2291	2.572	2.1434
18	.1715	.1715	.1715	2.4006	2.0576	2.4863	.2058
19	.1715	.1715	.1715	.2572	.2572	.1715	.2572
20	.1715	.2572	.1715	.2572	.2572	.1715	.2572
21	.1715	.2572	.1715	.2572	.2572	.1715	.2572
22	.2572	.2572	.1715	.2572	.2572	.1715	.1715
23	.1715	.2572	.1715	.2572	.2572	.2572	.1715
24	.8573	.8573	.8573	.1715	.2572	.2572	.1715
Max	2.7435	2.6578	2.7435	2.6578	2.572	2.6578	2.2291
Min	.1715	.1715	.1715	.1715	.1524	.1715	.1715
Avg	.8538	.8323	.8824	.9574	.8851	.9359	.7445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 204 / GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572	.2572	.2572	.3429
2	.2572	.2572	.2572	.2572	.2572	.2572	.3429
3	.2572	.2572	.2572	.2572	.2572	.2572	.3429
4	.2572	.1715	.2572	.2572	.2572	.2572	.3429
5	.2572	.1715	.2572	.2572	.2572	.2572	.2572
6	.2572	.1715	.2572	.2572	.2572	.2572	.2572
7	.2572	.1715	.2572	.3429	.2572	.2572	.2572
8	.2572	.2572	.2572	.2572	.3429	.2572	.3429
9	.2572	.3429	.3429	.2572	.2572	.2572	.2572
10	.3429	.2572	.3429	.2572	.2572	.2572	.2572
11	.3429	.2572	.3429	.2572	.2572	.2572	.2572
12	.1715	.2572	.3429	.2572	.3429	.2572	.2572
13	.2572	.2572	.2572	.2572	.2572	.3429	.2572
14	.3429	.2572	.2572	.2572	.2572	.2572	.2572
15	.1715	.2572	.2572	.2572	.1715	.2572	.2572
16	.1715	.2572	.1715	.2572	.1715	.2572	.2572
17	.1715	.2572	.2572	.2572	.1715	.2572	.2572
18	.3429	.2572	.1715	.2572	.1715	.2572	.2572
19	.2572	.2572	.2572	.3429	.2572	.2572	.2572
20	.3429	.3429	.3429	.3429	.3429	.2572	.2572
21	.3429	.3429	.3429	.3429	.3429	.3429	.2572
22	.3429	.3429	.3429	.3429	.3429	.3429	.1715
23	.3429	.3429	.3429	.3429	.3429	.3429	.1715
24	.2572	.3429	.2572	.3429	.2572	.2572	.3429
Max	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Min	.1715	.1715	.1715	.2572	.1715	.2572	.1715
Avg	.2715	.2643	.2786	.2822	.2643	.2715	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 205 / Kumbhej

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	28-APR-18
HR	Load (MW)
9	1.7661
10	2.8635
11	2.6749
12	2.6578
13	2.6063
14	2.8292
15	3.0007
16	3.2065
17	.3086
18	.2743
19	.3086
20	.3429
21	.3429
22	.3772
23	.3429
Max	3.2065
Min	.2743
Avg	1.5935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 206 / UPLAI(KH)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.6461	1.8861	.3258	.2572	.2572	.3258
2	1.8861	1.6461	1.9719	.3258	.2572	.2572	.3258
3	1.8861	1.6461	2.1434	.3258	.2572	.2572	.3258
4	2.0576	1.6975	2.2291	.3601	.2572	.2572	.3429
5	2.4006	1.8861	2.2291	.4115	.2572	.3429	.3772
6	2.4863	1.9719	2.4863	.463	.3429	.3429	.4115
7	2.7435	2.0748	2.915	.4973	.4801	.3944	.4458
8	2.7435	2.8635	2.8292	.4287	.3772	.4115	.4458
9	.1715	.3429	.2572	2.0576	1.0288	1.5432	
10	.2743	.3429	.3086	2.4863	1.5432	2.8635	
11	.2743	.2401	.3258	2.8292	2.572	2.9321	
12	.2572	.2572	.3258	2.572	2.6578	2.3148	
13	.2058	.3086	.3258	2.4863	2.7435	2.5549	
14	.2058	.3429	.2743	2.4863	3.0007	2.5549	
15		.3429	.2743	2.572	3.0864	2.3148	
16	.2572	.3429	.2743	2.4006	3.0864	2.332	
17	.3258	.3429	.2915	.2572	.3429	.2572	
18	.3258	.3429	.3086	.3429	.3429	.2915	
19	.3601	.3772	.3429	.4287	.4287	.3429	
20	.3429	.4287	.3601	.4287	.4287	.463	
21	.3086	.3429	.3944	.3429	.4287	.3429	
22	.3086	.3429	.3772	.3429	.4287	.3601	
23	.3086	.2915	.3429	.2915	.3429	.3429	
24	.2572	.3086	.2572	.3258	.2572	.2572	.3429
Max	2.7435	2.8635	2.915	2.8292	3.0864	2.9321	.4458
Min	.1715	.2401	.2572	.2572	.2572	.2572	.3258
Avg	.9572	.8638	.9888	1.0745	1.0502	1.0245	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 207 / vittalwadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.1886	.1715	.1715	.1715	.2572	.1543
2	.2572	.1886	.1715	.1715	.1715	.2572	.1543
3	.2572	.1886	.1715	.1715	.1715	.2572	.1543
4	.2572	.2058	.1715	.2058	.1715	.2572	.1715
5	.2572	.2229	.2572	.2401	.2572	.2572	.2058
6	.2572	.2572	.2572	.2572	.2572	.2572	.2229
7	.3429	.2572	.3429	.3086	.2572	.2572	.2401
8	.2572	.2915	.2572	.3429	.2572	.2572	.2572
9	1.7147	1.6289	1.5432	.3429	.1715	.2572	.2058
10	2.1091	1.8861	2.0405	.2572	.1715	.1886	.1886
11	1.5947	2.1776	2.0405	.1715	.1715	.1372	.1372
12	2.0062	2.0576	2.0405	.1715	.1715	.1543	.1715
13	1.6118	1.8176	1.9204	.1543	.1715	.0514	.1886
14	1.8861	1.8861	1.989	.1543	.1715	.1372	.1715
15	1.7661	1.8861	2.0576	.1372	.1543	.1372	.1715
16	1.9719	1.9204	1.989	.1715	.1543	.1543	.1543
17	.1372	.2572	.1543	1.8861	2.3148	1.4575	1.869
18	.1543	.2572	.1543	2.4006	2.2291	2.4691	2.3834
19	.2401	.2572	.1715	2.1434	2.0576	2.0576	2.2291
20	.2401	.2572	.2058	1.8861	1.9719	1.989	2.0576
21	.2401	.2572	.2229	1.9719	1.9719	1.9719	1.8861
22	.2401	.2572	.1886	1.8861	1.8861	1.9547	1.8347
23	.2058	.2572	.1886		1.7661	1.8519	1.7147
24	.1715	.1886	.1715	.1715	1.7147	1.7147	1.749
Max	2.1091	2.1776	2.0576	2.4006	2.3148	2.4691	2.3834
Min	.1372	.1886	.1543	.1372	.1543	.0514	.1372
Avg	.7680	.7937	.7866	.6859	.7902	.7809	.7780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 208 / londewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.1715	.2572	1.5432	1.4575	1.286	1.4232
2	.2572	.1715	.2572	1.5432	1.5432	1.5432	
3	.2572	.1715	.2572	1.5432	1.5432	1.5432	1.4232
4	.2572	.1715	.2572	1.6289	1.8861	1.6289	1.4575
5	.2572	.1715	.2572	1.9719	1.8861	1.8861	1.5432
6	.3429	.2572	.2572	2.1262	1.9719	2.0576	1.7147
7	.3429	.3086	.2915	2.3491	2.452	2.3148	1.8004
8	.2572	.2743	.2572	2.0576	2.2805	2.1091	2.0233
9	.2058	.2572	.2572	.2572	.1715	.1715	.1715
10	.1715	.2572	.2401	.2572	.1715	.1715	.1715
11	.1715	.1715	.2058	.1372	.1715	.1372	.1372
12	.1372	.1715	.1543	.1372	.12	.12	.1372
13	.1029	.1715	.1372	.1543	.12	.12	.1372
14	.12	.1715	.1372	.1372	.12	.1886	.1715
15	.12	.1715	.1543	.1029	.12	.1886	.1715
16		.1715	.1543	.1372	.12	.1886	.1886
17	2.4006	1.8861	1.5432	.1715	.1715	.1886	.2058
18	2.3834	1.9719	2.4177	.1715	.2572	.2058	.2058
19	2.2634	2.0576	2.3148	.2572	.4287	.2572	.2058
20	2.1434	1.8861	2.1434	.2572	.3429	.3086	.2058
21	1.7147	1.8861	1.9547	.2572	.2572	.2572	.2058
22	1.6118	1.8004	1.8861	.1715	.2572	.1886	.2058
23	1.7318	1.8004	1.8004	.1715	.2572	.1886	.1715
24	1.7147	1.6804	1.7147	1.7318	.1715	.1715	.1886
Max	2.4006	2.0576	2.4177	2.3491	2.452	2.3148	2.0233
Min	.1029	.1715	.1372	.1029	.12	.12	.1372
Avg	.8357	.7588	.8045	.8030	.7616	.7259	.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 201 / Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5041	.4641	.5281	1.6512	1.656	1.5384
2	.5041	.4887	.4531	.5228	1.5623	1.6129	1.6324
3	.5093	.4805	.4687	.547	1.5655	1.5684	1.6248
4	.5544	.5487	.4961	.5601	1.5684	1.4723	1.6876
5	.5788	.6161	.4641	.5788	1.5813	1.4575	1.3123
6	.679	.7922	.5441	.7545	.6099	.5788	.5434
7	.7655	.8029	.5761	.8299	.7095	.7095	.6089
8	.7356	.7282	.7059	.7922	.7468	.7468	.6443
9	.6722	.6908		.679	.7655	.7095	.6661
10	.5304	.6335			.7282	.6348	.6161
11	.5544	.6154	.6348		.7095	.6535	.5914
12	.5601	.3439	.5658			.6154	.5975
13	.298	.3258	.2987		.6348	.6878	.5914
14	2.0553	1.9845	1.906		.6161	.6154	.5914
15	2.0481	2.0081	2.0485			.5731	.5914
16	2.0317	2.0645	2.0622			.5792	.5975
17	2.0317	2.1445	2.1445		.7207	.5249	.5914
18	2.0719	1.9845	2.0622	.7865	.7023	.5731	.6535
19	2.0885	2.1052	1.9814	.8501	.7842	.7964	.7095
20	2.0481	1.9044	1.9052	.8215	.8871	.724	.6161
21	1.9364	1.8244	1.9757	.5304		.5194	.5175
22	.6161	.4641		1.8591	1.7284	1.4327	1.5546
23	.5601	.4801		1.7966	1.7341	1.5684	1.5729
24	.4854	.5175	.4687	.5788	1.7341	1.7185	1.4575
Max	2.0885	2.1445	2.1445	1.8591	1.7341	1.7185	1.6876
Min	.298	.3258	.2987	.5228	.6099	.5194	.5175
Avg	1.0586	1.0439	1.1113	.8135	1.0870	.9470	.9212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 202 / kevad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3547	.2534	.547	.5175	.5975	.4344
2	.3772	.3511	.2454	.5228	.5228	.5975	.4207
3	.3734	.3326	.2454	.5658	.499	.6535	.5304
4	.415	.3361	.2507	.6722	.5975	.7468	.5304
5	.4527	.4715	.2926	.7655	.7842	.8215	.724
6	2.4996	2.2885	2.3845	.8215	.8962	1.0829	.7602
7	2.5934	2.7681	2.5911	.8779	.9522	.9709	.7164
8	2.609	2.6216	2.5286	.8215	.8215	.8589	.8413
9	2.5926	2.7018	2.3205	.6413	.7207	.8215	.394
10	.8796	2.5926	2.5606		.7207	.6154	.5041
11	2.484	2.5766	2.5606		.5487	.6697	.5729
12	2.5459	2.6246	2.4985		.4887	.4835	.5601
13	2.5309	2.7846	2.1872		.1928	.5249	.2835
14	.4668	.2103	.4527		2.4863	2.8959	2.0873
15	.499	.1753	.5281		2.7938	2.7873	2.1538
16	.6099	.1753	.5601		2.8054	2.3765	2.119
17	.6099	.181	.6036		2.5101	2.4006	2.1247
18	.6283	.1753	.679	2.652	2.3777	2.2497	1.929
19	.8589	.1829	.7922	2.608	2.3472	2.2455	1.7375
20	.8962	.2103	.7545	2.392	1.2193	2.2725	1.7528
21	.7468	.1943	.7095	2.2222		2.2405	1.7375
22	.4805	.2328		.6099	.6348	.3041	.5228
23	.4066	.2507		.6468	.6535	.4031	.4854
24	.4481	.3734	.2534	.5658	.5601	.6161	.4755
Max	2.609	2.7846	2.5911	2.652	2.8054	2.8959	2.1538
Min	.3734	.1753	.2454	.5228	.1928	.3041	.2835
Avg	1.1423	1.0486	1.1933	1.1208	1.1587	1.2598	1.0166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 203 / Undergoan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.6481	.5441	.6481	.4294	.3734	.2804
2	.5624	.6405	.5312	.6249	.4294	.3734	.2686
3		.6401	.5376	.6874	.4108	.3547	.3077
4	.6554	.6483	.5441	.6874	.4668	.3547	.3258
5	.6478	.6722	.5441	.6706		.3734	.3292
6	.4527	.4481	.333	.7186	.7099	.8223	.7042
7	.4854	.5228	.3052	.7407	.8002	.8124	.703
8	.4854	.4805	.333	.7274	.7968	.7907	.7842
9	.4481	.4668	.3391	.6706	.7968	.7811	.8162
10	.4435	.4344	.415		.7926	.8162	.7253
11	.4108	.439	.4481		.7773	.8322	.679
12	.3881	.3439	.415		.7621	.8002	.6874
13	.3696	.3258	.415		.7621	.7655	.6874
14	.3326	.3292	.4108		.4251	.3506	.4108
15	.3326	.3077	.415		.5175	.3801	.4066
16	.3174	.2743			.4961	.333	.4294
17	.2957	.2561	.4527		.5544	.3155	.4435
18	.3658	.2534	.4527	.2926	.3688	.3403	.4668
19	.4668	.2715	.4854	.3921	.5729	.3258	.5041
20	.5041	.2715	.4527	.4294	.5975	.3258	.5601
21	.3921	.2534	.3772	.4854		.3475	.5788
22	.6874	.5441		.4854		.3258	.5228
23	.679	.5312		.4668	.4668	.3109	.4668
24	.7186	.6636	.5468	.6401	.4481	.4108	.2801
Max	.7186	.6722	.5468	.7407	.8002	.8322	.8162
Min	.2957	.2534	.3052	.2926	.3688	.3109	.2686
Avg	.4798	.4444	.4428	.5855	.5896	.5007	.5153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 204 / Darfal Water Supply

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.108	.108	.16	.1054	.108	.1524	.1619
2	.0926	.0926	.16	.1355	.0926	.1219	.16
3	.0772	.0772	.16	.1355	.0926	.1219	.16
4	.0772	.0772	.16	.1355	.108	.1219	.1457
5	.0772	.0772	.1696	.1204	.0926	.1235	.1475
6	.9031	.9722	1.1843	.1806	.1389	.1067	.144
7	.9332	1.1265	1.1248	.1806	.1235	.1372	.1265
8	1.2041	1.0957	1.2334	.1505	.1235	.1524	.1134
9	1.2643	1.0802	1.3123	.1656	.1852	.1524	.128
10	1.3889	1.1561	1.2452		.1829	.192	.1389
11	1.3735	1.3441	1.3546		.2439	.176	.1852
12	1.358	1.3279	1.3546		.2286	.192	.1698
13	1.358	1.3443	1.3546		.2743	.16	.1543
14	.1698	.2561	.1505		1.3108	1.3443	1.2809
15	.1698	.2429	.1355			1.406	1.2654
16	.1698	.2241	.1355			1.4723	1.2809
17	.1698	.192	.1355		1.387	1.4403	1.3117
18	.108	.2267	.2107	1.25	1.3889	1.406	1.2346
19	.1235	.192	.1806	1.2963		1.4243	1.1883
20	.1235	.16	.1505	1.2346	1.2498	1.3443	1.0648
21	.1235	.144	.1054	1.1883		1.3283	.9722
22	.1235	.16		.1389	.1698	.16	.1235
23		.1423		.1235	.1543	.1562	.108
24	.108	.108	.1406	.1054	.1235	.1524	.1562
Max	1.3889	1.3443	1.3546	1.2963	1.3889	1.4723	1.3117
Min	.0772	.0772	.1054	.1054	.0926	.1067	.108
Avg	.5045	.4970	.5599	.4154	.3889	.5644	.4967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 201 / 11 KV JAMGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4557	.4268	.0514	.0686	.0686	
2	.4115	.4733	.442	.0514	.0686	.0857	
3	.442	.4115	.4725	.0514	.0686	.0857	
4	.4572	.4268	.503	.0686	.0686	.0857	
5	.4725	.4268	.5182	.0857	.12	.1372	
6	.6554	.5792	.7164	.12	.1543	.1372	
7	.7316	.8413	.7468	.1372	.12	.1543	
8	.7316	.4031	.7011	.1029	.12	.1372	
9	.3201	.6401	.6401	.0686	.0857	.1372	.1372
10	.0857	.1052	.0686	.0686	.0724	.0857	.1029
11	.0686	.1052	.0514		.6335	.5335	.3353
12	.0857	.0876	.0514		.7621	.6097	.6859
13	.0686	.0876	.0514		.7621	.6097	.6859
14	.0526	.0876			.7316	.5639	.6554
15	.0526	.1052	.0857		.7316	.5639	.6097
16	.0526	.1052	.0857		.7011	.7011	
17	.0701	.0876	.0857	.7011	.6859	.7011	.6859
18	.1052	.1052		.7011	.6097	.7011	.6859
19	.1227	.1402	.1029	.1543	.1029	.1372	.12
20	.1402	.1402		.1543	.1029	.1372	
21	.1052	.1227		.12	.0857	.1543	
22	.0701	.1052		.0857	.0857	.0857	
23	.0701	.1052		.0686	.0686	.0686	
24	.381	.381	.4115	.0514	.0686	.0686	
Max	.7316	.8413	.7468	.7011	.7621	.7011	.6859
Min	.0526	.0876	.0514	.0514	.0686	.0686	.1029
Avg	.2556	.2720	.3423	.1579	.2950	.2813	.4704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 202 / 11 KV ANJANGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2103	.333		1.0669	1.1431
2	.3086	.1928	.3506		1.2193	1.2193
3	.3086	.2629	.3506		1.2803	1.448
4	.3429	.298	.3506		1.2803	1.5242
5	.3944	.333	.3856		1.6004	1.7985
6	.5316	.5784	.5784		1.7528	1.7528
7	.5316	.5258	.5959		2.0576	1.9814
8	.4973	.5083		1.768	1.8595	1.9052
9	.3429	.3681		1.7147	1.7223	1.9052
10	.2743	.2279		.2058	.1886	.1886
11	1.3717	1.0517			.1543	.1543
12	1.8595	1.8138			.1715	.1715
13	1.7223	2.1033			.1886	.1715
14	1.9052	2.0157			.1886	.2058
15	1.9357	1.7223			.2058	.2058
16	1.9509	2.1033			.2058	.2058
17	2.1559			.2572	.2058	.2572
18	1.829	1.7223		.2229	.2229	.2915
19	.3506	.3506	.3429	.3258	.2915	.3086
20	.4733	.5258		.3258	.3429	.3429
21	.4557	.4115		.3086	.3429	.3944
22	.4031	.3856		.2743	.2572	.3086
23	.3506	.333		.2572	.2401	.2572
24	.3086	.2629	.3155	1.3108	.945	.9145
Max	2.1559	2.1033	.5959	1.768	2.0576	1.9814
Min	.2743	.1928	.3155	.2058	.1543	.1543
Avg	.8714	.7960	.4003	.6337	.7496	.7940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 203 / 11 KV WADACHIWADI(AU)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7164	.6554	.0857	.0686	.0686	.0686
2	.6097	.7164	.6859	.0686	.0686	.0686	.0686
3	.6401	.7468	.7164	.0686		.0686	.0686
4	.6401	.7468	.7468	.0686	.0857	.0857	.0686
5	.6401	.7773	.823	.0857	.0857	.1029	.0857
6	.823	.884	1.0517	.1029	.1029	.12	.12
7	.9297	1.0059	1.1431	.12	.12		
8	1.0059	.884	1.0822		.0857		
9	.7621	.9297	1.0669	.0086	.0857	.1029	
10	.0514	.0876	.0514	.1029	.0724	.0686	
11	.0514	.0701	.0686		.8383	.9145	.9145
12	.0514	.0701	.0457		1.2193	1.0669	1.0822
13	.0686	.0876	.0514		1.2193	1.0669	1.0669
14	.0526	.0701	.0514		1.2193	.8383	.9907
15	.0701	.0526	.0514		1.2193	.884	1.0059
16	.0457	.0526	.0514		1.1431	.9755	1.0364
17	.0457	.0526	.0514	1.0822	1.2193	1.0669	1.2174
18	.0526	.0526	.0686	.8688	1.0669	1.0669	1.1317
19	.0762	.0701	.0857	.0857	.0686	.0857	.0857
20	.1227	.0876		.0857	.0857	.12	
21	.0701	.0701		.1029	.0857	.0857	
22	.0876	.0701		.0857	.0857	.0686	
23	.0701	.0526		.0857	.0686	.0686	
24	.5639	.7011	.6249	.1029	.0857	.0686	.0686
Max	1.0059	1.0059	1.1431	1.0822	1.2193	1.0669	1.2174
Min	.0457	.0526	.0457	.0086	.0686	.0686	.0686
Avg	.3392	.3773	.4587	.1889	.4522	.4120	.5675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 201 / 11 KV UPLAI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1886	1.046	1.1831	1.2003	1.2651
2	.1886	.1715	.1886	1.1831	1.3032	1.5947	1.4937
3	.2058	.1886	.1886	1.3375	1.5604	1.7147	1.6004
4	.2401	.1886	.2058	1.4403	1.8519	1.8004	2.0424
5	.2743	.1886	.3086	2.0576	2.5377	2.6063	2.21
6	.3772	.3601	.3772	2.3834	2.7949	2.7263	2.4844
7	.3772	.3258	.3429	2.7435	3.0864	2.9835	1.7375
8	.2915	.2915	.2743	2.3491	1.6804	2.4844	1.6804
9	.1886	.2058	.2058	2.4006	2.5549	2.1948	2.8464
10	.1543	.1715	.1886	.1886	.1715	.1886	.2058
11	.6516	1.749	1.4746	.1372	.1886	.1372	.1715
12	2.6235	2.7606	2.8121	.1372	.12	.1372	.1543
13	2.8464	2.7263	2.8635	.1543	.1372	.1372	.1715
14	2.4691	2.8464	2.5892	.1543	.1715	.1543	.1715
15	2.5377	2.572	2.572	.1372	.1372	.1543	.1543
16	2.4691	2.7435	2.7778	.1372	.1715	.1543	.1543
17	3.0521	2.7606	2.572	.1543	.12	.1543	.1715
18	2.6749	2.7949	3.0178	.1543	.1543	.1886	.2229
19	.2743	.2401	.2401	.3086	.2229	.2572	.3086
20	.3429	.3429	.3429	.3429	.3258	.3429	.3601
21	.2915	.3429	.2915	.2229	.2915	.2915	.3086
22	.2572	.2743	.2743	.2229	.2401	.2572	.2743
23	.1886	.2058	.2743		.1886	.2572	.2229
24	.1886	.1715	.1886	.8402	.8402	1.0288	1.1888
Max	3.0521	2.8464	3.0178	2.7435	3.0864	2.9835	2.8464
Min	.1543	.1715	.1886	.1372	.12	.1372	.1543
Avg	.9731	1.0331	1.0317	.8797	.9181	.9644	.9001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 202 / 11 KV ROPALE NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.8059	.2401	.2229	.2058	.2058
2	.8745	1.1145	1.1488	.2401	.2229	.2401	.2058
3	1.0288	1.1145	1.1831	.2743	.2401	.2401	
4	1.1831	1.166	1.2346	.2915	.2915	.2401	.3086
5	1.2689	1.2346	1.406	.3601	.3429	.3429	.3601
6	2.0233	1.8861	1.5432	.463	.3944	.4115	.4458
7	2.1948	2.0576	2.5034	.463	.3601	.3944	.3601
8	1.6804	2.1948	2.2291	.3429	.3772	.3506	.3429
9	1.5947	1.4403	2.1091	.3601	.2058	.3258	.3258
10	.1543	.3086	.2743	.2229	.1715	.2401	.2401
11	.1886	.1715	.2229	1.6461	.5144	.5792	1.3375
12	.1715	.1715	.2058	1.7318	1.8861	1.829	2.0576
13		.1715	.2401		2.0576	2.1033	1.9033
14	.1886	.1715	.1886		1.9376	2.0119	1.7147
15	.1886	.1715	.2058		2.0233	2.0424	1.166
16	.2058	.1715	.2743		2.0576	1.8138	2.0576
17	.1886	.1715	.2915	1.3717	2.1091	2.1091	2.1948
18	.2058	.1715	.3086	1.3717	2.2291	1.9814	1.9033
19	.3601	.3086	.3429	.3944	.2743	.3258	.2915
20	.3772	.3601	.3944	.4458	.3601	.3772	.4458
21	.2915	.3429	.3086	.3429	.3258	.3944	.3258
22	.2743	.2743	.3086	.2915	.2915	.3086	.3086
23	.2229	.2743	.2915		.2229	.2572	.2915
24	.5144	.8059	.6344		.2229	.2058	.2572
Max	2.1948	2.1948	2.5034	1.7318	2.2291	2.1091	2.1948
Min	.1543	.1715	.1886	.2229	.1715	.2058	.2058
Avg	.6985	.7130	.7773	.6030	.8059	.8054	.8283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 203 / 11 KV GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1029	.1067	.1715	.1372	.1372
2	.12	.1372	.1029	.12	.1543	.12	.1372
3	.1029	.1543	.1029	.12	.1886	.12	.1372
4	.12	.1029	.1029	.12	.2058	.12	.1715
5	.1543	.12	.1715	.1715	.2229	.1543	.2058
6	.2229	.2058	.2058	.2058	.2229	.1886	.2229
7	.2229	.1886	.1886	.1886	.1715	.2058	.2229
8	.1886	.1715	.1543	.1715	.1715	.1715	.1715
9	.1715	.1715	.1715	.1715	.1886	.1886	.1886
10	.1715	.1715	.1715	.1715	.1543	.1715	.1715
11	.1543	.1715	.1715	.1715	.1543	.1715	.1715
12	.1543	.1543	.1543	.1715	.1372	.1715	.1543
13	.1543	.1715	.1372	.1543	.1372	.1543	.1715
14	.1029	.1372	.12	.1543	.12	.1372	.3086
15	.1029	.12	.1029	.1372	.1029	.1372	.1372
16	.12	.1372	.1029	.12	.1029	.1372	.1715
17	.1372	.1372	.1372	.1372	.1029	.1543	.1543
18	.1372	.1372	.1543	.1372	.1543	.1543	.1715
19	.1886	.1715	.1886	.2229	.1715	.2058	.1886
20	.2058	.2058	.1715	.2229	.2058	.2229	.2229
21	.1886	.1715	.1715	.2058	.2401	.2229	.2229
22	.1886	.1715	.1715	.1886	.2058	.2058	.2058
23	.1715	.1543	.1543		.1543	.1715	.1715
24	.1543	.1543	.12	.1372	.1715	.1543	.1543
Max	.2229	.2058	.2058	.2229	.2401	.2229	.3086
Min	.1029	.1029	.1029	.1067	.1029	.12	.1372
Avg	.1572	.1565	.1472	.1612	.1672	.1658	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 201 / 11 KV SAPATANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1829	.2572	1.0288	.9145	1.1736	1.1831
2	.1524	.1677	.2058	1.0117	.823	1.1888	1.2689
3	.1524	.1372	.2058	1.1145	.8993	1.2193	1.5775
4	.1829	.1524	.1886	1.5775	1.166	1.2193	1.8861
5	.2439	.2439	.2743	1.9204	1.4918	1.3717	2.4006
6	.3353	.381	.3772	2.0576	2.1776	1.7528	2.6578
7	.3353	.3506	.3601		2.1948	1.9814	2.5377
8	.2743		.3429	1.8519	2.0919		1.9719
9	.1677			2.0576	2.1776	2.2291	1.89
10	.1981				.1524	.1524	.1981
11	1.8176	1.3717	2.0748	.1524	.1524	.1829	.2058
12	2.0576	1.9357	2.4863	.1677		.1981	.2058
13	2.1434	1.9814	2.2805	.2134	.1524	.2286	.2058
14	2.1948	1.9814	2.2291	.1677	.1524	.1981	.2401
15	.7202	1.9357	2.3148	.1524	.1524	.1524	.2572
16	2.2462	1.8595	2.4348	.1677	.1829	.1981	.2572
17	2.3491	1.9052	2.0576	.1829	.2058	.1829	.2743
18	2.1948	1.5242	2.0576	.1677		.2134	.2134
19	.1372	.2229	.1524	.2743		.2743	.3048
20	.1829	.3772	.3048	.2286	.3086	.2743	.3353
21	.2591	.3048	.2439	.1829	.2743	.3048	.3048
22	.2439	.3429	.2134	.2286	.2401	.2743	.3048
23	.2286	.3086	.1829	.2134	.2229	.2439	1.1488
24	.1829	.2286	.3086	.9774	1.0802	.9145	.9774
Max	2.3491	1.9814	2.4863	2.0576	2.1948	2.2291	2.6578
Min	.1372	.1372	.1524	.1524	.1524	.1524	.1981
Avg	.7987	.8522	.9797	.7317	.8197	.7013	.9503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 202 / CHINCHOLI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.7202	.8688	.0914	.0914	.1372	.0914
2	1.1145	.8573	.9145	.0914	.0914	.1372	.0914
3	1.3375	1.1145	.945	.1067	.1219	.12	.1067
4	1.3889	1.3375	1.0669	.1067	.1372	.1372	.1219
5	1.6632	1.5261	1.326	.1219	.1829	.1715	.1524
6	1.869	1.7318	1.6156	.1524	.1981	.2058	.1829
7	1.9547	1.749	1.9509	.2134	.1981	.2572	.2134
8	1.8176	2.1948	2.1338	.1829	.1829	.2134	.1829
9	1.6289	1.9814	2.1434	.1677	.1829	.1981	.1886
10	.1524	.1715	.1219	.1372	.1524	.1067	.1543
11	.1524	.1029	.0914	.7888	1.5775	1.0802	1.3108
12	.1372	.1372	.0914	1.6804	2.0919	1.9719	1.8595
13	.1219	.1372	.1219		2.3491	2.0748	1.5242
14	.1372	.1715	.0914		2.1776	1.6804	1.4632
15	.1677	.1372	.0914		2.0576		1.5242
16	.1219	.1372	.1219		1.9547	1.3889	1.7528
17	.1067	.1372	.0914	1.5947	1.6004	2.1434	2.1948
18	.0914	.1372	.0914	2.2119	1.5242	2.1091	2.1948
19	.1677	.2058	.1219	.1677	.1543	.2439	.1829
20	.2134	.2915	.2134	.2134	.2401	.2134	.1677
21	.1829	.2229	.1829	.1829	.2058	.2134	.1981
22	.1677	.1886	.1524	.1524	.1715	.1524	.1677
23	.1524	.1715	.1219	.1219	.1543	.1219	.1372
24	.8916	.4973	.7316	.0914	.1067	.1372	.0914
Max	1.9547	2.1948	2.1434	2.2119	2.3491	2.1434	2.1948
Min	.0914	.1029	.0914	.0914	.0914	.1067	.0914
Avg	.7029	.6691	.6418	.4289	.7460	.6615	.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 201 / 11 KV NIMGAON NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1052	1.2955	1.448	.1372	.1715		.2572
2	2.2672	1.3717	1.448	.1372	.1715		.2572
3	2.2672	1.448	1.5242	.1543	.1715		.2572
4	2.8502	1.5242	1.5394	.1886	.1715		.2743
5	2.8044	1.6766	1.5394	.2058	.2058		.2743
6	3.0484	1.6918	1.6004	.2229	.2058		.2743
7	3.2541	1.7071	1.6004	.2229	.2058		.2743
8	1.5242		1.448	.2058	.2058	.3086	.5486
9	1.7318	1.6766	1.5546	.1715	.2058	.3086	.5144
10	.1715	.2058	.1372	.2058	.2229	.1715	.4802
11	.1715	.1715	.1886	1.2193	1.3717	1.5432	3.0788
12	.1715	.1715	.1886		1.5242	1.5242	3.719
13	.1715	.1715	.1886		1.6766	1.7147	3.719
14		.1715	.1543		1.7071	1.6004	1.7071
15	.1886	.2058	.1543		1.6766	1.8004	1.7833
16	.2058	.2058	.1886		1.7528	1.6766	1.829
17	.2058	.2058	.1715		1.8442	1.8861	1.8138
18	.2229	.1715	.2058		1.9547	1.8861	1.8595
19	.2401	.1715	.2058	.1715	.1715	.2743	.2401
20	.2572	.1715	.2058	.2058	.2058	.2743	.2229
21	.2058	.1715	.2058	.2058	.2401	.2743	.2572
22	.2229	.1715	.2229	.2058	.2743	.2572	.2572
23	.1886	.1715	.1715	.1715	.3086		.2401
24	1.9433	1.2193	1.0669	.1715	.1715		.0154
Max	3.2541	1.7071	1.6004	1.2193	1.9547	1.8861	3.719
Min	.1715	.1715	.1372	.1372	.1715	.1715	.0154
Avg	1.1487	.7021	.7233	.2472	.7007	1.0334	1.0064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 202 / 11 KV SULTANPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3258	.4287	1.0669	1.1431		.9431
2	.2743	.3429	.4287	1.0669	1.1431		.9431
3	.2915	.3772	.4287	1.1279	1.1888		1.0288
4	.2915	.4115	.4287	1.1584	1.2193		1.0288
5	.2915	.4287	.4287	1.2193	1.2193		1.0631
6	.2743	.4458	.4287	1.2651	1.2193		1.0974
7	.2743	.4458	.4287	1.3565			1.1317
8	.2743	.3429	.3429	1.3717	1.2193	1.4232	1.1317
9	.2743	.3429	.3944	1.448	1.0517	1.5089	1.0974
10	.2229	.3601	.3429	.3429	.1715	.3429	.2743
11	1.0288	1.0669	1.1736	.3772	.2058	.3429	.3429
12	1.2003	1.3717	1.2651	.4287		.3086	.4287
13	1.2193	1.3717	1.387			.3086	.4287
14	1.2955	1.448	1.4022	.4287		.2915	.3601
15	1.3717	1.448	1.4022	.4287		.2915	.3944
16	1.4022	1.4937	1.448	.4287		.2915	.463
17	1.4022	1.448	1.4632	.4287	.463	.3258	.463
18	1.4022	1.448	1.5089	.4287	.5144	.3429	.463
19	.3048	.1715	.2572		.5144	.3429	.4458
20	.3772	.3429	.2743	.4287	.5316	.3429	.4115
21	.3772	.3772	.2743		.463	.3429	.3772
22	.3429	.3772	.2915		.4458	.3429	.3772
23	.3258	.3772	.2572	.3429	.4287	.3772	.3258
24	.2401	.3086	.3772	.9145	1.0669		.9431
Max	1.4022	1.4937	1.5089	1.448	1.2193	1.5089	1.1317
Min	.2229	.1715	.2572	.3429	.1715	.2915	.2743
Avg	.6250	.7031	.7026	.8030	.7894	.4704	.6652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 201 / WIRELESS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2743		.2439	2.5758	2.8178	2.5911
2	.2652	.2896		.2439	2.713	2.9835	2.6216
3	.2984	.3048		.2743	2.8045	3.1493	2.652
4	.3315	.3353		.2743	2.8959	3.1493	2.713
5	.3647	.3658		.3353	2.9569	3.0483	2.8807
6	.3978	.3658		.3658	3.0483	3.4808	3.0483
7					3.2617	3.514	3.1093
16	2.652	2.8045	2.7435				
17	3.1703	3.315					
18	3.3532	3.4476					
19	3.1093	3.4476					
20	2.8654	3.4873		.3353	.3315		.3658
21	2.7435	3.1824		.3048	.3315		.3506
22	2.652	3.1017		.2439	.3315		.3048
23	2.5758	2.9835		.2439	.3315		.3048
24	.2652	.2743		.2134	2.4387	2.4863	2.5606
Max	3.3532	3.4873	2.7435	.3658	3.2617	3.514	3.1093
Min	.2652	.2743	2.7435	.2134	.3315	2.4863	.3048
Avg	1.6873	1.8653	2.7435	.2799	2.0017	3.0787	1.9586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 202 / PIMPALNER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4863	2.1033	2.1338	.3353	.3978	.3048
2	2.4863	2.1643	2.1491	.3506	.3978	.3048
3	2.652	2.2558	2.1643	.3658	.4475	.3048
4	2.8178	2.2862	2.271	.3963	.3978	.3048
5	3.0178	2.3472	2.5034	.4115	.431	.3353
6	3.0498	2.8045	2.2558	.4268	.4641	.3658
7	3.1824	2.8045	2.4996			
8			2.2558	2.1033	2.1338	2.4387
9	3.2922		2.5692	2.7435	2.8197	2.6825
10	3.2922		2.652	2.8959	2.8045	2.6216
11	3.0636			2.8502	2.6673	2.7435
12	3.1093			2.8654	2.3624	2.6216
13	3.0636			2.5606	2.3929	2.1643
14	3.0483				2.4082	2.2862
15	2.8349			2.4996	2.4387	2.3777
20	.3658	.4641	.4572	.4641		.381
21	.3658	.3978	.3658	.431		.3658
22	.3506	.3978	.3658	.3978		.3658
23	.3353	.3978	.3353	.3978		.3201
24	1.989	2.0119	2.4387	.3658	.3978	.3048
Max	3.2922	2.8045	2.652	2.8959	2.8197	2.7435
Min	.3353	.3978	.3353	.3353	.3978	.3048
Avg	2.3581	1.7029	1.8278	1.2701	1.5308	1.2418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 203 / NIMGAON (T)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2743		.1829	.1981	.2321	.2134
2	.2321	.2743		.2134	.2134	1.4918	.2134
3	.2321	.2896		.2134	.2286	.2652	.2134
4	.2321	.2896		.2134	.2439	.2984	.2134
5	.2652	.3048		.2743	.2591	.3149	.2134
6	.2683	.2896		.2439	.2896	.3315	.2439
7				.2439			
8		2.3929		.2439			
9	3.2922	3.0483	3.1398				
10	3.2922	2.8654	2.9874				
11	3.0636	2.9721	3.0483				
12	3.1093	3.0483	3.1093				
13	3.0636	3.0483	2.5606				
14	3.0483	2.7435	2.5911				
15	2.8349	3.3608	2.6825				
16					2.8045	2.7587	2.3167
17					3.3813		2.9874
18				3.1093	3.315		2.8807
19				3.1398	3.1161		3.0483
20	.2743	.3353		3.1398	3.4476		2.9264
21	.2591	.2652		3.1703	2.9835		2.7435
22	.2743	.2652			2.7846		2.6216
23	.2896	.2652		2.8045	2.6216		2.5911
24	.2652	.2439		.1829	.1981	.2155	.2439
Max	3.2922	3.3608	3.1398	3.1703	3.4476	2.7587	3.0483
Min	.2321	.2439	2.5606	.1829	.1981	.2155	.2134
Avg	1.3645	1.3988	2.8741	1.2411	1.739	.7385	1.5780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 204 / PIMPALNER GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.583		.5144	.583	.583	.5487
2	.6001	.6173		.4801	.6173	.6001	.5182
3	.6001	.6516		.5487	.6516	.6859	.6173
4	.6344	.6859		.6173	.6859	.7202	.6516
5	.6859	.703		.6859	.7545	.7545	.6401
9	.7545	.6859	.703	.7545	.7373	.7373	.7202
10	.6859	.583	.6001	.6859	.6516	.6859	.6859
11	.5144	.5487	.5658		.6173	.5658	.5658
12	.5144	.5144	.5316		.5487	.5487	.5144
13	.5487	.4801	.4973		.463	.4973	.463
14	.4801	.4287	.4973		.4268	.463	.4458
15	.5144	.463	.4801		.4801	.4458	.4458
16		.4801	.4973		.4458	.463	.463
17							.4801
18							.4973
20	.7716	.7545		.8402	.7545		
21	.7545	.7545		.8402			
22	.6859	.6859		.7202			.703
23	.6001	.6001		.6687			.6173
24	.5658	.5487		.5316	.583	.5658	.5144
Max	.7716	.7545	.703	.8402	.7545	.7545	.7202
Min	.4801	.4287	.4801	.4801	.4268	.4458	.4458
Avg	.6163	.5982	.5466	.6573	.6000	.5940	.5607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 205 / Dahiwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372		.0686	.1372	.1372	.061
2	.1029	.1372		.0686	.1372	.1372	.061
3	.1029	.1372		.0914	.1372	.1372	.061
4	.1029	.1543		.0914	.1543	.1372	.061
5	.12	.1543		.0914	.1543	.1543	.061
6	.1372	.1372		.1219	.1543	.1543	.0305
8		2.7263					
9	3.3608	3.2065	3.2922				
10	3.3093	3.2236	3.1722				
11	3.4637	3.3436	3.1893				
12	3.2922	3.3093	3.2236				
13	3.1207	3.2579	2.9664				
14	3.0521	2.9321	3.0864				
15	2.9492	2.915	3.1207				
16					2.8654	3.0864	2.8464
17					3.5151		3.4294
18				3.3265	3.5494		3.4637
19				3.2922	3.5494		3.2922
20	.1372	.1372		.1715	3.4808		3.3265
21	.1029	.1372		.1715	3.4294		3.035
22	.12	.1372		2.9492	3.2579		2.915
23	.1372	.1372		3.155	3.0864		2.8121
24	.1029	.1372		.061	.1372	.1372	.061
Max	3.4637	3.3436	3.2922	3.3265	3.5494	3.0864	3.4637
Min	.1029	.1372	2.9664	.061	.1372	.1372	.0305
Avg	1.3232	1.3925	3.1501	1.0508	1.8497	.5101	1.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 206 / TAMBAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	1.9204		2.4082	2.7778	2.915	2.3472
2		2.0748		2.8292	3.0178	3.0864	2.4082
3	2.572	2.2462		2.9492	3.1893	3.0864	2.4691
4	2.572	2.4348		2.7435	3.2922	3.2579	2.6825
5	2.7435	2.572		3.155	3.5665	3.2579	2.8045
6	2.915	3.2922		3.2579	3.7209	3.4294	3.0483
7		***		2.5911	3.7723	3.5322	3.0483
8				3.1036			
9				2.572			
10				2.1434			
16	2.7435	3.2922	2.8807				
17	3.3265	3.4294					
18	3.7723	3.7723					
19	3.7723	3.6008					
20	3.4637	3.6008		.2058	.1715		.4115
21	3.2579	.2572		.2229	.2401		.3429
22	3.0521	3.0864		.2058	.2401		.3086
23	3.0007	2.915		.2058	.2401		.3086
24	2.4006	1.7147		3.0521	2.572	2.572	2.1643
Max	3.7723	46.9651	2.8807	3.2579	3.7723	3.5322	3.0483
Min	2.4006	.2572	2.8807	.2058	.1715	2.572	.3086
Avg	3.0240	5.4484	2.8807	2.1097	2.2334	3.1422	1.862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 207 / GOATHAN TEMBHURNI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-APR-18
HR	Load (MW)
9	1.5432
24	1.3717
Max	1.5432
Min	1.3717
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274026 / TEMBHURNI

Feeder No / Name : 208 / AKOLE BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-APR-18
HR	Load (MW)
8	.6859
24	.6173
Max	.6859
Min	.6173
Avg	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 201 / PARITE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432			.3086		
2	1.4746			.2713		
3	1.4918			.2572		
4	1.4575			.2915		
5	1.6461			.3391		
6	1.8176			.407		
7				2.0576		
8			3.1499	1.8673	1.9805	2.2068
9				1.6617		
10				1.7295		
11				1.7147		
12				1.7465		
13				1.7126		
14				1.6289		
19	.3429			.4115		
20	.3944			.3601		
21	.4287			.3086		
22	.463					
23	2.4348					
24	1.5775	2.6029	2.6406	.3361	.5601	.3734
Max	2.4348	2.6029	3.1499	2.0576	1.9805	2.2068
Min	.3429	2.6029	2.6406	.2572	.5601	.3734
Avg	1.2560	2.6029	2.8953	.9672	1.2703	1.2901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 203 / Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458			.4668		
2	.4115			.39		
3	.4115			.373		
4	.4801			.4115		
5	.5487			.4239		
6	.583			.5658		
7	.6001			.6001		
8	.5487	.5658	.6036	.5658	.5281	.5658
9	.5316			.4801		
10	.4917			.4973		
11	.4115			.3601		
12	.3772			.3429		
13				.3258		
14	.3086			.3429		
15	.3258			.3391		
16	.3429	.3206	.5093		.4527	.2829
17	.3601			.3772		
18				.4115		
19	.4973			.5144		
20	.4801			.6173		
21	.4973			.5658		
22	.5144					
23	.4801					
24	.5144	.4904	.3395	.5093	.4904	.5093
Max	.6001	.5658	.6036	.6173	.5281	.5658
Min	.3086	.3206	.3395	.3258	.4527	.2829
Avg	.4619	.4589	.4841	.4515	.4904	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 204 / AKOLE BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1694				
16	1.7918				3.3573
24	.9335	1.1317	2.8292	2.4709	2.6029
Max	1.7918	1.1317	2.8292	2.4709	3.3573
Min	.9335	1.1317	2.8292	2.4709	2.6029
Avg	1.2982	1.1317	2.8292	2.4709	2.9801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 205 / Palwan ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888			2.8292		
2	.7545			2.8807		
3	.823			2.7949		
4	.8573			2.7092		
5	.9259			2.6578		
6	.9835			2.5549		
7	1.9719					
8	2.0748					
9	2.4863					
10	2.4006					
11	2.2291					
12	2.2977					
13	2.0348					
14	2.0062					
15	2.34			1.6448		
16	2.6235	3.1687		2.0559		3.0933
17	2.7092			2.4348		
18	2.7778			2.6749		
19	2.7435			2.6406		
20	2.6406			2.572		
21	2.572			2.5265		
22	2.452					
23	.9945					
24	.7716	1.0829	.7468	3.2065	***	3.0744
Max	2.7778	3.1687	.7468	3.2065	22.2565	3.0933
Min	.7545	1.0829	.7468	1.6448	22.2565	3.0744
Avg	1.8858	2.1258	.7468	2.5845	22.2565	3.0839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 201 / AKOLE(KH) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.4294			
16		3.3532	3.3836	3.9609
20			1.4632	
24	2.7778	1.4746	1.4632	1.2498
Max	3.4294	3.3532	3.3836	3.9609
Min	2.7778	1.4746	1.4632	1.2498
Avg	3.1036	2.4139	2.1033	2.6054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 202 / SHIRAL (T) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	3.3608	3.0788	3.155
24	3.2579	2.2862	2.5453
Max	3.3608	3.0788	3.155
Min	3.2579	2.2862	2.5453
Avg	3.3094	2.6825	2.8502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 203 / SURLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.1379			
16		3.2312	2.8654	3.3608
24	2.2462	.5487	.5182	.5182
Max	3.1379	3.2312	2.8654	3.3608
Min	2.2462	.5487	.5182	.5182
Avg	2.6921	1.8900	1.6918	1.9395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 204 / SHIRAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3601	.3772		.2896
16		.1829	.1829	.1907
24	.2743	.2401	.2134	.2439
Max	.3601	.3772	.2134	.2896
Min	.2743	.1829	.1829	.1907
Avg	.3172	.2667	.1982	.2414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 201 / KALWEL WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	2.0805	2.1125	.112	.096	.12	.096
2	1.4083	2.0805	2.1445	.112	.096	.12	.096
3	1.5203	1.9204	2.1605	.112	.112	.12	.096
4	1.6804	1.9204	2.1605	.128	.128	.12	.112
5	1.7924	1.8884	2.2085	.144	.128	.1372	.112
6	1.9271	1.8884	2.2405	.144	.112	.1372	.128
7				2.3205	2.4966	2.572	2.2085
8				2.5606	2.4166	2.6578	2.2245
9				2.4006	2.4486	2.6578	2.2245
10				2.4486	2.4486	2.6063	2.1925
11					2.4806	2.5892	2.1605
12					2.4006	2.5377	2.2085
13					2.3205	2.4863	2.2405
14					2.0805	1.7661	2.3045
19	.096	.096	.112	.112	.128	.1029	.096
20	.096	.112	.112	.128	.128	.1029	.096
21	.08	.096	.128	.112	.112	.1029	.096
22	.096	.08	.112	.096	.112	.1029	.096
23	2.0805	1.9364	.112	.096	.112	.1029	.096
24	1.1523	2.0805	2.1125	.112	.096	.12	.096
Max	2.0805	2.0805	2.2405	2.5606	2.4966	2.6578	2.3045
Min	.08	.08	.112	.096	.096	.1029	.096
Avg	1.0981	1.3483	1.3096	.6961	1.0226	1.0631	.949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 202 / KADAM WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0492	.0655	.0486	.0324	.0514	.0328
2		.0492	.0655	.0486	.0324	.0514	.0328
3	.0162	.0492	.0492	.0486	.0324	.0514	.0328
4	.0162	.0328	.0492	.0486	.0486	.0514	.0492
5	.0162	.0328	.0492	.0486	.0486	.0514	.0492
6	.0162	.0328	.0492	.0486	.0486	.0514	.0492
7	1.5061	1.6385	1.8515				
8	1.5384	1.7532	1.9006				
9	1.587	1.7695	1.9826				
10	1.6194	1.8679	2.0243				
11	1.6194	1.917	2.1052				
12	1.668	1.9498	2.0405				
13	1.7004	1.9334	2.0243				
14	1.7004	1.9334	2.0243				
15					2.13	2.3148	1.9662
16					2.2119	2.3834	1.9662
17					2.2119	2.332	1.9826
18				1.8138	2.13	2.3148	1.9989
19	.0324	.0655	.0486	1.8461	2.0481	2.2805	1.9989
20	.0648	.0492	.0486	1.8461	2.0481	2.2462	1.9662
21	.081	.0328	.0486	1.8299	1.9662	2.2291	1.9498
22	.081	.0328	.0486	1.8299	1.9989	2.1948	1.917
23	.0324	.0492		.0324	.0164	.0343	.0328
24	.0162	.0492	.0655	.0486	.0324	.0514	.0328
Max	1.7004	1.9498	2.1052	1.8461	2.2119	2.3834	1.9989
Min	.0162	.0328	.0486	.0324	.0164	.0343	.0328
Avg	.7015	.7644	.8706	.7337	1.0648	1.1681	1.0036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 203 / PARITE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.4024	.3887	1.6385	2.4577	2.572	2.4291
2	.3563	.4207	.4049	1.6385	2.4577	2.572	2.4291
3	.3887	.4207	.4372	1.6385	2.4905	2.572	2.4615
4	.4049	.4572	.4534	1.6385	2.4905	2.6578	2.4615
5	.4372	.4938	.4696	1.8023	2.6216	2.8292	2.5911
6	.4534	.5121	.4696	1.7204	2.6543	2.915	2.3967
15	2.4777		2.7035				
16	2.9312		2.8673				
17	2.8502	2.9959	2.7854				
18	3.0803	3.1741	2.5396				
19	2.7206	2.7854	2.2939	.426	.4096	.3601	.3887
20	2.769	2.9312	2.2119	.4096	.4096	.3944	.4049
21	2.6216	2.8178	2.13	.3605	.4096	.3601	.3887
22	2.556	2.5749	1.9662	.3277	.3277	.3429	.3563
23	.3605	.439	1.8023	2.4249	2.3758	2.5206	3.1579
24	.3239	.4024	.3887	1.7204	2.4249	2.572	2.3967
Max	3.0803	3.1741	2.8673	2.4249	2.6543	2.915	3.1579
Min	.3239	.4024	.3887	.3277	.3277	.3429	.3563
Avg	1.5670	1.4877	1.5195	1.3122	1.7941	1.8890	1.8219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 201 / UPALWATE BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0358	.0343	.1715	1.2041	.4515	.3048
2	.0343	.0358	.0343	.2058	1.3108	.4572	.3086
3	.0343		.0343	.2401	1.1888	.4572	.2591
4	.0343	.0358	.0343	.3086	1.0669	.4572	.2591
5	.0343	.0358	.0343	.4115	.9755	.4572	.2743
6	.0343	.0358	.0343	.3429	.5487	.4572	.2896
7	.0343	.0358	.0343	.3772	.6097	.4268	.503
8	.0343	.0358	.0343	.3429	.5182	.3963	.4725
9	.0358	.0343	.0343	.0305	.0358	.0343	.0305
10	.0358	.0343	.0343		.0358	.0343	.0152
11	.0358	.0343	.0343		.0358	.0343	.0152
12	.0701	.0343	.0343		.0358	.0343	.0152
13	.0532	.0343	.0343		.0358	.0343	.0152
14	.1753	.0343	.0343		.0358	.0343	.0152
15	.1772	.0343	.0343		.0358	.0343	.0152
16	.0358	.0343	.0343		.0358	.0343	.0152
17	.5944		.6001		.0358	.0343	.0152
18	.5944	.5639	.5144		.0358	.0343	.0152
19	.5487	.5182	.3772		.0358	.0514	.0305
20	.4877	.4725	.3772	.0305	.0358	.0343	.0305
21	.3963	.381	.3086	.0305	.0358	.0343	.0305
22	.2896	.3353	.2401	.0305	.0358	.0343	.0305
23	.2968	.2591	.2058	.0305	.0358	.0343	.0305
24	.3086	.2812	.2134	.1715	.0305	.0358	.0343
Max	.5944	.5639	.6001	.4115	1.3108	.4572	.503
Min	.0343	.0343	.0343	.0305	.0305	.0343	.0152
Avg	.1837	.1516	.1411	.1946	.3329	.172	.1260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 202 / DAHIWALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5377	1.8595	1.9814	.2058	.1981	.2328	.1543
2	2.4006	1.9204	1.9509	.1372	.1981	.2328	.1543
3	2.4348	1.9867	1.9662	.1372	.1981	.2149	.1715
4	2.4691	2.1186	1.9814	.2058	.1981	.2149	.1886
5	2.332	2.4082	1.9814	.2058	.1981	.2149	.2229
6	2.4863	2.2577	2.1948	.1715	.1981	.2149	.2572
7	2.6063	2.452	2.3015	.2401	.1677	.1433	.2229
8	2.6406	2.0168	2.1338	.1715	.1219	.1433	.1715
9	.1052	.1219	.12	2.9264	2.8235	2.8045	2.9264
10	.1254	.1029	.1029		2.7938	2.9569	2.8349
11	.1075	.1029	.1029		2.8597	2.9721	3.0483
12	.1075	.0857	.1029		2.7092	2.3624	
13	.1075				2.3926	2.1948	2.6216
14	.1075				2.2878	2.1338	2.4996
15	.1075				2.2276	2.0119	2.4082
16	.1075		.12			2.0881	2.3167
17	.1254	.0857	.1372		.0895	.1029	.0914
18	.1433	.1029	.1029		.0895		
19	.208	.12	.1372	.1372	.1791	.1372	.1524
20	.1791	.1886	.1372	.1981	.197	.2229	.1829
21	.1612	.1886	.1715	.1981	.2279	.2401	.2134
22	.1433	.1886	.2058	.1981	.2507	.2401	.1981
23		.1543	.2401	.1981	.2454	.2058	.1981
24	.2058	.1433	.1372	.2401	.1981	.2507	.1543
Max	2.6406	2.452	2.3015	2.9264	2.8597	2.9721	3.0483
Min	.1052	.0857	.1029	.1372	.0895	.1029	.0914
Avg	.9543	.9303	.8719	.3714	.9152	.9798	.9723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 203 / DAHIWALI BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0895	.0857	.1372	.0762	.0895	.0686
2	.0857	.0895	.0857	.1029	.0762	.0895	.0686
3	.1029	.1075	.0857	.1372	.0762	.0895	.0686
4	.1029	.1075	.0857	.1029	.0762	.0895	.0686
5	.1029	.1075	.1029	.1029	.0762	.1075	.0857
6	.0686	.1254	.1029	.0686	.0914	.1075	.1029
7	.1029	.0895	.0857	.0686	.0914	.0895	.0857
8	.0686	.0895	.0686	.0686	.061	.0895	.0686
9	1.0669	1.1431	.9945	.061	.0716	.0686	.0457
10	1.2342	1.1279	.8573		.0716	.0343	.0305
11	1.0536	.945	.7888		.0716	.0343	.0305
12	.9031	.9297	.6859		.0537	.0343	.0305
13	.7977	.7621	.6173		.0537	.0343	.0305
14	.8278	.7621	.5487		.0537	.0343	.0305
15	.8322	.6859	.5144		.0537	.0343	.0457
16	.8173	.7621	.4801		.0537	.0514	.0457
17	.0701	.0343	.0343		1.3546	1.1126	1.3108
18	.0876	.0514	.0343		1.4175	1.1736	1.2193
19	.1075	.0686	.0343	1.8595	1.189		1.2041
20	.1075	.0857	.0686	1.9509	1.1431	1.0822	1.0059
21	.1075	.1029	.0686	1.8595	.9145	1.0059	.8535
22	.1075	.1029	.1029	1.7375	.7876	.7926	.823
23	.1075	.0857	.0686	1.6156	.7526	.6859	.7316
24	.0343	.1075	.0857	.1029	1.0364	.8002	.6097
Max	1.2342	1.1431	.9945	1.9509	1.4175	1.1736	1.3108
Min	.0343	.0343	.0343	.061	.0537	.0343	.0305
Avg	.3743	.3568	.2786	.6651	.4043	.3361	.3610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 201 / MIDC TEMBHURNI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.6516	.4287	.4801	.5316	.7202
2	.5144		.5144	.4287	.4801	.5316	.6859
3	.5144		.5144	.4287	.4801	.5144	.6173
4	.5144		.4801	.4287	.4801	.5144	.6173
5	.5144		.4115	.4287	.4801	.5144	.5658
6	.5658		.3601	.3429	.4801	.5144	.5658
7	.4287		.4287	.2572		.583	.5316
8	.4287		.463	.3086	.4801	.583	.5658
9	.5658	.6554	.6344	.463	.6344	.6687	.823
10	.7716	.8745	.9259	.5144	.8745	.8059	.8573
11	.8059	.9259	.8745	.463	.9259	1.0288	.9945
12	.7716	1.0631	.8059	.4115	.9774	1.0974	.9259
13	.7716	.9945	.8916	.4115	1.0288	.9431	.8573
14	.7716	.9259	1.0631	.4115	1.0288	1.0802	.9431
15	.703	.9945	1.1317	.4115	1.0974	1.1831	1.0288
16	.703	.8078	1.1317	.4115	1.1317	1.2174	.8573
17		.8573	.8573	.3601	.9259	1.0802	.9088
18		.7545	.7716	.3601	.823	.8573	.7716
19		.7545	.7716	.3601	.7716	.8402	.7716
20		.6516	.7716	.4287	.6516	.8916	.7373
21		.703	.7716	.4287	.583	.823	.7716
22		.7716	.7716	.4287	.5144	.823	.8059
23		.6859	.6859	.4287	.5144	.8402	.7202
24	.6859		.7716	.6859	.5144	.5144	.7202
Max	.8059	1.0631	1.1317	.6859	1.1317	1.2174	1.0288
Min	.4287	.6516	.3601	.2572	.4801	.5144	.5316
Avg	.6203	.828	.7273	.4180	.7112	.7909	.7652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 202 / KANHERGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		1.6613	2.0576	2.0576	2.2634	1.4784
2	.3429		1.9509	2.0576	2.0576	2.5377	1.768
3	.3429		2.0119	2.0576	2.0576	2.5377	1.9814
4	.3429		2.1338	2.4006	2.0576	2.5892	2.21
5	.3429		2.2405	2.572	2.4006	2.6406	2.6368
6	.3772		2.4387	2.8635	2.7435	2.8292	2.9874
7			2.5911	3.2922	3.3436	3.0864	2.7892
8			2.5301	3.1722	3.3093	2.7778	2.6825
9		2.4844	3.0864	3.0007	3.0864	2.3777	2.7435
11	2.2805						
12	3.2579						
13	3.1893						
14	3.1893						
15	3.0864						
16	3.0007						
19		.1981	.2058	.1715	.1543	.1829	.1677
20		.2439	.2229	.2915	.1715	.2134	.1524
21		.1981	.2229	.3086	.1715	.2229	.1524
22		.1829	.2229	.3086	.1715	.1981	.1677
23		.2286	.2229	.3086	.1715	.1677	.1981
24	.3429		1.448	1.8861	1.8861	1.8004	1.4022
Max	3.2579	2.4844	3.0864	3.2922	3.3436	3.0864	2.9874
Min	.3429	.1829	.2058	.1715	.1543	.1677	.1524
Avg	1.5722	.5893	1.5460	1.7833	1.7227	1.7617	1.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 203 / VENEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291		.5182	.5144	.5144	.5144	
2	2.2291		.5182	.5144	.5144	.5144	
3	2.2291		.5792	.5144	.5144	.5144	
4	2.4006		.5792	.5144	.5144	.5144	
5	2.6578		.5944	.5144	.5144	.5144	
6	2.915		.5792	.6001	.6516	.5487	
7	3.1722						
8	3.0864						
9	2.8292						
11		2.3167	2.3148	2.2291	2.7435	2.5758	1.9357
12		2.774	2.8121		3.155	2.4844	2.1643
13		2.9721	2.6578		3.0693	2.4691	
14		2.8959	2.6749		3.0007	2.5453	
15		2.8197	2.572		2.9835	2.5149	2.5301
16		2.8502	2.3148	.0154	2.9321	2.4844	
17		2.8502	2.4006		2.915	2.4387	
18		2.6368	2.4006		2.7606	2.3472	2.5453
19		.3048	.4287		.3086	.442	.3506
20		.4572	.4801	.6001	.5487	.4572	.381
21		.4268	.4801	.6001	.5487	.442	.4572
22		.503	.4801	.6001	.5144	.442	.4725
23		.4725	.4287	.6001	.5144	.0457	.4572
24	1.8861		.4725	.4287	.5144	.5144	
Max	3.1722	2.9721	2.8121	2.2291	3.155	2.5758	2.5453
Min	1.8861	.3048	.4287	.0154	.3086	.0457	.3506
Avg	2.5635	1.8677	1.3143	.6343	1.4866	1.2662	1.2549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION

Feeder No / Name : 201 / 11 KV BHEND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498	1.2955	1.829	.2743	.2439	.2591	.3048
2	1.4632	1.4937	2.1338	.2896	.2439	.2743	.3048
3	1.768	1.8138	2.2862	.3048	.2743	.2743	.3353
4	2.0424	2.1033	2.4387	.3353	.3048	.3048	.3353
5	2.3167	2.3167	2.4387	.4268	.3353	.3658	.3963
6	2.4996	2.4082	2.5149	.4725	.3658	.4115	.3963
7	2.5911	2.6063	2.5911				
11					1.9052		1.4022
12					2.4691	2.1338	1.7985
13					2.4996	2.1338	2.1338
14					2.4996	2.1033	1.9814
15					1.9052	2.3777	2.1948
16					2.4691	2.4082	2.3777
17					2.4691	2.4082	2.4691
18					1.9509	2.4082	2.4082
19	.3048	.3658	.3048	.2439	.3048	.3353	.2439
20	.3048	.3658	.3048	.2743	.3048	.3353	.3048
21	.2743	.3353	.2896	.2591	.3048	.3353	.2743
22	.2591	.3048	.2743	.2439	.2743	.3048	.2743
23	.2439	.3048	.2743	.2439	.2591	.3048	.2743
24	1.1888	1.2193	1.0669	.2743	.2134	.2439	.3048
Max	2.5911	2.6063	2.5911	.4725	2.4996	2.4082	2.4691
Min	.2439	.3048	.2743	.2439	.2134	.2439	.2439
Avg	1.2697	1.3026	1.4421	.3036	1.0799	1.0380	1.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 201 / MITKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	.1829	.2401	.3481	.3048	.2572	.3258
2	2.3434	.1829	.2401	.3315	.3048	.2743	.3429
3	2.3746	.1372	.2401	.3121	.3353	.2743	.3601
4	2.4059	.1524	.2572	.3481	.3353	.2743	.4075
5	2.4215	.1524	.2572	.3647	.3048	.3086	.2241
6	2.4371	.2134	.2743	.3481	.3048	.3258	.2721
7	2.4528	.1829	.2743	.1932	.3201	.3258	.4252
8	2.4528	.2134	.2743	.3149	.3353		.2688
9	.1189		.2058	.3315	.2572	.1402	.1067
10	.1355	.1052	.104	.1524			.1524
11	.1189	2.4371	2.9984		2.8121	3.1659	3.0152
12	.1505		3.3482		3.094	3.4873	3.3684
13	.1677	3.0152	3.5376		3.2769		3.1089
14	.1372	2.9721	3.1659		2.9721	3.3699	3.2388
15	.1054	3.1245	3.1659		3.094	3.4202	3.2065
16	.0903	3.1398	3.0026		3.1398	3.4705	3.1417
17	.1204	3.1398	3.3867		3.2693	3.4537	3.3522
18		2.8959	3.2322	2.915	3.1398	3.3867	
19		.1387	.0914	.1219	.1227	.1739	
20	.1355	.2401	.1067	.1829	.2743	.2591	.2591
21	.1829	.2572	.3201	.2743	.3086	.3401	.2896
22	.2656	.2572	.3721	.3201	.2915	.25	
23	.1981	.2601	.3481	.2743	.2915	.2846	
24	.1524	.1829	.2572	.3481	.2743	.2572	.3258
Max	2.4528	3.1398	3.5376	2.915	3.2769	3.4873	3.3684
Min	.0903	.1052	.0914	.1219	.1227	.1402	.1067
Avg	.9661	1.0720	1.2375	.4401	1.2680	1.3095	1.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 202 / MALEGAON CANAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	2.556	2.1125	2.1216	2.1872	2.1445	2.0405
2	.3429	2.5396	2.1925	2.1216	2.3122	2.2245	2.13
3	.3601	2.2834	2.3205	2.2045	2.5101	2.2965	2.2672
4	.3201	2.332	2.3845	2.3703	2.5587	2.4059	2.3482
5	.4115	2.3644	2.5926	2.3975	2.5911	2.484	2.4086
6	.4287	2.4615	2.6886	2.4036	2.6558	2.6715	2.6543
7	.4287	2.7035	2.7526	2.4036	2.672	2.7496	2.8182
8	.4115	2.6871	2.6715	2.5459	2.7044	2.7686	2.8346
9		2.4806	2.6086	2.6023	2.5152	2.6886	2.4215
10	.3725	.156	.1907	.1372	.1907	.192	.1829
11	.3932	.2743	.394		.3429	.3258	
12	.2785	.3429			.3601	.3258	
13	.3768	.3601			.3429		
14	.3201	.3772	.1823		.3601	.3429	
15	.4096	.463	.1823		.3601	.3429	
16	.1829		.2402		.3258	.4031	
17	3.2861				.3429	.4075	.3506
18	3.504	.463		.2896	.3944	.4075	.3658
19	3.1493	.3086		.3048	.2915	.3721	.4268
20	3.1327	.5487	.3696	.3353	.3772	.4252	.4572
21	2.8012	.3944	.3696	.3658	.3944	.4075	
22	2.6379	.4115	.3681	.381	.3772	.3721	
23	2.7199	.3772	.3881	.3353	.3772	.3721	
24	2.7652	2.5888	2.0317	2.0719	2.0309	2.1125	1.9433
Max	3.504	2.7035	2.7526	2.6023	2.7044	2.7686	2.8346
Min	.1829	.156	.1823	.1372	.1907	.192	.1829
Avg	1.2769	1.3397	1.4232	1.4936	1.2323	1.2714	1.7100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 203 / HARINAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0926	.0983	.104	.1219	.0983	.1067
2	.0152	.0914	.0983	.1189	.1219	.0983	.1219
3		.1067	.1147	.1355	.1372	.1147	.1372
4		.1219	.1147	.1337	.1372	.1147	.1372
5		.1219	.1475	.1581	.1524	.1311	.1372
6		.1372	.1638	.1448	.1677	.1475	.1677
7		.1543	.1638	.1581	.1677	.1475	.1852
8		.1372	.1638	.1739	.1677	.1638	.1829
9	.1406	.1475	.1638	.1698	.1638	.1802	.1677
10	.1562	.0181	.0187			.0189	.0152
11	.1718	.0181	.0189			.0189	.0152
12	.1718	.0181	.0187			.0189	.0152
13		.0181	.0187				.0152
14		.0181	.0187			.0377	.0152
15		.0181	.0187			.0189	.0152
16		.0181	.0187			.0377	.0152
17		.0181	.0187			.0377	.0152
18		.0181	.0187			.0377	.0152
19	.0183	.0181	.0187		.0181	.0189	
20	.0183	.0181	.0187		.0181	.0189	
21	.0183	.0181	.0187		.0181	.0189	
22	.0183	.0181	.0187		.0181		
23	.0183	.0181	.0187		.0181		
24	.0152	.0183	.0983	.104	.1219	.0995	.1067
Max	.1718	.1543	.1638	.1739	.1677	.1802	.1852
Min	.0152	.0181	.0187	.104	.0181	.0189	.0152
Avg	.0648	.0576	.0662	.1401	.1033	.0752	.0835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 408 / JINDAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	.7716		
2		1.0288	.7716		
3		1.0288	.7716		
4		1.0288	.7716		
5		1.0288	.7716		
6		1.0288	.7716		
7		1.0288	.7716		
8	.6173	1.0288	.7716	.6173	.6173
9		1.1317	.2058		
10		1.1317	.2058		
11		1.1317	.2058		
12		1.1317	.2058		
13		1.1317	.2058		
14		1.1317	.2058		
15		1.1317	.2058		
16	.7202	1.1317	.2058	.5144	.5144
17	.6173	1.0288			
18	.6173	1.0288			
19	.6173	1.0288			
20	.6173	1.0288			
21	.6173	1.0288			
22	.6173	1.0288			
23	.6173	1.0288			
24	.6173	.6173	1.0288	.463	.5144
Max	.7202	1.1317	1.0288	.6173	.6173
Min	.6173	.6173	.2058	.463	.5144
Avg	.6276	1.0460	.5205	.5316	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 409 / MILLENIUM EXPRESS
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1317	1.0288		
2		1.1317	1.0288		
3		1.1317	1.0288		
4		1.1317	1.0288		
5		1.1317	1.0288		
6		1.1317	1.0288		
7		1.1317	1.0288		
8	1.2346	1.1317	1.0288	1.2346	1.1317
9		1.1317	.5144		
10		1.1317	.5144		
11		1.1317	.5144		
12		1.1317	.5144		
13		1.1317	.5144		
14		1.1317	.5144		
15		1.1317	.5144		
16	1.286	1.1317	.5144	.7716	1.0288
17	1.0288	1.1317			
18	1.0288	1.1317			
19	1.0288	1.1317			
20	1.0288	1.1317			
21	1.0288	1.1317			
22	1.0288	1.1317			
23	1.0288	1.1317			
24	1.0802	1.1317	1.1317	1.0802	1.1831
Max	1.286	1.1317	1.1317	1.2346	1.1831
Min	1.0288	1.1317	.5144	.7716	1.0288
Avg	1.0802	1.1317	.7928	1.0288	1.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 201 / 11KV MARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1463	.1463
2	1.5223	1.3763	1.3279
3	1.5364	1.3279	1.2803
4	1.5729	1.3123	1.3108
5	1.8138	1.8023	1.7284
6	2.0165	2.17	2.0317
7	2.3594	2.5587	2.2996
8	2.4615	2.4939	2.3594
24	.181	.1448	.181
Max	2.4615	2.5587	2.3594
Min	.1433	.1448	.1463
Avg	1.5119	1.4814	1.4073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 205 / ITI COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.197	.1448	.1646
2	1.1142	1.278	1.1797
3	1.1797	1.2308	1.1336
4	1.1984	1.2452	1.1469
5	1.278	1.3603	1.4403
6	1.5043	1.6194	1.7284
7	1.8138	1.7204	1.7532
8	1.8724	1.8351	1.7368
24	.2195	.1646	.1629
Max	1.8724	1.8351	1.7532
Min	.197	.1448	.1629
Avg	1.1530	1.1776	1.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 206 / GUNJEGAON FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1463	.1448
2	.1448	.1448	.1463
3	.181	.1791	.197
4	.1829	.1829	.2012
5	.2195	.2149	.2172
6	.2507	.2534	.2534
7	.2926	.2507	.2195
8	.2195	.1646	.2353
24	.181	.1448	.1433
Max	.2926	.2534	.2534
Min	.1448	.1448	.1433
Avg	.2061	.1868	.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 201 / 11 Kv Machnur new
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0549	.0514	.0514	.0549	.0514
2	.0514	.0514	.0549	1.6004	1.4937	1.5074	1.0364
3	.0514	.0514	.0549	1.6004	1.5546	1.5074	1.0364
4	.0514	.0514	.0549	1.6156	1.5546	1.5238	1.2041
5	.0514	.0514	.0549	1.6766	1.6004	1.5238	1.3717
6	.0514	.0514	.0732	1.6766	1.6461	1.5238	1.5851
7	.0514	.0514	.0549	1.7223	1.6766	1.7695	1.6613
8	.0514	.0514	.0549	1.7375	1.7223	1.9662	1.989
9	.0514	.0549	.0549	1.768	1.8679	1.8515	1.768
10		.0549	.0514	1.7223	1.9334	1.7985	1.7071
11		.0549	.0514	1.7375	1.8842	1.768	1.7223
12	1.829	2.13	1.829	.0514		1.6385	.0514
13	1.768	2.0972	1.829	.0514		1.7204	.0514
14	1.9509	2.0972	1.9204	.0514	.0549	1.7204	.0514
15	1.8747	2.0481	1.8595	.0514	.0549	1.8023	.0514
16	1.8747	2.0153	1.8747	.0514	.0549	1.7859	.0514
17	1.829	2.0972	1.8138	.0514	.0549	1.7695	.0514
18	1.8595	2.0645	1.9662	.0514	.0549	1.7204	.0514
19	1.9662	2.1464	1.8595	.0514	.0549	1.7204	.0514
20	.0514	.0549	.0514	.0686	.0549	.0514	
21	.0514	.0549	.0514	.0686	.0549	.0514	.0514
22	.0514	.0549	.0514	.0514	.0549	.0514	.0514
23	.0514	.0549	.0514	.0514	.0549	.0514	.0514
24	.0514	.0514	.0549	.0514	.0514	.0549	.0514
Max	1.9662	2.1464	1.9662	1.768	1.9334	1.9662	1.989
Min	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.7123	.7310	.6595	.7338	.7993	1.2889	.6848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 202 / 11 Kv Bramhpuri Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 River Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0732	.0686	.0686	.0732	.0686
2	1.0364	1.0974	1.278	.0686	.0686	.0732	.0686
3	1.0364	1.1279	1.3108	.0686	.0686	.0732	.0686
4	1.1279	1.1888	1.3763	.0686	.0686	.0732	.0686
5	1.1584	1.3717	1.4091	.0686	.0686	.0732	.0686
6	1.1584	1.2193	1.278	.0686	.0686	.0732	.0686
7	1.3108	1.2803	1.4091	.0686	.0686	.0732	.0686
8	1.1888	1.2944	1.278	.0686	.0686	.0732	.0686
9	1.1584	1.3763	1.4419	.0686	.0732	.0732	.0686
10	1.1888	1.4091	1.2803	.0686	.0732	.0686	.0686
11	1.2803	1.4091	1.2803	.0686	.0732	.0686	.0686
12	.061	.0732	.0686	1.3413	1.4091	1.3413	1.2193
13	.0686	.0732	.0686	1.3413	1.4419	1.3413	1.3413
14		.0732	.0686	1.3413	1.4419	1.2803	1.3413
15	.0686	.0732	.0686	1.3413	1.1797	1.2803	1.3413
16	.0686	.0732	.0686	1.3413	1.2125	1.3413	1.3413
17	.0686		.0686	1.3413	1.2289	1.3413	1.3717
18	.0686	.0732	.0686	1.3413	1.278	1.3413	1.3717
19	.0686	.0732	.0686	1.3108	1.278	1.3413	1.3413
20	.0686	.0732	.0686	.0686	.0732	.0686	
21	.0686	.0732	.0686	.0686	.0732	.0686	.0686
22	.0686	.0732	.0686	.0686	.0732	.0686	.0686
23	.0686	.0732	.0686	.0686	.0732	.0686	.0686
24	.0686	.0686	.0732	.0686	.0686	.0732	.0686
Max	1.3108	1.4091	1.4419	1.3413	1.4419	1.3413	1.3717
Min	.061	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.5447	.5964	.5963	.4916	.4833	.4897	.5086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 203 / 11kv GFSS Bramhapuri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.2534	.2401	.2229	.2534	.2401
2	.2229	.2401	.2172	.2401	.2229	.2534	.2401
3	.2229	.2401	.2172	.2401	.2229	.2534	.2229
4	.2229	.2572	.2534	.2572	.2401	.2715	.2229
5	.2401	.2572	.3077	.2572	.2915	.3077	.2572
6	.3258	.2743	.3801	.2915	.3086	.3258	.2915
7	.2915	.2915	.3077	.2743	.2572	.3258	.3258
8	.2572	.3077	.2896	.2572	.2401	.2715	.2915
9	.2229	.2715	.2715	.2229	.2172	.2353	.2743
10	.2572	.2715	.2401	.2058	.2172	.2229	.2572
11	.2401	.2715	.2401	.1715	.2172	.2401	.2743
12	.2401	.2896	.2743	.1886	.2353	.2401	.2401
13	.2572	.2715	.2743	.2058	.2172	.2058	.2058
14	.2058	.2353	.2058	.1886	.1991	.1886	.2058
15	.2058	.2353	.2229	.1715	.1629	.1715	.2058
16	.2401	.2172	.2229	.1715	.181	.1886	.2058
17	.2401	.2172	.1886	.1715	.181	.2058	.2058
18	.2229	.2534	.1886	.1715	.1991	.2229	.2229
19	.2915	.2534	.2401	.2401	.2715	.2058	.2743
20	.3601	.2896	.2743	.2743	.3258	.2572	
21	.3429	.3258	.2401	.2743	.3258	.2572	.2915
22	.3086	.2896	.2229	.2743	.3077	.2743	.2743
23	.2743	.2715	.2401	.2401	.2715	.2401	.2401
24	.2229	.2401	.2534	.2401	.2229	.2534	.2401
Max	.3601	.3258	.3801	.2915	.3258	.3258	.3258
Min	.2058	.2172	.1886	.1715	.1629	.1715	.2058
Avg	.2558	.2630	.2511	.2279	.2399	.2447	.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 204 / 11 KV BRAHAMPURI BORE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0732	.0686		.0732	.0686
2	1.3108	1.5432	1.4998	.0686		.0732	.0686
3	1.3108	1.4632	1.3763	.0686		.0732	.0686
4	1.3413	1.4632	1.3763	.0686		.0732	.0686
5	1.3717	1.4937	1.4419	.0686		.0732	.0686
6	1.3717	1.5394	1.4746	.0686		.0732	.061
7	1.4327	1.6004	1.5729	.0686		.0732	.0686
8	1.6156	1.6712	1.6549	.0686		.0732	.0732
9	1.5546	1.6876	1.6876	.0686		.0732	.0686
10	1.6309	1.4746	1.5546	.0686		.0686	.0686
11	1.8176	1.5402	1.5394	.0686		.0686	.0686
12	.0686	.0732	.0686	1.1431	1.5893	.5182	1.5546
13	.0686	.0732	.0686	1.2193	1.6385	.503	1.4937
14		.0724	.0686	1.3108	1.8187	.503	1.4937
15	.0686	.0732	.0686	1.4327	1.7695	.4877	1.6804
16	.0686	.0732	.0686	1.5089	1.7695	.4572	1.6975
17	.0686	.0732	.0686	1.5242	1.7368	.4877	1.7833
18	.0686	.0732	.0686	1.5242	1.8351	.4725	1.6766
19	.0686	.0732	.0686	1.448	1.7695	.4725	1.4937
20	.0686	.0732	.0686		.0732	.0686	
21	.0686	.0732	.0686		.0732	.0686	.0686
22	.0686	.0732	.0686		.0732	.0686	.0686
23	.0686	.0732	.0686		.0732	.0686	.0686
24	.0686	.0686	.0732	.0686		.0732	.0686
Max	1.8176	1.6876	1.6876	1.5242	1.8351	.5182	1.7833
Min	.0686	.0686	.0686	.0686	.0732	.0686	.061
Avg	.6804	.6871	.6728	.5967	1.1850	.2102	.6043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 205 / Machnur AG-2

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0732	.0686	.0686	.0732	.0686
2	.0686	.0686	.0732	1.1279	1.0364	1.2452	1.1279
3	.0686	.0686	.0732	1.1279	1.0364	1.2452	1.1888
4	.0686	.0686	.0732	1.2041	1.0669	1.278	1.2193
5	.0686	.0686	.0732	1.2193	1.1279	1.3108	1.2193
6	.0686	.0686	.0732	1.2651	1.1584	1.3763	1.2346
7	.0686	.0686	.0732	1.2651	1.1736	1.4255	1.3272
8	.0686	.0686	.0732	1.326	1.2651	1.4419	1.4091
9	.0686	.0732	.0732	1.3108	1.3108	1.3763	1.3108
10		.0732	.0686	1.3108	1.2616	1.2955	1.3413
11		.0732	.0686	1.3108		1.3108	1.2955
12	1.2651	1.6385	1.4784	.0686		.061	.0686
13	1.4175	1.5565	1.3717	.0686		.0686	.0686
14	1.4175	1.5238	1.326	.0686	.0732	.0686	.0686
15	1.3717	1.5402	1.326	.0686	.0732	.0686	.0686
16	1.387	1.5729	1.3413	.0686	.0732	.0686	.0686
17	1.5947	1.5074	1.2955	.0686	.0732	.0686	.0686
18	1.4022	1.4419	1.2651	.0686	.0732	.0686	.0686
19	1.4022	1.4091	1.2651	.0686	.0732	.0686	.0686
20	.0686	.0732	.0686	.0686	.0732	.0686	
21	.0732	.0732	.0686	.0686	.0732	.0686	.0686
22	.0686	.0732	.0686	.0686	.0732	.0686	.0686
23	.0686	.0732	.0686	.0686	.0732	.0686	.0686
24	.0686	.0686	.0732	.0686	.0686	.0732	.0686
Max	1.5947	1.6385	1.4784	1.326	1.3108	1.4419	1.4091
Min	.0686	.0686	.0686	.0686	.0686	.061	.0686
Avg	.5556	.5550	.4922	.5595	.5384	.5945	.5898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 201 / 11 KV KHOMNAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
24	.0693
Max	.0693
Min	.0693
Avg	.0693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 202 / 11 KV DONGARGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						1.8347	1.869
16						.1772	
24	.2229	.2035	.2401	.2303	.2401	.2229	.2279
Max	.2229	.2035	.2401	.2303	.2401	1.8347	1.869
Min	.2229	.2035	.2401	.2303	.2401	.1772	.2279
Avg	.2229	.2035	.2401	.2303	.2401	.7449	1.0485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 203 / 11 KV KHOMNAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.0747	.0747
16						.0373	
23					.0373		
24	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Max	.0373	.0373	.0373	.0373	.0373	.0747	.0747
Min	.0373	.0373	.0373	.0373	.0373	.0373	.0373
Avg	.0373	.0373	.0373	.0373	.0373	.0498	.056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 201 / DAMAJINAGAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.695		.6653	.6219	.5792	.5792
2	.6653	.6767	.5792	.7023	.6283	.6154	.5792
3	.695	.7133	.6335	.7392	.6468	.6878	.6154
4	.7682	.7682	.6878	.8048	.7095	.7701	.7362
5	.8688	.7964	.7701	.905	.8962	.9313	.8954
6	.9412	.905	.8775	.9412	1.2323	1.0029	1.0029
7	.8131	.8688	.788	1.0242	1.1088	.9671	.8954
8	.7392	.7522	.6984	.7682	.8859	.8954	.7522
9	.6653	.6805	.6268	.6584	.8869	.7164	.7164
10	.6584	.724	.3696		.8059	.6089	.6379
11	.7602	.8059	.2957	.6584	.7164	.5014	.6219
12	.7023	.7059	.2896	.5068	.8417	.5611	.5853
13	.7207	.6878	.6154	.5316	.8059	.6516	.5316
14	.6516	.6697	.6219	.4458	.7059	.5731	.5121
15	.6878	.6697	.6219	.6348		.5611	.5792
16	.6154	.7059	.5792	.5552		.6516	.6219
17	.7964	.6335	.5121	.6516	.7059	.6878	.6516
18	.8326	.6878	.5175	.7655	.8059	.7164	.6878
19	1.0136	1.1104	.5121	.9816	1.0029	.788	.905
20	1.1104	.9134	1.0719	.439	.9492	.9671	
21	.9313	.7522	.961	1.1273	.8596	.8775	.9511
22	.8326	.7522	1.0242	.924	.788	.724	.7602
23	.7964	.6516	.8413	.724	.6335	.6154	.7316
24	.7392	.7602		.6653	.6878	.5973	.5973
Max	1.1104	1.1104	1.0719	1.1273	1.2323	1.0029	1.0029
Min	.6154	.6335	.2896	.439	.6219	.5014	.5121
Avg	.7779	.7536	.6589	.7313	.8148	.7187	.7020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 202 / Mangalwedha A.G. Feeder

SHEDDABLE RURAL

(M.I.D Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.1663	.168	.1509	.1478	.1463
2	.1663	.1478	.1478	.168	.1509	.1478	.1463
3	.1848	.1848	.1663	.1848	.1698	.1848	.1829
4	.2033	.2033	.2218	.2033	.1848	.2033	.2195
5	.2195	.2378	.2772	.2218	.2033	.2402	.2534
6	.2378	.2743	.3142	.2587	.2743	.2587	.3077
7	.2957	.3109	.2957	.2587	.2378	.2772	.3258
8	.2587	.2743	.2402	.2772	.3018	.2587	.2715
9	.2218	.2378	.2218	.2402	.2263	.2402	.2534
10	.2033	.2195	.2195	.2218	.1886	.2195	.197
11	.1492	.1829	.2033	.1663	.1698	.1829	.1478
12	1.9725	2.0178	1.9662	1.4232	1.9839	1.9784	2.0056
13	1.9559	2.0454	2.0645	1.5154	2.1795	1.9951	2.0153
14	2.0388	1.933	1.9334	1.5432	2.1293	2.0119	1.9826
15	2.1382	1.9161	1.9271	1.4937		2.0719	1.989
16	2.1714	1.9839	1.9498	1.475		2.1216	1.9334
17	2.2542	2.0119	1.9989	1.7966	2.1628	2.0719	1.8679
18	2.2542	1.9669	1.8351	1.6248	2.2542	2.0388	1.7859
19	2.0553	1.8991	1.6385	1.6004	2.0719	1.9393	1.9006
20	.2715	.2587	.2957	.2218	.2772	.2926	
21	.2534	.2033	.2587	.1867	.2957	.2378	.2033
22	.2378	.1848	.2218	.1509	.2218	.2195	.1848
23	.2012	.1663	.1867	.1698	.2033	.1829	.1663
24	.1478	.1646	.1848	.168	.1698	.1663	.1646
Max	2.2542	2.0454	2.0645	1.7966	2.2542	2.1216	2.0153
Min	.1478	.1478	.1478	.1509	.1509	.1478	.1463
Avg	.8434	.7989	.7890	.6558	.7367	.8204	.8109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 203 / M.I.D.C. Express Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0187	.0187	.0187	.1848	.1848
2	.0187	.0189	.0187	.0187	.0187	.168	.1848
3	.0187	.0189	.0187	.0187	.0187	.168	.1829
4	.0185	.0189	.0189	.0187	.0187	.2033	.2195
5	.0185	.0189	.0189	.0187	.0187	.2402	.2534
6	.0185	.0187	.0189	.0187	.0187	.2772	.2715
7	.0187	.0187	.0189	.0187	.0183	.2218	.1991
8	.0187	.0187	.0189	.0187	.0187	.2772	.1991
9	.0187	.0187	.0189	.0187	.0187	.2587	.2534
10	.0187	.0187	.0185	.0187	.0187	.2743	.3045
11	.0187	.0187	.0187	.0187	.0187	.2926	.2218
12	.0187	.0187	.037	.0187	.0187	.2772	.2195
13	.0187	.0187	.037	.0185	.0187	.2957	.2172
14	.0187	.0187	.037	.0185	.0187	.3109	.2195
15	.0187	.0187	.037	.0185		.2402	.2378
16	.0187	.0187	.037	.0183		.2218	.2561
17	.0187	.0187	.037	.0185	.2987	.2378	.2172
18	.0187	.0187	.0185	.0185	.3292	.2561	.2743
19	.0187	.0187	.0185	.0185	.3439	.2534	.2926
20	.0187		.0187	.0183	.3109	.3109	
21	.0187		.0187	.0185	.3109	.2926	.3292
22	.0187		.0187	.0187	.2772	.2561	.2926
23	.0187		.0187	.0187	.2033	.2402	.2561
24	.0187	.0187		.0187	.0187	.2402	.1848
Max	.0187	.0189	.037	.0187	.3439	.3109	.3292
Min	.0185	.0187	.0185	.0183	.0183	.168	.1829
Avg	.0187	.0188	.0235	.0186	.1070	.2500	.2379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 201 / DARSHAN MANDAP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.4801	.4801	.5144	.5144	.4973
2	.4715	.5093	.463	.4801	.4801	.4801	.4801
3	.4904	.5093	.463	.463	.4801	.4801	.4801
4	.5093	.4715	.4801	.463	.4801	.5144	.4801
5	.5281	.4715	.4973	.4973	.5144		.4801
6	.6036	.4904	.5658	.5144	.583	.5487	.5487
7	.547	.5281	.5144	.4801	.4801	.5144	.5487
8	.4904	.5093	.4801	.4458	.463	.4801	.5487
9	.5093	.4904	.5093	.5281	.4715	.5281	.5658
10	.5316	.6413	.679	.679	.6036	.547	.7167
11	.5487	.7545	.7545	.7733	.7545	.8299	.8299
12	.6173	.9242	.8676	.7545	.7733	.8676	.8865
13	.6173	.9242	.8488	.9054	.8488	.9242	.8488
14	.6173	.9619	.9054	.8865	.9242	.9619	.8488
15	.6173	.9054	.9242	.9808	.8676	.9431	.8676
16	.6001	.9619	.823	.9431	.9054	.9431	.8488
17	.6344	.8916	.8402	.8745	.8916	.8916	.8299
18	.6516	.8745	.8573	.8745	.8916	.9088	.811
19	.7888	1.0288	.9945	1.0288	1.0288	1.0288	.9431
20	.7716	.9602	.9259	.9945	.9431	.9602	.9808
21	.6859	.7888	.7716	.7888		.823	.9054
22	.6413	.6859	.6001	.6859	.6516	.6687	.7202
23	.6036	.5316	.5487	.583	.5487	.6001	.6173
24	.6036	.5658	.4801	.5144	.5487	.5144	.5316
Max	.7888	1.0288	.9945	1.0288	1.0288	1.0288	.9808
Min	.4715	.4715	.463	.4458	.463	.4801	.4801
Avg	.5920	.7045	.6781	.6925	.6804	.7162	.7007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 202 / 11KV GANESHNAGAR SHEDDABLE URBAN
PANDHARPUR Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.0562	.9774	.9945	1.0288	1.0288	1.0802
2	1.1694	.9808	.9431	.9431	.9774	.9945	1.0288
3	1.1317	.9431	.9088	.9088	.9259	.9945	.9602
4	1.0185	.8865	.8573	.8573	.8916	.8916	.9602
5	.9431	.8488	.8573	.8573	.8745	.8573	.5487
6	.9619	.8865	.8916	.8573	.8745	.9431	1.2346
7	1.0185	.9054	.9088	.8745	.8916	.8916	.9602
8	.9997	.9431	.8573	.823	.8573	.8916	1.1145
9	.9054	.9054	.9054	.8299	.9054	.8488	.9808
10	.8745	.9242	.9619	.7922	.9431	.9054	1.0751
11	.8573	.9054		.7733	.9808	.9242	.9242
12	.8916	.9242	.9431	.7922	.9242	.9431	.9431
13	.9431	.9431	1.0185	.9054	.8865	.9997	.9242
14	.9602	.9431	.9808	.9431	.9054	.9808	1.094
15	1.0288	.9242	1.0562	1.0185	1.0374		1.1506
16	.9945	.9242	.9088	.9431	.9997	.9997	1.1506
17	.9259	.8402	.8745	.8402	.8573	.8916	1.094
18	.8402	.823	.823	.823		.8573	1.1317
19	.9945	1.0288	1.0631	1.0288	.9774	.9602	1.2071
20	1.0802	1.0631	1.0974	1.0288	1.0288	1.0974	1.1694
21	1.0802	1.0974	.9602	1.0631	1.1145	1.1488	1.1694
22	1.1883	1.1488	1.1145	1.1145	1.166	1.2003	.8745
23	1.1506	1.2003	1.1488	1.1488	1.166	1.166	.6001
24	1.2637	1.1317	1.0802	1.0631	1.0802	1.0288	1.1317
Max	1.2637	1.2003	1.1488	1.1488	1.166	1.2003	1.2346
Min	.8402	.823	.823	.7733	.8573	.8488	.5487
Avg	1.0194	.9657	.9625	.9260	.9693	.9759	1.0212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 203 / CABLE EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0343	.0343	.0343	.0343	.0343
2	.0377	.0377	.0343	.0343	.0343	.0343	.0343
3	.0377	.0377	.0343	.0343	.0343	.0343	.0343
4	.0377	.0377	.0343	.0343	.0343	.0343	.0343
5	.0943	.0377	.0343	.0343	.0343	.0343	.0343
6	.0377	.0377	.0343	.0343	.0343	.0343	.0343
7	.0377	.0377	.0343	.0343	.0343	.0343	.0343
8	.0377	.0377	.0343	.0343	.0343	.0343	.0343
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0343	.0377	.0377	.0377	.0377	.0377	.0377
11	.0343	.0377		.0377	.0377	.0377	.0377
12	.0343	.0377	.0377	.0377	.0377	.0377	.0377
13	.0343	.0377	.0377	.0377	.0377	.0377	.0377
14	.0343	.0377	.0377	.0377	.0377	.0377	.0377
15	.0343	.0377	.0377	.0377	.0377	.0377	.0377
16	.0343	.0377	.0343	.0377	.0377	.0377	.0377
17	.0343	.0343	.0343	.0343	.0343	.0343	.0377
18	.0343	.0343	.0343	.0343	.0343	.0343	.0377
19	.0343	.0343	.0343	.0343	.0343	.0343	.0566
20	.0343	.0343	.0343	.0514	.0343	.0514	.0566
21	.0343	.0343	.0343	.0514	.0343	.0343	.0377
22	.0377	.0343	.0343	.0514	.0343	.0343	.0343
23	.0377	.0343	.0343	.0343	.0343	.0343	.0343
24	.0377	.0377	.0343	.0343	.0343	.0343	.0343
Max	.0943	.0377	.0377	.0514	.0377	.0514	.0566
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0384	.0367	.0352	.0376	.0354	.0361	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 204 / 11 KV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263						
2	.2452	.2829	.2572	.2572			
3	.2829	.2829	.2572	.2572			
4	.2641	.3018	.2743	.3086			
5	.3206	.3395	.3086	.3258			
6	.5093	.415	.3429	.3258			
7	.415	.4338	.4287	.3258			1.046
8	.3961	.4527	.4287	.3429			
9	.3772	.4527	.4715	.3772			
10	.3429	.4527	.4527	.4527			
11	.3601		.4904	.415			
12					.415	.415	.5281
13					.4527	.4338	.4904
14					.4715	.4527	.5281
15					.547	.4527	.547
16					.5658	.4527	.5281
17					.3944	.3944	.5281
18					.3944	.3772	.4904
19					.0171	.3601	.415
Max	.5093	.4527	.4904	.4527	.5658	.4527	1.046
Min	.2263	.2829	.2572	.2572	.0171	.3601	.415
Avg	.3400	.3793	.3712	.3388	.4072	.4173	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 205 / 11 KV SARGAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6036	.5658	.5658	.6001	.6001	.6344
2	.6602	.5658	.5487	.5487	.5658	.5487	.6001
3	.5658	.5658	.5487	.5487	.5487	.5487	.5658
4	.6036	.6036	.5487	.5487	.5487	.5487	.5658
5	.6413	.6413	.583	.583	.5487	.5487	1.5432
6	.679	.6602	.6344	.6516	.583	.583	1.5432
7	.679	.6979	.6173	.6173	.5487	.6173	1.5432
8	.6036	.6602	.5658	.5487	.5144	.6036	.4801
9	.6413	.6036	.5658	.6413	.5281	.679	.5093
10	.583	.7545	.7167	.7167	.7545	.7167	.7545
11	.6516	.8299	.8299	.7922	.8299	.7922	.9431
12	.583	.7922	.8676	.7922	.9054	.7167	.9054
13	.6516	.9054	.9431	.8299	.8676	.7545	.9431
14	.6516	.8299	.9431	.8488	.9054	.7922	.8676
15	.6173	.9054	.9054	.9054	.9054	.8676	.9808
16	.6516	.9054	.8573	.9431	.9054	.9431	.9431
17	.6344	.8402	.7545	.823	.8573	.8573	.9431
18	.6173	.8402	.7545	.7716	.7545	.8573	.9808
19	.6859	.8916	.9259	.8573	.823	.8916	1.0185
20	.7545	.8402	.8573	.7716	.823	.8573	.9808
21	.7373	.7888	.7545	.7545	.7888	.7716	.8676
22	.7545	.7373	.7202	.7202	.7202	.6859	.7716
23	.6979	.6859	.6516	.6859	.6859	.6859	.7545
24	.7167	.6413		.583	.6516	.6173	.6687
Max	.7545	.9054	.9431	.9431	.9054	.9431	1.5432
Min	.5658	.5658	.5487	.5487	.5144	.5487	.4801
Avg	.6543	.7413	.7243	.7104	.7152	.7119	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 206 / 11 KV AMBIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.0562	.9945	1.0288	1.0288	.9945	1.0288
2	.9808	.9808	.9602	.9945	.9945	.9945	.9774
3	1.0185	.9619	.9431	.9431	.9602	.9602	.9774
4	1.0562	.9431	.9602	.9945	.9602	1.0288	.9774
5	1.0751	.9431	1.0288	1.0288	.9945	1.0288	.9774
6	1.2826	1.094	1.2689	1.286	1.2346	1.286	1.0802
7	1.226	1.2826	1.0974	1.166	1.1145	1.1145	1.2003
8	1.0374	1.1694	1.0288	.9088	1.0288	.9088	1.1145
9	.9431	.9808	1.0751	.9619	1.0751	.9619	1.1317
10	.9259	.4715	1.0562	1.0562	1.0185	1.0562	1.1506
11	.9602	1.1694	1.0751	1.1317	1.1506	1.1506	1.1883
12	.9774	1.2449	1.2071	1.094	1.1883	1.2071	1.2637
13	.9774	1.2637	1.2449	1.1317	1.226	1.226	1.2637
14		1.2826	1.1883	1.1694	1.2449	1.2637	1.2637
15	1.0117	1.2449	1.3203	1.2449	1.3014	1.2826	1.2826
16	.9945	1.3203	1.1145	1.1694	1.1883	1.226	1.2449
17	.9945	1.2346	1.1488	1.0974	1.0802	1.1317	1.2071
18	.9774	1.2174	1.2003	1.1145	1.166	1.1488	1.1317
19		1.4403	1.4403	1.4232	1.3717	1.4403	1.5089
20	1.286	1.4232	1.406	1.4403	1.3546	1.3717	1.4335
21	1.2174	1.3032	1.2174	1.3032	1.2346	1.286	1.4335
22	1.3203	1.2346	1.1831	1.2174	1.2003	1.2003	1.2517
23	1.2071	1.1488	1.166	1.1145	1.1145	1.1317	1.2174
24	1.1128	1.094	1.0288	1.046	1.0631	1.0631	1.0631
Max	1.3203	1.4403	1.4403	1.4403	1.3717	1.4403	1.5089
Min	.9259	.4715	.9431	.9088	.9602	.9088	.9774
Avg	1.0745	1.1461	1.1398	1.1278	1.1373	1.1443	1.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 201 / 11 KV Manisha Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.8145	.7716	.7373	.8145	.8145	.8688
2	.7602	.7783	.7373	.7202	.7602	.7783	.8145
3	.6878	.724	.7202	.6687	.724	.724	.7783
4	.6697	.6697	.6687	.6516	.7059	.6878	.7602
5	.6516	.6516	.6516	.6687	.7059	.7059	
6	.7059	.6878	.6687	.6516	.724		
7	.7602	.6516	.6687	.6687	.724	.7783	
8	.7783	.7964	.6859	.6687	.7059	.7602	1.1403
9	.7602	.7059	.7202	.703	.7602	.724	.9231
10	.6516	.6154	.6173	.5316	.5973	.6697	.8326
11	.6154	.6154	.6344	.6001	.5792	.6335	.7964
12	.6154	.5973	.6173	.6001	.5973	.5611	.724
13	.6335	.6335	.6173	.6344	.6154	.6335	.7602
14	.6516	.6516	.6173	.6344	.6154	.6697	.7783
15	.724	.6335	.6001	.6344	.6335	.724	.7602
16	.724	.6516	.6516	.6173	.6878	.724	.7783
17	.724	.6335	.6173	.6687	.6154	.724	.724
18	.6697	.6697	.6001	.6687	.6516	.6878	.7421
19	.7964	.7783	.7373	.7545	.7783	.8145	.8507
20	.9055	.9412	.8059	.8573	.8507	.8326	.9231
21	.9055	.905	.823	.8402	.8869	.8507	.9231
22	.8688	.905	.8402	.8573	.905	.9593	.9593
23	.9231	.9231	.8916	.8745	.9412	.9774	.9774
24	.8869	.8688	.823	.8059	.8869	.8688	.9231
Max	.9231	.9412	.8916	.8745	.9412	.9774	1.1403
Min	.6154	.5973	.6001	.5316	.5792	.5611	.724
Avg	.7452	.7293	.6994	.6966	.7278	.7523	.8447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 202 / 11KV PANI PURWATHA EXP. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.3734	.2058	.5144	.6722	.6535	.6722
2	.6722	.3921	.2058	.6173	.6535	.6535	.6535
3	.7095	.4668	.2229	.6687	.6535	.6908	.7282
4	.8775	.7095	.5316	.9602	.7842	.7655	.8962
5	1.1389	.8029	.703	.9945	.9149	1.0269	
6	1.2323	.8775	.7888	1.0117	1.0829	1.2136	
7	1.2136	.9335	.823	1.046	1.0829	1.2136	
8	1.2136	1.0456	.823	1.1145	1.1576	1.1949	.4481
9	1.1763	1.1763	.7545	1.0802	1.1389	1.1203	1.2323
10	1.1763	1.1763	.7716	1.046	1.0829	1.5123	1.1576
11	1.0269	1.1389	.6687	.9431	1.0456	1.1389	1.1763
12	1.0082	.6908	.703	.9259	1.0082	1.0082	1.1576
13	.9522	.6908	.9602	.9774	1.0082	.9709	1.0829
14	.8962	.5601	.8573	.8745	1.0456	.8962	1.0269
15	.9149	1.307	.8745	.823	.8962	.8962	1.0642
16	.9149	1.3443	.8745	.8916	.9335	.5975	1.1016
17	.9055	.5601	.8916	.8402	.9335	.5975	
18	.6908	.5788	.7545	.8402	.6722	.8402	.6348
19	.5041	.3547	.6344	.7545	.2427	.5228	.6535
20	.3921	.4854	.463	.2743	.3734	.3734	.5788
21	.2054	.3734	.4458	.1715	.1494	.2054	.5041
22	.2054	.3547	.4458	.3258	.2054	.1867	.6722
23	.3921	.2241	.6344	.6516	.2054	.6908	.6722
24	.7095	.3921	.3601	.6516	.7095	.6908	.7095
Max	1.2323	1.3443	.9602	1.1145	1.1576	1.5123	1.2323
Min	.2054	.2241	.2058	.1715	.1494	.1867	.4481
Avg	.8242	.7087	.6416	.7916	.7772	.8192	.8411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 203 / 11 KV ISBAWI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.2012	1.1317	1.0631	1.1458	1.2752	1.2752
2	1.1273	1.1458	1.0117	.9945	1.0534	1.2012	1.2012
3	1.0534	1.1088	.9431	.9431	.9979	1.1088	1.1088
4	1.0164	1.1273	.8916	.9088	.9425	1.0534	1.0534
5	1.0719	1.1273	.9259	.9088	1.0534	1.0719	
6	1.0903	1.1458	1.0117	.8916	1.0903	1.1827	
7	1.0719	1.1458	1.046	.8745	1.0903	1.1458	
8	1.0903	1.1088	1.046	.9945	1.0719	1.0719	1.3491
9	1.0719	1.0534	.9774	.9602	1.1458	1.0534	1.0719
10	1.0719	1.1088	1.0631	1.0117	1.1273	1.1273	1.0349
11	1.1643	1.1273	1.0117	1.0631	1.1088	1.1088	1.1458
12	1.1273	1.1273	1.0288	1.0631	1.0903	1.1088	1.2012
13	1.1088	1.1643	1.0288		1.1458	1.0903	1.2197
14	1.1088	1.0903	1.0974	1.0974	1.2012	1.1088	1.2197
15	1.1273	1.1273	1.0631	1.0631	1.1458	1.1273	1.2197
16	1.2382	1.1827	1.1488	1.0802	1.1088	1.1458	1.2752
17	1.2936	1.2197	1.0974	1.2174	1.1827	1.2012	1.2752
18	1.1643	1.2382	1.046	1.166	1.1088	1.2012	1.2197
19	1.386	1.3491	1.2174	1.3032	1.3121	1.3121	1.5524
20	1.3306	1.386	1.2003	1.3375	1.2752	1.386	1.4969
21	1.3676	1.3306	1.2174	1.3203	1.2752	1.4045	1.5154
22	1.4415	1.3121	1.2346	1.3717	1.3306	1.4415	1.4969
23	1.4045	1.3121	1.2174	1.3032	1.3306	1.4784	1.4784
24	1.2936	1.2382	1.2346	1.1317	1.2567	1.3491	1.3491
Max	1.4415	1.386	1.2346	1.3717	1.3306	1.4784	1.5524
Min	1.0164	1.0534	.8916	.8745	.9425	1.0534	1.0349
Avg	1.1843	1.1866	1.0788	1.0899	1.1496	1.1981	1.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 402 / 33KV Bandishegaon
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.8213	5.8213	5.144	9.3622	9.5359	5.7659	5.7105
2	10.6447	10.4784	10.8025	10.8539	11.2546	11.0328	12.1416
3	11.1991	10.9774	8.179	10.751	11.6427	12.0862	12.9733
4	11.6427	10.5893	8.3848	10.8025	12.1416	12.5297	13.5831
5	11.6981	10.4784	8.2819	11.0597	12.6406	12.1971	
6	11.6981	10.8111	8.8477	11.3169	13.0287	10.6447	
7	11.6427	11.5872	9.3107	11.0597	12.5297	12.0862	
8	12.2525	10.1458	6.9445	12.2943	9.2033	11.7536	11.1437
9	12.0862	10.9774	7.6646	11.1626	12.6961	13.5831	14.5256
10	4.1581	4.5462	4.2181	3.8066	5.3778	5.3224	14.3039
11	7.3737	7.9281	4.0124	6.9959	4.4353	4.8234	6.2649
12	8.5934	9.4805	7.9218	5.9156	7.041	6.4312	12.0308
13	6.4312	6.7084	6.2757	1.1317	6.2649	10.6447	11.3655
14	8.8152	8.1499	8.3333	1.0288	11.7536	10.2566	11.2546
15	8.8706	8.9815	8.3333	1.0802	11.5872	10.2012	11.31
16	8.8706	8.4271	8.2305	1.1831	8.538	10.8665	6.2094
17	9.3141	9.0369	8.4362	1.1317	9.9794	9.0369	9.5913
18	8.1499	8.538	8.642	1.286	6.653	9.0924	9.3696
19	5.5441	4.768	5.4012	4.5782	5.156	4.8234	5.4887
20	6.9302	6.8193	6.0185	3.4465	5.655	5.0452	5.4332
21	6.7638	6.3203	2.4691	5.2984	5.2669	5.1006	5.0452
22	6.4866	5.8768	4.6296	4.9897	4.6016	4.3244	4.768
23	6.0431	5.7659	4.5268	4.784	4.2135	4.3244	4.5462
24	5.7105	6.0985	3.8066	4.4239	5.1006	4.0472	4.0472
Max	12.2525	11.5872	10.8025	12.2943	13.0287	13.5831	14.5256
Min	4.1581	4.5462	2.4691	1.0288	4.2135	4.0472	4.0472
Avg	8.6142	8.3047	6.8673	6.2393	8.5957	8.5842	9.1003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 201 / 11KV Bhalwani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5546	1.7833	1.4918	1.6461	1.448	.2587	.2134
2	.1829	.1715	.2033	.1829	1.448	1.5912	1.2041
3	.1829	.1715	.2033	.1829	1.448	1.6244	1.2498
4	.2439	.1886	.2402	.1829	1.5242	1.7404	1.4327
5	.2439	.2058	.2772	.2134	1.6461	2.0388	1.7528
6	.2743	.2915	.2957	.2743	1.7833	2.4034	2.0576
7	.3048	.2743	.2957	.2743	2.2405	2.652	2.5301
8	.2743	.2572	.2772	.2439	2.2558	2.6355	2.6216
9	.2591	.2218	.2402	.1829	1.5546	1.5089	2.0881
16		.2033	.1524		.1663	.1829	.2033
17		.2033	.1524	.2286	.1848	.2134	.2402
18		2.5857	2.4082	2.5149	.2218		.1848
19		2.7515	2.4996	2.5453	.3142		.3881
20		2.3205	2.1338	2.1338	.3511		.3881
21		2.1714	1.829	1.9509	.2772		.3326
22		1.6741	1.829	1.6766	.2402		.2957
23	1.989	1.5912	1.6766	1.6766	.2402		.2772
24	1.5242	1.8861	1.5415	1.6766	1.5242	.2587	.2134
Max	1.989	2.7515	2.4996	2.5453	2.2558	2.652	2.6216
Min	.1829	.1715	.1524	.1829	.1663	.1829	.1848
Avg	.6394	1.0529	.9860	1.0463	1.0483	1.4257	.9819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 202 / 11KV Jainwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4801	.5359	.4268	.4572	.5359	.4268
2	.9145	1.0288	1.387	.9907	.4572	.5359	.4268
3	.9145	1.0288	1.4217	.9907	.4572	.5359	.4268
4	1.0364	1.166	1.5257	1.1888	.4877	.5729	.4572
5	1.2803	1.4403	1.7337	1.3717	.5182	.6283	.503
6	1.5851	2.0405	2.0111	1.89	.5792	.6838	.5639
7	2.2862	2.572	2.6006	2.5149			
8	2.21	2.7435	2.4099	2.3624			
9	2.1033	2.5139	2.1714	2.0729			
10					2.5833	2.3777	2.5139
11					2.4099	2.2862	2.2365
12					2.4792	2.1948	2.3926
13					2.5312	1.829	2.1672
16		.499	.4115		2.5312	1.9814	2.4619
17		.5544	.4268	.4115	2.5486	1.9204	2.4272
18		.5914	.4572	.4572	.5359		.6099
19		.6468	.5182	.5335	.6468		.6099
20		.6468		.5792	.7392		
21		.6283	.4572	.5182			.6283
22		.5914	.4572		.5544		.5729
23	.4801	.5729			.5544		.5359
24	.4268	.4801	.5544	.4268	.4572	.5544	.4572
Max	2.2862	2.7435	2.6006	2.5149	2.5833	2.3777	2.5139
Min	.4268	.4801	.4115	.4115	.4572	.5359	.4268
Avg	1.2422	1.1236	1.1925	1.1157	1.196	1.2797	1.1343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 203 / 11 KV KESKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1543	.1663	.1524	.1829	2.0885	1.89
2	.1219	.1543	.1478	.1524	.1829	.1848	.1219
3	.1219	.1543	.1478	.1524	.1829	.1848	.1219
4	.1219	.1543	.1478	.1524	.1829	.2033	.1219
5	.1524	.2058	.1848	.1829	.2134	.2218	.1524
6	.2286	.2572	.2402	.2286	.2134	.2587	
7					.1829	.2218	.1981
8					.1829	.2033	.1524
9					.1524	.1524	.1524
10		2.652	2.2558	2.2862			
11		2.7018	2.21				
12		2.6852	2.21				
13		2.6852					
15			2.332				
16		2.4863	2.1033		.1109	.1219	.1848
17		2.5194	.1829	2.4539	.1294	.1219	.1848
18		.2772	.1829	.1524	2.6023	2.1338	2.1879
19		.2957		.1981	2.2542		2.2874
20			.1524	.2134	2.6023		2.1216
21		.2402	.1524	.2134	2.652		
22		.1848	.1524	.1829	2.2708		1.8233
23	.1543	.1848	1.2193	.1829	2.2708		1.757
24	.1524	.1543	.1663	.1524	.1829	2.1879	1.9814
Max	.2286	2.7018	2.332	2.4539	2.652	2.1879	2.2874
Min	.1219	.1543	.1478	.1524	.1109	.1219	.1219
Avg	.1469	1.0082	.7975	.4704	.9307	.6373	.9650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 204 / 11 KV BHALWANIN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.4001	.3923	.4572	.5182	.3978	.4512
2	.4877	.4001	.3788	.4572	.5182	.3978	.4512
3	.4877	.4268	.3788	.4572	.5487	.3978	.4793
4	.5792	.6173	.4268	.5487	.6097	.4527	.5213
5	.7011	.6401	.5441	.6706	.7316	.6704	.5681
6	.8078	.6935	.6607	.8078	.8535	.6607	.6996
7	.6097	.6935	.57	.6401	.6706	.5571	.57
9	.4725	.4146	.4877	.503	.5335	.5182	.4664
10		.3201	.4268	.4115	.3155	.4268	.3734
11		.3292	1.1888	.3506	.306	.3506	.3704
12		.3338	.3658		.3338	.3353	.3429
13		.3199	.3353		.3384	.3353	.3429
14		.306	.3658		.2538	.3353	.3286
15		.3199	.3658		.2679	.3658	.3243
16		.3755	.3658	.3963	.2782	.3658	.3243
17		.4172	.3963		.4033	.3658	.3868
18		.4033	.5944		.3923		.5959
19		.6259	.7011	.6706	.5335		.6089
20		.5959	.7621	.7316	.6668		.6089
21		.5653	.6706	.6706	.5489		.5441
22		.4864	.6097	.6401	.4723		.5182
23	.4534	.4534	.5487	.5792	.4275		.4075
24	.4877	.4268	.4329	.4572	.5182	.4134	.4572
Max	.8078	.6935	1.1888	.8078	.8535	.6704	.6996
Min	.4534	.306	.3353	.3506	.2538	.3353	.3243
Avg	.5559	.4593	.5204	.5559	.4800	.4322	.4670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 206 / 11 KV GARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.462	.4572	.4572	2.2377	1.9814
2	.7621	.8573	.663	.7621	.4572	.462	.4572
3	.7621	.8573	.663	.7621	.4572	.462	.4572
4	.9145	1.0288	.7956	.9145	.4572	.5544	.4572
5	1.3717	1.5432	1.2431	1.0669	.6097	.7392	.6097
6	1.6766	1.8861	2.1548	1.6766	.6097	.8316	.6097
7	1.9814		2.3205	1.9814	.1524	.1663	.3048
8	1.829		2.0719	1.829	.1524	.1663	.1524
9	1.5242	1.6575	.9116	1.5242	.1524	.1372	.1524
10		2.7349	2.4387	2.2862	1.8233	1.829	1.6575
11		2.7349	2.2862			1.6766	1.4918
12		2.652	2.2862		1.5746	1.2193	1.326
13		2.5692	2.1338		1.5746	1.2193	1.1603
14					1.5746		
15					1.4089		
16		2.7349	2.2862	2.5911	1.5746	1.3717	1.8233
17		2.7349	2.4387	.3048	1.6575	1.3717	1.8233
18		.4251	.4572		2.9007		2.652
19		.5544	.6097	.6097	2.9007	1.829	2.652
20		.6468	.6097		2.7349		2.652
21		.6468	.6097	.4572	2.7349		2.4863
22		.5544	.4572	.4572	2.4034		2.1548
23	.3429	.5544	.4572	.4572	2.4034		1.989
24		.3429	.5175	.4572	.4744	2.3205	2.2862
Max	1.9814	2.7349	2.4387	2.5911	2.9007	2.3205	2.652
Min	.3048	.3429	.4572	.3048	.1524	.1372	.1524
Avg	1.1469	1.4029	1.3124	1.0938	1.3585	1.0938	1.4244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 201 / 11 KV SHELAVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	1.0631				
2	2.8292	3.0007	3.0864	3.0864	3.0007	3.0864	3.0007
3	2.8807	3.0864	3.0864	3.1722	3.0864		3.0864
4	2.915	3.0864	3.2579	3.2579	3.2579	3.0864	3.2579
5	2.915	3.0864	3.2579	3.3436	3.3436	3.2579	
6	3.1379	3.3436	3.4294	3.858	3.6008	3.2579	
7	4.0295	3.5151	3.6866	4.1152	4.1152	3.6866	
8	3.858	3.6008	3.858	3.6866	3.858	3.6008	3.5151
9	3.858	3.6008	3.6008	3.6008	3.7723	3.4294	4.1152
10	.1372						4.2867
11							3.9438
20	.8916	1.0631	1.0288				
21		1.0631					
22	.9431	1.0631					
23	.9431	1.0631					
24	.9431	.9431	1.0631				
Max	4.0295	3.6008	3.858	4.1152	4.1152	3.6866	4.2867
Min	.1372	.9431	1.0288	3.0864	3.0007	3.0864	3.0007
Avg	2.2303	2.3185	2.7653	3.5151	3.5044	3.3436	3.6008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 202 / 11 KV UPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1543	.1715	.1715
2	.1715	.1886	.2058	.1886	.1543	.1715	.1715
3	.1715	.1886	.2401	.1886	.1543	.1715	.1715
4	.1715	.2401	.2572	.2058	.1715	.1715	.2058
5	.1715	.2743	.2743		.2572	.1715	
12	2.2291	2.4006	1.9719	2.0576	2.3148	2.0576	2.2291
13	2.4006	2.4006	2.1262		2.4006	2.0576	2.2291
14	2.4006	2.4006	2.2291		2.332	2.1948	2.2291
15	2.3148	2.3148	2.1262		2.2805	2.0919	2.2291
16	2.2291	2.0576	2.0576		2.3663	2.2405	2.0576
17	2.0576	1.8861	1.9547		2.1776	2.0576	2.0576
18	2.0576	1.7147	1.8861		2.1434	2.0576	1.8861
19	1.989	1.5432	1.7147		2.0576	1.8861	.2286
20	.2058	.2058	.2401	.1715	.1715	.1715	.2286
21	.2058	.1715	.1715	.1715	.1715	.1715	
22	.1715	.1715	.1715	.1715	.1715	.1715	.2096
23	.1715	.1715	.1715	.1715	.1715	.1715	.1905
24	.1715	.1715	.1715	.1715	.1543	.1715	.1715
Max	2.4006	2.4006	2.2291	2.0576	2.4006	2.2405	2.2291
Min	.1715	.1715	.1715	.1715	.1543	.1715	.1715
Avg	1.0812	1.0374	1.0079	.3670	1.1003	1.0199	1.0417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 203 / 11 KV BHANDISHEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2058	.2058	.2572	.2058	.2058
2	.2572	.2401	.2401	.2229	.2572	.2058	.2058
3	.3086	.2743	.2572		.2572	.2229	.2058
4	.3258	.2915	.3086	.2743	.2572	.2743	.2058
5	.3429	.3258	.3429	.3086	.3086	.3601	
6					.3429		
12	3.0864	3.3436	3.3265	3.4122	3.9266	3.858	3.3608
13	3.5151	3.3436	3.5494		3.6008	3.738	3.858
14	3.4294	3.3436	3.6351		3.8752	3.9095	4.0295
15	3.5151	3.2579	3.6351		3.9952	3.8923	3.9438
16	3.5151	3.3436	3.6694		3.9952	3.8066	3.6008
17	3.4294	3.3436	3.1893		4.0124	3.7209	3.9438
18	3.4294	3.3436	3.3436		3.2407	3.6008	3.9438
19	3.275	3.3779	3.3093		3.5494	3.5151	3.6008
20	.3429	.3086	.3772	.2572	.3086	.3429	.2743
21	.2915	.2572	.2743	.3429	.2401	.2915	.3086
22	.2743	.2401	.2401	.3429	.2743	.2572	.2915
23	.2572	.2058	.2058	.2572	.2058	.2058	.2401
24	.2572	.2572	.2058	.2058	.2572	.2058	.2058
Max	3.5151	3.3779	3.6694	3.4122	4.0124	3.9095	4.0295
Min	.2572	.2058	.2058	.2058	.2058	.2058	.2058
Avg	1.6728	1.6299	1.6842	.5830	1.7454	1.8119	1.9073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 204 / 11 KV WADIKUROLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2058	.2058	.1715	.3429	.2058
2	2.915	2.7435	2.7435	2.915	3.0864	3.4294	3.0864
3	2.9664	2.8292	2.7435	2.915	3.1722	3.4294	3.2579
4	3.0007	3.0007	2.915	3.0864	3.2579	3.4294	3.5151
5	3.0007	3.0864		3.2579	3.4294	3.6008	
6	3.1722	3.4294		3.6008	3.6008		
7	3.6866	3.7723		3.858	3.7723	4.1152	
8	3.5151	3.5665		3.7723	3.858	3.6866	3.6008
9	3.3436	3.4637		3.7723	3.7723	3.4294	4.201
10							3.6866
11							3.6008
20	.2401	.2743	.2915	.2572	.3429	.3429	.2572
21	.2401	.2229	.2572	.2572	.3429	.3429	.2572
22	.2058	.2229	.2401	.2572	.3429	.3429	.2401
23	.2058	.2058	.2058	.1715	.3429	.3086	.2401
24	.2058	.2058	.2058	.2058	.1715	.3429	.3086
Max	3.6866	3.7723	2.915	3.858	3.858	4.1152	4.201
Min	.1715	.2058	.2058	.1715	.1715	.3086	.2058
Avg	1.9192	1.9449	1.0898	2.0380	2.1189	2.0879	2.0352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 205 / 11 KV BHANDISHEGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6173	.6173	.6173	.6344	.6516	.6173
2	.6173	.6001	.6173	.6173	.6173	.6344	.6173
3	.6173	.6001	.6516	.6516	.6516	.6173	.6516
4	.7202	.6516	.7545	.7373	.6859	.6859	.6859
5	.8402	.9259	.8916	.8916	.8573	.9602	
6	.9774	.9431	.9602		.9774	.9431	
7			.7545				
8			.6516				
9			.583				
10	.6859	.7202	.5316	.6687	.6344	.6516	.6859
11	.583	.6516	.4973	.6001	.5658	.5658	.6173
12	.5144	.5144		.4801	.4973	.5144	.5487
13	.5144	.5144	.4801	.463	.5316	.463	.5144
14	.4801	.5144	.4458	.463	.5144	.4287	.463
15	.5144	.5144	.4458	.4287	.5144	.4801	.5144
16	.5144	.5144	.4801	.5144	.5316	.4801	
17	.6001	.5316	.5316	.6001	.583	.5144	.5487
18	.6859	.5487	.6001	.6001	.6516	.7716	.6001
19	.8059	.7373	.7716	.7716	.7545	.823	.823
20	.8916	.8916	.8573	.7716	.9259	.9088	.9088
21	.7545	.7545	.7716	.8573	.8573	.8573	.8573
22	.703	.7202	.7202	.7716	.7545	.7716	.8059
23	.6859	.6859	.6859	.6859	.7202	.6516	.7202
24	.6516	.6516	.6516	.6516	.6344	.6859	.6344
Max	.9774	.9431	.9602	.8916	.9774	.9602	.9088
Min	.4801	.5144	.4458	.4287	.4973	.4287	.463
Avg	.6663	.6573	.6501	.6421	.6712	.6695	.6563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 207 / TEJUS AGRO EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3944	.3429	.2058	.2058	.2572
2	.3772	.4287	.4115	.3086	.1886	.2229	.2229
3	.3944	.4458	.4115	.2743	.1715	.2401	.2401
4	.3944	.4801	.4287	.2572	.2058	.2572	.2572
5	.3944	.5316	.4287	.1886	.2229	.2743	
6	.4973	.4287	.463	.3944	.2058	.2229	
7	.3944	.5144	.3258	.2229	.2229	.1715	
8	.3772	.4287	.3772	.2229	.2572	.2058	.0857
9	.3086	.3944	.3429	.1715	.3086	.4115	.1372
10	.4801	.4458	.3429	.1715	.2915	.4115	.2058
11	.4458	.5144	.3086	.2058	.3086	.4287	.2401
12	.5487	.4287	.2743	.1886	.4287	.2743	.2229
13	.4287	.3429	.3944	.2401	.2058	.2743	.2743
14	.4801	.3772	.4801	.2572	.2058	.2572	.3258
15	.4458	.3601	.3944	.2743	.2229	.3258	.2915
16	.4458	.4115	.3429	.2058	.2229	.2401	.2743
17	.4973	.3944	.3601	.1715	.2229	.1715	.3429
18	.5144	.3601	.3429	.1543	.1715	.1715	.3429
19	.4973	.4458	.4287	.2058	.1543	.2058	.4801
20	.4973	.463	.3429	.2572	.4115	.2058	.463
21	.4458	.4801	.4115	.2915	.2915	.2743	.4287
22	.4287	.4287	.3944	.2572	.2229	.2572	.4287
23	.3944	.4287	.3944	.2229	.2229	.2572	.3944
24	.3772	.3944	.4115	.3772	.2058	.2058	.2401
Max	.5487	.5316	.4801	.3944	.4287	.4287	.4801
Min	.3086	.3429	.2743	.1543	.1543	.1715	.0857
Avg	.4351	.4294	.3837	.2443	.2408	.2572	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 201 / 11 KV KALERAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.381	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	2.4387	2.1338	2.1338	2.1338
3	.3048	.3048	.3048	2.4387	2.1338	2.2862	2.2862
4	.3048	.3048	.3048	2.5911	2.2862	2.2862	2.2862
5				2.5911	2.4387	2.4387	2.4387
6				2.5911	2.5911	2.4387	2.4387
7				2.7435	2.8197	2.7435	
8				2.7435	2.8197	2.8959	
9				2.7435	2.7435	2.5911	2.5149
10				2.5911	2.5911	2.5911	2.5911
11							2.4387
12	2.7435	2.8197	2.7435				
13	2.7435	3.0483	2.8959				
14	2.8959	2.5911	2.8959				
15		2.8959					
16	2.8959	2.8959					
17	3.0483		3.0483				
18	3.0483	2.8959	2.7435				
19	2.4387	2.8959	2.4387	.4572	.6097	.6097	.3048
20	.5335	.3048	.3048	.4572	.6097	.6097	.3048
21	.381	.3048	.3048	.3048	.3048	.3048	.3048
22	.381	.3048	.3048	.3048	.3048	.3048	.3048
23	.381	.3048	.3048	.3048	.3048	.3048	.3048
24	.3048	.381	.3048	.3048	.3048	.3048	.3048
Max	3.0483	3.0483	3.0483	2.7435	2.8197	2.8959	2.5911
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	1.4384	1.4336	1.3006	1.6194	1.5813	1.5718	1.4175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 202 / 11 KV AMBE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0457	.0762	.0762	.0762
2	.381	.3048	.381	.0457	.0762	.0762	.0762
3	.381	.381	.381	.0457	.0762	.0762	.0762
4	.4572	.381	.381	.0457	.0762	.0762	.0762
5	.4572	.381	.4572				
6	.4572	.4572	.4572				
7	.4572	.4572	.4572				
8	.4572	.4572	.5335				
9	.381	.4572	.4572				
10	.381	.381	.4572				
12				.4572	.4572	.4572	.4572
13					.4572	.4572	.4572
14					.4572	.4572	.4572
15					.4572	.4572	
16					.4572	.4572	
17					.4572	.4572	.4572
18					.4572	.4572	.4572
19	.0762		.0457	.0762	.0762	.0762	.4572
20	.0762	.0762	.0457	.0762		.0762	.0762
21	.0762	.0762	.0457	.0762	.0762	.0762	.0762
22	.0762	.0762	.0457	.0762	.0762	.0762	.0762
23	.0762	.0762	.0457	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0457	.0762	.0762	.0762
Max	.4572	.4572	.5335	.4572	.4572	.4572	.4572
Min	.0762	.0762	.0457	.0457	.0762	.0762	.0762
Avg	.2715	.2743	.2715	.0970	.2429	.2331	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 203 / 11 Kv Ranzani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	1.5242	1.6766	1.829
2	.1524	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.1524	.1524		.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1524	.1524	.1524
10	2.4387	2.4387	2.5911				
11	2.7435	2.7435	2.5911				
12	2.7435	2.7435	2.4387				
13	2.4387	2.4387	2.2862				
14	2.2862	2.4387	2.5911				
15	2.2862	2.4387					
16	2.4387	2.4387					
17	2.5911	2.4387	2.4387				
18		.1219			2.7435	2.2862	2.8959
19	.1524	.1524	.1524		2.7435	2.2862	2.1338
20	.1524	.1524	.1524	2.1338	2.2862	2.2862	1.9814
21	.1524	.1524	.1524	2.4387	2.2862	2.2862	1.6766
22	.1524	.1524	.1524	2.4387	2.2862	2.2862	1.829
23	.1524	.1524	.1524	2.4387	1.829	1.829	1.6766
24	.1524	.1524	.1524	.1524	2.1338	1.829	1.829
Max	2.7435	2.7435	2.5911	2.4387	2.7435	2.2862	2.8959
Min	.1524	.1219	.1524	.1524	.1524	.1524	.1524
Avg	1.1939	1.1455	1.0288	1.2574	1.6627	1.5657	1.4826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 204 / 11 KV CHALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7621	.6097	.7621		.7621	.7621
2	.6097	.6859	.6097	.9145	.7621	.7621	.7621
3	.6097	.6859	.6097	.9145	.7621	.7621	.9145
4	.7621	.6859	.7621	1.0669	.8383	.7621	.7621
5	1.0669	.9907	.9145		.9145	.9907	.9145
6	.9145	.9145	.9145	1.0669	1.0669	1.0669	1.0669
9		.6859	.4572	.9145	.9907	1.0669	.4572
10	.6097	.6859	.5335	.6097	.9907	.4572	.4572
11	.6097	.6097	.4572	.4572	.6859	.4572	.4572
12	.7621	.6097	.7621	.4572	.6097	.4572	.4572
13	.9145	.6097	.9907	.4572	.6097	.4572	.6097
14		.6097	.9145	.4572	.6097	.4572	.6097
15	.5335	.6097	.5335	.4572	.6097	.4572	.6097
16		.6097	.5335	.4572	.6097	.4572	.6097
17		.6097	.6097	.4572	.6859	.4572	.7621
18		.6097	.9145	.6097	.6859	.4572	.7621
19	1.0669	.9145	.9145	1.0669	.9907	1.0669	1.0669
20	1.1431	.9145	.9145	1.0669	.9907	1.0669	1.0669
21	1.1431	.9145	.7621	.9145	.9145	.9145	1.0669
22	1.0669	.9145	.7621	.9145	.9145	.9145	1.0669
23	1.0669	.7621	.7621	.7621	.8383	.7621	1.0669
24	.6097	.7621	.6097	.7621	.7621	.7621	.7621
Max	1.1431	.9907	.9907	1.0669	1.0669	1.0669	1.0669
Min	.5335	.6097	.4572	.4572	.6097	.4572	.4572
Avg	.8293	.7344	.7205	.7403	.8020	.7170	.7759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 205 / 11 Kv Chale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	
2	2.1338	1.9814	2.1338	.3048	.3048	.3048	.3048
3	2.1338	2.1338	2.1338	.3048	.3048	.3048	.3048
4	2.2862	2.2862	2.1338	.3048	.3048	.3048	.3048
5	2.4387	2.1338	2.4387				
6	2.4387	2.4387	2.4387				
7	2.7435	2.4387	2.7435				
8	2.7435	2.5911	2.7435				
9			2.7435				
10				2.2862	1.9814	2.1338	2.2862
11					1.829	2.2862	2.2862
12					2.1338	2.5911	2.2862
13					2.2862	2.4387	2.2862
14					2.2862	2.4387	2.2862
15					2.2862	2.4387	
16					2.2862	2.2862	
17					2.1338	2.2862	2.4387
18		.3048					
19	.3048	.3048	.3048	.3048	.3048	.3048	.3048
20	.3048	.3048		.3048	.3048	.3048	.3048
21	.3048	.3048	.3048	.3048	.3048	.3048	.3048
22	.3048	.3048	.3048	.3048	.3048	.3048	.3048
23	.3048	.3048	.3048	.3048	.3048	.3048	.3048
24	.3048	.3048		.3048	.3048	.3048	.3048
Max	2.7435	2.5911	2.7435	2.2862	2.2862	2.5911	2.4387
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	1.3608	1.2295	1.6179	.4849	1.1262	1.2193	1.1075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 206 / 11 KV DARLING
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.9145	.7621	.0762	.0762	.0762
2	.0762	.0762	.0762	.7621	.4572	.6097	.6097
3	.0762	.0762	.0762	.7621	.4572	.6097	.6097
4	.0762	.0762	.0762	.6097	.6097	.6097	.6097
5				.6097	.6097	.9145	.9145
6				.6097	.7621	.9145	.9145
7				.7621	1.0669	1.2193	
8				.6097	1.0669	1.2193	
9				.7621	.9145	1.0669	1.0669
10					.9145		
18	.9145	.9145	1.2193				
19	.9145	1.3717	1.2193	.0762	.0762	.0762	.0762
20	1.2193	1.3717	1.2193	.0762	.0762	.0762	.0762
21	1.2193	1.2193	1.2193	.0762	.0762	.0762	.0762
22	1.2193	1.2193	1.0669	.0762	.0762	.0762	.0762
23	.9145	1.0669	.9145	.0762	.0762	.0762	.0762
24	.9145	.9145	.9145	.9145	.0762	.0762	.0762
Max	1.2193	1.3717	1.2193	.9145	1.0669	1.2193	1.0669
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.769	.8383	.8106	.5030	.4620	.5131	.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 201 / 11 KV KHARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.4458	.4115	.4973	.463	.4287	.2743
2	.884	1.2146	1.2955	.463	.463	.4287	.2743
3	.9755	1.2955	1.2955	.463	.4801	.4115	.2743
4	.9755	1.4089	1.6518	.463	.4801	.4287	.2743
5	.9755	1.749	1.7814	.4801	.5144	.4458	.2743
6	1.7985	2.5263	2.5263	.5144	.5316	.4458	
7	2.0424	2.8826	3.336				
8	2.1338	2.6235	3.3036				
9	2.21	2.4387	3.2388				
10	2.6235	2.4539	2.6397				
12				3.1093	3.2007	2.7892	3.4332
13					3.3836	2.713	3.3036
14					3.2922	2.6673	3.2712
16					3.0178	2.2405	
17					3.5951	2.5606	
18					3.2065	2.5911	3.1093
19					2.915	2.6216	3.3074
20	.5144	.5144	.5487	.5144	.5144	.3429	.3429
21	.5316	.5144	.5144	.5316	.5144	.3772	.3772
22	.5144	.5144	.5144	.4973	.4973	.3772	.3772
23	.5144	.4458	.5144	.4458	.4973	.3086	.3086
24		.4801	.4115	.5144	.4458	.2743	.2743
Max	2.6235	2.8826	3.336	3.1093	3.5951	2.7892	3.4332
Min	.2743	.4458	.4115	.4458	.4458	.2743	.2743
Avg	1.2120	1.4339	1.5989	.7078	1.5562	1.2474	1.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 202 / 11 KV BOHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4458	.4458	.4115	.3944	.4287	.4115
2	.463	.4287	.4287	1.6248	1.749	1.7652	1.3717
3	.463	.4458	.4115	1.7185	1.8785	1.9271	1.6766
4	.463	.4458	.4287	1.7185	2.1052	2.3482	1.6766
5	.463	.4801	.4458	1.9685	2.2996	2.6397	1.8861
6	.463	.4801	.4801	2.6368	3.1741	3.5303	2.4996
7				2.9569	3.0769	3.5789	2.753
8				3.0788	3.5627	3.4332	2.753
9				2.6978	3.2312	3.6599	2.753
10				2.753	3.0026	2.652	2.8349
12	2.915	3.2617	3.1741				
13	3.1741	3.1398	3.2388				
14	3.1093	2.9721	3.0769				
16	2.4129	3.2388					
17	3.336	3.417	3.3074				
18	3.4332	3.2226	2.332				
19	2.915	.8259	2.774				
20	.4973	.4458	.4458	.4801	.4801	.4115	.3429
21	.4458	.4115	.4115	.4458	.4801	.4458	.4458
22	.4801	.4287	.4115	.4458	.4287	.4115	.4458
23	.4458	.4287	.4115	.4115	.4287	.4115	.4458
24		.4458	.4115	.4115	.4115	.4115	.4458
Max	3.4332	3.417	3.3074	3.0788	3.5627	3.6599	2.8349
Min	.4458	.4115	.4115	.4115	.3944	.4115	.3429
Avg	1.5260	1.3869	1.3315	1.5840	1.7802	1.8703	1.5161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 203 / 11 KV T SHETPHAL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.1886	.2058	.2229	.1715
2	1.0669	1.2308	1.2146	.2058	.2058	.2229	.1715
3	1.2498	1.2955	1.2146	.2058	.2058	.2401	.1715
4	1.2498	1.4251	1.2955	.2058	.2743	.2572	.1715
5	1.2498	1.5546	1.5546	.2058	.2743	.2572	.1715
6	1.5242	1.6194	1.6842	.2401	.3429	.2229	.2058
7	1.6156	1.9433	1.5546				
8	1.6766	1.8785	1.4251				
9	1.8138	1.5851	1.3117				
10	1.8623	1.5242	1.4251				
12				1.8138	1.7497	1.4937	2.0081
13					1.8747	1.7985	2.0081
14					1.7497	1.8442	2.0729
16					1.6248	1.768	
17					1.8785	1.5242	
18					1.8138	1.768	1.829
19					1.4251	1.829	1.6766
20	.2058	.2743	.1886	.2743	.2058	.2743	.3086
21	.2743	.2401	.2058	.2743	.2229	.3086	.3429
22	.2743	.2401	.2058	.2743	.2229	.2401	.2743
23		.2229	.2058	.2058	.2229	.2058	.2058
24		.2058	.2229	.1886	.2058	.1715	.1715
Max	1.8623	1.9433	1.6842	1.8138	1.8785	1.8442	2.0729
Min	.2058	.2058	.1886	.1886	.2058	.1715	.1715
Avg	1.0976	1.0297	.9276	.3569	.8170	.8138	.7476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 204 / 11 KV KHARDI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.3429	.3429	.3429	.3086	.3086
2	.3086	.2743	.3601	.3429	.3772	.3258	.3086
3	.3086	.3258	.3601	.3429	.4287	.3601	.3086
4	.3086	.3772	.4115	.3772	.4973	.4287	.3086
5	.3429	.463	.4973	.4458	.5658	.4973	.4115
6	.4801	.5658	.6001	.6173	.6001	.5316	.5144
8	.4115	.4801	.4115	.4458	.463	.4115	.4115
9	.4115	.3772	.4287	.3772	.3772	.3429	.3086
10	.3601	.3772	.3944	.4287	.3772	.3086	.3429
11	.3258	.3429	.3772	.3086	.3601	.2743	.3086
12	.2915	.3429	.3429	.2915	.3429	.2743	.1715
13	.3086	.3086	.3429	.2743	.3258	.3086	.1886
14	.3086	.2743	.3258		.3601	.3086	.2915
15	.2743	.2058	.3086		.2743	.3086	.2743
16	.2572	.2743			.2743	.3086	.3086
17	.3429	.3772	.3601		.2915	.3086	
18	.4115	.4115	.3772	.3944	.3086	.3429	.3429
19	.5316	.5487	.463	.5316	.4801		.4115
20	.5658	.6001	.5487	.5658	.4973	.4458	.4458
21	.4287	.463	.5144	.4801	.463	.4458	.4458
22	.3772	.463	.4801	.4287	.3944	.3772	.4115
23	.3429	.4115	.4458	.3601	.3086	.3086	.3429
24		.3086	.3772	.3772	.3429	.3086	.3086
Max	.5658	.6001	.6001	.6173	.6001	.5316	.5144
Min	.2572	.2058	.3086	.2743	.2743	.2743	.1715
Avg	.3640	.3854	.4123	.407	.3936	.3562	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 205 / 11KV Umbargaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4801	.5144	.4287	.4458	.4458	.3772
2	.3772	.4458	.5144	1.8278	1.166	1.2955	1.7985
3	.3772	.4458	.4973	1.8747	1.2955	1.5546	1.9814
4	.3772	.4801	.5316	1.8747	1.5546	2.332	1.9814
5	.3772	.5144	.5316	2.0729	2.1376	2.2024	1.9814
6	.3772	.5316	.5487	2.5606	2.7206	2.9797	3.2465
7				2.5911		3.255	3.4494
8				3.0483	2.6558	2.753	3.4656
9				3.0178	3.4008	2.9797	3.4656
10				2.7206	2.5606	2.7435	3.1741
12	2.5911	3.2769	3.2712				
13	3.1093	2.9264	3.2388				
14	3.2388	2.8654	3.1741				
16	1.9433	3.2226					
17	3.2388	2.834	2.4387				
18	3.1741	1.8138	2.4387				
19	3.0445	2.8502	2.3167				
20	.4858	.463	.463	.4801	.5487	.3772	.4458
21	.5487	.5144	.4458	.5144	.5316	.3772	.4115
22	.5487	.5144	.4458	.4801	.5487	.3772	.3772
23	.5144	.5144	.4458	.463	.5144	.3772	.3944
24		.5144	.5144	.4287	.4458	.3772	.3772
Max	3.2388	3.2769	3.2712	3.0483	3.4008	3.255	3.4656
Min	.3772	.4458	.4458	.4287	.4458	.3772	.3772
Avg	1.4530	1.4004	1.3136	1.6256	1.4662	1.6285	1.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 206 / 11KV Kasegaon (BEND WASTI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1543	.2229	.2229	.1543	.2229	.2058
2	.7316	.9717	.8097	.2229	.1543	.2229	.2058
3	.823	.9393	.8097	.2229	.1715	.2401	.2058
4	.823	.9393	.8907	.2229	.1886	.2743	.2058
5	.823	1.004	.9717	.2401	.2229	.2401	.2743
6	1.2193	1.0688	1.5546	.2572	.2229	.2401	.3086
7	1.2803	1.1336	1.5546				
8	1.3413	1.0688	1.5546				
9	1.5546	1.0364					
10	1.2955	1.2955	1.3603				
12				1.4575	1.2498	1.4022	1.3117
13					1.2811	1.3717	1.4575
14					1.3123	1.3413	1.4575
16					1.3279	1.2193	
17					1.3765	1.1584	
18						1.0974	1.0974
19					1.2146	1.0669	1.0822
20	.1715	.2572	.2058	.1886	.2743	.3086	.3086
21	.1886	.2401	.2401	.1886	.2743	.3086	.3086
22	.1886	.2401	.2401	.1886	.2743	.2743	.2743
23	.1715	.2401	.2401	.1715	.2401	.2058	.2401
24		.1715	.2229	.2229	.1715	.2058	.2058
Max	1.5546	1.2955	1.5546	1.4575	1.3765	1.4022	1.4575
Min	.1715	.1543	.2058	.1715	.1543	.2058	.2058
Avg	.7751	.7174	.7770	.3172	.5948	.6334	.5719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 201 / Tisangi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715	.1715
2	.5144	.6859	.5144	.1715	.1715	.1715	.1715
3	.6001	.7716	.6859	.1715	.1715	.1715	.1867
4	.6859	.7716	.6859	.1715	.1715	.1715	.1715
5	.6859	.7716	.8573	.1715	.1715	.1715	.1715
6	.7621	.8573	1.1145	.1715	.2572	.1715	.1715
7	.8573	.9431	1.0288				
8	.9431	.9431	1.0288				
9	.9431	.8573	.8573				
10	.9431	.8573	.7716	.1715	.0857	.1715	.0857
11	1.0288	.7716	.7716	.1715	.0857	.1715	.0857
12				.9431	1.0898	1.0059	.9431
13					1.0898	.9221	.9431
14					1.0898	.8383	.7716
15					1.0898	.8383	.7716
16	.1715	.1715	.0857		.9221	.8383	.9431
17	.1715	.1715	.0857		.9221	.9221	.9431
18	.1715	.1715	.0857		1.0898	.9116	.9431
19	.2572	.1715	.1715	.1715	1.0898	.8383	.9431
20	.2572	.1715	.1715	.1715	.1715	.1715	.1715
21	.2572	.1715	.1715	.1715	.1715	.1715	.1715
22	.2572	.1715	.1715	.1524	.1715	.1715	.1715
23	.1715	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	1.0288	.9431	1.1145	.9431	1.0898	1.0059	.9431
Min	.1715	.1715	.0857	.1524	.0857	.1715	.0857
Avg	.5011	.4973	.4887	.2217	.5013	.4450	.4417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 202 / 11 KV SONAKE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715	.1715
2	1.0288	1.4575	1.3717	.1715	.1715	.1715	.1715
3	1.2003	1.5432	1.5432	.1715	.1715	.1715	.1715
4	1.5432	1.5432	1.7147	.1715	.1715	.1715	.1715
5	1.8861	1.7147	1.8861	.1715	.1715	.1715	.1715
6	2.572	2.0576	2.2291	.1715	.1715	.1715	.1715
7	2.7435	2.6578	2.572				
8	2.8292	2.7435	2.572				
9	2.2291	2.572	2.4863				
10	2.3148	2.4006	2.3148	.1715	.1715	.1715	.1715
11	2.3148	2.0576	2.0576	.1715	.1715		
12	.1715			2.2291	2.1795	2.3472	2.3148
13	.1715				2.4863	2.4863	2.4006
14	.1715				2.4863	2.4863	2.4006
15	.1715				2.4034	2.4863	2.3148
16	.1715	.1715	.1715		2.4034	2.3205	2.3148
17	.1715	.1715	.1715		2.3205	2.1548	2.3148
18	.1715	.1715	.1715		2.2377	2.1795	2.2291
19	.1715	.1715	.1715	.1715	2.1795	2.3472	2.0576
20	.1715	.1715	.1715	.1715	.1715	.1715	.1715
21	.1715	.1715	.1715	.1715	.1715	.1715	.1715
22	.1715	.1715	.1715	.1715	.1715	.1715	.1715
23	.1867	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	2.8292	2.7435	2.572	2.2291	2.4863	2.4863	2.4006
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.9616	1.1231	1.1231	.3087	.9965	1.0433	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 203 / 11 KV KORTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.2572	.2572	.1715
2	.1715	.1715	.1715	.5144	1.2003	1.3413	1.0288
3	.1715	.1715	.1715	.6001	1.2574	1.4251	1.2003
4	.1715	.1715	.1715	.9431	1.3413	1.5927	1.3717
5	.1715	.2572	.1715	1.4575	1.5432	1.8442	1.5432
6	.2572	.2572	.2572	1.8004	1.7404	1.8233	1.7147
7				1.9719	2.3205	2.3205	2.2291
8				2.0576	2.1548	2.5692	1.8861
9				2.0576	1.989	1.2431	1.8861
10	.1715	.1715	.1715	1.9719	1.989	1.6575	1.8861
11	.1715	.1715	.1715	1.8004	1.989	1.6575	1.8861
12	2.4006	2.572	2.572				
13	2.4863	2.4006	2.572				
14	2.4006	2.2291	2.572				
15	2.3148	1.8861	2.4006				
16	2.0576	2.0576	2.3148		.1715	.1715	.1715
17	2.0576	2.2291	2.4863		.1715	.2572	.1715
18	2.0576	2.0576	2.4863		.1715	.2572	.1715
19	2.3148	1.7147	2.3148	.2572	.1715	.2572	.1715
20	.3429	.2572	.2572	.2572	.2572	.2572	.2572
21	.3429	.2572	.2572	.2572	.2572	.2572	.2572
22	.3429	.1715	.2572	.2572	.2572	.2572	.2572
23	.2572	.1715	.1715	.2572	.2572	.2572	.2572
24	.1715	.1715	.1715	.1715	.2572	.2572	.2572
Max	2.4863	2.572	2.572	2.0576	2.3205	2.5692	2.2291
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	1.0002	.9390	1.0615	.9885	.9877	.9980	.9388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 204 / GADEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.3429	.1715	.3429	.2572	.2572
2	.2572		.2572	.7716	1.0898	1.0898	1.2003
3	.1715		.2572	.9431	1.1736	1.0774	1.3717
4	.1715		.2572	1.1145	1.3413	1.326	1.5432
5	.1715		.2572	1.3717	1.4918	1.5746	1.7147
6	.2572		.3429	1.5432	1.8233	1.6575	1.8861
7				1.8004	2.3205	1.9062	2.2291
8				1.8861	2.1548	1.989	2.0576
9				1.7147	2.0576	1.8233	2.0576
10	.1715		.1715	1.7147	1.8233	1.6575	1.7147
11	.1715		.1715	1.286	1.7404	1.4918	1.6289
12	2.1434		1.8861				
13	2.2291		2.0576				
14	2.0576		1.9719				
15	1.8861	2.2291	1.8861				
16	1.8861	2.2291	1.7147		.1715	.1715	.2572
17	1.8861	2.0576	1.8861		.1715	.1715	.2572
18	1.8004		1.9719		.1715	.1715	.2572
19	1.7147	1.7147	.1715	.3429	.2572	.2572	.2572
20	.3429	.4668	.2572	.3429	.2572	.2572	.3429
21	.3429	.4287	.1715	.3429	.2572	.3429	.3429
22	.3429	.3429	.1715	.3429	.2572	.2572	.2572
23	.2572	.3429	.1715	.3429	.2572	.2572	.2572
24	.2286	.2572	.3429	.1715	.3429	.2572	.2572
Max	2.2291	2.2291	2.0576	1.8861	2.3205	1.989	2.2291
Min	.1715	.2572	.1715	.1715	.1715	.1715	.2572
Avg	.8927	1.0326	.7961	.9531	.9751	.8997	1.0074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 205 / Gaothan No.1 Takali-
Gadegaon Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.2572	.1715	.0857	.1715	.1715
2	.1715	.1715	.2572	.1715	.0857	.1715	.1715
3	.1715	.1715	.2572	.1715	.1715	.1715	.1715
4	.1715	.1715	.2572	.0857	.2572	.1715	.2572
5	.2572	.2572	.2572	.1715	.3429	.1715	.2572
6	.2572	.2572	.3429	.1715	.3429	.2572	.3734
7	.2572	.2572	.3429	.1715	.3429	.2572	.3429
8	.1715	.1715	.3429	.1715	.2572	.2572	.2572
9	.1715	.1715	.1715	.1715	.1715	.1715	.1715
10	.1715	.2572	.1715	.1715	.1715	.1715	.1715
11	.1715	.1715	.1715	.1715	.1715	.1715	.1715
12	.1715	.1715	.1715	.1715	.1715	.1715	.1715
13	.1715	.1715	.1715	.1715	.1715	.1715	.1715
14	.1715	.1715	.1715	.0857	.0857	.1715	.1715
15	.1715	.1715	.1715	.0857	.0857	.1715	.1715
16	.1715	.1715	.1715	.1715	.0857	.1715	.1715
17	.1715	3.6008	.1715	.1715	.1715	.1715	.1715
18	.1715	.1715	.1715	.1715	.1715	.2572	.1715
19	.2572	.1715	.2572	.2572	.1715	.3429	.1715
20	.2572	.2572	.2572	.2572	.2572	.3429	.2572
21	.3429	.2572	.1715	.2572	.1715	.2572	.2572
22	.3429	.1715	.1715	.1715	.1715	.1715	.2572
23	.2572	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.0857	.0857	.1715
Max	.3429	3.6008	.3429	.2572	.3429	.3429	.3734
Min	.1524	.1715	.1715	.0857	.0857	.0857	.1715
Avg	.2064	.3358	.2179	.1715	.1822	.2001	.2085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 206 / 11KV Navale College
Express Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.0857	.0857
2	.0857	.0857	.0857	.0857	.0857	.0857	.0857
3	.0857	.0857	.0857	.0857	.0857	.0857	.0857
4	.0857	.0857	.0857	.0857	.0857	.0857	.0857
5	.0857	.0857	.0857	.0857	.0857	.0857	.0857
6	.0762	.0857	.0857	.0857	.0857	.0857	.0857
7	.0857	.0857	.0857	.0857	.0857	.0857	.0857
8	.0857	.0857	.0857	.0857	.0857	.0857	.0857
9	.0857	.0857	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	.0857	.0857	.0857
11	.0857	.0857	.0857	.0857	.0857	.0857	.0857
12	.0857	.0857	.0857	.0857	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857	.0857	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857	.0857	.0857	.0857	.0857
18	.0857	.0857	.0857	.0857	.0857	.0857	.0857
19	.0857	.0857	.0857	.0857	.0857	.0857	.0857
20	.0857	.0857	.0857	.0857	.0857	.0857	.0857
21	.0857	.0857	.0857	.0857	.0857	.0857	.0857
22	.0857	.0857	.0857	.0857	.0857	.0857	.0857
23	.0857	.0857	.0857	.0857	.0857	.0857	.0857
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0762	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0853	.0857	.0857	.0857	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 207 / Gaothan No.2 Sonke-Tisangi
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2572	.2572	.2572	.2572	.2572
2	.2572	.1715	.2572	.2572	.2572	.2572	.2572
3	.2286	.1715	.2572	.2572	.2572	.2572	.2572
4	.2572	.1715	.2572	.2572	.2572	.2572	.2572
5	.2572	.2572	.2572	.2572	.3429	.2572	.3429
6	.3429	.3429	.3429	.3429	.3429	.3429	.3429
7	.3429		.3429	.3429	.3429	.3429	.3429
8	.2572	.2572	.2572	.3429	.3429	.3429	.2572
9	.2572	.2572	.2572	.2572	.3429	.2572	.2572
10	.2286	.1715	.1715	.2572	.2572	.2572	.2572
11	.2572	.1715	.1715	.2572	.1715		.2572
12	.2572	.1715	.1715	.3429	.2572	.1715	.2572
13	.2572	.1715	.1715	.4287	.2572	.1715	.2572
14	.2572	.1715	.1715	.4287	.2572	.2572	.2572
15	.2572	.1715	.1715	.4287	.2572	.2572	.2572
16	.2572	.1715	.1715	.4287	.2572	.2572	.2572
17	.2572	.1715	.1715	.4287	.2572	.2572	.2572
18	.2572	.1715	.1715	.4287	.2572	.2572	.2572
19	.3429	.2572	.1715	.4287	.2572	.3429	.2572
20	.3429	.2401	.3429	.4287	.3429	.3429	.3429
21	.3429	.2572	.3429	.4287	.3429	.3429	.3429
22	.2286	.2572	.3429	.3429	.3429	.2572	.2572
23	.1715	.2572	.2572	.2572	.2572	.2572	.2572
24	.2572	.1715	.2572	.2572	.2572	.2572	.2572
Max	.3429	.3429	.3429	.4287	.3429	.3429	.3429
Min	.1715	.1715	.1715	.2572	.1715	.1715	.2572
Avg	.2643	.2080	.2393	.3394	.2822	.2721	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 201 / 11 KV ANAWALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2641	.1886	.2401	.2401	.2058	.2058
2	1.3717	.3018	.1886	.2401	.2401	.2058	.2401
3	1.5432	.3018	.1886	.2401	.2572	.2058	.2401
4	1.7147	.3395	.1886	.2743	.2572	.2058	.3086
5	1.8861	.3395	.1886	.2743	.2743	.2058	.3429
6	2.0576	.3395	.1886	.2743	.2743	.2058	.4287
7	2.3148	.3395	.1886	.3086	.2743	.2058	
8	2.4006						
9	2.4006	.2829				.1715	
10	2.4006	.2829	.2263	.1715	.2058		
11	.1715	.2263	.2263	.1715	.2401		
12	.1886	2.452	2.6406	1.8861	2.2291	2.4006	
13	.2058	2.452	2.7349		2.572	2.4006	2.4006
14	.2058	2.2634	2.4863		2.4006	2.4006	2.572
15	.2401						2.4006
16	.2058	2.6406	2.4006	.1715	2.4006	2.4006	2.4006
17	.2641	2.6406	1.7147	.1715	2.4006	2.3148	2.572
18	.2641	2.6406	2.0576	.1715	2.4006	2.3148	2.4006
19	.2641	2.6406	2.2291	.2743	2.4006	2.2291	2.4006
20	.3018	.2263	.2572	.3086	.2058	.3429	.3772
21	.3018	.2263	.2572	.2743	.1715	.4115	.4458
22	.3018	.2263	.2401	.2743	.1715	.3429	.4115
23	.2641	.2263	.2401	.2401	.1715	.3086	.3429
24	.2743	.2641	.2263	.2401	.2401	.2401	.2401
Max	2.4006	2.6406	2.7349	1.8861	2.572	2.4006	2.572
Min	.1715	.2263	.1886	.1715	.1715	.1715	.2058
Avg	.9112	.9962	.9170	.3267	.9537	.9860	1.1517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 202 / 11 KV TAWASHI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3018	.3772	.2743		.3086	.2743
2	.2743	2.2634	1.8861	2.4006	1.8861	2.0576	2.2291
3	.2743	2.2634	1.8861	2.7435	2.0576	2.0576	2.4006
4	.2915	2.6406	2.2634	3.4294	2.0576	2.4006	2.4863
5	.3086	3.0178	2.6406	3.4294	2.4006	2.7435	2.572
6	.3086	3.7723	3.3951	3.0864	2.6578	3.0864	2.7435
7		3.3951	3.9609	3.0864	3.0007	3.2579	2.915
8		3.3951	3.7723	3.0864	2.7435	3.2579	3.0864
9		3.3951	4.1495	3.0864	2.7435	3.2579	3.1722
10		3.2065	4.1495	2.2291	2.7435	3.2579	3.1722
11		.2263	.1886		.2058	.1715	
12	3.2579	.2075			.2058		
13	3.1722	.2263				.0857	.1029
14	3.3436	.2263					
15		.2263					
16	3.4294	.2263	.1715				
17	4.1495	.2641	.1715				
18	4.3381			.3086			.2058
19	3.9609			.3429			.3086
20	.3772	.3772	.3429	.3772	.3772	.3086	.3086
21	.3395	.3772	.3944	.3429	.3429	.3601	.3429
22	.3772	.4338	.3429	.3429	.3429	.3429	.3086
23	.3395	.3584		.3429	.3429	.3429	.2743
24	.3086	.3395	.3772	.3429	.3086	.3429	.2743
Max	4.3381	3.7723	4.1495	3.4294	3.0007	3.2579	3.1722
Min	.2743	.2075	.1715	.2743	.2058	.0857	.1029
Avg	1.6190	1.4155	1.7923	1.7207	1.5261	1.6259	1.5099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 203 / 11 KV ANAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9431	.9431	.8573	.8573	.8573	.8573
2	.8573	1.1317	1.0374	.8573	.8573	.8573	.8573
3	.8573	1.1317	1.0374	1.0288	1.0288	.8573	.8573
4	1.0288	1.3203	.9431	1.0288	1.0288	.8573	.9431
5	1.0288	1.3203	1.0374	1.286	1.2003	.8573	1.0288
6	1.2003	1.3203	1.1317	1.2003	1.2003	1.0288	1.2003
7							1.0288
8	.8573	1.1317	1.1317	.9431	1.0288	.8573	.9431
9	.8573	.9431	.9431	.8573	.8573	.8573	.8573
10	.4287	.9431	.7545	.8573	.7716	.6859	.8573
11	.8573	.9431	.7545	.8573	.6859	.6859	
12	.6859	.9431	.9431	.8573	.6859	.8573	
13	.6859	.9431	.9431	.8573	.6001	.8573	.8573
14	.6859	.9431	.8573	.8573	.6859	.8573	.7716
15	.6859	.9431	.8573	.8573	.6859		.8573
16	.6859	.9431	.6859	.8573	.6859	.7716	.8573
17	.7545	.9431	.5144	.8573	.8573	.7716	.8573
18	.9431	.9431	.8573	.8573	.9431	.8573	.9431
19	.9431	1.1317	1.2003	.8573	1.0288	.8573	1.0288
20	.9431	1.3203	1.0288	1.0288	1.2003	1.1145	1.1145
21	.9431	1.1317	1.0288	1.0288	1.0288	1.2003	1.2003
22	1.1317	.9431	.8573	1.0288	.8573	1.0288	1.0288
23	.9431	.9431	.8573	.8573	.8573	.9431	.9431
24	.8573	.9431	.9431	.8573	.8573	.8573	.8573
Max	1.2003	1.3203	1.2003	1.286	1.2003	1.2003	1.2003
Min	.4287	.9431	.5144	.8573	.6001	.6859	.7716
Avg	.8573	1.0497	.9256	.9319	.8909	.8807	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 204 / Shirgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2641	.2075	.1715	.2401	.1715	.1715
2	.8573	.2641	.2075	.1715	.2743	.1715	.1715
3	.8573	.2641	.2075	.1715	.2743	.1715	.1715
4	.9431	.3395	.2075	.2401	.2743	.1715	.2401
5	1.0288	.3395	.2075	.2401	.2743	.1715	.2743
6	1.2003	.3018		.2401	.2743	.1715	.3086
7	1.286	.2641	.2075	.2743	.2743	.2058	
8	1.3717						
9	1.3717						
10	1.3717						
11		.1886	.1886				
12		1.5089	1.5089	1.3717	1.2003	1.3717	
13		1.5089	1.5089		1.5432	1.3717	1.3717
14		1.3203	1.3717		1.3717		1.3717
15	.2058						1.3717
16	.2058	1.5089	1.2003		1.3717	.8573	1.3717
17	.2561	1.5089	.8573		1.3717	1.4575	1.5432
18	.2641	1.5089	1.0288	.2572	1.3717	1.3717	1.3717
19	.3018	1.5089	1.2003	.3086	1.3717	1.2003	1.2003
20	.3395	.2829	.2572	.3086	.2572	.2401	.2058
21	.3395	.2829	.2572	.2743	.2058	.3258	.3086
22	.3772	.2829	.2401	.2743	.2058		.2743
23	.3395	.2829	.2229	.2743	.2058	.2058	.2743
24	.3086	.3018	.2829	.2229	.2401	.2058	.1715
Max	1.3717	1.5089	1.5089	1.3717	1.5432	1.4575	1.5432
Min	.2058	.1886	.1886	.1715	.2058	.1715	.1715
Avg	.6767	.7016	.5984	.3201	.6633	.5790	.6763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 205 / VITHURAYA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.132	.1543	.1372	.1372	.1372
2	1.7147	.1886	.1509	.1543	.1372	.1372	.1372
3	2.0576	.1886	.1509	.1543	.1372	.1372	.1372
4	2.2291	.1509	.1509	.1543	.1372	.1372	.1543
5	2.4006	.1698	.1509	.1543	.1715	.1372	.1715
6	2.5206	.1698	.1886	.1543	.1715	.1715	.1886
7	2.5034		.1886	.1886	.2058	.1886	.1886
8	2.4691	.2075	.1886	.1886	.2058		
9	2.4691	.132	.1886	.1886	.1886		
10	.1372	3.2065	3.2065	2.4006	2.4006	2.1605	2.0576
11	.1509	3.2065	3.2065		2.572	2.572	
12	.1132	3.2065	3.1121			2.7435	
13	.1132	3.0178	3.0178		2.915	2.7435	2.6578
14	.1132	3.1121	2.7435		2.915	2.7435	2.8292
15	.1509	3.0178	2.572		2.7435		2.572
16	.1132	3.2065	2.572		2.572	2.572	2.4006
17	.0943	3.2065	2.572		2.572	2.572	1.9719
18	.1132	.2263	.1886	.1029	.2058	.1715	.0857
19	.1886	.3018	.1886	.12	.1715	.1886	.1372
20	.1886	.2263	.1886	.1543	.1715	.1886	.1372
21	.2075	.2263	.1886	.1715	.1715	.2058	.1543
22	.2263	.2263	.1715	.1715	.1715	.1715	.1372
23	.1886	.1886	.1715	.1715	.1715	.1543	.1372
24	.1698	.1886	.1886	.1543	.1372	.1715	.1372
Max	2.5206	3.2065	3.2065	2.4006	2.915	2.7435	2.8292
Min	.0943	.132	.132	.1029	.1372	.1372	.0857
Avg	.8669	1.2244	1.0741	.2905	.9297	.9717	.8265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 206 / SIDDHANATH
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1886	1.5089	1.2003	1.3717	1.286	1.0802
2	.2263	.2452	.2195	.1715	.1372	.2058	.1543
3	.2263	.2263	.2263	.1715	.1372	.2058	.1715
4	.2263	.2641	.2263	.1715	.1715	.2058	.1715
5	.2452	.2641	.2263	.2058	.1715	.2058	.1715
6	.2641	.2641	.2263		.1715	.2058	.1886
7	.2452	.2641	.2263	.2058	.2229	.2401	.1886
8	.2075	.2641	.2641	.2401	.2229	.2401	.1715
9	.2075	.2641	.2263	.2058	.1886	.2401	.1715
10	1.8861	.2641	.2829	.1886	.2229	.2915	.1715
11	2.0748	.2452	.2829	.1886	.2229	.2572	
12	2.1033	.2263	.2829		.2229	.1886	
13	1.829	.2263	.1886		.2229	.1886	.1715
14	1.6975	.2263	.2058		.2229	.1715	.1886
15	1.6975	.2263	.2058		.2229		.2058
16	1.7918	.1886	.12		.2229	.1715	.2058
17	1.6975	.2075	.12		.2229	.1715	.2058
18	.132	1.8861	1.7147	1.8861	1.8861	1.7147	1.8861
19	.1509	2.0748	1.8861	.3429	1.7147	1.7147	1.7147
20	.1886	1.8861	1.5432	1.2003	1.6289	1.4575	1.7147
21	.1886	1.8861	1.4575	1.2003	1.6289	1.286	1.5432
22	.2075	1.6032	1.2003	1.2003	1.3717	1.2346	1.5432
23	.2075	1.5089	1.2003	1.2003	1.3717	1.2003	1.286
24	.2641	.1886	1.5089	1.2003	1.2003	1.3717	1.166
Max	2.1033	2.0748	1.8861	1.8861	1.8861	1.7147	1.8861
Min	.132	.1886	.12	.1715	.1372	.1715	.1543
Avg	.7580	.6287	.6479	.6576	.6409	.6285	.6578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 207 / MAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	2.6406	.1886	.2401	.3086	.1715	.1886
2	.1886	2.6406	2.0748	1.8861	1.8861	1.7147	2.4006
3	.2263	2.6406	2.2634	2.2291	2.0576	2.0576	2.4863
4	.2641	2.6406	2.2634	2.572	2.572	2.2291	2.572
5	.3018	2.6406	2.452	2.572	2.7435	2.2291	2.7435
6	.3018	2.6406	2.8292	2.7435	3.0864	2.572	2.915
7	.3018	2.6406	2.9235	3.0007	3.0864	2.7435	2.9835
8	.3018	2.6406	3.0178	2.915	2.7435	2.7435	3.0178
9	.2829	2.6406	3.0178	2.915	2.4006	2.7435	3.0864
10	.2452	.1886	.2452	.1715	.2401	.1543	.2401
11		.1886	.2829		.2401	.1543	
12		.2829	.2452		.2401	.2058	
13		.2641	.2075		.2401	.2058	.2401
14		.2641	.1886		.2401	.2058	.2229
15	.1886	.2452	.2058		.2401		.2572
16	.2263	.3018	.2743		.2401	.1715	.2572
17	.2641	.2641	.2743		.2572	.2058	.2572
18	3.1121	.3018	.2743		.2572	.2058	.3086
19	3.0178	.3018	.2915	.2743	.2572	.3429	.3086
20	2.8292	.2829	.2915	.3086	.2572	.3429	.3429
21	2.6406	.2075	.2058	.3086	.2572	.3086	.3601
22	2.6406	.2075	.2401	.2743	.2572	.2743	.3086
23	2.6406	.1886	.2401	.2743	.2572	.2401	.3086
24	2.6406	2.6406	.1886	.2401	.2743	.2572	.1886
Max	3.1121	2.6406	3.0178	3.0007	3.0864	2.7435	3.0864
Min	.1886	.1886	.1886	.1715	.2401	.1543	.1886
Avg	1.2628	1.2456	1.0286	1.4328	1.0267	.9774	1.1816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 201 / WAKHARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.8573	.8573	1.9814	2.4082	2.5301	
2	.4268	.8573	.823	1.9814	2.3777	2.4996	2.7435
3	.4268	.8573	.7545	1.9814	2.3472	2.4387	2.7435
4	.3963	.8573	.6859	2.0119	2.3472		2.7435
5	.3963	.8916	.7888	2.0119	2.3472	2.5301	2.7435
6	.3963	.8916	.5487	2.0119	2.3472	2.5301	2.7435
7	.5182	.5144	.5487	.5144	.5487	.583	.583
8	.4877	.4458	.4115	.4115	.5487	.6173	.4115
9	.4115	.3429	.3086	.4115	.4458	.4115	.3772
10	.4458	.5144	.5144	.6173	.4115	.5121	.3429
11	.4801	.4458	.4801	.6173	.4458	.5487	.3429
12	.4801	.4115	.4801	.5144	.4458	.4755	.3772
13	.4458	.3772	.3772	.4115	.3772	.3658	.3429
14	.3772	.3429	.3429		.3429	.3658	.3772
15	2.4387	2.4691	2.1643		.5487	.5487	.4458
16	2.5301	2.2862	2.1643		.6173	.3429	
17	2.5911	2.6825	2.1643		.6516	.3429	.4801
18	2.652	2.6216	1.7375	.5144	.5487	.4458	.4801
19	2.4387	2.6825	2.2862	.6173	.9259	1.0242	.4801
20	2.1643	2.652	2.2862	.9259	1.1317	.5487	.4458
21	2.1643	2.5301	2.3167	.9945	1.0631	.5487	.5144
22	2.1338	2.4082	2.3167	.9259	.9602	.4877	.5144
23	.823	.8573	2.1643	2.3167	2.5606	2.4387	2.4387
24	.5121	.8573	.7545	1.9814	2.4082	2.4387	2.7435
Max	2.652	2.6825	2.3167	2.3167	2.5606	2.5301	2.7435
Min	.3772	.3429	.3086	.4115	.3429	.3429	.3429
Avg	1.1068	1.2773	1.1782	1.1877	1.2149	1.1120	1.1552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 202 / KHED BHALWANI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3086	.3086	2.4691	3.9323	3.5056	.9145
2	.2401	.2743	.3772	2.4691	3.8714	3.3836	.9145
3	.2561	.2743	.2743	2.4691	3.658	3.4141	.9145
4	.2401	.2743	.2401	2.4691	3.5361	3.3532	.9145
5	.2926	.3429	.3429	2.4691	3.3532	3.4751	.945
6	.2926	.3429	.3086	2.4691	3.1398	3.3227	.945
7		.0343		.0686	.3086	.2743	.1829
8				.2058	.3086	.3429	.2134
9		.0343		.2058	.3429	.3429	.2743
10				.2401		.3086	.2743
11				.2401		.2439	.2401
12						.2743	.2058
13					.2058	.2401	.2058
14					.2058	.2401	.1715
15	3.8714	3.3836	3.3532				
16	3.9323	3.719	3.3532				
17		3.6275	3.3532				
18		3.5665	3.1093				
19	3.9628	3.597	3.2007				
20	3.9323	3.4141	3.4446	.3429	.2058	.2561	.3429
21	3.7799	3.2617	3.0788	.3772	.2401	.2058	.1715
22	3.4751	3.4141	3.0788	.1715	.2058	.2058	.1029
23	.3772	.1715	2.1338	3.9628	3.2617	.4115	3.0178
24	.2561	.3086	.3429	2.4691	3.9323	3.4141	.9145
Max	3.9628	3.719	3.4446	3.9628	3.9323	3.5056	3.0178
Min	.2401	.0343	.2401	.0686	.2058	.2058	.1029
Avg	1.7975	1.6861	1.8938	1.4437	1.9193	1.4324	.6245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 203 / KOUTHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1703	3.3227	3.5056	.2058	.0686	.1715	.0514
2	3.1703	3.3227	3.4751	.2058	.0686	.1886	.0514
3	3.2312	3.3532	3.5361	.2058	.0686	.1372	.0514
4	3.3532	3.3227	3.4446	.2058	.0686	.2401	.0514
5	3.4141	3.3532	3.4141	.2058	.1029	.12	.0686
6	3.5361	3.3532	3.4141	.2058	.1543	.1886	.1029
7	.1543	.3429	.1543				
8	.1543	.3429	.2229				
9	.1029	.3429					
10	.1029	.1029	.2058				
11		.0343	.0343				
12	.1029	.0343	.2058				
13		.12	.0343				
14		.1029	.0343				
15					3.9018	3.9018	3.9628
16					3.719	3.9018	
17					3.9628	3.9018	3.9018
18					3.9018	3.9628	3.658
19	.2743			3.7799	3.9018	3.658	3.658
20	.2743	.1886		3.9018	3.658	3.658	3.5361
21	.2743	.1543	.2058	3.719	3.658	3.658	3.719
22	.2743	.12	.2058	3.7799	3.2312	3.658	3.719
23	3.3532	3.2312	.2058	.0686	.1543	.0514	.1372
24	3.1703	3.3227	3.4141	.2263	.0686	.1543	.0514
Max	3.5361	3.3532	3.5361	3.9018	3.9628	3.9628	3.9628
Min	.1029	.0343	.0343	.0686	.0686	.0514	.0514
Avg	1.6537	1.4983	1.5125	1.3925	1.9181	1.9720	1.7814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 204 / SHIRDHONE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.8535	.7926				
2	.8535	.8535	.7621				
3	.8535	.823	.7316				
4	.8535	.823	.7011				
5	.8535	.7926	.7621				
6	.8535	.7926	.7926				
7	2.4996	2.5911	2.4387	2.3167	2.4996	2.5606	2.4387
8	2.5606	2.6216	2.8654	2.3167	2.5606	2.6825	2.8121
9	2.6216	2.6216	2.8045	2.3167	2.6216	2.6216	2.5606
10	2.5911	2.6825	2.6216	2.4082	2.5606	2.5606	2.4387
11	2.4996	2.6825	2.6216	2.4387	2.5606	2.6216	2.4387
12	2.5606	2.8045	2.6216		2.7435	2.8654	2.4387
13	2.6216	2.8045	2.5911		2.8654	2.7435	2.5606
14	2.6216		2.6825		2.7435	2.6825	2.7435
15					.9755	.9755	1.0364
16					1.0364	.9755	
17					1.0364	.8535	.9755
18					.9755		1.0364
19				1.0974	.9755	.8535	.9145
20				1.1317	1.0364	.884	.9755
21				1.166	.9755	.9145	.9755
22				1.166	.9755	.9145	1.0364
23	.8535	.7926					
24	.8535	.8535	.7316				
Max	2.6216	2.8045	2.8654	2.4387	2.8654	2.8654	2.8121
Min	.8535	.7926	.7011	1.0974	.9755	.8535	.9145
Avg	1.7128	1.6928	1.7680	1.8176	1.8214	1.8473	1.8255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 205 / WAKHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.5304	.5316	.4973	.5304	.4801	.4938
2	.4024	.5487	.5144	.4973	.5304	.4115	.4938
3	.439	.5487	.583	.5144	.5487	.4115	.5121
4	.439	.5487	.5487	.5144	.5853	.5144	.5144
5	.4755	.5853	.5144	.6001	.6036	.5487	.5487
6	.4938	.6036	.583	.5316	.6401	.5487	.5658
7	.3658						
8	.3475						
9	.3658						
10	.3658						
11			.3601	.2743	.3429	.3475	.3429
12	.3658		.3429	.3109	.3086	.3475	.3429
13	.3658	.2743	.2743	.3292	.3429	.3658	.3429
14	.3841	.2915	.2915		.3258	.3841	.3086
15	.2743	.3258	.2743		.3258	.3429	.3429
16	.3109	.2743	.3086		.3258	.2058	
17	.3475	.3944	.3429		.3429	.3429	.3944
18	.3601	.3429	.3772	.3292	.3772	.3944	.4115
19	.4287	.3944	.5144	.5304	.463	.567	.5144
20	.5316	.5487	.6173	.5487	.5316	.5487	.6516
21	.5304	.5316	.3601	.5853	.463	.5487	.6173
22	.4938	.5487	.3601	.567	.4458	.5487	.5487
23	.4938	.4801	.4801	.5121	.463	.4938	.5144
24	.4024	.4938	.4801	.4801	.5121	.4287	.4938
Max	.5316	.6036	.6173	.6001	.6401	.567	.6516
Min	.2743	.2743	.2743	.2743	.3086	.2058	.3086
Avg	.4081	.4592	.4330	.4764	.4504	.4391	.4713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 201 / 11 KV SIDDHESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4001	.3429	.3239	.2858
2	1.2517	.4191	.362	.3429	.362
3	1.2517	.4191	.362	.3429	.362
4	1.4232	.4572	.381	.381	.4001
5	1.6118	.5335	.381	.4001	.4572
6	2.3491	.5906	.4191	.4954	.4954
7	2.4006	.7049	.4572	.4763	.4001
8	2.6578	.5144	.3429	.362	.362
9	2.3148	.4382	.3239		.3239
10	2.6235	.4001	.2096	.2286	.2477
11	2.6235	.3048	.1524	.1715	.2286
12	.2667	2.6578	1.989	2.0405	2.4177
13	.2667	2.8121	2.1948		2.4177
14	.2667				
15	.2858	2.915	1.9033		2.4006
16	.2667	2.9664	2.0233		2.3834
17	.362	2.6749	1.9033		2.3663
18	.4382	2.4863	1.4575		2.4348
19	.4572		2.0748		2.2805
20	.6287	.4191	.4191	.4572	.4763
21	.5144	.381	.381	.4001	.3429
22	.4382	.362	.362	.3239	.3429
23	.4001	.3429	.3429	.2858	.3239
24	.4572	.4001	.3429	.3239	.2858
Max	2.6578	2.9664	2.1948	2.0405	2.4348
Min	.2667	.3048	.1524	.1715	.2286
Avg	1.0831	1.0727	.8316	.4598	.9738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 202 / 11 KV SATWAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.1886	.2229	.2667
2	1.5261	.2058	.2058	.2229	.2667
3	1.5775	.2058	.2058	.2401	.2667
4	1.749	.2058		.2572	.2572
5	2.1605	.2401	.2572	.2572	.2915
6	2.2291	.2572	.2915	.2915	.3258
7	2.9835	.3429	.2572	.3772	.2743
8	3.1379	.2915	.2572	.2915	.3258
9	2.9321	.2229	.2058	.2743	.3086
10	3.155	.2058	.2229	.2572	.3086
11	2.9492	.2401	.2229	.2401	.2058
12	.1715	3.0864	2.5892	2.9664	2.8807
13	.1886				
14	.1886	2.7778	2.9492		2.7435
15	.2229	2.9492	3.2236		2.915
16	.1543	2.9664	2.9492		2.6749
17	.3086	3.0007	3.3265		3.0178
18	.2915	2.9835	2.3663		3.4294
19	.3086	2.5034	2.7949		3.3608
20	.3601	.2572	.3086	.3944	.4115
21	.3086	.2229	.2915	.3601	.3086
22	.2572	.2058	.2743	.2915	.2743
23	.2058	.1886	.2572	.2572	.2401
24	.2229	.1886	.1886	.2401	.2572
Max	3.155	3.0864	3.3265	2.9664	3.4294
Min	.1543	.1886	.1886	.2229	.2058
Avg	1.1588	1.0415	1.0834	.4378	1.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.381	.4954	.4001	.4001
2	.4572	.381	.4763	.4001	.4001
3	.4763	.381	.4763	.4001	.4001
4	.4763	.4191	.4954	.4001	.4191
5	.5335	.4572	.5144	.4191	.4191
6	.5525	.4954	.5716	.4763	.4572
8	.5335	.4572	.4191	.4382	.2477
9	.381	.4382	.5335	.4382	.2667
10	.4191	.4382	.4001	.362	.5144
11	.2858	.4382	.4954	.3048	.4763
12	.1524	.4382	.362	.3429	.4763
13	.6668	.4954	.4954	.4382	.5906
14	.3239	.4191	.4763	.5144	.5335
15	.381	.3239	.2858		.5144
16	.2286	.3429	.1715		.3239
17	.3429	.2858	.1524		.3239
18	.3048	.2858	.1905	.5335	.3239
19	.381	.4572	.4382	.5716	.362
20	.5335	.4763	.5144	.5144	.4954
21	.5716		.4001	.4763	.4382
22	.4572	.5335	.4001	.4572	.4763
23	.4572	.4954	.4001	.4191	.4382
24	.4763	.4001	.4954	.4001	.4001
Max	.6668	.5335	.5716	.5716	.5906
Min	.1524	.2858	.1524	.3048	.2477
Avg	.4282	.4200	.4200	.4353	.4216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274138 / 33/11 KV KASEGAON

Feeder No / Name : 206 / Dongare Shala
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.6097	.8192	.724	.8192
2	.4954	1.105	1.2765	2.5549	2.8959
3	.5716	1.1241	.5716	2.6749	2.9912
4	.6097	1.2955	1.4098	2.8121	3.1626
5	.6478	1.6956	1.5432	3.3913	3.2769
6	.724	2.1529	3.5246	4.4582	4.5915
7	.7049	.6097	5.2202	5.7918	6.0966
8	.5906	3.1817	5.2774	6.0395	6.0776
9	.6287	3.5246	5.2202	5.5632	6.3253
10	.4191	3.1626	4.9726	5.5441	5.849
11	.3429	2.8197	4.9726	1.5242	4.6487
12	2.21	.3429	.5144	.2858	.5144
13			.381		.5716
14	2.8006	.3239	.5716		.5525
15	2.1529	.381	.1143		.5525
16	2.191	.381	.381		
17	3.315	.4763	.5716		.5525
18	3.5818	.4572	.6859		.8002
19	3.6008		.9335		1.2574
20	.8573	1.086	1.2765	1.3146	1.2955
21	.7621	.9907	.9717	1.2384	1.1812
22	.6287	.9145	.8954	1.0479	.9907
23	.6287	.8002	.8192	.8573	.9907
24	.4763	.6287	.8192	.7621	.8573
Max	3.6008	3.5246	5.2774	6.0395	6.3253
Min	.3429	.3239	.1143	.2858	.5144
Avg	1.2790	1.2756	1.8226	2.7403	2.4718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 201 / 11 KV SARKOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7202	.4801	.5487	2.572	2.8635	2.7778
2	.5487	.7373	.463	.5487	2.4863	2.915	2.8292
3					2.5377	2.9492	2.7435
4					2.5206	2.915	2.8807
5					2.5377	2.8978	2.8292
6					2.572	2.9321	2.572
7	3.1379	2.8292	2.9321	2.4691			
8	2.915	3.2922	2.8807	2.572			
9	2.9321	3.3265	3.155	2.6578			
10	2.7435	3.275	3.1036	2.692			
11	2.915	3.275	3.2922				
12	3.035	3.2922	3.3951				
13	3.0178	3.1722	3.2236				
14	3.0178	2.6578	3.155				
19	.8573	.4287	.6001	.4115	.6859		.823
20		.463	.583	.463	.8573	.4458	.8573
21	.6859	.4801	.583	.4287	.8573	.4801	.823
22	.6859	.5144	1.4232	.4115	.8573	.4801	.7373
23	.7716	.5144	.5144	2.4006	2.6578	2.4691	2.572
24	.5144	.7716	.5144	.5144	2.572	2.7606	2.7435
Max	3.1379	3.3265	3.3951	2.692	2.6578	2.9492	2.8807
Min	.5144	.4287	.463	.4115	.6859	.4458	.7373
Avg	1.8862	1.8594	1.8937	1.3432	1.9762	2.1917	2.0990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 202 / 11 KV OZEWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	2.2291	2.0233	2.2462	.2401	.2229	.1715
2	1.8861	2.2634	2.0405	2.2119	.2401	.1715	.1715
3	1.9719	2.3148	2.0576	2.2291			
4	2.0405	2.4006	2.2291	2.3663			
5	2.1948	2.4863	2.4006	2.4863			
6	2.4006	2.5206	2.5377	2.6749			
7					2.5034	2.5206	2.3148
8					2.572	2.572	2.7778
9					2.6063	2.7435	
10					2.7092	2.7435	
11					2.6578	2.6063	
12					2.4177	2.572	2.4863
13					2.4691	2.5377	2.5206
14					2.4863	2.0576	2.5377
15	.1886	.1372	.1372				
16	.2058	.1543	.1543				
17	.2229	.1715	.1715				
18	.1886	.2058	.1886				
19	.2058	.2229	.2401	.2229	.1886	.1715	.2229
20	.2058	.2058	.2229	.2401	.2229	.2058	.2229
21	.2058	.1715	.2058	.2401	.2229	.1886	.2229
22		.1715	.2058	.2229	.2229	.2058	.2058
23	2.2977	2.0405	2.1776	.2401	.2229	.2229	.2058
24	1.8004	2.1434	2.0576	2.2805	.2401	.2229	.2058
Max	2.4006	2.5206	2.5377	2.6749	2.7092	2.7435	2.7778
Min	.1886	.1372	.1372	.2229	.1886	.1715	.1715
Avg	1.19	1.2400	1.1906	1.4718	1.3889	1.3728	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 203 / 11 KV KHATAKALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6859	.3944	.5316	.4115	.463
2	.583	.6859	.3772	.5144	.3944	.463
15	1.8004	1.5947	1.7147		1.3032	1.749
16	1.8347	1.6289	1.7661		1.3203	1.8861
17	1.869	1.6804	1.749		.8573	1.8861
18	1.8861	1.749	1.7147		1.2346	1.8519
19	1.749	1.7833	1.8347	1.3717	1.6289	1.8004
20	1.6289	1.8004	1.6975	1.3717	1.5604	1.6289
21	1.7147	1.749	1.6289	1.3717	1.5947	1.5432
22	1.7318	1.7661	1.6118	1.3375	1.6289	1.5089
23	.6173	.4287	.6001	.4115	.6859	.583
24	.5144	.6859	.4115	.5487	.4115	.4458
Max	1.8861	1.8004	1.8347	1.3717	1.6289	1.8861
Min	.5144	.4287	.3772	.4115	.3944	.4458
Avg	1.3746	1.3532	1.2917	.9324	1.0860	1.3174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 204 / 11 KV AMBIKA NAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.4287	.3086	.2743	2.0576	2.572	2.2291
2	.2229	.4287	.2915	.2743	2.0576	2.6063	2.3148
3					2.1434	2.572	2.4006
4					2.2291	2.5377	2.4863
5					2.3491	2.4863	2.572
6					2.4006	2.3834	2.6578
7	2.6749	2.6578	2.572	2.7435			
8	2.8635	2.6406	2.6578	2.572			
9	2.8807	2.7092	2.8807	2.572			
10	2.8635	2.1605	2.7435	2.5892			
11	2.8292	2.2291	2.8292				
12	2.8292	2.2977	2.8121				
13	2.7778	2.5549	2.7778				
14	2.7435	2.572	2.7435				
15					.3429		
16					.3429	.2401	.2572
17					.3429	.2743	.3429
18					.4287	.3086	.4115
19	.3601	.2743	.2915	.3086	.3429	.3258	.3944
20	.3944	.3086	.2915	.3086	.3429	.3429	.3772
21	.4287	.3429	.2743	.2915	.3429	.3258	.3601
22	.4287	.3601	.2572	.2743	.3429	.3086	.3429
23	.4287	.3601	.2572		2.572	2.0576	1.8861
24	.2401	.4287	.3429	.2572	1.9719	2.5892	2.1434
Max	2.8807	2.7092	2.8807	2.7435	2.572	2.6063	2.6578
Min	.2229	.2743	.2572	.2572	.3429	.2401	.2572
Avg	1.5754	1.4221	1.5207	1.1332	1.2881	1.4620	1.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 205 / SHIVAJI NAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	1.3889	1.3717	1.1831	.4115	.5144	.4115
2	1.286	1.3032	1.286	1.1488	.4115	.5144	.3944
3	1.2003	1.3203	1.3375	1.1488			
4	1.2346	1.3717	1.3717	1.1488			
5	1.3032	1.3889	1.3717	1.2174			
6	1.3889	1.3889	1.406	1.286			
7					1.3375	1.3375	1.3717
8					1.3717	1.3375	1.5432
9					1.3717	1.406	1.5604
10					1.3717	1.3546	1.6118
11						1.406	1.5775
12					1.4232	1.406	1.5432
13					1.406	1.3889	1.5432
14					1.286	1.3717	1.5432
15	.5144	.2743	.463				
16	.5144	.3086	.4973				
17	.5144	.3429	.5487				
18	.6001	.3772	.5487				
19	.6516	.4287	.6173	.5316	.5144	.5316	.5487
20	.6859	.463	.6001	.5316	.5144	.5487	.5658
21	.6001	.4973	.6001	.5487	.5144	.5144	.5144
22	.5144	.5316	.583	.5487	.5144	.4801	.4801
23	1.3032	1.3717	1.2003	.4801	.5487	.4287	.4458
24	1.2517	1.4575	1.406	1.2174	.4115	.5144	.4287
Max	1.3889	1.4575	1.406	1.286	1.4232	1.406	1.6118
Min	.5144	.2743	.463	.4801	.4115	.4287	.3944
Avg	.9259	.8884	.9506	.9159	.8939	.9409	1.0052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274142 / 33/11 KV SARKOLI

Feeder No / Name : 206 / SARKOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1715	.1543	.1715	.1543	.1715
2	.1543	.1543	.1543	.1543	.1715	.1715	.1715
3	.1543	.2058	.1543	.1543	.1886	.2915	.2058
4	.2058	.3429	.1715	.1715	.2401	.3429	.2401
5	.2572	.3772	.2058	.2229	.3086	.4287	.2743
6	.3429	.3944	.2743	.2915	.3086	.3772	.3258
9	.2058	.2058	.1886	.2229	.1715	.2058	.2401
10	.2058	.1543	.1715	.2058	.1715	.1715	.2058
11	.1715	.1372	.1715	.1715	.1543	.1543	.1715
12	.1372	.12	.1543	.1715	.1543	.1372	.1715
13	.1543	.1029	.1543	.1543	.1372	.12	.1543
14	.1372	.1029	.1372	.1543	.1372	.12	.1543
15	.1715		.1372	.1543	.1372		.1543
16	.1372	.12	.1372	.1543	.1543	.1372	.1543
17	.1372	.1372	.1543	.1715	.1543	.1543	.1715
18	.2572	.1715	.2058	.2058	.1886	.1715	.2058
19	.3258	.2058	.3258	.2572	.3601	.2401	.2743
20	.3601	.2229	.2915	.2915	.3258	.2743	.3429
21	.3086	.2401	.2572	.2743	.3944	.2401	.3429
22	.2058	.2572	.2229	.2743	.3429	.2058	.3086
23	.1715	.2229	.2058	.1886	.1543	.2058	.2058
24	.1543	.1543	.2058	.1715	.1715	.1543	.1715
Max	.3601	.3944	.3258	.2915	.3944	.4287	.3429
Min	.1372	.1029	.1372	.1543	.1372	.12	.1543
Avg	.2050	.1984	.1933	.1987	.2136	.2123	.2190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 201 / 11 KV DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.0762	.0762	1.2955	1.2955	1.2955
2	.0905	.0905	.0762	.0762	1.2955	1.2955	1.2955
3	.0905	.0905	.0762	.0762	1.2955	1.2955	1.2955
4	.0905	.0905	.0857	.0762	1.2955	1.2955	1.2955
5	.0905	.0905	.0762	.0762	1.2955	1.2955	
6	.0905	.0905	.0762	.0762	1.2955	1.4575	
7	.0905	.0905	.0762	.0762	1.2955	1.6194	
8	.0905	.0905	.0762	.0762	1.2955	1.4575	
9	.0905	.0905	.0905	.0905	.0905	.0905	.0905
10	.0905	.0905	.0905	.0905	.0905	.0905	.0905
11	.0905	.0905	.0905	.0905	.0905	.0905	.0905
12					.0905	.0905	
17	1.2955	1.3717	1.4575				
18	1.2955	1.5432	1.4575		.0905	.0905	.0905
19	1.448	1.3717	1.5432	1.3717	.0905	.0762	.1448
20	1.4575	1.3717	1.5432	1.3717	.0905	.0762	.181
21	1.4575	1.3717	1.3717	1.3717	.0905	.0762	.181
22	1.4575	1.3717	1.3717	1.2193	.0905	.0762	.181
23	1.2955	1.3717	1.3717	1.2193	.0905	.0762	.181
24		1.2955	1.3717	1.3717		.0905	
Max	1.4575	1.5432	1.5432	1.3717	1.2955	1.6194	1.2955
Min	.0905	.0905	.0762	.0762	.0905	.0762	.0905
Avg	.5946	.6350	.6515	.5180	.6261	.6282	.4933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 202 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.915	2.915	2.8959	2.5911	.181	.362	.362
2	2.915	2.915	2.8959	2.5911	.362	.362	.181
3	2.915	2.915	2.8959	2.5911	.362	.362	.181
4	2.915	2.915	2.8959	2.5911	.362	.362	.181
5	2.915	2.915	3.0483	2.5911	.362	.362	
6	3.0769	2.915	3.0483	2.7435	.181	.362	
7	3.0769	3.0769	3.0483	2.7435	.181		
8	3.0769	3.0769	3.2007	2.7435			.181
9	.181	.362	.181	.362	2.915	3.7247	3.8009
10	.181	.362	.181	.362	3.2388	3.2388	3.4008
11	.181	.181	.181	.181	3.0769	3.0769	3.2388
12	.181	.181	.181			3.4008	3.5627
13						3.2388	3.5627
14					3.4008	2.915	3.4008
15					3.4008	2.915	3.2388
16					3.2388	3.2388	3.0769
18					.362		.181
19	.362	.1524	.1524	.3048	.362	.3048	.181
20	.362		.3048	.1524	.362	.3048	.362
21	.362	.3048	.3048	.1524	.362	.3048	.362
22	.362	.3048	.3048	.1524	.362	.3048	.362
23	.362	.3048	.3048	.1524	.362	.3048	.362
24	.362	.362	.3048	.3048		.362	
Max	3.0769	3.0769	3.2007	2.7435	3.4008	3.7247	3.8009
Min	.181	.1524	.1524	.1524	.181	.3048	.181
Avg	1.4834	1.5387	1.4628	1.3712	1.2334	1.4903	1.5883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 203 / 11 KV CHANDRABHAGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
24	1.166
Max	1.166
Min	1.166
Avg	1.166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4887	.4801		.4525	.4525	.4344
2	.4887	.4887	.5144	.4287	.4525	.4525	.4887
3	.5249	.5249		.463	.5068	.4887	.5249
4	.5611	.6154	.5487	.4973	.543	.5249	.543
5	.5973	.6878	.5487	.5658	.6335	.6335	
6	.7059	.8145	.6001	.6516	.724	.8145	
8	.5249	.5249	.5487	.3772	.543	.5611	.4525
9	.362	.4344	.4706	.362	.362	.4163	.3982
10	.4344	.362	.4344	.4163	.3982	.3258	.362
11	.4344	.3258	.362	.362	.3439	.2896	.3439
12	.362	.3439	.3077	.2896	.3258	.2715	.3439
13		.3439	.3077	.3258		.2715	.2896
14		.3258	.3077	.2896	.2715	.2715	.3258
15	.3258	.3258	.3077	.2896	.2896	.2715	.3077
16	.3258	.3439	.3258	.3077	.2715	.3258	.362
17	.3439	.3258		.3439		.362	.3982
18	.3982	.3982	.3982	.362	.3801	.4344	.4344
19	.5973	.442	.381	.4572	.6154	.5487	.6335
20	.6878	.6001	.4973	.4973	.724	.6097	.7421
21	.7964	.5487	.5487	.4801	.8145	.6001	.8145
22	.6878	.5144	.463	.4458	.8507	.5487	.7602
23	.5973	.4973	.4287	.4115	.724	.5144	.6878
24	.4525	.5068	.4801	.4287		.5611	
Max	.7964	.8145	.6001	.6516	.8507	.8145	.8145
Min	.3258	.3258	.3077	.2896	.2715	.2715	.2896
Avg	.5094	.4689	.4410	.4115	.5113	.4587	.4824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 205 / NEW DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2534	.2134	.2058	.2534	.2715	.2172
2	.2534	.2534	.2134	.1829	.2534	.2715	.2172
3	.2534	.2715	.2134	.1981	.2534	.2896	.2534
4	.2534	.181	.2401	.2134	.2715	.3077	.2534
5	.2715	.362	.2572	.2286	.2715	.3258	
6	.2715	.3801	.2401	.2286	.2896	.3439	
7					.2896	.362	
8					.2353	.3077	.2172
9	2.2624	1.8785	2.1052	2.0243	.2172	.2534	.1991
10	2.0891	2.1862	2.2186	2.1052	.1629	.1991	.1448
11	2.1052	2.0891	2.0081	2.1052	.1448	.1629	.1267
12	2.1214	2.0243	2.0729				
14	1.9109	1.749	1.7652				
15	1.8947	1.9757	1.9433				
16	1.8947	1.7976	1.8785				
17					2.1052	2.2348	2.1376
18	.1867				2.0243	2.2996	2.0243
19	.2896	.2229	.2058	.2286	2.3482	1.9204	1.9595
20	.3258	.2439	.2286	.2286	2.332	2.1262	1.8947
21	.2896	.2743	.2286	.2286	2.1376	1.5242	1.8623
22	.2896	.2401	.2286	.2134	2.0243	1.5242	1.7004
23	.2534	.2134	.1981	.2134	1.7814	1.4175	1.5384
24	.2534	.2353	.2134	.1829		1.5546	
Max	2.2624	2.1862	2.2186	2.1052	2.3482	2.2996	2.1376
Min	.1867	.181	.1981	.1829	.1448	.1629	.1267
Avg	.8862	.8859	.8775	.5858	.9664	.9314	.9831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 201 / UJANI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1389	.1235	.0772	.1094	.0469	.0469
2	.8333	.8488	.9374	.9568	.1094	.0469	.0474
3	1.0029	.9414	.9374	.9722	.0937	.0469	.0469
4	1.1104	1.034	1.0155	1.0494	.0937	.0474	.0469
5	1.0802	1.1728	1.0936	1.0957	.125	.0469	.0469
6	1.2037	1.25	1.1405	1.2037	.1562	.0469	.0625
7	1.2809	1.2963	1.3279	1.1728	.1718	.0625	.0469
8	1.358	1.2654	1.3279	1.2037	.1718	.0625	.0469
9	1.2651	1.2193	1.2654	1.1561	.2031	.0469	
10	1.2346	1.1888	1.2193	1.1561	.1875	.0469	.0469
11	.1067	.0762	.0457		.1581	.0469	.0469
12	.1219	.061	.0457		1.4685	.7811	.9488
13	.1219	.0305	.061		1.4842	.8749	1.2498
14	.0914	.0305	.061		1.2498	.9374	1.2498
15	.0914	.0152	.0457		1.1561	.9686	1.1717
16	.0926	.0154	.0305		1.1717	.9374	.9842
17	.1235	.0309	.0152		1.1873	.6249	.9842
18	.0772	.0617	.0309		1.0467	.8592	.8592
19	.0926	.1389	.0772		.125	.0469	.0469
20	.0926	.1389	.0772	.125	.1406	.0469	.0781
21	.108	.1235	.0926	.1406	.0937	.0469	.0781
22	.0926	.1235	.108	.125	.0312	.0469	.0625
23	.108	.1235	.0926	.1423	.0469	.0469	.0469
24	.1235	.1235	.1235	.0926	.125	.0469	.0469
Max	1.358	1.2963	1.3279	1.2037	1.4842	.9686	1.2498
Min	.0772	.0152	.0152	.0772	.0312	.0469	.0469
Avg	.4974	.4770	.4706	.7113	.4544	.2839	.3605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 202 / RAMESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3241	.3241	.3077	.2932	.3201	.2743	.3281
2	.3241	.3395	.3086	.2778	.8383	.9145	.8749
3	.3395	.3395	.3086	.2778	.9145	1.0669	.9374
4	.3549	.3704	.2778	.3086	.9145	1.0669	1.0031
5	.3549	.4012	.2932	.3704	1.3717	1.3717	1.3117
6	.3549	.463	.3241	.4167	1.7833	1.9357	1.7341
7	.3704	.4321	.3086	.4012	2.1338	2.1186	2.1247
8	.4321	.4012	.3241	.4784	2.1186	1.9814	2.0153
9	.3658	.381	.3086	.4268			1.6872
10	.3963	.381	.3506	.3963	1.6766	1.448	1.4937
11	.2896	.2439	.2591	.3506	.2743	.2286	.2286
12	1.5089	1.5699	1.6766		.3048	.3048	.2743
13	1.7223	1.7528	1.8747	.823	.3201	.3353	.3048
14	1.7223	1.6766	1.7985		.3201	.3201	.3048
15	1.6766	1.5699	1.7223		.3048	.3353	.381
16	1.6766	1.5466	1.6766		.3048		.4115
17	1.6309	1.6716	1.6461		.3201	.3086	.4115
18	1.6667	1.6404	1.6204		.442	.3086	.381
19	.2315	.2968	.2315		.442	.3395	.3906
20	.2315	.2968	.216	.2743	.4268	.3086	.381
21	.216	.2968	.216	.4268	.381	.3241	.3353
22	.2469	.3125	.2469	.4115	.3506	.3395	.2743
23	.2469	.2968	.2469		.3048	.3241	.2439
24	.3086	.2778	.3125	.2778	.3353	.2743	.3395
Max	1.7223	1.7528	1.8747	.823	2.1338	2.1186	2.1247
Min	.216	.2439	.216	.2743	.2743	.2286	.2286
Avg	.7080	.7201	.7023	.3882	.7349	.7377	.7572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 203 / 11Kv palashi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0305	.0316	.0762	.0791	.0474	.0469
2	.3506	.3963	.3163	.3658	.0633	.0474	.0469
3	.3353	.3963	.3163	.3658	.0633	.0474	.0469
4	.3658	.3506	.3005	.3506	.0791	.0474	.0469
5	.3395	.381	.3163	.381	.0633	.0474	.0625
6	.7773	.3658	.3321	.4012	.0633	.0474	.0781
7	.4012	.3963	.4586	.4115	.0791	.0474	.0781
8	.4115	.4475	.4586	.442	.0633	.0474	.0937
9	.3963	.4321	.4111	.3953	.0633	.0474	
10	.463	.4012	.4321	.3321	.0633	.0474	.0633
11	.0309	.0309	.0305		.0474	.0474	.0791
12	.0309	.0463	.0463		.4428	.3953	.4744
13	.0463	.0617	.0463		.4744	.4744	.5218
14	.0463	.0617	.0309		.4902	.4902	.5535
15	.0463	.0617	.0309		.4744	.4744	.506
16	.0457	.0633	.0463		.506	.4744	.4744
17	.0457	.0633	.061		.4744	.427	.4744
18	.0457	.0633	.061		.4902	.2846	.3953
19	.061	.0316	.0914		.0791	.0474	.0633
20	.0617	.0316	.0914	.0791	.0791	.0633	.0791
21	.0457	.0316	.108	.0791	.0474	.0791	.0633
22	.0617	.0316	.1067	.0791	.0474	.0781	.0633
23	.0457	.0316	.0926	.1265	.0474	.0625	.0633
24	.0457	.0457	.0316	.1067	.0791	.0474	.0469
Max	.7773	.4475	.4586	.442	.506	.4902	.5535
Min	.0305	.0305	.0305	.0762	.0474	.0474	.0469
Avg	.1888	.1772	.1770	.2661	.1858	.1633	.1922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 204 / Palashi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2686	.2353	.2686	.2715	.2715	.2172
2	.2507	.2865	.2172	.2686	.2353	.2353	.2353
3	.2686	.3045	.2353	.3045	.2056	.2353	.2534
4	.3224	.3582	.2715	.3403	.2172	.2715	.2715
5	.394	.4298	.3801	.4119	.3258	.362	.3982
6	.4835	.4835	.5068	.4835	.4525	.3982	.543
9	.3077	.3258	.2715	.2715	.3258	.362	.3077
10	.3258	.2715	.2353	.2353	.2172	.2534	.2715
11	.2715	.2715	.2353	.181	.1991	.2715	.2715
12	.1991	.2353	.1991		.2172	.2353	.2353
13	.1629	.1991	.181	.181	.1991	.2715	.2353
14	.1629	.1991	.181	.2172	.1991	.2353	.2353
15	.1629	.181	.1629	.2353	.2172	.2172	.2534
16	.2328	.181	.1612	.2715	.2172	.2172	.2534
17	.2686	.2172	.1612	.2715	.2534	.181	.1629
18	.2865	.2353	.1612	.3258	.2715	.2715	.2715
19	.3045	.362	.197	.3258	.362	.362	.3982
20	.2686	.3258	.2328	.4525	.4525	.3258	.4525
21	.2686	.2715	.2328	.4525	.4525	.2715	.4525
22	.2865	.2353	.2507	.4525	.362	.2534	.3258
23	.2686	.2172	.2507	.3258	.3258	.2534	.3258
24	.2328	.2507	.2172	.2507	.2715	.2715	.2172
Max	.4835	.4835	.5068	.4835	.4525	.3982	.543
Min	.1629	.181	.1612	.181	.1991	.181	.1629
Avg	.2718	.2777	.2353	.3108	.2841	.2740	.2995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 201 / 11 KV LAXAMAN DAS
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0857	.0857	.6859	.0686	.6516	.0686
2	.0514	.9774	.6859	.7545	1.0288	.6859	1.1145
3	.0686	.9774	.7545	1.0288	1.0288	.7545	1.1145
4	.1029	.9774	.8916	1.0802	1.0802	.9259	1.1145
5	.12	1.0288	.9945	1.2003	1.0802	.9431	1.1145
6	.0686	1.0288	1.0974	1.2003	1.1145	1.0288	1.1145
7	.0686	1.0631	1.1145	1.2517	1.1145	1.1317	1.2174
8	.0857	1.1145	1.1145	1.2689	1.1145	1.0288	1.2174
9	.0514	1.166	.9259	1.2003	1.1831	1.1145	.9945
10	.0857	1.166	1.0288	1.2174	1.166	1.0631	.7202
11	.0857	.0686	.0857	.0857	.0686	.0857	.0857
12	.5316	.0686	.0686	.0857	.0686	.0857	.0686
13	.6859	.0857	.0686	.0686	.0857	.0857	.0686
14	.5144	.0857	.1029		.0857	.0857	.0857
15	.0514	.1029	.0857		.1029	.0857	.0857
16	.0171	.0857	.0686		.12	.0857	.1029
17	.0171	.0857	.0514		.1029	.1029	.0857
18		.0857	.0857	.0686	.1029	.1029	.1029
19		.0857	.0343	.1372	.0686	.0686	.12
20	.0686	.0857	.0686	.1372	.12	.0686	.1372
21	.0686	.0857	.1029	.1029	.0857	.0857	.1029
22	.0686	.0857	.0686	.1372	.0514	.0686	.0857
23	.0857	.0686	.0514	.1372	.0686	.0686	.0857
24	.0343	.0857	.0686	.1029	.1029	.0857	.0686
Max	.6859	1.166	1.1145	1.2689	1.1831	1.1317	1.2174
Min	.0171	.0686	.0343	.0686	.0514	.0686	.0686
Avg	.1356	.4480	.4044	.5976	.4672	.4372	.4615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 203 / GADEGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7202	.7202	.7888	.7202	.7888	.7545
2	.6859	.7716	.6859	.7202	.7716	.823	.7545
3	.7545	.7716	.6859	.6859	.7716	.6859	.7716
4	.7202	.823	.6516	.7545	.7888	.7545	.7716
5	.7888	.823	.7202	.7888	.7888	.7888	.7716
6	.7888	.8745	.7888	.8402	.7716	.823	.823
7	.823	.9259	.8573	.7888	.823	.823	.8916
8	.7888	.823	.7202	.6859	.7716		.8916
9	.7545	.7202	.7202	.6516	.6859	.7202	.8573
10	.8573	.7202	.7202	.6859	.7202	.7545	.8916
11	.6859	.7202	.7202	.6859	.583	.7202	.7888
12		.6859	.6859	.6173	.7202	.6859	.7545
13	.9259	.6859	.6859	.6516	.6859	.6516	.7888
14	.823	.6859	.6859		.6859		.7545
15	.5258	.7202	.7202		.7202	.1715	.7202
16	.8573	.7888	.7202		.7202	.8573	.7202
17	.8573	.7888	.6859		.6859	.8573	.823
18	.823	.7888	.7545	.3086	.9259		.9259
19	.823	1.0288	.7202	.9602	.8916	.7888	1.0288
20	.7716	1.166	.7888	.823	.8573	.823	1.0974
21	.823	1.0288	.9945	.7716	.9259	.823	1.0974
22	.7716	.9259	.6859	.7202	.6859	.7545	1.0631
23	.7716	.823	.7545	.7716	.7545	.7545	1.0288
24	.823		.7545	.7202	.7202	.7888	.7545
Max	.9259	1.166	.9945	.9602	.9259	.8573	1.0974
Min	.5258	.6859	.6516	.3086	.583	.1715	.7202
Avg	.7825	.8178	.7345	.7210	.7573	.7447	.8552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274225 / 33/11 KV GADEGAON

Feeder No / Name : 205 / SIDHNATH GADEGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3547	.3361	.3734	.3361	.2987	.4481
2	.7468	.4481	.3734	.4108	.5041	.3361	.3921
3	1.1203	.4481	.3734	.4481	.5041	.3734	.3921
4	1.251	.4668	.4108	.4108	.5041	.4108	.3921
5	1.6804	.4668	.4481	.4108	.5601	.4481	.4481
6	2.0538	.5041	.5041	.3361	.5601	.4108	.4481
7	2.3339	.5415	.5601	.5601	.6348	.3734	.4668
8	1.4937	.4481	.4481	.5228	.5601	.5601	.4668
9	.9709	.3921	.3361	.4481	.4668	.4108	.3361
10	1.8671	.3734	.3174	.2987	.4481	.3547	.2987
11		.3174	.2801	.3174	.4481	.3361	.3174
12	.2801	2.2405	2.2405	2.2405	2.5393	2.1472	2.0351
13	.2801	2.3339	2.2405		2.5019	2.0911	2.0725
14	.2427	2.2405	2.0538		2.4272	2.0165	2.1285
15	1.4563	2.2405	2.2405		2.4272	2.1472	2.2032
16		2.2405	2.3712		2.4272	2.2218	2.2592
17	1.4003	2.2405	2.0725		2.0538	2.1658	2.3899
18	1.8671	1.9231	2.0538	.2801	2.2218	2.1472	2.2965
19	.3361	.3174	.3734	.3174	.4108	.5041	.4668
20	.3361	.3361	.4108	.3174	.4481	.5041	.4668
21	.3361	.3361	.3734	.3174	.3734	.4481	.4108
22	.3361	.3734	.3361	.3361	.3921	.4481	.3734
23	.3361	.3547	.3734	.3361	.4108	.4481	.3734
24	.3734	.3547	.3361	.3361	.3361	.2801	.4481
Max	2.3339	2.3339	2.3712	2.2405	2.5393	2.2218	2.3899
Min	.2427	.3174	.2801	.2801	.3361	.2801	.2987
Avg	.9802	.9289	.9110	.4746	1.0207	.9118	.9304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274246 / 33/11 KV AMBE

Feeder No / Name : 201 / 11 KV WAGHATE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1524
2	2.7435	2.7435	2.8959	.1524	.1524	.1524	.1524
3	2.7435	2.7435	2.8959	.1524	.1524	.1524	.1524
4	2.7435	2.7435	2.8959	.1524	.1524	.1524	.1524
5	2.7435	2.7435	2.8959				
6	3.0483	2.7435	2.8959				
7	3.0483	2.7435	2.8959				
8	3.0483	2.7435	2.8959				
9	2.8959	2.8197	2.8959				
10	2.8959	2.8197	2.8959				
12				2.8197	2.8197	2.7435	2.5149
13				2.9721	2.8197	2.7435	2.5149
14						2.7435	2.8959
15					2.7435	2.7435	
16					2.8197	2.7435	
17					2.8197	2.7435	3.1245
18						2.7435	3.0483
19					2.7435	2.7435	2.4387
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	3.0483	2.8197	2.8959	2.9721	2.8197	2.7435	3.1245
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.7883	1.7172	1.7985	.6512	1.2092	1.3717	1.1939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274246 / 33/11 KV AMBE

Feeder No / Name : 202 / DURWASHRUSHI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762			1.829	1.829	1.829	1.6766
3	.0762			1.829	1.829	1.829	1.6766
4	.0762			1.829	1.829	1.829	1.6766
5				1.9814	1.9814	1.9814	1.829
6				1.9814	1.9814	1.9814	1.829
7				1.9814	1.9814	1.9814	
8				1.9814	1.9814	1.9814	1.829
9				1.9814	1.9814	1.9814	1.829
10				1.9814	1.9814	1.9814	1.829
11							1.829
12	1.9814	1.9814	2.1338				
13	1.9814	1.9814	2.1338				
14			2.1338				
15	1.9814	2.0576					
16	1.9814	2.0576					
17	1.9814	2.0576	2.1338				
18	1.9814	2.0576	2.1338				
19	1.9814		2.1338				
20	.0762	.0762	.0762	.0762	.0762	.0762	.0762
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	1.9814	2.0576	2.1338	1.9814	1.9814	1.9814	1.829
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.9097	1.0542	1.105	1.1888	1.1888	1.1888	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274254 / 33/11 KV TANALI

Feeder No / Name : 201 / 11 KV TANALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.1886	1.9938	1.8724	1.7164
10	.2229	1.9418	1.8724	1.6817
11	.2058	1.8724	1.7164	1.647
12	2.0111	.1715	.1543	.1543
13	2.0631		.1715	.12
14	2.1672		.1715	.1372
15	2.2365		.1715	.1715
16	1.6644		.1715	.1715
Max	2.2365	1.9938	1.8724	1.7164
Min	.1886	.1715	.1543	.12
Avg	1.3450	1.4949	.7877	.7250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274254 / 33/11 KV TANALI

Feeder No / Name : 202 / 11 KV YALLAMA DEVI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.7164	.2229	.1886	.2229
10	1.6644	.2229	.2401	.2229
11	1.5257	.2229	.2229	.2229
12	.1886	1.543	2.0285	1.7511
13	.2229		1.9938	1.6124
14	.2229		1.9591	1.9244
15	.2401		1.9071	1.9938
16	.1543		1.7684	1.8724
Max	1.7164	1.543	2.0285	1.9938
Min	.1543	.2229	.1886	.2229
Avg	.7419	.5529	1.2886	1.2279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 201 / 11 KV GURUSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.4006	2.8959	.0686	.061	.12	.0686
2	2.4006	2.4006	2.8959	.0686	.061	.0686	.0686
3	2.4006	2.572	2.8959	.0686	.061	.0686	.0686
4	2.572	2.7435	3.0178	.0686	.061	.0686	.0686
5	2.7435	2.9492	3.4294	.0686	.0686	.0686	.0686
6	3.4294	3.4294	3.2312	.0686	.061		.0686
7	3.4294	3.6351	3.4141		.061		
8	3.4294	3.4294	3.4294		.061		
9				2.8807	3.6351	3.4294	3.1245
10				2.8121	3.7723	3.4294	2.9264
11				3.0521	3.8409	3.0178	3.4979
12				2.9492	3.8409	3.0864	3.0483
13					3.7037	3.0864	3.0483
14					3.6351	2.6749	2.9874
15					3.4294	2.9492	2.9416
16					3.5665	2.8464	2.774
17	.0686	.0686	.0686				
18	.0686	.061	.0686		.0686	.0686	.0686
19	.0686	.061	.0678		.0686	.0686	.0686
20	.0686	.061	.0678	.0686	.0686	.0686	.0686
21	.0686	.061	.0686	.061	.0686	.0686	.0686
22	.0686	.061	.0686	.061	.0686	.0686	.0686
23	.0686	.061	.0686	.061	.0686	.0686	.0686
24	.0686	.0686	.061	.0686	.061	.0686	.0686
Max	3.4294	3.6351	3.4294	3.0521	3.8409	3.4294	3.4979
Min	.0686	.061	.061	.061	.061	.0686	.0686
Avg	1.4596	1.5039	1.6093	.8284	1.3214	1.2697	1.2019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 202 / 11 KV HOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.6956	1.829	2.0576	1.7147
2				1.8991	1.829	2.0576	1.7147
3				1.8991		2.0576	1.8861
4				1.8991	1.9509	2.0576	2.0576
5				1.8519	2.0119	2.1434	2.0576
6				1.9547	2.0729	2.1262	2.0576
7				2.0748	1.9814	2.2291	1.9814
8				2.2805	2.0729	2.2634	2.1338
9	2.1795	2.5377	2.4006				
10	2.1338	2.6063	2.6749				
11	2.1338	2.572	2.4691				
12	2.1948	2.572	2.6063				
13	2.1948	2.4006	2.6063				
14	2.1338	2.4006	2.6063				
15	2.1033	2.6282	2.6749				
16	2.1033	2.6578	2.5774				
Max	2.1948	2.6578	2.6749	2.2805	2.0729	2.2634	2.1338
Min	2.1033	2.4006	2.4006	1.6956	1.829	2.0576	1.7147
Avg	2.1471	2.5469	2.5770	1.9444	1.964	2.1241	1.9504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 203 / 11 KV CHILAIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.0576	3.0864	.7373	.8059	.7545	1.0974
2	2.4006	2.0576	3.0864	.7373	.8059	.7545	1.0974
3	2.6063	2.2291	3.3951	.7373	.823	.7545	1.0974
4	3.0178	2.4006	3.3951	.823	.8573	.8573	1.0974
5	3.0178	2.7435	3.4294	.8745	.8916	.8573	1.0974
6	2.6063	2.8807	3.0864	.7888	.8916		1.0974
7	3.155	2.7435	3.3608	.823			
8	3.0178	3.0178	3.0521				
9				3.1722	3.1722		
10				3.3951	2.915	3.7037	3.7209
11				3.2922		3.5665	3.0864
12				3.0178	3.2579	3.8752	3.7037
13				3.0864		3.3265	3.3951
14						3.618	3.2922
15						3.7037	3.2579
16					2.8807	2.8464	3.275
17	.6516						.3944
18	.5487					.9602	.4115
19	1.0974	.5487	.78	.5487	.9602	1.2346	.6173
20	1.0974	.5487	1.0288	.5487	.9602	1.3717	.7545
21	1.0974	.583	1.0288	.6173	.9774	1.0974	.7888
22	.9602	.6344	.8817	.6516	.9431	1.0974	1.0288
23	.823	.6344	.7373	.7202	.8573	1.0974	1.0288
24	.6859	.6859	.6344	.7373	.8059	.8573	1.0974
Max	3.155	3.0178	3.4294	3.3951	3.2579	3.8752	3.7209
Min	.5487	.5487	.6344	.5487	.8059	.7545	.3944
Avg	1.8240	1.6975	2.2131	1.4060	1.4253	1.9123	1.7351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 204 / 11 KV GURSALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7545	.7202	.6344	.703	.5144	.6516
2	.823	.7545	.7202	.6344	.7545	.5144	.6516
3	.823	.7545	.823	.6859	.7888	.5144	.6516
4	.9602	.8573	.9602	.7545	.823	.5144	.7888
5	1.0631	1.0288	1.0288	.9259	.9259	.7545	1.0631
6	1.166	1.2003	.9259	.8916	1.0631	.7545	1.0631
7		1.0631	.823	.9945	.9774	1.0288	1.0288
8	.9945		.7716	.7716	.823	.9602	.8916
9	.7545	.7888	.7888	.7202	.823		.7716
10	.6859		.7202	.7202	.7202	.7888	.6859
11	.6859	.6952	.6516	.6001		.6687	.6859
12	.823	.6516	.6516	.5658	.5658	.6173	.6687
13	.7202	.6173	.6173	.6344	.5658	.5316	.583
14	.6516	.6344	.583	.5316	.6516	.4801	.583
15	.6173	.583	.583	.5316	.583	.5316	.583
16	.6173	.6516	.5487	.6001	.6859	.6001	.6173
17	.7888	.583	.5087	.6859	.7545		
18	.823	.703		.8916	.7545	.7373	.6173
19	1.2003	.823	1.0513	.8916	1.0288	1.0288	.7888
20	1.0288	.8916	.9774	.8573	1.0288	1.0631	.823
21	.9259	.8916	.8478	.823	1.0288	.8573	.8916
22	.8573	.823	.8139	.7716	.9259	.7888	.9259
23	.7888	.7545	.7122	.7202	.7545	.6859	.7888
24	.8573	.7545	.7202	.6344	.6249	.6859	.6516
Max	1.2003	1.2003	1.0513	.9945	1.0631	1.0631	1.0631
Min	.6173	.583	.5087	.5316	.5658	.4801	.583
Avg	.8469	.7845	.7630	.7280	.7980	.7100	.7589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 206 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	2.7435		3.0864	3.0864
2	.1372	.1372	.1372	2.7435		3.0864	3.0864
3	.1372	.1372	.1372	3.2236		3.0864	3.0864
4	.1372	.1372	.1372	3.4294		3.2579	3.5151
5	.2743	.2743	.2743	3.4294		.3429	3.8923
6	.2743	.3429	.2743	3.7037		.3048	4.0466
7		.2743	.2743			.3429	3.5665
8				3.7037		.3429	3.3608
9	3.4294		2.3148				
10	3.4294	3.8409	2.3148				
11	3.4294		2.2291				
12	3.4294	3.8409	2.2291				
13	3.4294	3.7037	2.0576				
14	3.3951	3.6626	2.0576				
15	3.2922	3.9781	2.0576				
16	3.2922	3.7037	2.1704				
17	.1372	.1372	.1696	.1372	.1372		.1372
18			.2035	.2743	.1372	.1372	.1372
19	.2743	.1372	.2743	.2743	.1372	.3429	.1372
20	.2743	.1372	.2713	.2743	.1372	.3429	.1372
21	.2743	.1372	.2401	.2743	.1372		.1372
22	.1372	.1372	.2035	.1372	.1372	.2743	.1372
23	.1372	.1372	.2058	.1372	.1372	.1372	.1372
24	.1372	.1372	.1372	.2058		.1372	.1372
Max	3.4294	3.9781	2.3148	3.7037	.1372	3.2579	4.0466
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	1.4093	1.2565	.8917	1.6461	.1372	1.0873	1.7961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 207 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17	1.4746	1.5947	1.5939		1.5775	1.5261	1.3203
18	1.5775	1.5775	1.6787	1.6289	1.5775	1.5261	1.3203
19	1.5947	1.5775	1.4752	1.6461	1.5775	1.4918	1.3203
20	1.5432	1.5775	1.4575	1.6461	1.5432	1.4575	1.3203
21	1.5432	1.5432	1.4413	1.6118	1.5432	1.4575	1.3203
22	1.5089	1.6804	1.4575	1.5775	1.5432	1.4575	1.286
23	1.5432	1.6461	1.4575	1.5432	1.5432	1.4232	1.286
24	1.286	1.5432	1.4575	1.4575	1.5261	1.5432	1.4232
Max	1.5947	1.6804	1.6787	1.6461	1.5775	1.5432	1.4232
Min	1.286	1.5432	1.4413	1.4575	1.5261	1.4232	1.286
Avg	1.5089	1.5925	1.5024	1.5873	1.5539	1.4854	1.3246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 201 / 11 KV UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8951	1.1431	1.0852	1.3336		.1619
2	.9717		1.1797	1.2003		.1696
3	1.1984	1.448	1.2452	1.3395		.2035
4	.9667		1.3565	1.5432		.2035
5	1.085		1.3108	1.3565		.2601
6	1.2308		1.4918	1.5089		.298
7	1.4089		1.4575	1.7147		.2429
8	1.4918	1.6766	1.4746	1.4752	.1715	.2458
9		.1619	.1905		.1638	.2858
10		.16	.1905		.1638	.3239
11		.1619	.1905		.1638	.2667
12		.16	.1905		.16	.2858
13		.1638	.1905			.2858
16		.1107	.1905		.1311	.2858
17		.1475	.1905		1.2146	1.2574
18		.1619	.1905		1.3413	1.3413
19		.2267	.1905		1.3927	1.1869
20		.2267	.1905		1.4091	1.4582
21		.1943	.1905		1.2407	1.5261
22		.1802	.1905		1.1469	1.3413
23		.1865	.1905		.9556	1.2548
24	.1905	.1905	.1802	.1905	1.1145	.8002
Max	1.4918	1.6766	1.4918	1.7147	1.4091	1.5261
Min	.1905	.1107	.1802	.1905	.1311	.1619
Avg	1.0488	.3941	.6026	1.2958	.7692	.6221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 202 / 11 KV SANGAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763		.6554	.4382		2.3739
2	.5144	.6478	.6554	.5525		2.5232
3	.5525		.5735	.6097		2.5434
4	.4572	.6287	.5571	.5906		2.6216
5	.5716		.5571	.5716		2.6216
6	.743	.5906	.5506	.6478		2.7035
7	.743		.4096	.5716		2.8673
8	.6097	.5906	.4049	.5335	.4973	2.9504
9	2.7343	3.0178	2.7195		.4641	.5716
10		3.0769	2.8235		.4534	.6668
11		3.1352	2.6406		.4915	.6097
12		3.0514	2.4223		.4915	.5525
13		3.0011	2.4059		.4641	.5144
16		3.1352	2.4966		.503	.5144
17		.5365	.5906		.503	.5716
18		.5533	.6478		.5121	.4954
19		.6706	.6668		.57	.5525
20		.7545	.6097		.5571	.4763
21		.7287	.5525		.57	.5144
22		.7122	.6478		.5365	.5716
23		.7122	.6097		.4801	.5525
24	.6097	.7049	.7122	.6287	.5144	.4096
Max	2.7343	3.1352	2.8235	.6478	.57	2.9504
Min	.4572	.5365	.4049	.4382	.4534	.4096
Avg	.8012	1.4582	1.1322	.5716	.5072	1.3081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 203 / 11 KV RANMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4382	.3978	.5144		.5087
2	.4382		.407	.4763		.5256
3	.4763	.5716	.4588	.6287		.5426
4	.4382		.5935	.4954		.5243
5	.5144	.6287	.5735	.5716		.5344
6	.6668		.5935	.6668		.5281
7	.6668		.5571	.6097		.4481
8	.6668	.6287	.6219	.6668	1.6804	.4588
9		.503	.6097		1.6617	2.6673
10		.503	.6478		1.587	2.1102
11		.4527	.6097		2.2939	1.9566
12		.4862	.5716		2.332	2.062
13		.4024	.5716		2.2672	1.9616
16		.4191	.4954		2.0243	
17		1.643	1.3375		.4024	
18		1.6194	1.4563		.4096	
19		1.7436	1.4299		.5243	.5716
20		1.704	1.4861		.57	.6478
21		1.6385	1.511		.503	.5906
22		1.6078	1.4861		.503	.6668
23		1.5893	1.5697		.4862	.6287
24	1.7736	1.8861	1.5708	1.4861	.6516	.4641
Max	1.7736	1.8861	1.5708	1.4861	2.332	2.6673
Min	.4001	.4024	.3978	.4763	.4024	.4481
Avg	.6712	1.0259	.8889	.6795	1.1931	.9683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 204 / 11 KV JADHAVWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.5242	1.7004	2.4768		.1905
2	2.7244		1.8023	2.6673		.2286
3	3.1626	2.0957	2.1548	3.2388		.2543
4	3.0483		2.2672	3.0483		.3391
5	3.2388	2.4768	2.3482	3.4103		.3239
6	3.6199	3.0483	2.4291	3.6199		.3391
7	3.6199	3.6199	2.753	3.4294		.3277
8	3.4294	3.4294	2.8807	3.4294	.1715	.3277
9		.16	.1905		.1638	.1905
10		.1677	.1905		.1638	.1905
11		.1753			.1638	.1905
12		.1638	.1905		.1638	.1905
13		.1753	.1905		.1696	.1905
16		.1696	.1905		.1696	.1905
17		.1638	.1905			3.0521
18		.3315	.1905		3.1855	3.2217
19		.3277	.1905		3.0178	3.1855
20		.3467	.1905		2.8502	.5716
21		.3391	.1905		2.8502	.743
22		.3277	.1905		2.6825	.6478
23		.3467	.1905		2.6825	.7049
24	.2858	.381	.3391	.1905	2.7435	2.4291
Max	3.6199	3.6199	2.8807	3.6199	3.1855	3.2217
Min	.2858	.16	.1905	.1905	.1638	.1905
Avg	2.8239	.9885	.9981	2.8345	1.5127	.8195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 205 / 11 KV BARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3429	.2949	.5144		.4096
2	.4572		.3841	.4382		.4096
3	.381	.381	.3932	.4763		.4534
4	.4763		.4096	.4191		.4748
5	.4191	.4382	.4424	.5525		.4858
6	.5144		.4424	.5906		.4801
7	.5144	.4382		.5716		.4096
8	.4763	.381		.4382	.463	.4049
9			.362		2.6543	2.66
10			.3239		3.2769	2.2291
11			.2858		3.2217	2.2291
12			.2286		2.5587	2.5737
13			.2096		2.2996	2.2276
16			.3048		2.8487	2.66
17			2.2291			.362
18			2.6749		.3932	.2858
19		2.4966	2.7995		.3521	.3239
20		2.5286	2.6189		.3441	.362
21		2.6113	3.4294		.3521	.3048
22		2.2672	2.8578		.2949	.2667
23		2.0809	2.6673		.3113	.2858
24	2.3703	2.7435	2.0325	2.553	.3429	.2753
Max	2.3703	2.7435	3.4294	2.553	3.2769	2.66
Min	.381	.3429	.2096	.4191	.2949	.2667
Avg	.6677	1.5190	1.2695	.7282	1.4081	.9352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 206 / 11 KV Karkamb Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.7392	.7621		.543
2	.7621	.7621	.7392	.7621		.543
3	.6783		.7545	.7621		.5373
4	.6783	.7621	.9335	.7621		.7316
5	.7621		.905	.9526		.724
6	.7621	.9526	.905	.9526		.7316
7	.7621		.724	.7621		.7011
8	.6783	.7621	.724	.7621	.6859	.724
9		.6478	.7621		.7011	.7621
10		.6401	.6783		.7164	.7621
11		.6478	.7621		.7011	.7621
12		.6554	.7621		.724	.7621
13		.4801	.7621		.543	.7621
14		.4801	.7621		.5373	.7621
15		.6478	.7621		.5373	.7621
16		.6554	.7621		.724	.7621
17		.6706	.7621		.6706	.7621
18		.8383	.9526		.6706	.6783
19		.8383	.9526		.6706	.8478
20		.8383	.7621		.8192	.8383
21		.7011	.7621		.8383	.7621
22		.724	.7621		.6706	.7621
23		.7468	.7621		.6706	.7621
24	.7621	.7621	.7468	.7621	.6859	.5258
Max	.7621	.9526	.9526	.9526	.8383	.8478
Min	.6783	.4801	.6783	.7621	.5373	.5258
Avg	.7342	.7106	.7875	.8044	.6804	.7196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 207 / 11 KV Diwan Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1905	.3239		.4572
2	.4572	.2858	.2858	.4001		.4572
3	.4001		.3429	.362		.4572
4	.4763	.3429	.3429	.4763		.4763
5	.4382		.4763	.4572		.4763
6	.5144	.381	.4763	.5335		.4763
7	.5144		.4191	.5144		.3048
8	.3239	.381	.4191	.5525	.3429	.3048
9		.285	.362		2.8578	3.4294
10		.1677	.3239		3.1436	3.5437
11		.16	.362		3.1436	3.6199
12		.16	.381		3.0483	3.8104
13		.1638	.381		2.8578	4.02
16		.2429	.3239		3.1626	4.0771
17		2.7854	3.1207		.503	
18		3.2388	3.4179		.503	
19		3.0102	2.9487		.4915	.381
20		2.6155	2.8235		.503	.4382
21		2.934	2.4082		.503	.4191
22		2.8578	2.5587		.503	.4763
23		2.8578	3.5056		.4915	.4001
24	3.6199	3.0483	2.8578	3.1878	.5144	.4382
Max	3.6199	3.2388	3.5056	3.1878	3.1626	4.0771
Min	.1905	.16	.1905	.3239	.3429	.3048
Avg	.7705	1.4399	1.3058	.7564	1.5046	1.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 208 / 11 KV DESHMUKH PATT
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905		
2	.1905		.1905		
3	.1905	.1905	.1905		
4	.1905		.1905		
5	.1905	.1905	.1905		
6	.1905		.1905		
7	.1905	.1905	.1905		
8	.1905		.1905	3.4294	
9					.1905
10					.1905
11					.1905
12					.1905
13					.1905
16					.1905
17		.1677			.1905
18		.1677			.1905
19		.1638			.1905
20		.16			
22					.1905
23					.1905
24	.1905	.1905	.1905	.1715	
Max	.1905	.1905	.1905	3.4294	.1905
Min	.1905	.16	.1905	.1715	.1905
Avg	.1905	.1791	.1905	1.8005	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 209 / 11 KV GULAME FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	1.7147	1.8652	1.9319		.3467
2	1.989		1.8233	2.6673		.3582
3	2.5774	2.0957	1.989	2.6482		.3506
4	2.8578		2.5911	2.8578		.5087
5	2.4697	2.2862	2.6216	2.6673		.4858
6	2.6673		2.8826	2.8578		.4744
7	2.3739	2.6673	1.8023	2.8578		.3315
8	2.5149	2.4768	1.8023	2.6673	.3429	.3391
9			.3239			
10		.3277	.381			
11		.2458	.3239			
12		.16	.2858			
13		.3201	.1905			
16		.16	.1905		.1638	
17		.16	.381			3.0483
18		.3041	.4763		2.6825	2.5149
19		.3239			2.5819	2.6023
20		.3239	.4763		2.3472	2.6825
21		.3239	.5525		2.3472	2.1795
22		.3391	.381		2.1795	2.3472
23		.3391	.381		2.1795	2.1795
24	.381	.381	.3391	.381	1.8861	1.9071
Max	2.8578	2.6673	2.8826	2.8578	2.6825	3.0483
Min	.381	.16	.1905	.381	.1638	.3315
Avg	2.2564	.8305	1.0505	2.3929	1.8567	1.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 201 / 11 KV MENDHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6413	.7167	2.7854	3.1093	3.4332	3.5141
2	.6602	.6413	.7545	2.7854	3.1417	3.4656	3.5141
3	.6602	.7167	.7922	2.834	3.2712	3.4656	3.5789
4	.7545	.7922	.9054	2.834	3.4494	3.5627	3.6761
5	.8488	.9054	.9431	2.9473	3.7409	3.5951	3.7247
6	.9242	1.0751	.9054	3.0445	3.919	3.7247	3.7732
7	.9431	.9808	.9242	3.1741	3.4332		3.8218
8	.7922	.8676	.679	.7545	.7545		.8488
9	.6413	.6036	.679		.7167		.8488
10	.6036	.5658	.6036	.6036	.7167		.6036
11	.4527	.5281	.6036		.7167	.6602	.679
12			.5281		.6602	.7922	.6036
13	.4527				.4527	.7167	.679
14	.8865	.7545				.6602	.679
15	.7545	.7545	.6036			.6036	.7545
16	3.7571	3.5465	3.7247		.6036	.6036	.679
17	4.0486	3.6113	3.5627		.7167	.6036	.6036
18	3.9676	3.6437	3.6923	.679	.8299	.6036	.6036
19	3.8542	3.0931	3.8218			.7545	
20	3.7409	3.336	3.6275	.9431	.9431	.8488	.9431
21	3.5789	3.3198	3.6599		.8299	.9808	.9054
22	3.3846	3.0121	3.0445	.8676	.7922	.9054	.7922
23	3.0931	2.9473	2.915		.7545	.8299	.6036
24	.7356	.6979	.7922	2.915	2.9797	3.4494	3.6923
Max	4.0486	3.6437	3.8218	3.1741	3.919	3.7247	3.8218
Min	.4527	.5281	.5281	.6036	.4527	.6036	.6036
Avg	1.7501	1.6834	1.7490	2.0898	1.7396	1.7130	1.7444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 202 / 11 KV KHARATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.1886	.2263	.2829	.1509	.1886	.1132
2	.2641	.1698	.1886	.3018	.1509	.2263	.1132
3	.2829	.1698	.1886	.3018	.1698	.2263	.132
4	.3018	.1698	.2263	.3584	.1698	.2641	.132
5	.3206	.1886	.2829	.415	.1886	.2641	.1509
6	.3206	.2263	.3018	.5093	.2263	.2829	.1509
7	.3206	.2452	.3018	.5093	.2452	.1509	
8	2.7854	2.6882	2.9959	.4715	.2263	.2263	.3772
9	2.9797	2.9473	3.1741		.2075	.1715	.3395
10	3.1093	2.9797	2.7044	.1509	.1886	.1509	.2075
11	3.1741	3.3198	2.753		.1886	.1509	.1886
12	3.2388	3.0931	3.0607		.1509	.1509	.1886
13	3.2712	2.6882	2.9473		.1132	.1509	.1509
14					.1132	.1509	
15	2.9959	2.834	2.915		.1132	.1509	3.336
16		.1886			2.8826	3.0445	2.9797
17		.1886			3.2388	3.4818	2.9797
18				3.2065	3.1093	3.0607	2.7854
19		.1886		3.1417	2.6397	3.5465	3.0769
20	.1509	.2263	.4715	3.0931	3.0607	3.4494	3.1093
21	.2075	.2263	.415		3.1255	3.3198	3.1417
22	.2263	.1886	.3395	2.7854	2.9959	3.1093	2.672
23	.2075	.1509	.2829	2.672	2.9473	2.9797	2.332
24	.2452	.1886	.2641	.2829	.1509	.1509	.1132
Max	3.2712	3.3198	3.1741	3.2065	3.2388	3.5465	3.336
Min	.1509	.1509	.1886	.1509	.1132	.1509	.1132
Avg	1.2982	1.0661	1.2652	1.2322	1.1147	1.2104	1.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 203 / 11 KV PANDHAREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.8299	1.8785	.1509	.1132	.1509	.132
2	1.587	1.8623	1.8785	.1509	.1132	.1698	.132
3	1.6032	1.9595	1.9109	.1886	.132	.1698	.1698
4	1.7814	2.0567	1.9919	.2641	.1698	.2263	.2075
5	1.8299	2.1214	2.1052	.2829	.1698	.3018	.2452
6	1.9271	2.2186	2.2348	.3772	.1886	.3206	.3584
7	1.9109	2.0891	2.2996	.2452	.2829	.2829	
8	.3206	.2829	.1509	2.17	2.2348	2.1052	1.9433
9	.1698	.2452	.2829		2.2672	2.3482	2.1052
10	.132	.1886	.1698		2.2996	2.2672	2.251
11	.0943	.0943	.1509		2.2672	2.2996	2.0405
12		.0754			2.1052	2.2672	2.251
13		.0754	.1509		1.8785	2.17	2.1052
14		.0754	.0754				
15		.1132	.0943		1.9109	2.1538	1.5546
16		.0943			.0943		
17		.132			.0943		
18		.1509		.132	.0943		
19	.2452	.2263					
20	.2829	.2263	.3395	.2452	.1509	.1886	.2829
21	.3206	.2263	.2829	.2075	.1509	.2452	.2452
22	.2641	.1886	.1509	.1698	.1509	.2075	.2263
23	.1509	.1698	.1509	.132	.1509	.1698	.1886
24	1.7166	1.7814	1.7976	.1509	.132	.1509	.132
Max	1.9271	2.2186	2.2996	2.17	2.2996	2.3482	2.251
Min	.0943	.0754	.0754	.132	.0943	.1509	.132
Avg	.9386	.7702	.9524	.3477	.7796	.9576	.9206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 204 / 11 KV Jadhavwadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2452	.2263	.3018	.2452	.2263
2	2.2672	2.7044	2.9473	.2452	.3018	.2452	.2263
3	2.4453	2.9312	2.9797	.2641	.3206	.2641	.2263
4	2.8664	3.1579	3.0769	.3395	.3584	.2829	.2641
5	3.0931	3.5789	3.7247	.3395	.3961	.3018	.2829
6	3.255	3.9838	3.919	.3961	.4338	.3395	.3018
7	3.5465	3.9352	3.7247	.3772	.3584	.2829	.3206
8	3.8704	3.8866		.3584		.3772	.2829
9	3.8056	3.8542	3.8056				.1886
10	3.7409	3.919	3.8056	3.4494			.1132
11	3.6923	3.6761	3.8542			.2641	
12			.132		3.8866	3.8866	3.2874
13						3.9352	3.8542
14		.1509			3.6761	3.6437	3.5951
15		.1698			3.919		
16	.0943	.1698	.1698		3.7409		3.7409
17	.1132	.132	.1509		3.838	4.0809	3.8542
18	.1698	.3018	.1509	3.8056	3.7247	3.5789	3.4008
19	.2829	.3018	.1509	3.6599	3.3684	3.9514	3.255
20	.3206	.3018	.3772	.2263	.2263	.2829	.2829
21	.3961	.2829	.3395	.2452	.2452	.3584	.2452
22	.3584	.2829	.2829	.2641		.3206	.2263
23	.2263	.2641	.2829	.3018		.2452	.2263
24	.2452	.2263	.2641	.2829	.3018	.2263	.2452
Max	3.8704	3.9838	3.919	3.8056	3.919	4.0809	3.8542
Min	.0943	.132	.132	.2263	.2263	.2263	.1132
Avg	1.7508	1.7472	1.7192	.9238	1.7293	1.3557	1.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 205 / 11 KV Ropale Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2452	.2075	.1886	.2452	.2263	.1886
2	.2641	.2452	.2263	2.1795	2.1376	2.1376	1.7004
3	.2829	.2452	.2452	2.1052	2.251	2.2024	1.8138
4	.3018	.2641	.2452	2.3482	2.4939	2.2996	1.9595
5	.3018	.2829	.2641	2.5101	2.672	2.4291	2.1376
6	.3206	.3018	.2829	2.672	2.8016	2.5263	2.5749
7	.3206			2.834		2.4129	2.8178
8	.3018			2.9635	2.5911	2.834	2.915
9					2.4615	2.8178	2.9959
10					2.4615	2.5263	2.6073
11					2.4939	2.4615	2.7044
12	2.4453	2.9312	3.0121				
13	3.0445	1.9433	2.9635				
14	2.7692	2.915	.3239				
15			2.6235				
16	2.753	3.0769	3.0769				
17	2.4939	2.6397	2.9635				
18	2.7206	3.1255	2.915				
19	2.672	2.3158	2.9635				
20	.1886	.1886	.1886	.1886	.1886	.1886	.2263
21	.2075	.1886	.1886	.2263	.2452	.1886	.2641
22	.2075	.2075	.2641	.2263	.2452	.1886	.2263
23	.2263	.2075	.2263	.2452	.2452	.1886	.2263
24	.2641	.2263	.1886	.1886	.2452	.2452	.1886
Max	3.0445	3.1255	3.0769	2.9635	2.8016	2.834	2.9959
Min	.1886	.1886	.1886	.1886	.1886	.1886	.1886
Avg	1.1175	1.1972	1.2300	1.4520	1.5852	1.6171	1.5967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 201 / 11 KV DEWADE FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.2291	2.2291	.5144	.4115	.4115	.5487
2	2.0576	2.4006	2.2291	.5144	.5144	.4801	.5487
3	2.0576	2.572	2.3148	.4973	.5144	.5144	.5658
4	2.4006	2.572	2.4006	.4801	.5144	.5487	.6001
5	2.4006	2.572	2.572	.4973	.6001	.583	.6173
6	2.3663	2.572	2.572	.5144	.5144		.6859
7	2.5892	2.572	2.7435	.5487		.5487	
8	2.6063	2.572	2.4863	.4801		.5144	
17	.3772	.3429	.3258		2.4006	2.6406	
18	.5144	.4973	.3944		2.572	2.9182	2.0576
19	.5144	.583	.3429	2.6063	2.4006	2.7435	2.3148
20		.5487	.3772		2.4006	2.7435	2.6406
21	.5487	.5487	.4287		2.4863		2.5377
22	.5658	.5487	.4973		2.4006	2.915	2.4348
23	.5144	.5144	.4801		2.4006	2.7435	2.3663
24	.4973	.5144	.5144	.4973	2.4006	2.4006	2.572
Max	2.6063	2.572	2.7435	2.6063	2.572	2.9182	2.6406
Min	.3772	.3429	.3258	.4801	.4115	.4115	.5487
Avg	1.4483	1.5100	1.4318	.7150	1.6094	1.6218	1.5762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 202 / 11 KV WATER SUPPLY FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	1.3717	1.3717		.5144	.3429	.3429
2	1.5432	1.3717	1.3717	.4458	.3429	.3429	.5144
3			1.3717	.4287	.5144	.3429	.5144
4	1.5432	1.3717	1.3717	.4801	.5144		.5144
5	1.5432	1.5432	1.5432	.4973		.3429	.5144
6	1.5432	1.5432	1.5432				.4115
7	1.5432	1.5432	1.5432	.4115			
8	1.5432	1.7147	1.5432				
9	1.6804	1.3717	1.7147				
10		1.4575	1.8519				
11	1.5432	1.5432	1.9719				
12					1.7147	1.7147	
13					1.5432	1.7147	
14						1.8519	
16					1.7147	1.7147	
17					1.7147	1.7147	
18					1.7147	1.5432	
19		.1715		1.5432	1.7147	1.7147	1.7833
20	.3429	.3429	.4458	.3429	.5144	.3429	2.0233
21		.3429	.4973	.3429	.5144		.3086
22	.3437	.3429	.5487		.5144		.4458
23	.3429	.3429	.6687	.3429	.5144	.5144	.5144
24	.3429	.3429	.3429	.4973	.5144	.5144	.5144
Max	1.6804	1.7147	1.9719	1.5432	1.7147	1.8519	2.0233
Min	.3429	.1715	.3429	.3429	.3429	.3429	.3086
Avg	1.0922	1.0449	1.2313	.5333	.9717	1.0509	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 203 / 11 KV PAT KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.2291		.2572	.1715	.3429
2	2.0576	2.2291	.2401	.1715	.1715	.3429
3	2.0576	2.0576	.2572	.1715	.2058	.3429
4	2.0576	2.0576	.2572	.1715	.2058	.3429
5	2.0576	2.2291	.2915	.1715	.2401	.3429
6	2.0576	2.4006	.2915	.2572	.2058	.3429
7	2.0576	2.4006	.3086		.2058	
8	2.0576	2.4006			.2058	
10			.2743			
17				2.4006	2.2291	
18		.1715		2.4006	2.6749	2.0576
19		.1715	2.4006	2.4006	2.572	2.4006
20	.1715	.1715	2.4006	2.4006	2.572	2.572
21	.1715	.1715	2.4006	2.4006		2.572
22	.1715	.1715	2.4006	2.4006	2.572	2.7435
23	.1715	.1715	2.4006	2.4006	2.572	2.7435
24	.1715	2.0576	.2229	2.4006	2.4006	2.572
Max	2.0576	2.4006	2.4006	2.4006	2.6749	2.7435
Min	.1715	.1715	.2229	.1715	.1715	.3429
Avg	1.3058	1.4061	1.0882	1.4575	1.2803	1.5168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 204 / 11 KV SHEVATE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0857		.0857	.1715	.1715
2	.1029	.0857	.0857	.0857	.1715	.1715	.1715
3	.1029	.0857	.0857	.0857	.1715	.1715	.1715
4	.1029	.0857	.0857	.0857	.1715	.1715	.1715
5		.1029	.1029		.1715		.1715
6	.1029	.1372	.1029	.1029	.1715	.1715	.1715
7	.1029	.1372	.1029	.1029	.1715		
8		.1372	.1029	.5847	.1715		
9					.8573	.7202	
10				.6001	.8916	.8573	
11					.9431	.7202	
12					.9431	.7888	
13					.9431	.7888	
14					.8916		
16					.9431	.7202	
17	.7888	.7716	.8402		.0857	.1715	
18	.9088	.8573	.8745		.0857	.1715	.12
19	.9431	.8573	.7888	.0857	.1029	.1715	.1029
20		.823	.8402	.1715	.1715		.1029
21	.8573	.7716	.7888	.1715	.1715	.1715	.1029
22	.8573	.7202	.7716	.1715	.1715		.12
23	.7716	.7716	.7202	.1715	.1715	.1715	.12
24	.6516	.6859	.7716	.6859	.0514	.1715	.1715
Max	.9431	.8573	.8745	.6859	.9431	.8573	.1715
Min	.1029	.0857	.0857	.0857	.0514	.1715	.1029
Avg	.4920	.4447	.4469	.2389	.3787	.3813	.1438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 205 / 11 KV OLD NANDURE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715		1.7147	1.7147	2.0576
2		.1715	.1715	2.0576	2.4006	1.8861	2.4006
3		.1715	.1715	2.2291	2.2291	1.8861	2.572
4	.1715	.1715	.1715	2.2291	2.4006	2.4006	2.7435
5	.1715	.1715	.1715	2.4006	2.572	2.4006	3.0864
6	.1715	.1715		2.4006	2.572	2.4006	2.7435
7		.1715		2.4006	2.572	2.4006	
8	.1715	.1715	1.8861	2.7435	2.572	2.4006	
9	1.7147	2.4006	1.9204				
10	2.0576	2.4006	1.989				
11		2.4006	1.8519				
12	2.0576	2.4006	1.9204				
13	2.2291	2.4006	1.7833				
14			1.8176				
15	2.2291	1.0288	1.9719				
16	2.2291	2.0576					
17	.1715						
19		.1715	.2229	.1715	.1715	.1715	.2229
20	.1715	.1715	.2058	.1715	.1715	.1715	.2401
21		.1715	.2058		.1715	.1715	.2401
22	.1715	.1715	.2229	.1715	.1715		.2572
23	.1715	.1715	.2229	.1715	.1715	.1715	.2229
24	.1715	.1715	.1715	.2229	.1715	.1715	.1715
Max	2.2291	2.4006	1.989	2.7435	2.572	2.4006	3.0864
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.8895	.8329	.9079	1.4475	1.433	1.4113	1.4132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 206 / 11 KV PAT.KUROLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1715	.1715		.1715	.1715	.3429
2	.3429	.1715	.1715	.1715	.1715	.3429	.3429
3	.3429	.3429	.3429	.1715	.1715	.3429	.3429
4	.3429	.3429	.3429	.3429	.1715	.3429	.3429
5	.3429	.3429	.3429	.3429	.3429	.3429	.3429
6	.3429	.3429	.3429	.3429	.3429		.3429
7	.3429	.3429	.3429	.3429	.3429		
8	.3429		.3429	.3429	.3429	.3429	
9	.3429	.3429	.3429	.1715	.1715	.1715	
10		.3429	.3429	.1715	.1715		
11	.1715	.1715	.1715		.1715	.1715	
12	.1715	.1715	.1715	.1715	.1715	.1715	
13		.1715	.1715		.1715	.1715	
14		.1715	.1715	.1715	.1715		
15		.1715	.1715	.1715	.1715		
16		.1715	.1715	.1715	.1715	.1715	
17	.1715	.1715	.1715	.1715	.1715	.1715	
18	.1715	.1715	.1715		.1715	.1715	
19	.3429	.3429	.1715	.3429	.1715	.3429	1.7833
20	.3429	.3429	.1715	.3429	.3429	.3429	2.0233
21	.3429	.3429	.3429	.3429	.3429	.3429	.3086
22	.3429	.3429	.3429	.3429	.3429	.3429	.3429
23	.3429	.3429	.3429	.1715	.1715	.3429	.3429
24	.1715	.3429	.3429	.3429	.1715	.1715	.3429
Max	.3429	.3429	.3429	.3429	.3429	.3429	2.0233
Min	.1715	.1715	.1715	.1715	.1715	.1715	.3086
Avg	.2978	.2684	.2572	.2572	.2215	.2617	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 207 / New Nandure

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715		2.915	2.915	1.2003
2	.1715	.1715	.2058	2.8807	3.0864	3.0864	3.0864
3		.1715	.2058	3.0178	3.0864	3.2579	4.8011
4		.3429	.2058	3.0864	3.2579	3.5665	3.6008
5		.3429	.2058	3.2922	3.6008	3.2579	3.0864
6		.3429	.2058	3.3951	3.6008	3.2579	1.7147
7		.3429		3.5322	2.572	3.0864	
8	.1715	3.6008		3.2579	3.6008	3.0864	
9	2.572	3.6008	3.6008				
10	3.0864	3.4294	3.5665				
11		3.4294	3.6008				
12	4.0295		3.5322				
13			3.5665				
14			3.1207				
15	3.5665	.6859	3.2236				
16	3.6008	3.6008	3.738				
17		3.6008					
18	.1715						
19		.2058	.2401	.1715	.1715	.1715	.2743
20	.1715	.2058	.2229	.3772	.2058		.2572
21		.2058	.2058	.3429	.2058		.2572
22	.1715	.2058	.2058	.3429	.2743	.3429	.2401
23	.1715	.1715	.2058	.3429	.2572	.3429	.2572
24	.1715	.1715	.1715	.2229	.3429	.2572	.3429
Max	4.0295	3.6008	3.738	3.5322	3.6008	3.5665	4.8011
Min	.1715	.1715	.1715	.1715	.1715	.1715	.2401
Avg	1.4021	1.2500	1.5201	1.8664	1.9413	2.2191	1.5932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 208 / taratgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715		.3429	.2058	.5144
2	.1715	.3429	.1715	.2058	.5144	.2058	.3429
3	.1715	.3429	.1715	.2229	.5144		.3429
4		.3429	.1715	.2572	.5144	.2572	.3429
5		.3429	.1715	.2743	.5144	.2572	.3429
6		.3429	.1715	.3086	.5144	.2572	
7		.3429	.1715	.3429			
8		.1715	.1715	.2572			
9				1.7833	1.8861	2.0576	
10				2.2291	2.0576	2.2291	
11					2.0576	2.5034	
12					2.4006	2.5034	
13					2.4006		
15					2.0576	2.4348	
16					2.0576	2.4348	
17	2.2291	2.572	2.1605				
18	2.2291	2.3148	2.2291			.1715	
19	2.0576	2.3148		.3429	.1715	.3429	.2572
20		2.4006	.3429	.5144	.1715	.3429	.2401
21	2.0576	2.572	2.0576	.5144	.1715		.2229
22	2.0576	2.572	.3429		.1715		.2229
23	2.0576	2.2291	2.0576	.5144	.1715	.3429	.2572
24	2.2291	.1715	2.2291	1.8861	.5144	.1715	.3429
Max	2.2291	2.572	2.2291	2.2291	2.4006	2.5034	.5144
Min	.1715	.1715	.1715	.2058	.1715	.1715	.2229
Avg	1.5432	1.2217	.8528	.6895	1.0108	1.0449	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 209 / 11 Kv khed Bhose

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.0288	.6859		.6859	.6859	.8573
2	1.3717	1.0288	.1715		3.0864	2.915	2.4006
3	.8573	.8573	.7716	2.8464		3.0864	3.0864
4	.8573	1.3717	.7716	2.9492	3.4294	3.4294	3.4294
5	.8573	1.5432	.8573	2.9835	3.4294	3.4294	3.4294
6	.8573		.9431		3.2579	3.4294	3.4294
7				3.0178	3.2922	3.4294	
8				3.0521			
9				2.692	3.4294	3.0864	
10				2.572	3.4294	3.6008	
11					3.0864	3.4294	
12	3.0864	2.8807					
13	3.0864	2.8635					
14	3.0864						
15		.3429					
16	3.2579	3.4294	3.1207				
17	3.2579	3.4294	3.0864				
18		3.4294	3.1036				1.3375
19	3.6008	3.4294	2.4348	.3429	.5144	.3429	1.406
20	.6859	.6859	1.3717	.6859	.7716	1.2003	1.4746
21		.7202	1.3032	1.0288	.7716		
22	.6859	.7202	1.3375	.8573	.6859	1.2003	1.4746
23	.8573	.6859	1.3546	1.0288	.6859	.3429	1.5775
24	1.5432	.6859	.6859	1.406	.6859	.6859	1.0288
Max	3.6008	3.4294	3.1207	3.0521	3.4294	3.6008	3.4294
Min	.6859	.3429	.1715	.3429	.5144	.3429	.8573
Avg	1.8433	1.7137	1.4666	1.9587	2.0828	2.2863	2.0776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 201 / 11 KV TUNGAT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.2058	.1543	.1886	.1372	.2058
2	2.4387	1.829	2.0881	.1715	.2058	.1715	.1886
3	2.6978	1.8595	2.3167	.1886	.2058	.2058	.1886
4	2.8197	1.9509	2.3777	.1886	.2229	.2229	.2058
5	2.8959	2.1643	2.5911	.2058	.2229	.2401	.2229
6	3.1703	2.5606	2.8045	.2058	.2401	.2572	.2401
7	2.9874	3.0026	3.0636	.1886	.2058	.2572	.2401
8	2.8197	3.0178	3.0636	.1715	.2058	.2401	.2229
9	2.2405	2.7435	2.713	.1715	.1886	.2401	
10	.1677	.2058	.2058	.2401	.1372	.1715	
11	.2058	.1886	.1886	.2229	.1372	.1543	.1715
12	.1886	.1715	.1715	2.7587	2.8959	2.6368	2.9874
13	.1886	.1543	.1715	2.7282	2.8045	3.0178	
14	.2058	.1543	.1715				2.8959
15	.2058	.1886	.1886	2.8502	2.6978	2.4996	2.6825
16	.1715	.1543	.1886	2.8959	2.8045	2.5149	3.1245
17	.1715	.1543	.2229	2.8045	2.0271	2.7587	2.7435
18	.1677	.1715	.2229	3.1245	2.3777	2.6216	2.8959
19	.1715	.1543	.2401	3.0788	2.774	2.5911	2.2253
20	.2401	.2058	.2229	.2229	.0335	.2058	.218
21	.2743	.1886	.2229	.2058	.0857	.2058	.2572
22	.2743		.2058	.2572	.1029	.1886	.2401
23	.2572	.1715	.1886	.2229	.12	.2058	.2572
24	.2058	.2401	.1886		.2058	.1372	.2058
Max	3.1703	3.0178	3.0636	3.1245	2.8959	3.0178	3.1245
Min	.1677	.1543	.1715	.1543	.0335	.1372	.1715
Avg	1.0572	.9509	1.0094	1.0572	.9170	.9514	1.0771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 202 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343		.0343	.0343	.0305	.0343
2	.0343	.0343	.0343	.7926	.823	.9145	.9602
3	.0343	.0343	.0343	.7926	.8535	.823	1.0669
4	.0343	.0343		.823	.9145	.9145	1.0669
5	.0343	.0343	.0343	.9145	.9755	.8383	1.1126
6	.0343	.0343	.0343	1.0364	1.1888	.8535	1.2346
7	.0343	.0343	.0343	1.1279	1.2803	1.4632	1.3565
8	.0343	.0343	.0343	1.2803	1.2803	1.3413	1.4937
9	.0343	.0343	.0343	1.2193	1.4022	1.2498	1.4327
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	1.1279	1.2955	1.2498				
13	1.3108	1.2803	1.2498				
14	1.3413	1.2955	1.2803				
15	1.3413	1.3413	1.3413				
16	1.2498	1.3108	1.3413				
17	1.2803	.9145	1.2498				
18	1.1888	.9145	1.1279	.0343	.0343	.0343	.0343
19	.9755	1.2498	1.2193	.0343	.0343	.0343	.0343
20	.0343	.0343	.0305	.0343	.0305	.0343	.0343
21	.0343	.0343	.0343	.0343	.0305	.0343	.0343
22	.0343	.0343	.0343	.0343	.0305	.0343	.0343
23	.0343	.0343	.0343	.0343	.0305	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0305	.0343
Max	1.3413	1.3413	1.3413	1.2803	1.4022	1.4632	1.4937
Min	.0343	.0343	.0305	.0343	.0305	.0305	.0343
Avg	.4319	.4230	.4789	.4628	.5026	.4852	.5593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	1.5089	1.9204		.0343	.0343	.0343	.0343
3	1.5089	1.9509		.0343	.0343	.0343	.0343
4	1.5394	1.9814		.0343	.0343	.0343	.0343
5	1.5242	2.0119		.0343	.0343	.0343	.0343
6	1.7223	2.2253	1.5394	.0343	.0343	.0343	.0343
7	2.0424	2.3167	2.3929	.0343	.0343	.0343	.0343
8	2.1338	2.1491	2.5758	.0343	.0343	.0343	.0343
9	2.0729	2.2405	2.4996	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12				2.4082	2.8045	2.3777	
13				2.4082	2.7435	2.6063	
14						2.5301	.7468
15					2.7435		2.0271
16				2.4082	2.1948	2.6825	2.1338
17				2.713	2.4996	2.4691	2.3167
18	.0343	.0343	.0343	2.7435	2.6825	2.3472	2.1643
19	.0343	.0343	.0343	2.713	2.3777	2.1643	2.1948
20	.0343	.0343	.0343	.0335	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0335	.0343	.0343	.0343	.0343	.0343
Max	2.1338	2.3167	2.5758	2.7435	2.8045	2.6825	2.3167
Min	.0343	.0335	.0343	.0335	.0343	.0343	.0343
Avg	.7998	.9521	.6679	.7246	.8085	.7707	.5515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 204 / 11 KV NARANCHOLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1715	.2058	.1372	.1543	.1715	.1886
2	.2058	.1543	.1715	1.2193	1.2193	1.2193	1.5394
3	.1886	.1543	.1543	1.3717	1.2955	1.448	1.7375
4	.1886	.1543	.1715	1.3717	1.326	1.7528	1.7985
5	.2229	.1715	.2058	1.5546	1.448	1.9814	1.8442
6	.2229	.1715	.2401	1.8595	2.0576	2.21	2.1338
7	.2743	.1543	.2401	2.1643	2.4996	2.2862	2.5301
8	.1886	.1543	.2229	2.3015	2.4539	2.6368	2.6825
9	.2229		.1886	2.2253	2.3777	2.5453	2.6825
10	.2058		.2229	.2743	.2401	.2401	.2572
11	.2229	.2229	.2401	.2286	.1372	.3601	.3601
12	2.2253	2.8807	2.5453				
13	2.4844	2.5149	2.5149				
14	2.5606	2.3929	2.5149				
15	2.6368	2.5758	2.5301				
16		1.5242					
17	2.4539	2.0119	2.5301				
18	2.2405	2.21	2.0576	.1886	.1372	.2058	.1715
19	1.448	1.8442	2.3167	.1886	.2743	.2743	.2058
20	.2401	.2743	.2229	.2229	.2229	.2572	.2401
21	.2058	.2743	.1886	.2058	.2058	.2801	.2058
22	.2058	.2058	.1886	.2058	.2229	.2572	.1886
23	.1886		.1715	.1886	.2058	.2058	.1715
24	.2229	.1715	.1715	.1715	.1715	.1715	.1886
Max	2.6368	2.8807	2.5453	2.3015	2.4996	2.6368	2.6825
Min	.1886	.1543	.1543	.1372	.1372	.1715	.1715
Avg	.8469	.9709	.8790	.8933	.9250	1.0280	1.0626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 205 / 11 KV TUNGAT GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4801	.442	.4801	1.3375	.3353	.4268
2	.4801	.4801	.3963	.4801	.4801	.3201	.4115
3	.5144	.4801	.4115	.4801	.4801	.3506	.5487
4	.5658	.5144	.4725	.5487	.4973	.381	.583
5	.6516	.6173	.5335	.6001	.583	.4572	.6859
6	.7545	.7202	.5487	.6173	.703	.5182	.6859
7	.583	.5144	.4572				
8	.4801	.4973	.4268				
9	.463	.4287	.381	.4973	.5487	.4115	.4801
10	.4973	.4115	.4801	.5658	.583	.4572	.4801
11	.5144	.4268	.4801	.4973	.5144	.4115	.4287
12	.4973	.381	.4458	.3944	.4973	.3201	.3258
13	.463	.3506	.463	.4115	.3258	.2896	.3601
14	.4287	.3506	.4115		.3429	.2896	.3772
15		.3048	.3772		.3601	.2743	.3429
16	.4115	.3353	.3944	.3429	.3429	.3048	.3429
17	.4458	.3201	.3772	.3944	.3601	.3048	.3258
18	.4458	.3353	.3944	.463	.4115	.3963	.4287
19	.5658	.4572	.463	.6001	.5487	.4725	.583
20	.6516	.5487	.6173	.6687	.6001	.5487	.6516
21	.6001	.4725	.6173	.6173	.6001	.503	.6859
22	.5316	.4572	.5487	.5658	.5487	.5182	.5658
23	.4801	.4572	.5316	.5144	.5144	.4572	.5144
24	.5144	.463	.4115	.5144	.4973	.3658	.442
Max	.7545	.7202	.6173	.6687	1.3375	.5487	.6859
Min	.4115	.3048	.3772	.3429	.3258	.2743	.3258
Avg	.5234	.4502	.4618	.5127	.5308	.3949	.4853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 201 / 11 KV KANHAPURI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1844		.2134	.2515	.3018	.285
2	.1677	.1509		.1981	.218	.3018	.2515
3	.2012	.218		.2134	.2515	.3353	.285
4	.2012	.1677		.1981	.285	.3353	.3185
5	.218	.2012		.2401	.2515	.3688	.2515
6	.2012	.2347		.2134	.3018	.3353	.3018
7	.1677	.2012		.1677	.218	.3018	.2515
8	.2012	.218		.1372	.1677	.3018	.2012
9	.1677	.1509		2.652	3.3029	3.4034	3.0514
10	.1677	.1677		2.5301	3.3532	3.4034	3.4034
11	.1509			2.934	3.5208	3.3532	3.094
12	.1341				3.4034	3.2693	3.4465
13	.1341					3.1855	3.0178
14					3.4034		
16	.1174				3.2693	3.2693	3.0788
17	3.1352		3.0483				
18	3.0681		3.094	.2515			
19	3.0011		3.0483	.285	.3018	.3353	
20	3.0178		3.0636	.3353	.3018	.3688	.3048
21	2.9675		3.0483	.3521	.3018	.4191	.3353
22			2.9874	.285	.3353	.3856	.3506
23			2.8654	.3521	.3353	.4191	.4115
24	2.8502	2.8166		2.8349	.3185	.3018	.3521
Max	3.1352	2.8166	3.094	2.934	3.5208	3.4034	3.4465
Min	.1174	.1509	2.8654	.1372	.1677	.3018	.2012
Avg	1.0219	.4283	3.0222	.7996	1.2046	1.2348	1.2101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 202 / 11 KV KAROLE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1492		.1067	.1372	.1372	.1457
2	.1433	.1619		.1067	.1581	.1581	.2035
3	.1254	.12		.1372	.1852	.1852	.1619
4	.1254	.1612		.1524	.1457	.1457	.1886
5	.1254	.1991		.1524	.1898	.1898	.2155
6	.1254	.1294		.1067	.1524	.1524	.208
7	.1254	.124		.1067	.1406	.1406	.1372
8	.1254	.1372		.1219	.1619	.1619	.0972
9	.12	.1227		2.2558	2.372	2.372	2.6578
10	.1227	.1372		2.0729	2.3777	2.3777	2.692
11	.0857			2.3703	2.3624	2.3148	2.3624
12	.0972				2.3624	2.2253	2.4082
13	.0753					2.5526	2.3929
14					2.3624		
16	.0514				2.0881	2.2834	2.1186
17	2.5029		2.3472			.1677	.1524
18	2.3245		2.3777	.1372		.1543	.1677
19	2.21		2.3777	.1581	.2229	.1656	.2058
20	2.2672		2.4082	.1505	.208	.2031	.2058
21	2.1142		2.3777	.1739	.208	.1658	.1524
22	2.1032		2.332	.1457	.1783	.1677	.1677
23	2.0557		2.452	.1981	.1783	.192	.1829
24	2.4034	2.2119		2.0729	.1656	.1656	.2006
Max	2.5029	2.2119	2.452	2.3703	2.3777	2.5526	2.692
Min	.0514	.12	2.332	.1067	.1372	.1372	.0972
Avg	.8897	.3322	2.3818	.5959	.8179	.7627	.7920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 204 / 11 KV UMBRE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4298		.4458	.4904	.951	.4755
2	.439	.4755		.4458	.4435	.9183	.5175
3	.4755	.4805		.4801	.4706	.9868	.5281
4	.5487	.5228		.583	.5658	1.0917	.5658
5	.5853	.6036		.583	.6413	1.1786	.6036
9	.5121	.4298		.4458	.4066	.8722	.4108
10	.4755	.362		.4115	.3582	.7994	.3734
11	.394			.3224	.3326	.3856	.3086
12	.3155				.2957	.3506	.2401
13	.2743				.2987	.3429	.2743
14	.2507				.2987	.2896	.2401
15	.2534				.2614	.2743	.2743
16	.2926				.2058	.3506	.3429
17	.3696		.3086		.2865	.3582	.4458
18	.3696		.3772	.4024	.3734	.439	.4801
19	.5121		.4801	.5014	.4298	.5281	.5487
20	.6036		.5487	.679	.5601	.6413	.5487
21			.5144	.5914	.5601	.5601	.583
22	.5228		.4801	.5544	.5228	.4854	.5487
23	.4805		.4458	.5228	.4458	.4435	.4801
24	.4298	.4207		.4458	.5175	.9831	
Max	.6036	.6036	.5487	.679	.6413	1.1786	.6036
Min	.2507	.362	.3086	.3224	.2058	.2743	.2401
Avg	.4272	.4656	.4507	.4943	.4174	.6300	.4395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 205 / 11KV Kanal Fata Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1493	2.7006		.463	.4119	.4119	.381
2	3.1493	2.6882		.4458	.4525	.4525	.3401
3	3.1493	2.649		.4115	.3944	.4031	.3858
4	3.1493	2.7435		.4801	.4887	.4835	.3961
5	3.2322	2.9254		.463	.4525	.4525	.3868
6	3.2322	3.1417			.4733	.4733	.4311
7	3.1493	3.1855		.4287	.3601	.3601	
8	3.0167	3.2579		.3429	.3045	.3045	
9	.2214	.3012		.3944	.2058	.2058	
10	.2214	.2915			.1907	.1886	
11	.1492				.2743		
12	.1543				.2915		
13	.2058						
14					.2818		
16	.2743				.2572		
17	.362		.3048		3.1855	3.155	2.9321
18	.3544		.3601	3.4979	3.2861	3.2985	2.9664
19	.4115		.3772	3.453	3.2861		3.155
20	.4557		.4287	3.1369	3.4294	3.2386	3.1379
21	.3601		.463	2.9835	3.5818	3.0283	3.0864
22			.463	3.0283	3.4027	3.1036	3.0693
23	.3366		.4458	3.275	3.2236	3.3311	3.035
24	.4024	.2984		.463	3.2065	3.2065	3.2065
Max	3.2322	3.2579	.463	3.4979	3.5818	3.3311	3.2065
Min	.1492	.2915	.3048	.3429	.1907	.1886	.3401
Avg	1.3875	2.1984	.4061	1.5511	1.4291	1.5351	1.9221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 206 / 11 KV SANGAVI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.2003		.1981	.16	.128	.112
2	1.4403	1.1203		.2058	.16	.096	.112
3	1.5203	1.2003		.2439	.144	.096	.112
4	1.5203	1.3283		.1981	.16	.128	.144
5	1.6004	1.4403		.2134	.208	.128	.176
6	1.6004	1.4883		.2286	.192	.128	.16
7	1.8442	1.5844		.2286	.144	.128	.16
8	1.6194	1.6164		.1981	.16	.128	.144
9	.1134	.112		.1219	.112	.1296	.112
10	.1134	.1509		.1372	.096	.1341	
11	.081			.081	.112	.112	.1067
12	.0972				.2721	.08	.1029
13	.081					.096	.0762
14					.2561		
16	.0648				.096	.096	.061
17	.1134		.1067		1.5364	1.5203	1.4784
18	.1457		.1219	1.3443	1.6004	1.4723	1.4632
19	.1619		.1829	1.4403	1.6324	1.4403	1.4937
20	.1943		.1677	1.5043	1.6804	1.5684	1.4632
21	.1619		.1829	1.4723	1.6804	1.6108	1.4175
22	.1619		.1677	1.3603	1.4883	1.3923	1.5775
23	.1134		.1715	1.4243	1.5203	1.3123	1.3413
24	.1134	.1296		.1677	1.4083	1.4403	1.2963
Max	1.8442	1.6164	.1829	1.5043	1.6804	1.6108	1.5775
Min	.0648	.112	.1067	.081	.096	.08	.061
Avg	.6501	1.0337	.1573	.5982	.6736	.6075	.6243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 207 / 11 KV JALOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.3077		2.8464	2.7149	3.0769	2.7511
2	.2534	.2715		2.8464	2.8235	3.0769	2.8235
3	.2896	.3077		2.8635	2.8959	3.0769	2.7149
4	.3258	.2715		2.8807	2.9864	3.1674	2.8778
5	.3258	.3077		2.915	2.914	3.1674	2.9864
6	.3258	.362		2.5911	3.0588	3.1855	3.0407
7	.2896	.2715		3.0178	3.095	3.1855	3.1674
8	.2896	.2172		2.9492	3.1674	3.1312	3.0769
9	3.276	3.276		.2058	.2353	.181	.1991
10	3.3484	3.4389		.1886	.1991	.181	.181
11	3.2579			.1267	.1991	.1991	.1715
12	3.1131				.181	.181	.1543
13	3.1855					.1629	.1372
14					.181		
16	3.2579				.2534	.1991	
17	.1991		.1372		.2534	.181	.1543
18	.181		.1543	.181	.2858	.181	.1715
19	.2715		.1886	.2353	.3077	.2353	.2572
20	.362		.2058	.2896	.3077	.2534	.2401
21	.3077			.3077	.3077	.181	.2401
22	.2715		.1886	.3439	.3982	.1991	.2058
23	.2353		.2058	.3077	.3258	.2172	
24	.2534	.2534		.1886	.1991	.3258	.181
Max	3.3484	3.4389	.2058	3.0178	3.1674	3.1855	3.1674
Min	.181	.2172	.1372	.1267	.181	.1629	.1372
Avg	1.0852	.8441	.1801	1.4047	1.2405	1.2703	1.2866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 208 / 11 KV KALANANI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0457	.0663	.0452	.0457
2			.0457	.0486	.0452	.0633
3			.0457	.0678	.0452	.0497
4			.0457	.0486	.0452	.0648
5			.0457	.061	.0602	.0457
6			.0457	.048	.0602	.0625
7			.061	.048	.0602	.0457
8			.0457	.0486	.0602	.0648
9	.0526	.0497				
10	.0469	.0537				
11	.0633					
12	.0497					
13	.0648					
16	.0509					
Max	.0648	.0537	.061	.0678	.0602	.0648
Min	.0469	.0497	.0457	.048	.0452	.0457
Avg	.0547	.0517	.0476	.0546	.0527	.0553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 209 / 11 KV SUTAR MALA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524		.0171	.1905	.381	.1524
2	.1524	.1143		.2667	.2286	.381	.1905
3	.1524	.2286		.3048	.2667		.1524
4	.2286	.1905		.2667	.2286	.381	.1905
5	.2286	.2286		.3048	.2667	.4191	.2286
6	.1905	.1905		.3048	.2286	.4191	.1905
7	.1905	.1524		.3048	.1905	.381	
8	.1905	.1524			.1905	.381	
9	.1524	.1905		3.0864	3.6961	3.4294	3.658
10	.1524	.1905		3.5818	3.6199	3.4294	3.6199
11				3.7342	3.2579	3.315	3.658
12	.1143				3.6199	3.3913	3.6199
13	.0762					3.2769	3.658
14					3.6199		
16	.1143				3.6199	3.4294	3.5437
17	3.5056		3.5056				
18	4.0009		3.5437	.1905			
19	3.6199		3.5437	.2286	.3048	.2286	
20	3.8866		3.5056	.2286	.3048	.1905	.381
21	3.8866		3.5056	.1905	.3048	.2286	.381
22	3.8104		3.4294	.2286	.4191	.1905	.381
23	3.7342		3.3532	.2286	.381	.2286	.381
24	3.4294	3.6961		3.2769	.1905	.3429	.1905
Max	4.0009	3.6961	3.5437	3.7342	3.6961	3.4294	3.658
Min	.0762	.1143	3.3532	.0171	.1905	.1905	.1524
Avg	1.5242	.4988	3.4838	.9850	1.2565	1.2855	1.4457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 201 / 11 KV TARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.4049	.4763	.381	.0924	.1905	.1524
2	.1905	.2343	.4763	2.7515	1.6404	1.7394	1.8976
3	.1905	.3077	.4954	2.7515	1.8138	1.8404	1.9608
4	.2286	.3475	.4954	2.7831	1.9757	1.9204	2.0083
5	.2477	.3582	.4954	2.7989	1.8747	1.9528	2.1464
6	.2858	.3906	.5144	2.8147	1.8747	2.0525	1.8976
7	.2858	.4049	.4763	2.9887	2.2348	2.0881	
8				3.0994	2.0557	2.1403	
9				2.8622	2.0645	1.9766	2.2186
10	.1867				.1524	.1524	.0953
11	.1867	.1143			.1334	.1143	.0953
12	2.915	2.6871	2.7673				
13	2.9127	2.6566	2.9887				
14	2.8826	2.8967	2.7357				
15	2.774	2.8664					
17	2.834	2.8807	2.9254				
18	2.8549	2.7366	2.7673	.1867	.1143	.1715	.1307
19	2.609	2.6886	2.7357		.1905	.1905	.1629
20	.4525	.381	.4572	.128	.2286	.1905	.1629
21	.3801	.4382	.4572	.1307	.2096	.2096	.181
22	.4108	.4382	.381	.1307	.1905	.2096	.1867
23		.4572	.381	.0953	.1524	.1905	.0905
24	.2096	.4525	.4763	.381	.0747	.1524	.1524
Max	2.915	2.8967	2.9887	3.0994	2.2348	2.1403	2.2186
Min	.1867	.1143	.381	.0953	.0747	.1143	.0905
Avg	1.1614	1.2071	1.2501	1.6189	.9485	.9712	.8462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 202 / 11 KV KHARSOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0934	.0953	.1905	.5373	.4763	.4763
2	2.7206	2.915	2.7673	.1905	.2378	.4763	.4763
3	2.878	3.0769	2.8807	.1905	.2743	.4763	.4763
4	3.0045	3.0769	2.9254	.1905	.3658	.5716	.4763
5	3.0678	3.2388	3.0464	.2858	.4572	.5716	.1905
6	3.1626	2.9683	3.1245	.2858	.6535	.5716	.5716
7	3.1626	3.2388	3.1245	.2858	.1867		
8	3.1626	3.2388	3.1626				
9	3.2388	3.1245	2.5301				.4668
10	.1867	.0953	.0953	.2715			.5601
11	.2743	.0953	.0953	.0953			.181
12				3.2388	3.2007	3.1626	3.1245
13				3.2388	3.0483	3.1626	3.2388
14				3.2388	3.0483	3.1626	3.1687
15						.2286	1.2803
16						.2286	.8764
17				3.2388	3.0483	3.1626	3.2388
18					3.1245	3.1626	3.2388
19	.1867	.2858	.2858	3.2388	3.0483	3.1626	2.9959
20	.0953	.9526	.2858	.2772	.7621	.381	.724
21	.0934	.1905	.1905	.4668	.2858	.381	.724
22	.0934	.0953	.1905	.4382	.381	.381	.724
23	.0934	.0953	.1905	.362	.381	.4763	.905
24	.1905	.0934	.0953	.1905	.5316	.4763	.4763
Max	3.2388	3.2388	3.1626	3.2388	3.2007	3.1626	3.2388
Min	.0934	.0934	.0953	.0953	.1867	.2286	.181
Avg	1.5177	1.5809	1.4756	1.0482	1.3096	1.2985	1.2996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 203 / 11 KV MAGARWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1562	.1524	.1905	.1562	.1905	.1905
2	.1334	.1562	.1524	1.7394	1.7185	1.6766	1.7394
3	.1334	.1562	.1524	1.8185	1.8122	1.8061	1.7869
4	.1334	.1875	.1905	1.8185	1.5432	1.9052	1.866
5	.1334	.1562	.1905	1.8976	1.8519	1.9814	1.8976
6	.1524	.2343	.2286	2.0557	2.2138	2.2577	2.3245
7	.1524	.1562	.2858	2.2929	2.4291	2.3624	
8				2.372	2.372	2.2588	
9				2.2929	2.2276	2.2929	2.2653
10		.0953	.0953		.1143		.181
11		.0762	.0953		.0953		.1581
12		2.2276	2.0557				
13	2.3746	2.2862	2.2455				
14	2.1914	2.1373	2.372				
15	2.3434						
16	2.4684	2.1994					
17	2.4291	2.2291	2.2138				
18	2.2455		2.2138	.1562		.1715	.1619
19	2.284	2.1824	2.2455	.1562	.1524	.1524	.1638
20	.2343		.1905	.1581	.1905	.1905	.1696
21	.2315	.1524	.1905	.1875	.1905	.1905	.1696
22	.2343	.1524	.1905	.1875	.1905	.1905	.2543
23	.2343	.1524	.1905	.1581	.1905	.1905	.2035
24	.1334	.2343	.1524	.1905	.1562	.1905	.1905
Max	2.4684	2.2862	2.372	2.372	2.4291	2.3624	2.3245
Min	.1334	.0762	.0953	.1562	.0953	.1524	.1581
Avg	.9672	.8067	.7902	1.1045	1.0356	1.1255	.8577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 204 / Tarapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.3544	.3224	.3239	.3189	.3224	.3239
2	.2561	.3258	.3045	.2429	.3189	.3544	.3563
3	.2561	.3544	.3045	.2401	.3366	.3544	.3725
4	.2721	.3898	.3189	.3201	.3721	.3898	.3725
5	.2721	.443	.3898	.3887	.4252	.4763	.4049
6	.3005	.5316	.5316	.4858	.5316	.5316	.4858
7	.4858	.443	.443	.4481	.4784	.443	
8	.4111	.4252	.421	.4001	.443	.4075	.421
9	.4252		.3725	.3563	.3544	.3239	.4252
10	.3544	.3045	.2915	.3189	.3224	.3077	.3544
11	.3544	.2658	.2753	.2658	.2865	.3077	.2658
12		.2835	.2753	.2658	.2835	.2753	.3012
13	.3544	.2835	.2591	.3189	.3012	.2753	.3721
14	.2835	.2658	.2591	.2658	.3012	.2753	.3506
15	.2835	.2835	.2591	.2658	.3045	.2858	.3681
16	.2835	.2835	.253	.2658	.2865	.2858	.3155
17	.3189	.3189	.2915	.3189	.3189	.2753	.3721
18	.3189	2.2878	.3239	.3189	.3544	.3401	.3681
19	.443	.443	.4049	.443	.4961	.4641	.4382
20	.5316	.5373	.3725	.5316	.4477	.5144	
21	.443	.4477	.3239	.443	.4075	.4049	.443
22	.4075	.4119	.3239	.443	.3898	.3725	.4207
23	.3721	.3582	.3239	.3721	.3582	.3361	.3155
24	.2915	.3544	.3582	.3239	.3189	.3224	.3239
Max	.5316	2.2878	.5316	.5316	.5316	.5316	.4858
Min	.2561	.2658	.253	.2401	.2835	.2753	.2658
Avg	.3480	.4520	.3335	.3486	.3649	.3603	.3714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 206 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.1524	.3048	
2	.0191	.0191	.0191	.0381	.0381	.2858	
3	.0191	.0191	.0381	.0381	.0572	.2858	
4	.0381	.0191	.0381	.0381	.0762	.2858	.2286
5	.0381	.0381	.0381	.0381	.0953	.2858	.2286
6	.0381	.0381	.0381	.0381	.1334	.2858	.2477
7	.0381	.0381	.0572	.0381	.0762	.3048	
10	.0191	.0381	.0381				
11	.0191	.0381					
12	.3281	.2688	.3953		1.1385	1.0437	1.0936
13	.4111	.3637	.3953	.2286	1.1544	.9962	1.1584
14	.3795	.3795	.3953	.3506	1.1544	1.0911	1.1873
15		.3637		.5155			
16	.4111			.578			
17	.4062	.4111	.3953	.6405	1.1092	1.0279	1.0467
18	.3795	.3795	.4111	.7907	1.1248	1.0279	1.0279
19	.3953	.3953	.4111	.6958	1.1248	.9646	1.0722
20	.0381	.0381	.0381	.0953	.1524	.3048	.1715
21	.0191	.0381	.0381	.1715	.2667	.3048	.2667
22	.0191	.0381	.0381	.2096	.2858	.3048	.2858
23	.0191	.0381	.0381	.0953	.2858	.2667	.0762
24	.0191	.0191	.0381	.0191	.1524	.2858	.2667
Max	.4111	.4111	.4111	.7907	1.1544	1.0911	1.1873
Min	.0191	.0191	.0191	.0191	.0381	.2667	.0762
Avg	.1463	.1429	.1516	.2441	.4766	.5365	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 207 / 11 KV GANESH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1562	.0953	.0953	.0781	.1143	.0953
2	.0953	.1562	.0953	.7432	.6097	.6173	.6325
3	.0953	.1562	.1143	.7907	.6249	.6097	.6325
4	.0953	.1562	.1143	.8223	.6562	.6944	.6642
5	.1143	.1562	.1524	.9172	.703	.7621	.6642
6	.1143	.1562	.1524	.9488	.7716	.8383	.8697
7	.1143	.1562	.1905	.8697	.8488	.9145	
8				.8223	.9172	.884	
9				.7907	.8488	.8697	.8697
10	.0781	.0572		.0781	.0953		.0781
11	.0469	.0572		.0474	.0953	.0953	.0781
12	.8592	.7621	.8697				
13	.9061	.8488	.9488				
14	.9172	.8025	.8697				
16	.9061	.8383					
17	.9172	.945	.9488				
18	1.0467	.8383	.9488	.0781	.0953	.0953	.1562
19	.9172	.8025	.9488	.1562	.1143	.1143	.1619
20	.1562	.1524	.1524	.1562	.1905	.1143	.1581
21	.1543	.1143	.1143	.1581	.1905	.1143	.1581
22	.1524	.1143	.1143	.0949	.1905	.0953	.1619
23	.1562	.1143	.1143	.0937	.1524	.0953	.1562
24	.0953	.1524	.1143	.0953	.0781	.1143	.0953
Max	1.0467	.945	.9488	.9488	.9172	.9145	.8697
Min	.0469	.0572	.0953	.0474	.0781	.0953	.0781
Avg	.3825	.3663	.3922	.4310	.4034	.4202	.352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7735	.7735	.6935	.7335	.8288	.8002	.7868
2	.7735	.7735	.7335	.8383	1.0227	.9907	.9145
3	.7602	.7735	.7868	.9602	1.073	1.0364	.945
4	.8002	.8269	.8002	.9945	1.1568	1.2955	1.0364
5	1.0402	.9602	.9736	1.046	1.2887	1.3717	1.3032
6	1.1069	1.1336	1.0002	1.4403	1.4922	1.5089	1.4232
7	.7602	.7602	.9736	1.5089	1.5939	1.4918	1.5089
8	.5735	.7735	.9869	1.3717	1.448	1.3413	1.3413
9	.6668	.7068	.7335	1.3108	1.4937	1.3565	1.3108
10	.5468	.5335	.5601		1.4784	1.1736	1.3272
11	.4934	.4534	.4401			1.0517	1.247
12	1.4022	1.2651	1.387		.4801	.4801	.5624
13	1.448	1.2651	1.0669		.4534	.4668	.5213
14	1.4022	1.2346	1.0669		.4801	.5201	.5624
15	1.2193	1.2651	1.0974		.5068	.5335	.5761
16	1.2498	1.3413	1.3413		.5601	.5601	.5898
17	1.1888	1.4022	1.448		.5868	.6001	
18	1.2803	1.3108	1.448	.7682	.5735	.6268	.8177
19	.9145	1.1888	1.4175	.9736	.7602	.9069	.8901
20	1.0269	.9069	.9602	1.1126	.8135	.9602	.9717
21	.9469	.9335	.9069	1.0292	.9069	.9602	1.0292
22	.8802	.7335	.8535	.9728	.8669	.9069	1.0002
23	.6935	.6668	.8002	.9002	.8535	.8535	.8741
24	.7868	.6668	.6401	.7735	.8431	.8135	.8002
Max	1.448	1.4022	1.448	1.5089	1.5939	1.5089	1.5089
Min	.4934	.4534	.4401	.7335	.4534	.4668	.5213
Avg	.9473	.9437	.9632	1.0459	.9374	.9420	.9713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 202 / 11 KV ADHIV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4287	.4458	.463	.5083	.5144	.4801
2	1.4403		1.3413	.4801	.5083	.4801	.463
3	1.5775	1.3413	1.3717	.4801	.5375	.5316	.463
4	1.6118	1.4937	1.4937	.5144	.6173	.5658	.5487
5	1.6804	1.6766	1.7528	.5487	.6859	.6001	.6859
6	1.8861	1.7985	1.9662	.823	.7716	.6344	.8059
7	1.467	2.1186	2.3624	.7202	.5316	.6516	.4973
8	2.2119	1.9509	2.332	.463	.4287		
9	2.452	2.0271	2.3015	.3772	.3772		
10	1.7337	2.1491	2.1491	.4066	.3772	.4458	.5258
11	1.4403	2.0576	2.0576	.3681		.3772	
12	.3772	.3601	.3601	2.3137	2.1948	2.2558	2.2611
13	.3429	.3258	.3258		2.3929	2.3015	2.4366
14	.3601	.2915	.3601		2.1338	2.0119	2.4615
15	.3429	.3258	.3772		2.2558	1.9662	2.4291
16	.3772	.3429	.4115		1.9357	1.8595	2.4129
17	.4287	.3944	.4115		2.1795	1.829	2.304
18	.4801	.4458	.5487	2.3685	1.6004	2.0881	2.2939
19	.5658	.5487	.6687	2.251	1.9509	2.0424	2.2348
20	.7373	.583	.8573	.8775	.7773	.7545	.6588
21	.6687	.6173	.7202	.8059	.703	.703	.7011
22	.5658	.5316	.6173	.691	.6516	.6516	.6485
23	.4801	.5144	.5487	.5609	.6001	.5487	.567
24	.4801	.4458	.4801	.4973	.5258	.5316	.4801
Max	2.452	2.1491	2.3624	2.3685	2.3929	2.3015	2.4615
Min	.3429	.2915	.3258	.3681	.3772	.3772	.463
Avg	1.0064	.9900	1.0942	.8426	1.0976	1.1066	1.2552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 203 / 11 KV AJANSOND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	1.0364	1.1279	1.2193	1.448
3	.0191	.0191	.0191	1.0669	1.1888	1.326	1.448
4	.0191	.0191	.0191	1.1279	1.2346	1.5604	1.4937
5	.0191	.0191	.0191	1.2041	1.4022	1.6766	1.5851
6	.0191	.0191	.0191	1.4022	1.6918	1.6613	1.7985
7	.0191	.0191	.0191	1.7375	2.0424	1.7375	2.0576
8	.0191	.0191	.0191	1.9357		1.829	2.1643
9	.0191	.0191	.0191	1.9662		1.9662	2.0119
10	.0191	.0191	.0191			1.7528	1.9334
11	.0191	.0191	.0191			1.6004	1.7394
12	1.6613	1.768	1.6461			.0191	.0191
13	1.7071	1.829	1.6461				.0191
14	1.768	1.8442	1.5242		.0191	.0191	.0191
15	1.7375	1.8138	1.7833		.0191	.0191	.0191
16	1.7528	1.8138	1.9204		.0191	.0191	.0191
17	1.6309	1.7985	1.8138		.0191	.0191	.0191
18	1.4327	1.8747	1.7528	.0191	.0191	.0191	.0191
19	1.2651	1.8595	1.6918	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	1.768	1.8747	1.9204	1.9662	2.0424	1.9662	2.1643
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5525	.6211	.5868	.7269	.4954	.7208	.7478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 205 / 65 ACRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2058	.2229	.1886	.1715	.2229
2	.1886	.1715	.1886	.2229	.1886	.2058	.2229
3	.2058	.1715	.1715	.2229	.2058	.2229	.2229
4	.2229	.1886	.2229	.2401	.2229	.2229	.2058
5	.2401	.2229	.2401	.2743	.2401	.2401	.2058
6	.2743	.2401	.1715	.2401	.2401	.2058	.1715
7	.1715	.1886	.1543	.2058	.2058	.1715	.1886
8	.1715	.1715	.1372	.1715		.1372	.1886
9	.2058	.1715	.1372	.1543		.12	.1715
10	.1886	.2229	.1886	.181			.2012
11	.2058	.2229	.1886	.1578		.2058	.4607
12	.1886	.2058	.1715	.1928	.2058	.2058	.2507
13	.2058	.1886	.1543	.2103	.1886	.2058	.2507
14	.2058	.1886	.1543	.2103	.1715	.1715	.2507
15		.1715	.1715	.1928	.1886	.1715	.2507
16	.1886	.1715	.1543		.1715	.1715	.2507
17	.1886	.1543	.1543		.1886		.2353
18	.1543	.1715	.1715	.1791	.2058	.1886	.2149
19	.1886	.1372	.1886	.197	.2058	.2572	.2149
20	.2743	.1543	.2058	.2033	.2229	.2401	.2353
21	.2229	.1715	.2058	.197	.2058	.2058	.2534
22	.2401	.2229	.2401	.2149	.2058	.2229	.2328
23	.2058	.2058	.2401	.2149	.2229	.2572	.2328
24	.1467	.1886	.2229	.2401	.1886	.1886	.2572
Max	.2743	.2401	.2401	.2743	.2401	.2572	.4607
Min	.1467	.1372	.1372	.1543	.1715	.12	.1715
Avg	.2025	.1865	.1851	.2066	.2032	.1995	.2330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 201 / 11 KV PEHE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1829	.1677	.1829	.1524	.1372	.1219
2	1.3565	1.387	1.387	.1829	.1372	.1372	.1219
3	1.448	1.4327	1.5242	.1677	.1372	.1372	.1067
4	1.4937	1.5242	1.5699	.1677	.1372	.1372	.1067
5	1.7528	1.6766	1.6613	.1677	.1829	.1524	.1067
6	1.7985	1.7528	1.7833	.1677	.1829	.1677	.1219
7	1.829	1.829	1.8747	.1677	.1524	.1677	.1219
8	1.8747	1.9662	1.7985	.1677	.1524	.1372	.1372
9	1.829	1.829	1.829	1.6766	.1372	.1372	.1372
10	1.7985	1.7985	1.7528	1.7528	.1219	.0914	.1067
11	.9297	1.7071	1.7375		.0914	.1067	.1372
12	.1372	.2286	.1219		1.8747	1.9052	
13	.1219	.0914	.1219		1.9662	1.9814	2.0576
16	.1372	.1067	.1219		1.7985	1.9814	2.1948
17	.1524	.1067	.1219		1.9509	1.9204	.6097
18	.1524	.1219	.1219			1.8595	2.0881
19	.1677	.1372	.1829	1.7833		1.8595	1.9509
20	.1677	.1677	.1829	.1524	.1372	.1524	.1524
21	.1677	.1829	.1524	.1677	.1524	.1524	.1524
22	.2134		.1524	.1677	.1524	.1524	.1524
23	.2134		.1524	.1524	.1524	.1219	.1524
24	.1829	.1829	.1829	.1524	.1524	.1524	.1219
Max	1.8747	1.9662	1.8747	1.7833	1.9662	1.9814	2.1948
Min	.1219	.0914	.1219	.1524	.0914	.0914	.1067
Avg	.8224	.9206	.8501	.4611	.4961	.6249	.5218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 202 / 11 KV SUGAON BHOSE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2286	.2286	.2286	.2286	.1981	.1829
2	2.1033	2.5606	2.4387	.2286	.2439	.1981	.1829
3	2.1338	2.6216	2.5606	.2439	.2439	.1981	.1829
4	2.21	2.6825	2.6368	.2743	.2439	.2134	.2134
5	2.2862	2.7892	2.7435	.2896	.2896	.2286	.2134
6	2.3472	2.8959	2.8197	.3658	.2743	.2743	.2439
7	2.4996	2.9569	2.9874	.3353	.3048	.3048	.2896
8	2.7587	2.9874	2.5149	.3048	.2743	.2134	.2439
9		2.8807	2.8349	2.9874	.2286	.1981	.1981
10	2.8654	2.8045	2.9264	2.6368	.2134	.1829	.1372
11	2.4082	2.774	2.6673		.1829	.1981	.1372
12	.1067	.1524	.1677		2.8959	2.4691	
13	.1219	.1524	.1524			2.5911	2.3929
16	.1524	.1524	.1067			2.5301	2.4996
17	.1677	.1677	.1524			2.5606	2.4844
18	.1677		.2134			2.5911	2.4387
19	.2591	.2896	.3506	2.6673		2.5911	1.829
20	.2743	.2896	.3048	.3048		.2439	.2591
21	.2896	.2896	.2743	.2896	.2591	.2439	.2439
22	.2743		.2439	.2743	.2134	.2286	.2134
23	.2743		.2439	.2591	.2134	.2286	.1829
24	.1829	.2439	.2439	.2439	.2439	.2134	.2286
Max	2.8654	2.9874	2.9874	2.9874	2.8959	2.5911	2.4996
Min	.1067	.1524	.1067	.2286	.1829	.1829	.1372
Avg	1.1446	1.5747	1.3551	.7459	.4096	.8591	.7142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 203 / 11 KV BHOSE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3658	.3658	.3353	.3506	.3353	.3506
2	.3201	.381	.3658	.3353	.3658	.3353	.3506
3	.3353	.381	.3506	.3963	.3658	.3353	.3658
4	.3506	.4115	.3353	.4268	.4115	.3506	.3658
5	.381	.5335	.3506	.4725	.4877	.381	.4268
6	.4572	.6097	.4572	.6554	.5944	.442	.5487
7	.5639	.5944	.5792	.5487	.5639	.503	.6097
8	.5335	.4877	.5639	.4572	.4877	.442	.4877
9	.4572	.4115	.5335	.442	.4268	.3658	.442
10	.381	.3506	.3506	.3506	.3506	.3048	.381
11	.3201	.3201		.3048	.2896	.2896	.2896
12	.3658	.3048	.2896	.2896	.2896	.2439	
13	.381	.3048	.2134	.2743	.2743	.2286	.2591
14	.3353	.2743	.1981	.2591	.2743	.2134	.2743
15	.3048	.2896	.2286	.2743	.2591	.2134	.2896
16	.3201		.2896	.3048	.2896	.2743	.3353
17	.3658		.3658	.3506	.3353	.3048	.381
18	.3963		.442	.3963		.3506	.4572
19	.5792	.5487	.5792	.4572		.5182	.5487
20	.5487	.3334	.5182	.5487	.5487	.5487	.5182
21	.5182	.5335	.4572	.4725	.4877	.4877	.503
22	.4115		.4268	.381	.3963	.4268	.4572
23	.3963		.3658	.3658	.3658	.3658	.4115
24	.3658	.381	.381	.3353	.3506	.3506	.3658
Max	.5792	.6097	.5792	.6554	.5944	.5487	.6097
Min	.3048	.2743	.1981	.2591	.2591	.2134	.2591
Avg	.4052	.4114	.3916	.3931	.3894	.3588	.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 204 / 11 KV Sol Patti Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.2743	.2743	.2286	.1981	.2134	.2286
2	.1677	.2743	.2591	1.6766	2.4691	2.4387	2.2862
3	.1524	.2743	.2591	1.6766	2.5911	2.4996	2.2862
4	.1677	.2591	.2286	1.7985	2.6368	2.5606	2.4691
5	.2286	.2743	.2743	1.9204	2.7587	2.5911	2.5606
6	.2591	.2896	.3048	2.1338	2.8959	2.6673	2.6673
7	.3506	.2743	.381	2.4387	2.9416		2.8197
8	.2439	.2439	.3048	2.5911	2.652		2.8197
9	.2439	.2743		.1677	2.9569	2.8197	2.8654
10		.2439	.2439	.1829	2.8045	2.6978	2.8654
11	.1677	.1829	.2286		2.6216	2.7435	2.8197
12	2.6216	2.6673	2.7892		.1981	.2286	
13	2.8197	2.774	2.9416		.2591	.2286	.1981
16	2.8197	2.713	2.652		.2134	.2134	.2896
17	2.8502	2.8349	2.8197		.1981	.2743	.3048
18	2.7435	2.8959	2.9111			.3048	.3353
19	2.5301	2.5606	2.7892	.2896			.3658
20	.3048	.2743	.3048		.3353	.3201	.3658
21	.3353	.3353	.2743	.3658	.2896	.3048	.3506
22	.3201		.2591	.3201	.2591	.3048	.3201
23	.3048		.2591	.2591	.2439	.2743	.2896
24	.1829	.2896	.2896	.2743	.1981	.2286	.2286
Max	2.8502	2.8959	2.9416	2.5911	2.9569	2.8197	2.8654
Min	.1524	.1829	.2286	.1677	.1981	.2134	.1981
Avg	.9515	1.0105	1.0023	1.0883	1.4861	1.2586	1.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 205 / 11 KV Nematwadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1067	.1067	.1219	.1067	.1067	.1372
2	.1219	.1067	.1067	1.7985	1.326	1.1736	1.6766
3	.1219	.1067	.1067	1.829	1.3717	1.2193	1.6766
4	.1067	.1067	.1067	1.8595	1.5699	1.4632	1.7528
5	.1219	.1219	.1219	1.89	1.9052	1.6613	1.7528
6	.1372	.1524	.1372	1.9814	2.1338	1.7833	1.829
7	.1372	.1372	.1677	2.21	2.271	2.0424	1.9052
8	.1372	.1219	.1372	2.2558	2.1186	2.0881	1.9814
9	.1067	.1067	.1067	.1219	2.1491	1.9052	1.9814
10	.1067	.1067	.1219	.1524	1.9357	1.6156	1.7071
11	.1067	.1067	.1524		1.7375	1.5546	1.8138
12	2.0881	2.21	2.332		.1067	.0762	
13	2.1338	2.3624	2.2405		.1067	.0914	.0762
16	2.0576	2.21	2.2558		.0914	.0914	.1067
17	2.0729	2.2862	2.1033		.1067	.0914	.1372
18	2.1033	2.0729	1.89			.1067	.1524
19	1.9814	2.0576	1.829	.1067		.1829	.1677
20	.1524	.1219	.1219	.1219	.1829	.1829	.1524
21	.1524	.1524	.1372	.1372	.1524	.1524	.1524
22	.1372		.1372	.1219	.1677	.1524	.1524
23	.1372		.1219	.1219	.1372	.1219	.1372
24	.1219	.1219	.1219	.1219	.1067	.1067	.1219
Max	2.1338	2.3624	2.332	2.2558	2.271	2.0881	1.9814
Min	.1067	.1067	.1067	.1067	.0914	.0762	.0762
Avg	.6575	.7438	.6665	.9345	.9892	.8168	.9319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 202 / 11 Kv AMBE CHINCHOLI SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2193	1.2955	2.4577	2.3624	2.5857	2.6189
2	1.2193	1.1622	1.2955	2.3758	2.2862	2.5857	2.5987
3	1.1241	1.1622	1.2955	.823	2.4646	2.2775	2.5316
4	1.1241	1.1622	1.3336	.9145	.9526	1.0974	.724
5	1.1622	1.2193	1.4098	.8954	.9907	1.0974	.7621
6	1.2003	1.2955	1.5242	1.0745	1.0479	1.134	.9145
7	1.2193	1.6004	1.6004	1.1104	1.1431	1.134	1.105
8	1.2955	1.5242	1.5623	1.2071	1.2384	1.134	1.1812
9	1.3717	1.448	1.1431	1.0608	1.3908	1.134	1.3908
10	1.3336	1.4098	1.1431				
11	1.086	1.2955	.8048				
12	2.2611	2.5149	1.0974				
13	2.6543	2.5652					
14		2.6189					
15	2.6216	2.7328					
16	2.7362	2.7846	2.6216				
17	2.769	2.7846	2.6871				
18	2.8346	2.8018	2.6871		.9145		
19	1.4098	2.8018	2.7035	2.1338	.9145	1.0288	1.105
20	1.4098	1.3908	2.7035	2.2862	2.5857	2.5069	2.1033
21	1.448	1.3717	2.6216	2.3929	2.6189	2.6189	2.2558
22	1.3527	1.3527	2.4905	2.4234	2.6189	2.6216	2.5758
23	1.2955	1.3527	2.4905	2.4387	2.5857	2.7161	2.4387
24	1.2384		1.3336	2.4577	2.4387	2.5857	2.6216
Max	2.8346	2.8018	2.7035	2.4577	2.6189	2.7161	2.6216
Min	1.086	1.1622	.8048	.823	.9145	1.0288	.724
Avg	1.6255	1.8074	1.8021	1.7368	1.7846	1.8838	1.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 203 / 11 Kv JACKWELL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7072	1.9559	2.0153	.2858	.2667	.381	.381
2	1.6741	1.9062	1.9448	.2858	.2667	.2858	.362
3	.1905	.9282	1.1401	1.2963	.2286	.2858	.3429
4	.2286	.9614	1.1736	1.4883	1.9814	1.6095	1.7204
5	.2667	1.0277	1.2597	1.7924	2.1338	1.8778	1.9334
6	.3048	1.0608	1.4251	2.0645	2.431	2.146	2.0719
7	.3048	1.2763	1.5089	2.0805	2.2558	2.3472	2.3304
8	.9503	1.1768	1.4922		2.2558	1.7604	2.3594
9	1.0322	1.1797	1.4255		2.4143	1.9281	2.2634
10	.9614	1.1961	1.1469	1.6613	2.3137	2.1125	1.9966
11	.1715	.2667	.381	.2858	2.1795	2.1125	1.9814
12	.2667	.2858	.381	.1905	1.0159	1.2125	1.0517
13	.3239	.3048			1.1142	1.3108	1.0974
14	.7049	.3048			1.1469	1.3108	1.1126
15	.3048	.2858			1.1633	1.3245	1.2071
16	.2667	.2858	.2858		1.278	1.2431	1.2407
17	.2667	.2477	.2858		1.278	.9667	1.1431
18	.3048	.2858	.3048	.9297	1.278	1.0059	1.2742
19	.2858		.4001	1.0669	1.278	1.0486	1.2346
20	2.1216	2.4577	.381	.2286	.2858	.3429	.3239
21	2.0222	2.0972	.3239	.3429	.3239	.362	.3429
22	1.9559	2.1125	.3239	.3429	.4191	.381	.4001
23	2.0222	2.079	.3239	.3239	.381	.4001	.381
24	1.9559	1.989	2.0317		.3429	.4191	.381
Max	2.1216	2.4577	2.0317	2.0805	2.431	2.3472	2.3594
Min	.1715	.2477	.2858	.1905	.2286	.2858	.3239
Avg	.8581	1.1162	.9502	.9166	1.2513	1.1739	1.2055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 201 / 11 kv Nanure Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2715	.2534	.2534	.2507	.2328	.2534
2	.2715		.2896	.2534	.2328	.2507	.2534
3	.2534	.3077	.2896	.2896	.2865	.2507	.2896
4	.3258	.3189	.3258	.3258	.3224	.2865	.2896
5	.4163	.3734	.3801	.4163	.3224	.2865	.3258
6	.3982	.3721	.362	.4024	.2865	.3045	.3258
7	.3982	.3721	.3258	.3258	.3224	.3224	
8	.3258	.3012	.2896	.2896	.2507	.2865	
9	.2715	.2172	.2534	.2534	.2149	.2507	
10	.2353	.2172		.2172	.2149	.2149	
11	.2172		.181		.197	.1791	
12	.2172		.1448	.1991	.197	.197	
13	.181		.1448	.1991	.1791	.1991	.1629
14			.1629	.1991	.1791	.2172	.1629
15	.1991	.2896	.1629	.2172	.1791	.2534	
16	.2172	.2534	.181	.1991	.1791	.2715	
17	.2353	.2353	.1991	.1991	.2149	.2715	
18	.2715	.2896	.2353	.2353		.2896	.1646
19	.3258	.3801	.2715	.3439		.3439	.3801
20	.3982	.362	.4163	.362	.3403	.3439	.3982
21	.362	.3258	.3982	.3258	.3403	.3258	.3258
22	.3258	.2896	.3801	.2896	.3045	.3077	.2896
23	.2715	.2534	.3258	.2534	.2507	.2534	.2896
24	.2896	.2715	.2534	.2926	.2507	.2507	.2534
Max	.4163	.3801	.4163	.4163	.3403	.3439	.3982
Min	.181	.2172	.1448	.1991	.1791	.1791	.1629
Avg	.2912	.3001	.2707	.2757	.2507	.2663	.2776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 202 / 11 KV Pehe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658		.1823	.116	.1311	.116	.1311
2	.1658		.1989	2.9504	2.8837	2.8012	2.7526
3	.1658		.1823	3.0001	2.9656	2.8675	2.9165
4	.1658		.1823	2.9172	3.0148	2.8675	2.9165
5	.1823		.1823	2.7831	3.0476	2.8509	2.9165
6	.1658		.1823	2.8306	2.9492	2.9835	2.9492
7	.1823		.1823	2.9835			
8	.1326		.1658	2.7018	2.8673	2.9007	
9	.1326		.1326	.1492	2.8182	2.7846	
10	.0995		.0829	.116	2.6216	2.8509	
11	.0663	.0829	.0829		2.6707	2.8012	
12	2.652	2.9172	2.7018		.0819	.0829	
13	2.967	3.083	2.9504		.0819	.0995	.0819
14	2.967	3.0001	2.8841		.0819	.0995	.0819
15	3.1327	3.0001	2.8841		.0819	.0663	
16	2.8675	2.967	2.8841		.0819	.0663	
17	2.967	2.9504	2.7183			.0663	
18	2.9835	2.967	2.9504		.0983	.0829	.0819
19	2.967	2.7018	2.536	.1658	.1475	.1658	3.0476
20		.1658	.2321	.1823	.1475	.1492	.1638
21		.1658	.1823	.1658	.1475	.1492	.1802
22		.1658	.1823	.1492	.1311	.1492	.1638
23		.1823	.1658	.1492	.1147	.1326	.1638
24	.1658		.1658	.1492	.1475	.116	.1311
Max	3.1327	3.083	2.9504	3.0001	3.0476	2.9835	3.0476
Min	.0663	.0829	.0829	.116	.0819	.0663	.0819
Avg	1.2647	1.8730	1.0498	1.3443	1.2415	1.1848	1.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 203 / 11 KV Ave

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.2915	.3005	.3163	.1739	.2429	.253
2	2.7673	2.4291	2.7831	.3321	.1739	.2429	.2214
3	2.7831	2.4291	2.8306	.3005	.1739	.2429	.2214
4	2.8147	2.5101	2.8622	.2846	.1739	.2429	.2214
5	2.7831	2.672	2.9412	.2846	.1898	.2429	.2214
6	2.9729	2.915	2.9729	.3005	.2214	.2429	.2214
7	3.0045	3.0445	2.8464	.2846	.1898		
8	3.0203	3.1255	2.8306	.1739	.1581		
9	3.0361	2.9412	2.7831	2.7673	.1581		
10	2.878	2.8306	2.7357	2.7515	.1423	.1265	
11	2.7673	2.6882	2.625		.0633	.0633	
12	.1739	.2214	.1898		3.1152	2.8306	
13	.1739	.253	.1581		3.0994	2.9729	2.878
14	.1423	.2846	.1265		3.0836	2.9887	2.9412
15	.1581	.253	.1423		3.0045	2.9729	
16	.2056	.2214	.1581		2.9571	3.0045	
17	.3321	.2214	.2214		3.1943	2.9571	
18	.3163	.2214			2.9887	3.0203	2.9887
19	.3163	.3005	.253	2.8622	2.8464	2.7515	.1581
20	.4428	.2846	.3163	.1265	.2214	.2214	.1739
21	.4534	.3163	.3321	.1423	.253	.253	.1898
22	.421	.3321	.3163	.1581	.253	.253	.1898
23	.4049	.3479	.3321	.1739	.253	.253	.1898
24	.1898	.4049	.3479	.3005	.1739	.2591	.253
Max	3.0361	3.1255	2.9729	2.8622	3.1943	3.0203	2.9887
Min	.1423	.2214	.1265	.1265	.0633	.0633	.1581
Avg	1.3632	1.3141	1.3654	.7225	1.1359	1.2564	.7548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 201 / 11 KV Shevate Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.2058	.0914	.1886	.2401	.1677
2	.1029	.1029	.2439	.1067	.1029	.2401	.1524
3	.1029	.1029	.2401	.1067	.1029	.2743	.1524
4	.1029	.1029	.3086	.1219	.12	.2401	.1372
5	.12	.1029	.3429	.1219	.12	.2401	.1372
6	.1543	.2401	.1715	.1219	.1372	.2229	.0914
7	.2401	.2229	.1715	.1524	.1543	.2401	
8	.2572	.3772	.1715	.1677	.1715	.2743	
9	.2743	.3601	.2743	.2439	.2915	.3944	
10	.3086	.3086	.381	.4115	.3258	.5182	
11	.3086	.1029	.1981	.4287	.3772	.2134	
12	.2915	.3429	.2134	.3963	.3772	.3353	
13	.1029	.3772	.2134	.3944	.4115	.381	.4287
14		.3429	.2286	.3772	.3429	.3353	.3258
15	.3772	.3772		.3353	.2572	.3048	
16	.2058	.3429		.3506	.2058	.2134	
17	.2058	.4115	.3201	.4115	.1715	.3658	
18	.1715	.2743	.3506	.4115	.2058	.2896	.3258
19	.2058	.2439	.2286	.2401	.2229	.3048	.1886
20	.1886	.2058	.2134	.2401	.2058	.2896	.2743
21	.1543	.1715	.1829	.2401	.2058	.2591	.2591
22	.1372	.1886	.1981	.2229	.2229	.2286	.2915
23	.12	.1715	.1981	.2058	.2058	.2134	.2743
24	.2058	.12	.1715	.1372	.2058	.1715	.1829
Max	.3772	.4115	.381	.4287	.4115	.5182	.4287
Min	.1029	.1029	.1715	.0914	.1029	.1715	.0914
Avg	.1938	.2374	.2376	.2516	.2222	.2829	.2260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 202 / 11 KV Shevate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372	.1677	.1829	.1981	.1829	.1677
2	1.1336	1.4251	1.3717	.1981	.1524	.1524	.1829
3	1.1498	1.4413	1.4022	.2134	.1677	.1524	.1829
4	1.2146	1.5546	1.4632	.2134	.1677	.1677	.1981
5		1.6194	1.4327	.2286	.1981	.1524	.2134
6		1.7976	1.448	.2286	.2134	.1981	.2134
7	1.587	1.9433	1.5851	.1677	.1981	.1829	
8	1.8461	1.8785	1.5851	.1219	.1981	.1981	
9	1.8947	1.8138	1.6309	1.7375	.1981	.1677	
10	1.7814	1.8138	1.6613	1.5242	.2134	.1372	
11	1.7004	.061	1.6309		.0914	.0914	
12	.1029	.0914	.1219		1.6461	1.6766	
13	.12	.0914	.1372		1.768	1.768	1.7223
14	.1372	.0914	.1524		1.829	1.6766	1.7375
15	.1372	.0914	.1524		1.8747	1.6309	
16		.1067	.1677		1.7071	1.5242	
17		.1067	.1677		1.4937	1.6004	
18	.12	.1219	.1677		1.5851	1.7833	1.6918
19	.1886	.1524	.2134	1.6309	1.6766	1.5394	1.7318
20	.2058	.1829	.2134	.2134	.1981	.1677	.2229
21	.2058	.1829	.1981	.2134	.1829	.1524	.1981
22	.2058	.1677	.1981	.1981	.1829	.1524	.1829
23	.1886	.1524	.1829	.1981	.1677	.1677	.1677
24	.1372	.1715	.1829	.1829	.1981	.1829	.1677
Max	1.8947	1.9433	1.6613	1.7375	1.8747	1.7833	1.7375
Min	.1029	.061	.1219	.1219	.0914	.0914	.1677
Avg	.7080	.7165	.7348	.4658	.6878	.6586	.5987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 203 / Ulabhagat Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.2439	.2286	.1829	.2134	.1829
2	.2915	.3258	.3048		1.8747	2.0729	2.271
3	.2915	.3429	.3658		2.1338	2.1948	2.5149
4	.3086	.3601	.3658		2.6063	2.4082	2.6216
5	.3772	.3772	.3353		2.6825	2.652	2.7587
6	.4115	.3944	.3506		2.8654	2.8045	.7621
7	.4115	.3944	.3048		2.8959	2.8959	
8	.3944	.3944	.3353		2.9874	2.9874	
9	.3772	.3944	.3048				
10	.3429	.2401	.2591				
11	.2743	.2286	.1981		2.8959	2.4234	
12	2.753	2.652	2.6673		.1524	.2134	
13	3.1417	2.9111	2.8197		.1981	.2286	.1981
14	3.0769	2.8959	2.8349		.2134	.2439	.2286
15	3.1093	2.8349	2.8654		.2439	.2439	
16	3.0769	2.8045	2.8654		.2134	.2743	
17	3.0769	2.8197	2.6216		.1829	.2743	
18	3.0769	2.5911	2.4387		.3048	.2896	.2286
19	2.8502	2.4691	2.1948		.3353	.2743	.3048
20	.3944	.2743	.2134	.2134	.2439	.2743	.3353
21	.3601	.2743	.2743	.2743	.2743	.2591	.3353
22	.3601	.3048	.2134	.2743	.2743	.2591	.3201
23	.3429	.3048	.2439	.2591	.3048	.2286	.3201
24	.2915	.3429	.2743	.2439	.2439	.2743	.2134
Max	3.1417	2.9111	2.8654	.2743	2.9874	2.9874	2.7587
Min	.2743	.2286	.1981	.2134	.1524	.2134	.1829
Avg	1.2361	1.1350	1.0790	.2489	1.1050	1.0905	.9064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 204 / CHOUFULA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.2439	.1524	.1524	.1829	.1524
2	2.3807	2.4291	2.8959	.1677	.1677	.1829	.1677
3	2.3482	2.5911	2.9264	.1677	.1677	.1524	.1677
4	2.5149	2.6558	2.9569	.1829	.1829	.1829	.1524
5	2.5819	2.753	3.0483	.1829	.1829	.1524	.1677
6	2.5911	2.8502	2.9264	.1981	.1677	.2439	.1829
7	2.672	3.2388	2.9874	.2134	.1524	.1524	
8	2.7854	3.2388	3.2007	.2134	.1219	.1219	
9	2.915	3.2065	2.8959	2.5911	.1219	.1219	
10	2.753	3.1417	2.5149	2.774	.1372	.0914	
11	2.753	2.8349	2.5911		.1219	.1219	
12	.0686	.2134	.0914		3.0483	2.652	
13	.1372	.1829	.1067		3.2312	2.8959	2.915
14	.2572	.1219	.1067		3.2922	2.9721	3.336
15		.1219	.1067		3.4141	3.094	
16	.1372	.1219	.1067			3.1245	
17	.1543	.0914	.1219		3.2007		
18	.1543	.1219	.1524		3.0788	3.0483	3.2712
19	.2401	.2439	.1524		3.0483	2.8959	3.0769
20	.2401	.2439	.1677	.1677	.1524	.1219	.1219
21	.2229	.2591	.1829	.1677	.1829	.1524	.1524
22	.2229	.2591	.1677	.1524	.2439	.1524	.1524
23	.2058	.2743	.1677	.1524	.2439	.1677	.1677
24	.1886	.1886	.2439	.1677	.1524	.2134	.1524
Max	2.915	3.2388	3.2007	2.774	3.4141	3.1245	3.336
Min	.0686	.0914	.0914	.1524	.1219	.0914	.1219
Avg	1.2484	1.3148	1.2943	.5101	1.0855	1.0086	.9558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 205 / 11 KV PATHAN SAHEB

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.5487	.2286	.2439	.4268	.2134
2		.6154	.5182	2.0119	2.0729	1.7071	1.7375
3		.6516	.5182	2.1643	2.1338	1.7985	1.89
4		.6516	.4877	2.21	2.2405	1.89	2.0119
5		.6516	.5182	2.3015	2.271	2.0729	2.0881
6		.6173	.5335	2.3624	2.271	2.1338	.381
7				2.1643	2.3015	2.1948	
8				2.0119	2.3167	2.1643	
9				.2439	2.3015	2.0424	
10				.3048	2.3167	1.9814	
11					2.2862	2.1033	
12	2.4939	2.2253	2.2558				
13	2.4291	2.3624	2.3624				.1372
14	2.3482	2.1338	2.3167				.1981
15	2.3482	2.0729	2.2862				
16	2.1052	2.1338	2.2862				
17	2.2348	2.3777	2.3015				
18	2.2024	2.2862	2.332				.1677
19	2.2024	2.1338	2.0881	.6706			.6554
20	.6516	.5487	.4115	.4115	.4268	.6097	.6706
21	.6001	.5182	.4877	.3506	.4572	.6401	.6859
22	.6859	.5182	.3048	.3353	.4572	.6401	.7468
23	.7202	.5182	.3048	.3201	.4877	.5335	.7468
24		.7202	.5182	.3658	.3201	.4572	.4877
Max	2.4939	2.3777	2.3624	2.3624	2.3167	2.1948	2.0881
Min	.6001	.5182	.3048	.2286	.2439	.4268	.1372
Avg	1.7518	1.2872	1.2305	1.1536	1.5565	1.4622	.8545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3761	.3761	.3403	.3403	.3582	.3761	.4119
2	.3761	.3403	.3582	.3761	.3761	.3403	.3761
3	.4119	.4119	.3761	.4298	.394	.4298	.394
4	.4835	.4835	.4119	.5194	.4298	.5194	.4298
5	.5373	.5552	.4656	.5731	.4835	.591	.4835
6	.5731	.5373	.5731	.5552	.591	.5731	.5731
7	.5014	.4656	.4835	.4835	.4477	.4477	.4835
8	.4119	.4656	.4656	.3761	.394	.4298	.4298
9	.4119	.4119	.3761	.4477	.4119	.394	.394
10	.3761	.3224	.394	.4298	.4298	.3761	.4119
11	.3582	.3582	.3761	.3582	.3582	.3582	.3761
12	.2865	.2328	.2686	.3045	.3045	.2865	.3761
13	.3045	.3224	.2328	.2686	.2686	.2686	.3224
14	.2149	.2149	.1791	.2865	.2328	.3045	.3403
15	.2328	.2507	.2149	.3045	.2865	.2686	.3045
16	.2686	.197	.2507	.3224	.2686	.2507	.2865
17	.2865	.2507	.2507	.3403	.3224	.3582	.3045
18	.3224	.3045	.3045	.3403	.3582	.4119	.3403
19	.4119	.4477	.4119	.5014	.4477	.5194	.5373
20	.5194	.5194	.5014	.591	.5552	.5373	.591
21	.5014	.5552	.5014	.5014	.5014	.4835	.5373
22	.4656	.4298	.4477	.4656	.4477	.4835	.5014
23	.4119	.3761	.4119	.4656	.4298	.4656	.4298
24	.4119	.3761	.3582	.3582	.4119	.394	.4298
Max	.5731	.5552	.5731	.591	.591	.591	.591
Min	.2149	.197	.1791	.2686	.2328	.2507	.2865
Avg	.3940	.3836	.3731	.4141	.3962	.4112	.4194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 202 / BABHULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.0312	.0469	.0469	.0625	.0625	.0625
2	.9686	.953	.9842	.0469	.0625	.0625	.0625
3	1.0467	1.0155	1.0623	.0469	.0625	.0625	.0625
4	1.078	1.1873	1.0936	.0625	.0625	.0625	.0625
5	1.1561	1.2811	1.1561	.0625	.0625	.0625	.0625
6	1.3748	1.531	1.406	.0625	.0625	.0625	.0625
7	1.6872	1.6872	1.8122	.0625	.0625	.0625	.0625
8	1.781	1.8435	2.0309	.0625	.0625	.0625	.0625
9	1.8122	1.8747	1.9685	.0625	.0312	.0625	.0625
10	1.7185	1.781	1.9997	.0469	.0312	.0625	.0625
11	1.6248	1.5935	1.8122	.0469	.0312	.0625	.0625
12	.0312	.0312	.0312	1.9685	2.0622	1.8122	1.9997
13	.0312	.0312	.0312		1.8747	1.8122	2.0622
14	.0312	.0312	.0312		1.8435	1.7185	1.906
15	.0312	.0312	.0312		1.8747	1.7497	1.9372
16	.0312	.0312	.0312		1.9685	1.9685	1.7185
17	.0312	.0312	.0312		1.9997	1.8122	1.9372
18	.0312	.0312	.0312	1.8122	1.8747	2.0309	1.8122
19	.0625	.0625	.0625	1.7497	1.8122	1.7497	1.8122
20	.0625	.0937	.0625	.0625	.0625	.0625	.0625
21	.0625	.0625	.0625	.0625	.0625	.0469	.0625
22	.0469	.0625	.0625	.0625	.0625	.0469	.0625
23	.0312	.0469	.0469	.0469	.0625	.0625	.0625
24	.0625	.0312	.0469	.0469	.0625	.0625	.0625
Max	1.8122	1.8747	2.0309	1.9685	2.0622	2.0309	2.0622
Min	.0312	.0312	.0312	.0469	.0312	.0469	.0625
Avg	.6190	.6399	.6640	.3380	.6757	.6509	.6744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0648	.0648	.0648	.0648	.0648	.0648
2	.081	.0648	.0648	2.2672	2.2024	2.3967	2.6558
3	.081	.0648	.0648	2.2996	2.2672	2.4615	2.7206
4	.0972	.0648	.081	2.3967	2.332	2.5263	2.7854
5	.1134	.1296	.0972	2.4615	2.4615	2.5911	2.8502
6	.1296	.1296	.1296	2.5263	2.7854	2.6558	3.1093
7	.1134	.0972	.1296	2.915	2.9797	2.915	3.1741
8	.0972	.0648	.081	3.1741	3.2388	3.2388	2.9797
9	.081	.0648		3.0445	3.0445	3.1741	3.4332
10	.0648	.0648			2.6558	3.1741	3.1741
11	.0648	.0648	.0648		2.5263	3.3036	3.1741
12	3.3684	3.1255	2.9797		.0648		
13	3.0445	3.1093	3.0931		.0324		
14	3.1093	3.1579	3.1903		.0324	.0648	.0648
15	3.1741	3.1741	3.2388		.0648	.0648	.0648
16	3.312	3.3036	3.3036		.0648	.0648	.0648
17	3.3036	2.7854	3.1741		.0648	.081	.0648
18	2.915		2.9797	.0972	.0648	.081	.0648
19	2.4615	3.0445	2.8502	.081	.0648	.0972	.0648
20	.0648	.1134	.0648	.0648	.0648	.1134	.0648
21	.0648	.1134	.0648	.081	.0648	.0972	.0648
22	.0648	.0972	.0648	.0648	.0648	.081	.0648
23	.0648	.081	.0648	.081	.0648	.081	.0648
24	.081	.0648	.081	.0648	.081	.0648	.081
Max	3.3684	3.3036	3.3036	3.1741	3.2388	3.3036	3.4332
Min	.0648	.0648	.0648	.0648	.0324	.0648	.0648
Avg	1.0847	1.0020	1.1785	1.3553	1.1397	1.3360	1.4023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 201 / 11KV SHINGARE/CHAWAN

SEPARATED AG FEEDERS HAVING SPECIAL

WASTI FE Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.16	.16	.16	.16	.1715	.1715
2	.1406	.16	.16	1.0883		1.1431	1.2955
3	.1562	.176	.16	1.1203	1.3283	1.2803	1.3717
4	.1875	.176	.16	1.2323	1.3283	1.448	1.4175
5	.2187	.208	.16	1.2323	1.5684	1.5242	1.448
6	.1875	.208	.208	1.3923	1.6484	1.6156	1.5242
7	.1718	.2721	.192	1.6804	1.8404	1.5851	
8	.3125	.2881	.16	1.5844	1.7924	1.4327	1.4175
9	.2031	.2561	.1562	1.2643	1.5242	1.4937	1.5242
10	.192	.192	.1562	.128	.2229	.1886	.1875
11	.16	.16	.1406	.08	.1886	.1715	.0937
12	1.5524	1.7764	1.7604				
13	1.6324	1.7604	1.8244				
14	1.6484						
15	1.6324	1.6484	1.6964				
16	1.6324	1.7284	1.7124				
17	1.6804	1.6804	1.7124				
18	1.7764	1.6804	1.6484	.128	.1372	.3086	
19	1.5684	1.6804	1.4883	.16	.1715	.3601	
20	.208	.208	.176	.192	.1886	.3429	.3593
21	.208	.208	.192	.192	.1715	.2915	.3437
22	.192	.208	.192	.208	.2915	.1715	.2968
23	.16	.192	.16	.208	.2229	.1715	.2812
24	.1718	.16	.192	.144	.16	.1886	.1715
Max	1.7764	1.7764	1.8244	1.6804	1.8404	1.6156	1.5242
Min	.1406	.16	.1406	.08	.1372	.1715	.0937
Avg	.6729	.6603	.6334	.6775	.7615	.7716	.7936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 202 / 11KV WATAR WAT FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1932	.2315	.2469	.2623	.2006	.3086	.2572
2	1.278	1.3117	1.3272	.2778	.216	.2743	.2743
3	1.3077	1.3889	1.3735	.3086	.2315	.2401	.3258
4	1.4712	1.3889	1.3735	.3395	.2315	.3258	.3772
5	1.5604	1.3889	1.5123	.3549	.2315	.3772	.4115
6	1.9319	1.7901	1.5123	.4012	.3086	.4973	.4801
7	1.9467	2.0525	1.6975	.4012	.3086	.3772	
8	2.0062	2.0833	1.9136	.3395	.3086	.2401	.3601
9	1.1294	.1852	1.813	.216	.3601	.2915	
10	.1698	.1852	.1932	.1543	.2915	.3258	.2526
11	.1543	.216	.1783	.1235	.2572	.2743	.104
12				1.7593	2.0576	1.8595	1.8427
13				1.7747	1.8747		1.709
14					1.9814	1.8747	
15					1.9662	1.9662	1.9319
16						2.0424	1.917
17					1.8138	2.0576	1.8724
18	.1389	.3395	.2623	1.8827	1.829	1.9814	
19	.3549	.4012	.3395	1.8673	1.7985	1.6613	1.7833
20	.3395	.3395	.3395	.1852	.3258	.3086	.3269
21	.3086	.3549	.3395	.2315	.3086	.2743	.3418
22	.3086	.3395	.2778	.2778	.3258	.2401	.2675
23	.2778	.3395	.2623	.2778	.3086	.2427	.2526
24	.2378	.2623	.2778	.2623	.2315	.2915	.2614
Max	2.0062	2.0833	1.9136	1.8827	2.0576	2.0576	1.9319
Min	.1389	.1852	.1783	.1235	.2006	.2401	.104
Avg	.8397	.8110	.8467	.5849	.7725	.7971	.7675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 203 / 11KV SUSTE RIVER SIDE SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0486	.0486	.0486	.0324	.0343	.0343
2	.0457	.0486	.0486	1.4575	1.3927	1.4746	1.1584
3	.0457		.0486	1.4575	1.4575	1.4022	1.2498
4	.0457	.0486	.0486	1.4899	1.4575	1.4937	1.3717
5	.0457	.0486	.0486	1.4899	1.587	1.749	1.4632
6	.0457	.0486	.0486	1.5223		1.5699	1.7833
7	.0457	.0486	.0486	1.5223	1.8138	1.7833	
8		.0486	.0486	1.6194	1.7814	1.5394	1.4327
9	.0305	.0486	.0486	1.668	1.6461	1.6156	1.5851
10	.0324	.0486	.0486	.0486	.0171	.0343	.0305
11	.0324	.0486	.0486	.0486	.0171	.0343	.0457
12	1.7814	1.8299	1.8138				.0457
13	1.7814	1.8461	1.7652				
14	1.7814						
15	1.7814	1.7814	1.7004				
16	1.8138	1.8299	1.7814				
17	1.8461	1.8138	1.749				
18	1.8623	1.8138	1.7652	.0324	.0343		
19	1.8461	1.7814	.0486	.0324	.0343	.0686	.0457
20	.0486	.0486	.0486	.0324	.0343	.0686	.0457
21	.0486	.0486	.0486	.0324	.0343	.0686	.0457
22	.0324	.0486	.0486	.0324	.0343	.0343	.0457
23	.0486	.0486	.0486	.0324	.0343	.0343	.0457
24	.0457	.0486	.0486	.0486	.0324	.0343	.0343
Max	1.8623	1.8461	1.8138	1.668	1.8138	1.7833	1.7833
Min	.0305	.0486	.0486	.0324	.0171	.0343	.0305
Avg	.6580	.6102	.4957	.7009	.6730	.7670	.6155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 201 / 11 KV KAROLE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1524	.2286	.1524
2	1.7147	2.0957	1.9052	.1905	.1524
3	1.7147	2.0957	2.2862	.1524	.1524
4	1.7147	2.2862	2.5149	.1524	.1524
5	1.7147	2.2862	2.553	.1905	.1524
6	1.7147	2.2862	2.6292	.2286	.1524
7	1.7528	2.4006	2.6292	.1905	.1524
8	2.4387	2.5149	2.553	.1524	.1334
9	2.2862	2.5149	2.5911	.1524	.1905
10	2.2862	2.4768	2.4768	.1524	.1905
11	2.3624	2.5149	2.4768		.0953
12	.1143	.0572	.1524	2.6292	2.7435
13	.0762	.0762	.1524	2.6292	2.7816
16	.1143		.1524	2.6292	2.8578
17	.1524		.1524	2.6673	2.5911
18	.1524	.1524	.1524	2.553	2.4768
19	.1524	.1524	.1524	2.6673	2.5149
20	.3429	.1524	.3429	.1905	.2858
21	.3048	.1905	.3429	.1905	.3429
22	.3429	.2286	.3429	.2286	.3429
23	.2667	.2667	.3429	.2286	.2858
24	.1905	.2286	.1524	.2667	.3429
Max	2.4387	2.5149	2.6292	2.6673	2.8578
Min	.0762	.0572	.1524	.1524	.0953
Avg	1.0046	1.2584	1.2366	.8891	.8747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 202 / 11 KV BELDAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1524	.1905
2	.1905	.1905	.1905	1.9052	1.7147
3	.1905	.1905	.1905	2.0957	1.9052
4	.1905	.1905	.1905	2.0957	2.0576
5	.1905	.2286	.1905	2.1338	2.0576
6	.1905	.2286	.1905	2.1719	2.0576
7	.1905	.1905	.1905		2.0576
8	.2096	.1905	.1524	2.2862	2.0576
9	.1524	.1524	.1524	2.1719	2.1338
10	.1524	.1143	.1143	2.1719	2.0957
11	.1524	.1143	.1143	2.1719	2.0957
12	2.2862	2.3243	2.4387	.1143	.1143
13	2.2862	2.3243	2.4387	.1143	.1143
16	2.2862	2.5149	2.4006	.1143	.1715
17	2.3624	2.5149	2.4768	.1905	.1715
18	2.2862	2.3243	2.4768	.1524	.1905
19	2.21	2.1719	2.2862	.1905	.2286
20	.1905	.1905	.1524	.1905	.2286
21	.1905	.1905	.1524	.1905	.2096
22	.2286	.1905	.1524	.1905	.1905
23	.2286	.1905	.1524	.1905	.1905
24	.1905	.1905	.1905	.1524	.3429
Max	2.3624	2.5149	2.4768	2.2862	2.1338
Min	.1524	.1143	.1143	.1143	.1143
Avg	.7612	.7777	.7811	1.0070	1.0262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 203 / 11 KV YAMGAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0953	.1143	.1143
2	.0762	.0762	.0762	1.7147	1.5242
3	.0762	.0953	.0762	1.7147	1.5242
4	.0953	.1143	.0762	1.7909	1.7147
5	.0762	.1143	.0762	1.8671	1.7147
6	.0953	.1143	.0762	1.9052	1.7147
7	.0762	.0762	.0572	1.9052	1.7147
8	.0762	.0762	.0762	1.829	1.7528
9	.0953	.0762	.0762	1.7909	1.7147
10	.0762	.0762	.0572	1.7909	1.6766
11	.0572	.0762	.0572	1.7909	1.6385
12	1.829	1.8671	1.9052	.0762	.0572
13	1.829	1.9052	1.9052	.0572	.0572
16	1.829	1.9433	1.6766	.0762	.0953
17	1.829	1.9433		.0953	.0762
18	1.829	1.8671	1.7147	.0953	.1143
19	1.7909	1.7909	1.7147	.1143	.1334
20	.1334	.0953	.1143	.1143	.1524
21	.1334	.0953	.1143	.1524	.1715
22	.1334	.0953	.1143	.1524	.1524
23	.1143	.0953	.1143	.1524	.1524
24	.0762	.1143	.0953	.1334	.1524
Max	1.829	1.9433	1.9052	1.9052	1.7528
Min	.0572	.0762	.0572	.0572	.0572
Avg	.5638	.5811	.4890	.8833	.8236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 201 / 11 KV NARSALE PATT
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1334	.132	.2096	.1524	.1509	.132
2	.1715	.1143	.1509	1.2955	1.5242	2.0748	2.1502
3	.1524	.0762	.1509	1.6766	1.6956	2.1313	2.2068
4	.1524	.1524	.1509	1.7528	1.8671	2.1879	2.2257
5	.1905	.1524	.1509	1.8671	1.9433	2.1879	2.2634
6	.2096	.1715	.1509	1.9052	2.0576	2.2634	2.2634
7	.1905	.1715	.1509	2.0195	2.1338	2.3011	2.3011
8	.2096	.1698	3.2442	1.7147	2.3624	2.3011	2.1502
9	.1905	.1886	3.2819	1.8671		2.2634	2.0748
10	.2286	.2263	.1524	1.8671		2.1502	1.9814
11	.1715	.1509	.1524			1.6221	1.9814
12	1.7909	2.2445	2.0195				.0953
13	2.3243	2.2862	2.1719				.1143
14						.0754	
15						.0754	
16	2.553	2.2257	2.1338			.0754	.0953
17	2.3624	2.2445	2.1719			.0754	.1334
18	2.2481	2.0748	2.0195	.1524		.1132	.2096
19	2.1719	1.8861	1.7909	.1905		.1509	.2286
20	.1905	.1132	.0953	.1905		.2263	.2667
21	.1905	.1132	.1905	.2096		.1886	.2477
22	.1715	.1132	.1905	.2096		.1886	.2096
23	.1524	.1132	.1905	.1905	.1509	.1509	.1905
24	.1905	.1334	.132	.1905	.1715	.1509	.1509
Max	2.553	2.2862	3.2819	2.0195	2.3624	2.3011	2.3011
Min	.1524	.0762	.0953	.1524	.1509	.0754	.0953
Avg	.7448	.6934	.9534	1.0299	1.4059	1.0502	1.0760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 202 / 11 KV NEW JALOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0953	.1132	.0953	.1143	.1132	.1132
2	.1334	.0762	.132	1.3336	1.4098	2.1125	2.0559
3	.1143	.0762	.1509	1.4861	1.7147	2.2257	2.1125
4	.1143	.0762	.1509	1.6766	1.9052	2.2257	2.1125
5	.1334	.1143	.132	1.829	2.0576	2.2634	2.1502
6	.1905	.1715	.1509	2.0576	2.0957	2.2634	2.1879
7	.2096	.1715	.1509	2.1719	2.1338	2.2634	2.1879
8	.1715	.1509	.132	2.0576	2.2481	2.3011	2.2634
9	.1905	.0943	.1132	2.0957		2.3011	2.3011
10	.1905	.0754	.1143	2.0195		2.2634	2.3243
11	.1524	.0754	.0572			2.2634	2.3243
12	2.1338	2.3765	2.3243				
13	2.3624	2.3388	2.3243				
16	2.4387	2.4897	2.2862				
17	2.4387	2.3777	2.4387				
18	2.4768	2.2634	1.9433	.1143			
19	2.4768	2.1125	1.9433	.1143			
20	.1524	.1132	.1143	.1524		.1132	.1143
21	.1524	.0754	.1334	.1715		.132	.0953
22	.1524	.1132	.1334	.1524		.1132	.0572
23	.1524	.1132	.1143	.1524	.132	.1132	.0572
24	.1715	.1143	.132	.1143	.1334	.1132	.1132
Max	2.4768	2.4897	2.4387	2.1719	2.2481	2.3011	2.3243
Min	.1143	.0754	.0572	.0953	.1143	.1132	.0572
Avg	.7656	.7121	.6948	1.0467	1.3945	1.4488	1.4107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 203 / 11 KV NEW SANGAVI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.2263	.4191	.3429	.2641	.3018
2	2.2862	2.5911	2.6783	.4191	.3048	.2829	.3018
3	2.6673	2.5911	2.7349	.4191	.3048	.3018	.3018
4	2.9531	2.6673	2.8104	.4572	.2667	.3018	.3395
5	3.0483	2.6673	2.9424	.4572	.2667	.3018	.3395
6	3.1436	2.7435	3.0556	.4572	.3048	.3395	.3018
7	3.2388	2.7816	3.0933	.381	.3429	.3772	.3395
8	3.4294	2.9235	3.2769	.3429	.362	.3395	
9	3.3532	3.131	3.315	.3429		.2263	
10	3.2388	2.5652	3.0483	.3429		.1886	
11	3.1245	2.8292	2.8959	2.2481		.1886	
12	.2858	.1509				3.2819	3.1626
13	.3048					3.3573	3.0483
14						3.3951	
15						3.3951	
16						3.3573	3.1245
17	.2477					3.3573	3.2769
18	.3048			3.0102		3.2442	3.2769
19	.4191			3.0483		3.1687	3.0864
20	.4572	.2263	.381	.4001		.4527	.4001
21	.4572	.2263	.381	.4382		.3772	.381
22	.4191	.2641	.381	.381		.3772	.362
23	.4191	.2829	.381	.381	.3018	.3395	.3429
24	.3429	.381	.2829	.4191	.362	.3018	.3395
Max	3.4294	3.131	3.315	3.0483	.362	3.3951	3.2769
Min	.2477	.1509	.2263	.3429	.2667	.1886	.3018
Avg	1.6403	1.7229	1.9928	.7980	.3159	1.3132	1.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 241 / 11 KV IAKSHMINAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18
HR	Load (MW)
8	.1296
Max	.1296
Min	.1296
Avg	.1296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 241 / 11 KV Gherdi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
1	.1829	
2	.3658	
3	.5182	
4	.5487	
5	.7316	
6	1.1584	
8		.2134
9		.1981
10		.1677
11		.2134
12		1.2498
13		1.2346
14		1.2193
15		1.2346
16		1.0517
17		1.326
18		1.1888
19		1.0974
20		.2743
21		.2439
22		.2286
23		.2134
24	.1829	
Max	1.1584	1.326
Min	.1829	.1677
Avg	.5269	.7097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 242 / 11 KV Pare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
1	.1219	
2	.3353	
3	.3353	
4	.381	
5	.4572	
6	.6097	
8		.1524
9		.1524
10		.1219
11		.1219
12		1.1279
13		.945
14		.8535
15		.7621
16		.8078
17		.9755
18		.945
19		.7621
20		.1981
21		.1829
22		.1677
23		.1372
24	.1219	
Max	.6097	1.1279
Min	.1219	.1219
Avg	.3375	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 243 / 11 KV Hangirge feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
1	.1524	
2	.1524	
3	.1524	
4	.1524	
6	.3201	
8		2.0119
9		2.0576
10		1.768
11		1.5851
12		.1219
13		.1067
14		.0914
15		.0914
16		.0914
17		.0914
18		.1524
19		.2134
20		.3048
21		.2743
22		.2286
23		.1829
24	.1524	
Max	.3201	2.0576
Min	.1524	.0914
Avg	.1804	.5858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 244 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
1	.2134	
2	.2134	
3	.216	
4	.2286	
5	.3353	
6	.4572	
8		.381
9		.3048
10		.3048
11		.2743
12		.2743
13		.2439
14		.2439
15		.2439
16		.2439
17		.2591
18		.2896
19		.3963
20		.4877
21		.4572
22		.3963
23		.3048
24	.2134	
Max	.4572	.4877
Min	.2134	.2439
Avg	.2682	.3191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 242 / 11 KV Gaudwadi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.2267	.2591	.2429	.2031	.2105	.2429
2	.5639	.6316	.8097	.7935	.2031	.2267	.2267
3	.5487	.6802	.9231	.8421	.2031	.2267	.2267
4	.6249	.6802	.9717	.8421	.2343	.2429	.2429
5	.8592	1.004	1.0364	.9231	.2812	.2753	.2591
6	1.5779	1.6842	1.8138	1.6032	.3437	.2915	.3239
7	1.89	2.0729	2.1538	2.2024	.2968	.2915	.2949
8	2.1491	1.9814	2.2996	2.1376	.2187	.2267	.2683
9	1.8747	1.7528	2.0891		.1718	.1943	.2785
10	1.6872	1.5699	1.9109		.1562	.1457	.1966
11	1.656	1.448	1.6842		.1562	.1943	.1802
12					2.0778	1.9109	1.8187
13					2.4215	2.1538	2.0553
14					2.1464	1.8785	1.7204
15					2.1464	1.4737	1.5893
16					2.1051	1.5546	1.7695
17					2.1051	1.3927	1.8461
18	.2187		.1677	.2656	2.0481	1.4089	1.6712
19	.2656	.1829		.2968	1.5581	1.4575	1.5746
20	.3077	.2915	.3563	.3749	.2294	.2753	.3125
21	.3401	.3725	.3239	.3437	.2785	.3239	.3281
22	.2915	.3563	.2915	.2968	.2949	.2915	.2968
23	.2429	.3077	.2753	.2343	.2294	.2915	.2656
24	.2286	.2267	.2753	.2429	.2187	.2429	.2591
Max	2.1491	2.0729	2.2996	2.2024	2.4215	2.1538	2.0553
Min	.1981	.1829	.1677	.2343	.1562	.1457	.1802
Avg	.8625	.9100	1.0377	.7761	.8470	.7159	.7603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 243 / 11 KV Junoni feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2429	.2591	.2105	.2031	.2105	.1943
2	.5944	.7125	.8421	.8097	.2031	.2429	.1943
3	.6097	.7611	.8745	.8421	.2031	.2429	.2105
4	.6097	.7611	.8745	.8745	.2187	.2915	.1943
5	.7316	.8745	1.0364	.9231	.2343	.2591	.2429
6	1.078	1.4413	1.2955	1.2146	.2656	.2267	.2915
7	1.1405	1.7814	1.6518	1.7976	.2031	.2429	.2458
8	1.7341	1.6091	1.7652	1.4089	.1718	.2105	.1802
9	1.0155	1.1888	1.5223		.1562	.1943	.1492
10	.9804	.6859	1.2631		.1406	.1296	.1326
11	.9374	.9145	.7449		.125	.1781	.1658
12					1.4217	1.4089	1.4582
13					1.5623	1.7166	1.4255
14					1.6244	1.4089	
15						1.3441	1.1934
16					1.6907	.8421	1.3599
17						1.2146	1.6575
18	.1562		.1562	.2031	1.8896	1.1498	1.5565
19	.2343	.2591	.2656	.2439	1.3272	1.1012	.9995
20	.2915	.3077	.2753	.2968	.2785	.3077	.2656
21	.2915	.3563	.2753	.2656	.2294	.2915	.2656
22	.2753	.2915	.2429	.2343	.2622	.2591	.2656
23	.2429	.2753	.2267	.2187	.213	.2105	.2343
24	.2134	.2429	.2591	.2105	.2187	.2267	.1943
Max	1.7341	1.7814	1.7652	1.7976	1.8896	1.7166	1.6575
Min	.1562	.2429	.1562	.2031	.125	.1296	.1326
Avg	.6305	.7474	.7684	.6503	.5837	.5796	.5686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 244 / 11 KV Pachegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1457	.1457	.1619	.1406	.1619	.1296
2	.125	.1457	.1457	.1457	.4687	.5668	.5668
3	.125	.1457	.1457	.1457	.5468	.7287	.4858
4	.125	.1457	.1619	.1457	.703	.8907	.4858
5	.1406	.1619	.1943	.1619	.8592	1.0526	.5668
6	.1562	.1781	.1943	.1781	.9374	1.1336	1.004
7	.1718				1.0936	1.1336	1.3108
8				.1457	1.2498	1.2146	1.4746
9	.1677	.1562	.1457		.9374	1.2146	1.1469
10	.1524	.1524	.1457		.9686	1.2955	1.1469
11	.1562	.1524	.1457		.7811	1.2955	.9831
12	.8383	.7621	1.1336				.1326
13	.9145	1.0936	.9717				.116
14	.703	.9145	1.1336	.9717			.116
15	1.0155	.9145	.9717	1.2498			.1326
16	1.0936	.9907	.9907	1.0669			.1326
17	1.2193		.9145	1.0155			.1326
18	.9145		.8383	1.0155	.1311	.1296	.1311
19	1.2498	.4572	.7811	.6249	.1326	.1296	.1311
20	.1943	.1619	.1943	.1875	.1311	.1457	.1562
21	.1943	.1619	.1619	.1875	.1492		.1562
22	.1781	.1619	.1619	.1562	.1492	.1619	.1562
23		.1457	.1619	.1562	.1638	.1457	.1562
24	.1372	.1619	.1457	.1619	.1562	.1619	.1296
Max	1.2498	1.0936	1.1336	1.2498	1.2498	1.2955	1.4746
Min	.125	.1457	.1457	.1457	.1311	.1296	.116
Avg	.4590	.3655	.4539	.4377	.5389	.6801	.4617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 245 / KOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401		.7125	.6154	.6249	.6478	.6154
2	.6401	.7449	.7125	.6154	.6249	.7125	.6478
3	.6706	.7449	.7125	.6154	.6874	.7773	.6478
4	.7316	.8097	.7773	.7125	.8124	.8421	.6802
5	.8535	1.004	1.004	.8421	.9061	.8745	.8745
6	1.0974	1.2308	1.2955	1.1336	1.0936	.9069	1.0688
7	.8749	.9069	.9393	.8097	.6874	.9054	.9054
8					.4687	.7125	.6413
9					.5312	.5182	.3772
10	.5792	.6249	.6802		.3125	.5506	.5487
11	.4687	.6249	.6478		.3437	.583	.6554
12	.6562	.5792	.6478		.3125	.4858	.695
13	.6249	.6097	.6478		.2812	.6154	.695
14	.6562	.6097	.6802	.7449	.3292	.6478	.7095
15	.5312	.6401	.6478	.6874	.3326	.583	.7468
16	.6249	.6562	.6562	.6249	.695	.5182	.8215
17	.6249		.6097	.5937	.663	.583	.8215
18	.6562		.6706	.6249	.7762	.6802	.8501
19	.8124	1.0936	.884	.8436	.8779	.7773	1.0608
20	1.166		1.1336	1.0669	.8619	1.004	1.0936
21	1.1336	1.2308	.9717	.9686	.9282	.9717	1.0936
22	.8421	.9069	.8097	.8436	1.0719	.8745	.9061
23	.8421	.8421	.7773	.6562	.6962	.7125	.7186
24	.6401	.7773	.7449	.7125	.6249	.6478	.6478
Max	1.166	1.2308	1.2955	1.1336	1.0936	1.004	1.0936
Min	.4687	.5792	.6097	.5937	.2812	.4858	.3772
Avg	.7440	.8131	.7892	.7617	.6476	.7138	.7718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 246 / 11 KV KOMBADWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.1781	.1619	.1781	.1524	.1619	.1457
2	.1581	.1781	.1619	.1619	.6097	.4858	.6478
3	.1581	.1781	.1619	.1619	.6859	.5668	.6478
4	.1562	.1781	.1619	.1619	.9374	.6478	.6478
5	.1677	.1943	.1781	.1781	1.0155	.8097	.7287
6	.1875	.2105	.1943	.1943	1.0936	1.0526	1.1336
7	.1875				1.4842	1.2955	1.8233
8				.1943	1.531	1.2955	1.8233
9	.1875	.1524	.1457		1.4842	1.2955	1.8023
10	.1718	.1524	.1457		1.3279	1.2955	1.4746
11	.1677	.1524	.1619		1.0936	1.3765	1.3108
12	1.3717	1.0155	1.6194				.1658
13	1.5242	1.3717	1.4575				.1311
14	1.1431	1.2193	1.4575	1.0155			.1311
15	1.2498	1.2193	1.2955	1.406			.1475
16	1.2498	1.3717	1.2955	1.2955			.1326
17	1.406		1.406	.6097			.1311
18	1.4842		1.2498	.9145	.1311	.1457	.1311
19	1.4842	.6097	1.1069	.7621	.1311	.1457	.1311
20	.2267	.1943	.2267	.2031	.1311	.1943	.1524
21	.2105	.1943	.1943	.2031	.1311	.1943	
22	.1943	.1943	.1781	.1875	.1475	.1943	
23	.1943	.1781	.1781	.1875	.1638	.1619	
24	.1875	.1781	.1781	.1781	.1524	.1619	.1619
Max	1.5242	1.3717	1.6194	1.406	1.531	1.3765	1.8233
Min	.1562	.1524	.1457	.1619	.1311	.1457	.1311
Avg	.5924	.4660	.6053	.4552	.6891	.6378	.6477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 247 / 11 KV BUDDIHAL FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1781	.1781	.1943	.1875	.2105	.081
2	.9374	1.0202	1.166	1.1336	.1875	.2267	.081
3	.9686	1.0526	1.2146	1.166	.1875	.2591	.081
4	.9686	1.0688	1.2955	1.1984	.2187	.1781	.0972
5	1.1561	1.247	1.3441	1.2631	.2187	.2105	.0972
6	1.8747	2.2672	2.1052	1.6194	.2343	.1943	.0972
7	1.829	2.5911	2.0243	1.9433	.2031	.1943	
8	2.4996	2.21	2.0243	2.1376	.1562	.2105	.0819
9	1.0936	1.0311	2.1376		.1406	.1781	.0819
10	.9374	1.0669	1.9919		.1406		.0819
11	.8993	.7621	1.6518		.1406	.0648	.0663
12			1.6518		2.0557	.9717	.9945
13					2.1872	.9717	1.0322
14						1.085	1.0159
15					2.5069	1.166	1.0322
16						1.1174	1.0322
17					1.9662	1.1012	.9831
18	.1562		.1619	.1406		1.0364	.9614
19	.2031	.1981	.2429	.1981	2.2045	.7935	.7625
20	.2267	.1943	.2429	.2343	.2321	.1296	.1562
21	.2267	.2105	.2105	.2343	.2486	.1296	.0937
22	.2105	.1943	.1943	.2031	.2429	.1134	.0762
23	.2105	.1781	.1943	.1875	.2622	.0972	.1067
24	.2031	.1781	.1781	.1943	.1875	.2267	.0972
Max	2.4996	2.5911	2.1376	2.1376	2.5069	1.166	1.0322
Min	.1562	.1781	.1619	.1406	.1406	.0648	.0663
Avg	.8205	.9205	1.0637	.8032	.6719	.4724	.3996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 241 / 11 KV Manjari feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0335	.0362	.0328	.0335	.0328	.0335
2	.1448	.2012	.1448	.1966	.1677	.2622	.1341
3	.1448	.3932	.181	.1966	.1677	.3391	.1311
4	.181	.4359	.2534	.2347	.2012	.3277	.2012
5	.2172	.5121	.3258	.2622	.2347	.3353	.3018
6	.2534	.5853	.362	.2949	.3018	.3353	.3353
7	.5068	.4915	.5068	.3688	.3353	.3353	.3353
8	.4706	.3353	.4706	.426	.3688	.4409	.3353
9	.4706	.3018	.4344	.4024	.4359	.4024	.4108
10	.362	.2683	.362	.3277	.3353	.2622	.3429
11		.2294	.3982	.3688	.3018	.3018	.3391
12	.0362	.0335	.0372	.0335	.0168	.0335	.0373
13	.0343	.0335	.0181	.0335	.0168	.0328	
14	.0362	.0366	.0335	.0328	.0168	.0328	
15	.0362	.0335	.0335	.0328	.0168	.0328	.0339
16	.0905	.0377	.0335	.0328	.0168	.0335	.0343
17	.0362	.0335	.0335	.0328	.0168	.0335	.0335
18	.0362	.0328	.0335	.0328	.0168	.0335	.0671
19	.0362	.0335	.0335	.0328	.0335	.0335	.0671
20	.0362	.0671	.0671	.0328	.0335	.0335	.0671
21	.0362	.0366	.0671	.0328	.0335	.0339	.0686
22	.0362	.0366	.0335	.0328	.0335	.0335	.0724
23	.0248	.0366	.0335	.0328	.0335	.0335	.0732
24	.0362	.0335	.0362	.0328	.0335	.0377	.0377
Max	.5068	.5853	.5068	.426	.4359	.4409	.4108
Min	.0248	.0328	.0181	.0328	.0168	.0328	.0335
Avg	.1434	.1780	.1654	.1475	.1334	.1589	.1588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 242 / 11 KV Bamni feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.1341	.0724	.0503	.0671	.1677	.1494
2	.3353	.503	.3772	.426	.3353	.3353	.3353
3	.3688	.061	.4344	.4359	.3688	.6706	.3353
4	.4024	1.0059	.543	.4915	.4024	1.0059	.407
5	.4359	1.0395	.6516	.583	.4359	1.1065	.6036
6	.503	1.1469	.7964	.6706	.5365	1.1469	.6706
7	.7377	1.0059	1.0136	.852	.8383	1.2742	.9496
8	.8048	.6706	1.0498	1.073	.9724	1.2742	1.0814
9	.8383	.7042	.9774	.8848	1.0059	.8421	.3688
10	.8718	.6226	.7602	.8192	1.0395	.7209	.8907
11	.6706	.57	.1086	.7461	.9054	.7042	.7377
12	.0671	.0671	.1006	.0995	.1341	.0983	.0678
13	.1097	.0335	.0671	.0671	.1341	.1017	.0671
14	.1006	.0328	.0671	.0655	.1341	.1006	.1006
15	.1006	.0335	.0671	.0655	.1341	.1006	.0972
16	.1006	.1006	.0671	.0655	.1341	.1341	.1006
17	.1006	.0671	.0671	.0983	.1341	.1357	.1341
18	.1006	.1006	.1006	.0983	.1341	.0671	.2347
19	.1341	.1341		.0983	.1677	.1006	.3018
20	.1463	.1341	.1006	.0983	.1677	.1341	.1677
21	.1341	.1341	.1006	.0983	.1677	.1311	.1677
22	.1341	.1006	.0671	.0983	.1677	.1006	.1677
23	.1341	.1006	.0671	.1006	.1677	.1006	.1341
24	.1006	.1341	.0724	.0671	.1006	.1886	.1006
Max	.8718	1.1469	1.0498	1.073	1.0395	1.2742	1.0814
Min	.0671	.0328	.0671	.0503	.0671	.0671	.0671
Avg	.3236	.3599	.3360	.3397	.3661	.4476	.3488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 243 / 11 KV Sangewadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.2035	.181	.1509	.1677	.1357	.1341
2	.1677	.2012	.1448	.1341	.1677	.1357	.1311
3	.1677	.2012	.1448	.1341	.1677	.1296	.1311
4	.1696	.2012	.181	.1357	.1677	.1311	.1341
5	.2012	.1677	.2172	.1638	.2012	.1326	.1677
6	.2012	.1677	.2172	.1696	.2012	.1296	.1696
7	.1677	.1677	.181	.1463	.2012	.1341	.1341
8	.1677	.1677	.181	.0983	.2012	.1341	.1341
9	.1715	.1677	.1448	.1475	.1677	.1341	.1341
10	.1677	.1341	.1448	.1311	.1677	.1006	.1494
11	.1341	.1341	.0991	.1509	.1006	.1006	.1829
12	1.0059	1.3413	1.6289	1.1336	.8383	1.073	1.3077
13	1.1401	1.4083	1.448	1.2125	1.1401	1.2071	1.4083
14	1.2742	1.5089	1.4842	1.2452	1.5089	1.2407	1.3413
15	1.3413	1.2071	1.0059	1.3108	1.5424	1.278	1.4083
16	1.4083	1.2742	1.1065	1.1797	1.3413	1.3413	1.5089
17	1.1736	1.5089	1.4083	1.153	1.3413	1.4419	1.6766
18	1.3717	1.5089	1.5424	1.0486	1.3748	.9503	1.5089
19	1.3413	1.3748	1.3413	1.0159	1.4083	1.0059	1.3413
20	.1715	.2012	.2012	.1966	.1341	.1886	.1886
21	.2012	.1638	.1677	.2294	.1341	.1638	.1677
22	.2012	.1677	.1677	.2294	.1341	.1677	.1341
23	.2012	.1677	.1677	.1966	.1341	.1341	.1463
24	.1677	.2012	.181	.1341	.1677	.1311	.1341
Max	1.4083	1.5089	1.6289	1.3108	1.5424	1.4419	1.6766
Min	.1341	.1341	.0991	.0983	.1006	.1006	.1311
Avg	.5368	.5812	.5703	.4937	.5463	.4884	.5781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 244 / 11 KV Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5121	.543		.3688	.3353	.3688
2	.4458	.3658	.5068		.3688	.503	.3353
3	.4458	.3391	.4706		.4024	.5426	.3353
4	.4801	.439	.5068		.503	.6554	.4024
5	.543	.9831	.5792		.6706	.78	.503
6	.905	.503	.905		.7712	.8048	.7377
7	.7602	.503	.7602		.6706	.8383	.583
8	.5144	.5365	.5792		.5365	.4973	.5426
9	.543	.3353	.6516		.503	.5365	.4694
10	.543	.4359	.5068		.4694	.4024	.4024
11	.543	.3932	.4344		.4359	.4024	.3353
12	.3982	.4359	.3982		.4024	.3353	.3353
13	.3429	.3932	.4344		.4024	.3018	.3688
14	.362	.3688	.4359	.2949	.3353	.3018	.3353
15	.362	.3932	.4024	.3277	.4694	.3353	.3391
16	.4344	.3353	.3353	.3605		.3353	.3688
17	.4706	.3688	.4024		.5365	.4024	.4024
18	.6859	.4694	.4024	.426	.57	.4024	.503
19	.7602	.57	.57	.6104	.6036	.503	.6371
20	.6859	.8048	.7712	.5571	.503	.8048	.6706
21	.6859	.7712	.7712	.5898	.4694	.7042	.503
22	.724	.7122	.6371	.4915	.4694	.5636	.4694
23	.724	.503	.503	.426	.4527	.5365	.4024
24	.4801	.6371	.543		.4024	.3688	.3688
Max	.905	.9831	.905	.6104	.7712	.8383	.7377
Min	.3429	.3353	.3353	.2949	.3353	.3018	.3353
Avg	.5561	.5045	.5438	.4538	.4920	.5081	.4466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 245 / 11 KV DEVALE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2622	.2534	.2294	.2012	.1677	.2347
2	.2534	.2683	.2172	.1966	.2012	.1677	.2012
3	.2534	.2035	.2172	.1966	.2012	.2012	.1677
4	.2172	.2012	.2172	.1638	.2012	.2012	.2012
5	.2896	.2012	.2172	.1966	.2347	.2012	.2347
6	.2534	.1966	.2534	.2294	.2347	.2012	.2347
7	.2534	.2012	.2534	.2294	.2012	.2012	.2012
8	.2172	.1966	.2534	.1966	.1677	.2035	.2012
9	.2172	.1966	.181	.1638	.1677	.2012	.1677
10	.181	.1638	.181	.1638	.1677	.1006	.1638
11	.1448	.1638	.1448	.1311	.1006	.1006	.1463
12	1.5927	1.5089	1.6651	1.0814	1.0059	1.1401	1.3413
13	1.6289	1.3904	1.6289	1.2452	1.3413	1.4083	1.5089
14	1.8099	1.3077	1.4754	1.278	1.576	1.4419	1.3108
15	1.9909	1.1469	1.5089	1.2125	1.1736	1.3748	1.1869
16	1.8099	1.2887	1.3413	1.1469	1.2071	1.3108	1.4266
17	1.1145	1.5402	1.4754	1.2452	1.1736	1.3435	1.4998
18	1.7013	1.4091	1.4083	1.1469	1.3077	1.153	1.3108
19	1.448	1.4243	1.3413	1.0486	1.2407	1.1191	1.3535
20	.181	.2683	.2683	.1966	.1677	.2622	.3018
21	.2534	.2294	.2347	.2294	.2012	.2347	.2683
22	.2896	.2347	.2347	.2294	.2012	.2374	.2347
23	.2896	.2347	.2347	.2294	.1677	.2294	.2347
24	.2896	.2683	.2534	.2294	.2012	.1677	.2347
Max	1.9909	1.5402	1.6651	1.278	1.576	1.4419	1.5089
Min	.1448	.1638	.1448	.1311	.1006	.1006	.1463
Avg	.7056	.6044	.6442	.5257	.5435	.5571	.5986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 246 / 11 KV Save Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4755	.3258	.3441	.3353	.3391	.4115
2	.3982	.4409	.3801	.3605	.3353	.3391	.3353
3	.3982	.503	.3982	.3932	.4191	.3353	.3521
4	.4706	.57	.4344	.4588	.503	.503	.4527
5	.5792	.6706	.5792	.5571	.5365	.5365	.5197
6	.905	.503	.8326	.7373	.8048	.6371	.8589
7	.6878	.4694	.5792	.5898	.6036	.6539	.5243
8	.4163	.4191	.5068	.4096	.4024	.3353	.4409
9	.4163	.4024	.362	.3932	.4024	.3185	.4481
10	.4344	.4359	.4706	.426	.4024	.4191	.4024
11	.4887	.439	.4344	.4588	.4024	.4191	.4024
12	.362	.3856	.4344	.3605	.3353	.3856	.4024
13	.362	.3605	.4706	.3113	.4024	.3521	.4191
14	.362	.3353	.3982	.3277	.4191	.3688	.3856
15	.362	.3688	.3688	.3441	.3353	.3521	.3856
16	.3982	.4024	.3688	.3768	.3688	.3856	.4024
17	.4163	.4024	.3856	.3768	.3353	.4527	.4359
18	.543	.4359	.503	.3932	.4024	.3856	.4694
19	.6516	.4534		.6062	.4527	.4359	.5197
20	.543	.6036	.57	.6226	.4694	.5668	.5365
21	.5792	.695	.6203	.5243	.3353	.5304	.503
22	.6154	.4862	.4527	.4915	.3521	.5197	.4694
23	.543	.3391	.4359	.4096	.4024	.4144	.4527
24	.4525	.4915	.362	.3932	.3688	.3391	.4239
Max	.905	.695	.8326	.7373	.8048	.6539	.8589
Min	.362	.3353	.3258	.3113	.3353	.3185	.3353
Avg	.4925	.4620	.4641	.4444	.4219	.4302	.4564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 247 / 11 KV Save AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1844		.1638	.1677	.1696	.2012
2	.6878	.8048	.6878	.5571	.6706	.8192	.6952
3	.724	1.1736	.724	.6554	.8383	1.0174	.8048
4	.905	1.6766	.905	.8848	.9221	1.3565	.8648
5	1.1222	1.8778	1.1222	1.1142	1.0059	1.6766	1.1401
6	1.3756	2.0538	1.4661	1.278	1.3413	1.6766	1.291
7	1.7737	1.5089	1.9004	1.7368	1.576	1.6956	1.358
8	1.7194	1.1736	1.9547	1.8023	1.6766	1.7101	1.6095
9	1.8099	1.291	1.8642	1.7532	1.5089	1.7604	1.8275
10	1.2489	1.3413	1.7737	1.6385	1.4922	1.5565	1.5089
11	.181	1.2689	1.5927	1.4746	1.1904	1.5775	1.4754
12	.181	.1006	.1448	.1311	.1677	.1677	.1134
13	.181	.1174	.1267	.1311	.1844	.1457	.1147
14	.181	.1341	.1448	.1147	.1509	.1341	.1341
15	.1448	.1509	.1174	.1147	.1006	.1341	.1341
16	.1448	.1006	.1174	.1311	.1006	.1174	.1341
17	.1448	.1006	.1341	.1311	.1677	.1341	.1509
18	.1448	.1677	.1341	.1475	.1677	.1677	.1677
19	.1448	.1844	.1677	.1966	.2347	.2195	.2683
20	.1448	.2683	.2683	.213	.2347	.2515	.2515
21	.181	.1844	.2012	.2374	.1677	.2374	.2515
22	.181	.1844	.1844	.213	.1677	.2374	.2035
23	.1991	.1844	.2012	.1966	.1677	.218	.1802
24	.2172	.1865	.181	.1802	.2012	.1677	.1966
Max	1.8099	2.0538	1.9547	1.8023	1.6766	1.7604	1.8275
Min	.1448	.1006	.1174	.1147	.1006	.1174	.1134
Avg	.5807	.6841	.7006	.6332	.6085	.7228	.6282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 241 / 11 KV Waki Gheradi Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2429	.1619	.4572	.3048
2	.1677	.2429	.381	.4858	.381
3	.1524	.2429	.4572	.3239	.5335
4	.1524	.2429	.4572	.4049	.4572
5	.1677	.2429	.6859	.5668	.381
6	.1981	.2429	.7621	.8907	.381
7	.1524	.081	.9145	1.0526	.5335
8	.1524	.2429	.9145	.9717	.4572
9	.1524	.1619	.8383	.6478	.5335
10	.1524	.1619	.7621	.4858	.6097
11	.1524	.1619	.7621	.4049	.4572
12	.8002	.4572	.1619	.1524	.1619
13	.6668	.5335	.1619	.1524	.1781
14	.6001	.4572	.1619	.1524	.1943
15	.5335	.5335	.1619	.1524	.1619
16	.6001	.6097	.1619	.1524	.1619
17	.8002	.6859	.1619	.1524	.1619
18	.8002	.7621	.2753	.1524	.1943
19	.8002	.7621	.2267	.1524	.2429
20	.1829	.1619		.1524	.2915
21	.1829	.1619		.1524	.2429
22	.1524	.1619		.1524	
23	.1524	.1619		.1524	
24	.1524	.2429	.1619	.1524	.1619
Max	.8002	.7621	.9145	1.0526	.6097
Min	.1524	.081	.1619	.1524	.1619
Avg	.3420	.3316	.4366	.3614	.3265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 242 / 11 KV Alegaon Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.3239	.2429	.1524	.2429
2	.4668	1.2955	.2429	.1524	.2429
3	.4801	1.448	.2429	.1524	.2429
4	.6668	1.5242	.2429	.2286	.2429
5	.9335	1.6766	.2429	.2286	.2429
6	1.6004		.3239	.3353	.2429
7	2.0805	1.9814	.3239	.3963	.2429
8	2.1338	1.829	.3239	.3353	.2429
9	1.8671	1.9052	.3239	.3048	.2105
10	1.8671	1.829	.3239	.3048	.1781
11	1.7337	1.5242	.2429	.3048	.1619
12	.1829	.2429	.9907	.7287	1.9814
13	.1829	.2429	1.5242	1.0526	1.9052
14		.2429	1.7528	1.3765	1.9814
15		.2429	1.7528	1.4575	2.0576
16		.2429	2.0271	1.5384	1.9814
17	.1524	.2429	2.1338	1.6194	2.0271
18	.1524	.2429	2.0271	1.3765	1.9052
19		.3239	1.9814	1.5384	1.5242
20		.3239		.2429	.2429
21	.2286	.2429		.2286	.2429
22	.1829	.2429		.2286	
23	.1524	.2429		.2286	
24	.1524	.3239	.2429	.1524	.2429
Max	2.1338	1.9814	2.1338	1.6194	2.0576
Min	.1524	.2429	.2429	.1524	.1619
Avg	.8089	.8147	.8755	.6110	.8448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 243 / 11 KV Medshingi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	27-APR-18
HR	Load (MW)
1	.5335
2	.4858
3	.4049
4	.5668
5	.8097
6	1.1336
7	1.2146
8	1.1498
9	1.0526
10	.8907
11	.6478
12	.1524
13	.1524
14	.1524
15	.1524
16	.1524
17	.1524
18	.1524
19	.1524
20	.1524
21	.1524
22	.1524
23	.1524
24	.1524
Max	1.2146
Min	.1524
Avg	.4530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 244 / Alegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2743	.2572	.1715	.2401
2	.1677	.3086	.2915	.1715	.2743
3	.1524	.3086	.3086	.2401	.3086
4	.1524	.3429	.3429	.3086	.4115
5	.1981	.3772	.3429	.3601	.4458
6	.2439	.3086	.4287	.4115	.4801
7	.3048	.2743	.5144	.4801	.4458
8	.2286	.2401	.4287	.4115	.3772
9	.2134		.3944	.3772	.3429
10	.1829	.2058	.3429	.3429	.3086
11	.1524	.2229	.2572	.3086	.3429
12	.1524	.2229	.2572	.2743	.2572
13	.1524	.2229	.2401	.2401	.2401
14		.2401	.2229	.2058	.2229
15	.1524	.2401	.2229	.2058	.2572
16	.1524	.2572	.2401	.2401	.2401
17	.1829	.2915	.2229	.2743	.2743
18	.2134	.2915	.3086	.3086	.3772
19	.2439	.3429	.2743	.3429	.463
20	.3048	.3429	.3429	.3772	.5144
21	.381	.3086	.2572	.3086	.4458
22	.3353	.2743	.2229	.2743	.3563
23	.3048	.2743	.2058	.2572	.3239
24	.2134	.2401	.2572	.1715	.2401
Max	.381	.3772	.5144	.4801	.5144
Min	.1524	.2058	.2058	.1715	.2229
Avg	.2160	.2788	.2994	.2943	.3413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 245 / Wanichanchale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	25-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134		.5335	.3239
2	.1829	.3239	.8907	1.2955
3	.1677	.3239	1.1012	1.448
4	.1524	.3239	1.2146	1.448
5	.1524	.3239	1.5384	1.5242
6	.2134	.3239	1.7814	1.5242
7	.3048	.3239	2.3482	2.4387
8	.3353	.3239	2.1052	2.0576
9	.2439	.3239	1.7814	1.6766
10	.2286	.3239	1.6194	1.5242
11	.2286	.2429	1.2955	1.3717
12	1.8671	1.5242	.3048	.2105
13	1.6004	1.6766	.3048	.2267
14	1.3336	1.829	.3048	.2267
15	1.3336	1.7528	.3048	.2591
16	1.467	1.829	.3048	.2753
17	1.6004	1.7528	.3048	.2915
18	1.467	1.6766	.3048	.3401
19	1.3336	1.7528	.3048	.3725
20	.3048	.3239	.3048	
21	.381	.3239	.3048	.3563
22	.3506	.3239	.3048	.3239
23	.3048	.3239	.3048	.2915
24	.2439	.3239	.2743	.3239
Max	1.8671	1.829	2.3482	2.4387
Min	.1524	.2429	.2743	.2105
Avg	.6671	.8074	.8392	.8752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 241 / 11 KV Jujarpur Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.1658	.1677	.1677	.1677	.1781	.1619
2	.1844	.1658	.1341	.1638	.7449	.7287	.6478
3	.1677	.1658	.1509	.1509	.8124	.8097	.7125
4	.2012	.1865	.1509	.1802	.828	.9069	.8097
5	.2105	.1989	.1677	.2012	.9175	1.004	.9717
6	.2458	.2486	.1677	.2347	1.004	1.247	1.247
7	.1966	.1989	.1966	.1638	1.2308	1.6194	1.247
8	.1802	.1492	.1844	.1509	1.3117	1.3441	1.3279
9	.1638	.1492	.1677		1.166	1.2955	1.3592
10	.1677	.1174	.1509		.9069	1.2146	1.326
11	.1341	.0995	.1006		.8907	1.1336	1.2597
12	1.1336	1.2631	1.2308				
13	1.1405	1.3108	1.1203				
14	1.1405	1.1437	1.2308	.9374			
15	1.1405	1.1603	1.3123	1.2967			
16	1.1405	1.1271	1.2323	1.3279			
17	1.1717		1.2323	1.3123			
18	1.0155		1.0883	1.2029	.2105	.1619	.1357
19	.8592	.6802	1.004	1.0936	.1943	.1943	.1823
20	.1943	.218	.218	.2949	.2105	.2105	.2347
21	.1966	.2347	.2012	.2785	.2429	.2105	.2347
22	.2012	.2347	.1844	.2294	.2105	.2105	.2347
23	.1844	.2012	.1844	.218	.1781	.1943	.2155
24	.1677	.1658	.1677	.1844	.1844	.1781	.1619
Max	1.1717	1.3108	1.3123	1.3279	1.3117	1.6194	1.3592
Min	.1341	.0995	.1006	.1509	.1677	.1619	.1357
Avg	.4884	.4357	.5061	.5152	.6340	.7134	.6928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 242 / 11 KV Junoni Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.017	.0168	.0168	.0168	.0162	.0162
2	.0168	.017	.0168	.0168	.1619	.1134	.8907
3	.0168	.017	.0168	.0168	.1619	.1296	.8907
4	.0168	.017	.0168	.0168	.1943	.1296	.9231
5	.0168	.017	.0168	.0335	.2105	.1619	.9717
6	.0335	.017	.0335	.0335	.2105	.2105	1.0526
7	.0168	.017	.0335	.0335	.2105	.2267	1.0526
8	.0168	.017	.0168	.0335	.2753	.2429	.9717
9	.0168	.017	.0168		.2591	.2429	1.0774
10	.0168	.017	.0168		.1134	.2429	1.0774
11	.0168	.017	.0168		.1619	.2429	1.0442
12	.2915	.2012	.9231				
13	.2753	.2155	1.004				
14	.285	.2204	1.085	.1802			
15	.2458	.2155	1.085	.1311			
16	.2294	.2012	.9842	.1311			
17	.213		1.0311	.213			
18	.213		.9878	.1966	.0162	.0162	.017
19	.213	.1844	.9555	.2267	.0324	.0324	.017
20	.0335	.0335	.0168	.0168	.0324	.0324	.0339
21	.0335	.0335	.0168	.0168	.0324	.0324	.0339
22	.0335	.0335	.0168	.0168	.0324	.0324	.0339
23	.0335	.0168	.0168	.0168	.0162	.0162	.017
24	.0168	.017	.0168	.0168	.0168	.0162	.0162
Max	.2915	.2204	1.085	.2267	.2753	.2429	1.0774
Min	.0168	.0168	.0168	.0168	.0162	.0162	.0162
Avg	.0966	.0709	.3482	.0718	.1197	.1188	.5632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 243 / 11 KV H.Mangewadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2012	.2012	.2012	.213	.2105	.2105
2	.9686	.7459	1.1437	.8124	.213	.2105	.1943
3	1.0623	.8288	1.2186	.9061	.2294	.2105	.1943
4	1.2452	.9665	1.3927	.9646	.2515	.2105	.2105
5	1.2498	1.0774	1.4723	1.1843	.2949	.2429	.2429
6	1.2811	1.2944	1.531	1.3283	.3441	.3401	.3401
7	1.5935	1.7204	1.6446	1.8679	.2949	.2753	.2915
8	1.781	1.7532	1.8747	1.6248	.218	.2429	.2105
9	1.7029	1.8023	1.8747		.2429	.1943	.1865
10	1.5935	1.5746	1.6404		.2267	.1943	.1696
11	1.406	1.4091	1.3904		.3239	.1781	.1187
12					1.4575	1.4575	1.7901
13					1.4899	1.4899	1.8233
14					1.5223	1.4575	1.6244
15					1.4899	1.4089	1.5912
16					1.4575	1.4089	1.5912
17					1.5384	1.3765	1.757
18	.218		.1509	.2294	1.587	1.3765	1.5402
19	.2683	.1966	.218	.213	1.0526	1.3765	1.3599
20	.2785	.3277	.3018	.3113	.2915	.2105	.3018
21	.2785	.2949	.2785	.2949	.2753	.2753	.3018
22	.2458	.285	.2347	.2785	.2429	.2267	.285
23	.218	.2515	.218	.2622	.2267	.2105	.2515
24	.2294	.2012	.2267	.2012	.2458	.2105	.2105
Max	1.781	1.8023	1.8747	1.8679	1.587	1.4899	1.8233
Min	.218	.1966	.1509	.2012	.213	.1781	.1187
Avg	.8805	.8783	.9452	.7120	.6554	.6248	.6999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274154 / 33/11 KV Junoni S/Stn

Feeder No / Name : 244 / 11 KV JUNONI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.213	.2543	.2458	.2294	.2294	.2572	.2572
2	.1966	.2374	.2294	.213	.218	.2572	.2572
3	.2294	.2374	.2321	.2294	.2012	.2572	.2572
4	.2683	.2543	.2458	.2622	.2294	.2572	.2572
5	.2949	.2883	.2753	.2949	.2785	.2915	
6	.3185	.3391	.2591	.3441	.3277	.3429	.3772
7	.2785	.3391	.2012	.3441	.3277	.3086	.3429
8							.2572
9						.3086	.2515
10	.2622	.2543	.1966		.2915	.3086	.2486
11	.2591	.3222	.3353		.2572	.2743	.2683
12	.2652	.2374	.3441		.3429	.3086	.2818
13	.2785	.2204	.2785		.3429	.3086	.2652
14	.2785	.3222	.2915	.2785	.3429	.3086	.2486
15	.2785	.2713	.3113	.2949	.3086	.3086	.2515
16	.2785	.2713	.3725	.3441	.2915	.3086	.2652
17	.2949		.3277	.3113	.2915	.3429	.2818
18	.3163		.3605	.2785	.3601	.3601	.2883
19	.3277	.2949	.3018	.3768	.3601	.3944	.3018
20	.3277	.4096	.4096	.3768	.3944	.3429	.3353
21	.2785	.3605	.3768	.3441	.3429	.3429	.3688
22	.2458	.3277	.3185	.3277	.2915	.3258	.3521
23	.2458	.2984	.2683	.285	.2572	.2915	.2683
24	.2294	.2543	.2622	.2458	.2458	.2572	.2572
Max	.3277	.4096	.4096	.3768	.3944	.3944	.3772
Min	.1966	.2204	.1966	.213	.2012	.2572	.2486
Avg	.2712	.2897	.2929	.2989	.2970	.3071	.2844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 241 / Chopadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.1886	.2058	.2058	.2058	.2229
2	.2058	.2229	.2058	.2058	.1886	.1886	.2229
3	.2058	.2229	.2058	.2229	.2229	.2058	.2058
4	.2401	.2429	.2401	.2229	.2401	.2229	.2401
5	.2743	.2591	.3258	.2743	.2572	.2572	.2743
6	.3429	.2915	.3429	.3258	.2915	.2915	.3086
7	.2915	.2591	.2743	.3086	.2743	.2915	.3258
8	.2401	.2429	.2401	.2401	.2229	.2401	.2743
9	.2572	.2572	.2401	.2743	.2401	.3086	.3086
10	.2915	.3086	.2915	.2915	.2915	.3086	.3258
11	.2743	.3077	.2915	.2915	.2743	.2915	.3086
12	.2743	.2743	.2401	.2058	.2229	.2401	.2915
13	.2401	.2401	.2572	.2229	.2401	.2229	.2572
14	.2058	.2058	.2401	.2229	.2058	.2058	.2743
15	.2229	.2401	.2572	.2229	.2401	.2229	.2401
16	.2229	.3086	.2743	.2058	.2401	.2401	
17	.2915	.2743	.2572	.2401	.2572	.2572	.2401
18	.2743	.2743	.2915	.2401	.2743	.2915	
19	.3429	.3258	.3601	.3258	.3086	.3429	.3772
20	.4115	.4287	.4287	.3601	.3772	.4115	.4458
21	.3601	.3601	.3429	.3086	.3601	.3429	.3772
22	.3429	.2743	.2572	.3086	.3086	.2915	.3258
23	.2915	.2401	.2401	.2743	.2572	.2572	.2743
24	.2401	.2572	.2058	.2229	.2401	.2229	.2401
Max	.4115	.4287	.4287	.3601	.3772	.4115	.4458
Min	.2058	.2058	.1886	.2058	.1886	.1886	.2058
Avg	.2736	.2718	.2708	.2593	.2601	.2651	.2892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 242 / balwadi feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.4534	.4534	.421	.3887	.3887	.4287
2	.7611	.3887	.4372	.4372	.9231	.8745	1.0117
3	.8907	.4049	.4534	.4372	1.0526	1.0202	1.166
4	1.0202	.4372	.4696	.4696	1.1498	1.2146	1.0631
5	1.1012	.4372	.5182	.502	1.2955	1.2955	1.3546
6	1.4413	.4696	.583	.5668	1.4251	1.4089	1.7318
7	1.8623	.421	.502	.4534	1.9271	1.9109	2.2291
8	1.9271	.421	.421	.3563	1.9595	1.668	2.1434
9	1.8785	.3401	.3725	.3887	1.9433	1.9595	1.9757
10	1.8461		.3563	.3725	1.9433	1.668	1.9757
11	1.7652	.3401	.3239	.3563	1.7004	1.5546	1.8299
12	.2753	2.0729	2.1052	1.8785	.2753	.3077	.2591
13	.2915	1.8785	1.9433	1.8461	.3239	.3077	.3077
14	.3563	1.9109	1.9757	1.7976		.3239	.3401
15	.3239	1.7004	1.7976	1.7652		.3239	.3077
16	.3563	1.8299	1.7166	1.8138		.3077	.3401
17		1.9757	2.0405	1.6356	.4115	.3429	
18	.421	2.1052	1.9271	1.9271	.4287	.3772	.3887
19		1.3603	1.9757	1.8299	.4801	.3944	.5182
20	.6154	.5182	.5668	.6316	.5344	.6173	.6154
21	.5668	.5182	.5182	.6154	.502	.5658	.5668
22	.5182	.502	.5344	.5344	.502	.4801	.3725
23	.502	.4534	.4372	.4858	.4534	.4801	.3887
24	.4049	.4858	.4372	.421	.4372	.4049	.4287
Max	1.9271	2.1052	2.1052	1.9271	1.9595	1.9595	2.2291
Min	.2753	.3401	.3239	.3563	.2753	.3077	.2591
Avg	.8877	.9315	.9528	.9143	.9551	.8415	.9454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 243 / BANDGARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1296	.1134	.1134	.1296	.1134	.12
2	.1134	.502	.4372	.3725	.1619	.0972	.12
3	.1457	.502	.4858	.421	.1781	.1457	.1372
4	.1781	.5182	.5344	.4534	.2267	.1943	.1372
5	.2105	.5506	.583	.502	.2753	.2591	.1715
6	.2753	.5992	.664	.5992	.3401	.3077	.2915
7	.2267	.7449	.7611	.7935	.2591	.2429	.3086
8	.1457	.7773	.8259	.8097	.1943	.1619	.1886
9	.081	.7125	.7287	.7773	.1457	.1296	.1134
10	.0648	.7287	.7287	.8421	.1296	.1134	.081
11	.081	.6802	.5992	.7287	.1134	.1296	.081
12	.6154	.081	.0972	.0648	.6478	.6802	.6802
13	.6154	.081	.0972	.0648	.6478	.6316	.7287
14	.5992	.0972	.081	.0648	.583	.6154	.7125
15	.583	.1134	.081	.081	.6001	.5992	.5992
16	.6316	.1134	.0972	.0648	.6687	.6964	.7125
17	.7773	.1134	.081	.0972	.6001	.7716	.8421
18	.8097	.1619	.1296	.1296	.5487	.6859	.8097
19	.7773	.1619	.1781		.4801	.823	.8745
20	.1943	.2105	.2105	.2105	.1781	.1715	.2105
21	.1619	.1619	.1457	.1619	.1619	.1543	.1619
22	.1296	.1296	.1296	.1619	.1457	.1372	.1457
23	.1296	.1134	.1296	.1457	.1296	.1372	.1296
24	.1296	.1134	.1134	.1134	.1296	.1296	.12
Max	.8097	.7773	.8259	.8421	.6687	.823	.8745
Min	.0648	.081	.081	.0648	.1134	.0972	.081
Avg	.3246	.3374	.3347	.3380	.3198	.3387	.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 244 / chopadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1781	.1781	.1943	.1943	.1781	.1886
2	.2105	.4858	.502	.5182	.2105	.1943	.2058
3	.1943	.5182	.5344	.5506	.2429	.2267	.2058
4	.2267	.5344	.6316	.6478	.3239	.2915	.2229
5	.2753	.583	.6802	.6964	.3887	.3563	.2572
6	.4049	.6802	.7935	.8583	.4372	.4372	.4287
7	.3077	.9393	.9717	.9878	.3725	.3401	.3437
8	.2267	1.0202	1.0364	1.004	.2591	.2105	.2401
9	.1619	1.004	.9878	.9878	.1781	.1781	.1781
10	.1457	.8907	.8907	.9393	.1619	.1619	.1781
11	.1134	.8583	.8907	.8745	.1296	.1134	.1619
12	.9555	.1134	.1134	.1134	1.0526	.9231	1.0526
13	.8745	.0972	.1457	.1134	1.0688	.7611	.8907
14	.7449	.1134	.1296	.1296	.9259	.7611	.8097
15	.7125	.1457	.1457	.1296	.9088	.7935	.7611
16	.7449	.1457	.1619	.1134	.9088	.9069	.7773
17		.1781	.1457	.1296	.8573	.9431	.9393
18	.9555	.2429	.1619	.1457	.7545	.9088	1.0202
19		.2753	.2591	.2591	.6687	.9945	.8907
20		.3725	.3401	.3725	.2915	.2915	.3563
21		.2915	.2591	.2753	.2591	.2572	.3077
22		.2267	.2429	.2105	.2105	.2229	.2105
23		.1781	.2267	.1943	.1943	.2058	.1943
24	.1943	.1943	.1619	.1943	.1781	.1781	.2058
Max	.9555	1.0202	1.0364	1.004	1.0688	.9945	1.0526
Min	.1134	.0972	.1134	.1134	.1296	.1134	.1619
Avg	.4246	.4278	.4413	.4433	.4657	.4515	.4595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 241 / Wadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1134	.1296	.1296	.1296	.1296	.1372
2	.1296	.1134	.1296	.1296	.1296	.1296	.1372
3	.1296	.1134	.1296	.1296	.1296	.1296	.1372
4	.1296	.1296	.1619	.1619	.1457	.1296	.1715
5	.1619	.1943	.1943	.1943	.1619	.1619	.2058
6	.2753	.2429	.2591	.2753	.2591	.2429	.3086
7	.2429	.2267	.2267	.2429	.2429	.2267	.2401
8	.1943	.1781	.1619	.1781	.1715	.1619	.1886
9	.12		.1543	.1372	.12	.1219	.1715
10	.12	.12	.1372	.1372	.12	.1219	.1372
11	.12	.12	.1372	.0914	.1543	.1219	.12
12	.1372	.12	.1372	.1067	.12	.1219	.12
13	.12	.12	.1372	.0914	.12	.1067	.12
14	.12	.12	.12	.1067	.12	.1067	.12
15	.1372	.12	.12	.1067	.12	.1219	.12
16	.12	.1372	.12	.1067	.12	.1219	.1029
17	.1296	.1372	.1372	.1372	.1372	.1219	.0686
18	.1296	.1372	.1372	.1715	.1372	.1524	.1715
19	.1619	.1715	.2058	.2058	.2401	.1981	.2058
20	.2429	.2401	.2429	.2401	.2572	.2439	.2401
21	.1943	.2743	.2105	.2058	.2058	.2058	.2058
22	.1619	.1943	.1619	.1886	.1619	.1715	.1715
23	.1457	.1457	.1296	.1457	.1296	.1543	.1543
24	.1296	.1134	.1134	.1296	.1296	.1296	.1372
Max	.2753	.2743	.2591	.2753	.2591	.2439	.3086
Min	.12	.1134	.1134	.0914	.12	.1067	.0686
Avg	.1534	.1558	.1581	.1562	.1568	.1514	.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 243 / DIGHEMALA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.3239	.3239	.3239	.3239	.3429
2	.3239	.3239	.3239	.3239	.9717	1.2955	1.2003
3	.3239	.3239	.3239	.3239	.9717	1.2955	1.0974
4	.3887	.3563	.3887	.3887	.9717	1.2955	1.3717
5	.3887	.3887	.421	.421	1.2955	1.6194	1.2955
6	.4696	.4534	.5182	.4858	1.5708	1.9271	1.768
7	.5344	.5344	.5182	.5668	2.2348	2.6397	2.21
8	.421	.421	.3887	.4858	2.1338	2.5101	2.2405
9	.3944	.3772	.3353	.381	2.1948	2.21	2.2253
10	.3772	.3429	.3353	.2286	2.1338	2.1338	2.1338
11	.3429	.2915	.3353	.2286	1.9509	2.0119	.4725
12	2.2862	2.2862	2.3167	1.7337	.3048	.1219	.2439
13	2.2558	2.2558	2.1795	1.8004	.3048		.2439
14	2.2253	2.2253	.5639	1.7604	.3086	.2286	.2439
15	1.6309	2.0576	1.9052	1.7337	.3086	.2286	.2591
16	2.0729	2.1643	1.9357	1.9338	.3772	.3353	.3048
17	2.5101	2.271	2.0729	2.2862	.3353	.3658	.3353
18	2.5425	2.1338	2.2558	2.1948	.3353	.3658	.3506
19	2.4291	2.0729	2.0576	1.9814	.4268	.381	.4268
20	.4858	.3353	.421	.3963	.4268	.4115	.3963
21	.4858	.3353	.4858	.3658	.3658	.4115	.3658
22	.421	.3563	.4534	.3353	.3563	.3772	.3772
23	.3563	.3239	.3887	.3239	.3239	.3429	.3429
24	.3563	.3239	.3239	.3239	.3239	.3239	.3429
Max	2.5425	2.2862	2.3167	2.2862	2.2348	2.6397	2.2405
Min	.3239	.2915	.3239	.2286	.3048	.1219	.2439
Avg	1.0144	.9699	.8989	.8887	.8855	1.0068	.8580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 244 / BURLEWADI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1781	.1781	.1619	.1457	.1457	.1457	.1543
2	.3239	.3239	.3239	.3239	.1457	.1457	.1543
3	.3239	.3239	.3239	.3239	.1457	.1457	.1543
4	.4858	.4858	.3239	.3239	.1457	.1619	.1543
5	.6478	.6478	.6478	.4858	.1619	.1943	.1715
6	.8259	.8097	.8097	.664	.1943	.2105	.1715
7	1.0202	1.085	1.0202	.9069	.1781	.1619	.1543
8	1.0202	1.1336	.9555	.8907	.1715	.1296	.1372
9	.9602	1.1488	.945	.7735	.12	.1219	.1067
10	1.0288	1.0631	.9656	.7735	.12	.1067	.0914
11	.8535	.8993	.8383	.6935	.0857	.0762	.0914
12	.0857	.0857	.0762	.0914	.9602	.9755	.884
13	.0857	.0857	.0762	.0762	.945	.9755	.945
14	.0857	.0857	.081	.0762	.9297	.9145	.9297
15	.0857	.0857	.0762	.0762	.9297	.8688	.8688
16	.0857	.0857	.0762	.0762	.9755	.9602	.9602
17	.081		.1067	.0762	.9907	1.0669	1.0517
18	.081	.1219	.1067	.0762	.9907	.9907	.9602
19	.1134	.1524	.1219	.1524	.9755	.9145	.823
20	.2105	.1524	.2105	.1829	.1677	.1829	.1524
21	.2429	.1886	.1943	.1829	.1524	.1715	.1524
22	.1781	.1619	.1619	.1219	.1457	.1715	.1543
23	.1781	.1619	.1457	.1457	.1457	.1715	.1543
24	.1781	.1781	.1619	.1457	.1457	.1457	.1543
Max	1.0288	1.1488	1.0202	.9069	.9907	1.0669	1.0517
Min	.081	.0857	.0762	.0762	.0857	.0762	.0914
Avg	.3900	.4193	.3713	.3244	.4195	.4212	.4055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 241 / Akola SSTn Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3772	.4115	.3772	.3772	.3601	.3601
2	.4115	.3944	.3944	.4115	.3944	.3772	.3772
3	.3944	.4287	.4287	.4287	.4458	.3944	.4287
4	.5144	.4801	.4801	.4973	.4973	.4973	.4973
5	.6516	.5487	.583	.5658	.583	.583	.583
6	.8402	.7716	.8059	.7888	.8059	.8402	.7716
7	.7545	.7716	.6687	.6344	.703	.6859	.6687
8	.5487	.6344	.583		.5316	.5316	.5316
9	.5144	.4801	.5316		.4973	.5144	.5144
10	.4458	.4458	.463	.4458	.4973	.4973	.4458
11	.4115	.4973	.5658	.4287	.4287	.4973	.4973
12	.3944	.4287	.4287	.4115	.3772	.4115	.463
13	.3772	.3944	.463	.3086	.3772	.3772	.4458
14	.3772	.3772	.3086	.3086	.3772	.3944	.4115
15	.4115	.3601	.3601	.3429	.3601	.3601	.4287
16	.3944	.3601	.3944	.4458	.3772	.3772	.3944
17	.4801	.4458	.4115	.4287	.3944		.4287
18	.4458	.3601	.4287	.4115	.463	.3601	.4458
19	.5144	.5658	.583	.583	.5658	.5144	.5316
20	.6344	.7202	.6344	.6687	.6859	.6516	.5658
21	.583	.6001	.5316	.6001	.6001	.5658	.5316
22	.5144	.5144	.4801	.4973	.4973	.4973	.4801
23	.463	.463	.4287	.4458	.4458	.4287	.4458
24	.4287	.4115	.4287	.3944	.3944	.3944	.3944
Max	.8402	.7716	.8059	.7888	.8059	.8402	.7716
Min	.3772	.3601	.3086	.3086	.3601	.3601	.3601
Avg	.4973	.4930	.4916	.4739	.4865	.4831	.4851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 246 / DATT MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572	.2572	.2572	.2572	.2572	.2401
2	.2743	.583	.6173	.6344	.2572	.2572	.2401
3	.3086	.6344	.6516	.6687	.2915	.2915	.2743
4	.3429	.6859	.6859	.7716	.3086	.3086	.3258
5	.4801	.823	1.1831	.9774	.3429	.4458	.3772
6		1.0288	1.6289	1.8004	.3944	.6001	.463
7	.3086	2.0576	2.1434	2.0233	.4801	.4458	.3258
8	.2058	2.0233	2.0576		.3429	.3429	.2401
9	.3086	1.989	1.989		.2915	.2401	.1886
10	.2401	1.286	1.9033	.6344	.2572	.1715	.1715
11	.2915	1.0631	1.7661	.6344	.2229	.1372	.1543
12	2.1262	.1543	.1886	.0857	2.0576	2.0919	2.0919
13	2.1091	.1715	.1715	.1029	2.0062	2.0405	2.2291
14	2.0233	.2058	.1372	.1029	1.9376	1.8861	2.0233
15	1.8519	.2401	.2229		1.7833	.8916	2.0233
16	1.8861	.3258	.2401	.2572	1.989	.9945	2.1091
17	2.0233	.2229	.2572	.2572	2.1605		2.1776
18	1.7318		.2229	.2229	2.0576	1.3203	2.2119
19	1.749	.3086	.2915	.3258	2.0233	1.749	1.9547
20	.463	.4458	.3772	.4287	.4115	.3258	.2915
21	.4115	.3772	.3772	.3944	.3944	.3086	.3429
22	.3258	.3258	.3429	.3429	.3429	.2401	.3086
23	.3086	.2915	.3258	.1886	.3086	.2229	.2743
24	.2915	.2743	.2743	.2915	.2743	.2743	.2229
Max	2.1262	2.0576	2.1434	2.0233	2.1605	2.0919	2.2291
Min	.2058	.1543	.1372	.0857	.2229	.1372	.1543
Avg	.8842	.6859	.7630	.5430	.8831	.6888	.8859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 247 / SOMNATH MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1715	.12	.12	.1372	.1372
2	.3944	.1543	.1543	.1543	.3944	.4458	.463
3	.4287	.1543	.1543	.1715	.4458	.5487	.5658
4	.4973	.1886	.1715	.2058	.5144	.583	.6687
5	.6859	.2229	.2058	.2572	.8402	.8745	.8059
6	.9259	.2743	.2401	.2743	1.0802	1.1317	1.1488
7	1.3717	.2743	.2229	.2401	1.3375	1.5947	1.4918
8	1.406	.2058	.1886		1.4403	1.1831	1.3889
9	1.3032	.1886	.1543	.2401	1.3375	1.3203	1.3717
10	1.2003	.2572	.1372	.1715	1.3889	1.406	.9259
11	1.1317	.2229	.12	.1886	1.286	1.1317	.9602
12	.12	1.4232	1.3203	1.1831	.1372	.1029	.1543
13	.1886	1.2003	1.1488	.8402	.1029	.12	.1715
14	.1886		.8059	.8916	.12	.2058	.1886
15	.1886	.9774	.9088	.9774	.12	.1715	.1886
16	.1543	1.0802	.9602	1.046	.12	.1886	.2058
17	.1715	1.1831	1.2517	1.2346	.1372		.2229
18	.1372	1.406	1.3717	1.3375	.1886	.1715	.2058
19	.1886	1.2689	1.406	1.3032	.2058	.1715	.2229
20	.2229	.2401	.2058	.2058	.2229	.1886	.2229
21	.1886	.2229	.1886	.1715	.2058	.1886	.1715
22	.1372	.2058	.1886	.1372	.2058	.1715	.1715
23	.1372	.1886	.1715	.1372	.1715	.1543	.1715
24	.1715	.12	.1715	.1543	.12	.1715	.1543
Max	1.406	1.4232	1.406	1.3375	1.4403	1.5947	1.4918
Min	.12	.12	.12	.12	.1029	.1029	.1372
Avg	.4880	.5129	.5008	.5062	.5101	.5375	.5158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 248 / AKOLA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.2229	.1715	.2058	.1715	.1715
2	.463	.1886	.2058	.1715	.463	.4973	.4973
3	.4973	.2229	.2229	.1886	.4973	.5144	.5487
4	.6173	.2401	.2401	.2058	.6173	.6173	.6344
5	.7545	.2915	.3086	.2058	.7545	.8402	.7888
6	.9259	.3601	.3601	.2229	.9431	1.0288	1.1488
7	1.2689	.3601		.3086	1.2346	1.3889	1.3032
8	1.406	.3429	.3086	.1886	1.3203	1.1488	1.3889
9	1.4575	.2401	.2058	.2229	1.2346	1.3032	1.3717
10	1.3717	.1715	.2058	.1886	1.3032	1.4403	.9602
11	1.2517	.1886	.1543	.1715	1.2517	1.166	.9602
12	.1715	1.3375	1.5089	1.2689	.1543	.1543	.1543
13	.1543	1.2003	1.3375	1.0974	.1715	.1715	.1372
14	.1715	1.166	.8573	.9088	.1715	.2229	.1715
15	.1372	1.1488	.9945	.9774	.1543	.1715	.1715
16	.1029	1.2346	1.1488	1.166	.1715	.1886	.1543
17	.1715	1.3717	1.4232	1.2517	.2229		.1886
18	.1886	1.406	1.3717	1.3375	.2058	.2058	.2401
19	.2401	1.3375	1.2689	1.3375	.2743	.2915	.2743
20	.2229	.2401	.2915	.2229	.3086	.3429	.2743
21	.2915	.2915	.2572	.2572	.2743	.2915	.2229
22	.2229	.2401	.2401	.2743	.2572	.2743	.2229
23	.2229	.2401	.2401	.2401	.2229	.2058	.1886
24	.2058	.1886	.2229	.2229	.2058	.2058	.1886
Max	1.4575	1.406	1.5089	1.3375	1.3203	1.4403	1.3889
Min	.1029	.1715	.1543	.1715	.1543	.1543	.1372
Avg	.5294	.5909	.5912	.5337	.5258	.5584	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 201 / 11 KV KATAFAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.2683	.2321	.2347	.2347	.1174	.1326
2	.1677	.218		.218	2.146	.7545	.6962
3	.2012	.2347	.2155	.218	1.9951	.9054	.7956
4	.2012	.2683	.2984	.2347	2.146	.9724	1.1271
5	.2347	.3353	.3149	.285	2.364	1.0395	1.3592
6	.2683	.3856	.3647	.3018	2.6322	1.5424	1.5083
7	.3018	.3353	.3315	.3185	3.0178	1.5089	1.7736
8	.2683	.285	.2321	.2683	2.9172	1.5257	1.7404
9	.2515	.2347	.1989	.2347	2.1293	1.576	1.3592
10	.2012	.2012	.1823	.2012	2.6658	1.3245	1.0608
11	.1677	.1844	.1989	.2012	2.3472	1.0059	.9614
12	3.3867	3.4537	3.3867	3.3699	.1844	.0838	.0829
13	3.219	3.0178	3.2023	3.1855	.0838	.1006	.0995
14	3.0681	2.934	3.0178	3.0178	.0838	.1174	.0995
15	2.9675	2.5149	2.8334	2.8334	.1006	.1006	.116
16	3.152	2.9843		3.0514	.0838		.0995
17	2.9508		3.1855	3.0514	.0838	.1509	.116
18	3.0346	2.9172	3.1017		.1341	.1492	.116
19	2.8166	2.8675	2.934	2.7831	.1677	.1823	.1823
20	.3018	.2984	.3018	.3018	.1844	.1658	.2155
21	.3018	.3315	.3353		.1509		.1823
22	.2683	.2984	.3185	.3185	.1677	.1492	.1492
23	.2683	.2652		.2683	.1509	.1658	.1492
24	.1844	.2683	.2321	.2347	.2347	.1341	.1326
Max	3.3867	3.4537	3.3867	3.3699	3.0178	1.576	1.7736
Min	.1677	.1844	.1823	.2012	.0838	.0838	.0829
Avg	1.1820	1.0914	1.2104	1.1424	1.1002	.6260	.5940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 202 / 11 KV ITAKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0492	.0492	.0492		.0492	
2	.1966	.2458	.2321	.2458	.0492	.0492	.0492
3	.2785	.2785	.2949	.3113	.0492	.0492	.0492
4	.3768	.3113	.3113	.4096	.0655	.0655	.0655
5	.4752	.3441	.3113	.5243	.0655	.0655	.0655
6	.5243	.5407	.5898	.5571	.0655	.0983	.0819
7	.5898	.6226	.6226	.6718	.0655	.0655	.0819
8	.6718	.6882	.6554	.6554	.0655	.0655	.0655
9	.6554	.6554	.5898	.6554	.0492	.0492	.0655
10	.5735	.5898	.5243	.6226	.0492	.0328	
11	.4424	.4915	.3932	.4915	.0492		.0328
12	.0328	.0492	.0328	.0328	.5571	.5407	.6554
13	.0328		.0328	.0328	.5571	.5735	.5735
14	.0328		.0328	.0492	.6062	.5407	.5079
15	.0328	.0492	.0328	.0328	.5735	.4752	.4096
16	.0492	.0492	.0492	.0328	.6718		.3768
17		.0324	.0328	.0328	.4915	.4752	.4752
18	.0492	.0328	.0503	.0492	.3932	.4534	.2458
19	.0655		.0655	.0655	.4752	.3725	.3605
20	.0983	.0983	.0655		.0983	.0972	.0819
21	.0655	.0819	.0492	.0655	.0655	.0655	.0655
22	.0655	.0655	.0492	.0492	.0655	.0655	.0655
23	.0655		.0492	.0492	.0492	.0655	.0655
24	.0492	.0655	.0492	.0492	.0492	.0492	.0492
Max	.6718	.6882	.6554	.6718	.6718	.5735	.6554
Min	.0328	.0324	.0328	.0328	.0492	.0328	.0328
Avg	.2379	.2671	.2152	.2493	.2273	.1984	.2041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 203 / KATAFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1663	.1463	.1848		.1663	.1646
2	.1478	.1478	.1463	.1663	.1663	.1478	.1463
3	.1663	.1663	.1646	.1663	.1848	.1663	.1463
4	.1848	.2033	.1829	.1848	.2218	.2218	.1646
5	.2218	.2587	.2012	.2218	.2587	.2587	.2195
6	.2218	.3142	.3292	.2587	.2957	.2772	.2926
7	.2402	.3326	.3109	.2957	.3142	.2218	.2561
8		.2218	.2378	.2033	.2218	.1829	.2195
9		.1848	.2012	.2033	.2033	.1829	.1829
10	.1848	.1663	.1829	.1848	.1663	.1463	.1646
11	.2402	.1848	.1463	.1848	.1478		.1463
12	.1478	.1294	.128	.1294	.1478	.1463	.128
13	.1478	.1294	.128	.1294	.1294	.128	.128
14	.1478	.1478	.1463	.1109	.1294		.1463
15	.1663	.1663	.1646	.1478	.1109		.1463
16	.1294	.1478	.2033		.1109		.1097
17	.1478	.2012	.1848	.1663	.1294	.2012	.1463
18	.2033	.2378	.2587	.2033	.1663	.1646	.1646
19	.2772	.2926	.2772	.2402	.2772	.2561	.2926
20	.3696	.3658	.2957	.2587	.2957		.2926
21	.2957	.2743	.2957	.2957	.2561	.2561	.2561
22	.2218	.2195	.2587	.1848	.2378	.2195	.1829
23	.2033	.2012	.2218	.2218	.2012	.2195	.1829
24	.2218	.1848	.1829	.2033	.1848	.1848	.1829
Max	.3696	.3658	.3292	.2957	.3142	.2772	.2926
Min	.1294	.1294	.128	.1109	.1109	.128	.1097
Avg	.2016	.2102	.2081	.1977	.1982	.1973	.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 244 / MANEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134	.1029	.1029	.0857	.1029	.0972	.1029
2	.1134	.12	.1029	.0686	.12	.0972	.1029
3	.1134	.1372	.12	.1029	.1029	.0972	.0857
4	.1134	.1543	.1543	.1372	.1372	.0972	.1029
5	.1296	.1886	.1886	.1372	.1886		.1543
6	.1781	.2229	.2743	.2572	.2572	.1619	.2401
7	.1296	.2229	.2058	.2229	.1715		.2058
8	.1372	.2058	.1372	.1372	.1372	.1781	.1372
9	.1372	.1981	.1543	.1543	.1781	.1619	.2058
10	.12	.1524	.1543	.12	.1781	.0972	.1715
11	.12	.1372	.1543	.1029	.1619	.1029	.1372
12	.1029	.12	.1029	.12	.1457	.12	.1543
13	.0686	.0914	.0857	.0857	.1296	.0857	.1372
14	.0857	.0762	.1029	.0686	.1134	.0686	.1029
15	.0686	.1543	.0686	.12	.1134	.0857	.1029
16	.1029	.12	.0514	.0857	.1296	.12	.1372
17		.1543	.0857	.1715	.1457	.1372	.1715
18	.1543	.1372	.1029	.1543	.1619	.1715	.2058
19	.2229	.2229	.1372	.1715	.1781		.2229
20	.2401	.2401	.1715	.2401	.1943	.2058	.1886
21	.1543	.1886	.1886	.1715	.1619	.1886	.1543
22	.1372	.1543	.1543	.1543	.1296	.1543	.1372
23	.1029	.1372	.12	.12		.1372	.1372
24	.1134	.0857	.12	.1029	.1029	.0972	.12
Max	.2401	.2401	.2743	.2572	.2572	.2058	.2401
Min	.0686	.0762	.0514	.0686	.1029	.0686	.0857
Avg	.1287	.1552	.1350	.1372	.1496	.1268	.1508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 249 / NIJAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2267	.2429	.2753	.2429	.2267	.2401
2	.2591	.2591	.2591	.3239	.5344	.5668	.4534
3	.2429	.2753	.2915	.3563	.5992	.6478	.502
4	.2429	.3077	.3077	.3725	.9069	.6478	.6802
5	.3239	.3401	.3401	.4049	1.1012	.7287	1.0364
6	.3887	.3725	.4049	.4534	1.2146	.9717	1.2955
7		.4049	.3239	.3725	1.2955	1.1336	1.4575
8	.2267	.2591	.2591	.2753	1.2793	1.2146	1.3927
9	.1943	.1781	.2105		1.2146	1.1336	1.2793
10	.1296	.1619	.2267		1.1336	1.085	1.2146
11	.2429	.1457	.1943	.2105	1.0526	.9231	1.1498
12	1.3927	1.1174	.6802	.9555	.2429	.1619	.2429
13	1.247	1.085	.9878	1.0364	.2591	.1619	.2267
14	.9878	.9555	.8907	1.1174	.2591	.1457	.1781
15	1.0202	1.1498	1.085	1.0526	.2591	.1619	.1619
16	1.1174	1.2308	1.2308	.9069	.2915	.1457	
17	1.1336	1.2955	1.2631	.9878	.3239	.1619	
18	1.2146	1.3441	1.3117	1.0202	.3563	.1943	
19	1.004	1.0526	1.1984	1.1012	.3077	.3401	.2915
20	.2753	.3401	.9393	.3887	.3563	.3563	.2915
21	.3077	.3239	.3401	.3563	.3239	.3401	.2591
22	.2591	.2753	.3077	.3239	.2915	.3077	.2267
23	.2267	.2591	.2915	.2915	.2591	.2915	.2429
24	.2591	.1943	.2591	.2591	.2753	.2267	.2591
Max	1.3927	1.3441	1.3117	1.1174	1.2955	1.2146	1.4575
Min	.1296	.1457	.1943	.2105	.2429	.1457	.1619
Avg	.5633	.5648	.5769	.5837	.5992	.5115	.6229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 251 / DONGARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2896	.2591	.2896	.2286	.2591	.2286
2		.5487	.3353	.4115	.2439	.2591	.2134
3	.7287	.6249	.442	.5944	.2743	.2591	.2591
4	.7287	.7011	.5792	.6859	.2896	.2591	.2896
5	.9717	.8078	.823	.8535	.3201	.2591	.3506
6	1.2146	1.0059	1.1279	1.0974	.3658	.2591	.3963
7		1.3108	1.387	1.1584	.3048	.2915	.3353
8	1.2308	1.326	1.3717	1.2346	.2743	.2915	.2896
9	1.1279	1.3717	1.1736	1.2041	.2105	.2267	.2134
10	.7316	1.2193	1.1279	1.1431	.1943	.1943	.1677
11	.6859	1.0974	1.0822	1.0059	.1619	.1677	.1372
12	.2743	.1829	.1981	.1829	.8907	1.0517	.5944
13	.1524	.1372	.1219	.1372	1.0526	.9907	.6859
14	.1372	.1524	.1372	.1372	1.2146	.945	.8993
15	.1219	.1677	.1524	.1524	1.1336	.9755	1.0364
16	.1524	.1677	.1829	.1524	1.1336	1.1126	1.1431
17		.1829	.1981	.1829	1.0526	1.2193	1.2651
18	.1829	.2134	.2134	.2134	1.1336	1.387	1.4022
19	.2896	.2591	.2439	.2896	1.1336	1.0212	1.1126
20	.3048	.3353	.2743	.3048	.2429	.2896	.3201
21	.3506	.3048	.2896	.3048	.3563	.2896	.2896
22	.3201	.2743	.3048	.2896	.3077	.2743	.2591
23	.3048	.2743	.2439	.2591	.2915	.2591	.2439
24	.2591	.2743	.2743	.2286	.2439	.2591	.2439
Max	1.2308	1.3717	1.387	1.2346	1.2146	1.387	1.4022
Min	.1219	.1372	.1219	.1372	.1619	.1677	.1372
Avg	.5014	.5512	.5227	.5214	.5440	.5334	.5157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 241 / SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4287	.3944	.4287	.4287	.3944	.3944
2	.8573	.3944	.6173	.5316	.463	.3944	.4115
3	1.0288	.4458	.7202	.6344	.4801	.4458	.463
4	1.0631	.6516	.823	.7545	.5144	.4973	.4973
5	1.1488	.9602	.9088	1.286	.6001	.5316	.5658
6	1.5261	1.3889	1.2517	1.5432	.6173	.6173	.5658
7	1.9033	1.8519	1.9204	1.8861	.6001	.5144	.6001
8	2.0748	1.9547	1.9376	1.8519	.4458	.3772	.4801
9	1.8519	1.6804	1.869	1.8176	.3086	.2743	.3258
10	1.6804	1.5432	1.1831	1.6632	.3086	.2401	.2401
11	1.4746	1.2003	1.0631	1.3375	.2743	.2058	.2572
12	.0514	.2058	.2229	.1886	1.4403	1.4746	1.4403
13	.0343	.1886	.2229	.1886	1.406	1.4403	1.3375
14	.0514	.1715	.2229	.1886		1.4746	1.2517
15	.2401	.1715	.2401	.2058	1.4403	1.5089	1.2346
16	.2743	.2058	.2401	.2229	1.5261	1.5261	1.5604
17	.3086	.3086	.2743	.2743	1.5947	1.5604	1.406
18	.3258	.2743	.3258	.4115	1.5432	1.1317	1.3546
19	.4973	.3944	.3772	.463	1.4746	1.286	1.4918
20	.6001	.4115	.5316	.5316	.5487	.463	.3601
21	.4973	.4801	.4801	.463	.4973	.4287	.5316
22	.4973	.4115	.4458	.4287	.4287	.3944	.4458
23	.463	.4115	.4115	.4458	.4287	.3944	.4115
24	.4115	.4287	.4115	.4115	.463	.4287	.3772
Max	2.0748	1.9547	1.9376	1.8861	1.5947	1.5604	1.5604
Min	.0343	.1715	.2229	.1886	.2743	.2058	.2401
Avg	.8030	.6902	.7123	.7566	.7753	.7502	.7502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 242 / WAKI SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2429	.2429	.2267	.2591	.2591	.2753
2	.2429	.2753	.2591	.2267	.8259	1.1145	1.0202
3	.2591	.3077	.2915	.2591	.9069	1.1012	1.1012
4	.2915	.3401	.3239	.2591	.9878	1.1984	1.1822
5	.3239	1.3117	.3401	.2915	1.085	1.247	1.2955
6	.4534	.3563	.4372	.3239	1.4413	1.8785	1.587
7	.3887	.3887	.4372	.421	1.8461	1.8785	1.7814
8	.2915	.3401	.2429	.3239	1.749	1.3765	1.7814
9	.2267	.2915	.2267	.2915	1.749	1.3441	1.7814
10	.1943	.2267	.2105	.2591	1.5384	1.3441	1.8347
11	.1943	.1619	.2267	.2267	1.3117	1.3279	1.2689
12	1.6356	1.6032	1.587	1.6032	.1619	.1457	.2105
13	1.5223	1.3927		1.3927	.1457	.1457	.1943
14	1.3927	1.3927	1.2308	1.2955	.1457	.1619	.1943
15	1.4251	1.3117	1.3279	1.2955	.1619	.1619	.1943
16	1.4737	1.4575	1.3765	1.4575	.1781	.1781	.2267
17	1.5708	1.6356	1.4899	1.6194	.1781	.1943	.2267
18	1.668	1.6518	1.6194	1.5708	.2267	.2591	.2591
19	1.2146	1.5061	1.4413	1.4899	.2915	.2915	.3401
20	.3077	.2915	.4458	.3401	.3401	.3563	.3401
21	.2753	.3077	.3563	.3077	.3077	.3239	.3239
22	.2591	.2429	.2915	.2753	.2753	.3239	.2915
23	.2267	.2429	.2591	.2753	.2753	.2915	.2915
24	.2429	.2429	.2429	.2267	.2753	.2753	.2915
Max	1.668	1.6518	1.6194	1.6194	1.8461	1.8785	1.8347
Min	.1943	.1619	.2105	.2267	.1457	.1457	.1943
Avg	.6802	.7301	.6481	.6775	.6943	.7158	.7622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 243 / GALVEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1372	.1372	.1372	.1372	.12	.12
2	.0857	.12	.1543	.1372	.6516	.8402	.8059
3	.0857	.12	.1715	.1886	.7545	.8916	.8745
4	.12	.1715	.1886	.1886	.9259	.9602	.9431
5	.1543	.2401	.2229	.2058	1.0117	1.0288	1.046
6	.2572	.2401	.2229	.2058	1.406	1.5604	1.2689
7	.2229	.2401	.2058	.2229	1.6289	1.7318	1.4403
8	.2058	.2058	.1372	.1543	1.5775	1.6632	1.5261
9	.1372	.1715	.12	.1372	1.5089	1.5604	1.5261
10	.1372	.1372	.1029	.1029	1.3546	1.4403	1.4403
11	.0686	.1029	.0857	.1029	1.2003	1.1488	1.2003
12	1.4575	1.2346	1.4575	1.3375	.1029	.1029	.0857
13	1.4746	1.3375	1.406	1.3375	.1029	.1029	.0857
14	1.5089	1.3717	1.3889	1.3375	.1029	.1029	.0686
15	1.3889	1.3203	1.3889	1.3889	.1029	.12	.0857
16	1.4232	1.3717	1.3889	1.4575	.1029	.12	.1029
17	1.4575	1.5089	1.406	1.4746	.0857	.12	.1029
18	1.406	1.5432	1.4403	1.4746	.1372	.1372	.1029
19	.7545	1.3717	1.286	1.2517	.1886	.1715	.1886
20	.2229	.1543	.2229	.2401	.2229	.1886	.1886
21	.1886	.1715	.2058	.1886	.1715	.1543	.1715
22	.1543	.1886	.1886	.1715	.0857	.1543	.1372
23	.1372	.1543	.1715	.1715	.1029	.1372	.12
24	.0857	.1372	.1372	.1372	.1543	.1134	.12
Max	1.5089	1.5432	1.4575	1.4746	1.6289	1.7318	1.5261
Min	.0686	.1029	.0857	.1029	.0857	.1029	.0686
Avg	.5508	.5730	.5766	.5730	.5759	.6113	.5730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 201 / WATAMBARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372	.1029	.12	.12
2	.1372	.1372	.1372	.1715	.12	.12	.1372
3	.1715	.1543	.1372	.1715	.12	.1029	.1372
4	.1886	.1543	.1029	.1886	.1372	.1029	.1715
5	.2229	.1372	.1029	.1886	.1543	.1372	.2058
6	.2058	.1372	.1029	.2058	.1715	.1372	.2058
7	.1886	.1372	.1372	.2058	.1715	.1715	.1886
8	.1543	.12	.1372	.1715	.1543	.1372	.1715
9	.1543	.12	.1372	.1372	.1372	.1372	.1543
10	.1543	.12	.1372	.12	.1372	.1372	.0857
11	.1372	.1372	.12	.1029	.1372		.1715
12	.1372	.12	.12	.1029	.1372	.1543	.1372
13	.1372	.12	.1372	.1029	.1029	.1372	.1543
14	.1372	.12	.1372	.1029	.1029	.1372	.0857
15	.1029	.12	.1372	.1029	.1029	.12	.1029
16	.1029	.1372	.1372	.12	.1372	.12	.1029
17	.1029	.1372	.12	.1372	.1715	.1372	.12
18	.12	.1372	.1715	.1715	.2058	.1715	.0857
19	.2058	.2058	.2058	.2401	.2743	.2229	.1715
20	.12	.2058	.2401	.2229	.2401	.2401	.1715
21	.12	.1715	.2572	.1886	.2058	.2401	.1715
22	.12	.1715	.2401	.1715	.2058	.2058	.1715
23	.1372	.1543	.2058	.1715	.1715	.1886	.1715
24	.1715	.12	.1715	.1715	.1715	.1543	.1715
Max	.2229	.2058	.2572	.2401	.2743	.2401	.2058
Min	.1029	.12	.1029	.1029	.1029	.1029	.0857
Avg	.1486	.1422	.1529	.1586	.1572	.1536	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 202 / 11 KV WATAMBARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1715	.0857	.1715	.1372	.1543	.1715
2	.1543	.5144	.4801	.8573	.1715	.1543	.1886
3	.1715	.6001	.5487	.9431	.2058	.1715	.2058
4	.1886	.8059	.7545	1.0288	.2229	.1715	.2058
5	.2058	.8916	.9945	1.0631	.2401	.2058	.2229
6	.2058	.9602	1.2003	1.1738	.2572	.2058	.2401
7	.2229	.9088	1.3375	1.2003	.2743	.2401	.3086
8	.1543	1.0288	1.3375	1.2003	.2058	.2058	.2401
9	.1543	1.2003	1.3032	1.3717	.1543	.2058	.2058
10	.1372	1.0631	1.2689	1.0631	.1372	.2229	.1715
11	.1543	.8573	1.0631	.9259	.1372		.2058
12	1.0288	.1372	.0857	.12	.6516	1.2003	1.1317
13	.9945	.1543	.1543	.12	.7545	1.1317	1.166
14	.9945	.1715	.1543	.1372	.9945	1.0974	1.0288
15	1.0288	.1715	.1543	.1372	1.0974	.9945	.823
16	1.0288	.1715	.1543	.1543	1.166	.9602	.8916
17	1.1145	.2058	.1715	.1888	1.2689	1.2003	1.1145
18	1.2003	.2401	.2058	.2058	1.406	1.1317	1.2003
19	1.2689	.2401	.2743	.2401	1.2003	1.046	1.2003
20	.1543	.2058	.3086	.2229	.1715	.1715	.1715
21	.12	.1715	.2572	.2058	.1715	.2058	.2058
22	.1372	.1715	.2401	.2058	.2058	.2229	.2058
23	.1543	.1372	.2058	.2229	.1715	.2401	.1886
24	.1715	.1543	.1372	.1715	.2572	.2058	.2058
Max	1.2689	1.2003	1.3375	1.3717	1.406	1.2003	1.2003
Min	.12	.1372	.0857	.12	.1372	.1543	.1715
Avg	.4708	.4723	.5366	.5555	.4858	.5107	.4958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 203 / 11 KV ANAKDHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.1029	.12	.1029	.1543	.12
2	.5144	.1372	.1372	.12	.9483	.4973	.5144
3	.6001	.1543	.1372	.1372	.9774	.823	.6001
4	.6859	.1886	.1715	.1372	1.0117	.9945	.7716
5	.8573	.2229	.2058	.1715	1.0631	.9945	.8573
6	.9431	.2572	.2058	.1715	1.1145	1.0288	1.0288
7	1.1145	.2401	.2058	.1543	1.1317	1.0631	1.2003
8	.9259	.1543	.1372	.1372	1.0974	1.0974	1.166
9	.9431	.1715	.1029	.1029	1.0631	1.0631	1.1317
10	.8916	.0857	.1029	.1029	1.0288	1.0288	1.0631
11	.8573	.0857	.12	.0857	.9602		.9602
12	.1029	1.0288	1.2174	1.2346	.1372	.0857	.0686
13	.0857	1.0631	1.1317	1.166	.1029	.0857	.0857
14	.0857	.9945	1.0631	1.0288	.1029	.1029	.1029
15	.0857	.9259	1.0288	.8916	.1029	.1029	.1029
16	.0857	.9602	1.0631	1.0631	.1372	.1029	.0857
17	.0857	1.0631	1.1317	1.2003	.1372	.1029	.1029
18	.1029	1.2689	1.1145	1.166	.1715	.1029	.12
19	.1543	1.0974	1.0974	1.0974	.1372	.12	.1372
20	.1372	.1715	.1715	.1372	.1372	.1715	.12
21	.1372	.1372	.2058	.12	.1372	.1543	.12
22	.1029	.1372	.1886	.1029	.1372	.1543	.1372
23	.1029	.1372	.1715	.1372	.12	.1372	.1372
24	.1372	.1029	.1372	.1372	.12	.1372	.1372
Max	1.1145	1.2689	1.2174	1.2346	1.1317	1.0974	1.2003
Min	.0857	.0857	.1029	.0857	.1029	.0857	.0686
Avg	.4108	.4537	.4730	.4551	.5075	.4481	.4530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 203 / 11 KV HANNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18
HR	Load (MW)
1	.3525
2	.3763
3	.4001
4	.4058
5	.3763
6	.4058
7	.5944
8	.6783
9	.9945
10	.3906
11	.3906
12	.463
13	.4744
14	.3858
15	.463
16	.4572
17	.463
18	.4572
19	.5601
20	.5335
21	.4934
22	.423
24	.3763
Max	.9945
Min	.3525
Avg	.4746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 204 / 11 KV NANHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18
HR	Load (MW)
1	.3201
2	.3239
3	.2543
4	.2515
5	.3315
6	.4239
7	.503
8	.3391
9	.3315
10	.2658
11	.2658
12	.2658
13	.2686
14	.2629
17	.2149
18	.1772
19	.2865
20	.2835
21	.2835
24	.2713
Max	.503
Min	.1772
Avg	.2962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 205 / 11 KV SULTANPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
1	.3201
2	.3353
3	.4239
4	.4049
5	.6401
6	.6783
7	.663
8	.663
9	.6299
10	.6401
17	.016
18	.0164
19	.016
20	.0164
21	.0164
22	.016
24	.0168
Max	.6783
Min	.016
Avg	.3243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 206 / 11 KV BAWKARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
1	.6783
2	.663
3	.7202
4	.7202
5	.8478
6	.6554
7	.6706
8	1.7635
9	1.7604
10	1.6484
17	.064
18	.064
19	.064
20	.096
21	.1638
22	.16
24	.1311
Max	1.7635
Min	.064
Avg	.6395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 207 / 11 KV ANV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18
HR	Load (MW)
1	.0164
2	.0166
3	.0164
4	.017
5	.0168
6	.0168
7	.0164
8	.017
9	.0168
10	.016
11	.016
12	.016
13	.016
14	.0164
15	.016
16	.016
17	.0164
18	.016
19	.0164
20	.016
21	.016
22	.0164
24	.0168
Max	.017
Min	.016
Avg	.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 204 / 11kv Rly Station Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4525	.4525	.462	.4525	.462
2	.4572	.4572	.4525	.4525	.462	.4525	.462
3	.5487	.4572	.4525	.543	.5544	.543	.462
4	.5487	.5487	.4525	.6335	.6468	.6335	.5544
5	.6401	.7316	.543	.724	.7392	.724	.5544
6	.7316	.823	.8145	.8145	.8316	.8145	.8316
7	.6401	.7316	.724	.7392	.7392	.6401	.6468
8	.5487	.4572	.543	.543	.5544	.5487	.462
9	.4572	.4572	.4525	.462	.462	.4572	.462
10	.4572	.4572	.4525		.462	.4525	.462
11	.3658	.3658	.4525		.462	.462	.462
12		.3658	.4525		.3696	.3696	.462
13	.3658	.362	.362		.3658	.3696	.3696
14	.3658	.362	.362	.3696	.3658	.3696	.3696
15	.3658	.362	.362		.3658	.3696	.462
16	.4572	.362	.4525	.462	.3658		.462
17	.4572	.3658	.4525	.5544	.4572		.462
18	.5487	.4525		.5544	.4572	.5544	.5544
19	.5487	.6335	.6335	.6468	.543	.7392	.7392
20	.7316	.724	.6335	.7392	.6335	.724	.7392
21	.6401	.543	.6335	.6468	.543	.6468	.6468
22	.5487	.543	.543	.5544	.543	.5544	.5544
23	.4572	.4525	.4525	.462	.4525	.462	.5544
24	.4572	.4572	.362	.4525	.462	.4525	.462
Max	.7316	.823	.8145	.8145	.8316	.8145	.8316
Min	.3658	.362	.362	.3696	.3658	.3696	.3696
Avg	.5129	.4971	.4997	.5688	.5125	.5360	.5275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 205 / 11 KV Gaudgaon Bk Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.08	.08	.08	.16	.2401	.16
2	.08	.08	.08	.08	.2401	.3201	.2401
3	.08	.08	.08	.08	.2401	.4001	.2401
4	.08		.08	.08	.3201	.4001	
5	.08	.08	.08	.08	.3201	.4801	.3201
6	.08	.08	.08	.08	.4001	.4801	.4801
7	.08	.08	.08	.08	.4801	.5601	.6401
8	.08	.08	.08	.08	.5601	.5601	.5601
9	.08	.08	.08	.08	.5601	.4801	.4801
10	.08	.08	.08		.4801	.4001	.4801
11	.08	.08	.08				
12		.4049	.4001				
13	.4049	.4049	.4801				
14	.4858	.4858	.4801	.2401			
15	.4049	.4049	.4801				
16	.4049	.4049	.4801	.3201			
17	.4858	.4049		.5601	.08	.08	.08
18	.4049	.4049	.4001	.5601	.08	.08	.08
19	.2429	.4049	.4001	.4801	.08	.08	.08
20	.081	.081	.08	.08	.08	.08	.08
21	.08	.081	.08	.08	.08	.08	.08
22	.08	.081	.08	.08	.08	.08	.08
23	.08	.081	.08	.08	.08	.08	.08
24	.08	.08	.08	.08	.08	.08	.08
Max	.4858	.4858	.4801	.5601	.5601	.5601	.6401
Min	.08	.08	.08	.08	.08	.08	.08
Avg	.1789	.1967	.1913	.1727	.2445	.2756	.2495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 201 / 11 KV MOTYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0953	.0953	.0953	.0953
2				.0953	.0953	.0953	.0953
3				.0953	.0953	.0953	.0953
4				.0953	.0953	.0953	.0953
5				.0953	.0953	.0953	.0953
6				.1905	.1905	.0953	.1905
7				.1905	.1905	.1905	.2858
8				.2858	.2858	.2858	.2858
9				.2858	.1905	.2858	.1905
10				.1905	.1905	.1905	.1905
12	.1905	.1905	.0953				
13	.1905	.1905	.0953				
14	.1905	.1905	.1905				
15	.1905	.1905	.1905				
16	.1905	.1905	.2858				
17	.1905	.1905	.1905				
18	.1905	.0953	.1905				
19	.1905	.0953	.1905				
Max	.1905	.1905	.2858	.2858	.2858	.2858	.2858
Min	.1905	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1905	.1667	.1786	.1620	.1524	.1524	.1620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 202 / 11 KV WAGADARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242	.6668	.0953	.0953	.0953	.0953
2	1.5242	1.5242	.8573	.0953	.0953	.0953	.0953
3	1.5242	1.7147	.8573	.0953	.0953	.0953	.0953
4	1.7147	1.9052	.8573	.0953	.0953	.0953	.0953
5	2.0957	2.0005	.9526	.0953	.0953	.0953	.0953
6	3.0483	2.4768	1.1431				
7	3.8104	3.1436	2.7625				
8	3.7151	2.8578	2.9531				
9	3.4294	2.6673	2.8578				
10	3.0483	2.7625	2.8578				
11		.0953	.0381				
12		.0953	.0381		3.8104	2.9531	3.2388
13		.0953	.0381		3.4294	3.0483	2.9531
14		.0953	.0381			2.9531	2.8578
15		.0953	.0381		3.6199	2.6673	
16		.0953	.0381		3.6199	2.572	2.9531
17		.0953	.0381		3.6199	2.8578	3.2388
18		.0953			3.4294	2.572	3.1436
19		.0953		2.8578	3.0483	2.191	2.8578
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.381	.0953	.0953	.0953	.0953	.0953
23	.0953		.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.8104	3.1436	2.9531	2.8578	3.8104	3.0483	3.2388
Min	.0953	.0953	.0381	.0953	.0953	.0953	.0953
Avg	1.7274	1.0479	.7959	.3464	1.5018	1.2649	1.3056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 203 / 11 KV SANGAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.3336	.0953	.0953	.0953	.0953
2	1.1431	1.2384	1.3336		.0953	.0953	.0953
3	1.1431	1.3336	1.3336	.0953	.0953	.0953	.0953
4	1.2384	1.4289	1.4289	.0953	.0953	.0953	.0953
5	1.4289	1.1431	1.7147	.0953	.0953	.0953	.0953
6	1.8099	1.9052	1.9052				
7	2.191	1.9052	2.0957				
8	1.9052	2.4768	2.191				
9	2.0957	2.2862	2.191				
10	2.0005	2.2862	2.0957				
12					2.3815	2.2862	2.3815
13					2.572	2.2862	2.572
14					2.572	2.0005	2.4768
15					2.7625	2.3815	2.2862
16					2.4768	2.4768	2.4768
17					2.3815	2.4768	2.4768
18					2.4768	2.3815	2.3815
19		.0953		2.191	2.2862	2.0957	2.191
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	2.191	2.4768	2.191	2.191	2.7625	2.4768	2.572
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.1050	1.1074	1.2066	.3049	1.1590	1.0743	1.1220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 204 / 11 KV Shirwal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4763	.5716
2						.5716	.5716
3						.6668	.6668
4						.7621	.7621
5						.9526	.9526
6						1.1431	1.1431
7						.9526	1.0479
8						.8573	
9							.7621
10						.6668	.6668
11						.5716	.5716
12						.5716	.5716
13						.5716	.4763
14						.4763	.4763
15						.4763	.4763
16						.4763	.5716
17						.5716	.5716
18						.5716	.4763
19						.8573	.8573
20						.9526	.9526
21						.8573	.8573
22						.7621	.7621
23	.6668	.5716	.6668	.6668	.5716	.6668	.6668
24	.5716	.5716	.5716	.5716	.6668	.5716	.6668
Max	.6668	.5716	.6668	.6668	.6668	1.1431	1.1431
Min	.5716	.5716	.5716	.5716	.5716	.4763	.4763
Avg	.6192	.5716	.6192	.6192	.6192	.6958	.7000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 205 / 11kv Wagdari Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.381	.4763	.4763	.4763	.4763
2	.4763	.4763	.381	.4763	.4763	.4763	.4763
3	.4763	.4763	.381	.4763	.4763	.4763	.4763
4	.4763	.5716	.5716	.4763	.5716	.5716	.5716
5	.5716	.7621	.6668	.5716	.6668	.6668	.6668
6	.6668	.8573	.7621	.7621	.8573	.8573	.8573
7	.5716	.7621	.7621	.6668	.7621	.8573	
8	.4763	.6668	.6668	.5716	.6668	.6668	.6668
9	.4763	.5716	.4763	.4763	.5716	.5716	.5716
10	.4763	.5716	.4763	.4763	.5716	.4763	.5716
11	.4763	.4763	.4763		.4763	.4763	.4763
12	.4763	.381	.4763		.381	.381	.4763
13	.4763	.381	.4763	.4763	.381	.4763	.4763
14	.4763	.381	.4763	.4763	.381	.4763	.4763
15	.4763	.381	.4763	.4763	.4763	.4763	.4763
16	.5716	.381	.4763	.4763	.4763	.4763	.4763
17	.4763	.381	.381	.4763	.4763	.4763	.4763
18	.4763	.381	.4763			.4763	.4763
19	.7621	.5716		.6668	.5716	.6668	.5716
20	.7621	.7621	.8573	.8573	.7621	.7621	.7621
21	.6668	.6668	.7621	.6668	.6668	.6668	.7621
22	.5716	.5716	.6668	.5716	.5716	.5716	.5716
23	.4763	.4763	.5716	.5716	.4763	.4763	.4763
24	.4763	.4763	.4763	.4763	.4763	.4763	.4763
Max	.7621	.8573	.8573	.8573	.8573	.8573	.8573
Min	.4763	.381	.381	.4763	.381	.381	.4763
Avg	.5319	.5358	.5467	.5534	.5509	.5597	.555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 206 / 11kv Borgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	1.1431	1.5242	1.1431	1.3336
2	.0953	.0953	.0953	1.1431	1.5242	1.3336	1.3336
3	.0953	.0953		1.1431	1.5242	1.3336	1.3336
4	.0953	.0953		1.2384	1.5242	1.5242	1.4289
5	.0953	.0953		1.4289	1.7147	1.5242	1.5242
6				2.0957	2.4768	2.2862	1.9052
7				2.4768	2.572	2.6673	2.191
8				2.191	2.6673	2.2862	2.2862
9				1.6194	2.4768	1.9052	2.0957
10				1.7147	1.9052	1.9052	1.8099
12	2.191	2.2862	2.4768				
13	2.4768	2.2862	2.3815				
14	2.191	2.2862	2.2862				
15	2.191	2.2862					
16	2.2862	2.6673	2.3815				
17	2.2862	2.6673	2.572				
18	2.2862	2.572	2.191				
19	1.7147	2.0957	1.9052				
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	2.4768	2.6673	2.572	2.4768	2.6673	2.6673	2.2862
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.0320	1.1167	1.2044	1.1114	1.3591	1.2257	1.1812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 201 / 11 KV TADWAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3672	1.3672	.0892	.104	.1189	.104	.104
2	1.382	1.4118	.0892	.104	.1174	.104	.104
3	1.4118	1.4415	.1189	.1189	.132	.1189	.1189
4	1.4266	1.6255	.1486	.1189	.1635	.104	.1337
5	1.5158	1.776	.1486	.1337	.1635	.1189	.1486
6	1.7238	1.8513	.1783	.1486	.1783	.1783	.1337
7	1.9319	2.1072	2.1696				
8	1.9913	2.2125	2.1399				
9	1.9616	1.9616	2.1102				
10		2.0062	2.1251				
12				1.6347	2.0953	1.8873	1.7833
13				1.9814	2.021	1.9022	1.8724
14				2.0119	2.021	1.8873	1.8873
15				2.0119	2.0359	1.8724	1.6347
16				1.9115	2.0508	1.917	2.0656
17				1.9616	2.0656	1.9319	2.0508
18				2.0508	2.0359	1.9616	2.0359
19	.0892	.1189	.1189	1.8576	1.8873	1.9913	1.917
20	.1486	.1337	.1337	.1337	.1337	.1337	.1189
21	.1355	.1337	.1337	.1337	.1486	.1337	.1189
22	.1355	.1189	.1337	.1189	.1486	.1337	.1189
23	.1355	.104	.1189	.1189	.1189	.1337	.104
24	.1189	1.2944	.0892	.104	.1189	.104	.1189
Max	1.9913	2.2125	2.1696	2.0508	2.0953	1.9913	2.0656
Min	.0892	.104	.0892	.104	.1174	.104	.104
Avg	1.0317	1.2290	.6279	.8820	.9345	.8799	.8721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 202 / 11 KV KHANAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0924	.0754	1.4327	1.6263	1.2955	1.5844
2	.0754	.0732	.0754	1.448	1.6632	1.326	1.6221
3	.0754	.0732	.0754	1.4784	1.7002	1.4243	1.6409
4	.0754	.0739	.0732	1.5089	1.9044	1.4403	1.6975
5	.0943	.0924	.0754	1.5242	2.0538	1.448	1.773
6	.0754	.0924	.0754	1.5394	2.1658	1.6156	2.1502
7				1.829	2.3712	1.7985	2.2822
8				1.9052	2.4025	1.8442	2.3011
9				1.9357	2.4646	1.7833	2.2257
10				1.8442	2.4272	1.8442	2.2068
12	2.2731	2.32	1.8138				
13	2.3655	2.3765	1.8747				
14	2.1098	2.3577	1.8442				
15	2.2546	2.3765	1.7833				
16	2.2405	2.4331	1.8442				
17	2.2546	2.452	1.89				
18	2.2546	2.3765	1.8747				
19	2.2177	2.3388	2.268	.0739	.0457	.0754	.0457
20	.112	.0943	.0762	.0924	.0762	.1132	.0762
21	.112	.0943	.0762	.0924	.0762	.1132	.0762
22	.112	.0943	.0762	.0924	.0762	.1029	.0762
23	.1109	.0943	.0762	.0934	.0762	.1132	.0762
24	.0943	.1109	.0754	.0762	1.531	.0762	.0943
Max	2.3655	2.452	2.268	1.9357	2.4646	1.8442	2.3011
Min	.0754	.0732	.0732	.0739	.0457	.0754	.0457
Avg	1.0001	1.0535	.8433	1.0604	1.4163	1.0259	1.2455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 203 / 11 KV MHAISALGI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.0914	.1543	1.7747	1.4632	1.4969	1.9444
2	.0772	.0762	.1235	1.821	1.6461	1.5278	1.9753
3	.0772	.061	.0926	1.8519	1.7071	1.5432	1.9753
4	.0772	.0617	.0772	1.929	1.821	1.5895	2.037
5	.0772	.0617	.0617	1.9662	1.9136	1.8056	2.2222
6	.0772	.0617	.0617	2.2994	2.0062	2.3457	2.4537
7				2.5463	2.4371	2.5	2.4691
8				2.5617	2.4371	2.5926	2.5772
9				2.608	2.4684	2.4846	2.5617
10				2.5309	2.4996	2.5926	2.4691
12	2.3434	2.5926	2.2531				
13	2.5777	2.5772	2.4846				
14	2.3434	2.5926	2.5309				
15	2.5154	2.5772	2.5772				
16	2.6235	2.5617	2.6389				
17	2.6235	2.608	2.6235				
18	2.5463	2.5772	2.5926				
19	2.5309	2.4691	2.5309	.0617	.0617	.0617	.0463
20	.1562	.1235	.1235	.1524	.1235	.1389	.108
21	.1543	.1543	.1235	.1389	.1389	.1389	.108
22	.1562	.1543	.1235	.216	.1389	.1543	.108
23	.1562	.1543	.108	.216	.1235	.1543	.108
24	.1235	.1235	.1543	.108	1.3592	.108	.1235
Max	2.6235	2.608	2.6389	2.608	2.4996	2.5926	2.5772
Min	.0772	.061	.0617	.0617	.0617	.0617	.0463
Avg	1.1226	1.1410	1.1282	1.4239	1.3966	1.3272	1.4554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 204 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9488	.9602	.128	.1107	.128	.112
2	.9922	.9804	.9922	.128	.1107	.128	.112
3	.9922	1.0753	.9922	.128	.1265	.128	.112
4	1.0242	1.1683	1.0242	.144	.144	.144	.144
5	1.0883	1.3123	1.1203	.16	.144	.16	.16
6	1.5043	1.4403		.176	.16	.176	.16
7	1.7604	1.8884	1.6964				
8	1.4883	1.8404	1.7764				
9	1.5524	1.5813	1.6964				
10		1.5497	1.6004				
11					1.6004		
12				1.4998	1.6004	1.4083	1.6004
13				1.5813	1.5043	1.4083	1.7124
14				1.5623	1.4243	1.4243	1.6164
15				1.4548	1.4403	1.4403	1.6804
16				1.5684	1.4563	1.4563	1.7284
17				1.5497	1.4723	1.5364	1.8084
18				1.5813	1.7444	1.6964	1.8244
19	.0949	.128	.128	1.5203	1.6644	1.5524	1.6644
20	.1581	.144	.176	.1423	.144	.144	.128
21	.1581	.16	.176	.144	.144	.16	.144
22	.1581	.128	.176	.128	.128		.16
23	.1423	.128	.16	.1265	.128	.144	.16
24	.128	.9014	.112	.128	.1107	.128	.128
Max	1.7604	1.8884	1.7764	1.5813	1.7444	1.6964	1.8244
Min	.0949	.128	.112	.1265	.1107	.128	.112
Avg	.8135	.9609	.8524	.7290	.7679	.7424	.7976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 205 / 11KV TADWAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4887	.4938	.5304	.4887	.5487	.4938
2	.5121	.5068	.5304	.5487	.5068	.6219	.5121
3	.6584	.5792	.6584	.6036	.6154	.6767	.6219
4	.8413	.695	.7316	.6401	.695	.7133	.7316
5	.7682	.7316	.823	.7316	.7682	.7682	.8413
6	.6767	.7682	.7316	.8048	.7682	.6401	.695
9	.5487	.5487	.5121	.4938	.5068	.5121	.5121
10		.4938	.5121	.4207	.4344	.4572	.5121
11	.4938	.4755	.4572	.439	.4572	.439	.4755
12	.4525	.4207	.439	.439	.4572	.4207	.439
13	.4706	.4207	.4024	.4163	.4207	.4024	.4572
14	.4344	.4024	.3841	.4525	.4207	.4207	.4755
15	.4344	.4024	.4024	.4163	.439	.4572	.4572
16	.4344	.4024	.3841	.4344	.4207	.439	.4321
17	.4163	.439	.4207	.4344	.439	.4572	.4938
18	.4525	.4755	.4207	.4706	.4572	.4755	.5304
19	.6219	.5853	.567	.5973	.6219	.5487	.695
20	.7316	.7316	.6767	.7316	.6805	.7133	.7316
21	.7316	.6584	.7133	.6767	.6767	.6767	.695
22	.6219	.5853	.6219	.543	.5487	.6219	.5247
23	.5853	.5487	.4938	.543		.5121	.695
24	.4938	.5121	.4938	.4755	.5068	.4938	.4938
Max	.8413	.7682	.823	.8048	.7682	.7682	.8413
Min	.4163	.4024	.3841	.4163	.4207	.4024	.4321
Avg	.5646	.5396	.5396	.5383	.5395	.5462	.5689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 207 / 11 KV Mangrul Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1791	.197	.1791	.1791	.197	.1791
2	.197	.197	.2149	.2328	.197	.2328	.1791
3	.2328	.2328	.2328	.2686	.2328	.2686	.2328
4	.2865	.2715	.2865	.3045	.2715	.3224	.2865
5	.3224	.3077	.3224	.3224	.3077	.3403	.3224
6	.3045	.3258	.3403	.3403	.3258	.3045	.3045
9	.1433	.1629	.197	.1791	.1791	.1791	.197
10	.197	.2172	.1791	.1612	.1791	.1612	.1791
11	.1433	.197	.1612	.1791	.1791	.1612	.1791
12	.1791	.197	.1612	.1612	.1612	.1612	.197
13	.181	.1791	.1612	.1612	.1612	.1612	.1791
14	.1791	.1612	.1612	.1629	.1254	.1612	.1612
15	.1791	.1612	.1791	.1629	.1254	.1433	.1612
16	.1791	.1612	.1791	.1612	.1254	.1791	.1612
17	.1791	.1612	.1433	.1629	.1254	.1612	.1612
18	.1791	.1612	.1829	.181	.1433	.1433	.197
19	.2353	.2507	.2378	.2353	.2686	.2328	.2328
20	.2715	.2865	.2686	.2896	.3045	.2865	.2686
21	.2715	.2686	.2865	.2715	.2507	.2686	.2865
22	.2353	.2507	.2149	.2353	.2328	.2507	.2149
23	.2172	.2328	.1791	.2172	.1791	.197	.1791
24	.1791	.1991	.197	.1791	.1991	.1791	.197
Max	.3224	.3258	.3403	.3403	.3258	.3403	.3224
Min	.1433	.1612	.1433	.1612	.1254	.1433	.1612
Avg	.2123	.2164	.2129	.2158	.2024	.2133	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 203 / 11 KV AHERWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0572	.0514	.5144	.5144	.5144	.6001
2	.0514	.0762	.0514	.5144	.5144	.6001	.6859
3	.0514	.0381	.0514	.5487	.5487	.6859	.703
4	.0514	.0572	.0514	.6173	.6173	.7716	.7716
5	.0686	.0572	.0514	.6859	.6859	.823	.7716
6	.0857	.0572	.0514	.7202	.7545	.8402	.823
7	.0857	.0572	.0514	.8059	.8573	.8916	.9259
8	.0686	.0572	.0514	.5487	.8573	.9259	.9602
9	.0572	.0514	.0514		.7888	.9431	.9088
10	.0762	.0514	.0343	.6344	.7716	.9431	.9259
11	.0762	.0514	.0343		.0514	.0514	
12	.6001	.823	.8402		.0514	.0514	.0572
13	.6344	.8573	.8573		.0343	.0514	.0572
14	.6859	.7716	.7716		.0343	.0514	.0572
15	.7716	.823	.8059		.0343	.0514	.0762
16	.8916	.8573	.823		.0343	.0686	.0762
17	.9088	.8916	.8573		.0343	.0857	.0762
18	.9259	.8573	.8916		.0343	.0686	.0762
19	.9431	.8573	.7716		.0514	.0686	.0762
20	.0572	.0514			.0514	.0686	.0762
21	.0572	.0514	.0514		.0686	.0686	.0762
22	.0572	.0514	.0514		.0686	.0686	.0762
23	.0572	.0514	.0514		.0514	.0514	.0762
24	.0514	.0572	.0514	.0343	.0343	.0343	.0572
Max	.9431	.8916	.8916	.8059	.8573	.9431	.9602
Min	.0514	.0381	.0343	.0343	.0343	.0343	.0572
Avg	.3069	.3172	.3198	.5624	.3144	.3658	.3909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 204 / 11KV KARJAGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4001	.3429	.3429	.3429	.2572	.3429
2	.3429	.3601	.3429	.3429	.2743	.2572	.2858
3	.3944	.3772	.4287	.4115	.5144	.3086	.2858
4	.463	.3772	.4801	.4801	.5487	.3429	.3601
5	.5144	.4287	.4801	.4801	.5144	.463	.463
6	.5658	.5144	.5144	.5487	.5487	.6001	.5658
7	.5144	.6344	.5316	.5658	.5144	.6516	.463
8	.463	.5487	.4801	.4801	.5144	.6687	.4115
9	.4115	.4287	.4287	.3944	.4287	.5144	.4287
10	.4287	.463	.463		.3601	.463	.4458
11	.4115	.3772	.3944		.3601	.3772	.4287
12	.3772	.3429	.3601		.3429	.3429	.4115
13	.3601	.3429	.3772		.3086	.3429	.4287
14	.3772	.3772	.4115		.3429	.3086	.4458
15	.3944	.4115	.3601		.2572	.3601	.463
16	.4115	.4287	.3258		.2915	.3772	.4801
17	.4287	.463	.3429		.3086	.3944	.4973
18	.4287	.3601	.4115		.3258	.4115	.5144
19	.4458	.3772	.463		.4801	.4973	.5658
20	.4287	.5316			.5487	.5316	.3944
21	.4115	.4801	.4801		.5144	.4973	.3772
22	.3944	.4287	.4115		.4801	.4458	.3601
23	.4801	.3944	.3944		.4115	.3429	.3944
24	.3086	.3258	.3601	.3601	.3429	.3086	.3429
Max	.5658	.6344	.5316	.5658	.5487	.6687	.5658
Min	.3086	.3258	.3258	.3429	.2572	.2572	.2858
Avg	.4194	.4239	.4167	.4407	.4115	.4194	.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 205 / 11 KV HILLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2858	.1886	.1886	.1715	.1886	.1905
2	.1715	.2858	.2058	.1715	.2401	.1886	.2286
3	.1715	.3048	.2401	.2401		.2058	.2667
4	.2572	.3429	.3086	.2743	.3086	.3086	.2858
5	.4115	.3429	.3772	.3086	.3429	.3086	.3429
6	.463	.4191	.4115	.3772	.3772	.4287	.3772
7	.4115	.4287	.4287	.4287	.4287	.463	.3429
8	.3086	.3772	.3429	.3429	.3429	.4801	.2915
9	.2401	.3086	.2743	.2915	.2743	.4287	.3086
10	.2286	.2229	.2401		.2915	.2058	.2743
11	.2286	.2229	.2401		.2572	.1715	.2572
12	.2096	.2058	.2229		.2229	.1543	.2401
13	.2096	.2058	.2401		.2058	.1543	.2401
14	.2286	.2229	.2743		.1886	.1372	.2858
15	.2667	.2401	.2229		.1886	.1372	.3048
16	.2858	.2743	.2058		.1886	.1543	.3239
17	.2667	.2229	.2401		.1886	.1543	.3258
18	.2477	.1886	.2743		.2058	.3086	.3429
19	.2858	.3086	.2915		.2915	.4115	.3772
20	.3429	.4115			.4115	.463	.3086
21	.4001	.3086	.3086		.3772	.2572	.2915
22	.2858	.2401	.2401		.2229	.1886	.2743
23	.3239	.1886	.2058		.2058	.1715	.2572
24	.1715	.2743	.1886	.1886	.1886	.1715	.1905
Max	.463	.4287	.4287	.4287	.4287	.4801	.3772
Min	.1715	.1886	.1886	.1715	.1715	.1372	.1905
Avg	.2745	.2847	.2684	.2812	.2661	.2601	.2887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 201 / 11 KV SHEGAON MIX AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.5487	.6201	2.4006	2.4577	2.1548	1.8023
2	.7011	.5487	.6135	2.4006	2.4291	2.1548	1.8023
3	.7164	.5487	.6135	2.4006	2.4577	2.1548	1.9662
4	.7011	.5487	.6201	2.4006	2.4577	2.1548	2.13
5	.7888	.5487	.6068	2.5606	2.5606	2.3205	2.2939
6	.7973	.6401	.7087	2.5606	2.672	2.3205	2.5396
7				2.1605	2.7035	2.6216	2.5396
8				2.2405	2.4577	2.4577	2.5396
14	.4572	.6135		.6935	1.0059	.9145	.964
15	.4572	.6135	.823	.6859	1.0059	.9145	.964
16	.4572	.5258	.823	.6935	1.0059	.9145	.9536
17	2.7035	2.0309	2.4806				.7011
18		2.2653	2.4806				
19	2.6216	2.1872	2.5606				
20	2.5396	2.2929	2.4806	.8573	1.0974	1.0059	.7888
21	2.5396	2.2377	2.4006	.8764	1.0974	1.0059	.7973
22	2.4577	2.2929	2.4006	.8573	1.0974	1.0059	.8764
23	2.2119	2.2929	2.3205	.8573	.9145	.9145	.8764
24	2.0309	.5487	2.2929	2.4006	.7716	.9145	.7316
Max	2.7035	2.2929	2.5606	2.5606	2.7035	2.6216	2.5396
Min	.4572	.5258	.6068	.6859	.7716	.9145	.7011
Avg	1.4301	1.2521	1.5529	1.6904	1.762	1.6206	1.4863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 202 / 11 KV S.JAWALAGE MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7907	1.2803	1.2498	.3696	.3467	.3696	.3658
2	.9488	1.2955	1.2498	.3696		.3696	.3658
3	.9374	1.2955	1.2498	.3696	.3467	.3696	.3658
4	.9374	1.2955	1.2346	.3696	.3467	.3696	.4572
5	1.0031	1.2955	1.2346	.3696	.4287	.3696	.4572
6	1.2498	1.2955	1.406	.5544	.4287		.4572
7	1.406	1.9662	1.406				
8	1.5813	1.6385	1.5623			.3696	.4572
9						.3658	.3906
10						.3658	.4744
11						.3658	.463
12				1.1603	1.2269	.9602	.6325
13				1.065	1.2269	.9602	.7811
14	.4572	.3544	.3696	.9945	1.0517	.9602	.7907
15	.4572	.3506	.3696	.9831	1.0517	1.1203	.7907
16	.4572	.3506	.3696	.9831	1.2269	1.1203	.7907
17				1.065	1.4022	1.2803	.9259
18					1.4022	.9602	.7811
19				.6554	1.2269	.9602	.7716
20	.4572	.3506	.7316	.4334	.7392	.3658	.3506
21	.4572	.3467	.7316	.4382	.5544	.3658	.3506
22	.4572	.3506	.462	.4334	.5544	.3658	.3506
23	.4572	.3506	.462	.4334	.5544	.3658	.3506
24	.3506	.3658	.3506	.3696	.3467	.3696	.3658
Max	1.5813	1.9662	1.5623	1.1603	1.4022	1.2803	.9259
Min	.3506	.3467	.3506	.3696	.3467	.3658	.3506
Avg	.7753	.8864	.9025	.6343	.8034	.6123	.5342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 203 / 11 KV KORSEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5813	1.6385	1.5623	.3696	.3429	.3696	.2743
2	1.5813	1.6385	1.5813	.3696	.3467	.3696	.2743
3	1.5813	1.6385	1.5623	.3696	.3429	.3696	.2743
4	1.6604	1.6385	1.5623	.3696	.3467	.3696	.2743
5	1.6404	1.8023	1.6404	.3696	.3467	.3696	.2743
6	1.6604	1.8023	1.6604	.462	.3506	.3696	.2743
7	1.7185	1.9662	1.7185			.2772	
8	1.7185	1.8023	1.6975				
9	.1829	.1829		1.8233	1.8842	1.7204	
10	.1829	.1753		1.9662	1.95	1.8023	
11	.1829	.1753		1.9433	1.8652	1.7204	1.7185
12	.1829	.1753		1.9662	1.7804	1.6385	1.5023
13	.1829	.1753		1.8842	1.6956	1.5565	1.5432
14	.1829	.1772	.1867	1.8023	1.7804	1.5565	1.406
15	.1829	.1772	.1867	1.8023	1.7804	1.5565	1.4232
16	.1829	.1772	.1867	1.7814	1.6956	1.6385	1.3889
17	.1829	.1753	.1848				
18	.1829	.2658	.1867	.2572			
19	.1829	.2658	.2801	.2601			
20	.2743		.3696	.3467	.3696	.2743	.2629
21	.2743		.3696	.3506	.3696	.2743	.2629
22	.2743	.2629	.3696	.3467	.3696	.2743	.2658
23	.2743	.2629	.3696	.3467	.3696	.2743	.2629
24	.2629	.2743	.2629	.3696	.3467	.3696	.2743
Max	1.7185	1.9662	1.7185	1.9662	1.95	1.8023	1.7185
Min	.1829	.1753	.1848	.2572	.3429	.2743	.2629
Avg	.6881	.7659	.8388	.9313	.9649	.8576	.7033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 204 / 11 KV KUMTHA MIX FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0089	.0914	.0088	.1848	.3277	.2772	.2401
2	.0089	.0914	.0088	.1848	.3315	.2772	
3	.0088	.0914	.0088	.1848	.3277	.2772	.2401
4	.0088	.0914	.0088	.1848	.3277	.2772	.2401
5	.0088	.0914	.0088	.1848	.3277	.2772	.2401
6	.0088	.0914	.0088	.1848	.4096	.2772	.2401
7				.1848	.4096	.2772	.2401
8				.1848	.4144	.2772	.2401
12	.3201	.3163	.2772				
13	.3201	.3086	.2772				
14	.3201	.3125	.2772	.0867	.0381	.0914	.0088
15	.3201	.3125	.2772	.0867	.0381	.0914	.0088
16	.3201	.3163	.2772	.0876	.0381	.0914	.0087
17	.3201	.3125	.2772				
18	.3201	.3125	.2772				
19	.3201	.3125	.2772				
20	.0914	.0088	.0953	.0867	.0953	.0914	.0088
21	.0914	.0088	.0953	.0857	.0953	.1463	.0088
22	.0914	.0088	.0953	.0867	.0953	.0914	.0088
23	.0914	.0088	.0953	.0867	.0953	.0914	.0088
24	.0088	.0914	.0088	.0953	.0857	.0953	.0914
Max	.3201	.3163	.2772	.1848	.4144	.2772	.2401
Min	.0088	.0088	.0088	.0857	.0381	.0914	.0087
Avg	.1573	.1673	.1400	.1363	.2161	.1880	.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 205 / 11 KV KALKARJAL MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943		.0943	.0857	.0953	
2	.0943	.0943		.0943	.0867	.0953	
3	.0943	.0943		.0943	.0857	.0953	
4	.0943	.0943		.0943	.0876	.0953	
5	.0943	.0943		.0943	.0857	.0953	
6	.0943	.0943		.0943	.0867	.0953	
9	2.1548	2.0719					
10	2.0719	2.0719					
11	1.989	2.1548					
12	2.0719	2.1548	2.0719				
13	2.1548	2.2377	2.1548				
14	2.1548	2.3205		.0867	.0953		.0088
15	2.1548		2.0719	.0857	.0953		.009
16	1.989		2.0719	.0867	.0953		.1753
17				2.2939	2.2377		.0088
18				2.2939	2.0719		1.9528
19				2.1052	2.0719		1.9528
20	.0943		.1509	2.0805	1.989		1.9766
21	.0943		.1509	2.2119	1.989		1.9766
22	.0943		.1132	2.1862	1.989		1.8747
23	.0943		.1132	2.13	1.9062		1.7966
24	.0943	.0943		.0943	2.13	1.9062	
Max	2.1548	2.3205	2.1548	2.2939	2.2377	1.9062	1.9766
Min	.0943	.0943	.1132	.0857	.0857	.0953	.0088
Avg	.9357	1.0517	1.1123	.9542	1.0111	.354	1.1732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 201 / 11 KV RUDDREWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716	1.1949	.6535	.0373	.0373	.0754
2		.0343		1.0082	.0373	.0373	.0754
3		1.0288	1.286	1.2012	.037	.0377	.0754
4		1.2003	1.3717	1.386	.037	.0373	.0747
5		1.4575	1.8004	1.6632	.037	.037	.0739
6		1.5604	2.2291	2.3777			
7		2.0748	2.4272	2.3663			
8		2.0576	1.8671	2.4587			
9	.5487	2.0576	1.5432	2.0719			
10	.8764	1.8004	1.5432	1.9662			
12					1.4998	2.1948	2.3777
13					2.3777	2.0157	2.3487
14					2.2786	2.1195	2.34
15					2.2382	1.9062	2.4247
16					1.9784	2.2377	2.4863
17					1.8233	2.2119	2.2939
18					1.9662	1.9662	2.0481
19					1.7204	1.6385	1.8023
20	.0366	.0686	.0377	.0366	.0366	.0732	.0366
21	.037	.0754	.0373	.037	.037	.0739	.0366
22	.037	.0686	.0373	.0373	.0373	.0739	.037
23	.0373	.0686	.0373	.0373	.0373	.0373	.037
24		.0377	.0686	.0377	.0377	.037	.0747
Max	.8764	2.0748	2.4272	2.4587	2.3777	2.2377	2.4863
Min	.0366	.0343	.0373	.0366	.0366	.037	.0366
Avg	.2622	.9575	1.1058	1.1559	.9030	.9318	1.0399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 202 / 11 KV BOROTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0754	.0373	.7468	.6348	1.0269
2	.0373	.0343	.0747	.0377	.924	.7468	1.0164
3	.0373	.0343	.0739	.0377	1.1088	.8962	.924
4	.037	.0343	.0739	.0377	1.2136	.961	1.0059
5	.037	.0343	.0732	.0377	1.2012	1.2437	1.0059
6					1.4632	1.5364	1.1393
7					1.56		
8					1.6766	1.5261	1.4746
9					1.6712	1.1469	1.2955
10					1.4746	.9831	1.0526
12	1.4632	1.0288	1.5089				
13	1.4022	1.1145	1.5432				
14	1.1869	1.286	1.8861				
15	1.0059	1.2003	1.8861				
16		1.1145	1.5089				
17	1.3435		1.4146				
18	1.0159	1.3717	1.2826				
19	1.2289	1.4575	1.226	1.1888			
20	.0366	.0686	.0343	.0366	.0366	.0732	.0366
21	.0366	.0686	.0373	.037	.037	.0739	.0366
22	.037	.0686	.0377	.037	.037	.0747	.037
23	.037	.0686	.0343	.0373	.037	.0747	.0373
24	.0377	.0343	.0754	.0377	.0373	.0377	.0747
Max	1.4632	1.4575	1.8861	1.1888	1.6766	1.5364	1.4746
Min	.0366	.0343	.0343	.0366	.0366	.0377	.0366
Avg	.5305	.5326	.7137	.1420	.8817	.7149	.7260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 203 / 11 KV DUDHANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.3696		.0373	.0377
2	.3734	.3734	.462		.0373	.0373
3	.4066	.4066	.5228		.037	.037
4	.4435	.4435	.5729		.0373	.037
5	.5487	.3658	.7468		.0373	.037
6	.5765	.4024	.7577			
7	.6783	.4748	.7291			
8	.6226	.4748	.6783		.1372	
9	.4915	.6554	.5735			
10	.4096	.6554	.5735			
12				.3292	.7682	.5544
13				.4024	.8048	.6401
14				.4207	.78	.6952
15				.7122	.8139	
16				.7122	.7956	.7373
17				.6882	.7956	.7537
18				.7865	.7865	.7773
19				.6554	.6882	.8097
20	.0343	.037		.0366	.0366	.0366
21		.0343		.0366	.0366	.037
22	.0343	.0343		.037	.037	.0373
23	.0377	.0377		.0373	.0373	.0373
24	.0377	.3395	.0366		.0377	.0377
Max	.6783	.6554	.7577	.7865	.8139	.8097
Min	.0343	.0343	.0366	.0366	.0366	.0366
Avg	.3593	.3381	.5475	.4045	.3548	.3141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 205 / Kallappawadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339	.0343	.0377	.5175	.5658	.5601
2	.0343	.0343	.0373	.5601	.5975	.5975
3	.0339	.0343	.0373	.5601	1.1576	.5914
4	.0339	.0343	.0373	.6722	1.3306	.5975
5	.0343	.0343	.037	.6653	1.4784	.7392
6				1.2071	1.4998	1.0974
7				1.0867	1.4582	
8				1.1191	1.2548	1.3435
9				1.094	.9012	1.3763
10				.8192	.9012	.664
12	1.166	1.0974				
13	1.2517	1.0288				
14	1.2003	1.1888				
15		1.226				
16		1.0974				
17	.8059	1.0288				
18	.8059					
19		.7545	.6401			
20		.0747		.0366	.0732	.037
21	.0343	.0754	.0373	.0373	.0739	.0373
22	.0343	.0754	.0373	.0373	.0739	.0373
23	.0343	.0686	.037	.0373	.0739	.0377
24	.0339	.0343	.0377	.0373	.0754	.0754
Max	1.2517	1.226	.6401	1.2071	1.4998	1.3763
Min	.0339	.0343	.037	.0366	.0732	.037
Avg	.3955	.4660	.0976	.5658	.7677	.5565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 207 / Sinnur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.373	.2641	.0373	.0377	.0373
2	.1478	.2263	.3206	.0373	.0377	.0377
3	.1848	.373	.3734	.0373	.0373	.0377
4	.2195	.3391	.4108	.0373	.0373	.0373
5	.2561	.3222	.5601	.037	.0373	.037
6	.2454	.39	.6283			
7	.2713	.4409	.6584			
8		.6443	.695			
9	.6371	.5935	.6104			
10	.5243	.5596	.5079			
11		.5601				
12				.4024	.6283	.6401
13				.7316	.5853	.6767
14				.6661	.5609	
15				.6104	.6135	.7011
16				.6299	.6783	.6783
17				.6554	.7122	.6299
18				.6226	.6882	.5571
19				.5853	.5243	.5243
20	.037	.0343	.0366	.0366	.037	.0366
21	.0373	.0373	.0366	.037	.0373	.0366
22	.0373	.0377	.0373	.0373	.0373	.037
23	.0377	.0373	.037	.0373	.0373	.0373
24	.0377	.0339	.0377	.0373	.0377	.0377
Max	.6371	.6443	.695	.7316	.7122	.7011
Min	.037	.0339	.0366	.0366	.037	.0366
Avg	.2017	.3127	.3476	.2931	.2981	.2812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 201 / ALAGI MIX AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0953	1.8442	1.6804	1.6766	1.2346
2	.0953	.1143	.0953	1.8442	1.6804	1.6766	1.2643
3	.0953	.1143	.0953	2.0348	1.7284	1.6766	1.3546
4	.0953	.1143	.0953	2.0348	1.7604	1.6766	1.3375
5	.0953	.1143	.0953	2.0348	1.7604	1.6956	1.4563
6				1.8442	1.8842	1.8023	1.6613
7				1.8442	1.9662	1.989	1.8435
8				1.8442	1.9662	2.1548	1.906
9				1.95	3.978	1.8233	1.9444
10				1.8442	3.315	2.0119	1.6358
12	1.9662	1.989	1.989				
13	2.0553	2.1795	1.989				
14	1.9334	2.0957	2.1795				
15	1.8023	1.989	2.1795				
16	2.0222	1.989	1.989				
17	2.0885	2.0119	1.989		.4668		
18	2.0553	1.989	1.989				
19	2.0553	1.8233	1.8842		.0953		
20	.1143	.0953	.1143	.1143	.0953	.1143	.1143
21	.1143	.0953	.1143	.1143	.0953	.1143	.1143
22	.1143	.0953	.1143	.1143	.0953	.1143	.1143
23	.1143	.0953	.1143	.1143	.0953	.1143	.1143
24	.0953	.1143	.0953	.0762	.1143	.0953	.1143
Max	2.0885	2.1795	2.1795	2.0348	3.978	2.1548	1.9444
Min	.0953	.0953	.0953	.0762	.0953	.0953	.1143
Avg	.9449	.9519	.9565	1.3102	1.3398	1.2491	1.0807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 202 / GUDDDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0572	.0953	1.1469	1.012	1.1469	.9259
2	.0953	.0572	.0953	1.4089	1.0883	1.1469	.9633
3	.0953	.0572	.0953	1.4089	1.0883	1.1469	.9633
4	.0953	.0572	.0953	1.5089	1.0722	1.1469	1.0936
5	.0953	.0572	.0953	1.5089	1.1363	1.2431	1.1248
6				1.5089	1.278	1.2003	1.2346
7				1.4089	1.3108	1.326	1.2654
8				1.2452	1.3108	1.326	1.2654
9				1.326	1.3592	1.3108	1.2654
10				1.326	1.4089	1.3108	1.1248
12	1.0814	1.1469	1.1469				
13	1.1305	1.326	1.326				
14	1.0978	1.4251	1.4251				
15	1.1469	1.4089	1.4251				
16	1.3435	1.4251	1.5261				
17	1.3435	1.4251	1.5261				
18	1.3108	1.326					
19	1.3108	1.3108	1.4251				
20	.0572	.0953	.0381	.0572	.0953	.0572	.0381
21	.0572	.0953	.0381	.0572	.0953	.0572	.0381
22	.0572	.0953	.0381	.0572	.0953	.0572	.0381
23	.0572	.0953	.0381	.0572	.0953	.0572	.0381
24	.0953	.0572	.0953	.0381	.0572	.0953	.0572
Max	1.3435	1.4251	1.5261	1.5089	1.4089	1.326	1.2654
Min	.0572	.0572	.0381	.0381	.0572	.0572	.0381
Avg	.5870	.6399	.6191	.9376	.8335	.8419	.7624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 203 / GUDDWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3361	.2801	.2614	.2987	.2801	
2	.2801	.3361	.2801	.2987	.2987	.2801	.2987
3	.2801	.3361	.2801	.2987	.2987	.2801	.3734
4	.3734	.3361	.3734	.3361	.2987	.2801	.4108
5	.3734	.4481	.3734	.3361	.4481	.3734	.5601
6		.3734					
7		.2241					
8		.2241					
9	.2801	.1867	.2801	.2801	.2241	.1867	.1867
10	.1867	.1867	.2801	.1867	.2801	.1867	.1867
11	.1867	.1867	.1867	.2241	.1867	.1867	.1867
12	.168	.1867	.1867	.1867	.1867	.1867	.1867
13	.168	.1867	.1867	.1867	.2801	.3361	.1867
14	.168	.1867	.1867	.1867	.1867	.1867	.1867
15		.1867	.1867	.1867	.1867	.1867	.2801
16	.1494	.1867	.1867	.1867		.2241	.2801
17	.1494		.2801	.1867	.1867	.2241	.2801
18			.2801	.1867	.1867	.2241	.2801
19	.3361	.2801	.2801	.4481	.1867	.3174	.2987
20	.4108	.4668	.2801	.4481	.4668	.3734	.2801
21	.3734	.3734	.2801	.3734	.3734	.3361	.2801
22	.3361	.3734	.2801	.3174	.3734	.2987	.1867
23	.3361	.2801	.2801	.2987	.2801	.2987	.1867
24	.2801	.3361	.2801	.2614	.2987	.2801	.2241
Max	.4108	.4668	.3734	.4481	.4668	.3734	.5601
Min	.1494	.1867	.1867	.1867	.1867	.1867	.1867
Avg	.2693	.2826	.2623	.2703	.2763	.2632	.267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 204 / 11KV ANKALGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7604	2.13	2.1548	.0953	.0953	.0953	.1905
2	1.7604	2.1628	2.1795	.0953	.0953	.0953	.1905
3	1.8023	2.1956	2.3472	.0953	.0953	.0953	.1905
4	1.7814	2.2119	2.3739	.0953	.0953	.0953	.1905
5	1.9433	2.2874	2.3739	.0953	.0953	.0953	.1905
6	2.2377	2.4366	2.5149		.0953		
7	2.8826	2.6189	2.5149				
8	2.5101	2.4531	2.652				
9	2.5692	2.3758	2.5396				
10	2.3758	2.3758	2.5692				
12				2.5194	2.5692	2.1072	2.1072
13				2.5819	2.8502	2.3182	2.2291
14				2.649	2.8178	2.3777	2.4387
15				2.6189	2.8178	2.4387	2.4387
16				2.6355	2.8502	2.4691	2.4387
17				2.649	2.8502	2.5926	
18				2.6189	2.8502	2.5926	
19				2.6355	2.7664	2.4387	2.3329
20	.0953	.0953	.0953	.0953	.0953	.1524	.0953
21	.0953	.0953	.0953	.0953	.0953	.1524	.0953
22	.0953	.0953	.0953	.0953	.0934	.1905	.0953
23	.0953	.0953	.0953	.0953		.1905	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.1905
Max	2.8826	2.6189	2.652	2.649	2.8502	2.5926	2.4387
Min	.0953	.0953	.0953	.0953	.0934	.0953	.0953
Avg	1.4733	1.5816	1.6464	1.2145	1.2957	1.1440	.9693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 201 / ANDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747	.056	.2286	.2195	.2715	.2629
2	.056	.0747	.056	.2858	.2743	.362	.298
3	.056	.0739	.056	.2858	.2743	.362	.333
4	.056	.0747	.056	.2858	.2715	.362	.3467
5	.056	.0747		.381	.3582	.543	.4334
6	.056	.0747	.056	.6668	.5201	.724	.7716
7	.056	.056	.056	.9145	.7716	.724	1.0174
8		.056	.0572	.8192	.8478	.724	.9724
9	.0554	.0554	.0572	.6859		.724	.9221
10	.056	.056	.0572	.6859	.8383	.724	.8478
11	.056	.0739	.0762	.056	.0543	.0373	.0373
12	.7973	.7011	.7621	.056	.0543	.0373	.0373
13	.7973	.7973	.7621	.056	.0543	.0373	.0373
14	.8413	.7973	.7621		.0543	.0373	.0373
15	.8764	.8328	.7621	.056	.0543	.0373	.0373
16	.8859	.8328	.8573	.056	.0543	.0373	.0373
17	.8859	.8764	.8573		.0543	.0373	.0373
18	.9465	.7011	.9526	.056	.0543	.0373	.0747
19	.7973	.7087	.7621	.056	.0543	.0373	.0747
20	.0747	.056		.0934	1.5023	.0934	.0747
21	.0739	.056	.0762	.0934	.0543	.0934	.0747
22	.0747	.056	.0762	.0934	.0543	.0934	.0747
23	.0747	.056	.0762	.0934	1.5023	.0934	.0747
24	.056	.0747	.056	.0572	.0747	.056	.0934
Max	.9465	.8764	.9526	.9145	1.5023	.724	1.0174
Min	.0554	.0554	.056	.056	.0543	.0373	.0373
Avg	.3366	.3038	.3339	.2756	.3501	.2619	.292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 202 / SANGMESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.3575	1.4022	.0572	.0747	.0934	.0747
2	1.086	1.3289	1.4175	.0381	.0747	.0934	.056
3	1.267	1.3321	1.4899	.0381	.056	.0934	.056
4	1.267	1.4022	1.4899	.0381	.056	.0905	.0373
5	1.448	1.4022	1.5424	.0381	.056	.0934	.0373
6	1.3717	1.4529	1.5775	.0381	.0373	.0905	.0373
7	1.3717	1.4022	1.5947	.0381	.0373	.0543	.0373
8	1.3717	1.5061	1.7147	.0381	.0373	.0934	.0373
9	1.4022	1.4899	1.5242	.0373	.0373	.0934	.0373
10	1.4022	1.5061	1.5242	.0373	.0362	.0934	.0373
11	.056	.056	.1143	.0373	.0191	.0934	.0373
12	.056	.0747	.0381	1.3765	1.448	1.2955	1.3765
13	.056	.0747	.0381	1.286	1.448	1.2955	1.3889
14	.056	.0747	.0381	1.3375	1.6289	1.3413	1.4784
15	.0747	.0747	.0381	1.3575	1.6289	1.4299	1.5242
16	.0747	.0747	.0381	1.3575	1.6289	1.46	1.5051
17	.0747	.0747	.0381	1.3717	1.7194	1.4299	1.5051
18	.0747		.0381	1.4289	1.7194	1.4148	1.5051
19	.0747	.0747	.0381	1.2689	.0905	1.3546	1.5051
20	.0934	.0747		.0934	.0905	.0934	.0747
21	.0934	.0747	.0381	.0762	.0905	.0934	.0747
22	.0934	.0747	.0762	.0934	.0934	.0934	.0747
23	.0934	.0747	.0572	.0934	.0905	.0934	.0747
24	.0934	.0934	.0747	.0572	.0747	.0934	.0934
Max	1.448	1.5061	1.7147	1.4289	1.7194	1.46	1.5242
Min	.056	.056	.0381	.0373	.0191	.0543	.0373
Avg	.5891	.6587	.6932	.4847	.5114	.5196	.5277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 203 / DEVIKAWATHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.8573	.6859	.543	.6068
2	.0373	.0373	.0373	.8573	.7716	.5601	.6859
3	.0373	.037	.0373	.9526	.763	.543	.7716
4	.0373	.037	.0373	.9526	.8383	.2858	.763
5	.0373	.037	.0373	.9526	.8478	.6335	.8383
6	.0373	.0924	.0373	.9907	.8383	.724	.8478
7	.0373	.0373	.0373	1.0479	.8383	.905	.8551
8	.0373	.0373	.0381	1.0479	.8383	.905	
9	.0373	.0373	.0381	.9945	.8383	.905	.8383
10	.0373	.0373	.0381	.9431	.8383	.905	.8383
11		.0373	.0381	.0373	.0362	.0187	.0187
12	.8764	.7973	.9526	.0187	.0362	.0187	.0187
13	.8764	.7888	.9526	.0187	.0373	.0187	.0187
14	.9114	.8505	.9526	.0187	.0362	.0187	.0187
15	.964	.8859	1.0479	.0187	.0362	.0187	
16	.964	.8764	1.0479	.0187	.0373	.0187	
17	1.0166	.9745	1.0479	.0187	.0373	.0187	
18	1.0277	.964	1.1431	.0187		.0373	
19	.964	.9745	1.105	.0373	.0934	.0187	.0373
20	.0373	.0373		.0373	.0373	.0373	.0373
21	.0373	.0373	.0191	.0373	.0373	.0187	.0373
22	.0373	.0373	.0191	.0187	.0373	.0187	.0187
23	.0373	.0373	.0191	.0747	.0373	.0187	.0187
24	.0373	.0373	.0373	.0191	.0187	.0373	.0187
Max	1.0277	.9745	1.1431	1.0479	.8478	.905	.8551
Min	.0373	.037	.0191	.0187	.0187	.0187	.0187
Avg	.3548	.3235	.3808	.4162	.3746	.3011	.3836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 202 / 11kv KURNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.2096	.1905	.2096	.1905	.2096
2	.2096	.2286	.2286	.2096	.2096	.1905	.2096
3	.2096	.2286	.2286	.2286	.2286	.2096	.2096
4	.3239	.3292	.3429	.3429	.3429	.2477	.2858
5	.381	.3841	.4191	.4572	.4191	.3326	.4191
6	.4954	.5544	.5525	.5335	.6099	.5434	
7	.4382	.4435	.4954	.4191	.5359	.4344	.4954
8	.381	.4024	.4001	.3841	.4024	.3881	.381
9	.3048	.3239	.3429	.3258	.3109	.3239	.362
10	.2477	.2477	.2667	.2126	.2858	.1715	.2667
11	.2096	.2096	.2096		.2096	.1905	.1905
12	.1524	.1524	.1905		.1715	.1715	.1524
13	.1334	.1334	.1524	.1715	.1524	.1524	.1524
14	.1187	.1334	.1402	.1524	.1524	.1334	.1524
15	.1357	.1524	.1402	.1524	.1524	.1524	.1715
16	.1187	.1715	.1524	.1524	.1524	.1334	.1715
17	.1578	.1524	.1524	.1524	.1715	.1905	.2096
18	.1949	.2096	.1715	.2096	.2286	.2477	.218
19	.3429	.3429	.3048	.4001	.3429	.4001	.3658
20	.5175	.5335	.3048	.4954	.4207	.4382	.462
21	.3475	.381	.3048	.362	.3326	.4001	.4001
22	.2477	.2477	.2286	.2667	.2667	.2667	.2477
23	.2286	.2286	.1949	.2286	.2286	.2286	.2477
24	.1905	.2096	.2096	.1905	.2096	.2096	.2096
Max	.5175	.5544	.5525	.5335	.6099	.5434	.4954
Min	.1187	.1334	.1402	.1524	.1524	.1334	.1524
Avg	.2616	.2754	.2643	.2835	.2811	.2645	.2691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 201 / 11 KV AKKALKOT URBAN

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.6461	1.6461
2					1.5546	1.5546
3					1.4632	1.5181
4					1.5181	1.4632
5					1.5546	1.5181
6					1.6095	1.5546
7					1.5181	1.5729
8					1.4266	1.4266
9	1.4266	1.3352	1.39	1.3717	1.4266	1.4998
10	1.4998	1.4815	1.5912	1.4632	1.5912	1.6095
11	1.6095	1.6461	1.6095	1.4998	1.6461	1.7924
12	1.6095	1.6804	1.7193	1.6095	1.6827	1.8107
13	1.5912	1.6804	1.701	1.5364	1.6827	1.7924
14	1.5546	1.643	1.701	1.6278	1.6827	1.7558
15		1.6804	1.7193		1.6827	1.7375
16	1.6278	1.6804	1.7193	1.6827	1.701	1.7558
17	1.5729	1.643				1.7193
24					1.7375	1.6461
Max	1.6278	1.6804	1.7193	1.6827	1.7375	1.8107
Min	1.4266	1.3352	1.39	1.3717	1.4266	1.4266
Avg	1.5615	1.6078	1.6438	1.5416	1.5955	1.6319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8962	.9896
2					.8589	.9335
3					.8402	.8962
4					.8029	.9335
5					.7468	.9335
6					.7842	.9709
7					.8402	.9522
8					.8402	1.1203
9	.9522	.8215	1.0829	.9896	.8402	.9335
10		.8402	1.0642	1.0456	1.1389	.8215
11	.9149	1.0829		1.0829	1.1576	.8779
12	.9335	1.1763		1.0082	1.1576	.8962
13	.9709	1.0269	.9335		1.0082	.8589
14	.9335	.9335	.9522		.8962	.8775
15	.8962	.9335	1.0829		1.1203	.9335
16	1.0082	.8962	1.1389		1.2136	1.0829
17	.8962	.8029				1.1203
24					.9335	1.0269
Max	1.0082	1.1763	1.1389	1.0829	1.2136	1.1203
Min	.8962	.8029	.9335	.9896	.7468	.8215
Avg	.9382	.9460	1.0424	1.0316	.9456	.9533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 203 / 11 KV Swami Vihar FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0305	.0305
2					.0305	.0305
3					.0305	.0305
4					.0305	.0305
5					.0305	.0305
6					.0305	.0305
7					.0305	.0305
8					.0305	.0305
9	.0305	.0305	.0305	.0305	.0305	.0305
10	.0305	.0305	.0305	.0305	.0305	.0305
11	.0305	.0305	.0305	.0305	.061	.0305
12	.0305	.0457	.0305	.0305	.0762	.0457
13	.0305	.0305	.0305		.0457	.0457
14	.0305	.0305	.0305		.0305	.0305
15	.0305	.0305	.0305		.0305	.0305
16	.0305	.0305	.0305	.0457	.0305	.0305
17	.0305					.0305
24					.0305	.0305
Max	.0305	.0457	.0305	.0457	.0762	.0457
Min	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.0305	.0324	.0305	.0335	.0359	.0322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 201 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3734	.3361	.3734	.3361	.3734
2	.3734	.3734	.3361	.3734	.3361	.3361	.4668
3	.5601	.4108	.3734	.3734	.3734	.4108	.4668
4	.6348	.4854	.4481	.4854	.4481	.5975	.5975
5	.6348	.5975	.6283	.5601	.5544	.6535	.7095
6	.7023	.7842	.7762	.7392	.7023	.7468	.7468
7	.5544	.7095	.7023	.6283	.5228	.6348	.6722
8	.3772	.6348	.5975	.5175	.5228	.4294	.5788
9	.4108	.5228	.4668	.4108	.4108	.3361	.4854
10	.4108	.4108	.3361	.3361	.3734	.2987	.3734
11	.3361	.2987	.2987		.3361	.2614	.2987
12	.2987	.2987	.2987		.3361	.2987	.2987
13	.2987	.3361	.2987	.3361	.3174	.2614	.2614
14	.2614	.2987	.3361	.2987	.2801	.2614	.2987
15	.2241	.2987	.2987	.2987	.2987	.2987	.2614
16	.2614	.3361	.2987	.2614	.3174	.3361	.2614
17	.2987	.3361	.3361	.2987	.3734	.3361	.3361
18	.4481	.3361	.4108	.3734	.4108	.4481	.4108
19	.4854	.3734	.5228	.5228	.5975	.5228	.5601
20	.5601	.5975	.5601	.6653	.5601	.5788	.7095
21	.4481	.5601	.5228	.5228	.4854	.5228	.5228
22	.4108	.4481	.4481	.4854	.4294	.4108	.3734
23	.3734	.3734	.3734	.4108	.3734	.3734	.3734
24	.3361	.3361	.3734	.3361	.3734	.3361	.3734
Max	.7023	.7842	.7762	.7392	.7023	.7468	.7468
Min	.2241	.2987	.2987	.2614	.2801	.2614	.2614
Avg	.4197	.4388	.4340	.4350	.4211	.4178	.4504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 202 / 11 KV KINI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.4403	1.3603			
2	1.5364	1.4403	1.4083			
3	1.5043	1.4083	1.4083			
4	1.5043	1.4723	1.4403			
5	1.4723	1.5364	1.5223			
6	1.7604	1.7284	1.7901			
7	1.8884	2.0165	1.8884			
8	1.8564	1.8884	1.8244			
9	1.7604	1.7924	1.6644			
10	1.6004		1.6004			
12					1.7185	1.8747
13					1.8747	1.8747
14					1.7966	1.781
15					1.8747	1.8747
16				1.6804	1.8747	1.8122
17				1.9524	1.9997	1.906
18				1.8564	1.7966	1.906
19				1.6004	1.781	1.7497
Max	1.8884	2.0165	1.8884	1.9524	1.9997	1.906
Min	1.4723	1.4083	1.3603	1.6004	1.7185	1.7497
Avg	1.6452	1.6359	1.5907	1.7724	1.8396	1.8474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 203 / 11 KV KAZIKANBUS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0883	1.1843	1.2193	1.3441
2				1.0883	1.1203	1.2498	1.3441
3				1.1203	1.2003	1.2955	1.3916
4				1.1843	1.2483	1.3717	1.4548
5				1.2803	1.3123	1.4022	1.5023
6				1.3443	1.5364	1.448	1.5813
7				1.6324	1.7924	1.5851	1.7394
8				1.2803	1.5364	1.6766	1.7078
9				1.4403	1.6004	1.6156	1.7394
10				1.2654	1.4403	1.3108	1.4864
11			1.7924				
12	1.7284		1.7284				
13	1.8244	1.7368	1.6324				
14	1.7604	1.704					
15	1.6964	1.9334	1.5684				
16	1.7284	1.8679	1.6964				
17	1.7444	1.9006	1.6644				
18	1.6804	1.7368	1.6644				
19	1.7695	1.6004	1.4723				
Max	1.8244	1.9334	1.7924	1.6324	1.7924	1.6766	1.7394
Min	1.6804	1.6004	1.4723	1.0883	1.1203	1.2193	1.3441
Avg	1.7415	1.7828	1.6524	1.2724	1.3971	1.4175	1.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 201 / 11 KV Hattikanbas Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				1.2003	1.2003	1.4217	1.3441
16		1.0155	1.1873				
23	1.0623						
24	.0848	.0983	.0848	.0819	.0819	.0829	.081
Max	1.0623	1.0155	1.1873	1.2003	1.2003	1.4217	1.3441
Min	.0848	.0983	.0848	.0819	.0819	.0829	.081
Avg	.5736	.5569	.6361	.6411	.6411	.7523	.7126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 202 / 11 KV Basalegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9686	.9686	1.0279				
16				.7811	1.5623	1.4842	1.6484
24	.0655	.0648	.0753	.0602	.0617	.0772	.096
Max	.9686	.9686	1.0279	.7811	1.5623	1.4842	1.6484
Min	.0655	.0648	.0753	.0602	.0617	.0772	.096
Avg	.5171	.5167	.5516	.4207	.812	.7807	.8722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 203 / 11 KV Mirajgi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2427	.2587	.2772	.2772	.2241	.2772	.2587
16	.1848	.1848	.1848		.1663	.2241	.1848
24	.2241	.1867	.2033	.2241	.2241	.2218	.2218
Max	.2427	.2587	.2772	.2772	.2241	.2772	.2587
Min	.1848	.1848	.1848	.2241	.1663	.2218	.1848
Avg	.2172	.2101	.2218	.2507	.2048	.2410	.2218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 201 / 11 KV ANAGAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1753	.1658	.1715	.1715	.1772	.1715
2	.1715	.1772	.1638	.1715	.1715	.181	.1715
3	.1715	.1753	.1638	.1715	.1715	.1753	.1715
4	.1715	.1753	.1658	.1715	.1715	.1753	.1715
5	2.7435	.2481	.1638	.1715	.1715	.1772	.2058
6	3.0483	.2481	.2458	.2743	.2401	.1772	.2743
7	.1715	.2126	.2458	.2743	.2401	.1772	.2401
8	.1715	.1772	.2486	.2401	.2058	.1772	.2058
9	.1372	.1772	.1638	2.3148	2.7435	2.5337	2.2977
10	.1417	.1619	.1715	2.4006	2.6755	2.4006	2.4577
11	.1772	.1619	.1715		2.3282	2.2291	2.4291
12	.1772	.1638	.1715		2.2085	2.0576	2.0719
13	.1753	.1638	.1715		2.3282	2.0576	1.8842
14	.1772	.1638	.1715		2.2786	2.0576	1.8233
15	.1772	.1677	.1715		2.2502	2.1605	1.8842
16	.1772	.1638	.1715		2.2786	2.1262	1.9662
17	2.8086	2.1052	2.7435		.1772	.2058	.1638
18	2.6179	2.6216	2.6749	.1372	.2126	.2401	.1619
19	2.4539	2.2939	2.572	.1715	.2126	.2401	.2105
20	2.0908	2.1052	2.4006	.2401	.1753	.2401	.2458
21	1.9281	1.8842	2.2291	.2058	.1753	.2058	.1966
22	1.8404	1.6385	2.0576	.1715	.1753	.2058	.1638
23	1.8404		1.989	.1715	.1753	.2058	.1638
24	1.7147	1.858	.1543	1.9547	.1715	.1753	.1715
Max	3.0483	2.6216	2.7435	2.4006	2.7435	2.5337	2.4577
Min	.1372	.1619	.1543	.1372	.1715	.1753	.1619
Avg	1.0607	.7574	.8229	.5538	.9212	.8650	.8293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 202 / 11 KV KOMBADWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0631	.6554	.1715	.1715	.1753	.1715
2	1.2003	1.0631	.8192	.1715	.1715	.1772	.1715
3	1.3717	1.4548	.9831	.1715	.1715	.2126	.1715
4	1.4575	1.6651	1.2431	.2401	.2058	.2126	.2058
5	1.6804	2.1033	1.4746	.3086	.2915	.2835	.2401
6	2.2977	2.524	2.1052	.4115	.4115	.443	.3429
7	2.915	1.2094	2.6216	.4115	.463	.4607	.3429
8	2.4863	2.1971	2.2939	.3429	.3429	.3506	.3429
9	.3086	.2658	.2429	.3086	.2915	.2658	.3429
10	.2126	.2458	.1715	.1715	.2149	.2401	.1802
11	.1772	.1619	.1715		.1772	.1715	.1619
12	.1772	.1619	.1715		.1753	.2058	.1658
13	.1772	.1638	.1715		.1753	.1715	.1638
14	.1772	.1619	.1715		.1753	.1715	.1638
15	.1753	.1638	.1715		.1772	.1715	.1619
16		.1638	.1715		.1772	.1715	.1619
17	.1772	.213	.2743		2.4013	2.572	2.343
18	.2303	.2429	.3086	2.7435	2.5591	2.4006	2.2939
19	.3898	.3277	.3086	2.572	2.5941	2.2291	1.9662
20	.4075	.3563		2.2291	2.226	2.0576	1.8842
21	.3189	.2949	.2743	2.0576	1.9136	2.0576	1.7604
22	.2103	.2105	.2401	1.8519	1.8604	2.0576	1.6194
23	.2103	.1638	.2058	1.7147	1.7364	2.0576	1.6057
24	.1715	1.0631	.1638	.1715	1.7147	1.7364	1.7147
Max	2.915	2.524	2.6216	2.7435	2.5941	2.572	2.343
Min	.1715	.1619	.1638	.1715	.1715	.1715	.1619
Avg	.7808	.7350	.6702	.9441	.8666	.8772	.7783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 203 / 11 KV KHANDOBACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1753	.1619	.8573	.6859	.7087	.8573
2	.1715	.1772	.1638	.8573	.6859	.7087	.8573
3	.1715	.1753	.16	1.0288	.8573	1.0631	1.0288
4	.1715	.1734	.1638	1.2003	1.0288	1.2269	1.0288
5	.1715	.1753	.192	1.3032	1.2003	1.2403	1.2003
6	.1715	.1772	.2486	1.7147	1.8004	2.1262	1.7147
7	.1715	.1772	.2429	1.8861	2.2291	2.4806	2.0576
8	.1715	.1715	.2105	1.7147	2.1434	2.3034	2.2291
9	1.8861	1.8604	1.9662	.2058	.1715	.1753	.1715
10	1.949	1.9662	1.8861	.1715	.1791	.1715	.1638
11	1.7718	1.8623	1.7147		.1791	.1715	.1619
12	1.7718	1.7004	1.7147		.1791	.1715	.1619
13	.8859	1.6385	1.7147		.1753	.1715	.1619
14	1.5947	1.6385	1.7147		.1753	.1715	.1619
15	1.7718	1.7004	1.8861		.1772	.1715	.1619
16	1.7718	1.8023	1.989		.1772	.1715	.1619
17	.1753	.1619	.1715		.1772	.2058	
18	.1772	.1638	.2058	.1372	.1772	.2401	.1638
19	.1772	.1943	.2401	.1715	.1753	.2401	.213
20	.1753	.2458	.2401	.1715	.1772	.2401	.2458
21	.1772	.2105	.2058	.1715	.1753	.2058	.1966
22	.1753	.1638	.1715	.1715	.1772	.2058	.1638
23	.1753	.1619	.1715	.1715	.1772	.1715	.1638
24	.1715	.1772	.1638	.1715	.1715	.1772	.1715
Max	1.949	1.9662	1.989	1.8861	2.2291	2.4806	2.2291
Min	.1715	.1619	.16	.1372	.1715	.1715	.1619
Avg	.6741	.7104	.7375	.7121	.5605	.6217	.5913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 204 / 11 KV PASALEWADI MIX AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0876	.081	.0857	.0857	.0886	.0857
2	.0857	.0876	.0819	.0857	.0857	.0876	.0857
3	.0857	.0876	.081	.0857	.0857	.0876	.0857
4	.0857	.0886	.0819	.0857	.0857	.0886	.0857
5	.0857	.0886	.0819	.0857	.0857	.0886	.0857
6	.0857	.1063	.081	.1029	.0857	.0886	.1029
7	.0857	.0886	.081	.0857	.0857	.0876	.0857
8	.0857	.0886	.0829	.0857	.0857	.0886	.0857
9	.0857	.0886	.0819	.0857	.0857	.0886	.0857
10	.0886	.0819	.0686	.0857	.0876	.0857	.081
11	.0876	.08	.0686		.0876	.0686	.0819
12	.0886		.0686		.0876	.0686	.0819
13	.0876		.0686		.0876	.0686	.081
14	.0886		.0686		.0876	.0686	.0819
15	.0876		.0686		.0876	.0686	.081
16	.0886	.081	.0686		.0876	.0686	.0819
17	1.5592	1.3117	1.5432		1.2403	.8573	1.3927
18	1.5592	1.4091	1.5432	1.4403	1.3321	1.0288	1.4737
19	1.5947	1.3765	1.4746	1.5432	1.3672	1.0288	1.1469
20	1.5777	1.3435	1.5089		1.382	1.0288	.9831
21	1.5592	1.3272	1.4403	1.4403	1.4175	.9945	.9175
22	1.5592	1.3763	1.4403	1.4403	1.4175	.9945	.9012
23	1.2757	1.3599	1.5432	1.4403	1.262	.9945	.8684
24	1.3717	.9465	.8848	1.5604	1.4575	1.3643	.9259
Max	1.5947	1.4091	1.5432	1.5604	1.4575	1.3643	1.4737
Min	.0857	.08	.0686	.0857	.0857	.0686	.081
Avg	.5602	.5753	.5247	.6087	.5109	.3993	.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 205 / 11 KV ANAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5316	.4858	.5144	.5144	.5258	.5144
2	.5144	.5316	.4915	.5144	.5144	.5316	.5144
3	.5144	.5316	.4858	.5487	.5144	.5258	.5487
4	.6001	.7888	.5735	.6173	.6001	.6201	.6173
5	.7716	.8764	.7459	.7545	.7716		.7202
6	1.0288	.964	1.0526	1.2003	1.0288	1.2269	.8916
7	1.2003	1.2403	1.1469	1.166	1.2003	1.2403	1.0631
8	1.1145	1.2403	1.1012	1.0288	1.1145	.8859	1.0288
9	.9431	1.0631	.9012	.9431	.7716		.8573
10	.7087	.7373	.8573	.7716	.7011	.7545	.7287
11	.6135	.6554	.7888		.6135	.7202	.6478
12	.6201	.6554	.6859		.6201	.6859	.5668
13	.6135	.6154	.6516		.6268	.6859	.5668
14	.6201	.5735	.6173		.6135	.6859	.5735
15	.6135	.5668	.6173	.6001	.6135	.6859	.5735
16	.5258	.5735	.6859		.6135	.6859	.6478
17	.6201	.6154	.8916	.6859	.7087	.7202	
18	.7888	.6554		.7716	.7087	.7888	.6401
19	.964	.9012	.823	.8573	.8764	.9259	.9116
20	.8859	.9945	.7888	1.2003	1.0631	1.0288	1.0526
21	.7973	.9012		.9431	.8859	.8573	.8097
22	.7011	.7373	.7716	.7716	.7087	.8916	.7287
23	.5201	.6554	.6173	.6859	.6201	.6859	.6554
24	.5144	.5316	.4915	.5144	.5144	.5316	.5144
Max	1.2003	1.2403	1.1469	1.2003	1.2003	1.2403	1.0631
Min	.5144	.5316	.4858	.5144	.5144	.5258	.5144
Avg	.7212	.7557	.7397	.7942	.7299	.7678	.7119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 201 / 11 KV ARDHANARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	1.448	1.2193	1.2955
2	.0171	.0171	.0171	.0171	1.448	1.2193	1.3717
3	.0171	.0171	.0171	.0171	1.5242	1.3717	1.3717
4	.0171	.0171	.0171	.0171	1.6004	1.448	1.3717
5	.0171	.0171	.0171	.0171	1.5242	1.448	1.3717
6	.0171	.0171	.0171	.0171	1.5242	1.5089	1.2193
7					1.5242	1.6004	
8					1.6766	1.448	
9					1.6766	1.5242	1.448
10					1.6766	1.7147	1.5242
12	1.3717	1.5242	1.5242				
13	1.6004	1.6004					
14	1.6766	1.5242	1.6004				
15	1.6766	1.5242	1.6766				
16	1.829	1.6766	1.5242				
17	1.9052	1.6766	1.6766				
18	1.6766	1.6004	1.6766	1.5242			
19	1.5242	1.5242	1.6766	1.5242	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171	.0171		.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	1.9052	1.6766	1.6766	1.5242	1.6766	1.7147	1.5242
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.7078	.6757	.6413	.2683	.9829	.9128	.7912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 202 / 11 KV ARBALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	1.9814	2.0576	1.6461	.0686	.0514	.1372
2	2.2558	2.2558		1.6766	.0686	.0514	.1372
3	2.2862	2.2862	2.2862	1.7528	.0857	.0514	.1372
4	2.3624	2.2862	2.2862	1.9052	.0857	.0514	.1372
5	2.4387	2.4387	2.3472	1.9814	.1029	.0514	.1715
6	2.4691	2.5606	2.3777	2.1033	.1029	.1543	.1372
7	2.713	2.774	2.4387	2.2405			
8	2.774	2.774	2.5911	2.3167			
9	2.774	2.5911	2.4844	2.0576			
10	2.713	2.5453	2.2862				
12					2.8121	2.8807	2.7435
14					2.8121	2.5377	2.652
15					2.8121	2.6749	2.6368
16					2.7435	2.7435	2.6673
17					2.4691	2.6063	2.5758
18					2.3624	2.652	2.6063
19	.1543	.1715	.1372	.1029	2.2405	2.5758	2.4844
20	.1715	.1029	.1543	.1372	.1372	.1543	.1029
21	.1715	.1029	.1543	.1029	.0514	.0514	.1029
22	.1715	.1029	.1543	.0857	.0514	.1372	.1029
23		.0857	.1372		.1372	.1372	.0857
24	.1029	.1715	.0857	.1372	.0857	.1372	.0514
Max	2.774	2.774	2.5911	2.3167	2.8121	2.8807	2.7435
Min	.1029	.0857	.0857	.0857	.0514	.0514	.0514
Avg	1.7179	1.5769	1.4652	1.3033	1.0683	1.0944	1.0927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 203 / 11 KV BEGAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.1029	.1372	1.5242	1.5242	1.2193
2	.1886	.1372	.1372	.1029	1.6004	1.6004	1.3717
3	.2058	.1372	.1029	.1029	1.6766	1.7528	1.4022
4	.2058	.1543	.1715	.1715	1.6766	1.7528	1.4632
5	.2229	.1543	.2058	.2058	1.829	1.9814	1.5546
6	.2401	.2058	.2229	.2229	1.9052	2.2253	1.8595
7					2.1338	2.3167	
8					2.3929	2.1795	
9					2.271	2.1186	2.2558
10					2.0729	2.4348	2.1338
12	2.2253	1.9966	1.829				
13	2.2558	2.1033					
14	2.2253	1.9052	2.0424				
15	2.1795	2.0424	2.1338				
16	2.1948	2.1795	2.2558				
17	1.7071	2.1491	2.271				
18	1.9662	2.1491	2.3472	2.1491			
19	1.8138	1.9966	2.1338	2.0424	.1543	.1715	.2058
20	.1715	.1715	.1715	.1886	.1715	.1886	.2058
21	.1715	.1715	.1715	.1543	.1715	.1886	.1715
22	.1372	.1715	.1715	.1543	.1543	.1886	.1543
23	.1372	.1543	.1543		.1372	.1372	.1372
24	.1543	.1372	.1029	.1372	.1372	.1372	.1372
Max	2.2558	2.1795	2.3472	2.1491	2.3929	2.4348	2.2558
Min	.1372	.1372	.1029	.1029	.1372	.1372	.1372
Avg	.9776	.9616	.9293	.4808	1.2505	1.3061	1.0194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 204 / 11 KV BEGAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.4458	.3772	.4115	.4115	.4458
2	.4458	.4458	.4287	.3429	.4115	.4115	.4115
3	.4801	.4801	.4458	.3429	.4801	.4801	.4458
4	.5144	.5144	.5316	.4287	.5316		.5144
5	.5144	.5144	.6001	.4801	.6001	.5316	.583
6	.5658	.583	.6344	.583	.6687	.6859	.6173
10	.4801	.5144	.5144	.5144	.5658	.5144	.6344
11		.5144	.4801	.4458	.4801	.4801	.5658
12	.5144	.5144	.5144	.4458	.5144	.4115	.4458
13		.4801	.4801		.4287	.3772	.5316
14	.4801	.4115	.4801		.4115	.3429	.4973
15	.4458	.4115	.4801		.4115	.3429	.4287
16	.4115	.4115	.3772		.3772	.3429	.3601
17	.4115	.4287	.3772		.4801		.4287
18	.4287	.463	.4973	.5487	.5316	.4458	.4973
19	.5658		.583	.6687	.6173	.6687	.703
20	.6001	.7716	.7545	.7716	.6687	.7202	.7373
21	.6344	.6859	.7202	.6687	.6344	.6173	.6516
22	.5487	.583	.583	.6001	.5658	.5144	.6173
23	.4973	.5316	.4973		.4287	.4458	.5487
24	.4287	.4287	.4287	.3944	.4287	.4287	.4458
Max	.6344	.7716	.7545	.7716	.6687	.7202	.7373
Min	.4115	.4115	.3772	.3429	.3772	.3429	.3601
Avg	.4936	.5050	.5169	.5075	.5070	.4828	.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 205 / 11KV YENKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0669	1.4632	1.448	.1543	.1372	.12
2	1.2193	1.2955	1.4937	1.4937	.1372	.1372	.12
3	1.5242	1.3717	1.6766	1.6766	.12	.1372	.1372
4	1.6004	1.5242	1.7528	1.7528	.12	.1372	.1372
5	1.6766	1.5242	1.829	1.7833	.1372	.1543	.1543
6	1.7223	1.7071	1.8595	1.7985	.1372	.1886	.1543
7	1.9204	2.0424	1.9966	1.9966			
8	2.0271	2.1338	2.0576	1.9814			
9	2.0271	2.0119	1.8442	1.6613			
10	1.9509	1.9204	1.7985				
12					2.1948	2.1948	1.8747
14					2.0576	2.0576	2.0576
15					2.0576	2.1948	2.1033
16					2.2634	2.0576	2.1033
17					2.0881	2.2253	2.1338
18					2.1033	2.1186	2.1491
19	.12	.1543	.1372	.12	1.9509	1.9662	1.9814
20	.1715	.2229	.1715	.2058	.1715	.1715	.1715
21	.1715	.2229	.1715	.1715	.1543	.1543	.1715
22	.1543	.2229	.1715	.2058	.1543	.1543	.1715
23	.1543	.2058	.1715		.1372	.1372	.1543
24		.1543	.1543	.1715	.1543	.1372	.12
Max	2.0271	2.1338	2.0576	1.9966	2.2634	2.2253	2.1491
Min	.12	.1543	.1372	.12	.12	.1372	.12
Avg	1.1773	1.1113	1.1718	1.1762	.9052	.9145	.8897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 206 / 11 KV KOTHALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1029	.0857	.1029	1.2955	1.2955	1.5242
2	.0686	.1029	.0686	.1029	1.3717	1.3717	1.5242
3	.0686	.1029	.0686	.1029	1.3717	1.448	1.5242
4	.0914	.1029	.0857	.1029	1.448	1.7147	1.5546
5	.1067	.1029	.0857	.1029	1.5242	1.6004	1.5851
6	.12	.1029	.0857	.1372	1.5546	1.6766	1.6766
7					1.6004	1.7985	
8					1.6918	1.6461	
9					1.7223	1.7071	1.7223
10					1.6918	2.0576	1.1279
12	1.5699	1.7223	1.5546				
13	1.6461	1.829					
14	1.6766	1.5851	1.6309				
15	1.6766	1.7985	1.6613				
16	1.6461	1.7985	1.768				
17	1.6156	1.768	1.7985				
18	1.5242	1.6766	1.7071	1.448			
19	1.4937	1.6766	1.5546	1.6004	.0686	.1029	.1372
20	.0343	.1372	.1029	.12	.1029	.1029	.1715
21	.0343	.1372	.1372	.1029	.0686	.1029	.1543
22	.1372	.1372	.1372	.1029	.0686	.1029	.1543
23	.1372	.1372	.1029		.1029	.1029	.1372
24	.1372	.1372	.1029	.1029	.0857	.1029	.0857
Max	1.6766	1.829	1.7985	1.6004	1.7223	2.0576	1.7223
Min	.0343	.1029	.0686	.1029	.0686	.1029	.0857
Avg	.7291	.7978	.7077	.3441	.9856	1.0584	.9342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 201 / 11 KV SHINGOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.1905	.5716	.3658	1.2193	4.0009	3.3913
2	.4572	.1905	.5716	.3963	1.2193	4.0009	3.6199
3	.4572	.1905	.5716	.3963	1.2955	3.8104	3.8104
4	.4572	.1905	.5716	.3963	1.4289	3.8104	3.8104
5	.4572	.1905	.5335	.4268	1.5242	4.0009	3.8104
6	.4572	.2858	.5716	.4268	1.6766	3.8104	3.6199
7	.4572	.1905					
8		2.572	2.6673	2.1338			
9	2.1338	2.6673		2.4387			
10	2.21		2.9531	2.3167			
11	2.21	2.8959					
12	2.21	2.8578	3.0483				
13	2.2862	2.6673	3.0483				
14	2.1338	2.8387	2.8197				
15	2.2862	2.8006	2.7625		3.4294		
16	3.3532	4.1914	3.9628		2.6673	3.2007	2.9531
17	2.8959	4.382	4.1914		3.0483	3.2388	3.0483
18	3.0483		4.1914		3.0483	3.1436	
19	3.3532	3.9057	3.6199	.4572	3.2388	3.1436	3.2769
20	3.0483	4.0009	3.8104	.6097	3.0483	2.9531	3.2388
21	2.8959	4.0962	4.0009	.5335	2.8578	2.7625	3.0483
22	2.8959	3.8104	3.4294	.4877	2.6673	2.6292	3.0102
23	2.8959	3.8104	3.315	.9755	3.8104	3.3913	4.1914
24	.4572	.2858	.5716	.3658	1.2193	4.0009	3.3913
Max	3.3532	4.382	4.1914	2.4387	3.8104	4.0009	4.1914
Min	.4572	.1905	.5335	.3658	1.2193	2.6292	2.9531
Avg	1.8919	2.2369	2.4659	.8485	2.3374	3.4598	3.4443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 202 / 11 KV ICHAGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	2.0957	2.2862	2.0729	.1524	.1715	.1715
2	1.829	1.9052	2.2862	2.4387	.1524	.1715	.1715
3	2.1338	1.7147	2.572	2.5911	.1524	.1715	.1715
4	2.4387	2.0957	2.9531	2.7435	.1524	.1905	.1715
5	3.4294	1.9052	3.3341	2.9721	.1524	.1905	.1715
6	3.8104	3.6199	3.8104	3.2769	.1905	.1905	.1905
7	3.6199		3.4294	2.713			3.0864
8					3.0483	3.7532	3.0483
9					3.4294	3.677	3.3913
10					3.5246		3.5056
11					3.8676		3.4294
12					3.8676	3.2388	3.8104
13					3.9057	3.3341	3.2388
14					3.4865	2.8959	3.2388
19		.2477			.1905	.2096	.2286
20	.2858	.2667	.2096		.2286	.2286	.2667
21	.1905	.1905	.1905		.2096	.2286	.2096
22	.1334	.1905	.1905		.362	.2477	.1905
23	.1524	.1905	.1905		.1905	.1715	.1715
24	1.6766	2.6673	1.6766	1.9509	.1905	.1905	.1715
Max	3.8104	3.6199	3.8104	3.2769	3.9057	3.7532	3.8104
Min	.1334	.1905	.1905	1.9509	.1524	.1715	.1715
Avg	1.7941	1.4241	1.9274	2.5949	1.4449	1.1330	1.4518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 203 / 11 KV WATWATE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.0572	.5716	.5792	.0572	.0762	.0572
2	.6097	.0572	.5716	.6097	.0572	.0762	.0572
3	.6097	.0572	.5716	.6097	.0572	.0762	.0572
4	.6668	.0572	.5716	.6097	.0572	.0762	.0572
5	.724	.0572	.6668	.6249	.0572	.0762	.0572
6	.7621	.0572	.5716	.6706	.0572	.0762	.0572
7	.9907	.0572	.6668	.6859			
8	1.1431		.9145				
9		.6668		.6859			
10		.8573		.6859			
12					.8573	.8573	.9526
13					.7621	.8573	1.0479
14					.7621	.7811	.8573
15					.724	.7811	.8573
16					.7621	.8192	.9145
17					.8383	.7621	1.0479
18					.7621	.7621	.9526
19		.0572		.0457	.7811	.7621	
20	.0572	.0572	.0762	.0457	.0762	.0572	.0572
21	.0572	.0572	.0762	.0457	.0762	.0762	.0572
22	.0572	.0572	.0762	.0457	.0762	.0572	.0572
23	.0572	.0572	.0762	.0457	.0762	.0572	.0572
24	.0572	.0572	.0572	.061		.0762	.0572
Max	1.1431	.8573	.9145	.6859	.8573	.8573	1.0479
Min	.0572	.0572	.0572	.0457	.0572	.0572	.0572
Avg	.4924	.1512	.4206	.4034	.3832	.3770	.4033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 204 / 11 KV WIRWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0762	3.2388	3.2388	3.3913
2	.0953	.0953	.0953	.0762	3.2388	3.2388	3.4294
3	.0953	.0953	.0953	.0762	3.3341	3.4294	3.4294
4	.0953	.0953	.0953	.0762	3.4294	3.4294	4.0009
5	.0953	.0953	.0953	.0762	3.6199	3.6199	4.382
6	.0953	.0953	.0953	.0762	3.8104	3.6199	
7					4.2867	4.5725	
8					4.4772	1.829	3.6199
9					4.1914	1.9052	
10					4.0009	2.6673	4.0009
12	4.5725	4.5725	4.4772				
13	4.382	4.5725	3.0483				
14	3.8104	3.4294	3.3532				
15	4.5725	.9526	1.2384				
16	4.1914						
17	3.6199	.9526	3.4294				
18	3.8104	.9526					
19	3.6199	4.1914	3.0483	.0762	.0953	.0953	.0953
20	.0953	.0953	.1905	.0762	.0953	.0953	.0953
21	.0953	.0953	.1715	.0762	.0953	.0953	.0953
22	.0953	.0953	.1715	.0762	.0953	.0953	.0953
23	.0953	.0953	.0953	.0762	.0953	.0953	.0953
24	.0953	.0953	.0953	.0762	.0953	.0953	.1524
Max	4.5725	4.5725	4.4772	.0762	4.4772	4.5725	4.382
Min	.0953	.0953	.0953	.0762	.0953	.0953	.0953
Avg	1.7699	1.1484	1.1700	.0762	2.3875	2.0076	2.0679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 205 / 11 KV KAMATI BK. GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.381	.6668	.7621	.6668	.6097	.6097
2	.5716	.381	.6668	.7621	.6668	.6097	.6097
3	.5716	.4763	.6668	.7621	.6668	.5716	.6097
4	.6668	.4763	.724	.7621	.724	.5716	.724
5	.9145	.5716	.8573	.8573	.8002	.8383	.8383
6		.7621	.9526	1.0288	.7621	.9145	.8764
7	.6668	.7621	.9526	.9907	.7621	1.0288	.9526
8	.6668	.7621	.7621	.9145	.6668	.8573	.7621
9	.5716	.7621	.6668	.8002	.6668	.7621	
10	.6097		.5716	.8002	.6097	.7811	.6668
11	.6668	.7621		.7621	.8002	.8002	.6668
12	.5716	.6097	.7621	.743	.7621	.743	.5716
13	.5716	.6668	.6859	.6859	.6859	.3239	.5716
14	.5716	.6478	.6859	.6668	.6859	.724	.7049
15	.6097	.724	.6478	.6287	.6859	.724	.6668
16	.6478		.7049	.6668	.7621	.6668	.6859
17	.7049	.7621	.8002	.6668	.8192		.6859
18	.5716	.7621	.7621	.724	.7621	.7621	.724
19	.5716	.8573	.9526	1.0479	.9907	.7621	1.0479
20	.4763	1.0479	.9907	1.0479	1.0669	.9907	1.1431
21	.4763	.9526	.8383	.9526	.9526	.9526	1.0479
22	.4763	.8573	.8383	.8764	.8002	.9526	.9526
23	.5716	.7621	.7621	.7621	.6859	.8383	.8383
24	.6097	.5716	.6668	.724	.6668	.6097	.8383
Max	.9145	1.0479	.9907	1.0479	1.0669	1.0288	1.1431
Min	.4763	.381	.5716	.6287	.6097	.3239	.5716
Avg	.6064	.6963	.7646	.8081	.7549	.7563	.7737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 206 / 11 KV HARALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5242	1.7147	2.0957	.381	.2667	.2858
2	1.8099	1.7147	1.7147	2.2862	.381	.2477	.2667
3	1.8099		1.9052	2.2862	.381	.2477	.2667
4	1.9052	2.0957	2.191	2.2862	.381	.2477	.2858
5	2.3815	2.2862	2.2862	2.3053	.381	.2477	.2858
6	2.6673	2.4768	2.572	2.3434	.381	.2477	.3429
7	2.8578	2.6673	2.8578	2.3815	.381		
8	3.1436	2.8578	3.0483	2.4768			
9	2.9531	2.6673	2.8578	2.572			
10	2.572		1.8671	2.553			
11					2.8769		
12					2.8769	2.8197	3.0483
13					2.6673	2.0005	3.2388
14					2.8769	3.1436	3.0864
15					2.8006	3.0102	3.0483
16					2.8387	3.0864	3.0864
17					2.8769	2.572	3.0483
18					2.8578	2.572	2.9531
19	.1905	.2477		.3429	2.3243	2.5149	2.6673
20	.2858	.381		.381	.2667	.2858	.381
21	.1905		.3239	.381	.3048	.3048	.3429
22	.2858	.3239	.3429	.4001	.3239	.362	.0572
23	.381	.3429	.3239	.381	.3048	.3429	.3239
24	.3429	.381	.3429	.3239	.381	.2667	.3239
Max	3.1436	2.8578	3.0483	2.572	2.8769	3.1436	3.2388
Min	.1905	.2477	.3239	.3239	.2667	.2477	.0572
Avg	1.5932	1.5359	1.7392	1.6123	1.3926	1.3046	1.4389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 207 / 11 KV DADPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1143	.1715	2.0957	2.3243	2.0957
2	.1524	.1715	.1143	.1715	2.0957	2.4768	2.191
3	.1524	.1715	.1143	.1715	2.0957	2.4768	2.191
4	.1524	.1524	.1143	.1905	2.2862	2.572	2.21
5	.1905	.1715	.1143	.1905	2.572	2.6863	2.2291
6	.2477	.1905	.1524	.1905	2.8197	2.6673	2.3243
7					2.8197	2.8959	2.8578
8					3.0483	2.9531	2.6673
9					2.9531	2.9531	2.6292
10					2.8769	2.7625	2.0957
12	2.6673	3.0483	2.7435				
13	2.6673	2.9912	2.4006				
14	2.5149	2.6292	2.6673				
15	2.5339	2.6863	2.6673				
16	2.7625						
17	3.0483	2.7625	2.8197				
18	2.6673	2.6673	2.934				.2667
19	2.6673	1.9052	2.7054	.3429	.1524	.1905	.2667
20	.1905	.1905	.1524	.381	.1524	.2096	.3048
21	.1905	.1524	.1715	.381	.1715	.2096	.2286
22	.1905	.1334	.1905	.4001	.1524	.2667	.1905
23	.1905	.1334	.0572	.381	.1524	.1715	.1715
24	.1524	.1905	.1334	.1715	.1334	.1524	.1715
Max	3.0483	3.0483	2.934	.4001	3.0483	2.9531	2.8578
Min	.1524	.1334	.0572	.1715	.1334	.1524	.1715
Avg	1.2364	1.1400	1.1315	.2620	1.6611	1.7480	1.4760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 201 / 11 KV LAMBOTI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
7	.5716	
23		.5335
Max	.5716	.5335
Min	.5716	.5335
Avg	.5716	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 202 / 11 KV SHIRAPUR

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
7	2.1795	
23		.5175
Max	2.1795	.5175
Min	2.1795	.5175
Avg	2.1795	.5175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 203 / 11 KV SAWALESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
7	3.5791	
23		.5544
Max	3.5791	.5544
Min	3.5791	.5544
Avg	3.5791	.5544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 205 / 11 KV ARJUNSOND FEEDER

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
7	.5914	
23		.4527
Max	.5914	.4527
Min	.5914	.4527
Avg	.5914	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 207 / 11KV TOLL PLAZA

Feeder KV- 11 / OUTGOING

DATE	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
7	.0205	
23		.0622
Max	.0205	.0622
Min	.0205	.0622
Avg	.0205	.0622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 201 / 11 KV KONHARI PAPRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5144	3.3436	2.915	3.4294
2	.5144	.5144	.5144	.5144	3.3436	3.0864	3.4294
3	.5144	.5144	.5144	.5144	3.4294	3.0864	3.4294
4	.5144	.5144	.4287	.5144	3.4294	3.0864	3.4294
5	.5144	.5144	.4287	.5144	3.4294	3.2579	.3429
6					3.4294	3.6008	3.4294
7					3.4294	3.6008	3.4294
8					3.4294	3.7723	
9					3.2579	3.7723	3.4294
10					3.4294	3.4294	3.4294
11	3.4294	3.4294	3.6866	3.4294			
12	3.4294	3.3436		3.6008			
13	3.4294		3.6008	3.6866			
14	3.4294	3.2579	3.6008	3.6008			
15	3.4294	3.3436	3.6008				
16	3.4294	3.3436	3.6866				
17	3.4294	3.2579	3.6866	3.6866			
18	3.4294	3.7723	3.6866	3.6008			
19	3.4294	3.9438	3.6008		2.8292	3.4294	3.4294
20	3.4294	3.0864	3.6008		3.2579	3.4294	3.4294
21	3.4294	3.0864	3.4294	.5144	3.2579	3.4294	3.4294
22	3.4294	3.0864	3.4294	.5144	3.0864	3.4294	3.4294
23	3.4294	2.8292	3.3436	.5144	3.0864	3.4294	3.4294
24	3.4294	3.4294	2.6578	3.6008	.5144	2.915	3.4294
Max	3.4294	3.9438	3.6866	3.6866	3.4294	3.7723	3.4294
Min	.5144	.5144	.4287	.5144	.5144	2.915	.3429
Avg	2.6623	2.5434	2.6673	1.9547	3.1239	3.3544	3.2236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 202 / 11 KV PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4294	2.7435	2.4006	3.6008	.3429	.3429	.5144
2	3.6008	3.2579	2.7435	3.6008	.3429	.3429	.5144
3	3.7723	3.4294	2.7435	3.6008	.3429	.3429	.5144
4	3.7723	3.4294	2.915	3.6008	.3429		.5144
5	3.7723	3.5151	3.0864	3.7723	.5144	.3429	
6	3.7723	3.7723	3.0864	3.7723			
7	3.7723	3.9438	3.2579	3.7723			
8	3.858	3.7723	3.6008	3.7723			
9	3.858	3.858	3.7723	3.7723			
10	3.858	3.2579	3.0864	3.6008			
13					3.6008	2.2291	3.6008
14					3.4294	2.572	3.6008
15					3.4294	2.572	3.6008
16					3.4294	2.572	3.6008
17					3.4294	2.572	3.5151
18					3.4294	2.4006	3.5151
19					3.2579	2.0576	3.4294
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.4287	.5144	.5144	.4287	.5144	.5144
23	.5144	.4287	.5144	.5144	.3429	.5144	.5144
24	.5144	.5144	.3429	.5144	.3429	.3429	.5144
Max	3.858	3.9438	3.7723	3.7723	3.6008	2.572	3.6008
Min	.5144	.4287	.3429	.5144	.3429	.3429	.5144
Avg	2.6692	2.4920	2.2062	2.6292	1.6491	1.2967	1.8433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 203 / 11 KV PENUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6008	3.4294	2.915	3.6008	.5144	.4287	.5144
2	3.6008	3.4294	3.0007	3.6008	.4287	.4287	.5144
3	3.6008	3.4294	3.0864	3.6866	.4287	.4287	.5144
4	3.4294	3.4294	3.0864	3.6866	.5144	.4287	.5144
5	3.4294	3.5151	3.2579	3.6866	.6859	.4287	.5144
6	3.6008	3.858	3.4294	3.6008			
7	3.6866	3.7723	3.7723	.4458			
8	3.738	3.9438	3.7723	.4458			
9	3.6866	3.6866	3.5151	.463			
10	3.6866	3.6008	3.6008	.4801			
11					3.9438	3.9438	3.4294
13					3.5151	3.9438	3.4294
14					3.5151	4.0295	3.4294
15					3.6008	4.0295	3.4294
16					3.4294	2.4006	3.4294
17					3.4294	3.9438	3.4294
18					3.4294	3.7723	3.4294
20	.5144	.5144	.6859	.6859	.5144	.5144	.5144
21	.5144	.5144	.6859	.5144	.5144	.5144	.5144
22	.5144	.5144	.6859	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5144	.5144	.4287	.4287	.5144
Max	3.738	3.9438	3.7723	3.6866	3.9438	4.0295	3.4294
Min	.5144	.5144	.5144	.4458	.4287	.4287	.5144
Avg	2.5755	2.5777	2.4349	1.7627	1.7601	1.8055	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 204 / 11 KV KHAWANI SAROLE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.0857	.0857
2	.0857	.0857	.0857	.0857	.0857	.0857	.0857
3	.0857	.0857	.0857	.0857	.0857	.0857	.0857
4	.0857	.0857	.0857	.0857	.0857	.0857	.0857
5	.0857	.0857	.0857	.0857	.0857	.0857	.0857
6	.0857	.0857	.0857	.0857	.0857	.0857	.0857
7	.0857	.0857	.0857	.0857	.0857	.0857	.0857
8	.0857	.0857	.0857	.0857	.0857	.0857	
9	.0857	.0857	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	.0857	.0857	.0857
11	.0857	.0857	.0857	.0857		.0857	.0857
12	.0857	.0857	.0857	.0857	.0857		.0857
13	.0857	.0857	.0857	.0857	.0857		.0857
14	.0857	.0857	.0857	.0857	.0857		.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857	.0857	.0857	.0857	.0857
18	.0857	.0857	.0857	.0857	.0857	.0857	.0857
19	.0857	.0857	.0857	.0857	.0857	.0857	.0857
20	.0857	.0857	.0857	.0857	.0857	.0857	.0857
21	.0857	.0857	.0857	.0857	.0857	.0857	.0857
22	.0857	.0857	.0857	.0857	.0857	.0857	.0857
23	.0857	.0857	.0857	.0857	.0857	.0857	.0857
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	.0857	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 205 / 11 KV YEWATI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.3429	.5144	3.4294	2.915	3.4294
2	.5144	.0514	.2572	.5144	3.4294	3.0007	3.4294
3	.5144	.5144	.2572	.5144	3.4294	3.0864	3.4294
4	.5144	.5144	.2572	.5144	3.4294	3.0864	3.4294
5	.5144	.5144	.2572	.6859	3.6008	3.0864	3.4294
6					3.6008	3.2579	3.4294
7					3.7723	3.2579	3.4294
8					3.7723	3.4294	
9					3.6008	3.4294	3.4294
10					3.5151	3.2579	3.4294
12	3.4294	3.6008					
13	3.4294	3.5151	3.6008	3.5151			
14	3.4294	3.4294	3.6008	3.6008			
15	3.4294	3.4294	3.7723				
16	3.4294	3.4294	3.738				
17	3.4294	3.5151	3.6008	3.7723			
18	3.4294	3.6008	3.6008	3.6008			
19	3.4294	3.0864	3.6008	3.6008			
20	3.4294	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.3429	.5144	.5144	.5144	.3429
22	.5144	.5144	.3429	.5144	.4287	.5144	.3429
23	.5144	.3429	.3429	.5144	.2572	.5144	.3429
24	.5144	.5144	.3429	.5144	.2572	.2572	.5144
Max	3.4294	3.6008	3.7723	3.7723	3.7723	3.4294	3.4294
Min	.5144	.0514	.2572	.5144	.2572	.2572	.3429
Avg	1.9719	1.7842	1.6925	1.5604	2.5034	2.2748	2.3516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 206 / 11 KV PENUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.5144	.5144	.5144	.5144	.6859
2	.6859	.6859	.5144	.5144	.5144	.4287	.6859
3	.6859	.6859	.4287	.5144	.5144	.4287	.6859
4	.6859	.6859	.4287	.6001	.5144	.4287	.6859
5	.6859	.6859	.4287	.5144	.6859	.4287	.6859
10	.6859	.6859	.6859	.6859	.6687	.6859	.6859
11	.6859	.7202	.7716	.7202	.6859	.6859	.6859
12	.6859	.6859	.6859	.6859		.6859	.6859
13	.6859	.6859	.6859	.4287	.7716	.6859	.6859
14	.6859	.6859	.6001	.5144	.7716	.6859	.6859
15	.6859		.5144	.5144	.7716	.6859	.6859
16	.6859	.6859	.6859	.5144	.7716	.6859	.6859
17	.6859	.7716	.7202	.5144	.6859	.6859	.6859
18	.6859	.7716	.6859	.6859	.7716	.6859	.6859
19	.6859	.7716	.7716	.6859	.7716	.6859	.6859
20	.6859	.8573	.7716	.6859	.8573	.6859	.6859
21	.6859	.8573	.6859	.6859	.8573	.6859	.6859
22	.6859	.7716	.5144	.6859		.6859	.6859
23	.6859	.6859	.463	.5144	.6859	.6859	.5144
24	.6859	.6859	.6001	.5144	.4287	.6001	.6859
Max	.6859	.8573	.7716	.7202	.8573	.6859	.6859
Min	.6859	.6859	.4287	.4287	.4287	.4287	.5144
Avg	.6859	.7238	.6079	.5847	.6802	.6216	.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 201 / 11 KV ASHTI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
11	1.4937
12	1.6461
13	1.6461
14	1.4632
15	1.448
20	.1715
21	.1372
Max	1.6461
Min	.1372
Avg	1.1437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 204 / 11 KV BAIRAGWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
16	2.5911
17	2.6978
18	2.9416
19	2.7282
20	2.6673
21	2.3929
Max	2.9416
Min	2.3929
Avg	2.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 209 / 11 KV TELANGWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18
HR	Load (MW)
10	2.5606
20	.2229
21	.2058
Max	2.5606
Min	.2058
Avg	.9964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV DIKSAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	1.2717
2	1.3565
3	1.3565
4	1.8004
5	2.2539
6	2.6006
8	2.4539
9	2.4272
10	2.2539
17	.503
18	.7545
19	1.1603
20	1.2574
21	1.1736
22	1.0059
23	.8383
24	.5801
Max	2.6006
Min	.503
Avg	1.4734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV NARKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	2.8349
2	3.5818
3	3.6713
4	3.94
5	4.4772
6	4.4772
8	4.2981
9	3.8504
10	3.6713
17	.663
18	1.1736
19	1.3565
20	1.6108
21	1.3413
22	1.1736
23	1.0059
24	.9221
Max	4.4772
Min	.663
Avg	2.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV EKURKE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	.1658
2	.1658
3	.1658
4	.1658
5	.1658
12	2.6578
13	2.8349
14	2.8349
15	2.8349
16	2.6578
17	2.6578
18	2.6578
19	2.6578
20	.4973
21	.3315
22	.2486
23	.2486
24	.1658
Max	2.8349
Min	.1658
Avg	1.3397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV WALUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	3.1893
2	3.4922
3	3.5818
4	3.5818
5	3.7609
6	.3315
7	.3315
17	.1658
18	.2486
19	.4144
20	.4973
21	.4144
22	.3315
23	.3315
Max	3.7609
Min	.1658
Avg	1.4766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV BHOPALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	.1658
2	.1658
3	.1658
4	.2486
5	.2486
12	2.8349
13	3.7609
14	3.7609
15	3.7609
16	3.5818
17	3.5818
18	3.7609
19	3.94
20	.4144
21	.3315
22	.2486
23	.1658
24	.1658
Max	3.94
Min	.1658
Avg	1.7390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV HINGANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-APR-18
HR	Load (MW)
1	.1658
2	.1658
3	.1658
4	.1658
5	.2486
12	3.1893
13	3.4027
14	1.7147
15	3.4027
17	3.1893
18	3.1893
19	3.3665
20	.3315
21	.2486
22	.1658
23	.1658
24	.1658
Max	3.4027
Min	.1658
Avg	1.3790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 201 / 11 KV OLD KURUL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.9528		.2214
5			.2846
6	2.5463		
8	2.8549		
9	2.7435		
18		2.7496	
23		.253	
24			.2372
Max	2.8549	2.7496	.2846
Min	1.9528	.253	.2214
Avg	2.5244	1.5013	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 202 / 11 KV KATEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			2.4691
5			2.9321
6			3.2617
9			3.8104
18		.25	
23		.2241	
24	.25		.2187
Max	.25	.25	3.8104
Min	.25	.2241	.2187
Avg	.25	.2371	2.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 203 / 11 KV ANKOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.206	.1406	1.1336		1.5432	
2	.2058		1.2003			
3	.1943		1.3565			
4	.1829		1.3717			
5	.206		1.4575		1.6204	
6			1.6194		2.037	
8			2.4006			
9			2.2672		2.4691	
10					2.2405	
12		2.5911				
13		2.672				
14		2.5149				
15		2.4387				
16		2.3624				
17		2.1338			.096	.1715
18		2.3148		.1581		.1715
19		1.9814				1.166
20						.2401
21						.2401
22						.2401
23				.1581	.16	
24	.2058	.1406	.2035		.0781	
Max	.206	2.672	2.4006	.1581	2.4691	1.166
Min	.1829	.1406	.2035	.1581	.0781	.1715
Avg	.2001	1.9290	1.4456	.1581	1.2805	.3716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 204 / 11 KV KURUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.7059	.7202		.5544	
2			.6859			
3	.5792		.6859			
4	.6687		.6964			
5	.7716		.823			
6	.8439	.8764	.8573		.8059	
7	.7621					
8	.7621	.6952	.6478			
9	.8402	.6516	.7202		.6687	
10		.9156			.6882	
11		.9259			.6722	
12		.7611			.5921	.8097
13		.7011			.6081	.8421
14		.763			.6081	.8097
15		.6964			.6401	.664
16		.6859			.5121	.6687
17		.6554			.6562	
18		.6859		.7202		.7716
19		.823				.8745
20						.9088
21						.8573
22						.7373
23				.7888	.7202	
24	.6859	.7362	.7373		.6335	
Max	.8439	.9259	.8573	.7888	.8059	.9088
Min	.5792	.6516	.6478	.7202	.5121	.664
Avg	.7255	.7519	.7304	.7545	.6431	.7944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 205 / 11 KV NEW KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3889	.2401		.1389	
2	1.3717		.2401			
3	1.7147		.2401			
4	1.5242		.2401			
5	1.8861		.2401		.1852	
6	1.7528	2.0062				
7	2.0576					
8	2.1338	2.21				
9	2.1338	2.3148				
10		2.1338				
11		2.1338			2.1125	
12					2.1605	2.1862
13					2.1605	2.2672
14		2.1338			2.2085	2.2672
15					2.2405	2.1862
16					2.0805	2.1862
17		.1619			2.2405	2.1862
18		.1886		2.3746		2.2291
19						2.0576
20						.2572
21						.2572
22						.2572
23				.1562	.16	
24	.2058	.1875	.2572		.1389	
Max	2.1338	2.3148	.2572	2.3746	2.2405	2.2672
Min	.2058	.1619	.2401	.1562	.1389	.2572
Avg	1.6152	1.4859	.2430	1.2654	1.4388	1.6670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 206 / 11 KV SHEJBABHULGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4515	2.572		2.3781	
2	.4287		2.572			
3	.4287		2.7435			
4	.4287		2.7435			
5	.4287		3.0007			
6			3.2922		3.2059	
7			3.4294			
8			3.4008			
9			3.3608		2.4533	
10					2.4326	
13		3.2579				
14		3.2226				
15		3.0483				
16		2.2348				
17		1.9757			.208	.3429
18		1.8595				.3944
19		3.0864				.463
20						.4372
21						.4287
22						.4287
23				.381	.4801	
24	.381	.3963	.3944		.3506	
Max	.4287	3.2579	3.4294	.381	3.2059	.463
Min	.381	.3963	.3944	.381	.208	.3429
Avg	.4208	2.1703	2.7509	.381	1.6441	.4158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 207 / 11 KV S.WARWADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.6975	.2591		.216	
2	1.8861		.2743			
3	1.7814		.2743			
4	1.829		.2743			
5	2.0576		.2743		.2591	
6	3.0007	2.0679				
8	2.8292	2.0881				
9	2.8292	2.7892	.2591			
10		2.3044				
12					2.9127	3.0769
13					3.0407	3.4294
14					3.2007	3.4008
15					3.2007	3.3684
16					3.2808	3.2388
17		.2743			2.8807	3.4008
18		.2591		2.774		3.0864
19		.3429				2.7778
20						.3258
21						.3086
22						.3086
23				.2623	.2561	
24	.3048	.1852	.2915		.2315	
Max	3.0007	2.7892	.2915	2.774	3.2808	3.4294
Min	.3048	.1852	.2591	.2623	.216	.3086
Avg	2.0386	1.3343	.2724	1.5182	1.9479	2.4293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 201 / 11 KV CHANDRAMOULI ESTATE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	1.0288	1.0059	1.0631	.4239	.9431	1.1145
2	1.1022	1.0288	.9221	1.0631	.4748	.9326	1.0631
3	1.0682	1.0288	.8478	1.0288	.4239	1.0174	1.0288
4	1.1022	.8573	.8573	1.0288	.4239	1.1022	
5	1.0174	.8916	1.1145	.9431	.5087	1.0174	.8573
6	.9326	.9431	1.1145	.9774	.4748	1.0059	.8573
7	.8478	.9431	1.0174	.8817	.5087	1.0059	.8573
8	.9326	1.0288	.9221		.5087	1.1022	.8059
9	1.1869	.9774	1.1145	.5087	.5935	.9431	.9945
10	1.2346	1.1361	1.1145	.5087	.8478	1.1145	.5935
11	1.3203	1.2717	1.2003		1.0898	1.3717	1.1022
12		1.0174	1.2003		1.1736	1.3717	1.153
13	1.1488	.6001	1.286	.4748	1.1736	1.3375	1.1869
14	.5487	1.0288	1.286	.4239	1.2574	1.3717	1.1022
15	1.0631	.9431	1.3717	.4239	1.326	1.0288	1.0174
16	1.1145	1.0288	1.286	.4239	1.1736	1.2346	.9835
17	.5487	1.0174	1.286	.4239	1.1736	1.166	1.1022
18	1.1488	.9431	1.2517	.4239	1.1736	.6516	.9326
19	1.0631	.8478	1.2346	.4239	1.0174	1.0631	.8478
20	1.0631	.9221	1.1488	.4239	1.0174	1.0288	.8478
21	.9774	.8383	1.2003	.4578	1.0898	1.0288	.8478
22	1.166	.8383	1.166	.4748	1.0898	1.0631	.9326
23	1.166	1.0059	1.1145	.4748	1.0898	1.1145	.9326
24	1.0174	1.1488	.9326	.9431	.4748	1.0174	1.2003
Max	1.3203	1.2717	1.3717	1.0631	1.326	1.3717	1.2003
Min	.5487	.6001	.8478	.4239	.4239	.6516	.5935
Avg	1.0379	.9715	1.1248	.6570	.8545	1.0847	.9722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 202 / 11 KV GOTEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2721	2.3329	2.3122	2.3781	.2721	.3149	.2439
2	2.4587	2.4232	2.3303	2.4383	.2881	.2949	.2439
3	2.6282	2.5135	2.4383	2.5286	.2561	.2949	.2439
4	3.103	2.6898	2.5149	2.5587	.2881	.2652	.2591
5	3.1369	2.9801	2.713	2.6791	.3201	.3018	.2743
6	3.2217		2.7587	3.1802			
7	3.5778	3.3139	3.236	3.7304			
8	3.5778	3.4476	3.5069	4.0295			
9	3.7813	3.2099	3.3733	3.7982			.9945
10	3.2545	3.3413	2.7641	3.7982			
12					3.4446	3.4903	3.9339
13					3.5521	3.6732	3.3573
14					3.5972	3.4141	3.8999
15					3.2811	3.4903	3.8321
16						3.6885	4.0695
17	.2134	.2652	.2439	.2721	3.4922	3.5361	3.8152
18	.2439	.2785	.2896	.3201	3.299	3.4903	4.0356
19	.3048	.3277		.3681	3.4903	3.4751	3.6626
20	.3506	.3768	.3353	.3841	.3681	.3506	.3681
21	.3048	.3315	.3201	.3361	.3521	.3048	.3841
22	.2743	.3315	.2743	.3041	.3481	.2896	.3361
23	.2591	.2683	.2439	.2721	.3149	.2743	.3361
24	.2401	.2439	.2486	.2134	.2721	.3149	.2439
Max	3.7813	3.4476	3.5069	4.0295	3.5972	3.6885	4.0695
Min	.2134	.2439	.2439	.2134	.2561	.2652	.2439
Avg	1.8446	1.6868	1.7590	1.8661	1.6021	1.7369	1.8176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 203 / 11 KV WADWAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4191	.3429	.3772	.3688	.373	.3772
2	.3353	.4191	.3052	.3772	.3688	.3353	.3772
3	.3353	.4191	.3429	.3856	.3856	.3429	.3772
4	.3018	.4191	.4287	.3856	.3856	.4287	.3772
5	.3688	.4694	.4801	.4382	.4191	.5087	.4287
6	.4191	.503	.5144	.4733	.4191	.5935	.4287
7	.503	.503	.5426	.4694	.4694	.4527	.6001
8	.3688	.503	.4748	.4748	.3856	.3353	.463
9	.3856	.4578	.5087	.4191	.3856	.4239	.5144
10	.373	.4287	.4239	.3856	.3856	.4239	.3353
11	.3391	.3988	.4287		.3772	.373	.3856
12	.3086	.4334			.3429	.3688	.2347
13	.3391	.3814	.2683	.3353	.3086	.373	.3018
14	.3391	.3391	.4287	.3353	.3086	.373	.3353
15	.3086	.3429	.4287	.3353	.3391	.3429	.3688
16	.3429	.3772	.4191	.3688		.373	.3688
17	.3429	.4334	.4239	.3688	.3391	.4239	.4191
18	.4239	.3429	.4239	.3856		.4287	.503
19	.5487	.6068	.5144	.4191	.373	.5487	.503
20	.5487	.5087	.6274	.4694	.4801	.5487	.503
21	.5426	.503	.5426	.4191	.4239	.5487	
22	.5144	.4191	.5087	.3856	.3688	.5144	.3856
23		.3688	.4748	.3353	.373	.4287	.3856
24	.3688	.4191	.3429	.4287	.3688	.3391	.4287
Max	.5487	.6068	.6274	.4748	.4801	.5935	.6001
Min	.3018	.3391	.2683	.3353	.3086	.3353	.2347
Avg	.3932	.4340	.4433	.3987	.3807	.4251	.4088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 204 / 11 KV VARDHMAN EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0377	.0343	.0377	.0343	.0347	.0377
2	.0343	.0377	.0351	.0377	.0343	.0347	.0377
3	.0343	.0377	.0351	.0377	.0343	.0343	.0377
4	.0343	.0377	.0347	.0377	.0343	.0347	.0377
5	.0343	.0377	.0351	.0377	.0343	.0347	.0377
6	.0343	.0377	.0347	.0377	.0343	.0347	.0377
7	.0343	.0377	.0339	.0343	.0343	.0351	.0377
8	.4287	.0377	.0343	.0343	.0343	.0343	.0377
9	.0343	.0377	.0377		.0343	.0347	.0377
10	.0377	.0351	.0377	.0343	.0351	.0377	.0343
11	.0377	.0347	.0377		.0343	.0377	.0339
12	.0377	.0343	.0377		.0343	.0377	.0343
13	.0377	.0347	.0377	.0343	.0343	.0377	.0343
14	.0377	.0343	.0377	.0343	.0351	.0377	.0343
15	.0377	.0347	.0377	.0343	.0343	.0377	.0343
16	.0377	.0351	.0377	.0343	.0343	.0377	.0343
17	.0377	.0347	.0377	.0343	.0343	.0377	.0343
18	.0377	.0343	.0377	.0343	.0339	.0377	.0343
19	.0377	.0351	.0377	.0343	.0347	.0377	.0343
20	.0377	.0351	.0377	.0343	.0347	.0377	.0343
21	.0377	.0347	.0377	.0343	.0343	.0377	.0343
22	.0377	.0347	.0377	.0343	.0343	.0377	.0343
23	.0377	.0347	.0377	.0343	.0351	.0377	.0343
24	.0343	.0377	.0351	.0377	.0343	.0343	.0377
Max	.4287	.0377	.0377	.0377	.0351	.0377	.0377
Min	.0343	.0343	.0339	.0343	.0339	.0343	.0339
Avg	.0527	.0360	.0366	.0354	.0344	.0364	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 201 / 11 KV BITALE BHAGIRATH

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	24-APR-18
HR	Load (MW)
12	.2772
23	.2587
24	.2743
Max	.2772
Min	.2587
Avg	.2701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 202 / 11 KV CHIKHALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18
HR	Load (MW)
23	.2218
24	.1509
Max	.2218
Min	.1509
Avg	.1864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 203 / 11 KV BITALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18
HR	Load (MW)
23	.2218
24	.1867
Max	.2218
Min	.1867
Avg	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 204 / 11 KV GHATANE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18
HR	Load (MW)
23	.1147
24	.1475
Max	.1475
Min	.1147
Avg	.1311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 205 / 11 KV BANDHARA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18
HR	Load (MW)
23	.1966
24	1.5844
Max	1.5844
Min	.1966
Avg	.8905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274128 / 33/11 KV BITALE

Feeder No / Name : 206 / 11 KV MALIKPETH
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-APR-18
HR	Load (MW)
12	2.8018
23	.1311
24	.1311
Max	2.8018
Min	.1311
Avg	1.0213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 201 / 11 KV BHAMBHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4191	2.4587	2.7816	3.0864	2.5911
2	.4191	.381	.4191	2.4006	2.934	3.1436	2.9012
3	.4191	.4191	.4191	2.1434	3.0864	3.1436	2.6246
4	.4191	.4572	.4572	2.5606	3.3913	3.2007	2.7206
5	.4954	.5716	.4954	2.915	3.4294	3.2388	2.8121
6	.5716	.5716	.5906	3.2007	3.658	3.4865	3.1367
7	.724	.6859	.6478	3.2808	3.7342	3.315	2.9447
8	.5716	.6097	.5716	3.3608	3.8104	3.6961	3.3573
9					3.8485	3.0864	
10				3.8104	3.7342	2.8121	3.315
12	3.2769		3.6008				
13			3.4294				
14	3.6199		3.4979	.381		.1715	.4191
15	3.8485		3.5322	.381	.4191	.1715	.381
16	3.6199	3.4637	3.4294	.381	.4954	.3429	.381
17	3.8104	3.6008	3.4637	.381	.5335	.3429	.4954
18	3.9247	4.1914		.4191	.5335		
19	3.6199	3.7342			.6097		.6097
20	.6859	.743		.724	.6859		.7621
21		.6859		.6478	.724		.6859
22	.5716	.5716		.5716	.5716		.4572
23		.4954		.4954	.4954		.381
24	.4191	.4191	.4572	.3144	.4191	.4191	.3239
Max	3.9247	4.1914	3.6008	3.8104	3.8485	3.6961	3.3573
Min	.381	.381	.4191	.3144	.4191	.1715	.3239
Avg	1.7443	1.2931	1.6954	1.6225	1.9948	2.2438	1.6473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 202 / 11kv Ashte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4098	1.3717	.1943	.1905	.2286	.192
2	1.448	1.448	1.3908	.1619	.1905	.2286	.181
3	1.4861	1.448	1.3908	.16	.2286	.2286	.141
4	1.5432	1.6766	1.4289	.2241	.2858	.2477	.1235
5	1.7528	1.829	1.4861	.2561	.3239	.2858	.1638
6	1.9814	1.9052	1.7718	.2286	.381	.4954	.3467
7	1.9052	1.9433	1.9052	.2881	.4382	.5335	.4694
8		1.9052	1.9814	.2881	.4001	.4191	.4334
9	2.1338	1.9052	1.6004				
10	1.8671	1.6632	1.3032				
12						1.8347	2.0957
13				1.6194	2.2862	1.8861	2.2481
14	.1334		.1715	1.7909	2.3243	1.9719	2.4196
15	.1334		.1715	1.5623	2.2862	1.8861	2.1338
16	.1524	.1715	.1715	2.0005	2.2481	1.8347	2.3243
17	.1715	.1715	.1715	1.9052	2.2291	1.8861	2.1529
18	.2096			2.0957	2.0957		2.2862
19	.2858	.3429		1.8861	2.0767		2.2481
20	.3239	.4001		.3239	.381		.4001
21		.381		.2858	.3239		.362
22	.2096	.3429		.2667	.2286		.2858
23	.1715	.2667		.2286	.2286		.2667
24	.1524	.1524	.1905	.2267	.2096	.2286	.2267
Max	2.1338	1.9433	1.9814	2.0957	2.3243	1.9719	2.4196
Min	.1334	.1524	.1715	.16	.1905	.2286	.1235
Avg	.9215	1.0757	1.1005	.7997	.9678	.9464	1.0238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802		1.2346		.3772	.4801	.4287
2	1.2003		1.6804		.3429	.4458	.4115
3	1.4746		2.0405		.3601	.4287	.3944
4	1.6804		2.2634		.3429	.3944	.3772
5	1.8861		2.4006		.3086	.4115	.3944
6	2.6406		2.8635				
7	3.2922		3.0864				
8	2.8464						
9	3.0521		2.5377				
10	2.2977		2.9835	2.7092			
12					3.0007	2.7778	2.8807
13					3.0864	3.0178	2.915
14					2.8292	2.8978	2.8635
15					2.5377	2.7949	2.7778
16							2.692
17					2.8292	2.6406	2.6406
18					2.915	2.5549	2.8121
19					2.2977	2.3663	2.4691
20	.4287	.5487		.4287	.4801	.4458	.5487
21	.5144	.5316		.4287	.5144	.4287	.5144
22	.5487	.4801		.4458	.5487	.4458	.4458
23		.3772		.4287	.5144	.463	.4287
24	.3772		.2572		.4115	.5144	.4458
Max	3.2922	.5487	3.0864	2.7092	3.0864	3.0178	2.915
Min	.3772	.3772	.2572	.4287	.3086	.3944	.3772
Avg	1.6657	.4844	2.1348	.8882	1.3939	1.3828	1.4689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 203 / 11 KV WAFALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3429		1.2003	1.0288	1.1831
2	.3601		.3258		1.3375	1.4575	1.4918
3	.3772		.3258		1.3717	1.5432	1.6975
4	.3944		.3429		1.9547	2.0233	2.4691
5	.4287		.3772		2.0576	2.4006	2.6235
6					2.2977	2.8292	2.8464
7					2.4863	3.0864	3.0521
8					2.4006	2.915	2.7778
9					2.4348		2.6235
10					2.4006		2.572
12	2.7435						
13	2.8292						
14	2.2291						
15	2.4863						
16	2.572						
17	2.6406						
18	2.4863						
19	2.0576			2.5377			
20	.3429	1.8861		.3772	.4287	.463	.583
21	.3772	.3601		.3944	.4458	.4458	.5487
22	.4115	1.8519		.4115	.4801	.4801	.4287
23		1.5775		.3944	.4458	.4458	.3772
24	.3772		1.2003		.3772	.4287	.463
Max	2.8292	1.8861	1.2003	2.5377	2.4863	3.0864	3.0521
Min	.3429	.3601	.3258	.3772	.3772	.4287	.3772
Avg	1.3798	1.4189	.4858	.8230	1.4746	1.5036	1.7158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 205 / 11 KV DEWADI - WAFAL

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401		.2229		.3258	.2058	.2572
2	.2572		.2229		.3429	.1886	.2743
3	.2572		.2401		.3429	.1886	.2915
4	.2743		.2401		.3086	.2229	.3086
5	.3086		.2743		.2915	.2058	.3258
6			.2401				
7			.2572				
8			.2058		.2058		
9			.1715		.1886		
10	.2743		.1886	.2058	.1715		.2058
11	.2572			.2058	.1886	.1886	.2058
12	.2058			.1886	.1715	.1715	
13	.2058			.1715	.1715	.1715	
14	.12			.1715	.1886	.1715	
15	.1715			.2058	.1886	.1715	.1886
16	.1715			.2058	.1715	.1715	.1715
17	.1543			.2229	.1543	.2058	.1715
18	.2572			.2229	.1372	.2058	.1715
19	.3429	.2743		.2572	.2058	.2572	.2743
20	.3601	.3429		.2743	.1886	.3258	.3429
21	.3772	.4115		.3086	.2058	.3601	.3429
22	.3429	.3772		.3086	.2229	.3429	.2915
23		.3429		.3258	.2401	.2915	.2572
24	.2401		.2401		.3429	.2229	.2743
Max	.3772	.4115	.2743	.3258	.3429	.3601	.3429
Min	.12	.2743	.1715	.1715	.1372	.1715	.1715
Avg	.2536	.3498	.2276	.2339	.2253	.2247	.2562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 201 / 11 KV JAMGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.6859	.7202	.823
2	.0343	.0343	.0514	.7888	.823	.9259
3	.0343	.0514	.0514	.9602	.8916	1.1145
4	.0514	.0514	.0514	1.0288	.9945	1.1145
5	.0514	.0686	.0686	1.1317	1.166	1.2003
6	.0514	.0686	.0686	1.2689	1.406	1.2689
7	.0686	.0686	.0686	1.4746	1.4403	1.2346
8		.0514		1.5432	1.0974	1.1317
9		.0343		1.3717	1.2689	
10		.0514		1.3717	1.2689	1.1317
11				.0514		.0686
12	1.0288	1.3889				
13	1.1317	1.4575				
14	1.2346	1.3717				
15	1.3375	1.3375				
17	1.406					
18	1.4403	1.3375		.0343		
19	.8916	1.286		.0514		
20	.0686	.0686	.0686	.0686	.0686	.0686
21	.0686	.0514	.0686	.0686	.0857	.0686
22		.0514	.0686	.0514	.0686	.0686
23		.0514		.0514	.0686	.0514
24	.0343	.0514	.0514	.0514	.0514	.0686
Max	1.4403	1.4575	.0686	1.5432	1.4403	1.2689
Min	.0343	.0343	.0343	.0343	.0514	.0514
Avg	.5275	.4270	.0592	.6697	.7613	.6893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 202 / 11 KV KORAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.869	1.6118	2.0919	.1372	.1372	.1372
2	2.0233	1.9547	2.3663	.1372	.1715	.1372
3	2.2291	2.3663	2.6063	.1715	.1886	.1372
4	2.4691	2.8978	2.8292	.1715	.1715	.1715
5	2.7435	3.2236	3.035	.1715	.1715	.2058
6	2.8978	3.7037	3.155	.2058	.1543	.2572
7	3.4637	2.7606	3.6351	.2058	.1715	
8	3.6866	3.4637	3.2236	.2401	.1886	
9	3.3093	3.2579	2.3491		.1372	
10		2.9835	2.6406		.1715	.1715
11					.1715	.1715
12				3.4637	3.4122	3.7037
13				3.5151	3.5494	3.7723
14				3.5494	3.4294	3.4294
15						3.3608
16				3.275	3.5848	.2743
17				3.4465	3.6351	3.2579
18				3.3608	.2915	3.3265
19	.1372	.1715		.1715	.2915	3.2579
20	.1372	.2058	.1372	.1543	.1372	.1715
21	.1715	.2058	.1372	.1715	.2058	.2058
22		.1715	.1372	.1372	.1715	.2058
23		.1715		.1372	.1715	.2058
24	.1372	.1543	.1372	.1372	.12	.1715
Max	3.6866	3.7037	3.6351	3.5494	3.6351	3.7723
Min	.1372	.1543	.1372	.1372	.12	.1372
Avg	1.9442	1.8315	2.0344	1.148	.9059	1.2730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 203 / 11 KV JAMGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029	.1029	.12	.1029
2	.1029	.1029	.1029	.12	.1029	.1029
3	.1029	.1029	.1029	.1372	.12	.1029
4	.1372	.1372	.1372	.1372	.1372	.1372
5	.1715	.1715	.1715	.1715	.1543	.1543
6	.2229	.2401	.2401	.2058	.2229	.2058
7	.2229	.1886	.2058	.2401	.2401	.1715
8	.1543	.1715	.1715	.1886	.1543	.1372
9	.1372	.1543	.12	.12	.1372	
10		.1372	.1029	.12	.1372	.1372
11			.1029	.1029	.1372	.1029
12	.1029	.1372	.1029	.12	.12	.1029
13	.1372	.12	.1372	.12	.12	.1372
14	.1372	.1029	.1372	.12	.0857	.1372
15	.1372	.1029	.1372	.12	.1029	.1543
16	.1372		.1372		.1029	.1543
17	.1372				.1372	.1715
18	.1543	.1543	.1372	.1543	.1543	.1715
19	.1886	.2058	.1715	.1715	.2401	.1886
20	.2058	.2058	.2058	.2229	.2229	.2058
21	.2915	.1715	.1715	.2229	.2058	.2401
22		.1715	.1715	.1715	.1543	.2058
23		.1372		.1543	.12	.1715
24	.1372	.1029	.1029	.1029	.12	.12
Max	.2915	.2401	.2401	.2401	.2401	.2401
Min	.1029	.1029	.1029	.1029	.0857	.1029
Avg	.1561	.1486	.1442	.1512	.1479	.1528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 201 / 11 KV YAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2058		.4572	1.4575	1.3717
2		.2401	.1886		.6859	1.5261	1.5432
3		.2401	.2572		.8535	1.7147	1.8004
4		.2743	.2743		.9602	2.1434	2.0576
5		.2743	.3429		1.1126	2.1776	2.21
6		.3086	.3601		2.0271	2.2291	2.2862
7			.3601		1.8747	2.2291	
8		.3048	.3429		2.2405	1.0212	
9	.2286	.1886	.2572	1.8747	1.2193	1.0212	1.9338
10		.1829	.2401	1.829	1.6118	1.9814	1.8004
11		.1524					
12		1.829					
13		1.9338					
14		1.9204	1.8138				
15		1.467					
16		2.0576					
17		1.7604		.1829	.2229	.1715	.1829
18		1.7337		.1981	.2058		.1981
19		1.587		.2896	.2572	.3429	
20		.3258		.2286	.2572	.3429	.3048
21		.3086		.2439	.3429	.3086	.2439
22		.2229		.2134	.3429	.2229	.1981
23		.2058		.1829	.3772	.2058	.1981
24		.2572	.2058		.1677	.3772	.2229
Max	.2286	2.0576	1.8138	1.8747	2.2405	2.2291	2.2862
Min	.2286	.1524	.1886	.1829	.1677	.1715	.1829
Avg	.2286	.7833	.4041	.5826	.8454	1.1455	1.1035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 202 / BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1372		.1372	.2401	.1543
2		.1829	.1715		.1372	.1715	.1372
3		.1829	.2058		.1543	.1715	.1715
4		.2058	.2572		.1543	.1715	.2401
5		.1829	.2743		.1543	.2058	.2915
6		.2286	.2915		.2401	.2058	.2743
7		.2743			.1886	.2058	
8		.2058	.2058		.1715	.1715	.2572
9	.1715	.2058	.2058	.2058	.12	.1715	.2058
10		.2058	.0686	.1829		.1715	.1715
11		.1886			.2058	.1715	.1715
12		.1715			.2058	.1715	.1372
13		.1677			.2058	.1543	.1029
14		.1677			.2058	.1372	.12
15		.1715			.2058	.1543	.1715
16		.1886		.2229	.2229	.1715	.1715
17		.1543		.2401	.2401	.1715	.1715
18		.2058		.2401	.1715	.1372	.2401
19		.2401		.2229	.1715	.2572	.2915
20		.2572		.2058	.2058	.2915	.2743
21		.2401		.1886	.2058	.2915	.2401
22		.2058		.1715	.2229	.2229	.1886
23		.2058		.1715	.2229	.1715	.1543
24		.1524	.1543		.1543	.2401	.1543
Max	.1715	.2743	.2915	.2401	.2401	.2915	.2915
Min	.1715	.1524	.0686	.1715	.12	.1372	.1029
Avg	.1715	.1977	.1972	.2052	.1871	.1929	.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 201 / 11KV Sakal
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
17	.1783		1.1458
18	.3525	1.0479	.9979
19	.3517	1.0288	
20	.3868	.8299	
21	.4344		
Max	.4344	1.0479	1.1458
Min	.1783	.8299	.9979
Avg	.3407	.9689	1.0719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 202 / 11KV VIDYAPEETH EXP. NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	25-APR-18	27-APR-18
HR	Load (MW)	Load (MW)
17	.9242	.3206
18		.2452
Max	.9242	.3206
Min	.9242	.2452
Avg	.9242	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 203 / 11 KV Smruti Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
OUTGOING

DATE	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
12			.7202
17	.5847		.7356
18	.679	.679	
19	.679	.7733	
20	.6602	.7356	
21	.679		
Max	.679	.7733	.7356
Min	.5847	.679	.7202
Avg	.6564	.7293	.7279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 205 / 11KV BPL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	27-APR-18
HR	Load (MW)
17	1.5339
18	1.3676
Max	1.5339
Min	1.3676
Avg	1.4508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 208 / 11kv volant
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
17	.2075		.8215
18	.3206	.8865	.9242
19	.5281	.7922	
20	.5281	.7733	
21	.5658		
Max	.5658	.8865	.9242
Min	.2075	.7733	.8215
Avg	.4300	.8173	.8729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 209 / 11KV AG KONDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
17	1.2637		1.1128
18	1.1506	1.2071	1.1317
19	1.0185	1.0562	
20	.0754	.0943	
21	.0754		
Max	1.2637	1.2071	1.1317
Min	.0754	.0943	1.1128
Avg	.7167	.7859	1.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 210 / 11kv ASHOK POLYMERS Exp. NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	25-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
17	.2873		.6535
18	.2987	.5247	.5992
19	.3841	.5556	
20	.3344	.5121	
21	.4252		
Max	.4252	.5556	.6535
Min	.2873	.5121	.5992
Avg	.3459	.5308	.6264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 201 / 11KV KARAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.3052	.6154	.4049	.57
2	.1905	.1905	.1905	.3795	.5761	.4161	.5365
3	.1905	.1905	.1905	.4858	.5281	.4096	.6554
4	.1905	.1905	.1905	.7969	.6722	.5079	.7611
5	.1905	.1905	.1905	.8718	.8097	.6401	.8802
6	.1905	.1905	.1905	.9717	.9393	1.1043	1.0526
7	.1905	.1905	.1905	1.1203	1.0978	1.1683	1.2955
8	.1905	.1905	.1905	1.0722	1.0562	1.166	1.1363
9	.1905	.1905		.9998	.9922	1.1012	1.012
10	.1905	.1905	.1905	.431	.8025	1.0227	.8429
11	.1905	.1905	.9878	.1905	.1905	.1905	.1905
12	1.1012	.9503	1.2631	.1905	.1905	.1905	.1905
13	1.1336		1.1869	.1905	.1905	.1905	.1905
14	1.1385	.9602	1.034		.1905	.1905	.1905
15	1.2146	.9145	1.0364		.1905	.1905	.1905
16	1.247	.945	1.0562		.1905	.1905	.1905
17	1.2944		1.2209		.1905	.1905	.1905
18	1.1797		1.1174	.1905	.1905	.1905	.1905
19	1.1469	1.1279	.9878	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905	.1905	.1905	.1905
21	.1905		.1905	.1905	.1905	.1905	.1905
22	.1905	.1905	.1905	.1905	.1905	.1905	.1905
23	.1905	.1905	.1905	.1905	.1905	.1905	
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	1.2944	1.1279	1.2631	1.1203	1.0978	1.1683	1.2955
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.5210	.3878	.5460	.4670	.4482	.4420	.4878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 203 / 11 KV AKOLEKATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2968	.426	.4572	.2829	.3174	.4435	.3361
2	.3795	.3841	.5079	.2452	.2987	.4066	.3174
3	.442	.4218	.5937	.2829	.2987	.4066	.2743
4	.5441	.4999	.5468	.3395	.3734	.4066	.3696
5	.6661	.7655	.578	.4715	.4481	.4854	.4066
6	.8322	1.0364	.7287	.4715	.5228	.5601	.5544
7	1.0059	1.0669	1.0486		.5658		
8	1.0753	1.0974	1.0395		.4527		
9	1.0269	.8573		.3361	.3961	.5415	.5601
10	1.0002	.8741	.7529	.2801	.3142	.4108	.5041
11	.2103	.2427	.2614	.2614	.2957	.2229	.4481
12		.2561	.2033	.6859	1.0974	.9214	.9536
13		.2378	.2427	.724	1.0402	.8916	.8977
14		.2378	.2801		.9659	.8288	.7895
15	.3142	.2402	.2241		.9701	.8859	.8573
16	.3142	.2743	.2402		.9556	.9659	.9511
17	.3511	.2572	.2801			1.0105	.9976
18	.3734	.2926	.3547	1.034	1.0848	.8573	.823
19	.4108	.4527	.415	1.0105	.8977	.7716	.8855
20	.5041	.6036	.4481	.4668	.6535	.5544	
21	.4294	.4904	.3734	.5601	.5975	.499	.5041
22	.3734	.3921	.3395	.4854	.4854	.4435	.4294
23	.3734	.3961	.3772	.3921	.4755	.4251	.3921
24	.2614	.3174	.3961	.3206	.3361	.4805	.3881
Max	1.0753	1.0974	1.0486	1.034	1.0974	1.0105	.9976
Min	.2103	.2378	.2033	.2452	.2957	.2229	.2743
Avg	.5326	.5050	.4647	.4806	.6019	.6100	.6019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 204 / 11KV MARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8215	.9335	.8886	.7975	.8149	.8322
2	.7842	.8029	.9335	.8745	.7373	.7802	.7888
3	.8402	.8402	.9709	.9259	.6706	.7888	.7716
4	.9149	.9522	1.0456	.8785	.8048	.7975	.8478
5	1.0642	1.0642	1.1389	.9835	.9892	.9431	.9724
6	1.2696	1.2883	1.3392	1.1145	1.2378	1.2209	1.1568
7				1.2742	1.4413	1.3077	1.3413
8				1.1934	1.4083	1.0814	1.2574
9	1.0903	1.0719		1.0486	1.1797	1.2071	1.1568
10	.9425	.961	.8779	.9804	.5079	.6401	1.0562
11		.7392	.9282	.7842	.6908	.695	.7655
12		1.1269	1.004	.7468	.6908	.6767	.6401
13	1.1142	1.1443	.9831	.7095	.7316	.7133	.6161
14	1.0526	1.1145			.7499	.7133	.695
15	1.1336	1.3014	.9012		.7499	.7316	.6535
16	1.1603	1.1683	.9555		.7865	.7682	.7316
17	1.1934	1.1469	1.0343		.8131	.7865	.8402
18	1.1469	1.1683	.9614	1.0269	.8501	.924	.9055
19		1.0978	.9614	1.3256		1.1458	1.2136
20	1.4045	1.307	1.3443	1.5497	1.4003	1.2936	1.2696
21	1.2567	1.358	1.307	1.3817	1.3203	1.2567	1.307
22	1.0903	1.1576	1.2136	***	1.2136	1.2012	1.0642
23	.8962	1.0751	1.0642	1.1203	.9619	1.1088	.9896
24	.8402	.8775	1.0562	.9335	1.0456	.9619	.9795
Max	1.4045	1.358	1.3443	12.6963	1.4413	1.3077	1.3413
Min	.7468	.7392	.8779	.7095	.5079	.6401	.6161
Avg	1.0496	1.0720	1.0477	1.6218	.9469	.9399	.9522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 206 / 11kv BB Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6024	.8297	.1524	.1715	.1143	.1334
2	.6173	.7059	.7773	.1143	.1715	.1143	.0953
3	.6973	.6859	.8552	.1143	.1715	.0953	.0953
4	.9829	.8032	.9701	.1334	.2096	.1905	.1334
5	1.1744	1.0608	.9488	.1334	.2667	.2286	.1524
6	1.3214	1.4986	1.0576	.1524	.3048	.2477	.1905
7	1.4251	1.5935	1.251	.2134	.3429	.2667	.2477
8	1.2346	1.5417	1.2892	.1429	.2477	.2667	.2096
9	1.4041	1.4365		.1429	.2286	.1905	.1715
10	1.2803	1.2879	1.4121	.1715			
11	.1524	.1	.1715	.1524			.1143
12		.1334	.1524		1.3717	1.4041	1.0402
13					1.2993	1.4297	1.1488
14		.1524			1.3323	1.2637	1.2382
15		.1334			1.1616	1.5287	1.451
16		.1334			1.0978	1.5318	1.6169
17		.1143			1.0059	1.5546	1.5158
18	.2286		.1905	1.6339	.9762	1.5158	1.5775
19	.2096	.2477	.2667	1.3786	1.0745	1.1919	1.3862
20	.1905	.2858	.2477	.2858	.2858	.2667	.2286
21	.1905	.2667	.2096	.2667	.2477	.2667	.2096
22	.1524	.2477	.2286	.2477	.2286	.2286	.2667
23	.1524	.2286	.1905	.2096	.1524	.1905	.1524
24	.1905	.1334	.2286	.1905	.1905	.1524	.1524
Max	1.4251	1.5935	1.4121	1.6339	1.3717	1.5546	1.6169
Min	.1524	.1	.1524	.1143	.1524	.0953	.0953
Avg	.6807	.6088	.6265	.3242	.5700	.6473	.5882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 207 / 11 KV Narotewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1276	.0975	.1532	.3429	.4001	.2667	.2667
2	.1276	.1006	.1532	.381	.381	.2286	.2477
3	.1341	.1276	.1276	.4191	.3429	.2286	.2286
4	.1829	.1532	.1532	.362	.3429	.2286	.2858
5	.1829	.1787	.1915	.4382	.4572	.2667	.381
6	.217	.2042	.2553	.4954	.5716	.5335	.5144
7	.2683	.2042	.2808	.6097	.724	.5716	.6859
8	.2553	.1915	.2298	.5525	.7049	.5906	.5906
9	.217	.1532			.6668	.4572	.5144
10	.1915	.1276	.1532	.4763	.5716	.3048	.6097
11	.1276	.1021	.381	.08	.1532	.1021	.1276
12	.5144	.5716	.4572	.08	.1276	.0894	.1143
13	.4954		.4954	.08	.1021	.0894	.1
14	.5335	.5335	.5335		.1021	.1021	.1143
15	.5525	.5906	.5906		.1021	.12	.1286
16	.5906	.5716	.5525		.1276	.1334	.1429
17	.5906	.6097	.4382		.1276	.1334	.1149
18	.5335	.5335	.4954	.1532	.1532	.1659	.1149
19	.5144	.4954	.5144	.2934	.2298	.2298	.1915
20	.2425	.2553	.2286	.285	.2681	.217	.2298
21	.2298	.3064	.3191	.2298	.2553	.1915	.2042
22	.1915	.2298	.2681	.2042	.1915	.1814	.1787
23	.1585	.1787	.2298	.1659	.1532	.1659	.1532
24	.1463	.1341	.1787	.1915	.1404	.1532	.1532
Max	.5906	.6097	.5906	.6097	.724	.5906	.6859
Min	.1276	.0975	.1276	.08	.1021	.0894	.1
Avg	.3052	.2892	.3209	.3074	.3082	.2396	.2664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 204 / 11KV Gaothan Wadala
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8916	1.0288	.9922		.9175	.9116
2	.9221	.9816	1.0852	.9362		1.0288	.9221
3	.9945	1.0402	1.2003	1.0631		1.0608	.9831
4	1.4251	1.2039	1.4091	1.2039		1.3032	1.1469
5	1.4918	1.4586	1.5775	1.4255		1.5775	1.2431
10	1.2269	1.1469	1.2689		1.2696	1.2437	1.2003
11	1.166	1.0288	1.1443	1.1469	.9175	.823	1.0974
12	1.0867	.9496	1.0288	.9116	.8764	.8505	.8764
13	.9602	.9259	.9189	.8192	.8139	.7459	.823
14	.8288	.8848	.8573	.8192	.8413	.7545	.8764
15	.8139	.8916	.8764	.8192	.8573	.7459	.8669
16	.7461	.9156	.7888	.8383	.7865	.7545	.8322
17	.8402		.8322	.9116	1.0288	.8288	.8573
18	1.0174	.9602	.8573		1.1869	.9831	.9568
19	1.2717	.8848	1.1789		1.3717	1.1469	1.2689
20	1.4255	1.0631	1.4582		1.5432	1.3765	1.5775
21	1.406	1.6461	1.4922		1.3226		1.3717
22	1.1869	1.1694	1.2003		.9945	1.2003	.9175
23	1.0517	1.0288	1.0867	1.2742	.8951	1.0174	.8764
24	.9536	.9465	.9175	1.0166		.8916	.9221
Max	1.4918	1.6461	1.5775	1.4255	1.5432	1.5775	1.5775
Min	.7461	.8848	.7888	.8192	.7865	.7459	.823
Avg	1.0879	1.0536	1.1104	1.0127	1.0504	1.0132	1.0264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 205 / 11KV Gawadi Darfal Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.286	1.5074	.0762		.0762	.0762
2	1.4918	1.3523	1.406	.0762		.0762	.0762
3	1.5729	1.286	1.4243	.0762		.0762	.0762
4	1.8023	1.3523	1.4091	.0762		.0762	.0762
5	1.9662	1.4243	1.5432	.0762		.0762	.0762
6	1.9662	1.7901	2.2325				
7	2.4577	2.4777	2.5434				
8	2.4577	2.4577	2.3838				
9	2.6216	2.5377	1.5432				
10	2.5206	2.4577	1.6644				
12					2.572	2.1262	2.2291
13					2.2939	2.3579	2.4539
14					2.332	2.4006	2.6006
15					2.4756	2.3739	2.0576
16					2.6292	2.5149	2.332
17					2.4097	2.3739	2.4577
18					2.0576	2.2939	2.5941
19	.0762		.0762			1.989	2.2291
20	.0762	.0762	.0762		.0762	.0762	.0762
21	.0762	.0762	.0762		.0762	.0762	.0762
22	.0762	.0762	.0762		.0762	.0762	.0762
23	.0762	.0762	.0762		.0762	.0762	.0762
24	.0762	.0762	.0762	.0762		.0762	.0762
Max	2.6216	2.5377	2.5434	.0762	2.6292	2.5149	2.6006
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.3014	1.2535	1.1322	.0762	1.5523	1.0662	1.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 206 / 11KV Nannaj Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.7373			
2	.381	.1905	.1905	.8063		1.6461	.547
3		.1905	.1905	.7802		1.5074	.6668
4	.381	.2286	.1905	.8238		1.6118	.5935
5	.381	.2286	.1905	.8764		1.5775	
6				1.1488			1.0059
7					1.989	2.1605	1.4918
8					2.3472	2.0683	
9					2.4006		2.4863
10					2.1628	1.1271	2.4006
12	2.489	2.4691	1.7684				
13		2.556	2.1776				
14		2.8045	1.949				
15	2.5434	2.572					
16	2.1338	2.13	1.4918				
17	2.4691	2.332	1.8861				
18	2.3472	2.13	1.8991				
19	2.2634	2.1262	1.7147				
20	.2667	.1905	.2286		.2286		.1905
21	.2286	.1905	.2286		.2286		.1905
22	.1905	.1905	.2286				.1905
23	.1905	.1905	.1905		.1905	.2667	.1905
24		.1905	.1905	.1905		.3429	.2667
Max	2.5434	2.8045	2.1776	1.1488	2.4006	2.1605	2.4863
Min	.1905	.1905	.1905	.1905	.1905	.2667	.1905
Avg	1.2512	1.1723	.8768	.7662	1.3639	1.3676	.8517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 207 / 11KV LokmangalR&D Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.0191		
8					.0191		
9					.0381		
10	.0191	.0381	.0381	.0572	.0381	.0381	.0381
11	.0381	.0572	.0572		.0381	.0572	
12	.0381	.0572	.0572	.0572	.0381	.0572	
13	.0381	.0572	.0381	.0381	.0572	.0572	
14	.0381	.0381	.0381	.0381	.0572	.0572	
15		.0381	.0381		.0572	.0572	.0381
16	.0381	.0381	.0381	.0381	.0572	.0572	.0381
17		.0381	.0381	.0381	.0572	.0381	.0381
18	.0191	.0381	.0191	.0381	.0381	.0381	.0381
19		.0191			.0191	.0191	.0381
Max	.0381	.0572	.0572	.0572	.0572	.0572	.0381
Min	.0191	.0191	.0191	.0381	.0191	.0191	.0381
Avg	.0327	.0419	.0402	.0436	.0411	.0477	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
17	2.2634	
18	1.4403	
24		.3018
Max	2.2634	.3018
Min	1.4403	.3018
Avg	1.8519	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV KAWATHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	28-APR-18
HR	Load (MW)
8	2.1948
9	1.9204
10	1.7833
24	.1509
Max	2.1948
Min	.1509
Avg	1.5124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV DONGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)
8		.5281
9		.3772
10		.3772
17	.3772	
18	.3772	
24		.4527
Max	.3772	.5281
Min	.3772	.3772
Avg	.3772	.4338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV NANDUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.3772			
8			3.6025				
17					2.1948	3.275	
18						2.915	
19	.2263						
20		.3772					
21	.3772	.4527					
24			.3961		.3772	.3018	.3584
Max	.3772	.4527	3.6025	.3772	2.1948	3.275	.3584
Min	.2263	.3772	.3961	.3772	.3772	.3018	.3584
Avg	.3018	.4150	1.9993	.3772	1.286	2.1639	.3584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV SOREGAON GFSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6036		
2					.5658		
3					.5281		
4					.5658		
5					.6413		
6					.7167	.7356	
7					.679		
8			.6979	.6979	.6413	.6979	.6413
9							.7167
17		.7545	.7545		.6979	.7545	
18		.7733				.7545	
19	.7545	.8299					
20		.8488					
21	.7922	.811					
24			.7356	.7356	.679	.6979	.7922
Max	.7922	.8488	.7545	.7356	.7167	.7545	.7922
Min	.7545	.7545	.6979	.6979	.5281	.6979	.6413
Avg	.7734	.8035	.7293	.7168	.6319	.7281	.7167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 206 / 11 KV PATHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.6783		
2					2.7161		
3					2.7161		
4					2.7538		
5					2.7915		
6					2.9801	2.7435	
7					3.2065		
8				2.7435	3.2442	2.8635	2.7606
9							2.7949
17		3.2579	2.915		.2075	.1886	
18		3.2922				.2452	
19	3.0007	3.155					
20		.2263					
21	.2452	.2641					
24			.1886	.1886	.1886	.2263	.2075
Max	3.0007	3.2922	2.915	2.7435	3.2442	2.8635	2.7949
Min	.2452	.2263	.1886	.1886	.1886	.1886	.2075
Avg	1.6230	2.0391	1.5518	1.4661	2.3483	1.2534	1.921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 207 / 11KV Commissioner SMC, NON SHEDDABLE WATER SUPPLY AND
P.Nagar Feeder KV- 11 / OUTGOING UTILITY

DATE	24-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132		
2		.1509		
3		.1509		
4		.1698		
5		.1698		
6		.1698		
7		.2452		
8	.0189	.1509		.0189
9				.0189
17			.0189	
18			.0189	
24	.2263	.0377		.132
Max	.2263	.2452	.0189	.132
Min	.0189	.0377	.0189	.0189
Avg	.1226	.153	.0189	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 201 / 11KV Rama

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641		.3772		.2263	.3395	.3018
2	.2641		.3395		.2263	.3395	.3018
3	.2641		.3395		.1886	.2641	.2263
4	.2641		.3018		.1886	.2263	.2263
5	.2641		.3018		.1886	.1886	.2263
6	.2641		.2641		.1886	.1509	.2263
7	.2587		.3395		.1886	.1509	.2263
8	.2263		.415		.2263	.2641	.3018
9	.3772		.4904		.4527	.3018	.3772
10	.5144	.5144	.679		.5281	.3395	.5281
11	.583	.583	.583		.5658	.4904	.679
12	.5487	.5487	.3429	.1886	.6036	.6036	.6413
13	.3429	.3429	.4801	.2263	.3772	.679	.3772
14	.4458	.4115	.5487	.1886	.5281	.6413	.5281
15	.4801	.5144	.6173	.1886	.6036	.5658	.6413
16	.4801	.6173	.583	.1886	.6413	.415	.6413
17	.5144	.6413	.6413		.7922	.4527	.583
18		.6036	.5658		.6413	.5281	.5487
19		.679	.5658		.5658	.4527	.5487
20		.5281	.4904		.4904	.3395	.5144
21		.4527	.3772		.415	.2641	.3429
22		.4435	.3772		.3018	.3018	.3086
23		.4527	.3395		.3395	.3018	.3429
24	.3395		.415		.2263	.3772	.3018
Max	.583	.679	.679	.2263	.7922	.679	.679
Min	.2263	.3429	.2641	.1886	.1886	.1509	.2263
Avg	.3720	.5238	.4490	.1961	.4039	.3741	.4142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 202 / 11KV Bhutada
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4045		1.1827		.7733	1.2449	1.1883
2	1.3676		1.251		.7733	1.2826	1.1317
3	1.2752		1.2382		.7499	1.2826	1.1317
4	1.2012		1.2012		.7733	1.2826	1.226
5	1.1643		1.1643		.811	1.2826	1.226
6	1.0534		1.1088		.811	1.2826	1.3203
7	.8589		1.2012		.811	1.2826	1.358
8	1.4045		1.3491		1.3203	1.6598	1.7164
9	1.423		1.6817		1.6827	1.7918	1.6297
10	1.406	1.7318	1.7187		1.8604	2.0022	1.8107
11	1.4575	1.6632	1.7147		1.9313	1.825	1.7684
12	1.406	1.6975	1.4232	1.1694	1.8107	1.8959	1.6644
13	1.3717	1.4575	1.5432	.9619	1.8111	2.0144	1.6278
14	1.4575	1.5432		.9431	1.9774	1.8073	1.7187
15		1.6461	1.8004	.2829	1.8839	1.7741	1.7187
16	1.3717	1.6975	1.7147	.3018	1.9936	1.8111	1.7896
17	1.3032	1.6078	1.8861		2.0559	1.5089	1.6975
18		1.4045	1.4146		1.6975	1.2637	1.3717
19		1.3121	1.4146		1.5089	1.2637	1.1317
20		1.4969	1.4523		1.2449	1.1506	1.166
21		1.4998	1.3203		1.2637	1.1506	1.0802
22		1.2567	1.1506		1.2637	1.1506	1.0117
23		1.2567	1.1643		1.226	1.1506	1.0288
24	1.5278		1.1458		.7733	1.2449	1.1883
Max	1.5278	1.7318	1.8861	1.1694	2.0559	2.0144	1.8107
Min	.8589	1.2567	1.1088	.2829	.7499	1.1506	1.0117
Avg	1.3208	1.5194	1.4018	.7318	1.3670	1.4752	1.4043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 205 / 11KV LDK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947		.8676		.6224	.9431	.9242
2	.8501		.8775		.6224	.9431	.9431
3	.7842		.924		.6224	.9431	.9054
4	.8488		.8962		.6036	.8676	.9054
5	.8402		.924		.6036	.8676	.7922
6	.7947		.8589		.6036	.8676	.7545
7	.7577		.7947		.6036	.8676	.679
8	.8686		.8316		.7167	.9431	.8299
9	1.0349		.9979		1.0791	.9619	.8676
10	1.0288	.8745	1.0534		1.3676	1.0349	1.0719
11	1.1145	.9088	1.0288		1.4045	1.1643	1.0349
12	1.0974	.9945	.8916	.5093	1.262	1.3491	.961
13	1.0288	.9945	.9945	.4904	1.1088	1.2803	.8962
14	1.166	1.0288	1.0288	.5658	1.2012	1.2382	.9795
15	1.1317	1.0288	1.0288	.5658	1.1273	1.2752	1.0425
16	1.0974	.9945	1.0631	.5847	1.1643	1.1643	.961
17	1.0974	1.0349	1.1694		1.226	.9431	.9602
18		.9795	1.1506		1.1694	.8488	.8573
19		.8775	.7545		1.1317	.8488	.6859
20		.7577	.6979		.9431	.7922	.6173
21		.8589	.7545		1.0374	.7922	.583
22		1.1088	.8676		1.094	.8865	.6173
23		1.0349	.9979		.9808	.8865	.6516
24	.8676		.8865		.6224	.9997	.9242
Max	1.166	1.1088	1.1694	.5847	1.4045	1.3491	1.0719
Min	.7577	.7577	.6979	.4904	.6036	.7922	.583
Avg	.9558	.9626	.9308	.5432	.9549	.9879	.8519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 206 / 11KV V.Datta

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545		.6036		.4338	.6224	.547
2	.6413		.6036		.4338	.6036	.547
3	.679		.5658		.4338	.6036	.547
4	.7167		.6036		.4715	.5658	.5093
5	.679		.5658		.4715	.5658	.5093
6	.6036		.5281		.4715	.4715	.5093
7	.4904		.5658		.4715	.4715	.5093
8	.4904		.6413		.5281	.6036	.5093
9	.6036		.679		.8501	.7167	.6979
10	.6859	.6344	.811		.8871	.8215	.6838
11	.7545	.7202	.6516		.961	.8501	.8501
12	.7202	.7202	.6859	.4904	.9055	.8596	.7947
13	.6516	.7545	.7202	.4715	.7577	.924	.7577
14		.7202	.7202	.4527	.8316	.8686	.8029
15	.6859	.6859	.7545	.4527	.8686	.8501	.8686
16	.7202	.6516	.7202	.4527	.8686	.8299	.9979
17	.7716	.7392	.7922		.9808	.7922	.823
18		.7392	.8676		.9054	.7922	.7716
19		.7167	.7545		.8488	.7167	.7716
20		.7392	.7356		.8488	.6602	.6859
21		.6602	.7167		.7167	.5847	.5144
22		.6036	.679		.6224	.5847	.583
23		.6413	.7545		.5658	.5847	.6173
24	.7762		.6413		.4338	.6224	.547
Max	.7762	.7545	.8676	.4904	.9808	.924	.9979
Min	.4904	.6036	.5281	.4527	.4338	.4715	.5093
Avg	.6720	.6947	.6817	.464	.6903	.6903	.6648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 207 / 11KV Venky Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9997		.9431		1.094	1.1128	
2	.9808		.961		1.094	1.0562	1.0751
3	1.0562		.924		1.1317	1.0562	1.1317
4	.961		.9979			1.0562	1.0374
5	1.0534		.9795			.9808	.9431
6	.9795		.924			.9431	.9431
7	1.0534		.8775		1.1506	.9431	.9054
8	1.0562		.811		1.2071	1.1694	.9054
9	1.2197		.7922		1.2012	1.2826	1.1883
10	1.0631	1.1488	.8962		1.2254	1.2752	.679
11	1.046	.703	1.0288		1.2197	1.3169	.8501
12	1.046	.9431	1.0288	.9619	1.1643	1.2437	.8299
13	.9945	1.1145	1.1145	.7922	1.2382	1.2803	.905
14	1.0802	1.0288		.9431	1.2936	1.3352	.9054
15	1.0288	1.0631		1.1694	1.2567	1.2803	1.1458
16	.9431	1.0974	.3944	1.2637	1.3352	1.2567	1.2936
17	.8916	1.1458			1.358		1.2689
18		1.1088			1.226		1.0288
19		1.2197	.7545		1.1317		.9431
20		1.0719	.9997		1.0185		.9431
21		.9979	.9431		1.1317		.9945
22		1.0534	.2641		1.1694		.9945
23		1.0349	.6653		1.094		1.0288
24	1.0349		.9979		1.094	1.1128	
Max	1.2197	1.2197	1.1145	1.2637	1.358	1.3352	1.2936
Min	.8916	.703	.2641	.7922	1.0185	.9431	.679
Avg	1.0271	1.0522	.8649	1.0261	1.1826	1.1589	.9973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 401 / 33KV KOTHARI PRIMA NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093		.5093		.4527	.7356	.5093
2	.4527		.4527		.3961	.7356	.5093
3	.5093		.4527		.2263	.6224	.5093
4	.4527		.3961		.3961	.6224	.5093
5	.5093		.4527		.3395	.5658	.4527
6	.5658		.4527		.3395		.6224
7	.679		.5093		.3395	.3961	.6224
8	.4527		.4527		.2829	.3961	.4527
9	.4527		.4527		.3395	.5658	.4527
10	.463	.463	.5093		.3395	.5093	.6224
11	.5144	.463	.3601		.4527	.6224	.5658
12	.5144	.3601	.5144	.2263	.3961	.4527	.5093
13	.5144	.3601	.5144	.2829	.4527	.3961	.5093
14	.4115	.4115	.5144	.4527	.5093	.4527	.5093
15	.5144	.4115	.5144	.3395	.3961	.4527	.4527
16	.5658	.5144	.6173	.3395	.5093	.5093	.5093
17	.5658	.5658	.679		.6224	.8488	.463
18		.5093	.9054		.5658	.6224	.5144
19		.4527	.3961		.4527	.3961	.6173
20		.4527	.3961		.4527	.4527	.6173
21		.3961	.3395		.3961	.4527	.6173
22		.4527	.3395		.3961	.4527	.4115
23		.9054	.3961		.4527	.5093	.4115
24	.5093		.5093		.2263	.4527	.5093
Max	.679	.9054	.9054	.4527	.6224	.8488	.6224
Min	.4115	.3601	.3395	.2263	.2263	.3961	.4115
Avg	.5087	.4799	.4848	.3282	.4055	.5314	.5200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 201 / 11KV Vasant Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706		.5249	.5611	.5068	.5249	.5611
2	.4525		.4887	.5249	.5068	.5068	.543
3	.4344		.4344	.4887	.4706	.4706	.5249
4	.3982		.4163	.4525	.4525	.4344	.5068
5	.3801		.3982	.4163	.3982	.4163	.4887
6	.3258		.4163	.4163	.3439	.3982	.4163
7	.3439		.3801	.3801	.3439	.3801	.4525
8	.3077	.3258	.3258	.3982	.3439	.362	.3801
9	.3077	.362	.6516	.4163	.3439	.3801	.362
10	.3982	.362	.362	.3801	.3258	.3258	.362
11	.362	.3982	.362	.3439	.3801	.362	.362
12	.362	.362	.3439	.3258	.3982	.3258	.3982
13	.3801	.3982	.362	.3258	.4163	.3982	.3982
14	.3982	.3801	.362	.3258	.4163	.4344	.4344
15	.4525	.4163	.3801	.3801	.4706	.3982	.4344
16	.4525	.4525	.4163	.362	.4525	.3982	.4344
17	.4344	.4163	.3982	.3801	.3982	.3801	.4344
18	.362	.4344	.3801	.3258	.3801	.3801	.4525
19	.4706	.4887	.4525	.4344	.4887	.4525	2.2624
20	.4887	.4887	.4525	.4706	.4887	.4706	.4706
21	.4887	1.0136	.4706	.4887	.4706	.5068	.5068
22	.5068	1.086		.5068	.5249	.543	.5611
23	.543	1.1946		.5068	.5611	.5611	.6154
24	.4706		.543	.543	.5249	.543	.5792
Max	.543	1.1946	.6516	.5611	.5611	.5611	2.2624
Min	.3077	.3258	.3258	.3258	.3258	.3258	.362
Avg	.4163	.5362	.4237	.4231	.4336	.4314	.5392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 202 / 11KV BHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7013		1.7556	1.8823	1.8823	1.8099	1.9366
2	1.6651		1.7375	1.8642	1.828	1.7737	1.9004
3	1.6289		1.7375	1.7918	1.8642	1.7013	1.8642
4	1.6651		1.7556	1.828	1.828	1.7375	1.8823
5	1.7375		1.7737	1.9185	1.8823	1.8099	1.8461
6	1.9547		2.0271	2.1357	1.8823	1.9909	1.8099
7	1.9366		2.1176	2.009	1.9366	2.0633	1.8823
8	1.7556	1.7375	1.8461	1.9366	1.7194	1.9185	1.6289
9	1.7013	1.7013	1.7918	1.647	1.5023	1.4661	1.6832
10	1.828	1.9185	1.8099	1.8461	1.9004	1.8461	1.9728
11	1.8099	1.7737	1.9185	1.7737	1.9004	1.9728	1.9728
12	1.9185	1.8099	1.6651	1.7918	1.7737	1.9004	2.0452
13	1.8461	1.7194	1.8099	1.5203	1.647	1.7737	1.9366
14	1.8823	1.7918	1.8099	1.7375	1.7556	1.7375	1.9547
15	1.9366	1.8642	1.7918	1.7918	1.8099	1.8823	1.8461
16	1.8823	1.6651	1.8642	1.8099	1.828	1.8823	1.9547
17	1.9004	1.8642	1.8461	1.8461	1.9366	2.009	1.8461
18	1.9185	1.8461	2.0271	1.8461	2.009	1.9004	1.9366
19	2.1357	2.1719	2.2624	2.1719	2.2262	2.2624	
20	2.2262	2.2262	2.3167	2.4072	2.2262	2.3529	2.3529
21	2.1719	2.1538	2.2986	2.2262	2.19	2.2624	2.3167
22	2.0452	2.1176		2.2081	2.19	2.2262	2.2081
23	2.009	2.009		2.1538	2.009	2.1538	2.1538
24	1.8099		1.7918	1.9547	1.9728	1.9004	1.9728
Max	2.2262	2.2262	2.3167	2.4072	2.2262	2.3529	2.3529
Min	1.6289	1.6651	1.6651	1.5203	1.5023	1.4661	1.6289
Avg	1.8778	1.8981	1.8979	1.9208	1.9042	1.9306	1.9523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 201 / 11KV BHAGAIWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.2241		.1867
2	.2241	.168	.1867		.1494
3	.2614	.2241	.1494		.1494
4	.3361	.3734	.1494		.2241
5	.5041	.4481	.2801		.3361
6	.3734	.3921	.3921		.4108
7	.168	.3734	.2987		.3921
8	.1494	.2241	.3921		.3361
9	.1494	.2241	.2801		.2614
10	.112	.2801		.2241	
11	.112	.2241			
12	.0934	.1867			
13	.112	.1494			
14	.112	.1494		.1867	
15	.112	.1494			
16	.112	.1494		.1867	
17	.112	.1867		.2241	
18	.2241	.2801		.3361	
19	.3361	.3921		.4481	
20	.3734	.5041		.3921	
21	.4854	.4481		.5041	
22	.5041	.3921		.4481	
23	.2241	.3361		.3361	
24	.1867	.1867	.2801		.2241
Max	.5041	.5041	.3921	.5041	.4108
Min	.0934	.1494	.1494	.1867	.1494
Avg	.2318	.2762	.2633	.3286	.2670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 202 / 11KV SAKHAREWADI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.759	.8855	.8539	
2	1.0437	1.0437	1.0279	
3	1.0437	1.3599	1.2967	
4	1.3916	1.3916	1.3916	
5	1.6617	1.4864	1.4232	
6	1.3125	1.4864	1.4706	
7	1.7711	1.5181	1.8343	
8	1.7711	1.4864	1.6604	
9	1.7394	1.7394	1.4232	
10	1.692	1.8027		
11		1.8027		
14				1.5497
15				1.5023
16				1.5023
17				1.7078
18				1.6129
19				1.6129
Max	1.7711	1.8027	1.8343	1.7078
Min	.759	.8855	.8539	1.5023
Avg	1.4186	1.4548	1.3758	1.5813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 203 / 11KV KAUTHALI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.5535
2			.8223
3			.8223
4			.8539
5			.9014
6			.9804
7			1.2809
8			1.3283
9			.8223
10		.6642	
12	1.1702		
13	1.1385		
14	1.1385		
15	1.3441		
16	1.3916		
17	1.3599		
18	1.186		
19	1.0437		
Max	1.3916	.6642	1.3283
Min	1.0437	.6642	.5535
Avg	1.2216	.6642	.9295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 203 / 11KV NEHRU NAGAR Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	3.6466	4.0143		.0829
10	3.5227	3.5227		.0829
11	.0686			.0829
12	.0829			
13	.081	.0838		4.3096
14	.081	.0838	3.3198	4.6944
15	.081	.0838	3.6466	4.7782
16	.0819	.0953	3.8123	4.7782
Max	3.6466	4.0143	3.8123	4.7782
Min	.0686	.0838	3.3198	.0829
Avg	.9557	1.3140	3.5929	2.6870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 204 / 11KV DEGAON-AG-
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0943	.0953		2.4215
10		.0953		2.4996
11	.0953	.0953		.0953
12	4.6944	4.1438		.0953
13	4.7782	2.8502		.0953
14	4.7782	3.8123	.0953	.0953
15	4.0609		.0953	.0953
16	4.1438		.0953	
Max	4.7782	4.1438	.0953	2.4996
Min	.0943	.0953	.0953	.0953
Avg	3.2350	1.8487	.0953	.7711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 207 / 11KV BALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		2.3472		.2743
10	2.3205	2.3472		.2829
11	.1867	.2801		.2829
12	.2801	.2743		2.713
13	.2801	.2743		3.1626
14	.2801	.2715	2.4034	3.3532
15	.2829	.2829	2.4587	3.3532
16	.2801	.2829	2.4587	3.3532
Max	2.3205	2.3472	2.4587	3.3532
Min	.1867	.2715	2.4034	.2743
Avg	.5586	.7951	2.4403	2.0969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 209 / 11KV TIKEKAR WADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0819	.0819	.703	.8383
10	.0953	.0953		.8383
11	.0953	.0953		.0953
12	.7907	.7811		.0953
13	.7811	.8592		.0953
14	.7811	.8592	.0829	.0953
15	.7716	.8488	.0829	.0953
16		.7811	.0829	.0953
23	.7811			
Max	.7907	.8592	.703	.8383
Min	.0819	.0819	.0829	.0953
Avg	.5223	.5502	.2379	.2811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 201 / 11 KV VINCHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7721	2.7435	2.2291	.381	.381	.381	.4001
2	2.7721	2.7435	2.2786	.381	.381	.381	.4001
3	2.7721	2.7435	2.2786	.381	.381	.4001	.4001
4	2.7721	2.7435	2.2291	.381	.381	.4001	.4001
5	2.9569	2.7435	2.2291	.5335	.5335	.4382	.4191
6	3.5113	3.2579	2.4863	.6097	.5335	.4382	.4572
7	3.6961	3.7723	2.8045	.5335	.5716	.4382	.5335
8	3.6961	3.6866	3.4294	.381	.5716	.4382	.4572
9	3.6037	3.6866	3.5757	.3048		.381	.3048
10	3.1722	3.2579	3.155	.3048	.381		.3048
11	.2286	.2667	.3048	3.3608	.5335	.3048	.2286
12	.2286	.3048	.3048	3.0864	3.2442	3.1417	3.2236
13	.3048	.3048	.3048		3.2442	2.9569	3.3608
14	.2858	.3048	.3048		3.315	3.1417	3.3913
15	.2858	.3048	.3048		3.315	3.1417	3.5151
16	.2858	.3048	.3048		3.315	3.5113	3.5608
17	.2858	.3048	.3048		3.315	3.6961	3.3913
18	.381	.381	.362	3.6866	3.2819	3.6961	3.3234
19	.5335	.5335	.5144	3.4294	3.2819	3.6961	3.0178
20	.5716	.6097	.6859	.5716	.381	.5716	.6097
21	.4763	.5716	.6668	.4763	.381	.6097	.5716
22	.4763	.4763	.5335	.4763	.4001	.5525	.4572
23	.2858	.4191	.381	.381	.4001	.4763	.4572
24	.4001	.2858	.2858	.381	.381	.381	.4763
Max	3.6961	3.7723	3.5757	3.6866	3.315	3.6961	3.5608
Min	.2286	.2667	.2858	.3048	.381	.3048	.2286
Avg	1.5314	1.5313	1.3441	1.0548	1.4306	1.4597	1.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 202 / 11 KV VADAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.2858	2.9569	3.4294	3.4705	3.1417
2	.3048	.2858	.2858	2.9569	3.4294	3.4705	3.1417
3	.3048	.2858	.2858	2.9569	3.4294	3.3951	3.1417
4	.3048	.2858	.2858	2.9569	3.4294	3.6008	3.1417
5	.3048	.2858	.2858	3.1417	3.4294	3.858	3.5113
6	.3429	.381	.3429	3.4189	3.858	3.8123	3.7885
7	.362	.381	.4001	3.9733	3.6866	.4108	4.0657
8	.2858	.2858	.3239	4.3429	3.6866	.4108	4.3429
9	.2286	.2858		4.1396	3.6866	3.7304	4.3429
10				4.1951	3.4294	3.3913	3.6037
11			.1905	.2858	.2858	.2286	.2286
12	3.7723		4.3429	.2858	.2286	.2286	.2858
13	3.7723	3.488	3.6961	.2858	.2286	.2477	.2858
14	3.2579	3.3573	4.2505		.2286	.2477	.2858
15	3.6008	3.3743	4.0657		.2286	.2477	.2286
16	3.6008	3.3573	4.1581		.2286	.2477	.2286
17	3.4294	3.3608	4.1581		.2858	.2286	.2858
18	3.6008	3.4082		.3048	.3239	.2667	.3239
19	3.6008	3.0864	3.1417	.381	.362	.381	.4382
20	.381	.4382	.4572	.381	.3239	.5144	.4763
21	.381	.4382	.4001	.381	.3239	.4763	.4191
22	.381	.4001	.4001	.381	.2858	.4191	.3239
23	.2858	.3429	.3429	.2858	.2858		.2858
24	.3048	.2858	.2858	.2858	.2858	.2286	.3429
Max	3.7723	3.488	4.3429	4.3429	3.858	3.858	4.3429
Min	.2286	.2858	.1905	.2858	.2286	.2286	.2286
Avg	1.5051	1.3381	1.5422	1.9148	1.6417	1.4571	1.6942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 203 / 11 KV KUSUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.1431	.6668	2.9569	3.0864	3.5837	2.7721
2	.9526	1.1431	.6668	2.9569	3.0864	3.5837	2.7721
3	.9526	1.1431	.6668	2.9569	3.0864	3.5837	2.7721
4	.9526	1.1431	.6668	2.9569	3.0864	.547	.3734
5	.9526	1.1431	.6668	3.2341	3.0864	.547	.3772
6	1.1431	1.1431	.6668	3.6037	3.5151	3.1687	.3772
7			.6097	3.9733		4.357	.3772
8			.6859	3.9733	3.6008	3.9609	3.0493
9				3.6961	3.858	3.7723	4.2505
10			.1524	3.6591	3.4294	3.7342	3.6961
11	.2286		3.5113	.6668	.8383	.6859	1.0669
12	3.4294	3.2579	3.6037	.8573	.8383	.8573	
13	3.6866	3.3653	3.6037	.9526	.8954	.8954	
14	3.6008	3.2217	3.6037		.8954	.9907	
15	3.6008	3.1878	3.6037		.9335	.9526	
16		3.2579	3.6037		.9335	.9907	
17	3.7723	2.6063	3.5113		1.0479	.9907	
18	3.858	3.0521		.9526	1.1431	1.0669	
19	3.7723	2.8807	4.3429	1.0479	1.2193		.7621
20	1.0479	.9907	.9717	1.1431	1.105	1.105	1.2955
21	1.2384	.9907	.9526	1.0479	1.0288	1.0669	1.1431
22	1.2384	1.0479	.9526	1.0479	.8764	1.0669	.5335
23	1.2384	1.0479	.9145	.1905	.7621	1.0288	.5335
24	.9526	1.1431	.7621	.4763	.1905	.5716	.9907
Max	3.858	3.3653	4.3429	3.9733	3.858	4.357	4.2505
Min	.2286	.9907	.1524	.1905	.1905	.547	.3734
Avg	1.9774	1.9426	1.7903	2.1175	1.8497	1.8742	1.5966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 204 / 11 KV INDIAN PUBLIC SCHOOL SINGLE PHASING
(IP Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.3717	1.0288	.1334	.1334	.1143	.1334
2	1.2936	1.3717	1.1393	.1334	.1334	.1143	.1334
3	1.2936	1.3717	1.1145	.1334	.1334	.1524	.1334
4	1.2936	1.3717	1.1145	.1334	.1334	.1524	.1334
5	1.4784	1.3717	1.1145	.1334	.1905	.1905	.1334
6	1.9404	1.7147	1.3717	.1715	.2286	.1905	.1715
7	2.1068	1.8004	1.5432	.2286	.1905	.2286	.1905
8	2.0144	1.9719	1.7177	.1715	.1524	.2286	
9	1.8111	1.8861	1.3717	.1143	.1524	.1334	
10	1.7147	1.8861	1.4373	.0953	.0762	.1334	
11	.0953	.0762	.0762	.0953	.0762	.1143	
12	.0953	.0762	.0762	1.8861	1.8591	1.848	1.2094
13	.0953	.0762	.0762	1.8861	1.8591	1.848	1.2269
14	.0953	.0762	.0762		1.8278	1.848	1.2003
15	.0953	.0762			1.8278	1.848	1.262
16	.0953	.0762	.0762		1.781	1.7556	1.286
17	.0953	.0762	.0953		1.8027	1.7556	1.262
18	.0953	.0762	.1334	2.0576	1.7394	1.7556	1.3847
19	.0953	.0953		2.0576	1.7394	1.848	.9945
20	.1905	.0953		.1524	.1143	.1905	.0953
21	.1905	.0953		.1524	.1143	.1715	.0572
22	.1905	.0953		.1524	.1334	.1524	.0762
23	.1334	.0762	.1524	.1143	.1334	.1524	.0762
24	.1143	.1143	.0762	.1334	.1143	.1143	.1524
Max	2.1068	1.9719	1.7177	2.0576	1.8591	1.848	1.3847
Min	.0953	.0762	.0762	.0953	.0762	.1143	.0572
Avg	.7465	.7208	.7259	.5068	.6936	.7100	.5656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 205 / 11 KV EXPRESS FDR
CRE/PHONIX Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0924		.037	.0886		
2	.0554	.0924		.052	.0886	.0543	
3	.0554	.0924		.0526	.0886	.0543	
4	.0554	.0924		.0526	.0886	.0693	
5	.0549	.0924		.0526	.0886	.0693	
6	.0549	.1109		.0526	.0886	.0709	
7		.0924	.0351	.0358	.0532	.0709	
8		.0914	.0549		.0532	.0709	
9		.0914	.0724	.0354		.0709	.0354
10	.0358	.0914	.0602			.0716	.0366
11	.0185	.0514	.052			.0354	.0114
12	.0185	.0328	.0526		.0514	.0358	.0097
13	.0185		.052		.0514		.0152
14							.0171
15		.0351					.02
16							.0183
17		.0343					.0305
18		.0572		.0358			.032
19		.0309		.0358		.0886	.0259
20				.0886		.056	.0181
21				.0886		.037	.0229
22				.0886		.0366	.0251
23				.0886		.037	.0514
24					.0886		.0366
Max	.0554	.1109	.0724	.0886	.0886	.0886	.0514
Min	.0185	.0309	.0351	.0354	.0514	.0354	.0097
Avg	.0404	.0738	.0542	.0569	.0754	.0581	.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 207 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.3717	1.7804	.5525	.6287	.6097	.5716
2	1.2936	1.3717	1.8004	.5335	.6287	.6097	.5716
3	1.2936	1.3717	1.8004	.5335	.6287	.6097	.5716
4	1.2936	1.3717	1.7804	.5335	.6287	.6097	.5716
5	1.4784	1.3717	1.7604	.5716	.6668	.6097	.5716
6	1.9404	1.6289	1.8861	.6668	.724	.6097	.5716
7	1.9774	1.8861	2.0576			.6097	
8	2.0883	1.8861	1.9033			.6097	
9	2.0698	1.9719	1.9456				
10	1.8004	1.9719	1.8229				
11	.5335	.3048	.6097	.4191	.5716	.2858	.3429
12	.5716	.4763	.6287	1.7147	2.4697	2.2177	2.1209
13	.5716			1.7147	2.4697	2.3101	2.2786
14	.5716				2.304	2.3101	2.2805
15	.5716				2.0222	.4668	2.3148
16	.5716				1.9062	.4668	2.4006
17	.5716				1.9062	2.1472	2.4714
18	.5716			1.8861	1.8679	2.0911	2.5065
19	.5716		5.6394	1.8861	1.8679	2.0538	1.8755
20	.5716	.6097	.6287	.7049	.5716	.5716	.6859
21	.5716	.6097	.5906	.6668	.5716	.6097	.6668
22	.5716	.5716	.5716	.6668	.6097	.5716	.5906
23	.381	.4763	.5525	.6287	.6097	.5716	.5716
24	.381	.381	.381	.5335	.6287	.6097	.5716
Max	2.0883	1.9719	5.6394	1.8861	2.4697	2.3101	2.5065
Min	.381	.3048	.381	.4191	.5716	.2858	.3429
Avg	1.0047	1.1549	1.5633	.8883	1.2141	1.0073	1.2554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 201 / 11 KV BALAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.679	.5658	2.3266	2.5377	2.3205	1.6409
2	.6001	.6348	.4287	2.5486	2.5549	2.3868	1.829
3		.679	.5975	2.6526	2.572	2.4531	2.5434
4	.6344	.7095	.6413	2.7349	2.5892	2.4577	2.6216
5	.6687	.7545	.5601	2.9127	2.692	2.5232	2.713
6	.7202	.7922	.5658	2.9647	3.0178	2.8673	3.0521
7	.6687	.7545	.5975	2.9492	3.1722	3.0803	3.0498
8		.6413	.5281	2.9504	3.1207	2.9492	3.0167
9	.5487	.5093	.4294	2.9001	3.1878	2.7681	2.8959
10		.415	.2241	3.035	2.572	2.8675	
11	.1509	.4715	.112	.2572	.2452	.2829	.3734
12	2.9504	2.8178	3.1207	.2572	.3772	.3961	.3734
13	2.982	2.9656	3.1727		.5281	.3961	.3772
14	2.9007	3.0182	3.0476		.6602	.4715	
15	2.8178	3.2217	3.0476		.5658	.4854	.3734
16	3.0498	3.12	3.0967		.5281	.4715	.7468
17	3.1131	3.0178	3.1131		.4904	.5228	
18	2.982	3.1161	3.0148	.1715	.5281	.4715	
19	2.8841	3.1161	2.9007	.3429	.5281	.5601	.6224
20	.4904	.4287	.2801	.3772	.6036		.5975
21	.5281	.5658	.2614	.3258	.4904	.4715	.5041
22	.6036	.6348	.2241	.3086	.3772	.2263	.3395
23	.679		.2263	.2572	.2641		.2801
24	.6516	.7167	.6036	.1867	.1543	.1886	.168
Max	3.1131	3.2217	3.1727	3.035	3.1878	3.0803	3.0521
Min	.1509	.415	.112	.1715	.1543	.1886	.168
Avg	1.4869	1.4687	1.3067	1.6031	1.4315	1.4372	1.4059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 203 / 11 KV B'KAWATHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.3868	1.6907	.6722	.4458	.5281	.3734
2	2.5549	2.7349	2.0119	.6535	.4115	.5601	.4668
3		2.9165	2.4577	.6979	.4458	.6602	.2829
4	2.9492	3.1824	2.8656	.7842	.4801	.7468	.2801
5	3.1379	3.3589	3.1369	.8676	.7202	.7922	.2801
6	3.6008	3.4736	3.3029	.9335	.6859	.8299	.3772
7	3.4122	2.6686	2.9835	.7095	.703	.7545	.2829
8		2.7035	3.2895	.5601	.5487	.6036	.2801
9	3.1893	2.8182	3.2217	.4668	.5041	.4527	.2801
10	2.9492	2.7681	3.0312	.3772		.3734	.3734
11	.4715		.4668	.3944			
12	.5093	.2829		3.1379	3.2322	3.2985	2.8837
13	.5093	.5281	.4904		3.4736	3.1878	3.2769
14	.5658	.3734	.4904		3.6702	3.315	
15	.5658	.5281	.5415		3.7685	3.3425	3.2114
16	.5281	.4668	.5228		3.7029	3.199	3.315
17	.5281	.4854	.5041		3.7129	3.3913	3.2769
18	.5658	.3734	.5041	3.3436	3.4408	3.5269	3.5803
19	.6036	.2829	.6348	3.1893	3.1824		3.3097
20	.7922	.2829	.7468	.5144	.679		.8488
21	.7167	.1886	.7468	.6001	.7545	.2829	.8865
22	.679	.0934	.7167	.6516	.7167	.1886	.7468
23	.6413		.6908	.5487	.6602		.7095
24	.3944	.6224	.0943	.679	.5144	.5847	.2801
Max	3.6008	3.4736	3.3029	3.3436	3.7685	3.5269	3.5803
Min	.3944	.0934	.0943	.3772	.4115	.1886	.2801
Avg	1.4604	1.5236	1.5279	1.0411	1.6570	1.5309	1.3456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 204 / LOKMANGAL EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18
HR	Load (MW)	Load (MW)
1	.0857	.0943
2	.0857	.0943
3	.0857	.0943
4	.0857	.0943
5	.0857	.0943
6	.0857	.0943
7	.0857	.0943
18	.0943	
19	.0943	
20	.0943	
21	.0943	
22	.0943	
23	.0943	
24	.0857	.0943
Max	.0943	.0943
Min	.0857	.0943
Avg	.0894	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 205 / 11 KV AMBEDKAR NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3206	.0934	1.3927	1.2346	1.2407	.9945
2	.0857	.3361	.168	1.3927	1.2346	1.2742	.9907
3	.3429	.3734	.1509	1.5083	1.3032	1.2929	1.1469
4	.3429	.3395	.1132	1.4752	1.3375	1.326	1.2717
5	.3429	.3361	.168	1.5604	1.3717	1.326	1.2597
6	.4115	.3772	.1867	1.491	1.4918	1.4083	1.3565
7	.3086	.3584	.0943	1.5083	1.5775	1.4255	1.4089
8		.3395	.1886	1.4746	1.5432	1.4419	1.4074
9	.2572	.3018	.2801	1.4419	1.5497	1.4255	1.3757
10	.2263	.1886	.168	1.5775	1.5089	1.4582	1.2125
11	.0943	.1886	.1307	.1372	.1509	.0934	.168
12	1.6907	1.6244	1.6385	.12	.2263	.1509	.1867
13	1.7695	1.757	1.6549		.1886	.1886	.2427
14	1.6244	1.8652	1.7804		.1886	.1867	
15	1.3757	1.8991	1.8378		.1886	.2829	.2427
16	1.5565	1.8564	1.7465		.1886	.2801	.2241
17	1.6712	1.8233	1.6385		.1886	.1886	.1886
18	1.7204	1.6956	1.4582	.1715	.1886	.1886	.3547
19	1.704	1.6409	1.6057	.2229	.2263		.2801
20	.3395	.0934	.1307	.1715	.2263	.2427	.2054
21	.3395	.0857	.1494	.12	.1886		.1886
22	.3772	.0943	.1494	.12	.1509	.1886	.168
23	.415		.132	.1029	.1132		.132
24	.3944	.3772	.0943	.0943	.1029	.0754	.0934
Max	1.7695	1.8991	1.8378	1.5775	1.5775	1.4582	1.4089
Min	.0857	.0857	.0934	.0943	.1029	.0754	.0934
Avg	.7710	.7944	.6566	.8465	.6946	.7469	.6565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 207 / 11 KV TELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5034	1.5746	1.6598	.8215	.6859	.7167	.8402
2	2.4863	1.8233	1.7204	.811	.6859	.7468	.8865
3	2.5377	2.1628	2.4863	.811	.703	.7167	.8775
4	2.6749	2.4863	2.7349	.7922	.7202	.7468	.8676
5	2.7778	2.8182	3.0521	.8775	.7888	.8299	
6	3.1893	2.9492	3.2819	.9335	.7202	.8676	.8962
7		2.9984	.1017	.7655	.6859	.8865	.8589
8		3.2442	2.774	.7282	.6687	.8299	.7167
9	3.2236	3.3425	3.2217		.6348	.7733	.5975
10	3.152	3.083	3.1295	.2743			.4108
11	.5093	.3734	.5847	.1715			
12	.5093	.5658	.5658	3.0864	3.315	3.1493	3.1459
13	.5281	.5144	.6535		3.3979	3.2217	3.7304
14	.5658	.7095	.7468		3.4408	3.3573	
15	.5658	.7167	.7545		3.4736	3.3913	3.4408
16	.6036	.6348	.7468		3.408	3.4476	4.161
17	.6602	.6348	.7468		3.3482	3.2217	4.3343
18		.7167	.8029		3.315	3.5269	3.7685
19	.679	.7167		3.0178	3.2487		3.4408
20	.7733	.7468	.9431	.3429	.5847	.7545	.7468
21	.679	.5658	.8962	.6516	.6413	.8962	.9431
22	.5658	.5601	.8029	.7202	.679	.7888	1.0185
23	.4527		.8299	.7202	.7167		.9896
24	.3086	.3584	.2987	.8215	.6859	.7545	.8589
Max	3.2236	3.3425	3.2819	3.0864	3.4736	3.5269	4.3343
Min	.3086	.3584	.1017	.1715	.5847	.7167	.4108
Avg	1.4260	1.4911	1.4580	.9616	1.6613	1.6812	1.7872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 201 / 11 KV FATATEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.9431	1.2003	.9335	1.0374	1.0374	.9335
2	1.286	1.1145	1.286	.9335	1.0374	1.0374	.9335
3	1.3717	1.286	1.3565	.9335	1.1317	1.1317	1.0269
4	1.4251	1.4575	1.5261	1.0269	1.1203	1.1317	1.1203
5	1.5746	1.6289	1.6956	1.2136	1.2136	1.226	1.2012
6	1.8023	1.8861	2.0576	1.307			1.2012
7	2.1052	1.3717	2.2291				.9335
8	1.2003	2.0576	2.2291				.9335
9	1.7147	2.0576	2.2291			.8488	.7468
10	1.8861	1.8861	2.2291	.9431	.9145	.9335	.7468
11	.6602	.6602	.7545	.8488	.7468	.8402	.6602
12	.8488	.7545	.7545	2.2291	2.13	1.989	1.8861
13	.8488	.7545	.7545	2.2291	1.9662	1.989	1.9719
14	.8488	.7545	.7545	2.2291	1.9662	1.9662	1.0288
15	.7545	.7545	.7545	2.2291	1.9662	1.989	1.8861
16	.7545	.7545	.7545	2.2291	1.9433	1.989	2.0119
17	.7545	.7545	.7545	2.2291	2.1052	2.0119	2.3148
18	.8488	.7545	.8402	2.2291	2.0805	1.989	2.0576
19	1.1317	1.0374	.9335	2.2291	2.13	1.6575	1.8652
20	1.1317	1.226	1.2136	1.307	1.307	1.307	1.2136
21	1.226	1.226	1.2136	1.307	1.3203	1.307	1.2936
22	1.1317	1.226	1.2136	1.307	1.226	1.307	1.1088
23	1.0374	.9431	1.0374	1.1203	1.1317	1.1203	1.1203
24	.9431	.9431	.9431	.9431	1.0374	1.0374	.9335
Max	2.1052	2.0576	2.2291	2.2291	2.13	2.0119	2.3148
Min	.6602	.6602	.7545	.8488	.7468	.8402	.6602
Avg	1.1870	1.1764	1.2798	1.5218	1.4756	1.4212	1.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 202 / 11 KV AUJ HIPPALE YATNAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.6535	.7716	.9431	.8288	.9431
2	.6602	.6535	.6468	1.0288	1.0288	.9221	1.0288
3	.7545	.7468	.7392	1.1145	1.0288	1.0174	1.0288
4	.9335	.7468	.8316	1.2003	1.1145	1.1022	1.1145
5	1.2136	.9431	.9335	1.286	1.2003	1.286	1.2003
6	1.2136	1.226	1.226	1.3717	1.3717	1.5432	1.3717
7	1.0269	1.1317	.7545	1.3717	1.6575		1.7147
8	.8402	.9431	.7545	1.3717	1.6575	1.1145	2.0119
9	.8402	.7545	.7545	1.286	1.4746	1.3717	1.5432
10	.7545	.8488	.7545	1.2003	1.2431	1.1869	.9431
11	.6602	.7545	.7545	.8488	.5601	.5601	.6602
12	1.4575	1.3717	1.5432	.7545	.6535	.7468	.7545
13	1.4575	1.3717	1.5432	.7545	.7468	.7468	.6602
14	1.4575	1.3717	1.5432	.7545	.6535	.6535	.6602
15	1.6289	1.3717	1.5432	.7545	.6535	.7468	.6602
16	1.6289	1.4575	1.5432	.7545	.7468	.7468	.6602
17	1.6289	1.4575	1.5432	.7545	.7468	.6535	.6602
18	1.5604	1.6289	1.3717	.7468	.7545	.6535	.7468
19	1.3717	1.4575	1.5089	.9335	.9431	.8402	.9335
20	1.1317	1.1317	.9335	1.0269	1.0374	1.0269	1.1203
21	1.0374	1.0374	.8402	1.0269	.9431	.9335	1.1203
22	.8488	.9431	.7468	.9335	1.094	.8402	.8402
23	.7545	.7545	.7545	.8402	.8488	.7468	.7468
24	.6602	.6602	.6535	.6602	.8488	.7545	.7545
Max	1.6289	1.6289	1.5432	1.3717	1.6575	1.5432	2.0119
Min	.6602	.6535	.6468	.6602	.5601	.5601	.6602
Avg	1.0909	1.0593	1.0363	.9811	.9979	.9140	.9949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 203 / 11 KV HOTAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6535	.6535	.7716	.7716	.6859	.7716
2	.6602	.6535	.6535	.9431	.8573	.763	.7716
3	.6602	.7468	.7392	1.0288	.9431	.8383	.9431
4	.7545	.7545	.7392	1.1145	1.0288	.9221	.9431
5	.8402	.8488	.8402	1.2003	1.1145	1.0059	1.0288
6	.9335	1.0374	1.0374	1.2003	1.286	1.1603	1.1145
7	.8488	.017	.7545	1.1145	1.286	1.2574	1.3717
8	.9431	.8488	.7545	1.2003	1.2003	1.2717	1.286
9	.8488	.8488	.7545	1.1145	1.2003	1.1736	1.2003
10	.7545	.6602	.7545	1.1145	1.065	1.0174	1.1145
11	.6602	.6602	.7545	.6602		.6602	.6535
12	1.2003	1.2003	1.2003	.5658	.6602	.6602	.6535
13	1.2003	1.2003	1.2003	.5658	.6602	.5658	.6602
14	1.2003	1.2003	1.2003	.5658	.6602	.5658	.6602
15	1.2003	1.2003	1.2003	.5658	.5658	.5658	.6602
16	1.2003	1.286	1.2003	.5658	.5658	.6602	.6602
17	1.2003	1.286	1.2003	.6602	.6602	.6535	.6602
18	1.1145	1.1145	1.1145	.6602	.6602	.6602	.6602
19	1.0288	1.1269	1.0898	.8488	.7545	.7545	.9431
20	.9431	.8402	.9431	.9431	.8488	.9431	1.0374
21	.0171	.7545	.9431	.8488	.7545	.9431	.9431
22		.7545	.7545	.7545	.7545	.8488	.7468
23	.6535	.6535	.6602	.6602	.6535	.7545	.6602
24	.6602	.6535	.6535	.6602	.6602	.6535	.6602
Max	1.2003	1.286	1.2003	1.2003	1.286	1.2717	1.3717
Min	.0171	.017	.6535	.5658	.5658	.5658	.6535
Avg	.8775	.8750	.9082	.8470	.8527	.8327	.8668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 204 / 11 KV BHARAT GARMENT
EXPRESS Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0381				
7		.0381				
8		.0381				
9			.0381			
10	.0381	.0381	.0381	.0381		
11	.0381	.0381	.0381	.0381		
12	.0381	.0381	.0381	.0381		
13	.0381	.0381	.0381	.0381		
14	.0381	.0381	.0381	.0381		
15	.0381	.0381	.0381	.0381		
16	.0381	.0381	.0381	.0381		.0381
17	.0381	.0381	.0381	.0381		.0381
18		.0381	.0381	.0381		
19		.0381	.0381	.0381		
20		.0381	.0381	.0381		
21			.0381	.0381		
22			.0381	.0381		
23			.0381	.0381		
24	.0381				.0381	
Max	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0381	.0381	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 201 / 11 KV YELEGAON(KANDALGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2801	.2829	.3353	1.0059	1.3413	1.4251
2	.1867	.2801	.2829	.503	1.3413	1.3413	1.5927
3	.1867	.2801	.2829	.6706	1.5089	1.6766	1.5927
4	.1867	.2801	.2829	.8383	1.8442	1.6766	1.5927
5	.1867	.3734	.2829	1.0059	2.1795	2.0119	1.7604
6	.3734	.4668	.2829	1.0059	2.3472	2.1795	1.7604
7	.3734	.4668	.4715	1.0059	2.2634	2.5149	2.2634
8	.1867	.4668	.3772	.503	2.1795	2.5149	2.2634
9		.2801	.2829	.503	2.0119	2.3472	
10	.1867		.2801	.503	2.1795		
11	.1867		.1867		.2801		.1867
12	2.3472		2.0119		.2801		.1867
13	2.3472		2.3472		.2801		.1867
14			2.5149		.2801		.1867
15	2.5149		2.3472		.2801		.1867
16	2.5149		2.3472		.2801		.3734
17	2.6825		2.5149		.2801		.3734
18	2.6825		2.1795		.2801		.1867
19	2.1795		2.1795		.4668		.3734
20	.4668		.3734		.4668		.3734
21	.4668		.3734		.3734		.4668
22	.3734		.3734		.2801		.3734
23	.2801		.3734		.2801		.1867
24	.3734	.2801	.2829	.3734	.2829	.2801	.2801
Max	2.6825	.4668	2.5149	1.0059	2.3472	2.5149	2.2634
Min	.1867	.2801	.1867	.3353	.2801	.2801	.1867
Avg	.9759	.3454	.9798	.6588	.9688	1.7884	.8260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 202 / 11 KV BASAVNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.6706	.8383	.2801	.2829	.3734	
2	.503	1.0059	1.0059	.1867	.2829	.3734	
3	.6706	1.0059	1.1736	.1867	.2829	.3734	
4	1.0059	1.3413	1.3413	.1867	.2829	.3734	
5	1.3413	1.3413	1.5089	.1867	.2829	.3734	
6	1.5089	1.5089	1.5927	.3734	.2829	.4668	
7	1.6766	1.5089	1.5927	.4668	.2829	.4668	
8	1.3413	1.6766	1.5927	.4668	.2829	.3734	
9		1.6766	1.5927	.3734	.2829	.3734	
10	1.3413		1.5089		.2801		
11	.2801		.4668		.2801		.3734
12	.3734		.3734		1.4251		1.1736
13	.3734		.3734		1.5089		1.3413
14	.3734		.3734		1.5089		1.3413
15	.3734		.3734		1.5089		1.3413
16	.3734		.3734		1.5927		1.3413
17	.3734		.3734		1.5927		1.3413
18	.3734		.3734		1.5927		1.3413
19	.4668		.4668		1.5089		.3353
20	.4668		.4668		.4668		.3734
21	.4668		.4668		.4668		.3734
22	.3734		.3734		.3734		.3734
23	.3734		.1867		.3734		.3734
24	.3353	.3734	.3772	.2801	.2829	.3734	
Max	1.6766	1.6766	1.5927	.4668	1.5927	.4668	1.3413
Min	.2801	.3734	.1867	.1867	.2801	.3734	.3353
Avg	.6638	1.2109	.7986	.2987	.7212	.3921	.8787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 203 / 11 KV WANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.6706	.6706	.1867	.1886	.1867	
2	.8383	.6706	.8383	.0934	.1886	.1867	
3	.8383	1.0059	1.0059	.0934	.1886	.1867	
4	1.1736	1.3413	1.1736	.0934	.1886	.1867	
5	1.3413	1.3413	1.1736	.1867	.1886	.2801	
6	1.4754	1.5089	1.4251	.2801	.1886	.3734	
7	1.6766	1.5089	1.4251	.3734	.1886	.3734	
8	1.4754	1.6766	1.3413	.2801	.1886	.3734	
9		1.3413	1.3413	.2801	.1886	.2801	
10	1.1736		1.5089	.2801	.1867		
11	.1867		.3734		.1867		.2801
12	.1867		.2801		1.5089		1.0898
13	.1867		.2801		1.6766		1.3413
14			.2801		1.6766		1.1736
15	.2801		.2801		1.6766		1.1736
16	.2801				1.6766		1.3413
17	.2801				1.6766		1.3413
18	.2801		.2801		1.6766		
19	.2801		.3734		1.5089		
20	.2801		.2801		.2801		.2801
21	.2801		.2801		.2801		.2801
22	.2801		.2801		.2801		.1867
23	.2801		.1867		.1867		.1867
24	.1867	.1867	.1886	.1867	.1886	.1867	
Max	1.6766	1.6766	1.5089	.3734	1.6766	.3734	1.3413
Min	.1867	.1867	.1867	.0934	.1867	.1867	.1867
Avg	.6294	1.1252	.6939	.2122	.6818	.2614	.7886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 205 / 11 KV MANDRUP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.6706	.8383	.5601	.5658	.7468	
2	.503	.6706	.8383	.4668	.5658	.7468	
3	.7545	.6706	1.0059	.4668	.5658	.7468	
4	.7545	.8383	1.0059	.4668	.5658	.7468	
5	.8383	.8383	1.0059	.4668	.8488	.9335	
6	1.0059	1.0898	1.0898	.5601	.8488	.9335	
7	1.0898	1.0898	1.0898	.5601	.7545		
8	1.1736	.9221	1.0898	.5601	.7545		
9		1.0059	1.0898	.4668	.6602	.8402	
10	.9221		1.0898	.7468	.6535		
11	.6535		.5601		.6535		.5601
12	.6535		.4668		.8383		1.0059
13	.6535		.4668		1.0059		.8383
14			.5601		1.0059		.8383
15	.7468		.5601		1.0898		1.0059
16	.7468		.5601		1.0898		1.0059
17	.7468		.5601		1.0898		1.0898
18	.7468		.7468		1.0898		1.0059
19	.9335		.8402		1.0059		.9335
20	.9335		.9335		.9335		.8402
21	.9335		.7468		.9335		.7468
22	.7468		.7468		.7468		.7468
23	.7468		.5601		.7468		.7468
24	.7468	.7468	.6602	.5601	.7545	.7468	
Max	1.1736	1.0898	1.0898	.7468	1.0898	.9335	1.0898
Min	.503	.6706	.4668	.4668	.5658	.7468	.5601
Avg	.7970	.8543	.7963	.5347	.8236	.8052	.8742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 206 / 11 KV KARKAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4715	.503	1.1736	1.0898
2	.3734	.3772	.6706	1.3413	1.3413
3	.3734	.3772	.8383	1.5089	1.3413
4	.3734	.3772	1.3413	1.5089	1.3413
5	.3734	.3772	1.6766	1.5927	1.3413
6	.3734	.3772	1.9784	1.8442	1.6766
7	.4668	.4715	2.1795	1.8442	1.8442
8	.4668	.4715	1.6766	1.8442	1.8442
9		.3772	1.5089	1.8442	.1844
10		.3734			1.8442
11		.4525			.3734
12		1.8442			.3734
13		1.8442			.3734
14		2.0119			.1867
15		1.8442			.1867
16		2.0119			.3734
17		1.6766			.3734
18		1.6766			.3734
19		1.5089			.3734
20		.4668			.5601
21		.4668			.5601
22		.4668			.3734
23		.4668			.3734
24	.5601	.4715	.4668	.3772	.3734
Max	.5601	2.0119	2.1795	1.8442	1.8442
Min	.3734	.3734	.4668	.3772	.1844
Avg	.4253	.8859	1.284	1.4879	.7948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 201 / 11 KV AUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	1.086	.4525	2.3148	2.6235	2.572	2.7435
2	.8145	1.086	.4525	2.3148	2.6578	2.572	2.7435
3	.8145	1.086	.4525	2.3148	2.6578	2.572	2.7435
4	.8145	1.086	.4525	2.4006	2.6578	2.572	2.7435
5	.8145	1.086	.4525	2.4006	2.7435	2.6578	2.7435
6	.8145	1.1222	.6335	2.4006	2.8292	2.8807	2.915
7	.8145	1.1765	.543	2.6578	3.3436	2.7435	
8	.905	1.086	.543	2.7092	3.2407	2.7435	3.0864
9		.9955	.543	2.4006	3.2407	2.7778	
10		.905		2.915	3.0864	2.8292	
11				.2715	.543	.3429	
12		2.572		.3258	.543	.5144	
13		2.7092		.5973	.724	.5144	
14		2.7435		.6154	.724	.5144	
15		3.0007		.6335	.724	.5144	
16		2.572		.7059	.724		
17		2.3663		.7059	.6335	.6001	
18		2.3148			.6335	.6859	
19		.6173		.5249	.6335	.6859	
20		.4525		.7059	.6335	.6859	
21		.4525		.7059	.6335	.6001	
22		.4525		.543	.6335	.5144	
23		.4525		.4344	.543	.3429	
24	1.0317	1.086	.4525	.905	.2715	.543	.2572
Max	1.0317	3.0007	.6335	2.915	3.3436	2.8807	3.0864
Min	.8145	.4525	.4525	.2715	.2715	.3429	.2572
Avg	.8487	1.4133	.4978	1.4132	1.5699	1.4774	2.4970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 202 / 11 KV TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5973	.6335	2.7435	1.9033	2.2291	2.7435
2	.5792	.543	.6335	2.7435	1.9719	2.2291	2.7435
3	.5792	.543	.6335	2.8292	1.9719	2.2291	2.7435
4	.6878	.6335	.6335	2.8292	1.9719	2.2291	2.7435
5	.8688	.6878	.724	2.915	2.0576	2.4006	2.915
6	.9774	1.7194	.9593	3.0007	2.1434	2.5892	3.0864
7	.905	.905	.8688	3.0864	.8573	3.3093	
8	.724	.7059	.724	3.2236	.8573	3.3608	3.1893
9			.6878	3.275	.8573	3.3608	
10		.6516		3.2579		3.2065	
11		.3801		.4344	.362	.3944	
12		3.2579			.4344	.3772	
13		3.3093		.5249	.4344	.3772	
14		3.3608		.6335	.4344	.4458	
15				.6335	.4344	.4458	
16		3.2579		.6335	.4344	.4458	
17		2.5034		.6154	.543	.4458	
18		3.2236		.6154	.6154		
19		2.9321		.6516	.6878	.6859	
20		.8869		.7783	.7602	.823	
21		.8145		.7421	.724	.8059	
22		.724		.6878	.6878	.6859	
23		.6878		.5792	.6154	.6001	
24	.5792	.6335	.6335	.543	.5249	.5792	.4287
Max	.9774	3.3608	.9593	3.275	2.1434	3.3608	3.1893
Min	.5792	.3801	.6335	.4344	.362	.3772	.4287
Avg	.7200	1.4981	.7131	1.6512	.9689	1.4894	2.5742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 203 / 11 KV NANDANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4575	.3258	.2715	.3258	.3086
2	1.286		1.4575	.3439	.2715	.3258	.3086
3	1.286		1.4575	.3439	.2715	.3258	.3086
4	1.3717		1.4575	.362	.3258	.3258	.3086
5	1.4575		1.5432	.362	.3801	.362	.3429
6	1.5947		1.7661	.4163	.4525	.4706	.3944
7	1.8176		1.8519	.362	.3439	.3258	
8	1.7661		1.8519	.2896	.2896	.2715	.2915
9		.3982	1.8861	.3077	.2715	.2229	
10		1.3717		.2896	.2715	.2058	
11		.2715		.2715	.2715	.2915	
12		.2715		1.7833	1.8347	1.8004	
13		.2715		1.8347	1.8519	1.7661	
14		.3077		1.8004	1.869	1.7661	
15		.2896		1.8004	1.869	1.7661	
16		.2715		1.8004	1.869	1.8004	
17		.2715		1.8176	1.9204	1.8347	
18		.2715		1.8347	1.8347	1.9719	
19		.2896		1.8004	1.8519	1.5432	
20		.5068		.4706	.3772	.4115	
21		.543		.4344	.3801	.4115	
22		.5249		.3801	.362	.4115	
23		.5068		.3258	.3258	.3429	
24	.2715		.4525	.543	.2896	.3258	.3086
Max	1.8176	1.3717	1.8861	1.8347	1.9204	1.9719	.3944
Min	.2715	.2715	.4525	.2715	.2715	.2058	.2915
Avg	1.3564	.4245	1.5182	.8458	.8357	.8169	.3215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV KUDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1434	2.3663	2.2291	.543	.5068	.543	.5144
2	2.1434	2.3148	2.2291	.543	.543	.543	.5144
3	2.2291	2.3148	2.2291	.5068	.543	.543	.5144
4	2.4006	2.3148	2.2291	.5068	.6335	.543	.5144
5	2.572	2.4006	2.3148	.543	.7421	.724	.6516
6	2.6235	2.4863	2.4863	.543	.8145	.9231	.8059
7	2.7606	2.5034	2.4691	.543	.5973	.7059	
8	2.7263	2.3663	2.4006	.4344	.5068	.6154	.463
9		2.6235	2.4006	.3982	.5068	.4115	
10		2.6749		.3439		.4287	
11		.4344		.3439	.362	.3944	
12		.4344		2.572	2.7263	2.5377	
13		.3982		2.3148	2.8292	2.6749	
14		.4706		2.452	2.915	2.6749	
15		.4525		2.4863	2.9664	2.692	
16		.4344		2.4863	3.0007	2.692	
17				2.452	2.7778	2.6235	
18		.5068		2.2977	2.9321	2.4006	
19		.6335		2.1776	2.7949	2.4006	
20		.7421		.7421	.6878	.6859	
21		.7602		.6878	.6516	.6859	
22		.724		.6154	.6335	.6001	
23		.6516		.543	.6154	.5144	
24	.543	.6697	.5792	.5611	.4887	.543	.5144
Max	2.7606	2.6749	2.4863	2.572	3.0007	2.692	.8059
Min	.543	.3982	.5792	.3439	.362	.3944	.463
Avg	2.2380	1.3773	2.1567	1.1515	1.3815	1.2542	.5616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV RTO CHECK POST
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0362	.0362	.0362	.0343	.0362	.0343
2	.0343	.0362	.0362	.0905	.0343	.0362	.0343
3	.0343	.0362	.0362	.0362	.0343	.0362	.0343
4	.0343	.0362	.0362	.0362	.0343	.0362	.0343
5	.0171	.0362	.0362	.0362	.0343	.0362	.0343
6	.0171	.0362	.0181	.0181	.0171	.0181	.0171
7		.0181	.0181	.0181	.0171	.0181	
8	.0171	.0181	.0181	.0181	.0171	.0181	.0171
9		.0181	.0181	.0181	.0171	.0171	
10		.0181		.0171	.0181	.0171	
11		.0181		.0171	.0181	.0171	
12		.0181		.0171	.0181	.0171	
13		.0181		.0171	.0181	.0171	
14		.0181		.0171	.0181	.0171	
15		.0181		.0171	.0181	.0171	
16		.0181		.0171	.0181	.0171	
17		.0181		.0171	.0181	.0171	
18		.0181		.0171	.0181	.0171	
19		.0362		.0171	.0362	.0171	
20		.0362		.0343	.0362	.0343	
21		.0362		.0343	.0362	.0343	
22		.0362		.0343	.0362	.0343	
23		.0362		.0343	.0362	.0343	
24	.0171	.0362	.0362	.0362	.0343	.0362	.0343
Max	.0343	.0362	.0362	.0905	.0362	.0362	.0343
Min	.0171	.0181	.0181	.0171	.0171	.0171	.0171
Avg	.0257	.0272	.0290	.0272	.0258	.0249	.03

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / 11 KV TANDULWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6859	.6706	.2286	.2286	.2286	.2286
2	.6173	.6859	.6783	.2286	.3048	.2286	.3048
3	.6173	.6859	.8139	.3048	.4572	.2286	.381
4	.6859	.6859	.8139	.381	.5335	.4572	.5335
5	.823	.6859	.9389	.5335	.6478	.6859	.6097
6	.9602	.6859	1.0059	.7621	.6859	.8383	.6859
7	.9602	1.0669	1.0608				
8	.8916	1.2193	1.0608				
9	.8916	1.0974	.8619	.6097	.5335	.6097	.6097
10	.9602	.8619	.7545	.381	.381	.4572	.5335
11	.381	.3048	.2286	.2286	.3048	.3048	.381
12	.381	.2286	.2286	.8619	.9945	.8619	.8916
13	.2286	.2286	.2286	.7956	.9945	.8619	.9602
14	.2286	.2286	.2286	.9282	.9945	.8619	.8916
15	.2286	.1524	.2286	.663	.7956	.663	.9602
16	.2286	.2286	.2286	.7293	.7956	.8619	.9602
17	.2286	.1524	.3048	.5967	.8619	.7956	.9602
18	.3048	.2286	.3048	.7293	.9945	.5304	1.0288
19	.4572	.381	.4572	.7293	.9945	.7956	.823
20	.6859	.6097	.6859	.7621	.6097	.5335	.6859
21	.7621	.6097	.5335	.5335	.5335	.4572	.6859
22	.4572	.3048	.381	.381	.4572	.3048	.4572
23	.381	.2286	.3048	.3048	.381	.2286	.3048
24	.3048	.4191	.2286	.3048	.3048	.3048	.2286
Max	.9602	1.2193	1.0608	.9282	.9945	.8619	1.0288
Min	.2286	.1524	.2286	.2286	.2286	.2286	.2286
Avg	.5534	.5278	.5513	.5444	.6268	.55	.6412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / 11 KV MUSTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.5432	1.5912	.8764	.8573	.8573	.9145
2	1.7147	1.5432	1.6575	.8383	.9145	.8573	.9526
3	1.8519	1.5432	1.7238	.8383	.9526	.8573	.9526
4	2.0576	1.8861	1.8564	.9145	.9526	.9526	.9907
5	2.1948	1.8861	2.0553	1.0669	1.1812	1.2384	1.0669
6	2.4177	2.2805	2.42	1.2574	1.3146	1.3527	1.105
7	2.7435	3.0521	2.6189				
8	2.6749	3.0864	2.42				
9	2.6063	2.915	2.3868	.8573	.8954	.9717	.9145
10	2.2119	2.5029	2.1948	.7049	.8573	.8954	.7811
11	.5716	.6097	.724	.6668	.7621	.6097	.743
12	.5906		.6859	2.6235	2.6235	2.3205	2.1776
13	.6478	.6478	.6478	2.5377	2.572	2.3868	2.2634
14	.6478	.6097	.6287	2.3663	2.3148	2.42	
15	.5716	.6097	.6287	2.0405		2.2874	2.3491
16	.6097	.6097	.6859	2.3491		2.2211	2.6749
17	.6668	.5716	.7621	2.2119	2.4006	2.2874	1.4575
18	.6859	.6097		2.0062	2.4006	2.2874	2.4006
19	.9717	.9526		2.1091	2.2291	2.1879	2.2805
20	1.1812	1.1431	1.1622	1.1622	1.1622	1.2765	
21	1.1431	1.105	1.1431	1.086	1.1431	1.105	1.1431
22	1.0288	.9907	1.0669	.9526	.9907	1.0288	1.1812
23	.9145	.9145	.9907	.9145	.8954	.9145	.9717
24	.8573	.8573	.8764	.9145	.8573	.8954	.8764
Max	2.7435	3.0864	2.6189	2.6235	2.6235	2.42	2.6749
Min	.5716	.5716	.6287	.6668	.7621	.6097	.743
Avg	1.3837	1.4117	1.4058	1.4225	1.4138	1.4641	1.4098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5242	1.2955	1.5775	1.3375	1.3717	1.5912
2	1.3717	1.5242	1.2955	1.6461	1.3375	1.3717	1.7238
3	1.448	1.5242	1.3717	1.7147	1.3717	1.4403	1.7238
4	1.5242	1.5242	1.5242	1.8519	1.5089	1.5089	1.8564
5	1.6766	1.7528	1.6004	1.9204	1.7147	1.9204	2.0553
6	1.7528	1.9052	1.6766	2.0576	2.1948	2.1948	2.1879
7				2.1948	2.6063	2.7435	2.2542
8				2.4006	2.5377	2.8807	2.7846
9	1.5242	1.5242	1.3717	2.1262	2.1262	2.572	2.4531
10	1.2955	1.3717	1.2193	1.8519	1.989	2.1216	2.2634
11	1.2193	1.1431	1.1431	.9907	1.1431	.9907	1.0669
12	2.0576	2.3205	2.4691	.9907	1.0669	.9907	.9907
13	2.4006	2.3205	2.4006	.9145	.9907	.9145	1.0669
14	2.2634	2.1216	2.1948	.8383	.9145	.9145	
15	2.332	2.1879	2.0576	.9145	.9145	.9145	1.1431
16	2.332	2.1216	2.0576	.9145	.9145	.9907	1.0669
17	2.6063	2.4531	2.4691	1.0669		.9907	1.1431
18	2.5377	2.4531	2.5377	1.1431		1.0669	1.2955
19	2.2634	1.9669	2.1948	1.448	1.5242	1.3717	1.448
20	1.7528	1.6766	1.6766	1.829	1.9052	1.6004	1.829
21	1.7528	1.6766	1.6004	1.6766	1.9052	1.5242	1.9052
22	1.6766	1.6004	1.5242	1.6004	1.6004	1.2955	1.5242
23	1.5242	1.448	1.448	1.3717	1.6004	1.3717	1.3717
24	1.448	1.448	1.2955	1.3717	1.3717	1.5242	1.2955
Max	2.6063	2.4531	2.5377	2.4006	2.6063	2.8807	2.7846
Min	1.2193	1.1431	1.1431	.8383	.9145	.9145	.9907
Avg	1.8276	1.7995	1.7465	1.5172	1.5716	1.5244	1.6539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 204 / 11 KV NEW KHANAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.9907	.8619	.1143	.0953	.0953	.1334
2	.9602	.9602	.8619	.1143	.0953	.0953	.1334
3	1.0288	1.0288	.9282	.1143	.1143	.0953	.1524
4	1.166	1.0288	1.0608	.1524	.1524	.1143	.1524
5	1.3032	1.2003	1.2929	.1905	.1905	.2286	.1905
6	1.5432	1.5432	1.5912	.1905	.1905	.2286	.1905
7	1.8519	1.8176	1.7238				
8	1.7833	1.9547	1.4586				
9	1.5432	1.8519	1.4586	.1524	.1524	.1905	.1905
10	1.4403	1.5912	1.3717	.1524	.1524		.1143
11	.1143	.0953	.1143	.1143	.1143	.1143	.0762
12	.0762	.0953	.0953	1.5089	1.7147	1.2266	1.3032
13		.0953	.0953	1.5432	1.5432	1.4586	1.3375
14		.0953	.0953	1.5432	1.5432	1.6575	1.2003
15	.0762	.0953	.1143	.9259	1.7147	1.5912	1.3032
16	.1143	.0953	.1143	1.5089	1.5432	1.6575	1.749
17	.0762	.0953	.1524	1.5089	1.5432	1.4586	1.3375
18	.1143	.1143	.1524	1.5775	1.3717	1.3592	.9945
19	.1715	.1715	.1905	1.5089	1.0288	1.326	1.2003
20	.1905	.2096	.2286	.2286	.2286	.2096	.1905
21	.1905	.1715	.2286	.1524	.1905	.1715	.1905
22	.1524	.1524	.1905	.1524	.1524	.1524	.1905
23	.1143	.1334	.1524	.1524	.1524	.1334	.1524
24	.1143	.0762	.1334	.1143	.1143	.1143	.1334
Max	1.8519	1.9547	1.7238	1.5775	1.7147	1.6575	1.749
Min	.0762	.0762	.0953	.1143	.0953	.0953	.0762
Avg	.6857	.6526	.6111	.6237	.6408	.6514	.5735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 205 / 11 KV SANGDARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0479	.9907	.8916	.9945	1.0288	.8478
2	1.0098	1.1431	.9907	.9602	1.0288	1.0288	.8619
3	1.0669	1.1812	1.0669	.9602	1.0288	1.0974	.8288
4	1.1431	1.1812	1.2955	1.0974	1.0631	1.2003	1.1271
5	1.2955	1.3336	1.2955	1.2346	1.0974	1.3717	1.2597
6	1.4098	1.4861	1.3336	1.3032	1.4403	1.4575	1.326
7				1.3375	1.7147	1.6289	1.7901
8				1.3032	1.2689	1.286	1.7575
9	1.0479	.9145		1.2003	1.166	1.0288	1.3923
10	1.0669	.8192	.9907	1.3336	1.166	1.0774	1.2003
11	.8383	.6859	.724	.5716	.6668	.4191	.7049
12	1.4232	1.326	1.3375	.6287	.6668	.4572	.6478
13	1.4403	1.2597	1.3203	.6097	.5906	.4954	.6097
14	1.3375	1.1271	1.2346	.6097	.6287	.6097	.6859
15	1.2689	1.0608	1.2174	.6097	.6287	.5716	.6668
16	1.4403	.7625	1.286	.5716	.6287	.6097	.6287
17	1.4746	1.2843	1.3203	.5716	.5906	.6097	.6478
18	1.5604	1.3923	1.3717	.5335	.6668	.6859	.6668
19	1.3717	1.2929	1.2174	1.105	1.0479	.9907	1.1241
20	1.3336	1.1271	1.4098	1.3527	1.2384	1.2765	1.2955
21	1.2955	1.2955	1.2765	1.2193	1.2384	1.2574	1.3336
22	1.2384	1.2574	1.2384	1.2193	1.2193	1.2193	1.3717
23	1.1812	1.105	1.1431	1.1431	1.2003	1.1812	1.1241
24	1.0669	1.0479	.9907	1.086	1.086	1.086	1.105
Max	1.5604	1.4861	1.4098	1.3527	1.7147	1.6289	1.7901
Min	.8383	.6859	.724	.5335	.5906	.4191	.6097
Avg	1.2427	1.1423	1.1929	.9772	1.0028	.9865	1.0418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 206 / 11 KV PINJARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2743	.1143	.0762	.0762	.1524
2	.2401	.2743	.2743	.1143	.0762	.0762	.1524
3	.2743	.2743	.3429	.1524	.0953	.0762	.1524
4	.2743	.3086	.3429	.1524	.0953	.1143	.1524
5	.3429	.381	.4801	.1905	.0953	.1905	.1524
6	.4115	.3429	.5487	.1905	.0953	.2286	.1905
7	.4801	.3772	.6173				
8	.5487	.4115	.5487				
9	.5144	.4115	.4801	.1905	.0762	.1905	.1143
10	.4801	.3429	.5144	.1524	.0762	.1143	.0762
11	.1524	.0381	.1143	.0762	.0762	.0381	.0762
12	.1524	.0953	.1143	.5335	.4287	.5144	.6478
13	.1524	.0762	.0762	.5144		.5487	.5716
14	.1524	.0762	.0762	.5487	.6859	.4801	.4801
15	.1524	.1143	.0762	.4458	.6859	.5487	.5487
16	.0762	.1143	.1143	.4801	.6859	.583	.5716
17	.0762	.1143	.1143	.5144	.6859	.5487	.5487
18	.0762	.0762	.1143	.5487	.6859	.5144	.5487
19	.1524	.1524	.1524	.4801	.6859	.583	.4458
20	.1905	.1524	.1905	.1905	.2286	.1905	.1524
21	.1905	.1524	.1905	.1524		.0762	.1905
22	.1524	.1524	.1524	.1334	.1524	.0762	.2286
23	.1524	.1143	.1143	.0953	.1524	.1143	
24	.1143	.0762	.1143	.1143	.0762	.1143	.1524
Max	.5487	.4115	.6173	.5487	.6859	.583	.6478
Min	.0762	.0381	.0762	.0762	.0762	.0381	.0762
Avg	.2396	.2043	.2558	.2766	.2958	.2726	.3003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 201 / 11 KV ULEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566			
2	.0377			
3	.0377			
4	.0377			
5	.0566			
6	.0943			
7	.12			
8	.0943			
17		.8886	.788	.0566
18		.8215	.6393	.0754
19		.7209	.57	.0948
20		.1509	.0943	.1509
21		.1521	.132	.132
22		.132	.1132	.1132
23		.1132	.0943	.1132
24	.0566		.1132	.0754
Max	.12	.8886	.788	.1509
Min	.0377	.1132	.0943	.0566
Avg	.0657	.4256	.3180	.1014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 204 / 11 KV MANCHUKONDA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754						
2	.0754						
3	.0566						
4	.0566						
5	.0754						
6	.0943						
7	.0948						
8	.0943						
17		.0943	.0754	.0754	.0943	.0754	.0857
18		.0758	.0754	.0943	.0754		.0754
19		.0566	.0754	.0754	.0566		.0857
20		.0566	.0754	.0754	.0754	.0758	.0754
21		.0566	.0754	.0754	.0754	.0754	.0566
22		.0566	.0754	.0754	.0754	.0754	.0566
23		.0566	.0754	.0754	.0754	.0754	.0754
24	.0754		.0566	.0686	.0754	.0754	.0754
Max	.0948	.0943	.0754	.0943	.0943	.0758	.0857
Min	.0566	.0566	.0566	.0686	.0566	.0754	.0566
Avg	.0776	.0647	.0731	.0769	.0754	.0755	.0733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 205 / 11 KV KHADAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3181						
2	1.4083						
3	1.5089						
4	1.7604						
5	2.0622						
6	2.2995						
7	2.3807						
8	2.4143						
17		.2829	.415	2.6825	2.6993	2.431	2.2466
18		.3961	.415	.8886	2.7496		2.4981
19		.5281	.4527	2.4143	2.8166		2.5849
20		.5658	.4715	.6413	.6036	.6602	.415
21		.4904	.547	.5658	.4973	.6036	.5658
22		.4715	.5093	.4458	.4904	.5093	.5093
23		.415	.4338	.4338	.3772	.4347	.4715
24	.3395		.3772	.3961	.3772		.3429
Max	2.4143	.5658	.547	2.6825	2.8166	2.431	2.5849
Min	.3395	.2829	.3772	.3961	.3772	.4347	.3429
Avg	1.7213	.4500	.4527	1.0585	1.3264	.9278	1.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 206 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132						
2	.132						
3	.1132						
4	.132						
5	.1509						
6	.1886						
7	.2075						
8	.3206						
17		1.226	.5487	.415	.7545	.7167	.679
18		.7922	.4715	.3018	.679		.5847
19		.2452	.2829	.2075	.1698		.2263
20		.2452	.2641	.1886	.1698	.1886	.2452
21		.2452	.2829	.2263	.1698	.132	.2643
22		.2454	.2452	.2263	.1698	.1509	.1509
23		.2452	.1698	.2075	.1698	.1698	.1698
24	.1509		.2452	.132	.2075	.1698	.1543
Max	.3206	1.226	.5487	.415	.7545	.7167	.679
Min	.1132	.2452	.1698	.132	.1698	.132	.1509
Avg	.1697	.4635	.3138	.2381	.3113	.2546	.3093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 207 / 11 KV ULE GAONTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658						
2	.5281						
3	.5093						
4	.5658						
5	.8865						
6	.9808						
7	1.094						
8	.811						
17		1.7269	1.3748	.5281	.5658	1.0562	.5658
18		1.6785	1.358	.6224	.6173		.6224
19		1.3916	.4115	.9242	.9619		.9054
20		.9431	.6979	.9808	.9808		.8488
21		.811	.8676	.9431	.8299		.8676
22		.7545	.7922	.8488	.6687	.9054	.7733
23		.679	.7167	.7167	.6602	.7922	.7167
24	.6224		.5487	.132	.6224	.6036	.6413
Max	1.094	1.7269	1.3748	.9808	.9808	1.0562	.9054
Min	.5093	.679	.4115	.132	.5658	.6036	.5658
Avg	.7293	1.1407	.8459	.7120	.7384	.8394	.7427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 208 / 11 KV EKRUKH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.1132				
2	.0568						
3	.0566						
4	.0566						
5	.0754						
6	.132						
7	.1886						
8	.1509						
17		.6036	.6371	.0943	.0943	.1509	.132
18		.5868	.6036	.1132	.1132		.1509
19		.57	.57	.1698	.1698		.132
20		.2263	.5093	.1886	.2075	.2075	.1698
21		.2075	.2075	.1886	.1886	.1886	.1886
22		.1886	.1698	.1372	.1698	.1886	.1698
23		.1509	.132	.133	.1509	.1698	.1509
24	.132		.132	.132	.1132	.132	.132
Max	.1886	.6036	.6371	.1886	.2075	.2075	.1886
Min	.0566	.1509	.1132	.0943	.0943	.132	.132
Avg	.1069	.3620	.3416	.1446	.1509	.1729	.1533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 209 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3077						
2	1.4083						
3	1.643						
4	1.7604						
5	2.4646						
6	2.6016						
7	2.6322						
8	2.3304						
9	2.2298						
17		.415	.415	2.4646	2.5484	2.146	2.5513
18		.4904	.5281	2.3975	2.4813		2.4646
19		.6602	.6036	2.3304	2.2131		2.1795
20		.7922	.5658	.7922	.679	.2075	.415
21		.7167	.5847	.7167	.6224	.415	.5658
22		.6622	.5658	.6432	.547	.4715	.5847
23		.5316	.547	.547	.4904	.5093	.5281
24	.4715		.547	.5093	.4904	.4527	.5281
Max	2.6322	.7922	.6036	2.4646	2.5484	2.146	2.5513
Min	.4715	.415	.415	.5093	.4904	.2075	.415
Avg	1.8850	.6098	.5446	1.3001	1.259	.7003	1.2271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 201 / 11 KV DINDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.2858	.5068	.5401	.5335	.5316
2	.2477	.2858	.3048	.5647	.5937	.5487	.4877
3	.2477	.2858	.3429	.6081	.6562	.5487	.5182
4	.2858	.3239	.4001	.6805	.7499	.5944	.5182
5	.381	.362	.4382	.6984	.7655	.8192	.5335
6	.4763	.4763	.4954	.7164	.8124	.945	.7926
7	.4191	.4382	.4001	1.0442	.9065	1.0517	1.0974
8	.362	.381	.4191	.9362	.9362	.7468	1.0822
9	.362	.3429	.4001	.7095	.535	.823	1.0212
10	.3429	.3239	.381	.5681	.6401	.7068	.9145
11	.2286	.2286	.3048	.2286	.1905	.2286	.2477
12	.7827	1.0117	.7164	.2286	.1715	.2096	.2477
13	.7526	.8745	.7049	.2286	.1905	.2286	.2667
14	.631	.7621	.6859	.1905	.2096	.2096	.2477
15	.6815	.7773	.743	.2286	.2286	.2477	
16	.7956	.8078	.7922	.2286	.2286	.2667	.2477
17	.8655	.9297	.8802	.2286	.2286	.2286	.2667
18	1.0517	.9602	.9145	.1715	.2286	.2096	.2858
19	.9755	.7316	.8716	.2477	.4382	.381	.4191
20	.4572	.4191	.4954	.4763	.4954	.5144	.4954
21	.4191	.4001	.4191	.4572	.4572	.4191	.4191
22	.362	.381	.381	.362	.362	.3429	.362
23	.3239	.3239	.3239	.3048	.3239	.2858	.3048
24	.2667	.2858	.2667	.2858	.2667		.2667
Max	1.0517	1.0117	.9145	1.0442	.9362	1.0517	1.0974
Min	.2286	.2286	.2667	.1715	.1715	.2096	.2477
Avg	.4986	.5166	.5153	.4542	.4648	.4822	.5032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 202 / 11 KV ACHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5647	.5792	.7202	.381	.4191	.4191	.4382
2	.5944	.5944	.6706	.4191	.4191	.4191	.4572
3	.5868	.6249	.7316	.4191	.4338	.4191	.4954
4	.7042	.6554	.7926	.4954	.4481	.4382	.5144
5	.743	.823	.8535	.5716	.4904	.4572	.5525
6	1.0002	1.0822	.9602	.6478	.7545	.4763	.724
7	1.0717	1.3108	1.2955	.5906	.6097	.5716	.7049
8		1.2803	1.4327	.4572	.4763	.4382	.4954
9	1.1584	1.1584	1.2651	.381	.4191	.4001	.4191
10	1.0551	1.0212	1.0437	.362	.381	.381	
11	.2751	.362	.362	.3048	.3429	.362	.4191
12	.362	.3429	.381	1.0997	1.1888	.8916	1.1431
13	.4001	.3429	.362	.9659	1.1584	1.0105	1.0822
14	.381	.362	.381	1.2574	1.1126	.9957	1.3336
15	.5335	.362	.381	1.0084	1.0669	1.0105	1.0364
16	.4001	.362	.381	1.0536	1.1736	1.0385	1.0517
17	.362	.3429	.381	1.174	1.2498	1.0997	1.1279
18	.362	.3429	.362	.8916	1.2186	1.1584	1.1279
19	.6097	.5144	.5525	.9808	1.0802	1.0059	1.0494
20	.6859	.5716	.6668	.6859	.7049	.743	.724
21	.6097	.6478	.6478	.6287	.6097		.6097
22	.4763	.6097	.4954	.5144	.5525	.4954	.5525
23	.4001	.5144	.4191	.4191	.4763	.4572	.4382
24	.362	.362	.381	.381	.4001	.4191	.4191
Max	1.1584	1.3108	1.4327	1.2574	1.2498	1.1584	1.3336
Min	.2751	.3429	.362	.3048	.3429	.362	.4191
Avg	.5956	.6321	.6633	.6704	.7161	.6568	.7355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 203 / 11 KV L.CHINCHOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.5487	.6001	.4763	.4572	.4954	.4954
2	.4938	.5487	.5487	.4954	.4954	.4954	.5144
3	.4999	.7049	.5792	.5716	.4954	.4954	.5335
4	.5937	.743	.6249	.6097	.5716	.5525	.5335
5	.7099	.8192	.6859	.6859	.6478	.5906	.5525
6	.8333	.823	.7773	.8002	.7621	.7621	.7621
7	1.0031	1.0364	1.0822	.743	.7621	.6859	.7621
8		1.0669	1.0212	.5716	.5906	.6287	.6097
9	.9389	1.2574	.823	.4572	.4572	.4763	.5335
10	.7819	.9297	.8855	.4191	.4382	.362	.3963
11	.3429		.362	.3429	.381	.362	.4191
12	.362	.4382	.3429	.8253	.9145	.7371	
13	.362	.4001	.381	.7649	.884	.7169	.7621
14	.381	.381	.381	.7093	.8383	.7133	.7773
15	.381	.381	.381	.7232	.7773	.6935	.6706
16	.381	.362	.381	.7649	.8535	.8067	
17	.4572	.362	.381	.8177		.8459	.7316
18	.4572	.4001	.4763	.6935	.9998	.7202	.86
19		.5716	.5906	.724	.8025	.7068	.7788
20	.743	.6097	.7621	.7811	.743	.7811	.7811
21		.6859	.6859	.6478	.743	.724	.724
22	.5144	.6478	.6287	.6097	.6478	.5906	.6287
23		.5716	.5144	.5144	.5716	.5335	.5335
24	.4763	.4763	.4763	.4763	.4572	.5144	.4763
Max	1.0031	1.2574	1.0822	.8253	.9998	.8459	.86
Min	.3429	.362	.3429	.3429	.381	.362	.3963
Avg	.5600	.6420	.5988	.6344	.6648	.6246	.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 204 / 11 KV SOOT MIL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0098	.9717	.3155	.3155	.503	.5487
2	.8764	.9907	.9717	.3189	.3121	.503	.5182
3	.8764	.9907	.8573	.3366	.3366	.503	.5182
4	.8764	1.0098	.8573	.3544	.3856	.5182	.5335
5	1.105	1.086	.9717	.3856	.4207	.5639	.5487
6	1.1431	1.2193	1.2003	.4031	.5434	.7773	.6859
7	1.105	1.1812	1.1431	.5658	.5548	.7926	.8993
8	.9526	.9717	1.0098	.4557	.5434	.7773	.8383
9	.9717	.9907	.9717	.4733	.4115	.6706	.7316
10	.5906	.9526	.9145	.631	.7202	.6718	.6554
11	.6478	.9907	1.0288	.8764	.9335	.9717	1.0288
12	.7888	.7545	.8478	.9717	1.0669	1.0098	
13	.4365	.6706	.8478	1.0288	1.0288	1.0098	
14	.4115	.7011	.7545	1.0288	1.0098	.9717	
15	.4748	.6859	.7209	1.0288	.9717	1.086	1.3336
16	.4917	.6554	.7377	1.0669	1.086	1.0479	1.3336
17	.4973	.6554	.7209	.9907	1.0288	.9526	1.1241
18	.503	.5944	.4527	1.0098	.6097	.9717	1.0669
19	.8002	.5487	.5624	1.1431	.8383	1.2765	1.1431
20	1.467	.9907	.8954	1.1431	.9526	1.4861	1.1431
21	1.3527	1.3908	.8764	.9526	.4954	1.4289	1.1431
22	1.2955	1.2765	.8573	.8573	1.2574	1.3527	1.1431
23	1.1622	1.105	.7049	.7621	1.1431	1.1622	1.1431
24	1.0098	1.0288	1.0098	.724	.3048	1.0288	1.105
Max	1.467	1.3908	1.2003	1.1431	1.2574	1.4861	1.3336
Min	.4115	.5487	.4527	.3155	.3048	.503	.5182
Avg	.8646	.9355	.8703	.7427	.7196	.9182	.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 205 / 11 KV HANJAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.2606	.2591	.3201	.3086
2	.0572	.0572	.0572	.2972	.3018	.4191	.3048
3	.0572	.0572	.0572	.2896	.3292	.3353	.3201
4	.0762	.0572	.0572	.3001	.3567	.3506	.3506
5	.0953	.0762	.0762	.3144	.3704	.381	.3658
6	.1143	.1143	.1143	.3384	.4033	.4268	.4572
7	.0572	.0572	.0762	.3978	.4868	.4877	.6401
8	.0381	.0572	.0572	.4527	.5647	.6478	.6249
9	.0381	.0572	.0381	.4633	.5647	.4572	.5944
10	.0572	.0572	.0572	.4075	.5944	.3418	.724
11	.0381	.0381	.0381	.0381	.0381	.0762	.0572
12	.5498	.5182	.4858	.0572	.0381	.0572	.0572
13	.5268	.4877	.4464	.0572	.0381	.0572	.0572
14	.439	.4572	.4268	.0381	.0381	.0572	.0572
15	.4344	.442	.4329	.0381	.0572	.0572	.0572
16	.4054	.4268	.4934	.0381	.0572	.0572	.0572
17	.3923	.4725	.4729	.0381	.0381	.0572	.0572
18	.4725	.4877	.5007	.0572	.0381	.0572	.0572
19	.4725	.4725	.4054	.0762	.0762	.0953	.0953
20	.1143	.0953	.0953	.0953	.0953	.1143	.1143
21	.0762	.0953	.0953	.0953	.0762	.0953	.0953
22	.0762	.0762	.0762	.0762	.0762	.0762	.0953
23	.0762	.0762	.0572	.0762	.0572	.0762	.0572
24	.0572	.0572	.0572	.0572	.0572	.5144	.0572
Max	.5498	.5182	.5007	.4633	.5944	.6478	.724
Min	.0381	.0381	.0381	.0381	.0381	.0572	.0572
Avg	.1991	.2021	.1972	.1817	.2089	.2340	.2359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 206 / Kardehalli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001		.4458	.2477	.2477	.2286	.2667
2	.3948	.442	.463	.2667	.2667	.2286	.2477
3	.3894	.5525	.4268	.4954	.2858	.2286	.2667
4	.4172	.4572	.442	.3048	.2858	.2477	.2858
5	.4938	.503	.4725	.3048	.3429	.2858	.3239
6	.6405	.6401	.5335	.3429	.362	.381	.3429
7	.9646	.8383	.884	.2477	.2667	.1905	.3429
8	.9686	.945	.884	.2477	.1905	.2096	.2667
9	.7926	.7011	.7468	.2096	.2096	.1905	.2286
10	.6226	.6401	.7042	.1715	.2286	.2286	.2286
11	.2477	.2286	.2286	.1715	.1715	.2286	.2096
12	.1189	.2667	.2286	.679	.7468	.587	.5944
13	.2477	.2477	.2096	.6321	.6859	.587	.743
14	.2667	.2286	.2096	.5201	.6249	.5357	.5792
15	.2477	.2286	.2096	.5796	.5487	.5575	.6097
16	.2477	.2286	.2096	.6859	.5335	.639	.6249
17	.2477	.2096	.2096	.8179	.7773	.6687	
18	.2286	.2096	.2286	.6241	.7655	.7011	.7095
19	.3429	.2667	.3239	.5569	.5735	.5792	.5573
20	.381	.3239	.381		.362	.4001	.381
21	.362	.362	.381	.4001	.362	.362	.381
22	.3239	.3429	.3048	.3239	.3239	.3239	.3429
23	.2858	.3048	.2858	.2858	.2858	.2858	.2858
24	.2477	.4268	.2477	.2477	.2477	.2477	.2667
Max	.9686	.945	.884	.8179	.7773	.7011	.743
Min	.1189	.2096	.2096	.1715	.1715	.1905	.2096
Avg	.4117	.4171	.4025	.4071	.4040	.3801	.3950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 207 / 11 KV MUDHOLKAR CRUSHER NON SHEDDABLE EXPRESS HV FEEDERS
 EXP. Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.2401		.2743		.2315	.2286	.2286
8	.2561			.216	.25	.2134	.2134
9			.2439	.2343		.1981	.2286
10	.1875		.2056	.2267	.2134		.2591
11	.0772			.2591	.2134		.2286
12		.1981	.16		.1524	.2429	
13	.2006	.1829			.1981	.0972	.0762
14					.1524		.0914
15	.1543	.2134					
16	.1852		.192		.2286	.0972	.1219
17	.2401		.176		.1829	.1619	.1829
18			.362		.2812	.2134	
Max	.2561	.2134	.362	.2591	.2812	.2429	.2591
Min	.0772	.1829	.16	.216	.1524	.0972	.0762
Avg	.1926	.1981	.2305	.2340	.2104	.1816	.1812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 201 / 11 KV HATTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3203			
2			.8488	1.3203			1.4575
3				1.3203			
4			.8488	1.5089			1.4575
5				1.5089			
6			1.094	2.2634			2.2291
7				2.452			
8	.7545	1.1317	.679	2.2634		1.5089	1.7147
9	1.5089				2.2939		2.1434
10	.5658	.5658			2.2291	2.1434	2.0576
11	.5658						2.452
12	1.7147	2.0576				.5658	.5658
13	2.0576						.5658
14	2.2539	2.0233					
15	2.2291						.7545
16	2.2291	1.9719	2.2634		.5658	.6413	
17	2.2291		2.2634				
18	2.2291	1.8004	2.0748			.679	
19	2.0576		1.8861				
20	1.1317	1.0562	.9431			1.0374	
21	.9431		.9431				
22	.9431	.9431	.9431			.8488	
23	.8488	.8865	.9431		.9431	.8488	
24		.8488	.8488	.9431		.6602	.7545
Max	2.2539	2.0576	2.2634	2.452	2.2939	2.1434	2.452
Min	.5658	.5658	.679	.9431	.5658	.5658	.5658
Avg	1.5164	1.3285	1.2753	1.6556	1.5080	.9926	1.4684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 202 / 11KV WADAKBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0943			
2				.0943			
3				.0943			
4				.0943			
5				.0943			
6				.0943			
7	.1886			.0943			
8			.0943	.0943		.1886	.1132
10		.0943					
12		1.0288					
14		1.0288					
16		1.0288	.0943		.0943	.0943	
17			.0943				
18		1.0288	.0943				
19			.0943				
20		.12	.0943				
21			.0943				
22			.0943				
23		.0943	.0943		.0943	.0943	
24	.0943		.0943	.0943		.0943	.0943
Max	.1886	1.0288	.0943	.0943	.0943	.1886	.1132
Min	.0943	.0943	.0943	.0943	.0943	.0943	.0943
Avg	.1415	.6320	.0943	.0943	.0943	.1179	.1038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 203 / 11 KV RAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3395			
2			1.2003	.3395			
3				.3395			
4				.3395			
5				.3395			
6				.3772			
7	2.2405			.3772			
8			1.7147	.3772		.3772	.3772
10		2.0576					
12		.2641				2.0576	
13						2.572	
14		.2263					
16		.2263	.2829		.1886	.2641	
17			.2829				
18		.2641	.2829				
19			.3772				
20		.415	.415				
21			.3772				
22			.3395				
23		.2641	.3395		.2829	.3206	
24	.2641		.2641	.3395		.2829	.2829
Max	2.2405	2.0576	1.7147	.3772	.2829	2.572	.3772
Min	.2641	.2263	.2641	.3395	.1886	.2641	.2829
Avg	1.2523	.5311	.5342	.3521	.2358	.9791	.3301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 204 / 11 KV AURAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144		.0566			
2		.5144	.2926	.0566			.0566
3		.5144		.0566			
4		.5935	.2926	.0566			.0566
5		.5935		.0566			
6		.5935	.5487	.0566			.0566
7	.4656	.5935		.0566			
8	.5144	.5144	.5853	.0566	.0566	.0566	.0566
9	.5144				.0566		.0566
10	.5658	.5487			.0566	.0566	.0566
11	.0566				.0566		.0566
12	.0566	.0566			.4287	.3292	.5658
13	.0566						.5144
14	.0566	.0566				.4572	.5144
15	.0566						.5144
16	.0566	.0566	.0566		.5487	.5121	
17	.0566		.0566				
18	.0566	.0566	.0566			.5304	
19	.0566		.0566				
20	.0566	.0566	.0566			.0566	
21	.0566		.0566				
22	.0566	.0566	.0566			.0566	
23	.0566	.0566	.0566		.0566	.0566	
24	.0566	.5658	.0566	.0566		.0566	.0566
Max	.5658	.5935	.5853	.0566	.5487	.5304	.5658
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.1585	.3495	.1714	.0566	.1801	.2169	.2135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 205 / SINDHKHED AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	26-APR-18	27-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.0943	.0943
10				.0943	.0943
12	.1715	.0754			
13	.1886				
14	.1886	.0754			
15	.1886				
16	.1886	.0566	.0943		
17	.1886		.0566		
18		.0566			
19	.0943				
Max	.1886	.0754	.0943	.0943	.0943
Min	.0943	.0566	.0566	.0943	.0943
Avg	.1727	.066	.0755	.0943	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 206 / 11 KV MANGOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.9431			
2		.1886	.1886	.9431			.8573
3		.1886		.9431			
4		.1886	.1886	1.1317			.8573
5		.2829		1.226			
6		.2829	.4527	1.226			1.2003
7	.4527			1.226			
8	.3395	.2829	.2829	1.226	1.286	1.286	1.0288
9	.2829				1.2536		1.2003
10	.2829	.1886			1.2003	1.1145	1.2003
11	.2572				.0943		.0566
12	1.7147	2.0576			.0943	.0566	.0566
13	2.0348				.0943		.0566
14	2.1548	1.286					.0566
15	2.2291						.0566
16	2.2043	1.3375	1.4146			.0566	
17	2.2291		1.4146				
18	2.0576	1.3375	1.4146			.0566	
19	1.8861		1.3203				
20	.5281	.3772	.0566			.0566	
21	.3772		.0566				
22	.3772	.2263	.0566				
23	.2829	.2075	.0566		.0566	.0566	
24	.1886	.1886	.1886	.0566		.0566	.0566
Max	2.2291	2.0576	1.4146	1.226	1.286	1.286	1.2003
Min	.1886	.1886	.0566	.0566	.0566	.0566	.0566
Avg	1.1044	.5506	.5455	.9913	.5828	.3425	.5570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 207 / 11 KV WANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	24-APR-18	25-APR-18	26-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3772	
2			.3772	
3			.3772	
4			.4715	
5			.5658	
6			.7922	
7	.3772		.7545	
8			.7545	.5658
16		.3395		
17		.3395		
18		.3395		
19		.6602		
20		.7545		
21		.7545		
22		.4904		
23		.4527		
24	.2263		.3772	
Max	.3772	.7545	.7922	.5658
Min	.2263	.3395	.3772	.5658
Avg	.3018	.5164	.5386	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 201 / 11 KV GODUTAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.9335	.9335	.9431	.9431	.8962	.9335
2	.8402	.8962	.8215	.9054	.9054	.8589	.8589
3	.7842	.8589	.8215	.9054	.8676	.8215	.8589
4	.8029	.7842	.7842	.9054	.8676	.7842	.8215
5	.7842	.8215	.7468	.8676	.8676	.7468	.7842
6	.8029	.7842	.7468	.8676	.8299	.7468	.7468
7	.8029	.7468	.7468	.7922	.7545	.7842	.7468
8	.7282	.7842	.7468	.7167	.7167	.7842	.7468
9	.7842	.7842	.7468	.7545	.7167	.7468	.7468
10	.8215	.7468	.8029	.7468	.7545	.7842	.8589
11	.8589	.7468	.8029	.7842	.7468	.8215	.8402
12	.8962	.7842	.8029	.8029	.7842	.8215	.8029
13	.8589	.8215	.8215	.8029	.7842	.7842	.8402
14	.8215	.8215	.8029	.7842	.8215	.8215	.7842
15	.8215	.7842	.8029	.7468	.7468	.8215	.8029
16	.7922	.7468	.8402	.7842	.8215	.8215	.8589
17	.8215	.7468	.7842	.7842	.7842	.8589	.8589
18	.7842	.7842	.7655	.6722	.9709	.8589	.9709
19	1.1203	1.1203	1.0642	.9522	1.1203	1.1203	1.1389
20	1.3443	1.2323	1.2696	1.226	1.307	1.2323	1.2696
21	1.2696	1.307	1.3203	1.2071	1.2323	1.2696	1.2323
22	1.1949	1.2323	1.2449	1.2071	1.1949	1.2323	1.307
23	1.1203	1.1203		1.1694		1.1203	1.1763
24	1.0269	1.0082	1.0456	1.0185	1.0185	.9709	.9709
Max	1.3443	1.307	1.3203	1.226	1.307	1.2696	1.307
Min	.7282	.7468	.7468	.6722	.7167	.7468	.7468
Avg	.9036	.8915	.8811	.8894	.8938	.8962	.9149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 202 / 11 KV KUMBHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3018	.3395	.3395	.3361	.3361
2	.4668	.3361	.3018	.3395	.3395	.2987	.2987
3	.5228	.3361	.3018	.3395	.3395	.2987	.2987
4	.6535	.4481	.3018	.3772	.3772	.4481	.3361
5	.7095	.5601	.5281	.3772	.415	.5601	.5228
6	.7282	.5975	.679	.6036	.6413	.5975	.6348
7	.5975	.5601	.6036		.6036	.5228	.5975
8	.4481	.5228	.5281	.6036	.4904	.4481	.5228
9	.4108	.4481	.415	.415	.4527	.3734	.4108
10	.4108	.4108	.3921	.3734	.415	.3361	.3734
11	.3361	.3734	.3734	.4108	.3018	.3361	.3361
12	.3361	.3361	.3361	.4294	.3361	.3361	.3174
13	.2987	.2987	.2987	.3361	.2987	.3361	.1867
14	.3361	.2987	.2987	.3361	.2987	.2987	.3361
15	.3361	.2987	.2801	.3174	.2987	.2987	.2801
16	.3361	.2987	.2801	.3174	.2987	.2987	.3361
17	.3361	.2987	.3361	.2801	.2987	.2987	.3361
18	.3361		.3361	.3174	.4108	.3361	.4668
19	.4481	.5228	.4668	.4481	.5228	.4481	.4854
20	.5228	.5601	.5415	.5658	.5975	.5228	.4668
21	.5228	.5601	.5658	.5281	.5228	.5228	.4854
22	.4481	.4854	.4904	.4904	.4854	.4854	.4668
23	.3734	.4108	.3772	.3772	.3734	.4108	.4294
24	.3547	.3734	.3772	.3395	.3395	.3361	.3361
Max	.7282	.5975	.679	.6036	.6413	.5975	.6348
Min	.2987	.2987	.2801	.2801	.2987	.2987	.1867
Avg	.4434	.4221	.4046	.4027	.4082	.3952	.3999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 203 / 11KV MICROWAVE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.0549	.0514	.0686	.0526	.061
2	.0366	.0358	.0549	.0514	.0686	.0526	.0914
3	.0366	.0537	.0366	.0514	.0686	.0693	.1311
4	.0366	.0537	.0366	.0686	.0686	.0693	.1311
5	.0549	.0709	.0366	.0678	.0857	.1029	.1677
6	.0732	.0716	.0732	.1341	.1696	.1357	.2347
7	.0914	.0886	.0732	.2012	.218	.1696	.2515
8	.0914	.0709	.1097	.1677	.2012	.1907	.2401
9	.0549	.0526	.0732	.1174	.1677	.1753	.2058
10	.0537	.0514	.0549	.1174	.1677	.1402	.1928
11	.0532	.0514	.0549	.0366	.0537	.0366	.0549
12	.1265	.0983	.1928	.0366	.0358	.0366	.0549
13	.1326	.1296	.2103	.0366	.0366	.0366	.0549
14	.1326	.1457	.1753	.0366	.0366	.0549	.0549
15	.1187	.1475	.1578	.0366	.0366	.0366	.0549
16	.1326	.1311	.1494	.0366	.037	.0366	.0549
17	.1423	.1341	.1578	.0366		.0549	.0549
18	.1204	.1372	.1578	.0549	.0549	.0549	.0549
19	.1677	.1402	.1578	.0549	.0732	.0732	.0549
20	.0537	.0549	.0732	.0549	.0724	.0732	.0549
21	.0537	.0549	.0549	.0549	.0549	.0549	.0549
22	.0549	.0549	.0554	.0549	.0549	.0549	.0549
23	.0549	.0549	.0554	.0366	.0549	.0549	.0366
24	.0366	.0366	.0549	.0554	.037	.0362	.0549
Max	.1677	.1475	.2103	.2012	.218	.1907	.2515
Min	.0366	.0358	.0366	.0366	.0358	.0362	.0366
Avg	.0811	.0815	.0963	.0688	.0836	.0772	.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 204 / 11 KV LOKMANGAL MEDICAL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.0953	.1143	.0953	.0953	.0953
2	.1334	.1143	.0953	.1143	.0953	.0953	.0953
3	.1334	.0953	.0953	.0953	.0953	.0953	.0762
4	.1334	.0953	.0953	.0953	.0953	.0953	.0762
5	.1334	.0953	.0953	.0953	.0953	.0953	.0762
6	.1334	.0953	.0953	.0953	.0953	.1143	.0953
7	.1334	.0953	.0953	.0953	.0953	.1143	.0953
8	.1143	.1143	.1143	.0953	.1143	.0953	.0953
9	.1334	.1334	.1334	.1143	.1334	.1334	.1334
10	.1143	.1524	.1715	.1334	.1715	.1143	.1905
11	.1143	.1524	.1715	.1524	.1524	.1334	.1715
12	.1334	.1524	.1715	.1715	.1715	.1334	.1905
13	.1334	.1524	.1524	.1715	.1524	.1524	.1905
14	.1143	.1524	.1524	.1524	.1524	.1524	.1524
15	.1143	.1524	.1524	.1715	.1524	.1524	.1524
16	.1143	.1524	.1524	.1524	.1715	.1334	.1524
17	.1143	.1524	.1143	.1334	.1334	.1334	.1143
18	.1143	.1524	.1143	.1143	.1143	.1143	.1143
19	.1143	.1334	.1143	.1334	.1334	.1143	.1143
20	.1143	.1334	.1334	.1143	.1143	.1143	.1143
21	.1143	.1334	.1524	.1334	.1143	.1143	.1143
22	.1143	.1334	.1334	.1334	.1143	.1143	.1334
23	.1143	.1143	.1334	.1334	.1334	.1143	.1143
24	.1334	.1143	.1143	.1143	.0953	.0953	.0953
Max	.1334	.1524	.1715	.1715	.1715	.1524	.1905
Min	.1143	.0953	.0953	.0953	.0953	.0953	.0762
Avg	.1226	.1286	.1270	.1262	.1247	.1175	.1231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 205 / 11 KV MINAXI TAI SANE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.3292	.3856	.4024	.3658	.3658
2	.2926	.3292	.2926	.3506	.2286	.3292	.3292
3	.2926	.2926	.2926	.3506	.3658	.3292	.3292
4	.2926	.2926	.2926	.2804	.3292	.2926	.2926
5	.3292	.2561	.2926	.2804	.2926	.2926	.2926
6	.3109	.2561	.2926	.2804	.1829	.2561	.3292
7	.2926	.2561	.2926	.2804	.2926	.2561	.3292
8	.2926	.2561	.2926	.2561	.2561	.2926	.3292
9	.2743	.2926	.2926	.2195	.2926	.2926	.2926
10	.2987	.3292	.2743	.2195	.2195	.2926	.3109
11	.2987	.3292	.2743	.2195	.2561	.2926	.2743
12	.2987	.3292	.2561	.2195	.2926	.2926	.2743
13	.2926	.3292	.2743	.2561	.2561	.3292	.2926
14	.2987	.3292	.2743	.2378	.2561	.3292	.3109
15	.2561	.3292	.2926	.2743	.2561	.3292	.3292
16	.2926	.3292	.3475	.2743	.2926	.3292	.3292
17	.2926	.3292	.2743	.2561	.2561	.3292	.3292
18	.2926	.3658	.2561	.2561	.3292	.3658	.3292
19	.3658	.439	.3658	.3109	.3658	.439	.4024
20	.4024	.4755	.439	.439	.4755	.4755	.439
21	.439	.5121	.4572	.4572	.439	.5121	.4572
22	.4024	.4755	.4572	.4572	.4024	.5121	.4755
23	.4024	.4024	.4024	.4024	.3658	.4755	.4207
24	.3292	.3658	.3658	.3856	.4024	.3658	.3658
Max	.439	.5121	.4572	.4572	.4755	.5121	.4755
Min	.2561	.2561	.2561	.2195	.1829	.2561	.2743
Avg	.3180	.3429	.3201	.3062	.3128	.3490	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 206 / 11 KV KUMBHARI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.2149	.2195	.4908	.4908	.5609	.7011
2	.128	.1791	.2195	.5609	.5609	.5959	.7712
3	.1463	.1791	.2195	.5609	.5959	.6661	.8413
4	.1463	.2149	.2561	.5959	.695	.7362	.9816
5	.1463	.2507	.2561	.6661	.695	.9465	1.1568
6	.1463	.2507	.2926	.8764	.9114	1.0867	1.3672
7	.2926	.2865	.2926	1.262	1.2971	1.1919	1.4022
8		.2149	.2195	1.1919	1.2269		1.3672
9	.2378	.2149	.1829	1.0517	1.1568	1.1218	1.1919
10	.2195	.1753	.1829	.9465	1.0517	.9816	.964
11	.1829	.1753	.1463	.1463	.1791	.1463	.1463
12	1.1462	.8063	1.0341		.1433	.1463	.1463
13	.9114	.9114	1.0517	.1463	.1433	.1463	.128
14	.9816	.9465	1.0867	.1463	.1433	.1829	.1097
15	1.0166		1.0974	.1463		.1829	.1463
16	1.0517	1.0867	.1753	.128	.1433	.2195	.1646
17	1.0867	1.1919	1.0517	.1646	.1433	.1829	.1829
18	1.1919	1.0867	1.0517	.1646	.1791	.1829	.1829
19	1.0517	.9816	1.0166	.2195	.2149	.1829	.1829
20	.2149	.1829	.2378	.2561	.2507	.2195	.2195
21	.2149	.2195	.2195	.2195	.2149	.2195	.2195
22	.2149	.1829	.1829	.1829	.1791	.1829	.1646
23	.2149	.1829	.1829	.1829	.1448	.1829	.1463
24	.1829	.2149	.1829	.1829	.1829	.1433	.1753
Max	1.1919	1.1919	1.0974	1.262	1.2971	1.1919	1.4022
Min	.128	.1753	.1463	.128	.1433	.1433	.1097
Avg	.4893	.4500	.4608	.4561	.4758	.4525	.5442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 201 / 11 KV BANKALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2477	.3814	.3048	.3658	.5201
2	.2286	.2286	.2477	.4108	.3704	.4268	.5268
3	.2286	.2286	.2477	.4458	.4321	.4572	.5719
4	.2667	.3429	.2667	.5117	.5093	.5401	.6171
5	.3429	.4572	.4382	.5792	.6173	.7655	.6773
6	.4763	.5716	.5906	.7116	.7716	1.0155	.9145
7	.4572	.4382	.4191	.9297	.9374	.9962	1.0669
8	.3239	.3239	.3048	.9242	.9374	.9686	1.1126
9		.2477	.2286	.8535	1.0059	1.0753	.9633
10	.2286	.2096	.2286	.7922	.6859	.884	.9362
11		.1524	.1524	.1905		.1905	.1905
12	.9217		.7727	.1905	.2096	.2096	.2286
13	.9374	.8619	.7876	.1905	.2286	.1905	.2096
14	.7468	.8025	.7922	.1524	.2286	.2286	.1905
15	.6241	.5569	.6173	.1905	.2286	.2286	.1905
16	.5944	.5796	.7482	.1524	.2286	.2286	.1905
17	.4401	.8768	.6226	.1905	.2477	.2477	.2286
18	.5868	.8128	.8362	.1905	.3239	.3048	.2858
19	.5868	.7282	.8173	.3048	.362	.381	.3429
20	.381	.4001	.381	.4191	.4572	.4191	.4382
21	.3239	.3429	.381	.3429	.381	.381	.3239
22	.2477	.2858	.3239	.3048	.3239	.3239	.2477
23	.2286	.2667	.2667	.2667	.2096	.2667	.2286
24	.2477	.2286	.2477	.1905	.1905	.1524	.2477
Max	.9374	.8768	.8362	.9297	1.0059	1.0753	1.1126
Min	.2286	.1524	.1524	.1524	.1905	.1524	.1905
Avg	.4386	.4423	.4569	.4090	.4431	.4687	.4771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 202 / 11 KV AHERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6539	.7074	.3429	.3429	.4001	.381
2	.6401	.7133	.7468	.3048	.3429	.4001	.381
3	.7316	.8429	.7926	.3048	.2858	.381	.4382
4	.945	1.0517	.8333	.4763	.4001	.2858	.4954
5	1.0936	1.2191	1.065	.6668	.5525	.5716	.5525
6	1.1843	1.3748	1.2616	.7811	.6287	.6478	.7621
7	1.3603	1.406	1.3441	.6668	.7621	.6668	.6478
8	1.3599	1.3279	1.3441	.4763	.5716	.5906	.5335
9	1.2654	1.3435	1.2186	.381	.4001	.4382	.4001
10	1.1591	1.2498	1.1126	.3048	.3429	.3429	.381
11	.3239	.2858	.3048	.3048	.2858	.3048	.3429
12	.2858	.2858	.3048	1.25	1.2651	1.0155	1.0974
13	.2477	.3048	.3048	1.2346	1.2342	1.0648	1.2037
14	.3429	.2858	.3239	1.2498	1.1561	1.0974	1.1589
15	.3239	.3048	.3048	1.1574	1.0595	1.0974	1.0709
16	.3239	.2858	.3239	1.0957	1.1043	1.1126	1.1439
17	.3239	.3048	.3048	1.2346	1.0669	1.1279	1.2191
18	.3239	.3429	.3048	1.2963	1.0997	1.1279	1.174
19	.4763	.4763	.4954	1.1111	1.1574	1.1431	1.2492
20	.6097	.6478	.6287	.6287	.5716	.6668	.6097
21	.5335	.5335	.5525	.5716	.5144	.5144	.5525
22	.4382		.4763	.4572	.4763	.4763	.4572
23	.381	.3429	.4001	.4572	.4382	.4191	.381
24	.3239	.3239	.3239	.362	.4001	.4382	.4001
Max	1.3603	1.406	1.3441	1.2963	1.2651	1.1431	1.2492
Min	.2477	.2858	.3048	.3048	.2858	.2858	.3429
Avg	.6490	.6916	.6575	.7132	.6858	.6805	.7097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 201 / 11 KV AKOLE (M)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3904	1.3435	.4687	.125	.1094	.125	.1094
2	1.4373	1.531	.4687	.125	.1094	.1406	.1094
3	1.4685	1.4998	.5468	.1406	.1094	.1562	.1094
4	1.531	1.6872	.703	.1562	.1406	.1875	.1406
5	1.6404	1.781	.7811	.2031	.1875	.2187	.2343
6	1.7185	1.7966	.8592	.2968	.2343	.2656	.3125
7	1.8278	1.7497	1.6404	.1875	.2343	.2343	.2343
8	1.7654	1.7497	1.5623	.1562	.1875	.1875	.1875
9	.1562	.1562	.1562	1.7185	1.6872	1.7185	1.8122
10	.1406	.1562	.125	1.7497	1.8122	1.7341	1.7029
11	.0937	.1562	.1094	.7186	1.7966	.703	.8436
12	.0937	.1562	.1094	.8592	.9686	.828	.9217
13	.0937	.0781	.0937	.8592	.9998	.7343	.9374
14	.0781	.0781	.0937		1.0155	.7968	.953
15	.0781	.0781	.0937	.8749	1.0155	.8905	.9842
16	.1094	.0781	.0937	.9374	.9374	.8905	.9686
17	.0937	.0781	.1094	.0781	.0937	.0937	.1094
18		.0781	.1094	.0937	.0937	.1094	.1406
19	.1562	.2343	.1875	.1875	.2031	.1406	.125
20	.2031	.3125	.1875	.2187	.25	.1875	.2031
21	.2187	.1562	.1562	.2187	.2187	.1562	.1875
22	.125	.1562	.1406	.1094	.1875	.1094	.1562
23	.1094	.1562	.125	.1094	.1562	.125	.125
24	.0937	.1094	.1562	.1094	.1094	.125	.1094
Max	1.8278	1.7966	1.6404	1.7497	1.8122	1.7341	1.8122
Min	.0781	.0781	.0937	.0781	.0937	.0937	.1094
Avg	.6358	.6399	.3782	.4449	.5357	.4524	.4882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 202 / 11 KV KANDALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4641	.4001	.4801	.2721	.3841	.4481
2	.4801	.4481	.4001	.4801	.2721	.3841	.4481
3	.4801	.4481	.4001	.5121	.2721	.4161	.4481
4	.4801	.5121	.5601	.5441	.2881	.4481	.4801
5	.5601	.5761	.6401	.5761	.4001	.4801	.6081
6	.7682	.6081	.7202	.6401	.4961	.6874	.7842
7	.6241	.6882	.6401	.5601	.4001	.6562	.7202
8	.4801	.4801	.4801	.4374	.3521	.5624	.5921
9	2.3365	2.1605	2.4006	.3749	.2401	.4801	.5281
10	2.6086	2.3205	2.3903	.3841	.2561		.4481
11	2.5777	2.5606	2.5465	.3841	.3841	.4801	.4321
12	2.6246	2.4806	2.4996	.3841	.3521	.4321	.4321
13	2.6566	2.4806	2.4486	.3521	.3841	.3841	
14	2.4006	2.4806	2.4646		.4001	.4481	
15	2.1715	2.0005	2.4006	.3841	.4001	.4481	.4481
16	2.3045	2.0805	2.3365	.3841		.4321	.4321
17	.4001	.4001		2.0005	2.7686	2.5446	2.5606
18		.4001	.4801	2.1125	2.8807	2.5606	
19	.6401	.5601	.6722	1.6804	2.7206	1.6964	2.8647
20	.7202	.7202	.5601		2.5606	2.2405	2.4326
21	.6722	.6401	.5601		2.4806	2.2085	2.3685
22	.6081	.5601	.5121		2.2653	1.9364	2.2405
23	.4961	.4801	.5121		2.2405	1.8884	2.1765
24	.4961	.4481	.4801	.5121		2.1605	1.8404
Max	2.6566	2.5606	2.5465	2.1125	2.8807	2.5606	2.8647
Min	.4001	.4001	.4001	.3521	.2401	.3841	.4321
Avg	1.2203	1.1249	1.1959	.6938	1.0494	1.0591	1.1302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 203 / 11 KV GUNJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.1406	.1562	2.1052	1.5154	1.4842	1.3748
2	.1562	.1406	.1562	1.9997	1.6248	1.7185	1.4373
3	.1562	.144	.1562	1.9685	1.6404	1.7966	1.4842
4	.1562	.16	.2343	2.0153	1.7185	1.8747	1.6404
5	.2343	.1875	.2343	2.0309	1.7966	2.1091	1.7966
6	.3125	.2343	.3125	2.0309	1.9841	2.2653	2.1715
7	.3125	.25	.3125	2.3434	2.484	2.6246	2.5621
8	.2343	.25	.3125	2.2184	2.2809	2.5152	2.3746
9	.2187	.2343		.2187	.2187	.1875	.2187
10	.2187	.1562	.1875	.2031	.1875	.1718	.1718
11	.1562	.1562	.1562	.1875	.1562	.125	.1718
12	.1562	.1562	.1562	.1562	.1562	.1406	.128
13	.125	.1562	.1406	.125	.1406	.1562	.125
14	.1406	.1562	.125		.1094	.125	.125
15	.1406	.1562	.125	.125	.125	.1562	.1406
16	.1265	.1562	.125	.1406	.125	.1406	.1718
17	2.3122	2.734	2.7027	.125	.1406	.1406	
18	2.609	2.8902	2.7027	.1562	.1562	.1562	
19	2.5309	2.3434	2.5934	.2187	.1875	.1718	.2343
20	2.484	2.1872	2.4996	.25	.25	.2343	.25
21	2.3903	2.1872	2.4215	.25	.2031	.2343	.2343
22	2.234	1.8747	2.3434	.2187	.1562	.2187	.1875
23	2.1091	1.8747	2.1872	.1718	.1562	.1718	.1562
24	2.0622	2.0309	.9374	2.0622	.1562	.1562	.1406
Max	2.609	2.8902	2.7027	2.3434	2.484	2.6246	2.5621
Min	.125	.1406	.125	.125	.1094	.125	.125
Avg	.9055	.8732	.9251	.927	.7362	.7948	.7862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 201 / 11 KV KANBAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.3315	.3429	.2667	.2667	.2286	.2096
2	.1966	.3481	.3163	.2667	.2667	.1905	.2096
3	.208	.3481	.3311	.2667	.2667	.1905	.2096
4	.2429	.3563	.4214	.2858	.2667	.3429	.2096
5	.2561	.3887	.4816	.381	.3048	.3048	.2286
6	.3041	.6154	.6642	.4191	.3429	.3429	.2858
7	.421	.6562	.759	.4191	.362	.381	.2667
8	.5243	.7682	.7186	.3048		.2667	.2286
9	.5992	.6882	.6249	.2667	.2096	.1905	.1715
10	.5182	.6401	.6009	.1715	.1715	.1905	
11	.1905	.1905	.1143		.1524	.1524	.1524
12	.1524	.1143	.1143		.6325	.4534	.3637
13	.1715	.0953	.1905		.6009	.4961	.3953
14	.1715	.0953	.2096		.5535	.4961	.4374
15	.1715	.1524	.2096		.6009	.5281	.5182
16	.1715	.1524	.2096		.5693	.6401	.6642
17	.1905	.1905	.2096	.7865	.6642	.6722	.7287
18	.2286	.2286	.2096	.3479	.6325	.6241	.506
19	.2477	.2858	.2477	.6009	.5693	.6241	.5535
20	.3239	.3239		.3239	.381	.2667	.2858
21	.3429	.3429	.3239	.3048	.3429	.2667	.2667
22	.2858	.3048	.2858	.3429	.2667	.2286	.2477
23	.2858	.2858	.2667	.2858		.2286	
24	.2667	.2477	.2667	.2667	.2667	.2286	.1905
Max	.5992	.7682	.759	.7865	.6642	.6722	.7287
Min	.1524	.0953	.1143	.1715	.1524	.1524	.1524
Avg	.2778	.3396	.3530	.3504	.3950	.3556	.3332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 202 / 11 KV TILLEHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.4973	.4687	.2858	.2858	.2858	.3048
2	.2915	.4858	.3395		.2858	.2858	.3048
3	.3239	.4858	.3953	.2858	.2858	.2858	.3048
4	.3201	.5182	.4428	.2858	.2858	.2858	.3048
5	.3841	.6081	.6167	.381	.3429	.3429	.3239
6	.7362	.9442	.8488	.4572	.381	.4191	.4572
7	1.1012	1.0242	1.0701	.4191	.4191	.4572	.381
8	1.0883	1.1523	1.142	.2858		.3429	.3429
9	.9878	1.0242	1.0957	.2477	.2477	.2667	
10	.9717	.9717	1.1012	.2096	.2477	.2667	
11	.2477	.2286	.2286		.2286	.2096	.1905
12	.2286	.2096	.2286		1.0155	.7611	
13	.2286	.1905	.2286		.9374	.9069	
14	.2286	.2096	.2286		.9061	.8962	.8124
15	.2286	.1905	.2286			.9282	.8002
16	.2286		.2286		.8592	.9282	.9488
17	.2286	.2286	.2286	.9488	1.0155	1.0402	.9804
18	.2477	.2858	.2667	1.2763	1.0936	.9922	.852
19	.3429	.3429	.381	1.1256	.9686	.9762	.7907
20	.381	.381		.4572	.4572	.4572	.4572
21	.381	.4191	.4191	.4191	.4763	.4191	.4191
22	.3239	.3429	.3429	.3429	.381	.362	.381
23	.2667	.3048	.3048	.362		.3429	.3429
24	.2858	.2667	.2858	.2858	.2858	.2667	.3239
Max	1.1012	1.1523	1.142	1.2763	1.0936	1.0402	.9804
Min	.2286	.1905	.2286	.2096	.2286	.2096	.1905
Avg	.4309	.4918	.4835	.4750	.5432	.5302	.5012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 203 / 11 KV INGALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2858	.2401	.3429	.3239	
2	.2667	.2667	.2858	.2915	.2846	.3239	.3277
3	.2667	.2667	.2858	.2881	.3125	.4096	.3441
4	.2667	.2667	.2858	.3239	.3906	.4096	.3441
5	.3048	.2858	.2858	.3479	.6722	.4858	.4752
6	.381	.3429	.3429	.5121	.703	.6325	.7682
7	.381	.3048	.3429	.6958	.7274	.759	
8	.2858	.2286	.2667	.6882	.6642	.8592	
9	.2286	.2286	.2286	.6483	.7202	.7186	.759
10	.2286	.2286	.2286	.3963	.6562	.6249	
11	.1905	.2477	.1905		.2286	.1905	.2667
12	.6722	.6009	.5121		.2286	.1905	.2286
13	.6722	.6325	.7116		.1905	.1905	.2286
14	.6081	.5693	.7522		.1905	.1905	.1905
15	.5761	.6009	.7202		.1905	.1905	.1905
16	.5761	.6432	.6478		.2286	.2286	.1905
17	.5992	.6642	.6722	.2477	.2286	.2286	.2286
18	.5992	.7116	.6478	.2667	.1905	.2477	.2667
19	.5992	.6642	.5506	.4191	.2858	.362	.3239
20	.381	.3429		.4382	.4382	.4001	.362
21	.4001	.381	.4001	.381	.4191	.381	.4191
22	.3239	.381	.3239	.2096	.3429	.362	.381
23	.3048	.2858	.3048	.2858		.3239	.3429
24	.2667	.2667	.2858	.2858	.2858	.2858	.2858
Max	.6722	.7116	.7522	.6958	.7274	.8592	.7682
Min	.1905	.2286	.1905	.2096	.1905	.1905	.1905
Avg	.4019	.4033	.4156	.3870	.3879	.3883	.3462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 201 / 11 KV SANJWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					1.1431	
7				1.2346		
8	.1029	.1029	.1029	1.2346	1.1584	.0857
12				.0514	.0686	
13			1.1888			
16	1.2193	1.1584	1.0974		.0686	.0686
24	.0857	.1029	.0857	.0686	1.0059	.0857
Max	1.2193	1.1584	1.1888	1.2346	1.1584	.0857
Min	.0857	.1029	.0857	.0514	.0686	.0686
Avg	.4693	.4547	.6187	.6473	.6889	.08

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 202 / 11 KV BANDALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			1.0212			
8	.9145			.1543	.1543	.2058
11			.0914			
12				.945		
13					1.0059	
16	.1543	.1029	.1372		.9145	.1715
24	.823	.1029	.7926	.1029	.0686	.12
Max	.9145	.1029	1.0212	.945	1.0059	.2058
Min	.1543	.1029	.0914	.1029	.0686	.12
Avg	.6306	.1029	.5106	.4007	.5358	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 203 / 11 KV TEMPLE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.3201		.3772	
8	.3353	.2743		.3601	.2401	.3086
9				.3944		
11					.1715	
12			.2058			
16	.2401	.2572	.2229		.1981	.2743
24	.2286	.2401	.2134	.1715	.2058	.2572
Max	.3353	.2743	.3201	.3944	.3772	.3086
Min	.2286	.2401	.2058	.1715	.1715	.2572
Avg	.268	.2572	.2406	.3087	.2385	.2800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 201 / 11KV WATER WORKS SOLAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.922	1.8107	1.9418	1.9204	2.0452	1.9204	1.957
2	1.8107	1.7741	1.8296	1.8111	1.8461	1.7737	1.885
3	1.7741	1.701	1.7926	1.7741	1.7737	1.6832	1.7926
4	1.6461	1.6644	1.7372	1.7372	1.7737	1.6651	1.7556
5	1.6095	1.6289	1.6817	1.6632	1.8099	1.647	1.6651
6	1.6817	1.6461	1.6804	1.6057	1.7556	1.6297	1.6827
7	1.5339	1.475	1.531	1.4937	1.6289	1.448	1.5912
8	1.46	1.4415	1.5708	1.4784	1.4815	1.46	1.5708
9	1.4784	1.46	1.6263	1.4266	1.4118	1.4815	1.5729
10	1.5023	1.5364	1.6476	1.5364	1.5565	1.5746	1.647
11	1.5729	1.7193	1.9387	1.7556	1.828	1.7924	1.8099
12	1.6632	1.885	1.957		1.9204	1.922	1.9547
13	1.7556	1.9404	1.9753		1.8656	1.9404	1.9959
14	1.7372	1.9589	2.0328		1.9774	1.885	1.9387
15	1.7002	1.9959	2.0883		2.0513	1.9791	2.0485
16	1.7551	2.0698	2.0698	2.2497	2.1582	1.9404	2.0883
17	1.701	2.0144	2.1437	2.2131	2.1622		2.1845
18	1.7013	2.0485	2.0485	2.0633	2.1582		2.3101
19	2.0022	2.4629	2.4356	2.4356	2.4615		2.4025
20	1.8983	2.4072	2.4434	2.4097	2.4253		2.5503
21	1.9366	2.1719	2.2081	2.1849			2.3152
22	2.0119	2.1216	2.2131	2.1132	2.0668		2.2131
23	2.0302	2.1582	2.1399	2.1719	2.0668		2.1399
24	2.0328	1.8111	2.0538	2.0328		1.9774	2.0119
Max	2.0328	2.4629	2.4434	2.4356	2.4615	1.9791	2.5503
Min	1.46	1.4415	1.531	1.4266	1.4118	1.448	1.5708
Avg	1.7466	1.8710	1.9495	1.9038	1.9193	1.7482	1.9618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 202 / 11 KV DAV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	1.1222	1.0608	1.0517	1.1104	1.086	1.0974
2	1.0136	1.0974	.9955	1.0099		1.0679	1.086
3	.9593	1.0425	.9955	.9922		1.0317	1.0317
4	1.0454	.9955	.9955	.9492		1.0136	1.0534
5	1.0277	1.0242	.905	.9671			1.0164
6	1.0277	1.0349	.9877	.9671		.9774	1.0425
7	.8596	.823	.8596	.8505		.7796	.9511
8	.8238	.7362	.7343	.823		.7796	.9055
9	.8063	.7455	.7888	.7716	.7712		.7537
10	.8048	.7701	.7865	.7712	.7712	.788	.8817
11	.7969	.7537	.8718	.7802	.7888	.7888	.8745
12	.8322	.8059	.8842		.823	.788	.9015
13	.9015	.823	.8478		.8413	.8063	.8764
14	.8745	.8413	.8573		.8764	.8328	.8939
15	.8842	.9189	.9015	.9816	.9134	.8954	.9214
16	.9568	.9015	.9036	.985	.9214	.9313	.9955
17		.8916	.8413	.8954	.9114		1.0974
18	1.0136	.9189	.8149	.8063	.8309		1.1403
19	1.1946	1.0852	1.0513	1.1096	1.0341		1.1765
20	1.2254	1.1443	1.1443	1.1744	1.1443		1.1888
21	1.2437	1.1393	1.1393	1.2048	1.1871		1.2437
22	1.2269	1.258	1.134	1.2178	1.2178		1.1458
23	1.2536	1.2536	1.2357	1.2127	1.2489		1.2136
24	1.1584	1.1946	1.134	1.1157	1.1765	1.1403	1.1888
Max	1.2536	1.258	1.2357	1.2178	1.2489	1.1403	1.2437
Min	.7969	.7362	.7343	.7712	.7712	.7796	.7537
Avg	.9984	.9717	.9529	.9827	.9746	.9138	1.0282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 203 / 11 KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7602	.823	.8589	.823	.8316	.8501	.8316
2	.724	.7602	.7762	.8048	.7392	.8402	.8402
3	.724	.724	.7577	.8048	.7023	.7577	.7655
4		.695	.7577	.7682	.7207	.7468	.7499
5	.7682	.7133	.7023	.7682	.7207	.7468	.7316
6	.7499	.7762	.7207	.8048	.7392	.7682	.7316
7	.6908	.6283	.679	.6348	.695	.6535	.7682
8	.7421	.6154	.6653	.7023	.6516	.6838	.7762
9	.7602	.6556	.6401	.6219	.6626	.724	.8145
10	.7964	.6935	.7796	.6767	.6626	.788	.8326
11	.8505	.7628	.8328	.5975			.9231
12	.8939	.8954	.8326		.8507	.8954	.8859
13	.7522	.8596	.8596		.8048	.905	.9231
14	.6626	.8326	.8596		.8316	.8131	.8596
15	.6626	.8869	.8779	.9425	.8962	.9328	.9694
16	.8326	.9134	.9593	.9149	.9145	.9328	.9795
17	.7442	.9134	.9774	.7655	.9145		1.0534
18	.7888	.8505	.8688	.7468	.8775		1.1576
19	1.0749	1.1043	1.1096	1.0029	1.1462		1.2136
20	.964	1.1104	1.134	1.0387	1.1462		1.1203
21	.9391	1.0277	1.0208	.9774	1.0136		1.0534
22	.9492	.9593	.9955	.9877	.9593		.9979
23	.9774	.9694	.9877	.4207	.9877		.9335
24	.8501	.8871	.8589	.8962	.8871	.8871	.8686
Max	1.0749	1.1104	1.134	1.0387	1.1462	.9328	1.2136
Min	.6626	.6154	.6401	.4207	.6516	.6535	.7316
Avg	.8112	.8357	.8547	.7953	.8415	.8078	.9075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 204 / 11 KV SAMACHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.5721	.5959	.6344	.6135	.6447	.7059
2	.5784	.5316	.567	.6068	.5959	.6089	
3	.5784	.5201	.5493	.5895	.5847	.5847	
4	.4973	.5028	.5083	.5609	.5493	.5493	.6767
5	.5316	.5144	.5083	.5609	.5493	.5731	.6335
6	.5083	.4557	.4835	.4961	.4784	.5258	.5853
7	.4784	.4252	.4656	.4784	.4656	.4854	.5487
8	.4681	.4207	.4656	.5144	.4854	.5194	.499
9	.4508	.4382	.4784	.4801	.4748	.4908	.4908
10	.5083	.5144	.5658	.5548	.5487	.6024	.5784
11	.6268	.6687	.788	.7783	.7164	.7888	.7712
12	.7316	.7964	.8775		.8596	.905	.9134
13	.7964	.7964	.9134		.8779	.9511	.9774
14	.7701	.7602			.9231	.9511	.9492
15	.6878			1.0387	.9145	.9694	.9492
16	.6767	.8507	1.0136	1.0974	.9511	.9328	.9511
17	.6201	.8413	.9328	1.0974	.9511		1.0059
18	.6661	.8238	.9955	1.0242	.9412		1.0349
19	.7802	.9922	1.182	1.1999	1.1462		1.0349
20	.703	.9877	1.1517	1.1283	1.1462		.9795
21	.6344	.7964	.9036	.8505	.7455		.9522
22	.6556	.6762	.7628	.7108	.7362		.8316
23	.6588	.6762	.7108	.7087	.6984		.7842
24	.6661	.6201	.6697	.6984	.691	.6984	.724
Max	.7964	.9922	1.182	1.1999	1.1462	.9694	1.0349
Min	.4508	.4207	.4656	.4784	.4656	.4854	.4908
Avg	.6203	.6601	.7313	.7528	.7352	.6930	.7990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 205 / 11 KV JODHBHAVI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.3292	.3142	.3475	.3511	.3921	.3429
2	.2772	.3142	.2957	.3475	.3326	.3361	.3155
3	.2587	.2957	.2772	.3292	.2957	.3361	.3224
4	.2957	.2743	.2957	.3292	.2957	.3174	.3045
5	.3109	.2534	.2772	.3109	.2587	.3018	.2896
6	.3077	.2303	.2743	.2926	.2772	.2772	.2896
7	.2686	.197	.2402	.2587	.2378	.2402	.2561
8	.2572	.2103	.2481	.2686	.2481	.2686	.2561
9	.2743	.2401	.2543	.2686	.2229	.2572	.2947
10	.2515	.2846	.2881	.2774	.2622	.2984	.3018
11	.2401	.3163	.2915	.3077	.3277	.3601	.3353
12	.2984	.3401	.3277		.3353	.3601	.3932
13	.3185	.3401	.3441		.373	.3429	.3441
14	.2774	.3121	.3086		.3224	.2896	.3086
15	.2629	.3353	.3294	.362	.3012	.3721	.3772
16	.2947	.3647	.39	.3658	.3601	.3856	.3641
17	.2601	.3481	.3521	.3326	.3641		.3988
18	.2743	.2949	.3315	.3224	.3481		.4115
19	.3814	.4144	.4049	.4207	.4239		.4115
20	.3391	.3988	.4287	.3681	.4382		.3772
21	.3601	.3641	.4031	.3544	.3982		.3814
22	.3582	.3761	.4298	.3761	.4207		.3814
23	.362	.4024	.4344	.4024	.4066		.3681
24	.3142	.3109	.3511	.3696	.3881	.3921	.3429
Max	.3814	.4144	.4344	.4207	.4382	.3921	.4115
Min	.2401	.197	.2402	.2587	.2229	.2402	.2561
Avg	.2975	.3145	.3288	.3339	.3329	.3252	.3404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 207 / 11 KV PUMP HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3292	.2926	.2926	.3155	.3326	.3292
2	.3142	.3109	.2926	.3109	.333	.333	.3326
3	.3142	.3077	.298	.3109	.333	.056	.3511
4	.3142	.3292	.298	.3109	.333	.056	.3475
5	.3326	.3109	.298	.3109	.333	.056	.3475
6	.3326	.3109	.298	.3109	.333	.3121	.3326
7	.3292	.3142	.298	.3109	.0175	.3121	.2987
8	.298	.3109	.298	.2743	.0175	.3155	.2987
9	.2804	.3109	.298	.3109	.003		.3121
10	.2896	.3109	.2818	.3121	.2896	.285	.3086
11	.2926	.3109	.2883	.3189	.2926	.285	.3121
12	.2926	.3109	.3086	.3012	.0343	.3189	.3109
13	.2926	.2926	.2926	.3045	.2241	.3189	.3109
14	.2926	.2926	.2926	.3045	.2896	.298	.3142
15	.2926	.2926	.2926	.003	.2926	.3012	.3142
16	.3258	.2926	.2926	.3189	.0629	.3012	.3142
17	.3109	.2926	.2012	.3189	.3142		.3326
18	.3077	.2926	.1048	.3366	.3109		.3361
19	.3109	.2957	.2926	.3366	.3326		.3174
20	.2926	.0461	.2926	.3155	.3326		.2987
21	.3142	.2926	.2896	.3155	.3292		.2957
22	.3109	.2926	.2896	.3121	.3326		.3292
23	.3109	.2896	.1886	.3155	.3142		.3142
24	.3142	.3292	.3109	.297	.333	.3326	.3292
Max	.3326	.3292	.3109	.3366	.333	.333	.3511
Min	.2804	.0461	.1048	.003	.003	.056	.2957
Avg	.3075	.2945	.2788	.2981	.2543	.2634	.3203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 201 / 11 KV SAKHAR PETH FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	1.5384	1.5043	1.5203	1.5384	1.5912	1.576
2	1.4842	1.4842	1.448	1.448	1.4998	1.5364	1.5023
3	1.4266	1.3969	1.4118	1.4266	1.4632	1.4661	1.448
4	1.3717	1.3432	1.3717	1.3717	1.4118	1.4118	1.4083
5	1.3032	1.3032	1.3169	1.3032	1.3575	1.39	1.4266
6	1.267	1.2489	1.2936	1.267	1.3169	1.3535	1.448
7	1.3014	1.2382	1.2567	1.2437	1.2382	1.3032	1.4083
8	1.2254	1.2851	1.3169	1.2803	1.267	1.3032	1.3535
9	1.267	1.3575	1.39	1.2851	1.3394	1.39	1.4632
10	1.4864	1.4842	1.5769	1.4327	1.4327	1.6476	1.6118
11	1.6108	1.7013	1.7909	1.5927	1.7556	1.9185	1.7194
12	1.6289	1.8088	1.9547		1.8461	2.0119	1.9004
13	1.6476	1.8642	1.9547		1.8461	2.0485	2.009
14	1.6108	1.7918	1.8804		1.8099	1.8642	1.9366
15	1.6297	1.7918	1.8823	2.0774	1.7375	1.9387	1.9204
16	1.6832	1.9022	1.9728	2.0058	1.9022	1.9753	1.9936
17	1.6278	1.8473		1.8983	1.957	2.009	2.0302
18	1.6118	1.8983	1.8983	1.8099	1.8823	1.9366	2.0237
19	1.9982	2.3663	2.4097	2.3461	2.392	2.3211	2.4893
20	1.9631	2.3102	2.4177	2.2502	2.3388	2.3211	2.4893
21	1.8404	2.0774	2.0553	2.0416	2.0908	2.073	2.2565
22	1.7541	1.8073	1.8604	1.8604	1.8446	1.9667	2.1491
23	1.7013	1.7193	1.7551	1.7193	1.7551	1.8088	1.9163
24	1.6108	1.5939	1.576	1.576	1.6108	1.6651	1.6834
Max	1.9982	2.3663	2.4177	2.3461	2.392	2.3211	2.4893
Min	1.2254	1.2382	1.2567	1.2437	1.2382	1.3032	1.3535
Avg	1.5662	1.6733	1.7085	1.6551	1.6931	1.7605	1.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 202 / 11 KV NETAJI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6697	.6516	.6447	.6697	.6516	.6584	.6447
2	.6335	.6154	.6154	.6335	.6219	.6219	.6335
3	.6219	.5853	.5973	.6219	.5853	.5973	.5792
4	.6036	.5611	.5853	.6036	.5611	.5792	.6036
5	.5914	.5487	.567	.5792	.543	.567	.6401
6	.5729	.5544	.5544	.543	.5304	.5487	.6878
7	.5792	.5359	.5175	.5304	.4938	.543	.6767
8	.6036	.5611	.5487	.567	.5249	.5973	.6584
9	.6335	.5973	.5853	.5611	.5552	.6401	.6767
10	.6805	.6556	.6335	.6036	.6219	.6447	.6805
11	.6805	.7442	.7701	.6401	.7602	.7421	.7796
12	.691	.7522	.788		.724	.7783	.8145
13	.6805	.7973	.7701		.724	.7602	.8145
14	.5792	.724	.695		.695	.7133	.7865
15	.6516	.724	.7602	.7964	.695	.7682	.7865
16	.6584	.7783	.7783	.7682	.7499	.7783	.8596
17	.6584	.823	.8145	.7499	.7499	.7964	.8413
18	.6984	.788	.788	.724	.724	.8145	.8238
19	.8589	.964	.9922	.8775	.8954	.9391	.9568
20	.8589	.985	1.0387	.9214	.8939	.9214	.9568
21	.8063	.9134	.9036	.8417	.815	.8328	.8775
22	.7701	.8328	.8505	.8328	.8059	.8682	.8775
23	.7701	.788	.788	.788	.788	.7701	.8775
24	.7059	.7164	.6984	.7164	.7059	.6836	.6805
Max	.8589	.985	1.0387	.9214	.8954	.9391	.9568
Min	.5729	.5359	.5175	.5304	.4938	.543	.5792
Avg	.6774	.7165	.7202	.6938	.6840	.7152	.7589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 201 / 11 KV RAMLAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8839				
2	1.8107				
3	1.7375				
4	1.6827				
5	1.6278				
6	1.5912				
7	1.4449				
8	1.3717				
9	1.4083	1.5546	1.5364	1.6095	
10		1.8839	1.829	1.957	
11		2.0485	2.1033	2.0851	
12		2.1765	2.0851	2.268	
13		2.2497		2.2862	
14		2.1582		2.3777	
15		2.2862		2.4143	
16				2.4874	
17	1.4998	2.3228			2.3045
18		2.2497			2.1216
19		2.5057			2.4874
20		2.4691			2.5057
21					2.3228
22					2.3045
23					2.396
24	1.9936			1.9753	
Max	1.9936	2.5057	2.1033	2.4874	2.5057
Min	1.3717	1.5546	1.5364	1.6095	2.1216
Avg	1.6411	2.1732	1.8885	2.1623	2.3489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 204 / 11 KV BAPUJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2715				
2	1.182				
3	1.0924				
4	1.0566				
5	1.0208				
6	.985				
7	.9671				
8	1.0924				
9	1.0029		1.1104	1.0566	
10			1.0387	1.0208	
11			1.0566	1.0924	
12			1.0745	1.0924	
13				1.1104	
14				1.1462	
15				1.1641	
16				1.1283	
17	1.1462	1.0924			1.1641
18		1.1283			1.2178
19		1.5223			1.5939
20		1.5223			1.7551
21					1.7013
22					1.576
24	1.3253			1.2715	
Max	1.3253	1.5223	1.1104	1.2715	1.7551
Min	.9671	1.0924	1.0387	1.0208	1.1641
Avg	1.1038	1.3163	1.0701	1.1203	1.5014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 205 / 11 KV JAGDAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7556				
2	1.6632				
3	1.5154				
4	1.46				
5	1.386				
6	1.3491				
7	1.2382				
8	1.2936				
9	1.3306		1.386	1.2752	
10			1.386	1.2936	
11			1.3121	1.3121	
12			1.2936	1.363	
13				1.2567	
14				1.2936	
15				1.386	
16				1.4415	
17		1.5339			1.423
18		1.6632			1.4415
19		2.0328			1.9959
20		2.1622			2.1253
21					2.1253
22					2.0698
23					2.0144
24	1.8296			1.8296	
Max	1.8296	2.1622	1.386	1.8296	2.1253
Min	1.2382	1.5339	1.2936	1.2567	1.423
Avg	1.4821	1.8480	1.3444	1.3835	1.8850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 206 / 11 KV DAK BUNGLOW
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-18	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0791				
2	1.0059				
3	.9694				
4	.9328				
5	.9145				
6	.9145				
7	.823				
8	.8413				
9	.823	.9694	.9328	.9694	
10		1.0059	1.0242	1.0608	
11		1.1523	1.134	1.2071	
12		1.1157	1.2803	1.39	
13		1.262		1.2803	
14		1.2071		1.2986	
15		1.2254		1.3169	
16				1.2986	
17	.9511	1.4083			1.3032
18		1.2071			1.4299
19		1.39			1.5203
20		1.3535			1.5565
21					1.4299
22					1.3575
23					1.3032
24	1.134			1.0974	
Max	1.134	1.4083	1.2803	1.39	1.5565
Min	.823	.9694	.9328	.9694	1.3032
Avg	.9444	1.2088	1.0928	1.2132	1.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 207 / 11 KV SHIDDHESHWAR PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362				
2	.362				
3	.3439				
4	.3258				
5	.3258				
6	.3439				
7	.3077				
8	.3439				
9	.3258		.3258	.3439	
10				.3801	
11			.4163	.3982	
12			.3801	.4344	
13				.4525	
14				.4706	
15				.4706	
16				.4887	
17	.3439	.4887			.4525
18					.4344
19		.4887			.4525
20		.4344			.4344
21					.4344
22					.4344
23					.3258
24	.3801			.3982	
Max	.3801	.4887	.4163	.4887	.4525
Min	.3077	.4344	.3258	.3439	.3258
Avg	.3423	.4706	.3741	.4264	.4241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 201 / 11 KV Limyewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.2536	1.2308	1.2012	1.2127	1.2752	1.262
2	1.1765	1.2178	1.1946	1.1643	1.1765	1.2197	1.2197
3	1.1584	1.1999	1.1765	1.1088	1.1584	1.1576	1.2197
4	1.1222	1.182	1.1584	1.1643	1.1222	1.1088	1.1827
5	1.1403	1.1641	1.1584	1.2197	1.1523	1.1088	1.1827
6	1.1584	1.2178	1.2127	1.2567	1.1888	1.1643	1.2012
7	1.1041	1.0924	1.1765	1.2012	1.0903	1.1827	1.251
8	.9955	1.0387	1.1222	1.1088	1.0903	1.1088	1.1203
9	1.0534	1.0059	1.0059	1.0498	1.0425	1.0059	.9955
10	.8131	1.0136	1.0387	.9955	.9568	1.0374	.9774
11	.924	.9979	1.0029	.9955	.9593	1.0242	1.0136
12	1.0534	1.0425	1.0317	.985	.9774	1.0425	1.0136
13	1.0719	1.1088	1.1041	1.0387	1.0242	1.086	1.0679
14	1.1088	1.1458	1.086	1.1946	1.0566	1.086	1.1403
15	1.1273	1.1458	1.0679	1.2803	1.0242	1.134	1.1403
16	1.2197	1.1827	1.1888	1.2308	1.0425	1.0791	1.1222
17	1.2071	1.1041	1.0974	1.1462	1.0745	.9694	1.1523
18	1.2851	1.0808	.8131	1.0566	.985	1.0974	1.1283
19	1.4723	1.4043	1.5708	1.3466	1.3432	1.2986	1.5043
20	1.5238	1.5581	1.6263	1.4685	1.4864	1.4998	1.6297
21	1.5402	1.5581	1.6263	1.5223	1.4685	1.4815	1.6289
22	1.5939	1.5384	1.5708	1.5203	1.4148	1.4998	1.6108
23	1.4148	1.448	1.4415	1.4661	1.4969	1.5546	1.5746
24	1.2851	1.3253	1.3213	1.2012	1.2851	1.2936	1.2986
Max	1.5939	1.5581	1.6263	1.5223	1.4969	1.5546	1.6297
Min	.8131	.9979	.8131	.985	.9568	.9694	.9774
Avg	1.1992	1.2094	1.2093	1.2051	1.1596	1.1882	1.2349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 202 / 11 KV Modi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3432	1.3535	1.448	1.3717	1.3394	1.386	1.4969
2	1.2894	1.3169	1.3575	1.386	1.3213	1.386	1.4045
3	1.2536	1.2803	1.267	1.2936	1.2489	1.2936	1.386
4	1.182	1.262	1.2308	1.2012	1.2308	1.2012	1.3676
5	1.1999	1.2437	1.2127	1.2012	1.2437	1.2012	1.3491
6	1.182	1.262	1.2851	1.2012	1.262	1.2012	1.3491
7	1.0924	1.1523	1.2127	1.2012	1.1273	1.2012	1.2883
8	1.0387	1.0974	1.1584	1.2012	1.0719	1.1088	1.1763
9	1.1088	1.1088	1.2012	1.2071	1.0425	1.134	1.1888
10	1.1088	1.2012	1.1641	1.1946	1.0242	1.2071	1.3535
11	1.1088	1.2936	1.1999	1.4118	1.262	1.3121	1.3717
12	1.386	1.2936	1.2803	1.2308	1.3121	1.386	1.4449
13	1.386	1.5708	1.3073	1.3575	1.4415	1.4784	1.5181
14	1.2936	1.5708	1.2536	1.3717	1.4815	1.4083	1.5181
15	1.386	1.6632	1.2357	1.3717	1.4969	1.5364	1.6278
16	1.4784	1.6632	1.39	1.4449	1.5497	1.6263	1.6278
17	1.8671	1.5912		.439	1.5708	1.5893	1.5912
18	2.0814	1.5581	1.4784	.5853	1.5181	1.5708	1.6263
19	2.1132	1.858	1.848	1.7551	1.8107	1.885	1.957
20	2.0774	2.009	2.0328	1.9185	1.9387	2.0698	1.9909
21	2.0668	1.9547	1.9404	1.8823	1.8839	1.9774	1.9185
22	1.957	1.7556	1.6632	1.6832	1.6461	1.848	1.7194
23	1.9753	1.5927	1.5708	1.6289	1.5708	1.7372	1.6651
24	1.3969	1.8656	1.4842	1.4784	1.4661	1.4784	1.5524
Max	2.1132	2.009	2.0328	1.9185	1.9387	2.0698	1.9909
Min	1.0387	1.0974	1.1584	.439	1.0242	1.1088	1.1763
Avg	1.4739	1.4799	1.4010	1.3341	1.4109	1.4677	1.5204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 203 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9745	1.0454	1.0631	1.0517	1.1041	1.2269	1.1163
2	1.1517	1.0099	.9745	1.0631	1.0317	1.1517	1.0631
3	.9036	.9568	.9391	.9955	.9955	1.1517	.9745
4	.8505	.9214	.9214	.905	.9412	1.086	.9568
5	.8328	.8859	.8859	.8145	.8869	.905	.9492
6	.7973	.8859	.9391	.8059	.905	.823	.9134
7	.8682	.8859	.9745	.7888	.9511	.905	.9671
8	.8682	.9036	.9214	.8059	.9145	.905	.8954
9	.7973	.7888	.8063	.8328	.8495	.8495	.8745
10	.7973	.7888	.8048	.7545	.8029	.8149	.4973
11	.7973	.7888	.823	.4382	.7802	.7888	.7716
12	.7973	.7888	.8063	.4557	.703	.7712	.823
13	.8764	.8764	.8238	.7888	.7716	.8238	.8059
14	.8764	.8764	.8238	.8589	.8322	.8413	.9602
15	.8764	.8764	.8402	.9015	.8939	.9036	1.0166
16	.964	.8764	.8954	.8939	.8413	.8859	.929
17	.9492	.8682	.8059	.8238	.8238	.8505	.9036
18	1.0166	.8648	.7164	.8063	.8573	.815	.9214
19	1.0117	.9496	.964	.9816	.9945	.9214	1.0277
20	1.0229	1.0341	1.0166	1.0166	1.046	1.1163	1.0808
21	1.0808	1.0985	1.0517	1.0692	1.0288	1.0985	1.134
22	1.134	1.2048	1.0517	1.1218	1.1218	1.2403	1.3112
23	1.2226	1.1694	1.1919	1.1744	1.2269	1.2934	1.382
24	1.134	1.1871	1.1694	1.1393	1.1517	1.2269	1.1694
Max	1.2226	1.2048	1.1919	1.1744	1.2269	1.2934	1.382
Min	.7973	.7888	.7164	.4382	.703	.7712	.4973
Avg	.9417	.9388	.9254	.8870	.9356	.9748	.9768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 204 / 11 KV RAILWAY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3018	.3206	.2829	.2829	.2829	.3395
2	.3018	.3018	.3018	.2829	.3018	.2829	.3018
3	.3018	.3018	.2829	.2829	.3018	.2829	.3206
4	.3018	.3018	.2829	.2829	.3018	.2829	.3206
5	.3018	.3018	.3018	.2829	.3018	.2829	.3206
6	.2829	.3018	.3395	.2829	.2829	.2829	.3018
7	.2829	.3018	.2263	.2829	.3018	.2829	.3206
8	.2829	.3018	.3206	.2829	.3018	.2829	.3206
9	.2829	.3772	.3961	.3961	.3772	.2829	.3584
10	.3772	.4338	.5093	.4338	.5093	.3584	.3772
11	.3772	1.2936	.5281	.5281	.5093	.4715	.3772
12	.3772	.5093	.5847	.547	.4715	.5281	.4527
13	.3961	.5093	.5281	.4904	.4904	.5093	.4338
14	.2829	.4715	.5093	.4527	.4715	.4715	.415
15	.3772	.5093	.415	.4904	.4527	.5093	.415
16	.3772	.5281	.5093	.547	.5093	.5281	.415
17	.3584	.5281	.4904	.4904	.4715	.5093	.3961
18	.3584	.4904	.4715	.4715	.4715	.4715	.415
19	.3584	.4527	.4338	.3961	.3772	.4338	.3961
20	.3961	.4338	.3772	.3772	.3961	.415	.415
21	.3961	.3961	.3772	.3961	.3961	.415	.415
22	.3584	.3772	.3772	.3584	.3395	.3772	.415
23	.3206	.3584	.3772	.3206	.3772	.3772	.3395
24	.3206	.3206	.3206	.3206	.3018	.2829	.3395
Max	.3961	1.2936	.5847	.547	.5093	.5281	.4527
Min	.2829	.3018	.2263	.2829	.2829	.2829	.3018
Avg	.3371	.4335	.3992	.3867	.3874	.3835	.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 205 / 11KV GANGA EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0566
2	.0377	.0189	.0189	.0377	.0189	.0377	.0377
3	.0377	.0189	.0189	.0189	.0189	.0377	.0377
4	.0377	.0189	.0189	.0189	.0189	.0377	.0566
5	.0377	.0189	.0189	.0189	.0189	.0189	.0377
6	.0377	.0189	.0189	.0377	.0377	.0189	.0566
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0566	.0566	.0377	.0377	.0377	.0566	.0566
9	.0377	.0566	.0189	.0566	.0566	.0566	.0566
10	.0377	.0377	.0754	.0566	.0566	.0566	.0754
11	.0377	.0377		.0566	.132	.0754	.0754
12	.0377	.0377	.0377	.0566	.1132	.0754	.0754
13	.0189	.0377	.0566	.0754	.0566	.1132	.0754
14	.0189	.0377	.0377	.0566	.1132	.0754	.0566
15	.0189	.0566	.0189	.0566	.0754	.0943	.0754
16	.0377	.0754	.0566	.0754	.0566	.0943	.0754
17	.0377	.0566	.0566	.0566	.0754	.0754	.0754
18		.0566	.0377	.0566	.0566	.0566	.0754
19	.0377	.0566	.0566	.0566	.0566	.0754	.0566
20	.0566	.0377	.0377	.0566	.0566	.0566	.0566
21	.0377	.0566	.0377	.0377	.0377	.0566	.0566
22	.0566	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0189	.0566	.0566	.0566
24	.0377	.0377	.0377	.0377	.0189	.0377	.0377
Max	.0566	.0754	.0754	.0754	.132	.1132	.0754
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0377
Avg	.0377	.0409	.0369	.0456	.0534	.0574	.0581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274200 / 33/11KV GADDA MAIDAN

Feeder No / Name : 201 / 11KV COLLECTOR OFFICE

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.1576	1.2323	1.2883	1.2136	1.3256	1.3443
2	1.1203	1.1576	1.1763	1.2323	1.1763	1.307	1.2696
3	1.0642	1.1203	1.1203	1.1203	1.1203	1.2136	1.1203
4	1.0269	1.0829	1.0082	1.0642	1.0082	1.1203	1.0829
5	.9896	1.0562	.8718	1.0082	.9709	1.1203	1.0269
6	.9709	1.0185	.9709	.9522	.9522	1.0829	1.0082
7	.9149	.9242	.9896	.9522	.9522	.9709	1.0082
8	.9896	1.0185	.9896	1.0456	1.0082	1.0642	1.0456
9	1.0082	1.1203	1.1763	1.1576	1.0829	1.1203	1.0164
10	1.0456	1.4003	1.363	1.2696	1.363	1.4377	1.1827
11	1.2323	1.6244	1.6804	1.475	1.7364	1.7737	1.6632
12	1.2883	1.6991	1.7924	1.4377	1.7551	1.8298	1.6632
13	1.2883	1.6991	1.8298	1.7924	1.8298	1.7924	1.6632
14	1.3256	1.7177	1.8298	1.8298	1.7924	1.6991	1.5708
15	1.363	1.7364	1.8484	1.8671	1.8298	1.7551	1.6632
16	1.2696	1.8858	1.8484	1.7924	1.9231	1.8484	1.6632
17	1.2696	1.8107	1.8671	1.7918	1.9044	1.7551	1.6078
18		1.7164	1.7177	1.6244	1.7737	1.4582	1.6804
19	1.5364	1.7918	1.7364	1.7551	1.8111	1.7926	1.7737
20	1.4415	1.5524	1.7551	1.6632	1.6817	1.7177	1.7364
21	1.4003	1.4415	1.5339	1.6078	1.6057	1.6617	1.6804
22	1.3306	1.419	1.4377	1.4563	1.4937	1.531	1.587
23	1.386	1.4003	1.4377	1.4377	1.419	1.5684	1.5684
24	1.2323	1.307	1.2883	1.363	1.2323	1.3443	1.4563
Max	1.5364	1.8858	1.8671	1.8671	1.9231	1.8484	1.7737
Min	.9149	.9242	.8718	.9522	.9522	.9709	1.0082
Avg	1.2047	1.4108	1.4376	1.4160	1.4432	1.4704	1.4201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 201 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801				.2477	.2263
2		.2801				.2667	.2075
3		.2926				.2667	.2263
4		.2896				.2858	.2263
5		.2865				.2926	.2263
6		.3012				.3077	.2378
7		.3045				.3077	.4458
8		.5216				.4805	
9	.598	.6226	.6062	.1143	.571	.7282	
10	.743	.744	.7133	.1334	.6537	.727	
11	.8368	.8882	.7956	.1143	.7232	.8128	
12	.7682	.8345	.6763	.1143	.6537	.6676	
13	.5792	.6748	.5093	.1143	.8025	.4915	
14	.5287	.5944	.6923	.0953	.7375	.5792	
15	.6704	.7232	.744	.0953	.6805	.719	
16	.6668	.7371	.7002	.0762	.6516	.6895	
17			.7371	.0762		.6081	.6344
18			.6767	.0953		.6908	.5001
19			.39	.1132		.2286	.3045
20			.3658	.1143		.2402	.1991
21			.2241	.1086		.2218	.1886
22			.1991	.1109		.2033	.1886
23			.2195	.0943		.1848	
24		.2829				.2477	.1698
Max	.8368	.8882	.7956	.1334	.8025	.8128	.6344
Min	.5287	.2801	.1991	.0762	.571	.1848	.1698
Avg	.6739	.5093	.5500	.1047	.6842	.4373	.2844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 202 / 11KV Bhadrawati

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1848				.2353	.2204
2		.197				.2561	.2229
3		.1949				.2957	.2229
4		.2103				.3361	.2229
5		.2328				.3734	.2427
6		.2561				.3961	.2401
7		.2801				.415	.285
8		.5121				.4854	.5792
9	.6481	.5851	.7253	.2614	.6718	.602	
10	.8162	.7968	.828	.2195	.8322	.7472	
11	.8796	.8535	.9181	.2195	.8124	.8109	
12	.828	.8749	.8796	.2012	.852	.7579	
13	.7701	.7209	.6325	.2033	.823	.571	
14	.6554	.5921	.6093	.2012	.7282	.5357	
15	.6882	.7968	.7225	.1734	.8669	.719	
16	.7499	.828	.7133		.7274	.8173	
17			.8078			.7526	.8097
18			.7316	.2096		.6097	.7373
19			.5258	.2286		.4012	.4527
20			.3658	.2286		.2622	.3391
21			.3258	.2286		.2667	.2957
22			.2743	.2286		.2204	.2829
23			.2561	.2286		.2006	
24		.1829				.2149	.2035
Max	.8796	.8749	.9181	.2614	.8669	.8173	.8097
Min	.6481	.1829	.2561	.1734	.6718	.2006	.2035
Avg	.7544	.4882	.6211	.2179	.7892	.4701	.3571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 203 / 11KV MIDC NO.4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715				.2096	.2286
2		.1905				.2286	.2286
3		.1905				.2286	.2286
4		.2096				.2477	.2286
5		.1677				.2267	.2286
6		.2058				.2214	.2286
7		.2241				.2315	.2347
8		.578				.3041	.5401
9	.8206	.6984	.8318	.1715	.724	.9015	
10	.904	.8916	.8655	.1715	.8916	1.182	
11	1.0551	1.0292	1.0425	.1905	1.0084	1.2346	
12	.9596	1.0425	1.001	.2096	1.0749	1.0576	
13	.7188	.7628	.6622	.2096	.7133	.6274	
14	.719	.6984	.6908	.2096	.7628	.6539	
15	.8928	.8916	.8002	.1905	.888	.9181	
16	.9318	.904	.8387	.1715	.8796	.9414	
17			.9054	.1715		.8278	.9907
18			.8505	.1905		.7727	.8619
19			.5506	.2477		.4527	.503
20			.2772	.2477		.2683	.2543
21			.2054	.2477		.2667	.2667
22			.1905	.2286		.2477	.2477
23			.1905	.1905		.2286	
24		.1715				.2096	.2286
Max	1.0551	1.0425	1.0425	.2477	1.0749	1.2346	.9907
Min	.7188	.1677	.1905	.1715	.7133	.2096	.2286
Avg	.8752	.5310	.6602	.2032	.8678	.5287	.3666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 204 / 11 KV MIDC NO.5

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5121				.4428	.499
2		.5249				.4428	.4904
3		.5373				.4586	.4715
4		.5493				.4586	.4715
5		.5609				.4586	.4904
6		.5658				.4744	.5041
7		.5935				.4902	.5365
8		.9602				.5761	.8619
9	1.1363	1.2378	1.2266	.3601	1.174	1.3108	
10	1.2894	1.3352	1.3146	.3641	1.3032	1.6617	
11	1.5508	1.5299	1.5861		1.5503	1.656	
12	1.4882	1.6272	1.5432		1.5123	1.5202	
13	1.2616	1.2616	1.278		1.2191	1.278	
14	1.001	1.0254	1.335	.3582	1.1888	1.0031	
15	1.2407	1.3032	1.3491	.3681	1.2654	1.4685	
16	1.4146	1.4861	1.4289		1.5074	1.4861	
17			1.4146			1.3032	1.3575
18			1.3253	.3277		1.2018	1.3643
19			.9555	.3812		.8907	.9831
20			.6783	.4525		.663	.7625
21			.6415	.4755		.5281	.6173
22			.6201	.462		.5426	.5658
23			.6024	.4715		.5658	
24		.499				.4428	.5359
Max	1.5508	1.6272	1.5861	.4755	1.5503	1.6617	1.3643
Min	1.001	.499	.6024	.3277	1.174	.4428	.4715
Avg	1.2978	.9476	1.1533	.4021	1.3401	.8885	.7008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 205 / 11 KV SANKURI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2477				.2286	.2477
2		.2667				.2477	.2477
3		.2667				.2667	.2286
4		.2858				.2858	.2286
5		.3048				.3048	.2286
6		.3048				.3239	.2477
7		.3239				.3239	.3048
8		.547				.4001	.4877
9	.6562	.7287	.7611	.2286	.6203	.8309	
10	.7968	.7842	.7522	.2286	.7865	.8223	
11	.828	.9332	.9217	.2286	.7716	.8993	
12	.7926	.9031	.8749	.2286	.8065	.8381	
13	.583	.7045	.6539	.2286	.6443	.5548	
14	.639	.6539	.6882	.2286	.7802	.6415	
15	.8436	.8951	.7968	.2286	.8097	.8322	
16	.828	.7968	.7362	.2286	.7865		
17			.7432	.2286		.6478	.8097
18			.7116	.2096		.5668	.68
19			.5249	.1905		.3772	.4938
20			.3429	.1905		.3239	.3511
21			.2858	.1905		.2667	.2829
22			.3018	.1905		.2477	.2641
23			.2858	.1905		.2477	
24		.2477				.2096	.2286
Max	.8436	.9332	.9217	.2286	.8097	.8993	.8097
Min	.583	.2477	.2858	.1905	.6203	.2096	.2286
Avg	.7459	.5409	.6254	.2146	.7507	.4647	.3554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 206 / 11 KV VINKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2658				.2427	.2229
2		.2804				.2572	.2401
3		.2915				.2713	.2401
4		.3052				.2818	.2254
5		.3149				.3185	.2427
6		.3401				.3361	.2987
7		.3681				.3593	.3561
8		.7459				.427	.6773
9	.8655	.8796	.9181	.1905	.7802	.7305	
10	.9701	.9556	1.1294	.1905	1.0566	.9164	
11	1.2186	1.278	1.3496		1.2887	1.2631	
12	1.1728	1.2548	1.2163		1.1683	1.2041	
13	.7754	.8688	.888		.9259	.8322	
14	.7385	.8322	.9728	.1524	.9181	.7827	
15	1.1717	1.2944	1.057	.1524	.9556	1.1294	
16	1.0425	1.0574	1.1288		1.1138	1.1574	
17			1.1589			1.0669	1.1888
18			1.0105	.1905		.9907	1.1591
19			.7362	.1905		.6274	.7611
20			.4527	.1905		.4066	.57
21			.3898	.2096		.3142	.4641
22			.3361	.2096		.2715	.4239
23			.3511	.2096		.2481	
24		.2507				.2303	.208
Max	1.2186	1.2944	1.3496	.2096	1.2887	1.2631	1.1888
Min	.7385	.2507	.3361	.1524	.7802	.2303	.208
Avg	.9944	.6814	.8730	.1886	1.0259	.6111	.4852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	10.623	1.7187	1.7375	1.6632	10.8859	11.3935
2	1.5524	10.4556	1.5364	1.5746	1.5524	10.5367	10.2075
3	1.4415	10.2327	1.5364	1.5203	1.4969	10.2601	9.5874
4	1.4266	10.0651	1.5364	1.5203	1.4815	10.0921	9.4599
5	1.4661	9.8977	1.5746	1.5203	1.5364	10.0343	9.513
6	1.5043	9.8125	1.5746	1.6289	1.5912	9.8645	9.736
7	1.6827	9.7634	1.7193	1.6832	1.6289	9.6576	9.8137
8	2.2222	10.8939	2.2685	1.6118	1.9433	10.7219	11.0528
9	11.3203	11.1825	12.1548	9.5051	11.306	11.5106	2.4966
10	11.8067	12.0908	12.4783	8.8935	11.893	12.5874	2.5966
11	10.6573	13.3917	13.5597	7.8321	13.1951	13.8666	2.7801
12	12.4955	13.0818	13.7094	13.3339	13.7095	14.0798	2.8607
13	11.769	12.7344	13.7123	14.2467	13.3779	13.3151	2.5309
14	11.3598	12.5194	13.3128	15.0309	13.123	12.9595	2.5446
15	12.4497	13.7328	15.2904	10.9934	13.5746	14.1918	2.8898
16	11.0642	14.1753	13.961	10.6562	13.8832	14.4536	1.9204
17	2.5737	2.8704	13.9255	11.1603	2.5777	13.9998	14.7194
18	2.4074	2.7892	13.2956	11.0694	2.5463	13.9552	14.0318
19	2.6355	2.9492	15.0274	14.241	2.6749	15.7734	16.5478
20	2.524	2.8607	9.0981	14.321	2.7869	15.3595	16.3552
21	2.3388	2.6526	13.9438	14.125	2.6046	14.5353	15.439
22	2.1491	2.4177	13.1407	13.1967	2.3388	13.73	14.489
23	2.1176	2.1399	12.6704	12.5532	2.1176	13.5666	2.2497
24	1.7741	10.7693	1.885	1.9547	1.8296	11.0339	12.0702
Max	12.4955	14.1753	15.2904	15.0309	13.8832	15.7734	16.5478
Min	1.4266	2.1399	1.5364	1.5203	1.4815	9.6576	1.9204
Avg	5.1834	8.9209	8.9429	8.1629	5.6847	12.5405	8.6369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 201 / 11 KV BIDIGHARKUL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	1.587	1.4784	1.3289	1.2012	1.2536	1.2403
2	1.3203	1.4784	1.386	1.2803	1.0974	1.1641	1.2403
3	1.226	1.4632		1.1888	1.0974	1.1517	1.2536
4	1.1317		1.307	1.2012	1.0164	1.1517	1.1641
5	1.0269	1.4003	1.307	1.1888	.924	1.1641	1.2403
6	1.1203	1.2936	1.2136	1.086	1.0269	1.1641	1.2536
7	1.1203	1.1203	1.1203	1.0631	1.0269	1.1765	1.3432
8	1.0269	1.1088	1.0164	1.0631	1.0164	1.0745	1.2536
9	1.1888	1.1888				1.0974	1.1888
10	1.2936	1.1888		1.0745	.9955	1.086	1.1765
11	1.2936	1.2536		1.086	1.086	1.086	1.2803
12	1.307	1.2536		1.0745	1.1641	1.1888	1.267
13	1.4003	1.3146		1.1765	1.1765	1.1765	1.267
14	1.2936	1.2403		1.1641	1.1765	1.086	.8002
15	1.3717	1.3432		1.1641	1.1888	1.2012	1.2803
16	1.2536	1.2536		1.1641	1.2012	1.1888	1.386
17	1.2003	1.3717	1.1145	1.0288	1.1145	1.2003	1.5546
18	1.2003	1.6289	1.2003	1.0288	1.1145	1.2003	1.7194
19	1.7147	1.8004	1.8004	1.5432	1.8004	1.8004	1.8604
20	1.8861	1.8004	1.8004		1.8004	1.8861	1.8099
21	1.8004	1.8004	1.8004	1.7147	1.8004	1.8861	1.9204
22	1.6289	1.7147	1.7147	1.6289	1.6289	1.7147	1.9004
23	1.6289	1.5432	1.5432	1.3717	1.4575	1.7147	1.7013
24	1.4784	1.5708	1.5708	1.5708	1.2936	1.2536	1.2403
Max	1.8861	1.8004	1.8004	1.7147	1.8004	1.8861	1.9204
Min	1.0269	1.1088	1.0164	1.0288	.924	1.0745	.8002
Avg	1.3464	1.4225	1.4249	1.2360	1.2350	1.2945	1.3892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 203 / 11KV GANDHI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.0164	1.0974	1.0631	.9431	.964	1.086
2	.985	.924	1.0974	1.0059	.8488	.8764	1.0745
3	.8954	.924		1.0164	.7468	.8859	1.0974
4	.8859	.823	1.0164	1.0059	.7468	.8859	1.0745
5	.7888	.7316	.924	.9145	.8316	.8764	1.086
6	.8669	.8402	.823	.7973	.8402	.8859	1.1641
7	.9431	.9145	.9145	.7888	.8402	.9745	1.1641
8	.8669	1.3717	1.3717	.8145	1.186	1.8604	1.5432
9	1.9071	1.7966		.8954			1.7309
10	2.1033	2.1348		.964			2.0062
11	2.3034	2.4006		.8859			2.1548
12	2.1033	2.1605		.964			
13	1.7528	1.8023		.8764			1.7604
14	1.5242	2.0243		.8954			1.929
15		2.2405		.905			2.0576
16		2.1605		.905			2.0576
17	1.8861	2.1434	2.1434	.8573	1.9719	1.9719	2.0805
18	1.7147	1.8861	1.8004	.7716	1.8004	1.8004	2.5149
19	1.4575	1.7147	1.7147	1.0288	1.6289	1.7147	1.7147
20	1.3717	1.5432	1.4575	1.0288	1.3717	1.4575	1.4899
21	1.2003	1.4575	1.2003	1.0288	1.286	1.2003	
22	1.1145	1.286	1.2003	.9431	1.2003	1.1145	1.267
23	1.0288	1.2003	1.1145	.8573	1.0288	1.1145	1.1641
24	1.086	1.0974	1.0974	1.0974	.9335	.9745	1.0974
Max	2.3034	2.4006	2.1434	1.0974	1.9719	1.9719	2.5149
Min	.7888	.7316	.823	.7716	.7468	.8764	1.0745
Avg	1.3578	1.5248	1.2649	.9296	1.1378	1.2224	1.5598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 207 / 11 KV GADAGI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.4784	1.4937	1.4632	1.307	1.3289	1.3432
2	1.2012	1.386	1.4003	1.3717	1.1203	1.2536	1.2403
3	1.0974	1.307		1.2936	1.1317	1.2536	1.2536
4	1.0059	1.2136	1.3203	1.2803	1.0374	1.2403	1.1517
5	1.1088	1.226	1.226	1.2803	.9335	1.2403	1.1641
6	1.1203	1.226	1.1203	1.1517	1.0269	1.1517	1.1517
7	1.1203	1.226	1.2136	1.1393	1.1317	1.1517	1.1517
8	1.2136	1.1203	1.1088	1.1393	1.1088	1.1517	1.2012
9	1.307	1.1888		1.0517	1.0974	1.2012	1.1888
10	1.307	1.2012		1.0517	1.086	1.0974	1.267
11	1.3717	1.2803		1.0631	1.1765	1.1765	1.267
12	1.386	1.2803		1.0631	1.1765	1.267	1.3575
13	1.4003	1.3717		1.0631	1.1765	1.1888	1.3575
14	1.2936	1.267		1.0631	1.1765	1.1888	1.2803
15	1.3717	1.3432		1.1517	1.2803	1.3717	1.3717
16	1.3432	1.3289		1.0517	1.1888	1.307	1.448
17	1.286	1.6289	1.2003	1.0288	1.1145	1.2003	1.6289
18	1.2003	1.7147	1.2003	.9431	1.1145	1.2003	1.7013
19	1.7147	1.8004	1.6289	1.3717	1.6289	1.6289	1.8804
20	1.8004	1.8004	1.8004	1.6289	1.7147	1.8004	1.9909
21	1.8004	1.7147	1.8004	1.6289	1.7147	1.8004	2.0119
22	1.5432	1.7147	1.7147	1.5432	1.6289	1.6289	1.9204
23		1.5432	1.6289	1.3717	1.4575	1.4575	1.6118
24	1.4003	1.4937	1.587	1.5546	1.307	1.3432	1.3432
Max	1.8004	1.8004	1.8004	1.6289	1.7147	1.8004	2.0119
Min	1.0059	1.1203	1.1088	.9431	.9335	1.0974	1.1517
Avg	1.3342	1.4106	1.4296	1.2396	1.2432	1.3179	1.4285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 201 / AMRAPALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5975	.5601	.5914	.5228	.5601	.5601
2	.4338	.5788	.5228	.5415	.4854	.5228	.5228
3	.415	.5601	.5228	.5228	.4854	.5041	.5041
4	.415	.5415	.5228	.5228	.5041	.5041	.5041
5	.4527	.5228	.5601	.5228	.5228	.5228	.5228
6	.4805	.5228	.5601	.5544	.5415	.5415	.5415
7	.5611	.5914	.6036	.5914	.6099	.5975	.5415
8	.7935	.7449	.7907	.6099	.7202	.7545	.7956
9	.8383	.8749	.9556	.6036	.8065	.8223	.9172
10	.9259	.9297	.8951	.6335	.8745	.9804	1.0185
11	.9907	1.0936	.9755	.695	.9804	1.0437	1.1092
12	1.0185	1.1111	1.1069	.6348	1.0082	1.0595	1.0936
13	.7907	.9221	.9831	.6722	.9175	1.0227	.9945
14	.7935	.9503	.9069	.6348	.8785	.9282	.9221
15	.8065	1.0437	1.0753	.6535	.9393	1.0486	1.0883
16	.8855	1.1012	1.0486	.6908	.9878	1.1012	
17	.8905	1.0883	1.1385	.7095	1.004	1.0562	1.0494
18	.9061	1.0595	1.0155	.7023	1.0364	1.0623	.5548
19	.9665	1.1361	1.0802	.8686	1.0341	1.0576	1.1462
20	.9313	1.0208	1.0867	.8871	1.0317	.985	1.086
21	.8048	.9671	.9955	.8686	.9231	.9145	.9877
22	.7133	.7865	.8326	.7947	.7682	.7762	.8131
23	.6838	.6838	.7783	.6908	.6653	.6908	.7282
24	.4668	.6283	.5975	.6401	.5601	.5601	.5788
Max	1.0185	1.1361	1.1385	.8871	1.0364	1.1012	1.1462
Min	.415	.5228	.5228	.5228	.4854	.5041	.5041
Avg	.7265	.8357	.8381	.6599	.7837	.8174	.8078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 202 / 11 KV ASHOK CHOWK1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5121	.4938	.5068	.4938	.5121	.5175
2	.5121	.4938	.4572	.4706	.4572	.4572	.4805
3	.4755	.4755	.4572	.4706	.439	.439	.462
4	.4755	.4572	.4572	.4887	.439	.4344	.4572
5	.4938	.4572	.4706	.5068	.4572	.4525	.4755
6	.4961	.4572	.5014	.5373	.4706	.4835	.5014
7	.5197	.6154	.5434	.5373	.4784	.5144	.5434
8	.8069	.7335	.7674	.4961	.6097	.7164	.7827
9	.8642	.8762	.9191	.5493	.7529	.8145	.9023
10	.9179	.8657	.8345		.8215	.8288	.8741
11	.9739	1.0014	1.0151		.9002	.9164	.9602
12	.9602	1.0136	.9179	.5611	.9305	.9596	1.0431
13	.8802	.7819	.8543	.5792	.8362	.8278	.8471
14	.7773	.8471	.8362	.567	.7811	.8124	.8642
15	.8833	.9446	.9596	.567	.8579	.9362	.9976
16	.9288	1.0145	1.0002	.5359	.8949	.9808	1.0425
17	.9288	.9556	.9122	.5175	.8173	.8949	1.0136
18	.8459	.9587	.9305	.4835	.8036	.9023	.9596
19	.8583	1.0279	.9122	.7362	.8029	.9488	.9922
20	.7975	.9556	.9054	.7712	.9088	.9088	.9602
21	.7455	.8309	.8987	.7712	.8322	.8322	.9015
22	.6556	.7619	.8149	.7343	.7888	.788	.8328
23	.5973	.6584	.7343	.5853	.6268	.6516	.6584
24	.5487	.5304	.5487	.5792	.5487	.5487	.5914
Max	.9739	1.0279	1.0151	.7712	.9305	.9808	1.0431
Min	.4755	.4572	.4572	.4706	.439	.4344	.4572
Avg	.7288	.7594	.7559	.5706	.6979	.7317	.7775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 203 / 11 KV PATHAN BAG1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.8029	.6535	.6535	.6722	.7095	.6908
2	.6161	.7655	.5975	.5975	.5975	.6348	.6535
3	.5788	.7095	.5601	.5601	.5601	.5601	.5975
4	.5601	.6722	.5601	.5415	.5601	.5601	.5601
5	.5601	.6535	.5601	.5415	.5601	.5601	.5975
6	.5729	.6283	.5544	.5601	.5788	.5975	.6468
7	.6036	.6584	.6036	.5601	.5544	.5792	.6036
8	.6952	.7209	.7291	.543	.6344	.6516	.6962
9	.6718	.6718	.6636	.567	.6274	.6539	.7287
10	.7287	.68	.7611	.6379	.6539	.663	.759
11		.6722	.7773	.5316	.6802	.7625	.7811
12	.8002	.4054	.7373	.4938	.7373	.7209	.8356
13	.6962	.6859	.6874	.5304	.6443	.6588	.7377
14	.6952	.7122	.6687	.5914	.6836	.7108	.7969
15	.8139	.8383	.8383	.7499	.7716	.8478	.9389
16	.8402	.8589	.8745	.823	.8149	.8589	.9156
17	.8048	.8817	.8718	.8048	.8322	.8048	.8648
18	.7287	.8139	.779	.6516	.7291	.7522	.8907
19	.8413	.8505	.8417	.8775	.8507	.8596	.8764
20	.8059	.9134	.905	.9313	.8596	.8775	.905
21	.8145	.8954	.905	.8688	.8326	.8688	.905
22	.823	.8779	.8596	.8596	.8145	.9145	.9694
23	.8871	.8316	.8686	.8131	.8501	.924	.9055
24	.7468	.8316	.7468		.7468	.7468	.7468
Max	.8871	.9134	.905	.9313	.8596	.924	.9694
Min	.5601	.4054	.5544	.4938	.5544	.5601	.5601
Avg	.7191	.7513	.7335	.6647	.7019	.7282	.7751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 404 / 33 KV BIDII GHARKUL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.787				.8796	.7407
2		.8333				.9259	.787
3		.9259				.9259	.7407
4		1.0185				.9722	.787
5		1.1111				1.0185	.787
6		1.2037				1.0648	.8796
7		1.3426				1.1574	1.0648
8		2.2685				2.2685	2.1296
9	2.7778	2.8241	3.0093	.6481	2.5926		
10	3.3796	3.3796	3.5185	.6944	3.1019		
11	3.7963	3.8889	3.9352	.1852	3.5185	3.75	
12	3.75	3.9815	3.6574	.1389	3.5185	3.75	
13	2.8704	2.6852	2.7315	.6019	3.0093	2.5926	
14	2.5	2.6852	3.1019	.6019	2.9167	2.4074	
15	3.2407	3.4722	3.4722	.6019	2.963	3.3796	
16	3.3333	3.5185	3.4722	.6019	3.1482	3.5648	
17			3.5648	.9259		3.4259	3.8889
18			2.963	.5556		3.0556	3.5648
19			1.9444	.5556		1.8982	2.1296
20			1.4815	.6944		1.25	1.5741
21			1.1111	.6481		.9259	1.2037
22			1.0648	.6481		.9259	1.1574
23			1.0185	.6481		.8796	
24		.7407				.8796	.787
Max	3.7963	3.9815	3.9352	.9259	3.5185	3.75	3.8889
Min	2.5	.7407	1.0185	.1389	2.5926	.8796	.7407
Avg	3.2060	2.1569	2.6698	.5833	3.0961	1.9045	1.4815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		9.2981			8.85	9.6342	9.8023
2		9.2421			8.4019	9.5222	9.4102
3		9.1861			8.1219	9.3542	8.682
4		9.1301			8.0098	9.2421	8.4019
5		9.0741			7.9538	9.1301	8.4019
6		9.0535			8.1219	8.906	8.626
7		8.906			8.2339	8.738	8.9621
8		10.8665			9.6902	10.7545	10.7545
9	11.7627	11.4266	12.3788	8.1779	11.5387	11.8747	
10	12.4909	12.883	13.163	7.9538	12.6589	13.2751	
11	11.9307	14.2273	14.2833	7.0016	13.9472	14.5633	
12	13.051	14.1152	14.3953	11.9868	14.2273	14.5073	
13	11.7627	12.7149	13.051	12.8269	13.5551	12.883	
14	11.4826	12.4349	13.4991	13.5551	13.3311	12.7149	
15	13.107	14.1152	13.9472	9.2981	13.8352	14.3953	
16	11.5947	14.5633	13.7792	9.5222	14.0032	14.5073	
17			14.1152	10.0823		14.4513	15.0675
18			13.107	9.4102		13.8352	14.2833
19			13.7232	11.8747		14.2273	14.8994
20			12.939	11.9307		13.7232	14.2273
21			12.0988	11.6507		12.6029	13.3311
22			11.4266	11.0345		11.8747	12.4349
23			10.6985	10.6424		11.7627	
24		9.3542			9.8023	9.7462	10.6424
Max	13.107	14.5633	14.3953	13.5551	14.2273	14.5633	15.0675
Min	11.4826	8.906	10.6985	7.0016	7.9538	8.738	8.4019
Avg	12.1478	11.2112	13.1070	10.4632	10.8401	11.9261	11.1951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 201 / 11KV RAMWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4506	1.4327	1.4864	1.4327	1.4327	1.5402	1.6118
2	1.379	1.3432	1.3611	1.3253	1.4327	1.5402	1.5223
3	1.3253	1.2536	1.2894	1.3253	1.3969	1.4327	1.4327
4	1.2178	1.2536	1.2178	1.2536	1.3969	1.2536	1.3611
5	1.1104	1.2536	1.1462	1.182	1.2536	1.2536	1.182
6	1.0208	1.1641	1.0745	1.1104	1.1462	1.1104	
7	.8954	1.0029	.985	.9313	1.0208	1.0387	1.0387
8	.8417	1.0566	1.0029	.8954	.9492	.9492	.9671
9	.7701	1.0387	1.0808	1.0808			.985
10	.567	.2507	1.1517	1.1517			1.0924
11	.9568	1.3969	1.2048	1.2048			1.182
12	.9745	1.2536	1.2757	1.1871			1.1641
13	.9745	1.2715	1.3112	1.1517			1.1641
14	1.1163	1.2357	1.3466	1.2934			1.2894
15	1.2403	1.3611	1.3466	1.3112			1.379
16	1.2048	1.379	1.3289	1.258			1.3611
17	1.1283	1.3073	1.2536	1.2536	1.3073		1.2536
18	1.0566	1.2536	1.2178	1.1641	1.2894		1.2357
19	1.3432	1.5402	1.4327	1.4506	1.4148		1.4864
20	1.4327	1.5402	1.5223	1.4685	1.4506		1.6297
21		1.5043	1.5939	1.4685	1.4864		
22	1.5581	1.5939	1.576	1.5939	1.5581	1.6297	1.6297
23	1.6297	1.6834	1.6118	1.6476	1.6655	1.7193	1.7551
24	1.5223	1.5581	1.5939	1.576	1.6118	1.6118	1.6834
Max	1.6297	1.6834	1.6118	1.6476	1.6655	1.7193	1.7551
Min	.567	.2507	.985	.8954	.9492	.9492	.9671
Avg	1.1616	1.2887	1.3088	1.2799	1.3633	1.3709	1.3367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 202 / 11KV PRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	.2667	.2477	.2667	.2286	.2286
2	.2477	.2286	.2477	.2477	.2667	.2286	.2286
3	.2477	.2286	.2477	.2286	.2286	.2286	.2286
4	.2477	.2286	.2477	.2286	.2286	.2286	.2286
5	.2477	.2286	.2477	.2096	.2286	.2096	.2286
6	.2477	.2286	.2477	.2096	.2286	.1905	.2286
7	.2477	.2477	.2286	.1905	.2096	.1905	.2286
8	.2286	.2477	.2286	.1905	.1905	.1905	.1905
9	.2286	.2286	.2858	.2286			.2286
10	.2667	.362	.3429	.1905			.3239
11	.2829	.4382	.3772	.2096			.381
12	.3048	.381	.4001	.2096			.362
13	.2477	.2858	.381	.2286			.2858
14	.3239	.362	.3239	.2096			.3048
15	.362	.4001	.381	.2477			.362
16	.3429	.4191	.4001	.2477			.362
17	.3239	.4001	.381	.2477	.362		.362
18	.2667	.3239	.3429	.2096	.3239		.362
19	.3048	.3048	.3239	.2286	.3239		.3239
20	.3048	.3048	.2858	.2286	.2858		.2858
21		.2477	.2477	.2286	.2477		.2286
22	.2667	.2477	.2477	.2286	.2096	.2286	.2286
23	.2477	.2477	.2477	.2096	.2286	.2096	.2286
24	.2477	.2477	.2477	.2477	.2667	.2286	.2286
Max	.362	.4382	.4001	.2477	.362	.2286	.381
Min	.2286	.2286	.2286	.1905	.1905	.1905	.1905
Avg	.2732	.2953	.2991	.2231	.2560	.2148	.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 203 / 11KV POLYTECHNIC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	.8962	.8589	.8859	.8063	.823	.9694
2	.9055	.9149	.8215	.8859	.7888	.8139	.9328
3	.8686	.8775	.8029	.8413	.7712	.7712	.9055
4	.8131	.8775	.7842	.8413	.7377	.7712	.8871
5	.7762	.8775	.7468	.7628	.7377	.7042	.8686
6	.7577	.8775	.7282	.7455	.6882	.663	.8501
7	.7701	.8596	.7522	.6554	.663	.7042	.7602
8	.8383	.985	.8886	.6722	.7545	.8048	.9326
9	.9804	.9442	.9945	.7455			1.0159
10	1.0631	.639	1.0867	.703			.9995
11	1.0402	1.0753	1.2136	.2774			1.1271
12	1.0867	1.0155	.9774	.2774			1.1568
13	1.0808	.8333	1.0166	.2915			.9393
14	1.0387	.7926	.9991	.2804			1.0159
15	1.1999	1.085	1.195	.8059			1.1736
16	1.1568	1.0753	1.134	.7802			1.1401
17	1.0974	1.0311	1.0279	.7762	.9503		1.1843
18	.9995	1.0242	.9686	.7701	.9922		1.1012
19		1.0974	1.0802	.9492	1.0923		1.1069
20	1.1218	1.1568	1.1218	1.0387	1.1218		1.3466
21		1.0867	1.1641	1.0498	1.0745		1.2715
22	1.0566	1.0974	1.1222	1.0679	1.0498	1.1403	1.2308
23	1.0608	1.0719	1.1088	1.0498	1.0029	1.1222	1.1403
24	.961	.9511	.961	1.0164	.9425	.9568	1.0242
Max	1.1999	1.1568	1.2136	1.0679	1.1218	1.1403	1.3466
Min	.7577	.639	.7282	.2774	.663	.663	.7602
Avg	.9825	.9643	.9815	.7571	.8859	.8432	1.0450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 204 / 11KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4685	1.5223	1.5223	1.4685	1.3969	1.5043	1.576
2	1.3969	1.4685	1.379	1.3969	1.3969	1.5043	1.4864
3	1.3073	1.3611	1.2894	1.2536	1.3969	1.4327	1.379
4	1.2357	1.3611	1.2178	1.2536	1.2536	1.3611	1.3073
5	1.1641	1.3611	1.1641	1.2178	1.182	1.2536	1.2536
6	1.1283	1.2357	1.1104	1.1641	1.0745	1.1462	1.2178
7	.9671	1.0208	.985	1.0745	.9671	1.0208	1.0924
8	.985	1.0566	1.0029	1.0029	.8954	.9313	1.0387
9	.9671	1.0029	.9745	.6201			1.0566
10		.9671	.9922	1.0099			1.0924
11		.9671	.9745	.9391			1.1283
12		1.0745	1.0277	.9745			1.1641
13		1.1641	1.0631	.9922			1.1641
14		1.1999	1.0985	1.0808			1.2357
15		1.2357	1.1694	1.134			1.2357
16		1.2894	1.1871	1.1871			1.2894
17	1.1283	1.1999	1.1283	1.0387	1.0924		1.1283
18	1.0924	1.182	.9671	.985	1.0387		1.1999
19	1.4148	1.5402	1.379	1.3073	1.3253		1.4864
20	1.4685	1.6476	1.4864	1.4506	1.5223		1.7013
21		1.6118	1.5402	1.4864	1.5402		1.6476
22	1.5043	1.6297	1.5939	1.5581	1.5402	1.6476	1.6834
23	1.6476	1.6655	1.6655	1.5939	1.6476	1.7013	1.7372
24	1.5581	1.6297	1.576	1.6297	1.5043	1.6118	1.6655
Max	1.6476	1.6655	1.6655	1.6297	1.6476	1.7013	1.7372
Min	.9671	.9671	.9671	.6201	.8954	.9313	1.0387
Avg	1.2771	1.3081	1.2289	1.2008	1.2984	1.3741	1.3320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 206 / 11KV ESTATE 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1905	.1709	.3067	.2317	.1928	.2279
2	.2191	.1551	.1621	.2892	.2317	.1928	.241
3	.2279	.1467	.1709	.2892	.2134	.1884	.2498
4	.2263	.1341	.1797	.2629	.1886	.1884	.2542
5	.2347	.1257	.1884	.2542	.1772	.1884	.2629
6	.2321	.1467	.1928	.2454	.1686	.1884	.2673
7	.1665	.2058	.2016	.2683	.1715	.2147	.2599
8	.2599	.3155	.3067	.3353	.2195	.306	.3437
9	.3768	.4801	.499	.4207			.5121
10	.5611	.5847	.5487	.4477			.6602
11	.4908	.6161	.5611	.4557			.5975
12	.5552	.5175	.5729	.4801			.6516
13	.5853	.5138	.591	.4239			.5083
14	.5068	.5316	.567	.4694			.5784
15	.5611	.5847	.6516	.463			.631
16	.4835	.6036	.5611				.5609
17	.4115	.6348	.5415	.2949	.4656		.5975
18	.4024	.5014	.5359	.2408	.4733		.5194
19	.3096	.427	.5083	.2641	.4424		.4641
20	.2652	.4365	.3963	.2267	.3525		.3864
21		.3429	.3243	.2202	.2652		.3384
22	.2572	.2766	.3286	.2202	.2542	.2366	.2835
23	.2382	.3067	.4001	.217	.2629	.2378	.3018
24	.2012	.2	.2542	.3102	.2439	.1972	.2191
Max	.5853	.6348	.6516	.4801	.4733	.306	.6602
Min	.1665	.1257	.1621	.217	.1686	.1884	.2191
Avg	.3475	.3741	.3923	.3220	.2726	.2120	.4132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 201 / 11 KV MANTRI CHANDAK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9335	.9431	.8779			1.0608
2	.8676	.8962	.8865	.8413			1.0242
3	.7545	.8775	.8488	.7316			.9145
4	.6602	.8402	.7922	.7316			.8779
5	.6224	.7922	.7545	.6722			.7865
6	.5847	.7356	.6979	.6161			.695
7	.5658	.7167	.6602	.6219			.6722
8	.5658	.6979	.6036	.6036	.5487	.6335	.6348
9			.6036		.5788	.6468	
10			.5975		.5788	.6468	
11			.6161		.5788	.6722	
12			.6535		.5731	.6722	
13			.6535		.6268	.7095	
14			.6908		.6805	.6908	
15			.6344		.7733		
16			.6767			.9242	.8145
17			.6767	.8029	.7865	.811	
18			.7133	.8048	.8413	.7733	
19			.823	.7865	.8775	.9149	
20		.9808	.9145		.9335	.9774	
21					.9709	.9709	
22					1.0269	1.1203	
23			1.1016			1.0974	1.1157
24	.9997	.9896	.9808	1.0456			1.1389
Max	.9997	.9896	1.1016	1.0456	1.0269	1.1203	1.1389
Min	.5658	.6979	.5975	.6036	.5487	.6335	.6348
Avg	.7293	.8460	.7510	.7613	.7411	.8174	.885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 203 / 11 KV SHINDU VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3769	1.4146	1.4146	1.4937			1.4632
2	1.3203	1.358	1.358	1.5123			1.4266
3	1.226	1.3203	1.3203	1.3169			1.3169
4	1.1694	1.2637	1.2449	1.262			1.2803
5	1.1317	1.226	1.1694	1.1706			1.262
6	1.0751	1.1883	1.1128	1.1576			1.251
7	1.0751	1.1694	1.094	1.1203			1.0974
8	1.0751	1.0751	.9808	1.0059	1.0242	1.1016	1.0059
9			.9431		.8962	.9431	
10			.9242		.8676	.9808	
11			.9431		.9335	.9088	
12			.8573		.8916	1.0374	
13			.8916		1.0082	1.0117	
14			1.046		1.0136	1.046	
15			1.0288		1.094	1.0631	
16			1.0517			1.2071	1.2986
17			1.0277	1.0974	1.1523	1.1317	
18			.9745	1.0829	1.251	1.094	
19			1.1946	1.251	1.262	1.3253	
20		1.4299	1.3213		1.3443	1.475	
21					1.3817	1.5655	
22					1.5123	1.6975	
23			1.5546			1.643	1.7375
24	1.4335	1.4523	1.4712	1.531			1.6244
Max	1.4335	1.4523	1.5546	1.531	1.5123	1.6975	1.7375
Min	1.0751	1.0751	.8573	1.0059	.8676	.9088	1.0059
Avg	1.2092	1.2898	1.1329	1.2501	1.1166	1.2020	1.3422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 205 / 11 KV KUMATHA GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6161	.6161	.567			.5853
2	.6413	.5975	.5975	.5228			.5788
3	.6224	.6036	.6036	.5304			.5487
4	.6224	.6036	.6224	.5041			.5304
5	.6224	.6224	.6036	.5121			.567
6	.6413	.6224	.5847	.5121			.5487
7	.6036	.6036	.5658	.5415			.5487
8	.5281	.5281	.547	.5228	.5121	.439	.5121
9			.3961		.5068	.4835	
10			.1509		.5068	.4835	
11			.1494		.5068	.463	
12			.1494		.2763	.4835	
13			.4207		.5121	.4835	
14			.5304		.4961	.4835	
15			.5304		.4961	.4656	
16			.5487			.5093	.5853
17			.5487	.5487	.5601	.5658	
18			.5121	.5975	.5853	.5658	
19			.5853	.6219	.6348	.5731	
20		.6878	.695		.6722		
21					.6767	.7023	
22					.6767	.6908	
23			.5853			.6584	.6722
24	.679	.6348	.6348	.5487			.6161
Max	.679	.6878	.695	.6219	.6767	.7023	.6722
Min	.5281	.5281	.1494	.5041	.2763	.439	.5121
Avg	.6245	.6120	.5081	.5441	.5442	.5367	.5721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 207 / 11KV WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1991	.1991	.1991			.1991
2	.1991	.1991	.1991	.181			.1991
3	.1991	.1991	.1991	.1991			.1991
4	.4344	.4344	.1991	.1991			.1991
5	.4344	.4344	.4344	.4163			.1991
6	.4344	.1991	.4344	.4344			.1991
7	.2172	.4344	.2172	.4163			.1991
8	.4163	.4344	.4344	.4344	.4344	.2172	.1991
9			.2172		.4344	.2172	
10			.2263		.4344	.2172	
11			.2172		.4163	.2172	
12			.2172		.4163	.2058	
13			.4163		.4163	.2172	
14			.4163		.4163	.2172	
15			.4163		.4163	.2172	
16			.4163			.2172	.4163
17			.3944	.4163	.4163	.2172	
18			.2172	.3982	.3982	.2172	
19			.3982	.4163	.4163	.2058	
20		.2172	.3982		.4163	.2058	
21					.1991	.1991	
22					.2172	.2172	
23			.1991			.1991	.1991
24	.1991	.1991	.2172	.1991			.1991
Max	.4344	.4344	.4344	.4344	.4344	.2172	.4163
Min	.1991	.1991	.1991	.181	.1991	.1991	.1991
Avg	.3037	.2950	.3038	.3258	.3892	.2128	.2188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 208 / 11 KV SHANTIVAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.5975			.8029
2	.1132	.1132	.1132	.6161			.7682
3	.1132	.1132	.1132	.7468			.8029
4	.1132	.1132	.1132	.8402			.8215
5	.1132	.1132	.1132	.8962			.9149
6	.132	.132	.132	1.0082			1.0082
7	.1509	.1509	.132	1.0269			.7282
8	.132	.132	.1132	1.0456	1.1128	1.086	.7282
9			.7733		.0566	.1132	
10			1.0374		.0566	.1132	
11			1.0562		.0566	.0943	
12			1.094		.0943	.0943	
13			1.0751		.0857	.0943	
14			.9619		.0905	.0857	
15			1.0562		.0943	.1132	
16			1.0562			.1132	.112
17			.0943	.132	.132	.1132	
18			.1132	.1509	.1132	.0857	
19			.1509	.132	.1509	.1372	
20		.1663	.1698		.1509	.1372	
21					.132	.12	
22					.1509	.132	
23			.6535			.6722	.5601
24	.1132	.132	.132	.6219			.8215
Max	.1509	.1663	1.094	1.0456	1.1128	1.086	1.0082
Min	.1132	.1132	.0943	.132	.0566	.0857	.112
Avg	.1216	.1279	.4712	.6512	.1770	.2066	.7335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 209 / 11 KV IMS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2986	1.2803	1.2803	1.2803			1.3169
2	1.2803	1.2254	1.2437	1.2696			1.307
3	1.2437	1.1888	1.2254	1.251			1.262
4	1.2254	1.1523	1.1888	1.134			1.2437
5	1.1888	1.0974	1.134	1.1763			1.1949
6	1.134	1.0608	1.0791	1.1203			1.1157
7	1.134	1.0608	1.0608	1.0456			1.0974
8	1.0791	.8962	.9877	.9877	1.0425	1.0425	1.0534
9			.8779		.9145	.8779	
10			.8238		.8596	.8048	
11			.823		.8779	.8413	
12			.7716		.9145	.8779	
13			.8596		.9328	.9328	
14			.9328		.9694	.9694	
15			.9511		1.0059	.9774	
16			1.0059			1.0059	1.2071
17			1.0242	1.1203	1.0608	1.0059	
18			1.0242	1.1157	1.134	.9431	
19			1.1157	1.1576	1.2071	1.2803	
20		1.262	1.2986		1.307	1.3535	
21					1.3169	1.39	
22					1.4563	1.4632	
23			1.4083			1.475	1.5546
24	1.3352	1.3352	1.3169	1.3717			1.4563
Max	1.3352	1.3352	1.4083	1.3717	1.4563	1.475	1.5546
Min	1.0791	.8962	.7716	.9877	.8596	.8048	1.0534
Avg	1.2132	1.1559	1.0652	1.1692	1.0714	1.0776	1.2554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 210 / 11 KV BOMBAY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029	1.0745	1.0745	1.0974			1.0974
2	.9492	1.1104	1.0387	1.0829			1.0242
3	.9313	1.0387	1.0387	1.0242			.9511
4	.8954	.8954	.985	.9335			.9694
5	.8417	.8417	.9313	.9145			.8779
6	.788	.8059	.8775	.7682			.8413
7	.788	.788	.8596	.7468			.8029
8	.7343	.7164	.788	.6908	.7133	.695	.7655
9			.6878		.6697	.6335	
10			.6697		.6335	.6001	
11			.6335		.6089		
12			.6335		.6089		
13			.6878		.6401	.2172	
14			.7421		.6697	.9774	
15			.7421		.7421	.8869	
16			.724			.8507	.8779
17			.724	.8779	.8413	.7783	
18			.6878	.8962	.8596	.7421	
19			.8326	.9335	.8779	.8688	
20		.8954	.9412		.9511	.9259	
21					.9877	1.0317	
22					1.0974	1.1222	
23			1.2012			1.1706	1.2437
24	1.0745	1.1104	1.1104	1.1576			1.2136
Max	1.0745	1.1104	1.2012	1.1576	1.0974	1.1706	1.2437
Min	.7343	.7164	.6335	.6908	.6089	.2172	.7655
Avg	.8895	.9277	.8460	.9270	.7787	.8215	.9695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 211 / 11 KV NEHARU NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.8596	.8954	1.0082			.9335
2	.8417	.8238	.8596	1.0269			.8779
3	.8596	.8238	.8596	.9335			.8775
4	.8954	.8059	.8417	.9145			.8596
5	.8596	.7701	.8059	.8962			.823
6	.8238	.7522	.7701	.823			.8029
7	.8059	.7522	.7522	.7468			.7468
8	.6984	.6626	.6805	.6908	.7133	.6401	.7133
9			.6268		.6626	.6401	
10			.6001		.6447	.6447	
11			.6447		.6447	.6447	
12			.7164		.7164	.6805	
13			.7343		.7164	.7164	
14			.788		.3048	.7522	
15			.8059		.7522	.788	
16			.8059			.788	.7762
17			.788	.8775	.823		
18			.7701	.8589	.9145	.7373	
19			.9671	.823	.9709	.9134	
20		1.0029	.9671		.9896	.9671	
21					1.0242	.9671	
22					1.0974	1.0136	
23			1.0425			.9694	1.1203
24	.8954	.8954	.9313	1.0269			.9511
Max	.8954	1.0029	1.0425	1.0269	1.0974	1.0136	1.1203
Min	.6984	.6626	.6001	.6908	.3048	.6401	.7133
Avg	.8377	.8149	.8024	.8855	.7839	.7908	.8620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 212 / 11KV NTPC SMC
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0189			.0189
2	.0189	.0189	.0189	.0189			.0189
3	.0189	.0189	.0189	.0189			.0189
4	.0189	.0189	.0189	.0189			.0189
5	.0189	.0189	.0189	.0754			.0189
6	.1132	.0189	.0189	.0377			.0189
7	.0189	.0189	.0189	.1132			.0189
8	.0189	.0189	.0189	.0189			.0189
9			.0189		.0189	.0189	
10			.1132		.0189	.0189	
11			.1132		.0171	.0189	
12			.1029		.1029	.0189	
13			.1132		.1132	.0171	
14			.1132		.0189	.1132	
15			.1097		.0189	.0171	
16			.0189			.0171	
17			.0189	.0189	.0189	.0189	
18			.0189	.0189	.0189	.0171	
19			.0189	.0377	.0189	.0171	
20			.0189		.0189		
21					.1132	.0187	
22					.0189	.1086	
23			.0189			.0189	.0189
24	.0189	.0189	.0189	.0189			.0189
Max	.1132	.0189	.1132	.1132	.1132	.1132	.0189
Min	.0189	.0189	.0189	.0189	.0171	.0171	.0189
Avg	.0294	.0189	.0440	.0346	.0397	.0314	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 202 / 11 KV SHANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0351	2.0538	2.0165	2.1285	2.0538	2.0165	2.2405
2	1.9605	1.9418	1.9231	2.0165	1.9791	1.9231	2.0725
3	1.8484	1.8111	1.9605	1.9231	1.9044	1.9044	1.9231
4	1.8671	1.8671	1.9231	1.9231	1.8484	1.9605	1.8858
5	1.7551	1.7737	1.8671	1.8671	1.8484	1.8298	1.8858
6	1.8858	1.8671	1.9418	1.9791	1.9231	1.8111	1.9978
7	1.8484	1.9231	1.9791	1.8671	1.7551	1.9044	1.8111
8	1.7924	1.7551	1.9418	1.8484	1.6991	1.8111	1.7737
9	1.6617	1.7551	1.9418	1.8298	1.6991	1.8858	1.8298
10	1.8671	1.8484	1.9978	1.8298	1.7177	1.8484	1.9605
11	1.8858	1.9044	1.9231	1.8484	1.8111	2.0725	1.8858
12	1.8858	1.9418	1.8671	1.8671	1.9044	2.0351	
13	1.8671	1.9605	1.8111	1.9044	1.9418	2.0538	2.5206
14	1.9231	1.9605	2.1472	2.0165	1.9978	1.9231	2.9313
15	1.9978	2.0725	2.1845	2.0538	2.0165	2.0911	2.3525
16	1.9418	2.1285	2.2032	2.1285	2.0538	2.0911	2.4272
17	2.0911	1.9605	1.9605	1.8484	2.0165	2.0351	2.2218
18	1.9605	1.9044	2.0351	1.7924	2.0165	2.1285	2.1472
19	2.4459	2.4272	2.5393	2.2779	2.4272	2.6699	2.6886
20	2.5766	2.6326	2.8567	2.5766	2.6699	2.782	2.8193
21	2.5206	2.7073	2.7633	2.5953	2.5766	2.7446	2.8006
22	2.5019	2.6513	2.8006	2.5579	2.5393	2.726	2.782
23	2.5579	2.6139	2.7446	2.6139	2.5766	2.7446	2.782
24	2.4832	2.3712	2.4086	2.4832	2.4086	2.2032	2.5766
Max	2.5766	2.7073	2.8567	2.6139	2.6699	2.782	2.9313
Min	1.6617	1.7551	1.8111	1.7924	1.6991	1.8111	1.7737
Avg	2.0484	2.0764	2.1557	2.0740	2.0577	2.1332	2.2746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 203 / 11 KV SHIDDHESHWAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934	.0934	.0934	.0934	.0747
2	.0934	.0934	.0747	.0747	.0934	.0934	.0747
3	.0934	.0934	.0934	.0934	.0934	.0934	.0934
4	.0934	.0934	.0934	.0934	.0934	.0934	.0934
5	.0934	.0934	.0934	.0934	.0934	.0934	.0747
6	.112	.0934	.0934	.0934	.112	.112	.112
7	.0857	.0934	.0934	.0934	.0934	.112	.0934
8	.0934	.0934	.0934	.0934	.0934	.0934	.0934
9	.1307	.0934	.0934	.0934	.0934	.0934	.0934
10	.1494	.1307	.2054	.0934	.112	.0934	.0934
11	.0934	.112	.112	.112	.112	.0934	.1494
12	.112	.0747	.1307	.112	.0934	.0934	.0934
13	.112	.112	.112		.0934	.0934	.0934
14	.1867	.0934	.1307	.112	.0934	.1307	.2054
15	.112	.0934	.168	.0934	.1494	.0934	.1494
16	.1494	.0934	.1307	.0934	.112	.0934	.0934
17	.0934	.0934	.168	.0934	.0934	.0934	.0934
18	.0934	.0934	.0934	.0934	.0934	.112	.0934
19	.0934	.112	.0934	.0934	.0934	.112	.0934
20	.0934	.0934	.0934	.0934	.0934	.112	.0934
21	.0934	.0934	.0934	.0934	.0934	.0934	.0934
22	.0934	.0934	.0934	.0934	.0934	.0934	.0934
23	.0934	.0934	.0934	.0934	.0934	.0934	.0934
24	.0934	.0934	.0934	.0934	.0934	.0934	.0934
Max	.1867	.1307	.2054	.112	.1494	.1307	.2054
Min	.0857	.0747	.0747	.0747	.0934	.0934	.0747
Avg	.1063	.0965	.1097	.0950	.0988	.0988	.1012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 204 / 11 KV SWAGAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7193	1.7741	1.6827	1.7741	1.5912	1.6827	1.7193
2	1.6461	1.6804	1.6827	1.7924	1.5364	1.6461	1.701
3	1.6644	1.7177	1.6095	1.7177	1.4937	1.5729	1.6461
4	1.5912	1.6057	1.6095	1.7177	1.531	1.5912	1.6278
5	1.6278	1.6095	1.5364	1.6095	1.5123	1.5912	1.6095
6	1.6461	1.6827	1.5912	1.6461	1.6057	1.7375	1.6278
7	1.5364	1.7193	1.6644	1.5912	1.531	1.6095	1.5912
8	1.6644	1.7924	1.5364	1.4815	1.5684	1.7551	1.7193
9	1.7193	1.829	1.6644	1.3352	1.7924	1.8107	1.8107
10	1.8656	1.8473	1.7741	1.2437	1.8656	1.7924	1.9418
11	1.2986	2.0302	1.9022	1.262	1.9022	2.0485	2.1472
12	2.0119	1.9387	1.957	1.39	1.9936	2.0119	2.2032
13	1.9387	1.8839	1.9387	1.3717	1.9204	1.829	2.0351
14	1.8473	1.829	1.8656	1.4815	1.957	1.6278	2.1285
15	2.0119	1.9022	1.957	1.5181	1.9204	2.0485	2.2314
16	2.0668	1.957	2.0119	1.5364	1.8839	1.957	2.1948
17	2.1033	1.9753	1.9753	1.4815	1.9936	1.9022	2.0119
18	1.9418	1.957	1.8839	1.39	1.9387	1.9204	2.1033
19	2.2779	2.3594	2.2497	1.8107	2.2314	2.3411	2.4326
20	2.3152	2.524	2.524	2.0668	2.4691	2.4326	2.5423
21	2.3339	2.3594	2.3045	2.1216	2.3594	2.3594	2.2131
22	2.1765	2.268	2.3045	2.1033	2.1948	2.2862	2.4326
23	2.0668	2.1582	2.1399	1.9387	2.0119	2.1765	2.1582
24	1.9022	1.8656	1.8839	1.9936	1.7924	1.9204	1.8473
Max	2.3339	2.524	2.524	2.1216	2.4691	2.4326	2.5423
Min	1.2986	1.6057	1.5364	1.2437	1.4937	1.5729	1.5912
Avg	1.8739	1.9278	1.8854	1.6406	1.8582	1.9021	1.9865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 205 / 11 kv Hatture Nager

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6401	.6584	.6584	.6401	.6584	.6767
2	.6219	.6219	.6401	.6401	.6401	.6219	.6401
3	.6219	.6219	.6219	.5853	.6219	.5853	.6219
4	.5853	.6036	.5853	.567	.567	.567	.6036
5	.567	.5853	.6036	.5853	.6036	.5853	.5853
6	.5853	.5487	.6219	.6219	.6036	.5853	.6401
7	.5304	.567	.6219	.5304	.5304	.567	.5853
8	.5121	.5121	.567	.4938	.4938	.5121	.5487
9	.5121	.5121	.5853	.4572	.4572	.5121	.5304
10	.5121	.5121	.5304	.4938	.5304	.4938	.5487
11	.5853	.4938	.5487	.4755	.5304	.4938	.567
12	.567	.567	.5121	.439	.5121	.4755	.6036
13	.567	.6036	.5853	.4938	.567	.5121	.6219
14	.6219	.6219	.7865	.5487	.6219	.5304	.695
15	.6219	.6401	.7682	.5304	.6401	.1463	.7133
16	.6401	.6767	.7682	.567	.6584	.6584	.5487
17	.6219	.6036	.6584	.567	.6219	.6401	.6584
18	.6036	.5487	.6584	.5487	.5487	.6036	.5853
19	.7316	.695	.8048	.7682	.7499	.7682	.7682
20	.7682	.823	.8779	.823	.7499	.823	.8962
21	.7865	.823	.8413	.8048	.7865	.823	.9145
22	.7499	.823	.8048	.7682	.7682	.823	.8413
23	.7682	.7499	.8048	.7682	.7499	.823	.823
24	.7133	.7133	.7133	.7316	.7133	.6767	.7499
Max	.7865	.823	.8779	.823	.7865	.823	.9145
Min	.5121	.4938	.5121	.439	.4572	.1463	.5304
Avg	.6264	.6295	.6737	.6028	.6211	.6036	.6653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 403 / 33 KV KIRLOSKAR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1219	5.3212	7.9538	6.7215	3.4728	6.1614	6.7776
2	6.8896	6.8336	6.0494	2.4086	4.5931	3.9769	8.3459
3	6.1614	5.9934	7.8978	6.7215	2.0165	4.257	4.201
4	1.8484	1.9044	3.3048	5.8814	6.0494	2.3525	5.8814
5	1.9605	5.4332	3.7529	8.57	4.6491	7.0576	3.9769
6	6.1614	1.9044	7.9538	4.9291	7.8978	2.1285	6.6095
7	1.4563	6.9456	8.1779	1.6804	3.3048	1.4003	7.6738
8	2.0165	5.7693	6.9456	1.4563	2.5766	1.9044	5.0412
9	2.7446	6.8896	4.145	.8402	6.7215	1.9605	6.3855
10	5.7133	2.9127	5.4893	.9522	4.8171	2.0165	6.1614
11	2.5766	7.0576	6.0494	2.5206	5.4893	1.6804	4.257
12	8.626	5.2092	7.7858	.7842	6.1614	1.9605	2.5766
13	4.425	6.3295	4.201	1.0642	4.537	3.6408	3.6408
14	4.7611	4.481	3.7529	1.1763	3.7529	6.8336	6.4975
15	4.7051	4.8171	4.313	.9522	5.0412	3.2487	4.8171
16	8.1219	5.2652	6.0494	1.0642	6.1054	4.313	4.5931
17	6.3295	2.9127	8.738	.8962	4.257	6.4975	9.1301
18	3.6969	5.9934	6.6095	1.2883	5.9934	4.6491	4.201
19	4.145	3.9769	2.7446	1.3443	2.5206	5.3212	7.1136
20	4.0329	6.7215	2.5206	1.6244	5.2092	4.481	6.7215
21	2.1285	4.0889	3.7529	3.6969	2.0165	2.0725	2.1845
22	4.481	4.425	5.8253	1.4003	4.0889	5.9934	3.9209
23	5.4332	8.682	5.9934	1.0642	6.2174	6.1614	7.2257
24	7.0016	4.313	4.9851	4.6491	1.6804	6.1054	7.0576
Max	8.626	8.682	8.738	8.57	7.8978	7.0576	9.1301
Min	1.4563	1.9044	2.5206	.7842	1.6804	1.4003	2.1845
Avg	4.7308	5.1742	5.6246	2.6536	4.5487	4.0073	5.6246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 404 / 33 KV HOTGI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	27-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.5947	1.8004	2.3148	2.3148	2.4177	2.3663
2	1.6461	1.5947	1.749	2.4177	2.3663	2.4691	2.4691
3	1.749	1.6461	1.9033	2.5766	2.4691	2.6235	2.572
4	1.9033	1.749	1.8519	2.6886	2.5206	2.7263	2.572
5	2.0576	2.0062	2.0062	2.9687	2.8292	2.8807	2.7263
6	2.3663	3.1379	2.5206	1.9044	2.6749	2.7263	3.2922
7	3.1893	3.4465	3.0864	2.9835	3.035	3.1893	3.7037
8	.5144	3.0864	3.035	1.1317	2.9835	2.6749	3.4465
9	1.9547	2.9321	3.1379	2.4691	2.8292	3.1893	3.0864
10	.7202	2.5206	2.8807	.7716	2.8807	2.9835	2.572
11	.6173	.6687	2.2119	.7716	.7202	.7716	.7202
12	3.0864	3.2922	3.1379	2.7778	3.035	2.6749	2.7778
13	3.2407	3.0864	3.2407	2.4691	3.1379	2.8006	2.8292
14	3.1893	2.9835	3.1379	2.8807	2.8807	2.4177	.4115
15	3.0864	2.8807	3.0864	2.9835	2.9835	2.7263	2.5206
16	3.1379	3.1379	3.1379	3.0864	2.9321	2.6749	2.9321
17	1.5432	1.5947	3.1893	2.8807	3.1379	2.7778	3.2407
18	2.7778	3.2407	2.9835	2.7778	3.1379	2.9321	2.7778
19	3.1893	3.1379	3.035	3.0864	3.1893	2.3663	2.9321
20	1.2346	1.1831	1.1317	1.1831	1.1831	1.2346	1.2346
21	1.1317	1.1317	1.1317	1.2346	1.2346	1.1317	1.286
22	1.0802	1.1317	1.0802	6.2757	1.1317	1.1831	1.2346
23	.9774	.9774	.9774	1.0288	1.0802	1.0288	1.0288
24	.823	.7202	.8745	.8745	.9774	.9774	.9774
Max	3.2407	3.4465	3.2407	6.2757	3.1893	3.1893	3.7037
Min	.5144	.6687	.8745	.7716	.7202	.7716	.4115
Avg	1.9505	2.2034	2.3470	2.3557	2.4027	2.3158	2.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 201 / 11 KV FURDE SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-APR-18	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.5316				.4784
2	.5316	.5138				.4607
3	.4961	.4961				.443
4		.4784				.4252
5		.4607				.4075
6		.443				.4075
7		.3721				.4075
8		.3544				.4075
9		.362	.3982	.3898	.3801	.3721
10		.3439	.3801		.3544	.362
11		.362	.4163		.362	.3801
12		.3801	.4163		.3721	.3982
13		.4525	.4344		.3982	.5068
14		.4706	.4525		.4075	.5249
15		.4706			.443	.4706
16		.4706			.4607	.4163
20	.4784					
24	.6201	.5493				.4961
Max	.6201	.5493	.4525	.3898	.4607	.5249
Min	.4784	.3439	.3801	.3898	.3544	.362
Avg	.5422	.4419	.4163	.3898	.3973	.4332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 202 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.443				.5316
2	.4252				.5138
3	.4075				.4961
4	.3898				.4784
5	.3721				.4607
6	.3544				.443
7	.3366				.3721
8	.3189				.3721
9	.3189	.3439	.3189	.3366	.362
10	.3189	.362		.3366	.362
11	.3077	.3439		.3366	.3801
12	.2896	.362		.3366	.3801
13	.3801	.3982		.3366	.4163
14	.4163	.4163		.3258	.4344
15	.4344			.3189	.4525
16	.4525				.4075
24	.4607				.5493
Max	.4607	.4163	.3189	.3366	.5493
Min	.2896	.3439	.3189	.3189	.362
Avg	.3780	.3711	.3189	.3325	.436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 203 / 11 KV VIJAPUR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3439
2					.3258
3					.3174
4					.3077
5					.2896
6					.2715
7					.2534
8	.362				
9	.2481	.2715	.2534	.2353	.2715
10	.2715	.3077		.2303	.2715
11	.2896	.3077		.2303	.2896
12	.2896	.2896		.2353	.3077
13	.3077	.3077		.2658	.3258
14	.3258	.3258		.3189	.3439
15	.3258			.3189	.362
16	.3258			.3366	.3439
24	.362				.362
Max	.362	.3258	.2534	.3366	.362
Min	.2481	.2715	.2534	.2303	.2534
Avg	.3108	.3017	.2534	.2714	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 204 / 11 KV ITI NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-APR-18	24-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0362	.0181		
10	.0543	.0181	.0362	.0181
11	.0181	.0181	.0362	
12	.0543	.0543	.0543	
13	.0181	.0181	.0543	
14	.0362	.0181	.0543	
15			.0362	
16			.0543	
Max	.0543	.0543	.0543	.0181
Min	.0181	.0181	.0362	.0181
Avg	.0362	.0241	.0465	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-APR-18 and 28-APR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 205 / 11 KV RAMLING NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	23-APR-18	24-APR-18	25-APR-18	26-APR-18	28-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.086	1.086	1.086	1.086	1.2308
10	1.1041	1.086		1.086	1.1765
11	1.1584	.9774		1.0498	1.267
12	1.1222	1.0317		1.1584	1.267
13	1.1765	1.2308		1.1584	1.3756
14	1.1765	1.2489		1.1584	1.6108
15	1.4299			1.3213	1.6289
16	1.448			1.3213	1.7737
Max	1.448	1.2489	1.086	1.3213	1.7737
Min	1.086	.9774	1.086	1.0498	1.1765
Avg	1.2127	1.1101	1.086	1.1675	1.4163