

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6706		.6706	.8573	.6706	.8573
2	.6859	.6706		.6706	.7716	.6706	.7716
3	.7716	.6706		.6706	.6859	.6706	.7716
4	.8573	.8383		.8383	.8573	.8383	.8573
5	.9431	.9221		.8907	.9431	.8907	.9431
6	1.0631	1.0059		.8907	1.0288	1.0059	.9431
9		.9221		.9221	.8573	.9221	
10	.7621	.7621	.7621	.7621			.7621
11	.6097		.6097	.6859	.6097		.6859
12	.381		.4572	.6097	.381		.4572
13	.381	.4572	.5335	.4572			
14		.3048	.4572	.3048			
15	.381	.3048	.3048		.3048	.3048	.4572
16	.6859	.3048	.3048	.4572	.3048	.6859	.381
17	.6859	.3048	.6859	.6859	.6859	.6859	.5335
18	.8383	.8573	.6706	.8573	.7545	.9431	.8383
19	.9221	1.0288	1.0059	1.0288	.9221	1.0288	1.0059
20	1.0059		1.0059	.9431	.9221	1.0288	.9221
21	.9221		.8907	.9774	.9221	.9774	.8383
22	.8907		.9221	.9431	.9221	.9431	.9221
23	.8383		.8383	.8573	.8383	.9431	.9221
24	.8573	.7545		.7545	.8573	.7545	.8573
Max	1.0631	1.0288	1.0059	1.0288	1.0288	1.0288	1.0059
Min	.381	.3048	.3048	.3048	.3048	.3048	.381
Avg	.7670	.6737	.6749	.7561	.7593	.8214	.7751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 202 / 11KV AKLUJ URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8383		.8383	1.0288	.8383	.9431
2	.8573	.8383		.8097	.9431	.8383	.9431
3	.8573	.8383		.8383	.8573	.8383	.8573
4	.9431	.8907		.8383	.9431	.8907	.9431
5	1.0288	1.0059		1.0374	1.0288	.9717	.9431
6	1.0288	1.0898		1.0059	1.2003	1.0898	1.0288
9		1.1736		1.1736	1.2346	1.2574	
10	.9907	1.0669	1.0669	1.0669			1.0669
11	.8383		.9907	.9145	1.0669		.9145
12	.8383		.9145	.9145	.9145		.9145
13	.8383	.9145	.9145				
14		.9145	.8383				
15	.9145		.9145		.9145	.9145	.9145
16	.8383	.9145	.9145		.9145	1.0669	.8383
17	.9145	.9145	.9145	.8383	.9907	1.0669	.9145
18		1.0288	1.0059	1.3717	1.0898	1.2003	1.0526
19		1.3717	1.2574	1.3717	1.3413	1.4575	1.3413
20	1.5927		1.2574	1.3717	1.3413	1.3717	1.2193
21	1.4251		1.1736	1.3032	1.2146	1.3203	1.3413
22	1.3413		1.1336	1.2346	1.2574	1.3717	1.3413
23	1.0898		.9717	1.2003	1.1736	1.2003	1.2574
24	.9431	.9221		.9221	1.0288	1.0059	1.0288
Max	1.5927	1.3717	1.2574	1.3717	1.3413	1.4575	1.3413
Min	.8383	.8383	.8383	.8097	.8573	.8383	.8383
Avg	1.0076	.9815	1.0191	1.0584	1.0781	1.1000	1.0423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 203 / 11KV DIVISION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4191		.4191	.4287	.4049	.8573
2	.5144	.4191		.4191	.4287	.4049	.7716
3	.6001	.4191		.4191	.5144	.4049	.7716
4	.6859	.4191		.4049	.6859	.4191	.8573
5	.7716	.4858		.503	.7716	.503	.8573
6	.8573	.6706		.503	.8573	.7545	.8573
9		.8383		.8383	.8573	.7621	
10	.7621	.7621	.7621	.7621			.7621
11	.7621		.7621	.7621	.8383		.7621
12	.7621		.7621	.7621	.7621		.7621
13	.7621	.6859	.7621	.6859			
14		.7621		.6859			
15	.6859	.4572	.7621		.7621	.7621	.7621
16	.7621	.7621	.7621	.7621	.7621	.7621	.7621
17	.7621		.7621	.7621	.7621	.7621	.7621
18	.8383	.9431	.8383	.8573	.9221	.9431	.9221
19	1.0898	1.1145	.9717	.9431	1.0526		.9907
20	1.0059		.8907	.9431	.8907	1.1145	1.0059
21	.9221			.8573	.8383	.9945	.8907
22	.7545		.8383	.8573	.8097	.9431	.7621
23	.503		.7545	.8573	.7545	.8573	.8097
24	.5144	.4191		.4191	.4287	.4191	.8573
Max	1.0898	1.1145	.9717	.9431	1.0526	1.1145	1.0059
Min	.503	.4191	.7545	.4049	.4287	.4049	.7621
Avg	.7415	.6385	.8024	.6868	.7435	.7007	.8307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 204 / 11KV BAGEWADI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5927		1.4937	1.7147	1.7269	.2915
2	1.5775	1.5927		1.5927	1.6804	1.6766	.2743
3	1.6118	1.5384		1.5927	1.7318	1.5384	.2572
4	1.6804	1.5927		1.5927	1.7833	1.5927	.3429
5	1.7147	1.668		1.6766	1.8519	1.7004	.3772
6	1.7661	1.7939		1.9281	1.9719	1.829	
7	1.8347	2.0119		2.0243		2.0454	
10							1.6766
13	.1829	.1829	.1829	.1829			
14		.1981	.1981	.1829			
15	.1829	.1981	.1981		.1981	.1829	
16	.1981	.1981	.1981	.1829	.1981	.1829	
17	.1981	.1829	.1981	.1829	.1829	.1829	
18	.2515	.2058	.1981	.2401	.2515	.2572	
19	.3353	.3429	.3353	.3772	.3239	.3944	.4191
20	.3353		.3353	.3601	.3353	.3601	.4191
21	.3353		.3353	.3601	.3239	.3429	.3353
22	1.7269		1.8442	1.8004	1.7604	.3086	.3772
23	1.5242		1.6004	1.7147	1.7269	.3086	.3086
24	1.5604	1.6263		1.6766	1.749	1.7604	.2915
Max	1.8347	2.0119	1.8442	2.0243	1.9719	2.0454	1.6766
Min	.1829	.1829	.1829	.1829	.1829	.1829	.2572
Avg	1.0311	.9950	.5113	1.0645	1.1115	.9641	.4475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 206 / 11 KV MIDC

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3239		.4191	.4115	.3353	.4115
2	.4191	.3239		.4191	.4115	.3048	.4115
3	.4115	.3353		.4191	.3772	.3353	.3772
4	.4458	.4049		.503	.4115	.4191	.4115
5	.4458	.3563		.4875	.4801	.4049	.4458
6	.463	.3688		.503	.463	.4191	.4801
9		.4191		.3353	.3772	.4191	
10	.3963	.381	.3963	.3048			
11	.4572		.3963	.4572	.4572		.4572
12	.4572		.4572	.4572	.4572		.4572
13	.4572	.3963	.5487	.4572			
14		.4572	.5335	.3963			
15	.4877	.4572	.3963		.5335		.4572
16	.5182	.4572	.3963	.5792	.4877	.5335	.4572
17	.4572	.5335	.5335	.5487	.4877	.5335	
18	.4191	.4458	.5668	.4287	.4527	.4973	.5868
19	.503	.5316	.4858	.5487	.5344	.5487	.6203
20	.4694		.5365	.5144	.5365	.463	.5868
21	.4191		.5365	.463	.5344	.463	.503
22	.4191		.5533	.4287	.503	.4115	.5182
23	.4191		.503	.4287		.463	.503
24	.4115	.415		.4694	.4287	.4191	.4458
Max	.5182	.5335	.5668	.5792	.5365	.5487	.6203
Min	.3772	.3239	.3963	.3048	.3772	.3048	.3772
Avg	.4427	.4129	.4886	.4556	.4636	.4356	.4783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274035 / 33/11 KV AKLUJ S/STN.

Feeder No / Name : 207 / DR INAMDAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0419		.0386	.0429	.0419	.0429
2	.0343	.0386		.032	.0412	.0419	.0429
3	.0326	.0352		.0335	.0394	.0386	.0394
4	.0309	.0302		.0319	.0377	.0305	.0394
5	.0291	.0405		.0302	.0343	.0324	.036
6	.0257	.0335		.0285	.0326	.0419	.036
7	.0274	.0285		.0218	.0274	.0419	.0446
8	.0412	.0275		.0227	.0326	.0486	.0429
9		.0319		.0285	.0291	.0369	
10	.0412	.0305	.0412	.0305			.0457
11	.0412			.0152	.0457		.061
12	.0381		.0351	.029	.0579		.0564
13	.0564	.0457	.0457	.0305			
14		.0457	.0457	.0305			
15	.0594	.0457	.0533		.0564	.0594	.0564
16	.0564	.0564	.0457	.0594	.0457	.0305	.0594
17	.0457	.0594	.0457	.0457		.0564	.0564
18	.0553	.0669	.0503	.048	.0533	.0652	.0677
19	.0537	.06	.0419	.0446	.0502	.0617	.0587
20	.0442		.034	.036	.0503	.0549	.0486
21	.0419		.0352	.0326	.0469	.0514	.0525
22	.0553		.0319	.0412	.0469	.0497	.0469
23	.0419		.0302	.0429	.0386	.0514	.0469
24	.0377	.0391		.0386	.0463	.0453	.0463
Max	.0594	.0669	.0533	.0594	.0579	.0652	.0677
Min	.0257	.0275	.0302	.0152	.0274	.0305	.036
Avg	.0424	.0421	.0412	.0345	.0428	.0463	.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 201 / 11 KV WAGHOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.372	2.3758	2.372	.2486	.1989	.2486	2.2929
2	2.2929	2.3758	2.372	.2486	.1658	.2652	2.2138
3	2.2929	2.2939	2.451	.2652	.1658	.2652	2.2138
4	2.2929	2.2939	2.372	.2984	.1989	.2984	2.2138
5	2.2929	2.2939	2.2929	.3481	.1989	.2984	2.2138
6	2.2929	2.3758	2.372				2.372
7	2.372	2.3758	2.372				2.372
10					2.372	2.6882	
11				2.6882	2.6882	2.8464	
12				3.0045	2.8464	2.8464	
13				2.7673	2.8464	2.6882	
14				2.6882	2.5301		
15						2.5301	
16				2.6092	2.451	2.5301	
17				2.5301	2.372	2.451	
18	.1341		.2652	.1715	.1989	.1658	.1966
19	.2012		.3315	.2058	.2652	.1658	.2347
20	.2012	.1581	.3315	.2572	.2652	.1326	.2347
21	.2012	.1581	.3315	.2572	.2652	.1326	.2347
22	2.2939	2.5301	.2818	.1989	.2486	2.372	2.4577
23	2.3758	2.372	.2652	.1989	.2486	2.372	2.4577
24	2.5301	2.3758	2.372	.2652	.2321	.2486	2.372
Max	2.5301	2.5301	2.451	3.0045	2.8464	2.8464	2.4577
Min	.1341	.1581	.2652	.1715	.1658	.1326	.1966
Avg	1.7247	1.9983	1.4845	1.0695	1.0925	1.3445	1.7200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 203 / 11 KV LAWANG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.3932	.112	1.5023	2.451	2.6882	.2652
2	.3647	.3932	.096	1.5023	2.372	2.6882	.2652
3	.3978	.3932	.096	1.5813	2.451	2.6882	.2984
4	.4144	.426	.096	1.5813	2.451	2.6882	.3315
5	.4475	.4588	.128	1.5813	2.451	2.7199	.3647
6				1.5813	2.5301	2.8464	
7				1.6604	2.6092	2.8464	
10	2.834	3.0045	1.2289				2.8673
11	2.834	2.9254	1.2289				2.9492
12	2.753						
13	2.753						
14	2.8006		1.6385				
15			1.6385				
16	2.8006		1.8023				
17	2.7206						
18	.1638		.0663	.1492	.1492	.1326	.1966
19	.3277		.0995	.1658	.1658	.3978	.2374
20	.3605	.0972	.0995	.1492	.1658	.4641	.3932
21	.3605	.0972	.0829	.1326	.1492	.4641	.3932
22	.3932	.1296	1.5813	2.5301	2.6092	.4973	.3932
23	.3932	.1134	1.5813	2.6092	2.6092	.3647	.3277
24	.3647	.3932	.128	1.5813	2.5301	2.6882	.2652
Max	2.834	3.0045	1.8023	2.6092	2.6092	2.8464	2.9492
Min	.1638	.0972	.0663	.1326	.1492	.1326	.1966
Avg	1.2552	.7354	.6885	1.3077	1.8353	1.7267	.682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 206 / Vajrai

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1823	.1781	.1581	2.4352	2.5143	2.5617	.1658
2	.1989	.1619	.1581	2.3878	2.451	2.5617	.1658
3	.2155	.1781	.1581	2.4194	2.4669	2.5459	.1823
4	.2155	.1943	.1898	2.4036	2.4985	2.6092	.1989
5	.2321	.1943	.2214	2.4036	2.6023	2.5775	.1989
6				2.5301	2.6092	2.6882	
7				2.6092	2.7199	2.7673	
10	2.9254	3.0045	2.9797				3.1417
11	2.7831	3.0045	3.0445				3.2065
12		2.8464					
13		2.7199					
14	2.7357	2.7515	2.8016				
15	2.7831	2.7673					
16	2.8938	2.8622	3.1903				
17	2.7673						
18	.1943			.1492	.1492	.1492	.1781
19	.2267		.2321	.1989	.1989	.2486	.2105
20	.2267	.253	.1989	.2321	.2155	.2486	.2105
21	.2267	.253	.1658	.2155	.1989	.2321	.213
22	.2105	.2056	2.5617		2.6724	.2155	.1943
23	.1943	.1898	2.5301		2.6408	.1989	.1943
24	.1823	.1781	.1739	2.5143	2.6092	2.5934	.1658
Max	2.9254	3.0045	3.1903	2.6092	2.7199	2.7673	3.2065
Min	.1823	.1619	.1581	.1492	.1492	.1492	.1658
Avg	1.0775	1.2907	1.2509	1.7082	1.8962	1.5856	.6162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274037 / 33/11 KV LAWANG S/STN

Feeder No / Name : 207 / 11 KV CANAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9096	3.1893	3.1539	.5304	.5304	.5138	3.0045
2	2.9096	3.2236	3.1369	.5304	.5304	.5138	3.0045
3	2.8938	3.2236	3.103	.5636	.547	.5304	3.0519
4	2.9571	3.2217	3.1369	.5636	.5636	.547	3.0678
5	2.9254	3.3093	3.0691	.6299	.5967	.5636	3.0836
6		3.3608	3.3913				3.2417
7	3.3208	3.4294	3.476				3.3208
10					3.6456	3.6965	
11				3.3913	3.6456	3.8999	
12				3.9847			
13				3.8152	3.8491	3.8999	
14				3.7304	3.6456	3.5608	
15				3.7304	3.6374	3.5608	
17				3.7473	3.476	3.5947	
18	.5144			.4641	.4641	.4475	.4973
19	.5658		.5138	.5304	.5304	.5304	.5658
20	.5658	.5487	.547	.547	.547	.547	.5658
21	.5658	.5658	.5636	.547	.5304	.5304	.5658
22	3.2579	3.1722	.547	.547	.5138	3.0361	3.4294
23	3.2922		.547	.547	.5138	3.0045	3.3951
24	2.9729	3.1893	3.1539	.547	.5304	.5138	3.0361
Max	3.3208	3.4294	3.476	3.9847	3.8491	3.8999	3.4294
Min	.5144	.5487	.5138	.4641	.4641	.4475	.4973
Avg	2.2809	2.7667	2.1800	1.6082	1.5721	1.8606	2.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 202 / VIZORI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.2896	.3391	.2743	1.6712	1.6289	1.7284
2	.3391	.2591	.3222	.2591	1.7814	1.6118	1.704
3	.3391	.2286	.3222	.2286	1.8679	1.5432	1.7532
4	.4338	.2286	.3561	.2134	1.7695	1.6975	1.933
5	.4239	.2743	.407	.2896	1.8351	1.8347	1.9334
6	.407	.3201	.4239	.3353	1.8679	2.0178	2.0317
7		.3201	.4338	.3658	1.9334	2.1091	2.0645
10	1.5223	1.8623	1.9433	1.7231			
11	1.7635	1.9989	2.079	1.6198			
12	1.933	2.1704	1.9334	1.5895			
13	1.8778	2.1026	2.0008				
14	1.7394	2.0008	1.9006	1.4861			
15	1.7635	1.9595	1.9334	1.579	.1578	.2103	
16	1.8138	1.9989	1.8351	1.9204	.1543	.197	
17	1.7695	1.989		1.8138	.1658	.2328	
18	.0914	.0671		.1619	.1677	.1457	
19	.2591	.2883	.2743	.1457	.2134		.3561
20	.2591	.3584	.3048	.1943	.3353	.1781	.4031
21	.2896	.3772	.3353	.1638	.2896	.1619	.3721
22	.2896	.3961	.2896	1.5592	1.8347	1.8351	1.6975
23	.3201	.415	.2743	1.4083	1.7661	1.8461	1.8299
24	.373	.3048	.3391		1.5402	1.6975	1.8778
Max	1.933	2.1704	2.079	1.9204	1.9334	2.1091	2.0645
Min	.0914	.0671	.2743	.1457	.1543	.1457	.3561
Avg	.8745	.9186	.9024	.8666	1.1383	1.1842	1.5142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274047 / 33/11 KV VIZORI S/STN.

Feeder No / Name : 205 / EXPRESS FEEDER WATER
SUPPLY Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.4287	.5601	.3601	.5898	.5316	
2	.4578	.3601	.5601	.3258	.6009	.4973	.2622
3	.5087	.3258	.5601	.3086	.6706	.463	.2785
4	.6348	.3944	.5788	.4287	.6882	.6001	.3185
5	.6443	.4973	.6161	.6001	.7045	.6516	.3441
6	.6783	.5487	.5975	.6687	.763	.7202	.3768
7	.78	.583	.5788	.7202	.7362	.7545	.3932
8	.78	.6173	.695	.6687	.679	.6859	.1844
9	.6722	.6344	.5975	.5658	.7164	.6344	.1311
10	.5182	.6478	.4096	.6859	.7343	.6249	.3725
11	.5765	.6443	.4748	.6344	.6516	.5668	.3353
12	.5533	.6104	.5243	.6327	.6636	.4784	.3086
13	.4902	.5441	.4858	.6081	.6249	.3567	.192
14	.4752	.5079		.6009	.6173	.3429	.2675
15	.6133	.5898	.3932	.5693	.5357	.3567	.4725
16	.5506	.6554	.4917	.5401	.6622	.1067	.5093
17	.6062	.6483		.5468	.5639	.112	.4778
18	.4458	.5376		.5506	.6687	.1475	.6783
19	.6001	.3113	.4287	.6203	.6859	.2035	.5256
20	.6344	.4294	.5487	.5571	.6516	.2105	.6081
21	.6687	.6722	.6173	.5365	.6173	.1989	.5792
22	.6859	.6348	.4287	.6104	.5658	.2294	.5487
23	.6516	.6161	.4287	.5571	.583	.1802	.5053
24	.5228	.6001	.5975	.3944	.6371	.5658	.1802
Max	.78	.6722	.695	.7202	.763	.7545	.6783
Min	.4458	.3113	.3932	.3086	.5357	.1067	.1311
Avg	.5927	.5433	.5320	.5538	.6505	.4258	.3848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 201 / JAMBUDBET

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.4294		3.2579	3.3913
2		3.4637		3.2922	3.476
3		3.6808		3.3951	3.7134
4		3.6008		3.4294	3.8152
5		3.6866		3.5151	3.883
6		3.738		3.7723	3.9847
7		3.6866		3.9438	3.9847
10	3.8999				
13	.2713		.3018	.2743	
14	.3052		.3353	.2401	
15	.3052			.2401	
16	.3052			.2572	
17	.3391		.4024	.2915	
18	.3772		.4359	.3222	
19	.4409		.4359	.373	.724
20	.4748		.4694	.4239	.7621
21	.4239		.4359	.4748	.7621
22	3.2217		2.9835	3.2217	3.8009
23	3.3065		3.0514	3.3065	3.8914
24		3.4294		3.1722	3.3065
Max	3.8999	3.738	3.0514	3.9438	3.9847
Min	.2713	3.4294	.3018	.2401	.724
Avg	1.1392	3.5894	.9835	1.9581	3.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 202 / BABHULGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	1.4373	1.56	.2374	.3048	.2804	.2883
2	1.4403	1.4899	1.6108	.2543	.3048	.2804	.3222
3	1.4403	1.5775	1.6108	.2374	.3048	.3155	.3391
4	1.5089	1.5775	1.6956	.2883	.3048	.3155	.3391
5	1.5432	1.7528	1.8652	.3391	.3048	.3506	.373
6	1.5432	1.7528	1.8652	.373	.3048	.3429	.373
7	1.6461	1.8404	2.0348				
8	1.4403						
10				1.7147	1.9071	1.6108	1.7147
11				1.989	2.0576	1.95	1.8519
12				1.8861	2.0919	1.8652	
13	.2454	.1753	.1696	1.8519	2.0576	1.8991	
14	.2454	.1753	.1696	1.8176	2.0233	1.9669	
15	.2804	.1753	.017	1.8176	1.9719	1.8991	
16	.2804	.2279	.1865	1.8519	1.8861	2.0008	
17	.2804	.2454	.2035	1.8519	1.9281	1.7804	
18	.3155	.3506	.1865	.2858	.3121	.1696	
19	.3467	.3544	.2035	.3239	.3506	.1696	.3429
20	.3506	.3721	.2374	.3048	.3772	.2035	.3429
21	.3155	.3721	.2543	.3048	.3467	.2374	.3239
22	1.4022	1.5261	.2374	.3048	.3506	.2713	.3239
23	1.4022	1.5261	.2204	.3048	.3155	.2713	.3239
24	1.406	1.4022	1.56	.2374	.3048	.3121	.2543
Max	1.6461	1.8404	2.0348	1.989	2.0919	2.0008	1.8519
Min	.2454	.1753	.017	.2374	.3048	.1696	.2543
Avg	.9420	.9648	.8362	.8846	.9576	.8806	.5367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274115 / 33/11 KV SANGAM

Feeder No / Name : 203 / SANGAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4748		2.0348	1.989
2		.4748		2.0348	2.0576
3		.5087		2.1195	2.1262
4		.5765		2.1195	2.1948
5		.6104		2.2043	2.1434
6		.6443		2.2043	2.2291
7				2.1026	2.2291
10	2.2977	1.8204			
12	2.3663				
13	2.3663		.5935	.5487	
14			.5765	.583	
15	2.2539		.5935	.583	
16	2.2539		.6104	.6173	
17	2.2539		.6104	.6516	
18	.57		.6443	.6173	
19	.6104		.6443	.583	.7621
20	.6443			.6173	.8002
21	.6104		.5935		.8002
22	.5426		2.0576	1.8519	2.0698
23	.5087		2.1033	1.9204	2.0698
24		.5087		2.0454	1.9719
Max	2.3663	1.8204	2.1033	2.2043	2.2291
Min	.5087	.4748	.5765	.5487	.7621
Avg	1.4399	.7023	.9027	1.4133	1.8033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 201 / 11KV YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	3.1207		.3601	.3086	.3048	
2	.2743	.3086		.3429	.3429	.3048	
3	.2743	.3258		.3258	.3258	.3201	
4	.2743	.3258		.3601	.3258	.3353	
5	.3048	.3429		.3772	.3601	.3201	
6		.3429		.3944	.3601	.3353	
7	.3353			.3086			
8	.3353			.3086			
9	.3353	.3258		.2572	.3772	.381	
10				.3086		.381	.4287
11			.3353	.3429		.439	.4287
12			.3201	.3772		.4066	.463
13			.3353	.4115		.4207	.4115
14			.3506	.4287		.4207	.3772
15			.3353	.4287		.4435	.4115
16			.3353			.439	.4115
17			.3201				.4458
18	.2572		.3429	.3944			
19	.2915		.3944	.3429	.3658		.381
20	.3258		.3944	.3258	.3658		.381
21	.2915		.3772	.2915	.3506		.3658
22			.3601	.2915	.3353		.3506
23	.3086		.3772	.3086	.3201		.3353
24	.3048	.3944	.3086			.3048	.3258
Max	.3353	3.1207	.3944	.4287	.3772	.4435	.463
Min	.2572	.3086	.3086	.2572	.3086	.3048	.3258
Avg	.3002	.6859	.3491	.3470	.3448	.3704	.3941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 202 / 11KV GRAMIN

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	2.7435		3.0864	.3944	.3048	
2	2.5911	2.915		3.1722	.3944	.3048	
3	2.753	3.0864		3.1722	.3772	.3963	
4	2.915	3.1722		3.2065	.4115	.4268	
5	3.0769	3.2579		3.2579	.4115	.4268	
6	3.2388	3.3265		3.2579			
7	3.3198	3.2579		3.3436			
10						2.834	3.0864
11							3.1722
12							3.2236
13				.2572			
14			.3353	.2743			
15				.2743			
16			.3048				
17			.3048				
18	.1715		.4287	.3429			
19	.1886		.4115	.3772	.4572		.4268
20	.2058		.4115	.3601	.4572		.4268
21	.1886		.3772	.3429	.4268		.3963
22	2.4006		2.915	.3429	.3963		.3658
23	2.6578		3.1722	.3601	.3353		.3353
24	2.5911	3.1379	.3429			.3239	.3772
Max	3.3198	3.3265	3.1722	3.3436	.4572	2.834	3.2236
Min	.1715	2.7435	.3048	.2572	.3353	.3048	.3353
Avg	2.0636	3.1122	.9004	1.5893	.4062	.7168	1.3123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 203 / 11 KV CHOUDESHWARWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.1715	1.9719	2.2672	
2		.1886		.1715	2.0576	2.2672	
3		.1715		.1715	2.0576	2.2672	
4	.1677	.1715		.1715	2.1434	2.3482	
5	.1677	.1715		.1715	2.1434	2.4291	
6				.1715	2.4863	2.5911	
7					2.572	2.753	
10				2.4006			
11			2.915	2.6578			
12			2.915	2.6578			
13			2.753	2.6578			
14			2.672	2.6578			
15			2.5149	2.572			
16			2.4387				
17			2.4291				
18	.1715		.1715	.1715			
19	.1715		.1715	.1715	.1829		.1981
20	.1715		.1715	.1715	.1981		.1981
21	.1715		.1715	.1715	.1981		.1981
22	.1715		.1715	1.7147	2.1052		1.9814
23	.1715		.1715	1.8861	2.2672		2.1862
24		.1715	1.8861			2.3482	
Max	.1715	.1886	2.915	2.6578	2.572	2.753	2.1862
Min	.1677	.1715	.1715	.1715	.1829	2.2672	.1981
Avg	.1706	.1772	1.5395	1.1622	1.6986	2.4089	.9524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 205 / GIRZANI FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433			.2439	
2	1.9433			.2439	
3	2.0243			.2743	
4	2.0243			.3048	
5	2.1862			.3048	
6	2.3482				
7	2.3482				
10				2.4291	
13		.1219			
14		.1524			
15		.1677			
16		.1829			
19			.3048		.3353
20			.3048		
21			.2743		.3048
22			.2743		.2896
23			.2591		.2743
24	1.8623			.2439	
Max	2.3482	.1829	.3048	2.4291	.3353
Min	1.8623	.1219	.2591	.2439	.2743
Avg	2.0850	.1562	.2835	.5778	.301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 206 / 11 kV MAHARSHINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.0288		1.0288	1.1145	.9145	
2	.7621	.9431		.9431	1.0288	.9145	
3	.7621	.9431		.9431	1.0288	.9145	
4	.7621	1.0288		.8573	.9431	.9907	
5	.9145	1.0288		.8573	.9431	.9907	
6	.9907	1.1145		1.1145	.9431	1.0669	
7	.9907			1.0288			
8				1.1145			
9	1.0669	1.2003		1.0288	1.0288	1.0669	
10				1.0288		1.0669	1.1145
11			1.1431	1.1145		1.1088	1.2003
12			1.1431	1.2003		1.2382	1.286
13			1.0669	1.2003		1.2012	1.2003
14			1.0669	1.2003		1.1827	1.2003
15			1.0669	1.1145			1.1145
16			1.0669			1.2382	1.1145
17			1.0974				1.0288
18	1.286		1.2003	1.2003			
19	1.286		1.1145	1.2003	1.1431		1.1431
20	1.2003		1.1145	1.1145	1.1431		1.1431
21	1.1145		1.0288	1.1145	1.1431		1.1431
22	1.1145		1.2003	1.0288	1.0669		1.0669
23	1.0288		1.2003	1.1145	.9907		.9907
24	.8383	1.1145	1.1145			.9145	2.2291
Max	1.286	1.2003	1.2003	1.2003	1.1431	1.2382	2.2291
Min	.7621	.9431	1.0288	.8573	.9431	.9145	.9907
Avg	.9920	1.0502	1.1160	1.0737	1.0431	1.0578	1.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274117 / 33/11KV YASHWANTNAGAR S/STN.

Feeder No / Name : 207 / Deshmukh Mala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1715		.1886	1.0974	.9717	
2	.1219	.1886		.1886	1.1488	.9717	
3	.1372	.1886		.2058	1.1488	1.0526	
4	.1524	.2058		.1886	1.166	1.1336	
5	.1524	.2058		.1886	1.166	1.2955	
6				.2058	1.286	1.3765	
7					1.3717	1.4251	
10				1.3717			
11			1.3117	1.4575			
12			1.3279	1.4575			
13			1.3765	1.3717			
14			1.3603	1.3717			
15			1.3765	1.4575			
16			1.3765				
17			1.3603				
18	.1029		.1543	.1372			
19	.1543		.1543	.1543	.1981		.2134
20	.1886		.1886	.1372	.2134		.2286
21	.1886		.1886	1.5775	.1981		.1981
22	.1715		.1715	1.166	.9717		.8907
23	.1715		.1886	1.1145	.9717		.8907
24	.1372	.1715	1.0974			.9717	1.1488
Max	.1886	.2058	1.3765	1.5775	1.3717	1.4251	1.1488
Min	.1029	.1715	.1543	.1372	.1981	.9717	.1981
Avg	.1500	.1886	.8309	.7745	.9115	1.1498	.5951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 201 / 11 KV CHAKORE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.442	.442	.4725	1.7071	1.9204	1.7985
2	.4572	.442	.4268	.4572	1.7071	1.9052	1.7985
3	.4572	.442	.4572	.4572	1.768	1.9052	1.829
4	.4877	.4877	.442	.4877	1.829	2.1033	1.9966
5	.4877	.5487	.4572	.5182	1.9204	2.2253	2.1033
6	.5182	.5944	.4572	.5487	2.0729	2.3167	2.2862
7	.5487		.4725	.5335	2.2862	2.3015	2.2558
10	2.6216	2.2558	2.4539	2.4082			
11	2.6063	2.3015		2.4844			
12	2.6368	2.3167	2.1186	2.4082			
13	2.5149	2.332	2.1948	2.3624	.2286	.2743	
14	2.271	2.3015	2.21	2.332	.2743	.3048	
15	2.3167	2.2253	2.21	2.2558	.2743	.3048	
16	2.271	2.1643	2.2253	2.1948	.2743	.3048	
17	2.1186	1.9814	1.9966	2.1186	.3048	.3048	
18	.2743	.3658	.3353	.3353	.3506	.3353	.3963
19	.4725	.4572	.4268	.4572	.4268	.4572	.4268
20	.4572	.4268	.4725	.4877	.4115	.4877	.4572
21	.4268	.4268	.4572	.4268	.3963	.442	.4877
22	.4877	.4572	.4725	1.7071	1.9662	1.9814	2.1186
23	.4725	.4572	.4572	1.6766	1.9509	1.9509	2.0576
24	.4572	.4572	.4572	.4725	1.6766	1.9204	1.8442
Max	2.6368	2.332	2.4539	2.4844	2.2862	2.3167	2.2862
Min	.2743	.3658	.3353	.3353	.2286	.2743	.3963
Avg	1.1736	1.1373	1.0306	1.2547	1.1487	1.2498	1.5612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 202 / 11 KV KONDBAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.9357	2.0119	2.21	.4572	.503	.3963
2	2.21	1.9357	2.0271	2.2253	.4877	.503	.3963
3	2.1338	1.9357	2.0729	2.2253	.4877	.4877	.3963
4	2.2558	2.0576	2.1033	2.3167	.4877	.5487	.4268
5	2.2862	2.1643	2.1643	2.3929	.5182	.5792	.4877
6	2.4234	2.4691	2.2862	2.4844	.5182	.5487	.5487
7	2.4996	2.3015	2.3472	2.4082	.6173	.5182	.4877
10					2.3167	2.4387	2.4691
11					2.4234	2.2558	2.4082
12					2.3472	2.1948	
13	.2286	.1981	.1981	.1829	2.3777	2.2558	
14		.2134	.2286	.1981	2.1338	2.1643	
15	.2439	.2286	.2439	.1981	2.0881	2.1643	
16	.3048	.2439	.2743	.2134	2.332	2.2558	
17	.3048	.2915	.3048	.2286	2.3015	2.2253	
18	.3658	.3963	.3506	.2743	.3506	.3506	.4268
19	.4572	.4572	.4268	.4877	.442	.4572	.442
20	.442	.4725	.4115	.4572	.4725	.442	.4877
21	.4115	.442	.3963	.4268	.4572	.4115	.503
22	2.0119	1.9814	2.2405	.4572	.503	.4268	.5944
23	1.9814	2.0119	2.2405	.4877	.4877	.4115	.4877
24	2.0576	1.9662	1.9814	2.21	.4572	.4877	.3963
Max	2.4996	2.4691	2.3472	2.4844	2.4234	2.4387	2.4691
Min	.2286	.1981	.1981	.1829	.3506	.3506	.3963
Avg	1.3751	1.2475	1.2795	1.1624	1.1393	1.1196	.7097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274143 / 33/11 kV ANANDNAGAR

Feeder No / Name : 204 / vaibhav agrotech ht
consumer Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0017	.0017	.0069	.0069	.0051	.0069	.0051
2	.0017	.0017	.0069	.0051	.0069	.0086	.0051
3	.0017	.0017	.0069	.0051	.0069	.0051	.0051
4	.0017	.0017	.0069	.0069	.0069	.0034	.0017
5	.0017	.0017	.0069	.0086	.0069	.0051	.0017
6	.0017	.0017	.0086	.0034	.0069	.0051	.0017
7	.0017	.0017	.0086	.0017	.0069	.0069	.0017
8	.0017	.0017	.0051	.0051	.0069	.0051	.0017
9	.0017	.0017	.0051	.0069	.0051	.0069	.0017
10	.0017	.0017	.0051	.0051	.0051	.0051	.0017
11	.0017	.0017	.0051	.0051	.0051	.0051	.0017
12	.0017	.0017	.0069	.0051	.0051	.0051	.0017
13	.0017	.0017	.0103	.0086	.0046	.0046	.0017
14	.0017	.0034	.0103	.0086	.0051	.0051	.0017
15	.0017	.0034	.0086	.0069	.0051	.0051	.0017
16	.0015	.0017	.0086	.0069	.0051	.0051	.0017
17	.0017	.0069	.0069	.0069	.0069	.0069	.0017
18	.0017	.0051	.0051	.0069	.0051	.0051	.0017
19	.0017	.0051	.0034	.0051	.0086	.0051	.0017
20	.0017	.0051	.0051	.0069	.0069	.0051	.0017
21	.0017	.0051	.0051	.0069	.0069	.0051	.0017
22	.0017	.0069	.0069	.0069	.0069	.0051	.0015
23	.0017	.0069	.0069	.0017	.0069	.0051	.0015
24	.0017	.0017	.0086	.0086	.0051	.0069	.0051
Max	.0017	.0069	.0103	.0086	.0086	.0086	.0051
Min	.0015	.0017	.0034	.0017	.0046	.0034	.0015
Avg	.0017	.0031	.0069	.0061	.0061	.0055	.0023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 201 / 11KV KHANDALI NAGTHANA SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5144	.4458	.5316	.823	.8573	.8573
2	.4801	.6001	.4458	.5144	.823	.8573	.8402
3	.5144	.6859	.4458	.4973	.8573	.8402	.8402
4	.5487	.7202	.4801	.6001	.8916	.8573	.8745
5	.6001	.7716	.5144	.6687	.9259	.8916	.9088
6	.7716	.8059	.7202	.7888	1.0117	.9088	.9945
7					1.0631	.823	.7888
10	1.0808	1.0277	.9391	1.0808			
11		1.0277	.9214	1.0808			
12		.9745	.8859	1.0985			
13		.8682	.815	.815	.3721		
14	.9214	.8682	.8859	.9391	.3898	.3898	
15	.8859	.7973		.9745		.3898	
16	.9214	.9088	.8859	1.0099	.3366	.3721	
17		.8573	.9602	.9431	.3429	.3601	
18	.4458	.4458	.4115	.3944	.4287	.3944	
19	.4973	.5144	.4801	.5316		.5144	.7373
20	.5144	.5144	.6687	.5144	.5144	.5487	.6001
21	.5487	.5144	.6001	.5144	.6001	.5487	.5487
22	.4801	.4801	.5487	.823	1.0288	.9602	.9431
23	.5144	.4801	.4801	.8402	.9259	.9088	.9259
24	.4801	.4801	.4458	.5144	.8059	.9088	.8745
Max	1.0808	1.0277	.9602	1.0985	1.0631	.9602	.9945
Min	.4458	.4458	.4115	.3944	.3366	.3601	.5487
Avg	.6285	.7075	.6490	.7464	.7142	.6851	.8257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 202 / 11KV DATTANAGAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		2.4863	2.4714
2		2.4348	2.4714
3		2.452	2.5072
4		2.572	2.5072
5		2.6063	2.561
6		2.692	2.6863
7		2.4691	2.7042
13		.3761	
14		.394	
15		.3761	
16		.3224	
17	.3772	.4119	
18	.5487	.4298	
19	.6344	.5731	.6859
20	.6001	.5731	.6001
21	.463	.5731	.5658
22	2.572	2.6326	2.452
23	2.5377	2.5072	2.4006
24		2.5206	2.5072
Max	2.572	2.692	2.7042
Min	.3772	.3224	.5658
Avg	1.1047	1.5475	2.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 203 / 11KV BHOSALE WASTI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	2.5377		2.452	.3506
2	2.21	2.5206		2.452	.3506
3	2.1338	2.4863		2.4348	.3658
4	2.1338	2.572		2.5206	.3658
5	2.0729	2.5377		2.572	.381
6	2.1033	2.572		2.572	.4572
7	2.2405	2.4177		2.6749	
10					2.3205
11					2.4806
12					2.4966
13		.2561		.2721	2.5126
14	.3201	.2881	.2721	.3201	2.4166
15	.3041	.2881	.3521	.3201	2.3525
16	.2241	.2896	.3681	.2881	2.5126
17	.3258	.2743	.3772	.2896	
18	.3429	.3048	.4458	.2896	
19	.3601	.3506	.4287	.3963	
20	.3772	.3506	.4115	.3658	
21	.3944	.3506	.4287	.3353	
22	2.6063		2.4863	.3506	
23	2.572		2.5377	.3506	
24	2.2862	2.572		2.4863	.3506
Max	2.6063	2.572	2.5377	2.6749	2.5126
Min	.2241	.2561	.2721	.2721	.3506
Avg	1.4010	1.3511	.8108	1.2496	1.4081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274196 / 33/11KV KHANDALI SUB STATION

Feeder No / Name : 204 / 11KV ITI KHADALI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0103	.0103	.0103	.0103	.0103	.0103	.0103
2	.0103	.0103	.0103	.0103		.0103	
3	.0103	.0103	.0103	.0103	.0103	.0103	.0103
4	.0103	.0103	.0103	.0103	.0103	.0103	.0103
5	.0103	.0103	.0103	.0103	.0103		.0103
6	.0103	.0103	.0103	.0103	.0103	.0103	.0103
7	.0103	.012	.012	.0103	.012	.0103	.012
8	.0166	.012	.0166	.0103	.0111	.012	.0129
9		.0129	.0148	.0129	.0111		.0129
10				.0148		.0111	.0129
11				.0111		.0111	
12						.0166	
13	.0111	.0111			.0129	.0111	.0111
14	.0111	.0111			.0111	.0011	.0129
15	.0111	.0111			.0129	.0111	.0111
16	.0111		.0111	.0111	.0148	.0111	.0111
17	.0103		.0103		.012		.0103
18	.0103		.0103	.0103	.012		.0103
19	.0103		.0103		.0103	.0103	.0103
20	.0103	.0103	.0103	.0103	.0103	.0103	.0103
21	.0103	.0103	.0103	.0103	.0103	.0103	
22	.0103	.0103	.012		.0103	.0103	.0103
23	.0103		.0103	.0103	.0103	.0103	.0103
24	.0103	.0103		.0103	.0103	.0103	.0103
Max	.0166	.0129	.0166	.0148	.0148	.0166	.0129
Min	.0103	.0103	.0103	.0103	.0103	.0011	.0103
Avg	.0108	.0108	.0112	.0108	.0112	.0104	.0110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 201 / BABULGOAN FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	1.1498	1.0031	.3163	.3269	.3001	.3479
2	1.2003	1.1498	1.085	.3479	.3286	.3418	.3479
3	1.2146	1.1984	1.1012	.3479	.3286	.3001	.3637
4	1.2163	1.1797	1.1142	.3795	.3567	.3864	.3795
5	1.166	1.2163	1.1227	.4428	.3858	.4001	.4111
6	1.1822	1.2146	1.1498	.4744	.3121	.4001	.4586
7	1.1822	1.1984	1.166			.3001	
10				1.2955	1.2955	1.3279	
11				1.2793	1.2631	1.3279	1.439
12				1.3117	1.247	1.3108	
13	.1572	.1486	.1429	1.2793	1.2631	1.3441	
14	.1429		.1715	1.1822	1.247	1.2654	
15	.1429	.1286	.1337	1.2793	1.247	1.2193	
16	.1429	.1572	.1429	1.2955	1.2631	1.2186	
17	.1858	.1715	.1572	1.2186	1.2003	1.2163	
18	.3001		.2372	.2778	.2572	.2214	1.1561
19	.3429	.3144	.2846	.2972	.3286	.253	.2652
20	.4001	.4012	.3953	.2972	.3864	.3321	.2984
21	.3286	.3144	.3795	.3241	.3429	.3637	.3647
22	1.1498	1.1012	.3637	.3001	.3429	.3479	.3144
23	1.166	1.1174	.3637	.3353	.3286	.3637	.3286
24	1.2146	1.1336	1.0526	.3321	.3001	.3429	.3637
Max	1.2308	1.2163	1.166	1.3117	1.2955	1.3441	1.439
Min	.1429	.1286	.1337	.2778	.2572	.2214	.2652
Avg	.7403	.7821	.6088	.6959	.6834	.6765	.4885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ I SUB-DN.[100] BU 6335

Substation No/ Name :- 274198 / 33/11 kv BABULGOAN SUB

STATI

Feeder No / Name : 202 / WAFEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1429	.1486	1.4632	1.2146	1.4899	1.4327
2	.1715	.1572	.1429	1.5546	1.2146	1.5223	1.4685
3	.1572	.1572	.1715	1.6078	1.1728	1.5384	1.5384
4	.1858	.1692	.1429	1.5893	1.247	1.4842	1.5402
5	.2	.2172	.1457	1.587	1.1873	1.5708	1.5061
6	.2	.2143	.1269	1.5893	1.2146	1.587	1.4899
7				1.6518	1.1822	1.5223	1.6385
10	1.8785	1.8299	1.9271				1.3117
11	1.9919	1.9757	1.9524	.1715			
12	1.9595	2.0567	1.7833	.0714			
13	1.7166	1.9433	1.7985	.0572	.0857	.0949	
14	1.9109		1.9006	.0743	.1189	.1107	
15	1.7652		1.8785	.1082	.1143	.1107	
16	1.8623	1.8947	1.8785	.1286	.1143	.1265	
17	1.7814	1.8299	1.6404	.1486	.1429	.1423	
18	.1715		.1581	.1572	.1429	.1581	.1326
19	.2	.0572	.2056	.1715	.1715	.1898	.1326
20	.2	.2	.1898	.1932	.1858	.2056	.1326
21	.1858	.2	.1423	.2	.1715	.2214	.2984
22	.1858	.1715	1.5546	1.07	1.4737	1.5384	1.3375
23	.1715	.1715	1.5546	1.1822	1.5223	1.5565	1.4899
24	.2	.1572	.1429	1.4969	1.1984	1.5384	1.4661
Max	1.9919	2.0567	1.9524	1.6518	1.5223	1.587	1.6385
Min	.1572	.0572	.1269	.0572	.0857	.0949	.1326
Avg	.8222	.7525	.9327	.7749	.7303	.8794	1.1277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 201 / 11KV JAMBHUD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3224	.2534	.3582	.362	2.2386	2.4539
2	.2896	.2865	.2534	.3224	.3258	2.2386	2.4188
3	.3258	.2865	.2896	.2865	.3258	2.2386	2.1033
4	.3258	.2865	.2896	.2865	.362	2.2923	2.2786
5	.3258	.3582	.3258	.3224	.3982	2.3998	2.2786
6	.2534	.3582	.3258	.3582	.3982	2.5072	2.3137
7	.2896	.3582	.2896	.2865	.3982	2.8117	2.5415
8	.2896	.394	.2715	.2865	.362	.2507	.2534
9	.2715	.362	.2686	.2896	.2715	.2896	.2507
10	2.3137	2.8296	2.7221	2.524	2.191	.362	.2865
11	2.6642	2.9012	2.9371	2.5941	2.4539	.362	.4477
12	2.8746	2.8296	2.8654	2.8921	2.489	.362	.3582
13	2.8746	2.9371	2.6147	2.7694	2.489	.362	.3224
14	2.6642	2.7759	2.5789	2.6642	2.489	.3258	.2865
15	2.5941	2.7759	2.5431	2.5941	2.4539	.3258	.2865
16	2.6642	2.7938		2.6642	2.4539	.362	.3224
17	2.6505	2.7168		2.5789	2.5431	.3982	.3258
18	.2865	.2534		.2172	.2507	.2715	.362
19	.2865	.2896		.362	.1791	.362	.362
20	.3582	.3258	.2896	.362	.3582	.362	.2896
21	.3582	.2896	.362	.2896	.3582	.362	.2896
22	.3582	.2715	.362	.3258	2.1849	2.4539	2.5072
23	.2865	.2715	.3982	.3258	2.2207	2.4539	2.5431
24	.3258	.2865	.3258	.3582	.362	2.2207	2.4539
Max	2.8746	2.9371	2.9371	2.8921	2.5431	2.8117	2.5431
Min	.2534	.2534	.2534	.2172	.1791	.2507	.2507
Avg	1.0925	1.1483	1.0283	1.0966	1.1950	1.1922	1.1807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 202 / 11KV KONDARPATTA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7328	1.7652	1.749	1.8461	1.6194		
2	1.7166	1.7328	1.749	1.8138	1.6194		
3	1.7166	1.7814	1.749	1.7814	1.6194		
4	1.6842	1.7814	1.7814	1.7814	1.6194		
5	1.7814	1.8299	1.7814	1.8623	1.6194		
6	1.9433	1.8785	1.8299	1.9757	1.7814		
7	1.8623	2.0405	2.0243	2.1052	1.9919		
10						2.0243	1.749
11						2.1862	2.1862
12						2.2672	2.1862
13						2.2672	2.1862
14						2.2672	2.1376
15						2.2672	2.1376
16						2.3482	2.2024
17						2.3482	2.2024
22	1.7004	1.7328	1.8138	1.7204			
23	1.7328	1.7166	1.8138	1.7004			
24	1.7328	1.7652	1.7166	1.8461	1.7004		
Max	1.9433	2.0405	2.0243	2.1052	1.9919	2.3482	2.2024
Min	1.6842	1.7166	1.7166	1.7004	1.6194	2.0243	1.749
Avg	1.7603	1.8024	1.8008	1.8433	1.6963	2.2470	2.1235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 203 / NEWARE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.6518	1.7814
2						1.6518	1.7814
3						1.6194	1.7814
4						1.587	1.8138
5						1.587	1.8138
6						1.7814	1.8623
7						2.0243	1.9757
10	1.9433	1.9271	1.8138	1.9433	2.1052		
11	2.0729	1.9433	2.0891	2.0567	2.1538		
12	2.1052	1.9757	2.0243	2.1862	2.1052		
13	2.0567	2.0567	2.0243	2.0729	2.0729		
14	1.9433	2.0729	2.0243	2.0405	2.0729		
15	1.9433	2.0081	2.0729	2.0729	2.1052		
16	2.0243	2.0405		2.1052	2.1052		
17	2.0243	1.9433		2.1862	1.9757		
22					1.7004		1.9757
23						1.6194	1.9919
24						1.6194	1.7814
Max	2.1052	2.0729	2.0891	2.1862	2.1538	2.0243	1.9919
Min	1.9433	1.9271	1.8138	1.9433	1.7004	1.587	1.7814
Avg	2.0142	1.9960	2.0081	2.0830	2.0441	1.6824	1.8559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 204 / 11KV NADURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4089	1.4089	1.0202	1.166	.8421		
2	1.3765		1.0202	1.1498	.8097		
3	1.3765	1.3765	1.0526	1.1336	.8097		
4	1.3765	1.3765	1.0526	1.1336	.8097		
5	1.4251	1.3927	1.0688	1.1822	.8421		
6	1.4251	1.4089	1.0364	1.1822	.8421		
7	1.4089	1.4089	1.0688	1.2146	.8907		
10						1.8623	2.1052
11						2.1052	2.1376
12						2.1862	2.17
13						2.1862	2.17
14						2.1376	2.2024
15						2.1862	2.2024
16						2.2996	2.2348
17						2.1862	2.1862
22	1.3765	1.0202	1.1336	.8097			
23	1.3765	1.0526	1.166	.8421			
24	1.4089	1.4089	1.0526	1.166			
Max	1.4251	1.4089	1.166	1.2146	.8907	2.2996	2.2348
Min	1.3765	1.0202	1.0202	.8097	.8097	1.8623	2.1052
Avg	1.3959	1.3171	1.0672	1.0980	.8352	2.1437	2.1761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274040 / 33/11KV NEWARE S/SN.

Feeder No / Name : 205 / NEWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7733	.6602	.7545	.7545	.7545	.7468
2	.7922	.8299	.679	.7733	.8488	.7922	.8402
3	.8299	.8299	.7545	.811	.9431	.8865	.9335
4	.9054	.9242	.8676	.8488	1.0374	1.0185	1.0269
5	1.0185	1.0185	1.0185	.9619	1.1317	1.094	1.0642
6	1.094	1.1506	1.1317	1.0562	1.1317	1.1317	1.1203
7	.7922	.8299	.7545	.8488	.8488	.8488	.8029
8	.6602	.6413	.6413	.679	.6602	.6602	.6908
9	.4572	.5041	.5658	.6219	.5487	.5601	.5281
10	.3658	.4108	.4904	.4207	.4572	.4668	.4715
11	.3658	.3734	.415	.439	.3658	.4668	.3772
12	.3658	.3734	.4338	.3658	.3658	.4668	.4715
13	.3658	.3734	.3772	.3658	.3658	.4668	.4715
14	.3658	.3361	.3772	.3292	.3658	.3734	.415
15	.3658	.3361	.3395	.3696	.3658	.4668	
16	.3658	.3734		.3658	.4024	.4668	.3772
17	.4338	.3658		.4108	.4715	.4207	.3734
18	.6413	.5228		.5041	.6036	.4668	.4108
19	.8865	.6722		.7468	.8488	.7095	.7842
20	.811	.7842	.8962	.8402	.8488	.8402	.8402
21	.7545	.8215	.8215	.7468	.7545	.7468	.7468
22	.7545	.7095	.7842	.7468	.7167	.7095	.7095
23		.6722	.7468	.7468	.7167	.7095	.7468
24	.7167	.7356	.6602	.7356	.7167	.6602	.7468
Max	1.094	1.1506	1.1317	1.0562	1.1317	1.1317	1.1203
Min	.3658	.3361	.3395	.3292	.3658	.3734	.3734
Avg	.6462	.6401	.6708	.6454	.6780	.6743	.6824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 201 / 11KV SHRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	1.2955	1.2955	1.3717	1.448	1.448
2	.3048	.1524	1.2193	1.2955	1.3717	1.448	1.3717
3	.3048	.1524	1.2193	1.3717	1.448	1.448	1.3717
4	.3048	.1524	1.3717	1.3717	1.5242	1.5242	1.4327
5	.3048	.1524	1.3717	1.5242	1.5242	1.6004	1.5546
6	1.6766	1.6004	1.7528	1.829	1.6766	1.5242	1.7528
7	1.829	1.9814	1.9204	1.829	1.829	1.5242	1.9052
8	.1524	.0762	.2286	.1524	.1524	.2286	.2743
9	.1524	.0762	.1981	.1524	.1524	.2286	.2439
10	.0762	.0762	.1829	.0857	.1677	.1829	.2286
11	.0762	.0762	.1829	.0857	.1524	.1677	.1524
12	.0762	.0914	.1524	.0857	.1524		.1524
13	.0762	.0914	.1524	.0857	.1524	.1677	
14	.1524	.0914	.1524	.0857	.1524	.1524	
15	.1524	.0914	.1524	.0857	.1524	.1524	
16	.1524	.1524	.1524	.0857	.1524	.1829	
17	.1524	.1829	.1524	.0857	.1524	.1981	
18		.2286	.2286	.0857	.2286	.3048	
19	.1524	.3353	.0305	.1715	.2286	.381	.2286
20	.1524	.3353	.3048	.1715	.3048	.4268	.3048
21	.1524	.3048	.3048	.1715	.3048	.4268	.3048
22	.1524	1.2193	1.0669	1.3717	1.2955	1.2955	.3048
23	.1524	1.2955	1.2193	1.5432	1.2955	1.3717	.3048
24	.2286	.1524	1.2955	1.2955	1.3717	1.3717	1.448
Max	1.829	1.9814	1.9204	1.829	1.829	1.6004	1.9052
Min	.0762	.0762	.0305	.0857	.1524	.1524	.1524
Avg	.3114	.3842	.6795	.6799	.7214	.7720	.8213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 202 / 11 KV NARALACHIWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1524	.1067	.1067	.0914	.0914	.1219
2	.1524	.1524	.1067	.1067	.0914	.0914	
3	.1524	.1524	.1067	.1067	.1067	.1067	.1524
4	.1524	.1524	.1372	.1219	.1219	.1219	.1677
5	.1524	.1524	.1524	.1219	.1219	.1372	.1677
6	.1219	.1372	.1524	.1219	.1524	.1372	.1524
7	.1067	.1067	.1372	.1219	.1524	.0914	.1219
8	.0914	.0762	.1219	.1067	.0914	.0914	.0762
9	.0914	.0762	.0762	.1067	.0914	.0914	.061
10	1.3717	.9145	1.1736	1.2003	1.1431	1.0669	1.1431
11	1.5242	1.0669	1.2193	1.3717	1.2193	1.4022	1.2193
12	.1219	1.2193	1.3108	1.3717	1.1431	1.1279	1.2955
13	.0762	1.2193	1.2193	1.1431	1.1431	1.1431	
14	.0914	1.2193	1.1431	1.286	1.1431	1.1584	
15	.1067	1.2193	1.1431	1.2193	1.0669	1.1584	
16	.0762	1.1888	1.0974	1.286	1.0669	1.1888	
17	.0762	1.1736	1.0669	1.286	.9907	1.1888	
18		.1219	.1219	.12	.1067	.1219	
19	.1524	.1219	.1219	.1715	.1067	.1219	.1219
20	.1524	.1219	.1219	.1715	.1067	.1219	.1219
21	.1524	.1219	.1219	.1715	.1067	.1219	.1219
22	.1524	.1219	.1219	.12	.0914	.1219	.884
23	.1524	.1219	.1067	.12	.0914	.1219	.884
24	.1372	.1524	.1067	.1067	.0914	.0914	.1219
Max	1.5242	1.2193	1.3108	1.3717	1.2193	1.4022	1.2955
Min	.0762	.0762	.0762	.1067	.0914	.0914	.061
Avg	.2385	.4693	.4706	.5069	.4433	.4674	.4079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 203 / 11KV NIMGAON VILLAGE

AG/SDT Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.0914	.1524	.1524
2	.1524	.1524	.1524	.1524	.0914	.1524	.1524
3	.1524	.1524	.1524	.1524	.0762	.1524	.1524
4	.1524	.1524	.1524	.1524	.0762	.1524	.1524
5	.1524	.1524	.1524	.1524	.0914	.1524	.1524
6	.1524	.0762	.1524	.1524	.1067	.1524	.1524
7	.1524	.0762	.1524	.0762	.1067	.1524	.1524
8	.1524	.0762	.0762	.0762	.1067	.0762	.1524
9	.1524	.0762	.0762	.0762	.0914	.0762	.0762
10	1.0669	.6859	.8383	.7621	.7621	.6859	.6097
11	1.2193	.7621	.7621	.9145	.7316	.7621	.6859
12	.0762	.9907	.7621	.9145	.7621	.7621	.6859
13	.0762	.9145	.7621	.9907	.8383	.7621	
14	.0762	.9145	.7621	.9907	.7621	.6097	
15	.0762	.9145	.6859	1.1145	.6859	.6097	
16	.0762	.8383	.6859	1.0288	.6097	.6097	
17	.0762	.7621		.9431	.6097	.6097	
18		.1524	.6859	.0857	.1524	.1524	
19		.1524	.1524	.1029	.1524	.1524	.1524
20	.1524	.1524	.1524	.1372	.1524	.1524	.1524
21	.1524	.1524	.1524	.1372	.1524	.1524	.1524
22	.1524	.1524	.1524	.12	.1524	.1524	.6097
23	.1524	.1524	.1524	.1029	.1524	.1524	.6097
24	.1524	.1524	.1524		.0914	.1524	.1524
Max	1.2193	.9907	.8383	1.1145	.8383	.7621	.6859
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.2217	.3715	.3512	.4125	.3169	.3207	.2837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 204 / NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.061	.0762	.0914	.0762	.0762
2	.0914	.0762	.0914	.0762	.0914	.0762	.0762
3	.1067	.0762	.1219	.0762	.0914	.0914	.0914
4	.1219	.0914	.1219	.0914	.1067	.0914	.1067
5	.1524	.0914	.1372		.1219	.1067	.1067
6	.1372	.1067	.1219	.1067	.1219	.1219	.1067
7	.1219	.1219	.1067	.1067	.1372	.1372	.0914
8	.0762	.0914	.0914	.0762	.0914	.0914	.0914
9	.0762	.0914	.0762	.0762	.0914	.0914	.0762
10	.061	.0762	.0762	.0857	.061	.0762	.0091
11	.061	.0762	.061	.0857	.061	.0762	.0914
12	.061	.061	.061	.0686	.0457	.0762	.1067
13	.061	.061	.061	.0686	.0457	.061	
14	.0457	.061	.061	.0686	.061	.0457	
15	.0457	.061	.0762		.061	.0457	
16	.0457	.061	.0762	.0857	.0762	.061	
17	.0457	.0762	.0914	.0857	.0762	.0762	
18		.0914	.1067	.1029	.0762	.1067	
19		.1067	.1067	.12	.0914	.1219	
20	.0914	.1219	.0914	.1372	.0914	.1219	
21	.1067	.1067	.0762	.1219	.0914	.0914	
22	.0914	.1067	.0762	.12	.0762	.0914	
23	.0914	.0762	.0762	.1029	.0762	.0914	
24	.0762	.0914	.061	.0762	.0914	.0762	.0762
Max	.1524	.1219	.1372	.1372	.1372	.1372	.1067
Min	.0457	.061	.061	.0686	.0457	.0457	.0091
Avg	.0838	.0857	.087	.0916	.0844	.0876	.0851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 205 / naganemala
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.884	.8383	.6097	.6097	.7621
2	.1524	.1524	.8383	.8383	.6097	.6859	.7621
3	.1524	.1524	.7621	.8383	.6859	.7621	.7773
4	.1524	.1524	.7621	.7621	.6859	.7621	.823
5	.1524	.1524	.7164	.7621	.7621	.8383	.8078
6	.8383	.7621	.9907	.7621	.7621	.8383	.8383
7	.9145	.9907	1.0212	.9145	.8383	.9907	.8535
8	.0762	.0914	.1067	.0762	.0762	.0762	.1219
9	.061	.0914	.061			.0762	.0762
10	.061	.0762	.061	.0857		.061	.061
11	.061	.0762	.0457	.0857	.061	.061	.061
12	.0762	.061	.0457	.0686	.061	.061	.061
13	.0762	.061	.0457	.0686	.0457	.0457	
14	.061	.061	.0457	.0686	.0457	.0457	
15	.0457	.061	.0457	.0857	.0457	.0457	
16	.061	.061	.061	.0857	.061		
17	.061	.061	.061	.0857	.061		
18		.1067	.061	.1715	.0914	.1219	
19	.1524	.1372	.1524	.1715	.0762	.1372	.1524
20	.1524	.1372	.1524	.1715	.1219	.1372	.1524
21	.1524	.1372	.1524		.1372	.1372	.1524
22	.1524	.7316		.6001	.5335	.6097	.1524
23	.1524	.8535	.8383	.6859	.5335	.7468	.1524
24	.1524	.1524	.884	.8383	.6097	.6097	.8078
Max	.9145	.9907	1.0212	.9145	.8383	.9907	.8535
Min	.0457	.061	.0457	.0686	.0457	.0457	.061
Avg	.1769	.2280	.3824	.4120	.3416	.3845	.4208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 206 / jay khanderaya
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1524	.1067	.1067	.0914	.0762	.1219
2	.1219	.1524	.1067	.0914	.0914	.0914	.1219
3	.1372	.1524	.1067	.0914	.0914	.0914	.1219
4	.1372	.1524	.1067	.0914	.0914	.0914	.1372
5	.1524	.1524	.1219	.0762	.1067	.1067	.1524
6	.1067	.1219	.1219	.0762	.1067	.1067	.1524
7	.1067	.1219	.1219	.0762	.1067	.0914	.1067
8	.0762	.1067	.061	.0762	.0914	.0762	.0762
9	.0762	.0914	.061	.0762	.0914	.0762	.061
10	1.0669	.6859	.6249	.7716	.9907	.9145	
11	1.2193	.7621	1.1584	.8573	1.0517	.9755	
12	.0762	.9145	1.1584	.8573	.9907	.9907	
13	.0762	1.0669	1.1431	1.0288	.9907	.9145	
14	.061	1.0669	1.0669	1.0288	.9145	.7926	
15	.061	1.0669	1.0669	.8573	.9145	.7926	
16	.061	.9297	1.0669	.8573	.9145	.7621	
17	.061	.7926	.9145	.8573	.884	.7621	
18		.1219	.1219	.1029	.0914	.1067	
19	.1524	.1219	.1219	.1372	.0914	.1219	
20	.1524	.1219	.1219	.1372	.0914	.1219	
21	.1524	.1219	.1219	.1715	.0914	.1219	
22	.1524	.1219	.1067	.12	.0914	.1219	
23	.1524	.1219	.1067	.12	.0914	.1219	
24	.1067	.1524	.1067	.1067	.0914	.0762	.1219
Max	1.2193	1.0669	1.1584	1.0288	1.0517	.9907	.1524
Min	.061	.0914	.061	.0762	.0914	.0762	.061
Avg	.1988	.3906	.4134	.3655	.3817	.3544	.1174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 207 / MAULI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1524	.1524	.1524	.1524
2		.1524	.1524	.1524	.1524	.1524	.1524
3	.1219	.1524	.1524	.1524	.1524	.1524	.1524
4		.1524	.1524	.1524	.1524	.1524	.1524
5		.1524	.1524	.1524	.1524	.1524	.1524
6		.0762	.1524	.0762	.1524	.1524	.1524
7		.0762	.1524	.0762	.1524	.1524	.1524
8		.0762	.0762	.0762	.0762	.0762	.1524
9			.0762		.0762	.0762	.0762
10			1.2193	1.1145	1.0669	1.2193	1.0669
11		1.0669	1.2193	1.286	1.2193	1.3717	1.0669
12		1.2193	1.0669	1.286	1.2193	1.0669	.9145
13		1.2193	1.0669	1.3717	1.2193	1.0669	
14		1.0669		1.3717	1.1431	.9145	
15		1.0669	1.0669	1.3717	1.1431	.9145	
16		1.0669	1.0669	1.286	1.0669	.9145	
17		.1524	1.0669	1.2003	1.0669	.9145	
18		.1524	.9907	.0857	.1524	.1524	
19	1.0669	.1524	.1524	.1715	.1524	.1524	.1524
20	1.2193	.1524	.1524	.1715	.1524	.1524	.1524
21	.1524	.1524	.1524	.1715	.1524	.1524	.1524
22	.1524	.1524	.1524	.1715	.1524	.1524	.9145
23	.1524	.1524	.1524	.1715	.1524	.1524	.9145
24		.1524	.1524	.1524	.1524	.1524	.1524
Max	1.2193	1.2193	1.2193	1.3717	1.2193	1.3717	1.0669
Min	.1219	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.4776	.4053	.4738	.5380	.4763	.4445	.3768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 208 / KESHAVNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.5792	.5335	.5335	.4572	.4877
2	.1067	.0914	.6097	.4572	.5335	.5335	.4877
3	.1067	.0914	.6097	.4572	.6097	.5335	.4725
4	.1219	.1067	.6401	.5335	.6097	.6097	.4725
5	.1219	.1067	.6554	.6097	.6859	.6097	.4877
6	.4572	.6097	.8383	.6097	.7621	.6097	.6097
7	.5335	.7621	.6859	.6554	.7621	.6097	.6554
8	.0762	.0914	.0762	.061	.061	.0762	.1067
9	.0762	.0762	.061	.061	.061	.0762	.061
10	.061	.0762	.0762	.0686	.061	.061	
11	.061	.061	.0762	.0686	.061	.0457	
12	.061	.061	.061	.0686	.061	.0305	
13	.0762	.061	.061		.0457	.0305	
14	.0762	.061	.061	.0686	.061	.0305	
15	.0762	.061	.061	.0686	.061	.0305	
16	.061	.0457	.061	.0686	.061	.0457	
17	.061	.0457	.061	.0686	.061	.0457	
18		.0762	.061	.1029	.0914	.0762	
19	.1524	.1067	.0762	.1372	.0914	.1067	
20	.1524	.1067	.0914	.1715	.1067	.1067	
21	.1524	.1067	.0914	.1372	.1067	.1067	
22	.1524	.4268	.4572	.4287	.4572	.3963	
23	.1067	.5335	.4572	.5144	.4572	.4572	
24	.0914	.1067	.5487	.5335	.4572	.4572	.4572
Max	.5335	.7621	.8383	.6554	.7621	.6097	.6554
Min	.061	.0457	.061	.061	.0457	.0305	.061
Avg	.1319	.1651	.2940	.2819	.2858	.2559	.4298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274041 / NIMGAON

Feeder No / Name : 209 / BALIRAJA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	1.0364	.9145	.6097	.8383	.8383
2	.0762	.0762	.9907	.7621	.6097	.8383	.8383
3	.0914	.0762	.9907	.7621	.6859	.8383	.8688
4	.0914	.0914	.9755	.7621	.7621	.9145	.884
5	.0914	.0914	.9755	.7621	.7621	.9907	.8688
6	.9145	.7621	.9907	.8383	.8383	1.0669	.9145
7	1.0364	.9907	.9755	.9145	.8383	1.0669	.9297
8	.0762	.0914	.061	.061	.061	.0762	.061
9	.061	.0914	.0457	.061	.061	.0762	.061
10	.061	.0914	.0457	.0686	.061	.061	
11	.061	.061	.0457	.0686	.061	.0457	
12	.0762	.061	.061	.0857	.061	.0305	
13	.0762		.061	.0857	.061	.0305	
14	.0762		.0061	.0686	.061	.0305	
15	.0762		.061	.0686	.0457		
16	.0457	.0457	.061	.0686	.0457		
17	.0457	.061	.061	.0686	.0457		
18		.061	.0914	.1029	.0762	.061	
19	.0914	.061	.0914	.1029	.0762	.061	
20	.0914	.061	.0914	.1097	.0762	.061	
21	.0914	.061	.0914	.12	.0762	.061	
22	.0914	.823	.7621	.6001	.6859	.6859	
23	.0914	.9907	.8383	.6859	.6859	.7773	
24	.0762	.0914	1.0212	.9145	.6097	.7621	.823
Max	1.0364	.9907	1.0364	.9145	.8383	1.0669	.9297
Min	.0457	.0457	.0061	.061	.0457	.0305	.061
Avg	.1550	.2293	.4346	.3774	.3315	.4464	.7087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 201 / BACHERI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2291					
2		2.2291					
3		2.2291					
4		2.3148					
5		2.4006					
6		2.6578					
7		2.915					
18	.5316		.6001				
19	.7373		.7202				
20	.7545		.7202				
21	.6344		.6516				
22	2.7435		2.5206				
23	2.4863	2.6578	2.5206	2.4006	2.5892	2.5377	.5658
24	2.1776	2.2977	2.4691	2.3491	2.332	2.3148	2.2291
Max	2.7435	2.915	2.5206	2.4006	2.5892	2.5377	2.2291
Min	.5316	2.2291	.6001	2.3491	2.332	2.3148	.5658
Avg	1.4379	2.4368	1.4575	2.3749	2.4606	2.4263	1.3975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 202 / PILIV SECTION GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6344					
2		.6344					
3		.6344					
4		.6859					
5		.7888					
6		.9431					
7		.8573					
10	.4458						
11	.1886						
12	.1715						
13	.1886						
14	.1715						
15	.1543						
16	.3944						
17	.4115		.4458				
18	.6001		.6001				
19	.8573		.8916				
20	.9774		1.0117				
21	.9259		.9431				
22	.7545		.7545				
23	.6687	.6859	.6859	.6516	.6516	.6516	.5144
24	.6516	.6344	.6516	.6344	.6001	.6001	.583
Max	.9774	.9431	1.0117	.6516	.6516	.6516	.583
Min	.1543	.6344	.4458	.6344	.6001	.6001	.5144
Avg	.5041	.7221	.7480	.643	.6259	.6259	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 203 / CHANDAPURI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2003					
2		1.2003					
3		1.2003					
4		1.2346					
5		1.286					
6		1.3889					
7		1.7147					
18	.2401		.1886				
19	.2743		.2401				
20	.2743		.2743				
21	.2572		.2743				
22	1.2689		1.3203				
23	1.286	1.2689	1.3717	1.286	1.286	1.286	.2058
24	1.1145	1.2174	1.2517	1.2003	1.166	1.1831	1.1488
Max	1.286	1.7147	1.3717	1.286	1.286	1.286	1.1488
Min	.2401	1.2003	.1886	1.2003	1.166	1.1831	.2058
Avg	.6736	1.3013	.703	1.2432	1.226	1.2346	.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 204 / KUSMODE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601					
2		.3601					
3		.3601					
4		.3772					
5		.3944					
6		.4115					
7		.4287					
10	3.4294						
11	3.7723						
12	3.6008						
13	3.5151						
14	3.3093						
15	3.5494						
16	3.2922						
17	3.3265		3.0178				
18	.3601		.3258				
19	.4458		.4115				
20	.4115		.4115				
21	.3944		.4115				
22	.3772		.3944				
23	.3601	.3601	.3258	.3601	.2915	.3258	3.6008
24	.3258	.3772	.3772	.3258	.3429	.3086	.3086
Max	3.7723	.4287	3.0178	.3601	.3429	.3258	3.6008
Min	.3258	.3601	.3258	.3258	.2915	.3086	.3086
Avg	2.0313	.3810	.7094	.3430	.3172	.3172	1.9547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 205 / SULEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857					
3		.0857					
4		.0857					
5		.12					
6		.1715					
10	1.3203						
11	1.3375						
12	1.4746						
13	1.5432						
15	1.6118						
16	1.3032						
17	1.2346		1.2003				
18	.1029		.0857				
19	.1372		.1372				
20	.12		.1372				
21	.1372		.12				
22	.1029		.1029				
23	.1029	.0857	.1029	.1029	.1029	.12	.8916
24	.1029	.0857	.0857	.1029	.0857	.1029	.1029
Max	1.6118	.1715	1.2003	.1029	.1029	.12	.8916
Min	.1029	.0857	.0857	.1029	.0857	.1029	.1029
Avg	.7594	.1029	.2465	.1029	.0943	.1115	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 207 / Sheri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886					
3		.1886					
4		.1886					
5		.1886					
6		.2058					
10	1.8861						
11	1.9376						
14	2.1262						
15	1.8519						
16	2.0233						
17	1.7318		1.5775				
18	.1029		.1543				
19	.1715		.1886				
20	.2058		.2229				
21	.2229		.2229				
22	.1886		.2058				
23	.1886	.1886	.2058	.2572	.2572	.2401	1.8861
24	.1715	.1886	.1886	.2058	.2572	.2229	.2229
Max	2.1262	.2058	1.5775	.2572	.2572	.2401	1.8861
Min	.1029	.1886	.1543	.2058	.2572	.2229	.2229
Avg	.9853	.1911	.3708	.2315	.2572	.2315	1.0545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274042 / PILIV

Feeder No / Name : 208 / PILIV (URBAN) GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287					
2		.3944					
3		.3944					
4		.4115					
5		.463					
6		.5487					
7		.463					
10	.3944						
11	.3601						
12	.3772						
13	.3772						
14	.3429						
15	.3429						
16	.3601						
17	.3944		.3772				
18	.4287		.4287				
19	.4973		.463				
20	.5316		.5316				
21	.463		.463				
22	.4973		.4973				
23	.463	.4458	.4458	.4458	.3772	.4458	.4458
24	.3772	.4287	.4458	.4287	.4115	.3944	.463
Max	.5316	.5487	.5316	.4458	.4115	.4458	.463
Min	.3429	.3944	.3772	.4287	.3772	.3944	.4458
Avg	.4138	.4420	.4566	.4373	.3944	.4201	.4544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 201 / 11KV KALAMWADI.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.5242	1.6004	2.1338	.1829	.1677	.1524
2	1.829	1.6004	1.829	2.2862	.2134	.1829	.1829
3	1.9052	1.6766	1.9814	2.4387	.2286	.1981	.1981
4	2.0576	1.829	2.1338	2.5149	.2591	.2134	.2134
5	2.0576	1.9814	2.2862	2.7435	.2743	.2286	.2286
6	2.21	2.1338	2.3624	2.8959	.3048	.2439	.2439
7	2.2862	2.2862	2.3624	2.8197			
8	2.2862	2.4387	2.4387	2.5911			
9					3.0483	2.7435	2.8959
10					2.9721	2.6673	
11					2.8959	2.5911	
12					2.8197	2.4387	
13					2.5911	2.3624	
14					2.7435	2.2862	
15					3.0483	2.1338	
16					3.2769	2.1338	
19	.2439	.2286	.2743	.2896	.2134	.2134	.2134
20	.2286	.2439	.2591	.2743	.1981	.1981	.1981
21	.2134	.1981	.2439	.2591	.1829	.1829	.1829
22	.1981	.1829	.2134	.2286	.1829	.1677	.1829
23	.1829	.1677	.1981	.1981	.1677	.1524	.1829
24	1.5242	.1677	.1981	.1677	.1677	.1524	.1372
Max	2.2862	2.4387	2.4387	2.8959	3.2769	2.7435	2.8959
Min	.1829	.1677	.1981	.1677	.1677	.1524	.1372
Avg	1.3500	1.1899	1.3129	1.5601	1.2986	1.0829	.4010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 202 / 11KV TANDULWADI FEEDER. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.1981	.1829	.2286		.1524	.1829
2	.2134	.2134	.2134	.2591		.1677	.1981
3	.2439	.2286	.2439	.2591		.1829	.2134
4	.2743	.2439	.2896	.2896		.1981	.2286
5	.2896	.2591	.3353	.3048		.2134	.2439
6	.3201	.2743	.3506	.3353		.2286	.2591
9	1.6004	1.9814	1.0517				
10	1.5242	1.6004	1.5242				
11		1.2955	.9145				
12		.9907	.6097				
13		.7621	.5335	.8383			
14		.6859	.6097	.7621			
15		.6859	.5335	.8383			
16		.6859	.8383	.9145			
17					1.829	.2439	
18					1.5242	2.4387	
19	.2591	.2591	.3506	.2134	1.2193	2.2862	1.6766
20	.2439	.2286	.3048	.2286	1.0669	2.1338	1.6004
21	.2286	.2286	.2743	.2439	.9145	1.9814	1.3717
22	.2134	.2134	.2591	.2439	.7621	1.829	.9145
23		.1829	.2134	.2286	.6859	1.6766	.8383
24	.1829	.1829	.1677	.2134		.6097	1.5242
Max	1.6004	1.9814	1.5242	.9145	1.829	2.4387	1.6766
Min	.1829	.1829	.1677	.2134	.6859	.1524	.1829
Avg	.4455	.5700	.4900	.4001	1.1431	1.0245	.7710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 203 / SALMUKH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.7468	.7011	.6859	1.0822	.5639	.5639
2	.884	.8078	.8383	.7773	1.2346	.7164	.7164
3	.9602	1.0822	.9297	.8993	1.3413	.8383	.8078
4	1.2041	1.3413	1.0822	.9755	1.3717	1.0517	1.0212
5	1.2193	1.4175	1.326		1.4175	1.3565	1.2346
6	1.4022	1.5546	1.4327	1.2955	1.4632	1.3108	1.0974
8	.6859	1.0212	1.0364	.9907	1.0059	.7164	.6097
9	.7316	.5792	.4725	.8383	.7621	.6554	.4877
10	.7621	.6706	.6706	.6859	.9755	.6249	.6097
11	.7164	.7621	.6554	.442	.7316	.5335	.5792
12	.6097	.5182	.9602	.442	.5944	.5487	.6097
13	.8078	.381	.8993	.4268	.5335	.4725	
14	.6859	.4115	.8078	.4268	.4572	.442	
15	.8383	.4268	.6097	.4115	.5639	.5335	.6097
16	.442	.6859	.5335	.4115	.7164	.381	.5335
17	.6554	.8078	.7316	.442	.7468	.5639	.5182
18	.945	.6554	.823	.5182	.945	.6554	.5335
19	.8688	1.0822	.884	.6706	.9907	.8383	.6097
20	.9297	1.1279	.9145	.7316	.8688	.8688	.7468
21	.8078	.9602	.8078	.7621	.7773	1.0212	.7164
22	.7621	.884	.7468	.8078	.6554	.7164	.7011
23	.7164	.7773	.7011	.7926	.5639	.503	.6859
24	.5639	.6554	.6401	.6097	.7773	.503	.4572
Max	1.4022	1.5546	1.4327	1.2955	1.4632	1.3565	1.2346
Min	.442	.381	.4725	.4115	.4572	.381	.4572
Avg	.8224	.8416	.8350	.6838	.8946	.7137	.6881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 204 / Shendechinch
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1677	.1677	.1219	.8383	1.0669	.7621
2	.1372	.1829	.2134	.1372	.7621	1.2193	.8383
3	.1524	.1981	.2286	.1372	.6859	1.3717	.9145
4	.1677	.2134	.2743	.1524	.7621	1.448	.9907
5	.1829	.2286	.2743	.1829	.8383	1.5242	1.1431
6	.1981	.2439	.2896	.1981	.9907	1.6004	1.2955
7					1.6004	1.6766	1.3717
8					1.5242	1.7528	1.448
17	2.2862	1.9814	1.6766	1.829			
18	2.1338	2.1338	1.6004	1.6004			
19	.2286	1.6004	1.3717	1.3717	.2286	.2286	.2286
20	.2134	1.448	1.2193	1.2955	.2134	.2134	.2134
21	.1981	1.2955	1.2193	1.1431	.1829	.1981	.1981
22	.1829	1.1431	1.0669	1.0669	.1677	.1829	.1981
23	.7621	1.0669	.9145	.9907	.1524	.1677	.1981
24	.1524	.6097	.9907	.9145	.9145	.1372	.1524
Max	2.2862	2.1338	1.6766	1.829	1.6004	1.7528	1.448
Min	.1372	.1677	.1677	.1219	.1524	.1372	.1524
Avg	.5095	.8938	.8220	.7958	.7044	.9134	.7109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 205 / FALAWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1524	.1372	.1524	.6097	.9145	.6097
2	.1372	.1677	.1677	.1677	.5335	.9145	.6859
3	.1677	.1829	.1829	.1829	.4572	.9907	.7621
4	.1829	.1981	.1981	.1981	.5335	1.0669	.8383
5	.1981	.2134	.1981	.2286	.6097	1.2193	.9145
6	.1981	.2286		.2439		1.2955	.9907
7					1.3717	1.3717	1.1431
8					1.2193	1.448	1.3717
17	2.1338	1.829	1.448	1.5242			
18	1.9814	1.5242	1.2955	1.448			
19	1.5242	1.2193	1.0669	1.0669	.1981	.1677	.1829
20	1.1431	1.0669	.9145	.9907	.1829	.1524	.1829
21	1.0669	.9907	.8383	.8383	.1677	.1372	.1677
22	.9145	.8383	.7621	.7621	.1524	.1219	.1524
23	.8383	.7621	.6859	.6097	.1372	.1219	.1524
24	.1067	.7621	.6097	.6097	.6859	.1219	.1372
Max	2.1338	1.829	1.448	1.5242	1.3717	1.448	1.3717
Min	.1067	.1524	.1372	.1524	.1372	.1219	.1372
Avg	.7653	.7240	.6542	.6445	.5276	.7174	.5923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274043 / SALMUKH

Feeder No / Name : 207 / maloli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219		.1524	.1372	.1981	.1372	.1524
2	.1372	.1829	.1677	.1524	.2134	.1677	.1677
3	.1524	.1981	.1981	.1829	.2439	.1829	.1829
4	.1829	.2134	.2286	.1981	.2439	.1981	.1981
5	.2134	.2286	.2286	.1981	.2591	.2134	.2134
6	.2439	.2439	.2439	.2134	.2591	.2286	.2439
9	2.4387	2.6673	2.5149	2.2862			
10	2.2862	2.1338	2.3624	2.21			
11		1.5242	2.21	2.1338			
12		1.3717	2.0576	2.1338			
13	2.1338	1.2193	2.0576	2.0576			
14	2.0576	1.6004	1.9814	1.9814			
15	1.5242	2.0576	1.9814	1.9814			
16	2.0576	1.829	1.829	1.9052			
17					2.5911	2.2862	
18					2.4387	2.1338	
19	.1981	.2591	.2439	.2134	2.0576	1.9814	2.1338
20	.1829	.2439	.2286	.2286	1.9814	1.829	1.9814
21	.1677	.2134	.2134	.2439	1.9052	1.6766	1.7528
22	.1524	.1677	.1981	.2134	1.6766	1.6004	1.6004
23	.1372	.1372	.1677	.1981	1.5242	1.3717	1.5242
24	.1219	.1372	.1219	1.0669	.1677	1.3717	1.2193
Max	2.4387	2.6673	2.5149	2.2862	2.5911	2.2862	2.1338
Min	.1219	.1372	.1219	.1372	.1677	.1372	.1524
Avg	.8061	.8752	.9694	.9968	1.1257	1.0985	.9475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 201 / BONDLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	.3048	.2286	.2572	1.2955	1.6766	1.5242
2	1.7528	.3048	.2286	.2572	1.2955	1.6766	1.5242
3	1.7528	.3048	.2286	.3429	1.2193	1.829	1.6004
4	1.829	.3048	.2286	.3429	1.2955	1.829	1.6004
5	1.9052	.3048	.3048	.4287	1.5242	1.9052	1.6766
6	1.9814	.3048	.3048	.4287	1.829	1.9052	1.9052
7	2.2862				2.2862	2.3624	2.21
10		1.829	1.829	2.0576			
11		1.9814	1.9814	2.1338			
12		1.9052	1.9814	2.2291			
13		1.829	1.829	1.9052			
14		1.5242	1.829	1.9052			
15		1.448	1.829	1.9052			
16		1.6766	1.6766	2.1338			
17		1.829	1.6766	1.9052			
19	.543	.3048	.381	.4287	.3048	.381	.3048
20	.4525	.3048	.3048	.3429	.3048	.4572	.3048
21	.4525	.3048	.3048	.3429	.3048	.381	.3048
22	.362	.2286	.3048	1.6766	1.5242	1.5242	1.6766
23	.362		.2286	1.5242	1.5242	1.6004	1.7528
24	1.6004	.362	.2286	.2572	1.2955	1.6766	1.5242
Max	2.2862	1.9814	1.9814	2.2291	2.2862	2.3624	2.21
Min	.362	.2286	.2286	.2572	.3048	.381	.3048
Avg	1.2985	.9135	.8954	1.1403	1.2310	1.4773	1.3776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 202 / VELAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6097	.4572	.6859	.5335	.4572	.6097
2	.7621	.6097	.4572	.6859	.5335	.4572	.6097
3	.7621	.6097	.4572	.8573	.6097	.5335	.7621
4	.9145	.7621	.6097	.8573	.7621	.6097	.9145
5	1.0669	.9145	.7621	1.1145	.9145	.9145	1.0669
6	1.2193	1.0669	1.1431	1.286	1.1431	1.1431	1.2193
7	1.2193	1.0669	1.2193	1.3717	1.2193	1.2193	1.1431
8	1.1431	1.0669	1.0669	1.286	.9907	.9145	1.1145
9	.9145	1.0669	.9145	1.1145	.9145	.8383	.8573
10	.9955	.9145	.8383	.8573	.9145	.9145	.9145
11	.9955	.9145	.7621	.8573	.9145	.9907	
12	.8145	.7621	.7621	.8573	.7621	.9145	.7621
13	.905	.6859	.6859	.8573	.7621	.9145	.8383
14	.905	.6859	.6859	.8573	.6859	.7621	.8383
15	.905	.7621	.6859	.8573	.6859	.7621	.8383
16	.905	.7621	.7621	.8573	.8383	.8383	.8383
17	.905	.7621	.8383	.8573	.8383	.9145	.9145
18	1.086	.8383	.9145	1.0288	.9145	.9145	.9907
19	1.448	1.0669	1.1431	1.3717	1.1431	1.1431	1.0669
20	1.448	.9907	1.0669	1.286	1.0669	1.0669	.9145
21	1.448	.9907	.9907	.9431	.9145	.9907	.7621
22	1.086	.7621	.9145	.8573	.7621	.7621	.8383
23	.905		.7621	.6859	.6097	.6097	.6097
24	.7621	.724	.4572	.6859	.6097	.4572	.4572
Max	1.448	1.0669	1.2193	1.3717	1.2193	1.2193	1.2193
Min	.7621	.6097	.4572	.6859	.5335	.4572	.4572
Avg	1.0116	.8433	.8065	.9573	.8351	.8351	.8644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 203 / 11 KV NEVARE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.3717	1.829	1.829	.1524	.1524	
2	.1524	1.3717	1.829	1.829	.1524	.1524	.1524
3	.1524	1.3717	1.829	1.829	.1524	.1524	.1524
4	.1524	1.3717	1.9052	1.829	.1524	.1524	.1524
5	.1524	1.5242	1.9052	1.9052	.1524	.2286	.0122
6	.1524	1.829	1.9052	1.9814	.1524	.3048	.1524
7		1.9814	2.2862	1.5242			
10	2.6578				2.3624	2.2862	2.6673
11	2.8292				1.829	2.4387	
12	2.2291				2.2862	2.2862	
13	2.4006				2.2862	2.2862	
14	2.2672				2.4387	2.1338	
15	2.2672				2.4387	2.1338	
16	2.4291				2.5149	2.2862	
17	2.4291				2.2862	2.2862	
19	.181	.1524	.1524	.2572	.2286	.2286	.2286
20	.181	.1524	.1524	.2572	.2286	.2286	.2286
21	.181	.1524	.1524	.2572	.1524	.1524	.1524
22	1.5432	1.7528	1.6766	.1715	.1524	.1524	.1524
23	1.5432		1.829	.1715	.1524	.1524	.1524
24	.1524	1.3717	1.7528	1.829	.1524	.1524	
Max	2.8292	1.9814	2.2862	1.9814	2.5149	2.4387	2.6673
Min	.1524	.1524	.1524	.1715	.1524	.1524	.0122
Avg	1.2103	1.2003	1.4773	1.2054	1.0212	1.0174	.3821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 204 / 11KV NIMGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.1524	2.1338	.1715	1.3717	2.0576	1.829
2	1.6766	.1524	.1524	.1715	1.3717	2.1338	1.829
3	1.6766	.1524	.1524	.1715	1.5242	2.1338	1.829
4	1.7528	.1524	.1524	.1715	1.5242	2.2862	1.829
5	1.9052	.1524	.2286	.1715	1.6004	2.2862	1.829
6	2.1338	.1524	.3048		1.829	2.2862	1.9814
7	2.2862				2.21	2.5149	2.4387
8						***	
9				.1715			
10		2.2862	2.2862	2.1338			
11		2.4387	2.4387	2.21			
12		2.4387		2.1338			
13		2.4387		1.9814			
14		2.1338	1.9814	1.829			
15		2.0576	1.829	1.829			
16		1.9814	1.829	2.0576			
17		1.9052	1.829	1.829			
19	.181	.1524	.1524	.2572	.2286	.2286	.2286
20	.181	.1524	.1524	.2572	.2286	.1524	.2286
21	.181	.1524	.1524	.2572	.1524		.1524
22	.181	.1524	.1524	1.5242	1.9814	1.829	2.0576
23	.181		.1524	1.3717	1.9814	1.829	2.0576
24	1.829	.181	2.2862	.1715	1.3717	1.9814	1.829
Max	2.2862	2.4387	2.4387	2.21	2.21	107.5752	2.4387
Min	.181	.1524	.1524	.1715	.1524	.1524	.1524
Avg	1.2303	1.0203	1.0203	1.0436	1.3366	9.9457	1.5476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 205 / TANDULWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.1524	.1524	.1715	.9907	1.0669	1.0669
2	1.0669	.1524	.1524	.1715	.9907	1.0669	1.0669
3	1.2193	.1524	.1524	.1715	1.0669	1.0669	1.0669
4	1.2193	.1524	.1524	.1715	1.1431	1.1431	1.0669
5	1.2955	.1524	.2286	.1715	1.2193	1.1431	1.1431
6	1.3717	.1524	.3048	.1715	1.3717	1.1431	1.5242
7	1.7528				1.7528	1.5242	1.6766
10		1.2193	1.5242	1.6004			
11		1.5242	1.5242	1.6766			
12		1.448	1.5242	1.448			
13		1.3717	1.3717	1.2193			
14		1.2193	1.2193	1.1431			
15		1.1431	1.0669	1.1431			
16		1.1431	1.0669	1.448			
17		1.1431	1.0669	1.4575			
19	.2715	.2286	.1524	.2572	.2286	.2286	.2286
20	.2715	.2286	.1524	.2572	.2286	.2286	.2286
21	.2715	.1524	.1524	.2572	.1524	.1524	.1524
22	.181		.1524	.9145	1.0669	1.1431	1.0669
23	.181		.1524	1.0669	1.0669	1.1431	1.0669
24	1.0669	.181	.1524	.1715	.9907	1.0669	1.0669
Max	1.7528	1.5242	1.5242	1.6766	1.7528	1.5242	1.6766
Min	.181	.1524	.1524	.1715	.1524	.1524	.1524
Avg	.8643	.6620	.6211	.7545	.9438	.9321	.9555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 206 / BHAKAREWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.3717	1.3717	1.0669	.1524	.1524	.1524
2	.1524	1.2193	1.3717	1.0669	.1524	.1524	.1715
3	.1524	1.2193	1.3717	1.2193	.1524	.1524	.1524
4	.1524	1.3717	1.5242	1.3717	.1524	.1524	.1524
5	.1524	1.5242	1.6766	1.5242	.1524	.2286	.1524
6	.1524	1.6766	1.829	1.6766	.1524	.3048	.1524
7		1.9814	1.9052	1.9052			
10	2.0576				1.9052	1.3717	1.6766
11	2.0243				1.829	1.6766	
12	1.8623				1.829	1.5242	
13	1.7814				1.6766	1.5242	
14	1.7814				1.5242	1.448	
15	1.7814				1.6004	1.3717	
16	1.9433				1.6766	1.3717	
17	1.9433				1.6004	1.5242	
19	.2715	.2286	.1524	.2572	.2286	.2286	.2286
20	.2715	.2286	.1524	.2572	.2286	.2286	.2286
21	.2715	.2286	.1524	.2572	.1524	.1524	.1524
22	1.3717	1.2193	1.2193	.1715	.1524	.1524	.1524
23	1.5432		1.1431	.1715	.1524	.1524	.1524
24	.1524	1.5432	1.2193	1.0669	.1524	.1524	.1524
Max	2.0576	1.9814	1.9052	1.9052	1.9052	1.6766	1.6766
Min	.1524	.2286	.1524	.1715	.1524	.1524	.1524
Avg	.9986	1.1510	1.1607	.9240	.7811	.7011	.2828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 207 / UGHDEWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.7621	.9145	.9145	.0762	.0762	.0762
2	.0762	.7621	.9145	.9145	.0762	.0762	.0762
3	.0762	.7621	.9145	.9145	.0762	.0762	.0762
4	.0762	.7621	.9145	.9145	.0762	.1524	.0762
5	.0762	.7621	.9145	.9907	.0762	.1524	.0762
6	.0762	.9145	.9145	.9907	.0762	.2286	.0762
7		.9145	.9907	1.0669			
10	1.0288				1.0669	1.0669	1.2193
11	1.1765				1.2193	1.1431	
12	1.0526				1.2193	1.1431	
13	.9717				1.1431	1.1431	
14	.9717				1.0669	1.2193	
15	.9717				1.0669	1.2193	
16	1.1336				1.0669	1.2193	
17	1.1336				1.1431	1.1431	
19	.181	.1524	.0762	.0857	.1524	.0762	.1524
20	.181	.1524	.0762	.0857	.1524	.0762	.1524
21	.181	.0762	.0762	.0857	.0762	.0762	.0762
22	1.0288	.9145	.9907	.0857	.0762	.0762	.0762
23	1.0288		.9145	.0857	.0762	***	.0762
24	.0762	.8573	.9145	.9145	.9907	.0762	.0762
Max	1.1765	.9145	.9907	1.0669	1.2193	81.2682	1.2193
Min	.0762	.0762	.0762	.0857	.0762	.0762	.0762
Avg	.5787	.6494	.7328	.6192	.5487	4.5854	.1759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274046 / 33/11KV VELAPUR

Feeder No / Name : 208 / NAGTHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.3717	1.6766	1.5242	.1524	.1524	.1715
2	.1524	1.3717	2.1338	1.5242	.1524	.1524	.1715
3	.1524	1.3717	1.6766	1.5242	.1524	.1524	.1715
4	.1524	1.5242	1.6766	1.6766	.1524	.1524	.2572
5	.1524	1.5242	1.829	1.7528	.1524	.2286	.2572
6	.1524	1.6766	1.829	1.7528	.2286	.3048	.2572
7		1.829	1.9052	1.9814			
10	2.1719				1.9814	1.829	2.4387
11	2.1719				1.9814	1.9052	
12	1.8623				2.1338	1.829	
13	1.7814				1.9814	1.829	
14	1.9433				1.829	1.7528	
15	1.9433				1.9052	1.6766	
16	2.1052				1.829	1.829	
17	1.9433				1.829	1.9052	
19	.2715	.3048	.1524	.2572	.3048	.1524	.3048
20	.2715	.3048	.1524	.2572	.3048	.1524	.3048
21	.2715	.3048	.1524	.2572	.3048	.1524	.2286
22	1.3717	1.6004	1.6766	.1715	.2286	.1524	.2286
23	1.5432		1.5242	.1715	.2286	.1524	.2286
24	.1524	1.5432	1.6766	1.5242	.1524	.1524	.1715
Max	2.1719	1.829	2.1338	1.9814	2.1338	1.9052	2.4387
Min	.1524	.3048	.1524	.1715	.1524	.1524	.1715
Avg	1.0359	1.2273	1.3893	1.1058	.8992	.8307	.3994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 201 / SHRIPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.2715	.2572	.3506	.362	.2572	.2572
2	.2629	.2686	.3429	.3506	.3658	.3429	.3429
3	.2629	.362	.4287	.3506	.362	.4287	.4287
4	.3506	.4477	.5144	.3506	.4525	.4287	.5144
5	.6135	.543	.6001	.5258	.5487	.5144	.6001
6	.6135	.543	.6001	.5258	.543	.6001	.6001
8	.5258	.4525	.6001	.5258	.4525	.6001	.5144
9	.4382	.362	.5144	.4382	.4525	.4287	.3429
10	.3429	.3506	.4525	.3429	.4382	.362	.2572
11	.2572	.3506	.3658	.3429	.2629	.362	.2572
12	.2572	.2629	.2715	.2572	.2629	.2715	.1715
13	.2572	.2629	.2715	.2572	.2629	.181	.1715
14	.2572	.2629	.1829	.2572	.1753	.181	.1715
15	.1715	.2629		.2572	.1753	.2715	.1715
16	.2715	.2629		.2715	.2629	.2743	.1715
17	.2715	.2572		.2715	.2572	.2572	.2743
18	.2715			.362	.2572	.3429	.2715
19	.4572	.4287		.4525	.4287	.4287	.3658
20	.543	.6001	.6135	.543	.5144	.5144	.543
21	.543	.5144	.5258	.543	.3429	.5144	.543
22	.4525	.4287	.4382	.4525	.3429	.2572	.4525
23	.3658	.2572	.3506	.362	.3429	.2572	.362
24	.2629	.2715	.2572	.3506	.362	.2572	.2572
Max	.6135	.6001	.6135	.543	.5487	.6001	.6001
Min	.1715	.2572	.1829	.2572	.1753	.181	.1715
Avg	.3614	.3647	.4215	.3801	.3577	.3623	.3496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 202 / MAHALUNG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.1753	.1715	2.4577	2.5301	2.3624	2.2862
2	.2629	.1753	.1715	2.4577	2.5301	2.3624	2.2862
3	.2629	.181	.2572	2.4577	2.5301	2.3624	2.2862
4	.2629	.181	.2572	2.5396	2.5301	2.4387	2.2862
5	.3506	.181	.2572	2.6216	2.5606	2.4387	2.2862
6	.3506	.181	.2572	2.7035	2.5606		2.2862
7	.3506	.1753	.2572	3.0312	2.6882	2.4387	2.4387
8	.3506	.1753	.2572	.3506	.2629	.2572	.2572
9	.2629	.1753	.2572	.2629	.2629	.2572	.2572
10	2.5911	2.9492	2.8807	.2572	.2629	.2629	.1715
11	2.5911	3.1131	3.0045	.2572	.2629	.2629	.1715
12	2.7435	3.1131	3.0045	.2572	.1753	.2629	.1715
13	2.7435	2.9492	3.1207	.2572	.1753	.2629	.1715
14	2.7435	2.9492	2.9254	.2572	.1753	.2629	.1715
15	2.7435	2.9492		.2572	.1753	.2629	.1715
16	2.8807	3.0312		.2629	.2629	.2629	.1715
17	2.8807	2.7435		.2629	.2572	.2572	.2629
18	.1753			.2629	.2572	.2572	.2629
19	.1753	.1715		.2629	.2572	.2572	.2629
20	.1753	.1715	.3506	.2715	.2572	.2572	.2629
21	.1753	.1715	.3506	.2715	.2572	.2572	.2629
22	.1772	.1715	2.5396	2.2405	2.2862	2.2862	.2629
23	.1753	.1715	2.5396	2.5301	2.3624	2.4387	1.0279
24	.3506	.1753	.1715	2.5396	2.5301	2.3624	2.4387
Max	2.8807	3.1131	3.1207	3.0312	2.6882	2.4387	2.4387
Min	.1753	.1715	.1715	.2572	.1753	.2572	.1715
Avg	1.0886	1.1492	1.2122	1.2221	1.1838	1.0927	.9548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 203 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.9602	1.0669	.0876	.0876	.0857	.0857
2	.8192	.9488	1.0669	.0876	.0876	.0857	.0857
3	.8192	.9488	1.0669	.0876	.0876	.0857	.0857
4	.8192	.9488	1.0669	.0876	.0876	.0857	.0857
5	.9012	.9488	1.1431	.0876	.0876	.0857	.0857
6	1.065	1.0279	1.2193	.0876	.0876	.0857	.0857
7	1.2289	1.2003	1.2955	.0876	.0876	.0857	.0857
8	.0876	.0876	.0857	.0876	.0876	.0857	.0857
9	.0876	.0876	.0857	.0876	.0876	.0857	.0857
10	.0857	.0876	.0876	1.2955	1.3108	1.1069	1.0669
11	.0857	.0876	.0876	1.448	1.3108	1.2003	1.2193
12	.0857	.0876	.0876	1.3717	1.2289	1.186	1.4575
13	.0857	.0876	.0876	1.2955	1.3108	1.1203	1.2955
14	.0857	.0876	.0876	1.2955	1.2289	1.1069	1.2955
15	.0857	.0876		1.2193		1.186	1.2193
16	.0876	.0876		1.2651	1.2289	1.2651	1.3717
17	.0876	.0857		1.2651	1.1431	1.2193	1.2651
18	.0876	.0857		.0876		.0857	.0876
19	.0876	.0857		.0876	.0857	.0857	.0876
20	.0876	.0857	.0876	.0876	.0857	.0857	.0876
21	.0876	.0857	.0876	.0876	.0857	.0857	.0876
22	.8697	1.0669	.0876	.0876	.0857	.0857	.9488
23	1.0279	1.0669	.0876	.0876	.0857	.0857	1.0279
24	.9012	.9488	1.0669	.0876	.0876	.0857	.0857
Max	1.2289	1.2003	1.2955	1.448	1.3108	1.2651	1.4575
Min	.0857	.0857	.0857	.0876	.0857	.0857	.0857
Avg	.4369	.4701	.5238	.4941	.4576	.4484	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 204 / CHAUKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1578	.1715	1.6385	1.8976	1.829	1.829
2	.1753	.1227	.1715	1.6385	1.8976	1.829	1.829
3	.1753	.1267	.1715	1.6385	1.9204	1.829	1.829
4	.1753	.1578	.1715	1.6385	1.9204	1.829	1.829
5	.1753	.1578	.1715	1.8023	1.8976	1.829	1.829
6	.1753	.1753	.1715	1.9662	1.8976	1.829	1.829
7	.1753	.1753	.1715	2.0481	2.0557	1.9814	1.829
8	.0876	.1753	.1715	.1753	.1753	.1715	.0857
9	.0876	.1227	.1715	.0876	.1753	.0857	.0857
10	1.9814	2.13	2.0557	.1715	.0876	.0876	.0857
11	1.9814	2.2939	2.1605	.1715	.0876	.0876	.0857
12	1.9814	2.13	2.1348	.0857	.0876		.0857
13	2.0576	2.13	2.0005	.0857	.0876		.0857
14	2.0576	1.9662	1.9766	.0857	.0876		.0857
15	1.9814	1.9662		.0857	.0876	.0876	.0857
16	2.0557	1.9662		.0876	.0876	.0876	.0857
17	2.0557	1.9814		.0876	.0857	.0857	.0876
18	.1227	.0857		.0876	.0857	.0857	.1227
19	.1578	.1715		.0876	.1715	.0857	.1227
20	.1578	.1715	.1753	.0876	.1715	.1715	.1227
21	.1578	.1715	.1753	.0876	.1715	.1715	.1227
22	.1402	.1715	1.8023	1.8976	1.829	1.829	.1227
23	.1578	.1715	1.8023	2.191	1.829	1.829	.1402
24	.1753	.1578	.1715	1.7204	2.0243	1.829	1.829
Max	2.0576	2.2939	2.1605	2.191	2.0557	1.9814	1.829
Min	.0876	.0857	.1715	.0857	.0857	.0857	.0857
Avg	.7760	.7932	.8420	.8189	.8675	.9357	.6769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 205 / MALEWADI AG/SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8023	1.8976	1.829	.0876	.0876	.0857	.0857
2	1.7204	1.8976	1.829	.0876	.0876	.0857	.0857
3	1.7204	1.9204	1.829	.0876	.0876	.0857	.1715
4	1.7204	1.9204	1.829	.1753	.0876	.1715	.1715
5	1.8023	1.8976	1.829	.1753	.1052	.1715	.1715
6	2.0481	1.8976	1.9052	.1753	.1227	.1715	.1715
7	2.2119	2.1605	2.1338	.1753	.1402	.1715	.1715
8	.1753	.1227	.0857	.1753	.1753	.1715	.1715
9	.0876	.0876	.0857	.1753	.1227	.0857	.0857
10	.0857	.0876	.0876	2.1338		2.1348	1.9052
11	.0857	.0876	.0876	2.2862	2.2939	2.0557	2.1338
12	.0857	.0876	.0876	2.2862	2.2119	2.1348	2.21
13		.0876	.0876	2.1338	2.3758	2.2929	2.4863
14	.0857	.0876	.0886	1.829	2.2119	2.0557	2.4006
15		.0876		1.9814	2.2119	2.0805	2.4006
16		.0876		1.8976	2.2939	2.1348	2.1338
17	.0876	.0857		1.8976	2.3624	1.9814	2.1605
18		.0857			.0857	.0857	
19	.0876	.0857		.1402	.0857	.0857	.0876
20	.0876	.0857	.0876	.1402	.1715	.1715	.0876
21	.0876	.0857	.0876	.1052	.1715	.1715	.1227
22	1.6604	1.9814	.0876	.0876	.0857	.1715	
23	1.8976	1.9814	.0876	.0876	.0857	.0857	2.0557
24	1.8023	1.8976	1.829	.0876	.0876	.0857	.0857
Max	2.2119	2.1605	2.1338	2.2862	2.3758	2.2929	2.4863
Min	.0857	.0857	.0857	.0876	.0857	.0857	.0857
Avg	.9671	.8627	.8407	.8004	.7718	.7887	.9798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 206 / Borgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.964	1.0059	.9431	.964	1.0059	.9431	.9431
2	.964	1.0164	1.1145	.964	1.0059	1.1145	1.1145
3	1.2269	.9955	1.286	1.2269	1.0164	1.286	1.286
4	1.4022	1.3717	1.4575	1.4022	1.086	1.3717	1.4575
5	1.6651	1.5546	1.5432	1.5775	1.4632	1.5432	1.5432
6	1.6651	1.6632	1.6289	1.5775	1.6461	1.5432	1.6289
8	1.4022	1.2803	1.2003	1.3146	1.2803	1.3717	1.286
9	1.0517	1.0059	1.0288	1.0517	.823	1.0288	1.0288
10	.9431	.8764	.823	.9431	.8764	.9145	.9145
11	.7716	.7888	.7392	.7716	.7888	.823	.7716
12	.7716	.7011	.7316	.7716	.5258	.7316	.6859
13	.6859	.7011	.6401	.7716	.7011	.6401	.6859
14	.6859	.7011	.6468	.6859	.7011	.6401	.6859
15	.6001	.7011		.6859		.6468	.6859
16	.7316	.7011		.7392	.7011	.7316	.6859
17	.7392	.6859		.7316	.7716	.6859	.7316
18	.823	.8573		.823	.8573	.8573	
19	1.1088	1.1145		1.1888	1.286	1.2003	1.2803
20	1.2936	1.286	1.5775	1.386	1.3717	1.286	1.2803
21	1.2012	1.286	1.4022	1.1888	1.286	1.2003	1.1888
22	1.0974	1.1145	1.0517	1.1088	1.1145	1.1145	1.1088
23	1.0974	.9431	1.0517	1.0059	1.0288	1.0288	1.0164
24	.964	1.0059	.9431	.964	.9955	.9431	.9431
Max	1.6651	1.6632	1.6289	1.5775	1.6461	1.5432	1.6289
Min	.6001	.6859	.6401	.6859	.5258	.6401	.6859
Avg	1.0372	1.0155	1.1005	1.0367	1.0151	1.0281	1.0433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274088 / SHRIPUR

Feeder No / Name : 207 / Mundafane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8192	.9602	.9145	.9907
2				.8192	.9488	.9145	.9907
3				.8192	.9488	.9145	.9907
4				.8192	.9602	.9145	.9907
5				.8192	.9488	.9145	.9907
6				.8192	.9602	.9145	.9907
7				.9012	.8002	.9907	1.0669
10	.9145	1.1469	.8697				
11	1.0669	1.1469	.9488				
12	.9145	1.065	.9488				
13	.9907	1.065	.9602				
14	.9907	.9831	.9488				
15	.9907	.9831					
16	1.0279	.9831					
17	.9488	.8383					
22			.9012	.9488	.9145	.9907	
23			.8192	.9488	.9907	.9907	
24				.8192	.9488	.9145	.9907
Max	1.0669	1.1469	.9602	.9488	.9907	.9907	1.0669
Min	.9145	.8383	.8192	.8192	.8002	.9145	.9907
Avg	.9806	1.0264	.9138	.8533	.9381	.9374	1.0002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274102 / KHALAVE

Feeder No / Name : 204 / 11 KV SHERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8747	2.0576	2.2558	2.2862	.1219	.1219	.1219
2	1.8747	2.0576	2.21	2.0005	.1067	.1524	.1219
3	1.829	2.1338	2.1948	1.9605	.1067	.1524	.1219
4	1.9052	2.1338	2.2862	1.9738	.1219	.1524	.1219
5	1.9814	2.21	2.3167	2.0671	.1524	.1829	.1524
6	2.2558	2.2862	2.3167	2.1338	.1829	.1829	.1677
7	2.4387	2.5149	2.5301	2.2672	.1829	.1829	.2134
8	.2134	.1829	.1829	.2134	.1829	.0914	.1981
9	.2134	.1677	.1829	.1829	.1677	.1829	.1829
10	.1372	.1219	.1067	.1219	2.4691	2.8197	2.4006
11	.1067	.0914	.08	.0914	2.7435	2.8959	2.8959
12	.0762	.061	.0914	.1219	2.8654	2.5149	2.8197
13	.0762	.0914	.08	.1219	2.8654	2.3929	2.3339
14	.0762	.0914	.08	.1219	2.6216	2.4387	2.8292
15	.0762	.0914	.0914	.1219	2.6825	2.3624	2.4387
16	.0762	.0914	.08	.1219	2.4691	2.4387	2.5149
17	.1524	.0914	.08	.1219	2.4387	2.5911	2.5149
18	.1219	.1219	.1524	.1372	.1524	.1524	.1524
19	.1372	.1524	.1829	.1372	.1524	.1829	.1334
20	.1524	.1219	.1677	.1524	.1524	.1524	.1524
21	.1524	.1219	.1524	.1524	.1219	.1524	.1524
22	2.21	2.2253	1.6004	.1219	.1219	.0914	2.1338
23	2.1338	2.2253	2.4387	.1524	.1219	.1219	2.1338
24	1.9204	2.0576	2.2558	2.2862	.1219	.1219	.1219
Max	2.4387	2.5149	2.5301	2.2862	2.8654	2.8959	2.8959
Min	.0762	.061	.08	.0914	.1067	.0914	.1219
Avg	.9247	.9793	1.0048	.7987	.9761	.9513	1.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 201 / HANUMAN MANDIR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.3052	
2		.3086	
3		.3391	
4		.3391	
5		.3391	
6		.3391	
7		.373	
8		.3018	
9			.3052
10			.2683
11			.1677
12			.1696
13			.1357
14			.1357
15			.1526
19	.1696		
20	.2374		
21	.2713		
22	.3018		
23	.3052		
24		.3052	
Max	.3052	.373	.3052
Min	.1696	.3018	.1357
Avg	.2571	.3278	.1907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 202 / UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1677	
2		.2012	
3		.2012	
4		.2012	
5		.1677	
6		.1677	
7		.2012	
8		.1677	
9			.1017
10			1.0159
11			1.0486
12			1.1191
13			1.153
14			1.1469
15			1.2289
16			1.3108
19	.1638		
20	.1638		
21	.1966		
22	.1638		
23	.1638		
24		.1677	
Max	.1966	.2012	1.3108
Min	.1638	.1677	.1017
Avg	.1704	.1826	1.0156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 203 / MIRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.9221	
2		.9835	
3		1.0174	
4		1.0852	
5		1.1401	
6		1.1869	
7		1.1869	
8		.1357	
9			.0819
10			.0328
11			.0492
12			.0655
13			.0655
14			.0819
15			.0655
19	.1174		
20	.1509		
21	.1509		
22	.8718		
23	.8718		
24		.9054	
Max	.8718	1.1869	.0819
Min	.1174	.1357	.0328
Avg	.4326	.9515	.0632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 204 / 11KV ANUSEWASTI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.7394	
2		1.7394	
3		1.8976	
4		1.8976	
5		2.1195	
6		2.0557	
7		2.119	
8		.1265	
9			.0949
10			.0949
11			.0949
12			.0791
13			.0791
14			.0791
15			.0949
19	.0937		
20	.1094		
21	.0949		
22	1.5813		
23	1.5813		
24		1.6604	
Max	1.5813	2.1195	.0949
Min	.0937	.1265	.0791
Avg	.6921	1.7061	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274127 / UMBARE(VELAPUR)

Feeder No / Name : 205 / 11KV THITWASTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	26-MAR-18
HR	Load (MW)
10	1.531
11	1.4842
12	1.406
13	1.3748
14	1.406
15	1.4842
16	1.5623
Max	1.5623
Min	1.3748
Avg	1.4641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 201 / MALKHAMBI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0857	.3429	.1715	1.5242	1.829	1.829
2	.3429	.0857	.2572	.1715	1.5242	1.7528	1.829
3	.2572	.1715	.2572	.1715	1.448	1.9719	1.9052
4	.2572	.1715	.3429	.2572	1.448	1.9719	1.9052
5	.2572	.2572	.3429	.2572	1.5242	1.9719	1.9052
6	.2572	.2572	.2572	.2572	1.6766	2.0576	1.9814
7	.1715	.2572	.1715	.2572	1.7528	2.2291	1.9814
8	.1715	.1715	.1715	.1715	.2286	.2286	.1715
9	.1715		.1715	.1715	.1715	.1715	.1715
10	1.9052		2.1338	1.9052	.2		.2572
11	1.9814		2.21	1.9052	.2286		.1715
12	2.0576	1.7528	2.2862	1.9052	.2	.1715	.1715
13	2.1338	1.829	2.1338	1.9814	.1334	.1715	.1715
14	1.9814	1.9052	1.9814	1.9814	.2	.1715	.1715
15	1.9052	1.9052	2.0576	1.829	.1334	.1715	.1715
16	1.9814	2.0576	1.9814	1.7528	.1334	.1715	.1715
17	2.0576	2.0576	1.9814	1.829	.2	.1715	.0857
18	.1715	.1715	.1715	.1715	.2	.1715	.1715
19	.1715	.1715	.1715	.1715	.2286	.1715	.1715
20	.1715	.2572	.1715	.1715	.2286	.1715	.1715
21	.2572	.2572	.1715	.0857	.1334	.1715	.1715
22	.1715	.2572	.1715	1.6766	2.0576	1.829	1.829
23	1.9814	.2572	.1715	1.6004	1.7528	1.829	1.829
24	.3429	.0857	.3429	.1715	1.6004	2.0576	1.829
Max	2.1338	2.0576	2.2862	1.9814	2.0576	2.2291	1.9814
Min	.1715	.0857	.1715	.0857	.1334	.1715	.0857
Avg	.8958	.6868	.8522	.8760	.7887	.9825	.8843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 202 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	.1715	.0857	.0857	.0667	.0857
2	.1715	.0857	.1715	.0857	.0857	.0667	.0857
3	.1715	.1715	.1715	.1715	.0857	.0667	.0857
4	.1715	.2572	.2572	.2572	.0857	.1334	.0857
5	.2572	.2572	.2572	.2572	.0857	.1334	.12
6	.2572	.2572	.2572	.2572	.1715	.2286	.1715
7	.2572	.2572	.2572	.2572	.2572	.2286	.2058
8	.1715	.1715	.1715	.1715	.1543	.1334	.1372
9	.0857		.0857	.0857	.1372	.0857	.12
10	.0857		.0857	.0857	.0667	.0857	.0857
11	.0857		.0857	.0857	.0667	.0857	.0857
12	.0857	.0857	.0857	.0857	.0667	.0857	.0857
13	.0857	.0857	.0857	.0857	.0667	.0857	.0857
14	.0686	.0857	.0857	.0857	.0667	.0857	.0857
15	.0857	.0857	.0857	.0857	.0667	.0857	.0857
16	.0857	.0857	.0857	.0857	.0667	.0857	.0857
17	.0857	.0857	.0857	.0857	.0667		.0857
18	.1715	.1715	.0857	.0857	.0762	.12	.1715
19	.1715	.1715	.1715	.12	.1334	.1715	.1715
20	.1715	.1715	.1715	.2058	.1524	.2401	.1715
21	.1715	.1715	.1715	.1543	.1524	.1715	.1715
22	.0857	.0857	.1715	.12	.0667	.12	.0857
23	.0857	.0857	.0857	.0857	.0667	.0857	.0857
24	.0857	.0857	.0857	.0857	.0857	.0667	.0857
Max	.2572	.2572	.2572	.2572	.2572	.2401	.2058
Min	.0686	.0857	.0857	.0857	.0667	.0667	.0857
Avg	.1386	.1429	.1429	.1322	.1007	.1182	.1136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 203 / MALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	2.2862	2.4387	2.21	.6001	.6097	.6001
2	2.5911	2.3624	2.5911	2.2862	.6001	.6097	.6001
3	2.7435	2.4387	2.8502	2.3624	.6516	.6859	
4	2.7435	2.5149	2.5911	2.3624	.6516	.7621	
5	2.8197	2.5911	2.5149	2.4387	.6859	.7621	.6859
6	2.8197	2.7435	2.5149	2.4387	.7716	.7621	.7716
7	2.6673	2.8197	2.5911	2.4387			
10					3.0007	2.4387	2.5911
11	.5144		.6001	.3429	3.1722	2.5911	
12	.5144	.3429	.5144	.3429	2.8292	2.5911	
13	.4287	.3429	.5144	.4287	2.572	2.5149	
14	.5144	.5144	.4287	.4287	2.572	2.4387	
15	.5144	.5144	.4287	.3772	2.6578	2.5149	2.1338
16	.6001	.6001	.4287	.3772	2.7435	2.4387	2.3624
17	.6001	.6001	.4287	.4287	2.8292	2.3624	2.6825
18	.5144	.6859	.6001	.5144	.5335	.6001	.5144
19	.6001	.6859		.6001	.6859	.6859	.5144
20	.6859	.7716	.7716	.6859	.6859	.6859	.6001
21	.5144	.7716	.7716	.7545	.7716	.7716	.6001
22	2.21	2.3624	2.2862	.6516	.6859	.6001	.6001
23	2.1338	2.4387	2.4387	.6516	.6097		.5144
24	2.5149	2.2862	2.4387	2.21	.6001	.5335	.6001
Max	2.8197	2.8197	2.8502	2.4387	3.1722	2.5911	2.6825
Min	.4287	.3429	.4287	.3429	.5335	.5335	.5144
Avg	1.5160	1.5337	1.5371	1.2063	1.4719	1.3980	1.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 204 / KAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	1.6004	1.7528	1.7528	.0857	.0667	.0857
2	1.7528	1.6766	1.829	1.7528	.0857	.0667	.0857
3	1.829	1.6766	1.829	1.829	.0857	.0667	.0857
4	1.829	1.7528	1.829	1.9052	.0857	.0667	.0857
5	1.829	1.829	1.7528	1.9814	.0857	.0667	.0857
6	1.9052	1.9052	1.7528	1.9814	.0857	.1334	.0857
7	1.7528	1.9052	2.1472	1.9814	.0857	.1334	.0857
8	.1715	.0857	.0857	.0857	.0857	.1334	.0857
9	.1715		.0857	.0857	.0857	.0857	.0857
10	.0857		.0857	.0857	1.9814	2.1338	2.21
11	.0857		.0857	.0857	2.4006	1.9814	2.0576
12	.0857	.0857	.0857	.0857	2.4006	1.9814	1.9052
13	.0857	.0857	.0857	.0857	2.0576	1.9052	1.9814
14	.0857	.0857	.0857	.0857	2.3148	1.9052	1.9814
15	.0857	.0857	.0857	.0857	2.3148	1.7528	2.0576
16	.0857	.0857	.0857	.0857	2.3148	1.7528	2.1338
17	.0857	.0857	.0857	.0857	2.0576	1.6766	2.1338
18	.0857	.0857	.0857	.0857	.1524	.0857	.0857
19	.0857	.0857	.0857	.0857	.1524	.0857	.0857
20	.0857	.0857	.0857	.0857	.1524	.0857	.0857
21	.0857	.0857	.0857	.0857	.1334	.0857	.0857
22	1.6004	1.6766	1.6766	.0857	.0762	.0857	.0857
23	1.6766	1.6766	1.7528	.0857	.0762	.0857	.0857
24	1.6766	1.6004	1.7528	1.7528	.0857	.0667	.0857
Max	1.9052	1.9052	2.1472	1.9814	2.4006	2.1338	2.21
Min	.0857	.0857	.0857	.0857	.0762	.0667	.0857
Avg	.7907	.8687	.8031	.6795	.8101	.6871	.743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274153 / Vitthalwadi

Feeder No / Name : 205 / VITTHALWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3429	.6001	.6001	1.9052	2.4863	2.21
2	.5144	.2572	.6001	.6001	1.829	2.4863	2.1338
3	.6001	.2572	.6859	.6001	1.829	2.21	2.1338
4	.6001	.3429	.6859	.6859	1.9052	2.4863	2.1338
5	.6001	.4287	.6859	.6859	1.9814	2.4863	2.21
6	.6001	.4287	.6859	.6001	2.0576	2.21	2.21
7					2.0576	2.7435	2.2862
10	2.1338		2.2862	2.2862			
11	2.2862			2.2862			
12	2.3624	2.2862	2.4387	2.2862			
13	2.2862	2.2862	2.4387	2.3624			
14	2.21	2.3624	2.21	2.3624			
15	2.1338	2.3624	2.2862	2.4387			
16	2.1338	2.21	2.3624	2.3624			
17	2.21	2.21	2.4387	2.2862			
18	.5144	.5144	.4287	.3429	.3048	.5144	.3429
19	.6001	.5144	.5144	.3429	.4572	.6001	.3429
20	.6859	.6001	.6001	.4287	.381	.6001	.4287
21	.6001	.6001	.6001	.4287	.3048	.6001	.4287
22	.3429	.5601	.6001	1.7528	2.6578	2.2862	2.4387
23	.4287	.6001	2.5149	1.9052	2.572	2.2862	2.4387
24	.6001	.3429	.6001	.6001	1.9052	2.572	2.21
Max	2.3624	2.3624	2.5149	2.4387	2.6578	2.7435	2.4387
Min	.3429	.2572	.4287	.3429	.3048	.5144	.3429
Avg	1.1885	1.0267	1.3132	1.3450	1.5820	1.8977	1.7106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 201 / KOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1989	.2172	.2218	.1943	.1989	.2172
2	.1943	.1989	.2172	.2218	.1943	.1989	.2172
3	.2105	.2155	.2328	.2353	.1943	.2155	.2534
4	.2267	.2486	.2686	.2715	.2267	.2652	.2715
5	.2591	.2652	.3045	.3224	.2267	.2984	.3077
6	.3077	.2984	.3898	.3761	.3077	.3647	.394
7	.2915	.3315	.3258	.3077	.2753	.2818	.2686
9	.2486	.2172	.2279	.2591	.2486	.2353	.2896
10	.2321	.2172	.2629	.2105	.2321	.181	.2378
11	.1989	.2172	.1928	.1943	.1823	.181	.2012
12	.0995	.2172	.1772	.1781	.1989	.181	.1829
13	.0995	.1646	.1629	.1457	.1326	.1463	.168
14	.0995	.1448	.1494		.1326	.1463	.168
15	.116	.1254	.1494	.1457	.1326	.1267	.168
16	.1326	.1433	.1663	.1619	.1326	.1463	.168
17	.1326	.1433	.2195	.1943	.1492	.181	.168
18	.1989	.1991	.2561	.2267	.1989	.2012	.2033
19	.2652	.2896	.3292	.2915	.2486	.2896	.3109
20	.2984	.3439	.3403	.3077	.2984	.3475	.3258
21	.2652	.3077	.3109	.2591	.2818	.3475	.3292
22	.2486	.2715	.2743	.2429	.2486	.2534	.2772
23	.2321	.2534	.2378	.2105	.2321	.2353	.2378
24	.1943	.1989	.2353	.2218	.1943	.1989	.2172
Max	.3077	.3439	.3898	.3761	.3077	.3647	.394
Min	.0995	.1254	.1494	.1457	.1326	.1267	.168
Avg	.2064	.2266	.2456	.2367	.2115	.2270	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 202 / Kolegaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0243	2.0271	1.9467	1.7236	1.8461	1.9258	1.9319
2	1.9271	1.8823	1.8576	1.6604	1.7004	1.9547	1.9022
3	2.0081	1.9113	1.7833	1.781	1.9271	2.0271	1.8964
4	2.251	2.0995	1.829	1.9907	2.0891	2.0995	1.917
5	2.5425	2.3167	2.0921	2.1373	2.4939	2.1719	2.0805
6	.2591	2.4905	2.3765	2.3028	2.7368	2.2443	2.4206
7	2.753	2.6063	2.3912	2.7046	2.9959	2.4905	2.6699
8	.1989	.2486	.2896	.2429	.2321	.2926	.2926
9	.1658	.1991	.1848	.2591	.1989	.2378	.2402
10	.1823	.1646	.1867	.1943	.2012	.2012	.2033
11	.1326	.1086	.168	.1943	.1844	.1448	
12	.1492	.1267	.168			.1267	
13	.1326	.1267	.168			.1646	
14	.1326	.1448	.168	.1296		.1646	
15	.1326	.1448	.1494	.1619		.1448	
16	.1492	.181	.168	.1619		.181	
17	.1492	.181	.2033	.1943	.1989	.1463	
18	.1658	.2172	.2218	.1943	.1524	.181	
19		.3109	.2561	.2591	.2984	.2896	.3475
20		.2587	.3109	.2753	.2818	.3077	.3109
21	.1989	.2427	.2957	.2591	.2486	.2743	.2926
22	1.9982	2.0391	2.1559	2.1376	1.7375	2.1418	.2561
23	2.0271	2.0538	2.1091	2.3805	1.7665	2.2592	.2218
24	2.2024	2.0561	2.0098	1.9528	2.1052	1.8823	2.0831
Max	2.753	2.6063	2.3912	2.7046	2.9959	2.4905	2.6699
Min	.1326	.1086	.1494	.1296	.1524	.1267	.2033
Avg	.9947	1.0058	.9787	1.0590	1.2313	1.0023	1.1917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274160 / Kolegaon

Feeder No / Name : 203 / Phalawni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2818	.3439	.3109	.2753	.2818	.3439
2	.2753	.2818	.3439	.3109	.2753	.2818	.3439
3	.2753	.2984	.362	.3258	.2591	.2818	.3439
4	.3077	.2984	.3801	.3982	.2591	.3149	.3801
5	.3401	.3315	.4119	.4477	.2915	.3978	.4119
6	.3887	.3647	.5552	.5493	.3725	.4807	.5014
7	.4534	.431	.5194	.4835	.4049	.431	.394
8	.3315	.3315	.3224	.3077	.3149	.3475	.3258
9	.2984	.2743	.2715	.2105		.2172	.2743
10	2.0851	1.8278	2.0645	2.1376	1.9982	1.8873	2.1845
11	2.3602	1.8873	1.8461	2.251	2.0706	1.7238	
12	2.0706	1.8362	1.7652		.1823	1.6406	
13	1.7086	1.5503	1.668		.1658	1.5051	
14		1.3395	1.4582	1.2146	.1658	1.3717	
15		1.387	1.2929	1.5546	.1658	1.3592	
16		1.6156	1.326	1.8461	.1989	1.4661	
17		1.3998	1.4752	1.7976	1.419	1.4352	
18		.2172	.2195	.1943	.2155	.2172	
19	.2652	.3475	.3109		.3149	.3077	.4477
20	.3647	.3658	.3475	.2915	.3149	.3658	.4163
21	.3201	.3475	.3475	.2915	.3149	.3292	.3801
22	.3315	.3658	.362	.2915	.2984	.3258	1.4864
23	.2984	.3475	.3292	.2753	.2984	.3292	1.4575
24	.2915	.2984	.3475	.3292	.2753	.2984	.3258
Max	2.3602	1.8873	2.0645	2.251	2.0706	1.8873	2.1845
Min	.2652	.2172	.2195	.1943	.1658	.2172	.2743
Avg	.6873	.7511	.7779	.7533	.4718	.7332	.6261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 201 / DOMBALWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.3018	.2683	.3018	.3353	.3353	.3018
2	.3688	.3018	.2683	.3018	.3688	.3353	.3018
3	.3688	.3018	.3018	.3018	.3688	.3353	.3018
4	.3688	.3353	.3018	.3018	.3688	.3521	.3353
5	.3688	.4024	.3353	.3353	.4024	.3688	.3353
6	.3688	.3521	.3353	.3353	.4024	.3688	.3688
10	2.5911	3.0803	2.2283	2.4577	2.6216	2.2024	2.5069
11	2.7854	2.5888	2.2283	2.5232	2.6379	2.4291	
12		2.6216	2.3102	2.4249	2.6379	2.3482	
13		2.3594	2.3266	2.2611	2.5232	2.3482	
14		2.4577	2.3922	2.1628	2.2283	2.17	
15		2.2939	2.3102	1.8679	2.1956	2.1052	
16		2.2611	2.1136	1.9662	2.1464	2.1376	
17		1.8351	2.0153	1.9006	2.0972	2.0243	
19	.285	.1677	.3353	.2347	.4527	.3018	.285
20	.3018	.3018	.3018	.3018	.4527	.3018	.285
21	.3185	.3018	.3018	.2683	.4527	.3018	.285
22	.3185	.2683	.3018	.3018	.4191	.3018	1.7532
23	.3185	.2683	.3018	.3018	.3688	.3018	1.7368
24	.3688	.3185	.2347	.3018			.3018
Max	2.7854	3.0803	2.3922	2.5232	2.6379	2.4291	2.5069
Min	.285	.1677	.2347	.2347	.3353	.3018	.285
Avg	.6786	1.1560	1.0756	1.0576	1.2358	1.1247	.6999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 202 / AMBEMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.4694	2.3266	2.1628	2.2447	2.4291	1.9433
2	.5365	.4694	2.13	2.1628	2.2775	2.4291	1.9433
3	.5365	.4694	2.1628	2.2611	2.3102	2.3482	1.9433
4	.5365	.4862	2.1956	2.2611	2.343	2.2672	1.9433
5	.5365	.503	2.2283	2.3758	2.3758	2.3158	2.0243
6	1.9433	2.5911	2.2611	2.3758	2.4086	2.5587	2.1052
7	2.4291	2.8502	2.5232	2.7035	2.4577	2.8178	2.3644
8	.0503	.0503		.0339	.0509		.0503
9	.0503	.0339		.0509			
10	.0671	.0848	.0848	.0509	.0848	.0335	.0678
11	.1174	.1357	.0848	.1526	.1187	.1174	.0678
12	.1174	.0678	.1526	.0848	.1187	.1509	.0678
13	.1174	.1526	.1357	.1187	.0848	.1509	.0678
14	.1174	.0848	.1187	.1017	.1357	.1341	.0678
15	.1174	.1017	.1526	.0848	.1696	.1006	.0678
16	.1006	.0848	.1526	.1017	.1187	.1006	.0678
17	.1006	.1017	.1526	.1017	.1187	.0671	.0678
18	.0838	.0848	.1526	.0678		.0671	.0678
19	.5197	.4024	.4191	.5197	.503	.4694	.4694
20	.5868	.4359	.4024	.503	.503	.4527	.4694
21	.5868	.4527	.4024	.4862	.503	.4359	.4694
22	.503	1.9989	2.0645	2.0645	2.2672	2.0081	.4694
23	.4694	2.3266	2.1628	2.1792	2.5587	2.0081	.4862
24	.5365	.4694	2.3922	2.1628	2.2119	2.5101	1.9433
Max	2.4291	2.8502	2.5232	2.7035	2.5587	2.8178	2.3644
Min	.0503	.0339	.0848	.0339	.0509	.0335	.0503
Avg	.4707	.6211	1.1299	1.0487	1.1802	1.1806	.8363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 203 / KHUDUS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3353	.3353	.3353	.3018	.3018	.3018
2	.4191	.3353	.3353	.3353	.3018	.3018	.3018
3	.4191	.3521	.3521	.3353	.3185	.3353	.3353
4	.4191	.3688	.3521	.3353	.3185	.3353	.3688
5	.4191	.4191	.3688	.3353	.3353	.3688	.3688
6	.4191	.3688	.3688	.3353	.3353	.3688	.3688
10	2.4291	2.7199	2.1956	2.0481	2.5396	2.0243	2.5396
11	2.5911	2.556	2.2447	2.1136	2.6871	2.4615	
12		2.4249	2.1956	1.9498	2.8018	2.3967	
13		2.4577	2.2939	1.7368	2.6543	2.1052	
14		2.3594	2.3922	1.6712	2.5232	2.0405	
15		2.3266	2.4086	1.5249	2.556	2.2996	
16		2.2775	2.3594	1.7204	2.6052		
17		2.1628	2.1628	1.704	2.5069		
19	.3018	.2515	.3353	.285	.3856	.285	.3353
20	.3185	.3018	.3353	.285	.3856	.3018	.3353
21	.3353	.3018	.3521	.2683	.3856	.3018	.3353
22	.3521	.3018	.3353	.3018	.3353	.285	2.0972
23	.3353	.3018	.3353	.3018	.3353	.285	2.0972
24	.4191	.3353	.3185	.3353	.3185	.3353	.3018
Max	2.5911	2.7199	2.4086	2.1136	2.8018	2.4615	2.5396
Min	.3018	.2515	.3185	.2683	.3018	.285	.3018
Avg	.6855	1.1629	1.1189	.9129	1.2466	.9519	.7759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 204 / ZANJEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2347	1.442	1.5083	1.3927	1.5384	1.166
2	.2012	.2347	1.4255	1.5083	1.4255	1.4575	1.166
3	.2012	.2347		1.5581	1.4582	1.4575	1.166
4	.2012	.2347	1.4255	1.5581	1.491	1.4899	1.166
5	.2012	.2347	1.4089	1.5083	1.5238	1.4899	1.2146
6	1.6194	1.587	1.4089	1.5581	1.5565	1.6842	1.3279
7	1.8623	1.7328	1.4918	1.6385	1.7368	1.7976	1.5384
19	.1509	.1509	.1677	.1677	.1677	.1677	.1677
20	.2012	.1677	.1677	.1677	.1677	.1677	.1677
21	.2012	.1509	.2012	.1341	.1677	.1677	.1677
22	.2347	1.278	1.4089	1.2266		1.2631	.1677
23	.2347	1.4255	1.4089	1.326		1.2631	.1677
24	.2012	.2347	1.442	1.5083	1.3599	1.5384	1.2146
Max	1.8623	1.7328	1.4918	1.6385	1.7368	1.7976	1.5384
Min	.1509	.1509	.1677	.1341	.1677	.1677	.1677
Avg	.4394	.6078	1.1166	1.1822	1.1316	1.1910	.8306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274175 / KHUDUS

Feeder No / Name : 205 / 11 KV Ranvijay Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0671	.1174	.1006		.1006	.1677
2	.0838	.0671	.1174	.1341	.1341	.1006	.1677
3	.0838	.0671	.1341	.1341	.1509	.1006	.1677
4	.0838	.0671	.1341	.1341	.1509	.1006	.1677
5	.0838	.0671	.1341	.1341	.1509	.1006	.1677
6	.0838	.0671	.0838	.1341	.1677	.1006	.1677
7	.0838	.0671	.1341	.1341	.1677	.1006	.1677
8	.1006	.0671	.1341	.1677	.1677	.1006	.1677
9	.1006	.0671	.1341	.1677		.1006	.1677
10	.0671	.0671	.1677	.1341	.1509	.1341	.1677
11	.0671	.0335	.1677	.1341	.1677	.1341	.1677
12	.0503		.1844	.1341	.1677	.1677	.1677
13	.0503		.1677	.1341	.1509	.1677	.1677
14	.0503		.1677	.1341	.1509	.1677	.1677
15	.0503		.1509	.1341	.1844	.1677	.1677
16					.1006		
24	.0838	.0671	.1006	.1006	.1006	.1006	.1006
Max	.1006	.0671	.1844	.1677	.1844	.1677	.1677
Min	.0503	.0335	.0838	.1006	.1006	.1006	.1006
Avg	.0754	.0643	.1394	.1341	.1509	.1216	.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 201 / GARWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3144	1.6804	1.4373	1.5089	1.3717	1.2498	1.2498
2	.2972	1.5432	1.448	1.6289	1.3203	1.2193	1.1431
3	.3715	1.3717	1.6004	1.749	1.2346	1.1717	1.0974
4	.3572	1.2003	1.6872	1.8519	1.286	1.0936	1.0936
5	.4161	1.4575	1.6644	1.7147	1.5089	1.5242	1.3717
6	1.6432	1.6804	1.6766	1.8861	1.8861	1.7071	1.5242
7	1.829	1.6309	1.6194		2.1434	1.829	1.6004
18	.3429	.2858	.3772	.3772	.1524	.1715	.208
19	.3772	.3572	.3944	.3944	.2858	.2143	.3715
20	.3944	.3269	.4115	.3944	.3311	.3144	.4161
21	.4115	.2675	.4287	.4115	.3572	.3763	.3864
22	1.4575	1.1888	1.3717	1.4575	1.4861	1.448	.3567
23	1.7147	1.2955	1.406	1.406	1.4299	1.4373	.3353
24	.4001	1.8861	1.3717	1.4575	1.4575	1.2955	1.3717
Max	1.829	1.8861	1.6872	1.8861	2.1434	1.829	1.6004
Min	.2972	.2675	.3772	.3772	.1524	.1715	.208
Avg	.7376	1.1552	1.2068	1.2491	1.1608	1.0751	.8947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274213 / GARWAD SUBSTATION

Feeder No / Name : 202 / CHANDAPURI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3258	.2378	.3086	.3772	.2858	.2286
2	.1429	.3429	.2572	.3086	.3944	.3121	.2858
3	.1429	.3429	.2972	.3258	.3772	.3269	.3144
4	.2286	.3944	.3001	.3429	.3944	.3144	.3429
5	.2858						
10	2.572	2.713	2.8292	2.8292	2.2862	2.2737	2.2672
11	3.0864	2.5911	2.915		2.5911	2.4387	
12		2.5263	2.9492	3.0864		2.5911	
13		2.3746	2.6749	3.0007	2.6558	2.6216	
14		2.2862	2.7435	2.915	2.2148	2.5101	
15		2.3122	2.4348	2.8292	2.1338	2.2653	
16		2.2253	2.2291	2.4006	2.0062	2.0062	
17		2.3482	2.0576	2.2291	2.0576	1.9814	
18	.2058	.1486	.2572	.2058	.1429	.1429	.1429
19	.2401	.2	.2401	.2229	.2229	.1715	.2229
20	.2915	.2229	.2401	.2572	.2378	.2	.2143
21	.3258	.2378	.2572	.2743	.2572	.2378	.2286
22	.2915	.2675	.2743	.3086	.2858	.2439	2.1338
23	.2572	.2286	.3086	.3086	.2858	.2286	2.2809
24	.1715	.3086	.2143	.2915	.3429	.2858	.2143
Max	3.0864	2.713	2.9492	3.0864	2.6558	2.6216	2.2809
Min	.1429	.1486	.2143	.2058	.1429	.1429	.1429
Avg	.6010	1.1788	1.2483	1.2469	1.0702	1.1283	.7397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 201 / DASUR PATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1067	.0914	.1067	1.1431	1.2803	1.2803
2	.0762	.0914	.1029	.1067	1.0669	1.2803	1.2803
3	.0762	.0914	.0914	.1067	.9907	1.2955	1.2955
4	.1067	.1219	.1372	.1219	1.1431	1.3108	1.2955
5	.1067	.1219	.1715	.1524	1.2193	1.3108	1.3413
6	.1524	.1677	.1715	.1829	1.3108	1.3565	1.3717
7	.1829	.1677	.1715	.1829	1.326	1.4022	1.4022
8	.1524	.1219	.1715	.1524	.1219	.1372	.1715
9		.1219		.1067	.0914	.1372	.1543
10	1.4022	1.6004		1.5546	.0762	.1219	.12
11	1.5089	1.5699	1.5546	1.5242	.0762	.1219	.1029
12	1.4937	1.5242	1.5394	1.6004	.1219	.1219	.12
13	1.4784	1.5242	1.4937	1.6309	.1219	.1219	.1372
14	1.4937	1.5242	1.5242	1.6004	.1219	.1219	.1543
15		1.4937	1.5546	1.6156	.1067	.1372	.1372
16	1.3565	1.2955	1.5242	1.6156	.1067	.1524	.1715
17	1.2498	1.4022	1.4632	1.4175	.1219	.1524	.1886
18	.1067	.1372	.1219	.1219	.1219	.1829	.1886
19	.1677	.1886	.1524	.1524	.1829	.1981	.2058
20	.1524	.1715	.1524	.1219	.1981	.1524	.2229
21	.1219	.1372	.1219	.1067	.1829	.1372	.1715
22	.1219	.1372	.1219	1.1736	1.1888	1.3108	.1372
23	.1067	.1372	.1219	1.1888	1.2498	1.2955	.1029
24	.0914	.1067	.1029	.1067	1.1431	1.2803	1.2803
Max	1.5089	1.6004	1.5546	1.6309	1.326	1.4022	1.4022
Min	.0762	.0914	.0914	.1067	.0762	.1219	.1029
Avg	.5362	.5859	.5754	.6979	.5639	.6300	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 202 / 11 KV NANAWARE WASTI

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9297	.823	.945	.1829	.2134	.2286
2	.8535	.9145	.8535	.9145	.1981	.2134	.2286
3	.8535	.9297	.8535	.9145	.2286	.2439	.2439
4	.884	.945	.884	.9145	.2591	.2743	.2286
5	.884	.945	.9145	.945	.2743	.3048	.2439
6	.9602	.9755	.9145	.945	.3353	.3353	.3048
7	.9297	1.0517	.945	1.0974	.3506	.2743	.3506
8	.2286	.2591	.2743	.2743	.2591	.2743	.3429
9	.1829	.1981	.2401	.2439	.1829	.2134	.2572
10	.1677	.1886	.2134	.1829	1.0669	.9755	.884
11	.1677	.1715	.1829	.1981	.945	.9145	1.0059
12	.1372	.1715	.2134	.1829	.8993	.7773	.9145
13	.1372	.1886	.1981	.1829	.9297	.7926	.8535
14		.1886	.2134	.1677	.9145	.7926	.9945
15	.1829	.1886	.2134	.1829	.9145	.8078	.8383
16	.1981	.1715	.2134	.1829	.884	.8383	.9945
17	.1829	.2572	.2743	.2134	.8383	.8535	.9145
18	.2591	.2743	.3353	.3048	.1219	.3353	.1715
19	.3658	.3429	.4458	.3353		.3201	.2401
20	.2896	.3086	.3429	.3048	.3201	.2591	.3086
21	.2134	.2286	.2401	.2439	.2134	.2286	.2401
22	.9145	.8383	.9755	.1981	.2134	.2286	1.0288
23	.9145	.8383	.9755	.1829	.2134	.2286	1.0288
24	.823	.9297	.8383	.945	.1829	.2134	.2134
Max	.9602	1.0517	.9755	1.0974	1.0669	.9755	1.0288
Min	.1372	.1715	.1829	.1677	.1219	.2134	.1715
Avg	.5030	.5181	.5241	.4668	.4751	.4547	.5442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

AKLUJ II SUB-DN.[716] BU 4716

Substation No/ Name :- 274214 / DASUR

Feeder No / Name : 203 / 11 KV BHIMA NADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.503	.7621	.9755
2					.503	.7926	.9755
3					.5335	.7926	.9145
4					.5335	.823	.9145
5					.5182	.823	.9602
6					.5792	.8535	.9907
7					.5487	.945	1.0059
10	.7926	.8535	.7926	.7621			
11	.823	.8383	.7926	.7926			
12	.7926	.7621	.7164	.7621			
13	.7621	.7011	.7316	.7011			
14		.6554	.7316	.6859			
15	.7621	.6859	.7164	.6401			
16	.7621	.7164	.6706	.6249			
17	.7011	.7926	.6249	.5335			
22				.4268	.7316	1.0669	
23				.4572	.7621	1.0364	
24					.4877	.7621	.9907
Max	.823	.8535	.7926	.7926	.7621	1.0669	1.0059
Min	.7011	.6554	.6249	.4268	.4877	.7621	.9145
Avg	.7708	.7507	.7221	.6386	.5701	.8657	.9659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 201 / 11KV JADHAVWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3239	.3391	.2896	.3048	.2915	.3185
2	.3077	.3048	.3391	.3048	.3048	.2915	.3353
3	1.004	1.5546	1.7295	1.5546	1.4937	1.6518	1.6712
4	1.0526	1.5546	1.8652	1.6766	1.5546	1.7814	1.8023
5	1.0364	1.8652	2.0348	1.9662	1.6766	1.9109	1.9109
6	2.0243	1.829	2.1704	1.9509	1.9052	2.0729	1.9109
7	2.5911	2.1376	.2543	2.1338		2.4615	2.2466
8	2.672	2.2253	.1187	2.5453		2.4453	2.0622
9	2.2996	1.9433	.1187	2.3167		2.2348	2.0348
10	1.9052	1.9109	1.9498	2.1338	2.1795	2.0645	1.1797
19	.3222	.3401	.3605	.3506	.3201	.3605	.3077
20	.3353	.3201	.3605	.3353	.3048	.3239	.3048
21	.3353	.3201	.3113	.3353	.3048	.3239	.3048
22		.3239	.3277	.3048	.2896	.3401	.3048
23		.3048	.3077	.3048	.2896	.3077	.3391
24	.2949	.3401	.3561	.3113	.3048	.3077	.3185
Max	2.672	2.2253	2.1704	2.5453	2.1795	2.4615	2.2466
Min	.2915	.3048	.1187	.2896	.2896	.2915	.3048
Avg	1.1766	1.0999	.8090	1.1759	.8641	1.1981	1.0845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 202 / 11KV CHAUR WASTI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.9433	2.8147	2.3266	3.0445
2	2.1862	1.7814	2.713	2.0972	2.8826
3	.3932	.4572	.5426	.4588	.4268
4	.3887	.4877	.5935	.4915	.442
5	.4115	.4877	.5935	.5243	.442
6	.5506	.4877	.6104	.5898	.4572
7	.4725	.4877	.5765		.4725
19	3.2217	3.0178	3.0967	2.9656	2.8045
20	3.0182	2.9473	3.0639	3.1131	2.6673
21	2.7808	2.8988	2.8018	3.3753	2.6216
22	2.5095	2.834	2.8018	3.3261	2.0972
23	2.2382	2.7854	2.6379	3.2933	1.9052
24	2.4777	2.0729	2.8826	2.4387	3.1131
Max	3.2217	3.0178	3.0967	3.3753	3.1131
Min	.3887	.4572	.5426	.4588	.4268
Avg	1.7525	1.7453	1.9791	2.0834	1.7982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 203 / 11KV SIDACHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1781	.1677	.1638	.1829	.1943	.2012
2	.1781	.1781	.1677	.1638	.1829	.1943	.2683
3	1.4022	1.6518	2.0008	1.9334	1.5546	1.668	1.6876
4	1.6766	1.9109	2.0454	1.9989	1.6766	1.7976	1.8821
5	1.9814	2.0081	2.2043	2.13	1.9509	2.0891	2.1628
6	2.2834	2.3967	2.34	2.2939	2.0729	2.3967	2.4905
7	2.6073	2.6882	2.4247	2.5396	2.0729	2.9835	2.6825
8	2.5069	2.6882	2.6155	2.8837		3.1093	
9	2.4249	2.2558	2.5652	2.6543		2.8018	2.2996
10	2.1538	2.2348	2.1195	2.2939	2.3624	2.556	1.9595
19	.1619	.1619	.1311	.2294	.1802	.2267	.2286
20	.1802	.1619	.1475	.2294	.1829	.2267	.2134
21	.1802	.1677	.1638	.2035	.1943	.2105	.2134
22	.1802	.1677	.1802	.1865	.1829	.2429	.2134
23	.1802	.1524	.1638	.1865	.1677	.1943	.2286
24	.1619	.1781	.1638	.1638	.1966	.1781	.2012
Max	2.6073	2.6882	2.6155	2.8837	2.3624	3.1093	2.6825
Min	.1619	.1524	.1311	.1638	.1677	.1781	.2012
Avg	1.1513	1.1988	1.2251	1.2659	.9401	1.3169	1.1288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 204 / 11KV DEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.1524	.2035	.1524	.1524	.1619	.1696
2	.1524	.1524	.2012	.1524	.1524	.1619	.2012
3	.1781	.1524	.2347	.1829	.1524	.1781	.1865
4	.1829	.1524	.2543	.1829	.1524	.1802	.1865
5	.2267	.1829	.2515	.1334	.1829	.1966	.2035
6	.2429	.1829	.2713	.2286	.2134	.1966	.2543
7	.2134	.2134	.218	.1372		.213	.2012
11	1.668	1.6032	1.7939	1.5394	1.829	1.668	
12	1.7166	1.4937	1.7604	1.5242	1.5242	1.7004	
13	1.6194	1.4784	1.7101	1.448	1.587	1.6876	
14	1.4413	1.4784	1.6617	1.4022	1.4937	1.3927	
15		1.5384	1.5384	1.3717	1.448	1.3763	
16	1.4413	1.4327	1.4575	1.4022	1.4632	1.3763	
17	1.4089	1.4175		1.1888	1.4784	1.5893	
18	1.2955	1.4327		.1981	1.5546	1.5729	
19	.1781	.1524	.1619	.1981	.2429	.1638	1.829
20	.1943	.1524	.1943	.1829	.2134	.1638	1.6309
21	.1943	.1524	.1781		.1829	.1619	1.4022
22	.1943	.1524	.1943	.1677	.1829	.1638	1.4022
23	.1943	.1524	.1619	.1524	.1677	.1781	1.3717
24	.1966	.1524	.1696	.1524	.1619	.1802	.1865
Max	1.7166	1.6032	1.7939	1.5394	1.829	1.7004	1.829
Min	.1524	.1524	.1619	.1334	.1524	.1619	.1696
Avg	.6551	.6656	.6640	.6049	.7268	.6983	.7096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 205 / 11KV MALSHIRAS URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3226	1.2209	1.2239	1.0623	1.0822	1.2517	1.1961
2	1.3395	1.153	1.1869	1.1142	1.0526	1.166	1.1797
3	1.3565	1.2209	1.3226	1.1469	1.0364	1.2003	1.3927
4	1.4922	1.3226	1.4586	1.4255	1.1584	1.4918	1.4255
5	1.5091	1.326	1.5424	1.5074	1.2498	1.5775	1.56
6	1.4922	1.56	1.4251	1.3927	1.2955	1.5261	1.5238
7	1.3413	1.5091	1.4083	1.3435	1.2955	1.4403	1.4074
8	1.3056	1.3904	1.2378	1.3108		1.2346	1.1797
9	1.2039	1.2378	1.0898	1.3546		1.1831	1.2125
10	1.17	1.0852	1.1401	1.3375	1.2803	1.2174	1.1797
11	1.0513	1.0174	1.0631	1.0631	1.3565	1.166	1.0159
12	1.0513	.9496	1.0288	.9945	1.0822	1.1488	.8478
13	1.0174	.9326	.9945	.9259	1.153	1.1145	.8848
14	.9496	.9496	.9431		1.1022	.9602	.8356
15	.9496	.9231	.9774		.9667	1.0631	.8817
16	1.0004	.9326	.9431		.8688	.9945	.4239
17	1.0513	.9665		1.2346	.9145	1.0974	.9496
18	1.0852	1.0343		1.0631	1.0059	1.1831	.7287
19	1.4243	1.4752	1.5775	1.4575	1.2498	1.4232	1.4255
20	1.56	1.4582		1.5432	1.3413	1.5089	1.4575
21	1.3717	1.4243	1.4746	1.5089	1.3717	1.5432	1.3927
22	1.2955	1.3904	1.4575	1.4746	1.3565	1.5261	1.4575
23	1.3279	1.2955	1.3717	1.406	1.2803	1.4403	1.3603
24	1.3565	1.2193	1.3245	1.1305	1.3108	1.3546	1.3395
Max	1.56	1.56	1.5775	1.5432	1.3717	1.5775	1.56
Min	.9496	.9231	.9431	.9259	.8688	.9602	.4239
Avg	1.2510	1.2081	1.2472	1.2761	1.1732	1.2839	1.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 206 / 11KV Medad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.89	1.7985	2.4587	1.8023	1.8351	2.3482	
2	1.8947	1.6309	2.3569	2.9492	1.7204	2.2672	
3	.3963	.3353	.373	.3605	.3605	.3353	
4	.3963	.3353	.39	.3768	.3605	.3353	
5	.4268	.3658	.407	.3932	.4096	.381	
6	.5182	.3963	.5596	.3768	.4588	.3963	
7	.4268	.3963	.4748	.3605		.3963	
13				.3605			
19	3.0312	2.6673	2.8826	2.9165	2.713	2.4996	.4534
20	2.7854	2.5606	3.1255	2.6543	2.5606	2.4234	.426
21	2.5888	2.4082	2.7206	2.5232	2.6052	2.3624	.3963
22	2.1956	2.3624	2.2348	2.1956	2.5396	2.2996	.381
23	2.1052	2.3167	2.1052	2.1628	2.4741	2.4453	.4115
24	2.1862	1.9204	2.5265	1.8515	2.0645	2.4249	
Max	3.0312	2.6673	3.1255	2.9492	2.713	2.4996	.4534
Min	.3963	.3353	.373	.3605	.3605	.3353	.381
Avg	1.6032	1.4995	1.7396	1.5203	1.6752	1.6088	.4136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 207 / 11KV TARANGFAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.4572	.4359	.4915	.4572	.4424	.4424
2	.421	.4572	.4359	.4915	.502	.4424	.5243
3	1.1012	1.0364	2.1704	2.0972	1.0974	1.2452	1.2308
4	1.1336	1.166	2.4813	2.4249	1.1584	1.3108	1.3108
5	1.2146	1.1984	.4748	2.13	1.2193	1.3763	1.4243
6	2.17	1.3279	.5365	1.9989	1.2803	1.4419	1.2793
7	1.9595	1.4413	.5935	1.1633		1.4746	1.4091
8	2.332	1.1984	.4917	1.3599		1.2944	1.3395
9	2.4996	1.1012		1.3108		1.2597	1.5729
10	1.7833	1.004		1.278	1.1736	1.2431	1.9498
11	.7926	2.6073	2.5987	1.8023	1.6032	2.2542	
12	.9602	2.4234	2.5316	2.4249	1.7071	2.6686	
13	.9907	2.5587	2.4478	2.5724	1.7985	2.4577	
14	1.0364	2.5425	2.3739	2.6543	1.9509	2.3102	
15	1.1869	2.5425		2.2611	1.9204	1.9662	
16	1.2289	2.5263	1.9826	2.0317	1.9052	1.8515	
17	1.0974	2.3967	2.0972	1.9662	1.9814	2.0645	
18	.9602	2.1538	.3768	1.8023	1.7833		
19	.381	.381	.4424	.3441	.3963		.4115
20	.3963	.4268		.4096	.4115	.4424	.4115
21	.4268	.4268	.4424	.4588	.4268	.4588	.4372
22	.4268	.4115	.4588	.4915	.4115	.4424	.4572
23	.4572	.4115	.4588	.4915	.4115		.4858
24	.4534	.4858	.4748	.4752	.4915	.4424	.4424
Max	2.4996	2.6073	2.5987	2.6543	1.9814	2.6686	1.9498
Min	.381	.381	.3768	.3441	.3963	.4424	.4115
Avg	1.0763	1.3618	1.2153	1.4555	1.1470	1.3757	.9456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 208 / 11 KV TARANGFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.4049	.4359	.4144	.4268	.4144	.4527
2	.4268	.4049	.4239	.4144	.4268	.4144	.4409
3	.4268	.381	.4191	.4144	.4268	.4641	.4694
4	.4572	.3963	.4748	.4641	.4572	.4807	.4752
5	.4877	.4534	.4694	.4641	.4877	.547	.5596
6	.4877	.4572	.4696	.4807	.5487	.5967	.5735
7	.4115	.4534	.4748	.3481		.5304	.426
8	.3201	.3887	.3239	.3481		.3812	.3277
9	.2743	.3048	.3222	.3315		.3077	.2622
10	.2105	.2439	.2543	.2486	.2743	.2915	.213
11		.1943		.2155	.2439	.2753	.1638
12		.1781	.2204	.1989	.2134	.2429	.1966
13	.1677	.1372	.2035	.1823	.1829	.1989	.1966
14	.2134	.1219	.1844	.1823	.1677	.1989	.2035
15	.1981	.1219	.1658	.1823	.1677	.2155	.1943
16		.1524		.2155	.1981	.2321	.1829
17	.2439	.1677	.1823	.2486	.2286		.2134
18	.2743	.1829		.2984	.2743	.3315	.2439
19	.4915	.3506	.4144	.4807	.3963	.4475	.3963
20	.4268	.3658	.4807	.4973	.442	.431	.4572
21	.4268	.3963	.431	.4973	.4572	.4973	.4268
22	.3963	.3963	.431	.4641	.4268	.4641	.381
23	.3963	.381	.3978	.4641	.4268	.4641	.3963
24	.4049	.421	.4191	.3978	.4268	.4475	.4578
Max	.4915	.4572	.4807	.4973	.5487	.5967	.5735
Min	.1677	.1219	.1658	.1823	.1677	.1989	.1638
Avg	.3590	.3107	.3618	.3522	.3477	.3859	.3463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 209 / 11KV KALE-PANDARE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2753	.3052	.2743	.3077	.2652	.2683
2	.2743	.2591	.3052	.2743	.2896	.2984	.2683
3	.3048	.2591	.3391	.3239	.2896	.2984	.3052
4	.3401	.2915	.3391	.3048	.3048	.3149	.3052
5	.3506	.3048	.3391	.3048	.3048	.3149	.3353
6	.3768	.3353	.373	.3353	.3353	.3315	.407
7	.3506	.3201	.407	.2743		.3315	.3521
10					2.0729		
11	2.1792	2.3967	2.431	2.2024	1.9509	2.1956	
12	2.1052	2.2024	2.2801	2.1376	1.9052	2.3758	
13	2.0729	2.3967	2.1125	1.9204	2.0081	2.1052	
14	2.0405	1.9357	1.9448		1.8595	1.9433	
15	2.0729	1.8595	1.8461	1.829	1.829	2.0243	
16	2.0567	1.7833	1.8299	1.8595	1.7833	2.0567	
17	2.0645	1.829		1.7528	1.7528	1.8623	
18	2.0081	1.9757		.3201	1.7859	1.7652	
19	.2949	.2915	.3239	.3048	.2896	.2915	1.9814
20	.2949	.2743		.3239	.2896	.2622	1.9204
21	.2949	.2896	.2753		.2439	.2622	2.0348
22	.2785	.2896	.2915	.3077	.2439	.2458	1.6766
23	.2785	.2896	.2753	.3077	.2286	.2458	1.6309
24	.2915	.2591	.3222	.2753	.3113	.2486	.2515
Max	2.1792	2.3967	2.431	2.2024	2.0729	2.3758	2.0348
Min	.2743	.2591	.2753	.2743	.2286	.2458	.2515
Avg	.9812	.9580	.9078	.8228	.9708	.9543	.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274038 / 33/11kv MALSHIRAS S/Stn

Feeder No / Name : 210 / COURT-(GOVT) EXPRESS NON SHEDDABLE WATER SUPPLY AND
 FEEDER Feeder KV- 11 / UTILITY
 OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.1296	.1187	.1219	.1219	.1372	.1147
2	.1357	.1296	.1357	.1219	.1296	.1372	.0983
3	.1174	.1296	.1187	.1219	.1296	.1372	.1147
4	.1174	.1296	.1187	.1219	.1296	.1372	.1147
5	.1174	.1296	.1187	.1219	.1296	.1372	.1147
6	.1296	.1296	.1187	.1219		.1372	.1147
7	.1341	.1296	.1187	.1219		.1372	.1147
8	.116	.1296	.1187	.1219		.1372	.0983
9	.1174	.1296	.1187	.1219		.1372	.1187
10	.1174	.1296	.1187		.1219	.1372	.1311
11	.1134	.1457	.1187	.1219	.1457	.1372	.1311
12	.1357	.1457	.1372	.1219	.1457	.1372	.1311
13	.1357	.1457	.1372	.1219	.1475	.1372	.1311
14	.1174	.1457	.1372	.1219		.1372	.1311
15	.1341	.1457	.1372	.1296	.1457	.1372	.1219
16	.1187	.1457	.1372	.1296	.1475	.1372	.1311
17	.1311	.1296	.1372	.1372	.1457	.1372	.1219
18	.1357	.1296	.1372	.1219	.1219	.1372	.1219
19	.1174	.1296	.1372	.1219	.1219	.1372	.1219
20	.1174	.1296	.1372	.1219	.1296	.1372	.1219
21	.1174	.1296	.1372	.1311	.1296	.1372	.1219
22	.1174	.1296	.1372	.1219	.1219	.1372	.1219
23	.1174	.1296	.1372	.1219	.1296	.1372	.1219
24	.1357	.1296	.1187	.1219	.1296	.1372	.1357
Max	.1357	.1457	.1372	.1372	.1475	.1372	.1357
Min	.1134	.1296	.1187	.1219	.1219	.1372	.0983
Avg	.1235	.1336	.1287	.1236	.1328	.1372	.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 201 / 11KV KANHER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2105	.1802	.2286	.2267	.2294	.2134
2	.2286	.2105	.1638	.2286	.2267	.2294	.2187
3	.2286	.2267	.1802	.2286	.2105	.2458	.2134
4	.2286	.2267	.1966	.2286	.2105	.2622	.1981
5	.2343	.2267	.213	.2439	.2267	.2622	.1981
6	.2439	.2267	.213	.2439	.2267	.2622	.1981
7	.2286	.2267	.213	.1562	.2267	.2622	.2286
8	.1981	.2294	.2294	.1677	.213	.2294	.1981
9	1.9966	1.9433	1.8947	1.9204	2.1052	2.1376	.1829
10	2.2672	2.1538	1.9528	2.251	2.2348	2.1186	.1943
11	2.3482	2.0081	2.0881	2.1052	2.1862	1.9966	
12	2.0729	1.9919	1.9509	2.0405	2.2024	1.9509	
13	2.1214	2.0243	1.9509	1.9757	2.1376	2.0309	
14	2.1862	1.9433	1.89	1.9757	2.1052	2.0466	
15	2.1052	1.9109	1.8903	2.0243	2.0729	1.9509	
16	1.9109	1.8461	1.829	1.9919	2.0243	1.9204	
17	.1619	.1311	.1524	.1457	.1802	.1875	
18	.213	.1638	.1981	.1802	.1966	.1677	2.2283
19	.213	.1966	.2134	.2267	.2294	.1829	2.1538
20	.213	.1802	.2134	.2105	.2622	.1981	2.1464
21	.2267	.1638		.1943	.2294	.1981	2.0567
22	.2267	.1802	.2134	.1943	.2458	.1981	1.9595
23	.2267	.1966	.2286	.2105	.2622	.2187	1.9433
24	.2286	.2105	.1966	.2286	.2267	.2622	.2134
Max	2.3482	2.1538	2.0881	2.251	2.2348	2.1376	2.2283
Min	.1619	.1311	.1524	.1457	.1802	.1677	.1829
Avg	.8557	.7929	.8023	.8167	.8612	.8229	.8674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 202 / 11KV ISLAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8623	1.6518	1.7814	1.8623	2.17	1.7814	1.7814
2	1.8623	1.6194	1.7652	1.8623	2.17	1.749	1.7004
3	1.8623	1.6194	1.8623	1.8461	2.17	1.7328	1.7004
4	1.9109	1.749	1.8623	1.7966	2.1862	1.7814	1.7004
5	1.9271	1.7652	1.9109	1.9109	2.1376	1.8623	1.8138
6	1.9271		1.9757	1.9433	2.1214	1.9109	1.8947
7	2.0567	1.8623	2.0891	1.6194	2.2348	1.9109	1.9919
8	.1619	.1475	.1638	.1718	.1475	.1475	.1562
9	.125	.1134	.1311	.1406	.1457	.1475	.1406
10	.0972	.1147	.125	.1457	.1475		.1296
11	.0972	.0983	.1067	.1134	.1147	.1094	
12	.1134	.0983	.1067	.1134		.1094	
13	.1134	.0819	.1094	.1134	.1147	.1094	
14	.1134	.0819	.0781	.1134	.1147	.125	
15	.1134	.0819	.1094	.1134	.1147	.1067	
16	.0972	.1147	.1094	.1134	.0983	.125	
17		.1147	.125	.1134	.1311		
18	.1147	.1311	.1524	.1147	.1475	.125	.1147
19	.1475	.1475	.1562	.1943	.1638	.1718	.1638
20	.1475	.1638	.1562	.1943	.1966	.1718	.1638
21	.1296	.1475		.1781	.1802	.1562	.1475
22	1.7814	1.6518	1.9109	1.6356	1.9595	1.9595	.1457
23	1.7652	1.749	1.8299	1.9271	1.9433	1.8947	.1457
24	1.8299	1.6518	1.7814	1.8138	2.2024	1.9271	1.7976
Max	2.0567	1.8623	2.0891	1.9433	2.2348	1.9595	1.9919
Min	.0972	.0819	.0781	.1134	.0983	.1067	.1147
Avg	.8851	.7373	.8869	.8396	1.0049	.9143	.9228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 203 / 11KV MANAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3125	.2591	.2294	.3048	.2915	.2622	.2896
2	.3125	.2753	.2622	.3048	.2915	.2622	.2968
3	.3125	.2753	.2622	.3048	.3077	.2949	.2968
4	.3125	.2915	.2785	.3048	.3239	.2949	.2968
5	.3281	.2915	.2949	.3201	.3239	.3113	.2968
6	.3281	.2915	.2949	.3201	.3239	.3277	.2968
7	.3125	.2915	.2949	.1829	.3401	.2949	.2968
8	.2812	.2949	.3113	.2656	.3441	.2622	.2439
9	.2187	.2429	.2622	.1562	.2753	.213	.2031
10	.2105	.213	.2286	.1943	.2458		.1619
11	.2105	.213	.1372	.1943	.2294	.1562	
12	.1943	.1966	.1524	.1943	.1802	.1677	
13	.1943	.1966	.1562	.1619	.1638	.1562	
14	.1943	.1802	.1406	.1619	.1638	.1562	
15	.1781	.1638	.1406	.1943	.1802	.1067	
16	.1619	.1638	.1219	.1781	.1966	.1677	
17	1.8623	1.9109	2.234	2.0729	2.2996	1.9204	
18	2.0153	2.1214	.2656	2.4413		2.234	.213
19	2.0153	2.0243	1.5851	1.8623	1.9109	1.8435	.3277
20	1.7859	1.7814	1.6404	1.749	1.8299	1.7654	.3277
21	1.3435	1.3279		1.4575	1.5223	1.3592	.3277
22	1.2955	1.2631	1.2651	1.3117	1.4413	1.1873	.3239
23	1.1174	1.1012	1.1248	1.1984	1.2308	1.0155	.3239
24	.9842	.8907	.9231	.9907	1.0688	1.1336	.9602
Max	2.0153	2.1214	2.234	2.4413	2.2996	2.234	.9602
Min	.1619	.1638	.1219	.1562	.1638	.1067	.1619
Avg	.6867	.6776	.5481	.7011	.6733	.6910	.3226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 204 / ISLAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1403	.9878	1.086	1.1765	1.004	1.2489	1.2127
2	1.1765	.9878	1.1222	1.1765	1.0364	1.2308	1.2127
3	1.1765	1.1012	1.1222	1.2308	1.1174	1.2308	1.267
4	1.267	1.1984	1.1584	1.267	1.1984	1.267	1.3575
5	1.448	1.3117	1.2489	1.3575	1.2793	1.4661	1.5565
6	1.7013	1.4575	1.2851	1.5746	1.4251	1.6651	1.5775
7	1.3213	1.2793	1.1946	.9774	1.247	1.3032	
9	.9231	.8745	.905	1.0317	.8907	.905	.8688
10	.6154	.8326	.7421	.6964	.7783		.7287
11	.5668	.6878	.6335	.6154	.6335	.6516	.6226
12	.4858	.5792	.5611	.5992		.6516	.5735
13	.4858	.5973	.543	.5668	.5973	.6154	.5079
14	.4696	.5792	.4163	.5506	.5792	.6154	.5243
15	.4696	.5611	.543	.5344	.6154	.5068	.5735
16	.4858	.6154	.6154	.583	.6697	.5792	.6226
17	.583	.6335	.7059	.6964	.7602		.6554
18	.7209	.6697	.7964	.7701		.7783	.7537
19	.9717	1.2127	1.1403	1.0364	1.1584	1.1946	1.1142
20	.9878	1.2489	1.3394	1.085	1.448	1.3394	1.1633
21	.9995	1.1584		1.0526	1.2127	1.2851	1.1469
22	.9878	1.1584	1.1765	1.0526	1.2308	1.1393	1.1336
23	.9878	1.1222	1.1584	1.0364	1.2308	1.1393	1.1174
24	1.1403	1.004	1.086	1.1218	1.004	1.2489	1.2127
Max	1.7013	1.4575	1.3394	1.5746	1.448	1.6651	1.5775
Min	.4696	.5611	.4163	.5344	.5792	.5068	.5079
Avg	.9179	.9504	.9354	.9474	1.0056	1.0506	.9774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 205 / GORADWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3279	1.6518	1.3765	1.5623	1.9271	1.7814	2.0309
2	1.3279	1.6194	1.4575	1.5623	2.1052	1.9109	2.0309
3	1.406	1.6194	1.4575	1.7185	2.2834	2.1052	2.1338
4	1.406	1.4413	1.6518	1.8747	2.5749	2.3967	2.3434
5	1.4373	1.4251	1.7814	2.1091	2.6235	2.5749	2.4387
6	1.4685	1.4413	1.9109	2.484	2.8664	2.6235	.442
7	1.9216	1.5384	2.0405	2.3434	2.9312	.1781	
8	1.6091	1.5238	1.8138	2.6715	2.7362	.2591	2.5453
9	.2187	.2753	.3113	.4062	.3887		.3281
10	.1457	.1966	.2187	.3563	.3932		.2753
11	.1457	.1966	.2187	.3077	.3441	.2031	
12	.2429	.1966	.1875		.3277	.2656	
13	.2591	.2294	.1875		.2949	.2812	
14	.2753	.2294	.1875		.2785	.3281	
15	.2753	.2458	.1718		.2949	.3353	
16	.2591	.2785	.1562		.3277	.3437	
17	.2753	.2622	.2031	.3239	.3932	.4531	
18	.3113	.213	.3125	.4096	.4424	.4218	.3277
19	.3725	.2785	.3125	.5182	.5079	.4531	.5079
20	.3932	.2949	.3437	.4858	.5407	.4531	.4915
21	.426	.3113		.4372	.4752	.4531	.4915
22	.421	.3277	.381	.4372	.4752	.4374	.4858
23	.4049	.3441	.4062	.4372	.4424	.4218	.4858
24	.4062	.3887	.3441	.4115	.4534	.426	.3963
Max	1.9216	1.6518	2.0405	2.6715	2.9312	2.6235	2.5453
Min	.1457	.1966	.1562	.3077	.2785	.1781	.2753
Avg	.6974	.6887	.7579	1.0977	1.1012	.8685	1.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274105 / 33/11KV ISLAMPUR S/Stn

Feeder No / Name : 206 / SARGARWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2968	.2753	.2949	.2968	.2591	.2949	.2968
2	.2968	.2915	.2949	.2968	.2915	.2949	.2968
3	.2968	.3401	.3113	.2968	.3401	.3113	.2968
4	.2968	.3725	.3277	.3125	.3563	.3277	.2968
5	.3437	.3887	.3441	.3437	.3563	.3441	.3437
6	.3749	.4049	.3768	.3749	.3887	.3441	.3749
7	.3437	.3563	.3768	.2968	.3563	.3277	.3281
8	.2812	.3113	.2949	.2968	.2622	.2458	.2343
9	.2343	.1943	.2294	.2343	.1943	.1966	.2031
10	1.7004	1.587	1.749	1.8461	1.7652		1.668
11	1.749	1.9433	1.8785	1.8785	1.8461	1.9271	
12	2.2024	1.9433	2.0891	1.9919	1.9989	1.8138	
13	2.1376	1.9271	2.1052	1.8785	1.9109	1.7814	
14	1.9919	2.0405	1.8947	1.8947	1.7328	1.7328	
15	1.9433	1.9109	1.8623	1.7328	1.7166	1.7004	
16	1.8947	1.7814	1.7814	1.6518	1.668	1.7004	
17	1.6518	.1475	1.749	1.587	1.5223	1.531	
18	.1802	.1638	.1875	.1802	.1802	.1718	.1638
19	.2429	.2785	.2656	.2753	.2785	.25	.2622
20	.2591	.2785	.2812	.0162	.2949	.2656	.2622
21	.2622	.2785		.2591	.2294	.2812	.2622
22	.2591	.2785	.2812	.2591	.2622	.2812	1.1174
23	.2591	.2949	.2812	.2591	.2785	.2812	1.3117
24	.2968	.2753	.2949	.2968	.2591	.2949	.2968
Max	2.2024	2.0405	2.1052	1.9919	1.9989	1.9271	1.668
Min	.1802	.1475	.1875	.0162	.1802	.1718	.1638
Avg	.8248	.7527	.8501	.7815	.7812	.7261	.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 201 / DESHMUKH PATTAG AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2134	.2572	.2439	.3018	.3086	.3018
2	.3353	.2439	.2572	.2439	.3185	.3086	.3353
3	.3521	.2439	.2572	.2134	.3185	.3086	.3018
4	.3521	.2743	.2743	.2134	.3353	.2743	.3185
5	.3688	.2743	.2743	.2134	.3353	.2915	.3018
6	.3856	.3048	.3086	.2439	.3353	.2572	.3018
7	.3521	.3048	.3429			.2058	.285
8	.2347	.1981	.2401	.2134		.1886	.2515
10	1.6766	1.7528	1.5851	1.5242	1.5424	1.5604	1.2574
11	1.5242	1.9376		1.5424	1.7147	1.6804	
12	1.448	1.8004	1.448	1.5089		1.5947	
13		1.5089	1.4022	1.3748	1.286	1.5604	
14	1.3717	1.4575		1.3592	1.3032	1.406	
15	1.5242	1.406	1.448	1.3094	1.2517	1.3375	
16	1.5242	1.3889	1.2498	1.3413	1.3032	1.3546	
17	1.2193	1.3717	1.1431	1.3413	1.406	1.3546	
19	.2439	.2401	.2439	.2683	.2572	.2572	.2683
20	.2286	.2401	.2439	.2683	.2572	.2515	.2683
21	.2134	.2915	.2743	.3018	.2915	.2347	.2683
22	.2134	.2401	.2439	.3018	.2743	.2683	1.3413
23	.2134	.2743	.2439	.3018	.2743	.2683	1.2574
24		.2134	.2572	.2683		.2683	1.0898
Max	1.6766	1.9376	1.5851	1.5424	1.7147	1.6804	1.3413
Min	.2134	.1981	.2401	.2134	.2572	.1886	.2515
Avg	.7058	.7355	.5998	.6951	.7281	.7064	.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 202 / 11KV UMBARE DAHIGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	1.7071	1.8004	1.6766	1.6766	1.869	1.8067
2	1.8442	1.7985	1.8519	1.768	1.8442	1.9719	1.8564
3	1.9281	2.0424	1.8861	1.89	1.9281	2.0062	1.9393
4	1.9281	2.1948	1.9033	2.0729	2.0119	2.0919	1.9725
5	2.0119	2.3472	2.0405	2.1643	2.1795	2.1434	1.9989
6	2.0119	2.5301	2.3491	2.2862	2.431	2.3491	2.0885
7	2.5987	2.5911	2.6578			2.3834	2.1382
8	.2683	.3048	.2743	.3048		2.4348	.2652
11				1.3748			
12				1.4754			
19	.2896	.2572	.3201	.3481	.3258	.3258	.2984
20	.3048	.2743	.3201	.3521	.3601	.3185	.3185
21	.3048	.3086	.3353	.3688	.3601	.3353	.3185
22	1.5242	1.6804	1.5242	.3688	1.6118	1.8275	.3481
23	1.6156	1.7833	1.5851	.3521	1.6461	1.7939	.3647
24		1.6461	1.8004	1.4083		1.7101	.3647
Max	2.5987	2.5911	2.6578	2.2862	2.431	2.4348	2.1382
Min	.2683	.2572	.2743	.3048	.3258	.3185	.2652
Avg	1.4211	1.5333	1.4749	1.2141	1.4887	1.6829	1.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 203 / KHANDOBA WASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.3108	1.5089	1.3717	1.2955	1.4918	1.2944
2	1.4746		1.5261	1.4022	1.3765	1.5432	1.2452
3	1.5565		1.5604	1.4327		1.6118	1.4255
4	1.6057		1.5775	1.4937		1.5604	1.5074
5	1.6385		1.6461	1.5546	1.6194	1.6461	1.5402
6	1.704		1.8004	1.6156	1.6518	1.7147	1.5729
7	1.9662		1.989			1.7661	1.5074
8	.1638		.3086	.1981		.1715	.1638
19	.2286	.2401	.2286	.2294	.2572	.2229	.2267
20	.1981	.2229	.2286	.2267	.2229	.1943	.213
21	.1981	.2058	.2134	.2294	.1715	.1781	.213
22	1.1126	1.4575	1.2651	1.3435	1.406	1.4575	.1943
23	1.1888	1.4746	1.2955	1.3765	1.4403	1.4251	.1781
24		1.2193	1.4918	1.2289		1.3603	.1802
Max	1.9662	1.4746	1.989	1.6156	1.6518	1.7661	1.5729
Min	.1638	.2058	.2134	.1981	.1715	.1715	.1638
Avg	1.1099	.8759	1.1886	1.0541	1.0490	1.1674	.8187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 204 / 11KV KACHAREWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3149	.1357	.3086	.1174	.2652	.3086	.2949
2	.3315	.1372	.3086	.1189	.2652	.3086	.3113
3	.3315	.1387	.3086	.1219	.2984	.2915	.3239
4	.3315	.1417	.3258	.125	.2984	.2572	.2949
5	.3647	.1433	.3429	.1296	.3149	.2401	.2785
6	.3812	.1478	.3601	.1387	.3647	.2743	.2622
7	.3647	.1494	.3772			.3429	.2458
8	.2486	.1311	.3258	.1372		.2401	.2294
9	.2347	.1235		.1326		.2743	.2785
10	.1989	.1158	.0914	.1311	.1989	.1886	.213
11		.1715	.0793	.1989	.1886	.1886	.1802
12	.0823	.1886	.0777	.1823	.1715	.1715	.1638
13		.1886	.0762	.1638	.1372		.1677
14	.0793	.1715	.0732	.1475	.1372	.1543	.1341
15	.0762	.1543	.0716	.1311	.12	.1372	
16	.0716	.1715	.0686	.1492	.12	.1543	.1174
17	.0716	.1886	.0701	.1658		.1543	.1326
18	.0762	.1886	.0732	.2012		.1886	.1341
19	.1082	.3258	.0869	.285	.3944	.3086	.3113
20	.125	.3086	.1006	.2155	.3086	.2321	.3315
21	.128	.3086	.1067	.2321	.3086	.2652	.2818
22	.1311	.2743	.1113	.3149	.3086	.2652	.3315
23	.1341	.3086	.1143	.2984	.3086	.2652	.2949
24		.1357	.3086	.2652		.2818	.2949
Max	.3812	.3258	.3772	.3149	.3944	.3429	.3315
Min	.0716	.1158	.0686	.1174	.12	.1372	.1174
Avg	.1993	.1854	.1812	.1784	.2505	.2388	.2438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 205 / KAMALMALA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.3048	.3086	.2743	.4534	.3258	.3887
2	.3563	.3048	.3258	.2743	.4049	.3429	.3563
3	.3563	.3048	.3258	.2743	.421	.2915	.3401
4	.3768	.3201	.3429	.2743	.421	.3772	.3239
5	.3725	.3201	.3429	.2896	.4372	.4115	.3239
6	.421	.3353	.3601	.3048	.4372	.3772	.3401
7	.3887	.3353	.3944			.3429	.3239
8	.2915	.2743	.3086	.2591		.2401	.2949
10	3.0849	2.7435	2.3472	2.5149	2.3594	2.7092	
11		3.1207	2.6825	2.6216	2.7606	2.8635	
12		2.8807	2.4387	2.5888		2.692	
13		2.6063	2.3472	2.4291	2.5892	2.1262	
14	2.9416	2.7092	2.2862	2.3644	2.6406	2.1948	
15	2.9874	2.7435	2.2558	2.3158	2.5206	2.2805	
16	3.0178	2.6749	2.1948	2.3482	2.2462	2.2805	
17	2.7435	2.6063	2.1033	2.0972	2.1262	2.2977	
19	.3353		.3048	.3725	.3086	.3429	.3768
20	.3353	.2743	.3201	.3605	.3086	.3113	.3725
21	.3201	.3086	.3353	.3563	.3258	.3113	.3563
22	.3353	.3086	.2896	.3563	.3429	.3277	2.2611
23	.3353	.3086	.2896	.3277	.3772	.3277	2.2611
24		.3201	.3086	.3563		.3605	2.2348
Max	3.0849	3.1207	2.6825	2.6216	2.7606	2.8635	2.2611
Min	.2915	.2743	.2896	.2591	.3086	.2401	.2949
Avg	1.0753	1.2431	1.0551	1.1124	1.1934	1.0970	.7539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274132 / 33KV KACHREWADI S/STN

Feeder No / Name : 206 / TIRWANDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.945	.3429	.9145	.9831	1.046	.9892
2	.9012	.9755	.3601	.945	1.0159	1.0974	1.0322
3	.9012	1.0059	.3601	.9755		1.1831	1.0814
4	.9831	1.0364	.3772	1.0059	1.1142	1.2346	1.1797
5	1.065	1.1279	.4115	1.0364	1.1469	1.2689	1.1305
6	1.1142	1.2193	.4458	1.0669	1.1961	1.2174	1.085
7	1.3763	1.3565	.5487			1.1831	.8421
8	.3113	.3048		.3353		.2401	.2622
19	.3048		.2743	.3812	.3772	.3258	.3441
20	.3353		.2743	.3277	.3601	.2622	.3441
21	.3658		.2896	.3113	.3429	.2949	.3441
22	.823	.2915	.7926	.9012	.8916	.852	.3277
23	.884	.3429	.823	.8848	.9602	.8684	.3441
24		.9145	.3429	.8619		.9175	.3605
Max	1.3763	1.3565	.823	1.0669	1.1961	1.2689	1.1797
Min	.3048	.2915	.2743	.3113	.3429	.2401	.2622
Avg	.7834	.8655	.4341	.7652	.8388	.8565	.6905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 201 / 11KV LAXMINAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3429	.2311	.3201	.3555	.3201	.3601
2	.3353	.3429	.2311	.3201	.3555	.3201	.3601
3	.3353	.3429	.2489	.3201	.3377	.3201	.3772
4	.3506	.3772	.2489	.3353	.3377		.3944
5	.3963	.463	.3022	.3658	.3911	.3658	.4458
6	.4572	.463	.3911	.4268	.4266	.4268	.4458
7	.381	.4458	.4444		.4622	.4115	.4287
8	.2591	.3601	.3733	.3353	.4088	.3506	.3944
9	.2915	.3733	.2286	.3022	.2743	.2743	.3733
10	2.2977	2.293	2.3777	1.7776	2.2405	2.7949	2.7374
11	2.6578	2.3997	2.4691	2.4708	2.5149	3.035	
12	2.7949	2.4886	2.4387	2.7197	2.4996	2.8121	
13	2.5549		2.271	2.5241	2.3777	2.6235	
14	2.3663	2.613	2.1491	2.4886	2.0576	2.6406	
15	2.5892	2.3997	1.9814	2.4352	2.0424	2.5892	
16	2.5892	2.1508	1.9814	2.3997		2.572	
17	2.4177	2.0086	1.89	2.3286	1.7833	2.1948	
18	.2058	.2311	.1524	.2489	.2134	.2743	.1067
19	.3601	.2489	.2896	.2844	.2896	.3429	.1067
20	.3601	.2489	.3048	.3377	.2896	.3429	.1422
21	.3772	.2311	.3048	.3555	.2896	.3429	.3555
22	.3258	.2133	.3201	.3733	.3201	.3429	2.3641
23	.3429	.1955	.3201	.3555	.3201	.3429	2.3997
24	.3353	.3734	.1955	.3201	.3377	.3201	.3601
Max	2.7949	2.613	2.4691	2.7197	2.5149	3.035	2.7374
Min	.2058	.1955	.1524	.2489	.2134	.2743	.1067
Avg	1.0715	.9394	.9227	1.0498	.9098	1.1461	.7148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 202 / 11KV GIRVI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.989	2.0869	2.0405	2.4223	1.9547	1.8861
2	1.989	2.1658	2.1428	2.0405	2.5154	1.989	1.8861
3	1.989	1.989	2.2173	2.0576	2.6459	2.0062	1.8861
4	2.0233	2.0062	2.2359	2.0919	2.7949	2.1262	2.0538
5	2.0919	2.0233	2.3664	2.1605	2.8881	2.2291	1.9547
6	2.1776	2.1605	2.5154	2.2977	2.9813	2.8121	2.1262
7	2.2462	2.4863	2.7018		2.9999	2.5892	2.5377
8	.3601	.4287	.4658	.5316	.4658	.4801	.463
9	.3601	.3354	.3772	.4099	.3601	.3944	.354
10	.3258	.3168	.2743	.3727	.3086	.3258	.3727
11	.2743	.3168	.2743	.3168	.3086	.2743	
12	.2743	.2981	.2743	.205	.2915	.2915	
13	.2572	.2981		.2236	.2915	.3429	
14	.2401	.3354		.2422	.2915	.2401	
15	.2743	.3168	.3086	.2795	.2915	.2915	
16	.2743	.3354	.3258	.3168	.2915	.2915	
17	.2743	.3727	.3258	.3727	.3258	.3086	
18	.3601	.4099	.3772	.4099	.3944	.3258	.4658
19	.5487	.4472	.4458	.4472	.5316	.4801	.5031
20	.5487	.5404	.5316	.5031	.5144	.4973	.5404
21	.5487	.5217	.5316	.5404	.5144	.5316	.5776
22	2.0911	2.1428	2.0576	2.2732	2.2977	2.1262	.5404
23	1.989	2.1055	2.0405	2.3105	2.2634	2.0405	.3727
24	1.989	1.989	2.0496	2.0405	2.3291	1.9547	1.8861
Max	2.2462	2.4863	2.7018	2.3105	2.9999	2.8121	2.5377
Min	.2401	.2981	.2743	.205	.2915	.2401	.354
Avg	1.0623	1.0971	1.2239	1.0645	1.3050	1.1210	1.2004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 203 / 11KV MANDAVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9259	.801	.9602	.801	.9602	1.0974
2	.9088	.9259	.7846		.7846	.9602	1.1949
3	.9088	.9431	.7683	.9602	.7683	.9774	1.1949
4	.9602	.9774		.9945	.8173	.9945	1.2136
5	1.0117			1.0288	.9481	1.0288	1.2883
6			.7519	1.1488	1.0135	1.1145	1.251
7			.8173		.9318	1.0288	1.046
8		.2572	.6866	.9774	.8664	.9088	1.0269
9		.801	.6516	.85	.8059	.9088	.85
10	.2229	.7356	.583	.7846	.7716	.823	.7519
11	.6173	.7029	.5487	.7029	.7202	.7888	.6539
12	.6161	.6702	.4801	.6212	.6173	.6687	.6212
13	.6348	.6375	.5335	.6375	.5658	.6535	.5721
14	.6173	.5558	.4458	.6539	.583	.6173	.5394
15	.7202	.5394	.5144	.6866	.6173	.583	.5558
16	.7842	.5394	.7202	.7193	.703	.6516	.5721
17	.7888	.5558	.7716	.7519	.6687	.6516	.5885
18	.8059	.6866	.8745	.7846	.7373	.7545	.7356
19	1.0974	.8173	1.166	.8173	1.1488	1.0288	.85
20	1.0974	.9645	1.2174	.85	1.1831	1.046	.9154
21	1.1145	.9971	1.0117	.9318	1.0631	1.0802	.9808
22	1.2136	.8827	1.0631	.9154	1.0974	1.0802	.9154
23	1.0117	1.0098	1.0288	.8664	1.0288	1.1763	.8991
24	.8916	.9259	.8173	.9774	.8173	.9602	1.0974
Max	1.2136	1.0098	1.2174	1.1488	1.1831	1.1763	1.2883
Min	.2229	.2572	.4458	.6212	.5658	.583	.5394
Avg	.8457	.7643	.7744	.8464	.8358	.8936	.8922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 204 / 11KV AHILYANAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.4973	.3429	.6287	.5144	.5906	.5144
2	.5906	.4973	.4191	.6287	.4954	.5906	.5144
3	.5906	.5144	.4572	.6287	.4763	.5906	.5487
4	.5487	.5316	.4954	.6478	.5144	.6097	.6348
5	.6287	.583	.5144	.6859	.5525	.6287	.7282
6	.6668	.5658	.5525	.743	.5716	.7049	.6001
7	.5525	.5316	.5906		.5906	.7049	.5658
8	.5144	.463	.4763	.5716	.4954	.5716	.5601
9	.4458	.4382	.4001	.4572	.4572	.4458	.4382
10	3.1379	2.0957	3.1245	3.0674	3.2198		2.8578
11	2.9664	2.191	3.1055	3.1817	3.4103	2.9835	
12	3.0178	2.4577	3.1055	3.2388	3.3341	2.7778	
13	2.915	2.8578	2.934	3.0674	3.1245	2.692	
14	2.7606	2.9531	2.8959	2.915	2.7435	2.5206	
15	2.7778	2.8578	2.8387	2.8387	2.6863	2.5206	
16	2.7778	2.8197	3.0293	2.8006	2.6482	2.6235	
17	2.1948	2.6863	2.5149	2.7435	2.5339	2.3148	
18	.3258	.3429	.3429	.4001	.381	.4287	.381
19	.5144	.381	.5716	.4763	.5716	.5415	.4191
20	.5144	.4001	.5716	.5144	.6097	.4973	.4763
21	.4973	.362	.5906	.5716	.6097	.4973	.5525
22	.4973	.3429	.6478	.5716	.6287	.5144	2.7435
23	.4973	.3239	.6478	.5525	.6287	.5144	2.7625
24	.5906	.5415	.3048	.6287	.5335	.5906	.5144
Max	3.1379	2.9531	3.1245	3.2388	3.4103	2.9835	2.8578
Min	.3258	.3239	.3048	.4001	.381	.4287	.381
Avg	1.2964	1.1765	1.3114	1.4156	1.3471	1.1937	.9301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

MALSHIRAS S/DN.[808] BU 4808

Substation No/ Name :- 274177 / 33/11KV MANDAVE S/S

Feeder No / Name : 205 / 11KV PURANDAWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.4746	1.8861	1.7528	1.7147	1.5813	1.4563
2	1.5623	1.406	1.848	1.7528	1.7147	1.5623	1.2689
3	1.5623	1.406	1.8099	1.7337	1.6766	1.5623	1.2346
4	1.5813	1.406	1.8099	1.7337	1.6766	1.5813	1.2346
5	1.6385	1.406	1.829	1.7528	1.7909	1.6575	1.2003
6	1.8099	1.6118	1.848	1.7909	1.7528	1.7528	1.3375
7	2.1148	1.9376	1.848		1.7337	1.7909	1.4403
8	.2858	.2572	.3239	.3239	.3048	.3429	.2229
9	.2229	.2858	.2858	.3239	.2667	.2743	.1905
10	.2058	.2667	.2477	.2858	.2096	.2401	.2096
11	.2058	.2286	.2477	.2477	.1905	.2058	
12	.1886	.2096	.1524	.1905	.1905	.2058	
13	.1886	.2096	.1524	.1905	.1905	.2058	
14	.1886	.1905	.1905	.2096	.1905	.12	
15	.1715	.2286	.1905	.2096	.2096	.1543	
16	.1543	.2477	.1905	.2286	.2096	.1372	
17	.1543	.2667	.1905	.2286	.2286	.1543	
18	.2058	.2858	.2477	.2667	.2858	.1886	.2477
19	.3361	.3048	.381	.2858	.3429	.2401	.2858
20	.3174	.3239	.3429	.3048	.3239	.2229	.2858
21	.2743	.3048	.3429	.3239	.2858	.1886	.3048
22	1.7177	1.9624	1.6766	1.6766	1.848	1.4403	.3048
23	1.6804	1.9243	1.829	1.7147	1.7909	1.4232	.2858
24	1.5623	1.6057	1.9052	1.7909	1.7337	1.5813	1.3717
Max	2.1148	1.9624	1.9052	1.7909	1.848	1.7909	1.4563
Min	.1543	.1905	.1524	.1905	.1905	.12	.1905
Avg	.8288	.8229	.9073	.8399	.8692	.7839	.7578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 201 / 11KV DAHIGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.286	1.286	1.3717	.5935	.5658	.5487
2	1.3717	1.286	1.286	1.3717	.5935	.583	.5487
3	1.4575	1.3717	1.286	1.5432	.0593	.583	.5487
4	1.5432	1.6289	1.3717	1.5947	.5935	.6001	.5487
5	1.6289	1.8519	1.5432	1.8861	.6274	.583	.5487
6	1.8347	1.8861	.1638	2.0233			.583
7	1.7147	2.1434	1.9719				
8	.4458	.3201	.463	.4801	.4239	.4801	.5316
9	.3772	.3601	.3429	.4115	.4239	.3601	.4458
10		.2572	.3429	.3429	2.0919	1.8004	.3772
11		.2058	.2572		2.0576	1.8176	1.7804
12			.2229		1.9376	1.7147	1.4861
13	.2229		.2401		1.8004	1.5432	1.3413
14	.2572	.2229	.2401		1.8004	1.3717	1.0402
15	.2572	.1844	.2229	.3086	1.5775	1.286	1.1736
16		.1886	.2401	.3086	1.5775	1.2346	
17	.3429	.2915	.2401	.3429	1.3375	1.166	1.0059
18	.3601	.3429	.3086		.4801	.4115	
19	.5487	.503	.5658	.5426	.5144	.4973	.503
20	.5316	.5487	.5487	.6001	.5316	.5487	.57
21	.5658	.5487	.5487	.583	.583	.5487	.5658
22	1.2003	1.3717	1.3717	.6001	.5316	.5487	1.0288
23	1.286	1.291	1.4403	.6274	.5658	.5487	1.0059
24	1.4575	1.2689	1.286	1.3375	.0593	.5487	.5487
Max	1.8347	2.1434	1.9719	2.0233	2.0919	1.8176	1.7804
Min	.2229	.1844	.1638	.3086	.0593	.3601	.3772
Avg	.9388	.8800	.7413	.9042	.9437	.8792	.7967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 202 / 11KV KALAMBOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.703	.6516	.6859	2.2043	2.3148	2.4006
2	.6859	.7202	.6516	.6344	2.2043	2.3148	2.4006
3	.6859	.7202	.6516	.6516	2.2043	2.4863	2.4863
4	.6859	.7373	.6859	.6516	2.3739	2.6578	2.572
5	.7202	.7373	.7202	.6859	2.4587	2.6578	2.7435
6	.7545	.7545	.6859	.7202	2.6282	2.915	2.4863
7					2.9673	3.1722	3.0864
8	.5144	.6001	.6001	.6173	.5426	.6001	.6173
9	.4458	2.4863	2.0957	.4973	.4694	.4287	.5487
10	3.1893	2.6578	2.5434	.4973	.4287	.4287	.3772
11	3.3608	2.7092	2.7435	3.4294		.4287	.4024
12	2.7435		2.4006	3.2579			.3567
13	2.7435		2.4863	3.1855			.2972
14	2.4863	2.5149	3.2579	3.1722		.4458	.3353
15	2.6749	2.6825	3.1379	3.0864		.4458	.4024
16	2.4348	2.5149	2.9492	2.915		.4801	
17	2.3148	2.4006	2.7435	2.7435	.5658	.5144	.4191
18	.4287	.4115	.4115	.4694	.6859	.583	
19	.6344	.6706		.6274	.6859	.6687	.6706
20	.7202	.7209	.6516	.7461	.7202	.7888	.6687
21	.7716	.7373	.6859	.7011	.703	.7716	.7373
22	.7202	.7202	.6859	2.2043	2.4348	2.4863	.6859
23	.6859	.6706	.6859	2.2043	2.4863	2.7435	.5647
24	.6859	.703	.6859	.6859	2.2043	2.3148	2.6578
Max	3.3608	2.7092	3.2579	3.4294	2.9673	3.1722	3.0864
Min	.4287	.4115	.4115	.4694	.4287	.4287	.2972
Avg	1.3814	1.3130	1.4914	1.5248	1.6093	1.4840	1.2690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 203 / 11KV SHINDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4973	.3772	.4115	2.3739	2.7435	2.4006
2	.4458	.5144	.3772	.4115	2.3739	2.7435	2.4006
3	.4458	.5316	.3772	.4458	2.3739	2.8292	2.4863
4	.4973	.5316	.4287	.5144	2.5434	2.915	2.572
5	.4801	.5658	.5087	.5144	2.713	3.0007	2.7435
6	.5658	.6001	.4578	.5316	2.8826	3.3436	3.0864
7	.5487				3.0521	3.2579	3.1722
8	.4115	.463	.4287	.3944	.4748	.4458	.5658
9	.3258	.4287	.3429	.3944	.373	.2915	.4287
10	.6001	3.6008	3.3913	3.7209	.2743	.2401	.3429
11	2.572		3.7723	3.7723		.2572	.4024
12			3.6694	3.6008			.2229
13			3.6008	3.3532			.218
14		3.3532	3.6866	3.1855		.2572	.218
15	3.7037	3.9438	3.6694	3.0864		.2572	.1932
16	3.7723	3.9781		3.0864		.3086	.2515
17	3.9609	3.858	3.1722	2.8292	.3086	.3086	.4191
18	.3601	.5144		.4024	.4287	.463	
19	.5144	.5365	.5144	.5087	.4801	.463	.4527
20	.5316	.5365	.5144	.4748	.5316	.5144	.4694
21	.5658	.4801	.4801	.4578	.5316	.5144	.463
22	.5487	.4115	.4458	2.4587	2.7778	2.4006	.4287
23	.4801	.373	.4458	2.4587	3.0007	2.4863	.3856
24	.4458	.4801	.3688	.4115	2.3739	2.8292	2.4863
Max	3.9609	3.9781	3.7723	3.7723	3.0521	3.3436	3.1722
Min	.3258	.373	.3429	.3944	.2743	.2401	.1932
Avg	1.0606	1.3099	1.4776	1.6272	1.6593	1.4941	1.1656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 204 / 11KV SHERIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.6289	1.5089	1.5432	.39	.4115	.4115
2	1.2346	1.6289	1.6975	1.5775	.39	.4115	.4115
3	1.2346	1.7147	1.5089	1.5432	.4239	.4458	.4115
4	1.3717	1.8004	1.5261	1.7147	.4748	.4458	.4115
5	1.6289	1.8861	1.6289	1.8004	.5596	.4801	.5144
6	1.8519	2.1434	1.6766	2.0576			.5487
7	1.8861	2.2291	2.0748				
8	.4115	.5316	.463	.4801	.4191	.4458	
9	.3429	.3772	.3772	.4458	.373	.3086	
10			.3391	.2572	.3772	2.1434	
11			.2229		1.7147	2.4006	
12		.2401			2.5377	2.0576	1.0402
13	.2229	.2715			2.332	1.989	1.6347
14	.2058	.2515			2.2291	2.0919	2.0119
15	.2229		.2401	.2572	1.9204	1.8861	2.2043
16			.2743	.2572	2.0576	1.8004	
17			.2915	.3429	1.9204	1.7661	1.7804
18	.3601	.3944	.3086	.4024	.4287	.4115	
19	.5144	.5487	.5144	.5144	.463	.4458	.4694
20	.5316	.5868	.5144	.57	.463	.5144	.5426
21	.5144	.5487	1.6289	.503	.4801	.5144	.5144
22	1.5432	1.7147	1.6804	.4239	.4801	.5144	1.5432
23	1.6289	1.6766	1.6804	.4239	.4287	.4115	1.4586
24	1.286	1.6461	1.5927	1.5947	.039	.3944	.4115
Max	1.8861	2.2291	2.0748	2.0576	2.5377	2.4006	2.2043
Min	.2058	.2401	.2229	.2572	.039	.3086	.4115
Avg	.9620	1.1484	1.0357	.8794	.9501	1.0132	.9600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 205 / 11KV DAHIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1203	.1017	1.0288	1.0174	1.1203	1.0288
2	1.0288	1.1203	1.0174	1.0288	1.0174	1.1203	1.0288
3	1.0288	1.1203	1.0174	1.0288	1.0174	1.2136	1.0288
4	1.0288	1.2136	1.1022	1.0288	1.1022	1.2136	1.0288
5	1.2003	1.307	1.1869	1.2003	1.1869	1.307	1.2003
6	1.3717	1.4937	1.3717	1.286		1.4937	1.3717
7	1.2003	1.4937	1.0669				
8	.8573	1.2136	.1017	1.0288	1.0174	1.0269	1.0288
9	.6859	.9335	.8478	.8573	.8478	.9335	1.0288
10	.7468	.8402	.7716	.6535	.7716	.8402	.8573
11	.8402	.6535	.6859	.6535	.6535	.8402	.5944
12	.8402	.2801	.5144	.5975	.6535	.5144	.5868
13		.2572	.5144	.5487	.7468	.5144	.5935
14	.2801	.5144	.5144	.5201	.6535	.5144	.5944
15	.7468	.503	.5144	.5144	.6535	.5144	.5868
16	.8402	.503	.6859	.5144	.6535	.5144	
17	.8402	.6001	.8573	.6001	.7468	.6859	.6706
18	.8589	.6859	1.0288		.9335	.0857	
19	1.1203	1.0898	1.2003	1.1145	1.0269	1.286	1.0898
20	1.2136	1.2574	1.286	1.2003	1.2136	1.3717	1.2574
21	1.2136	1.2003	1.286	1.1361	1.2136	1.2003	1.2003
22	1.1203	1.1145	1.2003	1.1022	1.1203	1.0288	1.1145
23	1.1203	1.0059	1.0288	1.0174	1.1203	1.0288	1.0288
24	1.0288	1.1203	1.0288	1.0288	1.0174	1.1203	1.0288
Max	1.3717	1.4937	1.3717	1.286	1.2136	1.4937	1.3717
Min	.2801	.2572	.1017	.5144	.6535	.0857	.5868
Avg	.967	.9434	.8721	.8950	.9266	.9343	.9499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 206 / 11KV EXPRESS SHIVPRASAD NON SHEDDABLE EXPRESS HV FEEDERS
 MILK Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0934	.1174		.1017	.0934	.1372
2	.0686	.0747	.1006	.12	.0848	.0934	.0857
3	.0686	.0747	.1006	.12	.0848	.0934	.0857
4	.0686	.0934	.0943	.12	.0678	.112	.0857
5	.0686	.0747	.0671	.12	.0678	.112	.0857
6	.0686	.0934	.0671	.1372	.0678	.0934	.0857
7	.0686	.0934	.0671	.1372	.0678	.0934	.0686
8	.1029	.0747	.0686	.1372	.0829	.0934	.0514
9	.3429	.0934	.0857	.1372		.0934	.1029
10	.0934	.1307	.12	.112	.1372	.2054	.1029
11	.168	.1307	.12	.1867	.168	.4108	.1486
12	.112	.0934	.12	.1867	.1867	.2743	.1341
13	.2241	.0934	.12	.1844	.2054	.2743	.104
14	.0934	.12	.1372	.1341	.2054	.2401	.1006
15	.0934	.1341	.1372	.12	.1867	.12	.1006
16	.0934	.2347	.1372	.12	.1307	.1715	
17	.0934	.2572	.1372	.1372	.112	.1886	.0892
18	.056	.2743	.1372	.1174	.1494	.1715	
19	.168	.3395	.1372	.1187	.1494	.0857	.1189
20	.1494	.3185	.1372	.12	.1494	.12	.1509
21	.1494	.3258	.1372	.1357	.1307	.12	.1715
22	.1307	.3258	.1372	.1696	.1494	.1543	.1886
23	.1494	.2401	.1372	.1696	.1307	.1543	.1844
24	.12	.0934	.1677	.1372	.1187	.112	.1543
Max	.3429	.3395	.1677	.1867	.2054	.4108	.1886
Min	.056	.0747	.0671	.112	.0678	.0857	.0514
Avg	.1196	.1616	.1162	.1382	.1276	.1534	.1153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274036 / 33/11 KV DAHIGAON SUBSTATION

Feeder No / Name : 207 / 11 KV PIRALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5144	.5144	.2374	.2401	.2401
2	.5487	.6001	.503	.5144	.2374	.2401	.2401
3	.6001	.7716	.5144	.5144	.2374	.2572	.2401
4	.6001	.7716	.5935	.6001	.2543	.2572	.2401
5	.6859	.8573	.6859	.6516	.2883	.2401	.2572
6	.8059	.8573	.8573	.8745			.2915
7	.9774	1.0631	1.0898	.8745			.2572
8	.1715	.2229	.2229	.2743	.2683	.2229	.2229
9	.1543	.1543	.1715	.2229	.2035	.1715	.2229
10			.1696	.1543	.9431	.7716	.8573
11			.12	.12	1.0288	.8059	.8383
12		.0857	.12	.1029	.8745	.6859	.3715
13	.1372	.1006	.12	.1187	.7373	.6516	.4458
14	.1372	.1006	.12	.1372	.6859	.6516	.5868
15	.12	.1006	.12	.1372	.6859	.6173	.5365
16			.1715	.1372	.6859	.6859	.5365
17			.2401	.1372	.6344	.7202	
18	.2058	.2229	.2743		.2229	.2401	
19	.3086	.2683	.2743	.218	.2572	.2743	.2683
20	.2915	.2915	.2743	.2683	.2572	.3086	.2683
21	.2915	.2743	.5487	.2683	.2572	.3086	.2572
22	.4458	.6001	.5487	.2543	.2572	.2743	.5144
23	.5144	.5533	.583	.2374	.2401	.2401	.503
24	.583	.5316	.5487	.5144	.2374	.2401	.2401
Max	.9774	1.0631	1.0898	.8745	1.0288	.8059	.8573
Min	.12	.0857	.12	.1029	.2035	.1715	.2229
Avg	.4278	.4488	.3911	.3412	.4423	.4139	.3835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103] BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 201 / 11KV DHARMPURI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	2.0062	1.8519	2.0062	.5658	.7202	.6001
2	1.8176	2.1262	1.8519	2.0576	.5658	.7202	.6001
3	1.8176	2.2462	1.869	2.1091	.5658	.7373	.6001
4	1.8519	2.3663	1.869	2.1605	.6001	.7545	.6859
5	2.0919	2.5034	2.0919	2.2291	.6516	.7716	.7202
6	2.5377	2.6406	2.3663	2.2977	.6859	.7888	.7202
7	2.8464	2.7778	2.8464	2.3663	.7202	.7888	1.6975
8	.4287	.6173	.6173	.5487	.6173	.6516	1.8176
9	.5487	.4801	.5658	.5487	.5316	.5487	2.0062
10	.4287	.3944		.5228	2.9492	2.8978	2.4177
11	.3772	.3601	.3772	.4668	3.155	2.9492	2.5549
12	.3772	.3772	.3944	.4481	2.7606	2.8121	2.3148
13	.3601	.3601	.3601	.4115	2.6578	2.5377	2.0919
14	.3601	.3258	.3772	.3944	2.6063	2.2634	1.8861
15	.3944	.3429	.3601	.3772	2.572	2.2291	1.7318
16	.3772	.3429	.3429	.4108	2.8121	2.4348	.2915
17	.3944	.4115	.3601	.3944	2.4348	1.9204	.3601
18	.4458	.4801	.5144	.583	.4115	.5658	.3944
19	.5144	.6859	.5487	.6173	.4973	.6173	.6687
20	.583	.7545	.6001	.6859	.6001	.6859	.7373
21	.6516	.6687	.6516	.6859	.6859	.703	.6344
22	1.7147	1.9719	2.0233	.6001	.6859	.6859	1.9204
23	1.8004	1.8861	1.989	.6001	.6859	.6173	1.8519
24	1.7147	1.8861		1.9547	.5658	.703	.6173
Max	2.8464	2.7778	2.8464	2.3663	3.155	2.9492	2.5549
Min	.3601	.3258	.3429	.3772	.4115	.5487	.2915
Avg	1.0895	1.2088	1.1286	1.0615	1.3160	1.2960	1.2467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 202 / 11KV NATEPUTE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0288	.8573	1.046	.8573	1.3717	1.0288
2	.9945	1.0974	.8573	1.1317	.8573	1.406	1.0288
3	1.0288	1.166	.7716	1.2346	.8573	1.4403	1.0631
4	1.2003	1.2346	.7888	1.3375	.9774	1.4746	1.166
5	1.3546	1.3032	1.0117	1.4403	1.0974	1.5089	1.2346
6	1.4746	1.3717	1.2174	1.5432	1.3546	1.5432	1.4403
7	1.406	1.4403	1.406	1.6461	1.406	1.5775	1.5089
8	1.2517	1.2003	1.2003	1.406	1.2689	1.3032	1.3375
9		1.0288	1.0802	1.307	1.1488	1.1317	1.1317
10	1.166	1.0631		1.2696	1.166	1.1317	1.1831
11	1.1488	1.046	1.1145	1.2136	1.166	1.2517	1.0631
12	1.0974	1.0974	1.0974	1.0802	1.286	1.3032	1.0631
13	1.0974	1.046	1.1145	1.1949	1.2346	1.2003	1.1488
14	.9945	1.0802	1.0631	1.1317	1.2003	1.1145	1.2003
15	1.1145	1.0802	1.1317	1.1145	1.166	1.166	1.166
16	1.1488	1.1145	1.0974	1.166	1.2346	1.2346	1.0802
17	1.1145	1.1317	1.0288	1.1317		1.2346	
18	1.1317	.9774	1.0974	1.2003	1.2346	1.2003	1.0631
19	1.1488	1.3032	1.1145	1.3032	1.2517	1.3717	1.0974
20	1.1831		1.1488	1.3717	1.2689	1.406	1.406
21	1.2003	1.1488	1.166	1.2003	1.2689	1.3203	1.286
22	1.1317	1.1488	1.1317	1.1145	1.2689	1.2003	1.286
23	1.046	1.1145	1.046	.9431	1.3032	1.1831	1.2003
24	.9945	.9602	.9431	.9602	.8573	1.3375	1.0974
Max	1.4746	1.4403	1.406	1.6461	1.406	1.5775	1.5089
Min	.9945	.9602	.7716	.9431	.8573	1.1145	1.0288
Avg	1.1488	1.1384	1.0646	1.2287	1.1623	1.3089	1.1861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 203 / 11KV MANDAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0631	.9431	1.0974	.3429	.3944	.4287
2	.9431	1.166	.9431	1.166	.3429	.4115	.4287
3	1.0288		.9431	1.2346	.3429	.4115	.4287
4	1.1145		.9431	1.3032	.3944	.4287	.4458
5	1.3375	1.5089	1.0974	1.3717	.4287	.4287	.4801
6	1.4403	1.6289	1.2689	1.4575	.463	.4458	.5144
7	1.5604	1.749	1.8861	1.5432	.4801	.4458	.463
8	.4287	.4115	.3086	.4801	.4115	.4115	.4458
9	.3258	.3429	.3086	.3772	.3772	.3772	.3258
10	.2572	.2743	.2743	.4108	1.7318	1.406	1.4403
11	.2058	.2572	.1886	.3258	1.6975	1.4918	1.3203
12	.2058	.2058	.2229	.2915	1.5604	1.2517	1.166
13	.1543	.2229	.2229	.2572	1.406	1.2689	1.0631
14	.1715	.2229	.2401	.2058	1.2346	1.2346	1.0288
15	.1715	.1886	.2229	.2229	1.1831	1.2003	1.0117
16	.2058		.2058	.2427	1.2346	1.1317	1.0974
17	.2401	.2229	.2572	.2229	1.2003	1.0288	1.0802
18	.2058	.2229	.3086	.2915	.2401	.3601	.2572
19	.2743	.3429	.3429	.3258	.2915	.3944	.3944
20	.3601	.4287	.3772	.3429	.3429	.4287	.3944
21	.4458	.3772	.4115	.3772	.3944	.4458	.4115
22	1.0288	1.1145	1.1317	.3944	.3772	.4287	.8573
23	.9945	1.0288	1.0802	.3772	.3772	.4458	.9088
24	.9431	.9602	1.0288	1.0288	.3429	.3944	.4458
Max	1.5604	1.749	1.8861	1.5432	1.7318	1.4918	1.4403
Min	.1543	.1886	.1886	.2058	.2401	.3601	.2572
Avg	.6244	.6638	.6316	.6395	.7166	.6945	.7016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 204 / 11KV LONAND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.583		1.5432	1.9719	1.7147
2		.583		1.5432	2.0405	1.7147
3		.583		1.5432	2.1262	1.8176
4		.6001		1.7661	2.2119	1.9376
5		.6859		1.9204	2.2977	2.0576
6		.6859		2.1948	2.3663	2.2634
7		.7716		2.2462	2.4691	2.2119
8		.5144		.7202	.6516	.583
9		.4287	.4973	.6173	.4115	.583
10			2.3712	2.1434	1.6804	
11			2.1605	2.0576	2.0576	1.2517
12			2.2592	1.989	1.5089	1.7147
13			2.0062	1.8519	1.4232	1.3717
14			1.9204	1.6975	1.2346	1.2346
15			1.9547	1.286	1.0288	1.0288
16			1.9719	1.3546	1.0631	1.2346
17	1.5089		2.0233	1.166	1.3546	1.3375
18	.5144		.5658	.4115	.5144	.3772
19	.5144		.5658	.4801	.5144	.6001
20	.5144		.6173	.5316	.6859	.703
21	.5144		.6516	.6001	.6516	.6516
22	.583		1.4575	1.7318	1.5432	1.6289
23	.5144		1.6632	1.8347	1.6804	1.5432
24		.5487		1.5432	1.9033	1.6804
Max	1.5089	.7716	2.3712	2.2462	2.4691	2.2634
Min	.5144	.4287	.4973	.4115	.4115	.3772
Avg	.6663	.5984	1.5124	1.4489	1.4746	1.3583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274039 / 33/11 KV NATEPUTE SUB-STATION

Feeder No / Name : 205 / 11KV PHADATARI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2915	.2743	.3258	.2572	.3429	.3258
2	.2743	.3086	.2743	.3258	.2572	.3601	.3258
3	.2915	.3258	.3086	.3429	.2572	.3772	.3258
4	.2915	.3429	.3601	.3429	.3086	.3772	.3258
5	.3086	.3429	.4287	.3601	.3772	.3944	.3429
6	.3429	.3601	.4973	.3772	.4458	.4115	
7	.4115	.3772	.3944	.3772	.3772	.4115	.3601
8	.3086	.2401	.3429	.3429	.2743	.3086	.3086
9	.2401	.2058	.2401	.2058	.2058	.2743	.2229
10	.1543	.1715	.1886	.2058	.1715	.1886	.2058
11	.1372	.12	.1372	.1715	.1372	.1715	.1715
12	.12	.1029	.1715	.1715	.1543	.1372	.12
13	.12	.12	.1029	.1494	.1372	.1372	.1372
14	.1372		.1372	.1494	.12	.1372	.1372
15	.1715		.12	.12	.1372	.1372	.1372
16	.1543		.1372	.1494	.1543	.1372	.1715
17	.1543	.1372	.1372	.1372	.1372	.1543	.1543
18	.2058	.1715	.2058	.2058	.1715	.1886	.1886
19	.2401	.3086	.2401	.2743	.2229	.2572	.3429
20	.2915	.2401	.2915	.3258	.2915	.3429	.3772
21	.3429	.3429	.3429	.3086	.3429	.3601	.3429
22	.3258	.3258	.3086	.2743	.3429	.3429	.3086
23	.2915	.3086	.2915	.2743	.3258	.3258	.3086
24	.2743	.2743	.2743	.3086	.2572	.3258	.3258
Max	.4115	.3772	.4973	.3772	.4458	.4115	.3772
Min	.12	.1029	.1029	.12	.12	.1372	.12
Avg	.2443	.2580	.2586	.2594	.2443	.2751	.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDHIRAS S/STN

Feeder No / Name : 201 / 11KV WATER SUPPLY

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7814	1.7804	1.8442	1.8623	.6036	.5344	.57
2	1.7814	2.1845	1.9951	1.9433	.6335	.57	.5365
3	1.8623	2.1874	2.1628	1.9757	.6443	.5533	.4915
4	1.9433	2.6147	2.2672	2.0243	.7095	.5365	.5365
5	2.0729	2.95	2.6825	2.1052	.6613	.6036	.583
6	2.1862	2.9864	2.934	2.5911	.7842	.6706	.6154
7	2.7044	3.4541	3.1017		.6878		.5506
8	2.4291	2.9165	2.6825	2.8826	.6161		
9			.3353	.4049	3.2556	2.6825	2.5911
10	.3563	.3688	.3401	.3887	3.0521	2.8664	2.7044
11	.3772	.3018	.2267	.3052	3.0178	2.3158	2.6993
12	.3601	.3185	.2915	.3361	2.753	2.5911	2.95
13	.3429	.3185		.3547	2.5587	2.5101	2.6425
14	.3547	.3185	.2915	.3258	2.713	2.3158	2.2891
15	.3361	.3353	.2915	.3052	2.6993	2.3967	2.3739
16	.3734	.3353	.2915	.2543	2.6993	2.4291	2.4756
17	.3391	.3688	.3887	.3222	.2915	.2915	.3361
18	.4115	.3856	.421	.373	.3185	.3239	.407
19	.5144	.3887	.5506	.4748	.3521	.4858	.5415
20	.583	.4694	.5506	.5415	.4268	.5182	.5935
21	.6001	.5365	.5506	.5087	.5197	.5182	.6443
22	.6335	.5365	.5506	.5765	.583	.5344	.6443
23	.5935	.6036	.583	.5935	.6371	.583	.6104
24	1.8138	.6173	.6203	.583	.6535	.6036	.5668
Max	2.7044	3.4541	3.1017	2.8826	3.2556	2.8664	2.95
Min	.3361	.3018	.2267	.2543	.2915	.2915	.3361
Avg	1.0761	1.1860	1.1284	.9579	1.3280	1.2470	1.2588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 203 / 11KV PALASMANDAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4917	.503	.4858	.7468	.6706	.4858
2	.4534	.5601	.4862	.4858	.7468	.8383	.5182
3	.421	.5601	.4527	.4534	.8402	.9717	.5668
4	.4534	.5426	.4049	.4858	.8059	1.1736	.6154
5	.4858	.5792	.4359	.5182	.8954	1.3413	.6478
6	.4858	.4748	.4694	.5182	.9745	1.4413	.9555
7	.4534		.503		1.086	1.0059	1.1822
8				.4534	1.1203	.6706	1.004
9	2.3158	2.431	2.5149	2.5263	.4024		
10	2.5587	2.5101	2.8502	2.4291	.373	.4359	.2915
11	2.894	2.6825	2.6397	2.5149	.3185	.3239	.3222
12	2.8006	2.5987	2.5101	2.4006	.2683	.2915	.3222
13		2.4981	2.4291	2.3405	.2267	.1619	.3052
14		2.2672	2.1862	2.2291	.2347	.2429	.3052
15		2.431	2.1052	2.2891	.2347	.2429	.3052
16	2.6139	2.4291	2.0729	2.3739	.2267	.2429	.3222
17	1.4563	1.3077	.9717	1.0513	2.6825	2.915	2.5434
18	1.1022	1.3413	1.166	1.0004	2.5987	2.915	2.7073
19	1.0174	1.2955	1.085	.9835	2.5149	2.7044	2.3739
20	1.1203	1.2955	.9717	.9835	2.3472	2.3482	2.2891
21	.9221	1.2146	.9717	.9221	2.1795	2.2672	2.2891
22	1.0269	1.1336	.9393	.7716	2.1795	2.2186	2.0348
23	.9431	1.0059	.8907	.7468	2.1795	2.2186	2.0348
24	.4858	.8573	1.0059	.7287	.7468	1.9433	2.1052
Max	2.894	2.6825	2.8502	2.5263	2.6825	2.915	2.7073
Min	.421	.4748	.4049	.4534	.2267	.1619	.2915
Avg	1.2248	1.4776	1.3289	1.2910	1.1221	1.2863	1.1533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 204 / 11KV FONDSHIRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.6952	.8215	.8745	.8648	.8259	.7773
2	.8097	.8775	.8048	.8745	.8139	.8886	.8097
3	.8583	.9835	.8215	.9069	.9313	.9389	.8421
4	.8907	1.1763	.9221	.9393	1.0608	.9717	.9393
5	.9717	1.1763	.9724		1.1949	1.0395	1.0364
6	1.085	1.1191	.9717	1.0526	1.17	1.0562	1.0364
7	1.0202	1.0562	1.0059			1.0202	.9231
8	.8421	.9835	.8551	1.004	1.0082	.8886	.8745
9	.6802	.7545	.6203	.8907	.5765	.7209	.6802
10	.5668	.5868	.6539	.7611	.5087	.6371	.583
11	.5316	.4694	.6154	.6443	.4191	.5668	.5601
12	.5601	.4694	.5182	.5765	.3353	.5344	.4748
13	.4917	.4694	.4858	.5975	.3018	.5182	.4239
14	.4748	.421	.5182	.5415	.3239	.4372	.4801
15	.4409	.4534	.5182	.543	.3239	.4372	.4748
16	.4668	.503	.5182	.5935	.5182	.4534	.4854
17	.407	.57	.583	.5765	.5898	.5344	.39
18	.6104	.5868	.6316	.6687	.6706	.6316	.4917
19	.9945	.6706	.9878	1.0082	.8048	.8745	.6443
20	1.1016	.7712	1.085	.9326	.8551	.9878	.9835
21	1.0269	.8383	1.004	.9149	.9221	.8907	.8987
22	.8288	.9221	.9069	.8962	.8583	.8421	.8139
23	.8309	.9054	.9069	.7461	.8259	.7773	.7122
24	.7773	.8309	.8383	.8745	.7122	.8097	.7611
Max	1.1016	1.1763	1.085	1.0526	1.1949	1.0562	1.0364
Min	.407	.421	.4858	.5415	.3018	.4372	.39
Avg	.7519	.7621	.7736	.7917	.7213	.7618	.7124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 205 / 11KV TAMSHIDWADI

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.4694	.4578	.4062	.5041	.4694	.4049
2	.421	.4917	.421	.4372	.5788	.4694	.421
3	.4372	.4917	.407	.4534	.5975	.4372	.4372
4	.4372	.5487	.373	.4696	.5975	.4359	.4534
5	.4534	.5487	.4024	.4372	.6348	.421	.4696
6	.4696	.5788	.4049	.4858	.5975	.4359	.4858
7	.421		.4191		.4748		.4372
8		.5788		.3401	.4108		.4372
9	2.8016	3.0283	2.8178	2.7368	.2713		
10	3.0607	2.9473	2.934		.218	.2683	.2591
11	3.0864	2.8837	2.7206	2.6791	.218	.1781	.2204
12	2.9165	2.6825	2.5587	2.3908	.218	.1781	.2204
13	2.8334	2.3472	2.3967	2.34	.2012		.2204
14	3.006	2.1963	2.0891	2.0687	.218	.1619	.2035
15	2.5652	2.2298	2.1862	2.3348	.2012	.1619	.2204
16	2.8753	2.1862	2.3482	2.34	.2012	.1781	.2427
17	.2035	.2683	.2429	.218	3.0346	2.834	2.713
18	.3086	.285	.2429	.3052	2.753	2.9473	2.6113
19	.4115	.3185	.3887	.3222	2.4981	2.6235	2.4247
20	.4458	.3239	.3887	.373	2.2634	2.17	2.2043
21	.4801	.3887	.3887	.407	2.1125	2.1052	2.0517
22	.4801	.4534	.3725	.4239	2.0622	2.1214	2.0008
23	.4409	.4862	.3887	.4578	1.9616	2.0891	1.8991
24	.4049	.4287	.4527	.4049	.5041	1.9281	2.0243
Max	3.0864	3.0283	2.934	2.7368	3.0346	2.9473	2.713
Min	.2035	.2683	.2429	.218	.2012	.1619	.2035
Avg	1.2774	1.1809	1.1218	1.0378	.9722	1.1307	1.0027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 206 / 11KV KADAMWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.2035	.218	.1943	.4409	.5668	.5668
2	.1781	.1696	.2105	.1943	.5249	.6478	.5992
3	.1619	.1865	.1802	.2105	.5596	.7712	.6478
4	.1943	.2204	.1677	.2267	.5868	.8383	.7287
5	.2105	.2204	.1509	.2429	.7421	.9717	.8097
6	.2429	.2204	.1677	.2429	.8505	1.2574	1.0364
7	.2105		.1844		.8309	1.3916	1.3117
8				.1943	.8139	1.1568	1.1012
9			.1341	.1134	.1307		
10	.0972	.1341	.1006	.1134	.1187	.1174	.1296
11	.1006	.1134	.0972	.0848	.1006	.0972	.0848
12	.1029	.1134	.081	.0678	.081	.0972	.0848
13	.1006	.0972	.081	.0848	.0671	.081	.0678
14	.0838	.0972	.081	.0848	.0671	.081	.0678
15	.0848	.1006	.0972	.0848	.0648	.081	.0671
16	.0848	.0972	.1134	.0848	.0671	.0972	.0678
17	1.3395	1.1736	1.2308	1.2209	.0838	.0972	.0678
18	1.0802	1.1904	1.2955	1.153	.1174	.0972	.1526
19	.9835	1.1336	1.0526	1.0343	.1457	.1619	.1844
20	.9156	.9878	.8583	.9156	.1677	.1943	.2054
21	.8383	.9069	.8097	.7373	.1677	.1619	.2035
22	.763	.8097	.7125	.6613	.1619	.1457	.2035
23	.7545	.6802	.6802	.5765	.1844	.1781	.1696
24	.1943	.6783	.6706	.6316	.5601	.1619	.1781
Max	1.3395	1.1904	1.2955	1.2209	.8505	1.3916	1.3117
Min	.0838	.0972	.081	.0678	.0648	.081	.0671
Avg	.4053	.4540	.4076	.3980	.3181	.4109	.3798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 207 / 11KV CHAVANWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1012	1.17	1.1174	1.2146	.57	.502	.583
2	1.1012	1.2548	1.2574	1.247	.5935	.4858	.583
3	1.085	1.4918	1.2955	1.2955	.6443	.4694	.5668
4		1.7661	1.5384	1.4575	.6588	.4372	.5506
5	1.1336	1.8652	1.7814	1.668	.5868	.4359	.5344
6	1.2955	2.0233	2.0243	2.2024	.6161	.4359	.502
7	1.8461	2.4247	2.3137		.4694		.4372
8	1.5546	2.0687	1.9784	2.0567	.4239		
9		2.0454	.2515	.3077	2.3472	2.1795	1.9271
10	.2591	.2347	.2683	.3239	2.3472	2.0957	1.9271
11	.2713	.3018	.2429	.2883	2.0454	1.9109	1.8143
12	.2883	.3018	.2591	.3052	1.9433	1.7166	2.0748
13	.3018	.2753	.2753	.3361	1.8461	1.6032	1.6787
14	.3018	.2753	.2753	.3052	1.8442	1.5546	1.4413
15	.3018	.2683	.2915	.3052	1.8442	1.6032	1.5089
16	.3361	.2683	.2915	.3439	1.6194	1.6518	1.6956
17	.2883	.3185	.3239	.3561	.285	.2753	.2713
18	.4108	.3605	.3239	.373	.3185	.3563	.3391
19	.5228	.4024	.4696	.4748	.3353	.4372	.4668
20	.4917	.421	.4534	.4917	.4024	.4372	.4694
21	.5487	.4858	.4696	.4917	.4862	.4696	.4917
22	.5426	.5182	.4858	.5792	.5344	.5182	.5426
23	.5596	.57	.5506	.5973	.6154	.583	.5935
24	1.1174	.5487	.5426	.5506	.6161	.583	.5668
Max	1.8461	2.4247	2.3137	2.2024	2.3472	2.1795	2.0748
Min	.2591	.2347	.2429	.2883	.285	.2753	.2713
Avg	.7118	.9025	.7951	.7640	.9997	.9428	.9377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 208 / 11 KV ISHWAR PIND AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.5415	.4858	.4858	.2614	.2347	.2515
2	.4049	.6443	.5426	.5182	.2801	.2347	.2429
3	.4372	.7655	.6036	.5668	.3361	.2515	.2591
4	.4858	.8048	.6783	.6478	.3361	.2591	.2591
5	.5668	.9156	.9221	.7611	.3547	.2883	.2915
6	.6964	.9496	1.0526	1.1012	.3439	.2753	.2915
7	.8421	1.419	1.2742		.3361		.2591
8	.6964	.9156	.9717	.9393	.2686		
9			.1341	.2105	.9835	1.073	.9069
10		.1341	.1174	.1457	1.17	1.1401	.9069
11	.1543	.1296	.1296		1.1401	1.0202	.8309
12	.1372		.1296	.1526	1.1065	.9393	.7122
13	.1341		.1134	.1543	1.0364	.8097	.6706
14	.1174	.0972	.1296	.1372	1.004	.7449	.6274
15	.1187	.1174	.1296	.1357	1.0059	.6478	.7095
16	.1357	.1341	.1457	.1526	.8551	.6154	.7291
17	.168	.1509	.1619	.1357	.1677	.1457	.1865
18	.1865	.1677	.2105	.1867	.1844	.1619	.2515
19	.2572	.1677	.2591	.2204	.2347	.1943	.2713
20	.2572	.1781	.2591	.2543	.2683	.2429	.2987
21	.2883	.2267	.2591	.2204	.2683	.2267	.2347
22	.2915	.2347	.2591	.3174	.2591	.2267	.2374
23	.2915	.2347	.2429	.3174	.2683	.2429	.2614
24	.421	.2401	.2012	.2429	.2543	.2515	.2429
Max	.8421	1.419	1.2742	1.1012	1.17	1.1401	.9069
Min	.1174	.0972	.1134	.1357	.1677	.1457	.1865
Avg	.3406	.4366	.3922	.3638	.5302	.4648	.4319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274108 / 33/11KV FONDSHIRAS S/STN

Feeder No / Name : 209 / 11 KV MARKADWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.1696	.1844	.2105	.1696	.1677	.1781
2	.1943	.1696	.1619	.2105	.1865	.1526	.1781
3	.1943	.2204	.1509	.1943	.2241	.1296	.1943
4	.1943	.2204	.1296	.2105	.2204	.1174	.2105
5	.1781	.2012	.1509	.2267	.2241	.1296	.2105
6	.1781	.1357	.1457	.2105	.1526	.1619	.1781
7	.1457		.1457		.168		.1296
8				.1457	.1187		
9	.8097	.8048	.7773	.7773	.0934		
10	.8421	.8383	.7935	.8907	.1017	.1174	.1296
11	.8745	.8048	.8097	.8402	.0983	.0648	.0848
12	.9259	.7773	.8097	.8139	.0838	.081	.0848
13	.8478	.7377	.7935	.7122	.0648	.1134	.0848
14	.8139	.6964	.7449	.7282	.0648	.081	.0848
15	.8402	.7042	.7125	.6535	.081	.0648	.0848
16	.6613	.6706	.6802	.5765	.0648	.0486	.0848
17	.0678	.0671	.0972	.0678	1.0202	.8421	.8648
18	.1017	.0838	.081	.1526	1.0059	.9393	.8309
19	.1187	.0972	.1134	.1865	.8383	.7773	.7291
20	.1677	.1174	.1296	.2035	.6706	.6154	.6104
21	.2229	.1509	.1457	.2241	.6036	.5182	.6535
22	.2401	.1844	.1619	.2204	.57	.4858	.5426
23	.2058	.218	.1943	.2204	.503	.4696	.5426
24	.2105	.1357	.2035	.1943	.2035	.9393	.4534
Max	.9259	.8383	.8097	.8907	1.0202	.9393	.8648
Min	.0678	.0671	.081	.0678	.0648	.0486	.0848
Avg	.4020	.3730	.3616	.3857	.3138	.3341	.3248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 201 / 11KV KOTHALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.2591	.2896	.3601	1.6004	1.9547	2.0919
2	.3601	.3048	.2896	.3772	1.6004	1.9204	2.1091
3	.3944	.3201	.3048	.4115	1.6156	1.8861	2.1262
4	.4287	.3353	.3201	.4287	1.6309	1.9204	2.1434
5	.4801	.3506	.3658	.4458	1.6461	1.9547	2.1776
6	.5316	.3658	.4268	.4973	1.6461		2.1948
7					1.9357	2.2119	2.4006
8					.2591	.2572	.3258
9					.2743	.2134	
10	2.332	2.3777	2.7263	2.4863	.2591	.1677	
11	2.4348	2.3015	2.7435	2.7435		.1981	
12	2.6063	2.3472	2.7606	2.7092		.2286	
13	2.6749	2.2405	2.7435	2.6749			
14	2.572	1.9662	2.7092	2.6406		.2591	
15	2.4177	2.1491	2.692	2.4348		.2591	
16	2.5892	2.1643	2.5892	2.3834		.2591	
17	2.3491	2.0729	2.5377	2.2977	.2743	.3258	.2591
18	.2401	.2286	.3086	.3086	.2743	.3429	.2591
19	.3772	.3048	.3944	.3258	.3944	.3601	.3048
20	.3601	.3201	.3944	.3944	.3601	.3772	.3201
21	.3258	.3201	.3772	.3601	.3601	.3772	.3201
22	.3086	.3048	.3772	1.7661	1.989	2.0233	
23	.3086	.2743	.3601	1.7661	2.0233	2.0405	
24	.3601	.2743	.2896	.3601	1.5851	2.0405	2.0576
Max	2.6749	2.3777	2.7606	2.7435	2.0233	2.2119	2.4006
Min	.2401	.2286	.2896	.3086	.2591	.1677	.2591
Avg	1.1815	1.0277	1.2381	1.3415	1.0960	.9808	1.3636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 202 / 11KV GURSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.1584	1.1431	1.3889	.2134	.2572	.2915
2	1.1488	1.1736	1.1126	1.406	.2286	.2572	.3086
3	1.166	1.1736	1.1126	1.4403	.2439	.2915	.3258
4	1.2174	1.1888	1.1279	1.4746	.3201	.3086	.3772
5	1.286	1.1888	1.1584	1.5089	.3506	.3258	.4287
6	1.406	1.1888	1.3565	1.5604	.381	.3258	.463
7	1.6461	1.2193	1.5089	1.6461			.2743
8	.2743	.1981	.2439	.2743			.2401
9	.2572	.1829	.2229	.2401			
10	.2572	.2134	.1886	.2401	1.3108	1.2803	
11	.2401	.1981	.1715	.2401		1.5089	
12	.2401	.1981	.1715	.2401		1.4937	
13	.2229	.1981	.1715	.2229		1.2346	
14	.2229	.2134	.1886	.2058		1.3413	
15	.2058	.1829	.1886	.2058		1.3108	
16	.2229	.1829	.1886	.2229		1.2955	
17	.2401	.1981	.2058	.2401	1.2346	1.2689	1.2803
18	.2572	.1981	.2743	.2572	.2401	.2572	.2134
19	.3429	.2896	.3429	.2743	.3086	.3429	.2743
20	.3429	.2896	.3086	.3429	.3086	.3772	.3201
21	.3429	.2896	.2915	.3258	.3086	.3429	.2743
22	1.286	1.2651	1.3717	.2743	.3086	.3429	
23	1.3032	1.2498	1.3717	.2572	.2743	.3258	
24	1.166	1.1584	1.1888	1.3717	.1829	.2743	.3086
Max	1.6461	1.2651	1.5089	1.6461	1.3108	1.5089	1.2803
Min	.2058	.1829	.1715	.2058	.1829	.2572	.2134
Avg	.6859	.6249	.6505	.6609	.4143	.7030	.3843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 203 / 11KV SHINDEWADI FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0206	.0183	.0061	.0069	.0061	.0069	.0069
2	.0206	.0183	.0061	.0069	.0061	.0017	.0069
3	.0206	.0183	.0061	.0069	.0061	.0069	.0069
4	.0206	.0183	.0061	.0069	.0061	.0069	.0069
5	.0206	.0183	.0061	.0069	.0061	.0069	.0069
6	.0206	.0183	.0061	.0069	.0061	.0069	.0069
7	.0206	.0183	.0061	.0069	.0061	.0069	.0206
8	.0206	.0183	.0061	.0069	.0061	.0069	.0206
9	.0206	.0122	.0069	.0069	.0183	.0069	
10	.0206	.0122	.0069	.0069	.0122	.0061	
11	.0206	.0122	.0069	.0069		.0061	
12	.0206	.0122	.0069	.0206		.0061	
13	.0206		.0069	.0206		.0183	
14	.0206	.0122	.0069	.0206		.0122	
15	.0206	.0122	.0069	.0206		.0183	
16	.0206	.0122	.0069	.0206		.0122	
17	.0206	.0122	.0069	.0206	.0069	.0206	.0061
18	.0206	.0122	.0206	.0206	.0069	.0206	.0061
19	.0206	.0122	.0206	.0206	.0069	.0171	.0061
20	.0206	.0122	.0206	.0206			.0061
21	.0206		.0206	.0206	.0069	.0206	.0061
22		.0061	.0206	.0206	.0069	.0206	
23	.0206	.0061	.0206	.0069	.0069	.0069	
24	.0206	.0183	.0061	.0069	.0061	.0069	.0069
Max	.0206	.0183	.0206	.0206	.0183	.0206	.0206
Min	.0206	.0061	.0061	.0069	.0061	.0017	.0061
Avg	.0206	.0141	.0100	.0132	.0075	.0108	.0086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 204 / 11KV DHARMPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5182	.4877	.5487	.4268	.6687	.6516
2	.6001	.5792	.503	.5316	.4877	.6859	.6859
3	.6516	.6097	.5487	.6001	.5335	.6859	.7202
4	.7545	.6401	.6249	.6859	.5792	.7545	.7888
5	.8573	.6859	.7164	.7202	.6554	.823	.823
6	.9259	.8078	.8078	.8745	.7621	.8916	.9088
7	.6516	.6706	.6249	.6344	.6554	.7202	.7202
8	.583	.4572	.4877	.6344	.4572	.6001	.583
9	.3772	.4115	.1543	.4458	.3963	.381	
10	.3772	.3506	.1029	.3772	.3353	.3506	
11	.3601	.2896	.1372	.3429	.4877	.3201	
12	.3429	.2743	.1029	.3258		.3048	
13	.3258	.2743	.3258	.3086			
14	.3258	.2743	.3258	.3086		.3201	
15	.3258	.2896	.3086	.3258		.3506	
16	.3086	.3201	.3086	.3601		.3353	
17	.3601	.3353	.3258	.3429	.3772	.4115	.2896
18	.4458	.463	.4458	.4801	.4115	.4458	.381
19	.7716	.6554	.7373	.6001	.6687	.6173	.6097
20	.7545	.7164	.7202	.7716	.7545	.7716	.6401
21	.7373	.6401	.703	.6859	.6859	.7202	.6249
22	.6859	.5792	.6344	.6344	.5487	.6516	
23	.6173		.6001	.5487	.6516	.6344	
24	.583	.5335	.4877	.5658	.4572	.6687	.6173
Max	.9259	.8078	.8078	.8745	.7621	.8916	.9088
Min	.3086	.2743	.1029	.3086	.3353	.3048	.2896
Avg	.5544	.4946	.4676	.5273	.5438	.5702	.6460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 205 / 11 KV MASUGADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2286	.2286		.8993	1.3203	1.2689
2	.2743	.2743	.2439		.9145	1.3546	1.3032
3	.2915	.2896	.2591	.2915	.9297	1.3546	1.3375
4	.3258	.3048	.2743	.3086	1.0364	1.3717	1.3717
5	.3772	.3201	.2896	.3429	1.0974	1.406	1.406
6	.3772	.3353	.3353	.3601	1.1584	1.4232	1.4403
7					1.5699	1.6118	1.3889
8					.2134	.2229	.2401
9					.1677	.1981	
10	1.9719	1.768	1.6289	1.8861	.1524	.1677	
11	1.989	1.7071	1.5947	1.9204		.1067	
12	1.989	1.6918	1.5775	1.7147		.1219	
13		1.5546	1.5432	1.5775		.1524	
14	1.8861	1.4784	1.5261	1.4403		.1524	
15	1.749	1.448	1.5089	1.406		.1677	
16	1.5947	1.4175	1.4918	1.3889		.1677	
17	1.6975	1.3108	1.3717	1.3203	.2915	.2401	.1829
18	.1715	.1981	.2572	.2572	.3429	.2743	.1677
19	.2743	.1981	.3086	.2401	.3601	.3086	.2286
20	.2743	.3048	.3086	.3258	.3429	.3429	.2286
21	.2915	.2743	.3258	.3086	1.1488	1.1831	.2286
22	.2743	.2591	.2743	.9774			
23	.2743	.2286	.2572	.9945	1.2003	1.2003	
24	.2572	.2286	.2286		.884	1.2689	1.2346
Max	1.989	1.768	1.6289	1.9204	1.5699	1.6118	1.4403
Min	.1715	.1981	.2286	.2401	.1524	.1067	.1677
Avg	.8299	.7534	.7540	.9478	.7476	.7008	.8591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 206 / 11 KV KARUNDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0974	1.0822	1.3032	.2439	.3086	.3086
2	1.1488	1.1126	1.0669	1.3375	.2591	.2915	.3429
3	1.1488	1.1126	1.0517	1.3717	.2743	.2915	.3772
4	1.2174	1.1279	1.0822	1.406	.3506	.3086	.4458
5	1.3375	1.1279	1.1431	1.4746	.3963	.3772	.4801
6	1.3546	1.1279	1.1736	1.5089	.442	.4801	.5144
7	1.5604	1.4175	1.3565	1.4575			1.3717
8	.2915	.2286	.2915	.2572			1.5775
9	.2058	.1981	.1715	.2058			
10	.2058	.1981	.1715	.2058	1.6918	1.7528	
11		.1677	.1715	.1886		1.8595	
12	.2229	.1524	.1715	.1886		1.6918	
13	.2401	.1829	.1715	.2058		1.7223	
14	.2058	.1677	.1886	.2058		1.6461	
15	.1543	.1677	.1886	.2058		1.8519	
16	.1543	.1829	.1886	.1886		1.6918	
17	.2572	.1677	.2229	.1886	1.8004	1.6461	1.2803
18	.2229	.2591	.2572	.2572	.2915	.3086	.2134
19	.3772	.3201	.3601	.3086	.4287	.3601	.2896
20	.3429	.3353	.3258	.3772	.3944	.4458	.3201
21	.3258	.3201	.2915	.3429	.3772	.3772	.3201
22	1.2174	1.1736	1.3375	.3429	.4115	.3944	
23	1.3546	1.2498	1.3032	.3086		.3772	
24	1.2003	1.0974	1.1584	1.286	.2591	.3258	.3601
Max	1.5604	1.4175	1.3565	1.5089	1.8004	1.8595	1.5775
Min	.1543	.1524	.1715	.1886	.2439	.2915	.2134
Avg	.6918	.6122	.6220	.6301	.5443	.8814	.5858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

AKLUJ O AND M DIVISION[537]

NATEPUTE[103]

BU 6360

Substation No/ Name :- 274130 / 33/11 KV DHARMPURI

Feeder No / Name : 207 / 11 KV MOROCHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.0517	.9907	1.0288	.2134	.2572	.2915
2	.9774	1.0669	.9907	1.0631	.2286	.2743	.3086
3	.9774	1.0669	1.0059	1.1145	.2439	.2915	.3258
4	1.0631	1.0822	1.0669	1.166	.2743	.3086	.3258
5	1.1831	1.0974	1.1279	1.2346	.2896	.3086	.3429
6	1.3375	1.1126	1.2498	1.2689	.3048	.3086	.3429
7	1.406	1.1736	1.387	1.3032			.2401
8	.1715	.2286	.2134	.2229			.2229
9		.1829		.1543			
10		.1372		.12	1.1888	1.1736	
11	.1715	.1372		.1132		1.1126	
12	.1715	.1219		.12		1.1888	
13	1.4746	.1219	.1029	.12		1.1279	
14		.1219	.1029	.1372		1.0059	
15	.1029	.1219	.12	.1543		1.0974	
16	.1029		.12	.1715		1.0974	
17	.1543	.1219	.1543	.1543	1.4746	1.2174	1.0212
18	.1543	.1543	.2743	.2229	.2058	.2401	.1219
19	.3086	.2134	.3086	.2572	.3429	.2743	.2134
20		.2896	.2743		.2915	.3086	.2439
21		.2896	.2572	.2743	.2915	.2572	.2439
22	1.1488	1.0364	.9774	.2743	.2743	.2915	
23	1.166	1.0669	.9945	.2572	.2572	.2743	
24	.9945	1.0364	1.0059	1.0117	.2134	.2572	.2572
Max	1.4746	1.1736	1.387	1.3032	1.4746	1.2174	1.0212
Min	.1029	.1219	.1029	.1132	.2058	.2401	.1219
Avg	.7391	.5667	.6362	.5193	.4063	.6035	.3216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 204 / 11KV BORGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168	.503		
2	.0168	.0168	.0168	.503		
3	.0168	.0168	.0168	.4694		
4	.0168	.0168	.0168	.4694		
5	.0168	.0168	.0168	.4862		
6	.0168	.0168	.0335	.4862		
7				.6036		
8				.57		
9					.6706	.5868
24	.0168	.0168	.0168	.5197		
Max	.0168	.0168	.0335	.6036	.6706	.5868
Min	.0168	.0168	.0168	.4694	.6706	.5868
Avg	.0168	.0168	.0192	.5123	.6706	.5868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 205 / BABHULGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168	.0168	
2	.0168	.0168	.0168	.0168	
3	.0168	.0168	.0168	.0168	
4	1.1736	2.6825	2.3807	.0168	
5	1.8442	2.8334	2.5149	.0168	
6	2.2466	2.9005	2.6825	.0168	
7	2.431	2.7664	2.7496	.0168	
8	2.6825	2.6155	2.7161	.0168	
10					1.9281
11					2.7831
12					2.8502
13					2.8502
14					2.8837
15					2.8837
24	.0168	.0168	.0168	.0168	
Max	2.6825	2.9005	2.7496	.0168	2.8837
Min	.0168	.0168	.0168	.0168	1.9281
Avg	1.1606	1.5406	1.4568	.0168	2.6965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274001 / 33/11 KV BORGAON S/STN.

Feeder No / Name : 206 / 11 KV KALAMBWADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2347		
2	.2347		
3	.2515		
4	.2683		
5	.2683		
6	.3018		
7	.4694		
8	.503		
9		.503	.57
24	.2347		
Max	.503	.503	.57
Min	.2347	.503	.57
Avg	.3074	.503	.57

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 201 / CHIKHARDE FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-MAR-18
HR	Load (MW)
8	.583
9	.4287
Max	.583
Min	.4287
Avg	.5059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 202 / NARI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-MAR-18
HR	Load (MW)
8	.6173
9	.583
Max	.6173
Min	.583
Avg	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 203 / YELAMB FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-MAR-18
HR	Load (MW)
8	2.0576
9	1.8861
Max	2.0576
Min	1.8861
Avg	1.9719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 204 / forest Feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	26-MAR-18
HR	Load (MW)
8	.3086
9	.2743
Max	.3086
Min	.2743
Avg	.2915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 205 / Indapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-MAR-18
HR	Load (MW)
8	1.3546
9	1.5089
Max	1.5089
Min	1.3546
Avg	1.4318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274002 / 33/11 KV CHIKHARDE S/S

Feeder No / Name : 206 / Sawargaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	26-MAR-18
HR	Load (MW)
8	.2401
9	.1715
Max	.2401
Min	.1715
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 201 / 11 KV PANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762	.0838	.0762	.0838	.0838	.0762
2	.0943	.0762	.0838	.0476	.0838	.0838	.0762
3	.0943	.0762	.0838	.0762	.0838	.0838	.0762
4	.0943	.0762	.0838	.0762	.0838	.0838	.0762
5	.0943	.0762	.0838	.0762	.0838	.0838	.0762
6	.0943	.0762	.0838	.0762		.0838	.0762
7	.0943	.0762	.0838	.0762	.0076	.0838	.0762
8	.0943	.0838	.0762	.0762	.0838	.0838	.0762
9	2.0957		1.3717	1.7604	1.3413	1.3717	.0762
10	1.9814	1.5927	1.3717	1.7604	1.5927	1.5242	.0762
11	2.0576	1.5927	1.6766	1.5927	1.7604	1.5242	
12	2.0576	1.8442	1.6766	1.5089	1.7604	1.6004	
13	2.0576	1.8442	1.6766	1.4754	1.8442	1.6004	
14	1.9814		1.5242	1.3413	1.8442	1.6004	
15	1.9814	2.0119	1.5242	1.5089	1.5927	1.5242	
16	1.7528	2.0119	1.5242	1.5089	1.5089	1.6004	
17	.0762	.0838	.0762	.0943	.0838	.0762	
18	.0762	.0838	.0762	.0943	.0838	.0762	
19	.0857	.0838	.0762	.0943	.0838	.0762	1.6004
20	.0762	.0838	.0762	.0943	.0838	.0762	1.3717
21	.0762	.0838	.0762	.0943	.0838	.0762	1.3717
22	.0762	.0838	.0762	.0943	.0838	.0762	1.2955
23	.0762	.0838	.0762	.0943	.0838	.0762	1.2955
24	.0943	.0762	.0838	.0762	.0838	.0838	.0762
Max	2.0957	2.0119	1.6766	1.7604	1.8442	1.6004	1.6004
Min	.0762	.0762	.0762	.0476	.0076	.0762	.0762
Avg	.7232	.5535	.5677	.5739	.6272	.5681	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 202 / 11 KV SAKAT AG FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0762	.0838	.0762	.0838	.0838	.381
2	.0943	.0762	.0838	.0762	.0838	.0838	.0762
3	.0943	.0762	.0838	.0762	.0838	.0838	.3048
4	.0943	.0762	.0838	.0762	.0838	.0838	.3048
5	.0943	.0762	.0838	.0762	.0838	.0838	.381
6	.0943	.0762	.0838	.0762	.0838	.0838	.381
7	.0943	.0762	.0838	.0762	.0838	.0838	.4572
8	.0943	.0838	.0762	.0762	.0838	.0838	.5335
9	.0943	.0838	.0762	.0943	.0838	.0762	
10	.0762	.0838	.0762	.0943	.0838	.0762	
11					.0838		
17	.6097	.8383	.8383	.8383	1.0059	.9145	
18	.9145	.8383	.9145	.8383	1.0059	.9145	
19	.7621	.6706	.7621	.8048	.8383	.7621	.0762
20	.6097	.5868	.7621	.7545	.8383	.6859	.0762
21	.6097	.503	.6859	.7042	.7545	.6097	.0762
22	.5335	.4191	.6859	.6706	.7545	.6097	.0762
23	.5335	.3353	.6097	.6706	.6706	.6097	.0762
24	.5868	.0762	.3353	.6097	.5868	.6706	.4572
Max	.9145	.8383	.9145	.8383	1.0059	.9145	.5335
Min	.0762	.0762	.0762	.0762	.0838	.0762	.0762
Avg	.3380	.2807	.3561	.3716	.3882	.3666	.2613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 203 / 11 KV KALEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3916	1.2193	1.3413	.7621	1.3413	1.3413	.0762
2	1.6095	1.2955	1.4251	.9145	1.4251	1.4251	.0762
3	1.8442	1.2955	1.4251	.9145	1.6766	1.6766	.0762
4	2.0119	1.3717	1.5089	.9907	1.8442	1.7604	.0762
5	2.1795	1.6766	1.8442	1.0669	2.0119	1.7604	.0762
6	2.3807	1.829	1.9281	1.2955	2.2634	2.0957	.0762
7	2.431	2.3624	2.5987	1.6004	2.6825	2.2634	.0762
8	2.1795	2.3472	2.2862	.9526	1.5089	2.0119	.0762
9							1.7528
10							1.6766
15	.0762	.0838	.0762	.0943	.0838	.0762	
16	.0762	.0838			.0838	.0762	
17	.0762	.0838			.0838	.0762	
18	.0762	.0838		.0943	.0838	.0762	
19	.0762	.0838		.0943	.0838	.0762	.0762
20	.0762	.0838		.0943	.0838	.0762	.0762
21	.0762	.0838	.0762	.0943	.0838	.0762	.0762
22	.0762	.0838	.0762	.0943	.0838	.0762	.0762
23	.0762	.0838	.0762	.0943	.0838	.0762	.0762
24	.0943	.0762	.0838	.0762	.0838	.0838	.0762
Max	2.431	2.3624	2.5987	1.6004	2.6825	2.2634	1.7528
Min	.0762	.0762	.0762	.0762	.0838	.0762	.0762
Avg	.9338	.7904	1.1343	.5771	.8662	.8391	.2810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 204 / 11 KV OLD GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1715	.1886	.1715	.1886	.1677	.2058
2	.1886	.1715	.1886	.1715	.2263	.1677	.1715
3	.1886	.1715	.2263	.2572	.2263	.2263	.1715
4	.1886	.2572	.2829	.3429	.2829	.2829	.3429
5	.1886	.4287	.4715	.4287	.4715	.4715	.4287
6	.1886	.5144	.5658	.5144	.6602	.5658	.5487
7	.1886	.5144	.6036	.5144	.5658	.6036	.6001
8	.2829	.3772	.4287	.5144	.5658	.4715	.4287
9	.4715		.4287	.4715	.4715	.3429	.4287
10	.2572	.2515		.3772	.2829	.2572	.1715
11	.1715	.1677	.1715	.2263		.1715	.1715
12	.1715	.1677	.1715	.1509		.1715	
13	.1715	.1677	.1715	.1509	.1886	.1715	.1715
14	.1715		.1715	.1509	.1886	.1715	.1715
15	.1715	.1677	.1715	.1509	.1677	.1715	.1715
16	.1715	.1886	.1715	.1509	.1886	.1715	
17	.1715	.1886	.3086	.1509	.2263	.1715	
18	.2572	.1886	.2572	.3772	.3772	.2572	
19	.5144	.3772	.4287	.4715	.4715	.4287	.6001
20	.5144	.4191	.463	.5658	.5658	.5144	.6859
21	.4287	.4715	.4287	.3395	.4715	.4287	.5144
22	.2572	.3772	.4287	.3395	.3772	.3429	.4287
23	.2058	.1886	.2572	.2829	.2829	.2572	.3429
24	.3018	.1715	.1886	.1715	.2829	.1677	.2229
Max	.5144	.5144	.6036	.5658	.6602	.6036	.6859
Min	.1715	.1677	.1715	.1509	.1677	.1677	.1715
Avg	.2521	.2773	.3119	.3101	.3514	.2981	.3490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274004 / 33/11 KV PANGAON S/S

Feeder No / Name : 205 / 11 KV NEW PANGAON GAOTHAN SEPARATED GAOTHAN FEEDERS
FEED Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1886	.1715	.1886	.2263	.1715
2	.1698	.1715	.2263	.1715	.1886	.1886	.1715
3	.2263	.1715	.2829	.2058	.1886	.1886	.1715
4	.3206	.2572	.2829	.2572	.3395	.3772	.2572
5	.3395	.3429	.3772	.3429	.3395	.3772	.3772
8	.3018	.3772	.3772	.4115	.4338	.3772	.3429
9	.3395		.3086	.3206	.3395	.3429	.3429
10	.2401	.2829	.2058	.2829	.2641	.3429	.2572
11	.2058	.1886	.1715	.2263	.1886	.1715	.2229
12	.1715	.1886	.1372	.1886	.1886	.1715	
13	.1715	.1886	.1543	.1509	.1886	.1715	
14	.1715	.1886	.1372	.1509	.1886	.1715	
15	.1715	.1886	.1372	.1509	.1886	.1715	
16	.1715	.1886	.1372	.1509	.1886	.1715	
17	.1715	.1886	.1543	.1509	.2075	.1715	
18	.1715	.1886	.1886	.1509	.2263	.2058	
19	.3086	.2829	.2915	.2829	.3395	.3086	.4115
20	.4287	.3772	.3429	.3584	.3772	.3429	.4287
21	.3429	.3772	.2915	.2829	.3772	.3429	.3429
22	.2572	.2829	.2229	.2641	.3772	.2743	.2915
23	.1715	.1886	.1715	.2641	.2829	.2229	.2572
24	.2263	.1715	.1886	.1715	.2263	.2263	.2058
Max	.4287	.3772	.3772	.4115	.4338	.3772	.4287
Min	.1698	.1715	.1372	.1509	.1886	.1715	.1715
Avg	.2394	.2364	.2262	.2322	.2649	.2521	.2835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 201 / 11 KV Raleras SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		1.0669	1.1431
2		1.2193	1.2955
3		1.2193	1.3717
4		1.3717	1.3717
5		1.5242	1.448
6		1.6766	1.6004
7	1.9052	1.9814	1.9052
8		2.0576	1.9509
9	1.7071	1.9814	
10	.0457	.061	
11		.0305	
12		.0305	
13		.0305	
14		.0305	
15		.0305	
16		.0305	
17		.0457	
18		.1067	
19		.1067	
20		.0914	
21		.0914	
22		.0914	
23		.061	
24	1.2498	.9145	
Max	1.9052	2.0576	1.9509
Min	.0457	.0305	1.1431
Avg	1.2270	.6605	1.5108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 204 / 11 KV VAIRAG Urban Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.9145
2	.6097	.6859	.9145
3	.6097	.6859	.9145
4	.6859	.7621	.9145
5	.7621	.8383	.9907
6	.9145	.9145	1.0669
7	.8383	1.0669	.9907
8	.7621	.9145	.9145
9	.7621	.8383	
10	.7621	.8383	
11	.7011	.7621	
12	.6859	.7621	
13	.7621	.7621	
14	.7621	.7621	
15	.7621	.7621	
16	.7621	.7621	
17	.7621	.7621	
18	.9145	.9145	
19	1.0669	1.0669	
20	1.0669	1.0669	
21	.9907	.9907	
22	.9145	.9907	
23	.9145	.9907	
24	.7621	.9907	
Max	1.0669	1.0669	1.0669
Min	.6097	.6859	.9145
Avg	.7977	.8574	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274007 / 33/11 KV VAIRAG SUB STATION

Feeder No / Name : 205 / 11 KV IRLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0457	.0305
2		.0457	.0305
3		.0305	.0305
4		.0305	.0305
5		.0305	.0305
6		.0305	.0305
7		.0305	.0305
8		.0457	.0305
9		.0457	
10	1.1431	1.3717	
11	1.5242	1.6766	
12	1.5546	1.8138	
13	1.6766	1.6766	
14	1.6004	1.6156	
15	1.6766	1.6766	
16	1.6613	1.7071	
17	1.5242	1.7375	
18	.0457	.1219	
19	.0305	.1067	
20	.0457	.1067	
21	.0457	.0762	
22	.0457	.061	
23	.0457	.0457	
24	.0457	.0305	
Max	1.6766	1.8138	.0305
Min	.0305	.0305	.0305
Avg	.8444	.5900	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 202 / 11 KV SAROLE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5775	1.749	1.7833	
2	1.5432	1.5775	1.749	1.7833	1.8861
3	1.5432	1.5432	1.7661	1.8004	1.8861
4	1.5432	1.5432	1.7661	1.8004	1.8861
5	1.5432	1.6118	1.8004	1.8004	1.8861
6	1.5775	1.6461	1.8004	1.8004	1.8861
7	1.5775	1.6804	1.6289	1.8004	1.8861
24	1.6289	1.5775	1.749	1.7833	2.0576
Max	1.6289	1.6804	1.8004	1.8004	2.0576
Min	1.5432	1.5432	1.6289	1.7833	1.8861
Avg	1.5625	1.5947	1.7511	1.7940	1.9106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274085 / 33/11 KV JAVALGAON S/STN

Feeder No / Name : 204 / Rui SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4801	.4801	.5144	.4287
2	.3429	.4801	.4801	.5144	.4287
3	.3429	.4801	.4801	.5144	.4287
4	.3772	.5144	.5487	.5487	.463
5	.4115	.5144	.6173	.6173	.5144
6	.4801	.5144	.703	.6173	.6516
7	.4801	.5487	.7888	.6173	.6516
9	.3429	.2743			
10	.2058	.2058	.2058	.2572	.1372
11	.1543	.1715	.1372	.1715	.1372
12	.1372	.1372	.1372	.12	.1029
13	.1372	.1372	.12	.12	.1372
14	.1372	.1372	.12	.12	.1029
15	.1543	.1372	.12	.1029	.1029
16	.1715	.12	.1372	.1029	
17	.1715	.12	.1372	.1372	.1372
18	.2401	.1372	.1372	.1715	.2743
19	.2743	.3429	.3429	.4287	.3429
20	.2743	.4801	.4801	.4115	.3429
21	.2743	.4115	.4115	.3429	.3086
22	.2401	.2743	.2743	.3429	.2401
23	.2058	.2058	.2058	.3086	.1715
24	.3429	.4801	.4801	.4801	.4287
Max	.4801	.5487	.7888	.6173	.6516
Min	.1372	.12	.12	.1029	.1029
Avg	.2714	.3176	.3429	.3437	.3111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 201 / 11 KV MALWANDI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706				.08
2	.6706				.08
3	.7621	.6706		1.0898	.08
4	1.0669		.8383		.0914
5	1.2193				.1029
6	1.3717	1.2574			.1143
7	1.6766		1.3413		.1257
8	1.5242				.1257
9	1.5242	1.4083	1.8442	1.8442	.08
10	.0686		.0572		1.2955
11	.0686		.0572		
12	.0572	.1677	.0572		
13	.0572		.0686		
14	.0572		.0686	.1174	
15	.0572	.1006	.0686	.1006	
16	.0686		.0686		
17	.0686		.1029		
18	.08		.1029	.1341	
19	.1143		.1143		.1829
20	.1372		.1257	.1844	.16
21	.1372		.1143		.16
22	.1143		.1029	.1509	.1372
23	.1143		.1029	.1341	.1372
24	.503	.4191	.4191		.1174
Max	1.6766	1.4083	1.8442	1.8442	1.2955
Min	.0572	.1006	.0572	.1006	.08
Avg	.5079	.6706	.3142	.4694	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 202 / 11 KV GULPOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838			.0572		.4572
2	.0838			.0572		.4572
3	.0572	.0671			.0838	.6097
4	.0572		.0762			.6097
5	.0686					.7621
6	.08	.0838			.1341	.7621
7	.0914		.1341			.9145
8	.0914					1.0669
9	.0686	.1006	.1006		.1006	.8383
10	.4572		.7926		.6706	.0572
11	1.3108		.9145			
12	1.5242	1.3413	1.1431			
13	1.5242		1.1431		1.4251	
14	1.3717		1.1431			
15	1.3717	1.3413	1.1431		1.4251	
16	1.3108		1.2193			
17	1.0669		1.2193			
18	.0572		.0572		.1006	
19	.0572		.0686			.0686
20	.08		.08		.1341	.0914
21	.08		.08			.0914
22	.0686		.0686		.1174	.0914
23	.0686		.0686		.0914	.08
24	.0838	.0671	.0762	.0572	.0838	.4191
Max	1.5242	1.3413	1.2193	.0572	1.4251	1.0669
Min	.0572	.0671	.0572	.0572	.0838	.0572
Avg	.4631	.5002	.5293	.0572	.3970	.4611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 203 / 11 KV SURDI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509				.7621
2	.1341				.7621
3	.0914	.1341		.1174	.9145
4	.0914		.1677		.9145
5	.1143				1.0669
6	.1715	.2683		.285	1.2193
7	.2286		.3018		1.3717
8	.1143				1.6766
9	.1143	.218	.2012	.1677	1.5242
10	1.3108	1.2574	1.0974	1.3413	.08
11	1.9204		1.9204		
12	2.0271		2.0729	2.0119	
13	2.1338	2.0119	1.9509	1.7604	
14	2.1795		1.829		
15	2.0424	1.9281	1.768		
16	1.829		1.829	2.0957	
17	1.829		1.9204		
18	.0914		.0686	.1677	
19	.1372		.1372		.16
20	.1715		.1829	.1844	.1829
21	.16		.16		.16
22	.1372		.1143	.1677	.1372
23	.1143		.1143	.1677	.1143
24	.1677		.1677	.1509	.6706
Max	2.1795	2.0119	2.0729	2.0957	1.6766
Min	.0914	.1341	.0686	.1174	.08
Avg	.7276	.9696	.8891	.7182	.7323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 205 / 11 kV Yawali Ag feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736				.0343
2	1.1736				.0343
3	1.2193	1.1736		1.576	.0343
4	1.3717		1.5089		.0457
5	1.5242				.0572
6	1.6766	1.9616		1.8778	.0229
7	2.0576		2.1795		.0572
8	1.2193				.0572
9	1.5242	2.6322	2.3472	2.146	.0572
10	.0343		.0343		1.829
11	.0343		.0229		
12	.0229	.0503	.0229		
13	.0229		.0229	.0503	
14	.0229		.0229		
15	.0229	.0335			
16	.0229		.0229	.0503	
17	.0229		.0229		
18	.0343		.0229		
19	.0457		.0572		.0457
20	.0572		.0572	.0838	.0572
21	.0572		.0457		.0572
22	.0457		.0343	.0671	.0572
23	.0457		.0343	.0503	.0457
24	.9145	.8718	.7621	.7545	.0503
Max	2.0576	2.6322	2.3472	2.146	1.829
Min	.0229	.0335	.0229	.0503	.0229
Avg	.5978	1.1205	.4248	.7396	.1589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274123 / 33/11 KV SURDI S/S

Feeder No / Name : 206 / 11 kV Turk-Pimpri AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838				.3048
2	.0838				.3048
3	.0686	.061		.0671	.3048
4	.0914		.0838		.4572
5	.0914				.6097
6	.08	.1341		.1174	.6097
7			.1341		.7621
8	.0572				.8383
9	.0572	.061	.0838	.0838	.8383
10	.5487	.5868	.5335	.6706	.0572
11	1.1584	.9145	1.1584		
12	1.1584		1.3108	1.2574	
13	1.2193	1.3413	1.2193		
14	1.326		1.1584		
15	1.3108	1.1736	1.1126		
16	1.2498		1.1431	1.2574	
17	1.1584		1.1736		
18			.0572	.1006	
19	.0914		.0686		.08
20	.0914		.0686	.1341	.0914
21			.0686		.0914
22	.08		.0686	.1174	.0914
23			.0686	.1006	.0914
24	.0838	.0671	.0838	.0671	.3353
Max	1.326	1.3413	1.3108	1.2574	.8383
Min	.0572	.061	.0572	.0671	.0572
Avg	.5045	.5424	.5331	.3612	.3667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 201 / 11 KV SOUNDARE FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0457	.0686	.0514	.0857	.0457	.8916
2	.0514	.0457	.0686	.0514	.0857	.0457	.8916
3	.0514	.061	.0686	.0514	.0686	.0457	.8916
4	.0514	.061	.0686	.0514	.0686		.8916
5	.0514	.061	.0514	.0514	.0857		.9088
6	.0514	.061	.0514	.0514	.0343	.0457	1.0288
7	.0686	.061	.0514	.0514	.0457	.0514	1.3375
8	.0686	.061	.1715	.0514	.1067	.0514	1.2174
9	.0514	.0686	.0514	.0514	.1067	.0514	.0686
10		.0686	.12	.0857	.061	.0514	.0686
11		.0514		.0686	.0457	.0514	.0514
12		.0686	.0514	.0686	.0457	.0514	.0686
13	.0514	.0514	.0514	.0686	.0457	.0857	.0686
14	.0514	.0686	.0514	.0686	.0457	.0857	.0857
15	.0457	.0686	.0514	.0686	.0457	.0514	.0857
16	.0457	.1029		.0514	.0762	.0686	
17	1.8004	1.6118	1.6804	1.6632	1.5242	1.6461	
18	1.8347	1.6461	1.6289	1.5775	1.5851	1.6289	
19	1.4632	1.2346	.9774	1.3889	1.387	1.2517	.0514
20	1.2346	1.0974	1.1488	1.1831	1.3717	1.0802	.0514
21	1.0212	1.0802	1.1145	1.166	1.0364	.9774	.0514
22	.9907	.9774	1.1317	1.1317	1.0364	.9774	.0514
23	.945	.9602	1.1317	1.0802	1.0059	.9431	.0514
24	.9945	.9145	.8916	1.1317	1.0288	.9755	.8916
Max	1.8347	1.6461	1.6804	1.6632	1.5851	1.6461	1.3375
Min	.0457	.0457	.0514	.0514	.0343	.0457	.0514
Avg	.5226	.4387	.4856	.4694	.4595	.4665	.4621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 203 / 11 KV KASARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.7926	1.1488	1.1831	1.1317	1.0517	.0514
2	1.0288	.7926	1.1488	1.1831	1.1317	1.0669	.0514
3	1.0288	.8078	1.1488	1.2003	1.2174	1.0974	.0514
4	1.1145	.9145	1.2003	1.286	1.286	1.1279	.0514
5	1.2003	1.0517	1.3717	1.3717	1.3203	1.2346	.0514
6	1.3375	1.6461	1.5261	1.8004	1.4918	1.4784	.0514
7	1.6289	1.6156	2.0576	1.9719	1.8519	1.7833	.0514
8	1.7661	1.6004	1.9719	2.0405	1.5851	2.0576	.0686
9	.0686	.0686	.0686	.0514	.061	.0514	1.7833
10	.0514	.0686	.0514	.0514	.061	.0514	1.8861
11	.0514	.0686	.0514	.0514		.0514	2.1605
12	.0514		.0514	.0514		.0514	2.2291
13	.0514		.0514	.0514		.0857	2.3148
14	.0514		.0514	.0686		.0857	2.0062
15	.0457		.0514	.0514	.061	.0686	1.9719
16	.0457	.0686		.0514	.061	.0514	
17	.0457	.0686	.0514	.0514	.061	.0514	
18	.0457	.0857	.0514	.0686	.061	.0514	
19	.0762	.1029	.0514	.1029	.061	.0857	.0514
20	.0762	.0857	.0514	.0857	.061	.0857	.0514
21	.0762	.0857	.0686	.0857	.0457	.0686	.0514
22	.0762	.0857	.0514	.0686	.0457	.0686	.0514
23	.061	.0857	.0514	.0514	.0457	.0514	.0514
24	.0514	.0686	.0686	.0514	.0514	.061	.0514
Max	1.7661	1.6461	2.0576	2.0405	1.8519	2.0576	2.3148
Min	.0457	.0686	.0514	.0514	.0457	.0514	.0514
Avg	.4572	.5082	.5390	.5430	.5846	.4966	.7185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 204 / KASARWADI GAONTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2915	.1715	.3429	.3086	.3944	.1715
2	.2572	.3086	.1715	.3429	.3086	.3944	.1715
3	.2572	.3086	.1715	.3429	.3086	.3944	.1715
4	.3258	.3258	.1715	.3429	.3772	.4287	.2572
5	.3429	.3601	.3429	.4287	.4458	.4973	.3772
6	.5144	.583	.5144	.4973	.5316	.5316	.6001
7	.5487	.583	.5144	.5144	.5316	.463	.4287
8	.4287	.5144	.4287	.4801	.463	.4287	.1715
9	.3772	.3772	.1715	.4115	.3601		.3429
10	.3258	.2743	.1715	.2572	.2915	.3429	.2572
11	.3086	.1715	.1715	.2058	.2915	.1715	.2401
12	.2743	.1715	.1715	.1715	.2572	.1715	.2058
13	.2058	.1715	.1715	.1715	.2058	.1715	.1715
14	.1715	.1715	.2058	.1715	.2572	.1715	.1715
15	.2572	.1715	.1886	.1715	.2572	.1715	.1715
16	.3429	.1715		.2401	.2572	.2572	
17	.3086	.1715	.3429	.3772	.4115	.4287	
18	.3601	.1715	.4973	.4458	.5316	.3772	
19	.6173	.4287	.6001	.5316	.6001	.6001	.7202
20	.6344	.4287	.6859	.6173	.583	.4287	.6859
21	.5316	.4287	.6001	.5144	.583	.4287	.5144
22	.5316	.3086	.4801	.4287	.5487	.3429	.5144
23	.5316	.4287	.4287	.3772	.5316	.2572	.4287
24	.3086	.5144	.3772	.3944	.3086	.4973	.2572
Max	.6344	.583	.6859	.6173	.6001	.6001	.7202
Min	.1715	.1715	.1715	.1715	.2058	.1715	.1715
Avg	.3758	.3265	.3370	.3658	.3980	.3631	.3348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274125 / 33/11 KV KASARWADI S/S

Feeder No / Name : 205 / 11 KV Maruti Technofab NON SHEDDABLE EXPRESS HV FEEDERS
Express Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2058	.2058	.2401	.2401	.2058	.2058
2	.2058	.2229	.2229	.2229	.2058	.2058	.2058
3	.2229	.2743	.2572	.1886	.2058	.2058	.2058
4	.2229	.2058	.2572	.1886	.1886	.2229	.1886
5	.2401	.2229	.2401	.2058	.2743	.2229	.1886
6	.2401	.2229	.2401	.1886	.2743	.1372	.1715
7	.2401	.2401	.2572	.1372	.2743	.1543	.2229
8	.2229	.2229	.2572		.2743	.1715	.1372
9	.2401	.2401	.2058	.2058	.2743	.1543	.1372
10	.2401	.2743	.2401	.2058	.2743	.1543	.12
11	.2229	.2915	.2915	.2401	.2915	.3429	.1543
12	.2401	.2915	.2572	.2229	.3086	.2915	.12
13	.2572	.2743	.2743	.1886	.3086	.2572	.12
14	.2743	.2401	.1372	.1543	.2915	.2915	.1029
15	.3086	.2229	.2572	.1715	.3086	.3429	.1372
16	.2743	.2229		.2572	.2915	.2743	
17	.2743	.2229	.1372	.2572	.2743	.3429	
18	.2572	.1886	.2229	.2229	.2743	.3258	
19	.2229	.1886	.2915	.2058	.2572	.3772	.0686
20	.2058	.1715	.2229	.2229	.2572	.2229	.0857
21	.1886	.1886	.2401	.2058	.2572	.1372	.1715
22	.1886	.1715	.2229	.1886	.2401	.2229	.1886
23	.1886	.1886	.2401	.2401	.2229	.2229	.2058
24	.1715	.1886	.1886	.2401	.2401	.2058	.2229
Max	.3086	.2915	.2915	.2572	.3086	.3772	.2229
Min	.1715	.1715	.1372	.1372	.1886	.1372	.0686
Avg	.2308	.2243	.2334	.2088	.2629	.2372	.1600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 203 / Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.6562	.6874	.7403			
2	.6718	.6722	.6562	.6827			
3	.6562	.6722	.6249	.6413			
4	.703	.6722	.5937	.6089			
5	.7655	.7042	.703	.7042			
6	.9061	.7682	.7811	.8038			
7					.7655	.8642	
8					1.012	.9442	.8962
9					.9332	1.0082	.7682
10					.9626	1.0883	
11					.8796	1.0562	
12					.6832	1.0402	
13					.8344	1.0082	
14					.8068	.9602	
16							.8962
23	.7522	.6562	.8519				
24	.703	.6562	.703	.7948			
Max	.9061	.7682	.8519	.8038	1.012	1.0883	.8962
Min	.6562	.6562	.5937	.6089	.6832	.8642	.7682
Avg	.7307	.6822	.7002	.7109	.8597	.9962	.8535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 204 / Shelgaon(m)Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1385	1.1843	1.1248	.9895	.1235	.096	.0916
2	1.1069	1.2163	1.0936	1.0351	.1235	.096	.1068
3	1.0753	1.1843	1.0467	1.0808	.1235	.08	.1068
4	1.0722	1.1843	1.1069	1.1112	.1235	.08	.1221
5	1.1203	1.2925	1.3125	1.2178			
6	1.2163	1.5043	1.5023	1.4595			
7	1.9044	1.9845	2.1285	1.9613	1.3435	1.7604	1.6482
8	1.3923	1.9204	1.9528	.7682	1.7078		1.8084
9					1.7049	1.8343	1.6804
10					1.507	1.8818	
11					1.7071	1.7394	
12					1.8595	1.866	
13					1.7223	1.8185	
14					1.7071	1.6872	
19	.064	.108	.0913	.0926	.128	.1221	.1235
20	.064	.1235	.1066	.0926	.112	.1221	.1389
21	.064	.1235	.1218	.108	.112	.1221	.1389
22	.064	.1235	.0913	.108	.096	.1221	.1389
23	.064	.1235	.0913	.1235	.096	.1221	.108
24	.1852	.064	.0926	.0761	.1235		.0916
Max	1.9044	1.9845	2.1285	1.9613	1.8595	1.8818	1.8084
Min	.064	.064	.0913	.0761	.096	.08	.0916
Avg	.7522	.8669	.8474	.7303	.8012	.8469	.4849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274157 / 33/11 KV Sub Station Jamgaon

Feeder No / Name : 205 / DEVGAON Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9922	1.3443	1.3894
2					.8802	1.3443	1.3086
3					.8802	1.2963	1.2602
4					.8642	1.3283	1.2279
5					.8802	1.4243	1.3571
6					.9602	1.5844	1.6156
7	1.0202	.8962	.8162	.8249			
8	1.1984	.9602	1.1203	.9442			
9	1.1523	.9532	1.1646	1.0242			
10	1.0883	.9694	1.1646	1.094			
11	1.2308	1.0178	1.1646	.9282			
12	1.2308	1.0663	1.2617	.8642			
13	1.1822	1.0825	1.1646	.7682			
14	1.1498	.9855	1.0999	.6722			
15	1.6518	2.1649	.8411	2.3537	.9705	1.0402	
16	1.9364	2.4966		2.5126	1.3117	1.2483	.9122
17	2.2405	2.7206	2.5233	2.753	1.2803	1.3123	1.2163
18	2.3045	2.2996	2.6527	2.7206	1.2803	1.1808	1.1683
19	1.6644	2.1376	2.2024	2.3482	1.1523	.9705	1.1203
20	1.1683	1.9433	1.8138	1.7764	1.0562	.5176	1.0722
21	1.1457	1.6164	1.6356	1.5524	.9922	.6786	1.0402
22	1.0883	1.1683	1.5546	1.3123	.9602	.6947	.9762
23				1.2003	1.2963	1.5025	1.668
24					.9922	1.3443	1.4379
Max	2.3045	2.7206	2.6527	2.753	1.3117	1.5844	1.668
Min	1.0202	.8962	.8162	.6722	.8642	.5176	.9122
Avg	1.4033	1.5299	1.4787	1.5088	1.0468	1.1757	1.2514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 201 / Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2641	.2614	.2263	.2241	.2058	.2263
2	.2241	.2641	.2241	.2263	.2241	.2401	.2641
3	.2614	.3018	.2241	.2641	.2241	.2401	.2641
4	.3018	.3395	.2987	.4527	.3734	.3429	.3395
5	.415	.415	.4481	.4904	.4854	.4115	.4481
6	.5281	.5658	.5601	.5658	.6348	.5487	.6036
7	.4481	.5281	.5975	.5658	.5914	.5487	.4854
8	.4066	.415	.4805	.462	.4805	.4527	.3734
9	.2957	.3772	.362	.3898	.3086	.3658	.3086
10		.2507	.2896	.2481	.1715	.2241	.2743
11		.1791	.1448	.181	.1715	.2241	.1715
12	.1494	.1753	.1629	.181	.1715	.2241	.1715
13	.1494	.1791	.1629	.181		.2241	
14	.1494	.1772		.1448		.1867	
15	.1494	.1791	.1629	.1791	.1715	.1867	
16	.1494	.1772	.1629	.181	.1543	.112	
17	.1494	.1753	.2172	.181	.1715	.1494	
18	.2241	.2454	.2172	.2149	.1715	.1867	.2572
19	.3361	.4024	.3841		.3772	.3772	.4287
20	.4108	.439	.4108	.439	.4458	.3772	.3772
21	.3734		.3734	.4024	.3429	.3772	.3429
22	.3018	.2957	.3361	.3292	.2401	.3395	.2743
23		.2957	.2614	.6838	.2641	.2641	.2401
24		.2641	.2614	.2263	.2614		.2263
Max	.5281	.5658	.5975	.6838	.6348	.5487	.6036
Min	.1494	.1753	.1448	.1448	.1543	.112	.1715
Avg	.2854	.3003	.3045	.3224	.3028	.2961	.3198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 202 / Shripat-Pimpri Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9095	.9095	1.0974	1.3927	.2614	.1715	.2241
2	.9095	.9536	1.0974	1.4413	.2614	.1886	.2241
3	1.2803	1.0269	1.4937	1.5061	.2641	.1715	.2241
4	1.5364	1.2803	1.6461	1.5061	.2263	.1715	.2614
5	1.7284	1.7004	1.7985	1.7328	.2263	.2058	.2614
6	2.0317	1.9662	2.2024	2.17	.2263	.2572	.2987
7	3.0148	2.915	2.7831	3.2388			
8	2.6246	2.915	2.1506	2.5263			
9	2.5911	2.1052	2.7046	2.6882			
10					1.5242	2.2177	1.6461
11					1.0669	3.3265	2.5301
12					2.6825	3.5113	2.5301
13						3.6037	
14						3.3265	
16					2.3167	3.3265	
17						3.1417	
19	.2987	.3696	.3696	.4481	.3429	.2614	.3086
20	.3018	.4108	.3734	.3734		.2614	.3086
21	.2987	.3734	.3361	.3772	.2058	.2241	.2915
22	.2987	.3361	.2987	.3018	.2401	.2241	.2572
23	.208	.3361	.2614	.2641	.2401	.2241	.2401
24	.8509	.8916	1.0974	1.2955	.2614	.1886	.2241
Max	3.0148	2.915	2.7831	3.2388	2.6825	3.6037	2.5301
Min	.208	.3361	.2614	.2641	.2058	.1715	.2241
Avg	1.2589	1.2326	1.3140	1.4175	.6898	1.3160	.6553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274158 / 33/11 KV Shendri S/Stn

Feeder No / Name : 203 / Shendri Feeder AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1547	.16	.1143	.1734	.6481	.7202	.9574
2	.1547	.1879	.1143	.1734	.7099	.6935	1.0002
3	.1547	.16	.1143	.1734	.9335	.8002	1.1279
4	.1547	.1829	.1829	.1734	1.086	.9069	1.2955
5	.25	.1829	.2214	.1734	1.3245	1.1279	1.448
6	.25	.1829	.2214	.1734	1.3546	1.5546	1.829
7					1.9566	2.3167	2.4387
8					1.9364	2.3472	2.5911
9					1.8576	2.2577	2.4387
10	1.6194	1.2437	1.4937	1.7833			
11	2.4291	2.0424	2.2862	2.1674			
12	2.5911	2.6882	2.652	2.4691			
13	2.5911	2.8464	2.7892	2.4691			
14	2.4291	2.5911	2.5149	1.2689			
15	2.5911	2.5309	2.1186	2.2222			
16	2.753	2.4691	2.3777	2.2222			
17	2.7854	2.4383	2.3777	2.3746			
19	.2987	.1494	.1867		.2	.1867	.2134
20	.2987	.152	.2134	.2042	.1981	.1867	.2134
21	.2987	.1334	.1867	.2012		.2134	.1715
22	.2614	.1334	.1734	.1707		.1867	.16
23	.2614	.1334	.1734	.1574		.2	.1372
24	.1547	.16	.1143	.1734	.6481	.6668	.9288
Max	2.7854	2.8464	2.7892	2.4691	1.9566	2.3472	2.5911
Min	.1547	.1334	.1143	.1574	.1981	.1867	.1372
Avg	1.1241	1.0384	1.0313	.9960	1.0711	.9577	1.1301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 201 / 11 KV Gaudgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716		.7545	.7716		.6859	.6859
2	.7716		.7545	.7716		.7202	.6859
3	.8573		.7888	.823		.7202	.7202
4	.9431		.7888	.8916		.823	.7202
5	.9431		.823	1.0288		1.0288	.7202
6	1.1145		.9602	1.1145		1.2003	.9259
7	1.1488		1.166	1.166		1.2003	1.2003
8	1.1488	1.0212	1.2003	1.166		1.0802	1.1145
9		1.1145	1.2003		1.0288	.9602	
10		.4801	.463		.6001	.4801	
11			.4287		.4801	.4115	
12		.4458	.3772		.4287	.3772	
13		.4458	.3772		.4287	.4458	
14		.4458	.3772		.3772		
15		.4458	.4115		.4287	.4115	
16		.4115	.4287		.4287	.4458	
17		.4458	.463		.4801	.4458	.3772
18		.4801	.5144		.6001	.4801	.823
19		.7545	.8916		.8573	.7202	.9431
20		.8916	.8573		.8573	.8573	.9945
21		.7888	.823		.823	.7545	.8916
22		.6516	.6516		.6859	.6173	.7716
23		.5144	.5144		.5658	.5487	.6516
24	.7716		.7202	.7373		.6859	.6859
Max	1.1488	1.1145	1.2003	1.166	1.0288	1.2003	1.2003
Min	.7716	.4115	.3772	.7373	.3772	.3772	.3772
Avg	.9412	.6225	.6973	.9412	.6047	.7000	.8070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 202 / 11 KV Raulgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		1.0288	1.1145		1.0802	1.0974
2	1.1145		1.0288	1.1145		1.0802	1.0974
3	1.1145		1.0974	1.166		1.0802	1.0974
4	1.286		1.1317	1.166		1.166	1.1317
5	1.286		1.2003	1.3717		1.3717	1.1317
6	1.3717		1.2346	1.7147		1.5775	1.406
7	1.7147		1.9204	1.9204		1.9719	1.9719
8	1.8347	1.6613	2.0576	2.0576		1.6289	1.8176
9		1.8861	2.0576			1.8861	
10		.2743	.2058			.2401	
11		.2058				.2401	
12		.1715	.2058			.2401	
13		.2058	.1715			.2058	
14		.1715	.1715		.2229	.2058	
15		.1715	.1715		.2229	.2058	
16		.1715	.2058		.2229	.1715	
17		.2058	.2572		.3086	.2058	
18		.2401	.2915		.4115	.2572	.6001
19		.4801	.6516		.6516	.4801	.7202
20		.6859	.6001		.6859	.5487	.6859
21		.5487	.6001		.6001	.5144	.5144
22		.4115	.4115		.4801	.4115	.3772
23		.3429	.3429		.3772	.3772	.3429
24	.9945		.9945	1.0802		1.0802	1.0631
Max	1.8347	1.8861	2.0576	2.0576	.6859	1.9719	1.9719
Min	.9945	.1715	.1715	1.0802	.2229	.1715	.3429
Avg	1.3050	.4896	.7843	1.4117	.4184	.7595	1.0037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274192 / Gaudgaon Sub station

Feeder No / Name : 203 / 11 KV Bhalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.2743	.3086		.3429	.3086
2	.3429		.2743	.3086		.3429	.3086
3	.3429		.3086	.3429		.3429	.3086
4	.3772		.3772	.3429		.3772	.3772
5	.4287		.4458	.4287		.4287	.4458
6	.6859		.583	.5144		.4287	.583
7	.6173			.5144		.6344	.6516
8	.5144	.4725	.5487	.5144		.5144	.5487
10		2.1948	2.0233				
11		2.572	2.572		1.3717	.2401	
12		2.9492	2.572		2.4006	2.7435	
13		2.7435	2.572		2.4006	2.8807	
14		2.7778	2.5377		2.4006	1.8861	
15		2.5377	2.4863		2.4006	1.8861	
16		2.6749	2.4863		2.4006	1.5089	
17		2.7778	2.4006		2.4006	2.1262	
18		.2401	.2229		.2915	.2401	.6001
19		.4458	.5487		.5144	.4458	.6001
20		.6173	.6001		.5658	.5144	.6001
21		.5144	.4801		.4801	.4458	.5144
22		.3772	.3772		.4287	.3772	.4287
23		.3086	.3086		.3429	.3429	.3429
24	.3429		.2743	.3086		.3429	.3086
Max	.6859	2.9492	2.572	.5144	2.4006	2.8807	.6516
Min	.3429	.2401	.2229	.3086	.2915	.2401	.3086
Avg	.4439	1.6136	1.1488	.3982	1.4153	.8815	.4618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 201 / 11 Kv pathari Gaothan

GAOTHAN FEEDER

feeder Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1029	.1543	.12	.1029	.1543
2	.1029	.12	.1029	.1543	.12	.1029	.1372
3	.1029	.1543	.1543	.1372	.1543	.1715	.1372
4	.1372	.2401	.2401	.1543	.2401	.2401	.1715
5	.2401	.3086	.3086	.2743	.3086	.3086	.2743
6	.3772	.4115	.4115	.3601	.4115	.3772	.3601
7	.3772	.3772	.3429	.4115	.3944	.3772	.4115
8	.3429	.3086	.3086	.3258	.2743	.2743	.3086
9	.2058	.2401	.2743	.2572	.2401	.2058	.2229
10	.1715	.1715	.1372	.1886		.1715	.1543
11	.1715	.1029	.1029	.1372	.1372	.12	.1372
12	.1029	.0686	.1029	.1029		.12	.1029
13	.12	.0686	.0857	.1029		.1029	.1029
14	.1029	.0686	.1029		.1372	.1029	.1029
15	.1029	.0686	.1029	.1029	.1029	.1029	.1029
16	.1029	.0686	.1029	.1029	.1029	.1029	
17	.1029	.1029	.1029	.1029	.1029	.0857	
18	.12	.1029	.12	.12	.1029	.1029	
19	.2743	.2058	.2401	.2743	.2401	.2572	.2743
20	.2572	.3086	.2915	.3086	.2743	.2915	.3086
21	.2401	.2743	.2401	.2401	.2401	.2401	.2401
22	.2058	.2058	.2058	.2058	.1715	.2058	.2058
23	.1543	.1715	.1715	.1715	.1715	.1715	.1715
24	.1372	.1372	.1372	.1543	.1715	.1372	.1543
Max	.3772	.4115	.4115	.4115	.4115	.3772	.4115
Min	.1029	.0686	.0857	.1029	.1029	.0857	.1029
Avg	.1815	.1836	.1872	.1976	.2009	.1865	.2017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 202 / 11 Kv Dhanore Ag feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.1317	1.0288	1.166		
2	1.0631	1.1317	1.1145	1.2174		
3	1.0974	1.1145	1.166	1.3032		
4	1.166	1.166	1.2346	1.3375		
5	1.2689	1.2346	1.3375	1.3889		
6	1.3717	1.3375	1.3717	1.5432		
7	1.5432	1.6118	1.5432	1.5775		
8	1.6804	1.7833	1.749	1.5604		
9		1.5947	1.6461	1.5432		
10					1.286	1.5432
11					1.5775	1.8176
12					1.8519	1.286
13					1.8519	1.7833
14					1.8176	1.7318
15					1.8519	1.8004
16					1.8176	1.749
17					1.8519	1.6804
24	.6859	1.0974	.8573	1.1145		
Max	1.6804	1.7833	1.749	1.5775	1.8519	1.8176
Min	.6859	1.0974	.8573	1.1145	1.286	1.286
Avg	1.2079	1.3203	1.3049	1.3752	1.7383	1.6740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274208 / 33/11 KV Pathari Sub station

Feeder No / Name : 203 / 11 KV Pimpalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7202	.6859	.8745
2					.6516	.7202	.9088
3					.6516	.7545	.9602
4					.6859	.7888	.9945
5					.6859	.7888	1.0288
6					.7716	.823	1.046
7					.8916	.9602	1.0974
8					.9259	1.0288	.9431
9					.9602	1.0288	.9259
10	.7545	.8573	.8573	.8573			
11	1.0974	.8573	1.0288				
12	1.1317	.9259	1.1317	1.0288			
13	1.1488	.9945	1.046	1.1317			
14	1.1317	1.0288	.9602				
15	1.0974	.9945	.9602	1.0974			
16	1.1145	.9602	1.046	.9945			
17	1.0631	.9259	1.046	.9431			
24					.6859	.6859	.7888
Max	1.1488	1.0288	1.1317	1.1317	.9602	1.0288	1.0974
Min	.7545	.8573	.8573	.8573	.6516	.6859	.7888
Avg	1.0674	.9431	1.0095	1.0088	.7630	.8265	.9568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 201 / 11 KV DAM FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.0364
2							1.1279
3							1.1431
4							1.1126
5							1.1584
6							1.2041
7							1.2193
8							1.1888
9							1.2193
10	1.1431	1.0669	1.1888	1.4937	1.3717	1.387	
11	1.4937	1.3717		1.4632	1.5242	1.5851	
12	1.4784	1.5851		1.5851	1.5851	1.5699	
13	1.3413	1.5546	1.5242	1.6004	1.5242	1.5546	
14	1.3413	1.5851			1.5242	1.5699	
15	1.4022	1.5851	1.5546	1.5546	1.5242	1.5699	
16		1.5546	1.5699	1.6156	1.5546	1.5851	
17	1.2803	1.5546	1.6156	1.6004	1.5546	1.5242	
21		.1219					
Max	1.4937	1.5851	1.6156	1.6156	1.5851	1.5851	1.2193
Min	1.1431	.1219	1.1888	1.4632	1.3717	1.387	1.0364
Avg	1.3543	1.3311	1.4906	1.559	1.5204	1.5432	1.1567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274221 / 33/11KV BAVI SUB STATION

Feeder No / Name : 202 / 11 KV TANDULWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286		.2896	.2439	.3048	.061
2	.2439	.2286		.3658	.2439	.3048	.061
3	.2896	.2286	.3963	.3506	.2439	.3048	.0457
4	.3353	.2743	.4877	.3963	.2743	.3048	.0762
5	.442	.3048	.5639	.4268	.2743	.3353	.1067
6	.4572	.381	.5335	.442	.3048	.3658	.1372
7	.4877	.442	.503	.4572	.3048	.3963	.1372
8	.4572	.4268	.4572	.3963	.3963	.4572	.1372
9	.4268	.4268	.4268	.3658	.4877	.4725	.1219
10	.0457	.061	.0305	.0305	.061	.0457	.3353
11	.0305	.0457	.0457	.0305	.061	.061	
12	.0457	.0457	.0305	.0305	.061	.0457	
13	.0457	.0457	.0305	.0305	.061	.0457	
14	.0457	.0457	.0457		.061	.0457	
15	.0457	.0457	.0457	.0305	.061	.0305	
16	.0457	.0762	.0457	.0305	.061	.0457	
17	.061	.0762	.0457	.0457	.061	.0457	
18	.0762	.0914	.061	.0762	.0762	.0762	
19	.1219	.0914	.1067	.1219	.0914	.1067	.1219
20	.1219	.0914	.1219	.1372	.1219	.1067	.1372
21	.1219	.0914	.1372	.1219	.1219	.0914	.1372
22	.1067	.0914	.1524	.0914	.1372	.0762	.1067
23	.0762	.0914	.2134	.0762	.0914	.0762	.0762
24	.1981	.2134		.2286	.2439	.2591	.1372
Max	.4877	.442	.5639	.4572	.4877	.4725	.3353
Min	.0305	.0457	.0305	.0305	.061	.0305	.0457
Avg	.1899	.1727	.2134	.1988	.1727	.1835	.1210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (R) S/DN.[091] BU 1392

Substation No/ Name :- 274235 / 33/11 KV RATANJAN SUB
STATIONFeeder No / Name : 201 / 11 KV GAVTHAN FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1543	.2058	.1715	.2058	.1715
2	.2229	.2401	.1372	.2401	.1715	.1715	.1715
3	.2572	.2401	.1715	.2401	.1715	.1886	.1886
4	.2915	.2743	.1715	.2743	.2229	.2058	.2229
5	.3086	.3086	.2915	.2915	.3258	.2743	.3086
6	.3429	.2572	.2401	.2401	.3429	.3601	.3429
7	.2058	.2401	.2058	.2058		.3258	.3086
8	.1543	.1886	.1372	.2058	.2401	.2401	.1372
9	.1372	.1372	.1372	.1543	.1886	.2229	.2058
10	.12	.1029	.1029	.1543	.1543	.1886	.1715
11	.1372	.12		.12	.1543	.1715	.12
12	.1543	.1372	.12	.0857	.1886	.1715	.12
13	.12	.1029	.12	.1372	.2058	.1886	.1372
14	.1372	.1029		.12	.1372	.2058	.1372
15	.12	.12	.1372	.12	.1715	.1886	.12
16	.1029	.12	.12	.1029	.1886	.1886	.1029
17	.12	.1372	.1029	.12	.1715	.1886	.1029
18	.12	.0857		.1372	.1372	.2058	.1543
19	.2058	.1886			.2743	.2572	.2401
20	.2229	.2743	.2058	.2915	.2915	.3086	.2915
21	.1886	.2058	.1886	.2743	.2572	.2743	.3086
22	.1715	.1886	.2058	.2572	.2229	.2229	.2743
23	.1543	.1543	.1715	.2401	.2058	.1886	.2229
24	.1715	.1715	.1543	.1715	.1886	.2229	.1886
Max	.3429	.3086	.2915	.2915	.3429	.3601	.3429
Min	.1029	.0857	.1029	.0857	.1372	.1715	.1029
Avg	.1808	.1779	.1638	.1909	.2080	.2236	.1979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
stati

Feeder No / Name : 201 / 11KV TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.0296	1.105	.9955	1.0059	1.0498	1.1431
2	1.0059	1.048	1.0669	.9412	.9694	1.0136	1.1431
3	.9145	.9928	1.0098	.9412	.9145	.9412	1.0479
4	.9511	.956	.9526	.9412	.9145	.905	1.0479
5	1.0425	.9928	.9717	.9955	1.0059	.9955	1.1431
6	1.0974	.9744	1.0479	1.0136	1.0974	1.0136	1.2384
7	1.0425	1.048	1.1431	1.0498	1.134	1.1222	1.1431
8	.9955	1.0296	1.0669	.9955	1.0425	1.0679	1.1431
9	.9193	.9376	.9526	.9955	.9328	.9593	1.0479
10	1.2502	1.1431	.9412	1.0425	1.0317		1.0847
11	1.3421	1.3336	1.086	1.0425	1.2308		1.1215
12	1.3789		.9774	1.0059	1.3937		1.287
13	1.2318	1.3527	.9774	1.1888	1.3756		1.3421
14	1.287	1.448	1.1222	1.1157	1.3575		1.3237
15		1.3908	1.1222	1.1523	1.3937		1.3605
16	1.3605	1.3336	1.1765	1.1888	1.3032		1.3789
17	1.4708	1.3336	1.1946	1.2071	1.2127		1.3973
18	1.5995	1.2955	1.267	1.134	1.448		1.3789
19	1.6547	1.7147	1.6289	1.4266	1.7375		1.7466
20	1.5627	1.8099	1.6289	1.3717	1.6651		1.5811
21	1.4708	1.6194	1.448	1.3169	1.4661		1.4892
22	1.3237	1.3717	1.3394	1.2803	1.3756		1.3237
23	1.2318	1.2193		1.1041	1.267		1.2686
24	1.1157	1.0663	1.1431	1.086	1.0425	1.086	1.1431
Max	1.6547	1.8099	1.6289	1.4266	1.7375	1.1222	1.7466
Min	.9145	.9376	.9412	.9412	.9145	.905	1.0479
Avg	1.2309	1.2366	1.1465	1.1055	1.2216	1.0154	1.2635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 202 / 11 KV INDUSTRIAL ESTATE SHEDDABLE FEEDER HAVING WEEKLY
NO.02 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.4725	.4572	.5068	.4207	.543	.5716
2	.1886	.5103	.4191	.4344	.3772	.5068	.5716
3	.1698	.4914	.4191	.4344	.3772	.4706	.4763
4	.1886	.5292	.381	.4344	.3395	.4706	.4763
5	.1886	.4914	.4382	.4706	.3772	.4344	.4763
6	.2641	.5292	.4763	.5068	.415	.4344	.4763
7	.5093	.5859	.5716	.5792	.5658	.5792	.4763
8	.415	.6048	.7049	.5792	.5093	.5973	.381
9	.6237	.756	.7621	.6335	.6979	.7602	.4763
10	.756	.7621	.8145	.7545	.8326		.4914
11	.8127		.9955	.9431	.9593		.4536
12	.7749	.8573	.905	.8865	.8869		.3213
13	.8505	.9145	.9412	.6602	.7602		.2268
14	.8694	.9717	.6697	.4715	.7602		.2457
15	.8883	.9526	.905	.6602	.8145		.3024
16	1.0784	1.0479	.9774	.8676	1.0136		.2835
17		1.0479	.905	.7922	.9593		.2646
18	.8505	1.0288	.8507	.7545	.8507		.2268
19	.7938	.7621	.724	.6224	.724		.2835
20	.7182	.724	.6697	.6036	.543		.2646
21	.6237	.6668	.5792	.5853	.543		.2835
22	.5859	.5716	.5792	.5487	.5973		.2646
23	.5481	.5144		.4938	.5792		.2835
24	.2075	.5103	.5144	.543	.4715	.543	.5716
Max	1.0784	1.0479	.9955	.9431	1.0136	.7602	.5716
Min	.1698	.4725	.381	.4344	.3395	.4344	.2268
Avg	.5701	.7088	.6809	.6153	.6406	.5340	.3812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 274197 / 33/11 Kv Barshi Town Sub
statiFeeder No / Name : 203 / 11 KV BHAGAWANT FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.3135	.3239	.3258	.2743	.362	.381
2	.2012	.332	.3239	.3077	.2378	.3439	.2858
3	.1829	.3135		.3077	.2195	.3439	.2858
4	.2378	.2951	.3429	.3077	.2195	.362	.381
5	.3658	.332	.4763	.362	.3109	.3982	.4763
6	.4525	.3873	.4763	.3982	.4024	.4163	.4763
7	.4024	.3688	.381	.4163	.3658	.4344	.4763
8	.3109	.3873	.3429	.3982	.3109	.3439	.381
9	.2951	.332	.2858	.3258	.2743	.3258	.2858
10	.2766	.362	.2534	.2926	.2534		.2951
11	.2582	.3239	.3077	.2743	.3077		.3135
12	.2951	.2858	.3258	.2743	.2896		.3135
13	.332	.3239	.3258	.3109	.3077		.3504
14	.3135	.3429	.3439	.2926	.3258		.332
15	.2951	.3429	.3258	.2743	.2896		.3504
16	.332	.3239	.2896	.3109	.2896		.3135
17	.3688	.2858	.3077	.2926	.3077		.3135
18	.4057	.381	.2715	.3475	.2896		.332
19	.4611	.381	.4163	.4207	.4344		
20	.4242	.4763	.4163	.439	.4344		.4795
21	.4426	.4572	.4344	.4572	.4525		.4611
22	.4057	.4191	.4163	.4207	.4344		.4426
23	.3688	.4191		.3658	.4163		.4057
24	.2743	.3504	.381	.3982		.3982	.381
Max	.4611	.4763	.4763	.4572	.4525	.4344	.4795
Min	.1829	.2858	.2534	.2743	.2195	.3258	.2858
Avg	.3308	.3557	.3531	.3467	.3238	.3729	.3701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 203 / 11KV CANCER FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.5089	1.5089	1.5089		1.3336	1.3203
2	1.1203	1.5089	1.4937	1.5089		1.3336	1.3203
3	1.1317	1.3203	1.307	1.4937		1.3336	1.307
4	1.1203	1.3203	1.2936	1.3203		1.3336	1.3203
5	1.1203	1.3203	1.2936	1.5089		1.3336	1.3203
6		1.3203	1.4937	1.5089		1.3336	1.3203
7	1.1317	1.5089	1.307	1.5089		1.1431	1.3203
8	1.1203	1.3203	1.307	1.3203		1.1431	1.1317
9	1.1408	1.1317	1.307	1.3203		1.1431	1.1203
10		1.307	1.2936	1.3203	1.5242	1.5242	1.1203
11	1.4937	1.4784	1.6804	1.4937	1.7147	1.6804	1.1088
12	1.4784	1.4937	1.6804		1.7147	1.6804	1.307
13	1.4937	1.1088	1.4937	1.4937	1.3336	1.6804	1.1317
14	1.4784	1.0974	1.4937	1.4937	1.7147	1.6804	1.3203
15	1.4937	1.4784	1.4937	1.4937	1.7147		1.3203
16	1.6804	1.6632	1.6804	1.307	1.7147	1.6632	1.5089
17	1.6804	1.4937	1.6975	1.307	1.7147		1.5089
18	1.4937	1.6804	1.5089	1.331	1.7147	1.6804	1.307
19	1.4937		1.5089		1.7147	1.6975	1.307
20	1.307	1.4784			1.3336	1.6975	1.3203
21	1.5211	1.307			1.5242		1.1317
22	1.5089	1.307		1.307	1.5242	1.5089	1.1317
23	1.5089	1.307	1.5089	1.2003	1.5242	1.5089	1.3203
24	1.307	1.5089	1.5089	1.5089		1.5242	1.5089
Max	1.6804	1.6804	1.6975	1.5089	1.7147	1.6975	1.5089
Min	1.1203	1.0974	1.2936	1.2003	1.3336	1.1431	1.1088
Avg	1.3611	1.3900	1.4695	1.4128	1.6058	1.4742	1.2847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 204 / 11KV I.T.I. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.5487	.5316	.724		.5716	.5601
2	.7545	.5487	.5258	.543		.5716	.543
3	.7468	.5658	.5144	.543		.5716	.543
4	.7468	.5658	.5201	.543		.5716	.543
5		.5487	.5258	.543		.5716	.543
6		.7316	.5258	.724		.7621	.724
7	.7468	.7316	.7164	.724		.9526	.7164
8	.7468	.7468	.7087	.724		.7621	.7164
9		.543	.5258	.543		.7621	.5258
10		.5373	.5258	.543	.7621	.7621	.5316
11	.7316	.5258	.7164	.5601	.7621	.5487	.7087
12	.7164	.5258	.7164		.7621	.5258	.7164
13	.724	.7011	.5258	.5601	.7621	.5201	.7087
14	.7164	.5258	.5601	.5601	.7621	.7087	.7087
15	.7164	.7087	.5201	.7468	.7621		.7087
16	.5258	.7011	.5258	.7468	.7621	.7164	.7011
17	.5144	.7087	.6935	.7468	.7621		.7087
18	.6859	.7011	.7087	.5601	.7621	.5316	.7087
19	.905	.8859	.905		.9526	.724	.7164
20	.905	.7087	.905		.9526		.7164
21	.724	.8954	.905		.9526		.7164
22	.724	.7087		.7468	.7621	.724	.7087
23	.5487	.7087	.724	.7468	.7621	.724	.7164
24	.7468	.543	.5258	.724		.5716	.724
Max	.905	.8954	.905	.7468	.9526	.9526	.724
Min	.5144	.5258	.5144	.543	.7621	.5201	.5258
Avg	.7186	.6507	.6327	.6426	.8029	.6577	.6631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 206 / 11KV MILL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6975	1.6804	1.8861		1.9052	1.6975
2		1.6975	1.4632	1.8861		1.7147	1.6804
3		1.6975	1.4632	1.8671		1.7147	1.6804
4		1.6975	1.4632	1.8861		1.7147	1.6975
5		1.8861	1.6632	1.8861		1.7147	1.6975
6		1.8861	1.848	1.8861		1.9052	1.8861
7		1.8861	1.848	1.8861		2.0957	2.0748
8	1.6804	1.6975	1.6461	1.6975		1.7147	1.6975
9		1.6975	1.2803	1.6975		1.5242	1.4632
10		1.6804	1.4632	1.6804	1.9052	1.9052	1.4632
11	2.4272	2.0328	2.2177	1.6804	2.2862	2.4272	1.848
12	2.4272	2.2177	2.4272	1.8671	2.4768	2.4272	1.848
13	2.0538	2.0328	2.2405	1.8671	2.2862	2.2405	2.0538
14	2.0538	1.8671	1.8671	1.8671	1.7147	1.6975	1.6632
15	2.2405	1.848	1.8671	1.6804	2.0957		1.6632
16	2.4272	2.4272	2.452	1.8671	2.4768	2.2177	2.0328
17	2.4272	2.4272	2.6139	1.8671	2.4768		2.2405
18	2.4272	2.6139	2.8292	1.8671	2.4768	2.6139	2.0328
19	2.0748	2.4272	2.452	2.0538	2.2862	2.2405	2.0538
20	1.6975	1.6632	2.452		1.9052		1.6461
21	1.8861	1.6461			1.9052		1.6461
22	1.8861	1.848	1.6975	1.6804		2.0538	1.848
23	1.8861	1.848	1.8861	1.8671		1.8861	2.0328
24	1.8671	1.8671	1.6461	1.8671		1.9052	1.8671
Max	2.4272	2.6139	2.8292	2.0538	2.4768	2.6139	2.2405
Min	1.6804	1.6461	1.2803	1.6804	1.7147	1.5242	1.4632
Avg	2.0975	1.9288	1.9334	1.8314	2.1910	1.9809	1.8131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 207 / 11KV JAIN MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.829	1.6461	1.8099		1.9052	1.829
2		1.6632	1.4632	1.8099		1.9052	1.829
3		1.6461	1.448	1.6289		1.7147	
4		1.6461	1.6118	1.6289		1.7147	1.829
5		1.8861	1.8099	1.6289		1.7147	1.829
6		2.0119	2.0328	1.848		1.9052	2.0119
7		2.0119	1.848	2.0328		2.2862	2.2177
8	1.848	1.6461	1.848	2.0328		1.9052	1.829
9		1.6461	1.448	1.829		1.5242	1.6461
10		1.4632	1.2536	1.6461	1.5242	1.5242	1.4632
11	1.4632	1.267	1.448	1.4937	1.5242	1.448	1.4632
12	1.448	1.2536	1.448		1.7147	1.448	1.448
13	1.448	1.4327	1.448	1.6804	1.7147	1.448	1.6461
14	1.448	1.4327	1.448	1.6804	1.7147		1.6461
15	1.4632	1.448	1.448	1.6804	1.7147		1.6461
16	1.4632	1.4327	1.4632	1.6804	1.7147	1.6289	1.6289
17	1.6289	1.448	1.4632		1.7147		1.6461
18	1.6461	1.4327	1.6289		1.9052	1.448	1.6461
19	1.9909	2.0328	2.1719		2.0957	2.2405	2.4272
20	2.1719	2.2405			2.2862		2.2177
21	2.1948	2.2177			2.2862		2.2177
22	1.9909	2.0328		1.8671	2.2862	2.1948	2.2177
23	1.848	1.829	2.0119	1.8671	2.0957	2.0119	2.2177
24	1.829	1.829	1.6461	1.829		1.9052	2.0119
Max	2.1948	2.2405	2.1719	2.0328	2.2862	2.2862	2.4272
Min	1.448	1.2536	1.2536	1.4937	1.5242	1.448	1.448
Avg	1.7255	1.6991	1.6207	1.7597	1.8780	1.7828	1.8506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 208 / 11KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6632	1.4632	1.8671		1.9052	1.6632
2		1.6958	1.448	1.6632		1.7147	1.6632
3		1.6804	1.4327	1.6632		1.7147	
4		1.6804	1.4327	1.6461		1.7147	1.6804
5		1.6958	1.6118	1.6632		1.7147	1.6804
6		1.6461	1.6289	1.6804		1.9052	1.6804
7		1.8671	1.6632	1.6804		1.9052	1.6632
8	1.6461	1.6632	1.4632	1.4937		1.7147	1.6461
9		1.6461	1.4632	1.4784		1.7147	1.6461
10		1.4632	1.4632	1.4632	1.7147	1.7147	1.6461
11	1.6461	1.4327	1.6461		1.9052	1.6461	1.829
12	1.6461	1.8099	1.6289		1.9052	1.829	2.0328
13	1.6289	1.8099	1.829		1.9052		1.829
14	1.6289	1.6289	1.829	1.4937	2.0957	1.829	1.848
15	1.6461	1.6461	1.6461	1.6804	2.0957		2.0328
16	1.6461	1.6461	1.829	1.6804	2.0957	1.829	1.829
17	1.6461	1.6461	1.829	1.6804	1.848		1.848
18	1.6461	1.6461	1.8099	1.6804	2.0957	1.829	1.6461
19	2.2177	2.2177	2.1948		2.2862	2.2405	2.4272
20	2.1948		2.2177		2.2862	2.2405	2.4272
21	2.2177	2.2177	2.0538		2.0957		2.2177
22	2.0119	2.0328	2.0538	1.8671	2.0957	2.0328	2.2177
23	1.8099	1.848	1.848	1.8671	1.9052	2.0538	2.0328
24	1.8099	1.6461	1.6461	1.848		1.9052	2.0119
Max	2.2177	2.2177	2.2177	1.8671	2.2862	2.2405	2.4272
Min	1.6289	1.4327	1.4327	1.4632	1.7147	1.6461	1.6461
Avg	1.8028	1.7361	1.7138	1.6720	2.0236	1.8577	1.8782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 213 / 11KV BARSHI TEXTILE MILL NON SHEDDABLE EXPRESS HV FEEDERS
EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335	.9335	.9431		.9526	.9431
2		.9431	.9335	.9335		.9526	.9431
3		.9431	.9335	.9335		.9526	.9431
4		.9431	.9335	.9431		.9526	.9431
5		.9431	.9335	.9431		.9526	.9335
6		.9431	.9335	.9431		.9526	.9431
7		.9431	.924	.9431		.9526	.9335
8	.9431	.9431	.9335	.9431		.9526	.5144
9		.9431	.924	.9431		.9526	.3163
10		.9431	.9335	.9431	.9526	.9526	.3125
11	.9431	.9335	.9431	.9335	.9526	.9335	.1296
12	.9431	.9335	1.1317	.9335	.9526	1.1317	.1067
13	.9431	1.1317	.9431	.9335	.9526		.1143
14	.9335	.9335	.9431	.9335	.9526	1.1317	.1067
15	.9431	.924	.9431	.9335	.9526		.1143
16	1.1317	.9335	.9431	.9335	.9526	1.1317	.0152
17	.9431	.9335	1.1203	.9335	.9526		.0107
18	.9431	.9335	1.1317	.9335	.9526	.9431	.0124
19	.9431	.9335	1.1317		.9526	.9431	.0152
20	.9431	.9335					.0152
21	.9431	.9335	.9431		.9526		.0181
22	.9431	.9335	.9431	.9335		.9431	.0181
23	.9431	.9335	.9431	.9335		.9431	.0171
24	.9335	.9431	1.1203	.9431		.9526	.9431
Max	1.1317	1.1317	1.1317	.9431	.9526	1.1317	.9431
Min	.9335	.924	.924	.9335	.9526	.9335	.0107
Avg	.9544	.9454	.9781	.9376	.9526	.9779	.3901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 400 / Stn. T/F

Feeder KV- 33 / OUTGOING

DATE	28-MAR-18
HR	Load (MW)
1	2.8292
2	2.8292
3	2.8292
4	2.8006
5	2.8292
6	2.8006
24	2.8292
Max	2.8292
Min	2.8006
Avg	2.8210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 403 / Agalgaon

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.763	1.829	1.6461	1.701	1.7558	2.0005
2	1.3717	1.8198	1.7147	1.5364	1.5364	1.701	1.8861
3	1.262	1.7061	1.7147	1.5364	1.4815	1.6461	1.829
4	1.3717		1.6004	1.5364	1.4266	1.6461	1.829
5	1.5912	1.763	1.829	1.6461	1.6289	1.7558	1.9433
6	1.8107	1.8767	1.8861	1.7558	1.8461	1.8656	2.0576
7	1.9204	2.0473	1.9433	1.8656	2.009	1.9753	2.0005
8	1.5364	1.9905	2.0005	1.8656	1.8107	1.8656	1.829
9	1.8767	2.0473	1.9433	1.9204	1.8461	1.9753	1.6004
10	2.1042	2.0005	1.9204	2.0302	2.0851		1.7061
11	2.3317	2.2291	2.4143	2.1948	2.4691		1.763
12	2.5592	2.2291	2.1948	2.0851	2.524		1.9336
13	2.3317	2.5149	2.1948	2.0633	2.524		1.763
14	2.3885	2.6292	2.0851	1.8656	2.3594		1.8767
15	1.1943	2.572	2.4691	2.0302	2.4143		1.8198
16	2.8435	2.572	2.4691	2.2805	2.6337		1.8198
17	1.8767	2.5149	2.3045	2.2497	2.4691		1.8767
18	2.9004	2.5149	2.3045	2.1719	2.4691		1.8198
19	2.9573	2.7435	2.6337	2.4143	2.7435		2.3317
20	2.7298	2.8578	2.4977	2.4143	2.5789		2.1611
21	2.3317	2.6292	2.2497	2.3594	2.2497		2.0473
22	2.1611	2.2862	2.1399	2.2497	2.1948		1.9336
23	1.9905	2.0005		1.9753	2.0851		1.763
24	1.5912	1.8198	1.9433	1.8107	1.8107	1.8656	2.0005
Max	2.9573	2.8578	2.6337	2.4143	2.7435	1.9753	2.3317
Min	1.1943	1.7061	1.6004	1.5364	1.4266	1.6461	1.6004
Avg	2.0214	2.2229	2.0992	1.9793	2.1207	1.8052	1.8996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 407 / 33KV Atlanta Feeder (T/F

1) Feeder KV- 33 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.9209	3.9209	4.0889		3.8866	3.7758
2		3.5288	3.3265	3.9209		3.8866	3.7529
3		3.5288	3.3265	3.7529		3.7151	3.7529
4		3.5288	3.2922	3.5288		3.6008	3.7529
5		3.7529	3.8809	3.7529		3.5437	3.7529
6		4.1181	3.9209	4.0889		4.0009	4.0472
7		4.269	3.8409	4.313		4.2867	4.225
8	3.7146	3.7146	3.8009	4.0889		3.8866	3.6763
9		3.3265	3.2922	3.6763		3.5437	3.2922
10		3.3265	3.1893	3.4568	3.8866	3.8866	3.1276
11	3.095	3.2579	3.8009	10.6424	4.0009	3.638	3.2236
12	3.638	3.2236	3.8409	10.6424	4.1152	3.6763	3.2579
13	3.6763	3.2579	3.4568	10.6424	3.8866	3.638	3.2579
14	3.6763	3.2236	3.4568	10.751	4.1152	2.3594	3.8409
15	3.6763	3.8009	3.4568	11.7627	4.1152		3.8809
16	3.638	3.8009	3.6763	11.2026	4.1152	4.0055	3.7609
17	3.8009	3.7609	3.8009	11.2026	4.1152		3.7609
18	3.8009	3.7209	3.8409	10.6424	4.0581	3.6763	3.8009
19	4.3439	4.3439	4.5542		4.8583	4.5542	4.3439
20	4.4353	4.3439	4.5542		4.6868		4.3896
21	4.4353	4.4353	4.3896		4.5725		3.8809
22	4.269	3.8409			4.5725	4.4353	3.8409
23	3.8809	3.8009	4.269		4.4582	4.269	4.4353
24	3.9209	3.9209	3.8409	4.0889		4.0009	4.313
Max	4.4353	4.4353	4.5542	11.7627	4.8583	4.5542	4.4353
Min	3.095	3.2236	3.1893	3.4568	3.8866	2.3594	3.1276
Avg	3.8668	3.7395	3.7708	6.8550	4.2540	3.8245	3.7976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

BARSHI (U) S/DN.[090] BU 1384

Substation No/ Name :- 278003 / 220/110/33/11 KV BARSHI

Feeder No / Name : 408 / 33KV Atlanta Feeder (T/F

2) Feeder KV- 33 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.2624	5.0412	5.8282		6.0014	5.2092
2		5.2092	5.0926	5.4887		5.3155	5.0926
3		5.2624	4.9897	5.4887		5.3155	5.0926
4		5.2624	5.0412	5.4887		5.3155	5.0926
5		5.4887	5.0412	5.4887		5.3155	5.0926
6		5.4887	5.6584	5.4887		6.0014	5.2624
7		5.6584	5.0412	5.4332		6.0014	5.4887
8	5.0412	5.2624	5.0412	5.0412		5.3155	4.5268
9		5.2092	5.0412	5.0412		5.3155	4.0889
10		5.4332	4.9897	5.4332	5.7156	6.4015	4.0889
11	6.0985	5.487	6.0985	16.8039	6.5729	6.2003	4.9897
12	6.0985	5.9728	6.5535	17.364	6.6873		4.9897
13	5.5441	6.0985	6.1614	17.364	6.4015		5.0412
14	5.487	5.6013	5.6013	16.8039	6.0014	5.7105	4.5268
15	5.8711	5.6013	5.6013	16.2437	6.4586		4.5268
16	6.2649	6.1614	6.5535	18.4843	7.0302	6.2003	4.3896
17	6.2649	6.0357	7.041		6.6873		4.9383
18	6.2649	6.0357	7.041		6.8587	6.653	4.4353
19	6.3295	6.7215	6.8193		6.8587	6.2649	4.9897
20	5.7693	3.3265			6.4015		4.481
21	5.9934	6.1614	6.0545	17.364	6.0014		4.5268
22	5.7693	5.6013			5.7156	6.0545	5.0412
23	5.7693	5.6013	5.8282	17.9241	5.7156	5.7693	4.481
24	5.6584	5.6013	5.6013	5.8282		6.0014	5.8282
Max	6.3295	6.7215	7.041	18.4843	7.0302	6.653	5.8282
Min	5.0412	3.3265	4.9897	5.0412	5.7156	5.3155	4.0889
Avg	5.8816	5.5643	5.7242	10.4421	6.3647	5.8418	4.8425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 201 / 11 KV JEUR URBAN GAONTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5258	.5258	.5258	.6135	.5258	.5258	.5258
Max	.5258	.5258	.5258	.6135	.5258	.5258	.5258
Min	.5258	.5258	.5258	.6135	.5258	.5258	.5258
Avg	.5258	.5258	.5258	.6135	.5258	.5258	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 203 / 11 KV DAHIGAON-SHETFAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1753	.1753	.1753	.1753	.181	.0876	.181
Max	.1753	.1753	.1753	.1753	.181	.0876	.181
Min	.1753	.1753	.1753	.1753	.181	.0876	.181
Avg	.1753	.1753	.1753	.1753	.181	.0876	.181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 204 / 11 KV DAHIGAON W/S NON SHEDDABLE WATER SUPPLY AND
EXPRESS Feeder KV- 11 / UTILITY
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1753	.3506	.3544	.3544	.3506	.4382	.1753
Max	.1753	.3506	.3544	.3544	.3506	.4382	.1753
Min	.1753	.3506	.3544	.3544	.3506	.4382	.1753
Avg	.1753	.3506	.3544	.3544	.3506	.4382	.1753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO

J

Feeder No / Name : 205 / 11 KV PANGARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.7349	2.5692	2.5692	1.989	2.3739	.1562	2.753
Max	2.7349	2.5692	2.5692	1.989	2.3739	.1562	2.753
Min	2.7349	2.5692	2.5692	1.989	2.3739	.1562	2.753
Avg	2.7349	2.5692	2.5692	1.989	2.3739	.1562	2.753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274010 / 33/11 KV SUBSTATION JEUR (SO
JFeeder No / Name : 206 / 11 KV WANGI NO-2 AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.1562	.1562	.1562	.1562	.1562	.1562	2.2043
Max	.1562	.1562	.1562	.1562	.1562	.1562	2.2043
Min	.1562	.1562	.1562	.1562	.1562	.1562	2.2043
Avg	.1562	.1562	.1562	.1562	.1562	.1562	2.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 204 / 11 KV KAVITGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1829	2.4082	1.9052	1.829	1.9052	1.9814	1.9052
9	.1829	.1829	.1829	.1829	.1829	.1829	.1829
10	.1829	.7621	.1829	.1829	.1829	.1829	.1829
11	.1829	2.4082	.1829	.1829	.1829		.1829
12	.1829	.1829	.1829	.1829	.1829		
13	.1829	.1829	.1829	.1829			
14	.1829	.1829	.1829	.1829			
Max	.1829	2.4082	1.9052	1.829	1.9052	1.9814	1.9052
Min	.1829	.1829	.1829	.1829	.1829	.1829	.1829
Avg	.1829	.9014	.4289	.4181	.5274	.7824	.6135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 206 / 11 KV KANDAR VILLAGE AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.9509				1.829	
7		1.9814				1.9052	
8	.1829	1.9814	1.829	2.0576	1.9052	.1829	1.9052
9	.1829	.1829	.1829	.1829	.1829	.1829	.1829
10	.1829	.2134	.2134	.1829	.1829	.1829	.2134
11	.1829		.1829	.1829	.1829		
12	.2134		.1829	.1829	.1829		
13			.1829	.1829	.1829		
14			.1829	.1829	.1829		
Max	.2134	1.9814	1.829	2.0576	1.9052	1.9052	1.9052
Min	.1829	.1829	.1829	.1829	.1829	.1829	.1829
Avg	.189	1.262	.4224	.4507	.4289	.8566	.7672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 207 / 11 KV HARITKRANTI AG

PURELY LIS FEEDERS

EXPRESS F Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1829	.1219	.0762	.1219	.0762	.1219	.0762
9	.1219	.1219	.0762	.1219	.1219	.1219	.1219
10	.1219	.1219	.1219	.1219	.1219	.1219	
11				.1219			
Max	.1829	.1219	.1219	.1219	.1219	.1219	.1219
Min	.1219	.1219	.0762	.1219	.0762	.1219	.0762
Avg	.1422	.1219	.0914	.1219	.1067	.1219	.0991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274011 / 33/11 KV SUBSTATION KANDAR

(S

Feeder No / Name : 208 / 11 KV KANDAR BACKWATER AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.1829	
7						.1829	
8		1.829	1.829	1.829	2.2862	1.7528	1.9052
9		.1829	.1829	.1829	.1829	.1829	.1829
10	.1829	.1829	.2134	.1829	.1829	.2134	.2134
11	.2134	.1829	.1829	.1829	.1829		
12	.1829	.1829	.2134	.1829	.1829		
13		.1829	.2134	.2134	.1829		
14		.1829	.1829	.1829	.1219		
Max	.2134	1.829	1.829	1.829	2.2862	1.7528	1.9052
Min	.1829	.1829	.1829	.1829	.1219	.1829	.1829
Avg	.1931	.4181	.4311	.4224	.4747	.5030	.7672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KA

Feeder No / Name : 201 / 11 KV KEM GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.3206	.415
2		.3206	.3961
3		.3206	.3961
4		.3772	.3772
5		.4715	.3961
6		.5658	.415
7		.4715	.415
9	.3772		
10	.4904		
11	.3772		
12	.4715		
13	.4715		
14	.3772		
15	.3772		
16	.3772		
24		.3772	.4527
Max	.4904	.5658	.4527
Min	.3772	.3206	.3772
Avg	.4149	.4031	.4079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 202 / 11 KV WADSHIVANE AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		2.4291	2.905
2		2.672	3.1527
3		2.672	2.7794
4		2.672	3.1527
5		2.915	
6		2.7854	3.3404
7		.4287	3.3779
8		.3772	3.4155
9	.8573		
10	.7545		
11	.8573		
15	.7545		
16	.7716		
24		2.4291	2.7945
Max	.8573	2.915	3.4155
Min	.7545	.3772	2.7794
Avg	.7990	2.1534	3.1148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 203 / 11 KV MALAWADI AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.3429	.5883
2		.3429	.6067
3		.3506	.5885
4		.3944	.5883
5		.4287	.6381
6		.4287	.6756
7		.4287	.6381
8		.3944	.5603
9	.4287		
10	.4287		
11	2.672		
12	2.9959		
13	3.0312		
14	2.7206		
15	2.7199		
16	2.834		
24		.3429	.5699
Max	3.0312	.4287	.6756
Min	.4287	.3429	.5603
Avg	2.2289	.3838	.6060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274013 / 33/11 KV SUBSTATION KEM (SO
KAFeeder No / Name : 205 / 11 KV UPALWATE AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-MAR-18	25-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.4287	.3677
2		.4287	.3643
3		.463	.3677
4		.4287	.3677
5		.4287	.4133
6			.4321
7			.478
8		.4287	.4596
9	.4287		
10	.4287		
11	1.7814		
12	1.8785		
13	1.4575		
14	1.4575		
15	1.6004		
24		.4287	.3643
Max	1.8785	.463	.478
Min	.4287	.4287	.3643
Avg	1.2904	.4336	.4016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 201 / 11 KV UMRAD-KUMBHEJ

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /

OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Max	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Min	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.5144	.5144	.5144	.5144	.5144	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 205 / 11 KV BHAIRAVNATH NEW AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Max	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Min	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Avg	.0503	.0503	.0503	.0503	.0503	.0503	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 206 / 11 KV SOGAON NEW AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Max	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Min	.0503	.0503	.0503	.0503	.0503	.0503	.0503
Avg	.0503	.0503	.0503	.0503	.0503	.0503	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274145 / 33/11 KV SUBSTATION UMRAD

(SO

Feeder No / Name : 207 / 11 KV POPHALAJ-KUMBHEJ AG FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23					1.9281		
24	1.6766	1.8442	2.0119	1.8442		1.8442	2.0119
Max	1.6766	1.8442	2.0119	1.8442	1.9281	1.8442	2.0119
Min	1.6766	1.8442	2.0119	1.8442	1.9281	1.8442	2.0119
Avg	1.6766	1.8442	2.0119	1.8442	1.9281	1.8442	2.0119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 202 / 11 KV Dahigaon AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.2579	3.1722	3.0007	3.2579	3.2579	3.1722	.0857
Max	3.2579	3.1722	3.0007	3.2579	3.2579	3.1722	.0857
Min	3.2579	3.1722	3.0007	3.2579	3.2579	3.1722	.0857
Avg	3.2579	3.1722	3.0007	3.2579	3.2579	3.1722	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 203 / 11 KV SHETPHAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	.0857	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274163 / 33/11 KV SUSTATION DAHIGAON

(S

Feeder No / Name : 204 / 11 KV WANGI-2 AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0857	.0857	.0857	.0857	.0857	.0857	3.0007
Max	.0857	.0857	.0857	.0857	.0857	.0857	3.0007
Min	.0857	.0857	.0857	.0857	.0857	.0857	3.0007
Avg	.0857	.0857	.0857	.0857	.0857	.0857	3.0007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 202 / 11 KV YASHOBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.2589	.2298	.2246	.2452	.3069	.2932	.168
24	.2263	.2555	.2538	.2263		.3035	.2932
Max	.2589	.2555	.2538	.2452	.3069	.3035	.2932
Min	.2263	.2298	.2246	.2263	.3069	.2932	.168
Avg	.2426	.2427	.2392	.2358	.3069	.2984	.2306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 203 / 11 KV KOLDHARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.9431	.8745	.8916	1.0974	.9774	1.0802
Max	.9431	.8745	.8916	1.0974	.9774	1.0802
Min	.9431	.8745	.8916	1.0974	.9774	1.0802
Avg	.9431	.8745	.8916	1.0974	.9774	1.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274179 / 33/11 KV SUBSTATION

KAVITGAON

Feeder No / Name : 204 / 11 KV SANGAVI NO.2 AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	.0309	.0412	.0394	.036	.0463	.036	.0463
24	2.0576	1.9547	2.0576	2.0576		1.6804	1.7833
Max	2.0576	1.9547	2.0576	2.0576	.0463	1.6804	1.7833
Min	.0309	.0412	.0394	.036	.0463	.036	.0463
Avg	1.0443	.9980	1.0485	1.0468	.0463	.8582	.9148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274237 / 33/11 KV SHETFAL

Feeder No / Name : 202 / 11 KV MURMAI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0838	.0819	.0848	.0838	.0848	.0848	.0848
Max	.0838	.0819	.0848	.0838	.0848	.0848	.0848
Min	.0838	.0819	.0848	.0838	.0848	.0848	.0848
Avg	.0838	.0819	.0848	.0838	.0848	.0848	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274237 / 33/11 KV SHETFAL

Feeder No / Name : 204 / 11 KV KEDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.13	1.8442	1.6766	1.6956	2.0348	.081	.0848
Max	2.13	1.8442	1.6766	1.6956	2.0348	.081	.0848
Min	2.13	1.8442	1.6766	1.6956	2.0348	.081	.0848
Avg	2.13	1.8442	1.6766	1.6956	2.0348	.081	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 202 / 11 KV Ghoti I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1877	.244	.2259	.244	.2252	.2252	.1877
2	.1882	.244	.2259	.2447	.2259	.2252	.2252
3	1.126	.7255	.7529	.7506	.8069	1.126	1.126
4	1.689	.9383	.9412	1.4262	1.4262	1.5013	1.6941
5	1.8766	1.5951	1.126	1.6941	1.5013	1.689	
6	1.8823	1.7265	1.689	1.9146	1.689	1.689	1.8823
7	1.9951	2.0155	2.0643	1.9892	1.9765	1.9705	2.0706
8	1.8195	1.8391	2.0915	2.2895	2.1647	.9412	2.1082
9	1.9142	2.0643	1.9953	2.2056	2.1956	2.0329	1.8823
10	1.8391	1.8766	1.9517	2.0643	1.8766	1.2949	
11	.1819	.2766	.2627	.2001	.2824	.2023	
12	.1819	.2815	.2627	.1877	.2824	.2815	
13	.1877	.2183	.2824	.1901	.2815	.2824	
14	.2064	.2852	.2815	.1877	.2852	.2824	
15	.2252	.2282	.3003	.1882	.2852	.2824	
16	.2183	.3765	.3003	.3012	.2852	.2447	
17	.2911	.3803	.32	.2259	.2815	.2824	
18	.2547	.3753	.3378	.2447	.2824	.2824	
19	.3639	.3803	.4141	.4329	.3639	.3765	.3941
20	.3566	.3795	.3941	.3765	.3765	.3765	.3765
21	.3566	.3765	.3457	.3412	.3803	.3753	.3378
22	.319	.2824	.319	.3012	.2259	.3765	.32
23	.3003	.2815	.2815	.2815	.2259	.3423	.2815
24	.2252	.2729	.2252	.2635	.2635		.2824
Max	1.9951	2.0643	2.0915	2.2895	2.1956	2.0329	2.1082
Min	.1819	.2183	.2252	.1877	.2252	.2023	.1877
Avg	.7578	.7360	.7246	.7727	.7579	.7253	.9406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEJUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 203 / 11 KV Ghoti II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0751	.0751	.0941	.0753	.0938	.0941	.0751
2	.0728	.0751	.0951	.0761	.0938	.0938	.0751
3	1.0917	.5459	.5647	.563	.6568	.7529	.7506
4	1.6375	1.0353	.5647	.7694	1.0918	.9383	.9412
5	1.6375	1.3699	1.126	1.2949	1.3176	1.3176	1.3176
6	1.8195	1.5013	1.8823	1.445	1.5059	1.5059	1.5059
7	1.8195	1.9705	2.0643	1.5764	1.8766	1.689	1.689
8	1.8195	1.6514	2.0706	1.8203	1.9705	1.689	1.7828
9	1.9142	1.9329	1.7828	1.8259	1.8823	1.6753	1.764
10	1.764	1.8823	1.5812	1.5647	1.689	1.6941	
11	.0938	.0941	.0938	.0941		.0753	
12	.0751	.0938	.1126	.0938	.0938	.0751	
13	.0751	.0941	.1126	.0751	.0938	.0753	
14	.0751	.0907	.1126	.0751	.0938	.0753	
15	.0938	.0941	.0935	.0753	.0938	.0753	
16	.1088	.0951	.0941	.0951	.0938	.0843	
17	.1126	.0844	.1129	.0751	.0938	.0751	
18	.1126	.0941	.1126	.1126	.091	.0753	.0761
19	.1877	.1323	.1689	.1501	.1497	.1506	.1877
20	.1689	.1877	.1882	.1318	.1882	.1882	.1501
21	.1501	.1877	.1506	.1126		.1882	.1318
22	.1314	.1314	.1331	.1126		.1501	.1126
23	.1126	.1318	.1129	.0814	.0938	.0941	.1088
24	.0938	.0761	.0938	.0938	.0938	.0941	.0938
Max	1.9142	1.9705	2.0706	1.8259	1.9705	1.6941	1.7828
Min	.0728	.0751	.0935	.0751	.091	.0751	.0751
Avg	.6351	.5678	.5633	.5162	.6361	.5386	.6726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

JEUR SUB-DIVISION[757] BU 4757

Substation No/ Name :- 274242 / 33/11 KV GHOTI(SO SADE)

Feeder No / Name : 204 / 11 KV Pathurdi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0761	.4373	.4706	.4129	.3378	.5647	.4706
2	.0753	.4316	.3765	.4129	.3378	.5704	.4879
3	.0728	.4706	.3753	.4692	.3378	.563	.4929
4	.0751	.5271	.3791	.5818	.3378	.563	.5271
5	.1126	.6005	.4215	.64	.4504	.5647	.5271
6	.1501	.6756	.6011	.7131	.5255	.7529	.5647
7	.2252	.6193	.6005	.5818	.563	.7506	.563
8	.1877	.5067			.5095		.5647
9	.3753	.3753	.3941			.4518	.4706
10		.3803	.3941	.3003	.3378		
11	2.9651	2.2588		2.9651	2.8149	2.9364	
12	3.2653	3.0117	2.9553	3.1152	3.0422	3.0026	
13	3.2653	3.0117	2.8521	3.1527	3.1903	3.2	
14	3.0682	3.0026	2.8235	3.0494	3.1903	3.2	
15	3.1943	3.0117	3.0117	3.0401	3.1903	3.3592	
16	3.2188	3.0026	3.0026	3.0214	3.1903	2.7482	
17		3.0117	3.0026		3.1903	3.0026	
18	2.5522	3.0117	2.7008		3.1903	3.1812	3.1903
19	.4879		.5082	.2252	.563	.563	.4316
20	.4879	.563	.5459	.3232	.5647	.5647	.4504
21	.4692	.563	.5308	.3388	.5704	.5601	.4504
22	.4504	.5647	.4864	.3388	.563	.5647	.4706
23	.4518	.563	.4706	.3378	.4706	.4692	.4329
24	.0753	.4373	.563	.4504	.3388	.563	.4706
Max	3.2653	3.0117	3.0117	3.1527	3.1903	3.3592	3.1903
Min	.0728	.3753	.3753	.2252	.3378	.4518	.4316
Avg	1.1501	1.3495	1.2485	1.2235	1.3829	1.4862	.6603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 215 / DEVICHA MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5144
2	.5144	.5144	.5144	.5144	.5144	.5144	.5144
4	.5144	.5144	.5144	.5144	.5144	.5487	.5144
6	.6001	.6001	.6001	.6001	.6001	.6859	.6001
7						.6859	
8	.6001	.6859		.6859		.6001	.6001
10		.7621	.7621	.6001	.5716		
11		.6668	.7621	.6001	.6668		
12			.7049				
13		.7049	.7621	.5144	.5716		
14		.5716	.6668	.5144	.6668		
15			.5716	.5144	.7621		
16					.6344		
17	.5144	.6001	.5144	.5144	.5144		.6001
18		.6001	.5144	.5144	.6001		.6001
19	.6001	.5144	.5144	.6001	.6859	.6001	.6001
20			.5144	.6859	.6859	.6859	.6859
21	.5144			.6859		.6859	.6001
22	.5144	.5144	.5144	.6001	.6001	.6001	.6001
23	.5144	.5144	.5144	.6001	.5144	.6001	.6001
24	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Max	.6001	.7621	.7621	.6859	.7621	.6859	.6859
Min	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.5401	.5913	.5912	.5749	.6011	.6110	.5803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 216 / Bhavani Naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6001
2	.5144	.6001	.6001	.6001	.6001	.6001	.6001
4	.5144	.6001	.6516	.6516	.6001	.6001	.6001
6	.823	.7202	.7545	.7202	.8402	.7716	.7888
7						.8573	.8573
8	.703	.8059		.8916	.8059	.7545	.8573
10		.8954	1.0479	.823	.8954		
11		.8764	1.0479	.7888	.9526		
12		.9526	1.086		.8573		
13		.8573	.9526	.7716	.7621		
14		.7621	.7621	.7716	.7049		
15		.6668	.7049	.6859	.5716		
16					.5144		
17	.6344	.6516	.6001	.823	.5144		.823
18		.6516	.6859	.8573	.6001		.7716
19	.7202	.6859	.7716	.8573	.6859	.6859	.7716
20			.823	.9431	.9259	.9259	.823
21	.7716			.8573	.8573	.8916	.823
22	.6859	.6859	.7545	.823		.8059	.8059
23	.703	.6687	.7545	.7716	.7716	.7545	.7545
24	.6859	.6516	.6173	.6516	.6344		.6859
Max	.823	.9526	1.086	.9431	.9526	.9259	.8573
Min	.5144	.6001	.6001	.6001	.5144	.6001	.6001
Avg	.6756	.7333	.7884	.7817	.7275	.7647	.7544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 217 / Karmala Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7716
2	.6859	.7716	.7716	.6859	.6859	.6859	.6859
4	.6859	.7716	.7716	.6859	.6859	.6859	.6859
6	.9431	.8745	.9088	.8916	.8916	.9774	1.0117
7						1.0802	
8	1.046	.9602		1.0117	1.0974	1.0117	1.0631
10		1.086	1.105		1.1431		
11		1.1431	.9526		1.0479		
12		1.0479	1.086	.823	1.086		
13		1.086	.8573	.8573	1.1431		
14		.9526	.9526	.8573	1.0479		
15		.8954	.9907	.8916	.8573		
16					.8573		
17	.7716	.823	.8573	.8573	.6859		.8573
18		.8573	.9431	.9431	.6859		.9431
19	.8573	.9088	.8916	.9431	.6001	1.0288	1.0288
20			.9088	.9945		1.0631	1.0288
21	.8573		.9259	1.0288	1.1145	1.0631	1.0802
22	.8573	.1715	.9431	.9431		1.0802	1.0974
23	.1715	.1715	.9259	.9945	.9945	.9774	1.046
24	.8573	.8402	.8573	.823	.8573	.8745	.9088
Max	1.046	1.1431	1.105	1.0288	1.1431	1.0802	1.0974
Min	.1715	.1715	.7716	.6859	.6001	.6859	.6859
Avg	.7733	.8351	.9205	.8895	.9107	.9571	.9391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 218 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6859
2	.1715	.1715	.1715	.1715	.1715	.1715	.6859
4	.1715	.1715	.1715	.1715	.1715	.1715	.6859
6	.1715	.1715	.0857	.1715	.1715	.1715	.8573
10		.5716	.6668		.5716		
11		1.3336	1.7147		1.3336		
12		1.4289	1.4289				
13		1.7147	1.1431		1.5242		
14		1.6194	1.2384		1.6194		
15		1.9052	1.6194		1.7147		
16		1.8099					
17		1.5432					
19		.1715		.1715		.1715	
20				.1715		.1715	.1715
21				.1715		.1715	.1715
22			.1715			.1715	.1715
23			.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.0857	.6173
Max	.1715	1.9052	1.7147	.1715	1.7147	.1715	.8573
Min	.1715	.1715	.0857	.1715	.1715	.0857	.1715
Avg	.1715	.9834	.7295	.1715	.7621	.1620	.4687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 221 / 11KV PANDE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0857
2	.1715	.1715	.1715	.1715	.1715	.1715	.0857
4	.1715	.1715	.1715	.1715	.1715	.2572	.0857
6	.1715	.2572	.2572	.2572	.3429	.3429	.0857
7						.3429	
8	.2572	.3429			.3429	.4115	
9				.4115		.3429	
19				.0857	.0857	.0857	.0857
20				.0857		.0857	.0857
21				.0857	.0857	.0857	.0857
22	.0857	.0857	.0857	.0857		.0857	.0857
23	.0857	.0857	.0857	.0857	.0857	.0857	
24	.1715	.1778	.1715	.1715	.1715	.1715	.0857
Max	.2572	.3429	.2572	.4115	.3429	.4115	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1592	.1846	.1572	.1612	.1822	.2057	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 222 / 11 KV SANGOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				3.0007	3.3436		.1715
2	1.286	3.0864	2.7435	3.0864	.4287	2.4863	.1715
3				3.2579			
4		3.0864	3.2579		.4287	2.572	.1715
6		2.7435	3.4294		.4287	2.6578	.1715
7				3.0864		2.572	
8					.4287	2.6578	
9		3.4294				2.7435	
19				.1715		.1715	.1715
20				.1715		.1715	.1715
21				.1715		.1715	.1715
22	.1715	.1715	.1715	.1715	.1715	.1715	.1715
23	.1715	.1715	.1715	.1715	.1715	.1715	
24	2.572	3.0007	2.572	2.6578	2.915	2.1434	.1715
Max	2.572	3.4294	3.4294	3.2579	3.3436	2.7435	.1715
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	1.0503	2.2413	2.0576	1.5947	1.0396	1.5575	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 223 / 11 KV KARMALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6516
2	.5144	.5144	.5144	.5144	.5144	.5144	.5144
4	.6001	1.046	.5487	.6001	.5487	.5487	.5487
6	.8573		1.0288	.9431	1.0288	1.0288	1.0288
7						1.0631	
8	.7545	.823		.8916	.8916	.8573	
9		.7621	.9526		.8002	.7373	
10		.7621	.8573	.7716	.7621		
11			.9526		.8573		
12			1.0479		.9526		
13		.8573	.8573	.8573	1.0479		
14		.9526	1.1431	.8573	.9526		
15		1.1431	1.0479	.7716			
16		1.2384		.823			
17		1.0288	.8573	.8573			
18		.9431		.8573			
19			.8573	.8573		.8573	.9431
20				1.0288	1.0288	.8916	1.0288
21			.8573	.9431			1.0288
22	.7716	.6859	.8573		.6001		.9774
23	.6001	.6859	.6859		.5487	.583	.9774
24	.5144	.6001	.583	.6344	.6173	.5487	.5487
Max	.8573	1.2384	1.1431	1.0288	1.0479	1.0631	1.0288
Min	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.6589	.8602	.8530	.8139	.7965	.7630	.8248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274012 / 33/11 KV KARMALA S/S

Feeder No / Name : 224 / 11 KV MIDC KARMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0857
2	.0857	.0857	.0857	.0857	.0857	.0857	.0857
4	.0857	.0857	.0857	.0857	.0857	.0857	.0857
6	.0857	.0857	.0857	.0857	.0857	.0857	.0857
7						.0857	
8	.0857	.0857		.0857	.0857	.0857	.0857
9		.0953			.0953	.0857	
10		.0953	.0953	.0857	.0953		
11		.0953	.0953	.0857	.0953		
12		.0953	.0953	.0857	.0953		
13		.0953	.0953	.0857	.0953		
14		.0953	.0953		.0953		
15		.0953	.0953	.0857	.0953		
16		.0953		.0857			
17	.0857	.0857	.0857	.0857			.0857
18		.0857	.0857	.0857			.0857
19	.0857	.0857	.0857	.0857		.0857	.0857
20			.0857	.0857		.0857	.0857
21	.0857		.0857	.0857		.823	.0857
22	.0857	.0857	.0857	.823	.0857	.7202	.0857
23	.0857	.0857	.0857	.6859	.0857	.0857	.0857
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0953	.0953	.823	.0953	.823	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0900	.0891	.1600	.0905	.2000	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 230 / 11 KV MANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6578	3.3488	3.2579	3.6008	3.4294	3.1893	1.2757
2	2.7641	3.4551	3.3436	3.9438	3.4294	.7087	1.3289
3	2.9235	3.5437	3.4294	3.9095	3.9438	.9568	1.4175
4	3.3665	3.6323	3.7723	3.8066	3.4294	.9568	1.4529
5	4.0398	3.5437	3.858	3.9781	3.7723	.9568	1.5947
6	4.2347			3.9438			1.8427
7	3.9866	.7619	.6859	4.0295	3.5151	.5493	1.9136
8	4.0752	.12	.583	4.0638	.583	3.6145	1.5061
9	.0354	.0171	.0171	.0171	.0171	.0177	.3544
10	.0177		.0171	.0171	.0177	.0177	.443
11	1.3289		1.3032	1.3546	1.5769	1.2757	4.1993
12	.6024		1.3203	1.5947	1.6832	1.2403	
13	.6201	1.286	1.2689	1.5432	1.7187	1.2403	4.1284
14	.5847	1.5261	1.3203	1.406	1.7718	1.3466	
15	.6556	1.5432	1.4575	1.4575	1.7718	1.3466	
16	.6733	1.5947	1.4918	1.7718	1.7718	1.4175	
17	1.4175	1.6118	1.5261	1.8073	1.8073	1.5238	
18	1.5769	.2743	.1372		.5316	.1772	.4784
19	.2481	.4458	.4973	.443	.5847	.2481	.5138
20	.5316	.5316	.5658	.5316	.567	.3189	.5138
21	.5493	.4801	.5144	.6201	.567	.5316	.6556
22	.4961	.4801	.5487	.5487	.5316	.6024	.6201
23	.4784	.4458	.4801	.5316	.443	.6024	.6024
24	2.4983	1.5769	2.7435	3.0007	2.7435	3.0653	1.2757
Max	4.2347	3.6323	3.858	4.0638	3.9438	3.6145	4.1993
Min	.0177	.0171	.0171	.0171	.0171	.0177	.3544
Avg	1.6818	1.5110	1.4843	2.0835	1.7481	1.1263	1.3746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274014 / 33/11 KV MANGI S/S

Feeder No / Name : 241 / 11KV GFSS Mangi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1772	.3189	.4252	.3544	.1772	.4252
2	.1772	.1772	.2126	.4252	.2126	.1772	.5316
3	.2126	.1772	.3544	.4252	.2126	.1772	.567
4	.3189		.3898	.4961	.3544	.2658	.6379
5	.443	.6379	.4961	.6379	.6379	.7973	.7087
6	.6379	.6201	.6379	.7973	.8505		.8505
7	.7087	.6201		.7973	.8505	.8859	.6379
8	.5316	.6379	.4252	.6379	.6379	.443	.6201
9	.4075	.6379	.4252	.3721	.4252		.5316
10			.3189	.2658	.2658		.3189
11			.1063	.2126	.2658		.2658
12			.1063	.2126	.2481		
13		.2126	.1063	.1417	.1772	.0886	
14		.2126	.1063	.1772			
15		.2126	.1063	.2126			
16		.2658	.0532	.2126	.3544	.0886	
17	.3544	.4252	.1949	.3544	.443	.2126	
18	.5316	.4252	.3189	.4252	.6201	.2126	.4961
19	.7087	.443	.4784	.6379	.7087	.4252	.4961
20	.6733	.6379	.6379	.6201	.6201	.3544	.567
21	.6379	.4961	.5316	.6201	.6201	.3898	1.5061
22	.6379	.4961	.4961	.5316	.5493	.4252	.6379
23	.5316	.4252	.4607	.4961	.2658	.4252	.4961
24	.2126	.3544	.3544	.4252	.4252	.1772	.4252
Max	.7087	.6379	.6379	.7973	.8505	.8859	1.5061
Min	.1772	.1772	.0532	.1417	.1772	.0886	.2658
Avg	.4649	.4146	.3320	.4400	.4591	.3366	.5955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274015 / 33/11 KV MANJARGAON S/S

Feeder No / Name : 235 / 11KV MANJARGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18
HR	Load (MW)
1	.3048
2	.3048
3	.3048
4	.381
5	.381
6	.4191
7	.4191
8	.4191
9	.381
10	.2667
11	.3048
12	.3429
13	.3429
14	.3429
15	.2667
16	.2667
17	.3429
24	.3429
Max	.4191
Min	.2667
Avg	.3408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 235 / 11 KV KETTUR/PAREWADI POOL SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0305	.0305	.0305	.0305	.0305	.0457	1.5546
8	.0305	.0305	.0305		.0305	.0457	1.6918
12	.0305	.0305	.0305		.0305	.0305	
15					.0305		
16	1.7375	1.9204	1.9204		1.9204	.0305	
20	1.829	1.8747	1.829		1.8747	.0305	.0305
22	1.829						
24	.0305	.0305	.0305		.0305	.0457	.0305
Max	1.829	1.9204	1.9204	.0305	1.9204	.0457	1.6918
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.7882	.6529	.6452	.0305	.5639	.0381	.8269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 238 / 11 KV GFSS PAREWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6097	.5487	.5792	.6401	.5487	.6097	.6097
8	.6097	.6554	.6097		.6097	.6401	.6401
12	.4572	.4572	.4725		.4877		
13					.4268		
15					.4572		
16	.4572	.4572	.4572		.3658	.5487	.4877
20	.7011	.6554	.7621		.7316	.8535	.6859
22	.5639						
24	.503	.5487	.4572	.4877	.4572	.4877	.5335
Max	.7011	.6554	.7621	.6401	.7316	.8535	.6859
Min	.4572	.4572	.4572	.4877	.3658	.4877	.4877
Avg	.5574	.5538	.5563	.5639	.5106	.6279	.5914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274016 / 33/11 KV PAREWADI S/S

Feeder No / Name : 240 / 11KV POMALWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	3.9323	3.8866	3.9781	3.9018
13				3.9323
15	3.8104			3.9476
Max	3.9323	3.8866	3.9781	3.9476
Min	3.8104	3.8866	3.9781	3.9018
Avg	3.8714	3.8866	3.9781	3.9272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 253 / 11 KV JINTI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6097	.5335	.5335	.4572	.5335	.8383
2	.4572	.6859	.5335	.5335	.6097	.4572	.4572
3	.5335	.9907	.6097	.6097	.6859	.4572	.4572
4	.6097	1.1431	.7621	.7621	.7621	.6859	.6859
5	.6859		.9145	.9907	.9145	.9907	.8383
6	.8383		1.1431	1.0669	1.1431	1.1431	.9145
7			1.0669	1.2193		1.1431	
8	.7621		.9145	1.0669		.9907	.7621
9	.7621	.6859		.6097	.9907		.9145
10	.8383	.6097		.6097	.6859		
11	.5335			.5335	.5335		.6859
12	.4572		.3048	.4572	.4572		
13			.3048	.4572	.4572		
14		.4572		.4572	.4572		
15	.4572	.4572	.5335	.4572	.4572		
16	2.1338	2.2862	2.4387	2.5911	1.9814		
17	2.9721	3.5056	3.5056	2.7435	2.7435		
18	3.5056	3.3532	3.658	2.8197			
19	3.2007	3.1245	3.2007	2.5911			1.0669
20	2.9721	2.8959	2.5911	2.2862	2.8959		.9907
21	2.6673	2.5911	2.4387	2.0576	2.7435		.9145
22	2.5149	2.4387	2.1338	1.9814	2.4387		.8383
23	.6859	.5335	.6097	.6097	.5335		.6859
24	.5335	.6097	.4572	.5335	.4572	.5335	.6097
Max	3.5056	3.5056	3.658	2.8197	2.8959	1.1431	1.0669
Min	.4572	.4572	.3048	.4572	.4572	.4572	.4572
Avg	1.3609	1.5869	1.4327	1.1908	1.1203	.7705	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 254 / 11 KV KATRAJ AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1524
2	.1524	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.1524	.1524	.1524	.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1524	.1524	.1524
6	.1524	.1524	.1524	.1524	.1524	.1524	.1524
7	.1524	.1524	.1524	.1524	.1524	.1524	.1524
8	.7621	.7621	.8383		.7621	.8383	.1524
9	.7621	.9907	.9145	.9907	.9907	.9907	.1524
10	.7621	.9907	.9145		.9907	1.0669	.1524
11	.8383	1.0669	.9145	.9907	.9907	1.0669	.1524
12	.9907	.9907	.9907	.9145	.9907	1.0669	
13	.9907	.9907	.9907	.9907	.9907	1.0669	
14	.9907	.9907	.9907	.9907	.9907	1.0669	
15	.1524	.1524	.1524	.1524	.1524	.1524	
16	.1524	.1524		.1524	.1524	.1524	
17	.1524	.1524	.1524	.1524	.1524		
18	.1524	.1524	.1524	.1524			
19	.1524	.1524	.1524	.1524			.8383
20	.1524	.1524	.1524	.1524	.1524		.8383
21	.1524	.1524	.1524	.1524	.1524		.8383
22	.1524	.1524	.1524	.1524	.1524		.8383
23	.1524	.1524	.1524	.1524	.1524		.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	.9907	1.0669	.9907	.9907	.9907	1.0669	.8383
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.3620	.3906	.3910	.3395	.4087	.5110	.3138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 256 / 11 KV TAKALI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	.0762	.0762		.0762	.0762	.0762
7	.0762	.0762	.0762	.0762	.0762	.0762	.0762
8	.4572	.4572	.4572	.5335	.4572	.4572	.0762
9	.4572	.5335	.5335	.5335	.6097	.5335	.0762
10	.5335	.5335	.6097		.6097	.6097	.0762
11	.5335	.5335	.5335	.6097	.6097	.6097	.0762
12	.5335	.5335	.5335	.6097	.6097	.6097	
13	.5335	.5335	.6097	.6097	.6097	.4572	
14	.5335	.5335	.6097	.6097	.6097	.4572	
15	.0762	.0762	.0762	.0762	.0762	.0762	
16	.0762	.0762	.0762	.0762	.0762	.0762	
17	.0762	.0762	.0762	.0762	.0762	.0762	
18	.0762	.0762		.0762		.0762	
19	.0762	.0762	.0762			.0762	.6097
20	1.2955	.0762	.0762	.0762	.0762	.0762	.6097
21	.0762	.0762	.0762	.0762	.0762	.0762	.6097
22	.0762	.0762	.0762	.0762	.0762	.0762	.5335
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	1.2955	.5335	.6097	.6097	.6097	.6097	.6097
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.2540	.2064	.222	.2214	.2390	.2096	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 257 / 11KV RAMWADI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	.0762
6	.0762	1.2955	.0762	.0762	.0762	.0762	.0762
7	.0762	.0762	.0762	.0762	.0762	.0762	.0762
8	.0914	.0762	.0762		.0762	.0762	.0762
9	.0762	.0762	.0762	.0762	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11	.0762	.0762	.0762	.0762	.0762	.0762	.0762
12	.0762	.0762	.0762	.0762	.0762	.0762	
13	.0762	.0762	.0762	.0762	.0762	.0762	
14	.0762	.0762	.0762	.0762	.0762	.0762	
15	.0762	.0762	.0762		.0762	.0762	
16	1.1431	1.0669	1.3717		.9907	.9907	
17	1.3717	1.5242	1.5242	1.2955	1.2955	1.2955	
18	1.6004	1.5242	1.6004	1.3717		1.448	
19	1.6766	1.5242	1.5242	1.3717		1.5242	.0762
20	1.5242	1.448	1.3717	1.3717	1.2955	1.448	.0762
21	1.448	1.3717	1.3717	1.2955	1.2955	1.3717	.0762
22	1.3717	1.2955	1.2955	1.2193	1.2193	1.2955	.0762
23	.0762	.0762	.0762	.0762	.0762	1.2193	.0762
24	.0762	.0762	.0762	.0762	.0762		.0762
Max	1.6766	1.5242	1.6004	1.3717	1.2955	1.5242	.0762
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.4769	.5112	.4731	.4318	.3360	.5103	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274087 / 33/11 KV JINTI S/S

Feeder No / Name : 258 / 11KV NEMATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	1.6766	2.4387	1.9814	1.9814	1.9814	1.829
2	2.3624	1.829	2.5149	2.1338	2.2862	1.9814	1.829
3	2.4387	2.1338	2.5911	2.1338	2.5911	2.1338	1.9814
4	2.5911	2.5149	2.6673	2.4387	2.6673	2.2862	2.1338
5	2.7435	2.5149	2.5911	2.5911	2.7435	2.2862	2.2862
6	2.8197	2.5911	2.5911	2.7435	2.5911	2.4387	2.2862
7	2.8959	2.5911	2.5911	2.7435	2.4387	2.4387	2.2862
8	.1524	.1524	.1524	.1524	.1524	.1524	2.4387
9	.1524	.1524	.1524	.1524	.1524	.1524	2.4387
10	.1524	.1524	.1524	.1524	.1524	.1524	1.9814
11	.1524	.1524	.1524	.1524	.1524	.1524	1.9814
12	.1524	.1524	.1524	.1524	.1524	.1524	
13	.1524	.1524	.1524	.1524	.1524	.1524	
14	.1524	.1524	.1524	.1524	.1524	.1524	
15	.1524	.1524	.1524	.1524	.1524	.1524	
16	.1524	.1524	.1524	.1524	.1524	.1524	
17	.1524	.1524	.1524	.1524	.1524		
18	.1524	.1524	.1524	.1524			
19	.1524	.1524	.1524	.1524		.1524	.1524
20	.1524	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	2.1338	1.448	2.4387	1.9814	1.6766	1.829	1.6766
Max	2.8959	2.5911	2.6673	2.7435	2.7435	2.4387	2.4387
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.9431	.8224	.9526	.8827	.9595	.8868	1.6099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093] BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEAGAON S/S

Feeder No / Name : 201 / 11 KV POTEAGAON/TARATGAON SEPARATED AG FEEDERS HAVING SPECIAL
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1524	.1524	.1981	.1524	.1524	.1524	
16	1.9814	1.3108		2.1338	1.9814		
23	.1524	.1677	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	1.9814	1.3108	.1981	2.1338	1.9814	.1524	.1524
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.6097	.4458	.1676	.6478	.6097	.1524	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 202 / 11KV Borgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.1338	2.2862	1.829	2.1338	2.2862	2.2862	.1524
23	.1524	.1829	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	2.1338	2.2862	1.829	2.1338	2.2862	2.2862	.1524
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.8129	.8738	.7113	.8129	.8637	.8637	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 203 / 11KV Ghargaon/ Padali AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.5242	1.2346	1.2193	1.3717	1.3717	.1524
16		.0762					
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	.1524	1.5242	1.2346	1.2193	1.3717	1.3717	.1524
Min	.1524	.0762	.1524	.1524	.1524	.1524	.1524
Avg	.1524	.4763	.5131	.5080	.5588	.5588	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274124 / 33/11 KV POTEGAON S/S

Feeder No / Name : 242 / 11KV GFSS Potegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2134	.2439	.1829	.1829	.1829	.1372	.2286
16	.0762	.1524	.1067	.1372	.1219		.1372
23	.1981	.1524	.1219	.1372	.1829	.1524	.1238
24	.1524	.1981	.1372	.1219	.1372	.1829	.1524
Max	.2134	.2439	.1829	.1829	.1829	.1829	.2286
Min	.0762	.1524	.1067	.1219	.1219	.1372	.1238
Avg	.1600	.1867	.1372	.1448	.1562	.1575	.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 201 / 11KV WASHIMBE/BHAIRVNATH SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
1	.3963	.6859
2	.3963	.6859
3	.3963	.7621
4	.3658	.7621
5	.4572	.7621
6	.5182	.7621
7	.4877	.3353
11	.9145	
12	.9602	
13	.9755	
14	.9907	
15	.9907	
16	1.0059	
17	.945	
20	.3048	
21	.6859	
22	.6859	
23	.6859	
24	.4268	.7621
Max	1.0059	.7621
Min	.3048	.3353
Avg	.6626	.6897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 202 / 11KV Goyegaon AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.3717	1.5242	1.4937	1.5242	1.2955
2	1.5242			1.5242	1.4937	1.5546	1.3717
3	1.4784	2.0729		1.5242	1.4632	1.5699	1.3717
4	1.5089	2.0729		1.5242	1.5546	1.6766	1.448
5	1.5089	2.0729		1.5699	1.5851	1.6766	1.448
6	1.5242	2.1338		1.6004	1.6766	1.7071	1.5242
7	1.5394	2.1338		1.6918	1.6766		1.6309
8	1.4632	1.4022		1.6156	1.6766		1.4632
17							1.4327
18	.1219						
19	.1372						
20	.1829			.1829	.1829	.1524	.2134
21			.2134	.1829	.2134	.1524	.2286
22			.2134	.2439		.1524	.2286
23			.2743	.2743	.2743	.1524	.2286
24	.1524	.2743	.2439	.1219	.2743	.3353	.1219
Max	1.5394	2.1338	1.3717	1.6918	1.6766	1.7071	1.6309
Min	.1219	.2743	.2134	.1219	.1829	.1524	.1219
Avg	1.0428	1.7375	.4633	1.0446	1.1304	.9685	1.0005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 203 / 11KV WASHIMBE /NANGI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3658			
3				.5792	
4				.5487	
5		.4268		.6097	
6		.4572		.6097	
7		.4572			
11	2.2253				
12	2.5911		2.8197		
13	2.5606				
14	2.5606		2.8349		
15	2.6063		2.8349		
16	2.6216		2.8045		
17	2.652		2.774		
20	.2743		.6097		
21			.5792		
22	.3048				
23	.3048	.5182	.6097		.4268
24		.3353		.6097	
Max	2.652	.5182	2.8349	.6097	.4268
Min	.2743	.3353	.5792	.5487	.4268
Avg	1.8701	.4268	1.9833	.5914	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 204 / 11kv Jyotiba Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229		.6859		.5792	.7621
2	.2572	.2439	.6859	.4268	.5792	.7621
3			.6859	.4572	.5792	.7621
4	.2572		.7316	.4877	.5944	.7621
5	.2572	.3353	.7316	.4877	.6097	.7621
6	.2401	.3658	.6859	.5182	.6401	.7621
7	.2572	.3658	.2286	.3048		.3353
9	.2286					
11	1.6156			1.9814		
12	1.6766		2.2862	2.0729		
13	1.6766		2.3167	2.2558		
14	1.6918		2.3472	2.3624		
15	1.6461		2.3777	2.3624		
16	1.6461		2.3929	2.2862		
17	1.6613		2.3777	2.2558	2.1338	
19						.2286
20	.2743		.4572	.442	.3353	.2915
21			.4877	.5182	.6859	.3086
22	.3353			.5182	.6859	.3429
23	.3048		.4268	.5335	.7316	.3429
24	.2229	.2743	.6859	.4572	.5487	.8383
Max	1.6918	.3658	2.3929	2.3624	2.1338	.8383
Min	.2229	.2439	.2286	.3048	.3353	.2286
Avg	.8040	.3170	1.2113	1.1516	.7253	.5585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 205 / 11kv Washimbe gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.2743		.1524	.1715
2	.1886	.2439	.1829	.1677	.1524	.2058
3	.1715		.2134		.1829	.2058
4	.2058		.2134	.2439	.2134	.2401
5	.2401		.2743	.2743	.2896	.3086
6	.2915	.2743	.2896	.3658	.3353	.3429
7	.3429	.3048	.3353			.3772
8	.2915	.2439	.2743		.2591	.3429
9	.2134				.2134	.3086
10	.1829				.1981	.2401
11	.1829				.1524	
12	.1372				.1524	
13	.1372		.1372		.1524	
14	.1219		.1372		.1524	
15	.1219		.1524		.1524	
16	.1372		.1829		.1524	
17	.1524		.1829		.1524	.2229
18	.1829		.2134		.2134	.2915
19	.2134		.2134		.2591	.2743
20	.2439		.2134		.2439	.3258
21			.1829		.2134	.2915
22	.1829				.1829	.2572
23	.1829	.1829	.1677		.1524	.2229
24	.1715	.1677	.1524	.1677	.1829	.1715
Max	.3429	.3048	.3353	.3658	.3353	.3772
Min	.1219	.1677	.1372	.1677	.1524	.1715
Avg	.1943	.2363	.2102	.2439	.1961	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274171 / 33/11 KV WASHIMBE S/S

Feeder No / Name : 206 / Kettur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2193	1.3717		1.4937	1.1431
2	1.3717		1.448	1.448	1.4937	1.1431
3	1.3889	1.2955	1.448	1.4632	1.5394	1.1431
4	1.4232		1.448	1.4632	1.5394	1.2193
5	1.4232		1.4937	1.4937	1.5546	1.2193
6	1.4746	1.3413	1.4937	1.4632	1.5242	1.3108
7	1.4918	1.3717	1.5242			1.3413
8	1.4403	1.4022	1.4327		1.4022	.8535
17						1.3203
18	.061					
19	.061					
20	.0762		.061		.061	.0686
21			.061		.061	.0686
22	.0762				.061	.0857
23	.061		.0914		.061	.1029
24	.061	.061	.061		.061	.061
Max	1.4918	1.4022	1.5242	1.4937	1.5546	1.3413
Min	.061	.061	.061	1.448	.061	.061
Avg	.8416	1.1152	.9945	1.4663	.9044	.7915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 201 / 11 KV RAJURI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9755	1.4937	1.6495	1.3565	.4973		.3978
4	1.3565	1.7833	1.917	1.8724	.5304		.3353
6	2.1696	1.9616	2.1845	2.5149	.6554	1.0974	.431
8		2.3628	2.2142	2.5292	2.0995	1.7684	.8688
10	.3481	2.021	.3429	.4807	.3688	1.4148	.663
12		.3688	.1772	.6316	.5571	.4191	
14	.3978	.4641	.1629	.6154	.5636	.2743	
16	.4807	.4641	.1463	.6478	.663	.2401	
18	.4973	.3429		.6316	.663	.5636	.6554
20	.547	.4973	.4144	.5407	.7956	.6299	.8097
22	.4641	.5304	.4475	.5304	.7293	.7449	.8322
24	.3856	.4973	.4359	.3978	.5992	.5636	.5304
Max	2.1696	2.3628	2.2142	2.5292	2.0995	1.7684	.8688
Min	.3481	.3429	.1463	.3978	.3688	.2401	.3353
Avg	.7622	1.0656	.9175	1.0624	.7269	.7716	.6137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 202 / 11KV KORTI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0914	.1463	.1097	.0732	.1097	.1097	.1097
4	.128	.181	.1463	.1448	.1097	.1829	.128
6	.181	.2172	.2481	.1949	.2012	.2126	.1829
8	.1991	.2715	.128	.1772	.1829	.1646	.1991
10	.1629	.181	.1267	.1949	.1448	.1463	.1629
12	.1448	.1267	.1267	.1448	.1097	.1448	
14	.1267	.1448	.1097	.1448	.0914	.1267	
16		.1267	.1097	.1086	.0914	.1097	
18	.1991	.1448	.1267	.1448	.0914	.1097	.181
20	.2303	.1267	.1448	.1829	.2401	.1097	.2172
22	.181	.1646		.1463	.1463	.1463	.181
24	.1097	.128	.1097	.1097	.1097	.1097	.1097
Max	.2303	.2715	.2481	.1949	.2401	.2126	.2172
Min	.0914	.1267	.1097	.0732	.0914	.1097	.1097
Avg	.1595	.1633	.1351	.1472	.1357	.1394	.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274212 / 33/11Kv Korti Substation

Feeder No / Name : 203 / 11 KV GOREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1448	.1829	.2401	.1448	.1448	.1463	.7449
4	.1629	.2303			.1448	.1829	.8749
6	.181	.2658	.2743	.3189	.2915	.2481	1.3565
8	.3521	.3772	.2401	.3688	.2743	.2481	1.0364
10	.2126	.2401		.181	.181	.2126	.1463
12	1.7071			1.2793	1.0059	1.2041	
14	1.2041	1.3108	.7116	1.1126	.9374	1.1431	
16	1.0669	1.1584	.8688	1.0669	.9755	1.0517	
18	.1772	1.0364			.1463	.8697	.181
20	.2126	.1448	.1646	.2172	.2126	.197	.2172
22	.1991	.1629	.1991	.181	.1463	.1991	.1829
24	.1463	.181	.1629	.1629	.181	.1463	.1448
Max	1.7071	1.3108	.8688	1.2793	1.0059	1.2041	1.3565
Min	.1448	.1448	.1629	.1448	.1448	.1463	.1448
Avg	.4806	.4810	.3577	.5033	.3868	.4874	.5428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 201 / 11KV ZARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.9335		.8488			.9335	
8				.9709	1.1128		
9		.9431					
10							.7316
17	.4161						
18			.3475	.3978	.4938	.4572	
23	.4191	.4344	.1734		.4298	.4252	.4344
24	.5316	.4191	.4938	.5552	.3391	.543	.4163
Max	.9335	.9431	.8488	.9709	1.1128	.9335	.7316
Min	.4161	.4191	.1734	.3978	.3391	.4252	.4163
Avg	.5751	.5989	.4659	.6413	.5939	.5897	.5274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 202 / 11 KV KHADKEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							2.452
10					.2378		
11				3.0769		2.9569	
12		3.3981	3.2861				
13	3.1741						
18				.2772	3.1741		.2801
23	.2427	.2829	.1791		.3045	.2195	.3292
24	.1696	.2241	.2378	.1753	.2561	.2454	1.1088
Max	3.1741	3.3981	3.2861	3.0769	3.1741	2.9569	2.452
Min	.1696	.2241	.1791	.1753	.2378	.2195	.2801
Avg	1.1955	1.3017	1.2343	1.1765	.9931	1.1406	1.0425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KARMALA S/DN.[093]

BU 1376

Substation No/ Name :- 274220 / 33/11 KV ZARE SUBSTATION

Feeder No / Name : 203 / 11KV ZARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.3189
8				.2715			
9		.3921					
10	.4854					.4572	
11	.1478						.4066
12			.4251		.4706		
17				.4854			.156
18		.2241			.2172		
23	.2054	.1595	.1612		.1753	.1772	.1829
24	.1543	.1886	.1578	.1595	.1791	.156	.1578
Max	.4854	.3921	.4251	.4854	.4706	.4572	.4066
Min	.1478	.1595	.1578	.1595	.1753	.156	.156
Avg	.2482	.2411	.2480	.3055	.2606	.2635	.2444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 201 / CHOBE PIMPARI BOGDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2193	1.2498	1.1888	1.1279	1.1736	2.1186
2	1.1431	1.2346	1.2346	1.25	1.0974	1.1888	2.1033
3	1.2193	1.2651	1.2346	1.2193	1.1126	1.2041	2.1186
4	1.2193	1.2651	1.2498	1.2498	1.1279	1.2193	2.1186
5	1.2498	1.2803	1.2346	1.2803	1.1279	1.1888	2.0881
6	1.2498	1.326	1.2498	1.2041	2.1795	1.1888	2.0881
7	2.0881	2.1033	2.1795	2.21	2.1795	2.1643	.1372
8	2.0729	2.1795	2.2405	2.1948	2.0576	2.1186	.1067
9	2.0424	2.2253	2.1033	2.2405	2.0881	2.0729	
10		2.2405	2.1643	2.2253	2.1795	2.1948	
11		2.2862	2.2558	2.2253	2.1948	2.271	
12		2.1643	2.2253	2.2405	2.21	2.1491	
13	2.0271		2.2253	2.2253	2.1948	2.1643	
14	2.0424		2.21	2.2253	2.0881	2.1186	
15	.0914	.1524	.1677	.1677	.1524	.1981	
16	.0762	.1829	.1677	.1981	.1677	.1829	
17	.0914	.1677	.1829	.1981	.1981	.2134	
18	.1067		.1829	.1981	.2134	.2286	
19		.1524	.1829	.1981	.2286	.1981	1.0974
20	.1372	.1524	.1981	.1981	.2286	.2134	1.1888
21	.1524	.1524	.1981	.1829	.2286	.2134	1.3108
22	.0914	.1372	.0914	.1067	.1524	.1219	1.1888
23	1.1736	1.0059	1.1736	1.1736	1.1126	1.0059	2.1338
24	1.1431	1.2193	1.0822	1.2041	1.1431	1.1431	1.0364
Max	2.0881	2.2862	2.2558	2.2405	2.21	2.271	2.1338
Min	.0762	.1372	.0914	.1067	.1524	.1219	.1067
Avg	1.0280	1.1482	1.1952	1.2085	1.1996	1.1723	1.4882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 202 / 11KV Bogewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1677	.1372	.1524	.1829	.1372	.1372
2	.1524	.1829	.1372	.1524	.2439	.1372	.1524
3	.1524	.2286	.1219	.1829	.1981	.1677	.1677
4	.2439	.2286	.1372	.1981	.1981	.1677	.1829
5	.2439	.2286	.1524	.2134	.1981	.1829	.2134
6	.2591	.2286	.1829	.2134	.1981	.2134	.2286
7	.3048	.2286	.2286	.2134	.1981	.2591	1.9357
8	.2286	.2134	.2439	.2286	.1677	.2286	1.9204
9	.2134	.2134	.1829	.1829	.1677	.1981	1.6156
10		.1677	.1524	.1372	.1067	.1524	
11		.1524	.1219	.1372	.1219	.1067	
12		.1829	.1372	.1372		.1372	
13	.1524		.1372	.1372		.1219	
14	.2134	.2743	.2134	.1372	.2134	.2286	
15	2.3624	2.4996	2.3929	2.4387	2.1491	2.2558	
16	2.0881	2.5453	2.5149	2.5149	2.2558	2.5758	
17	2.21	2.4234	2.6216	2.5758	2.5301	2.5453	
18	2.4082	2.3472	2.4691	2.5453	2.3777	2.3472	
19		2.332	2.3472	2.2862	2.2558	2.3472	.2286
20	2.0576	2.2253	2.1795	2.1491	2.0881	2.0576	.2286
21	1.9662	2.1033	2.0576	1.9966	1.9814	1.9052	.1524
22	1.89	1.9662	1.9509	1.89	1.9204	1.9052	.1524
23	.1829	.1524	.1524	.1829	.181	.1219	.1524
24	.1524	.1524	.1524	.1372	.1524	.1524	.1219
Max	2.4082	2.5453	2.6216	2.5758	2.5301	2.5758	1.9357
Min	.1524	.1524	.1219	.1372	.1067	.1067	.1219
Avg	.8817	.9324	.8802	.8808	.9130	.8605	.5060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274155 / Chobe Pimpri

Feeder No / Name : 203 / GFSS chobepimpri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0181	.0181	.0181	.0181	.0181
2	.0181	.0181	.0181	.0181	.0181	.0175	.0181
3	.0181	.0181	.0181	.0181	.0181	.0181	.0181
4	.0181	.0181	.0181	.0181	.0181	.0181	.0181
5	.0181	.0181	.0181	.0181	.0181	.0181	.0181
6	.0181	.0181	.0181	.0181	.0181	.0181	.0181
7	.0181	.0181	.0181	.0181	.0181	.0181	.0181
8	.0181	.0181	.0181	.0181	.0181	.0152	.0181
9	.0181	.0181	.0181	.0145	.0181	.0152	.0181
10		.0145	.0109	.0175	.0175	.0145	
11		.0127	.0109	.0109	.0127	.0109	
12		.0109	.0109	.0109		.0109	
13	.0181		.0109	.0181		.0181	
14	.0109	.0109	.0109	.0109	.0127	.0181	
15	.0127	.0109	.0105	.0109	.0109	.0109	
16	.0109	.0109	.0109	.0109	.0181	.0109	
17	.0109	.0109	.0109	.0109	.0181	.0109	
18	.0109	.0109	.0109	.0109	.0181	.0181	
19		.0181	.0109	.0181	.0181	.0181	.0181
20	.0181	.0181	.0109	.0181	.0181	.0175	.0181
21	.0181	.0181	.0181	.0362	.0181	.0181	.0175
22	.0181	.0181	.0175	.0181	.0181	.0181	
23	.0181	.0181	.0181	.0181	.0181	.0181	.0181
24	.0181	.0181	.0181	.0181	.0181	.0181	.0181
Max	.0181	.0181	.0181	.0362	.0181	.0181	.0181
Min	.0109	.0109	.0105	.0109	.0109	.0109	.0175
Avg	.0164	.0158	.0148	.0166	.0173	.0162	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 201 / PADSALI AG.(Old Butashte) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.325	.2759	.2435
2	.3738	.2759	.2597
3	.39	.2759	.2922
4	.4388	.3193	.3084
5	.4875	.4058	.487
6	.52	.5701	.6168
7	.6013	.6493	.6006
8	.52	.5844	.5844
9	.455	.5152	.5032
10		.3571	.3246
11	2.0964	1.7693	1.6232
12	2.1289	2.1751	1.7369
13	1.9014	1.7856	1.7856
14	2.0477	1.7531	1.0551
15	1.8202	1.818	1.5258
16	2.0639	1.9803	
17	2.1289	2.094	
18	2.3077	2.1751	
19	.5363	.4383	
20	.585	.487	
21	.39	.3246	
22	.2925	.2922	
23	.2763	.2597	.2597
24	.26	.2597	.2597
Max	2.3077	2.1751	1.7856
Min	.26	.2597	.2435
Avg	.9977	.9100	.7333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 202 / DHORE WASTI AG FEEDER(OLD SEPARATED AG FEEDERS HAVING SPECIAL
LAUL Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1991	.183	.183
2	.2157	.1996	.183
3	.6638	.948	.9979
4	.9127	.9979	1.0811
5	1.1616	1.1643	1.5302
6	1.6926	1.4969	1.7963
7	2.1241	2.1289	2.2287
8	2.0411	2.1289	2.0624
9	2.0079	2.079	2.1622
10		1.763	
11	.1659	.1663	.1497
12	.1493	.1497	.1164
13	.1162	.1331	.1331
14	.1162	.1164	.1497
15	.1162	.1331	.1497
16	.1328		
17	.1493	.183	
18	.1493	.2329	
19	.3153	.3326	
20	.2987	.3659	
21	.2821	.2994	
22	.2157	.2495	
23	.1991	.1996	.1663
24	.1659	.1663	.1996
Max	2.1241	2.1289	2.2287
Min	.1162	.1164	.1164
Avg	.5909	.6877	.8306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 203 / GFSS Padsali

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.127	.1449	.1088
2	.127	.1268	
3	.1632	.1268	.1088
4	.1814	.1449	.127
5	.2177	.1812	.1814
6	.2177	.1993	.2358
7	.2358	.2355	.2358
8	.2177	.1993	.2177
9	.1995	.1631	.2177
10		.1449	.2177
11	.1632	.1449	.1451
12	.1451	.1087	.1632
13	.127	.1087	.1451
14	.1088	.1087	.1451
15	.1088	.1087	.127
16	.1451	.1087	.127
17	.1632	.1268	.1088
18	.1995	.1449	.1088
19	.2358	.1993	.1995
20	.2358	.2355	.1995
21	.2358	.2174	.1995
22	.2177	.1812	.1632
23	.1814	.1268	.127
24	.1451	.1449	.127
Max	.2358	.2355	.2358
Min	.1088	.1087	.1088
Avg	.1782	.1555	.1625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 204 / New BUTashte AG Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1604	.1456	.1444
2	.1925	.1618	.1604
3	.7219	.9705	.8342
4	.9625	1.1323	.8983
5	1.2031	1.3749	1.2031
6	1.524	1.5366	1.4919
7	1.7646	2.0219	1.7806
8	1.7646	1.941	1.6202
9	1.8448	1.941	1.7004
10		1.6175	1.6683
11	.1444	.2265	.1765
12	.1444	.1941	.1765
13	.1444	.1779	.1765
14	.1123	.1779	.1765
15	.1444	.1618	.2085
16	.1765	.1618	
17	.1604	.1618	
18	.1444	.2103	
19	.2406	.2588	
20	.2406	.2588	
21	.2406	.2588	
22	.2085	.2265	
23	.1765	.1618	.1925
24	.1444	.1451	.1604
Max	1.8448	2.0219	1.7806
Min	.1123	.1451	.1444
Avg	.5461	.6510	.7511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 205 / UJANI (M) AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.3812	.3493	.3315
2	.3978	.3659	.3315
3	.4144	.4158	.3481
4	.4475	.4491	.3812
5	.4973	.499	.4973
6	.5801	.6154	.5801
7	.663	.6653	.6464
8	.663	.632	.6133
9	.5801	.5655	.6464
10		.499	.5138
11	3.2653	3.3212	3.0001
12	3.315	2.8608	2.8509
13	3.1327	3.077	2.967
14	2.9338	3.0105	2.3205
15	3.1659	3.1934	2.9835
16	2.5692	2.9938	
17	3.083	3.1435	
18	3.0996		
19	.4807	.5322	
20	.4641	.5655	
21	.4475	.5322	
22	.4144	.4657	
23	.3812	.3493	.3812
24	.3812	.3326	.3481
Max	3.315	3.3212	3.0001
Min	.3812	.3326	.3315
Avg	1.3808	1.2797	1.1612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274167 / 33/11K V PADSALI S/STn.

Feeder No / Name : 206 / NEW LAUL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	2.1476	2.3012	2.073
2	2.2272	2.2218	2.0412
3	.3659	.2222	.2551
4	.3977	.2539	.2551
5	.4773	.3174	.3827
6	.5568	.4602	.4784
7	.6363	.6031	.6379
8	.5727	.5713	.6538
9	.4773	.6031	.5741
10		.5396	.4146
11	.3341	.5237	.4306
12	.35	.5396	.3349
13	.3659	.492	.3189
14	.3659	.365	.2711
15	.3977	.3491	.3987
16	.3977		
17	.4295	.4602	
18	.4613	.6031	
19	2.2431	2.9995	
20	2.5931	2.9201	
21	2.7044		
22	2.0363	2.3012	
23	2.1476	2.1266	3.0298
24	2.0681	2.3805	2.1049
Max	2.7044	2.9995	3.0298
Min	.3341	.2222	.2551
Avg	1.0762	1.0979	.8620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALKHUNTE AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575	1.7194	1.7194	1.7737	1.448	1.448	1.3756
2	1.4299	1.7194	1.7194	1.7194	1.6108	1.6289	1.3575
3	2.0995	1.8099	1.6289	1.7194	1.9909	2.1176	1.4118
4	2.2624	2.1719	2.1719	2.3891	2.2081	2.5339	1.4842
5	2.5158	2.7149	3.0769	2.8959	2.5158	2.9864	1.5927
6	3.0769	3.1674	3.2579	3.1131	2.9864	3.2579	1.647
7	3.6018	3.819	3.8009	3.7647	3.7104	3.4027	1.9547
8	3.4027	3.4027	3.2579	3.4027	3.1131	3.3303	1.7918
9							3.6742
17	2.1357	2.1719	2.1719	2.0271	2.2443	2.0452	
18	2.1357	2.1719	2.2262	2.2497	2.19	2.1538	
19		1.9909	2.1357	1.9547	2.009	2.0995	
20	1.7737	1.6289	1.8099	1.8099	1.9185	2.0119	.543
21	1.7556	1.5384	1.7918	1.6461	1.8461	1.8642	.4887
22	1.6651	1.5384	1.6289	1.7194	1.7737	1.6651	.4525
23	1.6289	1.3575	1.5927	1.4842	1.6651	1.5565	.4525
24	1.4118	1.5384	1.3575	1.5565	1.4118	1.5746	1.4299
Max	3.6018	3.819	3.8009	3.7647	3.7104	3.4027	3.6742
Min	1.3575	1.3575	1.3575	1.4842	1.4118	1.448	.4525
Avg	2.1502	2.1538	2.2092	2.2016	2.1651	2.2298	1.4040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 202 / 11 KV AMBAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1214	.12	.3772	.3086	.3429	.3429	1.0288
2	.12	.12	.3772	.3772	.3429	.3429	.9431
3	.1543	.1543	.3772	.4287	.3772	.3429	.9945
4	.2058	.2058	.3772	.5144	.463	.5487	1.0288
5	.2572	.2401	.4287	.6173	.5658	.6516	1.17
6	.2915	.2743	.4287	.6859	.6687	.7202	1.2548
7							1.5581
8							1.4922
9	2.8841	3.2526	2.5149	2.5819	2.6852	2.7846	
10		2.9835	2.9172	2.5857	2.5526	2.8509	
11		2.8502	2.8509	2.4863	2.5434	2.8509	
12		2.8826	2.7515	2.6023	2.4034	2.7183	
13	3.0178	2.6825	2.7183	2.42	2.3205	2.5819	
14	3.3482	2.652	2.6189	2.304	2.2708	2.5987	
15	2.8509	2.4863	2.5526	2.1548	2.3205	2.6155	
16	2.9673	2.8178	2.6155		2.5194	2.5819	
17	1.1869	1.5261	1.6956		1.5261	1.4582	
18	1.3748	1.5261	1.7436	1.5261	1.5939	1.56	
19		1.4413	1.5939	1.5912	1.4752	1.5592	3.1855
20	1.2071	1.326	1.4922	1.56	1.4582	1.4922	2.8178
21	1.1869	1.2717	1.2887	1.4918	1.3565	1.1869	2.652
22	1.0174	1.1869	1.1869	1.3717	1.2548	1.0631	2.5149
23	.9835	1.1736	1.1317	1.2209	1.1869	1.0288	2.3205
24	1.0974	.9088	1.0174	.9945	1.1361	1.1191	1.0288
Max	3.3482	3.2526	2.9172	2.6023	2.6852	2.8509	3.1855
Min	.12	.12	.3772	.3086	.3429	.3429	.9431
Avg	1.3485	1.5492	1.5935	1.4912	1.5165	1.5909	1.7136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274188 / 33/11 KV KURDU SUBSTATION

Feeder No / Name : 203 / GFSS KURDU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3944	.3429	.4287	.3772	.3258	.4115
2	.3944	.3944	.3429	.3429	.3772	.3258	.4115
3	.4287	.4287	.3429	.3429	.3944	.3429	.4458
4	.5144	.5144	.4115	.4287	.463	.3772	.5144
5	.5658	.5658	.5144	.5144	.5487	.3772	.6001
6	.6859	.6516	.6001	.6001	.6516	.4287	.6687
8	.5487	.6001	.5144		.4458	.3429	.5658
9	.6344	.4801	.5658	.583	.5487	.463	.6001
10		.6001	.6001	.583	.5487	.4458	.583
11		.6001	.4973	.5144	.4801	.5144	.5144
12		.4458	.3429	.463	.4287	.463	.4115
13	.4287	.4287	.3429	.4287	.3601	.4801	
14	.4287	.4115	.3772	.3772	.3772	.4115	
15	.3944	.3772	.3772	.3772	.4115	.3429	
16		.3772	.3772	.3944	.4287	.3258	
17	.463	.3772	.3429	.4287	.4115	.3944	
18	.5144	.4287	.5144	.5144	.4458	.4115	.4801
19		.5144	.6516	.583	.3258	.5658	.6859
20	.6516	.6516	.6344	.583	.5144	.6001	.7202
21	.6173	.6516	.6173	.5487	.4801	.6859	.6516
22	.5144	.6001	.6516	.5487	.4287	.583	.6001
23	.5144	.5144	.6001	.463	.3944	.5144	.6001
24	.3944	.3944	.4287	.5144	.4287	.3258	.4458
Max	.6859	.6516	.6516	.6001	.6516	.6859	.7202
Min	.3944	.3772	.3429	.3429	.3258	.3258	.4115
Avg	.5049	.4958	.4779	.4801	.4466	.4369	.5506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVLAS S/STN

Feeder No / Name : 202 / Dhavlas Bogda Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.034	.034	.0509	.0509	.034	.0509
2	.034	.034	.0679	.0509	.034	.0509
3	.0509	.034	.0679	.0509	.034	.0509
4	.0509	.034	.0509	.0509	.0509	.0509
5	.0509	.034	.034	.034	.034	
6	.034	.034	.0509	.034	.034	.0509
7	.034	.0509	.0679	.034	.034	.0509
8		.0509	.0509	.017	.0509	.0509
9		.0509	.034	.034	.0509	.0679
10		2.4444	2.2747	2.3256	2.4105	2.1972
11		2.5293		2.4275	2.4784	2.4614
12		2.6312	2.4444	2.4784	2.5972	2.6482
13	2.4614	2.4954	2.4275	2.5123		2.3426
14	2.4954	2.5463	2.4954	2.5972	2.4954	2.3426
15	2.4954	2.5803	2.4614	.017	2.4954	2.5803
16	2.4105	2.6991	2.5123	2.5463	2.5463	2.5293
17	2.4444		2.4614	2.5123	2.4954	2.4527
18	.034	.0679	.0509	.0509	2.5038	.0509
19		2.1728	.0509	.0509	.1019	.0509
20	.0509	.0679		.0509	.0509	.0509
21	.034	.0679	.0509	.0509	.0509	.0509
22	.034	.0509	.034	.0849	.0509	.0509
23	.034	.0509	.0679	.0679	.0495	.0679
24	.034	.034	.0509	.034	.034	.0509
Max	2.4954	2.6991	2.5123	2.5972	2.5972	2.6482
Min	.034	.034	.034	.017	.034	.0509
Avg	.7120	.9041	.8117	.7568	.9007	.8849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274223 / DHAVLAS S/STN

Feeder No / Name : 203 / jhakale-Bhogewadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5014	1.7654	1.9634	1.4354	1.4354
2	1.5344	1.9964	2.1284	1.4684	1.6169
3	1.5509	2.1284	2.2439	1.4519	1.6334
4	1.6994	2.1449	2.4584	1.4519	1.8479
5	1.7324	2.2274	2.7718	1.6334	2.0624
6	2.0459	2.2934	2.8048	2.0129	3.9268
7		2.3429	2.9038	2.4749	2.4419
8	2.1944	2.5079	2.8378	2.7058	2.6563
9	2.3429	2.7718	2.6728	1.7819	2.3429
10		.198	.2145	.198	.198
11		.1815		.2145	.132
12		.165	.198	.198	
13		.165	.198	.231	.2805
14	.1815	.198	.198	.198	.297
15	.2145	.2145	.165	.231	.2805
16	.099	.231	.165	.198	.297
17	.1815		.2145	.2145	.2805
18		.2475	.165	.2475	.231
19		.264	.297	.198	.3135
20	.3135	.297	.3135	.231	.33
21	.264	.3135	.2805	.231	.2805
22	.231	.2805	.2475	.231	.297
23	.231	.297	.2145	.198	.3135
24	1.3034	1.2704	1.3859	1.4189	1.3859
Max	2.3429	2.7718	2.9038	2.7058	3.9268
Min	.099	.165	.165	.198	.132
Avg	1.0365	1.0653	1.1757	.8690	1.0818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 201 / MAHADEVWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1524	.1715	.1524	.2286	3.3913
2	.1143	.1524	.1524	.0953	.1524	.2286	2.191
3	.1143	.1905	.1524		.1334	.1905	2.4768
4	.1524	.3048	.3429	.1143	.1715	.2096	2.4768
5		.3429	.2286	.1334	.1715	.2096	2.5149
6	.2286	.381	.2477	.1334	.1905	.2286	2.553
7	.3048	.4001	.3048	.1905	.3048		.2286
8	.2858	.3429	.3239	.2096	.1524	.3239	
9		.2286	.2667	.1334	.1143	.2667	
10		.2667	.3048	.0953	.1334	.2667	.1905
11		.2477		.0953	.1524	.2667	.1905
12		.2477		.0762	.1524	.1905	
13		.2477	.1524	.0762	.1524	.1715	
14	.1143	.1905	.1143	.1334	.1524	.1715	
15	2.6482		2.7435	1.7147	2.7054		
16	2.4958	2.5911	2.6292	2.0957	2.7244	2.7244	
17	2.572	2.7435	2.8006	2.1529	2.7244	2.8387	
18	2.7625		2.8387	2.572	2.7435	2.8006	
19		2.8197	2.7625	2.7816	2.7816	2.8578	.2858
20	.2667	2.6673	2.7625	2.7625	3.3532	2.7625	.3239
21	2.553	2.5911	2.7816	2.7435	2.7625	2.6292	.3048
22	2.4387	2.5149	2.7816	2.6863	2.7625	2.6101	.2477
23	2.4768	.2286	.2096		.2286	.2286	2.6482
24	.1143	.1143	.1905	.1715	.1715	.2286	.1715
Max	2.7625	2.8197	2.8387	2.7816	3.3532	2.8578	3.3913
Min	.1143	.1143	.1143	.0762	.1143	.1715	.1715
Avg	1.1622	.9058	1.1474	.9699	1.0518	1.0288	1.3464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274224 / BARLONI S/STN

Feeder No / Name : 203 / Bandhara Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.934	2.4768	2.8197		3.1626		.0953
2	2.9721	2.4768	2.7816		2.9721	.1715	.0953
3	2.9721	2.5149	2.7816		1.3336	.1715	.0762
4	3.0102	2.5149	2.8578		3.2769	.1334	
5	3.0102	2.5339	2.8959		3.315	.1143	.0762
6	3.0102	2.5149	3.0102		3.3722	.1143	.0762
7	.1143	.1143	.1143		.1143		3.7342
8	.1143	.0953	.1143		.0762		
9					.1143		
10					.1143		3.315
11					.0953		3.5818
13							2.8578
15	.0762				.1143		
16	.0762				.0953		
17	.0953	.0762			.0762	.0953	
18	.0762	.0762	.0762		.0762	.0762	
19		.0762	.0953		.1334	.1143	.1143
20	.0762	.0762	.0953		.1334	.0762	.1143
21	.0953		.0953		.1143	.0953	.1143
22	.0762		.0762		.0953	.1143	.1143
23	.0762	2.9721	2.572		3.5056	3.4294	.0762
24	2.8959	2.4006	2.934	2.6863	3.2198	3.6008	3.6961
Max	3.0102	2.9721	3.0102	2.6863	3.5056	3.6008	3.7342
Min	.0762	.0762	.0762	2.6863	.0762	.0762	.0762
Avg	1.2754	1.4942	1.5546	2.6863	1.2148	.6390	1.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / GFSS Tandulwadi

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1474
2					.1474
3					.1474
4			.0737		.1842
5	.0734		.1474	.1646	.2211
6	.132		.1474	.2012	.2027
7	.1907	.3018	.2579	.2378	.2395
8	.176	.2641	.2579	.1829	.2027
9	.1467	.1886	.2211	.1829	.1474
10		.1132	.1658	.1463	.0737
11	.132	.1132	.1474	.1463	.1474
12	.1027	.1132	.1474	.1463	.1474
13	.1027	.1509	.1474	.0732	.1105
14	.1027	.0754	.1658	.0732	.1105
15	.1027	.0754	.1658	.0732	
16	.1027	.0754	.1658	.1829	
17	.1174	.1509	.1474	.1463	
18	.1174		.1105	.1463	
19	.132	.1509	.1658	.1463	.1474
20	.132	.0754	.2211	.1829	.1842
21	.1174	.0754	.1658	.2561	.1842
22	.1174		.1474	.2561	.1474
23	.1174		.129	.1463	.1105
24					.1105
Max	.1907	.3018	.2579	.2561	.2395
Min	.0734	.0754	.0737	.0732	.0737
Avg	.1231	.1374	.1649	.1627	.1557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / Ridhore Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	.7095	.8488	.8488	.7914
2	1.448	.7095	.9054	.7922	.7537
3	1.448	.7095	.9054	.7922	.7914
4	1.467	.7095	.8299	.811	.7914
5	1.4861	.6908	.7922	.8299	.8102
6	1.5242	.6908	.8488	.8299	.8102
7	1.5623	.6722	.679	.8676	.8102
11		.1494			
14		.1494			
22	1.3336	.7655	.7922	.7545	1.4509
23	1.3717	.7842	.8299	.7733	1.5639
24	1.4289	.7095	.8488	.8676	.7914
Max	1.5623	.7842	.9054	.8676	1.5639
Min	1.3336	.1494	.679	.7545	.7537
Avg	1.4499	.6208	.8280	.8167	.9365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

KURDUWADI S/DN.[092] BU 1368

Substation No/ Name :- 274240 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / Tandulwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.2855		.1903
2	.2477		.2474		.1523
3	.2477		.2284		.1523
4	.2477		.2284		.1903
5	.2477		.2284	.1523	.1903
6	.2286		.2284	.1523	.1903
7	.2286		.2284	.1523	.1903
8	.2477		.3426	.1523	.1903
9	.2286	.2474	.3426	.1523	.1903
10		.2474	2.3791	1.6939	2.322
11	2.0957	.2474	2.303	1.8843	.1903
12	2.4006		2.3601	2.284	.1903
13	2.4196		2.284	2.322	.1903
14	2.4768	.1903	2.2269	2.3601	.1523
15	2.5149	.2474	2.2459	2.4743	.2284
16	2.4768	.2474	2.284	2.6836	.3236
17	2.3624	.1713	2.4362	2.6075	.3426
18	.2286		.2474		.3807
19	.2286	.2284	.2474	.1903	.3807
20	.1905	.2284	.1903	.1903	.3616
21	.1905	.2284	.1523	.1903	.2284
22	.1905	.3045	.1523	.1903	.1903
23	.1905	.3045	.1142	.1903	.1523
24	.2477		.3045		.1903
Max	2.5149	.3045	2.4362	2.6836	2.322
Min	.1905	.1713	.1142	.1523	.1523
Avg	.8863	.2411	.9287	1.1124	.3109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 201 / Nimgaon

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0686	.12	.1715	.1886	.2058	.8916
2	.0514	.0514	.12	.1715	.1715	.2058	.9088
3	.0514	.0514	.12	.1715	.1715	.2058	.9259
4	.0514	.0514	.1372	.1715	.1715	.2229	.9431
5	.0686	.0514	.1372	.1886	.1886	.2401	.9945
6	.0857	.1029	.1715	.2058	.1886	.2572	1.2346
7	.1029	.0686	.1886	.2058	.1543	.2572	1.3717
8	.0686	.0686	.1543	.1543	.1543	.2058	1.2346
9	.0686	.0514	.1372	.1543	.1543	.2572	1.0974
10		.1715	1.166	.9945	1.0136	.9259	.2058
11	.3086	.2058	1.6461	1.286	1.286	1.286	.1543
12	.3258	.2743	1.6975	1.2003	1.4232	1.4746	
13	.3086	.2572	1.7318	1.7833	1.5089	1.6289	
14	.2401	.2915	1.6975	1.7318	1.2003	1.5432	
15	.2743	.3086	1.7318	1.749	1.3375	1.1488	
16	.2915	1.406	1.6804	1.7833	1.5775	1.4403	
17	.3086	1.5432	1.6975	1.5432	1.5432	1.5775	
18	.0686	.1715	.1715	.1715	.2229	.3086	.2743
19	.0686	.1543	.2229	.2058	.2915	.3086	.2915
20	.0857	.1886	.2401	.2229	.2743	.3258	.3086
21	.12	.2058	.2058	.2572	.2743	.2915	.3086
22	.1029	.1886	.1886	.2401	.2572	.2743	.3086
23	.0857	.1543	.1715	.1486	.2401	.2229	.2915
24	.0686	.0686	.1372	.1543	.2058	.2058	.8573
Max	.3258	1.5432	1.7318	1.7833	1.5775	1.6289	1.3717
Min	.0514	.0514	.12	.1486	.1543	.2058	.1543
Avg	.1416	.2565	.6530	.6278	.5916	.6259	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 202 / MADHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.4287	.5144	.6001	.5144	.5316
2	.5144	.4801	.3944	.5144	.583	.4801	.5316
3	.5144	.5144	.3772	.5144	.583	.4801	.5487
4	.5144	.5144	.3772	.5144	.583	.5144	.5658
5	.5144	.5487	.4115	.5144	.5658	.5487	.583
6	.5144	.5487	.4973	.5658	.583	.6001	.6001
7	.583	.5487	.5658	.583	.6516	.703	.6344
8	.5658	.5487	.5487	.5658	.5658	.6001	.6173
9	.463	.463	.4801	.5487		.6001	.5487
10		.5316	.4973	.583		.4973	.6001
11	.463	.583	.463	.6001	.6859	.5316	.5658
12	.5658	.6001	.5316	.6344	.6859	.6344	.5487
13	.6001	.6173	.5487	.583	.12	.6173	
14	.6173	.6173	.5144	.6001	.6173	.6344	
15	.6001	.6173	.5487	.6001	.6516	.6516	
16	.583	.6344	.583	.6344	.6344	.6173	
17	.6173	.6516	.5658	.6516	.6859	.6516	
18	.6173	.6001	.6173	.6859	.6859	.7202	.8745
19	.6344	.7373	.7545	.7202	.823	.7545	.823
20	.6516	.7202	.703	.7888	.8059	.7888	.7888
21	.7202	.6687	.6344	.7373	.7202	.7373	.7716
22	.7373	.5658	.583	.7545	.703	.6859	.6859
23	.6001	.5144	.5487	.6687	.6173	.583	.6516
24	.4801	.4458	.4458	.4801		.5316	.5316
Max	.7373	.7373	.7545	.7888	.823	.7888	.8745
Min	.463	.4287	.3772	.4801	.12	.4801	.5316
Avg	.5733	.5708	.5258	.6066	.6263	.6116	.6317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 203 / JADHAVWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.3717	.9945	.9431	1.4575	1.2346	.2915
2	1.286	1.4575	1.0288	1.0288	1.6118	1.286	.2915
3	1.4575	1.5432	1.166	1.1145	1.7661	1.4232	.3086
4	1.6289	1.6289	1.3546	1.4575	1.8004	1.5432	.3086
5	1.8004	1.7147	1.6289	1.9719	1.8519	1.6804	.3258
6	2.2291	1.8861	1.8861	2.1776	2.1091	1.989	.3429
7	2.5206	2.5377	2.4863	2.572	2.8807	2.4177	.463
8	2.2634	2.7263	2.4863	2.5377	2.5206	2.4177	.4115
9	2.3663	2.4863	1.9376	2.7263	2.332	2.5377	.2915
10		.2572	.2915	.2743	.2572	.3086	.6001
11	.3086	.2572	.2743	.2915	.2743	.3086	2.4177
12	.2743	.2572	.3086	.3086	.2743	.2743	
13	.2743	.2915	.3258	.2915	.2915	.2915	
14	.2743	.3429	.3258	.2743	.2915	.3086	
15	.2915	.2572	.2743	.2915	.3429	.3258	
16	.3086	.2743	.2915	.3086	.3429	.2743	
17	.3086	.2915	.3429	.2915	.3772	.3086	
18	.3086	.2915	.3429	.2743	.3429	.3429	1.9719
19	.3086	.3944	.4115	.3086	.3772	.4458	.3429
20	.5658	.4287	.3601	.3429	.4287	.3944	.3944
21	.4115	.3429	.3429	.3944	.3429	.3772	.4287
22	.4115	.3086	.3258	.4115	.3086	.3429	.4115
23	.3601	.2572	.3086	.3429	.2743	.3258	.3944
24	.9259	1.2003	.9088	.8916	.6516	.9945	.3086
Max	2.5206	2.7263	2.4863	2.7263	2.8807	2.5377	2.4177
Min	.2743	.2572	.2743	.2743	.2572	.2743	.2915
Avg	.9527	.9502	.8502	.9095	.9795	.9231	.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274022 / 33/11KV MADHA SUBSTATION

Feeder No / Name : 204 / chincholi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2572	.2572	.3429	.3429	.0343
2	.5144	.4287	.2572	.3429	.3429	.3429	.0514
3	.6001	.4287	.3086	.4287	.4287	.3429	.0514
4	.6859	.6001	.3429	.5144	.5144	.3772	.0686
5	.7716	.6516	.5144	.5487	.5144	.4287	.0686
6	.8573	.6859	.6001	.5658	.6001	.6001	.0857
7	.9088	1.0288	.8059	.9602	1.0288	.8573	.1372
8	.9431	.9945	.823	.8745	1.046	.9431	.0686
9	.9088	.9774	.7202	.823	1.0631	.9774	.0514
10		.0343	.0343	.0514	.0343	.0343	.6001
11	.0514	.0343	.0343	.0343	.0343	.0343	.9259
12	.0343	.0514	.0171	.0343	.0343	.0343	
13	.0343	.0343	.0171	.0343	.0343	.0343	
14	.0343	.0343	.0171	.0686	.0343		
15	.0343	.0343	.0171	.0686	.0343	.0343	
16	.0343	.0343	.0171	.0514	.0343	.0514	
17	.0343	.0343		.0686	.0343	.0514	
18	.0514	.0343	.0514	.0686	.0343	.0343	.6859
19	.0686	.0343	.0686	.0686	.0514	.1029	.1029
20	.1029	.0686	.12	.0857	.0686	.0686	.12
21	.12	.0051	.0514	.12	.0514	.0686	.12
22	.12	.0343	.0514	.12	.0514	.0514	.1029
23	.0857	.0343	.0343	.1029	.0343	.0343	.0857
24	.1715	.1372	.2058	.1715	.1715	.2915	.0343
Max	.9431	1.0288	.823	.9602	1.0631	.9774	.9259
Min	.0343	.0051	.0171	.0343	.0343	.0343	.0343
Avg	.3265	.2824	.2333	.2693	.2758	.2669	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 201 / WAKAV

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1434	1.9719	2.2291		1.2346	.8573	.3429
2	2.1434	1.9719	2.2291		1.2346	.8573	.3429
3	2.1434	1.9719	2.2291		1.2346	.9431	.4287
4	2.4863	2.0576	2.4863		1.2346	.8916	.4801
5	2.572	2.1434	2.8292		1.3032	.9602	.6001
6	2.7949	2.6578	3.0521		1.406	.9602	.7373
7	3.1893	2.9835	3.2579		1.406	1.0288	.5144
8	2.8635	2.7606	2.915		1.4403	2.9492	.4801
9	.3601	.3429	.463	.4287	.4115	.3772	3.5837
10	.3086	.3429	.3601	.4287	.3258	.2743	
11	.2229	.2058	.3086	1.0288	.2743	.2058	
12	.1886	.2058	.2401	1.1145	.1715	.2058	
13	.2229	.2058	.2572	.2401	.1715	.2572	
14	.2058	.2229	.2572	.2401	.2743	.2572	
15	.2229	.2401	.2572	.2572	.2743	.2572	
16	.2572	.2572	.2572	.2743	2.6406	.3086	
17	.2058	.2572	.2572	.2915	.2743	.3258	.3429
18	.2572	.3086		.3772	.2743	.3601	.2743
19	.4458	.5658	.6001	.4287	.4458	.5658	.4458
20	.4801	.583	.6859	.6344	.6687	.6516	.7545
21	.4801		.583	.5144	.5658	.5316	.5144
22	.3429	.4115	.4458	.4973	.4801	.4801	.4801
23	.2743	.3429	.3772	.4287	.4458	.4115	.4115
24	.2915	.2743	.3086	.3429	.3772	.3429	.3601
Max	3.1893	2.9835	3.2579	1.1145	2.6406	2.9492	3.5837
Min	.1886	.2058	.2401	.2401	.1715	.2058	.2743
Avg	1.0460	1.0124	1.1690	.4705	.7737	.6359	.6526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 203 / ANGENGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.8004	2.1605	1.8004	1.8861	2.1434	.0857
2	1.8004	1.8004	2.1605	1.8004	1.8861	2.1434	.0857
3	1.8004	1.8004	2.1605	1.8004	1.8861	2.2291	.0857
4	1.8004	1.8861	2.3148	1.8861	1.8861	2.2634	.0857
5	1.8861	1.9719	2.7949	1.9204	2.2634	2.3148	.0857
6	1.9204	2.1434	3.0693	1.8347	2.4006	2.4006	.0857
7	2.2977	2.6578	1.6632	2.1262	2.4006	2.4863	.0857
8	2.1434	2.0576	2.915	2.0405	2.0576	2.7435	.0857
9	.1372	.1372	.1372	.1372	.0857	.1372	3.1379
10	.0686	.1372	.0686	.1029	.0686	.1372	
11	.0857	.1029	.0686	.0514	.1029	.1372	
12	.0857	.0686	.0686	.0514	.1029	.1029	
13	.0857	.0686	.0686	.0343	.1029	.0857	
14	.1029	.0686	.0686	.0343	.1029	.0857	
15	.0857	.0686	.0686	.0514	.1029	.0857	
16	.0857	.0686	.0686	.0514	.1029	.0857	
17	.1029	.0857	.0686	.0514	.1029	.0857	.1372
18	.1029	.1029		.0686	.1372	.0857	.1372
19	.1372	.1029	.2058	.1372	.1715	.2058	.2058
20	.1715	.0857	.0686	.2229	.1372	.1029	.1715
21	.1715		.0686	.1372	.1372	.1029	.1715
22	.1715	.0857	.0857	.1372	.1029	.0857	.12
23	.1372	.0857	.0686	.1029	.1029	.0857	.1029
24	.1029	.1372	.0857	.0686	.0857	.1029	.0857
Max	2.2977	2.6578	3.0693	2.1262	2.4006	2.7435	3.1379
Min	.0686	.0686	.0686	.0343	.0686	.0857	.0857
Avg	.7202	.7619	.8916	.6937	.7673	.8516	.2915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 204 / KHAIRAO

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2058	.2058	.1372	1.286
2	.2058	.2058	.2058	.2058	.2058	.1372	1.3375
3	.2058	.2058	.2058	.2058	.2058	.1715	1.1145
4	.2058	.2058	.2058	.2229	.2058	.3086	1.0288
5	.2743	.2743	.2572	.2915	.2572	.2743	.3429
6	.3086	.2743	.2915	.3258	.3086	.3086	.3086
7	.3258	.2743	.3086	.3429	.3258	.2915	.2572
8	.2572	.2058	.2915	.2572	.2229	.2572	.2401
9	.1886	.2058		.2572	.1715	.2058	
10	.1372	.2058			.1372	.1372	
11	.1029	.1715		.1029	.1372	.1372	
12	.12	.0857	.0857	.1029	.1029	.1372	
13	.1029	.0857	.0857	.0857	.1715	.0857	
14	.1029	.0857	.0857	.0857	.1029	.0857	
15	.1029	.1029	.0857	.0857	.1029	.1029	
16	.1029	.1029	.1029	.0857	.1029	.1372	
17	2.7778	3.4294	3.2579	1.7833	1.869	1.9204	.1029
18	2.9835	3.4637	3.4294	1.7833	1.4403	1.9719	.1715
19	2.8292	2.9664	3.3436	1.749	1.9547	1.6461	.2743
20	2.7092	3.0007	3.2407	1.7147	1.6975	1.6804	.2401
21	2.7092		3.2922	1.4403	1.6461	1.6804	.2743
22	2.7263	2.6235	3.2922	1.3546	1.6118	1.4403	.2229
23	2.3148	2.6063	3.3436	1.3717	1.4746	1.4403	.2058
24	.2058	2.3148	2.6406	3.7037	1.3717	1.3717	1.3717
Max	2.9835	3.4637	3.4294	3.7037	1.9547	1.9719	1.3717
Min	.1029	.0857	.0857	.0857	.1029	.0857	.1029
Avg	.9252	1.0132	1.3456	.7724	.6680	.6694	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 205 / KAPASEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1372	.0857	.12	.1372	.12	.1029
2	.0857	.1372	.0857	.12	.1372	.1715	.1029
3	.0857	.1372	.0857	.12	.1372	.1715	.1029
4	.0857	.1715	.12	.12	.1372	.2058	.1029
5	.1372	.2058	.1715	.1372	.2229	.2401	.1029
6	.2401	.2572	.2401	.2401	.2743	.2572	.2743
7	.2915	.2572	.3429	.2743	.3086	.2743	.2229
8	.2572	.2572	.2572	.2229	.2572	.2229	.2572
9	1.7833	1.8004	1.7661	1.7318	1.8004	1.9204	
10	1.9204	1.9204	1.7147	2.2805	1.6118	1.406	
11	1.8004	1.869	2.0576	2.0576	1.3717	2.0919	
12	1.9547	1.869	2.0919	1.9376	1.869	2.0919	
13	1.749	1.8519	1.9719	1.8004	1.869	2.0576	
14	1.8861	1.8519	1.8861	1.5604	1.9033	1.8861	
15	1.8176	1.8861	1.7147	1.7147	1.9033	1.8004	
16	1.7147	1.8861	1.6289	1.8176	.1029	1.8004	
17	.1372	.0857	.0514		.12	.0514	2.332
18	.1372	.0857	.0514	.0686	.1372	.0514	.1372
19	.2229	.0857	.1543	.1886	.1715	.1543	.1715
20	.2572	.1715	.2572	.2229	.2229	.2058	.2058
21	.2572		.1543	.1543	.1372	.1543	.1715
22	.1715	.0857	.12	.1372	.12	.1372	.12
23	.1372	.0857	.12	.1372	.12	.12	.1029
24	.0857	.1372	.0857	.12	.1372	.12	.1029
Max	1.9547	1.9204	2.0919	2.2805	1.9033	2.0919	2.332
Min	.0857	.0857	.0514	.0686	.1029	.0514	.1029
Avg	.7209	.7492	.7173	.7515	.6337	.7380	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274023 / 33/11KV MANEGAON SUB STATION

Feeder No / Name : 206 / kumbhej

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.0686	.0686	.0686	.1029	.0857
2	.12	.1372	.0686	.0686	.0686	.1029	.0857
3	.12	.1372	.0686	.0686	.0686	.1029	.0857
4	.12	.1715	.0857	.1029	.0686	.12	.0857
5	.1543	.2058	.12	.1543	.1029	.1372	.12
6	.2229	.2572	.1372	.1886	.1372	.1372	.12
7	.2229	.2572	.1372	.12	.1372	.1372	.12
8	.1543	.1715	.1372	.1029	.1372	.1372	.12
9	2.6235	2.7435	1.3546	.3086	.0514	1.4403	
10	2.6749	2.7606	1.3889	.3086	.0514	1.3889	
11	2.1948		1.3717	.2743	.0857	1.2003	
12	2.6235		1.3717	.2743	.0857	1.2517	
13	2.2977	1.3203	1.9204	.0857	.0857	.0857	
14	2.9321	1.3375	1.9204	.0857	.0857	.0857	
15	2.9664	1.406	1.8861	.0857	.0857	.0857	
16	2.6063	1.3032	1.8519	.0857	.0857	.0857	
17	.1029	.0514	.0857	.0514	.0857	.0857	2.692
18	.1029	.0514		.0857	.1715	.1029	.1372
19	.1715	.0686		.0857	.1715	.1372	.2058
20	.2572	.0686	.0857	.1372	.1372	.12	.1715
21	.2572		.0686	.12	.1372	.12	.1715
22	.1715	.0686	.0686	.12	.12	.12	.1372
23	.1372	.0686	.0686	.0686	.1029	.1029	.12
24	.12	.1372	.0686	.0686	.0686	.1029	.0857
Max	2.9664	2.7606	1.9204	.3086	.1715	1.4403	2.692
Min	.1029	.0514	.0686	.0514	.0514	.0857	.0857
Avg	.9781	.6124	.6516	.1300	.1000	.3122	.2840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 201 / Uplai(BK)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2572	.2572	.3429		1.3717
2	.1715	.2401	.2572	.2572	.3429		1.6289
3	.1715	.2401	.2572	.2572	.3429		1.8004
4	.1715	.2743	.2572	.3086	.3429		2.0576
5	.2401	.3086	.2572	.3429	.3429		2.3148
6	.3086	.3429	.3429	.3944	.3429		2.4006
7	.3601	.3772	.4287	.4287		.3429	3.0864
8	.3258	.2915	.3429	.3429		.3429	3.2579
9	.3429	.2572	.3772	.2572		.2572	3.0007
10		.8573	1.5432	1.6289	.2572	1.2003	.2401
11		2.8292	3.1722	3.0007	2.915	3.1722	.2058
12		2.4006	1.5432	3.2579	2.915	3.2579	.2058
13		2.6578	3.1722	3.0007	3.0007	2.8292	.1715
14		2.7435	3.0864	2.8292	3.0007	2.8292	.1715
15		2.8292	2.8292	3.0864	3.0007	2.8292	
16	3.0007	2.8292	3.3436		3.0864	2.915	.1886
17	3.0007	2.915	2.915	.2401	3.0007	2.915	
18	2.572	.2572	.2915	.3086	.2572	.2915	
19	2.3148	.3429	.3086	.3429	.3429	.3086	.0686
20	2.2291	.3429	.3429	.3772	.4287	.3429	.1029
21	.3429	.3429	.3772	.3429	.4287	.3772	.0857
22	.3086	.2572	.3086	.3258	.4287	.3429	.0857
23		.2572	.2743	.3086	.3429	.2058	.0686
24	.2743	.2401	.2572	.2572	.3429		.8573
Max	3.0007	2.915	3.3436	3.2579	3.0864	3.2579	3.2579
Min	.1715	.2401	.2572	.2401	.2572	.2058	.0686
Avg	.9643	1.0281	1.1060	.9632	1.2288	1.4565	1.1129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 202 / Rophale(KH)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.5144	1.2003	1.2003	1.1145	1.3717	.1715
2	1.2003	.5144	1.286	1.4575	1.0288	1.5432	.1715
3	1.4575	.5144	1.3717	1.6289	1.1145	1.6289	.1715
4	1.6289	1.0288	1.3717	1.6289	1.2003	1.6289	.1715
5	1.7147	1.5432	1.8861	1.8861	1.2003	1.8861	.1715
6	2.2291	2.3148	2.1434	2.2291	1.286	2.1434	.2572
7	2.572	2.572	2.6578	3.0007		2.4863	.2572
8	2.4006	2.7435	2.572	2.915		2.572	.1715
9	2.3148	2.7435	2.4006	2.4006		1.9719	.1715
10		.2572	.1715	.1715	1.1145	.2572	.8573
11		.1715	.1715	.1715	.2572	.2572	2.4863
12		.1715	.1715	.1715	.2572	.1715	2.5034
13		.1715	.1715	.1715	.2572	.2572	2.4863
14		.1715	.1715	.1715	.2572	.2572	
15		.1715	.1715	.1715	.1715	.2572	
16		.1715	.1715		.1715	.1715	
17		.1715	.1715	.1715	.1715	.1715	2.572
18	.1715	.1715	.1715	.1715	.1715	.1715	.2572
19		.2572	.1715	.1715	.2572	.2572	.1715
20	.1715	.2572	.2572	.1715	.2572	.2572	.2572
21	.2572	.2572	.2572	.1715	.2572	.2572	.2572
22	.1715	.2572	.2572	.1715	.2572	.1715	.1715
23		.2572	.1715	.1715	.2572	.1715	.1715
24	.8573	.5144	.9431	.8573	.8573	.8573	.1715
Max	2.572	2.7435	2.6578	3.0007	1.286	2.572	2.572
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	1.2983	.7466	.8538	.9319	.5675	.8823	.6704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 204 / GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3429	.2572	.1715	.1715	.2572	.2572
2	.1715	.1715	.2572	.1715	.1715	.2572	.2572
3	.1715	.2572	.2572	.1715	.2572	.2572	.2572
4	.1715	.2572	.2572	.2572	.2572	.2572	.2572
5	.3429	.2572	.2572	.2572	.2572	.2572	.2572
6	.3429	.2572	.2572	.2572	.2572	.3429	.4287
7	.3429	.2572	.3429	.4287		.2572	.3429
8	.2572	.3429	.2572	.3429		.2572	.4287
9	.1715	.3429	.2572	.2572		.3429	.3429
10		.3429	.2572	.1715	.2572	.1715	.2572
11		.3429	.1715	.2572	.4287	.2572	
12		.4287	.1715	.3429	.2572	.2572	.3429
13		.2572	.1715	.3429	.3429	.2572	.3429
14		.2572	.1715	.3429	.3429	.2572	.3429
15			.1715	.2572	.2572	.2572	
16	.2572	.1715	.1715		.1715	.2572	.1715
17	.2572	.1715	.1715	.2572	.1715	.2572	.1715
18	.2572	.1715	.1715	.2572	.1715	.2572	.2572
19	.3429	.2572	.4287	.2572	.2572	.4287	.2572
20	.3429	.3429	.4287	.2572	.3429	.4287	.3429
21	.3429	.3429	.4287	.3429	.3429	.4287	.3429
22	.3429	.2572	.3429	.3429	.3429	.4287	.3429
23		.2572	.2572	.3429	.2572	.4287	.2572
24	.2572	.3429	.2572	.1715	.3429	.2572	.3429
Max	.3429	.4287	.4287	.4287	.4287	.4287	.4287
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.2673	.2796	.2572	.2721	.2694	.2965	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 205 / Kumbhej

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	1.286	.8573	.8573	1.286	.1715
2	.7716	.8573	1.286	1.0288	.8573	1.286	
3	.9431	.8573	1.3717	1.286	.8573	1.3717	.1715
4	1.0288	1.2003	1.3717	1.4575	.8573	1.5432	.1715
5	1.5432	1.5432	1.5432	1.6289	.9431	1.6289	.1715
6	1.8861	1.8004	1.7147	1.8004	.9431	2.0576	.1715
7	2.0576	2.0576	2.0576	2.0576		2.1434	.1715
8	2.0576		2.2291	2.0576		2.2291	.2572
9	1.3717	2.0576	2.0576	1.8004		1.5432	.2572
10		.1715	.1715	.2572	1.0288	.1715	1.5432
11		.1715	.1715	.1715	.1715	.1715	2.2291
12		.1715	.1715	.1715	.1715	.1715	2.2291
13		.1715	.0857	.1715	.2572	.1715	
14		.1715	.0857	.1715	.2572	.1715	
15		.1715	.1715	.1715	.1715	.1715	
16		.1715	.1715		.1715	.1715	
17		.1715	.1715	.1715	.2572	.1715	
18	.1715	.1715	.1715	.1715	.2572	.1715	
19	.1715	.1715	.1715	.1715	.2572	.2572	
20	.1715	.2572	.1715		.2572	.2572	
21	.2572	.2572	.1715	.1715	.2572	.2572	
22	.1715	.2572	.1715	.1715	.2572	.2572	
23		.2572	.1715	.1715	.2572	.1715	
24	.6001	.8573	.8573	.7716	.8573	.8573	.1715
Max	2.0576	2.0576	2.2291	2.0576	1.0288	2.2291	2.2291
Min	.1715	.1715	.0857	.1715	.1715	.1715	.1715
Avg	.9259	.6449	.7502	.7677	.4858	.7788	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 206 / UPLAI(KH)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3944	.3429	.2572	.3086	.2572	.8573
2	.3086	.3944	.3429	.2743	.2572	.2572	1.0288
3	.2743	.3944	.3429	.3086	.2572	.2572	1.286
4	.2572	.4287	.3429	.3429	.2572	.2572	1.4575
5	.4801	.4801	.4287	.3429	.2572	.3429	1.6289
6	.5144	.5144	.5144	.4287	.2572	.5144	2.1776
7	.5487	.5487	.5144	.463		.4287	2.572
8	.5144	.4973	.5144	.4287		.3429	2.5892
9	.4287	.3429	.5144	.2915		.3429	2.5034
10		1.1145	1.4575	1.6975	.3429	.7716	.2401
11		3.0007	2.572	2.7092	2.8121	2.4006	.2229
12		3.2065	2.915	2.6749	2.8292	2.692	.2229
13		3.0864	2.915	2.7435	2.915	2.572	.2229
14			2.915	2.8292	2.9664	2.452	.2058
15		3.2065	3.0178	2.8292	2.572	2.4177	.2058
16	3.2407	2.572	1.8004		2.4863	2.4863	.1886
17	1.7147	2.915	2.9835	.3258	2.4006	2.572	.2058
18	2.5549	.2572	.3429	.3601	.1715	.2401	.2229
19	1.5261	.3429	.4287		.3429	.4458	.3429
20	1.5261	.3429	.4801	.4115	.4287	.4801	.4287
21	.4458	.4287	.4458	.3772	.4287	.4287	.3772
22	.3944	.4287	.3601	.3772	.4287	.3086	.3772
23		.3429	.3086	.3601	.3429	.3086	.3429
24	.3429	.3944	.3429	.2572	.3429	.2572	.6859
Max	3.2407	3.2065	3.0178	2.8292	2.9664	2.692	2.5892
Min	.2572	.2572	.3086	.2572	.1715	.2401	.1886
Avg	.9068	1.1145	1.1310	.9587	1.1145	.9931	.8581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 207 / vittalwadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.8573	.6001	.7373	.8573	.0343
2	.6859	.5144	.8573	.8573	.8573	.9431	.0343
3	.6859	.5144	1.0288	.8573	.8573	.9431	.0343
4	.9431	.6001	1.286	.9431	.9431	1.1145	.0514
5	1.0288	.8573	1.286	1.0288	.9431	1.2003	.0686
6	1.2003	1.2003	1.3717	1.0288	1.0288	1.286	.1029
7	1.286		1.3717	1.4918		1.3717	.1029
8	1.3203	1.3889	1.4918	1.4232		1.6289	.12
9	1.0288	1.5432	1.4232	1.2346		1.4232	.0857
10		.0857	.1029	.0857	1.6289	.12	.9774
11		.0686	.0686	.0857	.1029	.0686	1.2689
12		.0514	.0686	.0686	.0514	.0514	1.4575
13		.0857	.0686	.0514	.0514	.0514	1.4575
14		.1543	.0857	.0514	.0857	.0514	
15			.0857	.0514	.0857	.0514	
16			.0857		.0514	.0514	
17			.0514	.0686	.0514	.0514	1.286
18			.0514	.0857	.0686	.0514	.2572
19	.1372	.0857	.0686	.12	.0857	.0514	.2229
20	.0514	.0857	.0857	.1372	.0857	.0514	.2743
21	.1543	.12	.1029	.0686	.0857	.0514	.1886
22	.1029	.12	.0514	.0686	.0857	.0343	.1886
23		.0857	.0343	.0857	.0857	.0343	.1372
24	.5487	.5144	.7716	.4287	.5487	.7716	.0343
Max	1.3203	1.5432	1.4918	1.4918	1.6289	1.6289	1.4575
Min	.0514	.0514	.0343	.0514	.0514	.0343	.0343
Avg	.6981	.4521	.5315	.4749	.4058	.5130	.3993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274109 / 33/11 KV UPALAI SUB STATION

Feeder No / Name : 208 / londewadi FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	28-MAR-18
HR	Load (MW)
19	1.0974
20	1.5775
21	1.6975
22	1.6975
23	1.7833
Max	1.7833
Min	1.0974
Avg	1.5706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 201 / Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.8764	.415	1.0456	.8962	.9709
2	.5544	.5228	.9774	.4481	1.0456	.7682	.9709
3	.5658	.5093	.9465	.4527	1.0082	.8682	.9335
4	.5281	.5228	.8764	.4854	1.0349	.8939	.924
5	.4527	.5975	.7602	.5281	1.0719	1.0059	.6413
6	2.7206	.5228	.7316	.5788	1.1016	.8589	.6413
7	2.8807	3.1493	.6219	.6161	.7655	.5784	.6036
8	2.9096		3.1367	.7682	3.12		2.9675
9	2.9767			.8162	1.0903		.9431
10		.6836	.9619	.7362	1.0136	.7167	.9694
11	2.9887	.6478	.9619	.8288	.9465	.8131	
12	3.062	.7537	1.0269	.7611	1.0517	.9808	
13	3.0308	.7888	1.1128	.6882	.823	1.0456	
14	.6468	.8779	.9431	.5792	.7011	1.0349	
15	.6283	.7865	.8402	.5973	.8682	1.0269	
16	.6348	.8097			.8764	1.0082	
17	.6283	.8596	.9619	.724	.9465	1.0562	
18	.6979	.7562			1.0029	1.0456	
19	.7468	.8436		.9979	.9036	1.0269	1.0903
20	.8589	.9816		1.0456	.8764	1.0082	.8962
21	.8029	1.0517		1.0719		1.0751	1.0903
22	.7282	.9465		1.0534	.8413	1.0269	1.1203
23	.6348	1.0608		1.0719	.8328	1.0185	
24	.6413	.6161	.9231	.4108	1.0534	.8779	1.0082
Max	3.062	3.1493	3.1367	1.0719	3.12	1.0751	2.9675
Min	.4527	.5093	.6219	.4108	.7011	.5784	.6036
Avg	1.3426	.8568	1.0412	.7125	1.0444	.9378	1.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 202 / kevad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646	.3174	.5487	.3772	.3734	.3475	.3361
2	2.372	.3174	.4938	.3734	.3696	.3189	.3018
3	2.2497	.2926	.5304	.3881	.3511	.3012	.2957
4	2.0805	.3772	.567	.4108	.4108	.3475	.3361
5	2.0081	.5281	.6154	.4108	.4572	.3841	.3361
6	.5658	.7545	.7059	.3772	.462	.4207	.3772
7	.6413	.547	.7316	.415	.4755	.4557	.415
8	.5601		.7316	.3734	.4755		.3361
9	.5658			.3395	.1663		.1494
10		2.5606	2.8807	.4435	1.8099	1.8671	1.6762
11	.3439	.5434	.5601	.4525	.4344	.2801	
12	.1991		.5658		.4207	.3547	
13	.3982	.3658	.6036		.3681	.415	
14	.3696	.3856	.5788	.3881	.4252	.4108	
15	.3475	.439	.5601	.4163	.4207	.4066	
16		.4938	.6413	.4525	.4733	.4527	
17	.5853	.5121	.7545	.4887	.4207	.4481	
18	.6099	.5083		.3292	.4382	.4435	
19	.6602	.4207		1.6741	.4733	.415	.4294
20	.5658	.3681		.4108	.4207	.3921	.3547
21	.3734	.2715		.3921		.3772	.3547
22	2.6073	.298		.3921	.3506	.3734	.3696
23	2.5749	.3475		.4066	.3681	.3772	
24	2.4966	2.3758	.5121	.3921	.3881	.4024	.3734
Max	2.6073	2.5606	2.8807	1.6741	1.8099	1.8671	1.6762
Min	.1991	.2715	.4938	.3292	.1663	.2801	.1494
Avg	1.1654	.6202	.7401	.4593	.4675	.4542	.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 203 / Undergoan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3174	.2715	.415	.4294	.2454	.4914
2	.3206	.3018	.2715	.4527	.4108	.2481	.4854
3	.3018	.3018	.2561	.4527	.4108	.2629	.5175
4	.3361	.3584	.2378	.4527	.4481	.2629	.5228
5	.3772	.4527	.2561	.4854	.5601	.2629	.5281
6	.3018	.4715	.2561	.5601	.6535	.2481	.5658
7	.2641	.2641	.3475	.5975	.5975	.2715	.6036
8	.2241		.2561	.4481	.3772		.3734
9	.1886			.4527	.7865		.6401
10		.3239	.2263	.4066	.2454	.3734	.3326
11	.168	.2187	.2641	.3109	.2561	.3772	
12	.1478	.2743	.2987	.2957	.2658	.3395	
13	.1478	.2561	.3018		.2454	.3018	
14	.7274	.2561	.3018	.3292	.2629	.4854	
15	.703	.2195	.3018	.3292	.2454	.3018	
16	.7099	.1829	.3018	.3292	.2454	.3018	
17	.7407	.2195	.3018	.2033	.2454	.4527	
18	.7099	.2303		.3174	.2829	.5658	
19	.6706	.2629		.3734	.2629	.5975	.4207
20	.6401	.2629		.4481	.2561	.4527	.5729
21	.7274	.2454		.5175		.3018	.5544
22	.3734	.2103		.4854	.2561	.4481	.5359
23	.3206	.2378		.4481	.2743	.5281	
24	.3547	.3206	.3155	.3734	.4294	.2454	.5281
Max	.7407	.4715	.3475	.5975	.7865	.5975	.6401
Min	.1478	.1829	.2263	.2033	.2454	.2454	.3326
Avg	.4251	.2813	.2804	.4124	.3673	.3579	.5115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274162 / Darphal(sina) s/s

Feeder No / Name : 204 / Darfal Water Supply

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0301	.0151	.029	.0301	.0301	.029	.0452
2	.0452	.0151	.029	.0151	.0301	.029	.0301
3	.003	.0151	.029	.0151	.0301	.029	.0301
4	.0452	.0151	.029	.0301	.0301	.029	.0301
5	.0452	.0151	.029	.0301	.0301	.0175	.0301
6	.2107	.2559	.2258	.0211	.2559	.0724	.2408
7	.286	.3311	.2258	.286	.3612	.2172	.3311
8	.3161		.3041	.301	.4064		.4214
9	.3161			.3913	.3612		.3763
10		.3765	.3913	.4515	.3311	.3763	.4816
11	.3311	.3763	.3913	.4515	.4344	.4214	
12	.3913	.3763	.3913	.4816	.4344	.4214	
13	.3612	.3612	.3913	.4967	.4344	.3612	
14	.0151	.0301	.0301	.0452	.029	.0301	
15	.0151	.029	.0301	.0301	.029	.0301	
16	.0301	.0301	.0301	.0151	.029	.0301	
17	.0301	.029	.0301	.0151	.029	.0602	
18	.0301	.029			.029	.0452	
19	.0301	.0301		.0301	.029	.0602	.0452
20	.0452	.0301		.0301	.029	.0602	.0602
21	.0452	.029		.0452		.0452	.0452
22	.0301	.0301		.0452	.029	.0452	.0452
23	.0151	.029		.0602	.029	.0301	.0151
24	.0301	.0151	.0301	.0301	.0452	.029	.0452
Max	.3913	.3765	.3913	.4967	.4344	.4214	.4816
Min	.003	.0151	.029	.0151	.029	.0175	.0151
Avg	.1173	.1120	.1539	.1455	.1511	.1122	.1421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 201 / 11 KV JAMGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.3048	.2286	.7773	.823	.8535	.1991
2	.4858	.3048	.2743	.8097	.884	.9145	.2172
3	.583	.3048	.3048	.8907	.945	.9907	.2715
4	.6154	.3048	.381	.8993	1.0669	1.2346	.3258
5	.6478	.3506	.4268	.9145	1.0669	1.0517	.362
6	.6964	.4725	.4877	.9145	1.4632	1.2346	.4525
7	.7287	.6097	.5639	1.2955	1.6004	1.6309	.4525
8	.6859	.4572	.7011	1.3717	1.5394	1.3717	.3258
9	.7011	.6249	.6706	1.5242	1.4937	1.2498	.2804
10	.0701	.0857	.0724	.2401	.1402	.2353	1.1126
11	.0701	.0686	.0543		.1578		1.5699
12	.0526	.0514	.0543		.1928	.181	.1829
13	.0526	.0514	.0543	.0514	.1928	.181	.2454
14	.0526	.0514	.0543	.0686	.1928	.181	.2804
15	.0526	.0514	.0543	.1715	.2103	.181	.2629
16	.0526	.0514	.0543	.2058	.2103	.181	.2629
17	.0526	.0514	.0543	.2229	.2279	.181	.2804
18	.0701	.0686	.0905	.2572	.2454	.181	.333
19	.1578	.0857	.2172	.2743	.2454	.3077	.4207
20	.1402	.1372	.2353	.3086	.3506	.2715	.4207
21	.1052	.12	.2715	.2915	.3506	.3258	.333
22	.1052	.0857	.2353	.2572	.3155	.2353	.298
23	.0701	.0857	.181	.2229	.2629	.1991	.2629
24	.2915	.2743	.2134	.4534	.4268	.7773	.1991
Max	.7287	.6249	.7011	1.5242	1.6004	1.6309	1.5699
Min	.0526	.0514	.0543	.0514	.1402	.181	.1829
Avg	.2927	.2106	.2473	.5647	.6085	.6153	.3897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 202 / 11 KV ANJANGAON(U)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2401	.2058	.181	.1715	.1753	.9907
2	.181	.2572	.2229	.181	.1715	.1753	1.1888
3	.1991	.2743	.2572	.181	.2401	.1753	1.2498
4	.2172	.2743	.3772	.2715	.2572	.2103	
5	.2715	.3258	.4458	.3258	.3086		1.448
6	.4163	.3258	.4973	.4163	.3429	.298	1.448
7	.6154	.4458	.5144	.4525	.4458	.4733	1.9052
8	.4557	.4801	.5316	.362	.3856	.3506	1.829
9	.4207	.3429	.4287	.3086	.3155	.3506	1.6766
10	1.262	.9907	1.0526	1.4937	1.1888	1.1336	.1928
11	2.1559	1.829	1.6766	1.8747	1.9204	1.9433	.1227
12	2.4539	2.1338	1.9814	1.89	2.1735	1.9052	.1227
13	2.3663	2.0881	1.9814	1.9204	2.191	1.9814	
14	2.1559	1.9814	1.9814	1.829	2.1735	1.9052	
15	2.1033	1.9357	1.9814	1.7833	1.9806	1.9814	
16	2.0858	1.8747	1.9814	1.829	1.5699	1.9814	
17	1.8138	1.89	1.6004	1.8595	1.5699	1.9052	
18	.2629	.2229		.3086	.1753	.2172	
19	.4207	.3258	.2715	.2915	.298	.3982	.333
20	.3155	.463	.3258	.3258	.3155	.3439	.4382
21	.298	.4115	.2896	.2572	.298	.362	.3155
22	.2804	.3258	.2353	.2401	.298	.3258	.2629
23	.2629	.2915	.2896	.2058	.2454	.2896	.9602
24	.3077	.2572	.2743	.1991	.2058	.2279	.9717
Max	2.4539	2.1338	1.9814	1.9204	2.191	1.9814	1.9052
Min	.181	.2229	.2058	.181	.1715	.1753	.1227
Avg	.8997	.8328	.8436	.7911	.8018	.8309	.9092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274238 / 33/11 KV JAMGAON

Feeder No / Name : 203 / 11 KV WADACHIWADI(AU)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.503	.3048	.4858	.6097	.6401	.0724
2	.5344	.5959	.3048	.5487	.6097	.7712	.0724
3	.6478	.5959	.3353	.6478	.7716	.7712	.0724
4	.7773	.7186	.442	.6554	.7316	.7468	.0905
5	.8097	.6249	.5944	.7621	.9755	.7621	.0905
6	.9069		.7011		.9755	.8078	.1267
7	.8907	.9297	.884	1.0669	1.0669	.7926	
8	.9602	.6706	.9145	1.0669	1.0974	.7926	
9	.9145		.8688	.9145	1.0364	.8688	.0876
10	.061	.0686	.0905	.0514	.0876	.0724	.6097
11	.061	.0514	.0724	.0514	.0701	.0905	.8383
12	.0701	.0514	.0724	.0514	.0526	.0905	
13	.1052	.0514	.0543	.0514	.0526	.1086	
14	.1052	.0514	.0543	.0514	.0701	.0905	
15	.1052	.0857	.0543	.0514	.0701	.0905	
16	.0914	.0857	.0724	.0857	.0701	.1086	
17	.0876	.0857		.1029	.0701	.1086	
18	.0876	.0686	.0905	.1029	.0876	.0905	
19	.1402	.0857	.1086	.12	.1052	.1267	.1052
20	.1402	.12	.1448	.1029	.1227	.1267	.1402
21	.1052	.1029	.1448	.0857	.1052	.0905	.1052
22	.1052	.0857	.1086	.0857	.0876	.0724	.0857
23	.1052	.0686	.0905	.0857	.0876	.0724	.0701
24	.4049	.442	.3086	.3725	.3658	.5609	.0724
Max	.9602	.9297	.9145	1.0669	1.0974	.8688	.8383
Min	.061	.0514	.0543	.0514	.0526	.0724	.0701
Avg	.3626	.2792	.2964	.3305	.3908	.3689	.1760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 201 / 11 KV UPLAI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.12	.2058	.2058	.9145
2	.1715	.1715	.1715	.1543	.2058	.2058	1.1888
3	.1886	.1715	.1886	.1886	.2229	.2229	1.2651
4	.2229	.2058	.2058	.2401	.2401	.2401	1.4632
5	.2743	.2058	.2229	.2915	.3086	.3086	1.5546
6	.3429	.2401	.3601	.4287	.3944	.463	1.9204
7	.3772	.3429	.3772	.463	.4458	.4458	1.1431
8	.2743	.0171	.2401	.3086	.3772	.3086	2.2862
9	.1886	.2229	.2401	.3258	.2743	.2572	2.5892
10		1.046	1.3108	1.5947	1.6632	1.5242	.1886
11		2.3491	2.1033	3.0178	2.9835	2.5606	.1543
12		2.5892	2.4234	3.2579	2.5034	2.7282	.1543
13	2.7435	2.692		2.915	2.5549	2.652	
14	2.8807	2.5034		3.1036	2.915	2.2405	
15	2.7263	2.572		2.8464	2.7778	1.9814	
16	2.3663	2.6406	2.0271	2.7435	2.915	2.0576	
17	2.7092	2.572	2.1491	3.0864	2.8807	1.4937	
18	.1372	.12	2.2862	.1715	.1543	.1715	.1886
19		.2229	.3086	.3429	.3086	.3086	.3429
20	.2743	.2401	.3086	.3429	.3601	.3086	.3429
21	.2401	.2401	.3258	.3258	.3086	.3086	.3601
22	.1886	.2058	.2915	.2401	.2229	.2572	.3086
23	.1886	.1886	.1886	.2229	.2401	.6554	.2229
24	.1886	.1715	.1715	.12	.2058	.2058	.6554
Max	2.8807	2.692	2.4234	3.2579	2.9835	2.7282	2.5892
Min	.1372	.0171	.1715	.12	.1543	.1715	.1543
Avg	.8428	.9209	.7653	1.1188	1.0695	.9213	.9076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 202 / 11 KV ROPALE NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6516	1.1831	1.0802	.6173	.8402	.2572
2	.884	.7202	1.1831	1.2041	.6173	1.1488	.2058
3	1.2193	.9945	1.1831	1.3108	1.1831	1.2517	.2058
4	1.387	1.3203	1.1831	1.448	1.3546	1.3546	
5	1.8004	1.7147	1.3717	1.749	1.9719	1.5775	.3601
6	1.9052	2.0062	1.989	2.0405	2.0748	1.9204	.4287
7	2.5453	2.5549	2.5377	2.0576	2.0748	2.2977	.4801
8	2.3929	2.572	2.2291	2.2558	2.0748	1.9204	.4458
9	2.452	1.9376	2.1186	2.572	1.869	1.5699	.3429
10		.2401	.2401	.2743	.2058	.2229	1.5604
11		.1715	.2229	.2229	.2229	.1715	2.1262
12		.2743	.2229	.2229	.1886	.1715	
13	.2058	.2915	.1715	.1715			
14		.1715	.1715	.1886	.2229	.1715	
15	.2401	.1886	.1886	.1715	.2401	.1715	
16	.2915	.2743	.2743	.1715	.2401	.1886	
17	.3258	.3258	.2915	.2915	.2915	.2058	
18	.2915	.2915	.3258	.3258	.2915	.3258	.2401
19		.3601	.3772	.3258	.3601	.3258	.3429
20	.4115	.3772	.3772	.3772	.3944	.3258	.3944
21	.3429	.3601	.3772	.3429	.3429	.3086	.3429
22	.3086	.3258	.3086	.3086	.2401	.2743	.3086
23	.2915	.2915	.2743	.2915	.2743	.2743	.2743
24	.6001	.5487	.5487	.6401	.4458	.6859	.2743
Max	2.5453	2.572	2.5377	2.572	2.0748	2.2977	2.1262
Min	.2058	.1715	.1715	.1715	.1886	.1715	.2058
Avg	.9756	.7902	.8063	.8352	.7739	.7698	.5053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274243 / 33/11 KV UPLAI(BK)

Feeder No / Name : 203 / 11 KV GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.12	.1029	.1372	.1029	.1372	.1372
2	.1372	.12	.1029	.12	.1029		.12
3	.1372	.12	.12	.12	.12	.12	.1543
4	.1715	.12	.12	.12	.12	.12	.1886
5	.2229	.1543	.2896	.1543	.1715	.1715	.1886
6	.2572	.2401	.2229	.2229	.2229	.2229	.2401
7	.2229	.2229	.1886	.2572	.2743	.2058	.2572
8	.2058	.1715	.2058	.1886	.2229	.1715	.1886
9	.1715	.1715	.1715	.1715	.1715	.1715	.1715
10		.1886	.2058	.1886	.1715	.1372	.1715
11		.1715	.1543	.1715	.1543	.1715	.1543
12		.1543	.12	.1715	.1715	.1715	.1372
13	.1715	.1715	.1372	.1543	.1715	.12	
14	.1372	.1029	.12	.12	.1543	.1372	
15	.12	.1029	.12	.1029	.12	.1372	
16	.0686	.12	.12	.12	.12	.1372	
17	.1372	.1543	.1543	.1372	.1372	.1029	
18	.1715	.1543	.1715	.1715	.1029	.1543	.1886
19		.1886	.2058	.2058	.1715	.1886	.2229
20	.2058	.2058	.2058	.2229		.1715	.2229
21	.2229	.1886	.1886	.2058	.2058	.1543	.2401
22	.1715	.1715	.1715	.1715	.1715	.1543	.1715
23	.1372	.1372	.1715	.1715	.1715	.1372	.1715
24	.2058	.1372	.12	.1715	.12	.1372	.1372
Max	.2572	.2401	.2896	.2572	.2743	.2229	.2572
Min	.0686	.1029	.1029	.1029	.1029	.1029	.12
Avg	.1723	.1579	.1621	.1658	.1588	.1536	.1823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 201 / 11 KV SAPATANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1829	.1829	.1372	.1829	.2134	.9945
2	.1372	.1829	.1524	.1524	.1829	.2134	1.0802
3	.1829	.1524	.1372	.1524	.1524	.1829	1.3203
4	.2439	.1372	.1524	.1524	.2134	.2134	1.3889
5	.2591	.1677	.2401	.1829	.2743	.2439	1.6975
6	.3048	.2896	.2743	.2134	.3658	.3353	2.0748
7	.3353	.3506	.3353	.2743	.4268	.3658	2.0576
8	.3086	.3086	.2915	.2439	.3658	.3048	1.9719
9	.2743	.2743		.1981	.2591	.2134	
10		1.2803		1.0974	1.7318	1.2651	.7202
11		2.0424		.2058	2.332	2.1434	.1219
12		1.9814		1.9719	.7716	2.3663	.1219
13	2.0729	1.9357	1.9814		2.2119	2.332	
14	1.768	1.5242	2.2862	2.2119	2.2977	2.0919	
15	2.0729	1.6766	1.9357	2.0062	2.3148	1.989	
16	2.2634	2.1262	1.829	2.0919	2.1434	2.1091	
17		2.0233	1.9204	1.7833	1.9052	1.9509	
18	.1524	.2134	1.8861	.1677	.1886	.1715	.2058
19		.2439	.1981	.2591	.3086	.2572	.2915
20	.2439	.2439	.1981	.3429	.3429	.3086	.3429
21	.2134	.2134		.3086	.3086	.2915	.3086
22	.2134	.1981	.1524	.2743	.2439	.2134	.2439
23	.2134	.1829	.1524	.2134	.2439	.2134	.2439
24	.1524	.2134	.1829	.1524	.2134	.2439	.8573
Max	2.2634	2.1262	2.2862	2.2119	2.332	2.3663	2.0748
Min	.1372	.1372	.1372	.1372	.1524	.1715	.1219
Avg	.6087	.7561	.7626	.6432	.8326	.8431	.8913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274244 / 33/11 KV SAPATANE

Feeder No / Name : 202 / CHINCHOLI NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6687	.6516	.8059	.823	.8573	.0914
2	1.286	.9259	.6859	1.0802	.8573	.9088	.1067
3	1.2689	.9945	.823	1.3032	.8916	1.1831	.1219
4	1.2517	1.1831	1.0631	1.4232	1.0288	1.3717	.1524
5	1.3889	1.3032	1.3203	1.6632	1.2517	1.4575	.1829
6	1.4918	1.7661	1.5432	1.8004	1.4746	1.5432	.2439
7	2.1091	2.1605	1.9204	2.2805	1.7833	2.0919	.3048
8	1.829	1.89	1.89	2.1091	2.1776	1.869	.2134
9	1.8595	1.8595	1.4632	1.8861	1.9204	1.9033	
10		.1829	.2058	.1372	.1219	.1524	.1524
11		.1372	.1029	.2439	.1524	.1067	1.869
12		.12	.1029	.2134	.1067	.1067	
13	.1029	.1029	.12	.1829	.1067	.1219	
14	.12	.1029	.12	.1981		.1219	
15	.1372	.0857	.12	.1677	.0914	.0914	
16	.1067	.1219	.12	.1372	.1067	.1219	
17		.1067	.1372	.1886	.1372	.1372	
18	.1219	.1219	.1372	.2572	.2229	.1715	1.1584
19		.1524	.2286	.2572	.3086	.2058	1.4022
20	.2134	.2134	.2591	.3086	.3258	.2229	.3086
21	.1829	.1829		.2572	.2915	.1886	.2229
22	.1524	.1524	.1524	.2134	.2439	.1219	.1829
23	.1219	.1219	.1372	.1981	.2286	.0914	.1524
24	.5487	.5487	.5144	.6859	.823	.7888	.1067
Max	2.1091	2.1605	1.9204	2.2805	2.1776	2.0919	1.869
Min	.1029	.0857	.1029	.1372	.0914	.0914	.0914
Avg	.7929	.6336	.6008	.7499	.6729	.6640	.4102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 201 / 11 KV NIMGAON NO 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.12		.3658	.3353	.1715	.1886
2	.7316	.1372	.1715	.3658	.4115	.1715	.1886
3	.8535	.1372	.2058	.381	.4268	.1715	.2229
4	.9297	.1543	.2401	.381	.4572	.1715	.2401
5	1.0669	.1543	.2401	.4268	.503	.1715	.2401
6	1.4175	.1715	.2401	.442	.5639	.1886	.2572
7	1.3413	.1715	.2401	.4572	.5792	.1715	.3086
8	1.5394	.1543	.2401	.503		.2058	.2058
9	1.2803	1.448	1.5242	.4572	.5487	1.3717	1.2498
10		.1715	.1886	.5316	.0857	.1715	.1543
11	.1372	.1715	.1715	.0686	.0857		.1543
12	.1372	.1715	.1715	.0857	.0857		
13	.12	.1715	.2058	.12	.0857	.0857	
14	.12	.1715		.12	.0857	.0857	
15	.1029	.1715	.442	.1029	.0857	.0857	
16	.12	.1715	.4115	.1029	.1715	.1543	
17	.12	.1715	.0857	.12	.1715	.1715	
18	.1029	.1715	.0686	.12	.1715	.1886	.1543
19	.1029	.1715	.0857	.12	.3258	.2058	.1372
20	.12	.2401	.1029	.1372	.1715	.2229	.1372
21	.12	.2401	.12	.12	.1715	.2401	.12
22	.12	.2058	.1029	.12	.1715	.2572	.1372
23	.1029	.2058	.1029	.1029	.1715	.1886	.1543
24	.5487	.1029	.1715	.3963	.2572	.1715	.2058
Max	1.5394	1.448	1.5242	.5316	.5792	1.3717	1.2498
Min	.1029	.1029	.0686	.0686	.0857	.0857	.12
Avg	.5203	.2233	.2515	.2562	.2662	.2284	.2476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

MADHA SUB-DIVISION[806] BU 4806

Substation No/ Name :- 274245 / 33/11 KV NIMGAON

Feeder No / Name : 202 / 11 KV SULTANPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3429	.3429	.3086	.2401	.4287	.3658
2	.2915	.3772	.3429	.3086	.2401	.4115	.3658
3	.4115	.4115	.3429	.4115	.2572	.4287	.3963
4	.4458	.4458	.3429	.3963	.2572	.4287	.4268
5	.4801	.463	.3429	.4801	.2572	.4287	.4725
6	.5144	.4801	.3429	.5144	.2743	.4287	.4877
7	.4287	.4973	.3429	.5144	.2743	.4287	.5487
8	.463	.5316	.3601	.5487		.4458	.5792
9	.3506	.463	.3429	.5144	.2401	.4287	.3086
10		.4733	.2229	.4115	.6401	.4115	1.0059
11	2.4234	2.5149	1.4327	.2401	.9145	1.2651	.3086
12	2.4387	.5144	.4115	.3086	.2591	.503	.3429
13	2.4691	.5144	.463	.2915	.2591	.5335	
14	2.4844	.5144		.2572	.6344	.6097	
15	2.4996	.4801	.4973	.2572	.5639	.6097	
16	2.4844	.4801	.6344	.2572	.5487	.6097	
17	2.4996	.4801	.6173	.2743	.5487	.7621	
18	.2572	.5144	.6001	.2743	.4115	.4115	.3944
19	.2915	.3429	.6173	.2572	.4115	.4458	.4287
20	.3086	.3429	.6173	.2572	.4287	.4973	.463
21	.3258	.3429	.5316	.2572	.4287	.5316	.5144
22	.3429	.3429	.5316	.2401		.5658	.5658
23	.2743	.3429	.5144	.2401		.463	.5487
24	.3258	.3086	.3429	.3772	.2401	.4287	.3506
Max	2.4996	2.5149	1.4327	.5487	.9145	1.2651	1.0059
Min	.2572	.3086	.2229	.2401	.2401	.4115	.3086
Avg	1.0045	.5217	.4842	.3416	.3966	.5211	.4671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 201 / WIRELESS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1989		.2286	.2134	.1989	.1829
2	.1981	.2652		.2134	.2439	.1989	.2134
3	.2134	.2984		.2134	.2743	.2652	.2134
4	.2286	.3647		.2743	.2896	.2984	.2134
5	.2591	.431		.3201	.3048	.3315	.2439
6	.3353	.3978		.3353	.3506	.3647	.3048
7							.3048
8	1.6461	1.7404		2.0271	1.829	1.989	
9	2.4387	2.2558		2.652	2.4387	2.1338	
10	2.4387	2.2405	2.2253	2.5857	2.2862	2.3472	
11	2.5606	2.4387	2.2862	2.5857	2.2558	2.4082	
12	2.4691	2.4996	2.3167	2.5857	2.4387	2.3929	
13	2.4387	2.2862	2.3015	2.5692	2.2558	2.2862	
14	2.2558	2.1795	2.2862	2.4863	2.1643	2.1948	
15	2.2558	2.1338	2.21		2.1338	2.0729	
16				2.3205			
18							2.713
19							2.713
20	.2321	.1829	.3201	.2896	.2652		2.4996
21	.2321	.2439	.2591	.2439			2.2862
22	.1989	.2439	.2439	.2439	.2321		2.0424
23	.1989	.2134	.2439	.2286	.2321		1.9509
24	.1829	.1989	.1829	.2286	.2134	.1989	.1829
Max	2.5606	2.4996	2.3167	2.652	2.4387	2.4082	2.713
Min	.1829	.1829	.1829	.2134	.2134	.1989	.1829
Avg	1.1035	1.0954	1.3523	1.1912	1.1345	1.3121	1.1475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 202 / PIMPALNER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2652		.2896	.2743	.3315	.2743
2	.2743	.2984		.2743	.3048	.3315	.2743
3	.3048	.3315		.2743	.3353	.3315	.2743
4	.3353	.4144		.3353	.3658	.3647	.3048
5	.3658	.4475		.3963	.3963	.4475	.3048
6	.4572	.5304		.3963	.4725	.4973	.3658
10			.2286				
11			.1829				
12			.1677				
16	2.2558	2.2405	2.2253		2.4387	2.1643	
17	2.652	2.2862	3.2922	2.9874	2.8178		
18	2.8826	3.0483	2.8654	3.0636	2.9007		
19	3.0178	2.5377	2.8654	2.9111	2.9835		
20	2.8178	2.4387	2.8959	2.713	2.8178		.3963
21	2.652	2.2558	2.6673	2.4996	2.5857		.3658
22	2.4863	2.1643	2.5301	2.3167	2.3205		.3201
23	.1989	2.1338	2.4387	2.2558	2.2377		.3048
24	.2439	.2652	.2439	.2896	.2591	.2818	.2439
Max	3.0178	3.0483	3.2922	3.0636	2.9835	2.1643	.3963
Min	.1989	.2652	.1677	.2743	.2591	.2818	.2439
Avg	1.4126	1.4439	1.8836	1.5002	1.5674	.5938	.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 203 / NIMGAON (T)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6575		1.8442	1.9509	2.13	1.9509
2	1.6766	1.8233		1.9052	2.0119	2.3205	1.9814
3	1.768	1.8233		2.0576	2.0729	2.4034	2.0119
4	1.829	1.989		2.271	2.1338	2.4034	2.0424
5	1.8595	2.3205		2.3624	2.1948	2.4863	2.1643
6	2.0119	2.4531		2.4691	2.2862	2.652	2.3167
7	2.3472	2.4863		2.7435	2.5758	2.652	2.4387
8		2.5194					2.5301
9			2.4082				2.652
20	.2652	.2134	.3353	.2743	.2984		.3048
21	.2321	.2439	.2743	.2743	.2652		.2439
22	.1989	.2743	.2591	.2439	.2652		.2134
23	.1989		.2439	.2286	.2652		.2134
24	1.4327	1.5089	1.5851	1.7833	1.7375	1.8233	1.9814
Max	2.3472	2.5194	2.4082	2.7435	2.5758	2.652	2.652
Min	.1989	.2134	.2439	.2286	.2652	1.8233	.2134
Avg	1.2787	1.6094	.8510	1.5381	1.5048	2.3589	1.6461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 204 / PIMPALNER GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287		.4973	.5487	.4801	.4458
2	.5316	.4287		.4973	.583	.463	.4458
3	.5487	.463		.4801	.6001	.5144	.4801
4	.583	.5487		.6001	.6344	.6001	.5487
5	.6001	.6001		.6859	.6687	.6687	.583
9	.6173	.6344	.7373	.6001	.6859	.6687	.5316
10	.5316	.6173	.6173	.6001	.4458	.6001	.5144
11	.4287	.5316	.5144	.5144	.4458	.5144	
12	.3772	.463	.4801	.463	.4801	.4801	
13	.3944	.4458	.3429	.463	.3944	.4458	
14	.4115	.4287	.3086	.463	.4115	.4115	
15	.4115	.4287	.3772	.4458	.3944	.4115	
16	.4115	.3944	.3601	.4458	.4115	.4287	
18							.6173
19							.7202
20	.6001	.7202	.7888	.7202	.6859		.8059
21	.6001	.6687	.6687	.6687	.6687		.6859
22	.583	.6001	.6001	.6001	.6001		.6344
23	.5487	.583	.5658	.5487	.5144		.583
24	.4801	.4973	.5144	.5144	.5144	.4801	.4115
Max	.6173	.7202	.7888	.7202	.6859	.6687	.8059
Min	.3772	.3944	.3086	.4458	.3944	.4115	.4115
Avg	.5096	.5268	.5289	.5449	.5382	.5119	.5720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 205 / Dahiwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	2.0576		2.5377	2.4006	2.3148	1.9814
2	2.0576	2.0576		2.5377	2.4691	2.3148	2.0119
3	2.0919			2.572	2.5034	2.4006	2.0119
4	2.1262	2.4006		2.5892	2.5377	2.4863	2.0424
5	2.1434	2.572		2.6406	2.572	2.572	2.0729
6	2.3663	2.572		2.7435	2.6749	2.7435	2.0424
7	2.8121	2.7435		2.9492	2.8635	2.7435	2.3472
8		2.8292					2.1338
9			2.6406				2.4006
10							2.4863
20	.0686	.061	.1543	.1543	.1543		.1715
21	.0686	.061	.1543	.1372	.1543		.1372
22	.0686	.0686	.1029	.1372	.1543		.1372
23	.0686	2.1262	.0514	.1372	.1372		.1372
24	1.989	1.8861	2.1262	.0514	2.3148	2.332	1.9509
Max	2.8121	2.8292	2.6406	2.9492	2.8635	2.7435	2.4863
Min	.0686	.061	.0514	.0514	.1372	2.3148	.1372
Avg	1.4904	1.7863	.8716	1.5989	1.7447	2.4884	1.6043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274025 / 33/11KV PIMPLNEAR SUBSTATION

Feeder No / Name : 206 / TAMBAVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429		.2572	.3086	.3429	.2743
2	.3601	.3429		.2572	.3086	.3429	.2743
3	.4115	.4287		.2572	.3258	.3429	.2743
4	.3944	.463		.2915	.3429	.3772	4.161
5	.4115	.5144		.3258	.3601	.4287	.3048
6	.4458	.5144		.3772	.4458	.4458	.3048
8	2.5206	2.4006		2.5034	2.21	2.4006	
9	2.7435	2.915		2.4863	2.3015	3.1379	
10	2.7435	3.1722	2.9835	2.4863	2.2405	3.035	
11	2.7606	2.915	3.1722	2.572	2.5606	3.1722	
12	2.7092	3.0521	3.1207	2.6749	2.6673	3.1036	
13	2.572	3.0178	3.155	2.6749	2.4387	3.0178	
14	2.5377	3.0007	***	2.6749	2.4387	2.9321	
15	2.4348		2.9664	2.6578	2.4082	3.0521	
16	1.8519	2.1434	2.2291	2.572	1.9814	2.2119	
17	2.7435	2.572	3.0007	3.2065	2.915		
18	2.7435	2.6749	3.0864	3.0864	2.915		3.3265
19	2.8292	2.5377	2.915	3.035	2.9504		3.3951
20	2.7435	2.2405	2.9492	2.7606	2.7435		
21	2.6578	2.6063	2.4006	2.6235	2.4006		3.0178
22	2.572	2.2862	2.3663	2.5549	2.4006		3.0693
23	2.3148	2.2558	2.3148	2.4863	2.2291		2.7949
24	.3772	.3429	.3086	.2572	.2915	.2915	.2743
Max	2.8292	3.1722	38.6146	3.2065	2.9504	3.1722	4.161
Min	.3601	.3429	.3086	.2572	.2915	.2915	.2743
Avg	1.9234	1.9427	5.0389	1.9600	1.8341	1.7897	1.7893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 201 / PARITE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.499	.3944	.5853
2	.3944	.5415	.373	.5788
3	.4115	.5853	.4108	.5175
4	.4748	.6468	.4854	.5359
5	.6173	.7095	.6173	.4854
6	.7373	.7282	.6859	.4572
7				2.2032
8				2.1472
9				2.5318
10				2.95
11				2.7905
12				2.652
13				2.5318
14				2.1582
15	3.035		2.6749	.9335
16	.5658		2.7263	.9795
17	.4801		2.8978	1.0608
18			3.0521	1.134
19			2.8995	1.2883
20	1.9204		2.9664	1.2936
21	1.8482		2.9843	3.3981
22	1.95		3.0691	3.4168
23			.5658	.6283
24	.4115	.5228	.4115	.5788
Max	3.035	.7282	3.0691	3.4168
Min	.3944	.499	.373	.4572
Avg	1.0185	.6047	1.7009	1.5765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 203 / Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.4973	.3521	.4239	.499	.4359
2	.4115		.3688	.4115	.4854	.4694
3	.4748	.5487	.4024	.4458	.4435	.503
4	.5144	.5729	.3856	.407	.5228	.5365
5	.5426	.6036	.3688	.4748	.5975	.5197
6	.6104	.6283	.4191	.5658	.6722	.503
7	.6001	.5228	.3688	.4917	.5359	.503
8	.5087	.4251	.4694	.4801	.5281	.57
9	.5144	.4294	.3688	.6783	.4668	.5197
10		.4572	.3856		.4294	.503
11		.4294	.3353	.3429	.3734	
12		.3326	.2515	.2883	.2926	.3353
13	.3429	.3174	.2515	.1543	.3292	.2683
14	.4458	.3109		.2035	.3395	.3185
15	.4239	.3142	.3018	.1543	.3658	.3353
16	.4801	.3547	.4024	.1715	.3881	.3353
17	.4801	.2218	.4359	.3086	.3734	
18	.4578	.3841	.503	.3772	.3547	.4694
19		.5175	.7209	.6001	.6219	
20	.703	.6173	.6371	.6344	.8029	.6706
21	.6516	.6283	.5365	.6001	.6161	.6539
22	.5596	.5975	.4527	.6001	.6722	.5197
23		.5304	.4024	.4973	.5228	.4694
24	.4409	.5041	.4191	.4239	.5041	.4359
Max	.703	.6283	.7209	.6783	.8029	.6706
Min	.3429	.2218	.2515	.1543	.2926	.2683
Avg	.5046	.4672	.4148	.4233	.4891	.4702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSI DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 204 / AKOLE BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.5377	1.7269	2.2291	2.4086	2.146
2	2.2043	2.6513	1.7772	2.1776	2.2916	2.1628
3	2.2291	2.5423	1.8442	2.1262	2.3655	2.0957
4	2.2291	2.4949	1.8945	2.1605	2.3101	2.1293
5	2.1605	2.4874	1.9113	2.1434	2.3152	2.1125
6	2.915	2.5206	1.9448	2.0919	2.2081	2.0454
7	.2572	2.9938	2.1795	2.4006	2.2032	1.8442
8	3.0007	3.0678	2.3137	2.4348		1.291
9	3.1379	3.3794	2.4813	3.0007		1.291
10		3.062	2.4143	2.3834		1.7101
11		2.6242		2.2634		2.364
12		2.6326	2.4478	2.4832		2.3472
13	2.7092	2.8193	2.3472	2.4177		2.2634
14	2.7263	2.4326	2.2634			2.1795
19		1.1203	1.1633	1.286		1.0978
20	.9602	1.2986	.9831	1.3032		.9831
21	1.0004		.8192	1.2517	.7392	.639
22	.6516	1.0829	.6554	.9088	.7655	.4424
23		2.5393	2.1795	2.3148	2.4508	2.2634
24	2.3148	2.7435	2.3975	2.3491	2.4272	2.1795
Max	3.1379	3.3794	2.4813	3.0007	2.4508	2.364
Min	.2572	1.0829	.6554	.9088	.7392	.4424
Avg	2.0355	2.4753	1.8813	2.0908	2.0441	1.7794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274027 / WARWADE

Feeder No / Name : 205 / Palwan ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4863	1.3169	2.2131	2.4006	2.5766	2.0454
2	2.5206	1.4415	2.2466	2.4691	2.4949	2.0119
3	2.5892	1.475	2.3137	2.4348	2.5393	2.0454
4	2.713	1.4998	2.2298	2.5095	2.4326	1.9784
5	2.9492	1.6263	2.2634	2.6749		1.9448
6	3.2065	1.8484	2.7328	2.713		2.2131
7	2.4863	2.809	2.7328	2.8317	2.4394	2.4813
8	2.713	2.9127	2.6658	2.8995	2.5606	2.5316
9	2.8978	2.8006	2.7161	1.8652	2.6242	1.9616
10		3.1047	2.5149	2.1195	2.4272	1.9448
11		3.6595	3.0011	2.8807	2.9813	2.8166
12		3.6969	3.3196	2.9492	3.2861	2.9843
13	3.0864	3.6782	3.3364	3.035	3.2487	3.1017
14	3.0693	2.4209	2.6825	2.0576	3.1927	2.7161
19		.9877	.8356	.9665	1.0164	.9831
20	1.0288	1.0829	.7865	.9774	1.1203	.852
21	.8916	.9328	.7373	.8059	.7842	.7373
22	.7545	.8131	.7045	.6952	.7392	.6706
23		2.5206	2.2801	2.5206	2.1472	1.8778
24	2.572	1.307	2.4143	2.572	3.1741	2.0957
Max	3.2065	3.6969	3.3364	3.035	3.2861	3.1017
Min	.7545	.8131	.7045	.6952	.7392	.6706
Avg	2.3976	2.0967	2.2363	2.2189	2.3214	1.9997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 201 / AKOLE(KH) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.6981	.1307	2.726	2.7073			
16			.2987	.3391	3.3608	3.5101	
24	2.3101		1.8484	2.2592	.8916	.9522	.9709
Max	2.6981	.1307	2.726	2.7073	3.3608	3.5101	.9709
Min	2.3101	.1307	.2987	.3391	.8916	.9522	.9709
Avg	2.5041	.1307	1.6244	1.7685	2.1262	2.2312	.9709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 202 / SHIRAL (T) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				2.3908	2.1948	2.0424
16	2.4691	2.7435	2.7435			
24				2.1776	2.0424	2.0424
Max	2.4691	2.7435	2.7435	2.3908	2.1948	2.0424
Min	2.4691	2.7435	2.7435	2.1776	2.0424	2.0424
Avg	2.4691	2.7435	2.7435	2.2842	2.1186	2.0424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 203 / SURLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0424	1.6156	2.21	2.1948			
16	.0914	.1219	.0914	.1017	2.5301	2.4844	
24	1.3717	.2286	1.7375	1.6309	.3258	.2591	.2743
Max	2.0424	1.6156	2.21	2.1948	2.5301	2.4844	.2743
Min	.0914	.1219	.0914	.1017	.3258	.2591	.2743
Avg	1.1685	.6554	1.3463	1.3091	1.4280	1.3718	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274176 / 33/11kV SURLI

Feeder No / Name : 204 / SHIRAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3921	.3734	.4108	.3734	.3772	.3734	.3921
16	.1307	.168	.1867	.1372	.1867	.1867	
24	.2801	.2801	.2801	.2614	.2572	.2987	.3174
Max	.3921	.3734	.4108	.3734	.3772	.3734	.3921
Min	.1307	.168	.1867	.1372	.1867	.1867	.3174
Avg	.2676	.2738	.2925	.2573	.2737	.2863	.3548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 201 / KALWEL WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.6512	1.9052	1.8442	1.8591	2.0216	1.9966
2	1.5432	1.6667	1.9204		1.9216	2.0679	1.9966
3	1.5741	1.6975	1.9204		1.9841	2.0679	1.9966
4	1.5741	1.713	1.9357		2.0153	2.1296	1.9966
5	1.6204	1.713	1.9052		2.0309	2.1759	2.0271
6	1.6821	1.7284	1.9357		2.1091	2.1605	2.0576
7	1.7497	1.8056	2.332	2.3746		2.3472	
8	1.7654	1.8364	2.3472	2.4215	2.2377	2.3472	
9	1.6716	1.8364	2.271	2.3746	2.1605	2.332	
19	.0926	.108	.0305	.125	.1235	.1067	.125
20	.0772	.1389	.0914	.1094	.1235	.1219	.1406
21	.0617	.1235	.0914	.1094	.108	.1067	.125
22	.0617	.0133	.0914	.1094	.108	.0914	.1094
23	.0617	.108	.0914	.1094	.108	1.9052	2.2184
24	.787	1.0031		.945	1.5623	.9568	1.9509
Max	1.7654	1.8364	2.3472	2.4215	2.2377	2.3472	2.2184
Min	.0617	.0133	.0305	.1094	.108	.0914	.1094
Avg	1.0577	1.1429	1.3478	1.0523	1.3180	1.5292	1.3950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 202 / KADAM WASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.821	1.7223	1.5851	1.7341	1.5546	.0305
2	1.829	1.7985	1.7223	1.6918	1.7341	1.5546	.0305
3	1.829	1.8442	1.7375	1.7528	1.7654	1.5546	.0305
4	1.8442		1.7375	1.829	1.7654	1.5851	.0305
5	1.8442		1.5851	1.829	1.781	1.5851	.0305
6	1.8595	1.6309	1.6461	1.5242	1.7966	1.6004	.0305
7	1.929	1.8595	1.8747	1.8435		1.5242	1.9528
8	1.9444	1.89	1.89	1.8435	1.8442	1.6461	.9686
9	1.8673	1.9052	1.829	1.9216		1.6461	1.9528
10							1.9841
19	.0463		.0305	.0312	.0457	.0305	.0469
20	.0457		.0305	.0312	.0457	.0305	.0625
21	.061		.0305	.0312	.0457	.0305	.0469
22	.061		.0305	.0312	.0457	.0305	.0469
23	.061		.0305	.0312	.0457	.0305	.0469
24	.8078		1.2803	.8383	1.0936	.9145	.0305
Max	1.9444	1.9052	1.89	1.9216	1.8442	1.6461	1.9841
Min	.0457	1.6309	.0305	.0312	.0457	.0305	.0305
Avg	1.1906	1.8213	1.1452	1.1210	1.0571	1.0212	.4576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274186 / Parite

Feeder No / Name : 203 / PARITE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4372	.4096	.3401	.3239	.4119	.3401	.3563
2	.4372	.5079	.3725	.3563	.4477	.3563	.3725
3	.4858	.5571	.3725	.3887	.4835	.3725	.4049
4	.5344	.6062	.4049	.421	.5014	.4534	.421
5	.583	.639	.4858	.4534	.5373	.4696	.4372
6	.6154	.6062	.502	.4858	.5731	.4858	.4534
10	2.5446	1.9433	1.8947	1.945	1.3927	1.5384	
11	2.9767		2.4615	2.372	2.5911	2.3158	
12	3.1367	2.753	2.5263	2.5459	2.5587	2.4478	
13	.2881	2.8502	2.4453	2.2771	2.3967	2.2834	
14	.208	2.8502	2.4291	2.2771	2.3482	2.1376	
15		2.5263	2.3805	2.2929	2.332	2.2348	
16			2.4291	2.2929	2.3158	2.251	
17	.2427		2.332	2.2613	2.2672	2.3158	
18							2.5263
19	.4096		.3401	.3403	.3887	.3725	2.0729
20	.3932		.3563	.3761	.3401	1.2146	2.0405
21	.3605		.3239	.3761	.3077	1.2631	1.9109
22	.3768		.3239	.3761	.3077	1.3765	1.8623
23	.3932		.3239	.394	.3401	.3563	.3761
24	.421	.3932	.3401	.3239	.4119	.3401	.3563
Max	3.1367	2.8502	2.5263	2.5459	2.5911	2.4478	2.5263
Min	.208	.3932	.3239	.3239	.3077	.3401	.3563
Avg	.8247	1.3869	1.1692	1.1440	1.1627	1.2463	1.0454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 201 / UPALWATE BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0305	.0358	.0358	.0305	.0358	.0343
2	.0358	.0305	.0358	.0358	.0305	.0358	.0343
3	.0358	.0305	.0358	.0358	.0305	.0358	.0343
4	.0358	.0305	.0358	.0358	.0305	.0358	.0343
5	.0358	.0305	.0358	.0358	.0305	.0358	.0343
6	.0358	.0305	.0358	.0358	.0305	.0358	.0343
7	.0358	.0152	.0358	.0358	.0152	.0358	.0343
8	.0358	.0152	.0358	.0305	.0179	.0358	.0343
9	2.8045	2.6216	2.8166	2.713		1.406	
10	2.7587	2.5911	2.8807	2.6216		2.0576	
11	2.9264	2.6825	2.9447			2.2634	
12	2.8959	2.713	3.0087	2.713	3.0045	2.5034	
13	2.713	2.6825	2.9127	2.713	.0716	2.4348	
14	2.6368	2.6216	2.8166	2.6216	2.8464	2.5377	
15	2.5606	2.5301	3.1341	2.6216	2.9096	2.572	
16	2.5911	2.5911	2.8807	2.5911	2.9412	2.4348	
17	.0152	.0152	.032	.0152	.0358	.0343	
18	.0152	.0358	.0358	.0305	.0362	.0343	
19	.0305	.0358	.0358	.0305	.0358	.0343	2.5606
20	.0305	.0358	.0358	.0305	.0358	.0343	2.5301
21		.0358	.0358	.0305		.0343	2.5301
22	.0305	.0358	.0358	.0305	.0358	.0343	2.5606
23	.0305	.0358	.0358		.0358	.0343	2.4996
24	.032	.0305	.0358	.0358	.0305	.0036	.0343
Max	2.9264	2.713	3.1341	2.713	3.0045	2.572	2.5606
Min	.0152	.0152	.032	.0152	.0152	.0036	.0343
Avg	.9721	.8961	.9985	.8673	.6118	.7808	.9278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 202 / DAHIWALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2134	.2328	.2507	.2134	.2507	2.5377
2	.2507	.1981	.2507	.2507	.2134	.2507	2.4348
3	.2507	.1981	.2507	.0358	.2134	.2507	2.332
4	.2686	.1981	.2507	.2507	.2134	.2507	2.1948
5	.2686	.1981	.2507	.2507	.2134	.2507	2.0919
6	.2865	.2134	.2507	.2507	.2286	.2328	1.989
7	.2865	.1981	.2507	.2507	.1829	.2328	2.3663
8	.2507	.1677	.1791	.1829	.197	.1791	2.6749
9	.1372	.1372	.1433	.1524	.1433	.1372	.0914
10	.1219	.1067	.1254	.1219	.1433	.1029	
11	.0914	.0914	.1254	.1067	.1433	.1372	
12	.0762	.0914	.1254	.0762	.1075	.0686	
13	.0762	.0914	.1254	.0762	.1075	.1372	
14	.0762	.0914	.1254	.0762	.1075	.1029	
15	.0762	.0914	.1075	.0762	.1075	.0686	
16	.061	.0762	.0895	.061	.1075	.1372	
17	2.652	2.7435	3.0087	2.9569	2.9447	3.155	
18	2.9569	3.6176	3.1687	3.0178	3.4568	3.2922	
19	3.0178	3.5818	3.1687	2.8654	3.1367	3.1893	.1524
20		2.8464	3.0407	2.8959		2.8807	.1524
21	2.5911	2.5606	2.8807	2.652	2.5926	2.8121	.1372
22	2.4691	2.4006	2.8487	2.3777	2.4646	2.7435	.1372
23	2.3167	2.372	2.8807	2.3167	2.3045	2.6406	.1219
24	2.4646	2.2253	2.4985	.2507	2.2253	2.3045	2.572
Max	3.0178	3.6176	3.1687	3.0178	3.4568	3.2922	2.6749
Min	.061	.0762	.0895	.0358	.1075	.0686	.0914
Avg	.9260	1.0296	1.0991	.9085	.9464	1.0753	1.4657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274187 / Dahiwali

Feeder No / Name : 203 / DAHIWALI BOGADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3525	.061	2.1445	2.2405	2.0119	2.3045	.0686
2	2.6505	.061	2.1765	2.2885	2.0729	2.3045	.0686
3	2.3685	.061	2.1506	2.3365	2.1338	2.3045	.0343
4	2.4646	.061	2.2725	2.3365	2.1948	2.4006	.0686
5	2.4646	.061	2.3685	2.5126	2.2558	2.4966	.0686
6	2.5606	.061	2.4326	2.5606	2.3472	2.6406	.0343
7	2.878	2.4387	2.8166	3.1878	2.5911	2.7046	.0686
8	2.7515	2.4387	2.4486		2.6246	2.7206	.0343
9	.061	.0457	.0716			.0686	2.5606
10	.0457	.0457	.0716		.0358	.0686	
11	.0305	.0305	.0358		.0358	.0343	
12	.0305	.0305	.0358		.0537	.0343	
13	.0305	.0305	.0537		.0537	.0686	
14	.0305	.0305	.0537	.0305	.0537	.0686	
15	.0305	.0305	.0358	.0457	.0537	.0343	
16	.0305	.0305	.0358	.0457	.0537	.0343	
17	.0305	.0457	.0358	.0457	.0358	.0343	
18		.0716	.0537	.0457	.0537	.0343	
19	.061	.0358	.0537	.061	.0716	.0686	.0762
20	.061	.0895	.0895	.061		.0686	.0914
21	.061	.0895	.0895	.061	.0895	.0686	.0914
22	.0762	.0895	.0895	.0762	.0895	.0343	.0914
23	.0762	.0895	.0895	.061	.0716	.0343	.0914
24	.0895	.0762	.0895	.0895	.061	.0716	.0343
Max	2.878	2.4387	2.8166	3.1878	2.6246	2.7206	2.5606
Min	.0305	.0305	.0358	.0305	.0358	.0343	.0343
Avg	.9233	.2544	.8248	1.0048	.8657	.8626	.2322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 201 / MIDC TEMBHURNI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5487	.6344	.6859	.6859	.4287	.3772
2	.6001	.6001	.6344	.6859	.6859	.4287	.3429
3	.6001	.6001	.6344	.6516	.5792	.4287	.3429
4	.6001	.5658	.6344	.6859	.6859	.4287	.2896
5	.6001	.5144	.6344	.6687	.6516	.4287	.3086
6	.6001	.4801	.6344	.6516	.6516	.4287	.3258
7	.463	.4801	.5144	.6173	.6516	.3772	.3429
8	.4801	.4458	.5144	.7373	.6687	.5144	.3601
9	.6516	.7202	.7373	.9088	.8573	.6516	.4287
10	.7545	.6859	.823	1.0802	.9602	.7888	.463
11	.9088	.823	.8573	1.0631	1.1145	.823	.4115
12	.8402	.7202	.823	1.0517	1.166	.8573	.4458
13	.8573	.8059	.7888	1.0802	1.0288	.823	.3772
14	.7716	.8059	.823	1.0974	1.0288	.823	.3944
15	.823	.8916	.8916	1.1145	.8573	.7888	.3944
16	.9088	.8916	.9088	1.2003	.9259	.823	
17	.7716	1.0117	.8745	1.2346	.9431	.8059	
18	.6344	.9431		.9774	.6516	.6687	
19	.6687	.6344	.823	.9088	.823	.5639	.3601
20	.6859	.6344	.7888	.7545	.6859	.6344	.4115
21	.6344	.6344	.823	.7202	.6173	.6001	.4287
22	.6173	.6344	.7621	.7373	.703	.6001	.4287
23	.6516	.6344	.823	.6859	.6001	.583	.4287
24	.5144	.5144	.6344	.7202	.6859	.6001	.3772
Max	.9088	1.0117	.9088	1.2346	1.166	.8573	.463
Min	.463	.4458	.5144	.6173	.5792	.3772	.2896
Avg	.6766	.6759	.7399	.8633	.7879	.6208	.3829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSIDIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 202 / KANHERGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.2915	.3353	1.3717	2.0576	1.3565
2	.3429	.3048	.2915	.3048	1.6766	2.0576	1.4784
3	.3429	.3201	.2915	.3048	1.9814	2.0576	1.6461
4	.3429	.3353	.2915	.3353	2.5911	2.2291	1.9204
5	.3429	.3353	.2915	.3506	2.6673	2.4863	2.271
6	.3429	.3506	.3601	.3658	2.7435	2.6578	2.5606
7					2.8197	2.8959	2.9569
8					2.774	2.8502	2.774
9					3.0007	2.6216	2.7435
10	2.332	3.3779	1.9966	2.1033			
11	3.0636		2.6216	2.8197			
12	1.8138	3.3436	2.9111	2.6825			
13	.1372	3.2407	3.2065	2.774			
14	.1219	3.2407	2.7435	2.6368			
15	.1219	3.1722	2.6063	2.7435			
16	.1219	3.1722	2.3929	2.774			
17	.1219	2.7435	2.3015	2.5606			
18	.1372					.2134	
19	.2286	.2915	.3048	.2286	.2572	.2134	.1981
20	.2591	.2915	.3048	.2591	.2572	.2439	.2134
21	.2743	.2915	.3353	.2286	.2572	.2439	.2286
22	.3048	.2915	.3353	.1981	.2572	.2286	.1981
23	.3201	.2915	.3506	.2134	.2572	.1981	.1829
24	.3429	.3048	.2915	.3506	1.0822	1.7147	1.3565
Max	3.0636	3.3779	3.2065	2.8197	3.0007	2.8959	2.9569
Min	.1219	.2915	.2915	.1981	.2572	.1981	.1829
Avg	.5599	1.3686	1.2260	1.2285	1.5996	1.5606	1.4723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274193 / MIDC TEMBHURNI

Feeder No / Name : 203 / VENEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	.4268	2.7435	1.8138	.4572	.5144	.3048
2	2.572	.4268	2.7435	1.89	.503	.5144	.3048
3	2.572	.4115	2.7435	2.0729	.5487	.5144	.3201
4	2.572	.3963	2.915	2.2558	.5487	.5144	.3506
5	2.572	.4268	3.0864	2.3015	.5792	.5144	.381
6	2.8807	.4572	.5487	2.5301	.5944	.5487	.381
7	3.0864	.4877	.7716	.2439			
8	3.3779	.4725	.8573	.2286			
9	2.713	2.915	.6554	.2286			
10						1.7833	2.1033
11					3.1722	2.4691	
12						2.5758	
13					3.3436	2.6216	
14						2.3472	
15						2.2558	
16					3.3093	2.5453	
17					3.2579	2.4539	
18					3.0864		
19	.4268	.5144	.4572	.381	2.915	.3353	.3963
20	.4572	.5144	.4572	.442	2.572	.3658	.4115
21	.4877	.5144	.4877	.5335	2.4006	.3658	.4268
22	.4572	.5144	.503	.5487	2.2291	.3506	.4115
23	.4572	.5144	.5182	.4572	.5144	.3353	.3963
24	2.2291	.4572	2.572	1.7071	.503	.5144	.3353
Max	3.3779	2.915	3.0864	2.5301	3.3436	2.6216	2.1033
Min	.4268	.3963	.4572	.2286	.4572	.3353	.3048
Avg	1.9622	.6300	1.4707	1.1756	1.7962	1.2220	.5018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274209 / 33/11 KV BHEND SUB STATION

Feeder No / Name : 201 / 11 KV BHEND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.1888	1.0364	1.4327	1.3717	.945	.3506
2	1.2803	1.6766	1.4022	1.6461	1.7985	1.1888	.3506
3	1.4632	1.6766	1.7985	1.7375	2.4387	1.4022	.381
4	1.4937	1.9814	1.829	2.1338	2.4996	1.7985	.4268
5	1.829	2.0729	1.5851	2.4387	2.4996	2.1033	.4725
6	2.1948	2.1338	2.1338	2.5301	2.5911	2.2862	.5182
7	2.713	2.9264		2.8349	2.9569	2.8045	
10							2.1338
19	.3353			.3048	.3658	.2743	.3658
20	.3353			.3048	.3353	.3048	.3658
21	.3353		.2591	.3048		.3201	.3048
22	.3048		.2439	.2743	.2134	.3048	.3048
23	.3048		.2134	.2743	.2439	.3048	.3048
24	.6706	.9145	.7011	1.0364	.5792	.7011	.3048
Max	2.713	2.9264	2.1338	2.8349	2.9569	2.8045	2.1338
Min	.3048	.9145	.2134	.2743	.2134	.2743	.3048
Avg	1.1115	1.8214	1.1203	1.3272	1.4911	1.1337	.5065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 201 / MITKALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2683	.0137	.1214		.1524	.1227
2	.2229	.2683	.1219	.156		2.2862	2.4486
3	.2229	.3045	.1219	.1715		2.4806	2.4486
4	.2229	.3224	.1372	.1715		2.5766	2.5286
5	.2229	.3224	.1372	.1886		2.6726	2.5926
6	.2229	.3353	.1524	.2058		2.7366	2.7046
7	.156		.1524	.2058		2.8166	2.8006
8	.1907		.1677	.1543			2.5606
9	.208		.1734	.1214			2.6246
10	2.7027		2.9371	3.1017	.1524	.1214	
11	3.1687	3.3608	3.1703	3.2726		.1734	
12	3.3699	3.5471	3.0636	3.3743	.1219	.1907	
13	.2328	3.4974	3.1093	3.2556	.1372	.208	
14	.2865	3.3813	3.0178	2.8858	.1219	.208	
15	.1677	3.2167	2.9874	2.8902	.1219	.1734	
16	.2686		2.9569	2.7469	.0914	.1734	
17	.3121		2.8502		.0914	.1734	
18	.1791	.1067	.1227	.048	.0914	.208	
19	.2515	.1219	.2058	.093	.1524	.208	
20	.2515	.1372	.2229	.116	.1524		.0505
21	.2686	.1829	.2058	.0907	.1524	.1387	.0617
22	.2686	.1372	.2229	.0629	.1372	.1227	.1036
23	.2515	.1372	.2229		.1372	.1227	.0854
24	.2058	.2515	.1524	.1214		.1219	.1052
Max	3.3699	3.5471	3.1703	3.3743	.1524	2.8166	2.8006
Min	.156	.1067	.0137	.048	.0914	.1214	.0505
Avg	.5866	1.1055	1.1094	1.0707	.1278	.8603	1.5170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 202 / MALEGAON CANAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2245	.2926	2.8006	2.4646			2.9416
2	2.4646	.3224	2.8487	2.5126		.2134	.2058
3	2.4646	.3511	2.915	2.5926		.2134	.4287
4	2.6406	.3511	2.915	2.6726		.2134	.463
5	2.7027	.3353	3.0312	2.7206		.2572	.4973
6	2.9264	.4191	3.1493	2.8746		.3086	.4801
7	3.0483		3.1659	3.0026		.3048	.463
8	2.9874	.3856	3.1493	2.9874		3.4873	
9	2.7183	3.2648		2.8746		3.299	
10	.1875			.2012	2.8178		
11	.2686	.2134	.3086	.2149			
12	.2328	.3601	.3772		.2134		
13	.3045						
14	.3582						
16						3.1356	
17						.3086	
18					2.5606	3.0483	
19	.4298	.2572	.4458		1.0974		
20		.2743		.4854	1.1126		3.0464
21	.2686	.4287		.3988	1.1279	2.9721	3.7849
22	.2865		.2915	.4161		3.1802	3.7685
23	.2865		.3086		.9907	3.1207	3.7685
24	2.1445	.2686	2.7526	2.1925		1.0059	3.1245
Max	3.0483	3.2648	3.1659	3.0026	2.8178	3.4873	3.7849
Min	.1875	.2134	.2915	.2012	.2134	.2134	.2058
Avg	1.5234	.5375	2.0328	1.9074	1.4172	1.6712	1.9144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 274232 / MITKALWADI S/S

Feeder No / Name : 203 / HARINAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.639	.0377		.5571	.056	.0457	.0543
2	.6718	.0377		.6226		.0457	.0543
3	.6882	.0377		.6882	.0747	.0305	.0543
4	.6882	.0566		.7373	.0747	.0305	.0543
5	.7865	.0566		.5243	.0747	.0457	.0724
6	.8356	.0566		.6882	.056	.0457	.0724
7	.9012	.0566		.7373	.056	.0457	.0543
8	.9503	.1132		.8848	.056	.0457	.0724
9	.9175	.8002		.8192		.0543	.0543
10	.0189			.0168	.7316	.6226	
11	.0189			.0339		.6882	
12	.0168	.0152		.0678	.9297	.7537	
13	.0168			.0678	.9602	.6882	
14	.0147	.0305		.0934	.9145	.5243	
15	.0189			.0747	.9145	.5079	
16	.0566	.0305		.0347	.8993	.4915	
17	.0566	.0305		.0747			
18	.0566	.0305	.0181	.0671	.0152	.0362	
19	.056	.0305	.0181		.0152	.0543	
20	.0747		.0181	.0693	.0457		.0187
21	.0335	.0152	.0181	.0141	.0457	.0362	.0187
22	.0335	.0152	.0181	.056	.0305	.0543	.0373
23	.0189	.0152	.0181	.056	.0305	.0543	.0373
24	.5571	.0189		.4588	.056	.0457	.0543
Max	.9503	.8002	.0181	.8848	.9602	.7537	.0724
Min	.0147	.0152	.0181	.0141	.0152	.0305	.0187
Avg	.3386	.0782	.0181	.3237	.3018	.2249	.0507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 408 / JINDAL EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.286			.1029		
2		1.286			.1029		
3		1.286			.1029		
4		1.286			.1029		
5		1.286			.1029		
6		1.286			.1029		
7		1.286			.1029		
8	1.0288	1.286	.6173	.6687	.1029	.6173	.6173
9		.7716			.6173		
10		.7716			.6173		
11		.7716			.6173		
12		.7716			.6173		
13		.7716			.6173		
14		.7716			.6173		
15		.7716			.6173		
16	1.5432	.7716	.5658	.6173	.6173	.6173	.6173
17	.9259			.1029			.7716
18	.9259			.1029			.7716
19	.9259			.1029			.7716
20	.9259			.1029			.7716
21	.9259			.1029			.7716
22	.9259			.1029			.7716
23	.9259			.1029			.7716
24	1.0288	.9259	.6173	.6173	.1029	.6687	.6687
Max	1.5432	1.286	.6173	.6687	.6173	.6687	.7716
Min	.9259	.7716	.5658	.1029	.1029	.6173	.6173
Avg	1.0082	1.0227	.6001	.2624	.3450	.6344	.7305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

BARSII DIVISION[531]

TERMBHURNI S/DN.[821] BU 4821

Substation No/ Name :- 278022 / 220/33 kV TERMBHURNI EHV

Feeder No / Name : 409 / MILLENIUM EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1317			.7716		
2		1.1317			.7716		
3		1.1317			.7716		
4		1.1317			.7716		
5		1.1317			.7716		
6		1.1317			.7716		
7		1.1317			.7716		
8	1.286	1.1317	1.1317	1.0288	.7716	1.3375	1.3375
9		.6173			1.1317		
10		.6173			1.1317		
11		.6173			1.1317		
12		.6173			1.1317		
13		.6173			1.1317		
14		.6173			1.1317		
15		.6173			1.1317		
16	1.1317	.6173	1.0802	1.1317	1.1317	1.286	1.2346
17	1.5432			1.0288			1.1317
18	1.5432			1.0288			1.1317
19	1.5432			1.0288			1.1317
20	1.5432			1.0288			1.1317
21	1.5432			1.0288			1.1317
22	1.9547			1.0288			1.1317
23	1.5432			1.0288			1.1317
24	1.1317	1.5432	.9259	.9259	1.0288	1.1831	1.1831
Max	1.9547	1.5432	1.1317	1.1317	1.1317	1.3375	1.3375
Min	1.1317	.6173	.9259	.9259	.7716	1.1831	1.1317
Avg	1.4763	.9138	1.0459	1.0288	.9562	1.2689	1.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274028 / 33/11 KV ANDHALGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHUPSANGI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
12	1.9919
Max	1.9919
Min	1.9919
Avg	1.9919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 201 / 11KV HULJANTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.2209	1.3413	1.3748		
2	1.3413	1.4582	1.5089	1.4419		
3	1.5927	1.8821	1.6933	1.5424		
4	1.6766	2.0348	1.8778	2.0119		
5	1.7604	1.4752	2.0957	2.1293		
6	1.8442	2.1874	1.8945	1.9616		
7	1.9281	2.1704	2.3472	2.0119		
8	1.9951	2.1195	1.8442	1.9951		
9	1.7404	2.3061	2.146	2.0119		
19	.4527	.4409	.4359	.4694		
20	.4694	.4917	.4862	.503		
21	.4191	.4748	.4359	.503		
22	.3681	.4409	.4191	.4359		
23	.2753	.4239	.4024	.3688		
24	1.0898	1.153	1.0395	1.0562	1.3735	.1696
Max	1.9951	2.3061	2.3472	2.1293	1.3735	.1696
Min	.2753	.4239	.4024	.3688	1.3735	.1696
Avg	1.2085	1.3520	1.3312	1.3211	1.3735	.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 202 / 11 KV SODDI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1492	.1006	.116	.0995		
2	.1492	.1006	.0995	.0995		
3	.1492	.1006	.0995	.0829		
4	.1492	.1174	.116	.116		
5	.1492	.1174	.1326	.1326		
6	.1658	.1509	.1492	.1658		
7	.1658					
8	.1658					
9	.1658					
10	.1492	.1509		.116		
11	2.0553	.8048		.8619		
12	2.1879	1.8107		1.6575		
13	2.2045	1.8442		1.4918		
14	1.8399	1.6933		1.4255		
15	1.873	1.8107		1.5249		
16	1.7736	1.8442		1.6244		
17	1.9725	1.8107		1.6741		
18	1.9062	1.4419		1.7404		
19	.1658	.1341		.1326		
20	.1326	.1509		.1492		
21	.1492	.1677		.1326		
22	.1326	.1509		.1326		
23	.116	.1341		.1326		
24	.1658	.1006	.116	.116	.1006	.7042
Max	2.2045	1.8442	.1492	1.7404	.1006	.7042
Min	.116	.1006	.0995	.0829	.1006	.7042
Avg	.7597	.7018	.1184	.6480	.1006	.7042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 203 / 11 KV MARAWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.7604	1.9204	1.9204		
2	1.8233	2.2405	2.2405	2.2405		
3	2.1216	1.2803	2.4006	2.0805		
4	2.3205	2.4006	2.5606	2.5606		
5	2.4863	2.2405	2.7206	2.4006		
6	2.4863	1.9204	2.4006	1.4403		
7	1.8233	2.7206	2.7206	2.7206		
8	2.3205	2.2405	2.4006	1.7604		
9	1.989	2.4006	2.7206	2.4006		
15				1.4403		
19	.8288	.6401		.6401		
20	.8192	.6401		.6401		
21	.8192	.6401		.6401		
22	.8192	.6401		.4973		
23	.8192	.6401		.4973		
24	1.6575	1.6004	1.2803	1.2803	1.1336	.3239
Max	2.4863	2.7206	2.7206	2.7206	1.1336	.3239
Min	.8192	.6401	1.2803	.4973	1.1336	.3239
Avg	1.6528	1.6004	2.3365	1.5725	1.1336	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 204 / Gaothan Huljanti

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.6661	.6135	.6135		
2	.4973	.7011	.5959	.5959		
3	.6135	.7186	.5959	.5959		
4	.7362	.8063	.631	.6733		
5	.964	.8505	.815	.9391		
6	1.0774	1.0745		.9391		
7	1.1393	1.182	1.1283	1.1283		
8	.9945	1.0227	1.0745	.7888		
9	1.0867	1.0562	1.0059	1.1065		
10	.6299	1.073		1.1233		
11	1.2597	1.0059		.9389		
12		1.0059		.9389		
13	.6485	.9389		.6935		
14	1.1744	.7011		.7712		
15	1.2971	.9221		.7362		
16	.5959	.9389		.5609		
17	1.5546	.9054		.9054		
18	.7682	1.0898		.9724		
19	1.1523	1.1191		1.0631		
20	1.1888	1.1203		.9922		
21	.695	1.0029		1.0852		
22	.8048	.8505		1.1065		
23	.9145	.8063		1.1401		
24	.6135	.7011	.631	.631	1.1736	.9724
Max	1.5546	1.182	1.1283	1.1401	1.1736	.9724
Min	.4973	.6661	.5959	.5609	1.1736	.9724
Avg	.9103	.9275	.7879	.8766	1.1736	.9724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274031 / 33KV S/S HULJANTI

Feeder No / Name : 205 / 11 Kv Yedrav Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.3479	.3953	.3953		
2	.2753	.3163	.3953	.3953		
3	.2915	.4111	.4111	.3321		
4	.3077	.3953	.4111	.3479		
5	.3239	.3795	.3953	.3637		
6	.3239	.2846	.2846	.253		
7	.1619					
8	.2753					
9	.2753					
10	.2429	.2214		.2056		
11	2.3434	1.7078		1.5497		
12		2.625		2.5617		
13	2.6246	2.6566		2.7989		
14	2.0934	2.7673		2.6408		
15	2.3903	2.7199		2.6092		
16	1.6404	2.3878		2.4985		
17	1.9841	2.6092		2.5775		
18	2.2809	2.5301		2.4669		
19	.3563	.2372		.253		
20	.3725	.3479		.427		
21	.3401	.3953		.4111		
22	.3887	.4111		.427		
23	.4372	.4111		.4161		
24	.2915	.3953	.4111	.4111	.3725	1.3443
Max	2.6246	2.7673	.4111	2.7989	.3725	1.3443
Min	.1619	.2214	.2846	.2056	.3725	1.3443
Avg	.8825	1.1694	.3863	1.1591	.3725	1.3443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 201 / 11 kv Hunnur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943		.2267	.2591	.1781	.1372	.8097
2	.1943		.2267	.2591	.1781	.0972	.8907
3	.2105		.2429	.2915	.2267	.1296	.9393
4	.2429		.2591	.3239	.2591		1.004
5	.3239		.2915	.3563	.3239		1.1822
6	.3887		.3887	.4049	.421		1.4575
7	.3563		.3725	.3401	.3563		1.6194
8	.2591		.2429	.2429	.2429		.8421
9	.1943		.1619	.1781	.1781	.1619	1.4251
10		.1457	.1296	.1457	.1457	.1457	.1781
11	.664		.8583	.6802	.7449	.6154	.0972
12	1.9919		1.7166	1.7814	1.7004	1.7004	.0972
13		1.6842	1.7328	1.7976	1.7004	1.6842	
14		1.9433	1.7004	1.587	1.7661	1.4575	
15		1.8138	1.7652	1.7166	1.7814	1.2955	
16		1.7004	1.6194	1.7166	1.8138	1.4575	
17		1.6842	1.9271	1.8623	1.668	1.7652	
18		1.6518	1.8785		1.8785	1.7166	.1296
19		.2591	.2915	.2753	.2105	.2429	.2753
20		.2753	.2591	.3239	.2429	.2591	.2915
21		.2591	.2429	.2753	.2134	.2429	.2915
22		.2429	.2429	.2267	.1781	.2267	.3077
23		.2105	.2429	.1943	.1457	.2105	.1943
24	.1781		.2105	.2753	.1943	.1457	.6478
Max	1.9919	1.9433	1.9271	1.8623	1.8785	1.7652	1.6194
Min	.1781	.1457	.1296	.1457	.1457	.0972	.0972
Avg	.4332	.9892	.7179	.6745	.6978	.7206	.6674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 203 / 11 Kv Mahamdabad Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152		.0305	.0305	.0152		.0762
2	.0152		.0305	.0457	.0152		.0762
3	.0152		.0305	.0457	.0152		.1067
4	.0152		.0457	.0457	.0152		.1067
5	.0305		.0457	.0457	.0457		.1219
6	.061		.0457	.0457	.061		.2286
7	.061		.0305	.0457	.061		.3658
8	.0305		.0305	.0305	.0457		
9	.0305		.0305	.0305	.0152		.2439
10	.0152	.0457	.0305	.0152	.0152	.0152	.0305
11	.0457		.1829	.061	.0457	.0457	.0305
12	.3506		.2439	.4572	.3086	.3506	.0305
13		.3963	.4115	.4268	.3506	.3353	
14		.4268	.3048	.3963	.4115	.3506	
15		.4725	.3048	.4268	.463	.3048	
16		.4572	.2896	.3963	.4115	.381	
17		.2743	.3963	.3963	.3963	.3658	
18		.2896	.442		.4268	.3201	.0305
19		.0152	.0305	.0457		.0152	.0305
20		.0457	.0305	.0305		.0305	.0305
21		.0457	.0305	.0152		.0305	.0457
22		.0457	.0305	.0152		.0305	.0457
23		.0305	.0305	.0152		.0305	.0457
24			.0305	.0305	.0152		.061
Max	.3506	.4725	.442	.4572	.463	.381	.3658
Min	.0152	.0152	.0305	.0152	.0152	.0152	.0305
Avg	.0572	.2121	.1296	.1345	.1649	.1862	.0948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 205 / MANEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.2058	.2172	.2058		.9088
2	.2058		.2058	.2353	.2058		1.0288
3	.2229		.2229	.2353	.2058		1.0802
4	.2401		.2401	.2715	.2229		1.166
5	.2572		.2743	.2715	.2572		1.2346
6	.2743		.2915	.2896	.2915		1.7147
7	.2915		.2743	.2896	.2743		2.3148
8	.1886		.1886	.2353	.2572		2.0576
9	.1886		.1448	.181	.1886		2.0748
10	.1543	.1886	.1629	.1886	.1715	.2401	.1267
11	.4287		1.1041	.7373	.7373	.4115	.1086
12	2.5034		2.0814	2.1434	2.4086	2.3491	.0905
13		2.4691	2.3529	2.1434	2.1776	2.332	
14		2.2634	2.371	1.9033	2.0062	2.0576	
15		2.4177	2.0814	2.0062	1.8861	2.0576	
16		2.1434	2.4072	2.0062	2.1262	2.0748	
17		2.2977	2.4434	2.1605	2.2119	2.2634	
18		2.2291	2.6606		2.2462	2.0405	.1267
19		.2058	.2534	.1886		.2058	.1991
20		.2229	.2353	.2229		.2058	.1991
21		.2229	.2353	.2058		.1886	.181
22		.2058	.2353	.2058		.1715	.1991
23		.2058	.2172	.1886		.1543	.181
24	.1886		.1886	.2172	.1715		.6859
Max	2.5034	2.4691	2.6606	2.1605	2.4086	2.3491	2.3148
Min	.1543	.1886	.1448	.181	.1715	.1543	.0905
Avg	.4115	1.2560	.8783	.7280	.9606	1.1966	.8252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274032 / 33/11KV HUNNUR S/S

Feeder No / Name : 206 / Lonar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.6001	.6173	.9431		.12
2	.7202		.7202	.7373	1.0288		.12
3	.823		.8573	.8745	1.1145		.12
4	.9945		1.1145	1.3375	1.2003		.1372
5	1.1831		1.3717	1.5261	1.406		.1372
6	1.5261		1.6118	1.989	1.8861		.1372
7	2.0919		2.0576	2.0405	1.5947		.1543
8	1.3375		1.5432	2.0919			.1029
9	1.9719		1.9547	2.1262	1.4918		.1029
10	.1372	.2401	.1543	.3601	.1886		.2229
11	.1543		.12	.1715	.1543	.1543	1.0631
12			.12	.1715	.1543	.1029	2.1948
13		.12	.1029	.1372	.12	.1029	
14		.1029	.1372	.1372	.12	.1372	
15		.12	.1029	.1372	.1029	.1372	
16		.12	.1372	.12	.1029	.0857	
17		.1543	.1543	.1372	.1029		
18		.12	.1372		.1372	.0857	2.4691
19		.1715	.2572	.1886		.1543	.2915
20		.2058	.2401	.2743		.1543	.2572
21		.2058	.2401	.2572		.1543	.2572
22		.1886	.2229	.2229		.1372	.2401
23		.1886	.2229	.2058		.1372	.2229
24	.6001		.5144	.5658	.6516		.12
Max	2.0919	.2401	2.0576	2.1262	1.8861	.1543	2.4691
Min	.1372	.1029	.1029	.12	.1029	.0857	.1029
Avg	1.0160	.1615	.6123	.7142	.6944	.1286	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 201 / 11KV MARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.3384	.3384	
2	.3384	.3384	
3	.3384	.3429	
4	.3864	.4161	
5	.4268	.5121	
6	.6748	.7499	
7	.9804	.9442	
8	1.0242	.9922	
9	.8025		
10	.184		
11	2.0934		
12	3.0476		
13	2.7526		
17		1.0848	
18		1.0686	.2303
19		.2427	.298
20		.3045	.3841
21		.2427	.3045
24	.3199	.3155	
Max	3.0476	1.0848	.3841
Min	.184	.2427	.2303
Avg	.9791	.5638	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 205 / ITI COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1646	
2	.1629	.1646	
3	.1629	.1646	
4	.2033	.2241	
5	.2614	.2987	
6		.3547	
7	.3361	.2587	
8	.2614	.1867	
17		1.4529	
18		1.4548	.1772
19		.2195	.2378
20		.2561	.2926
21		.1791	.2149
24	.1629		
Max	.3361	1.4548	.2926
Min	.1629	.1646	.1772
Avg	.2142	.4138	.2306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274121 / 33/11KV MARAPUR

Feeder No / Name : 206 / GUNJEGAON FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	23-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.8185	1.8884	
2	1.8343	1.8564	
3	1.8343	1.8564	
4	1.866	1.9433	
5	1.7078	2.0553	
6		2.2186	
7	2.7349	2.8012	
8	2.769	2.9835	
17		.3121	
18		.3086	2.8837
19		.3801	.3841
20		.4805	.2957
21		.3511	.4572
24	1.7394		
Max	2.769	2.9835	2.8837
Min	1.7078	.3086	.2957
Avg	2.0380	1.4950	1.0052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 201 / 11 Kv Machnur new
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0549	.0514	.0549	.4268
2	.0514	.0514	.0514	.0549	.0514	.0549	.3963
3	.0514	.0514	.0514	.0549	.0514	.0549	.3963
4	.0514	.0514	.0514	.0549	.0514	.0549	.3963
5	.0514	.0514	.0514	.0549	.0514	.0549	.3963
6	.0514	.0514	.0514	.0549	.0514	.0549	.3963
7	.0514	.0514	.0514	.0549	.0514	.0549	.3963
8	.0514	.0514	.0514	.0549	.0514	.0549	.4572
9	.0514	.0514	.6859	.0514	.0514	.0514	.4641
10	.7926	.0514	.0514	.0514	.0514	.0514	.0549
11	.8383	.6097	.6859	.0514	.6554	.6097	.0549
12	.9145	.7926	.9945	.8078	.8535	.7316	.0549
13	.9602	.823	1.0288	.8078	.8383	.6859	.0549
14	.9602	.7164		.5182	.8078	.6706	.0549
15	.945	.7621	.8402		.6706	.6401	.0549
16	.8535	.7621	.7164	.7621	.7316	.5639	.0549
17	.823	.7164	.8573	.7164	.7701	.5182	.0514
18	.7926	.7164	.7537	.7316	.7373	.547	.0514
19	.0514	.0514	.0549	.0514	.0549	.0514	.0514
20	.0514	.0514	.0549	.0514	.0549	.0514	.0514
21	.0514	.0514	.0549	.0514	.0549	.0514	.0514
22	.0514	.0514	.0549	.0514	.0549	.0514	.0514
23	.0514	.0549	.0549	.0514	.0549	.0514	.0514
24	.0514	.0514	.0514	.0549	.0514	.0549	.4268
Max	.9602	.823	1.0288	.8078	.8535	.7316	.4641
Min	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.3605	.2802	.3196	.2282	.2877	.2425	.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 202 / 11 Kv Bramhpuri Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 River Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2439	.431	.3048	.2984	.0514
2	.2134	.2743	.2439	.3978	.3048	.2486	.0514
3	.1981	.2743	.2743	.3315	.2743	.2321	.0514
4	.2134	.2743	.2439	.2652	.2743	.2486	.0514
5	.2134	.2743	.2439	.2652	.2286	.2321	.0514
6	.2286	.3048	.2743	.2652	.2286	.2486	.0514
7	.2286	.3048	.2743	.2652	.2286	.2458	.0514
8	.2915	.3048	.3048	.2486	.2286	.2486	.0514
9	.061	.2439	.2591	.2286	.2572	.2286	.0549
10		.0686	.0686	.0686	.0686	.0686	.0549
11		.0686	.0686	.0686	.0686	.0686	.2652
12		.0686	.0686	.0686	.0686		.2984
13	.0686	.0686	.0686	.0686			.2486
14	.0686	.0686		.0686			.2486
15	.0686	.0686	.0686	.0686			
16	.0686	.0686	.0686	.0686			
17	.0686	.0686		.0686			
18	.0686	.0686	.0732	.0686		.0514	
19	.0686	.0686	.0732	.0686		.0514	.0686
20	.0686	.0686	.0732	.0686	.0732	.0514	.0686
21	.0686	.0686	.0732	.0686	.0732	.0514	.0686
22	.0686	.0686	.0732	.0686	.0732	.0514	.0686
23	.0686	.0686	.0732	.3048	.0732	.0514	.0686
24	.2743	.2439	.2439	.4144	.3048	.2984	.0514
Max	.2915	.3048	.3048	.431	.3048	.2984	.2984
Min	.061	.0686	.0686	.0686	.0686	.0514	.0514
Avg	.1405	.1556	.1571	.1796	.1843	.1653	.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 203 / 11kv GFSS Bramhapuri

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2172	.2058	.2172	.2058
2	.1886	.2058	.2058	.181	.2058	.2172	.2058
3	.2401	.2058	.2058	.181	.2058	.2172	.2058
4	.2401	.2743	.2058	.1993	.2058	.2172	.2401
5	.2572	.3086	.2743	.2715	.3086	.2896	.3086
6	.3772	.3429	.3429	.3439	.3429	.362	.3429
7	.3258	.3258	.3429	.3439	.3258	.3258	.3429
8	.2743	.2743	.2229	.3077	.2915	.3077	.3086
9	.2229	.2401	.2401	.2572	.2401	.2229	.2353
10	.2058	.2229	.2058	.2058	.2229	.2058	.2534
11	.2058	.1886	.2058	.1886	.2058	.2058	.181
12	.2058	.1886	.2229	.2058	.2058	.2058	.181
13	.2229	.1886	.2058	.1886	.2058	.2058	.1991
14	.1715	.1886		.1543	.1715	.1715	.2172
15	.1715	.1715	.1715	.1372	.1543	.1543	.1991
16	.1715	.1715	.1715	.1715	.1715	.1543	.1629
17	.1715	.1715	.1886	.1543	.181	.1715	.1715
18	.1715	.1543	.2172	.1886	.2172	.1886	.2058
19	.2058	.2058	.2896	.2401	.2534	.2401	.2915
20	.2572	.2572	.3258	.2572	.2896	.2572	.3086
21	.2572	.2572	.2715	.2572	.2896	.2572	.2915
22	.2229	.2401	.2534	.2572	.2715	.2572	.2572
23	.2229	.2058	.2534	.2229	.2534	.2401	.2229
24	.2229	.2058	.2058	.2353	.2058	.2353	.2058
Max	.3772	.3429	.3429	.3439	.3429	.362	.3429
Min	.1715	.1543	.1715	.1372	.1543	.1543	.1629
Avg	.2258	.2251	.2363	.2236	.2346	.2303	.2393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 204 / 11 KV BRAHAMPURI BORE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.4632	1.4937	1.6221	1.4632	1.6057	.0686
2	1.3108	1.4632	1.4937	1.6221	1.4937	1.6385	.0686
3	1.326	1.4632	1.4937	1.6712	1.4937	1.7695	.0686
4	1.3413	1.4937	1.5546	1.6712	1.4937	1.7695	.0686
5	1.3717	1.5546	1.6766	1.7204	1.6156	1.8351	.0686
6	1.4175	1.5546	1.6766	1.7859	1.6766	1.9006	.0686
7	1.6004	1.6461	1.6918	1.9498	1.768	2.0317	.0686
8	1.768	1.7985	1.829	2.0481	2.1776	1.9662	.0686
9	.061	1.8595	2.1434	1.9204	1.8442	1.9509	.0732
10	.0686	.0686	.0686	.0686	.0686	.0686	.0732
11	.0686	.0686		.0686	.0686	.0686	1.7695
12	.0686	.0686		.0686	.0686	.0686	1.9989
13	.0686	.0686		.0686	.0686	.0686	2.0481
14	.0686	.0686		.0686	.0686	.0686	1.9662
15	.0686	.0686	.0686	.0686	.0686	.0686	
16	.0686	.0686	.0686	.0686	.0686	.0686	
17	.0686			.0686	.0732	.0686	
18	.0686	.0686	.0732	.0686		.0686	
19	.0686	.0686	.0724	.0686		.0686	.0686
20	.0686	.0686	.0732	.0686	.0732	.0686	.0686
21	.0686	.0686	.0732	.0686	.0732	.0686	.0686
22	.0686	.0686	.0732	.0686	.0732	.0686	.0686
23	.0686	.0686	.0732	.0686	.0732	.0686	.0686
24	1.326	1.2803	1.3108	1.5402	1.4022	1.6057	.0686
Max	1.768	1.8595	2.1434	2.0481	2.1776	2.0317	2.0481
Min	.061	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.5741	.7160	.8952	.7713	.7852	.7931	.4445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274140 / 33/11KV Bramhapuri S/S

Feeder No / Name : 205 / Machnur AG-2

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0686	.0732	.0686	.0732	1.2803
2	.0686	.0686	.0686	.0732	.0686	.0732	1.2803
3	.0686	.0686	.0686	.0732	.0686	.0732	1.2803
4	.0686	.0686	.0686	.0732	.0686	.0732	1.2803
5	.0686	.0686	.0686	.0732	.0686	.0732	1.3108
6	.0686	.0686	.0686	.0732	.0686	.0732	1.3108
7	.0686	.0686	.0686	.0732	.0686	.0732	1.3565
8	.0686	.0686	.0686	.0732	.0686	.0732	1.4175
9	.0686	.0686	.0686	.0686	.0686	.0686	1.4582
10	1.3108	.0686	.0686	.0686	.0686	.0686	.0732
11	1.5089	1.2803	1.1736	.0686	1.3717	1.2955	.0732
12	1.4937	1.5699	1.6766	1.6461	1.4937	1.5546	.0732
13	1.4327	1.5546	1.6766		1.6004	1.5242	.0732
14	1.4937	1.5546	1.5242	.0686	1.7833	1.5546	.0732
15	1.4632	1.6766	1.3717		1.6918	1.4327	.0732
16	1.4937	1.6461	1.2041	1.6461	1.6766	1.5089	.0732
17	1.4632	1.4937	1.5242	1.4784	1.8023	1.5851	.0686
18	1.4632	1.6004	1.5546	1.5699	1.7204	1.5546	.0686
19	.0686	.0686	.0732	.0686	.0732	.0686	.0686
20	.0686	.0686	.0732	.0686	.0732	.0686	.0686
21	.0686	.0686	.0732	.0686	.0732	.0686	.0686
22	.0686	.0686	.0732	.0686	.0732	.0686	.0686
23	.0686	.0686	.0732	.0686	.0732	.0686	.0686
24	.0686	.0686	.0686	.0732	.0686	.0732	1.2498
Max	1.5089	1.6766	1.6766	1.6461	1.8023	1.5851	1.4582
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.5897	.5614	.5344	.3462	.5942	.5479	.5924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 201 / 11 KV KHOMNAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831	1.166	1.2193	1.5261	1.3717	1.2193	.1715
2	1.2174	1.2003	1.448	1.6804	1.4632	1.326	.1715
3	1.286	1.2346	1.4937	1.6975	1.6004	1.4632	.2058
4	1.5089	1.5261	1.6004	1.8519	1.6766	1.5242	.2401
5	1.8347	1.869	1.7528	2.4691	1.829	1.6004	.3429
6	2.2634	2.2977	1.8595	2.572	2.0881	2.0576	.4115
7		2.1434	2.5149	2.0576	2.5987	2.3167	.4115
8	2.2977	2.5377	2.652	2.7778	2.934	1.9204	.3258
9	2.4348	2.4006	2.4844	2.7263	2.7664	2.2862	.2572
10	.1715	.2058	.1715	.2572	.2229	.1677	.2229
11	.1543		.1886		.2401	.1886	1.5947
12	.1543	.1372	.1715		.2229	.1715	2.431
13		.1886	.1715	.2401	.2401	.1715	2.5652
14		.2058	.2572	.2401	.2401	.1715	2.2801
15		.2572	.2058		.2058	.2058	2.4813
16	.2229	.2915	.2401	.3086	.2401	.2401	2.431
17	.2572	.3086	.1715		.2743	.2229	2.5819
18	.2743	.2896	.3086		.2286	.2743	2.4082
19		.3353	.3601	.3353	.2134	.3772	.1981
20	.3086	.3353	.3429	.3201	.3353	.3258	.3048
21	.2743	.2896	.2743	.2743	.3048	.3086	.2286
22	.2743	.2286	.2743	.2286	.2439	.2743	.1829
23	.2229	.1981	.2401	.1981	.2134	.2058	.1677
24	1.1488	1.1317	.9907	1.2174	1.0669	1.1431	.1715
Max	2.4348	2.5377	2.652	2.7778	2.934	2.3167	2.5819
Min	.1543	.1372	.1715	.1981	.2058	.1677	.1677
Avg	.9205	.9034	.8914	1.2094	.9509	.8401	.9495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 202 / 11 KV DONGARGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2561	.1829	.2915	.2896	.3201	.8916
2	.2401	.2561	.1829	.2915	.2743	.3048	.9259
3	.2561	.2561	.1829	.3086	.2896	.3048	1.0631
4	.2561	.2721	.2439	.3086	.3048	.3048	1.4403
5	.3041	.3521	.2896	.3772	.3506	.3353	1.5089
6	.3681	.4001	.4268	.4287	.4572	.381	1.6118
7		.4531	.5182	.5144	.583	.5182	2.0062
8	.3521	.3437	.381	.4458	.4049	.381	2.0748
9	.2561	.3361	.2743	.3429	.3887	.2439	1.9052
10	.192	.2881	.2561	.3401	.2915	.2591	.2401
11	.7842		.9122	.8907	1.1174	.8097	.2429
12	1.8595	1.1043	1.9071	1.9662	1.9841	2.0309	.2267
13		1.8442	2.0424	1.8595	1.8278	1.906	.3239
14		1.9357	2.0119	1.6004	1.9216	1.8747	.3239
15		1.9204	1.9814	1.9814	1.8903	1.8122	.3239
16	1.9357		1.9357	1.9204	1.9216	1.8278	.3563
17	1.768	1.9204	2.2119	1.9052	2.0119	1.9841	.3563
18	1.0364	1.7528	.6687		.9907	2.2291	.2743
19		.3201	.3258	.3506	.1829	.3258	.4115
20	.3437	.3963	.3772	.4115	.4268	.3772	.442
21	.3201	.3353	.3772	.3658	.4115	.3601	.3658
22	.2881	.2743	.3258	.3201	.3658	.3429	.3506
23	.2561	.2743	.2915	.3048	.3506	.3258	.3353
24	.2241	.2286	.2743	.2915	.3048	.3353	.6173
Max	1.9357	1.9357	2.2119	1.9814	2.0119	2.2291	2.0748
Min	.192	.2286	.1829	.2915	.1829	.2439	.2267
Avg	.5929	.7055	.7742	.7747	.8059	.8289	.7758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274185 / 33/11 KV KHOMNAL SUBSTATION

Feeder No / Name : 203 / 11 KV KHOMNAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0373	.0373	.0373	.056
2	.0373	.0373	.0373	.0373	.0373	.0373	.056
3	.0373	.0373	.0373	.0373	.0373	.0373	.056
4	.0373	.056	.0373	.056	.056	.0373	.0934
5	.056	.0934	.0747	.0747	.0934	.0747	.112
6	.0934	.0934	.112	.0934	.112	.0934	.1494
7		.112	.1307	.112	.1307	.1307	.1307
8	.056	.0747	.056	.0934	.0934	.0747	.056
9	.056	.056	.0373	.0747	.0747	.0373	.056
10	.0373	.0373	.0189	.0373	.056	.0373	.0373
11	.0377		.0377	.0373	.0373	.0377	.0373
12	.0377	.0189	.0377	.0189	.0377	.0373	.0373
13		.0189	.0377	.0377	.0377	.0373	.0189
14		.0189	.0189	.0377	.0377	.0377	.0373
15		.0373	.0377	.0373	.0377	.0377	.0373
16	.0377	.0373	.0377	.0373	.0377	.056	.0373
17	.0373	.0373	.0373	.0373	.0373	.0373	.0373
18	.0373	.0187	.056		.0747	.056	.0373
19		.0747	.0747	.0934	.112	.0934	.056
20	.0934	.0747	.0934	.0934	.0747	.0934	.0762
21	.0747	.056	.056	.0747		.112	.0747
22	.056	.056	.056	.0457	.056	.0747	.0373
23	.0373	.0373	.0373	.0373	.0373	.056	.0373
24	.0373	.0373	.0373	.0373	.0373	.0373	.056
Max	.0934	.112	.1307	.112	.1307	.1307	.1494
Min	.0373	.0187	.0189	.0189	.0373	.0373	.0189
Avg	.0492	.0503	.0514	.0556	.0601	.0584	.0592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 201 / DAMAJINAGAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2218	.2957	.2829	.2614	.2218	.3881
2	.2587	.1848	.2957	.2641	.2614	.2218	.3881
3	.2772	.2402	.3326	.2263	.2801	.2957	.3109
4	.3142	.2772	.3326	.2263	.2987	.3326	.3475
5	.3475	.4024	.3696	.2641	.3174	.3696	.4251
6	.4207	.5121	.439	.3961	.4066	.4435	.462
7	.439	.4938	.4755	.4668	.4066	.4805	.462
8	.2926	.4572	.3696	.3734	.2987	.4066	.3511
9	.2195	.439	.3326	.3361	.4481	.3696	.3142
10	.1829	.3475	.3326	.2241	.4108	.3696	.2402
11	.3511	.2957	.3658	.2614	.2957	.3696	.2427
12	.3142	.4024	.4525		.2957	.4066	.2427
13	.2957	.3326	.3511		.2561	.2427	.2241
14	.3658	.2926	.3696	.3361	.2957	.3511	.2218
15	.3841	.2926	.3696	.3734	.3326	.2987	.2402
16	.3658	.3326	.2772	.4108	.3658	.2614	.2614
17	.4024	.3326	.3142	.3734	.3696	.2801	.2218
18	.4572	.3696	.4066	.4108	.4066	.3511	.2957
19	.5304	.4108	.462	.4108	.3734	.3881	.4481
20	.4938	.4481	.5544		.4805	.5175	.4481
21	.5121	.4481	.4805	.4251	.4066	.4251	.3361
22	.3841	.4066	.4066		.3696	.462	.2987
23	.3142	.3326	.3361	.3361	.2957	.4066	.2801
24	.2587	.2587	.2957	.3174	.2987	.2587	.4066
Max	.5304	.5121	.5544	.4668	.4805	.5175	.462
Min	.1829	.1848	.2772	.2241	.2561	.2218	.2218
Avg	.3517	.3555	.3757	.3358	.3430	.3554	.3274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 202 / Mangalwedha A.G. Feeder

SHEDDABLE RURAL

(M.I.D Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1663	.1478	.1698	.168	.1478	1.0852
2	.1478	.1478	.1478	.1698	.168	.1663	1.0852
3	.1663	.1663	.1663	.1886	.1867	.1848	1.17
4	.2218	.2033	.2033	.1886	.2054	.2033	1.2209
5	.2743	.2402	.2218	.2263	.2427	.2402	1.4074
6	.3109	.2957	.2561	.2641	.2801	.2743	1.56
7	.3109	.3142	.2926	.2263	.2957	.3475	1.8107
8	.2378	.2772	.2195	.3018	.2427	.2772	1.8442
9	.2378	.2218	.2033	.3395	.2241	.2587	1.8778
10	.1646	.1867	.1848	.2452	.2054	.1848	.2054
11	1.2039	1.2715	1.1869	1.291	1.1401	1.3226	.2241
12	1.7772	1.9281	1.7804		1.8564	1.6956	.2241
13	1.9951	1.7238	1.7764		1.8023	1.9951	.2427
14	1.8945	1.3923	1.7553	1.5912	1.7859	1.6617	.2402
15	1.9281	1.6712	1.7764	1.9062	1.7901	1.8442	.2218
16	1.9784	1.7072	1.6484	2.0317	1.7859	1.8945	.2241
17	1.989	1.6712	1.945	2.1548	1.8351	1.9448	.1663
18	1.9616	1.8842	1.8185	2.0809	1.9334	1.8945	.2033
19	.2402	.2033	.2204	.2801	.2587	.168	.3174
20	.2587	.2402	.2587	.2402	.2772	.2054	.2801
21	.2218	.2218	.2033	.2218	.2218	.2241	.2427
22		.1848	.2054	.1848	.1848	.2427	.2241
23		.1663	.1867	.1663	.1663	.2241	.2054
24	.1663	.1663	.1663	.168	.168	.1478	1.0513
Max	1.9951	1.9281	1.945	2.1548	1.9334	1.9951	1.8778
Min	.1478	.1478	.1478	.1663	.1663	.1478	.1663
Avg	.8107	.6938	.7071	.6653	.7260	.7396	.7223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

MANGALVEDHA[102]

BU 6351

Substation No/ Name :- 274227 / M.I.D.C. MANGALWEDHA

Feeder No / Name : 203 / M.I.D.C. Express Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0187	.0187	.0189	.0171	.0187
2	.0189	.0189	.0187	.0189	.0189	.0185	.0187
3	.0189	.0189	.0187	.0189	.0189	.0185	.0187
4	.0189	.0189	.0187	.0189	.0189	.0185	.0187
5	.0189	.0189	.0187	.0189	.0189	.0187	.0187
6	.0187	.0189	.0187	.0189	.0189	.0187	.0187
7	.0187	.0189	.0187	.0189	.0187	.0187	.0187
8	.0187	.0189	.0187	.0189	.0189	.0187	.0187
9	.0187	.0189	.0187	.0189	.0189	.0187	.0187
10	.0187	.0187	.037	.0189	.0187	.0187	.0189
11	.0187	.037	.0187	.0189	.0373	.0187	.0189
12	.0187	.037	.0187		.0373	.0187	.0189
13	.0187	.037	.0187		.0373	.0187	.0189
14	.0187	.037	.0187	.0187	.0373	.0187	.0187
15	.0187	.037	.0187	.0187	.0373	.0187	.0187
16	.0187	.037	.0187	.0187	.0373	.0187	.0187
17	.0187	.037	.0187	.0189	.0373	.0187	.0187
18	.0187	.0187	.0187	.0189	.0187	.0187	.0187
19	.0189	.0187	.0187	.0189	.0187	.0189	.0189
20	.0189	.0187	.0187		.0187	.0189	.0189
21	.0189	.0187	.0187	.0189	.0187	.0189	.0189
22	.0189	.0187	.0187	.0189	.0187	.0189	.0189
23	.0189	.0187	.0187	.0189	.0187	.0187	.0189
24	.0189	.0187	.0185	.0187		.0187	.0187
Max	.0189	.037	.037	.0189	.0373	.0189	.0189
Min	.0187	.0187	.0185	.0187	.0187	.0171	.0187
Avg	.0188	.0241	.0195	.0189	.0244	.0186	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 201 / DARSHAN MANDAP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.5281	.4115	.4115	.7167	1.2003
2	.4527	.3772	.5658	.4458	.3944	.7167	1.166
3	.4904	.4115	.6036	.4458	.3944	1.1317	1.166
4	.5281	.4115	.679	.5144	.4115	1.2071	1.2003
5	.5658	.4458	.7167	.6859	.4458	1.2826	1.286
6	.6036	.4801	.4715	.5487	.5658	1.358	1.5089
7	.6602	.4801	.5093	.4801	.5316	1.4335	1.4232
8	.583	.4115	.4338	.463	.463	1.2346	1.2346
9	.4458	.4115	.4338	.5281	.4287	1.2174	1.3203
10	.583	.5144	.4527	.5658	.6173	1.2689	1.358
11	.6859	.6516	.4527	.6224	.7545	1.3717	1.3014
12	.6859	.6859	.6036	.5658	.7545	1.5089	1.3957
13	.703	.7373	.679	.6413	.823	1.4575	1.6598
14	.703	.7373	.7167	.6224	.8488	1.4918	1.5655
15	.703	.7202	.679	.6224	.7922	1.4918	1.5278
16	.6859	.7733	.6602	.6036	.7922	1.4918	1.6598
17	.6859	.7733	.6173	.5658	.7922	1.4918	1.6598
18	.7545	.9431	.6859	.583	.9431	1.6632	1.6787
19	.823	1.0374	.9259	.7545	1.0562	2.0919	2.2445
20	.823	.9431	.7202	.7716	.9808	2.0576	2.2257
21	.6859	.8488	.7202	.6859	.8865	1.8347	2.0748
22	.5487	.5847	.6001	.5487	.7356	1.6289	1.6598
23	.4115	.5281	.4801	.4973	.5847	1.406	1.4335
24	.4527	.3944	.4904	.4115	.4287	.5658	1.3032
Max	.823	1.0374	.9259	.7716	1.0562	2.0919	2.2445
Min	.4115	.3772	.4338	.4115	.3944	.5658	1.166
Avg	.6116	.6116	.6011	.5661	.6599	1.3800	1.5106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 202 / 11KV GANESHNAGAR

SHEDDABLE URBAN

PANDHARPUR Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.7545	.7545	.7202	.7202	.8676	.823
2	.7922	.7202	.7545	.6859	.6859	.9054	.7373
3	.8299	.7716	.7922	.6859	.6859	.9054	.7373
4	.8676	.7888	.8299	.7716	.6859	.9431	.7373
5	.9054	.823	.8676		.703	.9431	.7373
6	.9431	.8573	.9242	.823	.8573	.9431	.9431
7	.9242	.583	.9431	.8573	.8573	.9808	.9088
8	.8573	.8059	.9242	.7888	.823	.8916	.8573
9	.7373	.6859	.7733	.7545	.823	.5373	.8676
10	.823	.6687	.7545	.7922	.823	.8059	.8676
11	.7373	.7545	.7167	.7922	.8059	.8059	.8488
12	.7716	.7716	.7922	.7167	.823	.823	.8488
13	.8059	.7202	.7922	.7356	.823	.823	.8488
14	.7545	.7373	.7545	.7167	.9242	.8573	.8299
15	.6859	.7545	.7922	.6979	.9242	.8573	.7922
16	.6859	.8299	.7922	.7922	.8676	.8573	.7922
17	.7888	.7922	.823	.7373	.8299	.8573	.7922
18	.7545	.811	.7888	.7545	.9242	.823	.9619
19	.8916	1.0374	.9945		1.0562	.9602	1.0562
20	.9431	1.0185	.9602		1.094	1.0288	1.1128
21	.9431	.9431	1.0288	.9602	1.1317	1.0288	.9808
22	.9259	.9997	.9088	.9431	1.1128	1.0117	1.0562
23	.8573	.9808	.8745	.8573	.9619	.9774	1.0374
24	.8676	.7373	.8676	.7888	.7716	.9054	.9088
Max	.9431	1.0374	1.0288	.9602	1.1317	1.0288	1.1128
Min	.6859	.583	.7167	.6859	.6859	.5373	.7373
Avg	.8301	.8061	.8418	.7796	.8631	.8892	.8785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 203 / CABLE EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	.0377	.0343	.0343	.4904	.0343
2	.0377	.0343	.0377	.0343	.0343	.0377	.0343
3	.0377	.0343	.0377	.0343	.0343	.0377	.0343
4	.0377	.0343	.0377		.0343	.0377	.0343
5	.0377	.0343	.0377	.0343	.0514	.0377	.0514
6	.0377	.0343	.0377	.0343	.0343	.0377	.0514
7	.0377	.0343	.0377	.0343	.0343	.0377	.0343
8	.0343	.0343	.0377	.0343	.0343	.0343	.0343
9	.0343	.0343	.0377	.0377	.0343	.0343	.0377
10	.0343	.0343	.0377	.0377	.0343	.0343	.0377
11	.0343	.0343	.0377	.0377	.0343	.0343	.0377
12	.0343	.0343	.0377	.0377	.0343	.0343	.0377
13	.0343	.0343	.0377	.0377	.0343	.0343	.0377
14	.0343	.0343	.0377	.0377	.0377	.0343	.0377
15	.0343	.0343	.0377	.0377	.0377	.0343	.0377
16	.0343	.0377	.0377	.0377	.0377	.0343	.0377
17	.0343	.0377	.0343	.0514	.0377	.0343	.0377
18	.0343	.0377	.0343	.0514	.0377	.0343	.0377
19	.0343	.0377	.0343	.0514	.0377	.0686	.0377
20	.0343	.0377	.0343	.0514	.0377	.0686	.0377
21	.0343	.0377	.0514	.0514	.0377	.0686	.0377
22	.0343	.0377	.0514	.0514	.0377	.0514	.0377
23	.0343	.0377	.0514	.0514	.0377		.0377
24	.0377	.0343	.0377	.0343	.0343	.0377	.0343
Max	.0377	.0377	.0514	.0514	.0514	.4904	.0514
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0354	.0354	.0388	.0407	.0364	.0604	.0379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 204 / 11 KV AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2058	.1509	.2229	.1886	.1132	.2401
2	.1886	.2401	.1509		.1886	.132	.2401
3	.2075	.2401	.1698	.2229	.1886	.1509	.2401
4	.2263	.2401	.1886	.2229	.1886	.1698	.2401
5	.2452	.2401	.2263	.2229	.2058	.2263	.2401
6	.2641	.2401	.2641	.2229	.2401	.2452	.2401
7	.3018	.2743	.2829	.2229	.2743	.2829	.3086
8	.2572	.3086	.3018	.2743	.2915	.2572	.3086
9	.2743	.3086	.2829	.3018	.3086	.2572	.3772
24	.1509	.1715		.2229	.1886	.0943	.2058
Max	.3018	.3086	.3018	.3018	.3086	.2829	.3772
Min	.1509	.1715	.1509	.2229	.1886	.0943	.2058
Avg	.2305	.2469	.2242	.2374	.2263	.1929	.2641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 205 / 11 KV SARGAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4801	.4527	.4115	.4801	.5658	.5144
2		.4458	.415		.4287	.6036	.5144
3	.4973	.4458	.4527	.3772	.4287	.6036	.5144
4	.5144	.4801	.4904	.4458	.4287	.6413	.5144
5	.5487	.5144	.5281	.5144	.4458	.6413	.5487
6	.5487	.5144	.5658	.5144	.5144	.6413	.6001
7	.4801	.4801	.5658	.5487	.4973	.5658	.5658
8	.4801	.4755	.4904	.4801	.463	.4801	.5316
9	.5487	.5281	.4904	.4904	.4458	.5487	.5658
10	.6173	.6413	.5281	.5281	.6516	.6859	.6036
11	.6687	.7545	.5658	.6224	.6859	.7888	.6224
12	.6687	.7733	.6979	.6602	.7202	.7888	.6224
13	.6859	.7167	.7167	.6602	.7545	.7888	.8488
14	.6687	.7167	.6979	.6413	.8299	.7888	.811
15	.6516	.7356	.679	.6413	.8676	.7888	.8299
16	.6344	.7356	.7545	.5658	.7922	.7888	.8488
17	.6516	.679	.6173	.5144	.7545	.7888	
18	.6516	.679	.6859	.4973	.7545	.7888	
19	.7545	.8676	.7545	.6859	.8676	.8916	
20	.7202	.7922	.7545	.6516	.8299	.8059	
21		.7545	.6516	.6344	.7545	.7716	
22	.6687	.6413	.583	.6001	.7167	.703	
23	.4801	.5658	.5144	.5658	.6413	.6173	
24	.5658	.4801	.5281	.4458	.5144	.5658	.5658
Max	.7545	.8676	.7545	.6859	.8676	.8916	.8488
Min	.4801	.4458	.415	.3772	.4287	.4801	.5144
Avg	.5994	.6207	.5909	.5520	.6362	.6935	.6248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274116 / 33/11 KV PADHARPUR (U)

Feeder No / Name : 206 / 11 KV AMBIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.823	.8299	.8402	.823	.7167	.9088
2	.8676	.823	.8676	.823	.823	.7545	.8745
3	.9242	.7716	.8676	.8573	.8573	.7922	.8745
4	.9431	.8573	.9431	.8745	.9431	.8299	.9088
5	.9808	.8745	.9808	.8745	1.0631	1.1317	.9945
6	1.4901	1.3546	1.4146	1.3032	1.3889	1.5278	1.4232
7	1.2071	1.0631	1.2449	1.0631	1.3375	1.3014	1.2689
8	.9088	.8916	.9619	.8745	.9088	.9774	.9088
9	.7373	.7716	.8299	.9242	.8745	.8402	.9619
10	.8402	.8059	.8865	.9808	.8916	.9259	.9242
11	.8402	.8573	.8676	.9431	.9259	1.0288	.9431
12	.8573	.9088	.9431	.9054	.9945	1.0288	.9431
13	.8745	.9602	.9242	.9997	1.0974	1.0288	.9808
14	.8916	.9431	.9431	.9619	1.1506	1.0117	.9431
15	.9259	.9259	.9808	1.0185	1.1317	1.0802	.9054
16	.9259	1.0185	.9431	.9242	1.1317	1.0802	1.1128
17	1.0288	1.0185	.8916	.8402	1.1317	1.0631	1.1506
18	1.0974	1.1128	1.0117	.8573	1.2637	1.1317	1.2071
19	1.3717	1.4523	1.3032	1.1317	1.5089	1.3889	1.5278
20	1.286	1.4146	1.286	1.166	1.3957	1.3717	1.4712
21	1.1488	1.226	1.1488	1.1317	1.3352	1.2517	1.3203
22	1.0288	1.1317	1.0802	1.0974	1.3203	1.166	1.226
23	.9088	1.0185	.9431	.9602	1.1883	1.0631	1.094
24	.9054	.8573	.9054	.8402	.8573		.9945
Max	1.4901	1.4523	1.4146	1.3032	1.5089	1.5278	1.5278
Min	.7373	.7716	.8299	.823	.823	.7167	.8745
Avg	.9941	.9951	.9999	.9664	1.0977	1.0649	1.0778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 201 / 11 KV Manisha Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.5487	.5316	.5658	.583	.6516	.6344
2	.5175	.5144	.4973	.5316	.5487	.6344	.6001
3	.4805	.4801	.463	.5144	.5144	.6001	.5658
4	.3511	.4973	.4801	.5316	.5144	.583	.5487
5	.4066	.5316	.4973	.5487	.583	.6173	.6173
6	.7023	.5658	.6344	.5487	.6516	.6344	.6687
7	.7577	.6344	.7716	.583	.7202	.6687	.703
8	.8686	.6344	.7716	.6173	.7545	.7373	.8059
9	.703	.5487	.7202	.583	.6859	.703	.703
10	.5487	.5544	.5914	.5914	.6653	.583	.7023
11	.5316	.5359	.5359	.5544	.5729	.583	.6283
12	.5487	.5175		.5544	.6283	.5658	.6099
13	.5144	.5359	.5359	.5359	.6838	.583	.5914
14	.5144	.5544	.5175	.5544	.6173	.583	.6283
15	.5144	.5729	.5544	.6099	.6173	.6173	.6468
16	.4801	.5359	.5729	.5316	.6001	.6173	.6099
17	.5611	.5249	.5973	.543	.5792	.6335	.583
18	.5611	.5792	.5973	.5973	.6878	.6697	.5658
19	.7783	.7964	.7783	.7964	.8507	.8326	.7888
20	.8326	.8326	.8326	.7964	.905	.8688	.823
21	.7783	.7783	.8145	.7602	.8688	.8326	.8059
22	.724	.7964	.7964	.7602	.8869	.8326	.7888
23	.6687	.6173	.6516	.703	.7716	.7545	.7888
24	.6653	.6001	.5658	.6001	.6173	.6859	.6687
Max	.8686	.8326	.8326	.7964	.905	.8688	.823
Min	.3511	.4801	.463	.5144	.5144	.5658	.5487
Avg	.6084	.5953	.6221	.6047	.6712	.6697	.6699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 202 / 11KV PANI PURWATHA EXP. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.2401	.3086	.1543	.3429	.3258	.2915
2	.3511	.1886	.4115	.1543	.3429	.3258	.3258
3	.3696	.12	.5487	.1543	.3944	.5487	.4973
4	.4435	.12	.6687	.3086	.4801	.8402	.583
5	.5914	.1543	.9774	.4458	.6001	.8745	.6001
6	.961	.2401	.9431	.5487	.703	.9774	.6001
7	1.0719	.2229	.9602	.5316	.703	.9774	.703
8	1.0534	.2058	.9431	.4973	.9431	.9602	.6859
9	1.046	.4973	.9088	.4973	.9088	.9431	.6516
10	1.0631	.5544	.961	.6283	.924	.9602	.7392
11	.9945	.5544	.924	.6653	.8501	.9431	.7577
12	.8916	.5359	.8871	.5914	.8871	.9602	.9425
13	.6173	.5175	.924	.5359	.8871	.9945	.9795
14	.4973	.7762	.8871	.5544	.6516	1.0288	.961
15		.8316	.7947	.5175	.5316	.8916	.9795
16		.7207	.8686	.3772	.583	.4801	.9055
17	.8589	.7095	.5041	.4108	.8962	.5228	.8402
18	.8402	.8962	.4854	.4294	.8589	.5228	.6344
19	.8215	.5041	.2241	.5041	.5228	.6348	.6173
20	.3921	.2427	.2054	.2241	.3174	.5975	.5487
21	.2241	.2241	.168	.2427	.3921	.2987	.1886
22	.2241	.2614	.1867	.2987	.3921	.2801	.2058
23	.2229	.3772	.2401	.3944	.4973	.2058	.4115
24	.462	.2401	.3601	.1543	.3944	.3258	.2401
Max	1.0719	.8962	.9774	.6653	.9431	1.0288	.9795
Min	.2229	.12	.168	.1543	.3174	.2058	.1886
Avg	.6547	.4140	.6371	.4092	.6252	.6842	.6204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 203 / 11 KV ISBAWI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.8402	.823	.8745	.7888	.9431	.9774
2	.961	.8059	.7888	.7888	.7888	.823	.9431
3	.8871	.7716	.7545	.7545	.7716	.8059	.9259
4	.7762	.7202	.7373	.7888	.7373	.8059	.9431
5	.8871	.8059	.7545	.8573	.8916	.9088	.9945
6	1.0719	.9088	.9945	.8745	1.046	1.0288	1.0631
7	1.1827	1.0117	1.046	1.046	1.0974	1.1145	1.166
8	1.0349	.9945	.9774	.9774	1.046	.9945	1.0288
9	.8916	.8059	.9774	.8745	1.0631	.9945	1.0288
10	.8745	.8871	.8871	.9055	1.1088	.9431	1.0719
11	.8573	.924	.8501	.9055	.9795	.9259	.9979
12	.8402	.8871	.961	.961	1.0903	.8745	.9795
13	.8865	.8501	.9979	.9979	1.1088	.9602	.9979
14	.8059	.7577	.8871	.961	1.0288	1.0117	1.0349
15	.823	.924	.9055	.9979	.9774	1.0288	1.0719
16	.8059	1.0349	.9425	.9945	.9945	1.0288	1.0903
17	.9055		1.1458	1.1088	1.1088	1.0349	.9945
18	1.0534	.8686	.9979	1.1643	1.1273	1.0719	1.0288
19	1.2752	1.3491	1.1273	1.1643	1.2752	1.2936	1.1488
20	1.1827	1.2936	1.1827	1.1643	1.3121	1.2567	1.2689
21	1.1273	1.1827	1.1273	1.1458	1.2936	1.2752	1.2003
22	1.0349	1.1643	1.1088	1.1273	1.3121	1.2567	1.166
23	.9088	.9945	1.0288	1.0117	1.0802	1.1488	1.0974
24	1.0349	.8745	.8573	.9602	.8745	1.046	1.0117
Max	1.2752	1.3491	1.1827	1.1643	1.3121	1.2936	1.2689
Min	.7762	.7202	.7373	.7545	.7373	.8059	.9259
Avg	.9535	.9416	.9525	.9753	1.0376	1.0240	1.0513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR (U)[099] BU 6319

Substation No/ Name :- 274144 / 33/11 KV LINK ROAD

Feeder No / Name : 402 / 33KV Bandishegaon
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.9856	7.3045	8.4877	8.9506	9.0021	9.0021	9.5679
2	8.3162	8.8477	8.8477	9.7222	9.2593	9.1564	10.0309
3	9.2587	9.4136	9.465	9.5679	9.3622	9.465	10.6482
4	8.9815	9.8766	9.8251	9.8766	9.5679	9.8766	11.214
5	9.3141	10.0823	10.3395	10.1338	9.8766	10.391	11.3169
6	9.5359	9.0021	8.8477	10.2881	8.3848	9.105	11.6255
7	10.3675	8.7963	8.5905	9.8251	8.0761	8.8992	6.1214
8	9.5913	6.5329	9.2593	8.1276	9.2593	9.5679	9.1564
9	4.1152	6.3272	9.3107	7.9733	9.465	10.751	11.8313
10	1.6975	1.9404	2.1068	1.9959	1.9404	1.9547	2.2177
11	2.6235	10.9774	10.423	5.7659	6.0431	1.5947	12.1416
12	12.5	13.9158	10.0349	13.5831	12.7515	6.4815	13.7494
13	12.4486	12.8069	12.5852	12.7515	13.0287	13.0659	1.386
14	6.2757	6.4312	6.4866	6.5975	5.5556	10.0823	1.4415
15	3.6008	8.7597	9.8131	3.8809	8.1276	8.179	1.3306
16	9.928	10.6447	13.5277	9.1564	8.6934	10.6996	1.386
17	13.8049	12.6961	13.1396	11.3655	11.1991	6.3758	1.3375
18	13.195	12.8069	12.8069	12.5852	12.2525	14.0267	1.3889
19	3.271	2.8829	3.271	3.0493	3.2156	3.271	3.1893
20	3.7146	3.8809	3.9918	3.77	3.6591	4.0472	3.7037
21	3.3265	3.3819	3.4374	3.3819	3.2156	3.7146	3.5494
22	3.1047	3.1602	3.2156	3.1047	2.8275	3.6037	3.2922
23	2.6749	2.7778	2.7263	2.7778	2.572	3.1379	3.1379
24	6.9302	4.5268	8.1276	8.0761	7.8704	7.5103	9.3107
Max	13.8049	13.9158	13.5277	13.5831	13.0287	14.0267	13.7494
Min	1.6975	1.9404	2.1068	1.9959	1.9404	1.5947	1.3306
Avg	7.3151	7.8239	8.2778	7.7628	7.7169	7.6650	6.4198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 201 / 11KV Bhalwani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2058	.2058	.2915
2	.2218	.2058	.2058	.2572
3	.2218	.2058	.2401	.2572
4	.2957	.2572	.2743	.2743
5	.3326	.3429	.3086	.3086
6	.3696	.3601	.3086	.3944
10	1.8067	2.0576	2.4006	2.5377
11	1.8399	2.0233	2.2291	2.2291
12	1.9959	2.0233	2.0576	2.0062
13		2.0233	2.1262	1.7147
15	2.304			
16	2.4697	2.0576	2.4348	2.3663
17	2.42	1.8176	2.4006	2.4006
18	.2587	.1715	.2572	.1715
19	.3511	.2572	.2915	.2058
20	.3326	.2401	.3258	.2058
21	.3326	.2401	.3086	.2401
22	.3142	.2058	.2915	.2401
23	.2402	.2058	.2915	.2229
24	.2218	.2058	.2058	.2915
Max	2.4697	2.0576	2.4348	2.5377
Min	.2218	.1715	.2058	.1715
Avg	.8711	.7951	.9034	.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 202 / 11KV Jainwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	1.6118	1.3375	1.286
2	.5175	.463	.3429	.4458
3	.5175	.463	.3429	.463
4	.5544	.4801	.3772	.463
5	.5544	.5144	.4115	.5144
6	.6099	.5487	.4801	.5658
7	.5914	.5144	.5144	.5658
8	.5544	.5144	.5144	.5658
9	.5544	.463	.4801	.4973
16	.3696	.3429	.463	.3429
17	.3696	.3772	.4801	.3429
18	1.8233	2.572	2.0576	2.4348
19	2.2542	2.5206	2.4348	2.3663
20	2.1548	2.5377	2.2291	1.8861
21	2.1548	1.7147	1.8861	1.6289
22	1.8233	1.5089	1.6118	1.4746
23	1.6078	1.3717	1.3717	1.4403
24	.5175	1.6289	1.3375	1.286
Max	2.2542	2.572	2.4348	2.4348
Min	.3696	.3429	.3429	.3429
Avg	1.0026	1.1193	1.0374	1.0317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 203 / 11 KV KESKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0719	.1372	.1372	.1715
2	1.8233	2.0576	1.8861	1.5432
3	1.6575	2.0576	1.8861	1.7147
4	1.6575	2.2291	2.0576	1.7147
5	1.989	2.4006	2.2291	2.0576
6	2.0885	2.6406	2.6063	2.4006
7	2.2874	2.7949	2.7435	2.6749
8	2.0056	2.692	2.7778	2.4691
9	2.0056	2.4348	2.452	2.5034
16	.1109		.1715	.1029
17	.1478	.1372	.2286	.1372
18	.1478	.1715	.2058	.2572
19	.1478	.1715	.2058	.2572
20	.1478	.1543	.2572	.2743
21	.2033	.1372		.2743
22	.2033	.1372	.2743	.2743
23	.2033	.1372	.1715	.1715
24	2.1548	.1372	.1372	
Max	2.2874	2.7949	2.7778	2.6749
Min	.1109	.1372	.1372	.1029
Avg	1.1696	1.2134	1.2016	1.1176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 204 / 11 KV BHALWANIN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4012	.3601	.3868	.3601
2	.3715	.463	.3201	.3601
3	.3715	.3734	.4115	.463
4	.4161	.4801	.4801	.5144
5	.5498	.4934	.6516	.4668
6	.8471	.8916	.7068	.9431
7	.7282	.6668	.6668	.6401
9	.431	.3601	.4801	.5144
10	.2972	.2934	.3772	.3601
11	.2972	.3258	.3429	.3429
12	.2972	.2915	.3601	.3258
13	.3121	.2134	.3601	.2401
14	.2972	.2667	.3429	.2267
15	.2972	.2667	.3601	.2134
16	.2972	.2667	.3772	.2134
17	.3269	.3201	.4458	.2
18	.4161	.4801	.6344	.4001
19	.6539	.6268	.6859	.6135
20	.7133	.6135	.5868	.6401
21	.6093	.5335	.6859	.5335
22	.5647	.4534	.583	.4934
23	.4458	.4001	.4001	.5487
24	.4012	.3601	.4001	.463
Max	.8471	.8916	.7068	.9431
Min	.2972	.2134	.3201	.2
Avg	.4497	.4261	.4803	.4381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 205 / 11 KV CHOUGHULEWADI SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1372	.1372	.12
2	.1848	.1372	.1372	.12
3	.1848	.1372	.1372	.12
4	.2218	.1715	.1372	.1715
5	.2402	.1886	.1543	.2058
6	.2772	.2058	.1715	.2801
10	1.989	1.869	2.1776	1.7147
11	1.6575	1.869	2.1434	1.7147
12	1.6575	1.5432	2.0576	1.5432
13	1.6575	1.5432	2.0576	1.5432
15	1.5912			
16	1.873	2.0576	1.8861	1.7147
17	1.8067	2.0233	1.7147	
18	.1658	.1372	.1372	
19	.1848	.1715	.1886	
20	.1848	.1715	.1715	
21	.1848	.1543	.1372	
22	.1478	.1372	.12	
23	.1294	.1372	.12	1.8519
24	.1848	.1372	.1372	.0934
Max	1.989	2.0576	2.1776	1.8519
Min	.1294	.1372	.12	.0934
Avg	.7354	.6805	.7328	.8610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274048 / 33/11 KV BHALWANI SUBSTATION

Feeder No / Name : 206 / 11 KV GARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	2.1548	1.5432	1.4575
2	1.989	2.4006	2.0576
3	1.6575	2.4006	2.0576
4		2.7435	2.572
5		2.915	3.0864
6		2.915	2.7435
7			3.2579
8		2.915	2.915
9		2.7435	2.6578
16		.2743	.3429
17		.3086	.3429
18		2.572	2.2291
19		2.4006	2.572
20		2.2291	2.0576
21		2.0576	1.8861
22		1.8861	1.7147
23		1.7147	1.3717
24	2.1548	1.5432	1.6289
Max	2.1548	2.915	3.2579
Min	1.6575	.2743	.3429
Avg	1.9890	2.0919	2.0528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 201 / 11 KV SHELAVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.4006	2.4006	2.3663	2.2119	1.8861	2.5911
2	2.5911	2.4348	2.4006	2.4006	2.2291	1.9376	2.652
3	2.5911	2.4348	2.5377	2.5377	2.2291	2.0233	2.774
4	2.9721	2.6063	2.6063	3.0521	2.2291	2.0748	2.8349
5	3.6199	2.6216	2.9492	2.8959	2.572	2.1948	2.9416
6	3.8676	2.8959	2.9874	2.8959	2.7092	2.2462	3.1855
7	4.1343	3.3074	3.094	3.1703	3.2579	2.0576	3.3532
8	4.0581	3.3227	3.7037	3.1093	2.7435	3.3074	3.2007
9	4.1343	3.3684	3.1703	2.7778	2.8959	3.1093	3.4637
19	.5144		.3944	.4458	.2477	.6859	.9088
20	.5144		.583	.5487	.3048	.7202	.9088
21	.6287		.7888	.6173	.4382	.7202	.9431
22	.6287		.9259	.6173	.2667	.724	.9431
23	.5716	.6859	.6173	.6859	.2477	.6173	.8916
24	2.4768	2.2119	1.8861	2.2634	2.0576	1.7833	2.5911
Max	4.1343	3.3684	3.7037	3.1703	3.2579	3.3074	3.4637
Min	.5144	.6859	.3944	.4458	.2477	.6173	.8916
Avg	2.3726	2.5718	2.0697	2.0256	1.7760	1.7392	2.2789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 202 / 11 KV UPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905	.2286	.2286	.1905
3	.1905	.2667	.2477	.2096	.2286	.2286	.1905
4	.2858	.3048	.3048	.381	.2477	.2667	.2667
5	.381	.4001	.381	.381	.381	.3239	.3429
6	.4191	.4572	.4572	.4191	.4572	.381	.4191
11	2.6673	1.5775		2.0576	2.2291	2.452	2.4006
12	3.4294	2.5911	2.4387	2.0576	2.6216	2.6216	2.572
13	3.2388	2.5606	2.4691	2.2291	2.5911	2.5911	
14				2.2291		2.3777	
15		2.4387	2.2291		2.2558		
16	3.2388	2.4387	2.4691	2.7435	2.4387	2.5034	
17	3.0483	2.6749	2.4387	2.7435	2.5034	2.6749	
18	2.572		2.5206	2.4006	2.2253	2.6749	
19	.362		.1715	.1715	.3429	.1715	.2058
20	.4382		.2058	.2229	.381	.381	.3429
21	.381		.2058	.2572	.2858	.3429	.3086
22	.2858		.1886	.1715	.2477	.2477	.3086
23	.2477	.1905	.1715	.1905	.2286	.2286	.2743
24	.2286	.2477	.1905	.1905	.1905	.1905	.1905
Max	3.4294	2.6749	2.5206	2.7435	2.6216	2.6749	2.572
Min	.1905	.1905	.1715	.1715	.1905	.1715	.1905
Avg	1.2109	1.1807	.9706	1.0230	1.0671	1.1093	.5860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 203 / 11 KV BHANDISHEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.1905	.2096	.2286	.2286	.2858
2	.2096	.1905	.1905	.2096	.2286	.2286	.2858
3	.2096	.1905	.2477	.2286	.2286	.2858	.2858
4	.2858	.2667	.3048	.2477	.3048	.3429	.3429
5	.4001	.381	.381	.3429	.4191	.381	.4001
6	.3429	.4382	.381	.4382	.4382	.4191	.4954
11	3.2388	1.749	1.749	3.4294	2.4348	2.572	2.915
12	3.8104	2.8654	2.8654	3.4294	3.1245	3.2007	3.5665
13	3.7151	2.9264	2.9569	3.4294	3.0483	3.2617	
14				3.4294			
15		2.8959	2.4387		2.8045	3.2065	
16	3.8104	2.8654	2.774	3.4294	2.8959	3.5665	
17	3.6199	3.0178	2.8959	3.4294	3.0636	3.3608	
18	2.8959		3.3436	2.915	2.8349	3.2065	
19	.3048		.2915	.3086	.3048	.3601	.3258
20	.381		.2743	.3086	.381	.4191	.4287
21	.3429		.2401	.3086	.381	.3429	.3944
22	.2858		.2229	.2401	.3048	.2858	.3429
23	.2477	.2096	.2058	.2286	.2667	.2858	.2743
24	.2286	.2096	.2096	.2096	.2286	.2286	.2858
Max	3.8104	3.0178	3.3436	3.4294	3.1245	3.5665	3.5665
Min	.2096	.1905	.1905	.2096	.2286	.2286	.2743
Avg	1.3643	1.3140	1.1665	1.4091	1.2590	1.3781	.7592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 204 / 11 KV WADIKUROLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	2.332	2.2291	2.1605	2.0576	1.9376	
2	2.5149	2.332	2.2291	2.1605	2.0576	2.0233	2.4691
3	2.5149	2.332	2.2634	2.1605	2.0576	2.1605	2.5149
4	2.5149	2.332	2.2634	2.2634	2.1091	2.3834	2.5911
5	2.8578	2.332	2.4006	2.3834	2.1605	2.5206	2.7435
6	2.9721	2.2862	2.3777	2.4006	2.2291	2.6749	2.9874
7	3.1436	2.3167	2.3167	2.6749	2.572	2.6368	2.8197
8	3.0864		2.4387	2.8959	2.3167	2.5149	3.0026
9	2.8197	2.5377	2.5377	2.0576	2.4863	2.5453	3.618
19	.1715		.1886	.2058	.1715	.2058	.3086
20	.2858		.2058	.2229	.2667	.2667	.3429
21	.2667		.2401	.2401	.2667	.2667	.2915
22	.1715		.2401	.2229	.1715	.1715	.2915
23	.1715	.1143	.1543	.1715	.1715	.1715	.2743
24	2.4006	2.2291	1.9719	2.1434	1.3146	1.749	2.2291
Max	3.1436	2.5377	2.5377	2.8959	2.572	2.6749	3.618
Min	.1715	.1143	.1543	.1715	.1715	.1715	.2743
Avg	1.8735	2.1144	1.6038	1.6243	1.4939	1.6152	1.8917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 205 / 11 KV BHANDISHEGAON

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5658	.6173	.5658	.6344	.5658	.6173
2	.6668	.6001	.6173	.6001	.6859	.6001	.6516
3	.724	.7202	.6859	.6001	.7373	.6687	.7202
4	.8383	.8573	.823	.7202	.8573	.823	.8573
5	1.0098	1.0631	.8916	1.0288	1.0631	.9774	1.0974
6	1.2955	1.2003	1.166	1.166		1.0631	1.2174
7				.9259			.9259
8	1.0669	.8402	.7716	.8059	.8573	.8573	
9	.724	.6173	.6344		.7202	.6859	.6687
10	.6668	.4801	.4801	.6001	.6173	.6001	.5658
11	.4763	.4458	.4458	.5144	.4954	.4458	.4801
12	.4763	.4801	.3772	.4801		.5335	.4458
13	.4382	.4115	.3429	.4801	.4763	.4954	.4458
14	.4763	.3944	.4572	.4801	.4191	.4191	.4458
15	.4763	.463	.4382	.5144	.381	.4801	.463
16	.4954	.3772	.4801	.5658	.5525	.4801	.4973
17	.5716	.4115	.5144	.5144		.4458	.5487
18	.6001		.5316	.6001	.6687	.5316	.6173
19	.8573		.823	.8916	.9602	.8573	.823
20	1.0631		.7716	1.0288	1.0288	1.0974	.9431
21	.8745		.7202	.9945	.8745	.8402	.8573
22	.7716		.6859	.7716	.4572	.6859	.7888
23	.6859	.6173	.6344	.7621	.6173	.6859	.703
24	.6859	.6173	.6173	.6173	.6344	.5658	.6173
Max	1.2955	1.2003	1.166	1.166	1.0631	1.0974	1.2174
Min	.4382	.3772	.3429	.4801	.381	.4191	.4458
Avg	.7221	.6201	.6316	.7056	.6869	.6698	.6956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274049 / 33/11 KV BHANDHSHEGAON

Feeder No / Name : 207 / TEJUS AGRO EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953		.0953	.1334	.2286	.2667	.0572
2	.0953			.0572	.2286	.2667	.0953
3	.0953		.0572	.0953	.2096	.2286	.1334
4	.1334		.0572	.0953	.2858	.2286	.1334
5	.1334		.0572	.0762	.2286	.2286	.1143
6	.0953		.0572	.1143	.2477	.2096	.1524
7	.0572		.0572	.1334	.1905	.2096	.0572
8	.0572	.0572	.0572	.2286	.1905	.1905	.0572
9	.0953	.0572	.0572	.1334	.2286	.2858	.2058
10	.1334	.0953	.0572	.1886	.2477	.2477	.2572
11	.1524	.0953	.0572	.2229	.2286	.2667	.3086
12	.1334	.0572	.1905	.2572	.1143	.2286	.2229
13	.0953	.0857	.2858	.2743	.2286	.3048	.2572
14	.1334	.0953	.2858	.3086	.1905	.362	.2915
15	.1524	.5144	.2286	.3086	.3429	.2572	.2572
16	.5335	.0953	.3429	.2229	.3239	.2743	.2229
17	.381	.0572	.2286	.2572	.2477	.2743	.2229
18	.4382		.2229	.2915	.3429	.3086	.2401
19	.1715		.2229	.2229	.3429	.2743	.2401
20	.0572		.2058	.2572	.3429	.3429	.2572
21	.0572		.2058	.3086	.381	.4115	.2572
22	.0572		.1886	.1886	.3429	.3772	.2229
23	.0572	.0953	.2229	.2477	.2858	.3601	.2229
24	.2286	.0572	.0572	.2286	.2858	.2096	.4115
Max	.5335	.5144	.3429	.3086	.381	.4115	.4115
Min	.0572	.0572	.0572	.0572	.1143	.1905	.0572
Avg	.1517	.1136	.1521	.2022	.2620	.2756	.2041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 201 / 11 KV KALERAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621		.7621	.6097	.7621
2	.7621	.7621	.7621		.7621	.7621	.7621
3	.7621	.7621	.7621		.7621	.7621	1.0669
4	.7621	.7621	.7621		.7621	.7621	1.0669
5							***
6							1.3717
7							1.829
8							1.9814
9							2.21
11	2.1338	2.2862	2.6673	2.5911	2.4387	1.5242	
12	2.2862	2.2862	3.0483	2.8959	2.8959	1.829	
13	2.7435		2.9721	2.9721		1.829	
14				2.8959		1.6004	
15	2.4387		3.0483			1.6004	
16	2.4387		3.2007			1.6766	
17	2.4387		2.8959	2.8959		1.6004	
18	2.4387		2.5149	2.5911		1.5242	
19			.4572	.3048		.3048	
20	.6097		.6097	.6097	1.3717	.3048	.3048
21	.7621		.6097	.6097	1.5242	.3048	.3048
22	.7621		.7621	.6097	.6097	.3048	.3048
23			.7621	.6859	.6097	.4572	.3048
24	.7621	.7621	.7621		.7621	.6097	.7621
Max	2.7435	2.2862	3.2007	2.9721	2.8959	1.829	10.7911
Min	.6097	.7621	.4572	.3048	.6097	.3048	.3048
Avg	1.5242	1.1976	1.6093	1.7874	1.2055	1.0204	1.7016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 202 / 11 KV AMBE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1219	.1524	.1524	.0762
2	.1524	.1524	.1524	.1219	.1524	.2286	.0762
3	.1524	.1524	.1524	.1067	.1524	.2286	.0762
4	.1524	.1524	.1524	.1067	.1524	.2286	.0762
6	.2286	.1524	.1524	.0762	.2286	.2286	
7	.2286	.2286	.2286	.1829	.2286	.2286	
8	.2286	.2286	.2286	.2286	.2286	.381	
9	.2286	.2286	.2286	.1829	.2286	.381	
11							.381
12							.381
19	.0762	.0762	.0305	.0762		.0762	.0762
20	.0762	.0762	.0305	.0762		.0762	.0762
21	.0762	.0762	.0305	.0762	.0762	.0762	.0762
22	.0762		.0305	.0762	.0762	.0762	.0762
23	.1524	.0762	.0305	.0762	.0762	.0762	.0762
24	.1524	.1524	.1524	.1219	.0762	.1524	.0762
Max	.2286	.2286	.2286	.2286	.2286	.381	.381
Min	.0762	.0762	.0305	.0762	.0762	.0762	.0762
Avg	.1524	.1465	.1252	.1165	.1524	.1851	.127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 203 / 11 Kv Ranzani
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1372	.1524	.1524	.9145
2	.1524	.1524	.1524	.1524	.1524	.1524	.9145
3	.1524	.1524	.1524	.1829	.1524	.1524	1.0669
4	.1524	.1524	.1524	.1981	.1524	.1524	1.0669
5		.1524					
7							1.6766
8							2.1338
9							2.1338
11	1.6766	1.829	1.9814	1.829	.7621	2.2862	
12	2.7435	1.829	2.4387	2.4387	2.1338	2.7435	
13	2.5911	2.7435	2.7435	2.4387		2.7435	
14	2.4387	2.4387	2.1338	2.5911			
15						1.6766	
16	2.4387	2.5149	2.2862	2.2862			
17	2.5911	2.4387	2.2862	1.9814			
18	2.4387	2.4387	1.9814	1.9814			
19	.1524	.1524	.1524	.1524		.1524	.1524
20	.1524	.1524	.2134	.1524	.1524	.1524	.1524
21	.1524		.2134	.1524	.1524	.1524	.1524
22	.1524		.1524	.1524	1.3717	.1524	.1524
23	.1524		.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1372	.1524	.1524	.9145
Max	2.7435	2.7435	2.7435	2.5911	2.1338	2.7435	2.1338
Min	.1524	.1524	.1524	.1372	.1524	.1524	.1524
Avg	1.0848	1.1634	1.0292	1.0068	.4988	.7838	.8910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 204 / 11 KV CHALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.4877	.4572	.7621	.7621
2	.6097	.7621	.6097	.6249	.5335	.6097	.6859
3	.6097	.9145	.7621	.7316	.5335	.7621	.9145
4	.6097	.7621	.7621	.8688	.8383	.7621	.9145
5	.6859	.9145	.9145	.9145	.9145	1.0669	.9145
6	.7621	.9145	.9145	.884	.9145	1.0669	.8383
7	.9145	.6097	.7621				
8	.6859	.6097	.9145				
9	.6859	.4572	.4572	.6859	.4572	.6097	.6859
10	.6859	.4572	.4572	.5944	.503	.6097	.5335
11	.6097	.4572	.3506	.381	.5335	.6097	.5335
12	.4572	.4572	.5639	.3048	.5335	.4572	.5335
13	.4572	.4572	.5487	.4572		.5487	
14	.4572	.4572	.4572	.4572		.3048	
15	.6097	.4572	.6554	.4572		.4572	
16	.6097	.4572	.5944	.4572		.5335	
17	.6097	.4572	.7164	.7621		.6859	
18	.7621	.4572	.7164	.6097		.6859	.7621
19	.7621	.9145	.9755	.9145		.7621	.9145
20	.9145	.9145	1.0517	.9145	1.0669	.8383	.9145
21	.7621	.9145	1.0974	.6859	1.0669	.8383	.9145
22	.6097	.7621	.8078	.6859	.6097	.6859	.9145
23	.6097		.6249	.6097	.6097	.5335	.7621
24	.6097	.6097	.6097	.6249	.5335	.7621	.6097
Max	.9145	.9145	1.0974	.9145	1.0669	1.0669	.9145
Min	.4572	.4572	.3506	.3048	.4572	.3048	.5335
Avg	.6541	.6428	.7056	.6415	.6737	.6797	.7711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 205 / 11 Kv Chale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.4572	.6097	.4572	.0762
2	.6097	.6097	.6097	.4572	.6097	.4572	.0762
3	.6097	.6097	.6097	.4572	.6097	.4572	.0762
4	.6097	.6097	.6097	.4572	.7621	.4572	.0762
6	.7621	.9145	1.0669	.6097	.6097	.4572	
7	.7621	.9907	1.0669	.9145	.6097	.4572	
8	.9145	1.0669	1.2193	.9145	.9145	.4572	
9	.9145	1.0669	1.2193	.9145	.7621	.4572	
11							1.0669
12							1.5242
18							1.9814
19	.1524	.0762		.0762		.0762	.3048
20	.1524	.0762	.1524	.0762	.0762	.0762	.3048
21	.1524	.0762	.1524	.0762	.0762	.0762	.4572
22	.1524	.0762	.0914	.0762	.0762	.0762	.4572
23	.1524	.0762	.1067	.0762	.0762	.0762	.4572
24	.6097	.6097	.6097	.4572	.6097	.4572	.0762
Max	.9145	1.0669	1.2193	.9145	.9145	.4572	1.9814
Min	.1524	.0762	.0914	.0762	.0762	.0762	.0762
Avg	.5117	.5335	.6249	.4300	.4924	.3211	.5334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274050 / 33/11 CHALE S/STN

Feeder No / Name : 206 / 11 KV DARLING
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.6097	.6097	.6097	.0762
2	.6097	.6097	.6097	.6097	.6097	.6097	.0762
3	.6097	.6097	.6097	.7621	.6097	.6097	.0762
4	.6097	.6097	.6097	.7621	.6097	.6097	.0762
6	.9145	.6097	.9145	.9145	1.0669	1.0669	
7	1.0669	1.2193	1.2193	.9145	1.2193	1.0669	
8	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	
9	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	
11							.7621
12							1.0669
18							1.2193
19	.0762	.0762	.1067	.0762	.0762	.0762	.0762
20	.0762	.0762	.0914	.0762	.0762	.0762	.0762
21	.0762	.0762	.0914	.0762	.0762	.0762	.0762
22	.0762	.0762	.0914	.0762	.0762	.0762	.0762
23	.0762	.0762	.1067	.0762	.0762	.0762	.0762
24	.4572	.6097	.4572		.6097	.4572	.0762
Max	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193	1.2193
Min	.0762	.0762	.0914	.0762	.0762	.0762	.0762
Avg	.5498	.5498	.5683	.5686	.5825	.5607	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 201 / 11 KV KHARDI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.166	1.3765	1.0202	1.0364	.9393	.4458
2	1.3765	1.2631	1.6518	1.0688	1.2631	1.0202	.4458
3	1.3765	1.2631	1.6194	1.1336	1.2631	1.0202	.4458
4	1.4575	1.2631	1.6518	1.2631	2.2672	1.166	.463
5	1.7814	2.1052	1.8623	1.4575	2.5587	1.3927	.463
6	2.2672	2.2834	2.332	2.1376	2.8988	1.6518	.5144
7	2.9959	2.2672	3.3036	2.915	2.8502	2.7206	
8	3.3036	2.1052	3.6923	2.7206	2.8178	2.5911	
9	3.0121	2.0729		2.7854	2.753	2.5911	
11							1.4575
12							2.915
19	.3086	.5144	.4115	.3429	.3601	.463	.3772
20	.3429	.6173	.4973		.4801	.6001	.4973
21	.4115	.6173	.4801	.4115	.4973	.5316	.5316
22	.3772	.5144	.4287	.3429	.463	.5316	.4458
23	.3429	.5144	.3429	.2743	.4115	.5144	.3601
24	1.2955	.3086	.5144	.2915	.2743	.3429	.5144
Max	3.3036	2.2834	3.6923	2.915	2.8988	2.7206	2.915
Min	.3086	.3086	.3429	.2743	.2743	.3429	.3601
Avg	1.4630	1.2584	1.4403	1.2975	1.4796	1.2051	.7055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 202 / 11 KV BOHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	.3429	.4115	.4115	.4115	1.5061
2	.4115	.3429	.3258	.4458	.4115	.4115	1.5061
3	.3944	.3429	.4115	.4801	.4115	.4458	1.5384
4	.3944	.3429	.4458	.4801	.4115	.4801	1.6842
5	.4973	.3429	.4458	.5144	.4458	.5144	1.7004
6	.5487	.5487	.5316	.5144	.4801	.5144	2.251
7							3.1741
8							3.1903
9							3.1255
11		1.7814	2.1052	2.1052	2.1052	1.7328	
12	3.4979	3.1093	3.0121	2.6558	2.915	3.1255	
13	3.1741	3.1903		2.5911	2.6558	3.1093	
14	3.1741	3.0769	3.0769	2.5101	2.8664	2.834	
15	3.1417	3.0769	3.1417	2.4615	2.9473	1.6194	
16	3.0769	3.0607	3.1417	2.753	3.0445	2.4291	
17	2.9473	3.1093	2.7854	2.8502	3.1741	2.7368	
18	2.0567	3.0121	3.1741	2.9473	2.9797	2.5911	
19	.3772	.2915	.3258	.3772	.3772	.3944	.2058
20	.4115	.4973	.4458	.4115	.4458	.4458	.5144
21	.4115	.4973	.4458	.4115	.4458	.4287	.4801
22	.4458	.4287	.4287	.4115	.4458	.4287	.4287
23	.4115	.4287	.4458	.4115	.4287	.4115	.4115
24	.4458	.3429	.3772	.4287	.4115	.4287	.4287
Max	3.4979	3.1903	3.1741	2.9473	3.1741	3.1255	3.1903
Min	.3772	.2915	.3258	.3772	.3772	.3944	.2058
Avg	1.3814	1.4083	1.3373	1.3086	1.3907	1.2747	1.4764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 203 / 11 KV T SHETPHAL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2229	.2058	.2058	.2058	1.0526
2	.2915	.2743	.2401	.2058	.2058	.2058	1.0688
3	.2743	.2743	.2572	.2058	.2058	.2058	1.0364
4	.2915	.2743	.2743	.2058	.2058	.2743	1.0526
5	.3086	.3086	.2915	.2743	.2743	.2743	1.1336
6	.3086	.3429	.2743	.2743	.3429	.3429	1.1984
7							1.6842
8							1.6842
9	2.0243	1.7814	1.4899	1.6842	1.6842		
10	2.0567	1.8138	1.749	1.7166	1.5546	1.5546	
11	2.1538	1.7814	1.6842	1.749	1.5223	1.5546	
12	2.1052	1.4575	1.749	1.6518	1.5546	1.5384	
13	1.9919	1.6842	1.8138	1.6518	1.4251	1.5223	
14	1.9433	1.6842	1.749	1.7166	1.4251	1.5061	
15	1.8785	1.6842	1.749	1.749	1.3603	1.5546	
16	1.6194	1.7004	1.8785	1.749	1.5546	1.6194	
19	.3086	.2915	.2058	.2743	.2058	.2229	.2058
20	.3429	.2743	.2743	.3086	.2743	.2915	.2743
21	.3772	.2743	.2743	.3429	.2743	.2915	.3429
22	.3429	.2743	.2743	.3086	.2743	.2229	.2743
23	.3429	.2401	.2743	.2743	.2743	.2229	.2058
24	.2743	.2743	.2229		.2058	.2058	.2058
Max	2.1538	1.8138	1.8785	1.749	1.6842	1.6194	1.6842
Min	.2743	.2401	.2058	.2058	.2058	.2058	.2058
Avg	.9755	.8482	.8474	.8710	.7515	.7272	.8157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 204 / 11 KV KHARDI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3429	.3086	.3086	.3086	.3944
2	.3429	.3086	.3429	.3601	.3086	.3086	.3772
3	.3601	.3086	.3601	.4287	.3086	.3944	.4115
4	.4973	.3086	.4973	.4801		.4801	.5144
5	.5658	.3772	.5144	.5658	.4115	.5487	.5487
6	.5658	.4801	.703	.6859	.5487	.6859	.6687
7		.4458					
8	.463	.3772	.4801	.4801	.4115	.4801	.4973
9	.3772	.3429	.4287	.3429	.3429	.3601	.3772
10	.3429	.3601	.3601	.3086	.3258	.2743	.3086
11	.3258	.3258	.2572	.3086	.3086	.3258	.3086
12	.3086	.2915	.3086	.2743	.3086	.3086	.2915
13	.2915	.2401	.2401	.2743	.3258	.3086	.2743
14	.2915	.2572	.2743	.2743	.3258	.3086	
15	.3086	.3086	.2572	.2743	.3258	.12	.2743
16	.3258	.2572	.2743	.2743	.3258	.0857	
17	.3429	.3258	.3086	.3086	.3601	.3258	.3772
18	.4458	.4115	.3601	.3772	.4115	.3944	.4801
19	.5144	.583	.5316	.4801	.6001	.5658	.4973
20	.5487	.6001	.6001	.5144	.6516	.6173	.4973
21	.583	.583	.4973	.463	.4973	.6001	.4801
22	.5487	.4287	.4115	.4115	.4458	.463	.3429
23	.4801	.3772	.3429	.3429	.3772	.4287	.3086
24	.3429	.3086	.3601	.3086	.3086	.3429	.3944
Max	.583	.6001	.703	.6859	.6516	.6859	.6687
Min	.2915	.2401	.2401	.2743	.3086	.0857	.2743
Avg	.4137	.3715	.3936	.3847	.3881	.3929	.4107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 205 / 11KV Umbargaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3772	.3429	.4115	.3772	.3772	.4287
2	.3944	.3772	.3086	.4458	.3772	.4115	.4287
3	.3944	.3772	.3429	.4801	.3772	.4115	.4287
4	.4115	.3772	.4115	.5144	.3772	.4801	.463
5	.4287	.3772	.4115	.5487	.3772	.5144	.463
6	.4287	.3772	.5487	.5658	.4115	.5316	.5487
9						.4115	3.1093
10							2.8016
17	3.4008		3.1741	3.1741	3.3036	3.2388	
18	3.1741	3.4979	3.4818	3.0445	3.5303	3.1093	
19	2.834	2.7206	3.1741	2.834	3.0121	2.9635	.4115
20	2.753	2.8502	2.915	2.753	2.5911	2.6882	.4973
21	2.753	2.753	2.5587	2.753	2.3967	2.4291	.4801
22	2.5263	2.4291	2.332	2.6558	2.4615	2.2024	.4801
23	2.2348	2.4291	2.4129	2.332	2.332	2.1052	.4973
24	.4115	2.2186	2.1052	2.2348	2.1052	2.2672	1.9433
Max	3.4008	3.4979	3.4818	3.1741	3.5303	3.2388	3.1093
Min	.3944	.3772	.3086	.4115	.3772	.3772	.4115
Avg	1.6112	1.6278	1.7514	1.7677	1.7164	1.6094	.9272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274053 / 33/11 KV KHARDI

Feeder No / Name : 206 / 11KV Kasegaon (BEND WASTI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	1.166	1.2955	1.1336	1.0364	1.0688	.4287
2	1.2146	1.1984	1.2146	1.3279	1.1336	1.1984	.4115
3	1.3765	1.1984	1.4575	1.4575	1.1336	1.2631	.4458
4	1.4575	1.1984	1.9433	1.5546	1.1336	1.3927	.4287
5	1.6194	1.8785	1.9109	1.7166	1.9109	1.4575	.4287
6	1.8623	1.9757	1.9433	2.0729	2.1052	1.9595	
7	2.2672	1.6194	2.2024	2.2348	2.1052	2.1376	
8	2.1052	1.1336	2.2024	2.2996	2.1052	2.2672	
11							2.5587
12							2.2348
19	.3086	.2915	.2743	.2743	.3772	.2572	1.2955
20	.3086	.4115	.3258	.3086	.3429	.4458	2.0405
21	.3429	.4115	.4458	.3429	.3429	.4115	2.1052
22	.3429	.4115	.4287	.2743	.3429	.4115	2.17
23	.2743	.3944	.3772	.2743	.3086	.3944	2.0729
24	1.0364	.2058	.2915	.3429	.2743	.3086	.4115
Max	2.2672	1.9757	2.2024	2.2996	2.1052	2.2672	2.5587
Min	.2743	.2058	.2743	.2743	.2743	.2572	.4115
Avg	1.1179	.9639	1.1652	1.1153	1.0466	1.0696	1.3102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 201 / Tisangi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.6859	.7545	.6706	.8383	.823	.1867
2	.1715	.6859	.7545	.6706	.8383	.823	.1867
3	.1715	.6706	.7545	.8383	.8383	.8402	.1867
4	.1715	.8383	.7545	.8383	1.0059	.823	.1867
5	.3429	.8383	.7545	.8383	1.0898	.9145	.1867
6	.4287	.9221	.8383	.9221	1.0059	1.0059	.1867
7	.6859		.9221	1.0059	.8383	1.0059	.1867
8	.6859	.6706	.9221	.8383	.8383	.823	.1867
9		.8383	.8383	.8383	.8383	.823	.1867
10		.1715	.1715		.2572	.1867	.1867
11		.1715	.1372	.1715	.0857	.1867	.6468
12		.1715	.0857	.1372	.0857	.1867	.924
13		.1715	.0857	.0857	.0857	.1867	
14		.1715	.0857	.0857	.0857	.1867	
15		.1715	.0857	.0857	.0857	.1867	
16		.1715	.0857	.0857	.0857	.1867	
17	.1715	.1715	.0857	.0857	.0857	.1867	
18	.1715	.1715	.0857	.0857	.1715	.1867	
19	.1715	.1715	.0857	.1715	.1715	.1867	.2801
20	.1715	.1715	.0857	.1715	.2572	.1867	.2801
21	.1715	.1715	.0857	.1715	.2572	.1867	.1867
22	.1715	.1715	.0857	.1715	.1715	.1867	.1867
23	.1715	.1715	.0857	.1715	.1715	.1867	.1867
24	.1715	.6859	.7545	.6706	.8383	.7316	.1867
Max	.6859	.9221	.9221	1.0059	1.0898	1.0059	.924
Min	.1715	.1715	.0857	.0857	.0857	.1867	.1867
Avg	.2626	.4016	.3910	.4266	.4595	.4678	.2636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 202 / 11 KV SONAKE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.1736	1.8442	1.3413	1.7404	2.0814	.1867
2	.1715	1.326	1.8233	1.5089	1.8442	2.0595	.1867
3	.1715	1.3413	1.8442	1.6766	1.8233	2.0157	.1867
4	.1715	1.6766	1.9281	1.6575	1.9062	2.1719	.1867
5	1.4575	2.0119	1.989	1.989	1.989	2.3529	.1867
6	2.0719	2.3205	2.1548	2.3205	2.3205	2.4291	.1867
7	2.652	2.7349	2.652	2.652	2.5692	2.915	.1867
8	2.652	2.4863	2.652		2.6825	2.8959	.1867
9		2.3205	2.3205	2.3472	2.4863	2.8959	.1867
10		.1715	.1715	.1715	.1715	.1867	.1867
11		.1715	.1715	.1715	.1715	.1867	2.3777
12		.1715	.1715	.1715	.1715	.1867	3.4389
13		.1715	.1715	.1715	.1715	.1867	
14		.1715	.1715	.1715	.1715	.1867	
15		.1715	.1715	.1715	.1715	.1867	
16		.1715	.1715	.1715	.1715	.1867	
17	.1715	.1715	.1715	.1715	.1715	.1867	
18	.1715		.1715	.1715		.1867	
19	.1715	.1715	.1715	.1715	.1715	.1867	.1867
20	.1715	.1715	.1715	.1715	.1715	.1867	.1867
21	.1715	.1715	.1715	.1715	.1715	.1867	.1867
22	.1715	.1715	.1715	.1715	.1715	.1867	.1867
23	.1715	.1715	.1715	.1715	.1715	.1867	.1867
24	.1715	1.0059	1.8107	1.1736	1.7604	1.9909	.1867
Max	2.652	2.7349	2.652	2.652	2.6825	2.915	3.4389
Min	.1715	.1715	.1715	.1715	.1715	.1867	.1867
Avg	.6807	.8968	.9758	.8290	1.0153	1.1009	.4891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 203 / 11 KV KORTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1867	1.4632
2	.1715	.1715	.1715	.1715	.1715	.1867	1.829
3	.1715	.1715	.1715	.1715	.1715	.1867	1.829
4	.1715	.1715	.1715	.1715	.1715	.1867	2.1719
5	.1715	.1715	.1715	.1715	.2572	.2801	2.5606
6	.2572	.2572	.2572		.2572	.2801	2.7149
7		.2572	.2572	.2572	.2572	.2801	3.0769
8		.2572	.1715	.2572	.1715	.2801	2.7149
9		.1715		.2572	.1715	.2801	2.5339
10		.1715		.1715	.1715	.2801	.2801
11		1.2003		1.6766	1.3413	1.6804	.2801
12		2.652		2.431	2.9835	3.2674	
13		2.652	2.652	2.5692		2.8959	
14		2.7349	2.652	2.652	2.7349	2.7149	
15		2.7349	2.3205	2.6825	2.4863	2.8006	
16	3.1493	2.7349	1.989	2.4034	2.5692	2.8006	
17	2.9835	2.7349	2.4863	2.4034	2.652	2.5339	
18	2.9835	2.5692	2.3205	2.7349	2.4863	2.3529	
19	2.652	.3429	.1715	.3429	.2572	.0934	.4668
20	.3429	.3429	.2572	.3429	.3429	.3734	.4668
21	.2572	.3429	.2572	.3429	.3429	.3734	.4668
22	.2572	.2572	.1715	.3429	.2572	.2801	.4668
23	.2572	.2572	.1715	.3429	.1715	.2801	.3734
24	.1715	.1715	.1715	.1715	.1715	.1867	1.0974
Max	3.1493	2.7349	2.652	2.7349	2.9835	3.2674	3.0769
Min	.1715	.1715	.1715	.1715	.1715	.0934	.2801
Avg	.9446	.9875	.8582	1.0104	.9030	1.0442	1.4584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 204 / GADEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4191		.3429	.4668	1.4632
2	.3429	.3429	.4287		.3429	.4668	1.829
3	.3429	.3429	.4287		.3429	.4668	1.829
4	.3429	.3429	.4287		.3429	.4668	2.1948
5	.4287	.3429	.4287		.3429	.4668	2.3529
6	.4287	.4287	.5144		.4287	.5601	2.7149
7		.4287	.5144		.4287	.5601	2.8959
8		.3429	.4287		.4287	.4668	2.7149
9		.2572	.2572		.3429	.4668	2.6244
10		.3429	.2572		.3429	.2801	.2801
11		1.3413	1.3413	1.7604	1.6766	1.6289	.1867
12		2.9007	2.4863	2.5149	2.9835	3.0864	
13		3.1493	2.8178	2.7349	2.652	2.915	
14		2.9007	2.8178	2.8178	2.5692	2.8959	
15		2.7349		2.8178	2.9007	2.7435	
16	3.1017	2.8178	1.326	2.652	2.8178	2.7435	
17	2.9835	2.9007	2.3472	2.5149	2.7349	2.7149	
18	3.315	2.5692		2.652	2.6825	2.3529	
19	2.4863	.3429		.3429	.2572	.1867	.4668
20	.4287	.4287		.4287	.3429	.4668	.4668
21	.4287	.4287		.4287	.4287	.4668	.4668
22	.3429	.4287		.3429	.4287	.3734	.4668
23	.3429	.4287		.3429	.4287	.3734	.4668
24	.3429	.3429	.7545		.2572	.4668	1.0974
Max	3.315	3.1493	2.8178	2.8178	2.9835	3.0864	2.8959
Min	.3429	.2572	.2572	.3429	.2572	.1867	.1867
Avg	1.0668	1.1346	1.0586	1.7193	1.1186	1.1701	1.4422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 205 / Gaothan No.1 Takali-
Gadegaon Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1867	.2801
2	.1715	.1715	.1715	.1715	.1715	.1867	.2801
3	.1715	.1715	.1715	.1715	.1715	.1867	.2801
4	.1715	.1715	.1715	.1715	.1715	.2801	.2801
5	.1715	.1715	.2572	.1715	.1715	.3734	.2801
6	.2572	.2572	.3429	.2572	.2572	.4668	.2801
7	.2572	.3429	.3429	.2572	.1715	.3734	.3734
8						.2801	.2801
9	.1715	.2572	.1715	.1715	.2572	.1867	.2801
10	.2572	.1715	.2572	.0857	.2572	.2801	.2801
11	.1715	.1715	.1715	.0857	.1715	.2801	.2801
12	.1715	.1715	.2572	.0857	.1715	.3734	.1867
13	.1715	.1715	.2572	.1715	.1715	.2801	.1867
14	.1715	.1715	.2572	.1715	.1715	.0934	.1867
15	.1715	.1715	.2572	.1715	.1715	.1867	.1867
16	.2572	.1715	.2572	.1715	.1715	.2801	.1867
17	.2572	.1715	.2572	.2572	.1715	.2801	.1867
18	.2572	.1715	.2572	.2572	.3429	.1867	.2801
19	.3429	.1715	.3429	.2572	.3429	.2801	.3734
20	.3429	.3429	.3429	.2572	.2572	.2801	.2801
21	.3429	.2572	.3429	.2572	.2572	.2801	.2801
22	.2572	.1715	.2572	.2572	.2572	.2801	.2801
23	.2572	.1715	.2572	.1715	.1715	.2801	.2801
24	.1715	.2572	.1715	.1715	.1715	.1867	.2801
Max	.3429	.3429	.3429	.2572	.3429	.4668	.3734
Min	.1715	.1715	.1715	.0857	.1715	.0934	.1867
Avg	.2237	.2013	.2497	.1901	.2088	.2645	.2645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274056 / 33/11 SONAKE

Feeder No / Name : 206 / 11KV Navale College
Express Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.0934	.0934
2	.0857	.0857	.0857	.0857	.0857	.0934	.0934
3	.0857	.0857	.0857	.0857	.0857	.0934	.0934
4	.0857	.0857	.0857	.0857	.0857	.0934	.0934
5	.0857	.0857	.0857	.0857	.0857	.0934	.0934
6	.0857	.0857	.0857	.0857	.0857	.0934	.0934
7	.0857	.0857	.0857	.0857	.0857	.0934	.0934
8	.0857	.0857	.0857	.0857	.0857	.0934	.0934
9	.0857	.0857	.0857	.0857	.0857	.0934	.0934
10	.0857	.0857	.0857	.0857	.0857	.0934	.0934
11	.0857	.0857	.0857	.0857	.0857	.0934	.0934
12	.0857	.0857	.0857	.0857	.0857	.0934	.0934
13	.0857	.0857	.0857	.0857	.0857	.0934	.0934
14	.0857	.0857	.0857	.0857	.0857	.0934	.0934
15	.0857	.0857	.0857	.0857	.0857	.0934	.0934
16	.0857	.0857	.0857	.0857	.0857	.0934	.0934
17	.0857	.0857	.0857	.0857	.0857	.0934	.0934
18	.0857	.0857	.0857	.0857	.0857	.0934	.0934
19	.0857	.0857	.0857	.0857	.0857	.0934	.0934
20	.0857	.0857	.0905	.0857	.0857	.0934	.0934
21	.0857	.0857	.0857	.0857	.0857	.0934	.0934
22	.0857	.0857	.0857	.0857	.0857	.0934	.0934
23	.0857	.0857	.0857	.0857	.0857	.0934	
24	.0857	.0857	.0857	.0857	.0857	.0934	.0934
Max	.0857	.0857	.0905	.0857	.0857	.0934	.0934
Min	.0857	.0857	.0857	.0857	.0857	.0934	.0934
Avg	.0857	.0857	.0859	.0857	.0857	.0934	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 201 / 11 KV ANAWALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
1	1.2003
2	1.2003
3	1.3717
4	1.7147
5	1.7147
6	2.0576
7	2.0576
24	1.2003
Max	2.0576
Min	1.2003
Avg	1.5647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 202 / 11 KV TAWASHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
1	.2572
2	.2572
3	.2743
4	.2743
5	.3086
6	.3086
7	.3944
Max	.3944
Min	.2572
Avg	.2964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 203 / 11 KV ANAWALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18
HR	Load (MW)
1	.8573
2	.8573
3	.9431
4	1.0288
5	1.0288
6	1.1145
24	.8573
Max	1.1145
Min	.8573
Avg	.9553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274114 / 33/11 KV ANAWALI

Feeder No / Name : 204 / Shirgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
1	.6859
2	.6859
3	.8573
5	1.0288
6	1.2003
7	1.2003
24	.5144
Max	1.2003
Min	.5144
Avg	.8818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 201 / WAKHARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	1.2498	1.5242	2.1338	2.4348	2.3663	.2058
2	.3086	1.2498	1.5242	2.1643	2.1338	2.0576	.2401
3	.3429	1.4632	1.5546	2.1948	2.4006	2.0424	.2401
4	.3772	1.4937	1.5546	2.2558	2.1033	1.829	.2743
5	1.4022	1.6004	1.5546	2.2862	2.1033	2.0424	.2743
6	1.829	1.9204	1.829	2.2862	2.2862	2.0424	.2743
7	2.0729	2.4082					1.5242
8	2.1033	2.4691					2.2862
9	2.1338	.2058					2.2862
10		.1715					1.9814
11		.1715					1.9204
14			.1372				
15			.2058	.1715	.1715	.1372	
16		.1715		.1715	.2058	.1372	
17		.1715		.2058	.2058	.1715	
18		.1715	.2058	.2058	.2058	.2058	
19		.1715	.2229	.2058	.3429	.2401	
20	.2743	.1372	.2572	.1715	.3086	.2058	.3429
21	.2401	.1372	.2743	.1715	.2743	.2058	.2058
22		.0686	.2439	.1715	.2401	.2058	.2058
23		1.3717	1.829	2.6825	2.2558	.2058	.1372
24	.2058	.2058	1.4022	2.1338	2.1338	2.0119	.2058
Max	2.1338	2.4691	1.829	2.6825	2.4348	2.3663	2.2862
Min	.2058	.0686	.1372	.1715	.1715	.1372	.1372
Avg	.9580	.8505	.9546	1.2258	1.2379	1.0067	.7878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 202 / KHED BHALWANI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	2.5606	2.8045	3.0178	2.7435	2.0424	.0343
2	.0343	2.5911	2.8045	2.9569	2.7435	2.1338	.0343
3	.0343	2.7282	2.8959	2.8959	2.6216	2.1948	.0343
4	.0343	2.7435	2.8959	2.8045	2.4387	2.0424	.0343
5	.0343	2.8045	2.9264	2.7435	2.5301	2.1338	.0343
6	.0343	2.8349	2.9264	2.713	2.5149	2.1338	.0343
7	.0343	3.1093	.0343	.0343	.0343	.0343	2.4387
8	3.0483	3.2007	.0343	.0343	.0343	.0343	3.3836
9	3.2312	.0343		.0343	.0343	.0343	3.5056
10		.0343	.0343	.0343	.0343	.0343	3.5056
11		.0343	.0343	.0343	.0343	.0343	3.5056
12				.0343	.0343	.0343	
13				.0343		.0343	
14				.0343		.0343	
19				.0343			
20	.1715	.0343	.0343	.0343	.0686	.0343	.0343
21	.1029	.0343	.0343	.0343	.0343	.0343	.0343
22		.0343	.0343	.0343	.0343	.0343	.0343
23		3.1893	2.774		2.1643	.0343	.0343
24	.0343	.0686	2.8045	3.2007	2.7435	2.1948	.0343
Max	3.2312	3.2007	2.9264	3.2007	2.7435	2.1948	3.5056
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.5690	1.6273	1.5381	1.0918	1.2261	.8046	1.0448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 203 / KOUTHALI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	3.2922
2	.0343	.0343	.0343	.0343	.0343		3.2922
3	.0343	.0343	.0343	.0343	.0343	.0343	3.3074
4	.0343	.0343	.0343	.0343	.0343	.0343	3.3227
5	.0343	.0343	.0343	.0343	.0343	.0343	3.3532
6	.0343	.0343	.0343	.0343	.0343	.0343	3.3532
7	.0343	.0343	.0343	.0343	.0343	.0343	
8	.0343	.0343	.0343		.0343	.0343	
9	.0343	.0343					
10	.0343	.0343					
11	.0343	.0343					
12	.0343	3.5361					
13	.0343						
14	.0343		1.829				
15			3.719	3.719	3.2312	2.7435	
16		.6706	3.7799		3.658	3.0483	
17		3.5056	3.8409	3.5056	2.9264		
18		3.5361	3.8409	3.5056	3.1093		
19		3.3532	3.658	1.89	2.6216	3.5361	.0343
20		.0343	3.5665	1.89	2.9264	3.3532	.0343
21		.0343	3.6275	1.9509	2.7435	3.1093	.0343
22		.0343	3.4141	1.89	2.6216	3.2007	.0343
23		.0343	.0343	.0343	.0343	3.2312	3.2312
24	.0343		.0343	.0343	.0343		3.2769
Max	.0343	3.5361	3.8409	3.719	3.658	3.5361	3.3532
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.7558	1.6641	1.1662	1.3434	1.6045	2.2139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 204 / SHIRDHONE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			3.3532	3.3532	2.9264	3.2312	
8			3.4141	3.4141	3.1703	3.2922	
9				3.4141	.4877	3.2922	
10			3.5056	3.3532	.4877	3.3836	
11			3.3532	3.2922	.4268	3.5056	
12		3.2922	3.2922	3.3532	.4268	3.597	
13		3.2312	3.2922	3.3532	.4268	3.658	
14		3.2312	3.2007	3.3532		3.2922	
15	2.8654	3.3532					
16	3.3532						
17	3.2922						
18	3.2007						
19	3.0483						3.1703
20							3.4751
Max	3.3532	3.3532	3.5056	3.4141	3.1703	3.658	3.4751
Min	2.8654	3.2312	3.2007	3.2922	.4268	3.2312	3.1703
Avg	3.1520	3.2770	3.3445	3.3608	1.1932	3.4065	3.3227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 205 / WAKHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3601	.3429	.4572	.3429	.4115	.3841
2	.3109	.4115	.3086	.4938	.3086	.4458	.4207
3	.3475	.3772	.3086	.5304	.3086	.4287	.4572
4	.3841	.3772	.3772	.5487	.3429	.4801	.4755
5	.3841	.4801	.5144	.5487	.4287	.4801	.4938
6	.3841	.5144	.4801	.5853	.4973	.5144	.5121
7							.4572
8	.2926	.3086					.2926
9	.1829	.2743					.2926
10		.12	.1463				.2572
11		.12	.1829	.2743			.12
12	.0686		.2378	.2743	.1543	.2378	.1715
13	.12		.2378	.1715	.2058	.2378	
14	.1372	.1372	.1829	.1372		.2012	.2058
15	.12	.1372	.1463	.1715	.1543	.2743	.2058
16	.1372	.1715	.1646	.1715	.1543	.3475	.1715
17	.1029	.2058	.1829		.2229		.1715
18	.1029	.2058	.1829		.2229		.2915
19	.1372	.3086	.2743	.3429	.3601	.4572	
20	.4287	.3086	.3475	.3429	.4287	.4572	.4287
21	.4287	.3086	.3841	.3944	.3944	.439	
22		.3429	.3658	.3944	.3944	.3658	
23		.3086	.4024	.3429	.463	.3658	
24	.2743	.3429	.3772	.4207	.3429	.3772	.3658
Max	.4287	.5144	.5144	.5853	.4973	.5144	.5121
Min	.0686	.12	.1463	.1372	.1543	.2012	.12
Avg	.2431	.2915	.2927	.3668	.3182	.3836	.3250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274131 / 33/11KV WAKHARI

Feeder No / Name : 206 / 11 KV Mauli Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4115	.3944	.5121	.3429	.4115	.5121
2	.5121	.4115	.3429	.5304	.3429	.463	.5304
3	.5304	.4287	.3429	.5487	.3772	.4973	.5487
4	.5487	.3772	.3429	.5487	.4287	.4115	.5853
5	.5487	.4458	.3772	.5487	.4287	.4458	.6219
6	.567	.463	.4458	.5487	.5144	.4973	.6401
7	.567	.583	.4801		.5658	.5316	.5304
8	.4572	.4801	.463		.463	.4458	.439
9	.3841	.3258		.4572	.463	.3601	.3475
10		.3429	.5121	.4458	.463	.4024	.4973
11	.4801	.3258	.5853	.4458	.463	.4024	.4115
12	.4458	.3601	.6584	.4458		.4024	.4115
13	.1886	.3601	.5121	.4458		.3841	
14	.1372	.4115	.4938	.4458	.4115	.3841	.4287
15	.2743	.3429	.5121	.3772	.3944	.439	.4287
16	.2915	.3429	.4572	.4801	.4287	.4938	.4287
17	.3258	.3601	.4207	.4801	.5144	.5121	.4458
18	.3086	.4801	.4207	.5316	.4973	.567	.5144
19	.3086	.4973	.4938	.5487	.6344	.6219	.5144
20	.4801	.5144	.5853	.5487	.583	.6219	.583
21		.5316	.6767	.5487	.6001	.6219	.5316
22		.5487	.6219	.5144	.583	.5853	.5487
23		.4287	.5487	.5144	.4973	.5304	.4801
24	.4755	.4287	.3944	.5121	.4287	.463	.5121
Max	.567	.583	.6767	.5487	.6344	.6219	.6401
Min	.1372	.3258	.3429	.3772	.3429	.3601	.3475
Avg	.4153	.4251	.4818	.4991	.4739	.4790	.4996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 201 / 11 KV DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	1.2955	1.3717	1.2146	1.4575	1.4575
2	1.1336	1.1336	1.2955	1.3717	1.2955	1.4575	1.4575
3	1.1336	1.1336	1.2955	1.3717	1.2955	1.4575	1.4575
4	1.1336	1.2955	1.2955	1.5432	1.2955	1.4575	1.6194
5	1.2955	1.4575	1.2955	1.5432	1.2955	1.4575	1.6194
6	1.2955	1.4575	1.4575	1.5242	1.2955	1.6194	1.6194
7	1.4575						
8		1.4575	1.6194	1.6766	1.7814	1.7814	1.7814
9	1.6194	1.6194	1.6194	1.5242	1.7814	1.7814	1.7814
10	.0905	.0905	.0905	.0762	.0905	.0905	.0905
11	.0905	.0905	.0905	.0857	.0905	.0905	
12	.0905		.0905	.0762	.0905		
18	.0905	.0905			.0905		
19	.0905	.0905	.0905	.0762	.0905	.0905	.181
20	.181	.181	.181	.0762	.0905	.181	.181
21	.181	.181	.181	.0762	.0905	.181	.181
22	.181	.181	.181	.0762	.0905	.181	.181
23	.181	.181	.181	.0762	.0905	.181	.181
24	.9717	.9717	1.2955	1.3717	1.2146	1.4575	1.4575
Max	1.6194	1.6194	1.6194	1.6766	1.7814	1.7814	1.7814
Min	.0905	.0905	.0905	.0762	.0905	.0905	.0905
Avg	.6771	.7402	.7974	.8187	.738	.9327	1.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 202 / 11 KV PIRACHI KUROLI SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	.181	.1715	.181	.181	.181
2	.181	.181	.181	.1715	.181	.181	.181
3	.181	.181	.181	.1715	.181	.181	.181
4	.181	.181	.181	.1524	.181	.181	.181
5	.181	.181	.181	.1524	.181	.181	.181
6	.181	.181	.181	.1524	.181	.181	.181
7	.0905	.181	.362	.1524	.181	.362	.181
10	.181	.181	.181	.1524	.181	.181	.181
11	2.1052	2.4291	2.5911	2.4387	1.9433	1.9433	2.915
12	2.915	2.915		2.5911	2.1052		3.2388
13	2.915	2.915	2.915	2.2862	2.1052	3.4008	
14	2.753	2.915	2.753	2.2862	2.1052	3.2388	
15			2.753				
16	2.915	2.5911	2.5911	2.2862	1.7814	3.4008	
17	2.915	2.5911	2.5911	2.2862	1.7814		
18	2.753	2.4291	2.4291	2.2862	1.7814	3.4008	
19	.1619	.181	.181	.1715	.181	.181	.362
20	.181	.181	.181	.1524	.181	.362	.362
21	.181	.181	.181	.1524	.181	.362	.362
22	.181	.181	.181	.1524	.181	.362	.362
23	.181	.181	.181	.1524	.181	.181	.362
24	.181	.181	.181	.1524	.181	.181	.181
Max	2.915	2.915	2.915	2.5911	2.1052	3.4008	3.2388
Min	.0905	.181	.181	.1524	.181	.181	.181
Avg	1.0331	1.0152	1.0161	.8891	.7684	.9812	.5996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 203 / 11 KV CHANDRABHAGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	1.2955	1.2955	1.1336	1.4575	1.4575
2	1.1336	1.1336	1.2955	1.2955	1.1336	1.4575	1.4575
3	1.1336	1.1336	1.2955	1.2955		1.4575	1.4575
4	1.1336	1.2955	1.2955	1.4575	1.2955	1.4575	1.4575
5	1.2955	1.4575	1.2955	1.4575	1.2955	1.4575	1.6194
6	1.2955	1.4575	1.4575	1.4575	1.2955	1.6194	1.6194
7	1.4575		1.4575	1.4575	1.2955	1.6194	1.6194
9		1.8099	1.6194	1.4575	1.7814	1.7814	1.6194
10	.0905	.0905	.0905	.0905	.0905	.0905	.0905
11	.0905	.0905	.0905	.0905	.0905	.0905	.0905
12	.0905		.0905	.0905	.0905		
13							.0905
14							.0905
18	.0905	.0905			.0905		
19	.0905	.0905		.0934	.0905	.0905	.0905
20	.0905	.0905	.0905	.0905	.0905	.0905	.1448
21	.0905	.0905	.0905	.0905	.0905	.0905	.0905
22	.0905	.0905	.0905	.0905	.0905	.0905	.0905
23	.0905	.0905	.0905	.0905	.0905	.0905	.0905
24	.9717	.9717	1.2955	1.2955	1.1336	1.4575	1.4575
Max	1.4575	1.8099	1.6194	1.4575	1.7814	1.7814	1.6194
Min	.0905	.0905	.0905	.0905	.0905	.0905	.0905
Avg	.6004	.6847	.8088	.7763	.6576	.8999	.8130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 204 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4887	.5316	.4801	.543	.4887	.543
2	.4525	.4887	.5144	.4801	.5792	.4887	.5068
3	.4887	.5611	.5487	.5144	.6154	.543	.5068
4	.5068	.6697	.583	.6516	.6516	.6516	.543
5	.5792	.7602	.6859	.703	.6878	.7602	.6335
7	.7602	.8326	.6859	.7373	.724	.724	.8507
8	.6697		.6344	.6173	.5973	.6154	.724
9	.4887	.4706	.3772	.463	.4887	.5068	.5249
10	.362	.3982	.4287	.3944	.3982	.3982	.4525
11	.362	.3258	.3601	.3086	.2896	.3801	.3801
12	.3258	.2715	.3772	.2572	.2715		
13	.3258			.2572	.2353		.4344
14	.362			.2572	.2534	.4163	.4163
15	.3801	.3258	.3772	.2572	.2715	.3982	.4163
16	.362	.362	.4115	.3086	.3077	.4344	.4344
17	.4163	.4344	.4458	.3429	.3439		.4706
18	.5611	.5249	.463	.4973	.362		.5068
19	.7602	.7602	.6859	.6516	.6697	.724	.6516
20	.8507	.8507	.7373	.5335	.6878	.8145	
21	.7602	.5792	.703	.4877	.6154	.7602	.6878
22	.6878	.5792	.6344	.4268	.543	.7059	.6154
23	.5249	.5792	.6001	.4268	.5068	.6335	.5792
24	.4887	.5068	.5316	.5144	.5068	.4887	.6335
Max	.8507	.8507	.7373	.7373	.724	.8145	.8507
Min	.3258	.2715	.3601	.2572	.2353	.3801	.3801
Avg	.5186	.5385	.5389	.4595	.4848	.5754	.5482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274161 / 33/11 KV PIRACHI KUROLI

Feeder No / Name : 205 / NEW DHONDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2715	.362	.3048	.2896	.362	.3258
2	.181	.2715	.362	.3048	.2715	.362	.3258
3	.181	.3258	.3982	.3353	.2715	.362	.362
4	.2172	.3982	.4706	.381	.3258	.3801	.362
5	.2534	.4887	.5068	.3963	.3258	.3982	.362
6	.2353	.5249	.543	.442	.3258	.4706	.362
7	.2353	.5611	.543	.4877	.362	.4706	.362
10	.2715	.2534	.2715	.2134	.2353	.1991	.2172
11	1.1336	1.6842	1.6842	1.9814	1.8785	1.8623	1.8947
12	2.1214	2.0729	2.2348	2.1338	2.2024		2.2348
13	2.1538	2.0729	2.1376	2.1338	2.2672	2.1052	
14	2.0567	1.9433	2.0405	2.1338	2.1862	2.2024	
15	1.9919	1.7814		2.1338	2.1052	2.0729	
16			2.1862				
17	2.1376	1.9433	2.2024	2.1338	2.251		
18	2.1862	2.1052	2.2186	2.1338	2.2834	2.4939	
19	.3439	.362	.2715	.3201	.3258	.181	.362
20	.3982	.4344	.4344	.3048	.4344	.362	.4344
21	.3982	.362	.4163	.3048	.4163	.362	.3982
22	.362	.362	.3801	.3048	.3801	.3801	.362
23	.3258	.362	.3801	.2439	.362	.362	.362
24	.181	.2715	.362	.3048	.2896	.362	.362
Max	2.1862	2.1052	2.2348	2.1338	2.2834	2.4939	2.2348
Min	.181	.2534	.2715	.2134	.2353	.181	.2172
Avg	.8355	.8977	.9717	.9254	.9424	.8290	.5681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 201 / UJANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9783	.9602	.7621	.9568	.9259	.9783	1.034
2	.9332	1.0212	.7926	.9877	.9568	.9783	1.034
3	.9783	1.0212	.8383	1.0494	.9722	1.0536	1.0802
4	.9783	1.1888	.884	1.0957	1.1641	1.1288	1.1265
5	1.0536	1.2193	1.1222	1.1574	1.0802	1.189	1.1574
6	1.1288	1.2651	1.0517	1.2346	1.1574	1.3245	1.2191
7	1.2793	1.3413	1.2193	1.25	1.2654	1.3847	1.3426
8	1.2793	1.2346	1.2803	1.2963	1.3117		1.3117
9	.0602	.061	.061	.061	.1219	.1054	.1219
10	.1235	.108	.0457	.0762	.1219	.1372	.1524
11	.1389	.108		.1219	.1372	.1677	.1677
12	.1235	.1543		.1219	.1067	.0914	.1219
13	.1389	.108	.0305	.0914	.0914	.1067	
14	.1389	.0772	.0305	.0762	.0762	.1219	
15	.1543	.0617	.0305	.0914	.1372	.1235	
16	.1389	.0617	.0305	.1067	.1505	.1389	
17	.1355	.0602	.0772	.0772	.1656	.1543	
18	.0903	.1204		.108	.1505	.1543	
19	.1204	.1957	.108	.1235	.1505	.1389	
20	.1656	.1957	.1389	.1235	.1505	.1543	.1829
21	.1505	.1806	.1389	.1389	.1505	.1543	.1829
22	.1355	.1204	.1389	.1389	.1505	.1389	.1981
23	.1204	.0753	.1235	.1235	.1355	.1389	.1981
24	.8322	.8078	.7676	.9105	.8951	.9482	.9877
Max	1.2793	1.3413	1.2803	1.2963	1.3117	1.3847	1.3426
Min	.0602	.0602	.0305	.061	.0762	.0914	.1219
Avg	.4740	.4895	.4606	.4799	.4886	.4788	.6835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 202 / RAMESHWAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5792	.442	.463	.463	.4572	.4938
2	.6097	.6859	.4572	.5864	.5401	.4877	.5864
3	.6554	.7164	.4877	.6944	.6481	.5335	.679
4	.6859	.8078	.5335	.7716	.7253	.7316	.787
5	.7621	.8688	.7164	.8951	.8333	.8993	.8951
6	.9907	1.0059	.9297	1.0185	.9722	1.1431	1.0031
7	1.387	1.2955	1.3108		1.0957	1.1888	.9568
8	1.3108	1.1888	1.3108	1.2809	1.2346	1.174	.9259
9	.1829	.0914	.0762		.1677	.1486	.1219
10	.1698	.1235	.1067	.1219	.1677	.1829	.1219
11	.1698	.1389	.1524	.1524			.1372
12	.108	.1389	.1524	.1524	.1677	.1372	.1677
13	.0926	.108	.1372	.1372	.1524	.1524	
14	.108	.108	.1372	.1372	.1524	.1677	
15	.0926	.1235	.1372	.1219	.1524	.1543	
16	.0926	.1389	.1219	.1067	.1524	.1543	
17	.1219	.1829	.1235	.1235	.1677	.1698	
18	.1524	.1981	.1389	.1852	.1677	.2315	
19	.1981	.2286	.1389	.1677	.1829	.216	
20	.2286	.2286	.1543	.1852	.1981	.2006	.2743
21	.1829	.1829	.1543	.2006	.2134	.2006	.2591
22	.1677	.1524	.1389	.2006	.1981	.2315	.2286
23	.1524	.1524	.1698	.1852	.2134	.216	.1981
24	.4572	.3506	.381	.3704	.3704	.4064	.4012
Max	1.387	1.2955	1.3108	1.2809	1.2346	1.1888	1.0031
Min	.0926	.0914	.0762	.1067	.1524	.1372	.1219
Avg	.4037	.4082	.3587	.3754	.4059	.4167	.4845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 203 / 11Kv palashi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.9259	.9259	1.0031	.9907	.8173	.8993
2	.6859	.9722	.9568	.9755	1.0212	.8916	.945
3	.6859	.9722	.9259	1.0059	1.0212	.8619	1.0031
4	.7316	1.0031	.9877	1.0364	1.0364	.8916	1.0364
5	.7621	1.0031	1.0031	1.0669	1.0364	.9214	1.0822
6	.945	1.0494	.9722	1.1126	1.0669	1.0105	1.1431
7	1.1126	1.142	1.1111	1.1279	1.1279	1.1443	1.142
8	1.1431	1.1574	1.142	1.1736	1.1888	1.0848	1.0974
9	.061	.108	.1543	.0926	.1235	.0753	.108
10	.1677	.1677	.1852	.1543	.1372	.108	.1389
11	.1543	.1852	.2006	.1698	.1991	.1235	.1852
12	.1219	.1698	.2006	.1852	.1991	.1219	.1543
13	.1372	.1829	.1852	.1543	.1698	.1372	
14	.1677	.1829	.1852	.108	.1543	.1543	
15	.1677		.1543	.1543	.1543	.1524	
16	.1524	.1829	.1389	.2006	.1635	.1543	
17	.1677	.1783	.1372	.1981	.1635	.1524	
18	.1677	.1932		.2006	.1783	.1543	
19	.1829	.1486	.1543	.1829	.1783	.1235	
20	.1829	.1486	.1981	.1698	.1486	.1524	.2286
21	.1829	.1486	.2134	.1829	.1635	.1698	.2439
22	.1677	.1337	.2006	.1981	.1635	.1524	.2743
23	.1524	.1337	.2006	.1981	.1337	.1677	.2896
24	.7526	.9259	.9105	.9755	1.0364	.8619	.8535
Max	1.1431	1.1574	1.142	1.1736	1.1888	1.1443	1.1431
Min	.061	.108	.1372	.0926	.1235	.0753	.108
Avg	.4106	.4963	.4976	.5011	.4982	.4410	.6368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274165 / 33/11KV PALASHI

Feeder No / Name : 204 / Palashi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2172	.2172	.2686	.2686	.2353	.2507
2	.2534	.2172	.2353	.3045	.2865	.2353	.2507
3	.3258	.1991	.2378	.3224	.2507	.2715	.2686
4	.3258	.2715	.2715	.3582	.2686	.3258	.3224
5	.362	.362	.3982	.4119	.3582	.4525	.3582
6	.4525	.5068	.543	.4835	.4835	.543	.5373
9			.4525	.3077	.3258	.3258	.362
10	.3224	.3045	.3258	.2715	.2715	.2715	.3077
11	.2686	.2686	.2715	.2353	.2353	.2353	.2172
12	.2507	.2686	.1267	.2172	.2353	.1448	.2172
13	.2507	.2865	.181	.181	.181	.1629	.2172
14	.2686	.2865	.1991	.1448	.1448	.181	.1991
15	.2865	.2686	.1991	.1448	.181	.2865	.2172
16	.2507	.2686	.2172	.1448	.1991	.2328	.2353
17	.2715	.2172	.2328	.2328	.2172	.2686	.2353
18	.3258	.2715	.2686	.2686	.2715	.2865	.2715
19	.362	.362	.2507	.2507	.2715	.2686	.3439
20	.5249	.3258	.2865	.2507	.3258	.2507	.3982
21	.4525	.2715	.2865	.3045	.362	.2686	.362
22	.2715	.2172	.2686	.2507	.3077	.2507	.3258
23	.2715	.2353	.2507	.2507	.2534	.2507	.2534
24	.2353	.2172	.2172	.2507	.2686	.2353	.2686
Max	.5249	.5068	.543	.4835	.4835	.543	.5373
Min	.2353	.1991	.1267	.1448	.1448	.1448	.1991
Avg	.3128	.2783	.2699	.2662	.2713	.2720	.2918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274254 / 33/11 KV TANALI

Feeder No / Name : 201 / 11 KV TANALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.2058	.1886	.2058	1.0802
2	.1715	.1715	.2572	.2058	.2058	1.1145
3	.1715	.1715	.2058	.1886	.2058	1.1145
4	.1886	.1715	.2229	.1715	.1886	1.166
5	.2058	.1886	.2572	.1715	.1886	1.1831
6	.2058	.2058	.2572	.1715	.2058	1.2174
7	.1543	.2229	.2572	.2058	.2058	1.5775
8	.12	.1886	.2229	.1543	.1715	1.5947
9	.1372	.1715	.2229	.1543	.1543	
10	.1372	.1372	.2229	.1543	.1543	
11	.6859	1.1145		1.2689	1.1831	
12	1.6118	1.5775	1.749	1.749	1.6975	
13	1.6289	1.5089	1.7318	1.5947	1.5261	
14	1.6289	1.6289	1.6461	.4801	1.5432	
15	1.5432	1.6118	1.5432		1.6289	
16	1.6118	1.5947	1.6289	1.5432	1.6461	
17	1.6118	1.6289	1.6461	1.5432	1.6289	
18	1.5775	1.5775	1.6289		1.6289	
19	.1715	.1543	.1543		.2058	
20	.2058	.2058	.2401		.2401	
21	.2401	.2229	.2229		.2401	
22	.2401	.2229	.2058		.2229	
23	.2058	.2058	.2058		.1886	
24	.1715	.2058	.2058	.2058	.2058	.9774
Max	1.6289	1.6289	1.749	1.749	1.6975	1.5947
Min	.12	.1372	.1543	.1543	.1543	.9774
Avg	.6173	.6359	.6583	.5971	.6530	1.2250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-I S/DN[098] BU 6327

Substation No/ Name :- 274254 / 33/11 KV TANALI

Feeder No / Name : 202 / 11 KV YALLAMA DEVI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	1.3717	1.4746	1.286	1.0974	.3944
2	1.3889	1.3717	1.5261	1.3717	1.0974	.3944
3	1.4746	1.3717	1.5261	1.4575	1.1145	.3944
4	1.6975	1.5432	1.5947	1.6289	1.1145	.3944
5	1.7147	1.7147	1.6975	1.7661	1.5432	.4115
6	1.7661	1.8004	1.869	1.8176	1.7147	.4115
7	1.9376	2.0576	2.0919	1.9033	1.8176	.4115
8	1.7661	2.2291	2.2119	1.9547	1.7814	.4458
9	2.0919	2.0062	2.2119	1.9376	1.7147	
10	.2229	.2401	.2229	.2401	.3944	
11	.1886	.3944		.3601	.2743	
12	.3944	.4115	.3944	.4287	1.6975	
13	.3944	.4287	.3601	.4458	.3601	
14	.4115	.4973	.3772	.3944	.4801	
15	.4458	.4973	.4458	.3772	.4115	
16	.4115	.3772	.5316	.3601	.4115	
17	.3772	.4115	.5487		.4115	
18	.4115	.463	.5658		.4287	
19	.463	.4458	.5658		.4287	
20	.463	.4115	.5316		.4458	
21	.463	.4115	.5144		.4287	
22	.4458	.4115	.4973		.4115	
23	.4458	.4115	.4973		.4115	
24	1.3032		1.4575	1.166	1.0288	.3944
Max	2.0919	2.2291	2.2119	1.9547	1.8176	.4458
Min	.1886	.2401	.2229	.2401	.2743	.3944
Avg	.9181	.9252	1.0310	1.1115	.8758	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 201 / 11 KV GURUSALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.4387	2.0576	2.6235	1.7147	3.0864	.0686
2	2.0576	2.4387	2.0576	2.572	1.7147	3.0864	.0686
3	2.2291	2.4387	2.1948	2.572	1.7147	3.0864	.0686
4	2.2291	2.6216	2.6406	3.0864	1.7147	3.2579	.0686
5	2.4006	2.7435	2.8807	3.0864	1.7147	3.4294	.0686
6	3.0864	2.8045	2.9835	3.1379	2.0576	3.6008	
7	3.0864	3.0483	3.2579	3.2579	2.1262	3.7723	
8	3.0864	3.1207	3.2579	2.8959	2.1262	3.0483	
9							3.0483
10							3.6351
11							3.6351
16							3.2922
17	.061		.0686	.0686		.0686	.0686
18		.0686		.0686	.0686	.0686	.0686
19	.061	.0686	.0686	.0686	.0686	.0686	.0686
20	.061	.0686	.0686	.0686	.0686	.0686	.0686
21	.061	.0686	.0686	.0686	.0686	.0686	.0686
22	.061	.0686	.0686	.0686	.0686	.0686	.0686
23	.061	.0686	.0686	.0686	.0686	.0686	.0686
24	.0686	.061	.0686	.0686	.0686	.0686	.0686
Max	3.0864	3.1207	3.2579	3.2579	2.1262	3.7723	3.6351
Min	.061	.061	.0686	.0686	.0686	.0686	.0686
Avg	1.3779	1.4752	1.4541	1.4863	1.0242	1.6823	.8531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 202 / 11 KV HOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.7147
2							1.8519
3							1.8519
4							1.8519
5							1.8519
6							2.0576
7							2.1262
8							2.2291
9	1.8519	1.7147	1.8519	1.6766	1.5699	1.9052	
10	1.869	1.7318	1.8519	1.6766	1.5699	1.8747	
Max	1.869	1.7318	1.8519	1.6766	1.5699	1.9052	2.2291
Min	1.8519	1.7147	1.8519	1.6766	1.5699	1.8747	1.7147
Avg	1.8605	1.7233	1.8519	1.6766	1.5699	1.8900	1.9419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 203 / 11 KV CHILAIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	2.5377	2.4006	3.0007	2.4691	3.0007	.8573
2	1.5432	2.5377	2.4006	3.0864	2.4691	3.0007	.8573
3	1.5432	2.7435	2.5377	3.0864	2.6063	3.0007	.8573
4	1.7147	2.8807	3.0521	3.0864	2.8807	3.0864	.8573
5	2.0576	3.2579	3.2236	3.0864	3.0178	3.0864	.8573
6	2.0576	3.4294	3.3265	3.2579	3.1893		
7	2.1948	3.275		3.2579	3.4637	3.0864	
8	3.858	3.2579		3.4294	3.5665	3.6008	
9							3.0178
10							3.4122
11							3.6351
16							2.572
17	.6859		.5658	.6859			
18		.6859	.5658	.9602	.8916	.8573	.7545
19	.8573	1.0974	.6859	.9602	.8916	1.1317	.7545
20	1.0288	1.0974	.6859	.9602	.8573	1.1831	.7545
21	.8916	1.0974	.6859	.9602	.8573	1.1145	.7545
22	.6859	.9602	.6859	.9602	.7716	1.1145	.6859
23	.5144	.823	.6859	.9602	.7202	1.0288	.6859
24	.8573	.6516	.823	.6859	.9602	.7888	1.0288
Max	3.858	3.4294	3.3265	3.4294	3.5665	3.6008	3.6351
Min	.5144	.6516	.5658	.6859	.7202	.7888	.6859
Avg	1.4689	2.0222	1.5947	2.0265	1.9742	2.0772	1.3964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 204 / 11 KV GURSALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.8402	.7888	.7716	.8573	.7545	.9602
2	.5144	.8573	.7888	.7716	.8573	.7888	.9602
3	.5144	.8573	.7888	.7716	.8573	.8676	1.166
4	.6173	.9259	.8573	.9259	.8573	.9259	1.3717
5	.6516	1.0288	.9945	1.0288	1.0631	1.0288	1.3717
6	.7545	1.1488	1.0288	1.2003	1.2346	1.0631	1.3375
7	1.0288	.9602	1.0631			1.2346	1.2346
8		.8745	.9259	.8573			
9	.8745	.8573	.8916	1.0802	.9088	.9431	.7373
10	.8573	.8402	.9602	.8916	.9945	.9259	.8573
11	.6001	.7888	.8573	.8573	.823	.8573	
12	.7373	.7202		.7545	.7545	.7373	
13	.703	.6859		.7545	.7716	.7545	.7716
14	.6859	.6516	.7545	.7545	.7202	.7716	.7888
15		.6173	.7545	.7716	.6859	.823	.7888
16	.6516	.7202	.7545	.703	.7922	.8402	.7545
17	.7202		.7716	.6859			
18		.9259		.8573	.7888	.9602	.9602
19	1.0802	1.0631	.7888	1.2346	1.166	1.2689	.8745
20	1.0631	1.166	.7545	1.2689	1.2003	1.3717	1.046
21	1.0288	1.166	.7888	1.0974	1.0288	1.2346	1.0288
22	.9945	.9945	.6859	.9945	.0686	1.0631	
23	.8573	.7888	.5487	.8573	.9259	.9602	.9259
24	.5487	.8402	.7888	.5144	.8573	.7545	.9602
Max	1.0802	1.166	1.0631	1.2689	1.2346	1.3717	1.3717
Min	.5144	.6173	.5487	.5144	.0686	.7373	.7373
Avg	.7634	.8834	.8255	.8872	.8673	.9513	.9945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 206 / 11 KV KARKHANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1372	.1372	.1372			
2	.2743	.1372	.1372	.1372	.1372		
3	.2743	.1372	.1372	.1372	.1372		
4	.2743	.2058	.1372	.1372	.1372		
5	.2743	.2743	.2743	.1372	.1372		
6	.2743	.2743	.2743	.1372	.2743		
7	.2743	.2743	.2743	.1372	.2743		
8	.2743	.2743	.2743	.1372	.2743		
9	3.2579	3.858	2.2462	3.4294	3.5665		
10	3.3093	3.5837	2.4177	3.9781	2.332		
11		3.7723	2.4006	3.2922	3.2236		
12		3.2236		3.1207	3.0178		
13	3.4808	3.2579		3.0864	3.155		
14	3.3436	3.8409	2.1434	2.7435	3.0864		
15	2.8807	3.3265	2.1434	2.4691	3.0178		
16	3.155	3.2922	2.0576	2.6406	3.0178		
17		.1372					
18	.1372		.1372	.1372	.2401		
19	.2743	.2743		.1372			
20	.2743	.2743	.1372	.2743			
21	.2743	.2743		.1372			
22	.2743	.1372	1.4746	.1372			
23	.1372	.1372	.1372	.1372			
24	.2743	.1372	.1372	.1372	.1372	.2401	.1372
Max	3.4808	3.858	2.4177	3.9781	3.5665	.2401	.1372
Min	.1372	.1372	.1372	.1372	.1372	.2401	.1372
Avg	1.1080	1.3583	.8989	1.1720	1.5392	.2401	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274051 / 33/11 KV GURSALE

Feeder No / Name : 207 / 11 KV JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17	1.0802	1.286	1.286	1.3546	1.286	1.5432	1.4918
18	1.046	1.2003	1.2346	1.4232	1.2517	1.6461	1.6461
19						1.5432	1.5604
20						1.5604	1.5432
21						1.4918	1.5432
22						1.5089	1.5432
23						1.5089	1.5432
24							1.5089
Max	1.0802	1.286	1.286	1.4232	1.286	1.6461	1.6461
Min	1.046	1.2003	1.2346	1.3546	1.2517	1.4918	1.4918
Avg	1.0631	1.2432	1.2603	1.3889	1.2689	1.5432	1.5475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 201 / 11 KV UMBARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7865		1.0374
2		.9156		1.1765
3		.9362		1.3336
4		1.0174		1.1317
5		1.0852		1.6194
6		1.1022		1.8671
7		1.4089		1.8671
8		1.5565		1.6118
19	.181			
20	.1829		.1966	
21	.1867		.2035	
22	.1867		.1696	
23	.1905		.1526	
24		.1905		.1715
Max	.1905	1.5565	.2035	1.8671
Min	.181	.1905	.1526	.1715
Avg	.1856	.9999	.1806	1.3129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 202 / 11 KV SANGAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.426		.4763
2		.426		.3048
3				.2667
4		.3224		.2667
17	3.1786		2.834	
18	2.9797		2.915	
19	2.9767		3.1369	
20	2.8807		3.086	
21	2.8837		2.9504	
22	2.713		2.7854	
23	2.713		2.5857	
24		2.5911		2.894
Max	3.1786	2.5911	3.1369	2.894
Min	2.713	.3224	2.5857	.2667
Avg	2.9036	.9414	2.8991	.8417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 203 / 11 KV RANMALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4578		.3978
2		.4748		.4572
3		.4239		.4191
4		.4049		.4191
9	1.8679		1.6004	
10	1.8515		1.5623	
11	1.9669		1.749	
12	1.8785		1.6108	
13			1.2631	
16	1.8623		1.4883	
19	.373			
20	.407		.4588	
21	.4748		.5906	
22	.4748		.4858	
23	.5784		.4748	
24		.5407		.4748
Max	1.9669	.5407	1.749	.4748
Min	.373	.4049	.4588	.3978
Avg	1.1735	.4604	1.1284	.4336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 205 / 11 KV BARDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5074		1.4022
2		1.8652		2.2672
3		2.1956		2.5339
4		2.5606		3.0445
5		2.5911		2.8826
6		2.9835		3.1878
7		3.086		2.9165
8		3.086		2.5749
19	.3932			
20	.4748			
21	.4588			
22			.3258	
23	.3582		.3584	
24		.3239		.3294
Max	.4748	3.086	.3584	3.1878
Min	.3582	.3239	.3258	.3294
Avg	.4213	2.2444	.3421	2.3488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 206 / 11 KV Karkamb Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5373		.5487
2		.543		.5258
3		.7392		.5373
4		.7468		.7087
5		.7392		.7164
6		.7316		.724
7		.7468		.724
8		.7011		.5487
9	.7164		.7164	
10	.724		.6935	
11	.7011		.7011	
12	.7164		.724	
13	.7164		.7164	
14	.5373		.5487	
15	.543		.543	
16	.543		.5487	
17			.7316	
18	.7164		.9335	
19	.7164		.905	
20	.924		.724	
21	.9145		.7468	
22	.7392		.7468	
23	.5601		.7468	
24		.543		.724
Max	.924	.7468	.9335	.724
Min	.5373	.5373	.543	.5258
Avg	.6977	.6698	.7151	.6397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 207 / 11 KV Diwan Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7625		2.9569
2		2.7625		2.8197
3		2.6673		.1905
4		2.6673		3.1436
5		2.6673		3.0483
6		2.8578		3.0483
7				3.0483
8		2.8578		2.934
19	.1905			
20	.3048		.2667	
21	.362		.2858	
22	.3239		.2858	
23	.3048		.2667	
24		.3048		.2667
Max	.362	2.8578	.2858	3.1436
Min	.1905	.3048	.2667	.1905
Avg	.2972	2.4434	.2763	2.3840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274052 / 33/11 KV KARKAMB

Feeder No / Name : 209 / 11 KV GULAME FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3391		.5201
2		.3467		.5258
3		.3391		.4887
4		.3391		.5373
9	2.13		2.4291	
10	2.13		2.3148	
11	2.2043		2.4291	
12	2.1548		2.4006	
13			2.1052	
16	2.2043		2.13	
19	.3239			
20			.381	
21			.381	
22	.3277			
23	.3277		.4588	
24		.3582		.5087
Max	2.2043	.3582	2.4291	.5373
Min	.3239	.3391	.381	.4887
Avg	1.4753	.3444	1.6700	.5161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 201 / 11 KV MENDHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.4715	.6036	.5658	.7545	.7545	.4338
2	.679	.5281	.6036	.6036	.7545	.7922	.5658
3	.679	.5658	.6602	.6602	.7922	.6802	.7356
4	.7167	.5658	.6979	.6602	.8488	.9054	.8865
5	.7545	.6036	.7922	.6036	.9431	.9431	.9054
6	.7922	.5658	.9054	.6602	.9808	1.0185	.8676
7	.7922	.6036	.5281	.811			.7922
8	3.3522	3.5303	3.7409	3.7571		3.6761	.6602
9	3.6761	3.4332	3.7247	3.8218	3.8866	3.6923	.7545
10	3.5627	3.1741	3.6437	3.8056	3.8056		
11	3.6599	3.5465	2.9473	3.6923	2.9959	3.5141	
12	3.7894	2.9635	3.0931	3.7571			
13	3.7085	3.5141	.7125	3.7571	2.672	3.0931	
14					3.9676	3.2388	
15	3.336	3.2388	2.8988	3.6275	3.8866	3.4008	
16	.4527	.4527	.5658	.3018	.5658	.3018	
17	.6224	.5281	.6224	.3772	.7356	.3584	
18	.5281	.6036	1.1694	.4527	.7545	.4534	3.1579
19	.547	.9808	.7356	.8299	.9431	.3772	3.3036
20	.5847	1.0185	.7733	.8299	.9619	.6036	2.8664
21	.6979	.9619	.7733	.9431	.8865	.4715	2.834
22	.6979	.8865	.811	.8299	.8865	.3584	2.5587
23	.7545	.7733	.6979	.7545	.8676	.3772	2.4615
24	.6413	.4715	.6979	.5281	.7545	.7545	.4338
Max	3.7894	3.5465	3.7409	3.8218	3.9676	3.6923	3.3036
Min	.4527	.4527	.5281	.3018	.5658	.3018	.4338
Avg	1.5523	1.4775	1.4086	1.5926	1.6021	1.4174	1.5136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 202 / 11 KV KHARATWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.5101	2.3805	2.4291	2.4291	2.7044	.132
2	2.332	2.5425	2.3805	2.4615	2.4291	2.7368	.132
3	2.332	2.5101	2.4615	2.5425	2.5911	2.7368	.1509
4	2.3967	2.6397	2.7044	2.5425	2.753	2.672	.1509
5	2.4777	2.7368	2.8016	2.6882	2.915	2.2024	.1698
6	2.7368	2.7692	2.9635	2.753	3.1579	2.7854	.1509
7	2.9473	2.834	2.3967		3.1741		.1509
8	.1886	.1886	.1509				2.9473
9	.1509	.1509	.1509				3.0607
10	.1509	.1509	.132				
11	.1509	.132	.132				
12	.132	.132	.132				
13	.1509	.132	.12			.1509	
14						.1509	
15	.1509	.1509	.1509			.132	
16		.1509	.1509		.1509	.132	
17		.1509	.132		.1509	.1132	
18	.1509	.1698	.1509		.2452	.132	.2263
19	.1509	.1698	.1509	.1509	.3018	.132	
20	.1509	.1698	.132	.3772	.3018	.1509	.3018
21	.1509	.1509	.1509	.2829	.3018	.1509	.3018
22	.1698	.1509	.1698	.2829	.2641	.1509	.2829
23	.132	.132	.1509	.2829	.2263	.132	.2263
24	2.2348	2.2348	2.3158	2.3805	2.3482	2.7368	.132
Max	2.9473	2.834	2.9635	2.753	3.1741	2.7854	3.0607
Min	.132	.132	.12	.1509	.1509	.1132	.132
Avg	1.0336	1.0026	.9809	1.5978	1.4838	1.1168	.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 203 / 11 KV PANDHAREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.132	.1509	.1509	.1509	2.1052
2	.1509	.1509	.132	.1132	.1509	.1509	2.2024
3	.2263	.1886	.1698	.1132	.1509	.1886	2.1214
4	.2452	.2263	.2075	.1886	.1509	.1886	2.0243
5	.3018	.2829	.2452	.2263	.1509	.2263	2.0729
6	.3772	.3772	.3395	.2829	.1509	.3206	2.1376
7	.3961	.3395	.3961	.3395	.1509		2.1538
8	.3018	.2829	.3395	.2829	.1886		.2452
9	.2641	.2263	.2829	.2829			.2075
10	.2263	.132	.2263	.2829			
11		.1132	.1698	.1132			
12		.1132	.1509	.0943			
13	.1132	.0943	.1509	.0943		.1698	
14						.132	
15	.1132	.0943	.1509	.0943		.0943	
16	2.1214	2.0081	2.1052	2.1862	2.1052	2.17	
17	2.1862	2.2186	2.2348	2.332	2.2348	2.3158	
18	2.2672	2.0729	2.332	2.2348	2.17	2.4615	.1509
19	2.1376	1.9433	2.2024	1.9109	2.1052	2.3967	
20	2.0405	2.0243	2.1376	1.8785	1.9433	2.1052	.3395
21	1.8623	1.9433	2.0729	1.749	1.8785	2.1376	.2641
22	1.8138	1.8299	1.9433	1.749	1.8461	2.1538	.2263
23	1.7652	1.668	1.8785	1.7652	1.8138	2.1214	.1509
24	.1509	.1698	.1372	.1509	.1509	.1509	2.0891
Max	2.2672	2.2186	2.332	2.332	2.2348	2.4615	2.2024
Min	.1132	.0943	.132	.0943	.1509	.0943	.1509
Avg	.9149	.8109	.8755	.8094	1.0290	1.0908	1.2327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 204 / 11 KV Jadhavwadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4615	2.5911	2.4939	2.5587	3.0769	2.2996	.2452
2	2.4777	2.6882	2.7044	2.6235	3.0769	2.672	.2452
3	2.4939	2.9312	2.9312	2.9473	3.2388	3.0121	.2641
4	2.834	3.1093	3.0769	3.1579	3.2388	3.2388	.2829
5	3.1093	3.3198	3.255	3.4008	3.4008	3.4008	.3395
6	3.417	3.7247	3.4008	3.838	3.4979	3.6275	.3772
7	3.4494	3.919	4.0929	3.838	3.8056	3.8218	.3584
8	3.5303	3.7571	.4715	3.7247	3.8866	3.9352	.2829
9	3.6113	3.4818	.2915	3.7409	3.7409	2.915	.2452
10	.1886	.1886	.1132	.2829	.1509	.0943	.1698
11	.1132	.1509	.1132		.0943	.1132	
12	.0943	.0943	.0943		.0943		
13	.0943	.1132	.0943		.0943	.1132	
14						.1132	
15	.0943	.1132	.0943		.0943	.1132	
16	.1132	.0943	.1132		.0943	.132	
17	.132	.0943	.132		.1132	.132	
18	.1509	.0943	.1132		.1509	.132	3.8866
19	.1886	.2075	.1509	.4338	.2829	.1886	.3018
20	.2641	.2452	.1886	.415	.3018	.2263	.3772
21	.2829	.2829	.2263	.3772	.3018	.2452	.3395
22	.3018	.2641	.2452	.3395	.2829	.2263	.3018
23	.2641	.2263	.2452	.3395	.2641	.2075	.2829
24	2.3482	2.4615	2.4939	2.3967	2.4291	2.251	.2075
Max	3.6113	3.919	4.0929	3.838	3.8866	3.9352	3.8866
Min	.0943	.0943	.0943	.2829	.0943	.0943	.1698
Avg	1.3920	1.4849	1.1798	2.1509	1.5527	1.4439	.5005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274054 / 33/11 KV MENDHAPUR

Feeder No / Name : 205 / 11 KV Ropale Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1698	.1698	.1886	.2263	1.5384
2	.1698	.1886	.1698	.1509	.1886	.2263	1.7814
3	.1698	.1886	.2075	.2263	.2263	.2263	2.0729
4	.1886	.2263	.2263	.2452	.2263	.2452	2.2348
5	.1886	.2641	.2263	.2829	.2241	.2641	2.4615
6	.2452	.2263	.2641	.2641	.2263	.2829	2.5911
7	.2641	.1509	.2263	.2641			2.6235
8	.2263	.1509	.2263	.2263			2.5749
9	.1698	.1509	.2263	.2263			2.5425
10	.1509	.1698	.2263	.1509			.1509
11	2.3954	2.2348	2.3482	1.9433	1.8785	2.0405	
12	2.7044	2.8664	2.6558	2.9473	2.6882		
13	2.8826	2.915	2.753	2.834	2.5911	2.7692	
14						2.6073	
15	2.8664	2.8016	2.5911	2.834	2.4291	2.4777	
16	2.7854	2.753	2.3482	2.5911	2.3967	2.5911	
17	2.672	2.7044	2.1052	2.0243	2.3644	2.4291	
18	2.5911	2.7854	1.9109	2.672	2.4291	2.3805	
19	.1886		.1886	.1886	.1698	.1509	.1509
20	.2263		.2452	.2263	.1886	.1509	.3018
21	.2641	.1509	.2641	.2263	.2075	.1886	.2641
22	.2263	.1698	.2829	.2058	.2263	.2263	.2263
23	.2263	.1698	.2452	.1886	.2263	.2263	.1886
24	.1698	.1698	.1698	.2075	.1886	.2263	1.2631
Max	2.8826	2.915	2.753	2.9473	2.6882	2.7692	2.6235
Min	.1509	.1509	.1698	.1509	.1698	.1509	.1509
Avg	.9627	1.0298	.8816	.9259	1.0139	1.0493	1.4354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 201 / 11 KV DEWADE FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4801	.4801	.4801	.6001	.463	1.326
2	.5144	.4801	.4458	.5144	.6859	.4801	1.3565
3	.5144	.5144	.5144		.7202	.4801	1.5604
4	.5487	.5487	.5487		.7202	.4973	1.4784
5	.6001	.5316	.5487	.583	.6859	.4973	1.5394
6	.6516	.5487	.583	.5316	.7202	.4973	1.6004
7	.6859				.6859		1.6613
8							1.7375
10		.3429	.4801	.3429	.381	.2743	
11		1.8861	1.7318	1.8861	.9145	1.6118	
12	2.1262	2.4691	2.8635	2.5034	1.829	2.0233	
13	2.2119	2.4863	2.5377	2.4006	2.1643	2.2291	
14	2.3148	2.572			2.0271		
15	2.4177	2.5377			2.0881		
16	2.5034	2.5206	2.7606	2.2291		2.2462	
17	2.5034	2.0919	2.6749	2.3148		2.2119	
18	2.5034		2.4348	2.4863	1.9509	2.3491	
19	.4458	.4458	.4458	.3429	.463	.4115	.1829
20	.5144	.5144	.4801		.4801	.4973	.3048
21	.4973	.5487	.5144		.4973	.3601	.3772
22	.4801	.5144	.4801		.4973	.3772	.4458
23	.4458	.4458	.463	.5144	.4973	.3944	.463
24	.4115	.463	.4458	.4458	.5144	.463	1.2498
Max	2.5034	2.572	2.8635	2.5034	2.1643	2.3491	1.7375
Min	.4115	.3429	.4458	.3429	.381	.2743	.1829
Avg	1.1685	1.1471	1.1281	1.2554	.9561	.9665	1.0917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274055 / 33/11 KV PAT KUROLI

Feeder No / Name : 204 / 11 KV SHEVATE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5316	.5144	.4973	.6097	.6859	.12
2	.5487	.6001	.5487	.583	.6097	.7716	.12
3	.6859	.6516	.6173		.6097	.8573	.1029
4	.7202	.6859	.6516	.8059	.6859	.8573	.1029
5	.6859	.7202	.7202		.7621	.9945	.1029
6	.7716	.7716	.8573	.8573	.7621	.9945	.0857
7	.8573	.9602	.8916		.8535	.9945	.0857
8	.9088	.9774	.9431	1.0117	.8078	.12	.1029
9	.9602	.0857	1.0288		.8383	.8402	.6706
10	.12	.0857	.0857	.1029	.0914	.0686	
19	.0686	.0857	.0857	.1029	.0857	.1029	.0857
20	.12	.1029	.0857	.1029	.0857	.12	.0857
21	.1029	.12	.1029		.1029	.12	.1029
22	.1029	.12	.12		.1029	.1029	.1029
23	.1029	.1372	.12	.1029	.1029	.12	.1029
24	.4458	.463	.4973	.4801	.4572	.4115	.12
Max	.9602	.9774	1.0288	1.0117	.8535	.9945	.6706
Min	.0686	.0857	.0857	.1029	.0857	.0686	.0857
Avg	.4823	.4437	.4919	.4647	.4730	.5101	.1396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 202 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343		.0343	.6706
2	.0343	.0343	.0343			.0343	.6706
3	.0343	.0343	.0343			.0343	.7011
4	.0343	.0343	.0343			.0343	.7316
5	.0343	.0343	.0343			.0343	.7926
6	.0343	.0343	.0343		.0343	.0343	.9145
7	.0343	.0343	.0343	.0343	.0171	.0343	1.1279
8	.0343	.0343	.0343	.0343	.0171	.0343	1.0669
9	.0343	.0343	.0343	.0343	.0171	.0343	.0343
10		.0343	.0343			.0343	.0343
11	.7926	.7621	.7468		.7926	.9755	.0343
12	1.0974	1.1279	1.1584		1.0364	1.0974	.0343
13	1.1584	1.1584	1.1736	1.1584	1.1584	1.0974	
14	1.0364	1.0364	1.0669		.9755	1.0364	
15	.9755	1.0364	1.0669		.9755	1.0212	
16	.9755	.9755	1.0364	.945	.9145	1.0364	.0343
17	.9755	.9145	1.0059	.9755	1.0364	1.0059	.0343
18	.9145	.9145	.9907		.9755	.9297	.0343
19	.0343	.0343	.0343		.0343	.0343	.0343
20	.0343	.0343	.0343		.0343	.0343	.0343
21		.0343	.0343		.0343	.0343	.0343
22	.0343	.0343	.0343	.0171	.0343	.0343	.0343
23	.0343	.0343	.0343	.0171	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0171	.0343	.0343
Max	1.1584	1.1584	1.1736	1.1584	1.1584	1.0974	1.1279
Min	.0343	.0343	.0343	.0171	.0171	.0343	.0343
Avg	.3821	.3531	.3664	.3285	.4522	.3645	.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.829	1.448	1.7071	1.3717	1.5242	.0343
2	1.6766	1.9509	1.448			1.6613	.0343
3	1.7071	1.9814	1.4937			1.7528	.0343
4	1.768	2.0119	1.5546			1.9814	.0343
5	1.7985	2.0729	1.7375			2.0576	.0343
6	1.829	2.1338	2.1643		2.0729	2.4006	.0343
7	2.1643	2.2253	2.5301	2.4082	.2743	2.6235	.0343
8	2.3777	2.4387	2.6216	.0305	2.6216	2.5606	.0343
9	.0343	.0343	.0343		.0171	.0343	
10		.0343	.0343		.0373	.0343	.0343
11	.0343	.0343	.0343		.0343	.0343	.0343
12	.0343	.0343	.0343		.0343	.0343	2.0119
13	.0343	.0343	.0343	.0171	.0343	.0343	2.4996
14	.0343	.0343	.0343		.0343	.0343	
15	.0343	.0343	.0343		.0343	.0343	
16	.0343	.0343	.0343		.0343	.0343	2.5606
17	.0343	.0343	.0343		.0343	.0343	2.8654
18	.0343	.0343			.0343	.0343	2.8045
19	.0343	.0343			.0343	.0343	.0343
20	.0343	.0343			.0343	.0343	.0343
21	.0343	.0343			.0343	.0343	.0343
22	.0343	.0343		.0171	.0343	.0343	.0343
23	.0343	.0343	.0343	.0171	.0343	.0343	.0343
24	.0343	.0343	.0343	.0171	.0171	.0343	.0343
Max	2.3777	2.4387	2.6216	2.4082	2.6216	2.6235	2.8654
Min	.0343	.0343	.0343	.0171	.0171	.0343	.0343
Avg	.6731	.7164	.8092	.6020	.3429	.7130	.6329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 204 / 11 KV NARANCHOLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1029	.0857	.1886	.1372	1.3413
2	.1029	.1029	.12			.1372	1.3717
3	.0857	.1029	.1372			.12	1.4022
4	.0857	.0857	.1372			.12	1.4022
5	.0857	.0857	.1543			.1372	1.5699
6	.1029	.1029	.1715		.2058	.1372	1.7985
7	.12	.1029	.1543	.1543	.1886	.1372	2.1033
8	.1372	.12	.1543	.1543	.1543	.1543	2.0271
9	.1543	.1372	.12		.1715	.1372	.12
10		.12	.2058		.1372	.1543	.1029
11	1.387	1.6156	1.387		1.3565	1.5242	.1029
12	1.829	2.1491	2.0729		2.2253	2.0881	.1372
13	2.5606	2.3015	1.6004	2.0119	2.332	2.0119	
14	2.4387	2.1033	1.6309		2.0271	2.1795	
15	2.5911	2.0881	2.0576		2.2634	2.1338	
16	2.3472	2.1033	2.0881	1.89	1.7375	2.0881	.1372
17	2.0271	2.1338	1.9357	1.7833	2.1338	1.9966	
18	2.1186	1.9204			1.8747	1.89	.1372
19	.2401	.1029			.2229	.1543	.2229
20	.2058	.1543			.2058	.1543	.2058
21	.1715	.12			.1886	.1372	.1715
22	.1543	.12		.1715	.1715	.1372	.1372
23	.1372	.12	.1029	.1886	.1715	.12	.1372
24	.1029	.12	.12	.0857	.1715	.1543	.1029
Max	2.5911	2.3015	2.0881	2.0119	2.332	2.1795	2.1033
Min	.0857	.0857	.1029	.0857	.1372	.12	.1029
Avg	.8386	.7597	.7607	.7250	.9064	.7559	.7366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274057 / 33/11 KV TUNGAT

Feeder No / Name : 205 / 11 KV TUNGAT GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4115	.4115	.3772	.4115	.3772	.4115
2	.3772	.4287	.3944			.3429	.3944
3	.3944	.4458	.3944			.4801	.3944
4	.4287	.463	.4115			.5144	.4458
5	.5658	.4973	.463			.583	.5487
6	.6687	.6344	.6516		.6516	.6344	.6859
7				.5316			
9	.4458	.4115	.4024	.4801	.4973	.4801	.4458
10		.2915	.3772		.4115	.4115	.4115
11	.3944	.3944	.3258		.3772	.3944	.3429
12	.3944	.2743	.3258		.0343	.4287	.3429
13	.3258	.3258	.3429	.3772	.3258	.4115	
14	.2915	.3086	.3258		.2915	.3429	
15	.2743	.3086	.2915		.2743	.3601	
16	.2743	.3086	.2572	.3258	.2572	.3772	.3601
17	.3258	.3258	.3258	.3086	.3734	.3601	.3772
18	.3429	.3944			.3601	.3688	.4115
19	.583	.5316			.5316	.4973	.6173
20	.5658	.5658			.5658	.583	.6859
21	.5487	.5316			.5144	.5316	.6001
22	.4973	.4801		.4801	.4801	.4694	.5316
23	.463	.4458	.4458	.4287	.463	.4801	.4458
24	.4115	.4287	.4115	.3944	.3944	.4287	.4287
Max	.6687	.6344	.6516	.5316	.6516	.6344	.6859
Min	.2743	.2743	.2572	.3086	.0343	.3429	.3429
Avg	.4270	.4185	.3858	.4115	.4008	.4481	.4675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 201 / 11 KV KANHAPURI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5987	2.3777	2.6063	2.652	2.4863		
2	2.6322	2.3777	2.692	2.7349	2.4863		
3	2.5316	2.4387	2.7949	2.6023	2.5692		
4	2.6322	2.5453	2.8635	2.7349	2.5692		
5	2.5987	2.5758	3.0007	2.8178	2.6825		
6	2.6993	2.6063	3.0521	2.9007	2.652	2.7435	.1715
7	3.0178	2.774	2.6825	2.967	2.6686	2.7606	.1715
8	3.1352	2.6978	3.035	3.0664	2.4697	2.5549	.1372
9	2.9843	2.774	2.7282	.1457	.1006	.1029	.1372
10	.12	.0457		.116	.1006	.1029	.1372
11	.1543	.0686		.0829			
12	.1219	.0857		.0663			
13	.1067			.0663			
16	.1067			.0829			
17	.1219			.1134			
18	.1219			.116			2.8178
19	.1981			.1326			2.7018
20	.1981	.1677	.1658	.2155			2.652
21	.1829	.1715	.1989	.1823			2.7349
22	.1981	.1372	.1658	.1658			2.7681
23	.1677	.1067	.2155	.1658	.1715	.1715	2.6686
24	2.5316	2.2862	2.2405	.1658	.1658	.1715	.1715
Max	3.1352	2.774	3.0521	3.0664	2.6825	2.7606	2.8178
Min	.1067	.0457	.1658	.0663	.1006	.1029	.1372
Avg	1.3255	1.5433	2.0316	1.1042	1.7602	1.2297	1.4391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 202 / 11 KV KAROLE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.3916	.9717	1.286	1.4289		
2	1.4089	1.2651	.9831	1.4706	1.1574		
3	1.439	.9831	.9717	1.4969	1.1574		
4	1.5384	1.1603	1.3413	1.5384	1.2346		
5	1.4918	1.0288	1.5432	1.4918	1.2346		
6	1.4043	1.6632	1.5947	1.5971	1.2346	1.3717	.1372
7	1.4449	1.2955	1.6632	1.4148	1.2963	1.4403	.1715
8	1.4718	1.1546	1.6118	1.6975	1.3426	1.4918	.1715
9	1.5051	1.1203	1.5604	.112	.0732	.1029	.1715
10	.0667	.0457		.1326	.0732	.1029	.1715
11	.0667	.0457		.096			
12	.0533	.0457		.096			
13	.08			.1017			
16	.0762			.0848			
17	.0762			.0947			
18	.1524			.1082			2.0567
19	.12			.1353			2.0222
20	.1067	.1067	.1457	.1353			2.0178
21	.1219	.0762	.116	.1353			1.8564
22	.1543	.0686	.1423	.1353			1.8056
23	.1219	.12	.1372	.1353	.1715	.1715	2.5101
24	1.3847	1.3413	.9831	.1219	.1353	.1715	.1715
Max	1.5384	1.6632	1.6632	1.6975	1.4289	1.4918	2.5101
Min	.0533	.0457	.116	.0848	.0732	.1029	.1372
Avg	.7140	.7596	.9832	.6190	.8783	.6932	1.1053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 203 / 11 KV UMBRE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18
HR	Load (MW)	Load (MW)
1	.0724	.0686
2	.0724	.0686
3	.0724	.0686
4	.0724	
5	.0724	.0686
6	.0724	.0686
7	.0724	.0686
8	.0724	.0686
9	.0724	.0686
10	.0724	1.0288
11	.8573	1.0288
12	1.5432	1.5432
13	1.6118	1.6118
16	1.5432	
17	1.5775	
18	1.6118	
19	.0686	
20	.0686	
21	.0857	
22	.0857	
23	.0686	
24	.0724	.0686
Max	1.6118	1.6118
Min	.0686	.0686
Avg	.4508	.4485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 204 / 11 KV UMBRE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4458	.4458	.4755	.439		
2	.4755	.4801	.4458	.4298	.439		
3	.5121	.4801	.4115	.4755	.5121		
4	.6036	.5144	.4458	.5281	.5121		
5	.6036	.5487	.3772	.5658	.5487		
9	.439	.4115	.3772	.3658	.3142	.2915	.3086
10	.4115	.3086	.3582	.3326	.3429	.3429	.3429
11	.3429	.3086	.2804	.3326			
12	.2401	.2401	.2058	.3696			
13	.2743	.1715	.2103	.3696			
14	.2401	.2058	.2058	.3326			
15	.2401	.1715	.1791	.3696			
16	.2058	.1715	.2195	.2218			
17	.2401	.3086	.2926	.2926			
18	.3772	.4115	.3326	.4066			.4115
19	.4801	.583	.439	.4755			.5121
20	.5487	.5487	.4805	.5121			.5658
21	.5144	.4801	.4904	.5121			.5121
22	.4801	.3772	.5175	.4755			.4805
23	.4458	.3772	.5175	.4755	.4458	.4458	.4115
24	.4298	.4115	.3429	.5175	.4755	.4458	.4458
Max	.6036	.583	.5175	.5658	.5487	.4458	.5658
Min	.2058	.1715	.1791	.2218	.3142	.2915	.3086
Avg	.4064	.3789	.3607	.4208	.4477	.3815	.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 205 / 11KV Kanal Fata Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.3658	.381	.333	.2782		
2	.3366	.3658	.3658	.2623	.2503		
3	.2883	.3506	.3506	.2372	.2225		
4	.3121	.3353	.3963	.2753	.2225		
5	.3439	.3658	.2743	.2315	.2225		
6	.3239	.3506	.2382	.2753	.2225	.2229	3.0864
7	.2591	.3353		.3149	.1808	.2229	3.2579
8	.2688	.3048		.2572	.1808	3.2579	3.4294
9	.2622	.3201		3.5437	3.2217	3.2579	.2572
10	.2134	.3506		3.5113	.1372	3.2579	.2572
11	2.1795	2.6978	1.7652	3.5294			
12	3.1207	2.8959	3.7037	3.5475			
13	2.8197	2.9416	3.6008	3.2156			
16	3.2065	2.9416	3.6523	3.5475			
17	3.2579	3.275	3.2874	.3292			
18	3.0864	2.8654	3.1659	.3292			.3511
19	.3772	.381	.3429	.3658			.3856
20	.3658	.3658	.3856	.3544			.3601
21	.3506	.381	.2818	.3658			.333
22	.3944	.3963	.3077	.3658			.3077
23	.3658	.3658	.3978	.4024	.3772	.3772	.2572
24	.2572	.3658	.3506	.4287	.3814	.3772	.3772
Max	3.2579	3.275	3.7037	3.5475	3.2217	3.2579	3.4294
Min	.2134	.3048	.2382	.2315	.1372	.2229	.2572
Avg	1.0313	1.0599	1.2916	1.1829	.4915	1.5677	1.055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 206 / 11 KV SANGAVI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.1372	.1372	.1296	.1296		
2	.1781		.1715	.1781	.1296		
3	.1296	.1372	.1886	.1457	.1296		
4	.1619	.1524	.1886	.1296	.1619		
5	.1943	.1334	.1715	.1619	.1619		
6	.1781	.1677	.2058	.1457	.1619	.1715	1.1145
7	.1619	.1829		.1296	.1619	.1715	1.2003
8	.1781	.1677		.1296	.1619	.1715	1.2346
9	.1619	.1524		1.4575	1.3279	1.406	.1715
10	.1372	.1677		1.3603	1.4575	1.4575	.1715
11	.9145	.8535	.7935	1.4575			
12	1.326	1.2193	1.3117	1.4575			
13	1.3717	1.2651	1.2146	1.3441			
15			1.2146				
16	1.0669	1.3565	1.5223	1.4575			
17	1.1431	1.3717	1.4575	.081			
18	1.1431	1.3413	1.5223	.081			.0972
19	.1219	.2286	.1781	.081			.1457
20	.1372	.1067	.1457	.081			.1296
21	.1219	.1372	.1781	.0972			.081
22	.1524	.1524	.1457	.0972			.0972
23	.1372	.1067	.1457	.0972	.1029		.0972
24	.1134	.1219	.0914	.1457	.0972	.1029	.1029
Max	1.3717	1.3717	1.5223	1.4575	1.4575	1.4575	1.2346
Min	.1134	.1067	.0914	.081	.0972	.1029	.081
Avg	.4262	.4600	.5781	.4748	.3487	.5802	.3869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 207 / 11 KV JALOLI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1715	.2229	.1629	.1991		
2	.2353	.1715	.2058	.181	.1991		
3	.2715	.1677	.2229	.1629	.181		
4	.3077	.2229	.2572	.2172	.181		
5	.2715	.1829	.2401	.1991	.2172		
6	.3077	.2915	.3086	.181	.2172	.2058	.0343
7	.2353	.2058		.2534		.2058	.0343
8	.2172	.2572		.2534	.1448	.1886	.0343
9	.181	.2058		.1991	.2172	.2058	
10	.1372	.2058		.1629	.2172	.2058	
11	2.4006	.0514	1.6289	.1267			
12	3.0007	2.7435	2.9321	.1267			
13	2.8635	3.0007	2.8959	.1267			
14				.1267			
16	2.7092	2.7949	3.2579	.1086			
17	2.7435	2.9492	3.1855	3.2579			
18	2.6578	2.8978	3.1493	3.3846			.1326
19	.1715	.3944	.181	3.4389			.2353
20	.1886	.2229	.2353	3.2579			.2896
21	.2229	.2058	.1991	2.7692			.2353
22	.2058	.1886	.2172	2.7149			.2172
23	.1886	.2058	.2172	2.6244	2.4863	.1715	.1991
24	.181	.1715	.1886	.2172	2.6244	2.4863	.1715
Max	3.0007	3.0007	3.2579	3.4389	2.6244	2.4863	.2896
Min	.1372	.0514	.181	.1086	.1448	.1715	.0343
Avg	.9044	.8141	1.0970	1.0545	.6259	.5242	.1584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 208 / 11 KV KALANANI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0305	.0343				
2	.0324	.0343	.0343				
3	.0309	.0343	.0343				
4	.0486	.0343	.0343				
5	.0305	.0343	.0514				
6	.0305		.0457				
7	.0293		.0514				
8	.044		.0457				
9	.0301		.0343				.0514
10							.0514
17				.0446			
18				.0446			
19				.0446			
20				.0446			
21				.0446			
22				.0446			
23				.0446	.0514	.0514	
24	.0347	.0305	.0343			.0514	.0514
Max	.0497	.0343	.0514	.0446	.0514	.0514	.0514
Min	.0293	.0305	.0343	.0446	.0514	.0514	.0514
Avg	.0361	.0330	.04	.0446	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274058 / 33/11 KV UMBRE

Feeder No / Name : 209 / 11 KV SUTAR MALA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	3.3913	3.3913	3.2007	3.6199		
2	2.8959	2.7435	3.3913	3.3532	3.6199		
3	3.0864	2.7435	3.4294	3.2388	3.6199		
4	3.1626	2.8959	3.5056	3.6199	3.7151		
5	3.2769	3.8104	3.5818	3.8104	3.8104		
6	3.4294	3.8104	3.5437	4.1914	3.8104	3.4294	
7	3.5437	3.6199		.381	3.8104	3.2579	.1715
8	3.6199	3.6961	3.8104	.3048	3.6199	3.2579	.1715
9	3.6199		3.8104	.1905	.1143	.1029	.1372
10	.1143	.1524			.0953	.0857	.1372
11	.1143	.1905		.1143			
12	.1143	.1905		.0953			
13	.1143			.0953			
16	.1143			.1334			
17	.1524			.1334			
18	.2667			.1524			
19	.3048			.1715			4.0009
20	.3048	.2286	.2286	.2286			4.0009
21	.3048	.2286	.1524	.2286			3.8104
22	.3048	.2667	.1905	.1905			3.6199
23	.3048	.2667	.1905	.1905	.1715	.1715	3.6961
24	2.934	3.2388	3.2388	.0762	.1905	.1715	.1715
Max	3.6199	3.8104	3.8104	4.1914	3.8104	3.4294	4.0009
Min	.1143	.1524	.1524	.0762	.0953	.0857	.1372
Avg	1.5969	1.9671	2.4973	1.1477	2.5165	1.4967	1.9917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 201 / 11 KV TARAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1715	.1715	.884
2					.1715	.1715	.9145
3					.1905	.1715	.9145
4					.1905	.1905	.9907
5					.2286	.2286	1.1431
6					.2667	.2667	1.5242
7					.2858	.2858	1.7375
8					.2286	.2286	1.9509
9					.1905	.1905	.1905
10					.1524	.0953	.1905
11					1.2955	1.2498	.0572
12					1.5851	1.6613	.1905
13					1.6156	1.6156	
14					1.5123	1.387	
15					1.4969	1.5242	
16					1.5123	1.3565	
17					1.4529	1.448	.1905
18					1.3123	1.2498	.1524
19						.1905	.1905
20					.1905	.1905	.2477
21					.1905	.1905	.2286
22					.1905	.1715	.2286
23					.1715	.1715	.2286
24	.1334	.1334	.1143	.1905	.1715	.1715	.1524
Max	.1334	.1334	.1143	.1905	1.6156	1.6613	1.9509
Min	.1334	.1334	.1143	.1905	.1524	.0953	.0572
Avg	.1334	.1334	.1143	.1905	.6423	.6074	.6154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 202 / 11 KV KHARSOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.0957	1.4529	.1905
2					1.7071	1.4842	.1905
3					1.7528	1.5339	.1905
4					1.7528	1.5813	.1905
5					1.9052	1.5971	.2858
6					2.1338	1.6288	.381
7					2.21	1.6975	.5716
8					2.3624	1.7071	.5716
9					.2858	.2858	.5716
10					.5716	.2858	
11					.7621	.1905	2.3434
12					.7621		2.5149
17						.1905	2.6673
18					.8573	.2858	2.9721
19						.2858	.1905
20					.8573	.3048	.7621
21					.7811	.2858	.7621
22					.724	.2858	.7621
23					.6478		.7621
24	.2858	.381	.2858	.6668	.381	.5716	.1905
Max	.2858	.381	.2858	.6668	2.3624	1.7071	2.9721
Min	.2858	.381	.2858	.6668	.2858	.1905	.1905
Avg	.2858	.381	.2858	.6668	1.2528	.8697	.8985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 203 / 11 KV MAGARWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1543	.1543	.1905	.1524	.1524	1.2955
2	.1334	.1543	.1562	.1905	.1524	.1524	1.3413
3	.1334	.1543	.1543	.1905	.1524	.1524	1.3413
4	.1715	.1543	.1543	.1905	.1715	.1524	1.3717
5	.1905	.1543	.1852	.1905	.1715	.1715	1.5242
6	.1905	.1852	.2343	.1905	.1905	.1715	1.6766
7	.1905	.2006	.1562	.1905	.2096	.1715	1.9052
8	.1905	.2105	.1905	.1905	.1905	.1562	2.0576
9	.1905	.1905		.1905	.1334	.1134	.1905
10	.08	.1905	.1524	.1905	.1143	.0829	
11	1.8519	1.9052	1.9052	1.6766	1.7528	1.7284	.0762
12	2.4691	2.2862	2.21	2.1643	2.21	2.1605	
13	2.4691	2.3457	2.0576	2.1338	2.077	1.6975	
14	2.4383	2.0576	2.1033	2.1338	2.0833	1.9052	
15	2.1914	2.0119	2.1338	2.0576	1.9814	2.0119	
16	2.21	2.0576	2.0873	2.0576	2.1033	2.0119	
17	2.2068	2.0062	2.1559	2.0576	2.2377	1.9814	.1905
18	2.284	2.037	2.0778	2.0576	2.0062	1.9814	.1905
19	.0762	.0772	.1905	.1715		.1524	.1524
20	.1524	.1543	.1905	.1905	.1905	.1524	.1524
21	.1524	.1543	.1905	.1905	.1905	.1524	.1524
22	.1524	.1543	.1905		.1905	.1524	.1143
23	.1543	.1543	.1905		.1715	.1334	.1143
24	.1905	.1524	.1543	.1905	.1715	.1715	.1143
Max	2.4691	2.3457	2.21	2.1643	2.2377	2.1605	2.0576
Min	.0762	.0772	.1524	.1715	.1143	.0829	.0762
Avg	.8608	.8043	.8424	.8630	.8263	.7446	.7756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 204 / Tarapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.3045	.3045	.3189	.2743	.3189	.2743
2	.3544	.3224	.3366	.3189	.2743	.3155	
3	.3544	.3582	.3721	.3544	.2896	.333	.2591
4	.3721	.4119	.4119	.3898	.3353	.3856	.3048
5	.443	.4477	.443	.4607	.442	.4908	.4115
6	.4961	.5014	.4961	.5316	.4725	.5316	.4877
7	.5316	.4477	.4656	.5316	.4115	.4908	.4268
8	.4961		.4119	.5014	.3353	.443	.3658
9	.443	.3403	.3582	.4477	.3582	.3898	.3048
10	.2865	.3045	.3224	.394	.3224	.3544	
11	.2686	.2686	.2865	.3045	.2865	.3189	.2658
12	.2686	.2686	.2686	.2865	.2686		.2686
13	.2686	.2328		.2686	.2686	.2658	
14	.2686	.2686	.2865	.2134	.2686	.3544	
15	.2686	.2865	.3045	.2286	.2686	.3544	
16	.2686	.2865	.3189	.2286	.3045	.3048	
17	.3045	.3045	.3155	.2591	.3012	.2896	.3045
18	.3403	.3224	.3544	.3048	.3544	.2591	.3544
19	.4298	.4298	.443	.442		.381	.443
20	.5014	.5014	.4908	.4877	.567	.4572	.4961
21	.4298	.4298	.443	.4268	.4961	.381	.4252
22	.3403	.3761	.3856		.443	.3353	.3582
23	.3045	.3012	.3506		.3721	.3048	.3224
24	.3366	.3045	.3045	.3506	.3048	.3544	.2743
Max	.5316	.5014	.4961	.5316	.567	.5316	.4961
Min	.2686	.2328	.2686	.2134	.2686	.2591	.2591
Avg	.3630	.3487	.3685	.3659	.3487	.3658	.3526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 206 / 11 KV SUSTE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0381	.0191	.1943
2	.0191	.0191	.0191	.0191	.0191	.0191	.2105
3	.0191		.0191	.0191	.0191	.0191	.2105
4	.0381	.0191	.0191	.0381	.0191	.0191	.2267
5	.0381	.0381	.0191	.0381	.0381	.0381	.2591
6	.0381	.0381	.0381	.0381	.0381	.0381	.2591
7	.0381	.0381	.0381	.0381	.0381	.0381	.2591
8	.0191	.0381	.0381	.0381	.0381	.0381	.3201
9	.0191	.0191	.0381	.0381	.0381	.0381	.0381
10	.0191	.0191	.0381	.0381	.0381	.0381	
11	.2743	.2656	.2343	.2812	.2343	.2743	.0191
12	.3749	.3281	.4001	.3593	.3281	.3048	.0191
13	.3241	.3125	.2812	.3125	.3281	.2187	
14	.3241	.3125	.3125	.3048	.3163	.2439	
15	.2932	.3125	.3437	.3048	.3163	.3048	
16	.2896	.3125	.3437	.3048	.3321	.3563	
17	.3048	.3086	.2315	.2591	.3593	.3239	.0191
18	.3048	.3086	.2968	.2439	.2778	.3077	.0191
19	.0191	.0191	.0381	.0381		.0381	.0381
20	.0191	.0191	.0381	.0191	.0191	.0381	.0381
21	.0191	.0381	.0381	.0381	.0381	.0381	.0381
22	.0191	.0191	.0191		.0381	.0381	.0381
23		.0191	.0191		.0191	.0381	.0381
24	.0191	.0191	.0191	.0191	.0381	.0191	.0381
Max	.3749	.3281	.4001	.3593	.3593	.3563	.3201
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1240	.1236	.1209	.1277	.1291	.1187	.1201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274104 / 33/11 KV TARAPUR

Feeder No / Name : 207 / 11 KV GANESH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0772	.0772	.0953	.0953	.0953	.6097
2	.0953	.1543	.0772	.0953	.0953	.0953	.6097
3	.0953	.0772	.0772	.0953	.0953	.0953	.6097
4	.0953	.0772	.0772	.0953	.0953	.0953	.6097
5	.0953	.0772	.0772	.0953	.1143	.1143	.6401
6	.0953	.0937	.0781	.0953	.1143	.1143	.6859
7	.0953	.0772	.125	.0953	.1143	.1143	.7316
8	.0953	.128	.1905	.0953	.0953	.0772	.7621
9	.0953	.1905	.1524	.0953	.0762	.0617	.1143
10	.0762	.1905	.1143	.0953	.0953	.0463	
11	.6173	.6481	.7407	.7407	.6944	.6401	.0309
12	.8951	.8488	.7716	.8488	.7716	.6401	.0953
13	.8592		.7407	.7716	.8488	.6944	
14	.8488	.8488	.6944	.7621	.7716	.6859	
15	.8488	.8488	.6944	.6859		.884	
16	.884	.7716	.6718	.6859	.7716	.884	
17	.884	.8488	.7499	.7621	.6944	.7926	.1143
18	.9259	.8951	.7499	.7316	.6173	.7621	.1143
19	.0463	.0772	.0953	.0953		.0953	.0953
20	.0781	.0772	.0953	.1143	.1143	.1143	.0953
21	.0781	.0772	.0953	.1143	.1143	.0953	.0953
22	.0772	.0772	.0953		.1143	.0953	.0953
23	.0772	.0772	.0953		.0953	.0953	.0953
24	.0953	.0762	.0772	.0953	.0953	.0953	.0953
Max	.9259	.8951	.7716	.8488	.8488	.884	.7621
Min	.0463	.0762	.0772	.0953	.0762	.0463	.0309
Avg	.3396	.3181	.3089	.3346	.3043	.3118	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.8716	.8135	.8688	.8402	.8977	1.0631
2	.8535	.8716	.8135	.8688	.8402	.8977	1.0631
3	.9069	.9846	.8802	.9288	.8802	1.0002	1.0974
4	.9869	1.0715	.9602	1.0145	.9602	1.1439	1.166
5	1.0669	1.1873	1.0936	1.1294	1.0802	1.2887	1.1888
6	.9202	.9682	.8402	1.2452	1.1869	.9536	1.3413
7	.7735		.8135	.8977	1.1203	.9095	1.6004
8	.7868		.6401	.7922		.6308	1.4022
9	.6268	.6135	.7468	.7202		.7202	1.2803
10	.6241	.5201	.5647	.5601		.4687	.5144
11	1.406	1.4575	1.3927	1.3889	1.3272	1.0517	.4572
12	1.7661	1.8519	1.643	1.5432	1.5912	1.387	.4252
13	1.7147	1.8347	1.7661	1.7318	1.6575	1.4022	.4329
14	.3567	1.7318	1.7318	1.7318	1.5729	1.4175	
15	.3715	1.7147	1.6632	1.5546	1.4746	1.3717	
16	1.7318	1.7318	1.5261	1.5546	1.4582	1.3108	
17	1.8861	1.8347	1.5947	1.6766	1.6575	1.1736	
18	1.7833	1.5851	1.7436	1.5851	1.6078	1.387	.7371
19	.8215	.9202	.8431	.9069	.9457	.8669	.9574
20	1.086	1.0136	1.1145	1.0269	1.1439	.9869	1.2029
21	1.0145	.9602	1.0288	.8802	1.028	.9335	.9717
22	.9701	.8269	1.0136	.8402	.9991	.8669	.9412
23	.9267		.9556	.8535	.9267	.8402	.8977
24	.8535	.8859	.8135	.8833	.8402	.8977	1.0631
Max	1.8861	1.8519	1.7661	1.7318	1.6575	1.4175	1.6004
Min	.3567	.5201	.5647	.5601	.8402	.4687	.4252
Avg	1.0453	1.2113	1.1249	1.1326	1.1971	1.0335	.9902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 202 / 11 KV ADHIV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.2018	1.3108	1.2498	1.1888	1.2643	.4973
2	1.1584	1.2483	1.3108	1.3123	1.1888	1.2803	.4973
3	1.2193	1.3123	1.3717	1.3763	1.2498	1.3117	.5487
4	1.2803	1.4255	1.4937	1.3927	1.3413	1.4419	.6173
5	1.3565	1.5581	1.5699	1.4586	1.4937	1.5581	.7202
6	1.5394	1.4752	1.6766	1.576	1.6918	1.2963	.8402
7	1.7528		1.9662	1.873	2.1033	1.8679	.7545
8	2.0576		1.9204	2.2085	2.0119	1.8842	.6173
9	1.9357	1.5242	1.8595	2.0271	1.9204	1.8747	.4973
10	.2743	.3086	.3258	.3944	.3258	.3086	
11	.2401	.2915	.2743	.3429		.2572	1.7004
12	.2915	.2572	.2572	.2572	.2835	.2915	1.9109
13	.3086	.2743	.2915	.2572	.1753	.3086	2.0481
14	.2804	.2572	.3086	.2572		.3258	
15	.1717	.3429	.3258	.2915	.3189	.3429	
16	.3258	.3601	.3086	.3772	.2804	.3601	
17				.3772		.2915	
18		.9259		.4287	.4656	.3772	2.0719
19	.4961	.6859	.6447	.6687	.591	.5658	.567
20	.7888	.7202	.7796	.703	.7975	.7202	.8589
21	.7362	.6516	.6836	.6516	.7186	.6687	.7712
22	.6485	.5487	.6485	.583	.6135	.583	.6588
23	.5721	.4973	.5316	.4801	.5258	.5144	.5375
24	1.1584	1.186	1.3108	1.2498	1.1888	1.2018	.4973
Max	2.0576	1.5581	1.9662	2.2085	2.1033	1.8842	2.0719
Min	.1717	.2572	.2572	.2572	.1753	.2572	.4973
Avg	.8978	.8120	.9623	.9081	.9750	.8707	.9059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 203 / 11 KV AJANSOND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.8684
2	.0191	.0191	.0191	.0191	.0191	.0191	.8684
3	.0191	.0191	.0191	.0191	.0191	.0191	.9614
4	.0191	.0191	.0191	.0191	.0191	.0191	1.0277
5	.0191	.0191	.0191	.0191	.0191	.0191	1.2071
6	.0191	.0191	.0191	.0191	.0191	.0191	1.291
7	.0191		.0191	.0191	.0191	.0191	1.7604
8	.0191		.0191	.0191	.0191	.0191	1.757
9	.0191	.0191	.0191	.0191	.0191	.0191	1.6385
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	1.4419	1.3413	1.4582	1.5851	1.5402	1.2651	.0191
12	2.0809	1.5546	1.8023	1.5851	2.0222	1.5546	.0191
13	2.1464	1.6461	1.9281	1.5699	2.0388		.0191
14	.0191	.5182	1.8023	1.6461	1.8515	1.5699	.0191
15	.0191	1.2193	1.7404	1.768	1.6804	1.4937	
16	2.2447	1.5394	1.7436	1.8442	1.3441	1.4175	
17	1.917	1.5699	1.7101	1.7528	1.5708	1.3717	
18	1.9662	1.4327	1.7901	1.326	1.6842	1.5394	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.8684
Max	2.2447	1.6461	1.9281	1.8442	2.0388	1.5699	1.7604
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5059	.5040	.5950	.5576	.5849	.4573	.5933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274119 / 33/11 KV DEGAON

Feeder No / Name : 204 / 11 KV S.Dumala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6201	.5658	.5847	.583	.6089	.6516
2	.6516	.6201	.5658	.6024	.583	.6089	.6516
3	.6516	.631	.583	.6024	.6173	.6379	.6859
4	.6516	.6415	.6173	.6201	.6516	.6733	.7202
5	.6859	.6588	.6516	.6556	.703	.7011	.823
6	.7716	.6859	.7202	.7011	.7888	.7537	.8916
7	.8916		.823	.8322	.8916	.8413	.8059
8	.8916		.7888	.7522	.9088	.815	.6344
9	.8573	.823	.7545	.6516	.7716	.823	.583
10	.5258	.3772	.394	.4287	.439	.3772	.567
11	.4119	.3086	.394	.4115	.4887	.4115	.7343
12	.4252	.3086	.4119	.3772	.5373		1.0277
13	.3681	.3429	.394	.4458	.5194	.4458	1.134
14	.3582	.3429	.3856	.4458	.5014	.4801	1.1283
15	.3761	.3772	.3856	.4458	.4835	.4801	1.0924
16	.4298	.4115	.4115	.4458	.3982	.4801	1.0745
17	.4207	.3467	.5083	.4458	.4656	.4973	1.0498
18	.4525	.4115	.5083	.4458	.3658	.5487	1.0387
19	.6268	.7545	.7343	.703	.8059	.7888	.6878
20	.7712	.7202	.8505	.7545	.8682	.8573	.9313
21	.7087	.6516	.7701	.6516	.8238	.823	.8417
22	.6878	.5487	.724	.583	.7602	.7545	.7602
23	.5487	.4973	.6219	.5316	.695	.6687	.6878
24	.6516	.6024	.5658	.5847	.583	.591	.6516
Max	.8916	.823	.8505	.8322	.9088	.8573	1.134
Min	.3582	.3086	.3856	.3772	.3658	.3772	.567
Avg	.6028	.5310	.5887	.5710	.6347	.6377	.8273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 201 / 11 KV PEHE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1888	1.2003	.884	1.3717	1.3203	.1543
2	1.1145	1.1888	1.2003	.9145	1.3717	1.3717	.1715
3	1.2003	1.2193	1.2689	.9145	1.3717	1.4403	.1715
4	1.2689	1.2193	1.3032	.9907	1.6118	1.4575	.1886
5	1.4403	1.2651	1.3717	.9907	1.7147	1.6632	.2058
6	1.5432	1.3413	1.4232	1.2193	1.9719	1.9033	.2058
7	1.6461	1.4022	1.5432	1.2651	2.0576	2.1434	.2058
8	1.7147	1.2651	1.6804	1.4022	2.332	2.2977	.1715
9	1.2346	1.4403	1.387	1.387	2.1605	1.8176	1.829
10	.0762	.0514	.0762	.0762	.1715	.1372	1.7985
11	.1067	.0514	.0457		.1029	.12	
12	.0457	.0514	.0457	.1219	.12	.1372	
13	.0305	.0343	.0457	.1219	.1372	.1029	
16	.0457	.0686	.061	.1219	.12	.1543	
17	.0762	.0686	.061	.0914	.12	.1543	
18	.0914	.0686	.0914	.0762		.1715	
19	.0914	.1372	.1219	.1677	.1372	.2229	.1524
20	.0914	.1543	.1067	.1524	.1372	.2572	.1524
21	.0914	.1543	.1067	.1524	.12	.2401	.1829
22	.0762	.1372	.0914	.1524	.12	.1715	.1829
23	.0762	.1029	.0914	.1372	.1372	.1715	.1524
24	1.0288	1.1431	1.0974	.8535	1.2517	1.2517	.1698
Max	1.7147	1.4403	1.6804	1.4022	2.332	2.2977	1.829
Min	.0305	.0343	.0457	.0762	.1029	.1029	.1524
Avg	.6418	.6252	.6555	.5806	.8875	.8503	.3809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 202 / 11 KV SUGAON BHOSE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3663	2.4539	2.332	1.9052	2.2291	2.1948	.3258
2	2.4348	2.5149	2.4006	2.0119	2.4863	2.2291	.3429
3	2.572	2.5606	2.4006	2.0576	2.572	2.2977	.3429
4	2.7435	2.6368	2.4348	2.1338	2.6749	2.4006	.4115
5	2.8292	2.7587	2.572	2.1643	2.7606	2.5377	.463
6	2.8978	2.8349	2.7092	2.21	2.915	2.7263	.4973
7	2.9492	2.9264	3.3951	2.6216	3.0521	3.035	.4458
8	2.915	2.8654	3.2236	2.7435	2.8121	3.0178	.3429
9	1.8861	3.155	2.5149	2.5301	2.7606	2.5892	2.4691
10	.1677	.1715	.1677	.2134	.1886	.1715	2.6063
11	.1067	.1543		.1677	.1886	.1372	2.6063
12	.1067	.1372			.1715		2.6063
13	.1524	.1372	.1524		.1715		
14	.1524						2.6063
15	.1524						
16	.1677			.1829	.1543	.2058	
17	.1829			.2743		.2058	
18	.1981		.1524			.2401	
19	.3506	.1372	.3506	.3658	.3772	.2858	.2743
20	.3048		.3353	.3353	.3601	.4458	.3048
21	.2896	.4115	.3353	.3048	.3601	.4115	.3353
22	.2743	.3429	.3048	.2896	.3429	.3429	.3048
23	.2743	.3086	.3048	.2743	.3086	.3086	.2743
24	2.2291	2.3167	2.2634	1.9052	2.0919	2.0576	.2915
Max	2.9492	3.155	3.3951	2.7435	3.0521	3.035	2.6063
Min	.1067	.1372	.1524	.1677	.1543	.1372	.2743
Avg	1.1960	1.6013	1.5750	1.2995	1.4489	1.3920	.9395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 203 / 11 KV BHOSE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.381	.3944	.3658	.381	.4801	.4287
2	.5144	.381	.4115	.3963	.381	.5144	.4287
3	.5487	.381	.463	.3963	.381	.5487	.4458
4	.5487	.3963	.5144	.4268	.3963	.583	.5144
5	.583	.4572	.6001	.5335	.4725	.6173	.583
6	.583	.5792	.6859	.6097	.5792	.6344	.6859
7	.583	.5487	.7202	.5792	.5792	.6687	.7202
8	.4973	.4572	.5658	.5182	.4877	.5316	.5316
9	.4287	.4801	.4268	.4268	.3963	.4287	.4115
10	.3353	.4115	.3048	.381	.3601	.3429	.3658
11	.2743	.3429	.3048	.3048	.3429	.3772	.2743
12	.2896	.2915	.2439	.2896	.3601	.3258	.2439
13	.2743	.2401	.3048	.2591	.2743	.3258	.2286
14	.2896	.2572	.2743	.2439	.2743	.3086	.2134
15	.3201	.2915	.3201	.2286	.2915	.3086	.2439
16	.2896	.3258	.2743	.2896	.2743	.2915	.2743
17	.3201	.3429	.2743	.3506	.3772	.3429	.3353
18	.3658	.3601	.4268	.3963		.4115	.3658
19	.5639	.5487	.6097	.6401	.6344	.583	.5487
20	.5182	.6001	.5639	.5487	.5658	.6516	.5487
21	.4572	.5144	.4877	.503	.5316	.5487	.5182
22	.4268	.463	.4268	.4572	.5144	.5144	.4572
23	.381	.4287	.3658	.4115	.4801	.4115	.3963
24	.4287	.3658	.3944	.3658	.381	.4287	.4115
Max	.583	.6001	.7202	.6401	.6344	.6687	.7202
Min	.2743	.2401	.2439	.2286	.2743	.2915	.2134
Avg	.4292	.4102	.4316	.4134	.4224	.4658	.4240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 204 / 11 KV Sol Patti Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2743	.3086	.1981	.3429	.4801	2.3491
2	.3258	.2743	.3258	.2286	.3429	.3601	2.4006
3	.3258	.2743	.3429	.2286	.3429	.3601	2.4006
4	.3429	.2896	.3429	.2743	.3601	.3944	2.4348
5	.3601	.2896	.4287	.3048	.4287	.3944	2.572
6	.3772	.3048	.4458	.3353	.463	.4115	2.6235
7	.3944	.3353	.4115	.3048	.4973	.4115	3.2236
8	.3772	.3048	.3601	.2743	.4458	.3772	.463
9	.2229		.2743		.3429	.2401	.3658
10	.1677	.2572	.1981	.2134	.2401	.2229	.3506
11	2.4387	1.7375	2.6216	2.8502	2.8807	3.0178	
12	.2134	3.738	3.2769	3.0026	3.3779	3.8237	
13	3.2769	3.6694	.6097		3.4979	3.858	
16	2.9874	3.6866	3.2007	3.1245	3.5494	3.7551	
17	2.9416	3.6694	3.2769	3.0483	3.6866	3.6008	
18	2.8959	3.4808	2.7435	2.9569		3.2407	
19	.381	.3601	.3658	.3658	.2572	.2058	.3201
20	.3353	.3772	.3048	.3353	.3086	.3429	.3201
21	.3201	.3429	.2439	.3201	.3772	.3258	.2896
22	.3048	.3429	.2286	.3201	.3601	.3258	.2743
23	.3048	.3258	.2286		.3601	.2915	.2743
24	.3086	.2743	.3086	.1981	.3429	.3429	2.2634
Max	3.2769	3.738	3.2769	3.1245	3.6866	3.858	3.2236
Min	.1677	.2572	.1981	.1981	.2401	.2058	.2743
Avg	.9051	1.1719	.9477	.9939	1.0860	1.2174	1.4328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274120 / 33/11 KV BHOSE

Feeder No / Name : 205 / 11 KV Nematwadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0914	.1029	.0914	.12	.12	1.3717
2	.1029	.0914	.12	.1067	.1372	.12	1.3717
3	.1029	.0914	.12	.1067	.1372	.12	1.4403
4	.12	.1219	.12	.1372	.1372	.12	1.5432
5	.12	.1219	.1372	.1677	.1543	.1372	1.5775
6	.1372	.1372	.1698	.1677	.1543	.1372	1.6975
7	.1372	.0914	.1543	.1677	.1715	.1543	1.8176
8	.1372	.061	.1372	.1219	.1543	.1543	1.8861
9	.1372	.0857	.0914	.0914	.0857	.12	.1067
10	.0914	.0857	.0762	.1524	.12	.1029	.1067
11	1.1431	1.3717	1.448	1.6766	1.3375	1.7147	.0914
12	1.829	2.2634	2.0729	1.6766	1.4232	2.0062	
13	1.9814	2.3148	2.1033	1.6918	1.9547	1.9719	
16	1.7833	2.3663	2.1338	1.6766	2.0748	1.9719	
17	1.8442	2.332	2.1033	1.829	2.2462	1.8861	
18	1.9814	2.2119	2.2558	1.8747		1.5261	
19		.1543	.2134	.1219	.1372	.1543	.1524
20	.0914	.1543	.1829	.1219	.1372	.1886	.1524
21	.0914	.1372	.1524	.1067	.1372	.1715	.1372
22	.0934	.1372	.0914	.1067	.1372	.1715	.1219
23	.0914	.12	.0914	.1067	.1372	.1372	.1219
24	.1029	.0914	.1029	.0914	.12	.12	1.286
Max	1.9814	2.3663	2.2558	1.8747	2.2462	2.0062	1.8861
Min	.0914	.061	.0762	.0914	.0857	.1029	.0914
Avg	.5820	.6652	.6446	.5632	.5340	.6048	.8813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 202 / 11 Kv AMBE CHINCHOLI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.7049	.7811	.7316	.6413	.7049	1.1904
2	.5716	.7049	.7621	.7316	.6097	.7049	1.1934
3	.5335	.7049	.7621	.7316	.6478	.7049	1.1961
4	.5525	.7049	.8002	.7133	.7049	.724	1.2431
5	.724	.724	.8573	.6984	.7621	.743	1.2452
6	.8192	.7621	.8573	.8059	.8954	.7621	1.326
7	.8764	.7049	.9717	.8764	.8954	.8002	1.4746
8	.8764	.7049	.9526	.7362	.9335	.8192	1.5238
9	.8954	.724	.8002	.6219	.7621	.8002	.4763
10	.8764	.7621	.7621	.5716	.9526	.6097	
11	1.5089	1.2193	1.7804	1.4175	1.7551	1.9433	
12	2.3137	1.9814	2.5434	1.9814	2.1548	1.7604	
13	2.3537	2.1186	2.6113	2.0424	2.3137	1.8842	
14		2.1338					
15	2.2939		2.3908	2.1948	2.3137	1.8515	
16	2.3137	2.0881	2.6452	2.1948	2.3205	1.8515	
17	2.2131	2.1338	2.5265	2.1338	2.2775	1.7924	
18	2.2131	2.2253	2.5774	1.9814	2.2939	1.7924	
19	.407	.6001	.7049	.4801	.547	.5281	.4763
20	.724	.9145	.823	.6001	.5716	.4954	.5716
21	.7811	.8954	.7362	.7468	.6668	.381	.4763
22	.7621	.8573	.7522	.6516	.6859	.3048	.3429
23	.6668	.8383	.7522	.6001	.7049	.2858	.3429
24	.6478	.7049	.8002	.7164	.6413	.7049	.2667
Max	2.3537	2.2253	2.6452	2.1948	2.3205	1.9433	1.5238
Min	.407	.6001	.7049	.4801	.547	.2858	.2667
Avg	1.1520	1.1266	1.3022	1.0852	1.1762	.9978	.8897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274139 / 33/ 11 Kv Shankargaon

Feeder No / Name : 203 / 11 Kv JACKWELL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7377	.9145	.6783	1.2193	.8886	.2286
2	.7316	.7377	1.0669	1.3735	1.5089	.9221	.0762
3	.7621	.7956	1.0974	1.4746	1.448	.9614	.0953
4	.8383	.9012	1.1431	1.5893	1.4937	.9831	.0953
5	.945	1.1401	1.1431	1.6549	1.5242	1.1142	.1143
6	1.0364	1.1469	1.1888	1.6712	1.6004	1.2929	.1132
7	1.2193	1.2929	1.2955	1.6712	1.6766	1.326	.1294
8	1.2498	1.3245	1.4175	1.5074	1.5242	1.3923	.096
9	.1334	.1067	.1143	.1334	.112		
10	.1524	.1524	.1143	.1334	.132		
11	.503	.3429	.3222	.2439	.2515	.2012	.5716
12	.503	.3048	.3561	.3391	.2984	.2321	.5792
13	.4973	.3658	.39	.3506	.3353		
14		.3658					
15	.4527	.3658	.3391	.2743	.3048	.2012	
16	.4694	.3658	.3391	.2743	.285	.218	
17	.431	.3506	.3561	.2743	.3052	.218	
18	.3978	.3353	.3391	.2743	.2915	.2204	
19	.1143	.1067	.1715	.1143	.1715	.1524	.1334
20	.1524	.1524	.1715	.1334	.1524	.1334	.1524
21	.1905	.1715	.1715	.1334	.1524	.1143	.1524
22	.1524	.1524	.1715	.1334	.1524	.1143	.1524
23	.1334	.1334	.1715	.1143	.1524	.1143	.1524
24	.1524	.1334	.1143	.1715	.1143	.1524	.1334
Max	1.2498	1.3245	1.4175	1.6712	1.6766	1.3923	.5792
Min	.1143	.1067	.1143	.1143	.112	.1143	.0762
Avg	.5176	.4993	.5613	.6399	.6611	.5476	.1860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 201 / 11 kv Nanure Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2378	.2378	.2195	.2378	.2195	.2195
2	.2743	.2378	.2378	.2195	.2561	.2195	.2195
3	.2926	.2561	.2012	.2195	.2378	.2195	.2561
4	.2926	.2561	.2195	.2561	.2926		.3292
5	.3292	.3292	.2561	.2926	.3292	.2561	.3841
6	.3841	.3292	.2926	.3292	.3658	.2926	.4024
7	.4207	.3841	.2926	.3292	.3292	.3292	.3475
8	.2926	.3658	.2926	.3658	.3292	.3292	.3292
9	.3109	.3292	.3292	.2926	.2743	.3292	.2561
10	.2561	.2561	.3292	.2926	.2378	.2926	.2012
11	.2195	.2561	.2012	.2195	.1829	.2012	
12	.2012	.2378	.2378	.1829	1.829	.1829	
13	.1646	.2195	.2012	.1646	.1646	.1829	
14	.1463	.2012	.1829	.1646	.1646	.1829	
15	.1646	.2561	.1646	.1829	.1463	.1646	
16	.1829	.2561	.2195	.1829	.1646	.1463	
17	.2195	.2926	.2378	.2195	.2195	.1829	
18	.2561	.3292	.2743	.2926	.2743	.2012	
19	.3475	.4024	.4207	.4024	.3841	.3841	.4024
20	.3841	.4024	.4024	.3841	.3841	.4024	.3841
21	.3658	.3658	.3658	.3658	.3658	.3658	.3841
22	.3292	.3292	.3292	.3292	.3292	.3292	.3292
23	.2561	.2561	.2561	.2926	.2926	.2926	.2926
24	.2561	.2378	.2378	.2195	.2561	.2561	.2195
Max	.4207	.4024	.4207	.4024	1.829	.4024	.4024
Min	.1463	.2012	.1646	.1646	.1463	.1463	.2012
Avg	.2751	.2927	.2675	.2675	.3353	.2592	.3098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 202 / 11 KV Pehe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.1718	.1492	.1475	.1989	.1802	2.6852
2	.1989	.1989	.1492	.1475	.1823	.1802	2.7349
3	.1989	.1989	.1492	.1475	.1989	.1802	2.7183
4	.1989	.2155	.1492	.1475	.1989	.1802	2.6852
5	.2155	.2155	.1492	.1475	.1989	.1802	2.8012
6	.2155	.2155	.1492	.1638	.2155	.1966	2.8509
7	.2155	.2155	.1492	.1802	.2155	.1966	2.8841
8	.2155	.1989	.1492	.1802	.2155	.1802	.0332
9	.1658	.1658	.1492	.1802	.1823	.1802	.0332
10	.1326	.1326	.1492	.1802	.116	.116	.0166
11	2.3537	1.9227	1.8896	2.0553	1.3927	2.5526	
12	2.4697	2.0885	2.3537	2.0056	1.7695	2.6355	
13	2.5029	2.42	2.3371	2.0056	1.7368	2.6852	
14	2.4531	2.4531	2.2542	1.9725	1.6057	2.6355	
15		2.4863					
16	2.6355	2.6189	2.2775	2.0719	2.2119	2.8841	
17	2.4697	2.4863	2.2775	1.9227	2.5888	2.9835	
18	2.42	2.3868	2.2775	1.873	2.7854	2.9835	
19	.1326	.1658	.1475	.116	.1638	.1492	.1492
20	.1658	.1823	.1966	.1823	.2294	.1823	.1492
21	.1823	.1823	.1802	.1989	.1966	.1989	.1492
22	.1658	.1823	.1802	.1989	.1966	.1823	.1492
23	.1658	.1658	.1802	.1823	.1802	.1658	.1492
24	.1989	.1658	.1823	.1802	.1989	.1802	2.6189
Max	2.6355	2.6189	2.3537	2.0719	2.7854	2.9835	2.8841
Min	.1326	.1326	.1475	.116	.116	.116	.0166
Avg	.8814	.9098	.7924	.7212	.7469	.9647	1.4255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274164 / 33/11 KV Nandure

Feeder No / Name : 203 / 11 KV Ave

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8976	2.2184	2.2297	2.2138	2.0399	2.2184	.1898
2	1.9134	2.2497	2.2455	2.2455	2.1348	2.234	.1898
3	1.8976	2.2809	2.2771	2.2771	2.1506	2.2184	.1739
4	1.9292	2.3434	2.2771	2.2771	2.119	2.1872	.1898
5	1.9292	2.359	2.3087	2.3087	2.1506	2.2497	.2056
6	2.1506	2.3278	2.3403	2.3403	2.198	2.3434	.1898
7	2.3562	2.3122	2.3403	2.3403	2.1822	2.3746	.1898
8	2.4827	2.2809	2.2771	2.3403	2.198	2.3903	2.484
9	2.3087	2.3278	2.2297	2.3087	2.1032	2.3903	2.4827
10	.1265	.1423	.1423	.1265	.1562	.0791	.1898
11	.0949	.1423	.0949	.1107	.1423	.0791	
12	.1107	.1423	.0949	.1107	.1406	.0949	
13	.0949	.1423	.0949	.1265	.1406	.1107	
14	.0949	.1423	.0949	.1423	.1406	.0937	
15		.1423					
16	.0791	.1581	.1107	.1107	.1406	.1107	
17	.0949	.1581	.1581	.1423	.1718	.125	
18	.125	.1898	.2056	.253	.1875	.1265	
19	.25	.2214	.2688	.3637	.3125	.2056	.1265
20	.2187	.2214	.253	.3321	.25	.2214	.1739
21	.2031	.1898		.2846	.25	.2031	.1898
22	.1562	.1898		.253	.25	.1898	.1898
23	.1562	.1739		.1581	.1562	.1898	.1898
24	1.8343	2.2028	2.2297	2.2455	1.945	1.9685	.1739
Max	2.4827	2.359	2.3403	2.3403	2.198	2.3903	2.484
Min	.0791	.1423	.0949	.1107	.1406	.0791	.1265
Avg	.9785	1.0525	1.2137	1.1048	1.0287	1.0611	.4705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 201 / 11 KV Shevate Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.2058	.2058	.12	.1524	.2229	.2229
2	.1067	.1829	.1886	.1029	.1524	.2229	.2058
3	.0914	.2058	.1715	.12	.1372	.2058	.1715
4	.0914	.2401	.1715	.12	.1219	.2401	.1543
5	.0762	.2058	.1886	.1372	.1219	.2743	.1543
6	.12	.2401	.2058	.1372	.1372	.3429	.12
7	.1543	.2058	.2229	.1543	.1524	.1219	.12
8	.1715	.2058	.4287	.1543	.1372	.1219	.1543
9	.2401	.1715	.4287	.1543	.2572	.12	.1981
10	.4115	.3429	.5144	.0762	.4115	.3944	.3353
11	.2572	.583	.4801	.0762	.1543	.4115	.3201
12	.2743	.3601	.4801	.0762	.3772	.4287	.3048
13	.3086	.3944	.4801	.1067	.463	.1829	.2743
14	.3944	.3429	.4287		.5144	.3429	.2743
15	.3772	.4458	.3429	.2591	.5487	.1715	.2591
16	.2915	.1886	.3429	.1981	.4801	.1715	.2591
17	.3429		.3086	.2134	.4458	.3772	.3048
18	.4287		.3086	.2134	.2229	.1886	.1677
19	.2229		.2229	.2134	.2915	.3772	.2591
20	.1886	.1543	.2229	.2286	.2743	.3429	.2286
21	.1715	.1715	.1543	.2591	.2743	.3258	.1981
22	.1715	.2229	.1543	.2286	.2401	.3086	.1981
23	.1715	.2915	.12	.2286	.2401	.2401	.1829
24	.1219	.1886	.2229	.12	.2134	.1829	.2401
Max	.4287	.583	.5144	.2591	.5487	.4287	.3353
Min	.0762	.1543	.12	.0762	.1219	.12	.12
Avg	.2205	.2643	.2915	.1608	.2717	.2633	.2212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 202 / 11 KV Shevate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.4327	1.2193	1.4575	1.2955	1.5775	.2134
2	1.2498	1.3717	1.2346	1.5089	1.2955	1.4022	.2134
3	1.2955	1.3717	1.3717	1.2955	1.326	1.4327	.2286
4	1.326	1.4632	1.5394	1.3765	1.3717	1.4632	.2439
5	1.3717	1.5242	1.5851	1.4575	1.387	1.4937	.2439
6	1.7528	1.6461	1.6918	1.5223	1.7985	1.5242	.2591
7	1.829	1.8595	1.7375	1.8947	1.9204	1.7375	.2591
8	1.6918	1.829	1.829	1.9109	1.768	1.6766	.1524
9	1.768	1.7985	1.6309	1.9433	1.5699	1.6461	1.5546
10	.0914	.0914	.12	.0762	.1219	.1067	
11	.0457	.061	.1029	.0762	.0762	.0914	
12	.0457	.1524	.1372	.0762	.0762	.1219	
13	.0457	.0914	.1029	.1067	.0914	.1067	
16	.061	.0914	.1029	.1372	.1372	.1067	
17	.061		.1029	.1219	.1372	.1067	
18	.0914		.1372	.1372	.1372	.1219	1.326
19	.1524		.2058	.1981	.1829	.1524	.1219
20	.1829	.1677	.2229	.1829	.1829	.1524	.1372
21	.1829	.1677	.1715	.1677	.1981	.1677	.1524
22	.1524	.1524	.1715	.1524	.1829	.1829	.1524
23	.1524	.1372	.1543	.1524	.1524	.1981	.1524
24	.9907	1.4327	1.1584	1.3765	1.2498	1.3717	.1981
Max	1.829	1.8595	1.829	1.9433	1.9204	1.7375	1.5546
Min	.0457	.061	.1029	.0762	.0762	.0914	.1219
Avg	.7094	.8864	.7604	.7877	.7572	.7700	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 203 / Ulabhagat Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2439	.2591	.3086	.2286	.2439	1.829
2	.2134	.2439	.2439	.3086	.2591	.2743	1.9814
3	.2286	.2439	.2896	.3086	.2743	.2743	1.9966
4	.2439	.2743	.3048	.3258	.3048	.2743	2.1338
5	.2743	.2743	.3201	.3429	.3048	.3048	2.4387
6	.2743	.3048	.3353	.3601	.3353	.3353	2.4539
7	.3048	.3048	.3658	.4458	.3658	.3658	2.5606
8	.2896	.2743	.381	.3772	.3506	.2743	2.5606
9	.2134	.2439	.2896	.3429	.2896	.2896	.2439
10	.2286	.1981	.3086	.2439	.2286	.2134	
11	1.5546	1.768	1.587	1.9814	1.9814	1.8747	
12	2.4996	2.6978	3.1255	2.3472	2.5911	2.4539	
13	2.774	2.7892	3.0769	2.5301	2.6825	2.6063	
16	2.652	2.5606	3.2388	3.0178	2.1948	2.5911	
17	2.5606		3.1093	2.774	2.3777	2.9264	
18	2.3624		2.9959	2.8349	3.0026	2.4539	.1829
19	.2134		.2429	.2896	.2896	.1677	.3506
20	.1829	.2896	.3772	.2743	.2439	.2591	.3353
21	.2134	.2743	.3429	.2591	.2439	.2439	.3201
22	.2134	.2591	.3429	.2439	.2743	.2439	.3048
23	.2439	.2591	.3429	.2439	.2591	.2286	.2743
24	.1829	.2439	.2743	.3086	.2286	.2439	1.7375
Max	2.774	2.7892	3.2388	3.0178	3.0026	2.9264	2.5606
Min	.1829	.1981	.2429	.2439	.2286	.1677	.1829
Avg	.8244	.7236	1.0070	.9304	.8778	.8702	1.3565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 204 / CHOUFULA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1643	2.2558	1.89	2.5101	2.2862	2.2253	.1524
2	2.21	2.5301	1.9814	2.5425	2.3167	2.3472	.1677
3	2.2558	2.652	2.1338	2.5425	2.3624	2.4387	.1829
4	2.2862	2.652	2.4387	2.6073	2.3624	2.5301	.1981
5	2.2862	2.7435	2.7282	2.7831	2.3777	2.7282	.2286
6	2.5911	2.8349	2.7435	2.934	2.8197	2.8349	.2439
7	2.6368	2.9264	2.7892	3.2712	3.0331	2.9874	.2439
8	2.713	2.8654	2.7435	3.2388	2.8502	2.8045	.2439
9	2.4691	2.8959	2.774	3.0931		2.4844	2.6825
10	.2591	.2286	.2401	.1829	.1981	.1981	
11	.1067	.2286	.1715	.1524	.1219	.1372	
12	.0762	.2134	.1543	.1219	.0914	.1219	
13	.061	.1219	.1372	.1372	.1372	.1067	
16	.1524	.1372	.1715	.1372	.1829	.1067	
17	.1219	.1715	.1886	.1524	.1524	.1219	
18	.1829	.3048	.2058	.1829	.1677	.1067	2.3015
19	.2591	.2896	.2743	.2591	.3963	.1219	.3048
20	.2439	.2591	.2743	.2286	.2743	.1677	.3201
21	.1829	.2591	.2572	.1981	.2743	.1829	.2134
22	.2134	.2439	.2229	.2134	.2439	.1981	.2439
23	.1829	.2286	.2058	.2134	.2439	.2286	.2591
24	1.829	1.89	1.9052	2.1862	2.0119	1.9204	.1677
Max	2.713	2.9264	2.7892	3.2712	3.0331	2.9874	2.6825
Min	.061	.1219	.1372	.1219	.0914	.1067	.1524
Avg	1.1584	1.3151	1.2105	1.3586	1.1859	1.2318	.5097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274174 / 33/11 KV Shevate Sub Station

Feeder No / Name : 205 / 11 KV PATHAN SAHEB

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.2134	1.387
2		.1524	.2134	1.4784
3		.1524	.2743	1.5394
4		.1677	.2743	1.5699
5		.1677	.3048	1.5699
6		.1981	.3658	1.6156
7		.2439	.3963	1.6309
8		.2134	.2134	1.6309
9			.2134	.1829
10	.1372	.2439	.2439	
11	1.1126	.9145	1.448	
12	1.0974	.9145	1.6613	
13	1.0669	.9755	1.7528	
16	1.1431	1.3717	1.3565	
17	1.0669	1.5242	1.5851	
18	.9602	1.5851	1.5394	
19	.1219	.1981	.1524	
20	.1524	.1829	.1372	
21	.1677	.1829	.1524	
22	.1524	.1981	.1524	
23	.1524	.1829	.1524	
24		.1677	.1829	1.387
Max	1.1431	1.5851	1.7528	1.6309
Min	.1219	.1524	.1372	.1829
Avg	.6109	.4812	.5903	1.3992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3841	.3841	.3475	.3475	.3658	.3658
2	.3658	.4024	.4024	.3841	.4024	.3841	.4024
3	.4024	.4207	.4207	.439	.4572	.439	.4572
4	.439	.4572	.4755	.4755	.4938	.4755	.5304
5	.4572	.5487	.567	.5304	.5121	.567	.5853
6	.6401	.6219	.6036	.6401	.5853	.6036	.6767
7	.5487	.567	.4755	.567	.567	.4755	.5121
8	.4207	.4755	.4024	.4938	.4024	.439	.4024
9	.3658	.3841	.3292	.4207	.2743	.4207	.3841
10	.3475	.3292	.3475	.4024	.3658	.3841	.3658
11	.2561	.2926	.2743	.2743	.3475	.2926	.2743
12	.2378	.2743	.2561	.2743	.3292	.2743	.2561
13	.2195	.2561	.1829	.2195	.2743	.2378	.2195
14	.2012	.2195		.1829	.2561	.2012	.1829
15	.1646	.2195		.2012	.2378	.2195	.2195
16	.1646	.2378	.2195	.2378		.2378	.2743
17	.2195	.2195	.2378	.2743	.3109	.2378	.2743
18	.2926		.3475	.2743	.2926	.3109	.3475
19	.4755	.4572	.5121	.4207	.5487	.4572	.4938
20	.5487	.5487	.6036	.5121	.567	.5487	.5853
21	.5487	.5304	.5853	.5304	.5304	.5121	.5304
22	.4755	.439	.4938	.4938	.4572	.4572	.4572
23	.4024	.3841	.439	.439	.4024	.3841	.4207
24	.3475	.4024	.3658	.4024	.3658	.3658	.3841
Max	.6401	.6219	.6036	.6401	.5853	.6036	.6767
Min	.1646	.2195	.1829	.1829	.2378	.2012	.1829
Avg	.3696	.3944	.4057	.3932	.4056	.3871	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 202 / BABHULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8905	1.0155	.9842	.9842	1.0155	1.0623	.0625
2	.9374	1.0311	1.0155	1.0467	1.078	1.0936	.0625
3	1.0467	1.0623	1.078	1.0936	1.1405	1.1561	.0625
4	1.1717	1.1873	1.1248	1.1717	1.2186	1.2342	.0781
5	1.3123	1.2811	1.2654	1.2186	1.2498	1.2967	.0781
6	1.5466	1.4998	1.4529	1.4842	1.4529	1.4529	.0937
7	1.9372	2.0309	1.906	1.9841	1.7654	2.0778	.0781
8	1.7497	2.0622	1.9372	2.0622	1.9841	2.0309	.0625
9	.9686	1.8747	1.7497	1.781	1.8591	1.8122	.0469
10	.0312	.0312	.0312	.0469	.0469	.0312	.0312
11	.0312	.0312	.0312	.0312	.0312	.0312	1.406
12	.0312	.0312	.0312	.0312	.0312	.0312	1.9216
13	.0366	.0312	.0312	.0312	.0312	.0312	1.8747
14	.0312	.0312	.0312	.0312	.0312	.0312	
15	.0312	.0312	.0312	.0312	.0312	.0312	
16	.0312	.0312	.0312	.0312		.0312	
17	.0312	.0312	.0312	.0312	.0469	.0312	
18	.0312	.0312	.0312	.0469	.0312	.0312	1.531
19	.0781	.0781	.0625	.0625	.0781	.0625	.0937
20	.0781	.0625	.0625	.0625	.0781	.0781	.0781
21	.0625	.0625	.0625	.0625	.0625	.0625	.0625
22	.0469	.0625	.0469	.0469	.0625	.0625	.0781
23	.0625	.0625	.0469	.0469	.0625	.0625	.0781
24	.8592	.953	.8905	.9686	.9842	.9686	.0625
Max	1.9372	2.0622	1.9372	2.0622	1.9841	2.0778	1.9216
Min	.0312	.0312	.0312	.0312	.0312	.0312	.0312
Avg	.5431	.6086	.5819	.5995	.6249	.6164	.3921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274181 / 33/11 KV BABHULGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV ROPALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.064	.08	.064	.064	.0648	1.8138
2	.0633	.064	.08	.064	.064	.0648	1.8785
3	.0949	.08	.08	.096	.064	.081	1.8785
4	.0949	.096	.096	.096	.096	.0972	1.9433
5	.1265	.112	.112	.128	.128	.1134	1.9757
6	.1265	.128	.128	.128	.128	.1296	2.0081
7	.0633	.096	.128	.096	.064	.1296	2.4615
8	.0633	.096	.08	.064	.064	.0972	2.5263
9	.0633	.08	.08	.064	.064	.081	2.4615
10	.0633	.064	.064	.064	.064	.0648	.0648
11	2.2138	2.4326	2.4326	2.4326	2.2405	2.332	.0648
12	3.1626	3.2007	2.8807	3.0087	3.1367	3.0769	.0648
13	2.9729	2.9447	3.0727	2.8166	2.9447	3.1093	.0648
14	.0633	2.7526	2.8807	2.8807	2.8166	2.9959	
15	.0633	2.8807	3.0727	3.0087	2.8166	2.8502	
16	2.7199	3.0087	3.0087	3.0727		2.8502	
17	3.1626	2.8807	2.8807	2.7526	2.8807	2.6886	
18	2.9096	2.9447	2.9447	2.7526	2.8166	2.7526	.0648
19	.0633	.08	.064	.064	.064	.0655	.081
20	.0791	.08	.0633	.064	.112	.0655	.0972
21	.0949	.096	.064	.064	.096	.0648	.081
22	.0949	.08	.064	.064	.08	.0648	.081
23	.0791	.096	.064	.064	.096	.0648	.0648
24	.0633	.08	.08	.064	.064	.081	1.7814
Max	3.1626	3.2007	3.0727	3.0727	3.1367	3.1093	2.5263
Min	.0633	.064	.0633	.064	.064	.0648	.0648
Avg	.7736	1.0182	1.0209	.9989	.9115	.9994	1.0729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 201 / 11KV SHINGARE/CHAWAN

SEPARATED AG FEEDERS HAVING SPECIAL

WASTI FE Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.16	.1265	.1581	.1457	.1457	.6249
2	.1581	.1562	.1265	.1581	.1457	.1457	.6481
3	.1581	.1718	.1581	.1581	.1619	.1457	.6401
4	.0316	.2187	.1898	.1562	.1619	.1457	.6401
5	.1898		.1739	.2056	.1781	.1619	.7621
6	.2056	.3041	.1739	.2372	.2267	.1943	1.0822
7	.2214	.2561		.2688	.3239	.2267	1.2346
8	.2372	.2241	.1581	.253	.2915	.2591	1.4506
9	.176	.1718	.2656	.2343		.1781	.1581
10	.16	.1406	.1581	.1562	.1134	.1524	.1898
11	1.1523	1.1248	.8855		.7164	1.0212	.2214
12	1.1203	1.6248	1.5971	1.5466	1.4327	1.2193	.1898
13	1.1203	1.3969	1.5813	1.5623	1.4784	1.0059	
14	.2241	1.3592	1.5813	1.4373	1.1431	1.0669	
15	.2401	1.5466	1.5813	1.4373	1.2498	1.0364	
16	1.4403	1.4217	1.5023	1.4373	1.3717	.6859	
17	1.5043	1.4217	1.5023	1.3748	1.2193	1.2346	.1739
18	1.6164	1.4529	1.4232	1.2654	.7011	1.326	.1898
19	.2241	.1406	.1581	.1406	.1619	.1372	.1898
20	.2401	.1875	.2056	.1875	.2105	.1524	.2056
21	.2241	.1875	.2214	.1718	.1781	.1524	.2214
22	.176	.1718	.2056	.1562	.1781	.1677	.2056
23	.176	.1718	.1581	.1406	.1619	.1829	.1898
24	.1581	.16	.2846	.1581	.1457	.1619	.1524
Max	1.6164	1.6248	1.5971	1.5623	1.4784	1.326	1.4506
Min	.0316	.1406	.1265	.1406	.1134	.1372	.1524
Avg	.4766	.6161	.6269	.5653	.5260	.4711	.4685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 202 / 11KV WATAR WAT FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0722	1.1591	1.0517	1.1294	1.1279	.2469
2	1.0364	1.1883	1.1888	1.1888	1.1888	1.1584	.2469
3	1.0364	1.2037	1.2631	1.1888	1.1888	1.1584	.2469
4	1.0623	1.2037	1.3375	1.1888	1.1888	1.1888	.2778
5	1.1431	1.2963	1.3375	1.3717	1.3375	1.1888	.3704
6	1.4632	1.7284		1.3717	1.4861	1.2955	.3858
7	1.9052	1.8519	1.7985	1.9052	1.8278	1.7223	.3858
8	1.9204	1.8982	1.9204	1.9814	1.9319	1.9907	.3858
9	.216	.2972	1.6347	.2229	.2526	.2932	.2469
10	.216	.3269	.2743	.2675	.2429	.216	.1852
11	.2778	.3715	.3353		.2267	.2006	1.0802
12	.3086	.4012	.3048	.1932	.2591	.216	1.8827
13	.3241	.3418	.3048	.2526	.2429	.216	
14	.3704	.3864	.3353	.2824	.1457	.2778	
15	.3704	.4012	.3048	.3121	.1457	.3395	
16	.3704	.3715	.3048	.3269	.2591	.3549	
17	.3858	.3121	.381	.3418	.3239	.3549	1.8982
18	.3858	.3269	.381	.4012	.1457	.3549	1.9599
19	.3704	.3864	.3048	.4012	.3077	.3704	.216
20	.3086	.3567	.3048	.3418	.4049	.3549	.3163
21	.2778	.3269	.3048	.3121	.3563	.2778	.3086
22	.2469	.3269	.3048	.2526	.2753	.2469	.2778
23	.2006	.3121	.2286	.2378	.2591	.2315	.2778
24	.9907	.2006	.2972	.2134	.2378	.2429	.2315
Max	1.9204	1.8982	1.9204	1.9814	1.9319	1.9907	1.9599
Min	.2006	.2006	.2286	.1932	.1457	.2006	.1852
Avg	.6603	.7037	.7092	.6786	.6402	.6408	.5714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274182 / 33/11 KV SUSTE SUBSTATION

Feeder No / Name : 203 / 11KV SUSTE RIVER SIDE SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0312	.0312	.032	.0457	.0324	.5864
2	.0316	.0312		.032	.0457	.0486	.5864
3	.0312	.0312	.0312	.0312	.0457	.0486	.5864
4	.0312	.0312	.0312	.032	.0457	.0486	.8642
5	.0312	.0312	.0312	.0316	.0457	.0486	1.2346
6	.0312	.0312	.0312	.032	.0457	.0486	1.3117
7	.0312	.0312	.0312	.032	.0457	.0486	1.5123
8	.0312	.0312	.0312	.032	.0305	.0309	1.6667
9	.0312	.0305	.0156	.0305	.0457	.0305	.0312
10	.0312	.0152	.0312	.0305	.0486	.0309	.0312
11	1.0467	1.0212	.8905		.7316	.2315	.0316
12	1.1092	1.1584	1.0936	1.0517	.9755	.2623	.0316
13	1.2342	1.1888	1.1248	1.0669	.9907	.3086	
14	1.1873	1.1279	1.1248	1.0822	.7926	.2778	
15	1.1561	1.0822	1.1248	1.0059	.884	.2932	
16	1.1717	1.0669	1.0936	1.0212	.945	.2932	
17	1.1405	1.0974	1.0936	1.0364	.7468	.2932	.0316
18	1.1405	1.1126	1.0623	1.0822	.4725	.3549	.0316
19	.0312	.0457	.0312	.0457	.0324	.0309	.0316
20	.0312	.0305	.0312	.0305	.0324		.0316
21	.0312	.0305	.0312	.0305	.0324		.0316
22	.0312	.0305	.0312	.0457	.0324	.0154	.0316
23	.0312	.0305	.0312	.0457	.0324	.032	.0474
24	.0312	.0312	.0312	.032	.0457	.0324	.0309
Max	1.2342	1.1888	1.1248	1.0822	.9907	.3549	1.6667
Min	.0312	.0152	.0156	.0305	.0305	.0154	.0309
Avg	.4036	.3896	.3939	.3431	.2996	.1292	.4371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 201 / 11 KV KAROLE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.6004	1.7147	1.6004	1.4861	1.8099	.1143
2	1.5242	1.6766	1.8099	1.6004	1.5242	1.9052	.1143
3	1.7147	1.7147	1.8099	1.6385	1.5242	1.9052	.1143
4	1.9052	1.7147	1.829	1.6385	1.5242	1.9052	.1143
5	1.9052	1.7147	1.829	1.7147	1.5623	1.9052	.1143
6	1.9052	1.7147	1.829	1.7147	1.5623	1.9052	.1143
7	1.9052	1.7528	1.829	1.7909	1.5623	1.9052	.1524
8	1.9052	1.7528	1.9052	1.9052	1.6385	2.0576	.1524
9	1.9052	1.7528	1.829	1.9052	1.5623	2.0576	.1524
10	.1524	.0953	.1524	.1334	.1143	.1524	
11	.1143	.0572	.0762	.0762	.0572	.0572	
12	.0762	.0572	.0572	.0572	.0572	.0572	
13	.0381	.0572	.0762	.0762	.0572	.1143	
16	.0572	.0572	.0762	.0762	.0572		
17	.1143	.0572	.1143	.0953	.1143		
18	.1143	.0572	.1143	.0762	.1143		2.2481
19	.1143	.1143	.1715	.1524	.1143		.1524
20	.1143	.1143	.1524	.1524	.1143		.1524
21	.1143	.1143	.1143	.1143	.1143		.1715
22	.1143	.1524	.0762	.1143	.1143		.0953
23	.1143	.1143	.0762	.1143	.1143		.0953
24	1.3336	1.5242	1.7147	1.5242	1.3717	1.7909	.1143
Max	1.9052	1.7528	1.9052	1.9052	1.6385	2.0576	2.2481
Min	.0381	.0572	.0572	.0572	.0572	.0572	.0953
Avg	.8487	.8167	.8799	.8305	.7482	1.3949	.2608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 202 / 11 KV BELDAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	.1905	.0953	.1143	1.9052
2	.2286	.1524	.1905	.1143	.1143	1.9814
3	.2286	.1524	.1905	.1143	.1524	1.9814
4	.2286	.1905	.1905	.1524	.1524	1.9814
5	.2286	.1905	.1905	.1905	.1524	1.9814
6	.2286	.1905	.1905	.1905	.1905	1.9814
7	.2286	.1905	.1905	.2286	.1905	1.9814
8	.2286	.1905	.2286	.1905	.1905	1.9814
9	.1905	.1524	.1905	.1524	.1905	1.9052
10	.1524	.1143	.0953	.1905	.1524	
11	1.4861	1.7147	1.7528	1.6004	1.7528	
12	1.7147	2.0576	1.9433	2.1338		
13	1.9052	2.0576	2.0386	1.9814	2.1338	
16	1.9814	2.0576	2.0957	2.0957	1.9814	
17	1.9433	2.0576	2.0957	2.0576	2.1338	
18	1.9814	2.0576	2.0957	2.0576	2.1338	.1143
19	.1524	.1143	.0953	.1143	.1905	.1524
20	.1524	.1143	.0953	.1143	.1905	.1524
21	.1524	.1143	.0953	.1143	.1905	.1334
22	.1524	.1143	.0953	.1143	.1905	.1143
23	.1524	.1143	.0953	.1143	.1905	.1143
24	.1524	.1524	.1143	.0953	.1143	1.9052
Max	1.9814	2.0576	2.0957	2.1338	2.1338	1.9814
Min	.1524	.1143	.0953	.0953	.1143	.1143
Avg	.6408	.6547	.6573	.6460	.6096	1.2729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274241 / 33/11 KV KAROLE

Feeder No / Name : 203 / 11 KV YAMGAR FATA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0572	.0762	.0762	1.7147
2	.0953		.0572	.0762	.0762	1.7147
3	.0953		.0572	.0953	.0762	1.7147
4	.0953		.0572	.0953	.1143	1.7147
5	.0953		.0572	.1143	.1143	1.7147
6	.1143		.0572	.1143	.1143	1.7147
7	.1143		.0572	.0953	.1143	1.7147
8	.1143		.0572		.1143	1.7147
9	.1143		.0953	.0572	.1143	1.6766
10	.1143	.0762	.1143	.0762		
11	1.3336	1.6004	1.6385	1.448	1.7147	
12	1.4098	1.9052	1.9433	1.7147	1.9433	
13	1.7528	1.9052	1.9052	1.7528	1.9433	
16	1.7528	1.9052	1.9433	1.7909	1.829	
17	1.7909	1.9052	1.9052	1.7909	1.829	
18	1.7909	1.9052	1.8671	1.7528	1.9052	.0762
19	.1524	.1524	.0953	.1143	.0953	.1143
20	.1524	.1524	.0953	.0762	.0953	.1143
21	.1524	.1143	.0953	.0762	.1143	.0953
22	.1524	.1143	.0953	.0762	.1143	.0953
23	.1524	.1143	.0953	.0762	.1143	.1143
24	.1143	.0762	.1143	.0762	.0762	1.7147
Max	1.7909	1.9052	1.9433	1.7909	1.9433	1.7147
Min	.0953	.0762	.0572	.0572	.0762	.0762
Avg	.5343	.8573	.5664	.5498	.6042	1.1074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 201 / 11 KV NARSALE PATTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.1524	.2286	.1143	.1905	1.105
2	.0762	.0953	.1524	.1905	.1143	.1905	1.2193
3	.0762	.0953	.1715	.1905	.1143	.1715	1.3717
4	.0762	.1143	.1905	.2286	.1143	.1715	1.5242
5	.0762	.1143	.1905	.2286	.1524	.1905	1.7909
6	.1143	.1334	.1905	.2477	.1524	.1905	1.8671
7	.1524	.1524	.2096	.2286	.1905	.1715	1.9052
8	.1905	.1524	.2667	.2667	.1905	.2477	2.1338
9	.1334	.1143	.2286	.2477	.1905	.2286	1.9814
10	.1143	.0762	.1905	.1905	.1905	.1905	
11	1.5242	1.2384	1.5242	1.5623	2.0195	1.7909	
12	1.829	2.21	2.0957	2.3243	2.2862	2.4006	
13	1.5242	2.2862	2.1338		2.2862	2.4387	
16	1.829	2.0957	2.3624	2.2481	2.2862	2.2481	
17		2.1719	2.0576	2.2672	2.2862	2.21	
18		1.8671	1.829	2.2862	2.1338	2.0957	.1524
19	.1143	.3048	.2286	.1524	.1524	.1524	.1905
20	.1334	.1905	.2286	.1524	.1905	.1905	.2667
21	.1524	.1905	.1905	.1524	.1905	.1143	.2286
22	.1143	.1524	.1905	.1524	.1905	.1143	.1524
23	.1143	.1524	.1905	.1143	.1905	.1143	.1334
24	.0762	.1143	.1715	.2286	.1143	.1905	.9907
Max	1.829	2.2862	2.3624	2.3243	2.2862	2.4387	2.1338
Min	.0762	.0762	.1524	.1143	.1143	.1143	.1334
Avg	.4249	.6417	.6885	.6614	.7205	.7274	1.0633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 202 / 11 KV NEW JALOLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0953	.1143	.0953	1.9052
2	.0762	.0762	.0572	.0953	.1143	.0953	2.0005
3	.0572	.0762	.0953	.0953	.1143	.0953	2.0576
4	.0572	.0762	.0953	.1143	.1334	.0953	2.0576
5	.0762	.0953	.1143	.1143	.1524	.1143	2.1338
6	.0953	.0953	.1143	.1524	.1715	.1143	2.2481
7	.1143	.1143	.1334	.1524	.1905	.1524	2.2481
8	.1334	.1143	.1143	.1334	.1905	.1524	2.3624
9			.1524	.1143	.1524	.1715	2.4006
10	.1524	.1143	.1143	.1143	.1524	.1524	
11	1.7147	1.6385	2.1719	1.9433	2.0576	2.0195	
12	2.0576	2.2862	2.4006	2.2862	2.1719	2.1338	
13	2.0195	2.3243	2.0957	2.21	2.21	2.2862	
16	2.1338	2.4006	2.2481	2.2862	2.2481	2.3624	
17		2.4006	2.21	2.2481	2.0957	2.3815	
18		2.3243	2.0576	2.2481	2.1719	2.3624	.0762
19	.0762	.0762	.1143	.1905	.1524	.1143	.1143
20	.0953	.0762	.1143	.1715	.1524	.1905	.1334
21	.1143	.0762	.0762	.1905	.1524	.0953	.1524
22	.1143	.1143	.0762	.1524	.1524	.0381	.1524
23	.1143	.0572	.0953	.1524	.1143	.0381	.1143
24	.0762	.0953	.0953	.0953	.1143	.0953	1.7528
Max	2.1338	2.4006	2.4006	2.2862	2.2481	2.3815	2.4006
Min	.0572	.0572	.0572	.0953	.1143	.0381	.0762
Avg	.4923	.7004	.6738	.6980	.6945	.6980	1.3694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

PANDHARPUR R-II S/DN[715] BU 4715

Substation No/ Name :- 274249 / 33/11 KV JALOLI

Feeder No / Name : 203 / 11 KV NEW SANGAVI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578	3.0483	2.9531	2.6673	1.5242	2.934	.2667
2	3.0483	3.3341	3.0483	2.7816	1.7147	3.0483	.2667
3	3.0864	3.4294	3.1436	2.9912	2.0957	3.1436	.3048
4	3.1245	3.5246	3.2769	3.1436	2.2862	3.2388	.3048
5	3.2007	3.6008	3.3913	3.315	2.6673	3.3341	.3048
6	3.315	3.7151	3.4675	3.4675	3.4294	3.4675	.3429
7	3.3913	3.6199	3.5246	3.6199	3.6199	3.658	.3429
8	3.3532	3.7342	3.7723	3.7723	3.658	3.8104	.3429
9	3.6199	3.658	3.7342	3.6199	3.6961	3.5056	.2858
10	.381	.381			.3048	.381	
11	.2667	.2667			.2667	.1905	
12	.2286	.2096					
18							3.6961
19	.4572	.3429	.381	.3429	.3429	.4191	3.6008
20	.4191	.4191	.381	.381	.381	.381	.381
21	.381	.381	.381	.3429	.3429	.3048	.381
22	.3429	.3048	.381	.3048	.3429	.2667	.3429
23	.3048	.3048	.381	.2667	.381	.2667	.3048
24	2.7816	2.6673	2.6673	2.6292	.9526	2.8578	.3048
Max	3.6199	3.7342	3.7723	3.7723	3.6961	3.8104	3.6961
Min	.2286	.2096	.381	.2667	.2667	.1905	.2667
Avg	1.92	2.0523	2.3256	2.2431	1.6474	2.0711	.7359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274059 / 33/11 KV ACHAKDANI

SUBSTATION

Feeder No / Name : 241 / 11 KV IAKSHMINAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)
10		.1097
11		.9907
12		1.829
13		1.7939
14		1.5927
15		1.0202
16		1.4089
22	.2652	
Max	.2652	1.829
Min	.2652	.1097
Avg	.2652	1.2493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 241 / 11 KV Gherdi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829		.5182		.5182	
2		.1829		.6097		.6859	
3		.1829		.7316		.8688	
4		.1981		.9145		.945	
5		.2134		1.0669		1.0669	
6		.2439		1.1584		1.2498	
7	.3048	.2591		1.2498	1.3717	1.3565	1.4632
8	.2134	.2134		1.5546	1.4022	1.387	
9	.1677		.1524		1.3413		
10	.1524		.1219		.1372		
11			.5639		.1219		
12	1.7071		1.6156		.1219		
13	1.6004		1.5242		.1219		
14	1.5546		1.387		.1372		
15	1.6156		1.4022		.1067		
16	1.7071		1.2651		.0914	.1372	
17	1.7985		1.4784		.1067		
18	1.4175		1.3413		.1067		
19	.1981		.2134		.2134		
20	.2896		.2743		.2743		
21	.2743		.2439		.2439		
22	.2439		.2286				
23	.2134		.2134		.1829		
24	.1677	.1829		.3353	.3048	.3353	.3201
Max	1.7985	.2591	1.6156	1.5546	1.4022	1.387	1.4632
Min	.1524	.1829	.1219	.3353	.0914	.1372	.3201
Avg	.8015	.2066	.8017	.9043	.3757	.8551	.8917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 242 / 11 KV Pare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1067		.3658		.3658	
2		.1067		.442		.5182	
3		.1067		.5335		.6401	
4		.1372		.6401		.823	
5		.1524		.7621		1.0212	
6		.1829		1.0364		1.1584	
7	.2134	.1981		1.2041		1.2193	1.1888
8	.1524	.1524		1.0669		1.2803	
9	.1219		.1067				
10	.1067		.1067		.0914		
11			.442		.0914		
12	1.2803		1.1279		.0914		
13	1.2041		1.0669		.0762		
14	1.1736		1.0974		.0762		
15	1.1584		.9755		.0762		
16	1.1279		.9145		.0762	.0762	
17	1.1888		1.2803		.0914		
18	1.0669		1.2803		.0914		
19	.1219		.1372		.1219		
20	.2134		.2134		.2134		
21	.1981		.1829		.1829		
22	.1677		.1524		.1677		
23	.1372		.1219		.1372		
24	.1067	.1067		.2591		.2439	.2896
Max	1.2803	.1981	1.2803	1.2041	.2134	1.2803	1.1888
Min	.1067	.1067	.1067	.2591	.0762	.0762	.2896
Avg	.5729	.1389	.6137	.7011	.1132	.7346	.7392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 243 / 11 KV Hangirge feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6249		.1829		.1524	
2		.6859		.1829		.1524	
3		.823		.1829		.1524	
4		.9145		.1981		.1829	
5		1.6613		.2134		.2134	
6		1.9662		.2439		.2743	
7	2.0729	2.0119		.2743	.3201	.3048	.3353
8	2.1795	2.21		.2286	.2743	.2439	
9	1.8595		1.9052		.2439		
10	.2134		.1829		.2134		
11			.1677		.5182		
12	.1524		.1219		1.6613		
13	.1219		.1067		2.1948		
14			.1067		2.0729		
15	.0914		.1067		1.89		
16	.0914		.1219		1.9204	2.0119	
17	.1067		.1219		2.0119		
18	.1067		.1524		1.829		
19	.1829		.1829		.1981		
20	.2743		.2591		.2591		
21	.2591		.2439		.2286		
22	.2286		.2286		.1981		
23	.1829		.1981		.1829		
24	.442	.4572		.1829	.1677	.1677	.1981
Max	2.1795	2.21	1.9052	.2743	2.1948	2.0119	.3353
Min	.0914	.4572	.1067	.1829	.1677	.1524	.1981
Avg	.5354	1.2617	.2804	.2100	.9103	.3856	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274061 / 33/11 KV Geradi

Feeder No / Name : 244 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2439		.2439		.2439	
2		.2439		.2439		.2439	
3		.2439		.2439		.2439	
4		.2743		.2743		.2743	
5		.3658		.3048		.3048	
6		.442		.3963		.3963	
7	.4572	.4572		.4572	.4572	.4572	.4572
8	.3963	.3963		.3658	.3963	.3658	
9	.3048		.3353		.3201		
10	.2743		.3048		.2743		
11			.2743		.2439		
12	.2439		.2743				
13	.2439		.2439		.2439		
14	.2439		.2439		.2439		
15	.2439		.2439		.2134		
16	.2439		.2134		.2134	.1829	
17	.2743		.2439		.2439		
18	.2743		.2743		.2439		
19	.3048		.3353		.3048		
20	.4877		.4877		.4877		
21	.4268		.4268		.4268		
22	.3353		.3353		.3353		
23	.2743		.3048		.2743		
24	.2134	.2439		.2439	.2439	.2439	.2439
Max	.4877	.4572	.4877	.4572	.4877	.4572	.4572
Min	.2134	.2439	.2134	.2439	.2134	.1829	.2439
Avg	.3084	.3235	.3028	.3082	.3039	.2957	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 242 / 11 KV Gaudwadi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	1.1336	1.1012	.6443	.703
2	.6706	1.166	1.1336	.8648	.9374
3	.7127	1.166	1.166	.9448	1.0623
4	.9556	1.1984	1.166	1.1022	1.1248
5	1.0774	1.3279	1.2955	1.3226	1.1561
6	1.6095	1.6842	1.8461	1.5746	1.1873
7	2.1216	2.1214	2.2672	2.1792	1.7185
8	2.3644	2.3158	2.3644	2.3908	2.1538
9	2.2672	.081	2.1628	1.9433	2.2348
10		.0648			
16	.1296	.1943	.1509	.1457	.2035
17	.2105		.2652	.2267	.2543
18	.1943	.1619	.2683	.2267	.3018
19	.3563	.2267	.3185	.2915	.3321
20	.2753	.2753	.39	.2915	.3479
21	.3725	.2591	.3561	.3077	.3437
22	.3563	.2429	.3258	.2915	.2846
23	.3239	.2267	.285	.2429	.253
24	.5138	.6154	.6316	.6299	.6249
Max	2.3644	2.3158	2.3644	2.3908	2.2348
Min	.1296	.0648	.1509	.1457	.2035
Avg	.8384	.8034	.9719	.8678	.8458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 243 / 11 KV Junoni feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.8097	.6802	.4359	.7499
2	.5801	.8421	.7287	.4752	.9061
3	.6371	.8745	.7287	.5801	1.0623
4	.763	.8421	.7611	.6962	1.1717
5	.9614	.9069	.8421	.8383	1.2186
6	1.1065	1.0688	1.5223	.8886	1.2498
7	1.6598	1.668	1.7976	1.6409	1.8747
8	1.668	1.7166	1.1498	1.7238	
9	1.4089	.081	1.2071	1.4413	1.668
10		.0648			
16	.1619	.1457	.1492	.1296	.2035
17	.1619	.2105	.2321	.1457	.2035
18	.1781	.2105	.1509	.1943	.1989
19	.2591	.2915	.2543	.2591	.2372
20	.2753	.3401	.3052	.2915	.3005
21	.2591	.3239	.2883	.2591	.3005
22	.2429	.2915	.2713	.2915	.253
23	.2267	.2753	.2543	.2429	.2187
24	.4144	.4049	.4372	.4096	.6562
Max	1.668	1.7166	1.7976	1.7238	1.8747
Min	.1619	.0648	.1492	.1296	.1989
Avg	.6349	.5983	.6534	.6080	.7337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 244 / 11 KV Pachegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1457	.1619	.1326	.1562
2	.1658	.1296	.1619	.1357	.1718
3	.1677	.1296	.1619	.1311	.1875
4	.1823	.1296	.1619	.1475	.1875
5	.1823	.1457	.1781	.1677	.2031
6	.1823	.1781	.1943	.1989	.2031
7	.1658	.1943	.1781		.2031
8	.1296	.1781	.1457		.1943
9	.1296	.0648	.1492		.1677
10	.1296	.0648	.1326	.1943	.1296
11	.4858		.5801	.6478	.4858
12	1.2955	.6478	.9614	.8907	.9717
13	1.2955	1.1336	1.2431	1.0526	.6478
14		1.2955		1.1336	.9945
15		1.1336		1.2146	1.1603
16	1.4575	1.1336	1.2431	1.2955	1.094
17	1.2955	1.1336	1.2929	1.2955	1.1271
18	1.1336	.6478	1.2674	1.2955	.9835
19	.1619	.1619	.1677	.1619	.1265
20	.1781	.1943	.2035	.1619	.1581
21	.1781	.1943	.2012	.1943	.1898
22	.1781	.1781	.1509	.1943	.1581
23	.1619	.1781	.1357	.1619	.1581
24	.1658	.1619	.1781	.1326	.1562
Max	1.4575	1.2955	1.2929	1.2955	1.1603
Min	.1296	.0648	.1326	.1311	.1265
Avg	.4358	.4154	.4205	.5210	.4256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 245 / KOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.6802	.7125	.7625	.6874
2	.7712	.6478	.6478	.9054	.7811
3	.8288	.7125	.6478	.9808	.9061
4	.9389	.7449	.7125	1.1317	.9686
5	1.1401	.8421	.9069	1.358	1.1248
6	1.4255	1.3279	1.2955	1.5844	1.2498
7	1.1603	1.1336	1.004	1.358	.9061
10	.6154	.1296	.663	.6478	.5182
11	.5506		.5967	.583	.583
12	.583	.6154	.5967	.6478	.5182
13	.6154	.7449	.6299	.6478	.5506
14	.6154	.6802	.6371	.6154	.6413
15	.583	.5182	.631	.5506	
16	.583	.6154	.7362	.5182	.7842
17	.583	.4858	.7164	.6802	.7087
18	.6802	.6478	.7922	.7773	.7468
19	1.1336	.9717	1.2826	1.004	1.1069
20	1.166	1.004	1.358	1.1336	1.1385
21	1.1012	1.0364	1.2071	1.0364	1.1069
22	.8421	.9393	1.094	.9069	.8855
23	.7773	.8421	.9431	.7449	.7907
24	.7625	.7125	.7449	.7625	.6874
Max	1.4255	1.3279	1.358	1.5844	1.2498
Min	.5506	.1296	.5967	.5182	.5182
Avg	.8281	.7634	.8435	.8790	.8281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 246 / 11 KV KOMBADWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1619	.1781	.1475	.1718
2	.1677	.1457	.1781	.1475	.1875
3	.1677	.1457	.1781	.1619	.2031
4	.1844	.1457	.1781	.1619	.2187
5	.1989	.1619	.1781	.1781	.2343
6	.2155	.1943	.2105	.2105	.2343
7	.1844	.2105	.1943		.2187
8	.1296	.1943	.1619		.2105
9	.1296	.081	.1658		.1943
10	.1296	.0972	.1341	.1619	
11	1.1336		.6706	.5668	.8097
12	1.9433	.8097	1.9448	.8097	1.4575
13	2.1052	1.6194	1.9281	.9717	1.2955
14		1.7814		1.2146	1.6956
15		1.6194		1.2955	1.6385
16	2.2672	1.2955	2.0719	1.2955	1.7532
17	2.1052	1.4575	2.1382	1.3765	1.8991
18	1.9433	1.1336	2.2377	1.3765	1.9062
19	.1781	.1781	.1989	.1619	.1581
20	.1943	.2105	.2347	.1619	.1898
21	.1781	.1943	.2155	.2105	.2214
22	.1781	.1781	.1696	.2105	.1898
23	.1781	.1781	.1619	.1943	.1898
24	.1658	.1781	.1781	.1492	.1718
Max	2.2672	1.7814	2.2377	1.3765	1.9062
Min	.1296	.081	.1341	.1475	.1581
Avg	.6474	.5379	.6321	.5316	.6717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274063 / 33/11 KV KOLA SUBSTATION

Feeder No / Name : 247 / 11 KV BUDDIHAL FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8122	1.0526	1.166	.8478	.9374
2	.8785	1.1012	1.1984	.9665	1.0155
3	.9614	1.085	1.1984	1.1022	1.2498
4	1.0774	1.1174	1.2631	1.3904	1.4842
5	1.1934	1.4899	1.3603	1.989	1.7185
6	1.6244	1.668	1.9109	1.8482	2.0309
7	2.0553	1.9595	.3401	2.4697	2.0309
8	2.1862	2.251	.2652	2.5943	2.3482
9	2.0405	.081	.2652	2.4291	
10		.0648			
16	.1134	.1457	.1341		.1326
17	.1943		.2683	.1781	.1696
18	.1781	.2105	.2652	.2753	.1966
19	.2753	.2267	.2984	.2267	.253
20	.3077	.2915	.3222	.3239	.2846
21	.2753	.2915	.3018	.3077	.2846
22	.2267	.2753	.2818	.2915	.2688
23	.2105	.2753	.2543	.2591	.253
24	.779	.7449	.7773	.7956	.8124
Max	2.1862	2.251	1.9109	2.5943	2.3482
Min	.1134	.0648	.1341	.1781	.1326
Avg	.8550	.7962	.6595	1.0762	.9100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 241 / 11 KV Shirbhavi feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2136	.3018	.3239	.2503	.3018	.2915	.1743
2	.2136	.285	.3239	.2503	.285	.2915	.1859
3	.2248	.3018	.3239	.2643	.2683	.2915	.1976
4	.2248	.3353	.3563	.2643	.3018	.3239	.2092
5	.2361	.3353	.3887	.2782	.3353	.3563	.2208
6	.3035	.4024	.4534	.3668	.4024	.421	.3041
7	.3788	.4024	.3887	.3521	.4359	.4534	.5415
8	.3382	.3688	.3239	.3227	.3688	.3239	.3547
9	.3018	.2683	.1219	.3185	.2683	.2915	.3018
10	.2012	.3239	.2968	.2683	.2591	.1097	.2683
11	.5868	1.2955	1.186	1.5089	.9717	.9907	
12	2.4143	2.17	1.866	2.079	1.8623	1.829	1.4251
13	2.146	1.9757	1.6288	2.0119	1.7004	1.7328	1.5424
14		1.7814	1.5181	1.7436		1.5384	1.8107
15		1.6842	1.0595	1.7101	1.1984	1.0202	2.3472
16		1.749		1.6766	1.3279	1.4089	1.5089
17	2.5149	1.7814	1.8564	2.1795	1.587		1.9113
18	2.3472	1.7166	1.8724	1.643	1.7814		1.8778
19	.3353	.4049	.2347	.4359	.3563		.3353
20	.4024	.4534	.2585	.4359	.3887	.2441	.4024
21	.4024	.3887	.2361	.3353	.3239	.2208	.3353
22	.3353	.3239	.2023	.3018	.2915	.1886	.3018
23		.3239	.2473	.3018	.2915	.1715	.3018
24	.2136	.3018	.3239	.2503	.3018	.2915	.1627
Max	2.5149	2.17	1.8724	2.1795	1.8623	1.829	2.3472
Min	.2012	.2683	.1219	.2503	.2591	.1097	.1627
Avg	.7167	.8198	.6866	.8146	.6787	.6091	.7400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 242 / 11KV Dhyati Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683		.1619	.1886	.2012	.1943	.2267
2	.285		.1619	.2058	.2347	.1943	.2429
3	.285		.1619	.2058	.2347	.1943	.2591
4	.3018		.1619	.2229	.2683	.2267	.2753
5	.3185		.1943	.2401	.3018	.2591	.2915
6	.2515		.2267	.2401	.3353	.2915	.3239
7	.4024		.2591	.2713	.3688	.2591	.2281
8	.5533		.2591	.3052	.3018	.2267	.1412
9	.3521		.1894	.3353	.2683	.1943	.285
10		.1943	.1894	.2012	.2267	.1486	.2012
11	.4191		.1143	.3353	.4534	.1486	.3353
12	.8383		.3544	.6706	.9393	.3957	.7545
13	.9221		.3658	.8383	.9069	.3957	.8383
14		.6478	.3772	.7545	.8745	.3319	.7545
15		.6154	.3658	.9221	.7449	.3702	.9221
16		.6154	.3544	.9221	.7449	.4085	.9221
17		.6154	.5197	.8383	.8097	1.0688	1.0059
18		.583	.4344	.8383	.9717	1.0688	1.0059
19		.1296	.1715	.3018	.2591	.3239	.2683
20		.2591	.1715	.3353	.2915	.2591	.3353
21		.1943	.1943	.2347	.2591	.2267	.2683
22		.1943	.1829	.2347	.2591	.2267	.2683
23		.1943	.1829	.2347	.2267	.2753	.2683
24	.2683		.1943	.1886	.2347	.1943	.2743
Max	.9221	.6478	.5197	.9221	.9717	1.0688	1.0059
Min	.2515	.1296	.1143	.1886	.2012	.1486	.1412
Avg	.4204	.3857	.2479	.4194	.4465	.3285	.4457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 243 / 11 KV Haldahiwadi feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0395	.9221	1.0364	.9556	1.0898	1.004	1.1065
2	1.1233	1.0059	1.0364	1.0898	1.1736	1.0364	1.2071
3	1.2071	1.0059	1.0688	1.2071	1.2574	1.2308	1.3077
4	1.291	1.073	1.1012	1.3413	1.2742	1.3279	1.4251
5	1.3748	1.1736	1.2308	1.4754	1.4754	1.5546	1.5257
6	1.7101	1.643	1.6518	1.7436	1.7436	1.9433	1.643
7	2.0454	2.1795	1.8461	2.1795	2.079	2.17	2.079
8	1.9448	2.4143	2.2348	2.3472	2.3472	2.1052	2.2131
9	1.8442	1.9784	2.4143	2.1795	1.2742	1.9433	2.146
10	.2012	.1943	.2012		.2267	.3688	.2683
11	.2012		.1677	.1677	.1943	.2683	.2012
12	.1341		.1677	.1677	.1943	.1677	.2012
13	.1341		.1677	.1341	.1943	.1341	.2012
14		.1619	.1677	.1677	.1619	.1341	.1677
15		.1296	.1677	.1677	.1619		.1677
16	.2012	.1943	.1677	.2347	.1943	.1677	.2012
17	.2012	.2267	.2347	.2683	.1943	.1677	.2347
18	.2347	.1943	.2347	.3018	.2267	.1677	.2683
19	.3353	.3239	.3688	.3688	.3563	.3018	.4024
20	.3688	.3887	.3688	.3688	.3887	.3688	.4359
21	.3353	.3239	.3353	.3688	.3563	.3688	.3688
22	.3018	.2915	.3018	.3353	.3239	.3353	.3353
23	.3018	.3239	.3018	.3353	.3239	.3353	.3353
24	.9724	.7545	.8745	.8383	.9221	.9393	1.0059
Max	2.0454	2.4143	2.4143	2.3472	2.3472	2.17	2.2131
Min	.1341	.1296	.1677	.1341	.1619	.1341	.1677
Avg	.7956	.8049	.7437	.8150	.7556	.8061	.8103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 244 / Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.3018	.2915	.2012	.3018	.3563	.2683
2	.2347	.3018	.2915	.2012	.3018	.3563	.2683
3	.2347	.3353	.2915	.2012	.3353	.3563	.2683
4	.3018	.3353	.2915	.2683	.3688	.3563	.3353
5	.3688	.3688	.3239	.3353	.4024	.421	.4024
6	.4359	.4694	.3887	.4024	.4694	.4534	.4694
7	.3688	.4694	.421	.3688	.503	.3887	.4359
8	.3018	.4024	.3887	.3353	.4024	.3563	.4024
9	.2683	.3688	.3688	.3018	.4024	.3239	.3688
10	.2347	.2915	.3353	.2683	.3239	.3018	.3353
11	.2347	.2591	.3018	.2347	.2915	.2683	.2683
12	.2012	.2267		.2012	.2267	.2347	.2347
13	.1677	.1943		.1677	.1943	.2012	.2347
14		.1619		.1677	.1619	.1677	.2012
15		.1619	.2012	.1677	.1619	.1341	.218
16		.1619	.1677	.2012	.1943	.1341	.2347
17	.2347	.1943	.2347	.2012	.2267		.2683
18	.2683	.2591	.3018	.3018	.2915		.3018
19	.4024	.3887	.3353	.4359	.421		.4024
20	.4694	.4858	.3688	.4527	.4858	.2347	.4694
21	.4024	.421	.3018	.4359	.4534	.3018	.4191
22	.3688	.3887	.3018	.3688	.421	.3688	.3688
23	.3353	.3563	.2683	.3353	.3887	.3353	.3353
24	.2683	.3018	.3239	.2347	.3353	.3563	.3018
Max	.4694	.4858	.421	.4527	.503	.4534	.4694
Min	.1677	.1619	.1677	.1677	.1619	.1341	.2012
Avg	.3018	.3169	.3095	.2829	.3361	.3051	.3255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 245 / Devkatewadi feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5197	.8383	.9069	.7712	1.0395	.8421	.8886
2	.4359	.9221	.9393	.8718	1.1065	.8421	1.0059
3	.3521	1.0059	.9717	.9724	1.1736	.8745	1.1233
4	.4191	1.0059	1.166	1.073	1.1736	1.1336	1.2407
5	1.0059	1.1065	1.4251	1.1736	1.2071	1.3927	1.358
6	1.5424	1.6095	1.5223	1.4754	1.2071	1.7814	1.4754
7	2.2131	2.0119	1.6194	2.0454	1.9448	2.0081	1.9784
8	2.4143	2.079	1.8461	2.1293	2.146	2.0729	2.2801
9	2.0957	2.079	1.9784	1.9616	2.079	2.1376	2.0622
10	.2347	.2267	.2347	.2012	.2267	.2012	.2683
11	.2012	.1943	.2012	.1677	.2267	.1677	.2012
12	.1677	.1619	.1844	.1677	.1943	.1677	.2012
13	.1677	.1296	.1677	.1341	.1619	.1509	.1677
14		.1296	.1509	.1341	.1619	.1677	.1677
15		.1619	.1509	.1677	.1619	.1677	.1677
16		.1619		.2012	.1619	.1677	.1677
17	.2012	.1943		.2347			.2012
18	.2347	.1943	.2515	.3353	.2267		.2012
19	.4024	.3563	.4024	.4694	.3563		.3353
20	.4359	.421	.4359	.4694	.4372	.4862	.4359
21	.4024	.3401	.3688	.4024	.3725	.4527	.4024
22	.3353	.3239	.3353	.3353	.3239	.3856	.3353
23	.3018	.3239	.3353	.3353	.3239	.3521	.3353
24	.6036		.7611	.6874	.6371	.7125	.788
Max	2.4143	2.079	1.9784	2.1293	2.146	2.1376	2.2801
Min	.1677	.1296	.1509	.1341	.1619	.1509	.1677
Avg	.6994	.6947	.7434	.7049	.7413	.7936	.7412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274065 / 33/11KV SHIRBHAVI S/STN.

Feeder No / Name : 246 / 11KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.0335	.0972	.0671	.0335	.0972	.0335
2	.1677	.0335	.0972	.1006	.0335	.0972	.0335
3	.1677	.0335	.0972	.1341	.0335	.0972	.0335
4	.1677	.0335	.0972	.1677	.0335	.0972	.0335
5	.1677	.0335	.1296	.2012	.0335	.1943	.0335
6	.2012	.0335	.1943	.2347	.0335	.3239	.0335
7	.2683	.0335	.3277	.2347	.0335	.3563	.0335
8	.2683	.1677	.3239	.2374	.0335	.421	.0335
9	.2683	.2012	.2683	.2347	.0335	.421	.0335
10	.2683	.1943	.2347	.2012	.1943	.3688	.0335
11	.2347		.2683	.2347	.1943	.0335	.0335
12	.2012	.1943	.2683	.1006	.1943	.3018	.1677
13	.2347	.1619	.2683	.1006	.1943	.3353	.1677
14		.1619	.3018	.1006	.1619	.0335	.0335
15		.1619	.0335	.0335	.1638	.0335	.0335
16	.2439	.1619	.0335	.0335	.1619	.0335	.2012
17	.3353	.1943	.0335	.0335	.1619	.0335	.2012
18	.3353	.1943	.0335	.0335	.1619	.0335	.2012
19	.1509	.0324	.0335	.0335	.0324	.0335	.1677
20	.1341	.0324	.0335	.0335	.0324	.0335	.1677
21	.0671	.0324	.0335	.0335	.0324	.0335	.1341
22	.0335	.0324	.0335	.0335	.0324	.0335	
23	.0335	.0324	.0335	.0335	.0324	.0335	.1341
24	.1677	.0335	.1296	.0335	.0335	.0324	.0335
Max	.3353	.2012	.3277	.2374	.1943	.421	.2012
Min	.0335	.0324	.0335	.0335	.0324	.0324	.0335
Avg	.1948	.0967	.1419	.1119	.0869	.1463	.0875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 241 / 11 KV Manjari feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.021	.0335	.1677	.362	.3258	.1715
2	.0335	.0724	.0377	.1677	.5144	.2896	.0343
3	.0335	.0724	.0671	.2012	.5068	.2534	.1886
4	.0335	.0724	.0671	.2012	.543	.2534	.2195
5	.0671		.0671	.2347	.6516	.362	.2195
6	.0671	.0724	.0671	.2347	.3963	.4706	.2347
7	.0671	.0495	.0671	.3688	.5792	.4115	.4409
8	.0335	.0362	.0671	.4694	.543	.4706	.4694
9	.0362	.0362	.0671	.4748	.4344	.4359	.4024
10	.0362	.0335	.0335	.0328	.0362	.0335	.0335
11	.2401	.3353	.2347	.0328	.0362	.0335	.0335
12	.4801	.4359	.3018	.0328	.0362	.0335	.0335
13	.4706	.4527	.4024	.0328	.0362	.0335	.0335
14	.4115	.3658	.3688	.0328	.0724	.0335	.0335
15	.4115	.4024	.4024	.0328	.0724	.003	
16	.4115	.439	.3018	.0328	.0362	.0335	.0335
17		.439	.4024	.0328	.0362	.0335	.0335
18	.4706	.2477	.4024	.0328	.0362	.0335	.0335
19	.0724	.0362	.0335	.0328	.0362	.0377	.0671
20	.0724	.0762	.0671	.0328	.0724	.0686	.0671
21	.0686	.0754	.0335	.0328	.0724	.0762	.0335
22	.0724	.0671	.0335	.0328	.0724	.0754	.0671
23	.0724	.0678	.0335	.0328	.0724	.0671	.0335
24	.0335	.0362	.0671	.1677	.2172	.3258	.1677
Max	.4801	.4527	.4024	.4748	.6516	.4706	.4694
Min	.0335	.021	.0335	.0328	.0362	.003	.0335
Avg	.1621	.1714	.1525	.1311	.2280	.1748	.1341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 242 / 11 KV Bamni feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.1086	.0671	.3353	.724	.6878	.4409
2	.1006	.1086	.0671	.3688	.8326	.724	.4359
3	.1006	.1086	.1006	.4024	.905	.7964	.503
4	.1341	.1086	.1006	.4359	1.267	.905	.5365
5	.1341	.1448	.1006	.4694	1.3032	1.086	.6371
6	.1677	.1448	.1341	.4694	1.1222	1.086	.7461
7	.1341	.1448	.1341	.8048	1.086	1.0498	.9389
8	.1006	.1086	.1006	.9724	1.1222	1.086	1.1191
9	.1086	.0724	.0671	1.0159	1.1584	1.1401	1.0059
10	.362	.0671	.0671	.0655	.0362	.0671	.1006
11	.362	.503	.6371	.0983	.0724	.0671	.0671
12	1.2346	.9389	.9724	.0983	.1086	.0671	.0671
13	1.166	.9945	.9389	.0983	.1086	.0671	.0671
14		.9724	.9724	.0983	.1448	.0671	.0671
15	1.1222	.9389		.0983	.1448	.0678	.0671
16	1.0974	.9054	.9724	.0983	.1448	.1341	.0671
17	1.1946	.9054	1.073	.0983	.1086	.1677	.1006
18	1.1584	.9054	.9389	.0983	.1086	.1341	.1341
19	.1086	.0671	.1006	.0983	.1086	.1006	.1006
20	.0743	.1017	.1341	.0983	.1372		.1341
21	.1086	.1006	.1006	.0983	.1448	.1341	.1341
22	.1086		.1006	.0983	.0686	.1006	.1006
23	.1086	.1006	.0671	.0983	.0724	.1006	.1006
24	.1006	.0724	.1017	.3353	.4706	.3982	.407
Max	1.2346	.9945	1.073	1.0159	1.3032	1.1401	1.1191
Min	.0743	.0671	.0671	.0655	.0362	.0671	.0671
Avg	.4082	.3749	.3499	.2897	.4792	.4450	.3366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 243 / 11 KV Sangewadi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359	.9412	.4359	.1341	.1448	.2172	.1341
2	.4694	1.0136	.4694	.1677	.1448	.2172	.1341
3	.503	1.0288	.503	.1677	.1448	.2172	.1341
4	.57	1.1946	.5365	.1341	.181	.2534	.1696
5	.6036	1.448	.6706	.2347	.181	.2534	.1677
6	.8048	1.4842	.8817	.2012	.181	.2534	.2058
7	1.643	1.7737	1.4419	.2012	.181	.2172	.1829
8	1.7101	1.8823	1.7101	.1677	.1448	.2172	.1463
9	1.5089	1.7101	1.7101	.0983	.1086	.1677	.1341
10	.1715	.0671	.1341	.0983	.1448	.1677	.1006
11	.1448	.0671	.0671	.9831	.543	.5365	.7042
12		.0625	.1006	1.0814	1.5927	1.1736	.7712
13		.0671	.1006	1.1469	1.6289	1.3413	1.2407
14	.1448		.1006	1.3108	1.4842	1.4251	1.3748
15	.1372		.1006	.8192	1.4118	1.4251	1.4419
16	.1086	.0671	.0671	.9831	1.448	1.5089	1.4419
17	.1029	.1006	.1006	1.3763	1.5203	1.5402	1.576
18	.181	.1006	.1006	1.4746	1.5203	1.576	1.7101
19	.2172	.1696	.2012	.1311	.181	.1677	.1677
20	.2534	.1677	.2012	.1311	.2534	.2012	.2012
21	.2534	.1696	.1677	.1311	.2534	.1677	.1677
22	.2534	.1677	.1677	.1311	.2534	.1677	.1677
23	.2534	.1677	.1341	.1357	.2614	.1357	.1677
24	.4024	.543	.4359	.1341	.1448	.2172	.1341
Max	1.7101	1.8823	1.7101	1.4746	1.6289	1.576	1.7101
Min	.1029	.0625	.0671	.0983	.1086	.1357	.1006
Avg	.4942	.6543	.4391	.4823	.5856	.5736	.5323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 244 / 11 KV Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.421	.4024	.3688	.4344	.4706	.4024
2	.4359	.543	.439	.3688	.543	.5068	.0328
3	.4694	.5792	.439	.4359	.5792	.543	.4359
4	.5365	.724	.543	.4694	.724	.6516	.5087
5	.6036	.8326	.6371	.503	.8573	.905	.6036
6	1.0059	.8097	.8383	.8718	.9412	.9774	.8139
7	.9054	.8688	.7377	.9054	.724	.9412	.8718
8	.57	.5068	.6036	.6371	.543	.7602	.57
9	.5487	.4344	.503	.5571	.4706	.4801	.3688
10	.4458	.3353	.4024	.4915	.4344	.4458	.4694
11	.3772	.3185	.3688	.3605	.3982	.4024	.3688
12		.3018		.3605	.362	.2713	.2683
13		.2683	.2683	.3277	.3982	.2347	.2683
14	.362		.3018	.3052	.4344	.2347	.2683
15	.3439		.3018	.2949	.4344	.2347	.3018
16	.3772	.2347	.3018	.3932	.4706	.2926	.3018
17	.4115	.3018	.3353	.426	.5068	.3018	.3353
18	.4801	.3688	.4694	.4588	.5792	.3353	.3688
19	.6878	.6371	.8048	.4588	.6516	.6539	.6706
20	.7964	.7042	.8718	.4915	.6878	.6371	.8383
21	.7202	.7545	.7712	.426	.7602	.57	.8048
22	.6516	.57	.6371	.3932	.6878	.503	.57
23	.543	.4024	.4694	.3932	.4706	.4024	.4694
24	.3688	.4534	.3688	.4024	.4344	.3982	.4024
Max	1.0059	.8688	.8718	.9054	.9412	.9774	.8718
Min	.3439	.2347	.2683	.2949	.362	.2347	.0328
Avg	.5474	.5168	.5137	.4625	.5636	.5064	.4714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 245 / 11 KV DEVALE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9602	.5243		.2534	.2172	.2561
2	.8718	.8745	.5792	.2012	.2534	.2172	.2347
3	.9054	.9393	.7095	.2347	.2534	.2172	.3185
4	.9389	1.086	.6706	.2347	.2896	.2172	.2374
5	.9724	1.5203	.8383	.2683	.2896	.2534	.2683
6	1.073	1.4251	1.0059	.2683	.2896	.2534	.3018
7	1.2407	1.2955	1.4754	.2347	.2896	.2172	.2652
8	1.4419	1.4842	1.5729	.2347	.2172	.2172	.2012
9	1.6651	1.5927	1.3748	.1638	.181	.2012	.2012
10	.1448	.1174	.1341	.1638	.181	.2012	.1677
11	.1372	.1006	.1006	1.0159	.6516	.426	1.1065
12		.0671		1.1469	1.8461	1.3748	1.3413
13	.1448	.0671	.1006	1.3108	1.8099	1.5424	1.7772
14	.1029		.1341	1.3763	1.8099	1.5089	1.6766
15	.1372		.1341	1.3108	1.8823	1.5089	1.7772
16	.1448	.0983	.1341	1.4746	1.8461	1.576	1.7101
17	.1372	.1677	.1677	1.6385	1.5565	1.6766	1.8107
18	.1715	.2012	.1677	1.704	1.7737	1.7772	1.7772
19	.2058	.2012	.2683	.1638	.2172	.285	.2683
20	.2401	.2347	.2683	.1966	.2172	.2683	.2683
21	.2401	.2347	.2347	.1966	.2534	.2439	.2347
22	.2534	.2347	.2347	.2294	.2534	.2347	.2347
23	.2172	.2347	.2347	.2294	.2172	.2515	.2347
24	.8048	.6878	.4915	.2347	.2534	.2172	.2347
Max	1.6651	1.5927	1.5729	1.704	1.8823	1.7772	1.8107
Min	.1029	.0671	.1006	.1638	.181	.2012	.1677
Avg	.5665	.6284	.5024	.6188	.7119	.6293	.7043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 246 / 11 KV Save Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359	.4458	.3688	.3688	.4706	.5249	.373
2	.4694	.5068	.3688	.3521	.543	.5068	.4024
3	.503	.5792	.4359	.4359	.724	.5792	.4359
4	.57	.543	.503	.4694	.905	.543	.503
5	.6539	.6516	.6036	.5365	.9412	.8688	.6036
6	.8718	.6478	.8383	.8718	.905	.905	.8383
7	.7377	.905	.7209	.9054	.8326	.8326	.7926
8	.4694	.543	.4752	.5197	.5068	.6706	.5868
9	.362	.3801	.3353	.3441	.3801	.3688	.3688
10	.3429	.3353	.3856	.3277	.3258	.4024	.4024
11	.3439	.3018	.3353	.3605	.3439	.4359	.3353
12	.3258	.3688	.3521	.3605	.3429	.3353	.2683
13	.3429		.3353	.4915	.3258	.3018	.3521
14	.3439	.2515	.2347	.4915	.362	.3018	.3353
15	.3258	.3353		.3441	.3982	.3086	.3521
16	.3772	.4024	.4024	.3277	.4163	.2713	.3856
17	.4458	.4096	.3688	.4588	.4706	.4024	.4191
18	.5144	.4527	.4191	.4752	.543	.503	.4694
19	.6173	.4917	.5868	.4915	.6878	.57	.7042
20	.6878	.5365	.5533	.3932	.7602	.6036	.6371
21	.5658	.5197	.5197	.426	.6878	.5365	.6539
22	.5228	.4694	.4527	.4588	.543	.4359	.5197
23	.4344	.4024	.4024	.4915	.5068	.3521	.4191
24	.4024	.3982	.3688	.3856	.4163	.4706	.3856
Max	.8718	.905	.8383	.9054	.9412	.905	.8383
Min	.3258	.2515	.2347	.3277	.3258	.2713	.2683
Avg	.4861	.4729	.4507	.4620	.5558	.5013	.4810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274069 / 33/11 KV MANJARI S/S

Feeder No / Name : 247 / 11 KV Save AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.2058	.1966	.6371	1.267	1.1488	.7377
2	.2012	.2172	.218	.6706	1.3756	1.3032	.7377
3	.2012	.2534	.218	.7042	1.8099	1.3756	.8048
4	.2347	.2534	.2683	.8383	1.9909	1.3717	.9156
5	.2683		.3018	.9054	1.8461	1.8099	1.0059
6	.3353	.3258	.3113	1.0898	1.8861	1.9909	1.5261
7	.3353	.3439	.3018	1.8107	2.0576	2.0814	2.0348
8	.2012	.2353	.2012	1.9616	2.2081	2.1719	2.0919
9	.2172	.1629	.1509	1.8023	2.1176	2.0856	1.8778
10	.1629	.1509	.1677	.0983	.181	.1341	.1844
11	1.1584	.8383	1.5089	.0983	.1629	.1174	.1006
12	1.8519	1.5424	1.8778	.0983	.181	.1341	.1509
13	2.0405	1.5939	1.8945	.1311	.1629	.1357	.1006
14	2.0576	1.6095	1.6598	.1147		.1341	.1174
15	1.8861	1.7604		.1311	.1086	.1357	.1341
16	1.8176	1.8652	1.6598	.1475	.1448	.1341	.1006
17	2.2081	1.9281	2.0119	.1638	.2353	.1341	.1341
18	2.1719	2.0119	1.8275	.1802		.1646	.1677
19	.1991	.218	.2012	.1802	.2534	.2743	.285
20	.2172	.2515	.2347	.1966	.2353	.2515	.3353
21	.2229	.2374	.2012	.2294	.2172	.2347	.2683
22		.2347	.1844	.2458	.2353	.2012	.2012
23	.2172	.2012	.1844	.2622	.2534	.1844	.218
24	.1844	.1991	.1966	.6371	.724	.724	.7209
Max	2.2081	2.0119	2.0119	1.9616	2.2081	2.1719	2.0919
Min	.1629	.1509	.1509	.0983	.1086	.1174	.1006
Avg	.8076	.7235	.6947	.5556	.8934	.7680	.6230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 242 / 11 KV Alegaon Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	1.5242	1.1431	.9717	1.448
2	.6097	.6478	1.5242	1.2193	1.1336	1.5242
3	.7621	.8097	1.6766	1.448	1.4575	1.5242
4	1.0669	1.0526	1.6766	1.5242	1.5242	1.6766
5		1.6194	1.9052	1.829	2.1052	1.9814
6	1.829	2.2672	2.1338	1.9814	2.3482	2.1338
7	2.1338	2.915	2.21	2.2862	2.4291	2.2862
8	2.2862	2.834	2.7435	2.6673	2.753	2.6673
9	2.2862	.1524	2.8197	2.2862	2.5911	2.7435
10	.1134	.1524	.1619	.1134	.1067	.1619
11	.1134	.1524	.1619	.1134	.1067	.1619
12	.1134	.1524	.1619	.1134	.1067	.1619
13	.1134	.1524	.1619	.1134	.1067	.1619
14	.1134	.1524	.1619	.1134	.1067	.1619
15	.1134	.1524	.1619	.1134	.1067	
16		.1524	.1619	.1134	.1067	.1619
17		.1524	.1619	.1134	.1067	
18		.1524	.1619	.1134	.1067	
19		.1524	.1619	.1134	.1524	.1619
20		.1524	.1619	.1134	.1524	.1619
21		.1524	.1619	.1134	.1524	.1619
22		.1524	.1619		.1524	.1619
23		.1524			.1524	.1619
24	.6478	.8097	1.2955	.9145	.7287	1.1431
Max	2.2862	2.915	2.8197	2.6673	2.753	2.7435
Min	.1134	.1524	.1619	.1134	.1067	.1619
Avg	.8608	.6621	.9397	.8482	.8235	.9957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 243 / 11 KV Medshingi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18
HR	Load (MW)
17	.1134
18	.1134
19	.1134
20	.1134
21	.1134
22	.1134
23	.1134
Max	.1134
Min	.1134
Avg	.1134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274110 / 33/11 KV ALEGAON S/S

Feeder No / Name : 245 / Wanichanchale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2286	.3239	.2429	.2286	.3239
2	.2429	.1677	.3239	.2429	.2286	.3239
3	.2429	.1524	.3239	.3239	.3048	.3239
4	.2429	.1524	.3239	.3239	.3048	.3239
5	.2915	.1981	.3239	.3239	.3048	.3239
6	.2915	.3048	.3239	.4049	.381	.3239
7	.4534	.381	.3239	.4049	.381	.3239
8	.4049	.3353	.3239	.4049	.381	.3239
9	.2267	.3048	.2429	.2753	.3048	.3239
10	.2591	1.3717	.2429	.2267	.9145	.3239
11	1.0669	1.6194	.5335	.6097	.9907	.6097
12	1.2955	1.7814	1.5242	1.9052	1.2955	1.3717
13	1.448	2.1052	1.9052	2.2862	1.448	1.5242
14	1.6766	2.2672	1.9814	2.4387	1.5242	1.829
15	2.0576	2.5911	1.9814	2.5149	1.5242	1.6766
16	2.1338	2.2672	2.0576	2.2862	1.5242	1.7528
17	2.2862	1.9433	2.0576	2.1338	1.6766	1.829
18	1.9814	1.7814	1.9052	1.9052	1.829	1.9052
19	.3725		.381	.4049	.3048	.4049
20	.421	.3239	.4049	.4372	.3048	.4049
21	.3725	.3239	.3239	.3725	.3048	.3239
22	.3239	.3239			.3048	.3239
23	.3077	.3239	.2429		.3048	.3239
24	.2429	.2743	.3239	.2429	.2286	.3239
Max	2.2862	2.5911	2.0576	2.5149	1.829	1.9052
Min	.2267	.1524	.2429	.2267	.2286	.3239
Avg	.7869	.9358	.8130	.9414	.7208	.7434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 241 / 11 KV Gaigavan Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)
8	1.2498	1.0364
9	1.1888	1.0669
12		.1715
13		.1372
14		.1524
15		.1905
16	.1715	.1905
Max	1.2498	1.0669
Min	.1715	.1372
Avg	.8700	.4208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 242 / 11 KV Khilarwadi Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	23-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.2572	.2743	.3506
9	.2229	.2134	.3658
12			1.7375
13			1.7833
14			1.9113
15			2.0748
16		1.7985	1.7101
17	1.6309		
Max	1.6309	1.7985	2.0748
Min	.2229	.2134	.3506
Avg	.7037	.7621	1.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 243 / 11 KV Dhalewadi Feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	23-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	1.4022	1.4632	1.6309
9	1.2193	1.3108	1.5242
12			.0857
13			.1029
14			.1132
15			.1132
16	.1715	.0857	.132
Max	1.4022	1.4632	1.6309
Min	.1715	.0857	.0857
Avg	.931	.9532	.5289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274137 / 33/11 kv Gaigavan sub
stationFeeder No / Name : 244 / 11kv gaighavan gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1067						
7	.1181						
8	.141	.1524	.1105				
9	.0953	.1372	.1105	.0495	.141	.0953	.16
10		.1334		.1105	.141	.1257	.1029
11				.1181	.0876	.0648	.0648
12			.0838	.1257	.1143	.0724	.0724
13			.0572	.0991	.1105	.0686	.0762
14			.0057	.0724	.0838	.061	.0838
15			.0679	.0953	.1067	.0724	.1296
16	.0876	.1296	.0754	.1143	.0953	.0838	.16
17			.0914	.1143	.1029	.0914	.1524
20			.1105	.1791	.0914	.1334	.1715
23			.08	.16	.1143	.1334	.1524
24	.0914						
Max	.141	.1524	.1105	.1791	.141	.1334	.1715
Min	.0876	.1296	.0057	.0495	.0838	.061	.0648
Avg	.1067	.1382	.0793	.1126	.1081	.0911	.1205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 241 / Chopadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1457	.1715	.1543	.1715	.1543	.1886
2	.1715	.1543	.1886	.1543	.1715	.1543	.1715
3	.2058	.1886	.2058	.1715	.2058	.1886	.1886
4	.2058	.1943	.2229	.2058	.2229	.2229	.2058
5	.2401	.2267	.2743	.2401	.2401	.2743	.2572
6	.3258	.2915	.3258	.3086	.2915	.3258	.3086
7	.3086	.2915	.3086	.3429	.3258	.3429	.2743
8	.2915	.2401	.2743	.2915	.2915	.2401	.2572
9	.2743	.1886	.2743	.2743	.2743	.2572	.2743
10	.2401	.1715	.2915	.2572	.2915	.2572	.2572
11	.2401		.2915	.2058	.2572	.2401	.2401
12	.2572	.2229	.2572	.1886	.2058	.1886	.2058
13	.2058	.2572	.2401	.1715	.2058	.1715	.1886
14	.1886	.2229	.2058	.1886	.2229	.1886	.2058
15	.2058	.2229	.1886	.1715	.2058	.1886	.2058
16	.2401	.2058	.1886	.2058	.2058	.1886	.1886
17	.2058	.2572	.2229	.2401	.2229	.2229	.2401
18	.2229	.2743	.2401	.12	.2572	.2229	.2401
19	.3086	.3601	.3086	.3429	.3429	.3086	.3258
20	.3429	.3944	.3601	.3772	.3601	.3772	.3944
21	.2743	.3086	.2743	.2915	.3086	.3086	.3258
22	.2401	.2572	.2572	.2743	.2572	.2743	.2915
23	.1715	.2229	.2229	.2229	.2401	.2401	.2401
24	.2058	.1543	.2229	.1715	.1886	.1886	.2229
Max	.3429	.3944	.3601	.3772	.3601	.3772	.3944
Min	.1715	.1457	.1715	.12	.1715	.1543	.1715
Avg	.2401	.2371	.2508	.2322	.2486	.2386	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 242 / balwadi feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.8421	.9231	.9878	.3563	.2915	.3239
2	.8745	.8907	1.004	1.0526	.3239	.3077	.3401
3	.9069	.9878	1.1012	1.1336	.3725	.3239	.3563
4	1.004	1.1336	1.2146	1.2308	.4049	.3725	.421
5	1.1174	1.2631	1.3279	1.3441	.4372	.4858	.4534
6	1.1822	1.3603	1.4413	1.4413	.5668	.5668	.502
7	1.7814	1.749	1.8138	1.6842	.5344	.5344	.5182
8	1.7976	1.7976	1.8785	1.8138	.4372	.3725	.3725
9	1.5546	.2753	1.4251	1.4899	.4858	.3239	.3239
10	.2591	.2591	.3725	.3401	.3725	.3725	.3887
11	.2591		.2753	.2915	1.3765	1.3279	1.166
12	.3239	.3077	.3725	.3077		2.17	2.0243
13	.3563	.2591	.2915	.3401	2.3158	2.0081	2.1052
14	.2915	.3401	.3239	.3401	2.3644	1.9919	1.9919
15	.3887	.3563	.3239	.3077	2.332	2.0891	2.0081
16	.2591	.2429	.2915	.3077	2.2834	2.1862	2.0567
17	.3887	.3887	.3725	.3725	2.4777	2.2348	2.2672
18	.3077	.3401	.3563	.2753	2.4939	2.1862	1.9109
19	.4858	.4696	.3563	.4372	.5344	.5344	.4696
20	.583	.5668	.5344	.5506	.5992	.5182	.5668
21	.502		.4696	.4372	.502	.5506	.4858
22	.4696	.421	.4372	.4372	.4372	.4858	.4696
23	.3887	.3725	.3887	.4049	.421	.4049	.4049
24	.7449	.8259	.8583	.9393	.3563	.3077	.3563
Max	1.7976	1.7976	1.8785	1.8138	2.4939	2.2348	2.2672
Min	.2591	.2429	.2753	.2753	.3239	.2915	.3239
Avg	.7099	.7022	.7564	.7611	.9907	.9561	.9285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 243 / BANDGARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.1134	.0972	.1134	.2429	.2591	.3077
2	.1457	.1457	.1296	.1457	.2753	.3077	.3401
3	.1619	.1619	.1457	.1781	.3077	.3401	.3887
4	.1943	.1781	.1781	.1943	.3401	.4049	.4372
5	.2429	.2267	.2267	.2267	.3887	.4696	.5182
6	.2753	.2591	.2591	.2753	.4534	.5668	.5992
7	.2429	.2429	.2429	.2267	.6154	.7125	.6802
8	.1457	.1619	.1619	.1781	.6316	.9069	.7611
9	.1134	.1296	.1134	.1457	.6316	.8097	.6478
10	.0972	.1134	.0972	.0972	.0648	.0972	.081
11	.4534		.2753	.3887	.0648	.0972	.0648
12	.7287	.3077	.4858	.6316	.0648	.081	.1134
13	.7449	.6802	.5992	.5992	.0486	.0648	.0972
14	.7287	.502	.5344	.6478	.0648	.0648	.081
15	.6802	.5668	.5668	.6316	.0486	.0972	.1134
16	.6964	.3077	.583	.7287	.081	.1134	.0972
17	.7773	.5668	.6964	.6316	.0648	.081	.0648
18	.7287	.6316	.583	.2429	.081	.0972	.0648
19	.1457	.1619	.1457	.1619	.1943	.1619	.1457
20	.1943	.2267	.2105	.1943	.1781	.2105	.1943
21	.1457	.1781	.1457	.1457	.1457	.1781	.1619
22	.1134	.1296	.1296	.1296	.1457	.1296	.1296
23	.1134	.1134	.1134	.1134	.1296	.1296	.1296
24	.1134	.1134	.1134	.1134	.2429	.2591	.3077
Max	.7773	.6802	.6964	.7287	.6316	.9069	.7611
Min	.0972	.1134	.0972	.0972	.0486	.0648	.0648
Avg	.3387	.2704	.2848	.2976	.2294	.2767	.2719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274166 / 33/11 KV Chopadi Sub-Station

Feeder No / Name : 244 / chopadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.1781	.1781	.1781	.502	.4858	.5992
2	.2267	.2105	.1943	.1943	.5182	.5182	.6316
3	.2753	.2429	.2267	.2429	.5506	.5668	.6478
4	.3401	.2915	.3077	.2753	.5992	.6478	.6802
5	.421	.3887	.3887	.3401	.6478	.7773	.7449
6	.4696	.4534	.4696	.4049	.7611	.8745	.8583
7	.3887	.4372	.3401	.4049	.9393	1.0202	1.1498
8	.2429	.2429	.2429	.3077	1.2631	1.1498	1.1822
9	.1619	.1457	.1781	.1619	1.1498	1.0526	1.0364
10	.1134	.1134	.1457	.1296	.1134	.1296	.1619
11	.6154		.6478	.7125	.1296	.0972	.1619
12	1.2631	.583	.9878	.9069	.1134	.1134	.1457
13	1.2793	1.1012	.9717	.9717	.1134	.1457	.1457
14	1.2793	1.0688	.9069	.8745	.1296	.1134	.1619
15	1.1174	1.1012	.8907	.8745	.1134	.1296	.1296
16	1.1336	.421	.9878	.9878	.1619	.1296	.1457
17	.9878	.9717	.9231	1.166	.1457	.1134	.1296
18	1.0364	.9555	1.1174	.3239	.1619	.1296	.1619
19	.2591	.2753	.2753	.2915	.2915	.3077	.2915
20	.3077	.3563	.3887	.3563	.3401	.3239	.3401
21	.2591	.2591	.2915	.3077	.2591	.2753	.3077
22	.2267	.2267	.2105	.2105	.2105	.2267	.2429
23	.1943	.1943	.1943	.2105	.1943	.1943	.2105
24	.1781	.1943	.1781	.1943	.5506	.4858	.6316
Max	1.2793	1.1012	1.1174	1.166	1.2631	1.1498	1.1822
Min	.1134	.1134	.1457	.1296	.1134	.0972	.1296
Avg	.5411	.4527	.4851	.4595	.4150	.4170	.4541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 241 / Wadegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029		.1372	.1029	.1372	.1029
2	.12	.1029	.1372	.1372	.1029	.1372	.1029
3	.12	.1029	.1372	.12	.1029	.12	.1029
4	.1715	.1372		.12	.1372	.12	.1715
5	.2058	.2058	.2058	.2058	.2058	.2058	.2058
6	.3258	.3086	.3086	.3086	.2915	.2915	.3258
7	.3429	.3258	.2915	.2743	.3258	.3258	.2401
8	.1886	.1715	.1715	.2058	.2058	.2058	.1715
9	.1372	.1715	.1372	.1715	.1543	.1372	.1372
10	.12	.1372		.12	.12	.12	.1029
11	.1029	.12	.1067	.1029	.0857	.1372	.12
12	.1029	.12	.12	.1029	.0857	.1029	.0762
13	.1029	.12	.12	.1029	.12	.1029	.0857
14	.1029	.1372	.12	.1029	.12	.1029	.0857
15	.1029	.12	.12	.1029	.12	.1029	.1372
16	.12	.12	.1372	.1029	.12	.1029	.1372
17	.1543	.12	.1372	.12	.12	.1543	.1372
18	.1543	.12	.1372	.1372	.1372	.1372	.1543
19	.2401	.2229	.2058	.2572	.1886	.1715	.2401
20	.2743	.2401	.2058	.2572	.2401	.2915	.2229
21	.2401	.1886	.1715	.2401	.2229	.1715	.1886
22	.1543	.1543	.1372	.1715	.1715	.1543	.1372
23	.12	.1372	.1372	.1372	.1372	.1372	.1372
24	.12	.12	.1372	.1219	.1029	.1372	.1029
Max	.3429	.3258	.3086	.3086	.3258	.3258	.3258
Min	.1029	.1029	.1067	.1029	.0857	.1029	.0762
Avg	.1643	.1586	.1610	.1608	.1550	.1586	.1511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 243 / DIGHEMALA FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3601	.3048	.3353	.3429	.3048	.3429
2	.3429	.3429	.3048	.3353	.3429	.3048	.3429
3	.3429	.3429	.3048	.3353	.3429	.3048	.3429
4	.3772	.4115	.3353	.3353	.3601	.3353	.3601
5	.4115	.4801	.4115	.3658	.463	.3963	.463
6	.5144	.5487	.5182	.4572	.583	.5792	.5658
7	.6001	.6173	.4725	.5792	.6001	.6097	.6344
8	.4458	.5487	.4115	.5792	.5487	.5944	.5487
9	.4801	.463	.3048	.4801	.3353	.3772	.4287
10	.4115	.3772		.3772	.3048		.3429
11		1.6289	.9907	1.3413	.6097	1.5242	.8535
12	2.7263	2.2253	2.2558	2.2558	2.1948	2.1338	2.2558
13	3.0178	2.3929	2.3624	2.2253	2.21	1.0974	2.1643
14	2.652	2.3777	2.3167	1.9966	2.21	1.8595	2.1033
15	2.6216	2.4234	2.3167	1.9814	2.2405	2.1491	2.1033
16	2.5758	2.4387	2.3167	2.332	2.1795	2.1643	2.1338
17	2.7435	2.4082	2.332	2.3015	2.3777	2.1795	2.3167
18	2.5758	1.9204	2.332	2.3015	1.9814	2.1948	2.1948
19	.3429	.3048	.3353	.3963	.3353	.3658	.3353
20	.4115	.4572	.4572	.4458	.4572	.4973	.4268
21	.4458	.3963	.4572	.4287	.3963	.4287	.3963
22	.3944	.3658	.4458	.3601	.3353	.3772	.3353
23	.3772	.3601	.3353	.3429	.3429	.3429	.3048
24	.3429	.3601	.3048	.3353	.3429	.3048	.3429
Max	3.0178	2.4387	2.3624	2.332	2.3777	2.1948	2.3167
Min	.3429	.3048	.3048	.3353	.3048	.3048	.3048
Avg	1.1086	1.0230	.9968	.9677	.9349	.9316	.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274169 / 33/11 KV Wadegaon Sub-
Station

Feeder No / Name : 244 / BURLEWADI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3429	.2743	.3506	.3658	.3353	.4115
2	.4115	.4287	.3048	.3506	.3658	.3353	.442
3	.442	.381	.3048	.3658	.381	.3353	.4725
4	.4877	.4877	.442	.4115	.4115	.3963	.5792
5	.5182	.6516	.5182	.7316	.4877	.5182	.6097
6	.6401	.6097	.7888	.7316	.7164		.8535
7	.7926	1.0364	.9907	1.1431	1.0822	1.2193	1.2041
8	.7926	1.0974	1.0669	1.0669	1.1888	1.2498	1.1584
9	.8078	1.0364	1.0212	1.1279	1.1736	1.1736	1.0669
10	.1219	.0914		.12	.0762	.0762	.0914
11	.1029	.0857	.0762	.1029	.0762	.0857	.0762
12	.0857	.0857	.0762	.0857	.0762	.0857	.0762
13	.1029	.0857	.0762	.0857	.0762	.0857	.0762
14	.1029	.0857	.0762	.0857		.0857	.0762
15	.1029	.0857	.0762	.0857		.0857	.0857
16	.1029	.0857	.0762	.0857		.0857	.0762
17	.1029	.0762	.0762	.0857		.0857	.0762
18	.1029	.0762	.0762	.0857	.0762	.0857	.0914
19	.1543	.1524	.1524	.1715	.1372	.1715	.1677
20	.2058	.1829	.1829	.2229	.1981	.2229	.1981
21	.2401	.1677	.2058	.1715	.1829	.1886	.1524
22	.1543	.1219	.1677	.1543	.1524	.1543	.1372
23	.1372	.1219	.1372	.1372	.1372	.1372	.1219
24	.3429	.3086	.2171	.2439	.2743	.3048	.3201
Max	.8078	1.0974	1.0669	1.1431	1.1888	1.2498	1.2041
Min	.0857	.0762	.0762	.0857	.0762	.0762	.0762
Avg	.3111	.3286	.3211	.3418	.3818	.3263	.3592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 241 / Akola SSTn Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.3429	.3772	.3772	.4287	.3601
2	.3086	.3429	.3429	.3772	.3772	.3944	.3429
3	.3429	.3601	.3601	.3601	.3944	.3944	.3601
4	.4287	.4458	.4458	.3601	.4458	.4801	.4115
5	.5658	.6173		.5144	.5316	.583	.5316
6	.8059	.8573	.8745	.7888	.8573	.8745	.7716
7	.7716	.823	.7888	.7888	.7716	.7202	.7373
8	.583	.5658	.6173	.6173	.5658	.4801	.4801
9	.463	.3944	.4458	.3944	.4458	.3772	.4115
10	.5144	.4287	.4115	.4458	.4287	.3944	.4458
11		.4458	.3772	.4115	.4115	.3772	.3944
12	.3258	.3429	.3601	.3944	.3772	.3601	.4115
13	.3944	.3086	.3429	.3944	.3601	.4287	.4287
14	.4287	.3086	.3429	.3772	.3601	.3429	.4458
15	.463	.3944	.3944	.3429	.3772	.3601	
16	.4287	.3772	.2743	.3429	.4115	.3772	
17	.3944	.3944	.3772	.3944	.4287	.3944	
18	.3772	.4115	.2743	.4115	.4458	.3772	.4458
19	.6344	.6001	.6344	.6173	.6173	.583	.6859
20	.703	.7202	.6173	.6516	.6687	.6173	.7202
21	.6173	.6001	.5487	.5487	.583	.583	.6516
22	.5144	.5144	.5144	.4973	.583	.4801	.5487
23	.4115	.4115	.463	.4458	.5487	.4115	.4801
24	.3429	.3429	.3772	.4115	.3944	.4801	.3944
Max	.8059	.8573	.8745	.7888	.8573	.8745	.7716
Min	.3086	.3086	.2743	.3429	.3601	.3429	.3429
Avg	.4838	.4730	.4577	.4694	.4901	.4708	.4981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 246 / DATT MANDIR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.2743	.2743	.2058	.7716	.823	.7716
2	.3601	.2743	.3086	.2058	.8059	.823	.7888
3	.3429	.3086	.3429	.2058	.8573	.9259	.823
4	.3086	.3429	.3601	.3258	.9259	1.0117	.9259
5	.4287	.4287	.4287	.4801	1.0288	1.1317	1.166
6	.6516	.6687	.5316		1.2517	1.1831	1.2517
7	.5487	.5487	.5487	.2229	1.8347	2.1434	2.2119
8	.3944	.3601	.3772	.1543	2.1091	2.2119	2.1262
9	.2572	.2572	.2572	.1715	1.7833	1.3032	1.989
10	.2058	.2058	.2401	.1372	.1372	.2058	.2058
11		.7202	.7373	1.0631	.1372	.1715	.1543
12	2.2462	2.2634	2.4863	1.9033	.2058	.2058	.1715
13	2.4348	2.5034	1.8176	1.8861	.1886	.2229	.2058
14	2.3834	2.3148	1.9204	1.8347	.2401	.2229	.2058
15	2.2977	2.1091	1.9376	1.7661	.2058	.2229	
16	2.3834	2.2119	1.8176	1.9547	.2229	.2401	
17	2.4348	2.2291	1.989	2.1434	.2058	.2229	
18	2.4691	2.2462	2.2805	2.0405	.2572	.2401	.2572
19	.3258	.3086	.3086	.3429	.3601	.3772	.4458
20	.463	.4287	.3944	.4115	.4115	.4458	.4801
21	.4115	.3944	.3944	.3772	.3601	.3944	.4115
22	.3772	.3772	.3429	.3429	.3601	.3601	.3772
23	.3086	.3086	.2915	.2915	.3086	.3258	.3086
24	.4801	.2915	.2743	.2401	.7373	.7202	.7373
Max	2.4691	2.5034	2.4863	2.1434	2.1091	2.2119	2.2119
Min	.2058	.2058	.2401	.1372	.1372	.1715	.1543
Avg	.9975	.9324	.8609	.8134	.6544	.6723	.7626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 247 / SOMNATH MANDIR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.5658	.5487	.1372	.12	.1372
2	.5658	.5487	.583	.6173	.1372	.12	.1372
3	.5658	.5487	.6001	.6173	.1372	.1029	.1372
4		.6516	.6173	.6687	.1543	.1372	.1372
5	.6173	.7373	.7716	.8059	.1715	.1372	.1372
6	.8573	1.046	.9945	.8745	.2058	.2058	.2058
7	1.3717	1.4575	1.0288	1.5604	.2229	.2058	.2229
8	1.6289	1.749	1.7661	1.8004	.2229	.1543	.2401
9	1.406	1.5604	1.6461	1.5604	.12	.1372	.1543
10	.1886	.1029	.1886	.1543	.1715	.1715	.1543
11		.12		.1029		.6859	.7888
12	.1372	.1029	.1886	.1543	1.4091	1.1831	1.4403
13	.1372	.0857	.12	.1372	1.3889	1.2003	1.286
14	.1886	.0857	.12	.1372	1.2689	1.2003	1.2003
15	.2058	.0686	.1372	.1372	1.2003	1.2174	
16	.2572	.1029	.0857	.1029	1.2003	1.2517	
17	.1715	.12	.2058	.1715	1.5775	1.5089	
18	.3772	.1372	.1715	.1715	1.4746	1.4575	1.4232
19	.4287	.2229	.2572	.2058	.2058	.1715	.2058
20	.4801	.2401	.2229	.2572	.2229	.2229	.2229
21	.3601	.2229	.2058	.2058	.1886	.1886	.1886
22	.2743	.2229		.1715	.1543	.1715	.1715
23	.2058	.1715	.1543	.1543	.1543	.1372	.1715
24	.5487	.5316	.5487	.5144	.1372	.1372	.1372
Max	1.6289	1.749	1.7661	1.8004	1.5775	1.5089	1.4403
Min	.1372	.0686	.0857	.1029	.12	.1029	.1372
Avg	.5238	.4744	.5082	.4930	.5332	.5094	.4238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274170 / 33/11 KV Akola Sub-Station

Feeder No / Name : 248 / AKOLA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5144	.5487	.583	.2058	.1886	.1886
2	.5658	.5144	.5658	.6001	.2058	.1715	.1886
3	.6173	.5144	.6687	.6001	.2058	.1715	.1886
4	.6516	.583	.7202	.6173	.2572	.2229	.2229
5	.6859	.6859	.9945	.7545	.3086	.2743	.2572
6	.7373	.9945	1.0631	.9088	.3601	.3429	.3429
7	1.0974	1.1831	.9774	1.3375	.3086	.4115	.3601
8	1.3717	1.5604	1.4403	1.4746	.3086	.3601	.3086
9	1.2003	1.2517	1.4918	1.3889	.2058	.2058	.2401
10	.1543	.1715	.2058	.1543	.1886	.2229	.2229
11		.1715	.1886	.1886	.8916	.3086	.823
12	.12	.1543	.2058	.1372	1.4232	1.4403	1.4918
13	.12	.1372	.1372	.12	1.3032	1.3032	1.406
14	.1372	.1372	.1372	.1372	1.2174	1.166	1.2346
15	.1543	.1372	.1886	.1372	1.2174	1.1317	
16	.1543		.1372	.1543	1.2346	1.2003	
17	.1715	.1715	.1543	.2229	1.3889	1.4746	
18	.2572	.2401	.2743	.2572	1.4232	1.4918	1.406
19	.3601	.2915	.3601	.2915	.2743	.2572	.2743
20	.3944	.3258	.3944	.3429	.3429	.3258	.3601
21	.3086	.3429	.2915	.3086	.2229	.2572	.3086
22	.2229	.2743	.2572	.2229	.2229	.2229	.2743
23	.1715	.2058	.2229	.2229	.1886	.2058	.2572
24	.5144	.4973	.6173	.583	.2058	.1886	.1886
Max	1.3717	1.5604	1.4918	1.4746	1.4232	1.4918	1.4918
Min	.12	.1372	.1372	.12	.1886	.1715	.1886
Avg	.4659	.4809	.5101	.4894	.5880	.5644	.5021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 201 / 11 KV KATAFAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.9559	1.8233	.2486	.1989	.2486	.2155
2	2.1879	2.1216	1.8233	.2652	.1989	.2486	.1989
3	2.4034	2.2377	1.8067	.2652	.3149	.2984	.1989
4	2.652	2.3205	1.9559	.2652	.3149	.2486	.2652
5	2.9007	2.5194	2.3205	.2984	.2984	.2818	.2984
6	3.0664	2.7349	2.6686	.3315	.2984	.3315	.2984
7	3.3482	3.1327		.3647	.2818	.3647	.2652
8	3.315	3.3482	3.1824	.2984	.2818	.2321	.2652
9	2.9338	2.5692	3.0498	.2321	.2155	.2155	.1823
10	.1492	.2321	.1989	.1658	.1658	.1658	.1658
11	.1326	.1492	.1492	2.0056	2.2211	2.0056	1.9062
12	.1326	.1658	.1823	3.2819	3.2487	3.514	3.0001
13	.1658	.1658	.1492	1.1603	3.3648	3.2322	2.9172
14	.1823	.1989	.1658	1.2266	3.4974	3.1824	2.8012
15	.1989	.1823	.1492	2.5857	3.1824	3.199	2.8178
16	.1658	.1492	.1823	3.3979	3.2156	3.2156	2.9007
17	.1989	.1658	.1989	2.8344	3.315	3.1493	2.8178
18	.2486	.1658	.1989	2.8841	2.9835	2.7681	2.7349
19	.3149	.2652	.2984	.3149	.3149	.3315	.2486
20	.3812	.3315	.3481	.3149	.3481	.2984	.3481
21	.3149	.2984	.2818	.3149	.3149	.2984	.2984
22	.2818	.2652	.2818	.2652	.3149	.2652	.2321
23	.2486	.2486	.2652	.2321	.3149	.2321	1.8233
24	1.9062	1.8233	1.7404	.2486	.1989	.2818	.2155
Max	3.3482	3.3482	3.1824	3.3979	3.4974	3.514	3.0001
Min	.1326	.1492	.1492	.1658	.1658	.1658	.1658
Avg	1.2424	1.1561	1.0183	.9918	1.2252	1.1921	1.1423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 202 / 11 KV ITAKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0492	.0492	.2294	.3113	.3277	.3277
2	.0492	.0492	.0492	.2622	.3932	.3768	.3277
3	.0492	.0492	.0492	.2622	.3932	.4424	.3932
4	.0492	.0492	.0655	.2949	.4588	.4915	.4915
5	.0655	.0655	.0819	.3441	.6554	.5243	.4915
6	.0983	.0819	.0983	.426	.6554	.6226	.5571
7	.1147	.1147		.5407	.6882	.7373	.5571
8	.0983	.0819	.0983	.7209	.7701	.7865	.7537
9	.0492	.0819	.0655	.5079	.7209	.7373	.7209
10	.0492	.0328	.0328	.0492	.0328	.0492	.0492
11	.4096	.3441	.3277	.0328	.0328	.0492	.0328
12	.7865	.7537	.6718	.0328	.0328	.0328	.0492
13	.7865	.8029	.6554	.0328	.0328	.0328	.0328
14	.7701	.7045	.6554	.0328	.0492	.0328	.0328
15	.7209	.639	.5735	.0328	.0492	.0328	.0328
16	.7045	.7045	.5735	.0328	.0328	.0328	.0492
17	.6882	.6882	.639	.0492	.0492	.0492	.0492
18	.7373	.639	.6226	.0492	.0492	.0492	.0492
19	.0655	.0655	.0819	.0819	.0819	.0983	.0983
20	.0819	.0983	.0819	.0819	.0983	.0983	.0819
21	.0819	.0655	.0655	.0655	.0819	.0655	.0655
22	.0655	.0655	.0655	.0492	.0819	.0492	.0492
23	.0492	.0492	.0492	.0492	.0655	.0492	.0492
24	.0492	.0492	.0492	.213	.1802	.2622	.2949
Max	.7865	.8029	.6718	.7209	.7701	.7865	.7537
Min	.0492	.0328	.0328	.0328	.0328	.0328	.0328
Avg	.2779	.2635	.2479	.1864	.2499	.2512	.2349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274172 / 33/11 kv KATAFAL SUBSTATION

Feeder No / Name : 203 / KATAFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.1478	.116	.1294	.1478	.1294
2	.1478	.1478	.1294	.1478	.1294	.1478	.1663
3	.1478	.1478	.1294	.1478	.1663	.1478	.1663
4	.1663	.1663	.1478	.1478	.2218	.1478	.1848
5	.1848	.2772	.1848	.1848	.2957	.2402	.1848
6	.3142	.3142	.3326	.3326	.2957	.2772	.2218
7	.3881	.3696		.3696	.2587	.3326	.2218
8	.2772	.2033	.2772	.2587	.2402	.2772	.2033
9	.2033	.2033	.2218	.2402	.2772	.2402	.1848
10	.1478	.1663	.1294	.1478	.1109	.1848	.1478
11	.0924	.0924	.1294	.1294	.1294	.1848	.1294
12	.1109	.1109	.1478	.1109	.1294	.1478	.1294
13	.1294	.1109	.1663	.1294	.1109	.1109	.0924
14	.1109	.1109	.1294	.1109	.1294	.1294	.1109
15	.1663	.1478	.1478	.1294	.1663	.1294	.1294
16	.1848	.1109	.1478	.1478	.1294	.1478	.1294
17	.1294	.1663	.1848	.1478	.1478	.1848	.1848
18	.1663	.1663	.1848	.1478	.1663	.2033	.2587
19	.2402	.2587	.2587	.2772	.2772	.2587	.2587
20	.3142	.2957	.3142	.2772	.3142	.2218	.3142
21	.2772	.2218	.2402	.2772	.2402	.1848	
22	.2402	.2033	.2033	.2402	.2033	.1294	.1848
23	.1848	.1663	.1663	.2033	.1848	.1294	.1478
24	.1478	.1663	.1478	.1294	.1294	.1478	.1294
Max	.3881	.3696	.3326	.3696	.3142	.3326	.3142
Min	.0924	.0924	.1294	.1109	.1109	.1109	.0924
Avg	.1925	.1863	.1856	.1896	.1910	.1856	.1744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 244 / MANEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0857	.12	.0857	.1372	.1029	.1029
2	.1372	.1029	.1372	.1029	.1715	.12	.12
3	.1372	.1029	.1886	.0686	.2229	.1029	.1372
4	.1886	.1372	.2058	.1372	.2401	.1543	.1715
5	.2229	.1715	.2229	.1715	.2401	.1715	.1886
6	.2572	.2401	.2401	.2229	.2229	.2058	.2572
7	.2058	.2743	.2058	.2743	.2058	.2401	.2743
8	.1715	.1886	.1715	.1543	.1543	.1543	.2401
9	.1715	.1219	.1543	.12	.1372	.12	.1543
10	.12	.1029	.12	.1372	.12	.1372	.0857
11	.1543	.0857	.0857	.12	.0857	.1372	.0686
12	.12	.1543	.1029	.1543	.0857	.0686	.0857
13	.1029	.1029	.0686	.1372	.0686	.0514	
14	.0686	.0857	.0857	.1029	.0857	.0857	
15	.0857	.0686	.0857	.0857	.1029	.1029	.1029
16	.1029	.1029	.12	.12	.12	.1372	.1372
17	.2058	.12	.1029	.1886	.1543	.1715	.1543
18	.1715	.1543	.1543	.2229	.1715	.2058	.1886
19	.2229	.2058	.1886	.2229	.1372	.2401	.2229
20	.1543	.2058	.1715	.2058	.1543	.2572	.2401
21	.1372	.12	.1372	.1715		.2229	.1715
22	.1372	.1029	.1543	.1543		.2058	.1543
23	.12	.12	.12			.1543	.12
24	.1029	.1029	.1029	.1029	.12	.12	.12
Max	.2572	.2743	.2401	.2743	.2401	.2572	.2743
Min	.0686	.0686	.0686	.0686	.0686	.0514	.0686
Avg	.1508	.1358	.1436	.1506	.1494	.1529	.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 249 / NIJAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.5506	.583	.2105	.1134	.2105	.2915
2	.7449	.6316	.6401	.2267	.1296	.1781	.3239
3	.8097	.6964	.7287	.2429	.1457	.1943	.3944
4	1.004	.7287	.7611	.2591	.1619	.2429	.3563
5	1.166	.8421	.7773	.3077	.1619	.2915	.3887
6	1.2955	1.2793	.9393	.2753	.1781	.3401	.4049
7	1.4899	1.587	1.085	.2429	.1457	.3077	.4372
8	1.5546	1.7652	1.587	.1943	.0972	.2753	.3725
9	1.7004	1.587	1.5546	.1619	.081	.2267	.2429
10	.1781	.1943	.2105	.1457	.1296	.1943	.2105
11	.1296	.1619	.1457	.4372	.6154	.3077	
12	.1457	.1457	.1619	1.4089	1.4089	1.3117	.6478
13	.1457	.1619	.1943	1.4251	1.3765	1.2308	
14	.1619	.1296	.2105		1.247	1.0202	
15	.1457	.1134	.1943	.6802	1.1336	1.2146	1.3279
16	.1781	.1781	.2105	.9069	1.2146	1.2955	1.587
17	.1943	.2105	.2267	.9231	1.4251	1.3603	1.5061
18	.2591	.2429	.2591	.9555	1.5384	1.4899	1.4413
19	.3725	.3725	.2753	.1781	.3239	.3887	.2915
20	.3401	.3563	.3239	.1781	.2915	.3563	.3887
21	.3239	.3239	.3077	.1457		.3239	.3239
22	.2753	.3077	.2915	.1296		.3077	.2915
23	.2591	.2915	.2429	.1296		.2915	.2591
24	.5182	.4858	.5316	.2267	.1134	.2267	.2753
Max	1.7004	1.7652	1.587	1.4251	1.5384	1.4899	1.587
Min	.1296	.1134	.1457	.1296	.081	.1781	.2105
Avg	.5850	.5560	.5184	.4344	.5730	.5661	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274173 / NIJAMPUR(MANEGAON)

Feeder No / Name : 251 / DONGARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2743	.2896	.3963	.4725	.5335	.5792
2	.2896	.2591	.2896	.4572	.6706	.6859	.7011
3	.3048	.2896	.3048	.6401	.7316	.8688	.7621
4	.3353	.3048	.3353	.8688	.8078	.9907	.8078
5	.3658	.3353	.381	1.2193	1.1584	1.1126	.8993
6	.381	.442	.4115	1.448	1.7223	1.2803	1.1431
7	.3201	.381	.3658	1.2041	1.9357	1.4784	1.6156
8	.2743	.2743	.3201	1.1736	1.3413	1.3717	1.5394
9	.1829	.1981	.1981	1.2193	1.2955	1.0974	1.4327
10	.1372	.6401	.1219		.1524	.2134	.1677
11	.823	1.4022	.4572		.1067	.1677	.2134
12	1.326		.7468		.1067	.2401	.2286
13	1.2803	1.4937	.945	.1677	.0914	.2286	
14	1.2955	1.448	1.1584	.1372	.1067	.1829	
15	1.2346	1.3413	1.2193	.1829	.1219	.1829	.1677
16	1.2803	1.2955	1.326	.1524	.1524	.2134	.1524
17	1.3108	1.2193	1.3717	.1981	.1981	.2439	.1829
18	1.3108	1.1584	1.2193	.2134	.2286	.2286	.2286
19	.3048	.2896	***	.2896	.2591	.2439	.2896
20	.3201	.3048	.3506	.3048	.2743	.2896	.3048
21	.3048	.2743	.3201	.2743		.3048	.3506
22	.2896	.2896	.2896	.2591		.3506	.3353
23	.2743		.2591	.2439		.3048	.3048
24	.2439	.2591	.2591	.3658	.3506	.2591	.442
Max	1.326	1.4937	11.0502	1.448	1.9357	1.4784	1.6156
Min	.1372	.1981	.1219	.1372	.0914	.1677	.1524
Avg	.6020	.6443	.9996	.5436	.5850	.5447	.5840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 241 / SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.823	.8573	.9945	.7716	.8573	.9259
2	.9602	.9431	.9431	1.046	.823	.9431	1.0288
3		1.0288	1.0288	1.1145	.9088	1.046	1.0974
4	1.286	1.1145	1.166	1.2174	1.0117	1.1488	1.2346
5	1.3717	1.3375	1.3375	1.3717	1.1488	1.286	1.3375
6	1.5432	1.6804	1.7147	1.5432	1.4575	1.5604	1.6461
7	2.2462	2.1948	1.3717	2.0748	2.0576	2.1605	1.7661
8	2.4177	2.2462	2.2462	2.4691	2.4691	2.2977	2.2805
9	2.1948	2.2119	2.0748	2.0748	2.1262	1.0288	2.2462
10	.3086	.2572	.2401	.2229	.2743	.2401	.2401
11	.2058	.2401	.2743	.2572	.2058	.2229	.2229
12		.2572	.2401	.2229	.2058	.2572	.2401
13	.1886	.2401	.2229	.2058	.1715	.2401	.2058
14	.2229	.2058	.1886	.2058	.2401	.2401	.2058
15		.2401	.2401	.1715	.2058	.2229	.2058
16		.2743	.2743	.2229	.2401	.2229	.2743
17		.2401	.3429	.3429	.2058	.2229	.2572
18	.3772	.3086	.3772	.4458	.4115	.3086	.3429
19	.3944	.4458	.583	.6001	.5487	.5658	.4458
20	.6344	.4973	.5487	.6001	.5487	.6001	.5316
21	.5144	.463	.5144	.5487	.4801	.5144	.5487
22	.5144	.4801	.463	.5144	.4458	.4801	.4801
23	.4115	.4287	.4458	.4801	.4287	.4458	.4458
24	.8402	.823	.7888	.9774	.7716	.7888	.7716
Max	2.4177	2.2462	2.2462	2.4691	2.4691	2.2977	2.2805
Min	.1886	.2058	.1886	.1715	.1715	.2229	.2058
Avg	.9205	.7909	.7702	.8302	.7566	.7459	.7909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 242 / WAKI SHIVANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.2753	.2915	.2429	.2591	.2572	.2743
2	.2429	.2753	.2915	.2429	.2591	.2743	.2915
3	.2429	.2915	.3086	.2591	.2753	.2915	.3086
4	.2591	.3077	.3258	.3077	.3077	.2915	.3086
5	.2753	.3725	.3772	.3563	.3563	.3601	.3429
6	.3239	.4458	.4801	.4372	.502	.463	.463
7	.421	.4049	.4287	.3563	.3725	.3944	.3772
8	.3077	.3086	.3601	.2267	.2753	.2915	.3258
9	.2753	.2572	.3086		.2058	.2401	.2267
10	.1943	.2058	.2401	1.247	.1715	.1886	
11	1.4089	1.3546	1.3717	1.8623	1.166	1.1145	1.1336
12	2.2672	1.9204	2.1091	1.8138		1.7661	1.8623
13	1.9433	1.9547	1.9719	1.749	1.9376	1.7833	1.7004
14		1.6804	1.7147	1.668	1.6975	1.7833	1.6194
15		1.5775	1.8004	1.8004	1.6289	1.7661	1.5708
16		1.6461	1.8519	1.869	1.8176	1.8004	1.6194
17	2.1862	1.869	1.9547	1.8519	1.9547	1.8861	1.587
18	2.1052	1.8176	2.0576	.2753	1.9204	1.6804	1.5546
19	.2915		.2915	.3429	.3258	.2572	.3239
20	.3239	.3601	.2915	.2591	.3944	.3429	.2915
21	.2753	.3086	.2915		.2915	.3429	.2591
22	.2753	.2743	.2743	.2591	.2401	.3258	.2591
23	.2429	.2915	.2743	.2591	.2401	.3086	.2429
24	.2429	.2753	.2915	.2429	.2591	.2572	.2743
Max	2.2672	1.9547	2.1091	1.869	1.9547	1.8861	1.8623
Min	.1943	.2058	.2401	.2267	.1715	.1886	.2267
Avg	.6832	.8032	.8316	.8150	.7330	.7695	.7486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274178 / SHIVANE

Feeder No / Name : 243 / GALVEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.12			.1543	.12
2			.1372			.1715	.12
3			.1543			.1886	.1372
4	.12	.1715	.1715	.1715	.1543	.1886	.1543
5		.2229	.1715	.1886	.2058	.2058	.2058
6		.2572	.2401	.2572	.2572	.2401	.2915
7		.2401	.2401	.2401	.2229	.2401	.2401
8	.1715	.1886	.1886	.1943	.1543	.1372	.1886
9		.12	.1372	.1781	.1372	.12	.12
10	.12	.1029	.12		.1029	.1029	.1029
11	.9945	.9602	1.0631	.9069	.8402	.9602	.7373
12	1.6804	1.5947	1.6632	1.5089	1.3889	1.0631	1.4575
13	1.749	1.5775		1.6118	1.3203	1.1488	1.286
14		1.6632	1.3889	1.6289	1.5775	1.166	1.286
15		1.5432	1.4746	1.4899	1.5775	1.166	1.3203
16		1.4403	1.5432	1.2003	1.5089	1.2689	1.4403
17	1.6289	1.1831	1.5089	1.3717	1.4918	1.3032	1.2689
18	1.7147	1.3889	1.4746	1.3032	1.4575	1.2174	
19	.1715	.1372	.1715	.1715	.1543	.1886	.1543
20	.1886	.1886	.1543	.1886	.1886	.1886	.2229
21	.1543	.1715	.1543	.1543	.1715	.1715	.1715
22	.1372	.12	.1543	.1372	.1715	.1543	.1543
23	.1029	.1029	.1372	.12	.1543	.1372	.12
24	.1029	.12	.1029	.12	.12	.1372	.12
Max	1.749	1.6632	1.6632	1.6289	1.5775	1.3032	1.4575
Min	.1029	.1029	.1029	.12	.1029	.1029	.1029
Avg	.6093	.6188	.5509	.6572	.6361	.5008	.4965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 201 / WATAMBARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.12	.1029	.1372	.1543	.1372
2	.1372	.0857		.0343	.1372	.1715	.1543
3	.12	.1372		.0686	.1715	.1715	.1543
4	.12	.1543		.0857	.2058	.1886	.1715
5	.1029	.1715		.1029	.2058	.2058	.1715
6	.1543	.2058		.1372	.2229	.2058	.1886
7	.1715	.1715		.1715	.2058	.1886	.2058
8	.1715	.1372		.1715	.1886	.1715	.1717
9	.1715	.1715		.1372	.1543	.12	.1372
10	.1543	.1715		.1543	.1886	.1372	.1543
11	.1715	.12		.1029	.12	.1372	.1372
12	.1543		.1715	.1372	.1372	.1372	.1543
13	.1543	.1372	.1715		.1372	.1372	.1715
14	.1543	.1372	.1886	.1543	.12	.1372	.1543
15	.1372	.12	.2058	.1372	.0857	.1372	.1543
16	.1029	.1029	.1886	.12	.1372	.12	.1372
17	.0857	.12	.1886	.1715	.1715	.1372	.1715
18	.0857	.1372	.2401	.2058	.1888	.1715	.2058
19	.2401	.2401	.2401	.2401	.2229	.2401	.2229
20	.2401	.2058	.2401	.2229	.2401	.2401	.2572
21	.2058	.1715	.2058	.2058	.2229	.2229	.2229
22	.1715	.1543	.1715	.1715	.2058	.2058	.2058
23	.1372	.12	.12	.1543	.1715	.1715	.1715
24	.1372	.1029	.1029	.1029	.1543	.1543	.1372
Max	.2401	.2401	.2401	.2401	.2401	.2401	.2572
Min	.0857	.0857	.1029	.0343	.0857	.12	.1372
Avg	.1508	.1469	.1825	.1432	.1722	.1693	.1729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 202 / 11 KV WATAMBARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1029	.1372	.9602		.823
2	.1543	.1372		.1543	1.0288	.8573	.9431
3	.1372	.1543		.1715	1.0631		.9945
4	.1372	.1715		.2058	1.0974		1.166
5	.12	.2058		.2058	1.1317	1.2003	1.3717
6	.1372	.2401		.2229	1.166		1.5432
7	.1543	.2401		.2401	1.406	1.6461	1.749
8	.1715	.2229		.2401	1.5432		1.5432
9	.2058	.2058		.2058	1.4746	1.3717	1.3717
10	.2229	.1886		.1715			.1886
11	.8573	.823		.7545	.1543	.1715	.1372
12	1.5089		1.5775	1.3203	.1543		.1372
13	1.3717	1.3032	1.4575	.4458	.1372	.1543	.1543
14	1.2689	1.2689	1.4403	1.2096	.1543	.1715	.1715
15	1.3032	1.3032	1.406	1.3375	.1543		.1886
16	.7545	1.4746	1.4746	1.3717	.1715		.1886
17	1.0288	1.5432	1.5432	1.5261	.1715		.1715
18	1.0974	1.6461	.2058	.2058	.1543	.1715	.1543
19	.2401	.2401	.1715	.2401	.2401	.2743	.2229
20	.2572	.1886	.1543	.2058	.2401	.2572	.2401
21	.2401	.1543	.1372	.1715	.2229	.2229	.2058
22	.2058	.1372	.1372	.1715	.2058	.2058	.1886
23	.1715	.12	.1372	.1715	.1886		.1886
24	.1715	.1543	.1029	.1372	.823	.6859	.583
Max	1.5089	1.6461	1.5775	1.5261	1.5432	1.6461	1.749
Min	.12	.12	.1029	.1372	.1372	.1543	.1372
Avg	.5030	.5338	.7177	.4677	.6106	.5685	.6094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 274239 / 33/11KV WATAMBARE

Feeder No / Name : 203 / 11 KV ANAKDHAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7202	.6859	.6173	.12	.1372	.1029
2	.6516	.7888	.7716	.7202	.1029	.1372	.12
3	.7545	.823	.823	.823	.1372	.1543	.1372
4	.823	.823	.8916	.9259	.1715	.1715	.1372
5	.9259	.8573	.9945	1.0288	.2058	.2058	.1543
6	1.0288	.8916	1.1145	1.1317	.2401	.2401	.1886
7	1.0631	1.2003	1.2003	1.2689	.2058	.2572	.2058
8	1.0974	1.3375	1.3032	1.3717	.1717	.1715	.1886
9	1.2346	1.3717	1.3032	1.0288	.1029	.12	.2058
10	.0857	.12	.1029	.1029	.0857	.1372	.1029
11	.0857	.1029	.1029	.0686	1.0288	.583	.5144
12	.0686		.0857	.0686	1.2003	1.166	1.2346
13	.0857	.0857	.0857	.0857	1.2346	1.0974	1.4403
14	.0857	.1029	.1029	.0857	1.1317	1.1317	1.3717
15	.0686	.0857	.12	.0857	1.2003	1.166	1.2003
16	.0686	.0857	.1029	.0857	1.2346	1.2003	1.0974
17	.1029	.0857	.0857	.1029	1.166	1.2346	1.2003
18	.0686	.0686	.0686	.1715	.1886	1.3717	1.2689
19	.1886	.1715	.1029	.2058	.1543	.1372	.1372
20	.1715	.1543	.1029	.2229	.1543	.1372	.1543
21	.1715	.1543	.1029	.2058	.1372	.12	.1715
22	.1372	.1372	.12	.1886	.1372	.1372	.1543
23	.1372	.12	.1029	.1372	.1372	.12	.1372
24	.4801	.6516	.5144	.5144	.12		.1029
Max	1.2346	1.3717	1.3032	1.3717	1.2346	1.3717	1.4403
Min	.0686	.0686	.0686	.0686	.0857	.12	.1029
Avg	.4222	.4756	.4580	.4687	.4487	.4928	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 271 / 11 KV SANGOLA U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429
2	.3429	.3429	.3429
3	.3429	.3429	.3429
4	.3429	.3429	.3429
5	.4287	.4287	.4287
6	.5144	.4287	.5144
7	.6001	.5144	.4287
8	.5144	.6001	
9	.3429		.4287
10	.4287	.4287	.4287
11	.4287	.4287	.3429
12	.4287	.4287	.3429
13	.3429	.4287	.3429
14	.3429	.4287	.3429
15	.5144	.3429	.4287
16	.4287	.4287	.4287
17	.4287	.4287	.4287
18	.4287	.3429	.5144
19	.4287	.4287	.5144
20	.5144	.4287	.5144
21	.4287		.4287
22	.4287		.3429
23	.4287		.3429
24	.4115	.3429	.3429
Max	.6001	.6001	.5144
Min	.3429	.3429	.3429
Avg	.4244	.4115	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 272 / 11 KV Gherdi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.8573	.2572
2	1.1145	.8573	.2572
3	1.1145	.9431	.2572
4	1.2003	1.0288	.3429
5	1.4575	1.2003	.4287
6	1.6289	1.2003	.4287
7	1.8861	1.286	
8	1.3717	1.6289	
9	.2572	.3429	1.8861
10	.2572		2.1434
11	.2572	.2572	1.3717
12	.2572	.1715	1.7147
13	.2572	.2572	1.7147
14	.2572	.2572	1.6289
15	.2572	.3429	1.6289
16	.2572	.3429	1.5947
17	.3429	.2572	.3429
18	.3429	.3429	.3429
19	.3429	.3429	.4287
20	.3429	.4287	.4287
21	.3429	.3429	.4287
22	.3429	.3429	.4287
23	.2572	.2572	.3429
24	1.286	.2572	.2572
Max	1.8861	1.6289	2.1434
Min	.2572	.1715	.2572
Avg	.6894	.5889	.8480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 274 / 11 KV Chincholi Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	.0857
2	.1715	.0857	.0857
3	.1715	.0857	.0857
4	.1715	.0857	.0857
5	.2572	.1715	.0857
6	.3429	.1715	
7	.4287	.3429	
8	.3429	.4287	
9	.0857	.0857	.2572
10	.0857	.0857	.3429
11	.0857	.0857	.4287
12	.0857	.0857	.3429
13	.0857	.0857	.3429
14	.0857	.0857	.3429
15	.0857	.0857	.2572
16	.0857	.0857	.0857
17	.0857	.0857	.0857
18	.0857	.0857	
19	.0857	.0857	.1715
20	.0857	.0857	.0857
21	.0857	.0857	.0857
22	.0857	.0857	.0857
23	.0857	.0857	.0857
24	.1715	.0857	.0857
Max	.4287	.4287	.4287
Min	.0857	.0857	.0857
Avg	.1464	.1179	.1757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 276 / 11 KV Mahud Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)
1	.2572	.2572
2	.2572	.2572
3	.2572	.2572
4	.2572	.2572
5	.2572	.5144
9		.4287
10	2.1434	.4287
11	2.0576	.2572
12	1.8004	.3429
13	2.0576	.3429
14	1.8861	.3429
15	2.0576	.3429
16	1.9719	.3258
17	.1543	
18	.4287	1.8861
19	.5144	2.0576
20		1.8004
21	.6001	1.7147
22	.5144	1.6289
23	.3429	1.5432
24	.3429	.2572
Max	2.1434	2.0576
Min	.1543	.2572
Avg	.9557	.7622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 277 / 11 KV Chandolwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	1.0288
2	.2572	.2572	1.0288
3	.2572	.2572	1.1145
4		.2572	1.0288
5	.2572	.2572	1.1145
6	.7716		1.286
7	.7716		1.4575
8	.7716		1.286
9	.2572	.2572	.2572
10	.2572	.3429	.2572
11	.1715	.2572	.2572
12		.2572	.1715
13	.2572	.2572	.2572
14	.1715	.1715	.2572
15	.2572	.1715	.2572
16	1.8004	.2572	.2572
17		1.3717	.2572
18		1.5432	.2572
19	1.3717	1.8861	
20	1.3717		.3429
21	1.286	1.4575	.2572
22	1.2003	1.3717	.2572
23	1.1145	1.2003	.2572
24	.2572	1.1145	1.1145
Max	1.8004	1.8861	1.4575
Min	.1715	.1715	.1715
Avg	.6559	.6601	.6113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

PANDHARPUR DIVISION[536]

SANGOLA[101]

BU 6343

Substation No/ Name :- 276009 / 132/33/11 KV SANGOLA S/S

Feeder No / Name : 278 / 11 KV super feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	25-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.6001
2	.5144	.5144	.6001
3	.5144	.5144	.5144
4	.6001	.6001	.5144
5	.6859	.6859	.8573
6	.9431	.9431	.9431
7	1.0288	1.0288	.7716
8	.9431	.9431	.7716
9	.6859	.8573	.6859
10	.6859	.8573	.7716
11	.8573	.8573	.6859
12	.8573	.9431	.6859
13	.6859		.6859
14	.7716	.8573	.6859
15	.6859	.7716	.6001
16	.6859	.6859	.583
17	.6001	.6859	.6001
18	.7716		.6859
19	.8573	.6001	.6859
20	.7716	.5144	.8573
21		.6001	.8573
22	.6859	.3858	.8573
23	.6859	.6859	
24	.6859	.6001	.6001
Max	1.0288	1.0288	.9431
Min	.5144	.3858	.5144
Avg	.7343	.7112	.7000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 201 / 11 KV CHUNGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829		.0829	.0895	.0791	
2	.0829	.0876	.0829	.0895	.081	
3	.0829	.0914	.0829	.0876	.0164	
4	.0829	.0895	.0995	.0895	.0819	
5	.0995	.0895	.0995	.0914	.0819	
6	.0995	.1075	.0995	.1097	.1134	
7	.0995	.1227	.0829	.1075	.1107	
8	.0995	.1075	.0829	.0895	.0972	
9		.1075	.0829	.0905	.081	
10	.0857		.0819	.0895	.08	
11	1.97	2.0243	1.8084	1.9204	1.8404	
12	2.3312	2.0243	2.0965	2.2672	1.9524	
13	2.13	2.2138	2.0805	2.2939	2.0805	
14	2.0481	2.2405	2.1464	2.2672	1.8842	
15	2.0005	2.1052	2.0062	2.1862	1.9204	
16	1.9364	2.13	1.9662	2.13	2.0005	
17	1.9204	2.3205	2.0805	2.1548	1.9204	.0655
18	1.9524	1.4918	2.0965		1.8515	
19	.0876	.1006	.0701		.0716	
20	.0876	.0995	.0876		.0876	
21	.1075	.1174	.0914		.0895	
22	.1052	.116	.0895		.0895	
23	.1075	.1006	.0895		.0895	
24	.0995	.0895	.0829	.0895	.081	.0914
Max	2.3312	2.3205	2.1464	2.2939	2.0805	.0914
Min	.0829	.0876	.0701	.0876	.0164	.0655
Avg	.7695	.8171	.7363	.9024	.6992	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 202 / 11 KV BOREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1966	.1638	.1791	.1619	
2	.1638	.192	.1638	.1753	.0164	
3	.1638	.192	.1638	.1753	.1619	
4	.1966	.1966	.1966	.1791	.1943	
5	.1966	.1966	.1966	.1791	.2155	
6	.1966	.192	.2294	.2103	.2155	
7	.2294	.192	.2294	.2103	.2155	
8	.1966	.16	.2294	.1791	.2012	
9	.1638	.16	.1966	.1433	.1943	
10	.128	.1619	.192	.1448	.192	
11	2.4006	2.6882	2.2405	2.3482	2.0062	
12	2.9607	2.6882	2.5606	2.7035	2.8006	
13	2.8807	2.5911	2.7206	2.672	2.5606	
14	2.8673	2.6216	2.7854	2.7035	2.3758	
15	2.5606	2.4291	2.7206	2.672	2.4006	
16	2.3205	2.2939	2.8006	2.5911	2.4006	
17	2.4006	2.652	2.6406	2.6216	2.4006	
18	2.5396	2.5692	2.13		2.4577	
19		.1823	.128		.16	
20	.16	.218	.16		.1966	
21	.1966	.2155	.1715		.192	
22	.192	.1989	.1753		.1966	
23	.192	.1781	.1791		.192	
24	.1638	.1966	.1638	.1791	.1658	.1989
Max	2.9607	2.6882	2.8006	2.7035	2.8006	.1989
Min	.128	.16	.128	.1433	.0164	.1989
Avg	1.0276	.9818	.9808	1.1259	.9281	.1989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 203 / 11 KV HANNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3944	.3525	.3525	.3429	
2	.362	.4058	.3525	.3525	.3525	
3	.4934	.4058	.4633	.3382	.3525	
4	.5639	.4601	.5201	.4001	.3429	
5	.6687		.6241	.4668	.4172	
6	.6687	.583	.639	.5182	.6173	
7	.639	.583	.6687	.5258	.6259	
8	.6687	.4734	.5944	.4058	.5487	
9	.5944	.4458	.5944	.3334	.3429	
10	.3525	.3429	.4172	.2743	.4115	
11	.2705	.2086	.3382	.2667	.3382	
12	.2667	.2058	.282	.2743	.282	
13	.2705	.2	.3429	.2743	.3525	
14	.2591	.2058	.3429	.2705	.3334	
15	.2591	.2086	.3525	.2743	.3525	
16	.2705	.2058	.282	.3429	.3525	.2896
17	.282	.2086	.3525	.3477	.4058	.2896
18	.3525	.2743	.4001		.5201	
19	.4058	.4172	.4934		.5944	
20	.4734	.4801	.4934		.5792	
21	.4001	.4868	.4801		.4734	
22	.3944	.3477	.4172		.423	
23	.4058	.362	.3429		.4058	
24	.2896	.3887	.362	.3382	.3477	.4058
Max	.6687	.583	.6687	.5258	.6259	.4058
Min	.2591	.2	.282	.2667	.282	.2896
Avg	.4156	.3606	.4378	.3531	.4215	.3283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 204 / 11 KV NANHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2629	.2801	.2658	.1867	
2	.462	.2715	.3326	.2686	.1848	
3	.462	.2658	.3326	.3189	.1867	
4	.5487	.3155	.3696	.3544	.2801	
5	.5853	.3506	.4572	.4382	.4668	
6	.6401	.3856	.5853	.4961	.4668	
7	.5487	.3544	.5487	.4607	.3734	
8	.462	.3224	.4668	.4477	.3734	
9	.462	.2454	.462	.3582	.2801	
10	.2658	.1867	.1829	.2715	.2658	
11	.016	.1867	.1772	.1791	.1753	
12	.1772	.1867	.1402	.0934	.1772	
13		.1867	.1417	.0905	.1791	
14		.1848	.1417	.1867	.1772	
15		.1848	.1075	.1867	.1791	
16	.2149	.1867	.1063	.181	.1772	.1494
17		.1867	.1791	.1867	.1791	.1494
18		.1867	.2481		.1772	
19		.2772			.2658	
20		.3696			.2686	
21		.3734			.2865	
22		.3734			.2804	
23	.2658	.2801	.2686		.2658	
24	.2801	.2629	.2801	.2658	.1867	.2801
Max	.6401	.3856	.5853	.4961	.4668	.2801
Min	.016	.1848	.1063	.0905	.1753	.1494
Avg	.3843	.2661	.2904	.2806	.2517	.1930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 205 / 11 KV SULTANPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4744	.4801	.4744	.4801	.4744	
2	.5376	.4801	.5376	.5247	.4744	
3	.5376	.4915	.5376	.5571	.4858	
4	.5535	.4801	.5693	.5601	.4858	
5	.5535	.4801	.5693	.6081	.5735	
6	.6009	.5735	.5851	.6554	.6554	
7	.6009	.5601	.5851	.6562	.7287	
8	.6009	.6554	.6009	.6401	.6554	
9	.6167	.6562	.6167	.6554	.5668	
10	.6401	.6401	.6562	.6478	.6401	
17	.016	.0162	.016	.0162	.016	
18	.016	.0164	.016		.016	
19	.016	.0162	.016		.016	
20	.0164	.0164	.0164		.016	
21	.016	.0164	.016		.0164	
22	.016	.0166	.016		.016	
23	.016	.0162	.0164		.016	
24	.0162	.0164	.0168	.0164	.0162	.016
Max	.6401	.6562	.6562	.6562	.7287	.016
Min	.016	.0162	.016	.0162	.016	.016
Avg	.3247	.3127	.3257	.5015	.3261	.016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 206 / 11 KV BAWKARWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.4403	1.6975	1.7604	1.4232	
2	1.6975	1.6004	1.929	1.8404		
3	1.8519	1.6385	1.9528	1.9662	1.4918	
4	1.9528	1.6004	2.0309	1.9204	1.7004	
5	1.9841	1.6004	2.1091	2.0805	1.9433	
6	2.0309	1.9662	2.1091	2.2119	2.1052	
7	2.0934	2.0165	2.1872	2.1765	2.1052	
8	2.1403	2.1605	2.2653	2.2405	2.13	
9	2.1872	2.2611	2.2653	2.4249	1.9433	
10	2.0965	2.1052	2.2085	2.1052	1.8884	
17	.08	.081	.096	.081	.08	
18	.0819	.0819	.1147		.0819	
19	.096	.1147	.128		.128	
20	.128	.1311	.16		.16	
21	.1311	.1457	.1966		.1638	
22	.16	.1457	.1943		.16	
23	.1638	.1509	.16		.16	
24	.116	.16	.0995	.1638	.1457	.16
Max	2.1872	2.2611	2.2653	2.4249	2.13	.16
Min	.08	.081	.096	.081	.08	.16
Avg	1.1408	1.0778	1.2169	1.7476	1.0477	.16

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274067 / 33/ 11 KV HANNUR S/S

Feeder No / Name : 207 / 11 KV ANV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.016	.0168	.0164	.0168	
2	.0168	.0168	.0168	.016	.0166	
3	.0168	.0171	.0168	.016	.0166	
4	.0168	.0175	.0168	.0164	.0166	
5	.0162	.0175	.0168	.016	.0168	
6	.0162	.0175	.0168	.0164	.0166	
7	.0162	.0171	.0168	.016	.0166	
8	.0162	.0175	.0168	.016	.0168	
9	.0162	.0179	.0168	.016	.0166	
10		.0166	.016	.016	.016	
11	.016	.0166	.016	.0162	.016	
12	.016	.0166	.016	.0162	.016	
13	.016	.0168	.016	.0164	.016	
14	.0164	.0166	.0164	.0166	.016	
15	.016	.0166	.016	.0164	.016	
16	.016	.0166	.0164	.0166	.0164	.0162
17	.016	.0166	.016	.0166	.016	.0168
18	.016	.0164	.0164		.016	
19	.0164	.0166	.016		.016	
20	.0164	.0162	.0164		.0164	
21	.016	.0158	.0156		.016	
22	.016	.0166	.016		.016	
23	.016	.0168	.016		.0154	
24	.0162	.0164	.0162	.0164	.0166	.0162
Max	.0168	.0179	.0168	.0166	.0168	.0168
Min	.016	.0158	.0156	.016	.0154	.0162
Avg	.0162	.0168	.0164	.0163	.0163	.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 201 / 11 KV NAVADAGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0876	.0914	.0914	.0914		.0914
2	.0914	.0886	.0886	.0905	.0857		.0905
3	.0914	.0895	.0914	.0895	.0876		.0905
4	.0924	.0905	.1829	.0886	.1734		.0905
5		.181	.1829	.0886	.1734		.1791
6	.1829	.181	.1772	.1791	.1734		.1791
7	.1829	.1829	.1829	.181	.1753		.1791
8	.1829	.1829	.1772	.1829	.1734		.181
9	.1848	.0914	.1829	.1829	.1772		.181
10	.0924	.0924	.0914	.1772	.0924		.181
11	1.4842	1.5708	1.4632	1.6461	1.0536		1.3575
12	1.8185	1.9404	1.9204	2.1033	1.5432		1.8099
13	1.6404	1.848	1.9204	1.829	1.448		1.3575
14	1.448	1.5708	1.8604	1.6461	1.1145		
15	1.0936	1.4784	1.4632	1.4632	1.0002		1.386
16	1.3117	1.7556	1.5546	1.5546	1.0431		1.4784
17	1.448	2.0328	1.829	1.9204	1.4299		1.6289
18	1.4118	1.9404	2.0119	1.9204	1.3756		1.5384
19	.1791	.1848	.1829	.1829	.1829		.181
20	.2743	.1848	.1829	.1829	.1791		.181
21	.1753	.1848	.1829	.1829	.1848		.181
22	.0876	.1848	.1829	.1829	.0914	.1848	.181
23	.0867	.1848	.1829	.1829	.0914	.1829	.181
24	.0895	.0867	.1829	.1829	.0914		.1848
Max	1.8185	2.0328	2.0119	2.1033	1.5432	.1848	1.8099
Min	.0867	.0867	.0886	.0886	.0857	.1829	.0905
Avg	.5974	.6840	.6904	.6888	.5097	.1839	.5691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 202 / 11 KV HAIDRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6687	.7202	.7202	.7202	.6478	.7545
2	.8192	.7335	.8002	.9602	.8002	.703	.7459
3	.8802	.8173	.8802	1.1203	.9831	.8278	.9012
4	1.0155	.8802	.9602	1.2803	.9831	.9412	1.2003
5	1.2346	1.0536	1.1203	1.6004	1.065	1.2193	1.2651
6	1.3889	1.2955	1.3603	1.7604	1.5261	1.4661	1.5623
7	2.1052	2.0805	1.9204	2.4006	2.2939	1.5623	1.6556
8	1.5023	2.1862	2.1605	2.3205	2.2939	2.1348	1.9319
9	1.7394	2.0243	1.6004	2.0805	1.9433	2.0805	1.7375
10	1.6604	1.7604	1.6004	1.6804	1.7966	1.6004	1.5203
11		1.7604					
17	.1829	.16	.16	.16		.16	.1677
18	.1772	.16	.16	.16		.1638	.1677
19	.1772	.16	.16	.16	.2715	.1638	.1696
20	.2715	.16	.16	.16	.2715	.1638	.1696
21	.1753	.16	.16	.16	.1772	.1638	.1696
22	.1734	.16	.16	.16	.1734	.1638	.1696
23	.1886	.16	.16	.16	.1734	.1658	.017
24	.1715	.1696	.16	.16	.16	.1734	.1696
Max	2.1052	2.1862	2.1605	2.4006	2.2939	2.1348	1.9319
Min	.1715	.16	.16	.16	.16	.16	.017
Avg	.8121	.8711	.8002	.9558	.9770	.8056	.8042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 203 / 11 KV Nagansur GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6335	.6335	.6335	.6335	.724	.543
2	.6335	.6335	.6335	.724	.6335	.6335	.8145
3	.6335	.724	.8145	.905	.724	.6335	.905
4	.8145	.905	.9955	1.1765	.9955		1.086
5	1.086	1.1765	1.1765	1.3575	1.086	1.086	1.267
6	1.3575	1.448	1.448	1.448	1.448	1.448	1.448
8	1.1765	1.1765	1.1765	1.086	1.1765	1.086	1.086
9	.9955	.905	.905	.905	.9955	.905	.905
10	.724		.6335	.8145	.724	.6335	
11			.543	.6335		.543	.543
12	.724		.4525	.543		.543	.4525
13	.6335	.543	.543	.543	.543	.543	.4525
14	.543	.4525	.4525		.543	.4525	.4525
15	.4525	.4525	.4525	.543	.543	.4525	.4525
16	.4525	.4525	.4525	.543	.543	.4525	.4525
17	.543	.543	.543	.543		.543	.543
18	.6335	.6335	.8145	.724		.724	.6335
19	.9955	1.086	.905	1.1765	1.1765	.905	.905
20	1.1765	1.1765	.9955	1.1765	1.3575	.9955	1.1765
21	.905	1.086	.9955	.9955	1.086	.905	1.086
22	.8145	.9955	.8145	.8145	.924	.8145	.8145
23	.724	.724	.724	.724	.724	.6335	.6335
24	.724	.6335	.6335	.6335	.6335	.724	.543
Max	1.3575	1.448	1.448	1.448	1.448	1.448	1.448
Min	.4525	.4525	.4525	.543	.543	.4525	.4525
Avg	.7898	.8190	.7712	.8474	.8679	.7446	.7816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 204 / 11kv Rly Station Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4668	.4668	.462	.4668	.462	.462
2	.4668	.4668	.4668	.462	.4668	.462	.462
3	.3734	.4668	.5601	.5544	.5601	.462	.5544
4	.4668	.5601	.5601	.6468	.5601	.5544	.5544
5	.6535	.7468	.8402	.7392	.6535	.7392	.6468
6	.9335	.9335	.9335	.8316	.8402	.924	.8316
7	.8402	.8402	.8402	.7392	.7468	.8316	.8316
8	.6535	.6535	.5601	.5544	.5601	.6468	.5544
9	.5601	.4668	.5601	.5544	.462	.462	.462
10	.4668	.4668	.4668	.462	.462	.462	.5544
11	.4668	.4668	.4668	.1848	.3696	.462	.4668
12	.4668	.4668	.462	.462	.3696	.462	.3734
13	.3734		.462	.462	.3696	.462	.3696
14	.3734	.4668	.462	.3696	.3696	.462	.3696
15	.3734	.4668	.462	.3696	.3696	.3696	.3734
16	.3734	.3734	.462	.3696	.2772		.3696
17	.4668	.4668	.462	.5544	.3696		.4668
18	.6535		.5544	.5601	.462	.5544	.5601
19	.7468	.8402	.7392	.7468	.7392	.7392	.7468
20	.8402	.8402	.7392	.7468	.7392	.7392	.7468
21	.6535	.7468	.6468	.6535	.6468	.6468	.6535
22	.5601	.6535	.5544	.5601	.5544	.5544	.5601
23	.4668	.5601	.462	.4668	.462	.462	.4668
24	.4668	.4668	.4668	.462	.4668	.462	.462
Max	.9335	.9335	.9335	.8316	.8402	.924	.8316
Min	.3734	.3734	.462	.1848	.2772	.3696	.3696
Avg	.5485	.5856	.5690	.5406	.5143	.5628	.5375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274070 / 33/11 KV NAGANSUR S/STN

Feeder No / Name : 205 / 11 KV Gaudgaon Bk Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.081	.08	.08	.08	.08	.08
2	.0953	.081	.08	.08	.08	.08	.08
3	.0953	.081	.08	.08	.08	.08	.08
4	.0953	.081	.08	.08	.08	.08	.08
5	.0953	.081	.08	.08	.08	.08	.08
6	.0953	.081	.08	.08	.08	.08	.08
7	.0953	.081	.08	.08	.08	.08	.08
8	.0953	.081	.08	.08	.08	.08	.08
9	.0953	.081	.08	.08	.08	.08	.08
10	.0953	.081	.08	.08	.08	.08	.08
11	.5544	.4049	.4001	.4801	.4001	.4001	.4001
12	.8316	.5668	.5601	.5601	.4801	.4801	.5601
13	.7011	.4858	.4801	.4801	.4001	.5601	.4801
14	.4973	.4049	.4801	.5601	.4001	.4801	
15	.4973	.4858	.4801	.4801	.4001	.4001	
16	.4973	.4858	.4001	.5601	.4801		
17	.4973	.4858	.5601	.5601	.4801		.5601
18	.4915	.4858	.5601	.4801	.5601	.5601	.4801
19	.0819	.08	.08	.08	.08	.08	.08
20	.081	.08	.08	.08	.08	.08	.08
21	.081	.08	.08	.08	.08	.08	.08
22	.081	.08	.08	.08	.08	.08	.08
23	.081	.08	.08	.08	.08	.08	.08
24	.0953	.081	.08	.08	.08	.08	.08
Max	.8316	.5668	.5601	.5601	.5601	.5601	.5601
Min	.081	.08	.08	.08	.08	.08	.08
Avg	.2509	.2124	.2167	.2267	.2034	.1891	.1791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 201 / 11 KV MOTYAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0953
2							.0953
3							.0953
4							.0953
5							.0953
6							.1905
7							.1905
8							.1905
9							.1905
10							.1905
11	.1905	.2858	.1905	.1905	.1905	.1905	
12	.381	.2858	.1905	.2858	.2858	.1905	
13	.381	.2858	.1905	.2858	.2858	.2858	
14	.2858	.2858	.1905	.2858	.381	.2858	
15	.2858	.2858	.1905	.2858	.381	.2858	
16	.2858	.2858	.0953	.2858	.381	.2858	
17	.2858	.2858	.2858	.2858	.381	.1905	
18	.2858	.1905	.2858	.1905	.2858	.1905	
Max	.381	.2858	.2858	.2858	.381	.2858	.1905
Min	.1905	.1905	.0953	.1905	.1905	.1905	.0953
Avg	.2977	.2739	.2024	.2620	.3215	.2382	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 202 / 11 KV WAGADARI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147	1.7147	1.5242	1.5242	1.5242	.0953
2	1.9052	1.8099	1.7147	1.5242	1.5242	1.5242	
3	1.9052	1.8099	1.7147	1.5242	1.5242	1.5242	.0953
4	1.9052	1.9052	1.7147	1.5242	1.6194	1.7147	.0953
5	1.9052	2.191	1.7147	1.9052	2.0005	2.0957	.0953
6	2.8578	2.4768	2.6673	2.8578	2.0005	2.572	
7	3.2388	3.9057	3.6199	3.6199	3.2388	3.4294	
8		3.6199	3.4294	2.9531	3.2388	3.2388	
9	.381	2.8578	3.0483	2.7625	3.0483	2.9531	
10	2.0957	2.9531	3.0483	2.8578	3.0483	2.572	
11							3.2388
12							3.5246
20	.0953	.0953	.0953	.0953	.0953	.0953	
21	.0953	.0953	.0953	.0953	.0953	.0953	
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.2388	3.9057	3.6199	3.6199	3.2388	3.4294	3.5246
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.3132	1.7147	1.6575	1.5686	1.5496	1.5750	.8256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 203 / 11 KV SANGAVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.2384	1.5242	1.3336	1.4289	1.2384	.0953
2	1.5242	1.2384	1.5242	1.5242	1.4289	1.3336	.0953
3	1.5242	1.2384	1.5242	1.5242	1.4289	1.3336	.0953
4	1.5242	1.3336	1.5242	1.5242	1.5242	1.4289	.0953
5	1.6194	1.6194	1.6194	1.6194	1.6194	1.6194	.0953
6	1.9052	1.8099	2.0957	1.9052	1.8099	1.8099	
7	2.3815	2.6673	2.4768	2.3815	2.4768	2.4768	
8	2.3815	2.6673	2.572	2.3815	2.0005	2.4768	
9	2.3815	2.191	2.3815	2.3815	2.4768	2.3815	
10	2.191	2.2862	2.191	1.7147	2.3815	2.2862	
11							2.572
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	2.3815	2.6673	2.572	2.3815	2.4768	2.4768	2.572
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.2956	1.2511	1.3273	1.2511	1.2702	1.2574	.3205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 204 / 11 KV Shirwal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.4763	.381	.4763
2	.5716	.4763	.4763	.4763	.4763	.381	.4763
3	.5716	.4763	.5716	.5716	.5716	.4763	.5716
4	.6668	.7621	.7621	.6668	.6668	.6668	.6668
5	.8573	.8573	.9526	.8573	.8573	.8573	.8573
6	1.0479	1.1431	1.0479	.9526	1.0479	.9526	1.0479
7	.8573	1.0479	1.0479	.9526	.9526	.8573	1.0479
8	.7621	.7621	.8573	.7621	.7621	.6668	.8573
9	.6668	.5716	.5716	.6668	.5716	.4763	.6668
10	.4763	.4763	.5716	.5716	.5716	.381	.5716
11	.4763	.381	.381	.4763	.4763	.381	.4763
12	.381	.381	.381	.381	.4763	.381	.4763
13		.381	.381	.381	.381	.381	.4763
14	.381	.381		.381	.381		.4763
15	.381	.2858	.381	.381	.2858		.4763
16	.381	.2858	.381	.381	.2858	.4763	.381
17	.381	.381	.381	.381	.381	.4763	.4763
18	.4763	.4763	.5716	.4763	.381	.4763	.5716
19	.7621	.7621	.7621	.6668	.7621	.7621	.8573
20	.8573	.8573	.8573	.7621	.7621	.8573	.8573
21	.7621	.7621	.6668	.6668	.6668	.7621	.7621
22	.6668	.6668	.5716	.5716	.5716	.6668	.6668
23	.5716	.5716	.5716	.5716	.4763	.5716	.5716
24	.4763	.4763	.4763	.4763	.4763	.4763	.5716
Max	1.0479	1.1431	1.0479	.9526	1.0479	.9526	1.0479
Min	.381	.2858	.381	.381	.2858	.381	.381
Avg	.6047	.5874	.6130	.5795	.5716	.5802	.6390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 205 / 11kv Wagdari Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.381	.381	.381	.381	.381	.381	.381
3	.4763	.4763	.381	.381	.4763	.381	.4763
4	.5716	.4763	.4763	.4763	.5716	.4763	.5716
5	.7621	.4763	.5716	.5716	.6668	.5716	.6668
6	.8573	.7621	.6668	.7621	.7621	.8573	.8573
7	.6668	.8573	.7621	.8573	.6668	.7621	.7621
8	.6668	.7621	.5716	.7621	.6668	.5716	.6668
9	.5716	.5716	.4763	.5716	.4763	.381	.5716
10	.4763	.381	.381	.4763	.4763	.381	.4763
11	.381	.381	.381	.4763	.4763	.381	.381
12	.4763	.381	.381	.4763	.381	.381	.381
13	.381	.381			.381	.381	.381
14	.381	.381	.381	.381	.381	.4763	.381
15	.381	.381	.381		.381	.381	.381
16	.381	.381	.381	.381	.381	.381	.381
17	.381	.381	.381		.381	.4763	.381
18	.381	.4763	.4763	.4763	.4763	.4763	.4763
19	.4763	.6668	.7621	.7621	.5716	.7621	.5716
20	.6668	.7621	.6668	.7621	.5716	.7621	.7621
21	.5716	.5716	.6668	.6668	.6668	.5716	.6668
22	.4763	.4763	.5716	.5716	.4763	.4763	.5716
23	.381	.381	.4763	.381	.381	.381	.4763
24	.4763	.381	.381	.381	.381	.381	.381
Max	.8573	.8573	.7621	.8573	.7621	.8573	.8573
Min	.381	.381	.381	.381	.381	.381	.381
Avg	.5001	.4961	.4929	.5398	.4922	.4922	.5160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274071 / 33/11 KV SHIRWAL S/S

Feeder No / Name : 206 / 11kv Borgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	1.3336
2	.0953	.0953	.0953	.0953	.0953	.0953	1.3336
3	.0953	.0953	.0953	.0953	.0953	.0953	1.3336
4	.0953	.0953	.0953	.0953	.0953	.0953	1.4289
5	.0953	.0953	.0953	.0953	.0953	.0953	1.5242
6							1.7147
7							2.191
8							2.2862
9							2.191
11	2.7625	2.2862	2.2862	2.0005	2.2862	2.2862	
12	3.2388	2.6673	2.6673	2.8578	2.8578	2.8578	
13	3.0483	2.4768	2.6673	2.9531	2.9531	2.8578	
14	3.0483	2.4768		2.9531	2.8578		
15	2.572			2.8578	2.572	2.4768	
16	2.572	1.5242	1.3336	2.8578	2.572	2.9531	
17	2.6673	2.0957	2.2862	2.7625	2.4768	2.7625	
18	2.3815	2.0957	2.2862	2.2862	2.3815	2.4768	
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.2388	2.6673	2.6673	2.9531	2.9531	2.9531	2.2862
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.2913	.9750	.9050	1.2490	1.2172	1.1544	1.1295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 201 / 11 KV TADWAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.382	1.2186	1.5158	1.5009	1.4861	1.5306	.104
2	1.3969	1.2616	1.5158	1.5306	1.5306	1.5604	.104
3	1.4266	1.3077	1.5455	1.5653	1.5604	1.5901	.104
4	1.4712	1.4118	1.5455	1.5604	1.6049	1.6049	.1189
5	1.6049	1.4415	1.5752	1.5901	1.6347	1.6347	.1337
6	1.7833	1.5604	1.6049	1.6495	1.709	1.6347	.1486
7	1.9616	1.9913	2.021	2.021	1.7833	2.0805	
8	2.0656	2.1824	2.1548	2.2439	1.8278	2.1102	
9	2.0508	2.1072	2.0656	2.1696	2.0656	2.0656	
10	2.0062	2.021	1.9913	2.0805	2.021	2.0656	
11							1.917
12							1.9319
13							1.9467
14						2.0508	1.9467
15						2.0805	1.9467
16						2.0805	
17						2.0953	1.917
18						2.0508	1.8873
19	.104	.1189	.104	.1337	.1337	.104	.1337
20	.1189	.1189	.1189	.1337	.1337	.104	.1337
21	.1189	.1189	.104	.1189	.1189	.104	.1189
22	.1189	.1189	.104	.104	.104	.104	.1189
23	.1189	.1189	.104	.104	.104	.104	.1189
24	.104	1.0997	.104	.1189	.104	.104	.104
Max	2.0656	2.1824	2.1548	2.2439	2.0656	2.1102	1.9467
Min	.104	.1189	.104	.104	.104	.104	.104
Avg	1.1145	1.1374	1.1359	1.1641	1.1201	1.3742	.7860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 202 / 11 KV KHANAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1109	.0943	.0754	.0762	.0762	.9602
2	.0754	.0924	.0754	.0754	.0762	.0762	.9907
3	.0943	.0924	.0754	.0754	.0762	.0762	.9907
4	.0943	.0924	.0754	.0754	.0762	.0762	1.0059
5	.0943	.0934	.0943	.0754	.0762	.0762	1.0059
6	.0943	.112	.0943	.0754	.0762	.0762	1.0212
7							1.2955
8							1.8673
9							1.2955
10							1.2498
11	1.6632	1.773	1.773	1.1888	1.5089	1.7164	
12	1.7737	1.8484	1.8673	1.6004	1.5851	1.9616	
13	1.7551	1.8296	1.9616	1.5699	1.5851	1.9239	
14	1.8111	1.8861	1.9427	1.4632	1.5699		
15	1.7551	1.8673	1.9805	1.4784	1.5699		
16	1.7924	1.8484	1.9616	1.5089	1.5699		
17	1.8111	1.8107	1.9427	1.6461	1.5851		
18	1.8111	1.8673	1.9427	1.5851	1.5851		
19	.1109	.132	.132	.1219	.0914	.0762	.1132
20	.1109	.1132	.1132	.0914	.1067	.0762	.1132
21	.1109	.1132	.132	.1067	.0914	.0762	.1132
22	.1109	.1132	.132	.1067	.0762	.0762	.1132
23	.1109	.1132	.1132	.0762	.0762	.0762	.1132
24	.0943	.1109	.1132	.0754	.0762	.0762	.0762
Max	1.8111	1.8861	1.9805	1.6461	1.5851	1.9616	1.8673
Min	.0754	.0924	.0754	.0754	.0762	.0762	.0762
Avg	.7675	.801	.8308	.6536	.6767	.4344	.7703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 203 / 11 KV MHAISALGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.108	.108	.0617	.0772	.0772	1.5432
2	.0926	.0772	.0617	.0617	.0772	.0772	1.5432
3	.0926	.0772	.0617	.0617	.0617	.0772	1.5586
4	.108	.0772	.0617	.0617	.0617	.0772	1.5586
5	.1235	.0937	.0617	.0463	.0463	.0772	1.5741
6	.1389	.0937	.0617	.0617	.0463	.0617	1.5741
7							1.8827
8							2.0062
9							2.037
10							2.0216
11	2.0622	2.037	2.0833	1.8056	1.8519	2.1914	
12	2.234	2.284		2.1296	2.2068	2.3148	
13	2.3122	2.3611	2.2377	2.1296	2.2068	2.392	
14	2.3434	2.3765	2.2531	2.1142	2.1605		
15	2.3746	2.3303	2.037	2.2068	2.1451		
16	2.4215	2.3148	2.1451	2.3303	2.2377		
17	2.4528	2.2994	2.1605	2.3457	2.4074		
18	2.4215	2.2685	2.1759	2.2222	2.3148		
19	.1543	.1698	.0926	.1235	.1543	.108	.1389
20	.1543	.1543	.0926	.1235	.1543	.1235	.1389
21	.1543	.1543	.0926	.1235	.1389	.1235	.1389
22	.1543	.1543	.0926	.0926	.1389	.1235	.1389
23	.1543	.1543	.0772	.0772	.1235	.1235	.1389
24	.0617	.1235	.1389	.0772	.0772	.108	.1235
Max	2.4528	2.3765	2.2531	2.3457	2.4074	2.392	2.037
Min	.0617	.0772	.0617	.0463	.0463	.0617	.1235
Avg	1.0052	.9855	.8471	.9128	.9344	.5371	1.1323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 204 / 11 KV MANGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9442	.9014	.8962	.9282	1.0883	1.0802	.128
2	.9922	.9172	.9282	.9602	1.1203	1.1523	.128
3	1.0402	.9804	.9282	.9922	1.1523	1.1683	.128
4	1.1043	1.0722	.9602	1.0242	1.1683	1.1843	.128
5	1.142	1.0883	1.0242	1.0562	1.1683	1.2003	.144
6	1.2803	1.1203	1.1043	1.2483	1.1683	1.2163	.16
7	1.4883	1.7124	1.6964	1.5844	1.5524	1.8884	
8	1.5203	1.7604	1.7444	1.8564	1.4243	1.8244	
9	1.4563	1.6004	1.6964	1.6804	1.6804	1.6964	
10	1.3923	1.5339	1.3283	1.5524	1.5203	1.6324	
11							1.6164
12							1.6164
13							1.6004
14						1.2483	1.5684
15						1.5203	1.5203
16						1.5203	1.5684
17						1.5043	1.6964
18						1.5684	1.6804
19	.16	.16	.16	.176	.176	.144	.16
20	.176	.176	.16	.176	.176	.144	.16
21	.176	.16	.144	.16	.16	.128	.16
22	.1581	.144	.144	.1389	.128	.128	.144
23	.1581	.128	.128	.128	.128	.128	.128
24	.128	.8697	.128	.128	.128	.128	.1235
Max	1.5203	1.7604	1.7444	1.8564	1.6804	1.8884	1.6964
Min	.128	.128	.128	.128	.128	.128	.1235
Avg	.8323	.8953	.8232	.8619	.8712	1.0574	.7279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 205 / 11KV TADWAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4938	.5121	.6401	.4938	.5487	.4938
2	.567	.5121	.5487	.6767	.5487	.5853	.5853
3	.6401	.5853	.6584	.7499	.5853	.6401	.6401
4	.7316	.7023	.7682	.8596	.6767	.6767	.695
5	.8413	.8131	.823	1.0059	.7865	.7865	.7865
6	.9145	.8686	.8413	.9511	.9877	.9328	.8596
7	.6036						
9	.4938	.4938	.6584	.567	.5853	.6584	.5304
10	.4572	.4024	.5853	.5487	.567	.5487	.5487
11	.4024	.4572	.4938	.439		.4938	.4755
12	.3841	.4755	.439	.3841	.3841	.5304	.4755
13	.439	.4572	.439	.4572	.5121	.4755	.4572
14	.4024	.4572	.3658	.4207	.4572	.4207	.4755
15	.4024	.4572	.3841	.4207	.439	.4207	.4024
16	.439	.4024	.3841	.4207	.4572	.4024	.3841
17	.4207	.3292	.4024	.439	.4755	.3841	.4207
18	.5487		.4755	.5121	.5304	.4572	.4024
19	.6838	.7865	.7499	.6019	.7682	.695	.6219
20	.7023	.9145	.8413	.7316	.7316	.7133	.7316
21	.6653	.695	.7682	.6767	.7316	.6401	.6767
22	.567	.6219	.7133	.6584	.7133	.6219	.6036
23	.5487	.5487	.6584	.5487	.5487	.5487	.5487
24	.5304	.5121	.5304	.6401	.4572	.4938	.4572
Max	.9145	.9145	.8413	1.0059	.9877	.9328	.8596
Min	.3841	.3292	.3658	.3841	.3841	.3841	.3841
Avg	.5623	.5708	.5928	.6068	.5922	.5761	.5578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274072 / 33/11 KV TADWAL SUBSTATION

Feeder No / Name : 207 / 11 KV Mangrul Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.1612	.1791	.1791	.197	.1791	.1254
2	.197	.197	.2149	.1791	.2328	.2149	.1254
3	.2149	.2328	.2507	.2149	.2686	.2507	.2686
4	.2686	.3077	.2865	.2865	.2865		.3045
5	.3045	.3258	.3224	.3403	.3224	.3045	.3224
6	.3582	.362	.3403	.3403	.3582	.3582	.3582
7	.197						
8	.1433						
9	.1612	.1267	.2149	.1075	.1791	.1791	.1612
10	.1612	.181	.197	.197	.1612	.1791	.1791
11	.1075	.1433	.1433	.1433	.1612	.1433	.1612
12	.1254	.1433	.1612	.1433	.1254	.1433	.1612
13	.1448	.1433	.1433	.1612	.1612	.1433	.1612
14	.1254	.1612	.1433	.1433	.1433	.1433	.1791
15	.1254	.1433	.1433	.1433	.1433	.1433	.1612
16	.1254	.1433	.1433	.1254	.1612	.1433	.1433
17	.1075	.1433	.1433	.1254	.1791	.1433	.1433
18	.197	.1612	.1612	.1791	.1612	.1791	.1612
19	.2715	.2507	.2149	.2328	.2686	.2507	.2507
20	.3077	.3045	.2865	.2686	.3045	.2686	.3045
21	.2715	.2686	.2507	.2507	.2507	.2328	.2865
22	.2353	.2328	.2149	.2328	.2328	.2149	.2507
23	.1991	.197	.1791	.1791	.1791	.1791	.2328
24	.197	.1791	.1791	.1791	.1791	.1791	.1791
Max	.3582	.362	.3403	.3403	.3582	.3582	.3582
Min	.1075	.1267	.1433	.1075	.1254	.1433	.1254
Avg	.1976	.2050	.2051	.1978	.2117	.1987	.2100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 201 / 11 KV HILLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.9431	.4287	.4287	.7716	.6859	.0343
2	.6001	.9602	.6001	.463	.8573	.7716	.0343
3	.6859	.9602	.6859	.5487	.9088	.823	.0343
4	.823	.9774	.7716	.583	.9602	.823	.0857
5	.8916	.9774	.7716	.6001	.9945	.7716	.0514
6	.9945	1.0288	.823	.6344	1.0288	.6859	.0514
7	1.0288	1.0288	.8916	.9431	1.0802	1.0288	.0343
8	1.1317	1.0631	.9431	1.1488	.6859	1.1145	.0343
9	1.1145	1.0288	.9431	1.1317	.9945	1.1145	.0343
10	1.1145	1.0288	.9259	1.0288	1.0288	1.0288	.0381
11	.0381	.0343	.0171	.0381	.0686	.0343	.9431
12	.0381	.0343	.0171	.0381	.0514	.0171	1.0288
13	.0381	.0343	.0171	.0381	.0343	.0171	.9259
14	.0381	.0343	.0171	.0381	.0343	.0171	.9088
15	.0381	.0343	.0171	.0381	.0343	.0171	.8573
16	.0381	.0343	.0171	.0381	.0343	.0171	.8573
17	.0381	.0343	.0171	.0381	.0343	.0171	.8402
18	.0381	.0343		.0953	.0343	.0343	.7716
19		.0343	.0343	.1143	.0343	.0514	.0381
20	.0381	.0343	.0343	.0762	.0343	.0514	.0381
21	.0381	.0343	.0343	.0762	.0343	.0514	.0381
22	.0381	.0343	.0343	.0572	.0343	.0343	.0381
23	.0381	.0343	.0171	.0572	.0343	.0343	.0191
24	.0171	.0381	.0343	.0343	.0572	.0343	.0343
Max	1.1317	1.0631	.9431	1.1488	1.0802	1.1145	1.0288
Min	.0171	.0343	.0171	.0343	.0343	.0171	.0191
Avg	.4075	.4367	.3519	.3453	.4110	.3865	.3238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 202 / 11 KV HANDRAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0381	.0514	.0343	.1886	.0343	.4287
2	.0343	.0381	.0514	.0343	.1886	.0343	.5144
3	.0343	.0381	.0514	.0343	.1715	.0343	.6001
4	.0343	.0381	.0514	.0343	.1715	.0343	.6173
5	.0343	.0381	.0514	.0343	.1715	.0343	.6516
6	.0343	.0381	.0514	.0514	.1886	.0343	.703
7	.0343	.2286	.0514	.0514	.2058	.0343	.7716
8	.0343	.1524	.0514	.0343	.2229	.0343	.7545
9	.0381	.0514	.0514	.0343	.2743	.0343	.7888
10	.0381	.0514	.0343	.0381	.0686	.0343	.8059
11	3.4008	.7202	.703	.7716	.6001	.4287	.0953
12	3.4332	.7545	.9945	.8402	.703	.5144	.1334
13	3.2388	.6859	.8916	.8573	.7716	.6001	.0953
14	3.083	.7545	.8573	.8916	.6859	.6859	.0953
15	3.0639	.7202	.7716	.9259	.7202	.703	.0953
16	3.0967	.6859	.7202	.8916	.6859	.7373	.1524
17	3.2922	.6859	.7373	.8573	.8573	.7716	.1715
18	3.3436	.7202	.7716	.823	.0343	.8573	.1715
19	.0572	.0857	.0343	.7888	.0343	.0343	.2096
20	.0381	.0514	.0343	.1715	.0343	.0343	.1715
21	.0381	.0514	.0343	.1886	.0343	.0343	.1715
22	.0381	.0514	.0343	.1886	.0343	.0343	.1524
23	.0381	.0514	.0343	.2058	.0343	.0343	.1334
24	.0343	.0381	.0514	.0343	.2058	.0343	.0343
Max	3.4332	.7545	.9945	.9259	.8573	.8573	.8059
Min	.0343	.0381	.0343	.0343	.0343	.0343	.0343
Avg	1.1061	.2820	.2986	.3674	.3036	.2436	.3549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 203 / 11 KV AHERWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514		.0686	.0686	.0686	.0686	.5144
2	.0514		.0686	.0686	.0572	.0686	.6001
3	.0686		.0686	.0686	.0572	.0686	.6859
4	.0686		.0686	.0686	.0762	.0857	.7716
5	.0857		.0686	.0857	.0762	.0857	.823
6	.0857		.0686	.0857	.0762	.0857	
7	.1029		.0686	.0857	.0953	.0857	1.0974
8	.0686		.0686	.0686	.0762	.0857	1.0974
9		.0514	.0514	.0686	.0686	.0686	1.0288
10		.0514	.0514	.0762	.0686	.0514	1.0288
11		.9431	.9602	1.0288	.8916	.9088	.0572
12		1.0631	1.0288	1.0631	.9945	.8573	.0572
13		.9945	.9774	1.1145	.9602	.8916	.0762
14		1.0631	.9259	1.2003	.8916	.8745	.0762
15		.9088	.8916	1.2346	.8573	.8916	.0762
16		.7716	1.046	1.286	.8916	.9602	.0762
17		.9431	1.0631	1.2346	.9602	.9945	.0762
18		1.0288	1.1145	1.2517	.9259	1.0288	.0762
19		.0857	.0686	1.2689	.0686	.1029	.0953
20		.0857	.0857	.0762	.0686	.1029	.0762
21		.0857	.1029	.0953	.0686	.0857	.0762
22		.0857	.1029	.0381	.0686	.0857	.0572
23		.0686	.0857	.0953	.0686	.0686	.0572
24	.0514		.0686	.0686	.0686	.0686	.0514
Max	.1029	1.0631	1.1145	1.286	.9945	1.0288	1.0974
Min	.0514	.0514	.0514	.0381	.0572	.0514	.0514
Avg	.0705	.5487	.3822	.4917	.3544	.3615	.3753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 204 / 11KV KARJAGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086		.3258	.1886	.3772	.3429	.1886
2	.2572		.3258	.1886	.4801	.4115	.2058
3	.3086		.3429	.2572	.4801	.4801	.2572
4	.3429		.3429	.3601	.5316	.5144	.3086
5	.4115		.3772	.463	.5316	.6173	.463
6	.5316		.4115	.6344	.5487	.6687	.703
7	.6344		.4115	.6859	.6001	.6001	.6173
8	.5487		.463	.6001	.4458	.5316	.5316
9		.4458	.4115	.5316	.3601	.4801	.3944
10		.4115	.4287	.4801	.3429	.463	.3601
11		.3429	.3772	.4287	.3601	.3944	.3601
12		.3772	.3429	.4115	.3429	.3601	.3429
13		.3772	.3429	.4458	.3944		.3429
14		.3429	.3429	.463	.3429	.3601	.4287
15		.3258	.3429	.4801	.3429	.3429	.4801
16		.3601	.3429		.3086	.3429	.5144
17		.3601	.3258	.5144		.3601	.5316
18		.3429	.3258	.5144	.3601	.3772	.5316
19		.5316	.463	.5316	.3601	.3944	.5658
20		.5144	.5316	.3429	.3772	.5487	.5144
21		.4801	.4801	.4287	.3944	.4458	.4801
22		.4458	.3772	.4115	.4115	.3429	.3429
23		.3772	.3086	.3772	.3429	.3086	.3772
24	.3429		.3086	.2058	.3429	.3429	.2058
Max	.6344	.5316	.5316	.6859	.6001	.6687	.703
Min	.2572	.3258	.3086	.1886	.3086	.3086	.1886
Avg	.4096	.4024	.3772	.4324	.4078	.4361	.4187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 205 / 11 KV HILLI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.1886	.1715	.1715	.1715	.1715
2	.1886	.2401	.1886	.1715	.2286	.2401	.1715
3	.2572	.2572	.2401	.1715	.2572	.2743	.1886
4	.3086	.2915	.2743	.3086	.2743	.3086	.2572
5	.3258	.3086	.3086	.3772	.2915	.3772	.3601
6	.3601	.3772	.3772	.463	.3429	.4458	.4458
7	.4287	.4458	.3429	.4458	.4287	.4115	.4115
8	.3429	.7544	.3772	.3772	.2743	.3601	.3429
9	.2401	.2743	.3086	.2915	.2572	.2915	.2572
10	.2058	.2229	.2229	.2572	.2572	.2743	.2401
11	.1886	.1886		.2286	.1886	.1886	.2229
12	.1543	.1886	.1886	.1905	.2058	.1715	.1886
13	.1543		.1886	.2286	.1886	.1715	.2058
14	.1543		.2058	.2858	.1886	.1886	.2572
15	.1543	.1543	.2058	.3048	.1715	.1886	.2572
16	.1543	.2058	.2058	.3239	.1886	.2058	.2743
17	.2572		.2229	.362	.2743	.2401	.3429
18	.3086		.2572	.3429	.3258	.2743	.3772
19	.3772	.3772	.3601	.3429	.3429	.3429	.4115
20	.3772	.3429	.3601	.2572	.2743	.3772	.3258
21	.3429	.3086	.3429	.2401	.3086	.2572	.3086
22	.3429	.2401	.3086	.2229	.2401	.2229	.2743
23	.3086	.1886	.2572	.2058	.1886	.2058	.2743
24	.1715	.2286	.1886	.1715	.1886	.2058	.1715
Max	.4287	.7544	.3772	.463	.4287	.4458	.4458
Min	.1543	.1543	.1886	.1715	.1715	.1715	.1715
Avg	.2629	.2918	.2661	.2809	.2524	.2665	.2808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274086 / 33/11 KV KARAJGI

Feeder No / Name : 206 / 11 KV JEUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	1.0288	.6001	.5144	.6859	.7716	.0857
2	.703	.6001	.7716	.6001	.8059	.7716	.0857
3	.8059	1.1145	.9431	.703	.9431	.8573	.0857
4	.9431	1.2003	.9945	.8745	1.0288	.8916	.0857
5	1.046	1.2346	1.1145	.9259	1.1145	.9431	.0857
6	1.3203	1.286	1.2346	.9774	1.2003	1.0288	.0857
7	1.3717	1.286	1.286	1.406	1.3717	1.3717	.0857
8	1.5432	1.3717	1.406	1.4575	2.7434	1.406	.0857
9	1.3889	1.2346	1.2003	1.2346	1.2003	1.0288	.0857
10	1.3717	1.2003	1.2003	1.2003	.0514	1.046	.0953
11	.0953	.0686	.0857	.0953	.0514	.0857	1.3336
12	.0953	.0686	.0857	.0953	.0514	.0857	1.3717
13	.0953	.0686	.0857	.0953	.0686	.0857	1.2003
14	.0953	.0686	.0857	.0953	.0686	.0857	1.286
15	.0953	.0857	.0857	.0953	.0686	.0857	1.1145
16	.0953	.0686	.0857	.0953	.0686	.0857	1.2003
17	.0953	.0686	.0857	.0953	.0686	.0572	1.2003
18	.0953	.0686	.0857	.0953	.0686	.0857	1.0288
19	.0953	.1029	.0857	.0953	.0686	.0857	.0953
20	.0953	.1029	.0857	.0953	.0686	.0857	.0953
21	.0953	.0857	.0857	.0953	.0343	.0857	.0953
22	.0953	.0857	.0857	.0953	.0686	.0857	.0953
23	.0953	.0857	.0857	.0953	.0686	.0857	.0953
24	.0857	.0953	.0857	.0857	.0953	.0857	.0857
Max	1.5432	1.3717	1.406	1.4575	2.7434	1.406	1.3717
Min	.0857	.0686	.0857	.0857	.0343	.0572	.0857
Avg	.5174	.5284	.4980	.4674	.5027	.4703	.4652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 201 / 11 KV SHEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.647	1.2955	1.2651	1.2803	.0867	.7011
2	1.4575	1.647	1.2955	1.2498	1.2955	1.5432	.7011
3	1.4403	1.647	1.2955	1.2651	1.2955	1.5432	.7011
4	1.6385	1.7337	1.2955	1.2651	1.2955	1.5432	.724
5	1.6004	1.7337	1.4575	1.406	1.4575	1.5432	.7011
6	1.7004	1.8652	1.8023	1.6975	1.7204	1.7804	.7011
7	1.9433	1.95	1.8842	1.7185	1.8842	1.95	
8	1.9662	2.0348	1.9662	1.8185	1.8842	2.0348	
9	1.9433	2.1195	1.9662	1.8747	1.95	1.8976	
10	1.8652	1.9662	1.8976	1.8023	1.8652	1.6404	
11							1.6385
12							1.9433
13							2.0005
14							1.9204
15							2.0243
16							2.0481
17	.3696	.5487	.5258	.5487	.5487	.8764	1.9662
18	.462	.5487	.6935	.6401	.6401	.6935	2.0719
19	.6401	.6401	.6068	.7316	.7316	.7087	.7802
20	.6401	.6401	.6135	.7316	.7316	.7011	.7888
21	.6401	.6401	.6201	.7316	.7316	.7087	.8573
22	.6401	.7316	.6068	.7316	.6401	.6935	.8669
23	.5487	.7316	.6201	.6401	.6401	.7011	.8669
24	.4287	.5316	.6401	.6135	.5487	.6401	.7011
Max	1.9662	2.1195	1.9662	1.8747	1.95	2.0348	2.0719
Min	.3696	.5316	.5258	.5487	.5487	.0867	.7011
Avg	1.1888	1.2976	1.1713	1.1517	1.1745	1.1825	1.2352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 202 / 11 KV S.JAWALAGE MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.724	.9602	.6325	.9602	.905	.3506
2	1.7194	.724	.9602	.6249	.9602	.905	.3506
3	.905	.724	.9602	.6325	.9717	.905	.3506
4	.905	.905	1.1203	.7116	.9717	.905	.3506
5	1.086	.905	1.1203	.7116	.9717	.905	.3544
6	1.2136	1.267	1.2803	.7116	1.1336	1.2269	.3506
7	1.5604	1.7337	1.6385	1.2651	1.6385	1.647	
8	1.7337	1.5604	1.6385	1.5813	1.2955	1.5604	
9	1.5604	1.5604	1.4575	1.7394	1.5604	.7907	
10	1.387	1.2803	.6325	1.2955	1.387	.6325	
11							1.326
12							1.1469
13							.9831
14							.9945
15							.9116
16							.9945
17	.3696	.4572	.3506		.3696	.3506	.9831
18	.3696	.4572	.3544		.3696	.3506	.9717
19	.7316	.4572	.3544		.5544	.3506	.3467
20	.7316	.4572	.3467	.4572	.5544	.2629	.4287
21	.5487	.4572	.3544	.4572	.5544	.3544	.4334
22	.5487	.4572	.3544	.4572	.462	.3506	.4334
23	.462	.4572	.3544	.4572	.462	.3506	.4334
24	.462	.462	.4572	.3506	.4572	.462	.3506
Max	1.7337	1.7337	1.6385	1.7394	1.6385	1.647	1.326
Min	.3696	.4572	.3467	.3506	.3696	.2629	.3467
Avg	.9505	.8359	.8164	.8057	.8686	.7342	.6423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 203 / 11 KV KORSEGAON MIX AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.2772	.2743	.2629	.2743	.2801	1.2651
2	.2629	.2772	.2743	.2629	.2743	.2801	1.2651
3	.2601	.2772	.2743	.2629	.2743	.2801	1.2651
4	.2572	.2772	.3658	.2629	.2743	.2801	1.2651
5	.3467	.3696	.3658	.2629	.2743	.2801	1.2651
6	.3506	.3696	.3658	.2629	.2743	.3734	1.2651
7			.3658	.2629	.1829		1.2651
8			.3658	.2629	.1829		1.2651
9			.2743	.1753	.1867		1.3108
10			.1753	.1829	.1867		1.3765
11	1.3003		1.186	1.2146	1.4737		
12	1.387	1.1203	1.186	1.2955	1.5604	1.2651	
13	1.5604	1.1203	1.186	1.4575	1.5604	1.2651	
14	1.5604	1.2803	1.2651	1.4575	1.5604	1.2651	.1734
15	1.4737	1.4403	1.3441	1.4575	1.4737	1.2498	.1715
16	1.387	1.2803	1.2498	1.3765	1.5604	1.3441	.1715
17	1.387	1.2803	1.4232	1.2955	1.4737	1.2651	
18	1.387	1.2003	1.3441	1.2955	1.5604	1.2651	
19	.3696		.2658	.1829	.2801		
20	.3696	.3658	.2629	.2743	.2801	.1772	.3467
21	.3696	.3658	.2658	.2743	.2801	.2658	.3506
22	.3696	.3658	.2629	.2743	.2801	.2629	.3429
23	.2772	.2743	.2629	.1829	.2801	.2629	.3467
24	.2601	.2772	.2743	.2629	.2743	.2801	.2658
Max	1.5604	1.4403	1.4232	1.4575	1.5604	1.3441	1.3765
Min	.2572	.2743	.1753	.1753	.1829	.1772	.1715
Avg	.7598	.6788	.6200	.6151	.6785	.6635	.8321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 204 / 11 KV KUMTHA MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0914	.0088	.0914	.0953	.3163
2	.0953	.0953	.0914	.0088	.0914	.0953	.3125
3	.0953	.0953	.0914	.0088	.0914	.0953	.3086
4	.0953	.0953	.0914	.0088	.0914	.0953	.3163
5	.0953	.0953	.0914	.0088	.0914	.0953	.3086
6	.0953	.0953	.0914	.0088	.0914	.0953	.3125
7							.3163
8							.3163
9							.3163
10							.3315
11	.2772	.2372	.3163	.3201	.2772	.3163	
12	.2772	.2401	.3125	.3201	.2801	.3163	
13	.2772	.2401	.3163	.3201	.3696	.3125	
14	.2772	.2401	.3163	.3201	.3696	.3163	.0857
15	.2772	.2401	.3086	.3201	.3696	.3125	.0867
16	.2772	.2401	.3163	.3201	.3696	.3125	.0857
17	.2772	.3201	.3163	.3201	.3696	.3163	
18	.2772	.3201	.3163	.3239	.3696	.3125	
19	.0953				.0953		
20	.0953	.0914	.0088	.0914	.0953	.0088	
21	.0953	.0914	.0088	.0914	.0953	.0088	
22	.0953	.0914	.0088	.0914	.0953	.0088	
23	.0953	.0914	.0088	.0914	.0953	.0088	
24	.0953	.0953	.0914	.0089	.0914	.0953	.0088
Max	.2772	.3201	.3163	.3239	.3696	.3163	.3315
Min	.0953	.0914	.0088	.0088	.0914	.0088	.0088
Avg	.1681	.1637	.1681	.1575	.1946	.1693	.2444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274103 / 33/11 KV KORSEGAON S/S

Feeder No / Name : 205 / 11 KV KALKARJAL MIX FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0867	.1334	.0914	.1753	.0914	.0953	.4744
2	.0867	.1334	.0914	.1753	.0914	.0953	.4687
3	.0876	.0953	.0914	.1753	.0914	.0953	.4744
4	.0867	.1334	.0914	.1753	.0914	.0953	.463
5	.0867	.1334	.0914	.1753	.0914	.0953	.4687
6	.0867	.0953	.0914	.1753	.0914	.0953	.4687
7							.4744
8							.4744
9							.5535
10							.4915
11	.6335	.4801	.4744	.4801	.5487	.4744	
12	.6335	.5601	.4744	.4801	.6401	.463	
13	.6335	.5601	.5535	.5601	.5487	.4744	
14	.6335	.5601	.5535	.5601	.5487	.4744	.0867
15	.6335	.5601	.6173	.4801	.5487	.4744	.0867
16	.6335	.4801	.4687	.4801	.5487	.4744	.0857
17	.543	.4801	.4744	.4801	.5487	.4744	
18	.543	.4801	.4744	.4001	.5487	.4744	
19	.0953				.0953		
20	.0953	.0914	.0088	.0914	.0953	.0088	.0867
21	.1334	.0914	.0088	.0914	.0953	.0087	.0857
22	.1334	.0914	.0089	.0914	.0953	.0088	.0857
23	.1334	.0914	.0088	.0914	.0953	.0088	.0867
24	.0867	.1334	.0914	.181	.0914	.0953	.0088
Max	.6335	.5601	.6173	.5601	.6401	.4744	.5535
Min	.0867	.0914	.0088	.0914	.0914	.0087	.0088
Avg	.3043	.2834	.2508	.2905	.2799	.2361	.3014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 201 / 11 KV RUDDREWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	.3696	1.1088	1.3443	1.1203	1.4937	1.1949
2	1.307	.9335	1.2012	1.5089	1.4003	1.4937	1.307
3	1.5154	1.3817	1.2136	1.5089	1.6263	1.386	1.6263
4	1.9959	1.6461	1.307	1.9044	1.848	1.4784	1.7193
5	2.0485	1.9909	1.386	2.2177	2.0119	1.6461	1.9281
6	2.3529	1.7528	1.6461	2.2382	2.1033	2.1033	1.95
7	2.3739	1.8652	2.4691	2.3537	1.8652	2.3739	2.0553
8	2.2939	2.1795	2.1195	2.3594	2.5149	2.3758	1.9989
9	1.9433	2.2119	2.1365	1.6385	2.2939	2.1052	2.0481
10	2.1052	2.0481	1.9662	1.4575	1.8842	1.9433	1.8023
19	.037	.0732	.0373		.0732	.0366	.0377
20	.037	.0732	.056		.0732	.0366	.0373
21	.037	.0739	.0554		.0739	.037	.0373
22	.0373	.0747	.0554		.0739	.0373	.0373
23	.037	.0747	.056		.0747	.0373	.0373
24	.0373	.0373	.0747	.056	.0377	.0747	.0377
Max	2.3739	2.2119	2.4691	2.3594	2.5149	2.3758	2.0553
Min	.037	.0373	.0373	.056	.0377	.0366	.0373
Avg	1.2073	1.0491	1.0556	1.6898	1.1922	1.1662	1.1159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 202 / 11 KV BOROTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.037	.0754	.0373	.0373	.0747	.0373
2	.0373	.037	.0754	.0377	.037	.0739	.0373
3	.0377	.0373	.0754	.0373	.0373	.0739	.0377
4	.0377	.0373	.0747	.0373	.037	.0747	.0377
11	1.2936		1.6632	1.4784	1.4632	.7392	1.4632
12	1.829	1.7375	2.1216	1.829	2.0157	2.0119	1.9281
13	1.8652	1.6461	1.9631	1.7804	1.7804	1.7878	
14	1.8023	1.6108		1.8442	1.9281	1.7295	
15	1.1469	1.1869	1.6712	1.9662	1.7404	1.7101	
16	1.2955	1.326	1.704	1.6385	1.4746	1.7368	
17	1.1336	1.4746	1.7166	1.7814	1.5565	1.704	
18	1.4575	1.5384	1.749	1.7814	1.3927	1.704	
19	.037	.0739	.0366	.0366	.0732	.0366	.0366
20	.0366	.0739	.037	.0366	.0732	.0366	.037
21	.037	.0747	.037		.0739	.037	.0373
22	.0366	.0747	.0373	.037	.0747	.0373	.0377
23	.0373	.0747	.0373	.0373	.0747	.0373	.0377
24	.0373	.037	.0747	.0377	.0373	.0747	.0373
Max	1.8652	1.7375	2.1216	1.9662	2.0157	2.0119	1.9281
Min	.0366	.037	.0366	.0366	.037	.0366	.0366
Avg	.6775	.6516	.7735	.8491	.7726	.76	.3137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 203 / 11 KV DUDHANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.5975	.5914	.3206	.6283	.4481
2	.3326	.5544	.6348	.415	.6348	.5228
3	.4481	.5228	.7316	.5914	.5975	.5975
4	.5175	.5175	.7682	.6584	.5544	.6584
5	.6036	.5487	.7602	.6661	.5853	.7316
6	.7133	.7682	.7964	.6783	.631	.7362
7	.6783	.763	.78	.7042	.7888	.7461
8	.7045	.7459	.8048	.7045	.7373	.7461
9	.7287	.7865	.8192	.6554	.6554	.7373
10	.7287	.6802	.7701	.5668	.6478	.7701
19	.0366	.0366	.0366	.0362	.0362	.0373
20	.0366	.0366	.0366	.0366	.037	.0373
21	.037	.037		.037	.0373	.0377
22	.0373	.0373	.0373	.0373	.0373	.0377
23	.0373	.0373	.0373	.0373	.0373	.0377
24	.0373	.0377	.0377	.0373	.0377	.0377
Max	.7287	.7865	.8192	.7045	.7888	.7701
Min	.0366	.0366	.0366	.0362	.0362	.0373
Avg	.3712	.4192	.5095	.3864	.4177	.4325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 205 / Kallappawadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0373	.0566	.0747	.0373	.0377	.0747
2	.056	.0373	.0566	.0747	.0373	.0377	.0747
3	.0554	.0373	.056	.056	.0377	.0377	.0747
4	.0554	.037	.056	.0554	.037	.0377	.0754
11	.9979	.8402	1.0349	1.2936	.924	.4108	1.0269
12	1.4969	1.3306	1.4045	1.3121	1.3169	1.2197	1.5123
13	1.5546	1.3717	1.3169	1.2803	1.2717	1.4266	
14	1.3735	1.3672		1.2039	1.1869	1.2548	
15	1.278	1.2209	1.1469	1.1934	1.1271	1.2209	
16	.9717	1.1869	1.1469	1.1603	1.1603	1.1603	
17	1.0159	.8192	1.1142	1.1305	1.1469	1.0486	
18	1.1012	.9012	1.0688	.9393	.9175	.9831	
19	.0366	.0732	.0549	.0366	.0549	.0549	.0373
20	.0366	.0739	.0739	.0366	.0549	.0747	.0373
21	.037	.0739	.0747	.037	.0554	.0747	.0377
22	.037	.0747	.0747	.0373	.056	.0754	.0377
23	.037	.0747	.0754	.0373	.056	.0754	.0373
24	.0554	.037	.0754	.0754	.0373	.0373	.0754
Max	1.5546	1.3717	1.4045	1.3121	1.3169	1.4266	1.5123
Min	.0366	.037	.0549	.0366	.037	.0373	.0373
Avg	.5696	.5330	.5228	.5575	.5286	.5149	.2585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274107 / 33/11 KV DUDHANI S/STN

Feeder No / Name : 207 / Sinnur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.4854	.5601	.3361	.4108	.4108
2	.3696	.4481	.5914	.4481	.3696	.4435
3	.4435	.4066	.6219	.4854	.3326	.5144
4	.4755	.4066	.6584	.5121	.3292	.5853
5	.5121	.439	.6516	.5487	.3658	.5959
6	.543	.4938	.6274	.5487	.4344	.5959
7	.5792	.6335	.6226	.5973	.6135	.5898
8	.5935	.6335	.6226	.5765	.6104	.5898
9	.5735	.5898	.6154	.6335	.5571	.5506
10	.5735	.5243	.5344	.4096	.3932	.502
18					.0343	
19	.0366	.0366	.0366	.0366	.0366	.0373
20	.0366	.0366	.0366	.037	.0366	.0373
21	.037	.037		.0373	.0373	.0373
22	.037	.037	.0373	.0373	.0373	.0377
23	.0373	.0366	.0373	.0373	.0373	.0377
24	.0373	.037	.037	.0377	.0373	.0373
Max	.5935	.6335	.6584	.6335	.6135	.5959
Min	.0366	.0366	.0366	.0366	.0343	.0373
Avg	.3250	.3301	.4194	.3325	.2749	.3502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 201 / ALAGI MIX AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0762	.1524	.1524	.0953	1.0279
2	.1143	.0953	.0762	.1524	.1524	.0953	1.0279
3	.1143	.0953	.0762	.1524	.1524	.0953	1.0279
4	.1143	.0953	.0762	.1524	.1524	.0953	1.1203
5	.1143	.0953	.1143	.1524	.1524	.0953	1.1203
6							1.1203
7							1.1203
8							1.1203
9							1.1203
10							1.0279
11	1.4918	1.4918	1.2483	1.3435	.9831	.9488	
12	1.4746	1.4918	1.3375	1.4746	1.2955	.9488	
13	1.6004	1.6766	1.3546	1.5074	1.2955	1.1203	
14	1.8442	1.6766	1.3847	1.5729	1.326	1.1203	
15	1.8233	1.8652	1.4327	1.5402	1.2955	1.3765	
16	1.8233	1.8652	1.4632	1.5074	1.2955	1.3765	
17	1.7404	1.7604	1.5623	1.4746	1.2651	1.3765	
18	1.6194	1.6575	1.5123	1.4746	1.2498	1.2803	
20	.1905	.0762	.1524	.1524	.0953	.1143	.1143
21	.1905	.0762	.1524	.1524	.0953	.1143	.1143
22	.0953	.0762	.1524	.1524	.0953	.1143	.1143
23	.0953	.0762	.1524	.1524	.0953	.1143	.1143
24	.1143	.0953	.0762	.1524	.1524	.0953	.1143
Max	1.8442	1.8652	1.5623	1.5729	1.326	1.3765	1.1203
Min	.0953	.0762	.0762	.1524	.0953	.0953	.1143
Avg	.8153	.7979	.6889	.7455	.6279	.5876	.7603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 202 / GUDDDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0953	.0572	.0762	.0762	.0953	.9259
2	.0572	.0953	.0572	.0762	.0762	.0953	1.0155
3	.0572		.0572	.0762	.0762	.0953	1.0155
4	.0572	.0953	.0572	.0762	.0762	.0953	1.1069
5	.0572	.0953	.0572	.0762	.0762	.0953	1.1069
6							1.1069
7							.9374
8							.9374
9							.9374
10							.9374
11	.8383	.8192	.9633	1.004	1.0526	.8192	
12	.7373	.8192	1.0059	1.1012	1.1336	.8192	
13	1.1203	.9831	1.0185	1.1336	1.2146	.9945	
14	1.2289	.9945	1.0802	1.1336	1.2003	.9945	
15	1.1603	1.2574	1.1111	1.1984	1.1203	.9945	
16	1.1603	1.2574	1.1111	1.1984	1.1336	1.0898	
17	1.1603	1.2574	1.1279	1.1984	1.1203	1.0898	
18	1.1603	1.1469	1.0623	1.166	1.1069	1.1065	
20	.0953	.0572	.0762	.0762	.0953	.0572	.0762
21	.0953	.0572	.0762	.0762	.0953	.0572	.0762
22	.0953	.0953	.0762	.0762	.0953	.0572	.0762
23	.0953	.0953	.0762	.0762	.0953	.0572	.0762
24	.0572	.0953	.0572	.0762	.0762	.0953	.1143
Max	1.2289	1.2574	1.1279	1.1984	1.2146	1.1065	1.1069
Min	.0572	.0572	.0572	.0762	.0762	.0572	.0762
Avg	.5161	.5480	.5071	.5498	.5511	.4838	.6964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 203 / GUDDWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3734	.3734	.4108	.4108	.3734	.3734
2	.4108	.3734	.4668	.4481	.4108	.3734	.4481
3	.4108	.3734	.4668	.4481	.4108	.3734	.4481
4	.4108	.3734	.5601	.4854	.4481		.5601
5	.4481	.5601	.5601	.4854	.5601	.4668	.5601
6							.3734
7							.2801
8							.2241
9	.2241	.2801	.2241	.2614	.2241	.2801	.2241
10	.2241	.2801	.2241	.2829	.2054	.2801	.2241
11	.1867	.2801	.1867	.2241	.1867	.2801	.2054
12	.1867	.1867	.1867	.2241	.1867	.7468	.2054
13	.1867	.1867	.1494	.2241	.1867	.1867	.2054
14	.2801	.1867	.1494	.2241	.1867	.1867	.2054
15	.1867	.1867	.1494	.2241	.1867	.1867	.2054
16	.1867		.1867	.2241	.3361	.1867	.2241
17	.1867	.1867	.1867	.2241	.1867	.1867	.2241
18	.1867		.2427	.2241	.1867	.2241	.3361
19	.3734	.2801	.4481	.3734	.3734	.1867	.4108
20	.4668	.1867	.4481	.4854	.3734	.2801	.4854
21	.4668	.2801	.4481	.4108	.3734	.2801	.4481
22	.3734	.2801	.4108	.4108	.2801	.2801	.4481
23	.3734	.3361	.4108	.4191	.2801	.3734	.4108
24	.4108	.3734	.3361	.4108	.4108	.3734	.3734
Max	.4668	.5601	.5601	.4854	.5601	.7468	.5601
Min	.1867	.1867	.1494	.2241	.1867	.1867	.2054
Avg	.3139	.2928	.3245	.3393	.3050	.3053	.3376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274146 / 33/11kv Guddewadi Sub/Stn

Feeder No / Name : 204 / 11KV ANKALGI PURE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8025	.8916	.8916	.8025	.9332	.9659	.0953
2	.8436	.8916	.8916	.873	.9633	.9659	.0953
3	.8436	.9031	.8916	.873	.9783	.9536	.0953
4	.8749	.9783	.8916	.884	1.0084	.9659	.0953
5	.9061	.9783	1.1288	.8993	1.0235	.9659	.0953
6	1.0595	1.1336	1.2193	.9105	1.1138	1.0802	
7	1.3435	1.1431	1.2193	1.0936	1.326	1.2955	
8	1.3927	1.2631	1.3889	1.142	1.3717	1.3717	
9	1.3927	1.2041	1.3889	1.1873	1.2955		
10	1.1203	1.3117	1.2193	1.2037	1.2955		
11							1.3279
12							1.3279
13							1.3279
14							1.3279
15							1.3279
16							1.3279
17							1.3279
18							1.2811
19		.0953					
20	.1905	.0953	.1524	.1905	.1905	.0953	.1905
21	.1905	.0953	.1524	.1905	.1905	.0953	.1905
22	.1905	.0953	.1905	.1905	.1905	.0953	.1905
23	.1905	.0953	.1905	.1905	.1905	.0953	.1905
24	.1905	.1905	.0953	.1905	.1905	.1905	.0953
Max	1.3927	1.3117	1.3889	1.2037	1.3717	1.3717	1.3279
Min	.1905	.0953	.0953	.1905	.1905	.0953	.0953
Avg	.7688	.7103	.7941	.7214	.8174	.7028	.6617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 201 / ANDEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0739	.0747	.0543	.0934	.056	.2858
2	.056	.0747	.056	.0543	.0934	.0554	.2858
3	.056	.0747	.056	.056	.0934	.056	.381
4	.056	.0747	.056	.0543	.0934	.056	.381
5	.056	.0747	.056	.0543	.0934	.056	.381
6	.056	.0747	.0747	.0543	.0934	.056	.6668
7	.056	.056	.056	.0543	.0934	.056	.8573
8	.056	.056	.056	.0543	.056	.056	1.0098
9	.056	.056	.056	.0373	.056	.056	.9907
10	.056	.056	.0381	.0724	.056	.056	.8478
11	.7011	.5201	.7621	.724	.7011	.7621	.0373
12	.7087	.6068	.8573	.724	.7087	.8573	.056
13	.7537	.6859	.8573	.8145	.7362	.9145	.056
14	.7973	.7716	.9526	.8145	.7888	.9526	.056
15	.7888	.7545	.9526	.905	.7802	.9526	.056
16	.8413	.7545	1.0098	.905	.8413	.9526	.056
17	.8764	.7716	1.0479	.905	.8413	.9526	.056
18	.7888	.7716	1.0479	.905	.7888	.9907	.056
19		.0934	.0572	.0543	.056	.0953	.056
20	.0739	.0747	.0572	.0543	.056	.0953	.0934
21	.0732	.0747	.0572	.0543	.0554	.0762	.0934
22	.0747	.0747	.0572	.0543	.056	.0762	
23	.0739	.0747	.0572	.0543	.0554	.0762	.0934
24	.056	.0747	.0747	.056	.0934	.056	.0762
Max	.8764	.7716	1.0479	.905	.8413	.9907	1.0098
Min	.056	.056	.0381	.0373	.0554	.0554	.0373
Avg	.3116	.2823	.3512	.3154	.3075	.3487	.3012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 202 / SANGMESHVAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		.5258	1.1765	1.2003	1.4899	.0762
2	1.2003		.5434	1.267	1.286	1.5775	.0572
3	1.2003		.5609	1.267	1.4575	1.5604	.0572
4	1.3717		.5609	1.448	1.5432	1.6301	.0381
5	1.3565		.5784	1.5384	1.5432	1.6651	.0381
6	1.5261		.5895	1.6289	1.5432	1.6832	.0381
7	1.5261		.6068	1.6289	1.5432	1.6651	.0572
8	1.5089		.6001	1.7194	1.5432	1.7187	.0381
9	1.5089		.6001	1.6651	1.5432	1.6651	.0572
10	1.4575		.6668	1.6651	1.5432	1.6832	.0747
11	.056			.0905	.0373	.0762	1.0936
12	.056			.0905	.0373	.0762	1.1431
13	.056		.0381	.0905	.0373	.0762	1.1888
14	.056		.0381	.0905	.037	.0762	1.286
15	.0554		.0381	.0905	.0373	.0572	1.3032
16	.056		.0381	.0905	.0373	.0572	1.3336
17	.056			.0905	.0373	.0572	1.3336
18	.056		.0381	.0905	.056	.0572	1.3032
19	.056	.056	.0381	.0905	.056	.1143	.0934
20	.0924	.0934	.0381	.0905	.056	.1143	.0934
21	.0934	.0934	.0381	.0905	.056	.1143	.0934
22	.0934	.0934	.0381	.0905	.0747	.0953	.0934
23	.112	.0934	.0381	.0934	.0739	.0953	.0934
24	.8573		.0934	.0362	1.267	.0747	.0762
Max	1.5261	.0934	.6668	1.7194	1.5432	1.7187	1.3336
Min	.0554	.056	.0381	.0362	.037	.0572	.0381
Avg	.6432	.0859	.3003	.6758	.6936	.7283	.4609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274151 / 33/11KV KUDAL SUB/STN

Feeder No / Name : 203 / DEVIKAWATHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0187	.0187	.0373	.0373	.7621
2	.0373	.0373	.0187	.0181	.0373	.037	.7621
3	.0373	.0373	.0189	.0181	.0373	.0373	.8573
4	.0373	.0373	.0189	.0181	.0373	.0373	.8573
5	.0373	.0373	.0377	.0181	.0373	.0373	.8573
6	.0373	.0373	.0377	.0181	.0373	.0373	.9526
7	.0373	.0373	.0189	.0187	.0373	.0373	.9526
8	.0373	.0373	.0189	.0362	.0373	.0373	.9526
9	.0373	.0373	.0189	.0181	.056	.0373	.9526
10	.0373	.0373	.0191	.0181	.0373	.037	.8288
11	.6135	.6859	.8573	.724	.7087	.7621	.0187
12	.6201	.703	.8573	.724	.7011	.8573	.0187
13	.6135	.7373	.9526	.9335	.7362	.9526	.0187
14	.6485	.7716	.9526	.905	.7973	.9526	.0187
15	.7087	.6859	.9526	.905	.7888	.9526	.0187
16	.7011	.6859	.9526	.9335	.7888	.9526	.0187
17	.7362	.7202	.9907	.905	.8238	.9526	.0187
18	.7888	.7545	.9907	.905	.7973	.9526	.0187
19	.0373	.0373	.0191	.0373	.0373	.0381	.0187
20	.037	.0373	.0191	.0373	.0373	.0381	.0373
21	.0373	.0373	.0191	.0373	.0373	.0381	.0373
22	.0373	.0373	.0191	.0373	.0373	.0381	.0373
23	.037	.0373	.0191	.0373	.037	.0381	.0373
24	.0373	.0373	.0373	.0187	.0373	.0373	.0381
Max	.7888	.7716	.9907	.9335	.8238	.9526	.9526
Min	.037	.0373	.0187	.0181	.037	.037	.0187
Avg	.2511	.2642	.3277	.3059	.2816	.3306	.3788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 202 / 11kv KURNUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2286	.2286	.2286	.1905	.2096
2	.2858	.2286	.2286	.2477	.2286	.2096	.2096
3	.381	.2286	.2286	.2667	.2286	.2096	.2286
4	.4763	.2858	.2858		.3258	.2858	.2477
5	.5144	.462	.4763	.4572	.4207	.4382	.2858
6	.5906	.5544	.5906	.499	.5544	.5525	.5359
7	.5335	.5175	.5525	.4435	.5175	.4954	.5544
8		.4382	.4382	.4435	.4024	.381	.4207
9	.3429	.362	.3239	.3475	.3439	.3048	.3048
10	.2477	.2858		.2286	.2126	.2667	.2096
11	.1715	.1905	.1715	.2096	.1905	.2477	.1715
12	.156	.1715	.1715	.1387	.1524		.1524
13	.1543	.1524	.1372	.1387	.1524	.1715	.12
14	.1187	.1524	.1543	.1387	.1524	.1715	.12
15	.1334	.1334	.1524	.1334	.1334	.1334	.12
16	.1334	.1334	.1715	.1372	.1334	.1524	.1402
17	.1372	.1524	.1524	.1578	.1524	.1715	.1457
18	.1753	.2477	.2096	.2286	.2477	.2286	.1928
19	.3841	.4382	.4382	.4251	.4382	.4382	.4024
20	.462	.4763	.5144	.4251	.4572	.4191	.4572
21	.362	.362	.4382	.3258	.4191	.3239	.3475
22	.2858	.2477	.362	.2858	.381	.2477	.2286
23	.2286	.2286	.2477	.2286	.3429	.2096	.2286
24	.2096	.2096	.2286	.2286	.2286	.1905	.2096
Max	.5906	.5544	.5906	.499	.5544	.5525	.5544
Min	.1187	.1334	.1372	.1334	.1334	.1334	.12
Avg	.2910	.2870	.3001	.2767	.2935	.2800	.2601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274156 / 33/11KV MOTYAL SUB/STN

Feeder No / Name : 203 / 11 KV Badole Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)
9	.3429	
10	.2477	
11		.2477
13		.1715
Max	.3429	.2477
Min	.2477	.1715
Avg	.2953	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 201 / 11 KV AKKALKOT URBAN

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.4266	1.5546	1.4632	1.3717	1.4632	
2	1.4632	1.4266	1.4632	1.4266	1.3717	1.4266	
3	1.4632	1.4266	1.3717	1.3717	1.3535	1.4266	
4	1.4632	1.4266	1.3717	1.3535	1.3535	1.4632	
5	1.4998	1.4632	1.4266	1.3717	1.3717	1.4998	
6	1.5546	1.5546	1.39	1.4632	1.4266	1.5546	
7	1.4815	1.4815	1.3717	1.4998	1.4998	1.5729	
8	1.3352	1.2986	1.2803	1.4266	1.4083	1.3535	
9	1.2071	1.2254	1.2803	1.3717	1.2437	1.3169	
10	1.2803			1.5181	1.4266		
11	1.3352			1.4998	1.5546		
12	1.3717			1.5729	1.6278		
13	1.39			1.6095	1.6278		
14	1.4632			1.5181	1.6461		
15	1.4632			1.4632	1.5181		
16				1.39	1.4449		
17	1.39			1.4266	1.5364	1.6827	1.4998
18	1.6095			1.4266	1.6461	1.7924	1.4998
19	2.1033			1.8473	2.1033	2.1399	2.0165
20	2.0485			1.8839	2.1582	2.1216	1.9978
21	1.829			1.829	1.9387	1.9936	1.9044
22	1.7375			1.7193	1.7924	1.8473	1.8107
23	1.6461			1.5912	1.6461	1.6827	1.6827
24	1.4815	1.4632	1.6461	1.4998	1.4449	1.5364	1.5546
Max	2.1033	1.5546	1.6461	1.8839	2.1582	2.1399	2.0165
Min	1.2071	1.2254	1.2803	1.3535	1.2437	1.3169	1.4998
Avg	1.5252	1.4193	1.4156	1.5226	1.5630	1.6396	1.7458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.7842	.8029	.8402	.8029	.7095	
2	.8775	.7842	.7842	.7842	.7842	.7095	
3	.8775	.7468	.7842	.7468	.7842	.7282	
4	.8775	.7842	.7468	.7842	.8029	.7468	
5	.8962	.8402	.8215	.8402	.8215	.8402	
6	.9335	.9335	.8589	.9149	.8402	.9335	
7	1.0269	1.0269	.9522	.9522	.8962	1.0269	
8	.8962	.8029	.8215	.9335	.8402	.8775	
9	.9335	.9522	.9335	.9149	.7655	.9522	
10	.8402			.8775	.8029		
11	.7842			.9335	.9335		
12	.8215			.9522	.9149		
13	.8402			.6908	.9335		
14	.8589			.9149	.6535		
15	.9709			.9149	.6348		
16	.4854			.9522	.8029		
17	1.0269			.9335	.7468	.9335	1.0082
18				.7655	.7468	.9335	.9335
19	1.0456			.9522	.9335	.9335	.9896
20	.9335			1.0082	.9335	1.0642	1.0456
21	.9709			1.0456	.9522	1.0269	1.0269
22	1.0269			.9709	.9335	.9896	1.0082
23	.9335			.8962	.8589	.9709	.9896
24	.8962	.8029	.8402	.8775	.8589	.7655	.8402
Max	1.0456	1.0269	.9522	1.0456	.9522	1.0642	1.0456
Min	.4854	.7468	.7468	.6908	.6348	.7095	.8402
Avg	.8970	.8458	.8346	.8915	.8324	.8907	.9802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274180 / AKKALKOT TOWN SUB-STATION

Feeder No / Name : 203 / 11 KV Swami Vihar FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152		.0305	.0152	.0152	.0152	
2	.0152		.0305	.0152	.0152	.0152	
3	.0152		.0305	.0152	.0152	.0152	
4	.0152		.0305	.0152	.0152	.0152	
5	.0152		.0305	.0305	.0152	.0152	
6	.0152		.0305	.0305	.0152	.0152	
7	.0152		.0305	.0305	.0305	.0152	
8	.0305		.0305	.0305	.0305	.0152	
9	.0305	.0305	.0305		.0152	.0305	
10	.0305			.0305	.0305		
11	.0305			.0305	.0305		
12	.0305			.0305	.0305		
13	.0305			.0305	.0305		
14	.0305			.0305	.0305		
15	.0152			.0305	.0305		
16				.0305	.0305		
17	.0152			.0305	.0305	.0152	.0305
18				.0305	.0305	.0152	.0305
19				.0305	.0152	.0152	.0305
20	.0305			.0152	.0152	.0152	.0305
21	.0152			.0152	.0152	.0152	.0305
22	.0152			.0152	.0152	.0152	.0152
23	.0152			.0305	.0152	.0305	.0152
24	.0152		.0305	.0152	.0152	.0152	.0305
Max	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Min	.0152	.0305	.0305	.0152	.0152	.0152	.0152
Avg	.0210	.0305	.0305	.0252	.0222	.017	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 201 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2801			.1848	.2801	.2614
2	.2801	.2801			.1829	.2801	.2614
3	.3361	.3361			.2587	.3734	.2987
4	.4481	.4668			.2587	.4108	.3734
5	.5544	.6722			.3658	.6535	.5415
6	.6468	.7468			.6219	.7468	.6722
7	.6653	.7095			.6584	.6535	.7023
8	.5228	.4854			.4706	.5041	.5228
9	.3734	.4481			.3696	.3734	.3734
10	.3361	.3734	.3696		.3326	.2987	.2801
11	.2801	.2241			.2587	.2801	.2801
12	.2614	.2427			.2402	.2241	.2614
13	.2241	.2241			.2402	.1867	.2241
14	.2054	.2427			.2033	.1867	.2241
15	.2241	.2054			.1663	.1867	.2241
16	.2241	.2427			.1848	.1867	.2241
17	.2987	.2801			.2218	.1867	.2801
18	.3734	.2987			.2987	.2987	.2614
19	.4481	.4854			.4481	.4668	.4854
20	.4481	.6348			.5228	.5601	.5228
21	.4668				.4294	.5228	.4481
22	.3361				.3361	.3361	.3361
23	.3174	.2987		.2587	.2987	.2801	.2987
24	.2801	.2801			.2218	.2801	.2614
Max	.6653	.7468	.3696	.2587	.6584	.7468	.7023
Min	.2054	.2054	.3696	.2587	.1663	.1867	.2241
Avg	.3680	.3845	.3696	.2587	.3240	.3649	.3591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 202 / 11 KV KINI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.4842		1.0936	.8749	1.448	
2	1.4403	1.5623		1.2498	1.0279	1.5242	
3	1.4403	1.5623		1.3435	1.0494	1.5242	
4	1.4723	1.5623		1.406	1.3108	1.6766	
5	1.5203	1.6091		1.4685	1.4251	1.7528	
6	1.6004	1.6248		1.6404	1.6004	1.829	
7	1.9204	1.9997		1.9685	1.8564	1.9204	
8	1.7924	1.6716		1.8747	1.8976	1.829	
9	1.8244	1.781		1.9372	1.7185	1.5546	
10	1.7604	1.7185	1.8884	1.8747	1.9227	1.5242	
11				.0076			1.6804
12				.0076			1.9204
13				.0076			
14				.0076			
15				.0076			
16				.0076			
18							1.8564
20			.0267				
21			.0267				
22			.0267		1.6766		
23			.0267				
24				.0267			
Max	1.9204	1.9997	1.8884	1.9685	1.9227	1.9204	1.9204
Min	1.4403	1.4842	.0267	.0076	.8749	1.448	1.6804
Avg	1.6212	1.6576	.3990	.9370	1.4873	1.6583	1.8191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274206 / 33/11 KV KINI SUBSTATION

Feeder No / Name : 203 / 11 KV KAZIKANBUS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.0031
2							1.0031
3							1.0031
4							1.0494
5							1.1561
6							1.2803
7							1.6385
8							1.6385
10	1.8244						1.0031
11	1.7985	1.5242	1.406	1.4403	1.4998		
12	1.768	1.7375	1.9109	1.5043	1.5935	1.4746	
13	1.768	1.7375	1.8023	1.6004	1.5623	1.7204	
14	1.829	1.7071	1.7436	1.6644	1.3435	1.6385	
15	1.7375	1.6766	1.6004	1.6964	1.3435	1.7204	
16	1.6766	1.7375	1.6004	1.4403	1.406	1.7204	
17	1.6766	1.6004	1.6964	1.5364	1.4842	1.7695	
18		1.5546	1.6324	1.4403	1.3748	1.8023	
Max	1.829	1.7375	1.9109	1.6964	1.5935	1.8023	1.6385
Min	1.6766	1.5242	1.406	1.4403	1.3435	1.4746	1.0031
Avg	1.7598	1.6594	1.6741	1.5404	1.4510	1.6923	1.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 201 / 11 KV Hattikanbas Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.3763
16	1.7604	1.5384	1.6604	1.8084	1.6129	1.6404	
24	.1372	.1372	.1219	.1187	.1219	.1219	.1357
Max	1.7604	1.5384	1.6604	1.8084	1.6129	1.6404	1.3763
Min	.1372	.1372	.1219	.1187	.1219	.1219	.1357
Avg	.9488	.8378	.8912	.9636	.8674	.8812	.756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 202 / 11 KV Basalegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5655	1.3441	1.5623	1.5043	1.7764	1.5023	
24	.0762	.0602	.0762	.0457	.061	.061	.0602
Max	1.5655	1.3441	1.5623	1.5043	1.7764	1.5023	.0602
Min	.0762	.0602	.0762	.0457	.061	.061	.0602
Avg	.8209	.7022	.8193	.775	.9187	.7817	.0602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

AKKALKOT S/DN.[096] BU 1341

Substation No/ Name :- 274228 / 33/11 KV Mirajgi Sub-station

Feeder No / Name : 203 / 11 KV Mirajgi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2427	.2218	.2587	.2587	.2614	.2218	.2587
16	.168	.1478	.168	.1478	.1478	.1294	.1294
24	.2054	.1848	.1848	.1867	.2054	.1848	.1848
Max	.2427	.2218	.2587	.2587	.2614	.2218	.2587
Min	.168	.1478	.168	.1478	.1478	.1294	.1294
Avg	.2054	.1848	.2038	.1977	.2049	.1787	.1910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 201 / 11 KV ANAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)
1	.0171	.0171
2		.0171
3		.0171
4		.0171
5		.3963
24		.0171
Max	.0171	.3963
Min	.0171	.0171
Avg	.0171	.0803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 204 / 11 KV PASALEWADI MIX AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8682		.0857	.0857	.0876	.0819	.0819
2	.7973		.0857	.0857	.0886		.0819
3	.7087		.0857	.0857	.0876		.08
4	.7087		.0857	.0857	.0876		.0819
5	.7186		.0857	.0857	.0876		.081
6	.7186		.0857	.0857	.0876		.0819
7	.8063		.0857	.0857			.081
8	.7973		.0857	.0857			.0819
9			1.0802	1.2003			1.065
10	.8785	1.166	1.2003	1.3643			1.0288
11		1.0974	1.286	1.4352	.852	1.2616	
12		1.0974	1.286	1.4175	1.0486	1.2289	
13		1.1317	1.286	1.3643	1.166	1.4091	
14		1.166	1.3717	1.3643	.9831	1.3603	
15		1.2003	1.2003	1.5592	.9878	1.4089	
16	.9282	1.2003	1.2003	1.2403		1.085	
17	1.094	.0857	.0686			.0819	
18	1.0978	.0857	.0686		.0819	.081	.0686
19	.8583	.0857	.0857	.0886	.081	.0819	.0686
20	.8907	.0857	.0857	.0876	.0819	.0819	.0857
21	.9175	.0857	.0857	.0876	.081	.0819	.0857
22	.9995	.0857	.0857	.0876	.081	.0819	.0857
23		.0857	.0857	.0876	.0819	.0819	.0857
24	.8764		.0857	.0857	.0876	.0819	.0819
Max	1.0978	1.2003	1.3717	1.5592	1.166	1.4091	1.065
Min	.7087	.0857	.0686	.0857	.081	.081	.0686
Avg	.8626	.6185	.4687	.5525	.3411	.566	.1945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274073 / 33/11 KV ANAGAR

Feeder No / Name : 205 / 11 KV ANAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.4858	.5144	.5144	.5258	.4915	.4858
2	.5316	.4858	.5144	.5144	.5258	.4858	.4915
3	.7087	.4801	.5144	.5144	.5258	.4858	.4858
4	.8859	.6226	.6173	.5144	.5258	.5668	.6154
5	1.0517	.8907	.7202	.7716	.7888	.8097	.8192
6	1.2403	1.065	1.1317	1.2003	1.1393		1.065
7	1.2269	1.2289	1.166	1.2003		1.1469	1.1469
8	1.1517	1.2003	1.1145	1.0288		1.0202	1.065
9		1.0288	.8573	.7716		.8097	.8684
10		.8573	.7716	.5316			.7716
11		.7888	.6859	.5316	.8097	.6554	
12		.6859	.6859	.5258	.7373	.6554	
13		.6859	.6001	.5316	.6882	.6478	
14		.6859	.6001	.5316	.6478	.5735	
15		.6859	.6859	.5316	.5801	.5735	.6859
16	.8192	.6859	.6859	.6135	.5801	.5801	.6001
17	.7373	.7202	.6859		.7287	.6554	.6859
18	.8288	.8573	.6859	.7087	.8097	.7373	.8573
19	1.1142	1.0288	.8573	1.1393	1.1469		1.0288
20	1.2146	1.0288	1.0288	1.0517	1.1469	1.1336	1.1145
21	.9116	.9602	1.0288	.8764		.8192	.8573
22	.6554	.8573	.6859	.6135	.6478	.6554	.6859
23		.6859	.6001	.5258	.5735	.5735	
24	.5316	.4915	.5144	.5144	.5258	.4915	.4915
Max	1.2403	1.2289	1.166	1.2003	1.1469	1.1469	1.1469
Min	.5316	.4801	.5144	.5144	.5258	.4858	.4858
Avg	.8838	.7997	.7480	.7068	.7186	.6937	.7801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 201 / 11 KV ARDHANARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0171
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.1524	.1524	.3048	.3048	.3048	.3048	
12	.2286	.1524	.3048	.3048	.2286	.2286	
13	.2286	.2286	.3429	.2286	.2286	.2286	
14	.2286	.2286	.2286	.2286	.2286	.2286	
15	.1524	.1524	.2286	.2286	.2286	.2572	
16		.1524	.2286	.3048	.2286	.2286	
17		.1524	.2572	.2286	.2572	.1524	
18	.1715	.2286	.2572	.2286	.1715	.1524	.2572
19	.0171		.0171	.0171	.0171	.0171	.0171
20	.0171		.0171	.0171	.0171	.0171	.0171
21	.0171		.0171	.0171	.0171	.0171	.0171
22	.0171		.0171	.0171	.0171	.0171	.0171
23	.0171		.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.2286	.2286	.3429	.3048	.3048	.3048	.2572
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0760	.1045	.1179	.1131	.1041	.0993	.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 202 / 11 KV ARBALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5432	1.4937	1.6118	1.4937	1.6461	1.1888
2	1.3717	1.5432	1.6004	1.5432	1.6004	1.5775	1.2193
3	1.5242		1.6004	1.5432	1.6004	1.5775	1.3108
4	1.829	1.749	1.768	1.6118	1.6766	1.6804	1.4937
5	1.9052	1.8861	1.829	1.7147	1.7528	1.7833	1.5546
6	1.9509	2.0576	1.8595	1.9204	1.89	2.0576	1.6918
7	2.1186	2.2291		2.0233	2.2253	2.332	2.0119
8	2.1033	2.4691	2.2862		2.2253	2.4006	2.0119
9	2.21	2.4006	2.2862	2.4691	2.21	2.1948	
10	2.1643	2.3491	1.9662	1.9966	1.9814	1.9204	
19	.1372		.1372	.1715		.1886	.1372
20	.1372		.1372	.1715	.1372	.2229	.1372
21	.1372		.1372	.1715	.1372		.1372
22	.1372		.1372	.1543	.1372	.1715	.1372
23	.1372		.1372	.1543	.1372	.1715	.1372
24	.1543	.1372	.1543	.1372	.1372	.1372	.1543
Max	2.21	2.4691	2.2862	2.4691	2.2253	2.4006	2.0119
Min	.1372	.1372	.1372	.1372	.1372	.1372	.1372
Avg	1.2118	1.8364	1.1687	1.1596	1.2895	1.3375	.9517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 203 / 11 KV BEGAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1372	.1372	.1372	.1715
2	.2058	.1715	.2058	.1372	.1372	.1372	.1715
3	.2058	.1715	.2058	.1372	.1372	.1372	.1715
4	.2058	.1715	.2401	.1715	.1543	.1372	.2058
5	.2401	.2058	.2743	.2058	.2401	.1372	.2401
6		.2401	.2743	.2743	.2915	.1372	.3086
11	2.2405	1.9357	2.1491	2.0881	2.1948	1.9814	
12	2.3472	2.5453	2.3777	2.1338	2.2862	2.1795	
13	2.5758	2.4387	2.4387	2.1948	2.2862	2.21	
14	2.3015	2.4539	2.2253	2.2862	2.2405	2.2862	
15	2.3929	2.3929	2.21	2.21	2.21		
16		2.3472	2.4539	2.3167	2.1033	2.0729	
17		2.3777	2.6749	2.3167	2.4691	2.271	
18	1.3032	2.1491	2.7435	2.3929	2.332	2.1033	2.7435
19	.1715		.2058	.1886	.2058	.2401	.1372
20	.2058		.2058	.2058	.2401	.2401	.1715
21	.2058		.2058	.2229	.2401	.2058	.1715
22	.1715		.1715	.2058	.2058	.1886	.1715
23	.1715		.1372	.1715	.1715	.1886	.1372
24	.1715	.1715	.1715	.1372	.1543	.1715	.1715
Max	2.5758	2.5453	2.7435	2.3929	2.4691	2.2862	2.7435
Min	.1715	.1715	.1372	.1372	.1372	.1372	.1372
Avg	.8993	1.3296	1.0871	1.0067	1.0219	.9033	.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 204 / 11 KV BEGAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.3429	.3086	.3429	.3429	.3429
2	.3429	.3429	.3429	.3086	.3258	.3086	.3429
3	.3429		.4115	.3086	.3258	.3086	.3429
4	.4287	.4115	.4801	.3429	.3772	.3772	.3772
5	.6173	.6173	.5487	.4115	.5487	.5144	.583
6	.703	.6859	.6173	.6173	.7545	.6859	.7545
10	.463		.4973	.4801	.463	.5316	.4973
11	.3429	.4801		.3772	.4287	.463	.3944
12	.3086	.2743	.2915	.3429	.3086	.3601	.4287
13	.3258	.2915	.3086	.3429	.3429	.3258	.4115
14	.3086	.3258	.3429	.3086	.3086	.3601	.3772
15	.3601	.3258	.3258		.2915	.3429	.3772
16			.3429	.3772	.4287	.3601	.3601
17	.3086		.3429	.4287	.3772	.4115	
18	.3429	.4458		.4458	.3429	.4458	.3429
19	.6173		.2743	.6516	.6173	.703	.6001
20	.6859		.6859	.6173	.6859	.703	.6859
21	.4115		.583	.6001	.4801	.6001	.5144
22	.3772		.5144	.5316	.4115	.4801	.4115
23	.3429		.3772	.4287	.3772	.4115	.3772
24	.3772	.3429	.3429	.3086	.3429	.3429	.3429
Max	.703	.6859	.6859	.6516	.7545	.703	.7545
Min	.3086	.2743	.2743	.3086	.2915	.3086	.3429
Avg	.4184	.4072	.4196	.4269	.4229	.4466	.4432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 205 / 11KV YENKI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0288	.945	1.0288	.7468	.0171	.7773
2	.9145	1.0288	.9755	1.0288	.7773	.7545	.8535
3	.9907	1.0288	.9755	1.0631	.884	.7545	.8535
4	.9907	1.0631	1.0059	1.0974	.884	.823	.8993
5	1.0364	1.1317	1.0669	1.166	.9755	.9945	.9755
6	1.0822	1.166	1.1279	1.2689	1.1431	1.2689	1.0212
7	1.0517	1.2689		1.3375	1.326	1.3032	1.2955
8	1.2955	1.3717	1.2498	1.3717	1.3565	1.3717	1.3565
9	1.2955	1.3032	1.2498	1.4403	1.2498	1.3717	1.2651
10	1.2346	1.3375	1.1736	1.1584	1.2498	1.2498	
17				1.1584		1.2498	
19	.1029		.1029	.1543	.1029	.2058	.1029
20	.1029		.1029	.1543	.1029	.2058	.1029
21	.1029		.1029	.1543	.1029	.1715	.1029
22	.1029		.1029	.1543	.1029	.1543	.1029
23	.1029		.1029	.1372	.1029	.1543	.1029
24	.0857	.1029	.1029	.1029	.1372	.1029	.1543
Max	1.2955	1.3717	1.2498	1.4403	1.3565	1.3717	1.3565
Min	.0857	.1029	.1029	.1029	.1029	.0171	.1029
Avg	.7129	1.0756	.6925	.8222	.7028	.7149	.6644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274074 / 33/11 KV BEGAMPUR

Feeder No / Name : 206 / 11 KV KOTHALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1029	.1715	.1029	.1543	.1029
2	.0857	.0857	.1029	.1715	.1029	.1543	.1029
3	.0686	.0857	.1029	.1715	.1029	.1543	.0857
4	.0686	.1029	.1029	.1715	.1029	.1543	.0857
5	.1029	.1372	.12	.1886	.1029	.1543	.1029
6	.1029	.1372	.12	.1886	.1372	.1543	.1029
11	1.3717	1.3108	1.4175	1.448	1.4022	1.2955	
12	1.5851	1.4937	1.5242	1.4937	1.3413	1.4022	
13	1.5851	1.3565	1.5242	1.5242	1.326	1.4022	
14	1.3717	1.3108	1.2803	1.4632	1.2651	1.326	
15	1.3717	1.3413	1.2498		1.2193	1.2955	
16		1.2193	1.2193	1.3108	1.1279	1.0822	
17		1.1279	1.3717	1.2498	1.3717	1.0669	
18	1.4403	1.2193	1.406	1.3717	1.2689	1.1584	1.2346
19	.1029		.1029	.1372	.1715	.1029	.12
20	.1029		.1372	.1372	.1715	.1372	.1029
21	.1029		.1715	.1372	.1715	.1029	.1029
22	.1029		.1715	.12	.1715	.1029	.1029
23	.0857		.1715	.1372	.1543	.1029	.0857
24	.0857	.0857	.1029	.1715	.12	.1543	.1029
Max	1.5851	1.4937	1.5242	1.5242	1.4022	1.4022	1.2346
Min	.0686	.0857	.1029	.12	.1029	.1029	.0857
Avg	.5457	.7400	.6251	.6192	.5967	.5829	.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 201 / 11 KV SHINGOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5716	.4572	.381	.381	.381	.3048
2	.4572	.6668	.4572	.2858	.381	.2858	.3048
3	.4572	.4763	.4572	.1905	.381	.381	.3048
4	.4572	.381	.4572	.1905	.381	.4763	.3048
5	.5335	.381	.4954	.2858	.4572	.4763	.4191
6	.5716	.2858	.5335	.2858	.5335	.5716	.5335
7	.5335	.6668	.5335	.5716	.5335	.4763	.5335
8	.4572		.4572	2.0957	.4572		.5335
9	.4572	2.0957	2.2862	2.2862	2.572	2.2862	2.6673
10		2.2862	2.4768	2.4768	2.572	2.8578	2.6673
11		2.4768	2.6673	2.6673	2.2862	2.6673	
12		2.2862	2.4768	2.4768	2.0957	2.2862	
13		2.0957	2.3815	2.4768	1.8099	2.191	
14	4.4772	2.0957	2.4768	2.4768	1.9052	2.0957	
15	4.2867	2.2862		2.3243	2.0957	1.9052	
16	3.5246	2.0957	2.2862	2.2862	1.9433	1.7147	
17	2.8578	2.6673	2.4768	2.2862	2.2862	2.6673	
18	3.6199		3.0483	2.8578	2.4768	2.6673	
19	.5716	2.7625			2.2862	2.572	.381
20	.6097	3.0483	2.6673	2.7625	2.6673	2.6673	.5716
21	.5716	2.6673	2.4768	2.6673	2.4768	2.6673	.4763
22	.4763	2.3815	2.4768	2.572	2.2862	2.4768	2.8578
23	.5716	2.2862	.362	1.9052	.381	2.4768	3.0483
24	.4572	.4763	.4572	.4191	.4382	.381	.3048
Max	4.4772	3.0483	3.0483	2.8578	2.6673	2.8578	3.0483
Min	.4572	.2858	.362	.1905	.381	.2858	.3048
Avg	1.3203	1.7017	1.5848	1.7056	1.5035	1.7230	1.0133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 202 / 11 KV ICHAGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	2.2862	2.0957	3.0483	2.4768	2.0957	1.9052
2	1.9052	2.4768	2.0957	3.4294	2.4768	2.6673	1.9052
3	1.9052	2.8578	2.2862	3.6199	2.4768	2.4768	1.9052
4	2.2862	3.2388	2.3815	3.2388	2.7625	3.4294	2.0576
5	2.6673	2.8578	2.6673	3.2388	2.8578	3.2388	2.3815
6	3.2388	2.6673	3.1436	3.4294	3.0483	3.0483	2.6292
7	3.4675	3.2388	3.5056	3.658	3.8104	2.6673	3.0483
8	3.4294		.2477	.1905	2.6673	.1334	2.8578
9	2.8578	.1524	.2477	.2096	.1524	.1143	.1524
10	3.2388	.2096	.2096	.1524	.1905	.1524	.1524
11	.1334	.1905	.1905	.1905	.1905	.1524	
12	.0572	.1905	.1905	.1715	.2286	.1334	
13		.1715			.2477	.1524	
14		.1715	.1715		.1715		
15		.1715	.1905		.1905	.1715	
16		.1905	.2096	.2286	.2096	.1524	
17		.1524	.1905	.2286	.2477	.1524	
18		.1524	.1905	.2096	.2858	.1524	
19	.1905	.1524		.1905	.2858	.1524	.1905
20	.2286	.2667	.1905	.2286	.2858	.1905	.1905
21	.1905	.1905	.1715	.1905	.1905	.1524	.1905
22	.1905	.1905	.2858	.1524	.2096	.1334	.1905
23	1.4289	.2286	1.5432	.1905	1.1431	.1524	.1905
24	.1715	1.9814	2.0957	2.4768	2.4768	2.2862	1.9052
Max	3.4675	3.2388	3.5056	3.658	3.8104	3.4294	3.0483
Min	.0572	.1524	.1715	.1524	.1524	.1143	.1524
Avg	1.6385	1.0603	1.1137	1.3654	1.2201	1.0503	1.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 203 / 11 KV WATWATE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.7621	.5716	.7621	.4763	.7621	.6097
2	.4763	.7621	.5716	.8573	.4763	1.1431	.6097
3	.4763	.8573	.5716	.8573	.4763	1.0479	.6097
4	.4763	.6668	.5716	.9526	.4763	1.0479	.6668
5	.5716	.7621	.6668	1.0479	.4763	.9526	.7621
6	.6859	.8573	.7621	.7621	.5716	.8573	.8573
7	.7621	.8573	.8573	.8573	.8573	.8573	1.0479
8	1.0479	.7621	.8573	.8573	.9526	.9526	1.0479
9	1.0479	.8002	.8573	.7621	.9526	.8573	.9526
10	.9526	.8573	.0572	.7621	.7621	.7621	.9907
11	.0953	.0953	.0572	.0572	.0572	.0572	
12	.0572	.0762	.0572	.0572	.0572	.0572	
13	.0572	.0762	.0572		.0572	.0572	
14	.0572	.0762	.0572		.0572	.0572	
15	.0572	.0762	.0572		.0572	.0572	
16	.0572	.0762	.0572	.0762	.0572		
17		.0762	.0572	.0762	.0572	.0762	
18	.0572	.0762	.0572	.0762	.0572	.0572	
19	.0572	.0762	.0572	.0762	.0572	.0572	.0572
20	.0572	.0762	.0572	.0762	.0572	.0572	.0572
21	.0572	.0762	.0572	.0762	.0572	.0572	.0572
22	.0572	.0762	.0572	.0762	.0572	.0572	.0572
23	.0572	.0762	.0572	.0762	.0572	.0572	.0572
24	.0572	.7621	.8192	.7621	.0762	.7621	.0572
Max	1.0479	.8573	.8573	1.0479	.9526	1.1431	1.0479
Min	.0572	.0762	.0572	.0572	.0572	.0572	.0572
Avg	.3372	.4049	.3295	.4745	.3041	.4656	.5311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 204 / 11 KV WIRWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0572	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953	.0953	.0953
9	1.0098	.0953	.0953		.0953	.0953	.0953
10	.0953	.0953				.0953	.0953
11	1.7147	2.6673	2.4387	2.8578	2.6673	2.2862	
12	2.9721	2.6673	2.4768	2.9531	3.0483	3.0483	
13	2.9531	2.4768	3.1055	3.0483	3.2388	3.2388	
14	2.8769	2.572	3.2388	3.0483	3.0483	3.1436	
15	2.8769	2.4768	2.8578	2.8578	2.8578	3.0483	
16	2.8959	2.8578	2.7244	2.8578	2.4768	2.6673	
17	2.8578	2.8578	2.7625	2.8578	2.6673	2.6673	
18	3.0483	2.6673	2.7054	2.2862	3.0483	2.6673	
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	3.0483	2.8578	3.2388	3.0483	3.2388	3.2388	.0953
Min	.0572	.0953	.0953	.0953	.0953	.0953	.0953
Avg	1.0249	.9487	1.0321	1.0955	1.0645	1.0122	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 205 / 11 KV KAMATI BK. GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.5716	.5335	.381	.5335
2	.5716	.4763	.5716	.6668	.5335	.2858	.5335
3	.5716	.4763	.5716	.7621	.5335	.381	.5335
4	.6097	.4191	.5716	.4763	.5716	.4763	.5335
5	.724	.5716	.5716	.5716	.6478	.381	.6668
6	.8383	.5716	.6668	.6668	.7621	.5716	.7621
7	.7621	.6478	.7621	.8383	.8573	.7621	
8	7.678	.6097	.6668	.5716	.7621		.6668
9	.6668	.6287	.5716	.5716	.6668	.5716	.6097
10	.5716	.6097		.5335	.6478	.5716	.5335
11	.5716			.5716	.5716	.5716	.5335
12	.5335	.5716		.5335	.6478	.5335	.5335
13	.5335	.5335	.5716	.4954	.5716	.4954	.5525
14		.5335	.5525	.5144	.5716	.5335	.5335
15	.4382	.5335	.5716	.4954	.5335	.381	.5335
16	.4954		.5906	.6097	.4954		.5335
17	.5144	.5716	.5716	.5716	.5525	.5335	.5716
18	.6478	.6097	.6478	.6668	.5716	.6668	.5716
19	.7621	.8573	.4763	.8954	.743	.7621	.6668
20	.8954	.9145	.5716	.9526	.8573	.9526	.8573
21	.6668	.7621	.8192	.7621	.5716	.8573	.5716
22	.5716	.6668	.6668	.5716	.6668	.724	.6668
23	.5716	.5716	.5716	.4763	.4763	.5716	.5716
24	.5144	.5716	.5716	.4763	.5335	.4763	.5716
Max	7.678	.9145	.8192	.9526	.8573	.9526	.8573
Min	.4382	.4191	.4763	.4763	.4763	.2858	.5335
Avg	.9253	.6036	.6051	.6176	.6200	.5655	.5931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 206 / 11 KV HARALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.7147	1.5242	1.9052	1.5242	2.0957	1.5242
2	1.3336	2.0957	1.5242	2.2862	1.5242	2.4768	1.5242
3	1.3336	2.2862	1.5242	2.4768	1.5242	2.6673	1.6194
4	1.7147	2.0957	1.5242	2.6673	1.8099	2.6673	1.6194
5	2.0005	2.3815	1.9052	2.3815	2.0005	2.4768	1.9052
6	2.2862	2.4768	2.2862	2.4768	2.2862	2.2862	2.191
7	2.572	2.5339	2.4768	2.572	2.6673	2.6673	2.572
8	2.7625	2.6101	2.7625	2.6673	2.6673		2.6673
9	2.7625	2.5149	2.6673	2.572	2.4768	2.6673	2.4768
10	2.6673	1.9433	.1715	2.5339	2.4958	2.6101	2.5339
11	.2096	.1715	.1905	.1905	.1715	.2477	
12	.2096		.2096	.1715	.2096	.2858	
13			.1905		.2096	.2667	
14					.2286	.3048	
15					.2477	.2667	
16				.3048	.2286	.2286	
17				.381	.2667	.2286	
18			.2858	.3429	.2858	.3239	
19	.4572		.2858	.362	.381	.381	.381
20	.4572		.4382	.381	.2858	.381	.4763
21	.381		.2286	.3429	.2667	.3429	.381
22	.2858		.381	.3048	.3429	.3048	.381
23	.362		.2858	.362	.381	.3048	.2858
24	.2286	1.5242	.2667	1.7147	.2858	1.9052	.3048
Max	2.7625	2.6101	2.7625	2.6673	2.6673	2.6673	2.6673
Min	.2096	.1715	.1715	.1715	.1715	.2286	.2858
Avg	1.2976	2.0290	1.0564	1.3999	1.0320	1.2342	1.4277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274076 / 33/11 KV KAMTI

Feeder No / Name : 207 / 11 KV DADPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1905	.1905	.1524	.1715	.1334
2	.1905	.1905	.1905	.1905	.1524	.1715	.1334
3	.1905	.1715	.1905	.1905	.1524	.1905	
4	.1905	.2096	.1905	.1905	.1524	.1905	.1334
5	.2667	.1905	.2286	.1715	.1905	.1334	.1905
6	.3429	.1905	.2667	.1905	.2096	.1715	.1905
7	.362	.2286	.2096	.2096	.1905	.1905	.1905
8	.3429	.2286	.1905	.1905	.1905		.1524
9			.1905		.1905	.1905	.1524
10	.2096		.1715				.1143
11	2.7054		1.8671	2.6292	1.9624	2.2481	
12	3.7723	2.7435		2.4768	2.5911	2.5339	
13	3.4294	2.7054	2.6673	2.4768	.381	2.4768	
14	3.4294	2.6673	2.8578	2.4768	.381	2.4387	
15	3.3341	2.7816	3.0483	2.4387	2.3243	2.2862	
16	3.6389	2.7054	2.4577	2.4958	2.3243	2.2481	
17		2.6673		2.572	2.3624	2.0957	
18	2.4768	2.3243	2.2862	2.1148	2.4768	2.0957	
19	.2667	.1715	.1905	.1905	.1905	.2286	.1715
20	.2477	.2667	.1905	.2286	.1905	.2667	.1905
21	.1905	.2286	.1715	.1905	.1905	.2667	.1905
22	.1905	.2286	.1905	.1905	.1334	.1905	.1905
23	.2096	.1905	.1715	.1524	.1905	.1524	.1905
24	.1905	.1905	.1905	.1905	.1524	.1334	.1334
Max	3.7723	2.7816	3.0483	2.6292	2.5911	2.5339	.1905
Min	.1905	.1715	.1715	.1524	.1334	.1334	.1143
Avg	1.1985	1.0234	.8322	1.0158	.7579	.9578	.1638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 201 / 11 KV LAMBOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14				.4359		
15			.4801	.5228	.6036	.373
16				.5601		
17		.6219	.5121	.5658		
18		.6401	.6401	.5658		
19		.5544	.823	.7545		
20		.815	.9511	.9431		
21		.8505	.8505	.8676		
22		.7442	.7865	.7682		
23	.7316	.6878	.695	.7316		
Max	.7316	.8505	.9511	.9431	.6036	.373
Min	.7316	.5544	.4801	.4359	.6036	.373
Avg	.7316	.7020	.7173	.6715	.6036	.373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 202 / 11 KV SHIRAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14		2.7349	1.8275	
15	2.13	2.1628	1.9448	
16		2.0119	2.1605	
17		1.2254	2.1735	
18		1.1888		
19		.3018		.8413
20				.7602
21		.2743		.724
22		.2829		.6584
23		.2829		.5121
Max	2.13	2.7349	2.1735	.8413
Min	2.13	.2743	1.8275	.5121
Avg	2.13	1.1629	2.0266	.6992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 203 / 11 KV SAWALESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14			3.8561	2.9984	3.8409
15			2.9835		3.5208
16				2.4905	
17		2.9673	3.1493	2.4006	
18		2.915	3.0521	2.5415	
19		.5121	.7545	.7545	
20		.6584	.8779	.7545	
21		.7316	.823	.7545	
22		.6584	.7316	.695	
23	.5601	.5853	.5853	.6335	
Max	.5601	2.9673	3.8561	2.9984	3.8409
Min	.5601	.5121	.5853	.6335	3.5208
Avg	.5601	1.2897	1.8681	1.5581	3.6809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 205 / 11 KV ARJUNSOND FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.7013			
2	1.2803	1.7013			
3	1.3756	1.6118			
4	1.4266	1.6476			
5	1.4022	1.6289			
6	1.5043	1.6651			
7	1.7909	1.8823			
14			.3658	.2641	
15		.3688		.3688	
16		.439	.415	.4854	
17	.8413	.4904	.4527	.3734	
18	.3658	.4904	.4715		
19	.439	.4527	.4715		.7316
20	.4755	.439	.5281	.4435	.7095
21	.5121	.439	.4904	.5228	.6722
22	.4755	.4024	.4527	.4854	.5975
23	.3658	.4024	.4527	.4481	.4481
24	.3506	.3658			
Max	1.7909	1.8823	.5281	.5228	.7316
Min	.3506	.3658	.3658	.2641	.4481
Avg	.9272	.9487	.4556	.4239	.6318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 206 / 11 KV PANCHRATNA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187			
2		.0187			
3		.0168			
4		.017			
5		.0168			
6		.0168			
7		.0168			
14			.0492	.0566	
15		.0503		.0503	
16		.0377	.0335	.0366	.056
17	.0377	.0377	.0717		.056
18	.0377	.0377	.066		.0038
19	.0566	.0377	.0604		.0038
20	.0566	.0377	.0566	.0373	.0038
21		.0377	.0189	.017	.0038
22	.0566	.0377	.0377	.0168	.0037
23	.0377	.0189	.0377	.0168	.0037
24		.0373			
Max	.0566	.0503	.0717	.0566	.056
Min	.0377	.0168	.0189	.0168	.0037
Avg	.0472	.0289	.0480	.0331	.0168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274077 / 33/11 KV LAMBOTI

Feeder No / Name : 207 / 11KV TOLL PLAZA

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0604	.0622			
2		.0622	.0585			
3		.0585	.0579			
4		.0585	.0547			
5		.0547	.0547			
6		.0566	.0547			
7		.0189	.0189			
14				.0207	.0264	
15			.0264		.0264	
16				.0245	.0245	
17		.0189	.0245	.0245	.0245	
18		.0434	.0321	.0321		
19		.049	.0472	.0547		.066
20		.0585	.0679	.0641	.066	.0641
21		.0604	.066	.0604	.066	.0604
22		.0585	.0622	.0622	.0641	.0641
23	.0622	.0604	.066	.0622	.0622	.0641
24		.0585	.0604			
Max	.0622	.0622	.0679	.0641	.066	.066
Min	.0622	.0189	.0189	.0207	.0245	.0604
Avg	.0622	.0518	.0509	.0450	.0450	.0637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 201 / 11 KV KONHARI PAPRI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.5144	.5144	.5144	.5144	.5144
2	.5144		.5144	.5144	.5144	.5144	.5144
3	.5144		.5144	.5144	.5144	.5144	.5144
4	.5144		.5144	.5144	.5144	.5144	.5144
5	.5144		.5144	.5144	.5144	.5144	.5144
11	2.4006			3.4294	2.7435	3.6008	3.4294
12	2.6578	3.0864		3.4294	3.2579	3.9438	
13	2.8292	3.0864			3.858	3.9438	
14	3.0007	2.915		.3429	3.3436	3.9438	
15	2.572	3.0864		3.4294	3.5151	3.7723	
16	2.6578	2.8807		3.4294	3.7723	3.5837	
17	2.8292	3.0864		3.4294	3.6008	3.6008	
18	3.0007	3.0864		3.4294	2.6578	3.7723	
19	2.8292	3.0864		3.4294	4.1152	3.7723	3.4294
20	2.572	2.915		3.4294	4.1152	3.7723	3.4294
21	2.0576	2.915		3.4294	3.6866	3.6008	3.4294
22		3.2579		3.4294	3.6008	3.8237	3.4294
23		3.2579		3.4294	3.4294	3.7723	3.4294
24	2.7435		.5144	.5144	3.4294	3.3436	3.4294
Max	3.0007	3.2579	.5144	3.4294	4.1152	3.9438	3.4294
Min	.5144	2.8807	.5144	.3429	.5144	.5144	.5144
Avg	2.0425	3.0550	.5144	2.2863	2.7209	2.8852	2.2148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 202 / 11 KV PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.4863	2.915	2.915	2.7435	3.4294
2	2.572	2.572	2.915	2.915	2.7435	3.6008
3	2.572	2.6578	3.0864	3.0864	2.915	3.6008
4	2.572	2.7435	3.0864	3.0864	2.915	3.6008
5	2.7435	2.915	3.4294	3.0864	3.0864	3.6008
6	3.4294	3.4294	3.6008	3.6008	3.4294	3.6008
7	3.6008	3.6008	4.1152	3.9438	3.7723	3.4294
8	4.1152	3.7723	3.9438	3.0864	3.7723	3.6008
9	3.7723	3.4294	3.4294	3.6008	3.9438	3.6008
10	3.2579	3.4294	3.4294	3.0864	3.2579	2.7435
19		.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5144	.5144	.5144	.5144
Max	4.1152	3.7723	4.1152	3.9438	3.9438	3.6008
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	2.2405	2.1326	2.3148	2.2184	2.2291	2.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 203 / 11 KV PENUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.915	2.8292	3.0864	3.0864	3.4294	4.1152
2	3.0864	3.0007	3.0864	3.0864	3.6008	4.1152
3	3.0864	3.3436	3.2579	3.4294	3.6866	4.1152
4	3.2579	3.5151	3.2579	3.6008	3.6008	3.9438
5	3.6008	3.6008	3.4294	3.9438	3.3436	4.2867
6	3.6866	3.858	3.9438	4.1152		
7	4.2867	3.3436	4.2867	4.2867	4.3724	
8	.5144	4.0295	4.2867	4.2867		3.9438
9	.5144	3.6008	4.3724	4.2867		4.1152
10	3.858	3.6008	3.9438	4.2867		4.201
19		.5144	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5144	.5144	.5144	.5144
Max	4.2867	4.0295	4.3724	4.2867	4.3724	4.2867
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	2.0919	2.3630	2.5024	2.5935	2.0933	2.5659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 204 / 11 KV KHAWANI SAROLE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857		.0857	.0857
2	.0857	.0857		.0857	.0857
3	.0857	.0857		.0857	.0857
4	.0857	.0857		.0857	.0857
5	.0857	.0857		.0857	.0857
6	.0857	.0857		.0857	.0857
7	.0857	.0857		.0857	.0857
8	.0857	.0857		.0857	.0857
9	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	
11	.0857	.0857	.0857	.0857	
12	.0857	.0857	.0857	.0857	
13	.0857	.0857	.0857	.0857	
14	.0857	.0857	.0857	.0857	
15	.0857	.0343	.0857	.0857	
16	.0857	.0857	.0857	.0857	
17	.0857	.0857	.0857	.0857	
18	.0857	.0857	.0857	.0857	
19	.0857	.0857	.0857	.0857	
20	.0857	.0857	.0857	.0857	
21	.0857	.0857	.0857	.0857	
22	.0857	.0857	.0857	.0857	
23	.0857	.0857	.0857	.0857	
24	.0857	.0857		.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857
Min	.0857	.0343	.0857	.0857	.0857
Avg	.0857	.0836	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 205 / 11 KV YEWATI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5144	.5144	.5144
2	.5144	.5144	.5144	.5144	.5144	.5144
3	.5144	.5144	.5144	.5144	.5144	.5144
4	.5144	.5144	.5144	.5144	.5144	.5144
5	.5144	.5144	.5144	.5144	.5144	.5144
11	3.2579	3.4294	3.4294	3.4294	3.4294	3.4294
12	3.4294	3.4808	3.4294	3.4294	3.6008	
13	3.4294	3.4294	3.4294	3.1722	3.7723	
14		3.4294	3.4294	3.4294	3.9266	
15		3.2579	3.4294	3.4294	4.0295	
16		3.4294	3.4294	2.915	3.8752	
17		3.4294	3.4294	3.2579	3.7723	
18	3.2579	3.4294	3.4294	3.0864	3.8237	
19	.5144	3.4294	.5144	.5144	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144
21	.5144	.5144	.5144	.5144	.5144	.5144
22	.5144	.5144	.5144	.5144	.5144	.5144
23	.5144	.5144	.5144	.5144	.5144	.5144
24	.5144	.5144	.5144	.5144	.5144	.5144
Max	3.4294	3.4808	3.4294	3.4294	4.0295	3.4294
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	1.2689	1.8889	1.7418	1.6741	1.8889	.7573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274081 / 33/11 KV PENUR

Feeder No / Name : 206 / 11 KV PENUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.6859	.6859	.4287
2	.6859	.6859	.6859	.6859	.6859	.3772
3	.6859	.6859	.6859	.6859	.6859	.3429
4	.6859	.6859	.6859	.6859	.6859	.5144
5	.6859	.6859	.6859	.6859	.6859	.6859
6	.6859	.6859				
10			.6859	.6859	.6859	.6859
11			.6859	.6859	.3429	.6859
12	.6859	.3429	.6859	.6859	.4973	
13	.6859	.4287	.6859	.6859	.6001	
14	.6859	.4287	.6859	.6859	.5144	
15	.6859	.4458	.6859	.6859	.6859	
16		.4801	.6859	.6859	.6859	
17		.4973	.6859	.6859	.5144	.6859
18		.5144	.6859	.6859	.5144	.6859
19	.6859	.6859	.6859	.6859	.5144	.6859
20	.6859	.6859	.6859	.6859	.5144	.6859
21	.6859	.6859	.6859	.6859	.6859	.6859
22	.6859	.4287	.6859	.6859	.6859	.6859
23	.6859	.4458	.6859	.6859	.6859	.6859
24	.6859	.6859	.6859	.6859	.6859	.5144
Max	.6859	.6859	.6859	.6859	.6859	.6859
Min	.6859	.3429	.6859	.6859	.3429	.3429
Avg	.6859	.5722	.6859	.6859	.6122	.6024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 201 / 11 KV ASHTI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)
20	.2743	.3429
Max	.2743	.3429
Min	.2743	.3429
Avg	.2743	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 204 / 11 KV BAIRAGWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	24-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)
8	2.4387	
9	2.5453	
10	2.2405	
11	2.4387	2.4082
12	2.2862	2.5149
13	2.2253	2.4691
14	2.1491	2.4387
15	2.1643	
16	2.1643	2.3167
17	2.0271	2.3929
18	2.4082	2.0119
19	2.2862	2.4691
20		2.3167
Max	2.5453	2.5149
Min	2.0271	2.0119
Avg	2.2812	2.3709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 205 / 11 KV SHETFAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	27-MAR-18
HR	Load (MW)
12	.4287
13	.3772
Max	.4287
Min	.3772
Avg	.4030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274082 / 33/11 KV SHETPHAL

Feeder No / Name : 209 / 11 KV TELANGWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	27-MAR-18
HR	Load (MW)
20	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV DIKSAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18
HR	Load (MW)
1	.5868
2	.5801
3	.5868
4	.6783
11	1.8004
12	2.774
13	3.0121
14	2.2786
15	2.5415
16	2.6292
17	2.6292
18	2.6292
19	.6783
20	.9326
21	.763
22	.6706
23	.6706
24	.5868
Max	3.0121
Min	.5801
Avg	1.5016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV NARKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18
HR	Load (MW)
1	.8478
2	.9326
3	.9326
4	1.0174
11	2.8349
12	3.4027
13	4.2086
14	4.3439
15	4.1629
16	4.0295
17	3.4027
18	3.5818
19	1.0174
20	1.5261
21	1.6956
22	1.3565
23	1.1869
24	.9326
Max	4.3439
Min	.8478
Avg	2.3007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV EKURKE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18
HR	Load (MW)
1	1.8004
2	1.9719
3	1.9719
4	2.0576
5	2.2539
6	2.5139
7	2.8921
8	2.8045
9	2.4539
10	2.5415
17	.1658
19	.3315
20	.4973
21	.4144
22	.4144
23	.3315
24	.2486
Max	2.8921
Min	.1658
Avg	1.5097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV WALUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18
HR	Load (MW)
2	.1658
3	.1658
4	.2486
11	2.6292
13	3.7609
14	3.4027
15	3.7609
17	3.3665
18	3.1893
19	.2486
20	.4144
22	.2486
23	.1658
24	.1658
Max	3.7609
Min	.1658
Avg	1.5666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274084 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV HINGANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	25-MAR-18
HR	Load (MW)
1	1.5432
2	1.5432
3	1.5432
4	1.7147
5	2.2291
6	2.5139
7	2.6292
8	2.5139
9	2.5139
10	2.3405
17	.1658
18	.1658
19	.2486
20	.3315
21	.3315
22	.2486
23	.1658
24	.1658
Max	2.6292
Min	.1658
Avg	1.2727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 201 / 11 KV OLD KURUL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8025		
7				2.2862
8		1.3272		2.2531
9		1.5432		
18			.1943	
19	.2267		.2591	
23	.1898		.2343	
24		.1543		.1852
Max	.2267	1.5432	.2591	2.2862
Min	.1898	.1543	.1943	.1852
Avg	.2083	.9568	.2292	1.5748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097] BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 202 / 11 KV KATEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241		
11			2.7778	
14	1.1717			
18			2.9012	
19	.253		.2846	
23	.2187		.2343	
24		.2591		.1875
Max	1.1717	.2591	2.9012	.1875
Min	.2187	.2241	.2343	.1875
Avg	.5478	.2416	1.5495	.1875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 203 / 11 KV ANKOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.2372	.2915		.3201	
2	.176		.3086		.3201	
3	.192		.3239		.3201	
4	.192		.3239		.3361	
10		2.7435				
11		2.7435				
12		2.8292			3.4259	
13		3.2579				
14	2.7778	3.4294				
15		3.0483				
16		2.8959		2.8807		
17		2.7435				
18		2.7435			2.6235	
19	.3125	.2439			.25	
20		.2915		.2881		
23	.2343			.3361	.3005	
24	.16	.2372	.2134		.3201	.2812
Max	2.7778	3.4294	.3239	2.8807	3.4259	.2812
Min	.16	.2372	.2134	.2881	.25	.2812
Avg	.5256	2.1111	.2923	1.1683	.9129	.2812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 204 / 11 KV KURUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4641	.4805	.5487		.4801	
2	.4641		.5487		.4801	
3	.4801		.6001			
4	.5121				.5601	
5	.5441		.6516			
6	.6722		.7373		.7202	
7	.7042		.7545		.7682	.8478
8	.6081		.703		.7202	.6874
9	.5441	.5426	.664		.6562	
10		.5487				
11		.6516				
12		.583				
13		.6173				
14	.4578	.442				
16		.4877				
17		.5487				
18		.6516			.78	
19	.7373				.8648	
20		.6859		.7202		
23	.463			.5761	.703	
24	.4321	.4572	.442		.5601	.7164
Max	.7373	.6859	.7545	.7202	.8648	.8478
Min	.4321	.442	.442	.5761	.4801	.6874
Avg	.5449	.5581	.6278	.6482	.663	.7505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 205 / 11 KV NEW KURUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.8519	2.0576		.6722	
2	1.8404		2.0576		.7202	
3	1.9204		2.0576		.7362	
4	2.0005		1.9814			
5	2.0005		2.0576		.8002	
6	2.7206		2.4863		1.0402	
7	2.9447		2.3624		1.2003	2.5
8	2.8807	2.8704	2.0576		1.1523	1.9814
9	2.8807	2.7435			1.1203	
10		2.915				
17		.1619				
18		.1829				
19	.2469	.2401			.25	
20		.2401		.096		
23	.2006			.144	.2315	
24	.176	.1852	.2401		.128	.1852
Max	2.9447	2.915	2.4863	.144	1.2003	2.5
Min	.176	.1619	.2401	.096	.128	.1852
Avg	1.8004	1.2657	1.9287	.12	.7319	1.5555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 206 / 11 KV SHEJBABHULGAON
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4321	.3858	.6173		.5601	
2	.4481		.583		.5761	
3	.4481		.5487		.5921	
4	.4801		.5487		.6081	
8		.381				
11		3.1579			3.236	
12		3.5151				
13		3.2388				
14	2.8898	3.2388				
15		3.4294				
16		3.3436		3.1207		
17		3.3951				
18		3.2579			3.0613	
19	.3161				.3763	
20		.3429		.6401		
23	.3353			.6401	.6097	
24	.4161	.381	.6001		.5761	.6321
Max	2.8898	3.5151	.6173	3.1207	3.236	.6321
Min	.3161	.3429	.5487	.6401	.3763	.6321
Avg	.7207	2.3389	.5796	1.4670	1.1329	.6321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274112 / 33/11 KV KURUL

Feeder No / Name : 207 / 11 KV S.WARWADE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7604	1.768	1.829		1.6004	
2	1.9204		1.829			
3	1.9204		2.1052		2.0805	
4	2.0005		2.2672			
5	2.1605		2.2672		.1036	
6	2.7206		2.572		2.5606	
7	2.9607		2.8826		2.8807	2.7435
8	2.8807	2.8959	3.2236		.192	2.5911
9	2.8006	2.7778	2.5911			
10		2.3624				
17		.2915				
19	.2623	.3258			.3658	
20		.3258		.3201		
23	.2623			.2721	.3506	
24	.2241	.2623	1.8861		.2561	.3353
Max	2.9607	2.8959	3.2236	.3201	2.8807	2.7435
Min	.2241	.2623	1.829	.2721	.1036	.3353
Avg	1.8228	1.3762	2.3453	.2961	1.1545	1.8900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 201 / 11 KV CHANDRAMOULI ESTATE SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.7773	.9945	.8097	.964	.964	.8478
2	.4239	.7287	.9116	.8802	.964	1.0517	.8669
3	.407	.7373	.9116	.9231	.964	.964	.9536
4	.4239	.8192	.9448	.9069	.964	.7888	.9015
5		.8421	.0332	.8907	.964	.964	.8916
6	.4239	.7125	.8288	.8097	.7888	.964	.8573
7	.5087	.6226	.9116	.7773	.7888	.964	.7802
8	.5765	.421	.9339	.8907	.8238	.964	.5548
9	.8478	.9831	.9116	.964	.964	.8764	.5243
10	1.0174	.9717	1.0402	1.0517	1.2717	.964	.5735
11	1.1022	1.0774	1.0526	1.1694	1.1393		.5668
12	1.2717	.4144	.9602	1.1393	1.1393		.5668
13	1.1869	1.0898	1.0688	1.1393	1.2269	.9431	.5601
14		1.1603	1.0402	1.226	1.0517	1.1022	
15	1.1022	1.0774	1.0526	1.1568	1.2269	1.0513	.4001
16		.9945	.9922	.964	1.0517	1.1022	.3563
17	.4096	.9116	.9717	.964	1.0517	1.0059	.3563
18	.7373	.8718	1.004	.9991		1.1145	.3563
19	.9069	.3315	.9717	.9114	1.0517	.9431	.4049
20	.8907	.7459	1.0402	.964	1.0517	.9431	.4049
21	.8421	.8619	.9831	.8764	1.2269	1.0174	.4858
22	.852	.9116	.9282	.9114	1.2269	1.0288	.4858
23	.852	.9724	.8907	.9536	1.2269	.9431	.5735
24	.4748	.8192	.9945	.8907	.964	.964	.9431
Max	1.2717	1.1603	1.0688	1.226	1.2717	1.1145	.9536
Min	.407	.3315	.0332	.7773	.7888	.7888	.3563
Avg	.7467	.8273	.9322	.9654	1.0475	.9829	.6179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 202 / 11 KV GOTEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4587	2.2653	2.2028	2.2653	2.2085	2.3663	2.0083
2	2.5095	2.4215	2.3278	2.4215	2.3365	2.3739	2.0833
3	2.6282	2.4691	2.5463	2.5621	2.4326	2.4587	2.2377
4	2.713	2.3122	2.5926	2.6092	2.5766	2.6282	2.4082
5	2.8656	2.734	2.6543	2.7808	2.6882	2.7978	2.5911
6	3.1878	3.0247	2.7006	3.062	2.5934	3.1369	2.8549
7	3.5947	3.2407	2.8241	3.2026	3.4888	3.5608	3.2465
8	3.866	3.3642	3.3379	3.4214	3.5896	3.883	3.3836
9	3.4252		3.4141	3.4057	3.5263	3.8152	2.8938
10	3.2733	3.3432	3.4995	3.4156	3.4408	2.7978	3.0361
17	.2241	.2458	.2214	.2721	.2401	.3077	
18	.3201	.3113	.3479	.3041		.3041	
19	.4428	.3441	.3795	.4049	.3521	.3978	.3521
20	.3953	.3768	.3953	.3563	.3681	.3647	.3795
21	.3953	.3277	.3437	.3005	.3041	.3315	.3605
22	.3479	.2949	.3163	.2846	.2881	.3315	.2881
23	.3479	.2818	.2846	.2561	.2561	.3113	.2881
24	.2543	.3241	.2622	.2881	.2241	.2561	.3113
Max	3.866	3.3642	3.4995	3.4214	3.5896	3.883	3.3836
Min	.2241	.2458	.2214	.2561	.2241	.2561	.2881
Avg	1.8472	1.6283	1.7028	1.7563	1.8185	1.8013	1.7952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 203 / 11 KV WADWAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.407	.4191	.4239	.4287	.4001	.4681
2	.373	.39	.4191	.4024	.4287	.4001	.4334
3	.3561	.39	.4527	.3812	.4287	.4001	.4334
4	.3561	.407	.503	.4144	.4287	.3841	.3467
5	.39	.4908	.5801	.5201	.4801	.4001	.3772
6	.4409	.5373	.5868	.6135	.6001	.4001	.4801
7	.4578	.6154	.6133	.6447	.7202	.4801	.3429
8	.4239	.5973	.5801	.543	.6859	.4481	.3086
9		.4656	.5304	.5014	.6001	.4481	.2629
10	.4239	.431	.4382	.4458	.4287	.4801	
11	.39	.503	.4334	.4801	.4115		.373
12	.4239	.3353	.4207	.4287	.3944		.373
13	.407	.4191	.4115	.4287	.4115	.3944	.4694
14		.4191	.4409	.4287	.4287	.4681	.5087
15	.39	.4191	.4748	.3688	.4287	.5201	.4748
16		.4527	.5201	.373	.4287	.5201	.4748
17	.373	.4191	.5548	.4239	.3429	.2629	.5426
18	.5201	.5365	.631	.4578		.5658	.6024
19	.6661	.5868	.7265	.6783	.5144	.6344	.567
20	.6516	.5801	.7087	.6443	.5144	.6001	.4915
21	.5194	.547	.5201	.6001	.5144	.6001	.4908
22	.4908	.4973	.4578	.5144	.4287	.6001	.4694
23	.4409	.4527		.4801	.4287	.5487	.4409
24	.407	.4334	.4191	.4239	.4287	.3841	.4287
Max	.6661	.6154	.7265	.6783	.7202	.6344	.6024
Min	.3561	.3353	.4115	.3688	.3429	.2629	.2629
Avg	.4416	.4722	.5149	.4842	.4742	.4700	.4418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274126 / 33/11 KV CHANDRAMOULI

Feeder No / Name : 204 / 11 KV VARDHMAN EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339	.037	.0347	.0373	.0377	.0377	.0332
2	.0339	.037	.0347	.037	.0377	.0377	.0339
3	.0339	.037	.0347	.037	.0377	.0377	.0343
4	.0339	.037	.0347		.0377	.0377	.0343
5	.0339	.037	.0343	.0373	.0377	.0377	.0343
6	.0339	.037	.0347	.037	.0377	.0377	.0332
7	.0339	.037	.0343	.037	.0377	.0377	.032
8	.0339	.037	.0343	.037	.0377	.0377	.0332
9	.0339	.037	.0347	.037	.0377	.0377	.0373
10	.0339		.037	.0377	.0377	.0377	.037
11	.0339	.0347	.037	.0377	.0377		.037
12	.0339	.0351	.037	.0377	.0377		.037
13	.0339	.0339	.0366		.0377	.0328	.0373
14	.0339	.0343	.037	.0377	.0377	.0328	.037
15	.0339	.0343	.037	.0377	.0343	.0332	.037
16		.0347	.037	.0377	.0343	.0328	.0373
17	.0366	.0347	.0366	.0377	.0377	.0328	.037
18	.0366	.0343	.037	.0377		.0335	.037
19	.0366	.0347	.037		.0377	.0335	.037
20	.0366	.0347	.037	.0377	.0343	.0332	.0373
21	.037	.0347	.037	.0377	.0377	.0332	.037
22	.037	.0514	.0366	.0377	.0377	.0332	.037
23	.037	.0514	.037	.0377	.0377	.0343	.0373
24	.0339	.0366	.0514	.0373	.0377	.0377	.0343
Max	.037	.0514	.0514	.0377	.0377	.0377	.0373
Min	.0339	.0339	.0343	.037	.0343	.0328	.032
Avg	.0348	.0371	.0366	.0374	.0373	.0355	.0358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 201 / 11 KV SOUNDANE

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6216	2.6825	2.5149	2.9492	3.2922	2.2862
2	2.6216	2.6825	2.5149	3.0312	3.0178	2.572
3	2.7035	2.6825	2.5149	3.0312	2.9835	2.5911
4	2.7035	2.6825	2.5911	3.195	3.1855	2.5911
5	2.7854	2.8166	2.6825	3.3589	3.1493	2.8959
6	2.8673	3.1184	2.774	3.5227	3.2487	3.0483
7	3.0312	3.3532	2.9264	3.5227		3.0483
8	3.195	3.3532	2.8959	3.6046	3.6466	2.7435
9	3.0312	3.3532	2.8654		3.2968	2.5911
10	2.4577	3.1184	2.7435	3.4408	3.0769	2.1338
19	.7316	.439	.5144		.543	
20	.695	.6219	.4801		.5544	.5144
21	.695	.5487	.5144		.5544	.6001
22	.695	.5121	.5144		.6468	.6001
23	.695	.4755	.5144		.6468	.6001
24	.4572	.5121	.4801	.5487	.5792	.6001
Max	3.195	3.3532	2.9264	3.6046	3.6466	3.0483
Min	.4572	.439	.4801	.5487	.543	.5144
Avg	1.9992	2.0595	1.8776	3.0205	2.1615	1.9611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 202 / 11 KV TAMBOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.6859	.7316		.7716
2	.7316	.7316	.6097	.7316		.7716
11	3.4736	1.2003	2.5149	3.3097	3.6466	3.0483
12	3.6046		3.2007		3.4808	
13	3.6046	3.5543	3.2769	3.3425	3.2388	
14	3.6046		3.0483	3.3753	3.315	
15	3.3753	3.5208	3.0483	3.4408	3.315	
16	3.6046	3.5208	3.2007	3.4736	3.4808	
17	3.4408	3.5543	3.2769	3.4736	3.2388	
18	3.3097	3.4873	3.0483	3.2769		
19	.6882	.823	.6859		.9145	.9431
20	.7682	1.0974	.7716		.9145	.9431
21	.8048	1.0059	.8573		.9145	.9431
22	.8048	.9145	.7716		.924	.9431
23	.7316	.8413	.7716		.8316	.8573
24	.7316	.7316	.6859	.7316	.823	.7716
Max	3.6046	3.5543	3.2769	3.4736	3.6466	3.0483
Min	.6882	.7316	.6097	.7316	.823	.7716
Avg	2.1256	1.8368	1.9034	2.5887	2.2337	1.1103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 203 / 11kv PATKUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.8807	2.5911	2.7035	2.8292	2.7435
2	3.1131	2.8464	2.7435	2.9492	2.915	2.7435
3	3.2769	2.8464	2.7435	3.0312	2.8178	2.5911
4	3.2769	3.2007	2.7435	3.1131	2.8178	2.7435
5	3.2769	3.1626	2.8959	3.3589	3.1131	3.0483
6	3.4408	3.3524	3.0483	3.4408	3.4294	3.0483
7	3.6046	3.4789	3.1398	3.5227		3.1245
8	3.8504	3.5421	3.1703	3.7685	3.9323	3.0483
9	3.6866	3.3524	3.2007	3.6866	3.746	2.5911
10	3.6046	3.2259	2.9874	3.4408	3.2099	2.4387
11			2.9874			
19	.5121	.3696	.3429			.4287
20	.5487	.5853	.4287			.5144
21	.5487	.4755	.4287		.543	.5144
22	.5487	.439	.4287		.5487	.5144
23	.5487	.439	.4287		.4572	.4801
24	.4572	.4755	.4287	.4572	.439	.4287
Max	3.8504	3.5421	3.2007	3.7685	3.9323	3.1245
Min	.4572	.3696	.3429	.4572	.439	.4287
Avg	2.3320	2.1670	2.0434	3.0430	2.3691	1.9376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274152 / 33/11 TAKALI SIKANDAR

Feeder No / Name : 204 / 11 KV TAKALI SIKANDAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4207	.3429	.3658	.439	.4287
2	.4572	.4207	.3429	.3658	.439	.4287
11		1.9608	1.7528	2.13	2.7435	2.0576
12	1.8023	2.1822	2.2862		2.7435	
13	2.0972	2.1822	2.3167	2.2119	2.3205	
14	2.13	2.119	2.21	2.2939	2.4006	
15	2.0481	2.0873	2.0119	2.2939	2.4577	
16	2.0972	2.0557	2.1338	2.2939	2.2939	
17	2.13	2.037	2.1338	2.2939	2.4577	
18	2.0481	2.0062	2.0576	1.9989		
19	.4287	.3658			.4144	.5144
20	.4755	.4755	.4287		.4477	.5144
21	.4572	.439	.4287		.4525	.5144
22	.4572	.4024	.4287		.4572	.5144
23	.4207	.3898	.3772		.4572	.4287
24	.4572	.4207	.3944	.4024	.439	.4287
Max	2.13	2.1822	2.3167	2.2939	2.7435	2.0576
Min	.4207	.3658	.3429	.3658	.4144	.4287
Avg	1.1976	1.2478	1.3098	1.6650	1.3976	.6478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 201 / 11 KV BHAMBHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3429	.381	.4001	.4191	.3086	2.7816
2	.4382	.3772	.4572	.4191	.4572	.2915	2.8197
3	.4572	.3772	.5335	.4763	.5144	.3429	2.8197
4	.5335	.4458	.6478	.5716	.6859	.3772	2.8578
5	.6097	.5144	.6859	.5906	.7621	.4115	2.934
6	.7811	.583	.7621		.8002	.4801	3.2388
7	.8192	.6516				.7716	3.5056
8							3.6199
10							3.2579
11	3.0178	3.155	3.0178	3.2769	3.0864		
12	3.3951	3.4294	3.4637	3.4865	3.1207		
13	3.4294	3.4637	3.4294	3.658	3.2579	3.035	
14	3.4294	3.4294	3.3951	3.296	2.9664	3.0521	
15	3.2579		3.4294	3.5056	3.0864	3.3779	
16		3.4808	3.4808	3.5246	3.2236	3.3951	
17	3.4465	3.3779	3.1722	3.3722	3.1893		
18	3.1893	3.4865	3.1245	3.3341	3.0864		
19	.5144	.5906	.6859	.6287	.3772	.6859	.7621
20	.6687	.743	.6668	.6668	.583	.7049	.5716
21	.5144	.6097	.5906	.6097		.6668	.6478
22	.5144	.5335	.5716	.5716	.4973	.6097	.5716
23	.3429	.4763	.4954	.5144	.4287	.4954	.4763
24	.4191	.3429	.4001	.4382	.4191	.3429	.4382
Max	3.4465	3.4865	3.4808	3.658	3.2579	3.3951	3.6199
Min	.3429	.3429	.381	.4001	.3772	.2915	.4382
Avg	1.5099	1.5205	1.6695	1.7548	1.6295	1.1382	2.0868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274194 / 33/11 KV BHAMBEWADI

Feeder No / Name : 202 / 11kv Ashte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4801	.4763	.5906	1.5242	1.6289	.4001
2	.4954	.5144	.5144	.6287	1.6004	1.8861	.4001
3	.5335	.5144	.5716	.6287	1.6766	1.8519	.4382
4	.5716	.6001	.6478	.6859	1.829	1.8004	.4763
5	.5906	.6687	.6859	.7621	1.9052	1.8004	.5335
6	.8192	.7202	.8383	1.0479	2.0957	2.1948	.6287
7	.9526	.8402	.9145	1.3717	2.191	2.1262	.6287
8	1.0669	.8402	.8954	1.6004	2.2481		.6097
9	.9717	.7888	.8573	1.6194	2.1338		
10	.6344	.7716	.7373	1.6194	1.9204	1.5947	.3944
11	.0857	.0857	.1372	.1524	.12		1.7147
12	.12	.12	.1372	.1524	.12		1.8347
13	.12	.12	.1372	.1524		.1543	
14	.12	.12	.1372	.1524	.1372	.1715	
15	.12	.1372	.1715	.1715	.1715	.2058	
16		.1715	.1715	.1715	.1715	.2058	
17	.2058	.1543	.2058	.2667	.2058	.3086	
18	.1715	.2096	.2096	.3048	.2743	.4191	
19	.2058	.2858	.3429	.4001	.3086	.5525	.4382
20	.3086	.3239	.3239	.4763	.3429	.5144	.4001
21	.2401	.2477	.2858	.362	.3772	.4763	.381
22	.2058	.2286	.2096	.3048	.4115	.4191	.362
23	.1715	.1905	.2096	.2477	.3429	.4191	.4001
24	.1905	.1372	.1905	.1905	.2477	.3772	.381
Max	1.0669	.8402	.9145	1.6194	2.2481	2.1948	1.8347
Min	.0857	.0857	.1372	.1524	.12	.1543	.362
Avg	.4085	.3863	.4170	.5858	.9720	.9554	.6130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 201 / 11 KV KURANWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0486	.0469	.0486	.0469	.0446	.0486
2	.0312	.0486	.0469	.0486	.0469	.0446	.0648
3	.0312	.0648	.0469	.0648	.0469	.0446	.0648
4	.0469	.0648	.0625	.0648	.0625	.0594	.0648
5	.0625	.081	.0937	.081	.0625	.0594	.0648
11	.6249	.7125	.6249	.7125	.6874	.5944	
12	1.0155	.8259	.7811	1.0202	.7655	.6241	
13	.9686	.8583	.9374	1.0688	.9061	.6093	
14	.9374	.8907	.9061	1.0526	.9061	.6241	
15	.9061	.8745	.9217	1.0202	.9374	.7133	
16	.9061	.8583	.9374	1.0364	.953	.743	
17	.8905	.8583	.9217	1.0364	.9686	.9214	
18	.8749	.9231	.9061	1.004	.953	.8322	
20	.0625	.0648	.0625	.0648	.0625	.0446	.0648
21	.0625	.0648	.0625	.0648	.0625	.0594	.0648
22	.0469	.0648	.0469	.0648	.0469	.0594	.0486
23	.0469	.0486	.0469	.0486	.0469	.0446	.0486
24	.0312	.0486	.0469	.0486	.0469	.0446	.0486
Max	1.0155	.9231	.9374	1.0688	.9686	.9214	.0648
Min	.0312	.0486	.0469	.0486	.0469	.0446	.0486
Avg	.4209	.4112	.4166	.4750	.4227	.3426	.0583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 202 / 11 KV ASHTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2241	.2587	.2241	.2587	.2587	.2614
2	.2587	.2241	.2587	.2241	.2957	.2218	.2987
3	.2957	.2987	.2957	.2614	.3326	.2957	.2987
4	.3696	.3361	.3326	.3361	.3696	.3696	.3361
5	.4805	.4108	.4805	.4481	.4435	.4805	.4108
6	.5175	.5228	.5175	.5228	.4805	.4066	.4854
7	.4805	.4854	.4805	.4854	.4435	.3696	.3734
8							.3361
9							.2614
10							.2614
12	.3696	.3361	.3326	.3734	.3696	.2587	
13	.3326	.2987	.2957	.3361	.3326	.2957	
14	.2587	.2614		.2987	.2587	.2957	
15	.2218	.2614		.2614	.2218	.2587	.2987
16	.2218	.2614		.2614	.2587	.2218	.2987
17	.2587	.2614			.2957	.2587	.2614
18	.2957	.2987	.3326		.3326	.2587	.3361
19	.3326	.4854	.4435	.4854	.3696	.3326	.4481
20	.4066	.4481	.4805	.4481	.4435	.3696	.4854
21	.4435	.3734	.4066	.4108	.4066	.4066	.4108
22	.3696	.3361	.3326	.3734	.3696	.3326	.3734
23	.2614	.2987	.2957	.3361	.3326	.2957	.3361
24	.2957	.9896	.2957	.2614	.2957	.2957	.2614
Max	.5175	.9896	.5175	.5228	.4805	.4805	.4854
Min	.2218	.2241	.2587	.2241	.2218	.2218	.2614
Avg	.3365	.3706	.3650	.3527	.3456	.3142	.3417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274201 / 33/11 KV KURANWADI(ASHTI)

Feeder No / Name : 203 / 11 KV MASOBA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1862	2.2377	2.1052	2.1548	2.2348	2.1338	2.2542
2	2.2672	2.3205	2.1862	2.3205	2.3482	2.21	2.3205
3	2.3482	2.4034	2.2672	2.5692	2.4291	2.3472	2.4863
4	2.4291	2.5029	2.3482	2.652	2.5263	2.4691	2.5029
5	2.5263	2.6189	2.4615	2.7515	2.6882	2.5606	2.5526
6	2.753	2.8178	2.6558	2.8178	2.915	2.5911	2.652
7	3.0445	2.9835	2.8502	2.9172	3.0769	2.6673	2.8344
8	3.0769	3.083	2.8826	3.0498	3.0445	2.7435	2.9172
9	3.0769	2.8178	2.8826	3.0167	3.0121	2.7587	2.8841
10	3.0121	2.7846	2.7368	2.9835	2.8502	2.7435	2.8509
20	.2591	.1326	.2591	.1326	.2591	.1219	.2984
21	.2267	.1326	.1943	.1326	.2267	.1524	.2984
22	.1943	.1326	.1619	.1326	.1943	.1524	.2984
23	.1619	.0995	.1296	.0995	.1619	.1219	.2652
24	.0972	.1326	.0972	.1326	.0972	.1219	.1326
Max	3.0769	3.083	2.8826	3.0498	3.0769	2.7587	2.9172
Min	.0972	.0995	.0972	.0995	.0972	.1219	.1326
Avg	1.8440	1.8133	1.7479	1.8575	1.8710	1.7264	1.8365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 202 / 11 KV DEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.9259	1.0631	1.0288	.9259	1.3717	1.1145
2	.9259	1.0288	1.0631	1.166	1.1145	1.4575	1.166
3	1.1488	1.3375	1.3889	1.286	1.2689	1.6289	1.286
4	1.5775	1.6289	1.5947	1.3717	1.4918	1.9719	1.6804
5	2.0919	2.0576	2.0576	2.0233	1.9547	2.0576	2.4006
6	2.5034	2.7778	2.8292	2.5377	2.4691	2.7435	3.1036
7	2.4006	3.0521	3.1893	2.572	3.3265	3.0864	2.7435
8	3.3608	3.0864	3.3951	2.9492	2.2977	2.9835	3.2579
9	2.9492	3.0178	2.7435	3.2065	3.3608	3.3265	
10	2.5034	2.7435			3.0178	1.989	
11		2.7435					
20	.3429	.4801	.4801	.5144	.4801	.3772	.4801
21	.4458	.4287	.4973	.4458	.463	.4287	.4287
22	.4287	.3772	.5144	.3772	.4287	.4115	.3601
23	.4458	.3429	.5316	.3429	.3944	.4287	
24	.3429	.4458	.3086	.4801	.3086	.3772	.4115
Max	3.3608	3.0864	3.3951	3.2065	3.3608	3.3265	3.2579
Min	.3429	.3429	.3086	.3429	.3086	.3772	.3601
Avg	1.4860	1.6547	1.5469	1.4501	1.5535	1.6427	1.5361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 203 / 11 KV WAFALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4458	.4115	.4801	.4115		.4115
2	.4115	.4458	.4115	.4287	.4115	.3429	.4287
3	.4287	.4801	.4287	.3772	.4458	.4115	.4801
4	.4801	.4458	.4287	.3601	.4801	.4287	.5144
5	.5144	.4801	.4458	.3772	.5316	.4801	.5487
11	2.4006	2.4691		2.6406	2.4691	2.2291	
12	2.2634	2.7435		3.1893	3.0864	3.0864	
13	2.4006	2.7092		3.0521	2.7778	2.7435	
14	2.3663	2.6063		2.8121	2.915	2.7435	
15	2.572	2.4006		2.8635	2.4006	2.8292	
16	2.4863	2.4348		2.9492	2.6578	2.8464	
17	2.4348	2.5034			2.572	2.572	
18	2.7435	2.5377			2.7435	2.4863	
19			2.6749				
20	.4458	.5144	.5144	.5487	.5487	.3772	.5144
21	.4801	.4458	.5658	.463	.5144	.3944	.463
22	.463	.4115	.5487	.4287	.4801	.4115	.4115
23	.4801	.4115	.5144	.4115	.463	.3944	
24	.3944	.4287	.3772	.5144	.3772	.4287	.3772
Max	2.7435	2.7435	2.6749	3.1893	3.0864	3.0864	.5487
Min	.3944	.4115	.3772	.3601	.3772	.3429	.3772
Avg	1.3432	1.3841	.6656	1.3685	1.4603	1.4827	.4611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274205 / 33/11 KV DEWADI

Feeder No / Name : 205 / 11 KV DEWADI - WAFALE

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3601	.2915	.3772	.2915	.3086	.3601
2	.3086	.3772	.2915	.3944	.2915	.3086	.3772
3	.3086	.3601	.3086	.3601	.3086	.3429	.3772
4	.3429	.3429	.3429	.3772		.3772	.3944
5	.3772	.3772	.3772	.3429	.3772	.3944	.3429
6							.3086
7							.3086
8							.2743
10							.3086
12	.2229	.2058		.2743	.2572	.2058	
13	.2058	.2058		.2401	.2401	.2229	
14	.1715	.1715		.2058	.2229	.2058	
15	.1886	.1715		.1715	.1715	.1715	
16	.2058	.1715		.1715	.1715	.1715	
17	.2401	.1715			.2229	.2058	
18	.2743	.2058			.2572	.3086	
19	.3086	.3772	.3086		.3772	.3429	.4287
20	.3258	.3772	.4115	.4801	.4458	.3601	.4801
21	.3772	.4115	.4458	.4287	.4287	.3772	.4458
22	.3601	.3429	.4287	.3772	.4115	.4115	.3772
23	.3772	.3086	.4115	.3086	.3772	.3772	
24	.2743	.3429	.2743	.4115	.2743	.3429	.3429
Max	.3772	.4115	.4458	.4801	.4458	.4115	.4801
Min	.1715	.1715	.2743	.1715	.1715	.1715	.2743
Avg	.2867	.2934	.3538	.3281	.3016	.3020	.3662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 201 / 11 KV NEW KOTHALE AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL
DEGA Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2667	.2667	.2667	1.105
2			.2096	.2667	.2667	1.105
3			.2096	.2667	.2667	1.105
4			.2286	.2858	.2667	1.1431
5			.2858	.3239	.3429	1.1431
6			.2987	.3174	.3361	1.1694
7						1.3817
8				3.2556		1.4937
11	1.4563	1.7909				
12	1.6244	1.8671				
13	1.5592	1.6118				
14	1.4861	1.6598				
15	1.6004	1.5623				
16	1.6598	1.5565				
24			.2294	.2134	.2347	.1677
Max	1.6598	1.8671	.2987	3.2556	.3429	1.4937
Min	1.4563	1.5565	.2096	.2134	.2347	.1677
Avg	1.5644	1.6747	.2469	.6495	.2829	1.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 202 / 11 KV WAD-DEGOAN AG (WAD- SEPARATED AG FEEDERS HAVING SPECIAL
DEGAV Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9243	1.9433	2.0386	.1905
2			1.9814		2.0386	.1905
3			1.9814	1.9433	2.0386	.1905
4			1.9814	2.0195	2.0386	.2286
5			2.1338	2.2291	2.21	.3429
6			2.4272	2.6139	2.6139	.3395
7			3.062	2.5206	2.9874	
8			3.2895		3.2674	
9		3.3265				
10	2.9874	2.9874				
24			.1311	.1219	1.7772	.1494
Max	2.9874	3.3265	3.2895	2.6139	3.2674	.3429
Min	2.9874	2.9874	.1311	.1219	1.7772	.1494
Avg	2.9874	3.1570	2.1013	1.9131	2.3345	.2331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274229 / 33/11 KV WAD-DEGAON S/S

Feeder No / Name : 203 / 11 KV AUNDHI AG (WAD-DEGAV SEPARATED AG FEEDERS HAVING SPECIAL
S.S Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2286	.2667	.2477	1.0669
2			.2286	.2667	.2477	1.0669
3			.2286	.2667	.2477	1.0669
4			.2667	.3239	.3429	1.1812
5			.381	.4572	.4191	1.2955
6			.4108	.4668	.4294	1.5466
7						2.0538
8						2.0911
11	2.3899					
12	2.8006	2.1658				
13	2.4451	2.3663				
14	2.1338	2.3011				
15	2.0767	2.3624				
16	2.3765	2.3529				
24			.1966	.1524	.2012	.168
Max	2.8006	2.3663	.4108	.4668	.4294	2.0911
Min	2.0767	2.1658	.1966	.1524	.2012	.168
Avg	2.3704	2.3097	.2773	.3143	.3051	1.2819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 201 / 11 KV JAMGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0514	.0686	.0514	.0857	.0514
2	.0343	.0514	.1029	.0514	.1029	.0514
3	.0514	.0514	.1029	.0514	.1029	.0514
4	.0514	.0514	.0686	.0686	.1372	.0514
5	.0686	.0514	.0686	.0686	.1372	.0686
6	.0857	.0686	.1029	.1029	.1029	.0686
7	.0857	.0514	.0686	.1029	.1029	.0686
8	.0686	.0343	.0686	.1029	.1029	.0514
9	.0514	.0343	.0686	.0857	.0686	.0343
10	.0686	.0343	.0857	.1029	.0686	.0514
11	1.2689	1.2689	1.1317		1.166	
12	1.6804	1.2689	1.3032	1.4746	1.406	
13	1.5432	1.3717	1.4575	1.5432	1.5089	
14	1.5261	1.406	1.3032	1.6118	1.4403	
15		1.5432	1.3375	1.3717	1.3375	
16	1.3375	1.4746	1.3375	1.3032	1.2689	
17	1.3032	1.5089	1.3717	1.2003	1.406	
18	.0514	1.4746	1.2517	1.3032	1.2346	
19	.0343	.0686	.0686	.0686	.0686	.1029
20	.0514	.0686	.0857	.0686	.0686	.0857
21	.0686	.0686	.0686	.0686	.0686	.0686
22	.0514	.0686	.0686	.0686	.0686	.0686
23	.0514	.0514	.0857	.0686	.0686	.0514
24	.0514	.0514	.0343	.0514	.0686	.0514
Max	1.6804	1.5432	1.4575	1.6118	1.5089	.1029
Min	.0343	.0343	.0343	.0514	.0686	.0343
Avg	.4182	.5072	.4880	.4779	.5080	.0611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 202 / 11 KV KORAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3889	1.4918	1.6118	1.2346	1.7147	1.2689
2	1.869	1.8004	1.7147	1.3889	1.8861	1.7661
3	2.5034	1.989	1.8861	1.6461	2.2291	1.989
4	3.0178	2.1948	2.1262	1.869	2.7435	2.5549
5	3.275	2.4863	2.572	2.5549	3.2579	3.4122
6	3.4808	2.9492	3.2579	3.3608	3.7723	3.738
7	3.3951	3.3093	3.6008	3.5837	3.9438	3.8752
8	3.2236	3.1379	3.1893	3.0178	3.4294	3.4637
9	.1372	.1372	2.0576	2.9835	3.0521	2.7092
10	.1372		2.0748	2.6749	2.8121	2.5206
11	.1372		.1372		.1372	
12	.1372		.12		.1372	
13	.12		.1372	.1372	.12	
14	.1372	.1372	.1372		.12	
15		.1372	.1372		.1372	
16	.1372	.1372	.1372	.1715	.1715	
17	.1372	.1372	.1372	.3086	.2401	
18	.1372	.1715	.1372	.2743	.3258	
19	.1372	.1715	.1372	.3258	.3601	.3429
20	.1372	.1715	.1372	.3429	.3429	.3601
21	.1372	.1715	.1372	.3772	.3086	.3086
22	.1372	.1372	.1372	.3772	.2743	.3429
23	.1372	.1372	.1372	.3429	.2915	.3258
24	.12	.1372	.1372	.1372	.3086	.2915
Max	3.4808	3.3093	3.6008	3.5837	3.9438	3.8752
Min	.12	.1372	.12	.1372	.12	.2915
Avg	1.0512	1.0571	1.0831	1.3555	1.3382	1.8294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274230 / 33/11 KV JAMGAON S/S

Feeder No / Name : 203 / 11 KV JAMGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0686	.1029	.1029	.1372	.1029
2	.1029	.0686	.12	.0857	.1715	.1029
3	.0857	.0857	.1372	.0857	.1715	.0857
4	.1029	.1029	.1372	.1029	.2058	.0857
5	.1372	.1715	.1715	.1372	.2058	.12
6	.1886	.2401	.2058	.1886	.2743	.1886
7	.2743	.2401	.2401	.2401	.2401	.2572
8	.1543	.1029	.1715	.1543	.1715	.1543
9	.1372	.12	.1029	.12	.1372	.1372
10	.1029	.1029	.0857	.0686	.1029	.12
11	.1029	.1029	.0686			.12
12	.0857		.1029		.1029	.1543
13	.0857		.0857	.1029	.1029	.1372
14	.1029	.1029	.0857	.1029	.1029	.12
15		.1029	.0857	.1029	.1029	.1372
16	.0686	.1029	.1029	.1029	.12	.1372
17	.12	.1372	.12	.1372	.1543	.1543
18	.12	.1715	.12	.1886	.1715	.1715
19	.1886	.2401	.2058	.2401	.1886	.2229
20	.2229		.2401	.2058	.2229	.2401
21	.1715	.2401	.2058	.1715	.2058	.2058
22	.1372	.2058	.1715	.1372	.1886	.2058
23	.1029	.1715	.12	.1372	.1543	.1715
24	.12	.1029	.1029	.1029	.1029	.12
Max	.2743	.2401	.2401	.2401	.2743	.2572
Min	.0686	.0686	.0686	.0686	.1029	.0857
Avg	.1312	.1421	.1372	.1372	.1625	.1522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 201 / 11 KV YAWALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.12	.1372	.1543	.1372	.1715	1.1431
2	.1029	.1067	.1829	.1372	.1372	.1829	1.2193
3	.1294	.1219	.1829	.1543	.1372	.2134	1.3717
4	.1715	.1372	.1829	.2058	.1372	.2058	1.829
5	.2401	.1677	.1829	.2401	.1524	.2058	1.9052
6	.2743	.1981	.2134	.2572	.3353		1.9052
7	.2401	.1981	.2401	.2401	.3201	.1715	1.9509
8	.2572	.1829	.2401	.2229	.2286	.1524	1.9814
9	.2058	.1372	.1715	.1715		.2058	
10	.12		.1543	.1715			1.9814
11	1.406	1.2346	1.0517	1.6461	1.7147	2.0576	
12	1.1831	1.4403	.8935		2.1434	2.1434	
13	1.4403		.9069	1.6766	2.0919	2.1776	
14	1.3032	1.1831	.8802	1.5851	2.0576	2.1948	
15	1.3546	1.2003	.6668	1.7375	2.2291	2.2291	
16	1.4232	1.3032	1.0002	1.9814	2.2634	2.0576	
17	1.3546	1.3032	1.0669	1.8442	2.2291	2.2119	.1829
18	1.2003	1.0288	.8802	1.7528	2.0576	2.1948	.2286
19	.1543	.2058	.2229	.1829	.2058	.3258	.2134
20	.1543	.2401	.2058	.2743	.2058	.3429	.2134
21	.1715	.2572	.1886	.2439	.2572	2.2634	.2134
22	.1543	.1715	.1543	.2286	.2572	.2743	.1829
23	.1372	.1715	.1372	.1829	.1715	.2743	.1829
24	.12	.12	.1715	.1543	.1524	.1715	.1829
Max	1.4403	1.4403	1.0669	1.9814	2.2634	2.2634	1.9814
Min	.1029	.1067	.1372	.1372	.1372	.1524	.1829
Avg	.5591	.5104	.4298	.6715	.8919	1.0195	.9934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

MOHOL S/DN.[097]

BU 1350

Substation No/ Name :- 274234 / 33/11 KV HIVARE S/S

Feeder No / Name : 202 / BHAGIRATH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1524	.1372	.1372	.1524	.1715
2	.1543	.1543	.1372	.12	.1543	.1524	.1715
3	.2401	.1715	.1524	.1029	.1715	.1829	.1715
4	.2572	.1886	.1829	.1715	.2058	.1829	.1715
5	.2743	.2572	.1981	.2401	.2229	.2134	.2572
6	.2915	.2915	.1829	.2743	.2915		.2743
7	.2401	.2229	.1981	.2915	.2572		.2743
8	.2572	.2058	.1829	.2401	.1715		.1715
9	.2058		.1524	.2229	.1543		
10	.1715	.1524	.1372	.1715	.1829		.1715
11	.1715	.1524	.1524	.1715	.1829		
12	.12	.1524	.1524		.1829		
13	.1715	.1524	.1372	.1715	.1829		
14	.1543	.1524	.1219	.1543	.1829		
15	.1372	.1524	.1219	.1372	.1981		
16	.1372	.1372	.1677	.1715	.1829		
17	.1543	.1524	.1981	.2058	.1829		.2401
18	.2058	.1829	.1829	.1715	.1372		.2572
19	.1886	.1981	.2572	.2229	.1524		.2572
20	.2058	.1829	.2743	.2572	.1829		.2229
21	.2229	.1829	.2401	.1886	.1829		.2058
22	.1715	.1829	.1886	.1715	.1829		.1715
23	.1715	.1829	.1715	.1543	.1829		.1543
24	.1715	.1715	.1524	.1543	.1372	.1524	.1715
Max	.2915	.2915	.2743	.2915	.2915	.2134	.2743
Min	.12	.1372	.1219	.1029	.1372	.1524	.1543
Avg	.1929	.1797	.1748	.1871	.1835	.1727	.2068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 201 / 11KV Sakal
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7545	.583		.7202
2				.7202	.583		.7202
3				.7202	.6001		.6859
4				.7202	.6001		.6516
5				.703	.6001		.6516
6				.6859	.6173		.583
7				.703	.6173	.7842	.5144
8				.6687	.7888	.8589	.4115
9	.7842	.7947	.7545	.9619			
10	1.0456	1.0185	1.0562	1.0288			
11	1.0456	1.1128	1.094	1.1317			
12	1.1203	.9808	.9997	.811			
13		1.0269	1.0374	1.2071			
14	1.1203	1.094	1.086	1.1812			
15	1.1576		1.1128	1.1317			
16			1.1694	1.2003			
17	.9602		1.1203	1.1203	1.0456		
18	.823		1.0269	1.0082	1.0082		
19	.7373						
20	.7202		.9335	.7468			
21	.7545		.6249	.5975			
24				.8059	.6344	.7842	.7545
Max	1.1576	1.1128	1.1694	1.2071	1.0456	.8589	.7545
Min	.7202	.7947	.6249	.5975	.583	.7842	.4115
Avg	.9335	1.0046	1.0013	.8861	.6980	.8091	.6325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 202 / 11KV VIDYAPEETH EXP. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058	.2229		.2058
2				.2058	.2058		.2058
3				.1715	.1715		.1715
4				.1715	.1715		.1372
5				.1543	.1372		.1372
6				.1372	.1029		.1372
7				.1372	.0686	.0747	.1372
8				.12	.1029	.112	.0686
9	.1867		.1132	.1886			
10	.2241	.2075	.1886	.2263			
11	.2987	.3018	.2829	.2641			
12	.3361	.3206	.3206	.2452			
13		.3772	.3018	.2263			
14	.3174	.3395	.2829	.2075			
15	.3174		.3018	.2263			
16			.3018	.2263			
17	.3258		.2801	.1829			
18	.2572		.2241	.2054			
19	.2058						
20	.1715		.2054	.2241			
21	.2058		.2241	.2241			
24				.2229	.2229	.2054	.2401
Max	.3361	.3772	.3206	.2641	.2229	.2054	.2401
Min	.1715	.2075	.1132	.12	.0686	.0747	.0686
Avg	.2588	.3093	.2523	.1987	.1562	.1307	.1601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 203 / 11 KV Smruti Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.463	.5144		.463
2				.463	.5144		.463
3				.4458	.4801		.4458
4				.4287	.4801		.4458
5				.4287	.4973		.4287
6				.4801	.4973		.4458
7				.4973	.4973	.4854	.4801
8				.4801	.4801	.5041	.4801
9	.5415		.4715	.547			
10	.5601	.5847	.4338	.547			
11	.5788		.4715	.5847			
12	.5601		.547	.6036			
13		.6036		.6036			
14	.5975			.5847			
15	.6161			.6036			
16				.5658			
17	.583		.6161	.4572	.5601		
18	.5487		.6348	.5601	.5228		
19	.5316						
20	.5144		.5788	.4801			
21	.5316		.5788	.5228			
24				.4801	.5316	.5228	.4973
Max	.6161	.6036	.6348	.6036	.5601	.5228	.4973
Min	.5144	.5847	.4338	.4287	.4801	.4854	.4287
Avg	.5603	.5942	.5415	.5156	.5069	.5041	.4611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 204 / 11KV BANG DATA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.583	.6859		.6859
2				.6001	.6859		.6859
3				.7202	.7202		.6687
4				.823	.7202		.6344
5				.823	.7373		.6516
6				.8573	.7202		.6516
7				.8573	.7373	.7842	.6344
8				.7373	.6173	.8589	.5658
9	.9522			1.0374			
10	1.0456	1.0185	1.0185	1.0751			
11	1.0642	1.1128	1.0185	1.094			
12	1.0642	.9242	1.1128	.9997			
13		.9808	1.0098	1.0374			
14	1.0829	1.0185	.9997	1.0185			
15	1.1203		.9997	1.0562			
16			1.0185	.9907			
17	.9945		.9896	.7621	.9709		
18	.9259		1.0082	.9335	.9709		
19	.8745						
20	.823		.9335	.8589			
21	.7545		.6722	.8029			
24				.6516	.703	.7545	.7202
Max	1.1203	1.1128	1.1128	1.094	.9709	.8589	.7202
Min	.7545	.9242	.6722	.583	.6173	.7545	.5658
Avg	.9729	1.0110	.9801	.8723	.7517	.7992	.6554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 205 / 11KV BPL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8573	.8745		.7202
2				.8573	.8745		.7202
3				.8059	.8402		.703
4				.8059	.8402		.6516
5				.823	.8573		.6516
6				.7716	.8573		.6001
7				.7202	.8573	.7095	.5487
8				.6859	.823	.7842	.4115
9	1.1203	.9335	.8299	1.0562			
10	1.2696	1.094	1.1694	1.2071			
11	1.0212	1.2826	1.2449	1.1694			
12	1.0082		1.1317	1.094			
13		1.0562	1.1317	1.3203			
14	1.0829	1.0562	1.3957	1.2071			
15	1.419		1.1694	1.358			
16			1.4712	1.2071			
17	1.0974		1.3957	1.1203	1.0082		
18	.9259		1.0082	1.1203	1.1203		
19	.823						
20	.8573		1.0082	1.0082			
21	.8916		1.0082	1.1203			
24				.8916	.8916	.7926	.7545
Max	1.419	1.2826	1.4712	1.358	1.1203	.7926	.7545
Min	.823	.9335	.8299	.6859	.823	.7095	.4115
Avg	1.0469	1.0845	1.1637	1.0099	.8949	.7621	.6402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 207 / 11KV AG PAKNI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058	.1715		.9945
2				.2058	.1715		1.166
3				.2401	.1886		1.3717
4				.2401	.2058		1.4403
5				.2572	.2058		1.5432
6				.2572	.2229		1.5432
7				.2572	.2229		1.5775
8							1.7661
11	1.6804	1.6164	1.8067	1.8564			
12	2.0165	1.8884	2.2382	2.2377			
13		2.0856	2.2874	2.1704			
14	1.6156	2.0388	2.1195	2.0388			
15	1.9418		2.1382	2.0405			
16			2.0679	1.8982			
17	1.7661		2.1434	2.2032	1.9418		
18	1.7318		2.2965	2.1658	1.8671		
19	.3086						
20	.2401		.2241	.2054			
21	.1886		.1715	.1867			
24				.1886	.1543	.1307	.1029
Max	2.0165	2.0856	2.2965	2.2377	1.9418	.1307	1.7661
Min	.1886	1.6164	.1715	.1867	.1543	.1307	.1029
Avg	1.2766	1.9073	1.7493	1.0475	.5352	.1307	1.2784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 208 / 11kv volant

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8916	.9945		.6859
2				.8573	.9431		.6516
3				.8573	.9259		.6516
4				.823	.8916		.583
5				.8402	.8573		.5487
6				.7545	.8573		.5144
7				.6859	.9259	.5415	.4115
8				.6859	.8573	.5041	.4801
9	.9335		1.2449	.8676			
10	1.1203	1.3203	1.1506	1.0562			
11	1.0456	1.3392	1.2637	1.1506			
12	.9709	1.2449	1.2449	1.1883			
13		1.1128	1.1694	1.0185			
14	1.1203	1.3203	1.1317	1.0751			
15	1.0212		1.2071	1.1317			
16			1.3203	1.1506			
17	1.2003		1.2136		.9522		
18	1.0974		1.2136	1.0829	.9259		
19	1.0974						
20	1.0288		1.0082	1.0082			
21	.9259		1.0269	1.0082			
24				.9259	1.0288	.8962	.7202
Max	1.2003	1.3392	1.3203	1.1883	1.0288	.8962	.7202
Min	.9259	1.1128	1.0082	.6859	.8573	.5041	.4115
Avg	1.0511	1.2675	1.1829	.9530	.9236	.6473	.583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 209 / 11KV AG KONDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5144	.3772		.0686
2				.6516	.4115		.0857
3				.7202	.5144		.0686
4				.7545			.0686
5				.823			.0857
6				.8573	.9259		.0857
7				.9259	1.0117	1.1203	.0686
8				1.0802	1.1488	1.0802	
9	.9709		.9945	1.1694			
10	1.0269	.6979	1.1361	.9779			
19	.1029						
20	.0857			.0934			
21	.0857			.1307			
24				.0686	.0857	.0934	.0686
Max	1.0269	.6979	1.1361	1.1694	1.1488	1.1203	.0857
Min	.0857	.6979	.9945	.0686	.0857	.0934	.0686
Avg	.4544	.6979	1.0653	.6744	.6393	.7646	.0750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274075 / 33/11 KV MIDC C. KATI - 1

Feeder No / Name : 210 / 11kv ASHOK POLYMERS Exp. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7202	.8745		.583
2				.7202	.8573		.5487
3				.7545	.823		.5487
4				.7716	.823		.5144
5				.7716	.8745		.5144
6				.7545	.8745		.5316
7				.7888	.8573	.6535	.5316
8				.8059	.9774	.6516	.463
9	1.1203	1.1317	.9979	.929			
10	1.1203	1.1128	1.2071	1.0136			
11	1.1203	1.1506	1.1883	1.0387			
12	1.0829	1.0164	.8688	.9492			
13		1.1883	.9991	.961			
14	1.0456	1.1317	1.1273	1.086			
15	1.0082		1.1827	1.134			
16			1.1576	1.0679			
17	1.046		1.1203	1.0829	.9522		
18	1.0288		1.1203	.9709	.7468		
19	1.0288						
20	.9945		1.0082	.9522			
21	.9431		1.0642	.9896			
24				.6859	.8916	.7842	.6001
Max	1.1203	1.1883	1.2071	1.134	.9774	.7842	.6001
Min	.9431	1.0164	.8688	.6859	.7468	.6516	.463
Avg	1.0490	1.1219	1.0868	.9023	.8684	.6964	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 203 / 11 KV AKOLEKATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.6009	.4904	.5735	.4877	.4111	.2614
2	.5571	.5376	.4755	.6478	.5335	.5243	.2427
3	.5182	.7712	.4458	.6554	.5312	.5335	.2427
4	.8122	.823	.5792	.6882	.7202	.6722	.3361
5	.9717	.9181	.8124	.7811	.9012	.884	.4854
6	1.1012	1.1984	1.0623	1.1142	1.0722	1.0155	.6161
7	1.2003	1.2967	1.3599	1.1633	1.2003	1.2018	
8	1.1431	1.4083	1.2346	1.2289	1.2186	1.0974	
9	1.1288	1.1138	1.1888	1.3077	.9907	1.0402	
10	1.1934	1.3077	.8177	1.1961	1.0883	1.1145	.3395
11	.1494	.2427	.3018	.2772	.2801	.2427	1.0159
12	.1848	.2241	.2263		.2241	.2427	1.1126
13	.2218	.2241	.2054	.2587	.2427	.2241	1.1984
14	.1848	.2241	.2054	.2587	.2614	.2241	.8688
15	.2033	.2054	.1867	.2587	.2054	.2427	.8916
16	.1867	.3174		.2772	.2427	.2801	.9002
17	.2427	.4108		.3142	.2801	.3174	1.0402
18	.3018	.5601	.4294	.3921	.4854	.4066	1.2071
19	.4715	.6722	.5228	.5601	.5601	.5041	.4904
20	.5601	.6348	.6535	.5975	.5228	.6535	.6602
21	.5228	.5041		.5041	.5975	.5601	.6036
22	.4294	.4481	.4904	.4668	.4854	.4668	.3961
23	.3734	.3921	.4527	.4294	.3921	.3361	.3772
24	.3772	.3361	.3361	.4481	.3921	.3361	.2801
Max	1.2003	1.4083	1.3599	1.3077	1.2186	1.2018	1.2071
Min	.1494	.2054	.1867	.2587	.2054	.2241	.2427
Avg	.5655	.6405	.5941	.6260	.5798	.5638	.6460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 205 / 11kv Banegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2058	.1572	.2743	.2012	.1698	.9907
2	.2	.2012	.1635	.2389	.1886	.1646	.9526
3	.2334	.2263	.1572	.2389	.176	.144	.9145
4	.2462	.2721	.2	.2389	.2138	.176	1.1431
5	.3045	.3018	.2534	.3041	.2641	.2263	1.4861
6	.3467	.3704	.2934	.3704	.3332	.2955	1.7528
7	.4201	.4184	.3467	.4047	.4087	.3206	2.21
8	.3909	.3521	.2934	.3292	.3772	.2703	2.0957
9	.2195	.2244		.2896	.2332		1.9243
10	.1823	.2138			.1886	.1635	1.8861
11	1.3717	1.5242		1.1812	1.2955	1.5432	.2263
12	1.3336	1.9052	1.2193	1.7147	1.9052	1.8671	.176
13	1.4289	1.8671	1.7337	1.7528	1.8671	2.0195	.1738
14	1.5623	1.8099	1.7909	1.7147	1.7909	2.0005	.1783
15	1.8671	1.7337		1.7528	1.6385	1.9814	.1886
16	1.9052	1.6766	1.8671	1.7147	1.3336	2.0576	.2012
17	1.9624	1.6385	1.829	1.6575	1.4098	2.1338	.2138
18	2.0195	1.6004	1.9052	1.5623	1.4861	1.9052	.2462
19	.2439	.2955	.2332	.2229	.3081	.2804	.2751
20	.3081	.3206	.3475	.2515	.3521	.317	
21	.2683	.2439		.2286	.2766	.2926	.2896
22	.2515	.2138		.2244	.2515	.2452	.2538
23	.2389	.1886	.2881	.2126	.2515	.1886	.2462
24	.2263	.2138	.1635	.2881	.2138	.1949	.1635
Max	2.0195	1.9052	1.9052	1.7528	1.9052	2.1338	2.21
Min	.1823	.1886	.1572	.2126	.176	.144	.1635
Avg	.7394	.7508	.7357	.7464	.7069	.8242	.7908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 206 / 11kv BB Darphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.1627	.4595	.3658	.4016	.3254	.0572
2	.4607	.2561	.4468	.3887	.4184	.3887	.0572
3	.4881	.3467	.4087	.3719	.3772	.3839	.0572
4	.5573	.3487	.4706	.4252	.4755	.5114	.0572
5	.582	.6043	.6192	.5144	.5487	.6316	.0953
6	.6706	.743	.8173	.815	.644	.7316	.1334
7	.8173	.8545	.9574	.9568	.8669	.8048	.1715
8	.8169	.7787	.9412	.9095	.8916	.9164	.1334
9	.8282	.7682	.8916	.9288	.8916	.8792	.1143
10	.7554	.7324	.756	.8688	.8716	.7316	
11	.0381		.0381	.0381	.0381	.0572	
12	.0381		.0381		.0381	.0572	.9362
13	.0381			.0381	.0381		.8459
14	.0381		.0381	.0381		.0381	
15	.0381	.0381		.0381	.0381	.0381	
16	.0381	.0381	.0381	.1905	.0381		
17	.0381	.0762	.0381		.0381	.0381	.9181
18	.0572		.0381		.0381	.0572	.7888
19	.0953	.1143	.0762	.0572	.0572		.0572
20	.1524	.0953	.1143	.0762	.0953	.1143	
21	.0953	.0762	.1143	.0572	.0762	.1143	.0953
22	.0572	.0572	.0953	.0381	.0572	.0953	.0572
23	.0572	.0572	.0572	.0381	.0381	.0572	.0381
24	.0572	.0381	.0572	.0381	.0381	.0381	.0572
Max	.8282	.8545	.9574	.9568	.8916	.9164	.9362
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.3036	.3256	.3414	.3425	.3050	.3338	.2595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274083 / 33/11 KV AKOLEKATI

Feeder No / Name : 207 / 11 KV Narotewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1532	.1429	.1532	.1404	.1532	.381
2	.1276	.1219	.1334	.1532	.1219	.1341	.3429
3	.1276	.1404	.1276	.1532	.1463	.1219	.3239
4	.1585	.156	.1532	.1915	.1707	.1659	.381
5	.2317	.18	.217	.2553	.2195	.1787	.4382
6	.2808	.2425	.2553	.2808	.2683	.217	.4954
7	.3191	.2926	.3064	.2808	.2926	.2683	.5716
8	.1915		.2936	.2553	.2195	.2553	.6097
9	.1585		.2681	.1787	.1532	.1659	.6097
10	.1276	.2681	.1787	.1532	.1404	.1149	.5906
11	.4572	.4191		.5335	.5144	.5144	.1787
12	.4001	.5335	.6097	.5906	.6478	.6478	.1276
13	.4954	.5335	.5716	.5716	.6287	.7049	.1021
14	.4382	.5144	.5906		.6859	.6478	.1021
15	.5335	.5144	.6859		.6097	.5716	.1276
16	.4954	.4954	.5335		.5716	.6287	.1276
17	.5716	.4954	.6097			.6859	.1404
18	.5335	.4572	.6478	.4191	.4572	.5144	.1404
19	.204	.2629	.1143	.2298	.1659	.2058	.1787
20	.2553	.2515	.2808	.2553	.2298	.2936	.2553
21	.2572	.2572	.2681	.23	.2808	.2553	.2681
22	.1915	.2286	.2298	.2029	.2681	.217	.2298
23	.1659	.1858	.1787	.1734	.2195	.1915	.1787
24	.144	.1787	.1572	.1787	.1532	.1787	.1787
Max	.5716	.5335	.6859	.5906	.6859	.7049	.6097
Min	.1276	.1219	.1143	.1532	.1219	.1149	.1021
Avg	.2916	.3128	.3284	.2720	.3176	.3347	.2950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 201 / 11 KV PADASALI Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7878	2.0645	2.332	1.5089	1.595	1.6766	.2286
2	1.9547	2.1628	2.0348	1.5089	1.6804	1.6575	.2286
3	1.9071	1.9784	2.0317	1.5089	1.7878	1.6385	.3048
4	1.7833	2.0119	2.2325	1.6095	1.7684	1.8023	.3048
5	1.9281	1.9662	2.2291	1.8442	1.8861	1.9662	.3429
6	2.332	2.6235	2.6749	2.2611	2.0348	2.2283	
7	2.9165	2.9127	2.7496	2.753	2.7778	2.5034	
8	3.0521	2.8807	2.8182	2.9473	2.8509	2.652	
9	2.8166	2.7206	1.6118	2.5232	2.8826	2.915	
10	1.9334	3.0178	1.9784	2.5194		3.155	
11							2.572
12							2.713
13							2.7808
14							2.8502
15							2.9127
16							2.7435
17							2.5434
19	.381	.381	.381	.3429	.2286	.3429	.381
20	.381	.381	.4191	.381	.2286	.3429	.3429
21	.381	.381	.381	.381	.2286	.3429	.3048
22	.3429	.3429	.3048	.3048	.2286	.3048	.2667
23	.3429	.3429	.1905	.2667	.2286	.2667	.2667
24	.2667	.3048	.3429	.1905	.2667	.2286	.2286
Max	3.0521	3.0178	2.8182	2.9473	2.8826	3.155	2.9127
Min	.2667	.3048	.1905	.1905	.2286	.2286	.2286
Avg	1.5317	1.6545	1.5445	1.4282	1.3782	1.5015	1.2398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 204 / 11KV Gaothan Wadala
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.8916	.852	.8573	.8573	1.0059	.9259
2	1.0517	.9945	.9945	.9259	.9709	.9945	.9054
3	1.2136	1.2071	1.166	1.1736	1.0174	1.065	1.0059
4	1.4403	1.3748	1.3108	1.3435	1.3226	1.3108	1.3375
5	1.6095	1.4746	1.5775	1.4746	1.5746	1.5089	1.5089
10	1.1065	1.1317	1.0395	1.0974	1.1317	1.0288	1.1096
11	.823	.9282	.8573	.8764	1.0402	.9389	.8573
12	.7888	.7545	.7545	.823	.8478	.8573	.8139
13	.7545	.6226	.4961	.7975	.7545	.7712	.7282
14	.7362	.6859	.4908	.7712	.7459	.7042	.7628
15	.6859	.7122	.6859	.7545	.7373	.7202	.6859
16	.6661	.7202	.7545	.7802	.7373	.7293	.7362
17	.6859	.7293	.7545	.8059	.7373	.7202	.7282
18	.8573	.9175	.823	1.0056		.823	
19	1.2742	1.5238	1.2689	1.3203	.8907	1.2071	1.5089
20	1.4419	1.5238	1.4754	1.4083	1.1469	1.3077	1.4582
21	1.2407	1.4022	1.2346	1.166	1.5927	1.2407	1.2003
22	1.0288	1.0402	.9945	1.0974	1.1022	1.0288	1.046
23	.9602	.9922	.9465	1.0402	1.0174	.9945	.9882
24	.8842	.823	.8573	.8916	.9465	.9259	.9114
Max	1.6095	1.5238	1.5775	1.4746	1.5927	1.5089	1.5089
Min	.6661	.6226	.4908	.7545	.7373	.7042	.6859
Avg	1.0088	1.0225	.9667	1.0205	1.0090	.9941	1.0115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 205 / 11KV Gawadi Darfal Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.0517	1.1317	1.2003	1.2971	1.4746	.0762
2	1.7684	1.0517	1.0277	1.2346	1.3375	1.4746	.0762
3	1.7147	1.1218	1.0974	1.2346	1.387	1.4746	.0762
4	1.8229	1.1568	1.094	1.3375	1.4403	1.5089	.0762
5	1.8652	1.2003	1.166	1.4403	1.4419	1.4918	.0762
6	2.0576	1.5432	1.6461	1.7901	1.5261	1.6095	
7	2.3663	2.2611	2.5869	2.4291	2.572		
8	2.6155	2.556	2.5888	2.6406	2.7435	1.6385	
9	2.4143	2.2611		2.4577	2.6749	2.5034	
10	2.2611	2.4006	1.7101	2.5943	2.3926	2.4863	
11						2.3663	1.9418
12							2.2043
13							2.4691
14							2.572
15							2.4619
16							2.34
17							2.0576
19	.0762	.0762	.0762	.0762	.0762	.0762	.0762
20		.0762	.0762	.0762	.0762	.0762	.0762
21	.0762	.0762	.0762	.0762	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762	.0762
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	2.6155	2.556	2.5888	2.6406	2.7435	2.5034	2.572
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.3965	1.0663	.9671	1.1760	1.2044	1.1554	.9381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 206 / 11KV Nannaj Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.2286	.7202
2	.1905	.1905	.1905	.1905	.1905	.2286	.7202
3	.1905	.1905	.1905	.1905	.1905	.2286	.7202
4	.1905	.2286	.1905	.2286	.2286	.2286	.823
5	.2286	.2286	.1905	.2667	.2667	.2667	.8573
6							1.1736
7							1.8023
8							1.9662
9							1.9662
10							1.8861
11	2.2874	2.1548	1.8107	1.749	2.0348	1.5729	
12	2.6871	2.4756	2.1956	2.2539	2.13	1.8861	
13	2.6543	2.5149	2.3922		2.13	2.0317	
14	2.4249	2.5857	2.3205		2.2211	2.2291	
15	2.2939	2.5034	2.2611	1.989	2.0119	2.2283	
16	2.4905	2.3594	2.2024	2.4272	1.6385	2.2977	
17	2.3102	2.4691	2.2024	2.4177	1.4918	2.4348	
18	2.1125	2.2939	2.0405	2.2539	1.5089	2.1948	
19	.2667	.2286	.2667	.2286	.2286	.2286	.2286
20	.2667	.2286	.2667	.2667	.1905	.2286	.2286
21	.2667	.2286	.2667	.2667	.1905	.2286	.1905
22	.2286	.2286	.2286	.2286	.1905	.2286	.1905
23		.2286	.1905	.2286	.1905	.1905	.1905
24	.1905	.1905	.1905	.1905	.1905	.2286	.1905
Max	2.6871	2.5857	2.3922	2.4272	2.2211	2.4348	1.9662
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	1.1928	1.1431	1.0415	.9157	.9166	1.0205	.8659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274089 / 33/11 KV WADALA

Feeder No / Name : 207 / 11KV LokmangalR&D Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191		.0191	.0191		
2	.0191	.0191			.0191		
3	.0191	.0191			.0191		.0191
4	.0191	.0191		.0191	.0191		.0191
5	.0191	.0191			.0191		.0191
6	.0191	.0191		.0191			.0191
7	.0191			.0191			.0191
8	.0191						
9	.0191	.0191			.0191		.0191
10	.0572	.0381	.0572	.0191	.0572	.0381	.0762
11	.0572	.0381		.0381	.0572	.0381	.0762
12	.0762	.0572	.0572	.0381	.0572	.0381	.0572
13	.0762	.0572		.0381	.0572	.0381	.0762
14	.0572	.0572		.0381	.0572	.0381	.0762
15	.0381	.0381		.0381	.0572	.0381	.0572
16	.0381	.0381		.0381	.0572	.0381	.0381
17	.0381	.0381		.0191	.0572	.0381	.0381
18	.0191	.0191		.0191		.0191	
19	.0191		.0191	.0191	.0381		.0191
20	.0191		.0191	.0191	.0381		.0191
21	.0191		.0191	.0191	.0381		.0191
22	.0191		.0191	.0191	.0191		.1524
23	.0191			.0191	.0191		
24	.0191	.0191		.0191	.0191	.0191	
Max	.0762	.0572	.0572	.0381	.0572	.0381	.1524
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0310	.0314	.0318	.0251	.0372	.0343	.0455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 201 / 11 KV DONGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				2.0576		1.989	
8			2.1262	1.989		2.0576	
9	2.2634	2.2634	2.1262	2.1262	2.332		
10	2.1948	2.0576	1.989		2.1262		
12							2.1948
19	.1509	.1509	.2263		.1509		
20	.2263	.2263					
21		.3018					
24		.1509	.1524	.0754	.1509	.1509	.1509
Max	2.2634	2.2634	2.1262	2.1262	2.332	2.0576	2.1948
Min	.1509	.1509	.1524	.0754	.1509	.1509	.1509
Avg	1.2089	.8585	1.3240	1.5621	1.19	1.3992	1.1729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 202 / 11 KV KAWATHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0754				1.6461
9							1.6461
10							1.5775
11	2.0919		1.8519		1.8519		
12	2.0576	2.1262	2.1262		2.0576		
14		2.2634			2.1262		
16	2.1125	2.1948	1.8519				
17	2.2634	2.1879	1.9616				
18	2.1879	2.1879	1.8861				
19	.0754	.1509	.1509		.0754		
20	.0754	.1509					
21		.1509					
24		.0754	.0754	.0754	.0754	.0754	.0754
Max	2.2634	2.2634	2.1262	.0754	2.1262	.0754	1.6461
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	1.5520	1.2765	1.2474	.0754	1.2373	.0754	1.2363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 203 / 11 KV DONGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.7545		.7545	
8			.679	.6036		.6036	.6036
9	.5281	.4527	.4527	.4527	.4527		.4527
10	.3772	.2263	.3018		.3772		.3018
11	.3772		.2263		.3018		
12	.3018	.2263	.3018		.3018		.3018
14		.2263			.3018		
16	.3018	.2263	.3018				
17	.3018	.3772	.3772				
18	.4527	.3772	.4527				
19	.679	.679	.7545		.8299		
20	.7545	.679					
21		.5281					
24		.3018	.3772	.3772	.3018	.4527	.4527
Max	.7545	.679	.7545	.7545	.8299	.7545	.6036
Min	.3018	.2263	.2263	.3772	.3018	.4527	.3018
Avg	.4527	.3909	.4225	.547	.4096	.6036	.4225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 204 / 11 KV NANDUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.0754		2.6749	
8			2.8121	2.0576		2.8807	
9	2.6063	2.915	2.8978		2.7949		
10	2.6406	2.7778	2.8807		2.692		
12							2.7435
19	.2641	.2641	.3395		.2263		
20	.3395	.3018					
21		.3018					
24		.2452	.2263	.2263	.2263	.2263	.2263
Max	2.6406	2.915	2.8978	2.0576	2.7949	2.8807	2.7435
Min	.2641	.2452	.2263	.0754	.2263	.2263	.2263
Avg	1.4626	1.1343	1.8313	.7864	1.4849	1.9273	1.4849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 205 / 11 KV SOREGAON GFSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.7421		.7783	
8			.6697	.7421		.724	.7059
9	.6602	.5847	.6602	.7167	.7167		.6602
10	.6602	.6224	.6602		.7356		.6602
11	.6602		.6602		.8865		
12	.6602	.6602	.7356		.7545		.6224
14		.6602			.7545		
16	.6602	.6224	.7545				
17	.6413	.6036	.7167				
18	.6413	.6036	.679				
19	.7545	.679	.7922		.8869		
20	.7545	.7545					
21		.7545					
24		.6413	.5973		.679	.6516	.6154
Max	.7545	.7545	.7922	.7421	.8869	.7783	.7059
Min	.6413	.5847	.5973	.7167	.679	.6516	.6154
Avg	.6770	.6533	.6926	.7336	.7734	.7180	.6528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 206 / 11 KV PATHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.2263		.1886	
8			.1698	.1509		.1698	1.4746
9		.1886	.0189	.1509	.1509		1.6975
10		.1886	.1509		.1698		1.5432
11	.4458		2.2462		2.3491		
12	.547	2.5549	2.6406		2.5377		.132
14		2.6235			2.3663		
16	2.5652	2.2977	2.572				
17	2.6217	2.7726	.8299				
18	2.5274	2.6595	2.6406				
19	.2075	.1886	.1886		.1886		
20	.2075	.1886					
21		.1886					
24		.1886	.1698	.1886	.1886		.1886
Max	2.6217	2.7726	2.6406	.2263	2.5377	.1886	1.6975
Min	.2075	.1886	.0189	.1509	.1509	.1698	.132
Avg	1.3032	1.2763	1.1627	.1792	1.1359	.1792	1.0072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274135 / 33/11 KV DONGAON

Feeder No / Name : 207 / 11KV Commissioner SMC,
P.Nagar Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
17	.0189	.0377	.132
18	.0189	.0189	.1509
19	.0189		.0377
20	.1509	.0189	
21		.1509	
Max	.1509	.1509	.1509
Min	.0189	.0189	.0377
Avg	.0519	.0566	.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 201 / 11KV Rama

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3772	.3018	.3429	.2641	.3429	.3395
2	.2263	.3429	.2641	.3086	.2641	.3086	.3395
3	.1886	.3429	.2641	.3086	.2587	.3086	.3395
4	.1886	.3086	.2641	.2743	.2641	.2743	.3018
5	.1886	.3086	.2641	.2743	.2263	.2058	.2641
6	.1886	.2743	.2641	.2401	.2263	.2058	.2641
7	.1886	.2401	.2641	.1715	.2263	.1715	.2641
8	.1886	.3086		.2743	.2641	.2401	.1886
9	.3772	.3772	.5281	.3429	.4527	.4801	.2263
10	.4527	.5658	.6413	.3206	.583	.5281	.2263
11	.4904	.6413	.679	.3206	.6859	.6413	.2641
12	.5658	.5658	.679	.3395	.6173	.6413	.2641
13	.5144	.3772	.4527	.3772	.3429	.415	.2263
14	.4801	.679	.6036	.5281	.583	.7545	
15	.4801	.7545	.7545	.6413	.5487	.5658	.1886
16	.5144	.7545	.7922	.6413	.583	.3772	.1509
17	.583	.7167	.5487	.7545	.583	.5658	
18	.6173	.6413	.5144	.6413	.4973	.6036	.1372
19	.4801	.5658	.4801	.5658	.4458	.6036	.1372
20	.3429	.4904	.3429	.4904	.3086	.415	.1715
21	.3086	.4904	.2743	.3772	.2401	.3395	.2058
22	.3429	.415	.3086	.3772	.3086	.415	.2401
23		.3395	.3429	.3395	.3429	.415	.2915
24	.2263	.3772	.3018	.3429	.3018	.3429	.3772
Max	.6173	.7545	.7922	.7545	.6859	.7545	.3772
Min	.1886	.2401	.2641	.1715	.2263	.1715	.1372
Avg	.3635	.4690	.4405	.3998	.3924	.4234	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 202 / 11KV Bhutada

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	1.2003	1.4045	1.3375	1.3491	1.166	1.3306
2	.9431	1.166	1.386	1.3375	1.2382	1.1317	1.2936
3	.9431	1.166	1.3306	1.2689	1.2012	1.1317	1.3491
4	1.0185	1.1317	1.423	1.2689	1.1643	1.0288	1.3121
5	1.094	1.1317	1.3491	1.2689	1.226	1.0288	1.2382
6	1.1317	1.1317	1.2936	1.2346	1.0751	.9431	1.1643
7	1.1883	1.0974	1.2936	1.166	.9431	.7888	1.0534
8	1.5655	1.5604	1.825	1.2003	1.5939	1.0288	.961
9	1.5844	1.6461		1.4575	1.5912	.9431	1.0349
10	1.7918	1.8673	2.0748	1.8296	1.9547	1.8861	1.2071
11	2.0559	1.8673	2.1313	1.9239	2.0405	1.9993	1.2071
12	2.037	1.7918	2.0748	1.8861	1.9204	2.037	1.2071
13	1.8519	1.7918	1.9239	1.773	1.6975	1.7353	1.1506
14	1.8004	1.9805	1.8861	1.8861	1.749	1.905	1.0751
15	1.7661	2.0182	1.8861	2.0182	1.9547	1.9427	1.094
16	1.7147	2.0182	1.8861	1.905	1.8519	1.9427	1.0374
17	1.6804	1.8107	1.6461	1.6478	1.749	1.825	.9431
18	1.5775	1.825	1.5432	1.7741	1.6289	1.7918	.5144
19	1.3717	1.6461	1.3889	1.5339	1.4575	1.1088	.6173
20	1.3032	1.4815	1.3375	1.1706	1.3375	1.4083	.703
21	1.166	1.4266	1.2003	1.1458	1.1488	1.2936	.703
22	1.1317	1.3306	1.3032	1.2197	1.166	1.2567	.703
23		1.448	1.3546	1.3169	1.1317	1.3491	.703
24	.8676	1.2003	1.4969	1.3375	1.4045	1.166	1.4045
Max	2.0559	2.0182	2.1313	2.0182	2.0405	2.037	1.4045
Min	.8676	1.0974	1.2003	1.1458	.9431	.7888	.5144
Avg	1.4110	1.5306	1.5843	1.4962	1.4823	1.4099	1.0420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 205 / 11KV LDK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	1.0288	.9055	1.2003	1.0562	1.2003	.9997
2	.6224	.9431	.8686	1.2003	1.0456	1.1145	.9425
3	.6224	.9431	.7947	1.1145	1.0534	1.1145	.924
4	.6224	.9431	.8488	1.0288	.9795	1.0288	.9997
5	.6413	.8573	.8488	.8573	.9425	.9602	.924
6	.6413	.7716	.7922	.823	.924	.8573	.924
7	.6413	.6859	.7922	.7888	.9335	.7202	.8686
8	.6602	.7202		.8059	1.3306	.7716	.679
9	.9619	.7545	.8299	.9945		.9945	.6602
10	1.1317	1.3203	1.094	1.3203	1.3717	1.2071	.6602
11	1.4146	1.7918	1.2826	1.5844	1.3717	1.4335	.7356
12	1.4146	1.6975	1.3203	1.4712	1.4403	1.1317	.6036
13	1.3717	1.6598	1.4146	1.4712	1.3717	1.226	.6036
14	1.3375	1.6975	1.4712	1.4712	1.3717	1.4712	.679
15	1.3717	1.7918	1.5089	1.4712	1.3032	1.4146	.6413
16	1.4403	1.7918	1.5089	1.5089	1.3032	1.3014	
17	1.5089	1.701	1.3032	1.386	1.3032	1.3306	.463
18	1.5432	1.5581	1.3032	1.3491	1.286	1.4415	.4973
19	1.3032	1.5154	1.3032	1.2382	1.2346	1.6263	.6001
20	1.1145	1.3306	1.2003	1.2012	1.166	1.3306	.6859
21	.9431	1.2382	1.2003	1.2012	1.1145	1.4045	.5487
22	.9602	1.2012	1.2689	1.2936	1.1831	1.2936	.5487
23		1.1458	1.3032	1.0349	1.166	1.1643	.583
24	.6224	1.0288	.8686	1.3032	1.0719	1.2003	1.0164
Max	1.5432	1.7918	1.5089	1.5844	1.4403	1.6263	1.0164
Min	.6224	.6859	.7922	.7888	.924	.7202	.463
Avg	1.0223	1.2549	1.1318	1.2133	1.1880	1.1975	.7299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 206 / 11KV V.Datta

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6173	.6036	.6859	.6036	.6173	.5847
2	.6036	.583	.6036	.6516	.5658	.583	.547
3	.6036	.583	.5658	.6516	.6036	.5144	.5658
4	.6036	.5487	.5658	.583	.547	.5144	.5658
5	.6036	.5487	.547	.583	.5658	.4458	.5281
6	.6036	.5144	.5093	.5144	.5093	.4287	.5658
7	.6036	.4287	.4904	.463	.4338	.3944	.5093
8	.5847	.463		.4973	.5281	.4287	.5093
9	.6602	.5144	.7733	.583	.5093	.6516	.4904
10	.679	.7167	.8488	.679	.6859	.6979	.4527
11	.679	.7733	.8865	.7167	.6516	.7545	.4527
12	.7545	.7545	.8488	.6602	.7373	.6224	.4527
13	.6173	.7167	.6413	.6602	.6344	.7356	.4338
14	.6516	.7167	.7167	.7545	.6001	.6602	.4527
15	.6516	.7167	.7922	.811	.7888	.7545	
16	.6173	.7545	.811	.7545	.7373	.8299	.4904
17	.6173	.7733	.6859	.6838	.7373	.7577	.4458
18	.6001	.8488	.6173	.679	.6859	.6838	.4458
19	.5487	.811	.583	.6602	.4973	.5914	.4801
20	.5658	.5127	.5144	.6224	.6001	.7023	.4973
21	.6001	.679	.4801	.5281	.6687	1.2936	.4801
22	.6001	.6979	.6516	.547	.6344	.7167	.4801
23		.7356	.6859	.6979	.6173	.679	.463
24	.6036	.6173	.6979	.6859	.6838	.6173	.5658
Max	.7545	.8488	.8865	.811	.7888	1.2936	.5847
Min	.5487	.4287	.4801	.463	.4338	.3944	.4338
Avg	.6198	.6511	.6574	.6397	.6178	.6531	.4982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 207 / 11KV Venky Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.9945	.9997	.9945	.9795	.9602	.9896
2	.9808	.9945	1.0349	.9945	.924	.9088	.9431
3	.9808	.9431	.9808	.9602	1.0164	.9088	.9709
4	.9808	.9431	.961	.9602	1.0534	.8916	.9808
5	.9808	.9431	1.0349	.9259	.961	.8916	.924
6		.8916	.9425	.9259	.924	.8573	.9795
7	.9997	.8573	.985	.8573	.9979	.823	.9335
8	1.0562	.9945		1.0288	.924	.8745	.9795
9	1.0562	.9602	1.0534	.9945	1.1088	1.1145	1.1458
10	1.1317	1.226	1.226	1.2071	1.0288	1.1506	1.2449
11	1.1694	1.2826	1.3203		.9945	1.3203	1.094
12	1.0751	1.1694	1.3203	1.226	.9259	1.226	1.1317
13	.9945	1.1694	1.1506	1.1317	.9431	1.226	1.2071
14	.9945	1.226	1.1694	1.2071	.9259	1.1128	1.1694
15	.9945	1.2637	1.1694	1.2637	.9602	1.1883	1.1317
16	.9945	1.2637	1.1694	.8488	1.0288	1.2752	1.1506
17	1.0117	1.3491	1.0974	1.0349	1.1488	1.1827	1.0802
18	1.0117	1.2752	1.0974	1.1458	1.0288	1.0534	1.1145
19	.9431	1.1643	1.1317	1.0745	1.0751	.9979	1.0802
20	.8916	1.1088	1.0631	1.1088	.9774	1.0164	1.0631
21	.9602	1.0534	.9945	.9979	.9088	.9795	.9431
22	.9602	1.0349	.9602	.9979	.9088	.9795	.9431
23		1.0374	.9945	.9979	.9602	.9795	1.4575
24	.9808	.9945	.9979	.9945	1.0349	.9602	.9431
Max	1.1694	1.3491	1.3203	1.2637	1.1488	1.3203	1.4575
Min	.8916	.8573	.9425	.8488	.9088	.823	.924
Avg	1.0059	1.0892	1.0806	1.0382	.9891	1.0366	1.0667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274168 / 33/11 KV MIDC C. KATI - 2

Feeder No / Name : 401 / 33KV KOTHARI PRIMA NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115		.4115		.5144
2		.3601		.4115		.6173
3		.3601		.4115		.5658
4		.3601		.3601		.4115
5		.3086		.3601		.4115
6		.3086		.3601		.3086
7		.3086		.3086		.3086
8		.3601		.3086		.3086
9		.3086		.463		.2572
10		.3395	.2829		.4115	.3601
11		.3395	.5658		.4115	
12		.3961	.6224		.4115	
13	.2572	.3961	.679		.4115	
14	.2572	.3395	.5658		.4115	
15	.2572	.3395	.4527		.4115	
16	.3086	.3961	.3395		.4115	
17	.3086		.3601		.3601	
18	.3086		.4115		.3601	
19	.3086		.463		.4115	
20	.3086		.4115		.4115	
21	.3086		.4115		.4115	
22	.3086		.3601		.4115	
23			.3601		.3601	
24		.4115		.3601		.3601
Max	.3086	.4115	.679	.463	.4115	.6173
Min	.2572	.3086	.2829	.3086	.3601	.2572
Avg	.2932	.3555	.4490	.3755	.4005	.4022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 201 / 11KV Vasant Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.3761	.3801	.394	.394	.4119	.4119
2	.3801	.3582	.362	.3582	.3761	.394	.4119
3	.362	.3582	.3439	.3582	.3582	.3761	.394
4	.362	.3403	.3258	.3582	.3582	.3582	.394
5	.362	.3403	.3258	.3224	.3403	.3582	.3761
6	.3982	.3582	.3077	.3224	.394	.3582	.394
7	.3801	.3582	.3258	.3761	.394	.4119	.3761
8	.362	.3224	.3077	.3761	.3403	.3582	.3403
9	.3077	.2865	.3077	.3982	.2865	.3045	.3761
10	.3045	.2865		.3801	.3224	.3045	.3224
11	.3224	.2686	.3077	.3403	.3403	.2686	.3224
12	.3403	.2686	.2896	.3582	.3403	.2865	.3224
13	.3582	.2686	.3077	.3224	.3403	.2686	.2865
14	.3224	.2865	.3258	.3224	.3224	.3403	.3224
15	.3224	.2865	.3077	.3224	.3224	.3582	.3403
16	.3045	.2865	.3258	.3224	.3224	.3582	.609
17	.2865	.2865	.3403	.3224	.3224		.3224
18	.3045	.2865	.3403	.3403	.3224		.3258
19	.4119	.4298	.4119	.8688	.905	.4525	.905
20	.4298	.4119	.4298	.4163	.4344		.4525
21	.4119	.4119	.394	.4298	.4344	.4477	.4706
22	.4477	.4163	.4119	.4477	.4656	.4656	.4706
23	.4298	.4163	.4477	.4477	.4656	.4656	.4706
24	.4163	.4119	.3982	.4119	.4298	.4298	.4477
Max	.4477	.4298	.4477	.8688	.905	.4656	.905
Min	.2865	.2686	.2896	.3224	.2865	.2686	.2865
Avg	.3636	.3384	.3489	.3882	.3888	.3703	.4110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274183 / 33/11 KV VASANT VIHAR

Feeder No / Name : 202 / 11KV BHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5565	1.4506	1.5203	1.5402	1.5402	1.576	1.576
2	1.5203	1.4685	1.4842	1.5223	1.4506	1.4864	1.576
3	1.4299	1.4685	1.448	1.5223	1.4685	1.4506	1.5402
4	1.5384	1.4864	1.5746	1.576	1.5223	1.5223	1.5939
5	1.7556	1.6476	1.6289	1.773	1.7013	1.6834	1.7193
6	1.9909	1.8983	1.8099	2.0416	1.97	1.9521	2.0237
7	2.009	1.9521	1.9547	2.0416	2.0237	2.0595	2.0416
8	1.7013	1.7193		1.8983	1.6476	1.7372	1.7551
9	1.4842	1.4864	1.5927	1.2715	1.6476	1.576	1.6655
10	1.4685	1.4864	1.4661	1.6655	1.6655	1.4685	1.6118
11	1.6476	1.5043	1.5384	1.7551	1.7013	1.6118	1.6118
12	1.7551	1.5581	1.5565	1.7372	1.8088	1.6476	1.6655
13	1.7372	1.6118	1.5927	1.6118	1.5939	1.6118	1.7013
14	1.6655	1.5402	1.6832	1.6118	1.6118	1.5939	1.6655
15	1.6655	1.1641	1.5203	1.6118	1.6118	1.6834	1.7013
16		1.4864	1.7375	1.6655	1.7193	1.6297	1.6834
17	1.7013	1.4864	1.6476	1.6655	1.773	1.7551	1.6655
18	1.6297	1.6476	1.6476	1.7551	1.8267	1.8461	1.7918
19	2.0595	1.9879	2.167	2.1176	2.2262	2.2262	2.1538
20	1.9342	2.0058	2.0416	2.0271	2.1176	2.19	2.0995
21	1.8446	1.8983	1.9163	1.9342	1.9547	2.0774	1.9728
22	1.7551	1.8642		1.8088	1.8446	1.9521	1.8099
23	1.6655	1.7013	1.8446	1.6476	1.7372	1.7909	1.7556
24	1.5927	1.5223	1.5565	1.6297	1.6118	1.6118	1.7013
Max	2.0595	2.0058	2.167	2.1176	2.2262	2.2262	2.1538
Min	1.4299	1.1641	1.448	1.2715	1.4506	1.4506	1.5402
Avg	1.7004	1.6268	1.6786	1.7263	1.7407	1.7392	1.7534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 201 / 11KV BHAGAIWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1898	.2286	.1867	.1905	.168	.1867	.2241
2	.2214	.2096	.1494	.1715	.2241	.1494	.2987
3	.2372	.2858	.1307	.2667	.3361	.1307	
4	.3321	.3239	.1307	.3429	.3361	.1307	.3361
5	.3795	.4001	.5041	.4382	.4854	.5041	.4854
6	.3479	.4763	.4481	.4954	.4481	.4481	.4481
7	.2846	.4191	.3921	.4191	.3734	.3921	.3921
8	.2214	.3174	.3174		.2614	.3361	.2614
9	.1581	.2614	.2054		.1867	.2801	.2241
10	.1905	.1867	.1524		.1867		.1867
11	.1143	.1307	.1524		.1494		.1494
12	.1334	.1307	.1524		.124		.1494
13	.1524	.112	.1334		.1063		.168
14	.1524	.112	.1334		.112		.168
15	.1334	.112	.1524		.112		.112
16	.1715	.1307	.1905		.1494		.168
17	.1905	.1494	.1905		.1867		.168
18	.2858	.1867	.1715		.2241		.2241
19	.381	.4481	.4001		.5041		.4481
20	.4572	.4481	.4763		.5041		.4481
21	.381	.4481	.4001		.4481		.3921
22	.3429	.3361	.3429		.3361		.3361
23	.2858	.2801	.2667		.2658		.2801
24	.1581	.2286	.2241	.2286	.1867	.2241	.1867
Max	.4572	.4763	.5041	.4954	.5041	.5041	.4854
Min	.1143	.112	.1307	.1715	.1063	.1307	.112
Avg	.2459	.2651	.2502	.3191	.2673	.2782	.2719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 202 / 11KV SAKHAREWADI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0437	1.3336	.8855	1.105	.8223	.8855	
2	1.2018	1.3717	1.0595	1.1812	1.0437	1.0595	
3	1.2453	1.2384	1.3125	1.2384	1.3916	1.1702	
4	1.2334	1.4861	1.5497	1.448	1.4864	1.2176	
5	1.3916	1.5623	1.4706	1.5242	1.5181	1.4706	
6	1.4864	1.9052	1.5181	1.9052	1.9608	1.7553	
7	1.6762	2.0957	1.8976	2.0957	1.9608	1.9925	
8		1.829	2.0557		1.8976	2.3339	
9	2.9729	.9488	1.5813		.9172	1.8976	
10	2.2672	1.5181	1.3908		1.3125		
11							1.6288
12							1.9134
13							1.9925
18							1.8501
Max	2.9729	2.0957	2.0557	2.0957	1.9608	2.3339	1.9925
Min	1.0437	.9488	.8855	1.105	.8223	.8855	1.6288
Avg	1.6132	1.5289	1.4721	1.4997	1.4311	1.5314	1.8462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 274215 / 33/11 KV KALMAN

Feeder No / Name : 203 / 11KV KAUTHALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	26-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6009
2					.6009
3					.6642
4					.6325
5					.5693
6					.6325
7					.6642
8					.8223
9					1.0437
10					.5535
11	1.2955	1.0753	1.1431		
12	1.467	1.1227	1.4861	1.1227	
13	1.7147	1.1385	1.4098	1.2334	
14	1.6194	1.2334		1.2334	
15	1.5813	1.2334		1.1385	
16	1.6004	1.2651	1.448	1.1544	
17	1.5623	1.2967	1.448	1.1702	
18	1.3336	1.2651	1.4861	1.1385	
Max	1.7147	1.2967	1.4861	1.2334	1.0437
Min	1.2955	1.0753	1.1431	1.1227	.5535
Avg	1.5218	1.2038	1.4035	1.1702	.6784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 203 / 11KV NEHRU NAGAR Ag.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.6825	2.0481	2.6825		2.1548	.081
10	2.6825	1.9662	2.6825	2.3205	2.1548	.08
11		.0886	.0895	.0848	.0819	2.2634
12	.0686	.081	.0514	.0848	.0772	
13		.0819	.0486	.0848	.0734	2.2634
14	.0762	.0819	.0448		.0753	
15	.0762	.0848	.0381	.0695		2.2377
16	.0829	.0848	.0362	.0667	.0648	1.6385
Max	2.6825	2.0481	2.6825	2.3205	2.1548	2.2634
Min	.0686	.081	.0362	.0667	.0648	.08
Avg	.9448	.5647	.7092	.4519	.6689	1.4273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 204 / 11KV DEGAON-AG-
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0943	.0953	.009	.0934	.0934	3.1207
10	.0953	.0953	.0914	.0953	.0934	3.0836
11			2.8178	3.6866	3.5227	.0953
12	3.6866	3.9323	3.6466	3.7247	3.9323	.0953
13	3.6866	3.9781	3.9781	3.7247	4.0143	.0953
14	3.4818	4.0238	3.8504	3.5627	3.7247	
15	3.8866	3.8056	3.5627	3.4818	3.3608	.0953
16	3.6046	3.7247	3.6866	3.4008	3.8866	.0953
Max	3.8866	4.0238	3.9781	3.7247	4.0143	3.1207
Min	.0943	.0953	.009	.0934	.0934	.0953
Avg	2.6480	2.8079	2.7053	2.7213	2.8285	.9544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 207 / 11KV BALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.4034	2.1548	.3277		1.8233	.2229
10	2.2119	2.13	1.8023	1.989	1.8233	.1867
11		.1829	.1867	.1791		.2343
12	.1848	.1886	.1867			.2343
13	.1848	.1886	.1867			.3953
14	.1848	.1886	.1867			
15	.1867					
16	.1867		.1772			.9602
Max	2.4034	2.1548	1.8023	1.989	1.8233	.9602
Min	.1848	.1829	.1772	.1791	1.8233	.1867
Avg	.7919	.8389	.4363	1.0841	1.8233	.3723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 209 / 11KV TIKEKAR WADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0819	.0819	.0819	.0819	.0819	.8488
10	.0819	.0953	.0819	.0819	.0724	.8802
11		.5601	.5535	.6401	.703	.0667
12	.7811	.703	.6325	.7202	.8697	.0753
13	.7907	.7116	.7116	.703	.8697	.0819
14	.7907	.7202	.7811	.7907	.8592	
15	.7907	.7907	.7116	.7907	.8488	.0953
16	.8697	.7907	.8802	.8802	.7811	.0743
Max	.8697	.7907	.8802	.8802	.8697	.8802
Min	.0819	.0819	.0819	.0819	.0724	.0667
Avg	.5981	.5567	.5543	.5861	.6357	.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 210 / 11KV GAONTHAN DEGAON
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.724	.7316	.823	.8402	.8145	.7468
10	.724	.6335	.8145	.7392	.7164	.6335
11			.724	.6335	.6401	.6201
12	.6335	.5544	.6401	.6335	.6468	.6335
13	.6468	.5601	.6401	.6335	.6335	.6401
14	.6401	.6468	.6335	.6401	.6335	
15	.6468	.7316	.6401	.6335	.543	.6335
16	.7316	.7316	.7164	.6268	.6401	.6335
Max	.7316	.7316	.823	.8402	.8145	.7468
Min	.6335	.5544	.6335	.6268	.543	.6201
Avg	.6781	.6557	.7040	.6725	.6585	.6487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-I S/DN.[094] BU 1325

Substation No/ Name :- 277002 / 132/33/11 KV DEGAON

Feeder No / Name : 213 / 11KV URBAN DEGAON NEW

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2715	.2772	.2658		.2715	.2743
10	.1772	.2801	.1734	.2715	.2658	.2658
11		.1829	.1829	.1772	.2743	.2658
12	.1791	.2715	.2772	.2658	.2772	.1772
13	.2658	.1829	.2772	.2658	.2686	
14	.2658	.1829	.2772	.2743	.2686	
15	.2686	.2658	.2743	.2715	.2715	.2715
16	.2686	.2658	.2772	.2658	.2743	.2658
Max	.2715	.2801	.2772	.2743	.2772	.2743
Min	.1772	.1829	.1734	.1772	.2658	.1772
Avg	.2424	.2386	.2507	.2560	.2715	.2534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 201 / 11 KV VINCHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	2.4539	2.5149	2.4025	2.4863	2.1033	.381
2	2.7721	2.4539	2.649	2.4025	2.4863	2.3282	.381
3	2.7721	2.4006	2.8502	2.4025	2.4863	2.3282	.381
4	2.7721	2.4006	2.934	2.4025	2.4863	2.2786	.381
5	2.9569	2.4539	3.0639	2.5873	2.4863	2.2786	.4763
6	3.4189	2.6292	3.2114	3.0493	2.915	2.6292	.5716
7	3.6037	2.1091	3.2114	2.3101	2.915	2.9767	.6478
8	3.6037	3.2602	3.1131	3.5113	3.0864	2.1491	.4954
9	3.5113	3.2952	3.1855	3.4189	2.915	3.1024	.3239
10	3.4004	.2858	3.3265	3.1722	2.915	3.2076	.3048
11		.2858	.2858	.2858	.2858	.2286	2.3663
12		.3239	.2858		.2858	.2858	
13	.381		.2477		.2858	.3048	
14	.4572	.3239	.2667	.381	.3048	.3048	
15	.4572	.3239	.2858	.381	.3048	.3048	
16	.4572	.381	.2858	.381	.3048	.3048	
17	.4191	.381	.2858	.381	.3429	.3048	2.8045
18			.3429		.4763	.362	2.9797
19	.4954	.381	.4763	.5716	.5716	.6097	
20	.5144	.381	.6097	.6668	.6097	.5716	.7621
21	.4572	.381	.5716	.4763	.5525	.5144	.6859
22	.381	.3429	.4763	.4763	.4763	.4572	.5716
23	.381	.3429	.4001	.381	.381	.4191	.4763
24	.381	.381	.3429	.3239	.381	.381	.381
Max	3.6037	3.2952	3.3265	3.5113	3.0864	3.2076	2.9797
Min	.381	.2858	.2477	.2858	.2858	.2286	.3048
Avg	1.6178	1.2714	1.4676	1.5412	1.3642	1.2806	.8540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 202 / 11 KV VADAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2477	.2858	.2858	.2286	1.8671
2	.2858	.2858	.3239	.2858	.2858	.2286	1.8671
3	.2858	.2858	.3239	.2858	.2858	.2286	1.8671
4	.2858	.2858	.381	.2858	.2858	.2286	1.848
5	.3429	.2858	.381	.2858	.381	.2286	2.0328
6	.4001	.3239	.4572	.381	.381	.2858	2.2177
7	.4572	.4001	.4572	.4572	.381	.3239	2.3655
8	.3048	.3048	.4572	.362	.381	.2667	2.4025
9		.2858	.381	.3048	.2858	.2477	2.4025
10	.2096			.2858		.1905	2.1735
11	1.4083		2.809	2.2291	2.3487	2.3655	
12	1.6651	2.4577	3.3265	2.7435	2.9271	2.7721	
13	1.6651	2.5396	3.2341	2.7435	2.8921	2.9569	
14	1.6655	2.5724	3.1417	2.915	2.6578	2.809	
15	1.6126	2.5724	3.1417	2.8292	2.6116	2.7721	
16	1.5947	2.6155	3.0493	2.8292	2.4539	2.4949	
17	1.6476	2.6155	3.0493	2.8292	2.5415	2.4025	.2286
18	1.5775	2.6155	2.9569	2.572	2.5415	2.2177	.2858
19	.381	.2286	.3239	.381	.4001	.381	.381
20	.381	.2286	.4572	.381	.4572	.3429	.4191
21	.381	.2858	.4382	.381	.4001		.4191
22	.2858	.2858	.381	.381	.381	.3239	.2858
23	.2858	.2858	.3239	.2858	.2858	.2858	
24	.2858	.2858	.2477	.2858	.2858	.2858	.2858
Max	1.6655	2.6155	3.3265	2.915	2.9271	2.9569	2.4025
Min	.2096	.2286	.2477	.2858	.2858	.1905	.2286
Avg	.7693	1.0151	1.3170	1.1253	1.1364	1.0812	1.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 203 / 11 KV KUSUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.7621	.9335	.5716	.9526	.6668	2.1472
2	.6668	.7621	.9526	.5716	.9526	.6668	2.1253
3	.6668	.7621	.9526	.5716	.9526	.6668	2.1472
4	.6668	.7621	.9907	.5716	.9526	.6668	2.1472
5	.9145	.8573	.9907	.5716	1.0479	.6668	2.2177
6	1.0669	.9526	.9907	.9335	1.0479	.7621	2.4025
7	1.0669	1.1431	.9907	1.0669	1.0479	.8383	
8	.9145	.9907	.6097	.9526	.9526	.7621	2.6797
9	.7621	.9145		.9145	.7621	.6097	2.4949
10	.5335	3.0178	.2286	.381	.6668	.381	2.6139
11	3.155	3.1121	3.0493	2.572	2.524	2.4949	
12	3.4294	3.1121	3.3265	3.2579	3.0864	2.8645	
13	3.4705	3.2065	3.5113	3.0864	3.155	3.0493	
14	3.4355	3.2065	3.5113	2.915	2.8746	2.7721	
15	3.3436	3.3008	3.4189	2.8292	2.8746	2.7721	
16	3.3303	3.3951	3.4189	2.8292	2.8349	2.7721	
17	3.155	3.4705	3.5113	2.8292	2.7221	2.6797	.2286
18	3.155	3.4705	3.0493	2.8292	2.6863	2.6797	.2286
19	.7621	.7621	.2667	.5716	.6859	.4572	.3048
20	1.0669	.8573	.5525	.9526	.8383	.6859	.3048
21	1.0669	.8573	.5335	.9526	.8383	.6478	.3048
22	.9526	.9335	.6097	.9526	.8383	.5716	.2286
23	.8573	.9335	.5716	.9526	.7621	.5144	.2286
24	.6668	.7621	.9335	.5716	.9526	.7621	.2667
Max	3.4705	3.4705	3.5113	3.2579	3.155	3.0493	2.6797
Min	.5335	.7621	.2286	.381	.6668	.381	.2286
Avg	1.6572	1.7627	1.6480	1.4670	1.5420	1.3504	1.3571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 204 / 11 KV INDIAN PUBLIC SCHOOL SINGLE PHASING
(IP Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.4022	1.3927	1.2012	1.2003	.3155	.1143
2	1.1088	1.4022	1.4746		1.2003	.3155	.1143
3	1.1088	1.4022	1.5565	1.2012	1.2003	.3155	.1143
4	1.1088	1.4022	1.6004	1.2012	1.2003	.3155	.1143
5	1.386	1.4899	1.6004	1.386	1.2003	.3086	.1143
6	1.7556	1.5775	1.6804	1.6632	1.8004	.3155	.1334
7	1.922	1.7147	1.7124	1.848	1.8004	.6485	.1715
8	1.9959	1.7528	1.8023	1.922	1.8004	1.4022	.1524
9	1.9404	1.8054	1.8023	1.6632	1.7147	1.7528	.1143
10	1.7002	.0762	1.8959	1.6632	1.7147	1.5775	.0953
11	.0762	.0762	.0762	.0953	.0762	.0572	1.0517
12	.0762	.0762	.0762	.0953	.0762	.0762	
13	.0762	.0762	.0762	.0953	.0762	.0762	
14	.0762	.0762	.0953	.0953	.0762	.0762	
15	.0762	.0762	.0953	.0953	.0762	.0762	
16	.0762	.0953	.0953	.0953	.0762	.0762	
17	.0953	.0953	.0953	.0953	.0762	.0762	1.7703
18	.0953	.0953	.0953	.0953		.0953	1.6651
19	.0953	.0953	.1143	.1905		.1905	.0953
20	.0953	.0953	.1905	.1905	.0953	.1905	.0953
21	.0953	.0953	.1715	.1905	.0762	.1715	.0953
22	.0953	.0762	.1524	.1905	.0762	.1334	.0762
23	.0762	.0762	.1334		.0762	.1143	.0762
24	.1143	.0953	.0762	.1143	.0953	.0762	.1143
Max	1.9959	1.8054	1.8959	1.922	1.8004	1.7528	1.7703
Min	.0762	.0762	.0762	.0953	.0762	.0572	.0762
Avg	.6815	.6344	.7526	.6995	.7175	.3647	.3304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 205 / 11 KV EXPRESS FDR
CRE/PHONIX Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0537	.1227	.0747	.0924	.0716	.0554
2	.0747	.0543	.1227	.0924	.0924	.1227	.0554
3	.0732	.0554	.1402	.0924	.0924	.1254	.0747
4	.0554	.056	.1417	.0924	.0924	.1402	.056
5	.0543	.0543	.1417	.0905	.0924	.1433	.0924
6	.0549	.0537	.1433	.0895	.0924	.1463	.128
7	.0537	.0701	.1433	.0914	.0924	.1417	.1463
8	.0549	.0358	.1433	.0554	.0924	.1448	.1294
9	.0924	.0543	.1433	.0739	.0924	.1663	.1294
10	.0924	.0724	.0739	.0857	.0924	.1433	.1052
11	.112	.0724	.0747	.0876	.0934	.112	.1052
12	.1109	.1109	.0924	.0876	.0905	.1097	
13	.112	.1109	.0924	.0876	.0924	.1097	
14	.1109	.1109	.128		.096	.1294	
15	.1109	.1086	.0914	.0857	.1052	.1294	.1097
16	.1109	.1448	.0747	.0886	.1075	.1097	.0554
17	.1254	.1417	.0739	.0886	.0838	.1307	.056
18	.1097	.1417	.0732	.0886	.0693	.1109	.0549
19	.1086	.1417	.056	.0914	.1029	.0566	.037
20	.124	.1417	.0739	.0914	.0693	.0754	.0373
21	.1227	.1227	.0747	.0914	.1214	.0754	.0739
22	.1063	.1227	.0747	.0914	.0857		.0366
23	.0724	.1227	.0747	.0914	.0876	.0739	.0351
24	.0554	.0549	.1227	.0747	.0914	.0886	.0747
Max	.1254	.1448	.1433	.0924	.1214	.1663	.1463
Min	.0537	.0358	.056	.0554	.0693	.0566	.0351
Avg	.0897	.0920	.1039	.0863	.0925	.1155	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274091 / 33/11 KV ANTROLI

Feeder No / Name : 207 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.3717	1.0059	1.307	1.4575	1.0745	.2286
2	1.2936	1.4022	1.0898	1.307	1.4575	1.0517	.2286
3	1.2936	1.4022		1.307	1.4575	1.0517	.2286
4	1.2936	1.4899		1.2936	1.4575	1.0745	.2286
5	1.46	1.5775		1.386	1.4575	1.1641	.2286
6	1.8111	1.6651		1.7556	1.8004	1.3146	.2477
7	1.9035	1.7878	1.1401	1.9404	1.8004	1.4685	.2477
8	1.9404	1.8229	2.0388	2.0328	1.8004	1.4373	.1715
9	2.0513	1.8054	2.0388	1.7556	1.8004	1.595	.1905
10	1.9774	.2858	2.1491	1.7147	1.8004	1.5061	.1715
11	.4763	.2858	.4763	.381	.4572	.2286	1.3717
12	.4763	.3239	.4763	.381	.4954	.2477	
13	.4954	.3239	.4572	.381	.5335	.2667	
14	.4954	.381	.381	.381	.5144	.2667	
15	.4763	.4191	.381	.381	.5144	.2667	
16	.4191	.4572	.362	.381	.5144	.2667	
17	.4572	.4572	.381	.381	.4763	.2858	1.5249
18	.4763	.4954	.381	.381	.4382	.2858	1.4899
19	.5525	.4191	.4001	.381	.4382	.2096	.1143
20	.5144	.381	.4001	.381	.4001	.2477	.1143
21	.4572	.381	.4001	.381	.3429	.2286	.0953
22	.381	.3429	.4001	.381	.3429	.2286	.0953
23	.3048	.3048	.381	.1905	.2858	.2286	.0953
24	.3239	.3048	.2667	.3048	.1905	.2858	.2286
Max	2.0513	1.8229	2.1491	2.0328	1.8004	1.595	1.5249
Min	.3048	.2858	.2667	.1905	.1905	.2096	.0953
Avg	.9427	.8287	.7503	.8695	.9264	.6784	.3843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 201 / 11 KV BALAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.2829	.5658	.3944	.3547	.3547	.4475
2	.4481	.2829	.5281	.3944	.3734	.3395	.7461
3	.4904	.3734	.5601	.4115	.3772	.3584	1.0227
4	.5228	.3772	.6036	.4287	.3961	.3921	1.1904
5	.5658	.2801	.6413	.4801	.4294	.4668	1.4586
6	.5975	.3772	.6535	.5144	.5041	.4294	1.95
7	.6413	.2829	.6602	.4801	.4854	.4108	2.323
8	.5281	.3734	.6001	.4115	.3361	.3361	2.1704
9	.3961			.3258	.1867	.2263	2.2291
10	.2075			.3361	.168	.1698	2.2291
11	2.1714	1.989	2.3663	2.2283	2.2119	2.1548	.3429
12	2.304	2.1956	2.5377	2.5434	2.4741	2.2211	.2915
13	2.3537	2.2939	2.7949	2.5095	2.2611	2.2611	
14	2.4577	2.3868	2.8807	2.4034	2.2542	2.1879	
15	2.5029	2.431	2.8464	2.3739	2.2611	2.2377	
16	2.5484	2.4531		1.8842	2.2939	2.2611	
17	2.652	2.3537	2.7435	2.4034	2.304	2.304	
18	2.3758	2.2801	2.3148	2.2939	2.2542	2.2447	.3429
19	.2829	.3206	.4115	.2241	.3547	.2054	.4287
20	.3734	.415	.4115	.4668	.3921	.2801	.4801
21		.5281	.4973	.4294	.3772	.2829	.3429
22		.5658	.4115	.4108	.3361	.2427	.3086
23		.6413	.4973	.3734		.1886	.2743
24	.5281	.3395	.6036	.4973	.3511	.3547	.1886
Max	2.652	2.4531	2.8807	2.5434	2.4741	2.304	2.323
Min	.2075	.2801	.4115	.2241	.168	.1698	.1886
Avg	1.2113	1.0829	1.2443	1.0508	1.0320	.9546	.9878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 203 / 11 KV B'KAWATHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	.4191	1.5089	2.0919	1.5777	1.4582	.6348
2	1.0059	.5801	1.643	2.0919	1.6448	1.5769	.7023
3	1.0608	.7459	1.8896	2.1948	1.7204	1.6448	.7922
4	1.1401	.9116	2.1216	2.2634	1.8351	1.6385	.8676
5	1.1603	1.0898	2.3472	2.6063	2.0481	1.8515	.8962
6	1.2407	1.1584	2.4366	2.7435	2.2119	1.5893	1.0642
7	1.2763	1.2929	2.5029	2.8292	2.0481	1.6385	.8402
8	1.2431	1.21	2.5857	2.7092	1.8351	1.7204	.6535
9	1.2239	1.1271	2.6216	1.9547	1.5729	1.7695	.3772
10	1.2517	1.1233	2.7161	2.2611	1.278	1.7072	.2743
11	.415	.3772	.3429	.4108	.4668	.3772	2.0576
12	.4294	.3772		.4668	.4481	.415	2.3148
13	.4904	.415			.4854	.4715	2.3148
14	.4854	.4338	.3772	.5601	.4668	.4527	
15	.4715	.4715	.4115	.5601	.4854	.4904	
16	.4338	.5093	.4458	.4668	.4668	.5093	
17	.3772	.5281	.4115	.4108	.3734		
18	.4715	.5281	.463	.4668	.3772	.5281	1.5947
19	.5658	.7167	.6516	.6535	.2829		
20	.4668	.7545	.7545	.8402	.2801	.8589	.823
21		.679	.6859	.7468	.2829	.811	
22		.6036	.6516	.6535	.3734	.6979	.6859
23		.5281	.5144	.5975		.6535	.6001
24	.547	.2801	.5093	.4801	.5601	.3734	.5658
Max	1.2763	1.2929	2.7161	2.8292	2.2119	1.8515	2.3148
Min	.3772	.2801	.3429	.4108	.2801	.3734	.2743
Avg	.7942	.7025	1.2997	1.3504	1.0053	1.0561	1.0033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 204 / LOKMANGAL EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.0857
2	.0943	.0943	.0943	.0857
3	.0934	.0943	.0943	.0857
4	.0943	.0857	.0943	.0857
5	.0943	.0857	.0934	.0857
6	.0934	.0857	.0943	.0857
7	.0943	.0857	.0943	.0857
8	.0943	.0857		.0857
9	.0943	.0857		
10	.0943	.0943		
11	.0943	.0943		
12	.0943	.0943		
13	.0943	.0943		
14	.0943	.0943		
15	.0943	.0943		
16	.0943	.0943		
17	.0943	.0943		
18	.0943	.0943		
19	.0943	.0943		
20	.0943	.0943		
21	.0943	.0943		
22	.0857	.0943		
23	.0943	.0943		
24	.0943	.0943	.0943	.0857
Max	.0943	.0943	.0943	.0857
Min	.0857	.0857	.0934	.0857
Avg	.0939	.0922	.0942	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 205 / 11 KV AMBEDKAR NAGAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1867	.415	.3086	.3921	.3734	.2321
2	.1509	.3772	.4481	.3086	.4294	.3961	.3441
3	.1867	.3395	.4715	.3429	.4338	.3961	.4641
4	.2075	.2829	.5041	.3429	.415	.3921	.5868
5	.2075		.5093	.3601	.4715	.4715	.7042
6	.2241	.2829	.5281	.3772	.5601	.4668	.8288
7	.2641	.2829	.547	.3601	.5041	.4108	.8619
8	.2263	.3734	.4904	.3086	.4481	.3361	.8288
9	.2075	.2829	.4715	.2743	.3734	.2829	.8573
10	.2829	.3395	.2743	.2614	.2614	.2452	.8573
11	.2486	.3688	.9602	1.0486	1.0576	.9389	.1715
12	.3315	.4359	1.1145	1.1022	1.0978	.9614	.1886
13	.3315	.4694	1.2003	1.1022	1.094	1.0395	
14	.4973	.5197	1.2346	1.0978	1.0978	.9892	
15	.5801	.9054	1.166	1.0814	1.0608	.9945	
16	.4973	.9945	1.166	1.0814	1.0814	.9221	
17	.5801	1.0395	1.166	1.1963	1.0774	.6464	
18	.4973	1.0608	1.0974	1.1616	1.0898	.8785	.1715
19	.1848	.2452	.2229	.2987	.2801	.132	.1886
20	.2772	.2829	.2743	.3547	.3206	.2075	.1543
21		.3395	.3429	.4108	.3772	.1867	.1543
22		.415	.3429	.4294	.4108	.1509	.1543
23		.4527	.3086	.3921		.1509	.1543
24	.2075	.1867	.4715	.3086	.3921	.3772	.132
Max	.5801	1.0608	1.2346	1.1963	1.0978	1.0395	.8619
Min	.1509	.1867	.2229	.2614	.2614	.132	.132
Avg	.3038	.4550	.6553	.5963	.6403	.5144	.4229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274092 / 33/11KV BHANDKAWATHE

Feeder No / Name : 207 / 11 KV TELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.6299	1.6766	1.8861	1.7532	1.6876	.7167
2	.4527	.4915	1.8778	1.8861	1.8351	1.6712	.5601
3	.4904	.6554	1.989	2.0233	2.0008	1.8143	.5658
4	.5281	.663	2.146	2.1262	2.0388	1.7859	.4668
5	.5601	.6299	2.2542	2.1434	2.0481	1.95	.4668
6	.5658	.663	2.2874	2.1948	2.2119	1.8023	.7095
7	.6036	.4588	2.3205	2.2977	2.13	1.8351	.679
8	.6413	.4588	2.3758	2.2634	2.1792	1.9662	
9	.6036	.431	2.3703	2.2634	2.0481	1.9989	.2401
10	.2641	.503	2.3663	2.3232	1.9989	1.9725	.2743
11	.6413	.7356	.5487	.3921		.5093	1.5432
12	.6413			.6535		.5281	1.7318
13	.6653		.3772	.7468		.4904	
14	.6722		.6516	.8402		.4904	
15	.7095			.8402	.5975	.5281	
16	.7468		.6859	.7842	.6535	.547	
17	.7545		.7202	.811	.7468	.5093	
18			.7545	.8589	.8676	.5658	1.749
19	.9431	.811	.6859	.8962	.8299	.6722	.4458
20	.9431	.8299	.6859	.8962	.8589	.7922	.4801
21		.7922	.7545	.8402	.6535	.7468	.5144
22		.7545	.7202	.6535	.5658	.6722	.6516
23		.6979	.6173	.5601		.6602	.6516
24	.4715	.7167	.4904	.3429	.4108	.5601	.7167
Max	.9431	.8299	2.3758	2.3232	2.2119	1.9989	1.749
Min	.2641	.431	.3772	.3429	.4108	.4904	.2401
Avg	.6157	.6425	1.3344	1.3135	1.3910	1.1148	.7313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 201 / 11 KV FATATEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.8288	.7716	.8288	.8288	.7716	.9335
2	1.1145	.9831	.8573	.8288	.9012	1.0288	.9335
3	1.2003	1.1336	1.1145	.9945	.9831	1.0288	.9335
4	1.4575	1.2803	1.2003	1.1336	1.1603	1.286	1.1203
5	1.5089	1.4403	1.3413	1.4746	1.326	1.4918	
6	1.6385	1.7814	1.6385	1.6385	1.6766	1.7204	
7	1.9433	1.9662	1.7814	1.9204	2.0576	1.9433	
8	1.6385	1.8442	1.7814	2.0005	2.1033	1.8842	
9	1.7814	1.0174	1.6194	1.9433	1.7147	1.8842	
10	1.6766	1.5089	1.4746	1.7204	1.3717	1.7404	.8402
11	.4668	.5601	.5601	.6535	.5658	.5601	1.5432
12	.5658	.5601	.5601	.6535	.6535	.6535	1.9719
13	.5658	.5601	.5601	.6602	.7468	.6535	1.7147
14	.6602	.5601	.5601	.6602	.6535	.6535	1.8861
15	.5658	.5601	.5601		.6535	.6535	1.9281
16	.6602	.5601	.5601	.7545	.6535	.6535	1.8861
17	.6602	.6468	.6535	.7545	.7468	.6535	1.8861
18	.7545	.7392	.7468	.9431	.8402	.7468	1.8861
19	1.1317	1.0269	.9335	1.1317	1.0269	1.0269	1.0374
20	1.226	1.2136	1.2136	1.226	1.1203	1.2136	1.3203
21	1.3203	1.2136	1.2136	1.226	1.2136	1.2012	1.3203
22	1.1317	1.1203	1.1203	1.1203	1.1203	1.1203	1.226
23	.9335	.9335	.9335	1.0269	.8402	1.1203	1.0374
24	.8488	.8402	.7545	.8402	.8402	.7468	.9335
Max	1.9433	1.9662	1.7814	2.0005	2.1033	1.9433	1.9719
Min	.4668	.5601	.5601	.6535	.5658	.5601	.8402
Avg	1.1033	1.0366	1.0213	1.1363	1.0749	1.1015	1.3862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 202 / 11 KV AUJ HIPPALE YATNAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.7392	.7468	.8402	.7468	.7468	.6859
2	.6602	.7316	.7468	.8402	.8402	.7468	.6859
3	.7545	.7392	.8402	.9335	.8402	.7468	.8573
4	.9335	.7392	.9335	1.1203	.9335	1.0269	1.0288
5	1.1203	.8402	1.2136	1.2136	1.1317	1.2136	1.2136
6	1.2936	1.0374	1.307	1.2936		1.307	1.2136
7		1.226				.9335	1.4737
8	1.1088	.9431	.9335		.7468	.7468	1.7147
9	.8402	.6602	.7468	1.0269	1.0374	.7468	1.5261
10	.6602	.6602	.5601	.8402	.8488	.7468	1.0288
11	1.2003	1.3717	1.1736	1.3717	1.0288	1.1603	.5601
12	1.3717	1.326	1.4746	1.5089	1.5089	1.4089	.5658
13	1.0288	1.3108	1.3108	1.3927	1.5089	1.4089	.5658
14	1.1736	1.3108	1.1469	1.2651	1.1736	1.3413	.6602
15	1.0898	1.2955	1.326	1.2803	1.286	1.2574	.6602
16	1.1603	1.3765	1.326	.6325	1.3413	1.2574	.6602
17	1.1736	1.3927	1.326	1.2803	1.2003	1.3413	.6602
18	1.3565	1.4746		1.1469	1.2003	1.2574	.7545
19	.9431	.7468	.8402	1.0269	1.0269	1.0269	.9431
20	1.0374	.9335	1.1203	1.1203	1.0269	1.1203	1.0374
21	.9431	.9335	1.1203	1.1317	.9335	1.1203	1.0374
22	.8488	.8402		.9431	.8402	.9335	.8488
23	.7468	.8402	.8402	.7392	.8402	.9335	.7545
24	.7545	.7468	.7545	.8402	.7468	.7468	.7468
Max	1.3717	1.4746	1.4746	1.5089	1.5089	1.4089	1.7147
Min	.6602	.6602	.5601	.6325	.7468	.7468	.5601
Avg	.9939	1.0090	1.0375	1.0813	1.0358	1.0532	.9118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 203 / 11 KV HOTAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6535		.6602	.6535	.6602	.8859
2	.7545	.6535		.6602	.6468	.7545	.8859
3	.8488	.7392		.7545	.7392	.7545	
4	.9431	.8316		.9431	.7468	.9431	.8859
5	1.0269	.8402		1.1317	.8402	1.1203	1.0517
6		.9431		1.226			1.2136
7		1.1317					1.286
8	.9431	.9431			.7545	.9431	1.2574
9	.8488	.7545		1.0374	.9431	.8488	1.1603
10	.6602		.6602	.7545	.7545	.7545	.9831
11	.9831		1.0288	1.0288	1.0288	1.1603	.5601
12	1.3413		1.1736	1.2003	1.2003	1.2431	.6602
13	.9831		1.2431	1.1736	1.2003	1.2574	.5658
14	1.1736		1.065	1.1022	1.2003	1.2574	.5658
15	1.1022		1.1469	1.1145	1.2003	1.1736	.5658
16	1.0898		1.1603	.7716	1.2003	1.1736	.4715
17	1.0774		1.1603	1.1269	1.2003	1.1736	.5658
18	.6554		1.0774	1.2003	1.2003	1.1603	.6602
19	.8402		.8488		.9431	.9335	.8488
20	.8488		.8488	.9335	.9431	.9431	.9431
21	.8488		.8488	.8488	.8488	.9431	.8488
22	.7545		.7545	.8488	.7545	.7545	.7545
23	.6535		.7545	.7545	.7545	.7545	.6602
24	.7545	.6535		.6602	.6602	.6602	.6602
Max	1.3413	1.1317	1.2431	1.226	1.2003	1.2574	1.286
Min	.6535	.6535	.6602	.6602	.6468	.6602	.4715
Avg	.9039	.8144	.9836	.9491	.9279	.9712	.8235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274093 / 33/11 KV HOTAGI

Feeder No / Name : 204 / 11 KV BHARAT GARMENT
EXPRESS Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381			.0381	
2	.0381	.0381	.0381		.0381	.0381	
3	.0381	.0381	.0381			.0381	
4	.0381	.0381	.0381			.0381	
5	.0381	.0381	.0381			.0381	
6		.0381	.0381		.0381	.0381	
7		.0381	.0381		.0381	.0381	
8		.0381	.0381		.0381	.0381	.0381
9	.0381	.0381	.0381		.0381	.0381	.0373
10	.0381	.0381	.0377	.0381	.0381	.0381	.0377
11	.0381	.0381	.0373	.0381	.0381	.0381	.0381
12	.0381	.0381	.0373	.0381	.0381	.0381	.1143
13	.0381	.0381	.0373	.0381	.0381	.0373	.0381
14	.0381	.0381	.0373	.0381	.0381	.0373	.0381
15	.0381		.0373	.0381	.0381	.0373	.0381
16	.0381	.0381	.0373	.0381	.0381	.0373	.0381
17	.0381	.0381	.0373	.0381	.0381	.0373	.0381
18	.0381	.0381	.0373	.0381	.0381	.0373	
19	.0381	.0381	.0373	.0381	.0381	.0381	.0381
20	.0381	.0381	.0373	.0381	.0381	.0381	.0381
21	.0381	.0381	.0377	.0381	.0381	.0381	.0381
22	.0381	.0381		.0381	.0381	.0381	.0381
23	.0381	.0381		.0381	.0381		.0381
24	.0381	.0381	.0381		.0381	.0381	
Max	.0381	.0381	.0381	.0381	.0381	.0381	.1143
Min	.0381	.0381	.0373	.0381	.0381	.0373	.0373
Avg	.0381	.0381	.0377	.0381	.0381	.0379	.0431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 201 / 11 KV YELEGAON(KANDALGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2829	.2801		.2801		1.0059
2	.1867	.2829	.2801		.2801		1.0059
3	.1867	.2829	.2801		.2801		1.3413
4	.1867	.2829	.2801		.3734		1.6766
5	.1867	.2829	.3734		.4668		1.8442
6	.1867	.3772	.4668		.4668		2.1795
7	.1867	.3772	.4668		.5601		
8	.3734	.3772	.3734		.4668		2.3472
9	.1867	.3772	.2801		.2801		2.2634
10		.1867		.2801		.2801	
11		1.6766		1.8442		2.0119	
12		2.431		1.8442		2.0119	
13		2.431		2.0119		2.1795	
14		2.5149		2.0119		2.6139	
15		2.5149		2.3472		2.3472	
16		2.3472		2.431		2.3472	
17		2.1795		2.431		2.1795	
18		2.1795		2.1795		2.1795	
19		.4668		.3734		.3734	
20		.4668		.3734		.3734	
21		.4668		.3734		.3734	
22		.3734		.2801		.2801	
23		.2801		.2801		.2801	
24	.1867	.2829	.2801		.2801		.1867
Max	.3734	2.5149	.4668	2.431	.5601	2.6139	2.3472
Min	.1867	.1867	.2801	.2801	.2801	.2801	.1867
Avg	.2054	.9884	.3361	1.3615	.3734	1.4165	1.5390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 202 / 11 KV BASAVNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	1.0059			.6706		.3734
2	.503	1.0059	1.0059		.6706		.3734
3	.6706	1.1736	1.0059		1.0059		.3734
4	.6706	1.5089	1.3413		1.0059		.3734
5	1.0059	1.5089	1.3413		1.3413		.4668
6	1.3413	1.6766	1.3413		1.5927		.3734
7	1.5089	1.6766			1.5927		
8	1.5089	1.5927	1.5089		1.5927		.4668
9	1.5089	1.3413	1.1736		1.5089		.3734
10	.6706	1.4251		1.3413		1.5089	
11		.2801		.2801		.2801	
12		.2801		.3734		.2801	
13		.2801				.2801	
14		.2801				.2801	
15		.2801		.3734		.2801	
16		.2801		.3734		.3734	
17		.3734		.3734		.3734	
18		.3734		.3734		.3734	
19		.3734		.5601		.4668	
20		.3734		.4668		.4668	
21		.3734		.4668		.4668	
22		.3734		.3734		.3734	
23		.3734		.3734		.3734	
24	.3734	.2829			.3734		.3734
Max	1.5089	1.6766	1.5089	1.3413	1.5927	1.5089	.4668
Min	.3734	.2801	1.0059	.2801	.3734	.2801	.3734
Avg	.9332	.7705	1.2455	.4774	1.1355	.4412	.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 203 / 11 KV WANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.8383	.6706		.503		.1867
2	.503	1.0059	.6706		.8383		.1867
3	.8383	1.1736	1.0059		.8383		.1867
4	.8383	1.3413	1.4937		1.1736		.1867
5	1.3413	1.5089	1.3413		1.3413		.2801
6	1.5089	1.5089	1.5927		1.5089		.3734
7	1.6766	1.6766	1.5927		1.5089		
8	1.6766	1.6766	1.6766		1.5089		.2801
9	1.5089	1.5927	1.6766		1.4251		.1867
10		1.5089		1.3413		1.5927	
11		.1867		.1867		.1867	
12		.1867		.1867		.1867	
13		.1867		.1867		.1867	
14		.1867		.1867		.1867	
15		.1867		.1867		.1867	
16		.1867		.1867		.1867	
17		.1867		.1677		.1867	
18		.2801		.1867		.1867	
19		.3734		.2801		.3734	
20		.3734		.2801		.3734	
21		.3734		.2801		.2801	
22		.1867		.1867		.1867	
23		.1867		.1867		.1867	
24	.1867	.1886	.1867		.1867		.1867
Max	1.6766	1.6766	1.6766	1.3413	1.5089	1.5927	.3734
Min	.1867	.1867	.1867	.1677	.1867	.1867	.1867
Avg	1.0582	.7125	1.1907	.2878	1.0833	.3205	.2282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 205 / 11 KV MANDRUP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.8383	.6706		.6706		.6535
2	.503	.8383	.6706		.6706		.6535
3	.6706	.8383	.6706		.8383		.6535
4	.8383	1.0059	.8383		.8383		.7468
5	.8383	1.0059	.8383		.8383		.9335
6	1.0059	1.2574	1.0059		1.1203		.8383
7	1.1736	1.2574	1.0059		1.0059		
8	1.1736	1.1736	1.0898		1.1736		.7468
9	1.0898		1.0898		1.0059		.7468
10		.8383		1.0059		.9221	
11		.5601		.6535		.5601	
12				.5601		.5601	
13		.6535		.5601		.5601	
14		.6535		.5601		.5601	
15		.6535		.5601		.5601	
16		.6535		.6535		.5601	
17		.6535		.6535		.6535	
18				.6535		.6535	
19		1.0269		.8402		.8402	
20		1.0269		.9335		.9335	
21		.8402		.9335		.9335	
22		.7468		.7468		.7468	
23		.6535		.7468		.6535	
24	.4668	.7545	.5601		.6535		.6535
Max	1.1736	1.2574	1.0898	1.0059	1.1736	.9335	.9335
Min	.4191	.5601	.5601	.5601	.6535	.5601	.6535
Avg	.8179	.8538	.8440	.7187	.8815	.6927	.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274094 / 33/11 KV MANDRUP

Feeder No / Name : 206 / 11 KV KARKAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18
HR	Load (MW)	Load (MW)
1	.3734	.3772
2	.3734	.3772
3	.4668	
4	.4668	
5	.5601	
6	.7468	
7	.7468	
8	.5601	
9	.4668	.4715
24	.5601	.3353
Max	.7468	.4715
Min	.3734	.3353
Avg	.5321	.3903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 201 / 11 KV AUJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4525	.4525	.543	.543	.6335	2.4006
2	.362	.4525	.4525	.543	.543	.6335	2.4006
3	.3982	.4525	.4525	.543	.543	.6335	2.4006
4	.3982	.4525	.4525	.543	.543	.6335	2.4863
5	.4344	.4525	.543	.5792	.543	.6335	2.572
6	.4344	.4525	.543	.6335	.543	.6335	2.6578
7	.4344	.543		.724	.5792	.6335	2.8292
8	.362	.543		.6335	.6335	.6335	2.7092
9	.2715	.543	.2715	.543	.5792	.543	
10		.362	.2715	.3801	.4525	.905	1.9033
11	.7716	1.0288	2.2291	2.7435	1.7147	2.572	.2715
12	.8573		2.3663	3.0864	1.7147	2.6749	.2715
13			2.572		1.5432	2.6749	.2715
14	1.1145		2.6749	2.3148		2.7778	.2715
15	1.6289	1.8861	2.8292	2.572	1.7147	2.1091	.543
16	1.8004	1.9719	2.8807	2.6578	1.8004	2.1948	.543
17				2.6749	1.8519	2.1605	.543
18	1.7147	2.0062	2.572	2.7092	1.9719	2.0576	.543
19	.6335	.4887		.543	.9955	.6001	.724
20	.6335	.543	.6859	.6335	1.0136	.724	1.0136
21	.543	.5068				.724	.0543
22	.543	.4706	.4887		.7059	.7602	.4525
23	.4525	.4163	.543		.6878	.724	.362
24	.362	.4525	.3982	.543	.6335	.6516	.724
Max	1.8004	2.0062	2.8807	3.0864	1.9719	2.7778	2.8292
Min	.2715	.362	.2715	.3801	.4525	.543	.0543
Avg	.6910	.7238	1.2463	1.3072	.9932	1.2467	1.2586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 202 / 11 KV TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543		.543	.6859	.6335	.6516	2.6578
2	.543		.543	.6859	.6335	.6516	2.6578
3	.6335		.543	.6859	.6335	.6516	2.6578
4	.724		.543	.6859	.724	.6516	2.6578
5	.8145		.6878	.7716	.7602	.6516	2.7435
6	.8869		.7602	.9088	.8326	.7602	2.7778
7	.7421		.8145	.8573	.8688	.8869	2.7949
8	.6516		.724	.724	.7421	.7602	2.572
9	.4706			.5068	.4525	.543	2.6406
10	.3982	.3077	.362	.5068	.362		2.5034
11	2.6749	2.0576		2.915	3.2579		.362
12	2.7435			3.1036	3.3265		.4163
13				2.1434	2.1434	3.0007	.4525
14	2.4348		2.4177	3.155	3.1036	3.2236	.4525
15	2.572	1.9719	3.0521	3.2579		3.2236	.4706
16	2.1948	1.989	3.1207	3.3093		3.2579	.5068
17		2.0919	2.8635	3.3951		3.1893	.5068
18	2.1091	2.0576	3.0007	3.1207	3.1379	3.1207	.5792
19	.724	.6154	.5792	.6154	.5611	.6697	.6335
20	.7421	.7421	.8573	.8688	.724	.7602	.6878
21	.724	.6878	.8573	.7602	.7783	.6878	.7783
22	.6516	.6516	.8145	.724	.724	.5792	.6516
23	.5792	.6154	.724	.6878	.724	.5068	.5792
24	.6154		.5792	.6859	.6697	.7059	.4525
Max	2.7435	2.0919	3.1207	3.3951	3.3265	3.2579	2.7949
Min	.3982	.3077	.362	.5068	.362	.5068	.362
Avg	1.1442	1.2535	1.2193	1.4900	1.2282	1.3873	1.4247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 203 / 11 KV NANDANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	1.3717	1.0631	1.0288	1.1145	1.286	.2896
2	.8573	1.3717	1.1145	1.0288	1.1145	1.286	.2896
3	1.0288	1.3717	1.1145	1.0288	1.2003	1.286	.2896
4	1.0288	1.3717	1.2003	1.0288	1.286	1.286	.3439
5	1.1145	1.3717	1.286	1.2003	1.3717	1.286	.3801
6	1.2003	1.3717	1.3717	1.286	1.5432	1.3717	.4344
7	1.4403	1.4918	1.4232	1.6461	1.6461	1.4746	.3439
8	1.749	1.5947	1.749	1.7147	1.7833	1.5432	.3258
9	1.7318	1.5947	1.7318	1.7147	1.749	1.406	.3258
10	1.6804	1.6289	1.6804	1.6804	1.6804	1.6289	.2715
11	.2353		.2715	.2715	.1629	.2353	1.406
12	.2353	.1991	.1991	.2353	.2172	.2172	1.6118
13	.2353	.1991	.1991	.2172	.2172	.1991	1.6461
14	.2058	.181	.1991	.2353	.2172	.2172	1.6461
15	.1715	.181	.2172	.2715	3.0864	.2172	1.7147
16	.2058	.2172	.2353	.2353	3.0007	.2353	1.7147
17		.2353	.2172	.2353	2.9664	.2715	1.749
18	.2353	.181	.2534	.2534	.2715	.2896	1.6118
19	.3982	.3982	.4344	.4344	.4163	.4344	.3258
20	.4344	.4706	.4344	.4706	.4344	.4706	.4525
21	.362	.4344	.4344	.4344	.4525	.3982	.4344
22	.3258	.362	.3982	.362	.4344	.3439	.4163
23	.3258	.3439	.362	.3258	.3982	.3258	.362
24	.3077	.3258	.3077	.2915	.2896	.3258	.2896
Max	1.749	1.6289	1.749	1.7147	3.0864	1.6289	1.749
Min	.1715	.181	.1991	.2172	.1629	.1991	.2715
Avg	.7079	.7943	.7457	.7346	1.1272	.7515	.7781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV KUDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	.6001	1.9547	2.2291	2.3148	2.4863	.4525
2	2.0576	.6001	2.0576	2.2291	2.3148	2.4863	.4525
3	2.0576	.6001	2.0576	2.2291	2.3148	2.4863	.4525
4	2.2291	.6001	2.1948	2.2291	2.4006	2.4863	.543
5	2.3148	.6001	2.3148	2.3148	2.572	2.4863	.6335
6	2.3834	.6001	2.4348	2.572	2.7092	2.572	.6878
7	1.7833	.5144	2.5206	2.8807	2.8292	2.6578	.724
8	2.3834	.4973	2.6578	2.8635	2.7949	2.6578	.4887
9	2.4177	.4801	2.572	2.8292	2.6063	2.6406	.4344
10	2.4863	.4458	2.3834	2.7606	2.6749	2.5549	.3439
11	.3077	.4163	.4525		.4525	.362	2.5892
12	.362	.362	.362	.2715	.3801	.3258	2.8978
13		.3258	.362	.3258	.3982	.2896	2.9321
14		.3258	.3258	.3801	.3982	.3801	2.9321
15	.4287	.3077	.3439		.4163	.3982	3.0007
16	.3772	.3258	.362	.3801	.4163	.362	3.035
17		.3439	.4525	.3801	.4163	.4344	3.035
18	.362		.3801	.4344	.4525		3.1379
19	.6335	.724	.6335	.6878	.6335	.6878	.5068
20	.7421	.7602	.6859	.7421	.724	.7421	.724
21	.724	.6878	.6878	.724	.7421	.6878	.6878
22	.6878	.5973	.6335	.6878	.724	.5973	.6335
23	.6335	.543	.5973	.6335	.6335	.543	.5792
24	.543	.543	.5249	.5316	.543	.5792	.4706
Max	2.4863	.7602	2.6578	2.8807	2.8292	2.6578	3.1379
Min	.3077	.3077	.3258	.2715	.3801	.2896	.3439
Avg	1.3320	.5131	1.2480	1.4235	1.3693	1.3871	1.3489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV KURGHOT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9							.3429
10	.0857						.3429
11	.0857	.3429	.0686	.0686	1.2346	.3429	
12	.2058		.0686	.0686	1.4403	.3429	
Max	.2058	.3429	.0686	.0686	1.4403	.3429	.3429
Min	.0857	.3429	.0686	.0686	1.2346	.3429	.3429
Avg	.1257	.3429	.0686	.0686	1.3375	.3429	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274096 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV RTO CHECK POST
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0362	.0343	.0362	.0343	.0362	.0343
2	.0343	.0362	.0343	.0343	.0343	.0362	.0343
3	.0343	.0362	.0343	.0362	.0343	.0362	.0343
4	.0171	.0362	.0343	.0362	.0343	.0362	.0343
5	.0171	.0362	.0171	.0343	.0171	.0362	.0343
6	.0171	.0362	.0171	.0362	.0171	.0362	.0171
7	.0171	.0181	.0171	.0181	.0171	.0181	.0171
8	.0171	.0181	.0171	.0181	.0171	.0181	.0171
9	.0171	.0181	.0181	.0181	.0181	.0171	.0181
10	.0181	.0181	.0181	.0181	.0181	.0171	.0181
11	.0181	.0181	.0181	.0181	.0181	.0171	.0181
12	.0181	.0181	.0181	.0181	.0181	.0171	.0181
13	.0171	.0181	.0181	.0181	.0181	.0171	.0181
14	.0171	.0181	.0181	.0181	.0181	.0171	.0181
15	.0171	.0181	.0181	.0181	.0362	.0171	.0181
16	.0171	.0181	.0181	.0181	.0362	.0171	.0181
17		.0171	.0181	.0171	.0362	.0171	.0181
18	.0181	.0171	.0181	.0171	.0181	.0171	.0181
19	.0362	.0171	.0181	.0171	.0181	.0171	.0181
20	.0362	.0171	.0362	.0171	.0362	.0171	.0362
21	.0362	.0171	.0362	.0171	.0362	.0171	.0362
22	.0362	.0171	.0362	.0171	.0362	.0171	.0362
23	.0362	.0171	.0362	.0171	.0362	.0343	.0362
24	.0171	.0362	.0171	.0362	.0171	.0362	.0343
Max	.0362	.0362	.0362	.0362	.0362	.0362	.0362
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0237	.0231	.0236	.0229	.0259	.0235	.0250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 201 / 11 KV TANDULWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.7545	.6859	.6859	.1524
2	.7545	.7545	.823	.823	.6859	.3429	.1524
3	.7545	.823	.823	.823	.7545	.4801	.2286
4	.823	.8916	.9259	.823	.823	.5487	.4572
5	.8916	.9602	.9602	.8916	.9602	.9602	.6859
6	.9602	1.0288	1.0288	1.0974	1.0288	1.0288	.7621
7	1.0974	1.0974	1.0288	1.166	1.166	1.166	
8	1.0974	1.166	.9602	1.166	1.166	1.2858	
9	1.0974	1.0288	.9602	1.0288	1.0288		1.6995
10	.9602	.9602	1.1431	.8916	.5487		1.4784
11	.1524	.2286	.2286	.3048	.3048		1.1202
12	.1524	.1524	.2286	.2286	.1524		1.326
13	.1524	.1524	.1524	.2286	.1524		1.3336
14	.1524	.1524	.1524	.1524	.1524		1.1812
15	.1524	.1524	.1524	.1524	.1524		1.1812
16	.1524	.1524	.2286	.1524	.1524		1.1812
17	.1524	.1524	.2286	.2286	.1524		1.044
18	.2286	.1524	.4572	.3048	.1524		1.2726
19		.381	.5335	.6097	.5335		.9907
20	.6097	.6097	.6859	.6097	.1524		1.2194
21	.5335	.381	.7621	.5335	.5335		1.2956
22	.381	.3048	.381	.381	.3048		.8382
23	.3048	.1524	.2286	.3048	.3048		.6858
24	.2286	.2286	.1524	.2286	.2286	.2286	.2286
Max	1.0974	1.166	1.1431	1.166	1.166	1.2858	1.6995
Min	.1524	.1524	.1524	.1524	.1524	.2286	.1524
Avg	.5424	.5312	.5796	.5785	.5115	.7474	.9325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 202 / 11 KV MUSTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4586	1.5432	1.6095	1.6804	1.6461	1.6561	.8764
2	1.6244	1.7147	1.7555	1.6804	1.7833	1.7237	.9145
3	1.6561	1.7147	1.9603	1.8004	1.9204	1.8927	.9526
4	1.7238	1.8861	2.0279	1.8004	2.0576	1.9227	.9526
5	1.9603	2.0576	2.3035	1.8861	2.332	2.0955	1.1431
6	2.2542	2.3148	2.5745	2.2634	2.5377	2.3035	1.2384
7	2.7846	2.915	1.4227	2.332	2.9492	2.8729	
8	.7293	3.0864	3.035	2.9492	2.9664	3.0167	
9	2.1948	2.8807	2.8664	2.572	2.4006	2.6749	
10	2.1605	2.652	2.6749	2.5206	2.0576	2.4006	
11	.5716	.5877	.5335	.5335	.4954	.724	2.6063
12	.5906	.5335	.5144	.5144	.381	.6859	2.7435
13	.5525	.5335	.4382	.4954	.381	.6097	2.4863
14	.5906	.4572	.4763	.5144	.4954	.4954	2.5377
15	.5906	.4572	.4572	.5335	.4954	.5335	2.4691
16	.5906	.381	.4954	.5335	.5335	.5335	2.4006
17		.4572	.5335	.5716	.5716	.6287	2.332
18	.6287	.4191	.724	.6097	.5716	.7621	2.1948
19	.9717	.9145	.9335	1.0288	1.0288	1.0288	1.0288
20	1.1431	1.105	1.105	1.0479	1.0669	1.1431	1.0669
21	1.0669	1.0669	1.1431	.9717	1.0669	1.1812	1.086
22	.9907	.9526	.9526	.9145	.9526	1.1431	1.0288
23	.8954	.9145	.9145	.8002	.9145	1.105	.9145
24	.7621	.8573	.8383	.8383	.6859	.7621	
Max	2.7846	3.0864	3.035	2.9492	2.9664	3.0167	2.7435
Min	.5525	.381	.4382	.4954	.381	.4954	.8764
Avg	1.2388	1.3501	1.3454	1.3080	1.3455	1.4123	1.6302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 203 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.448		1.3717	1.3717	1.448	1.3717
2	1.3717	1.448	1.3717	1.2193	1.3717	1.448	1.3717
3	1.3717	1.448	1.5242	1.2193	1.448	1.3717	1.4403
4	1.3717	1.5242	1.6766	1.4861	1.5242	1.4861	1.5775
5	1.6766	1.6766	1.7528	1.5242	1.6004	1.6004	1.7147
6	1.829	1.9814	1.9052	2.0576	1.6766	1.829	1.8519
7							2.1262
8							2.4006
9	1.1431	1.448	1.3717	1.448	1.3717	1.0669	2.4006
10	.9145			1.2193	1.1431	.9907	2.0576
11		2.0302	2.2634	2.0576	2.0576	2.0576	.9145
12	2.4006	2.5194	2.1262	1.9204	2.1879	2.4768	.9145
13	2.5377	2.3868	2.4006	1.9204	.823	2.4006	.9145
14	2.4006	2.1879	2.2634	2.0576	2.079	2.0576	.9145
15	2.332	2.1879	2.0576	2.0576	2.2542	2.4006	.9145
16	2.4691	2.3659	2.332	2.2634	2.1879	2.4006	.9907
17	2.4006	2.3659	2.5377	2.4691	2.2542	2.4006	.9907
18	2.4006	2.1948	2.1262	2.332	2.1879		.9907
19		1.5242	1.5242	1.5242	1.6004	1.5242	1.5242
20	1.9052	1.6766	1.5242	1.6766	1.7528	1.6004	1.7528
21	1.7528	1.6004	1.5623	1.6004	1.6766	1.6004	1.6766
22	1.6766	1.6004	1.6004	1.6004	1.6004	1.5242	1.5242
23	1.448	1.448	1.448	1.5242	1.5242	1.4861	1.448
24	1.3717	1.448	1.3717	1.3717	1.448	1.448	1.3717
Max	2.5377	2.5194	2.5377	2.4691	2.2542	2.4768	2.4006
Min	.9145	1.448	1.3717	1.2193	.823	.9907	.9145
Avg	1.8073	1.8338	1.8370	1.7237	1.6883	1.7437	1.4648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 204 / 11 KV NEW KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8112	.8573	.8807	.7545	.6859	1.1336	.1143
2	1.0139	1.0288	.9945	.823	.6859	1.2742	.0953
3	1.0815		1.1517	.8573	.823	1.4227	.0953
4	1.0828		1.1271	1.0288	1.2346	1.4211	.1524
5	1.2071		1.3923	1.2003	1.6461	1.7575	.1715
6	1.326		1.8251	1.5089	1.9204	1.8564	.1905
7	1.7901	1.8004	1.9603		2.1948	1.989	
8	1.8778	2.0576	2.1293	1.8861	2.0576	1.8896	
9	1.7833	1.9281	2.1262	2.0576	1.989	1.9204	.0762
10	1.5089	1.8442	1.8861	1.989	3.8195	1.7147	.0762
11	.0953	.0762	.0572	.0762	.1524	.0762	1.5432
12	.0572	.0762	.0572	.0762	.0381	.0762	1.8519
13	.0572	.0762	.0572	.0762	.0381	.0572	1.7147
14	.0572	.0572	.0572	.0762	.0381	.0572	1.9204
15	.0762	.0762	.0572	.0762	.0381	.0572	1.7833
16		.0953	.0572	.0762	.0381	.0762	1.7147
17	.0953	.0572	.0572	.0762	.0381	.0572	1.5775
18	.1143	.0953	.0953	.0953	.0381	.0762	1.6461
19	.1905	.1715	.1334	.1524		.1905	.1143
20	.2286	.2096	.1905	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905	.1905	.1524	.1905
22	.1524	.1143	.1334	.1524	.1334		.1524
23	.1143	.0953	.1143	.1143	.1334	.1143	.1143
24	.1143	.1143	.0953	.1143	.1143	.1334	.1143
Max	1.8778	2.0576	2.1293	2.0576	3.8195	1.989	1.9204
Min	.0572	.0572	.0572	.0762	.0381	.0572	.0762
Avg	.6533	.5511	.7011	.5934	.7930	.7693	.7091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 205 / 11 KV SANGDARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2384	1.1812	1.1431	1.1622	1.1812	1.2003
2	1.1812	1.2384	1.1812	1.105		1.1431	1.2003
3	1.2193	1.2955	1.2955	1.105	1.0669	1.1431	1.2346
4	1.2955	1.3336	1.3717	1.1431	1.105	1.2193	1.3717
5	1.448	1.5242	1.448	1.3336	1.3146	1.2955	1.5432
6	1.5242	1.7147	1.5242	1.6956	1.4098	1.5242	1.6804
7							1.8176
8							1.7833
9	.9907	.9907	.7621	1.086	.9335		1.5432
10	.6859		.724	.8573	.8192	.7621	1.406
11	1.3032	1.1869	1.406	1.5432	1.406	1.3375	.6478
12	1.4918	1.2887	1.4403	1.4403	1.6461	1.5242	.6097
13	1.4575	1.3565	1.2003	1.3032	1.6278	1.5432	.6668
14	1.4232	1.3565	1.3717	1.2689	1.2887	1.5623	.6668
15	1.3889	1.3565	1.3717	1.3717	1.2597	1.4746	
16	1.3889	1.4083	1.4575	1.5775	1.2209	1.5432	
17	1.4918	.6859	1.4575	1.6118	1.3923	1.5261	
18	1.4918	1.3565	1.3032	1.5089	1.5249	1.4232	
19		1.0669	.9526	1.2193	1.2193	1.105	1.2955
20	1.3527	1.3336	1.1431	1.4098	1.448	1.1812	1.5242
21	1.2765	1.3336	1.2955	1.3717	1.448	1.3336	1.467
22	1.2765	1.2574	1.3336	1.2955	1.3717	1.3717	1.4098
23	1.2384	1.2193	1.2574	1.2574	1.3336	1.3336	1.3717
24	1.2193	1.2003	1.1812	1.1622	1.2003	1.2955	1.2765
Max	1.5242	1.7147	1.5242	1.6956	1.6461	1.5623	1.8176
Min	.6859	.6859	.724	.8573	.8192	.7621	.6097
Avg	1.3031	1.2734	1.2573	1.3096	1.2952	1.3249	1.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274097 / 33/11 KV TANDULWADI

Feeder No / Name : 206 / 11 KV PINJARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2743	.2667	.2401	.3387	.0572
2	.2683	.2572	.2743	.2667	.2401	.3429	.0762
3	.2743	.3086	.3429	.3086	.2743	.4115	.0953
4	.2743	.3429	.3429	.3086	.3086	.4115	.1334
5	.3391	.4115	.3429	.3086	.3429	.4115	.1905
6	.5144	.4287	.4115	.3086	.4115	.4115	.2286
7	.5081	.6001	.4115		.4801	.5144	
8	.583	.5144	.4458	.4115	.4115	.4801	
9	.3772	.6001	.4115	.6859	.3772	.4801	.0572
10	.3429	.5144	.4115	.5487	.3086	.4115	.0572
11	.0572	.1143	.1524	.0762	.1143	.0762	.3772
12	.0762	.0381	.0762	.0762	.0381	.0572	.4801
13	.0762	.0381	.0762	.0762	.0762	.0572	.4458
14	.0762	.0762	.0762	.0762	.0762	.0572	.4458
15	.0762	.0381		.1143	.0762	.0572	.4801
16	.0762	.0381	.0572	.1143	.0762	.0572	.4801
17	.0762	.0381	.0572	.1143	.0762	.0572	.4801
18	.1143	.0381	.1143	.1524	.0762	.0762	.5144
19	.2096	.1524	.1905	.1905	.1524	.1524	.1143
20	.2286	.0381	.2286	.2286	.0762	.1905	.1524
21	.2096	.0381	.2286	.2286	.1715	.2286	.1524
22	.1905	.1524	.1524	.1905	.1524	.1905	.1143
23	.1524	.1143	.1524	.1524	.1524	.0953	.0762
24	.1143	.1524	.1143	.1334	.1143	.1524	.0572
Max	.583	.6001	.4458	.6859	.4801	.5144	.5144
Min	.0572	.0381	.0572	.0762	.0381	.0572	.0572
Avg	.2273	.2209	.2324	.2321	.2010	.2383	.2394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 201 / 11 KV ULEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0754	.4694
2					.0566	.442
3					.0566	.4862
4					.0566	.503
5					.0943	.4725
6					.1132	.6036
7					.132	.8048
8					.0943	.8259
9	.0754	.0943	.0943	.0943		
10	.0943	.0754	.0566	.0754		
11	.7377	.6539	.5365	.6979		
12	.7545	.7209	.7545	.6706		
13	.7377	.7545	.7209	.7209		
14	.7377	.788	.7377	.7712		
15	.7209	.7545	.7042	.7611		
16	.7042	.8048	.6874	.7545		
24					.0754	.0943
Max	.7545	.8048	.7545	.7712	.132	.8259
Min	.0754	.0754	.0566	.0754	.0566	.0943
Avg	.5703	.5808	.5365	.5682	.0838	.5224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 204 / 11 KV MANCHUKONDA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0754	.0754
2					.0566	.0754
3					.0566	.0754
4					.0566	.0754
5					.0754	.0754
6					.0943	.0943
7					.0943	.1132
8					.0943	.0943
9	.0943	.1132	.1132	.0943		
10	.0754	.1132	.1132	.0943		
11	.132	.0943	.1029	.1132		
12	.0754	.0754	.0943	.0754		
13	.0754	.0514	.0943	.0566		
14	.0754	.0754	.0943	.0754		
15	.0754	.0566	.0943	.0566		
16	.0754	.0566	.0943	.0566		
24					.0754	.0754
Max	.132	.1132	.1132	.1132	.0943	.1132
Min	.0754	.0514	.0943	.0566	.0566	.0754
Avg	.0848	.0795	.1001	.0778	.0754	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 205 / 11 KV KHADAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.4586	.3961
2					1.643	.3961
3					2.2634	.415
4					2.4646	.4715
5					2.6155	.5658
6					3.1184	.679
7					3.0481	.6036
8					3.0849	.4904
9	2.7664	2.8502	2.9172	2.8334		
10	2.3472	2.649	2.8669	2.6993		
11	.1886	.2266	.1132	.2829		
12	.2075	.2075	.132	.2452		
13	.2075	.2077	.2263	.2058		
14	.2263	.1886	.2452	.2452		
15	.2075	.2075	.2452	.2454		
16	.2075	.2452	.2641	.2641		
24					.3772	.3961
Max	2.7664	2.8502	2.9172	2.8334	3.1184	.679
Min	.1886	.1886	.1132	.2058	.3772	.3961
Avg	.7948	.8478	.8763	.8777	2.2304	.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 206 / 11 KV Stone Crusher
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1509	.1886
2					.132	.1698
3					.1132	.1698
4					.1132	.1509
5					.132	.1509
6					.132	.1509
7					.132	.1509
8					.1698	.1509
9	.2263	.132	.2452	.3206		
10	.2452	.4904	.2829	.4715		
11	.4338	.4338	.3395	.5658		
12	.4338	.5658	.3772	.5658		
13	.3772	.4914	.3961	.4904		
14	.2643	.3772	.4338	.3772		
15	.3018	.6036	.4536	.4527		
16	.3395	.7545	.4158	.3969		
24					.1886	.2263
Max	.4338	.7545	.4536	.5658	.1886	.2263
Min	.2263	.132	.2452	.3206	.1132	.1509
Avg	.3277	.4811	.3680	.4551	.1404	.1677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 207 / 11 KV ULE GAONTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5658	.9105
2					.5093	.9221
3					.4191	.8688
4					.4715	1.0059
5					.7167	1.1012
6					.811	1.3748
7					1.0751	1.643
8					.8676	1.6095
9	.7167	.6036	.6413			
10	.415	.4527	.6602			
11	1.3077	1.4419	1.2407	1.4251		
12	1.9113	1.8107	1.6263	1.3413		
13	1.9281	1.8128	1.8107	1.5089		
14	1.6766		1.7604	1.576		
15	1.8107	1.5927	1.7269	1.6263		
16	1.8275	1.7269	1.7604	1.5424		
24					.5847	.6036
Max	1.9281	1.8128	1.8107	1.6263	1.0751	1.643
Min	.415	.4527	.6413	1.3413	.4191	.6036
Avg	1.4492	1.3488	1.4034	1.5033	.6690	1.1155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 208 / 11 KV EKRUKH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1132	.2012
2					.0943	.2012
3					.0857	.218
4					.0943	.218
5					.1132	.2591
6					.1509	.3725
7					.1698	.5182
8					.0754	.5365
9	.132		.132	.1509		
10	.0754		.0754	.1132		
11	.3521		.3856	.4696		
12	.4862		.6036	.5197		
13	.503		.5688	.5533		
14	.5197		.5533	.5868		
15	.5197	.4862	.5182	.6036		
16	.5197	.5533	.5197	.5668		
24					.132	.1132
Max	.5197	.5533	.6036	.6036	.1698	.5365
Min	.0754	.4862	.0754	.1132	.0754	.1132
Avg	.3885	.5198	.4196	.4455	.1143	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274098 / 33/11 Ule

Feeder No / Name : 209 / 11 KV BORAMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1401	.5281
2					1.1736	.5281
3					1.4586	.5281
4					1.6263	.5281
5					1.9113	.547
6					2.2801	.6224
7					2.5987	.7545
8					2.5149	.679
9	2.4813	2.0287	2.4646	2.5484		
10	2.1963	1.7652	2.1052	2.3472		
11	.3584	.3584	.2452	.6036		
12	.3772	.3772	.3772	.3772		
13	.3772	.3395	.3395	.415		
14	.3772	.3584	.3206	.4338		
15	.3772	.3584	.3018	.3772		
16	.378	.378	.3584	.3395		
24					.6224	.547
Max	2.4813	2.0287	2.4646	2.5484	2.5987	.7545
Min	.3584	.3395	.2452	.3395	.6224	.5281
Avg	.8654	.7455	.8141	.9302	1.7029	.5847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 201 / 11 KV DINDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2477	.2667	.2667	.5487
2	.2477	.2667	.2858	.2477	.2667	.2667	.583
3	.2477	.2858	.3048	.2477	.2667	.3429	.5335
4	.2667	.381	.3239	.2858	.2858	.4191	.5487
5	.3239	.4191	.362	.381	.362	.4572	.5639
6	.5525	.4763	.4572	.4572	.5144	.4954	.6554
7		.2477	.4763	.4382	.4572	.4954	.9755
8	.3429	.2858	.2667	.362	.1715	.381	1.1126
9	.1905		.2096	.2667	.1715	.3048	.9755
10	.1524	.2096	.1905		.1715	.2096	.8402
11	1.0631	.8573	.9145		.8916	.7926	.1715
12	.9755	.9859	.9907		.8993	.9297	.1905
13	1.0059	.9976	.945		.8688	.9755	.1905
14	.9602	.9305	.9297		.8383	.884	.2096
15	.9297	.9305	.8535		.8535	.945	.2286
16	1.0059	.9023	.945		.8688	.9755	.3048
17	1.1126	1.0431	1.0059		.884	1.0364	.2096
18	.9164	.9869	1.0292	1.0517		1.0669	.2477
19	.381	.4382	.4001	.4001		.4191	.4763
20	.4954	.4572	.4954	.4954		.4954	.4954
21	.4572	.4572	.4572	.4191		.4191	.4191
22	.3429	.4001	.3429	.3239		.3429	.381
23	.2858	.2667	.2667		.2667	.2667	.2858
24	.2667	.2667	.2477	.2477	.2667	.2477	.2667
Max	1.1126	1.0431	1.0292	1.0517	.8993	1.0669	1.1126
Min	.1524	.2096	.1905	.2477	.1715	.2096	.1715
Avg	.5561	.5547	.5403	.3915	.5038	.5598	.4756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 202 / 11 KV ACHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.4134	.7545	.7133	.5944	.5792	.4001
2	.5792	.5053	.6554	.7042	.6097	.6836	.4191
3	.5792	.5213	.6859	.7133	.6097	.7133	.4572
4	.5944	.5502	.7011	.7225	.6249	.7727	.4954
5	.6401	.7529	.7316	.7827	.6859	.8109	.6097
6	.8688	.8977	.8535	1.1443	1.2574	.9511	.7621
7	1.1431	1.2631	1.1584	1.2334	1.2498	.6661	.6478
8	1.2955	1.3245	1.2803	1.3696	1.3108	1.1584	.4763
9	1.2193		1.2346	1.278	1.2803	1.2342	.3429
10	1.0822	.9659	1.0974		1.1126	1.0669	.2667
11	.2477	.2858	.2667		.3048	.2096	.6081
12	.2667	.2858	.3048		.3048	.1905	1.1443
13	.3239	.2858	.3048		.3048	.2286	1.1145
14	.3239	.3048	.3429		.3239	.3429	.9701
15	.3239	.3048	.3239		.3429	.3239	.9808
16	.3239	.3048	.3048		.3429	.3048	1.0136
17	.3429	.3239	.3239		.362	.3429	1.1145
18	.3239	.3429	.3429	.381		.4001	1.0822
19	.6097	.6097	.5906	.6287		.6097	.6478
20	.6668	.6097	.6287	.6668		.6668	.724
21	.6097	.5906	.6097	.6097		.5906	.6287
22	.4763	.5144	.4572	.4763		.4954	.4954
23	.4001	.362	.362		.362	.381	.4001
24	.362	.362	.3429	.3429	.362	.3429	.381
Max	1.2955	1.3245	1.2803	1.3696	1.3108	1.2342	1.1443
Min	.2477	.2858	.2667	.3429	.3048	.1905	.2667
Avg	.5903	.5514	.6108	.7844	.6498	.5861	.6743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 203 / 11 KV L.CHINCHOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.5792	.5144	.5182	.6401	.5792	.4191
2	.5792	.6241	.4877	.5182	.6554	.5944	.4382
3	.6097	.6622	.5182	.5106	.6554	.6241	.4763
4	.6249	.6622	.5487	.5521	.6706	.6836	.5335
5	.6401	.7225	.6249	.7811	.7468	.7042	.6478
6	.7316	.7773	.7164	.9259	.8383	.7628	.7811
7	.9297	.9846	.9297	1.0031	1.0517	.9808	.8192
8	.823	.8916	1.0517	1.2346	1.1431	.9846	.724
9	.945		.8688	1.1288	1.0364	.9976	.5716
10	.8383	.7644	.7011		.945	.884	.4572
11	.381	.2667	.381		.3048	.381	.8288
12	.362	.362	.3048		.3048	.3429	.7575
13	.362	.3239	.1524		.3239	.3239	.8471
14	.362	.3429	.362		.362		.723
15	.381	.3429	.3239		.3429	.3429	.7202
16	.4001	.3429	.3048		.3239	.362	.7956
17	.4382	.381	.362		.3239	.3429	.7756
18	.362	.381	.4191	.4572		.4191	.823
19	.6478	.6478	.6859	.6287		.724	.724
20	.8192	.6287	.724	.7621		.724	.8192
21	.743	.6668	.6478	.6859		.6287	.6859
22	.6668	.5335	.5716	.5525		.5716	.6097
23	.5716	.4382	.4382		.4382	.4763	.4954
24	.5144	.5335	.4001	.4191	.4382	.4191	.4382
Max	.945	.9846	1.0517	1.2346	1.1431	.9976	.8471
Min	.362	.2667	.1524	.4191	.3048	.3239	.4191
Avg	.5957	.5591	.5433	.7119	.6077	.6023	.6630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 204 / 11 KV SOOT MIL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.5906	.8954	.8764	.9526	.6287	.3772
2	.7621	.6097	.8764	.8573	.9526	.6478	.3772
3	.9526	.6097	.8954	.8573	.9335	.6478	.3201
4	.9717	.724	.9145	.8573	.9717	.6859	.3353
5	1.0288	.7621	.9335	.9526	.9907	.6859	.3506
6	1.2003	.7811	.9907	1.0669	1.0288	.8002	.503
7	1.2193	.8192	1.0288	1.105	1.1431	.8002	.5792
8	.9717	.724	1.0669	.8764	.9907	.7049	.6859
9	.8764		.9145	.8764	.9145	.5525	.6706
10	.8383	.8573	.8192		.8764	.8002	.4382
11	.7545	.4144	.6097		.5316	.6401	.5144
12	.6859	.664	.6097		.5792	.6859	.5525
13	.7164	.6154	.6554		.5792	.6554	.6097
14	.6859	.6226	.6706		.5792	.6554	.5906
15	.6554	.6554	.6097		.5944	.5944	.6668
16	.6401	.6882	.6706		.6249	.7316	.5906
17	.6249	.6796	.5792		.6097	.7011	.5716
18	.3241	.5792	.5487	.6249		.4115	.9145
19	.6405	1.1622	1.105	1.2765		1.3336	1.2955
20	.8573	1.1812	1.105	1.3717		1.4289	1.467
21	.8383	1.2765	1.105	1.3146		1.1812	1.3336
22	.4191	1.1812	1.105	1.2384		1.105	1.2955
23	.6097	.9717	.9907		.6287	1.0479	1.0288
24	.9907	.5906	.9145	.9145	.9717	.6287	.9145
Max	1.2193	1.2765	1.105	1.3717	1.1431	1.4289	1.467
Min	.3241	.4144	.5487	.6249	.5316	.4115	.3201
Avg	.8015	.7722	.8589	1.0044	.8133	.7815	.7076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 205 / 11 KV HANJAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0572	.0572	.0572	.0572	.0572	.2401
2	.0572	.0572	.0572	.0572	.0572	.0572	.2401
3	.0457	.0762	.0572	.0572	.0572	.0762	.2572
4	.0762	.0953	.0572	.0572	.0572	.0953	.2439
5	.0953	.0953	.0762	.0953	.0762	.0953	.2743
6	.1143	.1334	.1334	.0953	.1143	.1143	.3201
7	.0953	.0953	.0953	.0953	.0953	.0953	.503
8	.0572	.0572	.0572	.0762	.0762	.0572	.5182
9	.0381		.0572	.0572	.0381		.4725
10	.0572	.0572	.0572		.0572	.0572	.434
11	.5487	.4371	.4725		.5144	.4877	.0189
12	.5487	.5146	.5792		.4877	.5182	.0189
13	.5944	.4451	.5639		.4877	.5335	.0377
14	.5487	.4401	.5792		.4877	.4725	.0381
15	.503	.4464	.4725		.4725	.4572	.0381
16	.5182	.4527	.6097		.4115	.4877	.0572
17	.5335	.4401	.4725		.503	.5182	.0572
18	.4801	.4401	.4405	.503		.503	.0572
19	.0953	.0953	.0953	.0762		.0953	.0953
20	.1143	.0953	.0953	.0953		.1143	.0953
21	.0953	.1143	.0953	.0953			.0762
22	.0953	.0953	.0762	.0762		.0953	.0762
23	.1715	.0762	.0572		.0572	.0762	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.5944	.5146	.6097	.503	.5144	.5335	.5182
Min	.0381	.0572	.0572	.0572	.0381	.0572	.0189
Avg	.2328	.2119	.2238	.1034	.2192	.2328	.1785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 206 / Kardehalli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.3311	.4115	.5087	.442	.4344	.2858
2	.4115	.4572	.381	.4862	.4572	.4633	.2667
3	.4115	.4877	.3963	.4752	.4572	.535	.2667
4	.4268	.5487	.4115	.4752	.4725	.5418	.2858
5	.4725	.5864	.442	.5967	.503	.5213	.3048
6	.5487	.6562	.4877	.8097	.5944	.5639	.4001
7	.823	.9217	.8535	.8539	.8688	.9259	.3429
8	.9297	.9877	.9755	.9842		.5647	.2477
9	.884		.9297	.9105	.7773	.8278	.2096
10	.7468	.6001	.7468		.6249	.7468	.2096
11	.1715	.1905	.2096			.1905	.9105
12	.1715	.1715	.2096		.2096	.1905	.9061
13	.1905	.1905	.2286		.2096	.1905	.7811
14	.1905	.2096	.2477		.2096	.2286	.7253
15	.2096	.2096	.2096		.2096	.2096	.6718
16	.1905	.1905	.2286		.2096	.1905	.724
17	.1715	.1524	.2096		.1905	.1905	.7529
18	.1715	.0953	.2286	.2286		.2096	.6706
19	.3239	.381	.3429	.381		.3429	.3429
20	.4001	.381	.4191	.4001		.381	.381
21	.4001	.4001	.4001	.3429		.362	.3429
22	.3429	.381	.362	.362		.3429	.3239
23	.3048	.3239	.3429		.2667	.3048	.2858
24	.2286	.2858	.2858	.3239	.2439	.2667	.2858
Max	.9297	.9877	.9755	.9842	.8688	.9259	.9105
Min	.1715	.0953	.2096	.2286	.1905	.1905	.2096
Avg	.3966	.3974	.4150	.5426	.4086	.4052	.4552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274099 / 33/11 KV VALSANG

Feeder No / Name : 207 / 11 KV MUDHOLKAR CRUSHER NON SHEDDABLE EXPRESS HV FEEDERS
 EXP. Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.1943	.1981	.2006	.2439		.2439
8		.1578	.1981	.2006	.2134	.2073	
9				.216	.2134		.2229
10			.1677		.2134	.1981	.2401
11	.2915	.1219	.2439		.1067	.1829	
12	.2743	.2286	.1715		.1677	.1981	
13		.1677	.1524		.1677	.2134	
14			.1524		.1524	.1372	
15	.1829	.1543	.1829		.1677	.1372	
16	.2134	.1543	.1981			.2286	
17	.2134	.1543	.1981		.1524	.2286	
18	.1475	.1067	.1718	.2134		.1524	
23		.0572					
Max	.2915	.2286	.2439	.216	.2439	.2286	.2439
Min	.1475	.0572	.1524	.2006	.1067	.1372	.2229
Avg	.2205	.1497	.185	.2077	.1799	.1884	.2356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 201 / 11 KV HATTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7392		.9054		.7545	
2	.8488	.7316	.7545	.8488	.8488	.7545	1.3032
3		.7164		.8488		.7545	
4	.9431	.905	.7545	.9431	.9431	.8488	1.3032
5		1.0974		1.0374		.9431	
6	1.226	1.1203	.9431		1.1317	1.1317	2.0576
7		1.1088		.9808		1.0974	
8	.9431	.5658	.6602	1.0374	.9054	.924	2.1948
9	.5658	.5658	.6602		.6036	.7316	2.3577
10		.5658		.7545	.5658	.7545	2.2634
11	1.7147		2.2634		2.0576		
12	1.8652	1.9547	2.5463	1.9204	2.2291	2.0576	
13	2.0348		2.0748		2.2291		
14	2.0576	1.9547	2.0748	1.9334	2.0576	2.0576	
15	2.0576		2.3577		2.0576		
16	2.0805	.823	2.3577	1.9204	2.0348	2.0576	
17	2.0576		2.3577		1.8233		.4904
18	1.7147	.7316	2.2634	1.9109		1.9719	.7545
19	.9145		.9431		1.8861		.9431
20	1.0974	.132	1.094	1.0562	1.0974	1.0185	1.094
21	1.1088		1.0374		1.0745		1.0374
22	1.0164	.1132	1.0374	.9808	.9145	.9431	.9431
23	.823	.0943	.9431	.9054	.9145	.9054	.9054
24	.8488	.7468	.7545	.9431	.8488	.8488	.7922
Max	2.0805	1.9547	2.5463	1.9334	2.2291	2.0576	2.3577
Min	.5658	.0943	.6602	.7545	.5658	.7316	.4904
Avg	1.3641	.8148	1.4673	1.1829	1.3802	1.1420	1.3171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 202 / 11KV WADAKBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0943			
2				.0943			.3772
3				.0943			
4	.0943			.0943	.1886		.3658
5				.0943			
6							.6401
7				.0943			
8	.1886		.0943	.0943	.2263		.7316
9			.0943				.7545
10						.0943	
11			.3772				.0943
12		.823	.4572	.0943		.7316	.0943
13			.4715				.0943
14		.823	.4715			.7316	.0943
15			.4715				.0943
16		.695	.4715	.583		.695	.0943
17			.4715				.0943
18		.7167	.4715			.6401	.0943
19			.0943				.0943
20		.3658	.0943	.2263		.132	.0943
21			.0943				.0943
22		.3772	.0943				.0943
23		.823	.0943	.0943		.0943	.0943
24	.0943		.0943	.0943	.1509		.0943
Max	.1886	.823	.4715	.583	.2263	.7316	.7545
Min	.0943	.3658	.0943	.0943	.1509	.0943	.0943
Avg	.1257	.6605	.2761	.1460	.1886	.4456	.2205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 203 / 11 KV RAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5658			
2			.439	.5658	.503		
3				.5658			
4	.6443			.5658	.4915		
5				.5658			
6				.7545			
7				.7545			
8	1.3413		.7316	.7545	.9259		.3772
9			.7545				.3018
10			.7545	.7712		.6001	
11			.3395				.9431
12		.1886	.2829			.2263	1.1317
13			.2829				1.1317
14		.1886	.2829	.2641		.1886	
15			.2829				
16		.1886	.2829			.1886	.7545
17			.2829				1.1317
18		.2641	.2829	.3018		.3018	1.5089
19			.3395				.3395
20		.4338	.3772			.415	.415
21			.415				.3772
22			.3772				.5281
23		.3018	.3395	.2641		.2641	.3395
24	.3018		.2641	.5658	.2641		.2641
Max	1.3413	.4338	.7545	.7712	.9259	.6001	1.5089
Min	.3018	.1886	.2641	.2641	.2641	.1886	.2641
Avg	.7625	.2609	.3951	.5584	.5461	.3121	.6817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 204 / 11 KV AURAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772		.3772	.2149	.3429	
2	.2629	.5281	.2743	.3772	.2195	.3429	.0566
3		.5281		.3772	.2263	.3429	
4	.3155	.5281	.2743	.3772	.4108	.4287	.0566
5		.4715		.4715	.4066	.5144	
6	.5258	.5658	.4755	.4715	.5068	.5144	.0566
7		.5658		.5658	.5609	.5144	
8	.5316	.5658	.9694		.5373		.0566
9	.543	.4715	.6224		.5087	.5144	.0566
10	.5258	.3772	.6224	.5258	.5087	.5487	.0566
11	.5658		.0566		.5304		.5281
12	.0566	.0566	.0566	.0566	.0566	.0566	.5658
13	.0566		.0566		.0566		.5658
14	.0566		.0566		.0377	.0566	
15	.0566		.0566		.0377		
16	.0566	.0566	.0566	.0566	.0377	.0566	.3772
17	.0566		.0566		.0377		.5658
18	.0566		.0566		.0377	.0566	.6036
19	.0566		.0566		.0566		.0566
20	.0566		.0566		.0566	.0566	.0566
21	.0566		.0566		.0566		.0516
22	.0566		.0566		.0566	.0566	.0566
23	.0566	.0566	.0566	.0566	.0566	.0566	.0566
24	.0543		.0566	.0566	.0566	.0566	.0566
Max	.5658	.5658	.9694	.5658	.5609	.5487	.6036
Min	.0543	.0566	.0566	.0566	.0377	.0566	.0516
Avg	.2002	.3961	.2015	.3142	.2197	.2657	.2156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 205 / SINDHKHED AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.0377
4							.0377
6							.0377
8							.0377
9							.0377
10							.0377
11	.0377		.0566		.0566		
12		.0566	.0566	.0566	.0377	.0377	
13			.0549		.0377		
14			.0514		.0377	.0377	
15	.0377		.0566		.0377		
16	.0377	.0566	.0566	.0566		.0566	
17	.0377		.0566		.0377		
18	.0377	.0566	.0566		.0377	.0377	
20			.1509				
Max	.0377	.0566	.1509	.0566	.0566	.0566	.0377
Min	.0377	.0566	.0514	.0566	.0377	.0377	.0377
Avg	.0377	.0566	.0663	.0566	.0404	.0424	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 206 / 11 KV MANGOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.2263		.1886	
2	.1886	.1886	.1886	.2263	.1886	.1886	.823
3		.1886		.2263		.1886	
4	.2263	.1886	.1886	.2829	.1886	.1886	.695
5		.3772		.3772		.2829	
6	.4715	.4715	.4904	.415		.3772	1.4575
7		.4715		.4904		.4715	
8	.3018	.3772	.3772	.3772	.4338	.3772	1.6289
9		.2829	.3772		.3395	.2829	1.7353
10	.2829	.2829		.2641	.2263	.2641	1.6461
11	.1886		1.5089		.1886		.1509
12	1.7147	1.5432	1.8484	1.5089	1.7147	1.5432	.1509
13	1.8861	1.8861	1.8861		1.7147		.1463
14	1.8861	1.5432	1.8861	1.4419	1.7147	1.5432	.1509
15	1.8861	1.6956	1.8861		1.5432		.1509
16	1.6956	1.5432	1.8861	1.4746	1.5432	1.5432	.1509
17	1.4918	1.4918	1.9239		1.5432		.132
18	1.4918	1.5775	1.9805	1.4419	1.5432	1.3717	.132
19	1.4918		.3395		.2829		.3206
20	.3772	.3206	.3395	.3395	.3772	.3395	.415
21	.2829		.2829		.3772		.3395
22	.1886	.2075	.2452		.3772	.2452	.1886
23	.1886	.1886	.2263	.1886	.1886	.1886	.1886
24	.1886	.1886	.1886	.2263	.1886	.1886	.1509
Max	1.8861	1.8861	1.9805	1.5089	1.7147	1.5432	1.7353
Min	.1886	.1886	.1886	.1886	.1886	.1886	.132
Avg	.8647	.7240	.9500	.5942	.7723	.5430	.5377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274100 / 33/11 KV WADAKBAL

Feeder No / Name : 207 / 11 KV WANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.4904	.1886	.1886	
2	.1886	.1886	.2263	.4904	.3772	.1886	.5487
3		.1886		.3018	.1886	.1886	
4	.2641	.1886	.2263	.4904	.3772	.1886	.5487
5		.1886		.5658	.2641	.2829	
6	.5658	.3772	.4715	.83	.9808	.2829	.7316
7		.3772		.943	.415	.3772	
8	.3772	.2829	.2829	.6412	.679	.1886	.7316
9	.1886	.1886	.4526	.2263	.1886	.1886	.7545
10	.1509	.1886	.4526	.3772	.1886	.1886	.679
11	.6859		1.3204	.583	.6859		.1132
12	.6859	.7316	1.509	1.3412	.6859	.7316	.1132
13	.6859		1.509	.7209	.6859		.1132
14	.6859	.7316	1.509	1.3444	.663	.7316	.1132
15	.6783		1.509	.5487	.663		.1132
16	.663	.695	1.509	1.2742	.1886	.695	.1132
17	.6554		1.509	.6859	.5144		.132
18	.4973	.5487	1.509	1.262	.5144	.6401	.1509
19	.3772		.9808	.1886	.2829		.2829
20	.3772	.3206	.5469	.9054	.2829	.3395	.3206
21	.3772		.5281	.3018	.2829		.3395
22	.2829	.2641	.5281	.1886	.1886	.2641	.2829
23	.1886	.2452	.4526	.3772	.1886	.2452	.2263
24	.1886	.1886	.2452	.4904	.3772	.1886	.2263
Max	.6859	.7316	1.509	1.3444	.9808	.7316	.7545
Min	.1509	.1886	.2263	.1886	.1886	.1886	.1132
Avg	.4382	.3379	.8639	.6487	.4188	.3388	.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 201 / 11 KV GODUTAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9054	.8589	.8402	.9335	.8589	.8402
2	.8676	.8962	.8589	.8962	.8962	.8589	.7842
3	.8676	.8589	.8215	.8402	.8215	.8215	.8029
4	.9054	.7468	.8215	.8402	.7842	.8215	.8402
5	.9054		.7842	.8402	.8215	.8215	.7842
6	.9054	.8215	.7468	.8589	.8962	.8215	.8589
7	.7922	.7842	.7468	.8029	.7842	.8215	.8775
8	.7167	.7095	.6722	.7468	.7468	.7468	.7468
9	.6413	.6722	.6348	.7095	.7468		.7282
10	.5975	.6722	.6348	.7095	.7468	.6908	.7167
11	.6722	.6722	.6535	.7842	.7095	.7468	.679
12	.6348	.6722	.6722	.7468	.7468	.7842	.7167
13	.7095	.6722	.1494	.7468	.7468	.7842	.7545
14	.7468	.7095	.7282	.7095	.7468	.8215	.7545
15	.7468	.7095	.7095	.7468	.7468	.7842	.7545
16	.7468	.7095	.7095	.7095	.7468	.7842	.7922
17	.7167	.6722		.7468	.7468	.7842	.7545
18	.6722	.6722	.7282	.7468	.8215	.7468	.7167
19	.7842	1.1203	1.1203	.8962	1.1949	1.1576	1.094
20	1.1203	1.1576	1.3256	.7095	1.2696	1.2136	1.2449
21	1.1576	1.1203	1.2696	1.0829	1.307	1.2883	1.226
22	1.0829	1.0456	1.1203	1.0082	1.1949	1.2696	1.2071
23	1.0456	.8962	.8962	1.0456	1.0456		1.094
24	.9054	.9709	.8962	.8962	.9709	.9335	.9335
Max	1.1576	1.1576	1.3256	1.0829	1.307	1.2883	1.2449
Min	.5975	.6722	.1494	.7095	.7095	.6908	.679
Avg	.8254	.8203	.8069	.8192	.8822	.8801	.8626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 202 / 11 KV KUMBHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3361	.3018	.4668	.3361	.3361	.3174
2	.3395	.3361	.3018	.5228	.2987	.2987	.3361
3	.3395	.2987	.3018	.5601	.2987	.2987	.4668
4	.415	.4854	.3395	.6535	.5228	.3361	.7095
5	.5658	.5975	.6036	.5975	.5975	.5975	.6908
6	.7922	.6722	.7545	.5975	.6722	.7468	.6535
7	.679	.7316	.679		.7095	.6722	
8	.6413		.5281		.5601	.5228	.3734
9	.4715	.5228	.4854	.5228	.4481		.5975
10	.4108	.3734	.3361	.4108	.3734	.3734	.4527
11	.3734	.3361	.3174	.3734	.2987	.3361	.3772
12	.2987	.3361	.2987	.3361	.2614	.2987	.3395
13	.2987	.2987	.2987	.2987	.2614	.2801	.2641
14	.2987	.2614	.2987	.2987	.2987	.2614	.2641
15	.2987	.2614	.2987	.2987	.2987	.2241	.2641
16	.2987	.2987	.2987	.3361	.2987	.2241	.2641
17	.2987	.2987	.2987	.2987	.2987	.2241	.2641
18	.3361	.3361	.3174	.3361	.2987	.3734	.3395
19	.4481	.5281	.4668	.4481	.5975	.5601	.0191
20	.6348	.5228	.5788	.5975	.5975	.5601	.6413
21	.5601	.5228	.5228	.5228	.5601	.5228	.5281
22	.4481	.4904	.4668	.4481	.4854	.5228	
23	.3734	.415	.4108	.3734	.3734		
24	.3395	.3734	.3734	.4108	.3361	.3361	.2987
Max	.7922	.7316	.7545	.6535	.7095	.7468	.7095
Min	.2987	.2614	.2987	.2987	.2614	.2241	.0191
Avg	.4292	.4188	.4116	.4413	.4201	.4048	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 203 / 11KV MICROWAVE
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0549	.0549	.0549	.0366	.0549	.0526
2	.037	.0366	.0549	.0549	.0366	.0549	.0701
3	.037	.0366	.0732	.0549	.0549	.0366	.0876
4	.0554	.0537	.0732	.0549	.0537	.0366	.1052
5	.0739	.0716	.0732	.0549	.0709	.0549	.1227
6	.1109	.0895	.0914	.0549	.1075	.0732	.1227
7	.0924	.1063	.1097	.0549	.0895	.0914	.1753
8	.1109	.0886	.0732	.0549	.0716	.0732	.1753
9	.0554	.0709	.0914	.0549	.0709	.0732	.1578
10	.0701	.0701	.0549	.0366	.0716	.0732	.1696
11	.1595	.0857	.0876	.08	.1341	.112	.0554
12	.1638	.1029	.1052	.1147	.1475	.1052	.037
13	.1311	.1341	.1052	.0743	.1475	.1578	.0554
14	.125	.1475	.1052		.1509	.1578	.0554
15	.144	.1475	.1402		.1341	.1578	.0554
16	.1219	.1677	.1402	.1526	.1341	.1753	.0554
17	.125	.1677	.1753	.176	.1543	.1753	.037
18	.1227	.1715	.1578	.1265	.1227	.1646	.037
19	.1075	.0732	.0549	.0716	.0732	.0351	.0554
20	.0895	.0732	.0732	.0716	.0732	.0366	.0739
21	.0543	.0732	.0549	.0724	.0549	.0366	.0739
22	.0549	.0732	.0549	.0549	.0549	.0366	.0739
23	.0554	.0549	.0549	.037	.0549	.0366	.037
24	.0381	.0549	.0549	.0549	.0366	.0549	.0366
Max	.1638	.1715	.1753	.176	.1543	.1753	.1753
Min	.037	.0366	.0549	.0366	.0366	.0351	.0366
Avg	.0905	.0919	.0881	.0735	.0890	.0860	.0824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 204 / 11 KV LOKMANGAL MEDICAL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRES Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0953	.0953	.0953	.1143	.0953
2	.0762	.0953	.0953	.0953	.0953	.0953	.0953
3	.0762	.0762		.0953	.0953	.0953	.0953
4	.0762	.0762	.0762	.0953	.0762	.0953	.0953
5	.0762	.0762	.0762	.0953	.0953	.0953	.0953
6	.0762	.0762	.0762	.0953	.0953	.0953	.0953
7	.0953	.0762	.0762	.0953	.0762	.0762	.0953
8	.0953	.0953	.0762	.0953	.0953	.0762	.0953
9	.1143	.1143	.0953	.0953	.1143		.1143
10	.1143	.1143	.1524	.0953	.1524	.1715	.1334
11	.1334	.1334	.1524	.1143	.1524	.1524	.1715
12		.1524	.1524	.0953	.1715	.1715	.1524
13	.1524	.1524	.1524	.1143	.1715	.1715	.1524
14	.1143	.1524	.1524	.0953	.1524	.1524	.1715
15	.1334	.1334	.1524	.0953	.1334	.1334	.1524
16	.1334	.1143	.1524	.1143	.1334	.1334	.1524
17	.1143	.1143	.1334	.0953	.1143	.1334	.1334
18	.0953	.0953	.1143	.0953	.1143	.0953	.1143
19	.0953	.1143	.1143	.0953	.1143	.1143	.1143
20	.0953	.1334	.1143	.0953	.1143	.0953	.1143
21	.1143	.1334	.0953	.1334	.1334	.0953	.1334
22	.0953	.1143	.0953	.1143	.1334	.0953	.1334
23	.0953	.1143	.0953	.0953	.1143	.1334	.1334
24	.0762	.0953	.0953	.0953	.0953	.1143	.0953
Max	.1524	.1524	.1524	.1334	.1715	.1715	.1715
Min	.0762	.0762	.0762	.0953	.0762	.0762	.0953
Avg	.1011	.1104	.1127	.1001	.1183	.1176	.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 205 / 11 KV MINAXI TAI SANE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3292	.2926	.2743	.2926	.2926	.2926
2	.2926	.2926		.2743	.2926	.2926	.2926
3	.2926	.2926		.2926	.2561	.2926	.3292
4	.2926	.2561	.2561	.2926	.2561	.2926	.3658
5	.2926	.2561		.3292	.2926	.2926	.3475
6	.2926	.2926		.3109	.2926	.2926	.3475
7	.2926	.2926	.2926	.2743	.2926	.2926	.2926
8	.2195	.2561	.2561	.2561	.2926	.2561	.2926
9	.2195	.2195	.2561	.2561	.2561	.2926	.2561
10	.2195	.2195	.2378	.2561	.2195	.2378	.2378
11	.2195	.2195	.2195	.2561	.1829	.2378	.2378
12	.2195	.2195	.2195	.2561	.2195	.2378	.2195
13	.2561	.2561	.2195	.2561	.2195	.2561	.2561
14	.2561	.2561	.2378	.2561	.2561	.2743	.16
15	.2561	.2926	.2378	.2926	.2926	.2561	.2561
16	.2561	.2926	.2378		.2926	.2561	.2195
17	.2561	.2926	.2378	.2926	.2926	.2561	
18	.2926	.2926	.2743	.2926	.2926	.2743	.2195
19	.3292	.439	.4024	.3658	.439	.4207	.4024
20	.439	.439	.4572	.4024	.4207	.4572	.4755
21	.439	.4572	.439	.4024	.439	.439	.439
22	.4024	.3658	.4207	.3658	.4024	.439	.439
23	.3658	.3292	.3658	.3658	.3658	.4207	.3658
24	.4024	.3292	.2926	.3292	.3292	.3292	.3292
Max	.439	.4572	.4572	.4024	.439	.4572	.4755
Min	.2195	.2195	.2195	.2561	.1829	.2378	.16
Avg	.2987	.2995	.2927	.3022	.2995	.3079	.3076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274113 / 33/11 KV KUMBHARI

Feeder No / Name : 206 / 11 KV KUMBHARI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1433		.1829	.2149	.2195	.3506
2	.1829	.1433	.1829	.1829	.1791	.1829	.4908
3	.1829	.1791	.2195	.1829	.1791	.1829	.4382
4	.1829	.2149	.2195	.2378	.2149	.1829	.5258
5	.2561	.2149	.2926	.2743	.2507	.2561	.7011
6	.3658	.2149	.3292	.2926	.3224	.3292	.8238
7	.3658	.2507	.3658	.2926	.3582	.3658	1.1919
8	.3292	.1791	.2561	.2743	.2865	.2926	1.4022
9	.2561	.1433	.2195	.2195	.2507	.2195	1.0867
10	.2195	.1791	.2378	.1829	.2149	.1829	.9816
11			.7011		.8413	.7011	.1463
12	.9816	1.2269	1.0517	1.0517	.9114	.964	.1463
13	1.1568	1.262	1.0517	.9816	1.0517	1.0517	.1463
14	1.1218	1.262	1.0692	.9465	1.1576	1.0517	.1463
15	1.1218	1.2269	1.1393	.9816	1.1568	1.134	.1463
16	.394	1.2269	1.1744	1.0166	1.1568	1.0867	.1463
17		1.1919	1.1744	1.0517	1.262	1.1218	
18		1.1218	1.0692	.9816	1.2269	1.0692	.1463
19	.1433	.2195	.1097	.2507	.2195	.2195	.2561
20	.1791	.2195	.2561	.2454	.2195	.2195	.2561
21	.1791	.2195	.2378	.2103	.2195	.1928	.2561
22	.1433	.1829	.1829	.2149	.2195	.2012	.2195
23	.1433	.1829	.1829	.2149	.2195	.1829	.2195
24	.1829	.1433	.1829	.1829	.2149	.2195	.1646
Max	1.1568	1.262	1.1744	1.0517	1.262	1.134	1.4022
Min	.1433	.1433	.1097	.1829	.1791	.1829	.1463
Avg	.3939	.5021	.5177	.4632	.5228	.4929	.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 201 / 11 KV BANKALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.1524	.2858	.2858	.1905	.4365
2	.2858	.1905	.1524	.2667	.2667	.1905	.442
3	.3048	.2477	.1905	.2858	.2286	.1905	.4572
4	.3429	.3429	.1905	.3048	.3048	.2286	.4572
5	.4763	.4382	.3429	.5335	.4191	.2858	.6249
6	.6287	.6287	.4572	.6287	.6287	.3429	.7316
7	.4954	.5525	.3429	.5144	.6478	.381	.9755
8	.3239	.3429	.2858	.3048	.362	.2858	1.0517
9	.2477	.2858	.2286	.3048	.2477	.2286	.9907
10	.1905	.2667	.1905	.2096	.2286	.1715	.8579
11	.8535	.703	.8025	.7074	.6481	.9145	.2096
12	.9633	.0229	.945	.9031	.9259	.9755	.1905
13	.9065	.9842	.8535	.873	.8333	.8429	.2286
14	.7876	.9374	.8078	.743	.7407	.7926	.2286
15	.7335	.6401	.7926	.6622	.6944	.7526	.1905
16	.8025	.8436	.8535	.8642	.6481	.9145	.1905
17	.8796	.9488	.8535	.9031	.7716	.884	.1905
18	.873	1.012	.7968	.8429	.9259	.884	.2286
19	.3429	.3048	.3048	.3429	.3429	.3429	.381
20	.4001	.4191	.4001	.4572	.4191	.4382	.4191
21	.381	.381	.4001	.4001	.3429	.3429	.362
22	.2667	.3429	.3429	.3429	.2858	.2667	.2096
23	.2667	.3048	.3048	.3239	.2667	.2096	.2286
24	.2667	.2667	.1905	.2858	.3048	.2286	.1715
Max	.9633	1.012	.945	.9031	.9259	.9755	1.0517
Min	.1905	.0229	.1524	.2096	.2286	.1715	.1715
Avg	.5111	.4848	.4659	.5121	.4904	.4702	.4356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274141 / 33/11 KV AHERWADI

Feeder No / Name : 202 / 11 KV AHERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.888	.7621	.7811	.5335	.8128	.6173	.4191
2	.9568	.823	.8333	.5792	.873	.7407	.4191
3	1.0364	.8951	.9217	.6554	1.0059	.8436	.4572
4	1.0822	.9877	1.0526	.7074	1.1279	.9488	.5144
5	1.1279	1.0494	1.2651	.8322	1.2498	1.2003	.6668
6	1.2323	1.1227	1.4403	.884	1.3441	1.4899	.743
7	1.3443	1.4403	1.5623	1.2193	1.6842	1.6194	.6859
8	1.4022	1.4969	1.406	1.3283	1.6091	1.5432	.6097
9	1.3413	1.4217	1.5339	1.5181	1.4784	1.4815	.4382
10	1.3094	1.0802	1.0936	1.448	1.3413	1.406	.381
11	.4382	.5144	.362	.3239	.381	.362	1.2037
12	.4191	.4763	.4191	.4001	.3429	.2096	1.4661
13	.4191	.4001	.4001	.381	.3048	.2286	1.4022
14	.4001	.381	.3429	.381	.2858	.3429	1.3847
15	.4191	.4001	.362	.381	.3239	.362	1.3094
16	.4382	.4001	.362	.362	.3429	.3239	1.448
17	.362	.4001	.381	.362	.2858	.3429	1.3904
18	.381	.4572	.4191	.381	.2286	.4001	1.4352
19	.7049	.6668	.5906	.5716	.5716	.6478	.6097
20	.5144	.6668	.6859	.7049	.6287	.6859	.6478
21	.5335	.5716	.6287	.6097	.5716	.6097	.5525
22	.4954	.5716	.4954	.5144	.5144	.5144	.5144
23	.5144	.5144	.4191	.4001	.4001	.4382	.4191
24	.4191	.4382	.4572	.381	.381	.4001	.4191
Max	1.4022	1.4969	1.5623	1.5181	1.6842	1.6194	1.4661
Min	.362	.381	.3429	.3239	.2286	.2096	.381
Avg	.7575	.7474	.7590	.6608	.7537	.7400	.8140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 201 / 11 KV AKOLE (M)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.0312	.0781	.0156	.0156	.0156	.3906
2	.0156	.0312	.0781	.0156	.0156	.0156	.3906
3	.0156	.0312	.0781	.0312	.0156	.0156	.3906
4	.0156	.0312	.0781	.0312	.0156	.0156	.3906
5	.0312	.0312	.0781	.0312	.0312	.0312	.4687
6	.0312	.0312	.0781	.0312	.0312	.0312	.4687
7	.0312	.0312	.0781	.0156	.0312	.0312	.6874
8	.0156	.0156	.0781	.0156	.0156	.0156	.7811
9	.0156	.0156	.0312	.0156	.0312	.0156	.7811
10	.0156	.0156	.0156	.0156	.0156	.0156	.7655
11	.7343	.703	.7499	.703	.5937	.6249	.0156
12	.7811	.8592	.8592	.8592	.6405	.7811	.0156
13	.8436	.8592	.828	.7968	.703	.7499	
14	.7811	.8592	.8124	.703	.7186	.7655	
15	.7343	.7811	.8124	.7343	.7499	.7811	
16	.7655	.8592	.7968	.8436	.7811	.828	
17	.828	.7811	.7811	.7343	.7968	.8436	.0156
18	.7968	.7811	.828	.7811	.7811	.7655	.0156
19	.0156	.0781	.0156	.0156	.0312	.0469	.0312
20	.0312	.0781	.0156	.0156	.0312	.0469	.0312
21	.0312	.0781	.0156	.0156	.0156	.0156	.0312
22	.0156	.0781	.0156	.0156	.0156	.0156	.0312
23	.0312	.0781	.0156	.0156	.0156	.0156	.0312
24	.0156	.0312	.0781	.0156	.0156	.0156	.0156
Max	.8436	.8592	.8592	.8592	.7968	.8436	.7811
Min	.0156	.0156	.0156	.0156	.0156	.0156	.0156
Avg	.2753	.2988	.3040	.2695	.2545	.2708	.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 202 / 11 KV KANDALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.6401	.4001	.3201	.3521	.3681	1.5623
2	.3841	.6081	.4001	.3201	.3521	.3681	1.6804
3	.3841	.4801	.4001	.4001	.3521	.3841	1.7764
4	.4161	.4801	.4801	.4481	.3841	.4161	1.9204
5	.4801	.5601	.6401	.4801	.4481	.4481	2.1605
6	.6722	.6401	.7202	.6874	.6241	.5601	2.3434
7	.6401	.7042	.7202	.6401	.7202	.6401	2.7183
8	.4801	.4481	.4801	.4801	.4801	.4641	
9	.3521	.3841	.4001	.3437	.3521	.3841	1.8404
10	.3521	.3201	.3041	.3361	.3361	.3681	2.2885
11	2.4486	2.3205	2.3685	2.5606	2.4006	2.4006	.3681
12	2.5606	2.6406	2.7206	3.0247	2.5926	2.8006	.3681
13	2.7366	2.7206	2.7206	2.8647	2.7686	2.7046	
14	2.8166	2.6406	2.6726	2.7686	2.6886	2.7206	
15	2.9127	2.6406	2.6726	2.8006	2.5286	2.6558	
16	2.8967	2.6406	2.7206	2.8967	2.6086	2.8121	
17	2.9127	2.7206	2.8166	2.6406	2.6886	2.8902	.4801
18	2.7366	2.5777	2.7206	2.6086	2.6246	2.7206	.4801
19	.5761	.5601	.6081	.5761	.5761	.5441	.6562
20	.6081	.6401	.5761	.6401	.6401	.6401	.6882
21	.5761	.5601	.5441	.5441	.5441	.5601	.6401
22	.5441	.4801	.4801	.4801	.4961	.4961	.5121
23	.6081	.4801	.4001	.4321	.4481	.4161	.4481
24	.4001	.7042	.4001	.3201	.3681	.3841	.3749
Max	2.9127	2.7206	2.8166	3.0247	2.7686	2.8902	2.7183
Min	.3521	.3201	.3041	.3201	.3361	.3681	.3681
Avg	1.2456	1.2330	1.2236	1.2339	1.1823	1.2144	1.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 203 / 11 KV GUNJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1717	1.0623	1.1717	1.1717	1.1717	1.2186	.3906
2	1.1717	1.1873	1.1717	1.1717	1.2498	1.3279	.3906
3	1.2498	1.2498	1.2498	1.2498		1.531	.3906
4	1.3279	1.531	1.4842	1.3279	1.3279	1.7497	.4687
5	1.4842	1.7966	1.5623	1.5623	1.5623	1.9685	.5468
6	1.5623	2.0309	1.6404	1.7185	1.8591	2.1872	.6249
7	2.3434	2.2497	2.2653	2.3434	2.3746	2.4684	
8	2.4371	2.4215		2.4996		2.6402	
9	2.4006	2.4059	2.2653	2.3434	2.2028	2.5777	.3593
10	2.2085	2.1091	2.0309	2.1872	2.0309	2.4996	.4218
11	.1718	.1562	.1562	.2187	.2031	.2343	2.3746
12	.1875	.1562	.1562	.2187	.1875	.25	2.7965
13	.1875	.1562	.1562	.1875	.1718	.25	
14	.1875	.1562	.1562	.2187	.1875	.25	
15	.2031	.1562		.2031	.2031	.25	
16	.2031	.1562		.2031	.2187	.25	
17	.2031	.2343	.2343	.1875	.2343	.25	2.7652
18	.25	.2343	.3125	.2187	.25	.25	2.9527
19	.3749	.3906	.4687	.3437	.3437	.4374	.3749
20	.4531	.6249	.4374	.4374	.4218	.4687	.6405
21	.4374	.3906	.3437	.3437	.3593	.4687	.5468
22	.4062	.2343	.3125	.3125	.2968	.4374	.4374
23	.2812	.1562	.3125	.2187	.2656	.4062	.3906
24	.25	.2031	.1562	.3125	.2187	.2343	.3749
Max	2.4371	2.4215	2.2653	2.4996	2.3746	2.6402	2.9527
Min	.1718	.1562	.1562	.1875	.1718	.2343	.3593
Avg	.8814	.8937	.8592	.8833	.7882	1.0252	.9582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274199 / 33/11 KV GUNJEGAON

Feeder No / Name : 204 / Ecosol Exp. Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)
11	.0248	
12	.0248	
13	.0248	
18	.0248	
23		.0248
Max	.0248	.0248
Min	.0248	.0248
Avg	.0248	.0248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 201 / 11 KV KANBAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2688	.2881	.3277	.2778	.3125	.2984	.1905
2	.2858	.2881	.3277	.3125	.3858	.3277	.1905
3	.2858	.2915	.3605	.3953	.3868	.3277	.1905
4	.381	.3201	.4096	.4744	.4369	.3647	.1905
5	.4744	.3887	.4049	.6009	.4816	.4191	.2286
6	.759	.4534	.4858	.7526	.7811	.5992	.2858
7	.8322	.8139	.7116	.7676	.7827	.7362	.3048
8	.7907	.9156	.8697	.7827	.7526	.8745	.2286
9	.7236	.788		.7526	.7676	.8029	.1524
10	.583	.7122	.6859	.7811	.6401	.8097	.1905
11	.0953	.1334	.1143	.1334	.0953	.1143	.6081
12		.1143	.1334	.1143	.0953	.1143	
13		.1143	.1334	.1334	.1143	.1143	
14		.1143	.1143	.1334	.1143	.1143	.6154
15	.1334	.1143	.1334	.1143	.1143	.1143	.6401
16	.1334	.1334	.1334	.1334	.1334	.1143	
17	.1334	.1334	.1524	.1334	.1334	.1334	.6401
18	.1143	.1524	.1905	.0762	.1334	.1524	.6722
19	.2667	.2667	.2286	.1905	.1334	.2286	.2667
20	.3048	.2858	.362	.2286	.0572	.2858	.2858
21	.2858	.3048	.3429	.2667	.3048	.2858	.2667
22	.2477	.2096	.2286	.2667	.2667	.2667	.2477
23	.2286	.1905	.1905	.2096	.2286	.2286	.1905
24	.1905	.1905	.1905	.1715	.1715	.1905	.1905
Max	.8322	.9156	.8697	.7827	.7827	.8745	.6722
Min	.0953	.1143	.1143	.0762	.0572	.1143	.1524
Avg	.3580	.3216	.3144	.3418	.3260	.3341	.3227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 202 / 11 KV TILLEHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4001	.4191	.4744	.3125	.3932	.2858
2	.4049	.4534	.4096	.4744	.4374	.421	.2858
3	.421	.4534	.4534	.7773	.4744	.426	.3429
4	.4858	.4858	.4534	.8097	.5937	.4915	.3429
5	.5121	.7682	.5535	.9831	.7907	.6478	.381
6	.9779	.9602	.8697	1.1389	1.0936	.9393	.4191
7	1.1633	1.2407	1.2186	1.1574	1.2811	1.3279	.4572
8	1.1619	1.2887	1.1873	1.1728	1.2651	1.2308	.3429
9	1.1336	1.2071	1.0494	1.0936	1.1385	1.2452	.2667
10	1.1203	.6952	.9568	.9804	1.0155	1.1174	.2286
11	.1524	.1524	.1715	.1334	.1715	.1715	.8539
12	.1715	.1524		.1524	.1905	.2096	.8697
13	.1715	.1715	.2096	.1334	.1905	.1905	.933
14	.1905	.1715	.2096	.1334	.2096	.2096	.8642
15	.1905	.1715	.1905	.1524	.2096	.2096	.8162
16	.1905	.1905	.2096	.1524	.2096	.1715	.8802
17	.1905	.2286	.2667	.1905	.2286	.1715	.9442
18	.2286	.2858	.3048	.1905	.2667	.1905	1.0402
19	.362	.4191	.3429	.4001	.381	.4001	.4001
20	.4191	.4191	.4191	.4191	.4572	.4191	.4191
21	.381	.4572	.381	.4191	.4191	.4001	.4191
22	.3239	.3429	.4001	.381	.3429	.381	.362
23	.2858	.3048	.2858	.2667	.3048	.2858	.362
24	.2667	.2667	.2667	.2667	.2477	.2667	.2667
Max	1.1633	1.2887	1.2186	1.1728	1.2811	1.3279	1.0402
Min	.1524	.1524	.1715	.1334	.1715	.1715	.2286
Avg	.4742	.4870	.4882	.5189	.5097	.4966	.5326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274202 / 33/11 KV INGALAGI

Feeder No / Name : 203 / 11 KV INGALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2286	.2477	.2477	.2667	.3239
2	.2667	.2667	.2286	.2477	.2477	.2667	.3563
3	.2667	.2667	.2286	.2667		.2667	.3563
4	.2858	.2667	.2667	.3048	.2667	.2667	.4049
5	.3048	.3048	.3048	.3429		.2858	.4744
6	.3429	.381	.4191	.381		.3429	.6325
7	.381	.362	.381	.2667	.4001	.381	.7116
8	.2858	.2477	.2858	.1715	.3429	.3048	.759
9	.1715	.1905	.2286	.2286	.2286	.2096	.7432
10	.1715	.1715	.1524	.1905	.1715	.1715	.6642
11	.6009	.6154	.5801	.5693	.5601	.5668	.1524
12	.8002	.6478	.6401	.6642	.6401	.7287	.1524
13	.8322	.6325	.6642	.6325	.6802	.7611	.1524
14	.8002	.6009	.6081	.6009	.3658	.6483	.1524
15	.7287	.5693	.6325	.6009	.5335	.6642	.1905
16	.6964	.6642	.6562	.6325	.5182	.6483	.1524
17	.6554	.6958	.6478	.68	.5624	.7116	.1715
18	.664	.7116	.5601	.6325	.6316	.6642	.1524
19	.3429	.3429	.2286	.362	.362	.381	.362
20	.4191	.381	.3429	.381	.4191	.4001	.362
21	.381	.381	.381	.4001	.381	.381	.4001
22	.3429	.3429	.3429	.3429	.3429	.3429	.381
23	.3048	.2858	.2667	.2667	.3048	.3048	.3239
24	.2858	.2667	.2667	.2477	.2477	.2667	.2858
Max	.8322	.7116	.6642	.68	.6802	.7611	.759
Min	.1715	.1715	.1524	.1715	.1715	.1715	.1524
Avg	.4416	.4109	.3976	.4026	.4026	.4263	.3674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 201 / 11 KV SANJWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0686	
8	.1029	.1029	.0686	.12	.0686	.1029	1.0059
10				.0857	.0114		
12		.9907			.9755		.0343
13			1.0669				
15				1.0212		.9907	
16	.945	.9145	.9755	.9145	.8383	.9907	
18	1.0059						
19		.0171					
20			.0686				
24	.0857	.0857	.0686	.1029	.1029	.1029	.6401
Max	1.0059	.9907	1.0669	1.0212	.9755	.9907	1.0059
Min	.0857	.0171	.0686	.0857	.0114	.0686	.0343
Avg	.5349	.4222	.4496	.4489	.3993	.4512	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 202 / 11 KV BANDALGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.9145						
6				.9602		.884	
8	.7926	.442	.823	.8078	.6554	.7926	.1715
9			.8383				
10					.8383		
11							.7621
15					.0171		
16		.0171	.0857	.0686	.1372	.061	
23	.0686						
24	.5792	.0343	.0686	.4877	.503	.4877	.0857
Max	.9145	.442	.8383	.9602	.8383	.884	.7621
Min	.0686	.0171	.0686	.0686	.0171	.061	.0857
Avg	.5887	.1645	.4539	.5811	.4302	.5563	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR RURAL DIVISION[533]

SOLAPUR R-II S/DN.[095] BU 1333

Substation No/ Name :- 274219 / 33/11kV AURAD

Feeder No / Name : 203 / 11 KV TEMPLE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3201	.2896	.2896				
7				.3201		.3201	.4115
8	.2439	.2743	.2591	.2896	.1524	.3201	.3429
10							.2058
11	.1543						
12					.1543		
14			.1372	.1715			
16	.1677	.12	.1715	.2058	.2058	.2286	
24	.1829	.2401	.1715	.1981	.2286	.2134	.2058
Max	.3201	.2896	.2896	.3201	.2286	.3201	.4115
Min	.1543	.12	.1372	.1715	.1524	.2134	.2058
Avg	.2138	.231	.2058	.2370	.1853	.2706	.2915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 201 / 11KV WATER WORKS SOLAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893		1.5402	1.5364	1.5524	1.5893	1.6632
2	1.4998		1.5043	1.4632	1.4784	1.5154	1.5893
3	1.4998		1.4883	1.4266	1.4415	1.4784	1.5524
4	1.4449		1.4352	1.39	1.4045	1.4415	1.4937
5	1.46		1.4506	1.3676	1.4415	1.5524	1.531
6	1.5524		1.5581	1.386	1.5708	1.6975	1.643
7			1.6632	1.3306	1.5154	1.6409	1.6057
8			1.3717	1.4415	1.4083	1.3676	1.4266
9	1.3169	1.4118	1.3073	1.39	1.3756	1.4449	
10	1.3432	1.448	1.382	1.4864	1.5043	1.6095	
11	1.4815	1.6461	1.5384	1.5729	1.701	1.7187	
12	1.5912	1.7375	1.5912	1.5708	1.7375	1.7924	
13	1.6827	1.6644	1.6817	1.5364	1.7372	1.7926	
14	1.6263	1.6448	1.6095	1.5708	1.7193	1.7375	
15	1.7187	1.6817	1.6461	1.6095	1.7556	1.8665	
16	1.7187	1.6827	1.7002	1.6632	1.7741	1.829	
17	1.8111	1.7558	1.7375	1.6644	1.7737	1.848	1.8111
18	1.7737	1.8107	1.8099	1.6832	1.7737	1.922	1.848
19	2.2386	2.2131	2.3211	2.0683	2.2786	2.4356	2.3891
20	2.1132	2.0237	2.2262	2.0058	2.2081	2.3102	2.2986
21	1.8983	1.9909	1.9547	1.9879	1.9753	2.0814	2.0452
22	1.8642	1.8656	1.8656	1.9163	1.957	1.9753	1.9185
23		1.7375	1.8111	1.8107	1.885	1.9204	1.9022
24	1.7002		1.5565	1.6461	1.7002	1.7187	1.7556
Max	2.2386	2.2131	2.3211	2.0683	2.2786	2.4356	2.3891
Min	1.3169	1.4118	1.3073	1.3306	1.3756	1.3676	1.4266
Avg	1.6631	1.7543	1.6563	1.6052	1.6945	1.7619	1.7796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 202 / 11 KV DAV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499		.7316	.905	.9412	.9412	.9412
2	.7577		.724	.8688	.905	.905	.9231
3	.7392		.6878	.8507	.8688	.8869	.905
4	.6767		.695	.8238	.8417	.8413	.8688
5	.6767		.7682	.8417	.8238	.8413	.8688
6	.7207		.7762	.9134	.9134	.9511	.9955
7	.7842		.8402	.9313	.8596	.9145	.8688
8			.8402	.8859	.7796	.7796	.7712
9	.6447	.6687	.7499	.8238	.6661	.6836	
10	.5316	.7122	.7087	.7716	.6859	.7442	
11	.5784	.7545	.6984	.7796	.7108	.7712	
12	.5609	.6447	.6805	.7362	.7011	.7282	
13	.5493	.6556	.724	.7455	.7362	.7802	
14	.543	.6268	.6733	.691	.7343	.7265	
15	.6401	.695	.7522	.7421	.7973	.788	
16	.6154	.724	.6626	.7343	.8059	.9231	
17	.6447	.7122	.7087	.7712	.823	.8063	.7362
18	.6935	.7202	.7537	.7888	.823	.7975	.7282
19	.9465	1.0288	1.046	1.0513	1.1022	1.1145	1.0631
20	.9036	1.0576		1.1269	1.1096	1.182	1.0749
21	.9134	1.0387	1.0454	1.1443	1.1043	1.1517	1.1218
22	.905	.985	1.0745	1.0402	1.0517	1.1462	1.0985
23		.9955	1.0317	1.0387	1.0679	1.086	1.0745
24	.7865		.7682	.9593	.9774	.9955	.9955
Max	.9465	1.0576	1.0745	1.1443	1.1096	1.182	1.1218
Min	.5316	.6268	.6626	.691	.6661	.6836	.7282
Avg	.7074	.8013	.7887	.8736	.8679	.8952	.9397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 203 / 11 KV BHAVANI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316		.6697	.7023	.6653		.7392
2			.6401	.6653	.6283	.7392	.6584
3	.6838		.6401	.6468	.5914	.7023	.6584
4	.6838		.5914	.6219	.5914	.6653	.6401
5	.6401		.5914	.6401	.5914	.7023	.6401
6	.7095		.6401	.695	.6653	.7577	.7316
7	.7095		.6401		.5914	.7023	.695
8			.6516	.6335	.695	.6401	.5853
9	.6268	.6268	.6201	.7522	.6626	.631	
10	.6379	.6024	.6762	.7973	.7362	.6805	
11	.7108	.6588	.7537	.7865	.7343	.7602	
12	.1214	.7628	.788	.7964	.7701	.7343	
13	.788	.7701	.7602	.8059		.7796	
14	.7783	.7133	.7164	.7442	.7316	.7682	
15	.7783	.7421	.7783	.8059		.7964	
16	.7973	.7796	.724	.8417	.7964	.8059	
17	.8238	.7888	.7973	.7783	.8682	.8596	.7207
18	.8495	.8413	.815	.8413	.8682	.8764	.6653
19	1.0749	1.0166	1.0749	.9945	1.0288	1.1096	1.0277
20	1.0692	1.1043	1.0454	.9568	1.0099	1.1163	1.0277
21	.9568		.9492	.9214	.985	.9492	.9671
22	.8688		.8688	.9568	.9231	.9774	.9134
23			.8131	.8413	.8686	.8779	.8596
24	.7316		.6697	.7392	.7023	.7577	.7762
Max	1.0749	1.1043	1.0749	.9945	1.0288	1.1163	1.0277
Min	.1214	.6024	.5914	.6219	.5914	.631	.5853
Avg	.7510	.7839	.7465	.7811	.7593	.7995	.7691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 204 / 11 KV SAMACHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557		.4508	.5083	.4961	.5083	.5316
2	.4508		.4458		.4607	.4835	.4961
3	.4161		.3944	.4557	.4607	.4656	.4961
4	.4161		.39	.4382	.4477	.4656	.4835
5	.4207		.4239	.4382	.4477	.4706	.4835
6	.4557		.4191	.4382	.4477	.4525	.4656
7	.4973		.39	.4207	.4298	.4706	.4835
8			.39	.4031	.443	.4252	.4557
9	.4382	.4382	.4287	.4161	.4784	.443	
10	.4854	.5434		.4557	.5434	.5731	
11	.6516	.691	.6556	.591	.6447	.7133	
12	.7059	.7619	.6836	.691	.7059	.7964	
13	.7164	.7421	.7343	.7343	.7499	.8688	
14	.724	.7522	.7421	.6878	.695	.8507	
15	.7316	.724	.7316	.6767	.7577	.8238	
16	.7577	.691	.7577	.6767	.7207	.8059	
17	.7316	.724	.7682	.7059	.7059	.8048	.4024
18	.823	.8048	.8413	.6878	.7059	.8962	.6219
19	1.0631	1.0791	1.0745	.8764	.964	1.1163	.5731
20	.9922	.9671	1.0208	.815	.9214	1.0387	.5373
21	.7202	.8688	.7362	.7973	.7087	.7186	.3856
22	.6001	.7282	.6135	.7973	.631	.6485	.3294
23		.5548	.5784	.5609	.5959	.6379	.631
24	.4908		.4854	.5258	.5316	.5258	.5493
Max	1.0631	1.0791	1.0745	.8764	.964	1.1163	.631
Min	.4161	.4382	.39	.4031	.4298	.4252	.3294
Avg	.6247	.7380	.6155	.5999	.6122	.6668	.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 205 / 11 KV JODHBAVI PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534		.2507	.2801	.2587	.2614	.2587
2	.2561		.2353	.2614	.2402	.2614	.2587
3	.2195		.2353	.2561	.2378	.2195	.2587
4	.2241		.2195	.2378	.2195	.2195	.2402
5	.2241		.2195	.2534	.2195	.2195	.2402
6	.2587		.2686	.2534	.2378	.2743	.2587
7	.2957		.2353	.2534	.2012	.2195	.2402
8			.2195	.2481	.2427	.2374	.2303
9	.2374	.2515	.2774	.2601	.2915	.2458	
10	.2214	.2713	.2778	.2818	.3222	.3077	
11	.2561	.2721	.2881	.3005	.3258	.3481	
12	.2721	.2915	.3315	.2984	.3521	.3441	
13	.2753	.2881	.3113	.2622	.3315	.3353	
14	.2601	.2683	.3041	.2743	.2984	.2949	
15	.1907	.2883	.2846	.3155	.3277	.3149	
16	.2652	.3185	.3277	.3018	.3401	.3441	
17	.2743	.3005	.3437	.3077	.3361	.2984	.2378
18	.2785	.2622	.3113	.2561	.3361	.3361	.2481
19	.3978	.3856	.3932	.3768	.4111	.4096	.3429
20	.3601	.3688	.373	.3391	.3944	.4115	.3506
21	.3429	.3391	.3294	.3601	.3721	.3641	.3506
22	.3366	.2915	.3224	.3601	.3801	.3898	.3544
23		.298	.3109	.3292	.3475	.3658	.3658
24	.2896		.2507	.2987	.2772	.2987	.3142
Max	.3978	.3856	.3932	.3768	.4111	.4115	.3658
Min	.1907	.2515	.2195	.2378	.2012	.2195	.2303
Avg	.2723	.2997	.2884	.2903	.3042	.3051	.2844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274008 / 33/11 KV Water Works

Feeder No / Name : 207 / 11 KV PUMP HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142		.3086	.2926	.3361	.3109	.3326
2	.3292		.298	.2926	.3361	.3109	.3326
3	.3292		.298	.2926	.3361	.3109	.3326
4	.3326		.298	.2926	.3361	.3109	.3326
5	.3142		.3366	.2926	.3361	.3142	.3326
6	.3109		.3366	.3109	.3547	.3326	.3326
7	.3326		.298	.3109	.2241	.3142	.3326
8			.2774	.2896	.0617	.3142	.3326
9	.2172	.3086	.2947	.3077	.1097	.3109	
10	.2149	.3086	.3109	.2926	.1404	.3142	
11	.0732	.3294	.3292	.3109	.3109	.0566	
12	.298	.3294	.3086	.3142	.3109	.3292	
13	.0532	.3258	.3294	.3109	.3142	.3511	
14	.056	.3258	.2915	.3326	.3109	.0088	
15	.0686	.3294	.3121	.2987	.3109	.3439	
16	.298	.3326	.3109	.1006	.2926	.3475	
17	.3155	.3142	.2926	.3292	.2926	.3292	.2926
18	.298	.3326	.2896	.3326	.2896	.3292	.2896
19	.3121	.3142	.2006	.3326	.2926	.3326	.2896
20	.3086	.3326	.3109	.3326	.2926	.3326	.2896
21	.3258	.3326	.3109	.3326	.2926	.3326	.2896
22	.3294	.3109	.3109	.3326	.2926	.3326	.2896
23			.3109	.3326	.3109	.3326	.2926
24	.3142		.3086	.3109	.3361	.2926	.3326
Max	.3326	.3326	.3366	.3326	.3547	.3511	.3326
Min	.0532	.3086	.2006	.1006	.0617	.0088	.2896
Avg	.2612	.3233	.3031	.3033	.2842	.2998	.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 201 / 11 KV SAKHAR PETH FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.2308	1.2127	1.2357	1.2536	1.2894	1.3575
2	1.1765	1.1765	1.1584	1.1765	1.2127	1.267	1.3169
3	1.0745	1.1222	1.086	1.1222	1.1584	1.2308	1.2803
4	.985	1.1041	1.0317	1.0791	1.134	1.2071	1.2308
5	1.086	1.1403	1.0498	1.0608	1.0974	1.1523	1.1946
6	1.267	1.1946	1.1222	1.1273	1.1827	1.2197	1.2752
7	1.1765	1.1643	1.1088	1.0903	1.2012	1.2012	1.307
8	1.1403	1.1888	1.0974		1.1523	1.1706	1.2071
9	1.2127	1.1946	1.2127	1.2254	1.2851	1.2127	1.3352
10	1.2715	1.379	1.3289	1.3169	1.4299	1.4148	1.5223
11	1.4842	1.4815	1.5746	1.4815	1.6832	1.6289	1.6289
12	1.5581	1.647	1.6108	1.4815	1.7013	1.7013	1.6832
13	1.576	1.6651	1.5203	1.5203	1.7194	1.7013	1.647
14	1.4864	1.4998	1.5746	1.4661	1.5384	1.6289	1.6827
15	1.5181	1.4449	1.5364	1.386	1.5912	1.6461	1.5912
16	1.5546	1.4998	1.5912	1.4415	1.6461	1.6095	1.6632
17	1.5181	1.5023	1.6289	1.4083	1.647	1.7193	1.6078
18		1.5043	1.6655	1.4661	1.7558	1.8099	1.6827
19		2.1384	2.191	1.9547	2.2786	2.4177	2.1085
20		2.0683	2.1794	1.8755	2.1971	2.3034	2.1085
21		1.7718	1.825	1.7187	1.9342	2.0416	1.8959
22		1.5939	1.5947	1.5947	1.7375	1.7909	1.6834
23	1.5023	1.4685	1.4685	1.4685	1.5402	1.5746	1.5746
24	1.3575	1.3213	1.3032	1.2894	1.3073	1.3611	1.4118
Max	1.576	2.1384	2.191	1.9547	2.2786	2.4177	2.1085
Min	.985	1.1041	1.0317	1.0608	1.0974	1.1523	1.1946
Avg	1.3270	1.4376	1.4447	1.3907	1.5160	1.5542	1.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (B) S/DN.[087] BU 4087

Substation No/ Name :- 274133 / 33/11KV RAJENDRA CHOWK S/STN

Feeder No / Name : 202 / 11 KV NETAJI FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	.5853	.5792	.5194	.5373	.5552	.5611
2	.5068	.543	.5014	.5068	.5249	.543	.5487
3	.4656	.5068	.4656	.4887	.5068	.5249	.5304
4	.4477	.5014	.4656	.4755	.4938	.5121	.5175
5	.5068	.5014	.4887	.4572	.4755	.4938	.499
6	.5973	.543	.5249	.4805	.499		.5415
7	.5792	.5304	.4854	.462	.5175	.5359	.5415
8	.5611	.567	.5175	.5487	.5487	.567	.5544
9	.5973	.5373	.5068	.5304	.5249	.5792	.5359
10	.6268	.5847	.5249	.5792	.6036	.6201	.543
11	.6626	.6805	.6447	.6335	.6516	.6516	.6036
12	.6733	.6984	.6516	.6447	.6584	.7265	.5853
13	.6556	.6984	.6697	.6626	.695	.724	.6099
14	.6219	.6036	.6584	.6584	.6767	.695	.6283
15	.6767	.6219	.6335	.6219	.6584	.695	.6468
16	.6584	.6335	.6878	.6584	.6878	.724	.6283
17	.695	.6697	.6805	.6335	.6878	.695	.6283
18		.6805	.7265	.6516		.7087	.6401
19		.929	.964	.8507	.964	.985	.8682
20		.8764	.8682	.7888	.9036	.9745	.8505
21		.7442	.7796	.7265	.8596	.8417	.7973
22		.6984	.7087	.7265	.8145	.8059	.7522
23	.6878	.6878	.6447	.6268	.6626	.7059	.7059
24	.5792	.6401	.6335	.5552	.5731	.591	.5973
Max	.695	.929	.964	.8507	.964	.985	.8682
Min	.4477	.5014	.4656	.4572	.4755	.4938	.499
Avg	.596	.6359	.6255	.6036	.6402	.6720	.6215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 201 / 11 KV RAMLAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4632	1.4083	1.4998	1.5181		1.6827
2		1.39	1.3717	1.4266	1.4632		
3		1.3352	1.3169	1.39	1.39		
4		1.3717	1.3352	1.3169	1.4266		
5		1.3717	1.3717	1.3352	1.4632		
6		1.4632	1.3717	1.4449	1.4632		
7		1.4632	1.3717		1.4632		
8		1.2803	1.2254	1.4449	1.5181		
9			1.4266	1.4266	1.5729	1.7924	1.5729
10			1.5546	1.6095	1.8107	1.7924	1.7741
11			1.701	1.6461	1.9936	1.9753	1.829
12			.7133		2.0851	2.0851	1.8839
13			.7133		2.0668	2.1216	1.957
14			2.0302		2.0302	2.1399	1.957
15			1.8839		2.0668	2.2131	2.0302
16			1.7924		2.1399	2.2131	2.0485
17	1.9936	1.8656	1.7924	1.4998	2.0302	2.0851	1.9387
18	1.9022	1.9204	1.6827	1.5546	2.0485	2.1582	2.0119
19	2.3045	2.4143	2.2497	2.0119	2.5057	2.5972	2.4143
20	2.2497		2.1582	1.9753	2.4143		
21	2.0485		1.9204	1.9387	2.1399	2.3777	
22	1.957		1.8839	1.8473	2.0302	2.0485	
23			1.7741	1.7558	1.8473	2.0485	
24		1.5912	1.5181	1.6095	1.6461	1.7193	1.8107
Max	2.3045	2.4143	2.2497	2.0119	2.5057	2.5972	2.4143
Min	1.9022	1.2803	.7133	1.3169	1.39	1.7193	1.5729
Avg	2.0759	1.5775	1.5653	1.5963	1.8389	2.0912	1.9162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 204 / 11 KV BAPUJI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9745	.9745	.9922	1.0277		1.0277
2		.9568	.9568	.9745	.9922		
3		.9214	.9214	.9568	.9745		
4		.8859	.9391	.9391	.9214		
5		.8859	.9745	.9745	.9745		
6		.9391	1.0631	.9745	1.0631		
7		.9568	1.1163	.9214	1.2226		
8		.9568	1.0985	.9568	1.134		
9			1.0631	.9922	1.1517	.9568	1.0631
10			.8505	.9391	1.0631	.9391	.9745
11			.7796	.9922	.9568	.9214	.9391
12			.8328		1.0099	.9922	.8682
13			.9745		1.0808	1.0454	.9391
14			.9568		1.0099	1.0099	.9391
15			.9745		1.0099	1.0277	.9568
16			.9568		.9922	1.0099	.9568
17	.9214	.8505	.9214	.9568	.9036	.9568	.9568
18	.9745	.9391	1.0277	1.0099	1.0277	1.0631	.9391
19	1.4706	1.3643	1.4706	1.4529	1.5061	1.5061	1.2934
20	1.4706		1.4706	1.4175	1.5415	1.4883	
21	1.3998		1.3998	1.382	1.4175	1.4706	
22	1.3289		1.3112	1.2757		1.382	
23			1.2226	1.2226	1.2757	1.2934	
24		1.0808	1.0454	1.0808	1.0808	1.1163	1.1163
Max	1.4706	1.3643	1.4706	1.4529	1.5415	1.5061	1.2934
Min	.9214	.8505	.7796	.9214	.9036	.9214	.8682
Avg	1.2610	.9760	1.0543	1.0743	1.1016	1.1362	.9977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 205 / 11 KV JAGDAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4632	1.3717	1.2803	1.3535		1.3169
2		1.2986	1.3717	1.3535	1.3169		
3		1.262	1.3717	1.1888	1.4266		
4		1.2803	1.3717	1.2071	1.4632		
5		1.3717	1.3717	1.3352	1.4632		
6		1.39	1.39	1.5364	1.5364		
7		1.4083	1.3169	1.5181	1.5729		
8		1.3535	1.4083	1.4815	1.5546		
9			1.262	1.4449	1.3717	1.3717	1.2803
10			1.0608	1.1888	1.2803	1.3352	1.3717
11			1.134	1.134	1.3352	1.3352	1.2071
12			1.2071		1.262	1.4083	1.2986
13			1.2803		1.262	1.4083	1.2803
14			1.2803		1.262	1.4815	1.3352
15			1.262		1.2986	1.262	1.39
16			1.1888		1.2254	1.4083	1.2071
17	1.2071	1.4083	1.1888	1.2254	1.1888	1.39	1.2254
18	1.2437	1.4083	1.2803	1.39	1.2803	1.5181	1.2437
19	1.7741	1.9204	1.7375	1.7741	1.6644	1.9022	1.6644
20	1.7558		1.829	1.829	1.6827	1.9204	
21	1.6827		1.8839	1.8107	1.7741	1.9753	
22	1.6461		1.7741	1.7741	1.8473	1.8656	
23			1.6461	1.6644	1.7558	1.7924	
24		1.5546	1.4632	1.4998	1.4266	1.4815	1.3717
Max	1.7741	1.9204	1.8839	1.829	1.8473	1.9753	1.6644
Min	1.2071	1.262	1.0608	1.134	1.1888	1.262	1.2071
Avg	1.5516	1.4266	1.3938	1.4545	1.4419	1.5535	1.3225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 206 / 11 KV DAK BUNGLOW
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8779	.8048	.8413	.905		.9412
2		.8413	.8048	.8596	.8507		
3		.8048	.8048	.823	.7964		
4		.8048	.823	.8048	.7964		
5		.8413	.823	.7865	.8688		
6		.8779	.8596	.8048	.905		
7		.9145	.8596	.823	.8326		
8		.8413	.8962	.823	.8145		
9			.8596	.8326	.9231	.9955	1.0679
10			.9511	.7602	.9955	1.0317	1.0679
11			.8962	1.9004	1.1041	1.1403	1.1403
12			.9145	1.9547	1.1222	1.1041	1.1041
13			.9694	2.0814	1.1403	1.2489	1.1222
14			.9877	1.9909	1.1222	1.1222	1.1222
15			1.0059	1.8642	1.1041	1.1946	1.1946
16			1.0425	2.0814	1.2308	1.267	1.2489
17	1.1706	1.1157	1.0242	2.1176	1.1888	1.2489	1.1946
18	1.1157	1.1157	1.1157	2.1538	1.2308	1.1584	1.2127
19	1.2986	1.2071	1.2803	2.6244	1.3756	1.4118	1.3937
20	1.262		1.262	1.1946	1.4299		
21	1.1706		1.2437	1.1403	1.3032	1.3756	
22	1.1157		1.1157	1.1222	1.1946	1.2308	
23			1.0608	1.0498	1.1222	1.1403	
24		.9328	.8779	.9511	.9593	1.0136	.9955
Max	1.2986	1.2071	1.2803	2.6244	1.4299	1.4118	1.3937
Min	1.1157	.8048	.8048	.7602	.7964	.9955	.9412
Avg	1.1889	.9313	.9701	1.3494	1.0548	1.1789	1.1389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274019 / 33/11 KV CIVIL

Feeder No / Name : 207 / 11 KV SHIDDHESHWAR PETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.2896	.2715	.3077		.3258
2		.2896	.2715	.2896	.3077		
3		.2715	.2715	.2715	.3077		
4		.2534	.2715	.2715	.3077		
5		.2172	.2715	.2534	.3258		
6		.1991	.3258	.2715	.3439		
7		.1991	.3439	.2896	.3077		
8		.2715	.362	.2896	.3077		
9			.3439	.3258	.3258	.362	.3439
10			.3801	.3439	.362	.362	.3982
11			.362	.362	.3982	.3801	.3982
12			.362		.3982	.362	.4163
13			.3982		.3801	.4163	.3982
14			.362		.4163	.4163	
15			.3801		.4163	.4163	.4163
16			.3801		.3982	.4163	.3801
17	.4344	.362	.362	.3077	.4163	.4163	.4163
18	.3801	.362	.362	.3439	.4163	.4344	.4163
19	.4163	.3982	.3982	.3801	.4706	.4706	.4525
20	.4163		.3801	.3801	.4344	.4344	
21	.3801		.362	.362	.3982	.3982	
22	.362		.362	.362	.4163	.3801	
23			.3439	.3439	.362	.3801	
24		.3258	.3258	.3258	.3439	.3439	.362
Max	.4344	.3982	.3982	.3801	.4706	.4706	.4525
Min	.362	.1991	.2715	.2534	.3077	.3439	.3258
Avg	.3982	.2866	.3447	.3182	.3695	.3993	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 201 / 11 KV Limyewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	1.0136	.9877	1.0425	1.0317	1.086	1.1523
2	1.0242	.9694	.9511	.9877	.9955	1.0679	1.1157
3	1.0059	.9511	.9145	.9877	.9774	1.0498	1.1088
4	1.0059	.9511	.9328	.9877	.9955	1.0136	1.1088
5	1.0791	1.0425	.9979	1.0349	1.1041	1.0136	1.1763
6	1.2382	1.2382	1.1643	1.1458	1.2851	1.2489	1.2883
7	1.2382	1.2936	1.2696	1.251	1.2851	1.267	1.3491
8	1.1389	1.1389	1.2696	1.2323	1.1584	1.1222	1.2197
9	.9877	.9522	1.0456	1.0456	.9593	.9795	1.0791
10	.8048	.8488	.8962	1.0242	.8326	.8501	1.0136
11	.695	.7682	.7421	.9877	.7964	.7682	.9231
12	.6878	.7316	.7499	.9694	.7783	.8871	.9134
13	.6154	.823	.7499	.9774	.7783	.9145	.8145
14	.8688	.7602	.9694	.9511	.9145	.9877	.9593
15	.7964	.8326	.9511	.9328	1.0059	.9979	1.1041
16	.7602	.823	.8596	.9694	1.0059	1.0059	1.0974
17	.9955	.8596	.8413	.9955	.8596	1.0164	.9412
18	.9955	.924	1.0242	1.0029	.9877	.961	1.0136
19	1.3937	1.3676	1.4784	1.3321	1.3643	1.4784	1.3937
20	1.3466		1.386	1.3998	1.3969	1.5524	1.3937
21	1.3289	1.386	1.3676	1.3969	1.4118	1.4415	1.3937
22	1.258	1.3352	1.3306	1.3575	1.3394	1.4415	1.3937
23	1.2127	1.1888	1.2071	1.2127	1.2308	1.3121	1.2489
24	1.0679	1.0317	1.0059	1.0791	1.086	1.1222	1.2012
Max	1.3937	1.386	1.4784	1.3998	1.4118	1.5524	1.3937
Min	.6154	.7316	.7421	.9328	.7783	.7682	.8145
Avg	1.0240	1.0100	1.0455	1.0960	1.0659	1.1077	1.1418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 202 / 11 KV Modi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1403	1.0974	1.1157	1.1827	1.1403	1.2012	1.1888
2	1.086	1.0791	1.0608	1.1273	1.086	1.1643	1.1888
3	1.0679	1.0425	1.0242	1.0719	1.0679	1.1458	1.1203
4	1.0679	1.0425	1.0425	1.0903	1.0498	1.1458	1.1203
5	1.0974	1.0719	1.0534	1.1273	1.1222	1.1458	1.2012
6	1.2437	1.1827	1.1827	1.2197	1.2308	1.2197	1.2936
7	1.1643	1.1088	1.1016	1.1763	1.1584	1.2197	1.2012
8	1.1273	1.1203	1.1016	1.251	1.1222	1.1458	1.1088
9	1.0498	.9877	1.0456	1.1389	.9955	1.0791	1.1403
10	1.0136	.9877	1.0498	1.0498	1.0136	1.0808	1.1403
11	1.1946	.9795	1.0425	1.0534	1.1157	1.1157	1.1946
12	1.2127	1.1157	1.0903	1.2803	1.1403	1.1765	1.2489
13	1.1765	1.2127	1.1273	1.2803	1.2127	1.382	1.267
14	1.267	1.2803	1.2567	1.2803	1.2936	1.4118	1.2752
15	1.3169		1.2567	1.262	1.3443	1.4998	1.3121
16	1.3352	1.3676	1.3121	1.2803	1.4003	1.5364	1.2936
17	1.3717	1.386	1.2936	1.2803	1.307	1.4784	1.2936
18	1.3535	1.4937	1.386	1.3535	1.4003	1.5708	1.3121
19	1.8107	1.9404	1.848	1.7372	1.7013	2.0328	1.7375
20	1.829	1.848	1.7556	1.7372	1.8446	2.0328	1.7194
21	1.7375	1.885	1.6632	1.7194	1.7918	1.848	1.7556
22	1.4449	1.4784	1.5708	1.7194	1.5729	1.6632	1.5729
23	1.3352	1.3717	1.3306	1.3937	1.3717	1.4784	1.4449
24	1.1584	1.1523	1.1523	1.2012	1.2851	1.3121	1.2936
Max	1.829	1.9404	1.848	1.7372	1.8446	2.0328	1.7556
Min	1.0136	.9795	1.0242	1.0498	.9955	1.0791	1.1088
Avg	1.2751	1.2710	1.2443	1.2922	1.2820	1.3786	1.3094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 203 / 11 KV Mahalaxmi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.7973	.7701	.7964	.8059	.8764	.8764
2	.7701	.7619	.7164	.7421	.7343	.8413	.8764
3	.7701	.7442	.7164	.724	.7343	.7888	.7973
4	.7343	.7087	.6626	.724	.7343	.7888	.8145
5	.7522	.7522	.7602	.7421	.7522	.8063	.905
6	.8775	.8596	.8326	.7602	.8417	.8238	.905
7	.985	.9671	.8688	.8145	.9671	.9114	.9955
8	.9412	.8596	.905	.8869	.9671	.8939	.905
9	.823	.8059	.8326	.8326	.8238	.7888	.7888
10	.7202	.7202	.7545	.7373	.8417	.7042	.7459
11	.6001	.6687	.6516	.7186	.7522	.6762	.7545
12	.6687	.6516	.6241	.7362	.6805	.7108	.7042
13	.6687	.6344	.6661	.7282	.7164	.7186	.7202
14	.6859	.6687	.7011	.7537	.7619	.7712	.7712
15	.6687	.6485	.691	.788	.7796	.815	.815
16	.6516	.6556	.7762	.788	.7164	.7973	.7628
17	.6859	.7265	.8316	.7537	.7701	.7888	.7265
18	.7202	.7087	.7316	.7628	.7545	.7716	.7455
19	.9259	.9955	.9145	.9536	.9945	.964	.9362
20	.9536	1.0059	.9145	.9991	.9991	1.0517	.9816
21	.9536	1.0059	.9955	1.0166	1.0277	1.0517	1.0341
22	.964	.924	.905	1.0277	1.0745	1.0517	1.0277
23	.9214	.9134	.9593	.9922	1.0208	1.0517	1.094
24	.8417	.8328	.8059	.8688	.8954	.9465	.964
Max	.985	1.0059	.9955	1.0277	1.0745	1.0517	1.094
Min	.6001	.6344	.6241	.7186	.6805	.6762	.7042
Avg	.7961	.7924	.7911	.8186	.8394	.8496	.8603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 204 / 11 KV RAILWAY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2829	.2641	.2641	.2829	.3018	.2829
2	.2641	.2829	.2641	.2829	.2641	.2829	.3018
3	.2641	.2641	.2641	.2829	.2641	.3018	.3018
4	.2641	.2829	.2641	.2641	.2829	.3206	.3206
5	.2641	.2641	.2641	.2641	.2829	.3018	.3206
6	.2829	.2641	.2641	.3018	.2829	.2829	.3395
7	.2641	.2829	.2641	.2452	.2452	.3206	.2829
8	.2641	.2452	.2641	.2829	.3206	.3018	.2829
9	.2641	.2829	.2641	.2829	.3584	.3961	.3961
10	.3772	.2829	.2641	.3018	.4527	.4527	.4715
11	.415	.4527	.415	.3584	.4904	.4715	.4715
12	.4338	.415	.3772	.3584	.4904	.4904	.4527
13	.3961	.415	.3584	.3018	.4715	.4527	.4715
14	.3772	.3772	.3206	.3018	.4715		.4904
15	.415	.4527	.3395	.3206	.4715	.4338	.4904
16	.4338	.4715	.3772	.3018	.4904	.4904	.4527
17	.415	.415	.3772	.3206	.4527	.4715	.4715
18	.3772	.3772	.3772	.3018	.415	.4338	.4338
19	.415	.3772	.3772	.3584	.415	.3961	.3961
20	.3584	.3772	.3772	.3584	.3961	.3772	.3772
21	.3772	.3772	.3772	.3584	.3772	.3772	.3395
22	.3584	.3772	.3772	.3584	.3584	.3772	.3395
23	.3206	.3018	.3395	.3206	.3206	.2829	.3018
24	.2829	.3018	.2641	.2641	.3018	.3018	.2829
Max	.4338	.4715	.415	.3584	.4904	.4904	.4904
Min	.2452	.2452	.2641	.2452	.2452	.2829	.2829
Avg	.3387	.3427	.3207	.3065	.3733	.3748	.3780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274095 / 33/11KV ADITYA NAGAR

Feeder No / Name : 205 / 11KV GANGA EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0189	.0189	.0189	.0189	.0377
2	.0189	.0189	.0189	.0189	.0189	.0189	.0189
3	.0377	.0189	.0189	.0189	.0189	.0189	.0189
4	.0189	.0189	.0189	.0189	.0189	.0189	.0189
5	.0189	.0189	.0377	.0189	.0189	.0189	.0377
6	.0189	.0377	.0189	.0189	.0189	.0189	.0377
7	.0189	.0189	.0189	.0189	.0189	.0377	.0377
8	.0566	.0377	.0189	.0189	.0189	.0377	.0377
9	.0189	.0189	.0377	.0377	.0189	.0189	.0377
10	.0189	.0189	.0189	.0377	.0377	.0377	.0189
11	.0189		.0189	.0189	.0566	.0189	.0566
12	.0189	.0189	.0189	.0189	.0377	.0377	.0189
13	.0189	.0189	.0189	.0377	.0377	.0189	.0566
14	.0189		.0377	.0189	.0189	.0377	.0566
15	.0189	.0189	.0189	.0189	.0189	.0377	.0377
16	.0189	.0377	.0189	.0189	.0754	.0377	.0377
17	.0377	.8596	.0377	.0377	.0377	.0377	.0377
18	.0566	.0377	.0377	.0377	.0377	.0377	.0566
19	.0566	.0377	.0377	.0377	.0377	.0377	.0566
20	.0377	.0377	.0377	.0377		.0566	.0566
21	.0377	.0377	.0189	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0189	.0566	.0377	.0566	.0377
24	.0377	.0189	.0189	.0377	.0189	.0377	.0377
Max	.0566	.8596	.0377	.0566	.0754	.0566	.0566
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0299	.0657	.0252	.0283	.0304	.0322	.0385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (C) S/DN.[088] BU 4088

Substation No/ Name :- 274200 / 33/11KV GADDA MAIDAN

Feeder No / Name : 201 / 11KV COLLECTOR OFFICE

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	.9709	.924	.9979	1.0082	1.0269	1.0269
2	1.2696	.9619	.924	.9335	.9709	.9896	.9896
3	1.2826	.9431	.8871	.8589	.9431	.9997	.9896
4	1.226	.9054	.8501	.8676	.9054	.9619	.9522
5	1.2071	.8865	.8676	.8865	.9054	.8962	.8962
6	1.226	.9054	.8299	.8865	.9054	.9335	.9335
7	1.1883	.8865	.8488	.8962	.9431	.9522	.9149
8	1.226	.9997	.8488	.8676	1.0185	1.0456	.9335
9	1.307	1.0456	.8962	.8402	1.0751	1.1203	1.0269
10	1.6057	1.2323	1.0456	.9335	1.358	1.3769	1.2696
11	1.4377	1.4563	1.1576		1.5278	1.6409	1.475
12	1.4937	1.4937	1.2696		1.6221	1.6409	1.5497
13	1.4937	1.5497	1.3817		1.6221	1.6991	1.6804
14	1.4563	1.419	1.307	.1867	1.6032	1.587	1.643
15	1.5123	1.4377	1.251	.1867	1.5655	1.6409	1.6057
16	1.5123	1.5123	1.3256		1.6032	1.6787	1.6057
17	1.5123	1.4377	1.307		1.6032	1.6221	1.587
18	1.4377	1.4377	1.2696		1.531	1.6263	1.587
19	1.701	1.6448	1.5181		1.6632	1.7375	1.6057
20	1.5546	1.4998	1.4449	1.3676	1.5546	1.6617	1.587
21	1.4083	1.3717	1.3169	1.2936	1.4266	1.475	1.4377
22	1.2752	1.2567	1.2012	1.2752	1.307	1.363	1.3443
23	1.1458	1.2012	1.2012	1.1389	1.2136	1.2696	1.2323
24	1.4937	1.1016	1.0164	1.0534	1.0456	1.0642	1.0642
Max	1.701	1.6448	1.5181	1.3676	1.6632	1.7375	1.6804
Min	1.1458	.8865	.8299	.1867	.9054	.8962	.8962
Avg	1.3882	1.2316	1.1204	.9100	1.2884	1.3337	1.2891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 201 / 11 KV MIDC NO 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1907	.2149	.2033	.2033	.1715	.2241
2	.1334	.1928	.1543	.2033	.2033	.1509	.2054
3	.1334	.1753	.1509	.2012	.2033	.1734	.2033
4	.1524	.1543	.1526	.1646	.2195	.1753	.1829
5	.1524	.1696	.1663	.1646	.2195	.1543	.1829
6	.1715	.1696	.1829	.1646	.2195	.1753	.1629
7	.1715	.2614	.2507	.1949	.2195	.2402	.1646
8	.4652	.5841	.5563	.4572	.598	.5563	.1629
9	.6815		.6344	.6259	.6344	.6815	.1612
10		.6859	.744	.7468	.727	.7575	.1791
11	.751	.8368	.8251	.8833	.8093	.8345	.7316
12	.7649	.727	.8318	.7846	.7788	.8318	.1991
13	.6249	.6144	.6472	.4778	.5944	.6836	.1612
14	.602	.5721		.6203	.5937	.639	.2926
15	.6996	.7407	.7775	.8109	.7928	.8459	.2587
16	.6908	.727	.7788	.6859	.7682	.8177	.2772
17	.6537	.6935	.8002	.7371	.7305		.2772
18	.5216	.5952	.6984	.6573	.6036		.3326
19	.2804	.4111	.407	.3521	.3768		.1254
20	.2402	.2804	.3361	.2715	.2629		.12
21	.2195	.2172	.2263	.2587	.2241		.0995
22	.2172	.2012	.2075	.2427	.1991		.1063
23	.1949	.1791	.1886	.2195	.1829		.1017
24	.1143	.197	.1663	.2075	.2033	.1753	.2263
Max	.7649	.8368	.8318	.8833	.8093	.8459	.7316
Min	.1143	.1543	.1509	.1646	.1829	.1509	.0995
Avg	.3805	.4164	.4390	.4307	.4403	.4744	.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 202 / 11KV Bhadrawati
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104	.2096	.2096	.1905	.2402	.2218	.2926
2	.1204	.2286	.2096	.2096	.2378	.2172	.2743
3	.1204	.2477	.2096	.2096	.2353	.2054	.2772
4	.1372	.2096	.1715	.2096	.2507	.2054	.2587
5	.1715	.2096	.1905	.2096	.2587	.2054	.2587
6	.1905	.2286	.2096	.2096	.2614	.2452	.2427
7	.2096	.2561	.3018	.2427	.2641	.2829	.2427
8	.5316	.5258	.5735	.5609	.5487	.6036	.2452
9	.5596	.7045	.6882	.6964	.6722	.9717	.1791
10	.7377	.8642	.8642	.8192	.8192	.9717	.2033
11	.8162	.9231	.8802	.9442	.9217	.9442	.2218
12	.7209	.8785	.8539	.8684	.9069	.9217	.2195
13	.6516	.7537	.8048	.6443	.7459	.7522	.2587
14	.6464	.5935	.7865	.6952	.6464	.639	.2195
15	.7625	.7537	.7865	.8583	.8642	.9393	.2402
16	.7956	.759	.7935	.9442	.8642	.8436	.1658
17	.7293	.6958	.7773	.8962	.8749		.1753
18	.7209	.679	.8048	.888	.7287		.1715
19	.4344	.6241	.4748	.5281	.4784		.1526
20	.3734	.3772	.3921	.3734	.3761		.0857
21	.2587	.2772	.2987	.2801	.3109		.1334
22	.2427	.2033	.2427	.1848	.2218		.1463
23	.2172	.1867	.168	.1543	.2172		.1448
24	.104	.1905	.1905	.1698	.2427	.1829	.2926
Max	.8162	.9231	.8802	.9442	.9217	.9717	.2926
Min	.104	.1867	.168	.1543	.2172	.1829	.0857
Avg	.4315	.4825	.4951	.4995	.5078	.5502	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 203 / 11KV MIDC NO.4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1524	.1905	.1524	.2652
2		.1715	.1715	.1524	.1905	.1524	.2515
3		.1715	.1715	.1524	.1905	.1524	.2374
4	.1715	.1715	.1905	.1524	.1905	.1715	.2229
5	.1715	.1905	.1905	.1524	.1905	.1715	.2103
6	.1715	.1715	.1715	.1715	.1905	.1715	.1791
7	.1715	.1715	.1612	.1509	.1905	.2096	.1463
8	.4321	.7049	.6259	.4938	.7331	.6144	.1905
9	.7788	.8882	.8623	.8901	.8779	.9596	.1715
10	.9596	1.0153	1.0122	.9469	1.001	1.057	.1715
11	1.0431	1.1385	1.1934	1.1126	1.1822	1.1822	.1905
12	1.0431	.9446	1.0425	1.0715	1.1279	1.0997	.2096
13	.7529	.9164	.7964	.6895	.8215	.9122	
14	.7385	.8109	.9191	.7674	.8573	.8688	
15	.9054	1.0136	.9465	.9604	1.0562	1.0151	
16	1.0014	.9739	.9875	.9875	1.0425	1.0151	.2096
17	.9412	1.0014	1.0431	1.0014	.9736		
18	.8002	.8642	1.0562	.9334	.9465		
19	.4359	.639	.5182	.5937	.5624		
20	.2172	.2402	.3961	.3326	.2614		.1905
21	.2286	.2096	.1905	.2858	.1905		
22	.1715	.1905	.1905	.2096	.181		.1905
23	.1715	.1715	.1715	.1905	.1715		.1905
24		.1715	.1715	.1715	.1905	.1524	.2785
Max	1.0431	1.1385	1.1934	1.1126	1.1822	1.1822	.2785
Min	.1715	.1715	.1612	.1509	.1715	.1524	.1463
Avg	.5654	.5464	.5563	.5301	.5629	.5916	.2062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 204 / 11 KV MIDC NO.5

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.4108	.4656	.4835	.4481	.4572	.5487
2	.3292	.3921	.4344	.394	.4572	.4572	.5249
3	.3292	.3772	.4024	.3403	.4572	.4251	.5249
4	.2138	.3584	.4066	.3403	.4706	.4251	.5014
5	.3109	.3475	.4108	.3403	.4706	.4108	.5014
6	.3109	.3841	.4119	.3761	.4835	.4207	.4784
7	.3109	.4477	.5121	.4334	.4835	.5373	.4557
8	.7529	.9305	.9164	.8145	1.0425	.9604	.3561
9	1.0288	1.1984	1.3575	1.1904	1.1683	1.2483	.333
10	1.2597	1.3213	1.4803	1.363	1.3352	1.4186	.3561
11	1.5146	1.5927	1.6861	1.5508	1.6072	1.6289	.3467
12	1.3253	1.4861	1.5021	1.4603	1.5438	1.5438	.3121
13	1.1439	1.382	1.2323	1.1004	1.1728	1.3535	.298
14	.9701	1.0002	1.1984	.9604	1.0288	1.028	.2774
15	1.2574	1.262	1.283	1.3352	1.3306	1.3957	.3012
16	1.3717	1.438	1.4146	1.386	1.3392	1.4803	.3155
17	1.2452	1.3253	1.4769	1.363	1.3717		.3224
18	1.1574	1.2795	1.4266	1.2971	1.3535		.2896
19	.8356	1.0837	1.0155	1.0562	1.0753		.4024
20	.6274	.7625	.8048	.7122	.7287		.3982
21	.5487	.6068	.6413	.6241	.5895		.3801
22	.5083	.6024	.5258	.5373	.5552		.3658
23	.4706	.5258	.543	.4525	.5121		.3881
24	.3292	.4251	.4656	.4887	.4435	.499	.5487
Max	1.5146	1.5927	1.6861	1.5508	1.6072	1.6289	.5487
Min	.2138	.3475	.4024	.3403	.4435	.4108	.2774
Avg	.7700	.8725	.9173	.85	.8945	.9229	.3970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 205 / 11 KV SANKURI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2096	.2477	.2477	.2286	.2614
2	.2096	.2286	.2096	.2477	.2477	.2477	.2587
3	.2096	.2286	.2096	.2477	.2477	.2477	.2561
4	.2286	.2477	.2286	.2477	.2667	.2477	.2477
5	.2286	.2477	.2477	.2477	.2667	.2667	.2477
6	.2286	.2667	.2858	.2286	.2667	.2667	.2477
7	.2286	.2858	.2858	.2641	.2667	.2858	.2477
8	.4733	.5898	.6081	.4578	.6483	.6062	.2667
9		.7655	.7935	.703	.7716	.7811	.1905
10		.8333	.884	.8951	.8688	.8642	.2096
11	.9105	.9414	.9065	.8471	.9332	.8951	.2096
12	.8688	.8688	.9145	.9031	.8655	.8535	.2286
13	.6173	.7125	.8029	.6796	.6554	.6958	.2286
14	.6401	.663	.7628	.7459	.6299	.7125	.2286
15	.7968	.8993	.7977	.8322	.9031	.8333	.2286
16	.8333	.8429	.8383	.8535	.8796	.8025	.2477
17	.828	.7977	.8688	.945	.8509		.2477
18	.6802	.6562	.7432	.7468	.7522		.2286
19	.3772	.4681	.4108	.5258	.5373		.2477
20	.3048	.2477	.3395	.3395	.3395		.2286
21	.2286	.2286	.2402	.3142	.3018		.2477
22	.2477	.2286	.2477	.2858	.2667		.2286
23	.2477	.2286	.2477	.2477	.2286		.2096
24	.2096	.2477	.2286	.2667	.2477	.2286	.2641
Max	.9105	.9414	.9145	.945	.9332	.8951	.2667
Min	.2096	.2286	.2096	.2286	.2286	.2286	.1905
Avg	.4458	.4981	.5130	.5133	.5204	.5332	.2378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 206 / 11 KV VINKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.2286	.2667	.2427	.2477	.3125
2	.1715	.1905	.2286	.2667	.2587	.2286	.3041
3	.1715	.2096	.2096	.2667	.2561	.2286	.3429
4	.1715	.2096	.1905	.2096	.2772	.2477	.3239
5	.1715	.1905	.2096	.2096	.2801	.2667	.3048
6	.1715	.2096	.1905	.2096	.3018	.2858	.2667
7	.1715	.2587	.2241	.3239	.3206	.3961	.1715
8	.426	.6836	.5716	.6154	1.0269	.7225	.1715
9	.7482	.8916	.9214	.8993	.9536	.8093	.1524
10	1.0084	1.2146	1.2018	1.1294	1.17	.9869	.1334
11	1.1294	1.2631	1.2597	1.174	1.2651	1.174	.1715
12	1.189	1.2643	1.3395	1.001	1.189	.9389	.1524
13	.9602	.8116	.8905	1.1789	.9105	.7895	.1334
14	.9339	.8179	1.0402	1.0174	.9297	1.166	.1334
15	1.1288	1.1149	1.1439	1.291	1.07	1.166	.1334
16	1.1883	1.1294	1.25	1.0442	1.1296	1.1702	.1143
17	1.1702	1.1138	1.3123	1.0898	1.086		.1143
18	1.0595	1.0364	1.1227	1.1361	1.1265		.1143
19	.6836	.8383	.763	.7373	.7461		.1143
20	.4024	.5175	.6161	.4854	.5121		.1143
21	.3801	.4108	.415	.3681	.4525		.1334
22	.2534	.2286	.3429	.2715	.4207		.1334
23	.2286	.2286	.2829	1.3256	.2614		.1524
24	.1715	.1905	.2096	.2858	.2452	.2477	.3201
Max	1.189	1.2643	1.3395	1.3256	1.2651	1.174	.3429
Min	.1715	.1905	.1905	.2096	.2427	.2286	.1143
Avg	.5943	.6339	.6735	.7001	.6847	.6513	.1883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274009 / 33/11 KV MIDC SOLAPUR

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.5782	8.6105	8.554	8.4985	1.6461	9.0026	10.1229
2	14.8994	8.2191	8.2191	8.3876	1.5912	8.7237	10.2132
3	8.962	7.9395	8.0658	7.9401	1.5364	8.4442	10.1246
4	8.982	8.0098	7.7858	7.8287	1.4815	8.2762	10.0126
5	9.0038	7.9955	7.8978	7.8287	1.4815	8.6511	10.0515
6	9.4502	8.8889	9.0409	8.7237	1.5912	9.3736	10.3944
7	9.824	9.2615	9.1889	9.1712	10.2092	10.1143	10.2286
8	10.7602	10.8985	10.7048	10.0411	11.2392	11.1557	9.9588
9	11.5261	11.3386	11.8067	11.3627	12.1668	12.0542	9.8051
10	12.0468	12.3114	11.4986	11.3386	12.204	12.6909	8.7357
11	12.1039	13.2224	12.2565	10.8619	12.7796	13.8992	9.9062
12	12.2771	13.3134	12.6486	11.2409	13.4911	6.0471	10.1064
13	11.9021	12.3851	11.8519	10.7761	12.5617	13.6615	10.0921
14	11.4724	11.3157	11.937	10.0926	12.1171	12.7344	10.1624
15	12.2171	12.3349	12.452	11.1346	13.171	13.9461	10.1784
16	12.0833	12.6909	2.5966	10.1944	13.0264	13.9107	10.1206
17	12.292	12.7469	12.6452	10.2384	13.259	2.9424	9.9943
18	12.4348	13.091	12.9904	10.5305	13.6511	2.7726	10.3669
19	14.888	15.0434	15.1314	12.1308	15.4247	2.9492	13.4568
20	14.0101	14.5588	14.1244	13.6717	14.8034	2.7566	13.5666
21	12.987	12.7098	12.8189	12.931	13.5328	2.5766	13.0647
22	11.6221	11.5661	11.6992	12.1216	12.4205	2.364	11.9199
23	10.6036	10.4356	10.7728	10.9745	10.9408	2.0416	11.1637
24	9.8971	9.2816	9.1695	9.2822	1.6832	9.6176	10.2332
Max	14.8994	15.0434	15.1314	13.6717	15.4247	13.9461	13.5666
Min	8.962	7.9395	2.5966	7.8287	1.4815	2.0416	8.7357
Avg	11.4926	11.1737	10.6607	10.3043	9.5004	8.3628	10.5825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 201 / 11 KV BIDIGHARKUL
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.2136	1.2136	1.2936
2	1.2136	1.2136	1.1203	1.2936
3	1.1203	1.2136	1.1203	1.2136
4	1.1203	1.2136	1.1203	1.2136
5	1.1203	1.2136	1.2136	1.2136
6	1.0269	1.2136	1.1203	1.307
7	1.0269	1.1203	1.1203	1.2012
8	1.0269	1.0269	.924	1.1088
24	1.2936	1.2936	1.386	1.386
Max	1.2936	1.2936	1.386	1.386
Min	1.0269	1.0269	.924	1.1088
Avg	1.1278	1.1914	1.1487	1.2479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 203 / 11KV GANDHI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.823			
2	.6859	.6859	.7392			
3	.6859	.6859	.7316			
4	.6859	.6859	.7087			
5	.7716	.7716	.7087			
6	.7716	.7716	.8059			
7	.7716	.8573	.985			
8	1.3717		1.6832			
9			1.6347	1.5804	1.6137	1.8061
10			1.9319	1.7375	2.0062	1.9071
11			2.0576	1.9547	1.9052	1.9071
12			1.7528	1.8576	1.8576	2.0062
13			1.8976	1.3717	1.6575	1.8576
14			2.0481	1.4842	1.989	1.7833
15			2.2539	1.4403	2.0119	1.6004
16			2.3405	1.5384	2.1434	1.5956
17		1.8576	2.3034		2.0805	2.2634
18		1.5604	2.0157		2.1948	1.8233
19		1.3546	1.7718		1.7528	1.7147
20		1.2041	1.4175		1.4022	1.5604
21		1.0031	1.1641		1.2269	1.3146
22		.9602			1.0631	1.2403
23		.9745			1.0059	1.1517
24	.8573	.9431	.8954			
Max	1.3717	1.8576	2.3405	1.9547	2.1948	2.2634
Min	.6859	.6859	.7087	1.3717	1.0059	1.1517
Avg	.8192	1.0058	1.4850	1.6206	1.7274	1.7021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274045 / 33/11 KV BIDI GHARKUL

Feeder No / Name : 207 / 11 KV GADAGI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	.964	1.1317	1.226	1.2136	1.307
2	.9431	.9483	.8859	1.1317	1.1317	1.1203	1.2136
3	.9431	.9431	.9145	1.0374	1.1317	1.1317	1.226
4	.8573	.9431	.924	1.0374	1.1317	1.1317	1.1317
5	1.0288	1.0288	1.0059	1.0374	1.1317	1.1317	1.1317
6	1.1145	1.0288	1.0631	1.1317	1.1317	1.1317	1.226
7	1.2003	1.0288	1.0402	1.226	1.226	1.226	1.226
8	1.1145	1.0288	1.0631	1.2136	1.1203	1.1088	1.1203
9	1.0059	1.0059	1.0164	1.2012	1.1088	1.0059	
10	.8145	.905	.905	1.1088	1.0059	1.0164	
11	.905	.9955	1.0059	1.1203	1.0164	.9955	
12	.8954	1.0059	1.0059	1.1088	1.1088	1.086	
13	1.0059	1.086	1.1088	1.2136	1.1088	1.1203	
14	.9536	1.0164	1.1088	1.226	1.0402	1.1317	
15	1.0059	1.0974	1.0269	1.1088	1.086	1.1317	
16	1.0269	1.1203	1.1317	1.1888	1.226	1.1317	
17	1.086	1.086	1.2136		1.307	1.2136	
18	1.1393	1.1517	1.1888		1.4003	1.4784	
19	1.7013	1.6118	1.848		2.0119	1.9404	
20	1.8099	1.7909	1.848			1.9605	
21	1.7375	1.6832	1.7375			1.829	
22		1.4899				1.7375	
23		1.3146				1.587	
24	1.1145	1.2003	1.1269	1.226	1.2136	1.386	1.307
Max	1.8099	1.7909	1.848	1.226	2.0119	1.9605	1.307
Min	.8145	.905	.8859	1.0374	1.0059	.9955	1.1203
Avg	1.1105	1.1475	1.1424	1.1441	1.1932	1.2895	1.2099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 201 / AMRAPALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4715	.499	.5281	.6099	.4715	.5041
2	.4527	.4527	.4854	.4904	.5914	.4338	.4668
3	.4338	.4338	.4668	.4527	.5729	.4338	.4668
4	.4338	.415	.4294	.4338	.5544	.4527	.4668
5	.415	.415	.462	.4338	.5359	.5041	.5359
6	.4481	.4668	.5304	.4715	.5788	.5788	.724
7	.5415	.5601	.5973	.6219	.6468	.6468	.6878
8	.6859	.7461	.7625	.7611	.8097	.8097	.6805
9	.823	.8488	1.0031	.9181	.8642	.9145	.6099
10	.8951	.8951	.9755	.9259	.7977	.9722	
11	1.0031	.9332	1.0822	1.0235	.945	1.0155	.5729
12	.9602	.9998	1.0957	1.0364	1.1265	1.1092	.6348
13	.8383	.8745	.9602	.9061	1.004	.9503	.6348
14	.8259	.8421	.9374	.8436	.9393	.9116	.6161
15	.8802	.9414	1.0364	.9877	1.034	1.1092	.6348
16	.933	.9414	1.0494	.9602	1.0494	1.0595	.6602
17	.933	1.0059	1.0059	.9907	1.0364	1.1111	.6348
18	.8697	.9297	.9783	.9686	1.0648	1.0494	.6161
19	.964	1.1065	1.0923	1.1022	1.0923	1.166	.8316
20	.9145	.964	.8954	.8859	.9955	1.0566	.8686
21	.8501	.8413	.7762	.8048	.8596	.9412	.8131
22	.6283	.7499	.7392	.7316	.7207	.7865	.6838
23	.5601	.5853	.6535	.695	.5601	.6878	.5975
24	.5093	.4904	.5175	.5658	.6283	.5093	.5601
Max	1.0031	1.1065	1.0957	1.1022	1.1265	1.166	.8686
Min	.415	.415	.4294	.4338	.5359	.4338	.4668
Avg	.7196	.7463	.7930	.7725	.8174	.8200	.6305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 202 / 11 KV ASHOK CHOWK1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.4344	.4344	.4572	.4344
2	.4435	.439	.4435	.4163	.4163	.439	.3801
3	.4435	.4344	.4251	.3982	.4163	.4024	.3801
4	.4435	.4163	.4251	.3801	.4163	.4024	.3982
5	.4435	.439	.4207	.3801	.4163	.4525	.4477
6	.4755	.5611	.4835	.4119	.4298	.5373	.5258
7	.5249	.591	.5493	.5144	.5426	.6135	.5493
8	.6562	.7225	.7188	.6773	.6015	.7482	.4733
9	.7335	.8505	.8792	.8657	.9063	.9328	.4908
10	.7819	.8402	.8291	.9069	.9191	.8762	.4334
11	.8402	.9334	.9869	.9469	.9875	.9739	.4557
12	.8642	.9334	.9728	.9875	.9602	1.0416	.4607
13	.7754	.823	.8206	.8345	.8882	.8623	.4477
14	.7225	.7385	.8177	.7922	.8069	.7876	.4706
15	.8431	.8657	.9469	.904	.9318	.9446	.4572
16	.8741	.9198	.9198	.9179	.9587	.9739	.4755
17	.8177	.8522	.8802	.9164	.9604	.9877	.4572
18	.7895	.823	.8808	.823	.9334	.9328	.4656
19	.8482	.884	.8993	.8688	1.0311	.953	.7087
20	.8048	.8288	.8048	.8288	.8718	.8987	.7442
21	.6935	.6935	.7545	.703	.8402	.823	.7442
22	.6485	.6201	.6135	.6485	.7362	.7712	.6556
23	.5973	.5792	.5552	.5373	.5792	.5847	.5611
24	.4938	.4938	.4938	.4525	.4525	.5121	.4706
Max	.8741	.9334	.9869	.9875	1.0311	1.0416	.7442
Min	.4435	.4163	.4207	.3801	.4163	.4024	.3801
Avg	.6673	.6975	.7074	.6894	.7265	.7462	.5037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 274191 / 33/11 KV POLYTECHNIC

Feeder No / Name : 203 / 11 KV PATHAN BAG1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.5788	.5788	.5228	.5975	.5601	.5601
2	.5788	.5415	.5281	.5041	.5788	.5228	.5228
3	.5658	.5228	.5093	.4854	.5601	.5041	.4854
4	.547	.5228	.5093	.4668	.5415	.5041	.4854
5	.5281	.5228	.5093	.4668	.5415	.5415	.5228
6	.5975	.6099	.5601	.4854	.6161	.6283	.6535
7	.5975	.5914	.5415	.5121	.6401	.6584	.5914
8	.6661	.7202	.6516	.6613	.7291	.7291	.5973
9	.6706	.7045	.6554	.7209	.6962	.7293	.5729
10	.6241	.8223	.6325	.6562	.6718	.8097	.4656
11	.6009	.8162	.6722	.6802	.664	.8785	.4656
12	.5992	.7522	.6562	.6722	.7042	.8745	.439
13	.5487	.6539	.5801	.6226	.583	.7449	.394
14	.5765	.57	.57	.6104	.6371	.7122	.4344
15	.6539	.6718	.6882	.6718	.7373	.7956	.4854
16	.6443	.7459	.6952	.6706	.7122	.8139	.5788
17	.6613	.7209	.7293	.6962	.779	.8785	.4755
18	.6344	.7773	.7773	.7625	.7701	.852	.5373
19	.7973	.7888	.8238	.7888	.8417	.8939	.7682
20	.7522	.7973	.7442	.7701	.8417	.8507	.7865
21	.724	.6878	.724	.724	.8145	.8145	.7682
22	.7316	.6584	.6584	.7499	.7762	.823	.7577
23	.6838	.6838	.6099	.7023	.6838	.7947	.7392
24	.6348	.5975	.5975	.5601	.6099	.5975	.6348
Max	.7973	.8223	.8238	.7888	.8417	.8939	.7865
Min	.5281	.5228	.5093	.4668	.5415	.5041	.394
Avg	.6332	.6691	.6334	.6318	.6803	.7297	.5717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 404 / 33 KV BIDII GHARKUL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.427	.6642	.759	.759	.7499	.7407	.9842
2	.4744	.6642	.7116	.7116	.7968	.7407	.9374
3	.4744	.6642	.6642	.7116	.8436	.6944	.9231
4	.5218	.6167	.6167	.6642		.6944	.8436
5	.5407	.6167	.6642	.6642		.6944	.7968
6	.5693	.6642	.6642	.7116	.9842	.787	.7499
7	.5898	.8065	.8539	.7116	.9842	1.0185	.703
8	1.7695	2.2297	1.945	2.0399		2.3903	.6562
9	2.4669	3.0361	3.131	2.9995	2.9527	3.0933	
10	3.2733	3.5105	3.7952	3.4682	3.562	3.7494	
11	3.7477	3.9849	4.0798	3.9369	3.89	3.9369	
12	3.558	3.7952	3.9849	3.6557	3.8432	3.9838	
13	2.7989	2.9412	2.9412	3.3745	2.8121	3.2808	
14	2.6566	2.4669	3.2733	2.8121	2.6715	2.6715	
15	3.4156	3.5105	3.4631	3.6557	3.7494	3.8432	
16	3.4156	3.6054	3.6054	3.5151	3.6557	3.8432	
17	3.2259	3.4631	3.7003	3.4214	3.6528		
18	3.0361	3.2259	3.5105	3.7494	3.3682		
19	1.8027	2.4669	2.1822	2.2028	2.1296		
20	1.2334	1.4706	2.1822	1.406	1.4352		
21	1.0437	1.1385	1.1385	1.1248	1.1574		.4218
22	.8539	.9014	1.0911	.9374	.9722		.5218
23	.759	.8065	.759	.6562	.8333		.5693
24	.427	.6642	.7116	.759	.703	.7407	1.0311
Max	3.7477	3.9849	4.0798	3.9369	3.89	3.9838	1.0311
Min	.427	.6167	.6167	.6562	.703	.6944	.4218
Avg	1.7951	1.9964	2.1012	2.0270	2.1784	2.1708	.7615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (D) S/DN.[089] BU 4089

Substation No/ Name :- 277012 / 132/33/11 KV SUB STATION

MIDC

Feeder No / Name : 405 / 33 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.514	7.6738	7.5617	7.4497	8.4019	8.1482	9.4496
2	8.57	7.3377	7.2817	7.3937	8.514	7.9784	9.393
3	8.57	7.1136	7.1696	7.0016	8.626	7.7521	9.2798
4	8.626	7.1696	6.9456	7.0016	8.738	7.5823	9.1667
5	8.626	7.2257	7.0576	7.0016	8.85	7.8087	9.1101
6	8.682	7.8418	8.0659	7.8978	8.9621	8.3179	8.9969
7	8.682	8.1779	8.1779	8.1219	9.1301	9.0535	8.9403
8	10.5304	11.0906	10.8665	9.5782	11.713	11.1466	8.7706
9	11.9307	11.8747	12.2108	11.9393	12.7709	12.7315	
10	13.107	13.2751	12.6029	12.2668	13.4991	13.8632	
11	13.219	14.2833	13.4991	11.9307	14.0032	14.4856	
12	13.051	13.9472	13.6671	12.1548	14.3393	15.2212	
13	11.9868	12.4909	12.2788	11.3146	12.6589	14.1461	
14	11.8187		12.0525	10.5304	12.3788	13.1842	
15	12.995	13.3311	12.5469	12.0988	13.9472	14.712	
16	12.7149	13.3311	13.163	11.6507	13.7232	14.5422	
17	12.995	13.8912	13.4431	11.2026	13.9472		
18	12.7149	13.2751	13.5551	11.2026	13.8912		
19	13.5551	14.1152	14.1152	11.1466	14.2593		
20	12.2668	12.7709	12.7709	12.0988	13.1276		
21	11.4266	11.1466	11.2026	11.2026	11.8261		11.2037
22	10.2504	10.1943	10.3624	10.3064	10.9208		10.4115
23	9.3542	9.1301	9.5222	9.6902	9.7891		9.1101
24	8.514	8.2899	8.1219	8.2339	8.2899	8.6574	9.5628
Max	13.5551	14.2833	14.1152	12.2668	14.3393	15.2212	11.2037
Min	8.514	7.1136	6.9456	7.0016	8.2899	7.5823	8.7706
Avg	10.9459	10.8251	10.7600	10.0173	11.5128	11.1371	9.4496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 201 / 11KV RAMWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.1163	1.1517	1.1694	1.2048	1.382	1.3112
2	1.134	1.0808	1.0985	1.134	1.2048	1.382	1.258
3	1.0808	1.0808	1.0985	1.134	1.2048	1.3289	1.258
4	1.0277	1.0631	1.0985	1.134	1.2048	1.3289	1.258
5	.9745	1.0631	1.0985	1.134	1.2048	1.3289	1.1694
6	.9745	1.0099	1.0631	1.0985	1.1517	1.3289	1.0985
7	.9568	.9391	.9745	.9568	.9745	1.0454	.9922
8	.9214	1.0099	1.0277	.9214	.9922	1.0808	.9922
9	.9568	.9214	.8859	.8859	.9745	1.0454	1.0277
10	.9391	1.0099	.9214	.9214	1.0808	1.0454	1.0099
11	.9745	1.0099	.9568	.9391	1.134	1.0985	1.0631
12	.6024	.9745	.9214	.9745	1.0985	1.0985	1.134
13	1.0277		.9922	.9568	1.1517	1.0985	1.134
14	1.0277	1.0099	1.0631	.9745	1.134	1.1517	1.1163
15	1.0808	1.0454	.9568	1.0099	1.1871	1.2048	1.2403
16	1.0808	1.0277	1.0277	.9391	1.1517	1.1871	1.2403
17	1.0454	1.0808	.9922	.9568	1.1871	1.2048	1.1694
18	1.0631	1.0631	1.0099	1.0985	1.1163	1.1517	1.1871
19	1.382	1.4352	1.3466	1.2757		1.4706	1.3289
20	1.382	1.3643	1.3643	1.3112		1.5061	1.4706
21	1.3466	1.3289	1.382	1.3289	1.4883	1.5061	1.4706
22	1.3643	1.3466	1.3289	1.3289	1.4883	1.4883	1.5061
23	1.3112	1.3112	1.2934	1.3643	1.5592	1.5415	1.5061
24	1.2048	1.1694	1.2403	1.2226	1.258	1.4175	
Max	1.382	1.4352	1.382	1.3643	1.5592	1.5415	1.5061
Min	.6024	.9214	.8859	.8859	.9745	1.0454	.9922
Avg	1.0845	1.1070	1.0956	1.0904	1.1887	1.2676	1.2149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 202 / 11KV PRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2075	.1905	.2286	.2096	.2286	.2286
2	.2096	.1886	.1905	.2096	.2096	.2286	.1905
3	.2096	.1886	.1905	.2096	.2096	.2286	.1905
4	.2096	.1886	.1905	.2096	.2096	.2286	.1905
5	.2096	.1886	.1905	.2096	.2096	.2286	.1905
6	.2096	.1886	.1905	.2096	.2096	.2286	.1905
7	.2096	.2263	.2096	.2096	.2286	.2286	.1905
8	.1715	.2263	.2096	.2286	.2286	.2477	.1905
9	.1905	.1886	.2477	.1905	.2286	.2286	.1905
10	.2858	.2858	.2858	.2096	.362	.2477	.1905
11	.362	.3239	.2477	.2477	.381	.381	.2096
12	.362	.3429	.3048	.2858	.362	.381	.2096
13	.3429		.2667	.2477	.3048	.2667	.2096
14	.2477	.2667	.2858	.2477	.3239	.2858	.2096
15	.3048	.2858	.3048	.2667	.362	.381	.2096
16	.3048	.3429	.362	.3048	.3239	.362	.2286
17	.3429	.3048	.3239	.3048	.4191	.3239	.2096
18	.3239	.3048	.3239	.3048	.3048	.362	.2096
19	.2829	.3048	.2667	.2858		.3048	.2096
20	.2452	.2477	.2667	.2286		.2858	.2096
21	.2075	.2286	.2096	.2286	.2286	.2477	.2096
22	.2075	.2286	.2286	.2286	.2286	.2477	.2096
23	.2075	.2096	.2286	.2286	.2477	.2286	.2096
24	.2096	.2075	.2096	.2286	.2096	.2286	
Max	.362	.3429	.362	.3048	.4191	.381	.2286
Min	.1715	.1886	.1905	.1905	.2096	.2286	.1905
Avg	.2528	.2468	.2469	.2397	.2728	.2755	.2038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 203 / 11KV POLYTECHNIC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7133	.7762	.7468	.7762	.8316	.8402
2	.7207	.695	.7468	.7095	.7392	.8316	.8029
3	.7023	.7095	.7468	.7095	.7468	.8488	.8029
4	.6838	.7095	.7468	.7095	.7468	.8488	.8029
5	.6653	.7095	.7468	.7095	.7468	.8488	.8029
6	.7842	.7095	.7468	.7842	.7468	.8488	.8029
7	.7468	.7468	.8402	.8589	.8131	.8488	.823
8	.7865	.8596	.9492	.8916	.9313	.9511	.8596
9	.7907	1.0029	.929	1.1043	1.0341	1.0566	.6762
10	.9259	.9568	1.0059	.9998	1.0277	1.0387	.6733
11	.9709	1.0277	.8535	1.0911	1.134	1.1641	.6805
12	.9114	1.0454	.8078	.9414	1.0454	1.1145	.6173
13	.7796		.7935	.9804	.9568	.9671	.6135
14	.7888	.7973	.7811	.9448	.9036	.9492	.6379
15	.9391	.9214	.9374	1.012	1.1163	1.1283	.6379
16	.985	.3012	.9442	1.012	1.134	1.1462	.6379
17	.9214	1.0808	.933	.9804	1.1163	1.1403	.6584
18	.8322	.8749	.9374	1.0277	1.1317	.953	.6401
19	1.0517	1.0031	1.1401	1.1269		1.1568	.8688
20	.9061	1.0454	1.0867	1.0631		1.134	.985
21	.8592	.9745	1.0387	1.0791	1.0974	1.0745	.9955
22	.8124	.9568	.9694	1.0242	1.0608	1.0679	1.0059
23	.8779	.8779	.8962	.9055	.9145	.9979	.9145
24	.7762	.7682	.8131	.7842	.8316	.8779	
Max	1.0517	1.0808	1.1401	1.1269	1.134	1.1641	1.0059
Min	.6653	.3012	.7468	.7095	.7392	.8316	.6135
Avg	.8316	.8473	.8819	.9249	.9432	.9927	.7730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 204 / 11KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2048	1.1517	1.2226	1.2403	1.2536	1.2757	1.2536
2	1.1517	1.0985	1.1694	1.2048	1.2536	1.2403	1.2536
3	1.1163	1.0985	1.1694	1.2048	1.2178	1.2403	1.2536
4	1.0277	1.0985	1.1694	1.2048	1.2178	1.2403	1.2536
5	.9745	1.0985	1.1694	1.2048	1.2178	1.2403	1.2536
6	1.0985	1.0631	1.0985	1.134	1.1641	1.2403	1.2536
7	1.0277	.9922	1.0099	1.0631	1.0745	1.0631	1.1104
8	.9391	1.0277	1.0808	1.0099	1.0745	1.0277	1.0745
9	.8859	.8859	.9568	.9313	.9671	.9391	.9671
10	.9922	.8328	.9391	.9492	.9214	.8859	.9214
11	.815	.815	.8859	.9134	.9036	.8505	.9036
12	.8328	.9214	.7973	.9671	.9036	1.0099	.8859
13	.8505		.8682	.9671	1.0099	1.0808	.9391
14	.9036	1.0099	.9745	.9671	.9745	1.0631	1.0454
15	.8859	1.1517	1.0099	.985	1.0277	1.0808	1.0985
16	.9568	1.0277	1.0099	1.0029	.9391	1.0985	1.0631
17	.8859	.9568	.9036	.985	.9922	1.0985	.9671
18	.8859	.8859	.9391	1.1641	1.0454	1.0208	.9313
19	1.2757	1.4529	1.2934	1.4864		1.4506	1.2894
20	1.4175	1.4529	1.4352	1.4864		1.4685	1.3611
21	1.3466	1.3466	1.4175	1.4864		1.5223	1.379
22	1.4529	1.382	1.3643	1.4327	1.4706	1.5043	1.4327
23	1.3643	1.3466	1.3643	1.379	1.4352	1.4864	1.5043
24	1.2403	1.2226	1.258	1.2757	1.3253	1.3466	
Max	1.4529	1.4529	1.4352	1.4864	1.4706	1.5223	1.5043
Min	.815	.815	.7973	.9134	.9036	.8505	.8859
Avg	1.0638	1.1008	1.1044	1.1519	1.1138	1.1864	1.1476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274003 / INDUSTRIAL ESTATE.

Feeder No / Name : 206 / 11KV ESTATE 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.184	.2286	.218	.2058	.2515	.2286	.1829
2	.1718	.2096	.2	.1844	.2263	.221	.1551
3	.1677	.197	.192	.176	.2138	.2096	.1467
4	.1635	.1886	.18	.1677	.2138	.1981	.1383
5	.1593	.176	.168	.1928	.197	.1905	.1299
6	.1578	.1718	.16	.218	.2096	.1791	.1509
7	.1665	.1972	.2143	.2515	.2599	.2515	.2058
8	.3549	.2972	.3086	.381	.4115	.3467	.2743
9	.4887	.5068	.4287	.4508	.4298	.463	.3772
10	.6099	.5552	.5731	.5228	.6602	.6413	.443
11	.6036	.5493	.6036	.5041	.6516	.5914	.443
12	.6099	.5316	.5847	.5415	.6268	.6805	.3109
13	.5853		.591	.5121	.5847	.567	.3109
14	.6268	.5493	.5552	.4938	.4784	.6379	.3286
15	.6335	.5493	.6036	.5788	.567	.7442	.3109
16	.7343	.5493	.6161	.5415	.6602	.6733	.317
17	.6379	.5847	.5415	.4938	.6201	.6979	.3191
18	.5611	.4784	.5175	.463	.5973	.5601	.3286
19	.5138	.4372	.426	.421		.4012	.3067
20	.3429	.3286	.3155	.3909		.3498	.2641
21	.298	.2953	.285	.3567	.3749	.2469	.2481
22	.2641	.2881	.3155	.3239	.3658	.2515	.2322
23	.2789	.2698	.2431	.2743	.2724	.2103	.2016
24	.1928	.2378	.2305	.2241	.2606	.2362	
Max	.7343	.5847	.6161	.5788	.6602	.7442	.443
Min	.1578	.1718	.16	.1677	.197	.1791	.1299
Avg	.3961	.3642	.3780	.3696	.4151	.4074	.2663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 201 / 11 KV MANTRI CHANDAK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6653	.6653	.7023	.7023	.8131	.8686
2	.7682	.6468	.6468	.6468	.6838	.7947	.8316
3	.7133	.6535	.5914	.6348	.6468	.7762	.7842
4	.695	.6161	.5975	.5975	.6468	.7095	.7468
5	.695	.6413	.5975	.5658	.6602	.6535	.7167
6	.6767	.6413	.6224	.5281	.679	.6224	.6979
7	.7499	.6224	.6224	.5658	.6979	.6602	.6979
8	.7468	.5975	.6161	.5658	.6979	.6602	.679
16							.6979
17			.7316	.5788	.7468	.7865	.7682
18			.7682	.695	.8413	.8962	.8413
19			.8596	.8413	.9328	.9511	.8962
20			.8402	.8402	.8779	.9335	
21			.7842	.8402	.8596	.8596	
22			.8048	.8413	.8779	.9709	
24	.823	.7023	.7023	.7392	.7392	.8501	.8871
Max	.823	.7023	.8596	.8413	.9328	.9709	.8962
Min	.6767	.5975	.5914	.5281	.6468	.6224	.679
Avg	.7350	.6429	.6967	.6789	.7527	.7958	.7780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 202 / 11 KV VIMANTAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.4854	.4668	.4854	.5228	.5601	.5228
2	.6348	.4668	.4668	.4668	.5041	.5601	.5041
3	.6036	.4668	.4294	.4668	.5041	.5041	.5041
4	.5853	.4854	.4294	.4854	.499	.5041	.5093
5	.5788	.5041	.4338	.5041	.5175	.5281	.5658
6	.5487	.5544	.415	.5359	.5544	.5729	.5847
7	.4572	.5658	.4527	.5359	.5175	.5544	.5658
8	.4207	.5281	.4854	.5359	.499	.5175	.547
16							.7356
17			.5853	.5853	.567	.5487	.6584
18			.6219	.6219	.5601	.6535	.6401
19			.6401	.6036	.5487	.6767	.6219
20			.6036	.6401	.5853	.6401	
21			.6219	.6348	.6401	.6584	
22			.6767	.6908	.6348	.6348	
24	.6584	.5041	.5228	.5041	.5228	.5788	.5601
Max	.6584	.5658	.6767	.6908	.6401	.6767	.7356
Min	.4207	.4668	.415	.4668	.499	.5041	.5041
Avg	.5712	.5068	.5234	.5531	.5451	.5795	.5784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 203 / 11 KV SHINDU VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.0374	1.0374	1.094	1.1317	1.226	1.226
2	1.0642	1.0185	1.0185	1.0562	1.1128	1.1883	1.1694
3	1.1016	1.0185	1.0185	1.0374	1.1128	1.1694	1.1694
4	1.1203	1.0185	1.0185	1.0374	1.1128	1.1317	1.1317
5	1.1157	1.0374	1.0185	1.0374	1.1317	1.1317	1.1317
6	1.0974	1.0562	1.0374	1.0374	1.1694	1.1128	1.1694
7	1.0608	1.094	1.0562	1.094	1.1317	1.0374	1.1317
8	1.0425	1.0562	1.0185	1.0185	1.0751	.9808	1.094
16							.9997
17			.9145	1.1203	.9877	.9694	.9877
18			1.0059	1.1523	1.0974	1.1706	1.0974
19			1.2254	1.2254	1.3535	1.2986	1.1888
20			1.2254	1.2437	1.3443	1.3169	
21			1.2696	1.307	1.3352	1.2803	
22			1.2437	1.3443	1.4083	1.3717	
24	1.1203	1.094	1.094	1.1506	1.1694	1.2826	1.2826
Max	1.1203	1.094	1.2696	1.3443	1.4083	1.3717	1.2826
Min	1.0425	1.0185	.9145	1.0185	.9877	.9694	.9877
Avg	1.0871	1.0479	1.0801	1.1304	1.1783	1.1779	1.1369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 204 / 11 KV SHIVASHAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2641	.2641	.2801	.2614	.3018	.3018
2	.2801	.2452	.2641	.2614	.2641	.2829	.2829
3	.2926	.2452	.2641	.2641	.2641	.2829	.2829
4	.3109	.2641	.2829	.2641	.2829	.2987	.2987
5	.2926	.2801	.3018	.2641	.3018	.3174	.3361
6	.2926	.3174	.3395	.2829	.3206	.3547	.3734
7	.2743	.3361	.3206	.2829	.3018	.3361	.3361
8	.2614	.3584	.2829	.2829	.2641	.3174	.2987
16							.2241
17			.2926	.2561	.2987	.2801	.2987
18			.3174	.2987	.3174	.2987	.3109
19			.3475	.3292	.2926	.2926	.3475
20			.3292	.2987	.2926	.2926	
21			.3475	.3292	.3475	.3547	
22			.3292	.2926	.3658	.3658	
24	.2561	.2829	.2829	.2987	.2801	.3206	.3206
Max	.3109	.3584	.3475	.3292	.3658	.3658	.3734
Min	.2561	.2452	.2641	.2561	.2614	.2801	.2241
Avg	.2796	.2882	.3044	.2857	.2970	.3131	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 205 / 11 KV KUMATHA GAOTHAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4854	.4854	.4854	.5041	.5041	.4854
2	.4755	.4668	.4668	.4668	.4854	.4854	.5041
3	.4938	.4668	.4668	.4668	.4854	.4854	.5041
4	.5487	.5093	.5093	.5041	.5041	.5093	.5228
5	.567	.5658	.5658	.5601	.5601	.5658	.5658
6	.5975	.6413	.6413	.6161	.6348	.6413	.6224
7	.5487	.5658	.5658	.5601	.5601	.5658	.5658
8	.4755	.4481	.4854	.4854	.4854	.4904	.5281
16							.4715
17			.5487	.5487	.5975	.5853	.5487
18			.5975	.6348	.6584	.6401	.5853
19			.6401	.6767	.695	.6767	.6036
20			.6219	.6722	.7282	.6767	
21			.5853	.6767	.6584	.6584	
22			.5853	.6348	.5853	.6535	
24	.5121	.5041	.5041	.5041	.5228	.5228	.5601
Max	.5975	.6413	.6413	.6767	.7282	.6767	.6224
Min	.4755	.4481	.4668	.4668	.4854	.4854	.4715
Avg	.5236	.5170	.5513	.5662	.5777	.5774	.5437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 206 / 11 KV SANTOSH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.0456	1.0269	1.1203	1.1203	1.1576	1.1763
2	1.251	1.0082	.9896	1.0903	1.0719	1.1203	1.1203
3	1.0974	.9896	.9896	1.0903	1.0534	1.0719	1.0829
4	1.1157	.924	.9896	1.0349	1.0534	1.0349	1.0534
5	1.0608	.8962	.9979	.9511	1.0608	1.0059	1.0534
6	1.0791	.8686	.9979	.8962	1.0791	1.0059	1.0719
7	1.0829	.924	1.0164	.9511	1.0974	1.0425	1.0349
8	1.0791	.924	.9694	.8962	1.0425	.9694	.961
16							1.0719
17			1.0974	1.0242	1.1523	1.1706	1.0974
18			1.2437	1.3352	1.4083	1.3717	1.3535
19			1.4266	1.4266	1.4815	1.5364	1.4266
20			1.4377	1.475	1.4937	1.5181	
21			1.4266	1.4937	1.4998	1.5497	
22			1.39	1.3535	1.4632	1.5123	
24	1.307	1.1203	1.0829	1.1763	1.1949	1.2323	1.2323
Max	1.307	1.1203	1.4377	1.4937	1.4998	1.5497	1.4266
Min	1.0608	.8686	.9694	.8962	1.0425	.9694	.961
Avg	1.1483	.9667	1.1388	1.1543	1.2182	1.2200	1.1335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 207 / 11KV WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2172	.2172	.2172	.2172	.2172	.2172
2	.2172	.1991	.2172	.2172	.1991	.2172	.2172
3	.181	.1991	.1991	.2172	.1991	.2172	.2172
4	.2172	.4163	.1991	.2172	.1991	.2172	.2172
5	.4163	.4163	.2172	.4163	.2172	.2172	.2172
6	.4163	.4163	.4163	.4163	.4163	.4344	.4344
7	.3982	.4163	.4163	.4163	.4163	.4163	.2172
8	.4163	.2172	.2172	.4163	.2172	.2172	.4163
16							.2172
17			.3801	.3841	.2172	.3801	.2195
18			.3801	.4207	.2172	.3982	.2172
19			.3982	.4024	.2172	.4163	.4163
20			.4024	.2172	.2241	.2172	
21			.1991	.2172	.2241	.2172	
22			.2172	.2172	.2172	.4163	
24	.2172	.2172	.2172	.2172	.2172	.2172	.2172
Max	.4163	.4163	.4163	.4207	.4163	.4344	.4344
Min	.181	.1991	.1991	.2172	.1991	.2172	.2172
Avg	.2997	.3017	.2863	.3073	.2410	.2944	.2647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 208 / 11 KV SHANTIVAN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.0914	.0924	.0943	.0943	.6036
2	.0943	.0943	.0914	.0924	.0943	.0943	.6413
3	.1132	.0943	.0914	.0924	.0943	.0943	.6602
4	.1132	.0943	.0914	.0924	.0943	.0943	.6979
5	.132	.1132	.0914	.0924	.0943	.0943	.7545
6	.132	.132	.1097	.1109	.1132	.1132	.811
7	.0943	.1509	.128	.1294	.1509	.132	.9431
8	.1132	.132	.128	.1294	.132	.132	.132
16							.0943
17			.0943	.1132	.1132	.0943	.1132
18			.1097	.1132	.132	.1132	.0943
19			.0943	.1132	.1132	.132	.1132
20			.1132	.1132	.132	.1132	
21			.1132	.1132	.128	.132	
22			.1132	.132	.132	.5093	
24	.0943	.132	.1097	.1109	.1132	.1132	.5658
Max	.132	.1509	.128	.132	.1509	.5093	.9431
Min	.0943	.0943	.0914	.0924	.0943	.0943	.0943
Avg	.1111	.1174	.1047	.1094	.1154	.1371	.4788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 209 / 11 KV IMS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9335	.9335	.9979	.9979	1.0974	1.0974
2	.9328	.9149	.9149	.9795	.9795	1.0791	1.0608
3	.9896	.9149	.9149	.961	.9795	1.0425	1.0608
4	1.0829	.9335	.9335	1.0164	1.0164	1.0425	1.0608
5	1.1157	.9709	.9709	1.0719	1.0719	1.0608	1.0974
6	1.0974	1.0829	1.0456	1.1273	1.1273	1.0608	1.1157
7	1.0791	1.1203	1.0829	1.2012	1.1458	1.0974	1.134
8	1.0829	1.0269	1.0642	1.1458	1.0719	1.0425	1.0059
16							.8779
17			.8029	.9877	.823	.9709	.9511
18			.8962	1.0974	1.0608	1.0829	1.0242
19			1.2071	1.2254	1.2254	1.251	1.0974
20			1.1949	1.2323	1.251	1.2883	
21			1.1763	1.2254	1.2803	1.2803	
22			1.1706	1.1576	1.0974	1.3169	
24	1.1203	.9896	.9709	1.0349	1.0349	1.134	1.1523
Max	1.1203	1.1203	1.2071	1.2323	1.2803	1.3169	1.1523
Min	.9145	.9149	.8029	.961	.823	.9709	.8779
Avg	1.0461	.9875	1.0186	1.0974	1.0775	1.1232	1.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 210 / 11 KV BOMBAY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.7316	.7133	.7682	.7947	.8501	.8779
2	.8402	.7133	.695	.7316	.7762	.8316	.8596
3	.7865	.7133	.695	.7316	.7762	.8316	.8596
4	.823	.7316	.695	.7316	.7762	.8316	.823
5	.8413	.7499	.7133	.695	.7947	.8501	.823
6	.8402	.7865	.7133	.695	.8131	.8686	.8048
7	.7682	.7865	.7316	.7865	.8131	.8871	.823
8	.7655	.7865	.695	.8048	.7762	.8316	.8048
16							.6219
17			.8029	.7865	.7865	.7865	.6401
18			.8413	.8779	.9335	.8962	.7133
19			.8779	.9328	.9694	.9335	.823
20			.8962	.9335	.9896	.9511	
21			.9335	.9328	.9709	.9694	
22			.8962	.9877	.9877	1.0642	
24	.8596	.7682	.7499	.8048	.8316	.8871	.9145
Max	.8596	.7865	.9335	.9877	.9896	1.0642	.9145
Min	.7655	.7133	.695	.695	.7762	.7865	.6219
Avg	.8184	.7519	.7766	.8134	.8526	.8847	.7991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 211 / 11 KV NEHARU NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.7392	.695	.7316	.7682	.8316	.823
2	.695	.7023	.6767	.7133	.7499	.8131	.8048
3	.7316	.7023	.6767	.6767	.7682	.7947	.8048
4	.7655	.7207	.695	.6767	.7865	.7947	.8048
5	.7842	.7392	.7133	.6767	.823	.7947	.823
6	.8029	.7947	.7499	.6767	.8596	.8131	.8413
7	.7468	.7762	.7316	.7316	.8413	.8316	.823
8	.7282	.7023	.6767	.7133	.7316	.7207	.695
16							.6219
17			.823	.7682	.7316	.8029	.7133
18			.8779	.8779	.8779	.8962	.8779
19			.9328	.9522	.9328	.9694	.9511
20			.9335	.8962	.9694	.9694	
21			.8596	.8962	1.0425	1.0082	
22			.8962	.8596	1.0059	.9709	
24	.823	.7762	.7316	.7682	.7865	.8686	.8596
Max	.823	.7947	.9335	.9522	1.0425	1.0082	.9511
Min	.695	.7023	.6767	.6767	.7316	.7207	.6219
Avg	.7545	.7392	.7780	.7743	.8450	.8587	.8033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274068 / JULE SOLAPUR

Feeder No / Name : 212 / 11KV NTPC SMC
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.1132	.0377	.1132	.0189	.1132	.0189
2	.0189	.0377	.0377	.0377	.0189	.1132	.0189
3	.0377	.0377	.1132	.0377	.0189	.0189	.0189
4	.1132	.0189	.1132	.0189	.0189	.0189	.0189
5	.0943	.0189	.0189	.132	.0189	.1132	.0189
6	.132	.0189	.0189	.132	.0189	.1132	.0189
7	.0189	.1132	.1132	.132	.1132	.1132	.1132
8	.0189	.132	.1132	.0189	.1132	.1132	.1132
17			.0189	.0189	.0377	.0189	.0189
18			.0189	.0189	.0377	.0189	.0189
19			.0189	.0189	.0189	.0377	.0189
20			.0189	.1132	.0189	.0189	
21			.0189	.132	.1132	.0189	
22			.1132	.1132	.132	.0189	
24	.0189	.1132	.1132	.1132	.1132	.132	.0189
Max	.132	.132	.1132	.132	.132	.132	.1132
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0524	.0671	.0591	.0767	.0541	.0654	.0346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 202 / 11 KV SHANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.307	1.3256	1.307	1.2803	1.3443	1.419
2	1.251	1.2323	1.2136	1.2696	1.2696	1.307	1.3443
3	1.2323	1.251	1.1763	1.251	1.251	1.251	1.3443
4	1.251	1.2136	1.1763	1.2136	1.2136	1.2696	1.3443
5	1.251	1.2696	1.1763	1.2323	1.2323	1.2883	1.307
6	1.3443	1.419	1.251	1.3443	1.3443	1.4377	1.4377
7	1.419	1.6244	1.3256		1.307	1.4937	1.419
8	1.2883	1.4563	1.1203	1.2696	1.3443	1.419	1.2323
9	1.1949	1.307	1.1389	1.251	1.2136	1.363	1.1949
10	1.1203	1.251	1.1203	1.3256	1.2323	1.363	1.2136
11	1.1763	1.2136	1.2136	1.251	1.2136	1.2696	1.1763
12	1.2136	1.251	1.307	1.3256	1.251	1.3256	1.1949
13	1.1016	1.2136	1.251	1.2696	1.2136	1.4377	1.1949
14	1.1576	1.1576	1.251	1.2883	1.2883	1.3817	1.1949
15	1.2323	1.2136	1.251	1.3443	1.3443	1.475	1.307
16	1.251	1.307	1.307	1.2883	1.3443	1.475	1.307
17	1.2136	1.251	1.2323	1.251	1.2696	1.3443	1.307
18	1.1576	1.307	1.2136	1.1763	1.251	1.307	1.2136
19	1.6617	1.5497	1.2136	1.8298	1.363	1.9791	1.251
20	1.7737	1.9231	1.8484	1.8858	1.8671	1.8671	1.8671
21	1.8858	1.8298	1.8858	1.8671	1.7924	1.8484	1.7737
22	1.6991	1.7177	1.7551	1.7177	1.7364	1.9605	1.8484
23	1.6244	1.5684	1.6244	1.643	1.6804	1.7737	1.7551
24	1.475	1.4563	1.419	1.4563	1.4563	1.531	1.5684
Max	1.8858	1.9231	1.8858	1.8858	1.8671	1.9791	1.8671
Min	1.1016	1.1576	1.1203	1.1763	1.2136	1.251	1.1763
Avg	1.3451	1.3871	1.3249	1.3938	1.3650	1.4797	1.3840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 203 / 11 KV SHIDDHESHWAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0747	.0747	.0754	.0747	.0747
2	.0747	.0747	.0747	.0747	.0747	.0747	.0747
3	.0747	.0747	.0747	.0747	.0747	.0747	.0747
4	.0747	.0747	.0747	.0934	.0747	.0934	.0747
5	.0747	.0934	.0934	.0934	.0934	.0934	.0934
6	.112	.112	.0934	.0934	.112	.112	.0934
7	.0934	.0934	.112	.0934	.0934	.0934	.0934
8	.1868	.0934	.0747	.0934	.0934	.0934	.0934
9	.0934	.0934	.0934	.0934	.0934	.0934	.0934
10	.1307	.112	.1867	.1307	.112	.0934	.0934
11	.1494	.112	.1494	.112	.0934	.2054	.0934
12	.1494	.0934	.0934	.112	.0934	.1494	.0934
13	.0934	.112	.0934	.0934	.0934	.0934	.1307
14	.1867	.112	.0934	.1494	.0934	.0934	.1307
15	.0934	.168	.0934	.112	.0934	.1867	.0934
16	.0934	.112	.0934	.112	.0934	.1494	.0934
17	.168	.112	.0934	.0934	.0934	.1494	.0934
18	.0934	.112	.112	.1132	.0934	.0934	.112
19	.112	.1307	.1307	.0934	.112	.1307	.1307
20	.1307	.112	.112	.0934	.112	.112	.112
21	.0934	.0934	.0934	.0934	.112	.0934	.112
22	.0934	.0934	.0934	.0934	.0934	.0934	.0934
23	.0934	.0747	.0934	.0934	.0934	.0934	.0934
24	.0934	.0934	.0747	.0934	.0934	.0934	.0934
Max	.1868	.168	.1867	.1494	.112	.2054	.1307
Min	.0747	.0747	.0747	.0747	.0747	.0747	.0747
Avg	.1097	.1011	.0988	.0989	.0942	.1097	.0973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 204 / 11 KV SWAGAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3535	1.4266	1.4632	1.5364	1.5364	1.5729	1.6461
2	1.3169	1.4083	1.4632	1.4998	1.4998	1.4998	1.5729
3	1.2986	1.3717	1.3717	1.4815	1.4815	1.4449	1.4998
4	1.2803	1.3535	1.3535	1.4449	1.4449	1.4815	1.4998
5	1.39	1.4083	1.4266	1.4815	1.5364	1.4998	1.5729
6	1.6095	1.6461	1.6278	1.5729	1.5729	1.7375	1.8473
7	1.5912	1.6278	1.6644	1.5181	1.6827	1.6644	1.6461
8	1.4998	1.7741	1.5181	1.8107	1.6644	1.701	1.4998
9	1.531	1.701	1.6461	1.8107	1.7741	1.4266	1.3717
10	1.6278	1.6644	1.6461	1.8839	1.7558	1.6827	1.3169
11	1.701	1.6278	1.6827	1.8839	1.9204	1.8473	1.3169
12	1.7375	1.7741	1.7193	1.9022	1.957	1.8656	1.2803
13	1.5912	1.6827	1.6644	1.7741	1.957	1.7924	1.3535
14	1.7193	1.5181	1.7375	1.7924	1.8656	1.8107	1.39
15	1.8473	1.6827	1.8839	1.9204	2.1033	1.8839	1.4632
16	1.8656	1.7558	1.8473	1.9936	2.0485	1.8473	1.4449
17	1.7193	1.8107	1.8656	1.9022	1.9387	1.8839	.7865
18	1.8656	1.8107	1.9022	1.8656	1.957	1.8656	1.2437
19	2.3045	2.1948	2.1948	2.0302	2.2862	2.3594	1.7558
20	2.396	2.2862	2.3411	2.1948	2.4326	2.4143	1.9387
21	2.268	2.1033	2.2497	2.1399	2.268	2.2314	1.957
22	2.1948	2.1033	2.1399	2.0302	2.1948	2.3339	1.9387
23	1.7558	1.8473	1.8656	1.8473	1.8107	2.0485	1.7558
24	1.4815	1.6278	1.5912	1.6461	1.6461	1.6644	1.829
Max	2.396	2.2862	2.3411	2.1948	2.4326	2.4143	1.957
Min	1.2803	1.3535	1.3535	1.4449	1.4449	1.4266	.7865
Avg	1.7061	1.7170	1.7444	1.7901	1.8473	1.8150	1.5386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 205 / 11 kv Hatture Nager

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2926	.3109	.3292	.3292	.3292	.3292
2	.3109	.3109	.3109	.3109	.3109	.3109	.3292
3	.3109	.2926	.2926	.3109	.2926	.3109	.3292
4	.3109	.2926	.2926	.3109	.3109	.3109	.3109
5	.3475	.3292	.3109	.3109	.3292	.3475	.3292
6	.3658	.4024	.3292	.3109	.3475	.4207	.3658
7	.3658	.439	.3475	.3475	.3658	.439	.3841
8	.2926	.3475	.3109	.3109	.3109	.3658	.3109
9	.2378	.4024	.2561	.2743	.2743	.4024	.2561
10	.2378	.3658	.2195	.2378	.2926	.3658	.2378
11	.2195	.3475	.2378	.2743	.2561	.3841	.2561
12	.2561	.3292	.2743	.2926	.2743	.3658	.2743
13	.2743	.3292		.2926	.2926	.3475	.2926
14	.2926	.3292	.2926	.3109	.3109	.3475	.3109
15	.2743	.3109	.2926	.3109	.3292	.3658	.3109
16	.2743	.3109	.2926	.3109	.2926	.3292	.3109
17	.2743	.2926	.2926	.3109	.2926	.3109	.2926
18	.3109	.2926	.3109	.3292	.3292	.3292	.439
19	.4024	.439	.4024	.4024	.439	.439	.4572
20	.4572	.439	.4207	.439	.4572	.4572	.439
21	.439	.4024	.4024	.4207	.439	.4572	.4024
22	.4024	.4024	.4024	.4207	.4207	.4207	.439
23	.3658	.3841	.3841	.3658		.3841	.439
24	.3292	.3109	.3292	.3292	.3475	.3292	.3658
Max	.4572	.439	.4207	.439	.4572	.4572	.4572
Min	.2195	.2926	.2195	.2378	.2561	.3109	.2378
Avg	.3201	.3498	.3181	.3277	.3324	.3696	.3422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 403 / 33 KV KIRLOSKAR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5931	6.4415	4.537	6.7776	6.7776	6.8896	6.8336
2	4.537	4.8171	3.9769	6.6655	7.3937	7.0576	6.1054
3	4.7611	8.2899	6.9456	5.7693	6.3855	8.1219	5.0972
4	2.6886	7.6738	4.145	1.8484	5.4893	8.0659	3.8649
5	3.3608	5.7693	6.8896	2.0165	6.0494	6.1054	8.738
6	4.257	8.2899	8.626	4.9851	6.1614		6.7776
7	4.537	2.5206	6.1614	1.6804	5.8814	6.0494	1.7924
8	5.5453	6.0494	4.313	6.8896	8.626	5.0412	1.2883
9	5.5453	4.201	2.1845	4.481	6.2174	9.0181	1.0642
10	5.1532	3.1927	5.8814	6.1614	7.4497	5.1532	1.1203
11	5.3212	6.3855	8.9621	4.537	8.3459	4.7611	1.1203
12	5.2652	3.8089	3.9209	5.0972	4.481	6.2734	.9522
13	3.9209	5.9934	6.1614	2.4646	5.2092	4.0329	.9522
14	7.0016	6.2174	3.9209	6.7776	6.3855	4.481	1.1763
15	2.4646	3.5848	2.5766	2.5766	2.5766	3.9209	1.0642
16	2.4646	2.9127	4.5931	7.3377	6.3295	6.0494	.9522
17	4.537	4.481	6.9456	5.0412	5.4332	5.3772	.9522
18	4.0329	5.4332		2.8567	5.0412	4.257	1.1763
19	2.8006	7.3937	6.2174	4.0329	6.3855	7.0016	2.2965
20	4.9851	4.481	6.7215	4.481	4.537	5.7133	6.0494
21	2.2405	5.8814	7.5617	8.0659	2.4646	7.2817	5.9374
22	4.257	8.738	4.8731	6.8336	4.8171	6.2174	1.5684
23	5.7133	9.1301	6.1614	6.8336	6.2734	9.0181	3.1927
24	2.0725	3.9769	7.8418	3.3608	6.7215	5.8814	2.9127
Max	7.0016	9.1301	8.9621	8.0659	8.626	9.0181	8.738
Min	2.0725	2.5206	2.1845	1.6804	2.4646	3.9209	.9522
Avg	4.2523	5.6526	5.6573	4.8988	5.8930	6.1639	3.0410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274122 / PAPER PLANT

Feeder No / Name : 404 / 33 KV HOTGI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.4403	1.5432	1.5432	1.5432	1.5947	2.2119
2	1.6975	1.4918	1.5947	1.5947	1.5947	1.6975	2.4691
3	1.749	1.5947	1.5947	1.6461	1.6461	1.749	.9328
4	1.8004	1.6975	1.6975	1.6975	1.6975	1.8519	2.5789
5	2.0576	1.9033	1.8519	1.9547	1.9547	2.1091	1.9033
6	1.8519	2.2119	2.3663	2.3148	2.1605	1.9033	2.3663
7	2.2119	3.2922	1.9547	2.3148	2.2119	2.7778	2.9321
8	2.7263	2.8807	2.5206	2.2634	2.572	3.035	2.9835
9	2.7778	.4115	2.4177	2.9835	2.3148	2.0576	3.0864
10	.6687	1.9547	.5144	.6687	1.8004	.7202	.6173
11	2.572	2.9127	2.6235	2.9321	.2572	2.7778	2.2119
12	3.0864	2.9321	2.4691	3.5848	3.0864	3.0864	2.7263
13	2.9687	3.1379	2.8807	3.1893	2.8292	3.0864	2.572
14	2.7263	2.9835	2.6235	2.8807	2.8292	2.9835	2.6235
15	2.8292	2.9835	2.8807	2.9835	2.8292	2.8807	2.572
16	2.9321	3.035	3.0864	2.3148	2.8807	2.8292	2.572
17	2.9321	3.1379	3.0864	2.9835	2.6235	3.1367	2.0576
18	1.4918	2.7778	1.6461	2.8807	2.9835	3.1927	2.3663
19	1.0288	.9259	.8745	1.1317	.9259	1.1763	.9259
20	1.0802	1.0802	1.0802	1.1831	1.0802	1.1763	1.0802
21	1.1317	1.0288	1.1831	1.1317	1.0802	1.2323	1.0802
22	.9774	1.0288	1.0802	1.0802	.9774	1.2323	1.1317
23	.9259	.823	.9259	.9259	.8745	.9259	.9774
24	.823	1.1831	.6687	1.5947	.6687	.6173	.8745
Max	3.0864	3.2922	3.0864	3.5848	3.0864	3.1927	3.0864
Min	.6687	.4115	.5144	.6687	.2572	.6173	.6173
Avg	1.9455	2.0354	1.8819	2.0741	1.8926	2.0762	1.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 201 / 11 KV FURDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4252	.3898		.5138	
2			.4075	.3898		.4961	
3			.3898	.3366		.4784	
4			.3721	.3366		.4607	
5			.3544	.3366		.443	
6			.3544	.3366		.4252	
7			.3544	.3366		.4252	
8			.4075	.3721		.3439	
9	.3439	.3077	.3544	.3721	.3582	.3439	.3439
10	.3077	.3077	.3982	.3721	.3544	.362	.362
11	.3077	.3077	.3801	.3721	.362	.362	.362
12	.3258	.3258	.3982	.3721	.3801	.3801	.362
13	.3439	.3801	.3801	.3721	.3982	.3982	.4163
14	.362	.3982	.3801	.3721	.4163	.4344	.4525
15	.362	.362	.362		.4163	.4163	.3982
16	.362	.3801			.4163	.4163	.4163
17		.3544			.5316		
18		.3544			.567		
19		.443			.6201		
20		.4784			.6556		
21		.4961			.6201		
22		.4784			.567		
23		.4607			.5493		
24			.443	.4607		.5316	
Max	.362	.4961	.443	.4607	.6556	.5316	.4525
Min	.3077	.3077	.3544	.3366	.3544	.3439	.3439
Avg	.3394	.3890	.3851	.3685	.4808	.4254	.3892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 202 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.394	.3582		.4298	
2			.3761	.3224		.4119	
3			.3582	.3224		.394	
4			.3403	.3224		.3761	
5			.3403	.3224		.3761	
6			.3403	.3224		.3761	
7			.3403	.3582		.3761	
8			.3403	.3582		.362	
9	.3077	.2896	.3403	.3582	.3258	.362	.362
10	.2715	.2896	.3077	.3403	.2896	.3439	.3439
11	.2715	.2896	.3258	.3403	.3077	.3258	.3258
12	.2715	.3077	.3258	.3403	.3077	.3258	.2896
13	.3077	.3077		.3403	.3077	.3439	.362
14	.3258	.3077	.3439	.3403	.3258	.362	.3801
15	.3077	.3258	.362		.3258	.3801	.362
16	.2865	.3439			.3258	.3982	.362
17		.3582			.4119		.362
18		.5373			.4835		
19		.4298			.5014		
20		.4835			.5194		
21		.5014			.5068		
22		.4656			.4835		
23		.4298			.4656		
24			.4119	.3761		.4477	
Max	.3258	.5373	.4119	.3761	.5194	.4477	.3801
Min	.2715	.2896	.3077	.3224	.2896	.3258	.2896
Avg	.2937	.3778	.3498	.3415	.3925	.3760	.3499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 203 / 11 KV VIJAPUR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2715	.2507		.3045	
2			.2534	.2507		.2865	
3			.2534	.2507		.2686	
4			.2534	.2328		.2686	
5			.2534	.2328		.2686	
6			.2534	.2328		.2686	
7			.2534	.2507		.2686	
8			.2353	.2507		.2715	
9	.2534	.2172	.2534	.2507	.2534	.2715	.2534
10	.2534	.2172	.2534	.2507	.2534	.2715	.2353
11	.2507	.2172	.2534	.2507	.2534	.2715	.2534
12	.2534	.2534	.2534	.2507	.2715	.2715	.2715
13	.2534	.2534	.2715	.2507	.2715	.2715	.2896
14	.2715	.2534	.2715	.2507	.2896	.2896	.3077
15	.2715	.2534	.2896		.2896	.2715	.3077
16	.2715	.2534			.2896	.2534	.3077
17		.2715			.3582		
18		.3174			.394		
19		.3258			.394		
20		.3439			.4119		
21		.3439			.394		
22		.3258			.3582		
23		.3077			.3403		
24			.2896	.2865		.3224	
Max	.2715	.3439	.2896	.2865	.4119	.3224	.3077
Min	.2507	.2172	.2353	.2328	.2534	.2534	.2353
Avg	.2599	.2770	.2602	.2495	.3215	.2765	.2783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 204 / 11 KV ITI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-MAR-18	24-MAR-18
HR	Load (MW)	Load (MW)
8		.0181
9	.0181	
Max	.0181	.0181
Min	.0181	.0181
Avg	.0181	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-MAR-18 and 28-MAR-18

BARAMATI ZONE[052]

SOLAPUR CIRCLE[530]

SOLAPUR URBAN DIVISION[131]

SOLAPUR (E) S/DN.[579] BU 4579

Substation No/ Name :- 274184 / 33/11 KV I.T.I SUB STATION

Feeder No / Name : 205 / 11 KV RAMLING NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-MAR-18	23-MAR-18	24-MAR-18	25-MAR-18	26-MAR-18	27-MAR-18	28-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1629	.181		.1629	
2			.1629	.1629		.1629	
3			.1629	.1629		.1629	
4				.1629		.1629	
5			.1629	.1629		.1629	
6			.1629	.181		.1629	
7			.1629	.181		.1629	
8			.181	.2172		.181	
9	.181	.1629	.1629	.2172	.1991	.181	.1448
10	.181	.1448	.181	.1991	.181	.181	.1629
11	.1448	.1448	.1448	.181	.181	.181	.1629
12	.1267	.1629	.1267	.1629	.1629	.1629	.1629
13	.1448	.1629	.1448	.1629	.181	.181	.181
14	.1448	.1629	.1448	.1629	.181	.1991	.181
15	.1448	.181	.1448		.181	.1991	.181
16	.1448	.181			.181	.2172	.181
17		.1991			.1991		
18		.1991			.1991		
19		.1991			.1991		
20		.1991			.1991		
21		.1991			.1991		
22		.1991			.1991		
23		.1991			.181		
24			.181	.181		.1629	
Max	.181	.1991	.181	.2172	.1991	.2172	.181
Min	.1267	.1448	.1267	.1629	.1629	.1629	.1448
Avg	.1516	.1798	.1593	.1786	.1882	.1757	.1697