

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284029 / 33/11 KV TAPS SUBSTATION

Feeder No / Name : 200 / TAPS Substation
transformer Feeder KV- 11 /
OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| 2 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| 3 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| 4 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| 5 | .0038 | .0036 | .0038 | | .0038 | .0038 | |
| 6 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| 7 | .0019 | .0036 | .0038 | | .0019 | .0019 | .0038 |
| 8 | .0019 | .0018 | .0019 | | .0019 | .0019 | .0019 |
| 9 | .0018 | .0018 | .0018 | | | | .0019 |
| 10 | .0018 | .0018 | .0018 | .0018 | | | |
| 11 | .0018 | .0018 | .0018 | .0018 | | | |
| 12 | .0018 | .0018 | .0018 | .0018 | | | |
| 13 | .0018 | .0018 | .0018 | .0018 | | | |
| 14 | .0018 | .0018 | .0018 | .0018 | | | |
| 15 | .0018 | .0018 | .0018 | .0018 | | | |
| 16 | .0018 | .0018 | .0018 | .0018 | | .0019 | |
| 17 | .0018 | .0018 | .0018 | .0019 | | .0019 | |
| 18 | .0018 | .0019 | | .0019 | .0019 | | .0019 |
| 19 | .0018 | .0019 | | .0019 | .0019 | .0019 | .0019 |
| 20 | .0036 | .0036 | | .0038 | .0038 | .0038 | .0038 |
| 21 | .0036 | .0036 | | .0038 | .0038 | .0038 | .0038 |
| 22 | .0036 | .0036 | | .0038 | .0038 | .0038 | .0038 |
| 23 | .0036 | .0036 | | | .0038 | .0038 | .0038 |
| 24 | .0038 | .0036 | .0038 | | .0038 | .0038 | .0038 |
| Max | .0038 | .0036 | .0038 | .0038 | .0038 | .0038 | .0038 |
| Min | .0018 | .0018 | .0018 | .0018 | .0019 | .0019 | .0019 |
| Avg | .0027 | .0027 | .0027 | .0023 | .0033 | .0032 | .0033 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284029 / 33/11 KV TAPS SUBSTATION

Feeder No / Name : 202 / 11 KV BOISAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7164 | 1.7147 | 1.7337 | 1.9243 | 1.829 | 1.773 | 1.829 |
| 2 | 1.6598 | 1.6004 | 1.7147 | 1.829 | 1.7528 | 1.7164 | 1.8099 |
| 3 | 1.6032 | 1.5242 | 1.6575 | 1.7909 | 1.5432 | 1.6409 | 1.7718 |
| 4 | 1.5278 | 1.4861 | 1.6004 | 1.7147 | 1.5242 | 1.5655 | 1.6766 |
| 5 | 1.4523 | 1.4098 | 1.5242 | 1.6766 | 1.448 | 1.4901 | 1.6194 |
| 6 | 1.3957 | 1.3336 | 1.4289 | 1.6004 | 1.4098 | 1.4146 | 1.4289 |
| 7 | 1.3392 | 1.2765 | 1.3527 | 1.4098 | 1.8099 | 1.3769 | 1.3908 |
| 8 | 1.3014 | 1.2193 | 1.2955 | 1.3146 | 1.2384 | 1.3203 | 1.2955 |
| 9 | 1.1812 | 1.2384 | 1.3146 | 1.2574 | 1.2574 | 1.2765 | 1.2384 |
| 10 | 1.2384 | 1.2574 | 1.3146 | 1.2574 | 1.2765 | | 1.2765 |
| 11 | 1.2003 | 1.2384 | 1.3336 | 1.2574 | 1.2574 | | |
| 12 | 1.1812 | 1.2193 | 1.2765 | 1.2384 | | | 1.3146 |
| 13 | 1.1812 | 1.2574 | 1.3336 | 1.2765 | | | 1.3146 |
| 14 | 1.2384 | 1.0288 | 1.3336 | 1.2765 | 1.2765 | 1.8671 | 1.2955 |
| 15 | 1.2574 | 1.1241 | 1.2955 | 1.2765 | 1.2574 | 1.7147 | 1.3146 |
| 16 | 1.2384 | 1.1241 | 1.2765 | 1.2765 | 1.2384 | 1.5813 | 1.2955 |
| 17 | 1.2384 | 1.2384 | 1.2955 | 1.2384 | 1.2193 | 1.467 | 1.2384 |
| 18 | 1.2003 | 1.226 | | 1.2384 | 1.1694 | 1.3146 | 1.226 |
| 19 | 1.2765 | 1.3014 | 1.4289 | 1.3717 | 1.3203 | 1.448 | 1.4901 |
| 20 | 1.5432 | 1.5623 | 1.6194 | 1.6004 | 1.5655 | 1.6956 | 1.6221 |
| 21 | 1.5432 | 1.6004 | 1.6194 | 1.6194 | 1.5844 | 1.7528 | 1.5844 |
| 22 | 1.6004 | 1.7528 | 1.7147 | 1.6956 | 1.6598 | 1.829 | 1.6598 |
| 23 | 1.7718 | 1.8861 | 1.9052 | 1.8671 | 1.8861 | 2.0195 | 1.8673 |
| 24 | 1.773 | 1.8099 | 3.6967 | 1.9814 | 1.8861 | 1.8673 | 1.9243 |
| Max | 1.773 | 1.8861 | 3.6967 | 1.9814 | 1.8861 | 2.0195 | 1.9243 |
| Min | 1.1812 | 1.0288 | 1.2765 | 1.2384 | 1.1694 | 1.2765 | 1.226 |
| Avg | 1.4025 | 1.3929 | 1.5681 | 1.4996 | 1.4732 | 1.6066 | 1.4993 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284029 / 33/11 KV TAPS SUBSTATION

Feeder No / Name : 205 / 11 KV MAHAGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5089 | 1.6194 | 1.6194 | 1.829 | 1.7718 | 1.6975 | 1.6956 |
| 2 | 1.4335 | 1.5813 | 1.6194 | 1.7909 | 1.7337 | 1.6409 | 1.6766 |
| 3 | 1.3769 | 1.5242 | 1.5813 | 1.7147 | 1.5242 | 1.6032 | 1.6385 |
| 4 | 1.3014 | 1.5242 | 1.5432 | 1.6766 | 1.5432 | 1.5844 | 1.6194 |
| 5 | 1.2637 | 1.5051 | 1.5242 | 1.6385 | 1.5242 | 1.5466 | 1.5813 |
| 6 | 1.3203 | 1.4289 | 1.5432 | 1.6004 | 1.5051 | 1.5466 | 1.5623 |
| 7 | 1.2449 | 1.3908 | 1.3336 | 1.5242 | 1.3908 | 1.4146 | 1.448 |
| 8 | 1.2449 | 1.3527 | 1.4289 | 1.3527 | 1.3527 | 1.4146 | 1.3908 |
| 9 | 1.2765 | 1.2955 | 1.4289 | 1.2955 | 1.3336 | 1.3908 | 1.3527 |
| 10 | 1.3908 | 1.2193 | 1.3908 | 1.2955 | 1.2384 | | 1.3527 |
| 11 | 1.3527 | 1.2574 | 1.3908 | 1.3146 | 1.2574 | | |
| 12 | 1.3527 | 1.2384 | 1.4289 | 1.2765 | | | 1.448 |
| 13 | 1.3146 | 1.2574 | 1.3717 | 1.2955 | | | |
| 14 | 1.2765 | 1.2574 | 1.3717 | 1.2765 | 1.448 | 1.829 | 1.5051 |
| 15 | 1.2765 | 1.2193 | 1.3336 | 1.2765 | 1.4098 | 1.7147 | 1.3717 |
| 16 | 1.2384 | 1.2384 | 1.3527 | 1.2765 | 1.3146 | 1.5242 | 1.3336 |
| 17 | 1.2384 | 1.1622 | 1.3336 | 1.2955 | 1.3146 | 1.4289 | 1.1622 |
| 18 | 1.3336 | 1.2637 | | 1.3336 | 1.3392 | 1.4098 | 1.3392 |
| 19 | 1.4861 | 1.2449 | 1.6004 | 1.467 | 1.5655 | 1.6385 | |
| 20 | 1.6766 | 1.5813 | 1.829 | 1.7147 | 1.7353 | 1.8099 | 1.6409 |
| 21 | 1.7909 | 1.7909 | 1.9052 | | 1.8673 | 1.9243 | 1.6975 |
| 22 | 1.7528 | 1.7909 | 1.829 | 1.8099 | 1.8673 | 1.9052 | 1.6598 |
| 23 | | 1.7718 | 1.829 | 1.7718 | 1.8296 | 1.8861 | 1.6787 |
| 24 | 1.5655 | 1.6956 | 3.5443 | 1.8671 | | 1.7541 | 1.7718 |
| Max | 1.7909 | 1.7909 | 3.5443 | 1.8671 | 1.8673 | 1.9243 | 1.7718 |
| Min | 1.2384 | 1.1622 | 1.3336 | 1.2765 | 1.2384 | 1.3908 | 1.1622 |
| Avg | 1.3920 | 1.4255 | 1.6145 | 1.5084 | 1.5174 | 1.6332 | 1.5203 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284029 / 33/11 KV TAPS SUBSTATION

Feeder No / Name : 206 / 11 KV Tarapur Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.5837 | 3.4294 | 3.5246 | 3.8866 | 3.7151 | 2.1502 | 4.02 |
| 2 | 3.546 | 3.315 | 3.4865 | 3.8295 | 3.2769 | 2.0559 | 3.9819 |
| 3 | 3.4894 | 3.3341 | 3.4294 | 3.6961 | 3.2769 | 1.9239 | 3.9628 |
| 4 | 3.3951 | 3.296 | 3.4484 | 3.6199 | 3.2579 | 3.6969 | 3.8676 |
| 5 | 3.3008 | 3.2769 | 3.5246 | 3.4294 | 3.3341 | 3.5648 | 3.6199 |
| 6 | 3.1876 | 3.2388 | 3.5818 | 3.315 | 3.7151 | 3.4517 | 3.5818 |
| 7 | 3.2253 | 3.2388 | 3.3722 | 3.2198 | 3.5056 | 3.3573 | 3.5246 |
| 8 | 3.263 | 3.1817 | 3.4675 | 3.1626 | 3.4103 | 3.4517 | 3.5056 |
| 9 | 3.2579 | 3.3341 | 3.4294 | 2.9531 | 3.2007 | 3.1055 | 3.5627 |
| 10 | 3.0293 | 3.0293 | 3.3532 | 3.0864 | 3.1055 | 3.1626 | 3.4865 |
| 11 | 3.1817 | 3.1817 | | 2.934 | 2.9912 | 2.9721 | |
| 12 | 2.934 | 3.0483 | 3.2388 | 3.0293 | | | 3.0293 |
| 13 | 2.9531 | 2.8959 | 3.0674 | 2.8387 | 2.7625 | | |
| 14 | 2.9912 | 2.8959 | 3.1626 | 2.915 | | | 3.0483 |
| 15 | 2.9531 | 3.0864 | 3.1055 | 2.9721 | | | 3.0864 |
| 16 | 2.934 | 3.0483 | 3.2579 | 2.9721 | 3.7913 | | 3.1436 |
| 17 | 2.6482 | 2.934 | 2.915 | 3.0102 | 3.2579 | | 3.2198 |
| 18 | 2.8387 | 2.8104 | | 2.8769 | 3.0367 | | 2.9613 |
| 19 | 3.1817 | 2.8292 | 3.0102 | 3.1055 | 3.0744 | | 3.6969 |
| 20 | 3.8104 | 2.0576 | 3.7342 | 3.7913 | 4.0364 | 5.4108 | 3.7534 |
| 21 | 3.7723 | 3.8485 | 3.7723 | 3.9057 | 3.81 | 5.0488 | 3.7534 |
| 22 | 3.8295 | 4.0009 | 3.7723 | 4.02 | 3.8477 | 4.8583 | 2.9801 |
| 23 | 3.8295 | 4.02 | 3.8676 | 3.9438 | 3.8666 | 4.6868 | 3.6403 |
| 24 | 3.6969 | 3.4675 | 3.7151 | 3.9819 | 3.8295 | 3.7723 | 4.039 |
| Max | 3.8295 | 4.02 | 3.8676 | 4.02 | 4.0364 | 5.4108 | 4.039 |
| Min | 2.6482 | 2.0576 | 2.915 | 2.8387 | 2.7625 | 1.9239 | 2.9613 |
| Avg | 3.2847 | 3.1999 | 3.4198 | 3.3540 | 3.4334 | 3.5419 | 3.5211 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284029 / 33/11 KV TAPS SUBSTATION

Feeder No / Name : 207 / 11 KV GANESH NAGAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.0182 | 2.1719 | 2.0767 | 2.2862 | 2.0957 | 2.1691 | 2.2862 |
| 2 | 1.9239 | 1.9433 | 2.0005 | 2.2291 | 2.0005 | 2.0936 | 2.191 |
| 3 | 1.8673 | 1.9243 | 1.9243 | 2.1719 | 1.9052 | 2.0182 | 1.9243 |
| 4 | 1.8107 | 1.8861 | 1.9433 | 2.0767 | 1.8861 | 1.8861 | 1.8861 |
| 5 | 1.7353 | 1.8671 | 1.9052 | 1.9243 | 1.8099 | 1.8296 | 1.8671 |
| 6 | 1.7918 | 1.7337 | 1.8671 | 1.8671 | 1.829 | 1.7541 | 1.8671 |
| 7 | 1.5844 | 1.6004 | 1.6575 | 1.6575 | 1.6385 | 1.6787 | 1.6766 |
| 8 | 1.5844 | 1.6766 | 1.6766 | 1.6385 | 1.6194 | 1.6409 | 1.7147 |
| 9 | 1.6004 | 1.4861 | 1.6385 | 1.6194 | 1.7147 | 1.6766 | 1.7528 |
| 10 | 1.6766 | 1.5813 | 1.7528 | 1.829 | 1.7909 | | |
| 11 | 1.6956 | 1.7909 | 1.7528 | 1.8099 | 1.7718 | | |
| 12 | 1.6385 | 1.8099 | 1.8099 | 1.8671 | | | 1.7718 |
| 13 | 1.7528 | 1.7147 | 1.7718 | 1.8671 | | | |
| 14 | 1.6956 | 1.7337 | 1.7718 | 1.848 | 1.848 | 2.6482 | 1.829 |
| 15 | 1.7337 | 1.7147 | 1.7528 | 1.9243 | 1.8861 | 2.4768 | 1.7337 |
| 16 | 1.6194 | 1.7528 | 1.7528 | 1.848 | 1.8861 | 2.3815 | 1.7147 |
| 17 | 1.6766 | 1.7528 | 1.7909 | 1.8671 | 1.848 | 2.0576 | 1.7147 |
| 18 | 1.6385 | 1.6787 | | 1.829 | 1.7164 | 1.6956 | 1.5089 |
| 19 | 1.8671 | 1.773 | 1.9243 | 1.9243 | 1.8673 | 1.7337 | 2.0748 |
| 20 | 2.1338 | 2.1148 | 2.191 | 2.1719 | 2.1502 | 2.3243 | 2.2445 |
| 21 | 2.1338 | 2.191 | 2.191 | 2.1719 | 2.1313 | 2.4196 | 2.0936 |
| 22 | 2.0767 | 2.1719 | 2.1529 | 2.1719 | 2.1502 | 2.3624 | 2.1313 |
| 23 | 2.21 | 2.2481 | 2.3243 | 2.2672 | 2.2822 | 2.4196 | 2.2445 |
| 24 | 2.0748 | 2.21 | 2.2291 | 2.3815 | 2.191 | 2.2634 | 4.2676 |
| Max | 2.21 | 2.2481 | 2.3243 | 2.3815 | 2.2822 | 2.6482 | 4.2676 |
| Min | 1.5844 | 1.4861 | 1.6385 | 1.6194 | 1.6194 | 1.6409 | 1.5089 |
| Avg | 1.8142 | 1.8553 | 1.9069 | 1.9687 | 1.9099 | 2.0765 | 2.0236 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284030 / 33/11 KV DEDALE SUBSTATION

Feeder No / Name : 201 / 11 KV VANGAON FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.8296 |
| Max | 1.8296 |
| Min | 1.8296 |
| Avg | 1.8296 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284030 / 33/11 KV DEDALE SUBSTATION

Feeder No / Name : 202 / 11 KV CHINCHANI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.773 |
| Max | 1.773 |
| Min | 1.773 |
| Avg | 1.773 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284030 / 33/11 KV DEDALE SUBSTATION

Feeder No / Name : 203 / 11 KV VAROR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 1.6409 |
| Max | 1.6409 |
| Min | 1.6409 |
| Avg | 1.6409 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284030 / 33/11 KV DEDALE SUBSTATION

Feeder No / Name : 204 / 11 KV SAKHARE FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 1.2071 |
| Max | 1.2071 |
| Min | 1.2071 |
| Avg | 1.2071 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284040 / 33/11 KV WARANGADE SUBSTN

Feeder No / Name : 200 / Warangade Substation

Transform Feeder KV- 11 /
OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 2 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 3 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 4 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 5 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 6 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| 7 | .0171 | .0343 | .0189 | .0343 | .0189 | .0189 | |
| 8 | .0171 | .0343 | .0189 | .0343 | .0189 | .0189 | .0171 |
| 9 | .0171 | .0171 | .0189 | .0171 | .0189 | .0189 | .0171 |
| 10 | .0171 | .0189 | .0189 | .0189 | .0189 | .0171 | .0171 |
| 11 | .0171 | | .0171 | .0189 | .0189 | .0171 | .0171 |
| 12 | .0171 | .0189 | .0189 | .0189 | .0189 | | .0171 |
| 13 | .0171 | | .0171 | .0189 | .0189 | | .0171 |
| 14 | .0171 | .0189 | .0171 | .0189 | .0189 | .0171 | .0171 |
| 15 | .0171 | .0189 | .0381 | .0189 | .0189 | | .0171 |
| 16 | .0171 | .0189 | .0381 | .0189 | .0189 | | .0171 |
| 17 | .0171 | .0189 | .0381 | .0189 | .0189 | | .0171 |
| 18 | .0171 | .0189 | .0381 | .0189 | .0189 | .0171 | .0171 |
| 19 | .0171 | .0377 | .0171 | .0377 | .0377 | .0171 | .0171 |
| 20 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 | .0343 |
| 21 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 | .0343 |
| 22 | .0343 | .0377 | | .0377 | .0377 | .0343 | .0343 |
| 23 | .0343 | .0377 | | .0377 | .0377 | .0171 | .0343 |
| 24 | .0343 | .0343 | .0377 | .0343 | .0377 | .0377 | .0343 |
| Max | .0343 | .0377 | .0381 | .0377 | .0377 | .0377 | .0343 |
| Min | .0171 | .0171 | .0171 | .0171 | .0189 | .0171 | .0171 |
| Avg | .0250 | .0294 | .0294 | .0285 | .0283 | .0277 | .0253 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284040 / 33/11 KV WARANGADE SUBSTN

Feeder No / Name : 201 / 11 KV NAGZARI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.2977 | 1.7147 | 2.2634 | 1.7147 | 2.2634 | 2.2634 | 2.332 |
| 2 | 2.2977 | | 2.2257 | 1.6804 | 2.2445 | 2.4897 | 2.2291 |
| 3 | 2.0233 | 1.6804 | 2.1691 | 1.6461 | 2.1691 | 2.3388 | 2.0233 |
| 4 | 2.0233 | 1.6461 | 2.0748 | 1.6461 | 2.037 | 2.452 | 1.8004 |
| 5 | 1.8861 | 1.6804 | 2.0559 | 1.7147 | 1.9427 | 2.6029 | 1.9204 |
| 6 | | 2.0233 | 1.9239 | 1.9204 | 1.9239 | 2.2634 | 2.1605 |
| 7 | 1.8519 | 2.332 | 1.9427 | 2.332 | 2.5463 | 2.2257 | 2.0576 |
| 8 | 1.6289 | 2.6749 | 2.3765 | 2.7435 | 2.6029 | 2.6406 | 3.1722 |
| 9 | 1.6289 | 3.6214 | 2.0559 | 3.3265 | 2.6217 | 3.546 | 1.989 |
| 10 | 1.5432 | 3.8666 | 1.7541 | 3.6025 | 3.4517 | .4801 | 2.0233 |
| 11 | 1.5775 | 4.1307 | 1.5089 | 3.2819 | 3.6591 | .5144 | |
| 12 | 1.6804 | 3.5271 | 1.6221 | 3.4705 | 3.3008 | .6859 | 3.4637 |
| 13 | 1.6118 | 3.0367 | 1.5089 | 2.6972 | 2.3765 | .6859 | 2.7092 |
| 14 | 1.5775 | 3.4328 | 1.4575 | 2.6406 | 2.7349 | .6859 | 2.7778 |
| 15 | 1.6118 | 2.9801 | 1.6461 | 3.678 | 2.3765 | .703 | 1.5432 |
| 16 | 1.6461 | 3.3008 | 1.7147 | 3.4705 | 3.7723 | .7716 | 3.5665 |
| 17 | 1.6461 | 3.0933 | 1.8176 | 3.4894 | 3.1687 | .6859 | 3.1207 |
| 18 | 1.6461 | 3.0178 | 1.7147 | 2.8292 | 3.0556 | 2.7092 | 2.6406 |
| 19 | 1.9204 | 3.263 | 2.2291 | 2.7915 | 3.0933 | 2.915 | 2.572 |
| 20 | 2.1948 | 3.6214 | 2.5377 | 3.0933 | 2.9235 | 3.0521 | 2.915 |
| 21 | 2.2291 | 2.999 | 2.2634 | 2.9613 | 2.8669 | 2.7435 | 2.915 |
| 22 | 2.0919 | 2.6972 | | 2.8292 | 2.4897 | 2.6749 | 2.6406 |
| 23 | 1.9547 | 2.2634 | | 2.452 | 2.1879 | 2.4863 | 2.4691 |
| 24 | 2.3663 | 1.749 | 2.3388 | 1.8176 | 2.5274 | 2.1125 | 2.4006 |
| Max | 2.3663 | 4.1307 | 2.5377 | 3.678 | 3.7723 | 3.546 | 3.5665 |
| Min | 1.5432 | 1.6461 | 1.4575 | 1.6461 | 1.9239 | .4801 | 1.5432 |
| Avg | 1.8668 | 2.7979 | 1.9637 | 2.6595 | 2.6807 | 1.9470 | 2.4975 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284040 / 33/11 KV WARANGADE SUBSTN

Feeder No / Name : 202 / 11 KV VANJARWADA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.2922 | 3.6591 | | 3.155 | 3.9609 | 3.9609 | 3.4294 |
| 2 | 3.2922 | 3.5837 | | .3086 | 3.9986 | 3.9986 | 3.3436 |
| 3 | 3.2579 | 3.5082 | | 3.0178 | 3.7723 | 3.7723 | 3.2579 |
| 4 | 3.1893 | 3.263 | | 2.9492 | 3.7912 | 3.6403 | 3.1893 |
| 5 | 3.0521 | 3.1687 | | 2.915 | 3.5837 | 3.2065 | 3.2236 |
| 6 | | 3.2065 | | 2.9492 | 3.2819 | 3.2442 | 3.1893 |
| 7 | 2.8464 | 3.131 | 3.131 | 2.8464 | 3.0178 | 3.0933 | 2.8978 |
| 8 | 2.5892 | 2.572 | 3.0367 | 2.6063 | 2.9047 | 2.8292 | 2.7092 |
| 9 | 2.6578 | 2.572 | 3.1876 | 2.6063 | 2.7161 | 2.8669 | 2.7263 |
| 10 | 2.5377 | 2.9047 | 2.999 | 2.7915 | 2.7726 | 2.5377 | 2.6063 |
| 11 | 2.572 | 2.8481 | 2.7092 | 2.584 | 2.8292 | 2.0919 | 2.6063 |
| 12 | 2.572 | 2.7726 | 3.0744 | 2.6595 | 2.4331 | | 2.572 |
| 13 | 2.572 | 2.7161 | 2.6406 | 2.5463 | 2.8669 | | 2.7092 |
| 14 | 2.5034 | 2.6972 | 2.6063 | 2.6406 | 2.7349 | 2.4006 | 2.5377 |
| 15 | 2.4691 | 2.7349 | 2.572 | 2.6029 | 2.8669 | 2.332 | 2.6063 |
| 16 | 2.4691 | 2.3011 | 2.7092 | 2.6783 | 2.6972 | 2.1948 | 2.5377 |
| 17 | 2.4348 | 2.1313 | 2.6749 | 2.0936 | 2.6783 | 2.4006 | 2.5377 |
| 18 | 2.3663 | 2.5652 | 2.4006 | 2.037 | 2.6783 | 2.4863 | 2.332 |
| 19 | 2.6406 | 3.131 | 2.6406 | 2.2068 | 2.8858 | 2.6406 | 2.572 |
| 20 | 3.2579 | 3.678 | 3.3608 | 2.7161 | 3.5648 | 3.5151 | 3.3265 |
| 21 | 3.3265 | 3.8477 | 3.5665 | 3.9232 | 3.9986 | 3.6866 | 3.5322 |
| 22 | 3.4637 | 3.8477 | | 3.8855 | 4.0741 | 3.6351 | 3.4979 |
| 23 | 3.4294 | | | 3.8855 | 3.9798 | 3.5665 | 3.4294 |
| 24 | 3.3436 | 3.3265 | .4001 | 3.2922 | 3.9232 | 3.7912 | 3.4637 |
| Max | 3.4637 | 3.8477 | 3.5665 | 3.9232 | 4.0741 | 3.9986 | 3.5322 |
| Min | 2.3663 | 2.1313 | .4001 | .3086 | 2.4331 | 2.0919 | 2.332 |
| Avg | 2.8754 | 3.0507 | 2.7318 | 2.7457 | 3.2505 | 3.0860 | 2.9514 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284040 / 33/11 KV WARANGADE SUBSTN

Feeder No / Name : 203 / 11 KV TALEKHAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4287 | .5093 | | .4115 | .3772 | .5093 | .4115 |
| 2 | .4115 | .5281 | | .3944 | .3584 | .4338 | .4115 |
| 3 | .4115 | .4715 | | .3601 | .3206 | .415 | .4115 |
| 4 | .3944 | .4527 | | .3429 | .3395 | .3961 | .1715 |
| 5 | .3944 | .3772 | | .3429 | .3018 | .3584 | .4115 |
| 6 | .4115 | .3584 | | .3429 | .2641 | .3395 | .3772 |
| 7 | .3601 | .3018 | .3018 | .3086 | .3395 | .3395 | .3429 |
| 8 | .3086 | .3086 | .2829 | .2915 | .2829 | .3584 | .2915 |
| 9 | .3258 | .3429 | .3018 | .3601 | .3206 | .3772 | .4115 |
| 10 | .3429 | .3772 | .2829 | .415 | .3395 | .3772 | .4458 |
| 11 | .4115 | .3584 | .3086 | .4527 | .3584 | .3944 | .4115 |
| 12 | .3086 | .3584 | .3018 | .3772 | .3772 | .3258 | .3429 |
| 13 | .2915 | .3018 | .2743 | .3584 | .3961 | .3086 | .3429 |
| 14 | .3258 | .3018 | .2401 | .3961 | .3772 | .3086 | .3944 |
| 15 | .3258 | .3584 | .2743 | .3772 | .3961 | .2743 | .3772 |
| 16 | .3086 | .3206 | .3258 | .3584 | .3584 | .2915 | .3772 |
| 17 | .3429 | .3772 | .3086 | .3772 | .3772 | .3086 | .4115 |
| 18 | .3258 | .2829 | .2915 | .3772 | .3584 | .3086 | .3772 |
| 19 | .3429 | .3206 | .3429 | .3772 | .3206 | .3086 | .3772 |
| 20 | .4458 | .4338 | .4458 | .3584 | .3584 | .463 | .4801 |
| 21 | .4801 | .4527 | .4973 | .3772 | .5658 | .4801 | .5316 |
| 22 | .463 | .4715 | | .415 | .547 | .4801 | .5316 |
| 23 | .4458 | | | .4527 | .4904 | .4801 | .4801 |
| 24 | .4287 | .463 | .4001 | .4287 | .4904 | .4715 | .4115 |
| Max | .4801 | .5281 | .4973 | .4527 | .5658 | .5093 | .5316 |
| Min | .2915 | .2829 | .2401 | .2915 | .2641 | .2743 | .1715 |
| Avg | .3765 | .3839 | .3238 | .3772 | .3757 | .3795 | .3972 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284040 / 33/11 KV WARANGADE SUBSTN

Feeder No / Name : 401 / 33 KV KISSAN MOULDING NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3375 | 1.6409 | | .1143 | 1.6409 | 1.5278 | 1.5432 |
| 2 | 1.3375 | 1.4146 | | .1143 | 1.5278 | 1.4712 | 1.5432 |
| 3 | 1.3375 | 1.1883 | | .1143 | 1.3014 | 1.4146 | 1.4403 |
| 4 | 1.2346 | 1.0751 | | .1143 | 1.1883 | 1.0751 | 1.4403 |
| 5 | 1.2346 | 1.0185 | | .1143 | 1.0751 | 1.1317 | 1.4403 |
| 6 | 1.2346 | .9619 | | .1143 | 1.0185 | 1.358 | 1.4403 |
| 7 | 1.2346 | 1.4289 | | .1143 | .9619 | 1.5844 | 1.286 |
| 8 | .6687 | 1.3146 | .9619 | .1143 | .9619 | 1.5844 | 1.0288 |
| 9 | 1.2346 | 2.0576 | .9619 | .1143 | 1.0185 | 1.6409 | 1.4918 |
| 10 | 1.4861 | 2.2068 | .1132 | .0566 | 1.6409 | 1.749 | 2.0005 |
| 11 | 1.7147 | 2.2068 | .1029 | 1.1883 | 1.8107 | 1.6461 | 2.0576 |
| 12 | 1.6575 | 2.1502 | .1132 | 1.2449 | 1.7541 | 1.5947 | 2.1719 |
| 13 | 1.1831 | 1.7541 | .1029 | 1.1883 | 1.0751 | 1.5432 | 1.9433 |
| 14 | 1.286 | 1.8673 | | 1.4146 | 1.2449 | 1.4403 | 2.0576 |
| 15 | 1.6575 | 2.0936 | | 1.5844 | 1.8107 | 1.9033 | 1.9433 |
| 16 | 1.7147 | 2.037 | | 1.358 | 2.037 | 1.5947 | 1.829 |
| 17 | 1.8861 | 2.0936 | | 1.5844 | 1.8107 | 1.6461 | 1.8861 |
| 18 | 1.6004 | 1.8673 | | 1.4712 | 1.6975 | 1.5432 | 1.9433 |
| 19 | 1.4861 | 1.5278 | .1143 | 1.4146 | 1.8107 | 1.4403 | 1.829 |
| 20 | 1.086 | 1.4146 | .1143 | 1.0751 | 1.5844 | 1.1317 | 1.2574 |
| 21 | 1.7147 | 1.6975 | .1143 | 1.6409 | 1.5844 | 1.286 | 1.5432 |
| 22 | 1.5432 | 1.4712 | | 1.5844 | 1.8673 | 1.2346 | 1.5432 |
| 23 | 1.7147 | .8488 | | 1.5844 | 1.8107 | 1.4918 | 1.4289 |
| 24 | 1.3375 | 1.6575 | 1.2003 | .1143 | 1.6975 | 1.5844 | 1.5432 |
| Max | 1.8861 | 2.2068 | 1.2003 | 1.6409 | 2.037 | 1.9033 | 2.1719 |
| Min | .6687 | .8488 | .1029 | .0566 | .9619 | 1.0751 | 1.0288 |
| Avg | 1.4134 | 1.6248 | .3899 | .8139 | 1.4971 | 1.4841 | 1.6513 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 201 / TATA FEEDER NO. 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .811 |
| Max | .811 |
| Min | .811 |
| Avg | .811 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 202 / TATA FEEDER NO. 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0377 |
| Max | .0377 |
| Min | .0377 |
| Avg | .0377 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 203 / TATA FEEDER NO. 3

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .8676 |
| Max | .8676 |
| Min | .8676 |
| Avg | .8676 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 204 / TATA FEEDER NO. 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .132 |
| Max | .132 |
| Min | .132 |
| Avg | .132 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 205 / TATA S/S STATION

SHEDDABLE RURAL

TRANSFORMER F Feeder KV- 11 /
OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .2641 |
| Max | .2641 |
| Min | .2641 |
| Avg | .2641 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284617 / 33/11 KV TATA HOUSING SUB

STAT

Feeder No / Name : 206 / TATA FEEDER NO. 6

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .2641 |
| Max | .2641 |
| Min | .2641 |
| Avg | .2641 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284622 / New Contesa

Feeder No / Name : 200 / New Contesa Substation
transfo Feeder KV- 11 / OUTGOING

| DATE | 30-APR-18 | 01-MAY-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 19 | 2.9813 | |
| 20 | 3.3105 | |
| 24 | | .2286 |
| Max | 3.3105 | .2286 |
| Min | 2.9813 | .2286 |
| Avg | 3.1459 | .2286 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284622 / New Contesa

Feeder No / Name : 201 / Ostwal

Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 30-APR-18 |
|------|-----------|
| HR | Load (MW) |
| 11 | 3.1436 |
| 12 | 3.2198 |
| 13 | 3.1055 |
| 14 | 3.1626 |
| 15 | 3.1055 |
| 16 | 3.1626 |
| 17 | 3.0864 |
| Max | 3.2198 |
| Min | 3.0864 |
| Avg | 3.1409 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284623 / 33/11 KV TATA Mahendra

Betagao

Feeder No / Name : 203 / Tata Mahindra substation

trans Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .4001 |
| Max | .4001 |
| Min | .4001 |
| Avg | .4001 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

BOISAR (R) S/DN.[159] BU 4159

Substation No/ Name :- 284623 / 33/11 KV TATA Mahendra

Betagao

Feeder No / Name : 204 / Mahindra (11 kv feeder no

SHEDDABLE URBAN

4) Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .2286 |
| Max | .2286 |
| Min | .2286 |
| Avg | .2286 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 201 / 11 KV KAINAD (BORDI)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 6 | .1372 |
| Max | .1372 |
| Min | .1372 |
| Avg | .1372 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 203 / 11 KV DAHANUGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3584 | .3086 | .3361 | .4115 | .3921 | .3395 |
| 2 | .2743 | .3772 | .3258 | .3361 | .4115 | .3921 | .3206 |
| 3 | .2743 | .3395 | .3258 | .3361 | .3944 | .3734 | .3018 |
| 4 | .2915 | .3584 | .3086 | .3361 | .3772 | .3734 | .3206 |
| 5 | .2915 | .3206 | .2915 | .3547 | .3944 | .4294 | .3018 |
| 6 | .2915 | .3395 | .2915 | .3361 | .4115 | .3921 | .3206 |
| 7 | .3772 | .3206 | .2743 | .2987 | .2743 | .3921 | .2829 |
| 8 | .4458 | .415 | .3086 | .4854 | .2915 | .3734 | |
| 9 | .6602 | .7202 | .4668 | .8402 | .7842 | .3395 | .583 |
| 10 | 1.0185 | .7545 | .7282 | 1.0117 | .9896 | .3206 | .7888 |
| 11 | .811 | .703 | .5975 | .823 | .9149 | .3206 | .7716 |
| 12 | .7545 | .6859 | | .7545 | .7842 | | .6001 |
| 13 | | .6859 | .4108 | .703 | .5975 | | .4458 |
| 14 | .8488 | .6859 | .4668 | .8059 | .6722 | | .5144 |
| 15 | .9054 | .6859 | .4854 | .823 | .7282 | | .7202 |
| 16 | .6602 | .6687 | .4854 | .7373 | .7655 | | .6859 |
| 17 | .5093 | .6344 | .4854 | .6859 | .7095 | | .5487 |
| 18 | .6224 | .4287 | .2987 | .5316 | .5975 | | |
| 19 | .3584 | .3086 | .2614 | .3772 | .3921 | .2829 | .3429 |
| 20 | .3961 | | .3361 | .463 | .4481 | .3395 | .3772 |
| 21 | .4338 | .3944 | .3734 | .4287 | .4668 | .3206 | .4115 |
| 22 | .3772 | .3601 | .3734 | .4973 | .4294 | .3395 | .4287 |
| 23 | .3772 | | .0343 | .4458 | .4108 | | .4115 |
| 24 | .3086 | .3772 | .3429 | .3361 | .3944 | .3921 | .3395 |
| Max | 1.0185 | .7545 | .7282 | 1.0117 | .9896 | .4294 | .7888 |
| Min | .2743 | .3086 | .0343 | .2987 | .2743 | .2829 | .2829 |
| Avg | .5034 | .4965 | .3731 | .5451 | .5438 | .3608 | .4617 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 204 / 11 KV DAHANU RD.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3203 | 1.4146 | 1.3375 | 1.4003 | 1.3717 | 1.419 | 1.3769 |
| 2 | 1.286 | 1.3769 | 1.3203 | 1.307 | 1.3375 | 1.307 | 1.4146 |
| 3 | 1.2346 | 1.3957 | 1.286 | 1.2696 | 1.286 | 1.307 | 1.3392 |
| 4 | 1.2346 | 1.3203 | 1.2346 | 1.2696 | 1.3546 | 1.307 | 1.3203 |
| 5 | 1.2003 | 1.226 | 1.2003 | 1.2696 | 1.3889 | 1.2696 | 1.3957 |
| 6 | 1.0802 | 1.1506 | 1.166 | 1.2136 | 1.2003 | 1.251 | 1.2637 |
| 7 | 1.0288 | 1.1694 | 1.046 | 1.1576 | 1.1145 | 1.251 | |
| 8 | 1.0631 | 1.1128 | 1.0288 | 1.1763 | 1.0802 | 1.2323 | |
| 9 | 1.226 | 1.0802 | 1.2696 | 1.3203 | 1.307 | 1.4335 | 1.2003 |
| 10 | 1.4335 | 1.3375 | 1.3256 | 1.3889 | 1.587 | 1.6032 | 1.2689 |
| 11 | 1.3957 | 1.3375 | 1.419 | 1.4403 | 1.6991 | 1.6975 | 1.5261 |
| 12 | 1.4901 | 1.3717 | 1.4937 | 1.5775 | 1.8111 | 1.773 | 1.5089 |
| 13 | | 1.3032 | 1.4937 | 1.4575 | 1.7177 | 1.7541 | 1.5261 |
| 14 | 1.358 | 1.286 | 1.3817 | 1.5775 | 1.643 | 1.6409 | 1.3717 |
| 15 | 1.4335 | 1.286 | 1.419 | 1.6118 | 1.7177 | 1.6787 | 1.5775 |
| 16 | 1.4335 | 1.2517 | 1.4937 | 1.5947 | 1.6057 | 1.6787 | 1.5604 |
| 17 | 1.3769 | 1.2003 | 1.4563 | 1.5432 | 1.6057 | 1.5844 | 1.4918 |
| 18 | 1.3203 | 1.1145 | 1.3817 | 1.4746 | 1.4937 | 1.5466 | 1.4232 |
| 19 | | 1.2689 | 1.4377 | 1.4403 | 1.531 | 1.5278 | 1.4403 |
| 20 | 1.5466 | 1.286 | 1.531 | 1.5089 | 1.5684 | 1.6787 | 1.4918 |
| 21 | 1.5089 | 1.3546 | 1.5123 | 1.4232 | 1.5497 | 1.5466 | 1.4575 |
| 22 | 1.5089 | 1.4403 | 1.531 | 1.4575 | 1.587 | 1.6032 | 1.3889 |
| 23 | 1.5655 | | .0343 | 1.4918 | 1.5684 | | 1.4918 |
| 24 | 1.3546 | 1.4523 | 1.3717 | 1.5123 | 1.4232 | 1.5684 | 1.5278 |
| Max | 1.5655 | 1.4523 | 1.531 | 1.6118 | 1.8111 | 1.773 | 1.5775 |
| Min | 1.0288 | 1.0802 | .0343 | 1.1576 | 1.0802 | 1.2323 | 1.2003 |
| Avg | 1.3364 | 1.2842 | 1.2988 | 1.4118 | 1.4812 | 1.5069 | 1.4256 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 205 / 11 KV JAWAHAR RD.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8573 | 1.0562 | 1.0631 | 1.1203 | 1.0802 | 1.0456 | 1.2826 |
| 2 | .823 | .9997 | 1.046 | 1.0269 | 1.0631 | .9709 | 1.226 |
| 3 | .823 | 1.0185 | 1.0288 | .9709 | 1.0117 | .9709 | 1.1317 |
| 4 | .8059 | .9808 | .9945 | .9709 | 1.0288 | .9709 | 1.094 |
| 5 | .8059 | .9619 | .9431 | .9709 | .9774 | .9522 | 1.0562 |
| 6 | .8573 | .9431 | .9088 | .9522 | | .9709 | .9997 |
| 7 | .8745 | .9431 | .8573 | .9522 | | .9335 | 1.0185 |
| 8 | .8573 | .9431 | .9149 | 1.0082 | .9088 | .9522 | |
| 9 | .8676 | .8059 | .9149 | .8916 | .8775 | .8488 | .7716 |
| 10 | .8299 | .7888 | .8589 | .8402 | .9149 | .8865 | .823 |
| 11 | .7922 | .7373 | .8589 | .7888 | .9335 | .8488 | .8059 |
| 12 | .8299 | .7202 | | .8059 | .8402 | | .7545 |
| 13 | | .7716 | .9149 | .7716 | .8589 | | |
| 14 | .8865 | .7716 | .8962 | .8059 | .9335 | | .7716 |
| 15 | .9054 | .7202 | .8962 | .823 | .9335 | | .7716 |
| 16 | .8299 | | .9149 | .8059 | .9149 | | .8059 |
| 17 | .8676 | | .8402 | .7716 | .8589 | | .8059 |
| 18 | .811 | 1.0117 | .8402 | .7202 | .8215 | | .7202 |
| 19 | .8299 | .7545 | .9335 | .8402 | .8402 | 1.2637 | .7888 |
| 20 | .9997 | .8059 | .9709 | .9774 | 1.1016 | 1.3769 | .9774 |
| 21 | 1.0185 | 1.046 | 1.1576 | 1.046 | 1.1763 | 1.3957 | 1.0288 |
| 22 | 1.094 | 1.0974 | 1.1763 | 1.0802 | 1.1949 | 1.4146 | 1.0631 |
| 23 | 1.1317 | | .0343 | | 1.251 | | 1.1317 |
| 24 | .9774 | 1.1128 | 1.0802 | 1.1763 | 1.0631 | 1.1576 | 1.358 |
| Max | 1.1317 | 1.1128 | 1.1763 | 1.1763 | 1.251 | 1.4146 | 1.358 |
| Min | .7922 | .7202 | .0343 | .7202 | .8215 | .8488 | .7202 |
| Avg | .8859 | .9043 | .9150 | .9181 | .9811 | 1.0600 | .9630 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 206 / 11 KV ASHAGAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7147 | 1.7541 | 1.6289 | 1.8111 | 1.6118 | 1.5684 | 1.8107 |
| 2 | 1.6804 | 1.7918 | 1.6461 | 1.6804 | 1.5775 | 1.531 | 1.7918 |
| 3 | 1.6289 | 1.7353 | 1.6461 | 1.6804 | 1.5604 | 1.531 | 1.7541 |
| 4 | 1.6118 | 1.8107 | 1.5775 | 1.6804 | 1.5947 | 1.531 | 1.7918 |
| 5 | 1.6461 | 1.7918 | 1.5775 | 1.6804 | 1.5432 | 1.531 | 1.773 |
| 6 | 1.6289 | 1.8673 | 1.5432 | 1.8298 | 1.6289 | 1.6991 | 1.8107 |
| 7 | 1.5604 | 1.8861 | 1.5089 | 1.7551 | 1.6118 | 1.6804 | 1.773 |
| 8 | 1.6289 | 1.9993 | 1.5775 | 1.8298 | 1.5947 | 1.587 | |
| 9 | 2.0936 | 2.1605 | 2.3152 | 2.0233 | 2.2779 | 1.4335 | 1.4918 |
| 10 | 2.4331 | 2.2634 | 2.3712 | 2.1434 | 2.2592 | 1.4712 | 1.4232 |
| 11 | 2.3765 | 2.0576 | 2.1098 | 1.2346 | 2.1285 | 1.4146 | 1.4918 |
| 12 | 1.9805 | 1.8519 | 2.0165 | 1.0802 | 1.7737 | 1.2826 | 1.5089 |
| 13 | | 1.7147 | 1.8298 | 1.5432 | 1.7177 | 1.3769 | 1.4575 |
| 14 | 1.9993 | 1.8519 | 1.8858 | 1.6461 | 1.8484 | 1.4146 | 1.4403 |
| 15 | 1.9993 | 1.9719 | 1.8858 | 1.5604 | 1.643 | 1.3203 | 1.4575 |
| 16 | 1.9239 | 1.7661 | 1.9044 | 1.0802 | 1.7364 | 1.5089 | 1.4746 |
| 17 | 1.7164 | 1.5089 | 1.7177 | 1.4403 | 1.4563 | 1.2449 | 1.4575 |
| 18 | 1.5466 | 1.3717 | 1.4563 | 1.286 | 1.419 | 1.4146 | |
| 19 | 1.6598 | 1.5775 | 1.6804 | 1.3203 | 1.0829 | 1.4335 | 1.3889 |
| 20 | 2.1125 | 1.8861 | 2.1472 | 1.749 | 1.6617 | 1.9993 | 1.7661 |
| 21 | 2.1879 | 2.0576 | 2.1845 | 1.8176 | 1.7551 | 2.0748 | 1.8004 |
| 22 | 2.1125 | 1.989 | 2.1472 | 1.8519 | 1.8858 | 2.037 | 1.7661 |
| 23 | 1.9239 | | .0343 | 1.6804 | 1.7551 | | 1.8347 |
| 24 | 1.9223 | 1.8673 | 1.7147 | 1.8858 | 1.5947 | 1.643 | 1.773 |
| Max | 2.4331 | 2.2634 | 2.3712 | 2.1434 | 2.2779 | 2.0748 | 1.8347 |
| Min | 1.5466 | 1.3717 | .0343 | 1.0802 | 1.0829 | 1.2449 | 1.3889 |
| Avg | 1.8734 | 1.8492 | 1.7544 | 1.6371 | 1.6966 | 1.5534 | 1.6381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 401 / 33 KV Kosbad outgoing

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 3.5648 | 3.2407 | 3.6408 | 3.2922 | 3.4728 | 3.678 |
| 2 | | 3.5082 | 3.1893 | 3.5288 | 3.1893 | 3.3608 | 3.6214 |
| 3 | | 3.3951 | 3.1379 | 3.4728 | 3.0864 | 3.2487 | 3.678 |
| 4 | | 3.5648 | 3.1893 | 3.4728 | 3.1379 | 3.2487 | 3.5648 |
| 5 | | 3.4517 | 3.2407 | 3.4728 | 3.2407 | 3.2487 | 3.5082 |
| 6 | | 3.5082 | 3.1893 | 3.5288 | 3.2922 | 3.3608 | 3.678 |
| 7 | | 3.678 | 3.3436 | 3.6969 | 3.3436 | 3.5288 | 3.6214 |
| 8 | | 3.7912 | 3.1893 | 3.6969 | 3.4979 | 3.5848 | 3.678 |
| 9 | | 4.2181 | 4.8171 | 3.858 | 4.9851 | 4.357 | 3.3951 |
| 10 | | 4.6811 | 5.0972 | 4.4753 | 5.1532 | 4.1307 | 3.6523 |
| 11 | | | 5.0972 | 4.1667 | 3.6969 | 4.0741 | 3.8066 |
| 12 | | | | 3.858 | 3.7529 | 2.7161 | .5144 |
| 13 | | 3.5494 | 3.4728 | 3.5494 | 3.4168 | 2.3765 | |
| 14 | 4.8097 | 3.4979 | 4.0329 | 3.6523 | 3.8089 | 3.5082 | 3.1893 |
| 15 | 4.0741 | 3.9095 | 4.481 | 3.4465 | | 3.7912 | 3.2922 |
| 16 | 5.0926 | 4.4239 | 4.8171 | 1.4918 | | 2.8858 | 3.3436 |
| 17 | | | 4.313 | 1.5947 | 2.2965 | 2.7726 | 3.4465 |
| 18 | 4.2438 | 3.1893 | 2.9687 | 3.6008 | 3.4168 | 3.9609 | 3.3951 |
| 19 | 4.1307 | 3.4465 | 3.9769 | 3.6523 | 3.6408 | 4.0175 | 3.3436 |
| 20 | 4.4136 | 3.6008 | 4.313 | 3.858 | 4.0329 | 4.4136 | 3.858 |
| 21 | 2.8858 | 3.7037 | 4.369 | 3.9095 | 4.0889 | 4.357 | 3.9095 |
| 22 | 4.1307 | 3.6008 | 4.257 | 3.9095 | 3.9209 | 4.2438 | 3.858 |
| 23 | 3.9609 | | 3.9209 | 3.5494 | 3.6408 | | 3.8066 |
| 24 | | 3.7912 | 3.2407 | 3.7529 | 3.3436 | 3.4728 | 3.7912 |
| Max | 5.0926 | 4.6811 | 5.0972 | 4.4753 | 5.1532 | 4.4136 | 3.9095 |
| Min | 2.8858 | 3.1893 | 2.9687 | 1.4918 | 2.2965 | 2.3765 | .5144 |
| Avg | 4.1935 | 3.7037 | 3.8650 | 3.5348 | 3.6034 | 3.5710 | 3.4622 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 404 / 33 KV Jawhar

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 11.8313 | 12.7881 | 11.8313 | 12.7709 | 10.6996 | 12.995 | 13.071 |
| 2 | 11.7284 | 12.9013 | 11.7284 | 12.6029 | 10.5453 | 12.995 | 12.7881 |
| 3 | 11.5741 | 12.5052 | 11.677 | 12.5469 | 10.4424 | 12.883 | 12.3354 |
| 4 | 11.5741 | 12.3354 | 11.3169 | 12.5469 | 10.5967 | 12.883 | 12.4486 |
| 5 | 11.8313 | 11.9959 | 11.0597 | 12.5469 | 10.6482 | 12.995 | 12.6183 |
| 6 | 11.9856 | 11.8261 | 10.6482 | 12.3228 | 10.8539 | 13.163 | 13.1276 |
| 7 | 10.8539 | 10.5247 | 11.7696 | 10.8665 | 9.7737 | 11.4266 | 11.9959 |
| 8 | 9.4136 | 7.1296 | 9.3622 | 9.6902 | 9.1564 | 9.9703 | 10.355 |
| 9 | 10.355 | 8.642 | 9.9703 | 8.8477 | 10.4184 | 9.5628 | 9.1564 |
| 10 | 10.1852 | 9.2078 | 9.8023 | 8.7449 | 10.3624 | 8.8272 | 9.0535 |
| 11 | 10.355 | 9.105 | 9.0741 | 8.8477 | 9.8583 | 7.5257 | 8.7449 |
| 12 | | 8.7963 | 9.8023 | 8.7963 | 9.6342 | 7.7521 | 9.0021 |
| 13 | | 8.642 | 9.2421 | 8.4362 | 7.7858 | 7.5823 | 8.5391 |
| 14 | 10.5813 | 8.2305 | 9.2421 | 8.2305 | 9.1301 | 7.0731 | 8.4877 |
| 15 | 10.4681 | 8.5391 | 9.5222 | 3.7037 | 9.8023 | 7.1296 | 8.642 |
| 16 | 10.5247 | 8.5391 | 9.6902 | 8.0761 | 9.5222 | 8.714 | 8.4877 |
| 17 | | | 9.2981 | 8.2305 | 9.6902 | 9.1667 | 7.4589 |
| 18 | 9.9023 | 9.7737 | 9.1301 | 8.4877 | 8.682 | 8.9969 | 7.6132 |
| 19 | 11.5998 | 11.8313 | 11.5387 | 9.7737 | 11.0345 | 11.3169 | 10.4938 |
| 20 | 15.108 | 12.8601 | 15.0675 | 13.5288 | 14.6754 | 15.3344 | 14.3004 |
| 21 | 14.9383 | 13.7346 | 14.9554 | 13.9403 | 15.7396 | 15.6739 | 13.9918 |
| 22 | 14.429 | 13.5288 | 14.6194 | 13.6317 | 15.0115 | 15.0515 | 13.7346 |
| 23 | 13.6369 | | 13.6111 | 12.7058 | 11.8187 | | 13.1687 |
| 24 | 12.0885 | 13.0144 | 12.0371 | 13.107 | 11.0082 | 13.163 | 13.5237 |
| Max | 15.108 | 13.7346 | 15.0675 | 13.9403 | 15.7396 | 15.6739 | 14.3004 |
| Min | 9.4136 | 7.1296 | 9.0741 | 3.7037 | 7.7858 | 7.0731 | 7.4589 |
| Avg | 11.6650 | 10.7478 | 11.0832 | 10.5409 | 10.7038 | 10.9644 | 10.9641 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284031 / 33/11 KV DAHANU RD. SUBSTN

Feeder No / Name : 406 / 33 KV VADKUN OUTGOING

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4918 | 1.8673 | 1.8004 | 1.8484 | 1.6461 | 1.8484 | 1.7541 |
| 2 | 1.4403 | 1.7541 | 1.6975 | 1.8484 | 1.5432 | 1.7924 | 1.8107 |
| 3 | 1.3889 | 1.8107 | 1.6975 | 1.7364 | 1.5432 | 1.7924 | 1.6975 |
| 4 | 1.4403 | 1.7541 | 1.6461 | 1.7364 | 1.5947 | 1.7924 | 1.7541 |
| 5 | 1.4403 | 1.6975 | 1.5947 | 1.7364 | 1.6461 | 1.7364 | 1.7541 |
| 6 | 1.3889 | 1.7541 | 1.5432 | 1.7924 | 1.5432 | 1.7364 | 1.6975 |
| 7 | 1.2346 | 1.6409 | 1.5432 | 1.6244 | 1.5432 | 1.5684 | 1.5844 |
| 8 | 1.286 | 1.7541 | 1.5432 | 1.7364 | 1.4918 | 1.4003 | |
| 9 | 2.2068 | 2.0576 | 2.1285 | 2.0062 | 2.3525 | 1.4146 | 1.749 |
| 10 | 2.2068 | 2.1091 | 2.1285 | 2.2119 | 2.4086 | .7922 | 1.9033 |
| 11 | 2.2068 | 2.2119 | 2.1285 | 2.2634 | 2.4086 | .5658 | 1.8519 |
| 12 | 2.2068 | 2.0062 | 1.9044 | 2.0576 | 2.1845 | 1.1883 | 1.8004 |
| 13 | | 1.8004 | 1.7924 | 1.749 | 1.9044 | 1.3014 | 1.8519 |
| 14 | 2.1502 | 1.8004 | 2.1845 | 2.1605 | 2.2965 | 1.3014 | 1.8004 |
| 15 | 2.2068 | 2.1605 | 2.0725 | 2.1091 | 2.2405 | 1.4146 | 1.6461 |
| 16 | 1.9239 | 2.0576 | 1.9605 | 2.0062 | 2.0725 | 1.3014 | 1.5432 |
| 17 | 1.8673 | 1.8519 | 1.7364 | 1.6461 | 1.8484 | 1.358 | 1.3889 |
| 18 | 1.5844 | 1.4403 | 1.4563 | 1.4918 | 1.5684 | 1.2449 | 1.1317 |
| 19 | 1.5844 | 1.3889 | 1.5684 | 1.4403 | 1.5123 | 1.358 | 1.3375 |
| 20 | 1.9805 | 1.6461 | 1.9044 | 1.8004 | 1.9605 | 1.7541 | 1.8004 |
| 21 | 1.9239 | 1.8004 | 2.0165 | 1.8004 | 2.0165 | 1.8673 | 1.8519 |
| 22 | 2.0936 | 1.9547 | 2.0725 | 2.0062 | 2.0725 | 1.9805 | 1.8519 |
| 23 | 2.0936 | | 2.0725 | 1.9033 | 2.1285 | | 1.8519 |
| 24 | | 1.9805 | 1.8519 | 1.9605 | 1.749 | 1.9605 | 1.8673 |
| Max | 2.2068 | 2.2119 | 2.1845 | 2.2634 | 2.4086 | 1.9805 | 1.9033 |
| Min | 1.2346 | 1.3889 | 1.4563 | 1.4403 | 1.4918 | .5658 | 1.1317 |
| Avg | 1.7885 | 1.8391 | 1.8352 | 1.8613 | 1.8865 | 1.4987 | 1.7078 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284032 / 33/11 KV KOSBAD SUBSTN

Feeder No / Name : 201 / 11 KV GHOLWAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0191 | | | .0191 |
| 2 | | .0191 | | .0191 | .0191 | .0191 |
| 3 | | | .0191 | .0191 | | .0191 |
| 4 | | .0191 | | | .0191 | .0191 |
| 5 | | | .0191 | .0191 | | |
| 6 | | .0191 | .0191 | | .0191 | .0191 |
| 7 | | | | .0191 | | .0191 |
| 8 | | .0191 | .0191 | .0191 | .0191 | .0191 |
| 9 | | | .0191 | | .0191 | |
| 10 | | .0191 | | .0191 | .0191 | .0191 |
| 11 | | | .0191 | | .0191 | .0191 |
| 12 | | .0191 | | .0191 | .0191 | |
| 13 | | | .0191 | | .0191 | .0191 |
| 14 | .0191 | .0191 | .0191 | .0191 | .0191 | |
| 15 | .0191 | | | | | .0191 |
| 16 | | .0191 | .0191 | .0191 | .0191 | |
| 17 | .0191 | | | | | .0191 |
| 18 | .0191 | .0191 | .0191 | .0191 | | |
| 19 | .0191 | | | | .0191 | .0191 |
| 20 | | .0191 | .0191 | .0191 | .0191 | .0191 |
| 21 | | .0191 | | | | |
| 22 | | .0191 | .0191 | .0191 | .0191 | |
| 23 | | .0191 | .0191 | .0191 | .0191 | .0191 |
| 24 | | .0191 | .0191 | .0191 | .0191 | |
| Max | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Min | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Avg | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284032 / 33/11 KV KOSBAD SUBSTN

Feeder No / Name : 202 / 11 KV WAGHMARE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 1 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284032 / 33/11 KV KOSBAD SUBSTN

Feeder No / Name : 203 / 11 KV KOSBAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7202 | .6859 | .6859 | .6859 | .6859 | .6859 |
| 2 | | .6859 | .6516 | .6687 | .6859 | .6859 | .6859 |
| 3 | | .7888 | .6344 | .6516 | | .6687 | .7202 |
| 4 | | .6859 | .6344 | .6859 | .7545 | .6516 | .6516 |
| 5 | | .7202 | .6516 | .6687 | .6859 | .6687 | .6173 |
| 6 | | .7202 | .7373 | .6859 | .7545 | .6859 | .6859 |
| 7 | | .7545 | .7373 | .703 | .7202 | .703 | .7373 |
| 8 | | .823 | .7545 | .703 | .7888 | .703 | .6859 |
| 9 | | .9259 | .5944 | .9088 | .8916 | .7545 | .8916 |
| 10 | | .8916 | .9259 | .8573 | .9602 | .823 | .9259 |
| 11 | | .9259 | .9602 | .8916 | | .6516 | .8059 |
| 12 | | .8059 | .7202 | .8059 | .703 | .6859 | |
| 13 | | .7888 | .583 | .7888 | .703 | .6859 | .5316 |
| 14 | .8573 | .823 | .7202 | .7545 | .6173 | .7202 | .6516 |
| 15 | .8916 | .823 | .823 | .7545 | | .7545 | .6859 |
| 16 | .9088 | .7716 | .8402 | .7202 | .5487 | .6859 | .703 |
| 17 | .8573 | | .7716 | .6859 | .6516 | .6173 | .7202 |
| 18 | .823 | .5316 | .823 | .7202 | .6001 | .6859 | .7716 |
| 19 | .6859 | .5316 | .7888 | .7888 | .6516 | .7202 | .7888 |
| 20 | .7202 | .7373 | .823 | .823 | .7888 | .6859 | .7888 |
| 21 | .7545 | .7888 | .0191 | .7545 | .823 | .7545 | |
| 22 | .7202 | .7716 | .7888 | .7202 | .7202 | .6516 | |
| 23 | .6859 | .7545 | .7888 | .7545 | .703 | .6516 | |
| 24 | .6859 | | .7545 | .703 | .6859 | .6516 | |
| Max | .9088 | .9259 | .9602 | .9088 | .9602 | .823 | .9259 |
| Min | .6859 | .5316 | .0191 | .6516 | .5487 | .6173 | .5316 |
| Avg | .7810 | .7623 | .7172 | .7452 | .7202 | .6930 | .7229 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284033 / 33/11 KV GANJAD SUBSTN

Feeder No / Name : 202 / 11 KV SANTOSHI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284033 / 33/11 KV GANJAD SUBSTN

Feeder No / Name : 203 / 11 KV MAHALAXMI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284034 / 33/11 KV SURYANAGAR SUBSTN

Feeder No / Name : 201 / 11 KV TALWADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284034 / 33/11 KV SURYANAGAR SUBSTN

Feeder No / Name : 202 / 11 KV KASA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284034 / 33/11 KV SURYANAGAR SUBSTN

Feeder No / Name : 203 / 11 KV TAPS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284034 / 33/11 KV SURYANAGAR SUBSTN

Feeder No / Name : 204 / Reliance feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284601 / 33/11 KV VADKUN S/S.

Feeder No / Name : 203 / 11 KV Parnaka Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6804 | 1.8107 | 1.6632 | 1.6632 | 1.4352 | 1.6244 | 1.5844 |
| 2 | 1.5497 | 1.7541 | 1.5524 | 1.386 | 1.382 | 1.587 | 1.5089 |
| 3 | 1.531 | 1.6975 | 1.5893 | 1.4415 | 1.3112 | 1.5497 | 1.5466 |
| 4 | 1.4937 | 1.6598 | 1.5708 | 1.4045 | 1.3643 | 1.4937 | 1.4712 |
| 5 | 1.4563 | 1.6221 | 1.5524 | 1.423 | 1.4175 | 1.4563 | 1.4335 |
| 6 | 1.475 | 1.5844 | 1.5708 | 1.4784 | 1.4706 | 1.4003 | 1.4146 |
| 7 | 1.4784 | 1.5466 | 1.4784 | 1.3676 | 1.258 | 1.3443 | 1.3392 |
| 8 | 1.134 | 1.5466 | 1.423 | 1.3121 | 1.258 | 1.2437 | |
| 9 | 1.4685 | 1.4632 | 1.4415 | 1.423 | 1.382 | 1.2894 | 1.4712 |
| 10 | 1.4685 | 1.4415 | 1.4784 | 1.2934 | 1.2894 | | 1.4146 |
| 11 | 1.3611 | 1.4784 | 1.3491 | 1.3466 | 1.2894 | 1.2536 | 1.4712 |
| 12 | 1.3611 | 1.46 | 1.3306 | 1.2226 | 1.3253 | 1.2012 | 1.4146 |
| 13 | 1.2894 | 1.4148 | 1.2936 | 1.2048 | 1.2894 | 1.3121 | 1.4335 |
| 14 | 1.4327 | 1.423 | 1.3306 | 1.2757 | 1.3253 | 1.1827 | 1.4712 |
| 15 | 1.576 | 1.3969 | 1.3491 | 1.3998 | 1.3611 | 1.2936 | 1.4901 |
| 16 | 1.0387 | 1.4045 | 1.3676 | 1.3466 | 1.3969 | 1.423 | 1.5089 |
| 17 | 1.3611 | 1.386 | 1.2936 | 1.2934 | | 1.3676 | 1.4523 |
| 18 | 1.2178 | 1.2752 | 1.3676 | 1.2403 | 1.1104 | 1.3306 | 1.3957 |
| 19 | 1.3306 | 1.3121 | 1.3121 | 1.2226 | 1.1706 | 1.5154 | 1.6032 |
| 20 | 1.6804 | 1.6448 | 1.7002 | 1.4529 | 1.643 | 1.6448 | 1.7541 |
| 21 | 1.7164 | 1.7556 | 1.7556 | 1.5947 | 1.7924 | 1.6817 | 1.8484 |
| 22 | 1.8673 | 1.7372 | 1.7741 | 1.6124 | 1.8298 | 1.8111 | 1.8861 |
| 23 | 1.905 | 1.7556 | 1.7556 | 1.6478 | 1.7737 | 1.7926 | 1.9805 |
| 24 | 1.7551 | 1.8484 | 1.7002 | 1.7187 | 1.4883 | 1.6804 | 1.773 |
| Max | 1.905 | 1.8484 | 1.7741 | 1.7187 | 1.8298 | 1.8111 | 1.9805 |
| Min | 1.0387 | 1.2752 | 1.2936 | 1.2048 | 1.1104 | 1.1827 | 1.3392 |
| Avg | 1.4845 | 1.5591 | 1.5000 | 1.4072 | 1.4071 | 1.4556 | 1.5507 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284601 / 33/11 KV VADKUN S/S.

Feeder No / Name : 204 / 11 KV MASOLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9522 | .9431 | .9979 | .9979 | .9036 | 1.0829 | .9431 |
| 2 | .8775 | .9054 | .8501 | .8131 | .8505 | .9896 | .8962 |
| 3 | .8402 | .8413 | .8131 | .8417 | .7973 | .9335 | .9054 |
| 4 | .8215 | .8402 | .7522 | .7947 | .7619 | .8962 | .7922 |
| 5 | .8402 | .7922 | .788 | .8131 | .7973 | .8402 | .811 |
| 6 | .8589 | .7545 | .9055 | .8238 | .7796 | .8029 | .8299 |
| 7 | .7577 | .7499 | .8316 | .7947 | .7442 | .7842 | .7922 |
| 8 | .8048 | .7733 | .7762 | .7701 | .7442 | .7316 | |
| 9 | .8238 | .8488 | .8871 | .8871 | .7973 | .788 | .7922 |
| 10 | .7522 | .7762 | .8501 | .7973 | .7701 | | .7922 |
| 11 | .7343 | .7762 | .7947 | .7619 | .7522 | | .7733 |
| 12 | .6984 | .7762 | .6796 | .7265 | .7343 | .8316 | .7545 |
| 13 | .7164 | .7392 | .7392 | .7087 | .7164 | .9055 | .7545 |
| 14 | .7343 | .7947 | .7023 | .7796 | .8238 | .8686 | .7733 |
| 15 | .7343 | .7392 | .7207 | .815 | .7164 | .8501 | .7922 |
| 16 | .7522 | .7207 | .7392 | .7619 | .7343 | .8316 | .7922 |
| 17 | .7164 | .7207 | .7577 | .7087 | | .7577 | .9054 |
| 18 | .6626 | .6838 | .7577 | .6379 | .7343 | .6838 | |
| 19 | .7207 | | .7522 | .6733 | .7865 | .8131 | .9619 |
| 20 | .9335 | .9795 | .961 | .9568 | 1.0082 | .8775 | 1.0562 |
| 21 | .9431 | .9979 | 1.0534 | .9568 | 1.1203 | 1.0164 | 1.094 |
| 22 | 1.0185 | 1.0719 | 1.0903 | .9922 | 1.1576 | .9979 | 1.1128 |
| 23 | 1.0374 | 1.1458 | 1.0719 | 1.0631 | 1.1203 | 1.1088 | 1.1694 |
| 24 | .9896 | 1.0562 | 1.0745 | 1.0534 | .9922 | 1.1203 | 1.094 |
| Max | 1.0374 | 1.1458 | 1.0903 | 1.0631 | 1.1576 | 1.1203 | 1.1694 |
| Min | .6626 | .6838 | .6796 | .6379 | .7164 | .6838 | .7545 |
| Avg | .8217 | .8446 | .8478 | .8304 | .8410 | .8869 | .8904 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284601 / 33/11 KV VADKUN S/S.

Feeder No / Name : 205 / 11 KV COLLEGE RD. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4668 | .6036 | .3326 | .4066 | .4075 | .4481 | .2829 |
| 2 | .4668 | .5658 | .3142 | .3881 | .4075 | .4294 | .2641 |
| 3 | .4481 | .547 | .3326 | .3696 | .3898 | .4108 | .2641 |
| 4 | .4294 | .5847 | .2957 | .3326 | .4075 | .3921 | .3018 |
| 5 | .4294 | .6036 | .3142 | .2957 | .4252 | .3734 | .3206 |
| 6 | .4108 | .5847 | .3511 | .3142 | .443 | .3734 | .3772 |
| 7 | .4066 | .5658 | .3142 | .3142 | .443 | .3361 | .4338 |
| 8 | .6036 | .6036 | .5729 | .5729 | .567 | .2926 | |
| 9 | .9313 | 1.0974 | .7577 | .9979 | .9745 | .2149 | .7922 |
| 10 | 1.1641 | 1.0903 | .7392 | 1.2226 | 1.2357 | | .8488 |
| 11 | 1.1283 | 1.2567 | .7023 | 1.2048 | 1.1999 | | .6602 |
| 12 | 1.1641 | 1.2197 | .6653 | .9568 | 1.1283 | .1663 | .6036 |
| 13 | .9671 | 1.1827 | .6268 | .7619 | .8954 | .2218 | .547 |
| 14 | 1.2536 | 1.2197 | .6653 | 1.0631 | 1.1641 | | .6413 |
| 15 | 1.1283 | 1.1827 | .6468 | 1.1517 | 1.1104 | .2218 | .7356 |
| 16 | .8059 | .961 | .6653 | .9391 | .9492 | .2218 | .8299 |
| 17 | .8417 | .8871 | .6653 | .815 | | .2218 | .6036 |
| 18 | .591 | .5914 | .5359 | .6024 | | .2218 | .4338 |
| 19 | .462 | .4435 | .3881 | .4961 | .4755 | .2587 | .4338 |
| 20 | .4854 | .462 | .3881 | .5138 | .4481 | .2772 | .4338 |
| 21 | .4715 | .4435 | .463 | .5138 | .4481 | .2957 | .415 |
| 22 | .5281 | .4119 | .4066 | | .4668 | .3326 | .3961 |
| 23 | .5658 | .4298 | .4251 | .4607 | .4668 | .3142 | .3772 |
| 24 | .4854 | .6413 | | .4435 | .4252 | .4481 | .3206 |
| Max | 1.2536 | 1.2567 | .7577 | 1.2226 | 1.2357 | .4481 | .8488 |
| Min | .4066 | .4119 | .2957 | .2957 | .3898 | .1663 | .2641 |
| Avg | .6931 | .7575 | .5030 | .6581 | .6763 | .3082 | .4920 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284601 / 33/11 KV VADKUN S/S.

Feeder No / Name : 206 / 11 KV SAINT MARY FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3921 | .3395 | .2957 | .2957 | .3012 | .3361 | .2218 |
| 2 | .3734 | .2926 | .2218 | .2587 | .3012 | .3174 | .1848 |
| 3 | .3734 | .2641 | .2402 | .2218 | .2835 | .2987 | .1663 |
| 4 | .3921 | .2829 | .2218 | .2218 | .3012 | .2987 | .1848 |
| 5 | .3734 | .2641 | .2402 | .2402 | .3012 | .2801 | .2033 |
| 6 | .3734 | .2743 | .2587 | .2587 | .3012 | .2614 | .1848 |
| 7 | .2587 | .2926 | .2402 | .2033 | .2303 | .2241 | .2033 |
| 8 | .2195 | .2743 | .2033 | .3142 | .2658 | .2012 | |
| 9 | .5731 | .5853 | .3326 | .5729 | .6024 | .197 | .4805 |
| 10 | .6268 | .5544 | .3511 | .6201 | .6626 | | .5359 |
| 11 | .6268 | .6838 | .3696 | .691 | .7522 | | |
| 12 | .5731 | .6653 | .3881 | .567 | .6984 | .2033 | .4904 |
| 13 | .4656 | .6089 | .3696 | .4075 | .5014 | .1848 | .3772 |
| 14 | .4835 | .6268 | .3326 | .4961 | .6447 | .1848 | .4715 |
| 15 | .4656 | .6099 | .2957 | .567 | .6268 | .2033 | .5281 |
| 16 | .5194 | .5544 | .2772 | .5316 | .6089 | .1848 | .5847 |
| 17 | .4477 | .4801 | .2402 | .4961 | | .1848 | .3961 |
| 18 | .3224 | .2587 | .2218 | .3012 | | .1848 | .3018 |
| 19 | .2402 | .3142 | .2033 | .2835 | .2743 | .2402 | .3206 |
| 20 | .3361 | .3511 | .2587 | .3012 | .3361 | .2587 | .3395 |
| 21 | .3395 | .3696 | .2957 | .3012 | .3547 | .2772 | .3395 |
| 22 | .3395 | .3696 | .2957 | .3012 | .3734 | .2772 | .3206 |
| 23 | .3584 | .3511 | .2957 | .3012 | .3734 | .2772 | .3206 |
| 24 | .4108 | .3584 | .3326 | .3142 | .3012 | .3734 | .2402 |
| Max | .6268 | .6838 | .3881 | .691 | .7522 | .3734 | .5847 |
| Min | .2195 | .2587 | .2033 | .2033 | .2303 | .1848 | .1663 |
| Avg | .4119 | .4178 | .2826 | .3778 | .4271 | .2477 | .3362 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160]

BU 4160

Substation No/ Name :- 284601 / 33/11 KV VADKUN S/S.

Feeder No / Name : 208 / 11 KV WAKI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7167 | .6099 | .6283 | .567 | .6535 | .6219 |
| 2 | | .6979 | .6283 | .6099 | .5493 | .6348 | .6224 |
| 3 | | .6535 | .5731 | .6283 | .5847 | .5975 | .6036 |
| 4 | | .6979 | .5544 | .6468 | .6201 | .5788 | .6413 |
| 5 | | .6584 | .6099 | .6283 | .6379 | .5601 | .6602 |
| 6 | | .6602 | .6468 | .6468 | .6024 | .5975 | .6979 |
| 7 | | .679 | .6468 | .6468 | .6024 | .6348 | .679 |
| 8 | .5121 | .679 | .6805 | .6838 | .691 | .6036 | |
| 9 | .6805 | .8488 | .8059 | .8871 | .7796 | .5731 | .6979 |
| 10 | .5373 | .924 | .7392 | .8596 | | .5544 | .7356 |
| 11 | .6268 | .9055 | .8501 | .8328 | .8059 | .5175 | .7167 |
| 12 | .6447 | .8316 | .7207 | .6379 | .7164 | .3142 | .679 |
| 13 | .5731 | .7762 | .6838 | .6201 | .591 | .3696 | .6602 |
| 14 | .591 | .6838 | .7023 | .6733 | .6268 | .3881 | .6413 |
| 15 | .6268 | .6268 | .6283 | .6024 | .591 | .4066 | .6602 |
| 16 | .394 | .6283 | .6283 | .6024 | .5552 | .4066 | .6413 |
| 17 | .591 | .5373 | .6099 | .5493 | | .4477 | .5847 |
| 18 | .4835 | .4805 | .5731 | .5847 | .5014 | .499 | .547 |
| 19 | | .5359 | .6099 | .6201 | .5487 | .6283 | .6413 |
| 20 | .6908 | .6626 | .7762 | .7619 | .7468 | .7392 | .7167 |
| 21 | .7356 | .7207 | .6984 | .7442 | .7282 | .7762 | .7356 |
| 22 | .7545 | .7023 | .7577 | .7087 | .7095 | .7392 | .7545 |
| 23 | .7733 | .6447 | .7207 | .6556 | .6908 | .6838 | .7545 |
| 24 | .0747 | .7356 | .6283 | .6468 | .6024 | .6722 | .679 |
| Max | .7733 | .924 | .8501 | .8871 | .8059 | .7762 | .7545 |
| Min | .0747 | .4805 | .5544 | .5493 | .5014 | .3142 | .547 |
| Avg | .5806 | .6953 | .6701 | .6711 | .6386 | .5657 | .6683 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284615 / 33/11KV BORDI S/S

Feeder No / Name : 201 / 11 KV BORIGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

DAHANU S/DN.[160] BU 4160

Substation No/ Name :- 284615 / 33/11KV BORDI S/S

Feeder No / Name : 203 / 11 KV BORDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161] BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 300 / JAWHAR SUBSTATION
Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | | | | | | .381 |
| 8 | | | | | .1524 | |
| 9 | .1905 | | | | | |
| 17 | | | | .1143 | | |
| 23 | | .1143 | | | | |
| 24 | | | .1143 | | | |
| Max | .1905 | .1143 | .1143 | .1143 | .1524 | .381 |
| Min | .1905 | .1143 | .1143 | .1143 | .1524 | .381 |
| Avg | .1905 | .1143 | .1143 | .1143 | .1524 | .381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161]

BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 301 / 22 KV WALWANDA(VIKRAMGAD)

SHEDDABLE RURAL

FEED Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8002 | .8002 | .8002 | | .8383 | .7621 | .8002 |
| 2 | .7621 | .8002 | .8002 | | .8383 | .7621 | .7621 |
| 3 | .7621 | .8002 | .8002 | | .8002 | .8002 | .7621 |
| 4 | .8002 | .8002 | | | | .8002 | |
| 5 | .8002 | .8002 | .8002 | | .8383 | .8383 | |
| 6 | .8002 | .7621 | .8383 | | .8383 | .8383 | .724 |
| 7 | .6478 | | | | | .724 | .6478 |
| 8 | .5335 | | | | .5335 | .5716 | |
| 9 | .4572 | | | | .4954 | .4572 | |
| 10 | .4191 | .4572 | | | .4191 | .4572 | |
| 11 | | .4572 | | .4191 | .381 | .4191 | |
| 12 | | .4191 | | .4572 | .381 | .4572 | .381 |
| 13 | | .4572 | | | .4191 | | .4191 |
| 14 | | .4572 | | .4572 | .381 | | .4572 |
| 15 | | .4572 | | | .381 | | |
| 16 | | | | .4191 | .4191 | | .4572 |
| 17 | | | | .4572 | .4191 | | |
| 18 | .5335 | | | | .4572 | | .4954 |
| 19 | .6859 | .8002 | | | .6478 | | .6478 |
| 20 | .9526 | | | | .9907 | | |
| 21 | .9907 | .9907 | | .9907 | 1.0288 | | .9907 |
| 22 | | .9145 | | .9907 | .9526 | | .9526 |
| 23 | .8383 | .8764 | | .8764 | .8764 | | .8764 |
| 24 | .8002 | .8002 | .8383 | | .8383 | .8002 | .8383 |
| Max | .9907 | .9907 | .8383 | .9907 | 1.0288 | .8383 | .9907 |
| Min | .4191 | .4191 | .8002 | .4191 | .381 | .4191 | .381 |
| Avg | .7240 | .6971 | .8129 | .6335 | .6443 | .6683 | .6808 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161]

BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 302 / 22 KV NYHALE FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3429 | .3048 | | .3429 | .3429 | .3429 |
| 2 | .3429 | .3429 | .3048 | | .3429 | .3429 | .3429 |
| 3 | .3429 | .3429 | .2667 | | .3429 | .3429 | .3429 |
| 4 | .3429 | .3429 | | | | .3429 | |
| 5 | .3429 | .3429 | .2667 | | .3429 | .3429 | |
| 6 | .3429 | .3429 | .2667 | | .3429 | .3048 | .3048 |
| 7 | .2667 | | | | | .2667 | .1905 |
| 8 | .2667 | | | | .2667 | .2286 | |
| 9 | .1905 | | | | .1524 | .0762 | |
| 10 | .1905 | .1524 | | | .1524 | .1524 | |
| 11 | | .1143 | | .1905 | .1905 | .1905 | |
| 12 | | .1143 | | .1905 | .1524 | .1524 | .1524 |
| 13 | | .1143 | | | .1905 | | .1524 |
| 14 | | .1143 | | .1524 | .1905 | | .1905 |
| 15 | | .1524 | | | .1524 | | |
| 16 | | | | .1143 | .1524 | | .1143 |
| 17 | | | | | .1905 | | |
| 18 | .1524 | | | | .1905 | | .1905 |
| 19 | .2286 | .2667 | | | .2286 | | .2286 |
| 20 | .3429 | | | | .381 | | |
| 21 | .3429 | .381 | | .381 | .381 | | .381 |
| 22 | | .381 | | .381 | .381 | | .3429 |
| 23 | .381 | .3429 | | .381 | .3429 | | .3429 |
| 24 | .3429 | .3429 | .3429 | | .381 | .3429 | .3429 |
| Max | .381 | .381 | .3429 | .381 | .381 | .3429 | .381 |
| Min | .1524 | .1143 | .2667 | .1143 | .1524 | .0762 | .1143 |
| Avg | .2977 | .2667 | .2921 | .2558 | .2632 | .2638 | .2642 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161]

BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 303 / 22 KV JAWHAR FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2193 | 1.1812 | 1.1812 | | 1.1431 | 1.2193 | 1.2193 |
| 2 | 1.1812 | 1.1431 | 1.105 | | 1.105 | 1.1431 | 1.1431 |
| 3 | 1.1812 | 1.1431 | 1.105 | | 1.105 | 1.105 | 1.105 |
| 4 | 1.1812 | 1.1431 | | | | 1.105 | |
| 5 | 1.1431 | 1.0669 | 1.105 | | 1.105 | 1.105 | |
| 6 | 1.1812 | 1.2193 | 1.2574 | | 1.1812 | 1.2574 | 1.2574 |
| 7 | 1.2955 | | | | | 1.3717 | 1.3717 |
| 8 | 1.1812 | | | | 1.1431 | 1.2193 | |
| 9 | 1.105 | | | | 1.1431 | 1.1812 | |
| 10 | 1.1812 | 1.3717 | | | 1.3336 | 1.1812 | |
| 11 | | 1.3717 | | 1.3336 | 1.4098 | 1.2574 | |
| 12 | | 1.3336 | | 1.2193 | 1.3336 | 1.2955 | 1.3717 |
| 13 | | 1.2193 | | | 1.4098 | | 1.3336 |
| 14 | | 1.1812 | | 1.2193 | 1.2574 | | 1.2574 |
| 15 | | | | | 1.3336 | | |
| 16 | | | | | 1.3717 | | 1.3717 |
| 17 | | | | 1.1431 | 1.2955 | | |
| 18 | 1.105 | | | | 1.1812 | | 1.105 |
| 19 | 1.1812 | 1.4861 | | | 1.1431 | | 1.1431 |
| 20 | 1.4098 | | | | 1.3717 | | |
| 21 | 1.4098 | 1.5242 | | 1.4098 | 1.5242 | | 1.4098 |
| 22 | | 1.4098 | | 1.3717 | 1.448 | | 1.3336 |
| 23 | 1.2955 | 1.3717 | | 1.3336 | 1.3336 | | 1.3336 |
| 24 | 1.2574 | 1.1812 | 1.2574 | | 1.2193 | 1.2574 | 1.2574 |
| Max | 1.4098 | 1.5242 | 1.2574 | 1.4098 | 1.5242 | 1.3717 | 1.4098 |
| Min | 1.105 | 1.0669 | 1.105 | 1.1431 | 1.105 | 1.105 | 1.105 |
| Avg | 1.2193 | 1.2717 | 1.1685 | 1.2901 | 1.2678 | 1.2076 | 1.2676 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161]

BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 304 / 22 KV JAMSAR FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1431 | 1.3336 | 1.2574 | | 1.2955 | 1.3336 | 1.3336 |
| 2 | 1.1431 | 1.2955 | 1.2574 | | 1.2955 | 1.3336 | 1.3336 |
| 3 | 1.1812 | 1.2955 | 1.2193 | | 1.2955 | 1.3336 | 1.3336 |
| 4 | 1.1431 | 1.2955 | | | | 1.3336 | |
| 5 | 1.2193 | 1.3717 | 1.2574 | | 1.3336 | 1.3336 | |
| 6 | 1.2193 | 1.4098 | 1.3336 | | 1.2955 | 1.2955 | 1.2955 |
| 7 | 1.0669 | | | | | 1.1812 | 1.1812 |
| 8 | .9145 | | | | | .9526 | |
| 9 | .8002 | | | | .8764 | .7621 | |
| 10 | .8764 | .8764 | | | .8383 | .724 | |
| 11 | | .8764 | | .8002 | .7621 | .6859 | |
| 12 | | .8764 | | | .7621 | .6859 | .724 |
| 13 | | .8002 | | | .8383 | | .6478 |
| 14 | | .8383 | | .8764 | .8002 | | .6097 |
| 15 | | .8002 | | | .8002 | | |
| 16 | | | | .6859 | .9526 | | .6859 |
| 17 | | | | .7621 | .8764 | | |
| 18 | .9907 | | | | .9145 | | .8383 |
| 19 | 1.2193 | | | | 1.1431 | | 1.1812 |
| 20 | 1.6385 | | | | 1.7147 | | |
| 21 | 1.6385 | 1.7147 | | 1.6385 | 1.6766 | | 1.6766 |
| 22 | | 1.5242 | | 1.5623 | 1.5242 | | 1.6004 |
| 23 | 1.3717 | 1.4098 | | | 1.4098 | | 1.4861 |
| 24 | 1.1812 | 1.2955 | 1.2574 | | 1.2955 | 1.3336 | 1.4098 |
| Max | 1.6385 | 1.7147 | 1.3336 | 1.6385 | 1.7147 | 1.3336 | 1.6766 |
| Min | .8002 | .8002 | 1.2193 | .6859 | .7621 | .6859 | .6097 |
| Avg | 1.1717 | 1.1884 | 1.2638 | 1.0542 | 1.1286 | 1.0991 | 1.1558 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

JAWHAR S/DN.[161]

BU 4161

Substation No/ Name :- 284037 / 33/22 KV JAWHAR SUB/STN

Feeder No / Name : 305 / MOKHADA

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.829 | 1.9433 | 1.8861 | | .8002 | 1.7718 | |
| 2 | 1.8861 | 1.7147 | 1.8861 | | | 1.7147 | |
| 3 | 1.7718 | 1.7147 | 1.8861 | | | 1.7718 | |
| 4 | 1.829 | .9145 | | | | 1.7718 | |
| 5 | 2.0005 | .9145 | 1.9433 | | | 1.829 | |
| 6 | 2.0576 | .6859 | 2.0576 | | .9145 | 1.8861 | |
| 7 | 1.829 | | | | | 1.7147 | |
| 8 | 1.4289 | | | | 1.1431 | 1.3717 | |
| 9 | 1.4289 | | | | 1.3717 | 1.2003 | |
| 10 | 1.4861 | 1.2003 | | | 1.3146 | 1.086 | |
| 11 | | 1.4289 | | 1.4289 | 1.3717 | 1.0288 | |
| 12 | | 1.1431 | | 1.3717 | 1.4289 | 1.0288 | 1.3146 |
| 13 | | | | | 1.2574 | | 1.1431 |
| 14 | | 1.3146 | | 1.1431 | 1.1431 | | 1.1431 |
| 15 | | 1.2574 | | | 1.3717 | | |
| 16 | | | | 1.2574 | 1.2003 | | 1.3146 |
| 17 | | | | 1.3146 | 1.2574 | | |
| 18 | 1.5432 | | | | 1.3717 | | 1.2574 |
| 19 | 1.7147 | 1.9433 | | | 1.4861 | | 1.6004 |
| 20 | 2.3434 | | | | 2.1719 | | |
| 21 | 2.2862 | 2.4577 | | 2.2291 | 2.1719 | | 2.3434 |
| 22 | | 2.2862 | | 2.1719 | 2.1719 | | 2.1148 |
| 23 | 2.0576 | 2.1148 | | 2.0576 | 2.0005 | | 2.0576 |
| 24 | 1.9433 | 1.9433 | 1.9433 | | 1.8861 | 1.8861 | |
| Max | 2.3434 | 2.4577 | 2.0576 | 2.2291 | 2.1719 | 1.8861 | 2.3434 |
| Min | 1.4289 | .6859 | 1.8861 | 1.1431 | .8002 | 1.0288 | 1.1431 |
| Avg | 1.8397 | 1.5611 | 1.9338 | 1.6218 | 1.4650 | 1.5432 | 1.5877 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284026 / 33/11 KV SUBSTN NO.-

1(CONTESA)

Feeder No / Name : 201 / 11 KV FEEDER NO.-1

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1389 | | 1.2696 | .7842 | | 1.2136 | .9335 |
| 2 | 1.1016 | | 1.2323 | .8402 | | 1.1949 | .9335 |
| 3 | 1.0642 | | 1.2323 | .8029 | | 1.1203 | .8962 |
| 4 | 1.0642 | | 1.2136 | .7842 | | 1.1016 | .8589 |
| 5 | 1.0456 | | 1.1763 | .7468 | | 1.1576 | .8402 |
| 6 | 1.0829 | | 1.0642 | .7655 | | 1.1389 | .8029 |
| 7 | 1.0829 | | 1.9792 | .7655 | | 1.0456 | .8589 |
| 8 | 1.0269 | | .8962 | .8962 | | .8962 | .9709 |
| 9 | .9709 | | .8402 | 1.0082 | | .9149 | 1.1203 |
| 10 | 1.0269 | | | 1.0642 | | | 1.1763 |
| 11 | | | .7282 | | | | 1.2323 |
| 12 | | | | | | | 1.2323 |
| 13 | | | | | | | 1.2883 |
| 14 | | | | | | | 1.363 |
| 15 | | | | | | | 1.363 |
| 17 | | | .6348 | | | | |
| 18 | | | .6161 | | 1.1016 | .8962 | |
| 19 | | | .7655 | | 1.1949 | 1.0642 | |
| 20 | | | .8589 | | 1.251 | | |
| 21 | | | .8962 | | 1.363 | | |
| 22 | | 1.3443 | .9335 | | 1.3443 | 1.0456 | |
| 23 | 1.1016 | 1.3817 | .9335 | | 1.4003 | 1.0082 | |
| 24 | 1.1203 | | 1.2696 | .8215 | | 1.2696 | .9335 |
| Max | 1.1389 | 1.3817 | 1.9792 | 1.0642 | 1.4003 | 1.2696 | 1.363 |
| Min | .9709 | 1.3443 | .6161 | .7468 | 1.1016 | .8962 | .8029 |
| Avg | 1.0689 | 1.363 | 1.0300 | .8436 | 1.2759 | 1.0762 | 1.0503 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284026 / 33/11 KV SUBSTN NO.-

1(CONTESA)

Feeder No / Name : 202 / 11 KV FEEDER NO. 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1389 | 1.1763 | 1.0456 | .6348 | .3547 | 1.1763 | .9335 |
| 2 | 1.1576 | 1.1576 | 1.0269 | .6161 | .3921 | 1.1389 | .9335 |
| 3 | 1.1016 | 1.1389 | 1.0082 | .6722 | .4854 | 1.1949 | .9335 |
| 4 | 1.0829 | | .9896 | .7095 | | 1.1016 | .8962 |
| 5 | 1.0642 | 1.1016 | .9709 | .7468 | .6348 | 1.0829 | .8402 |
| 6 | 1.0829 | 1.0829 | .9896 | .8029 | .7095 | 1.0456 | .7468 |
| 7 | .8775 | 1.0456 | .9149 | .9149 | .7842 | .8962 | 1.0269 |
| 8 | 1.0456 | 1.1203 | 1.0269 | 1.1576 | 1.0642 | 1.0642 | 1.251 |
| 9 | 1.4563 | 1.475 | .8215 | 1.4377 | 1.3817 | 1.1389 | 1.4003 |
| 10 | 1.419 | 1.531 | .7468 | 1.587 | 1.587 | | 1.4937 |
| 11 | | 1.587 | .7842 | | 1.6804 | | 1.643 |
| 12 | | 1.4937 | .7468 | | 1.4003 | | 1.4937 |
| 13 | 1.3817 | 1.307 | .5601 | | 1.307 | | 1.1389 |
| 14 | 1.3817 | 1.419 | .5975 | 1.4377 | 1.3817 | | 1.363 |
| 15 | 1.475 | 1.4937 | .6535 | 1.5497 | 1.4937 | | 1.5497 |
| 16 | 1.419 | 1.4563 | .6535 | 1.643 | 1.4937 | | |
| 17 | 1.3817 | 1.4003 | .7468 | 1.4563 | 1.4937 | | 1.4563 |
| 18 | 1.251 | 1.307 | .6161 | 1.2696 | 1.251 | .5601 | 1.307 |
| 19 | 1.0829 | 1.2696 | .6161 | 1.1576 | 1.1576 | .7468 | 1.2136 |
| 20 | 1.0269 | 1.307 | .7095 | 1.0642 | 1.1389 | | 1.1203 |
| 21 | | 1.2136 | .6348 | | 1.1576 | | 1.1389 |
| 22 | | 1.1763 | .6535 | | 1.1949 | | 1.1576 |
| 23 | 1.0642 | 1.1763 | .6722 | | 1.0829 | .9335 | 1.1389 |
| 24 | 1.1576 | 1.1949 | 1.0456 | .6535 | .2987 | 1.1949 | .9335 |
| Max | 1.475 | 1.587 | 1.0456 | 1.643 | 1.6804 | 1.1949 | 1.643 |
| Min | .8775 | 1.0456 | .5601 | .6161 | .2987 | .5601 | .7468 |
| Avg | 1.2024 | 1.2883 | .8013 | 1.0840 | 1.0837 | 1.0211 | 1.1787 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284026 / 33/11 KV SUBSTN NO.-

1(CONTESA)

Feeder No / Name : 203 / 11 KV FEEDER NO. 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6804 | 1.587 | 1.4377 | .5601 | .5228 | .7842 | 1.0456 |
| 2 | 1.6244 | 1.5497 | 1.419 | .5975 | .5975 | .8215 | 1.0456 |
| 3 | 1.587 | 1.4937 | 1.4563 | .5788 | .6535 | .7655 | 1.0269 |
| 4 | 1.475 | | 1.419 | .5975 | | .8402 | 1.0082 |
| 5 | 1.4377 | 1.3817 | 1.4563 | .5788 | .7468 | .8775 | .9896 |
| 6 | 1.4563 | 1.2696 | 1.363 | .5975 | .7842 | .9149 | 1.0269 |
| 7 | 1.3256 | 1.1763 | .9709 | .5228 | .8215 | .8215 | .8402 |
| 8 | 1.0829 | .5041 | .8029 | .6722 | .9149 | .8589 | 1.251 |
| 9 | 1.4937 | 1.363 | 1.4564 | .8589 | 1.0269 | .9522 | 1.475 |
| 10 | 1.6804 | 1.8671 | .7468 | 1.0642 | 1.0082 | | 1.7551 |
| 11 | | 1.9231 | .8215 | | 1.0829 | | 1.6804 |
| 12 | | 1.7737 | .056 | | 1.0082 | | 1.6057 |
| 13 | 1.587 | 1.6804 | .056 | | 1.0456 | | 1.4937 |
| 14 | 1.6804 | 1.7177 | .5601 | 1.1576 | 1.0269 | | 1.531 |
| 15 | 1.7364 | 1.7551 | .6161 | 1.2323 | 1.0642 | | 1.7364 |
| 16 | 1.6804 | 1.7177 | .6535 | 1.2696 | | | |
| 17 | 1.6244 | 1.6804 | .5975 | 1.1763 | .9709 | | 1.587 |
| 18 | 1.5497 | 1.6804 | .6722 | 1.0829 | 1.0082 | | 1.3817 |
| 19 | 1.4937 | 1.587 | .5228 | .9896 | .8775 | .7468 | 1.4003 |
| 20 | 1.5123 | 1.5123 | .5041 | .9149 | .8215 | | 1.363 |
| 21 | | 1.531 | .5415 | | .8775 | | 1.3443 |
| 22 | | 1.6804 | .5228 | | .9149 | | 1.4003 |
| 23 | 1.4563 | 1.1763 | .5601 | | .8589 | .9896 | 1.3443 |
| 24 | 1.6617 | 1.6244 | 1.4377 | .5788 | .4668 | .8029 | 1.0642 |
| Max | 1.7364 | 1.9231 | 1.4564 | 1.2696 | 1.0829 | .9896 | 1.7551 |
| Min | 1.0829 | .5041 | .056 | .5228 | .4668 | .7468 | .8402 |
| Avg | 1.5413 | 1.5318 | .8604 | .8350 | .8682 | .8480 | 1.3216 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284026 / 33/11 KV SUBSTN NO.-

1(CONTESA)

Feeder No / Name : 204 / 11 KV FEEDER NO. 4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8484 | 2.0725 | 1.8298 | 1.2136 | 1.307 | 2.2779 | 1.9791 |
| 2 | 1.8671 | 2.0351 | 1.7364 | 1.2323 | 1.419 | 2.2405 | 1.9605 |
| 3 | 1.8858 | 2.0165 | 1.7737 | 1.1576 | 1.4937 | 2.2032 | 1.9605 |
| 4 | 2.0725 | | 1.6804 | 1.1763 | | 2.1472 | 1.9791 |
| 5 | 1.9044 | 1.9605 | 1.587 | 1.1389 | 1.6057 | 2.1285 | 1.9605 |
| 6 | 2.0725 | 1.9418 | 1.5497 | 1.1203 | 1.6617 | 2.1098 | 2.0351 |
| 7 | 1.8671 | 1.9231 | 1.0829 | 1.251 | 1.6991 | 1.9791 | 1.8671 |
| 8 | 2.0725 | 2.1098 | 1.0829 | 1.4937 | 2.1472 | 2.0538 | 2.1472 |
| 9 | 2.2218 | 2.3339 | 2.3526 | 1.7551 | 2.2592 | 2.1472 | 2.4272 |
| 10 | 2.4646 | 2.5206 | 1.2136 | 2.1845 | 2.4272 | | 2.6513 |
| 11 | | 2.7633 | 1.251 | | 2.7073 | | 2.7633 |
| 12 | | 2.782 | 1.2136 | | | | 2.7446 |
| 13 | 2.4086 | 2.3525 | 1.2323 | | 2.3152 | | 2.2592 |
| 14 | 2.4459 | 2.5206 | 1.2136 | 2.1285 | 2.4272 | | 2.5393 |
| 15 | 2.5019 | 2.6699 | 1.1949 | 2.2218 | 2.6699 | | 2.726 |
| 16 | 2.5206 | 2.6139 | 1.251 | 2.3899 | 2.6139 | | |
| 17 | 2.5393 | 2.4272 | 1.307 | 2.2405 | 2.6139 | | 2.5206 |
| 18 | 2.3152 | 2.1472 | 1.2696 | 2.0725 | 2.3339 | | 2.3712 |
| 19 | 2.1098 | | 1.1389 | 2.0911 | 2.3152 | 1.7551 | 2.2405 |
| 20 | 2.1098 | 1.9418 | 1.1389 | 2.0911 | 2.4459 | | 1.9791 |
| 21 | | 2.2032 | 1.1949 | | 2.3899 | | 1.9418 |
| 22 | | 2.1285 | 1.1389 | | 2.3899 | | 1.9605 |
| 23 | 1.7364 | 2.0538 | 1.2323 | | 2.3339 | 1.9418 | 2.1472 |
| 24 | 1.7924 | 2.1098 | 1.8111 | 1.2323 | 1.2136 | 2.3152 | 1.9791 |
| Max | 2.5393 | 2.782 | 2.3526 | 2.3899 | 2.7073 | 2.3152 | 2.7633 |
| Min | 1.7364 | 1.9231 | 1.0829 | 1.1203 | 1.2136 | 1.7551 | 1.8671 |
| Avg | 2.1378 | 2.2558 | 1.3949 | 1.6773 | 2.1268 | 2.1083 | 2.2235 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 101 / S/STN TRANSFOEMER

Feeder KV- 33 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | | .2858 | | | | |
| 24 | .1052 | .2858 | .1143 | .1052 | .1143 | .1052 |
| Max | .1052 | .2858 | .1143 | .1052 | .1143 | .1052 |
| Min | .1052 | .2858 | .1143 | .1052 | .1143 | .1052 |
| Avg | .1052 | .2858 | .1143 | .1052 | .1143 | .1052 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 201 / 11 KV FEEDER NO. 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6032 | | 1.5242 | 1.0185 | | 1.5242 | 1.3769 |
| 2 | 1.6032 | | 1.5242 | 1.0185 | | 1.3336 | 1.3769 |
| 3 | 1.6598 | | 1.448 | .9997 | | 1.3336 | 1.3957 |
| 4 | 1.6409 | | 1.3336 | .9997 | | 1.3336 | 1.3957 |
| 5 | 1.6032 | | 1.3336 | 1.0185 | | 1.4098 | 1.4146 |
| 6 | 1.6221 | | 1.3336 | 1.0374 | | 1.4098 | 1.4146 |
| 7 | 1.5655 | | 1.3336 | 1.0374 | | 1.4289 | 1.5466 |
| 8 | 1.5089 | 1.4861 | 1.2955 | 1.2826 | | 1.3717 | 1.6032 |
| 9 | | 1.8671 | | | 1.848 | | |
| 10 | | 2.0957 | 1.2449 | | 1.9052 | 1.4712 | |
| 11 | | 2.0957 | 1.2449 | | 2.0195 | 1.4146 | |
| 12 | | 2.2481 | 1.1694 | | 2.191 | 1.358 | |
| 13 | | 1.9052 | 1.0562 | | 1.5242 | 1.2826 | |
| 14 | | 1.9052 | 1.094 | | 1.9052 | 1.3769 | |
| 15 | | 1.829 | 1.1128 | | 2.0957 | 1.358 | |
| 16 | | 1.829 | 1.1694 | | 2.0957 | 1.358 | |
| 17 | | 1.9052 | 1.1883 | | 2.0957 | 1.3203 | |
| 18 | | 1.9052 | 1.1694 | | 1.9052 | 1.2826 | |
| 19 | | 1.8671 | 1.2071 | | 1.9052 | 1.3203 | |
| 20 | | 1.9052 | 1.1694 | | 1.7147 | 1.358 | |
| 21 | | 1.7147 | 1.1317 | | 1.6766 | 1.4146 | |
| 22 | | 1.6385 | 1.094 | | 1.7147 | | |
| 23 | | 1.5242 | 1.0562 | | 1.5242 | | |
| 24 | 1.6409 | | 3.6008 | 1.0374 | | 1.5242 | 1.3957 |
| Max | 1.6598 | 2.2481 | 3.6008 | 1.2826 | 2.191 | 1.5242 | 1.6032 |
| Min | 1.5089 | 1.4861 | 1.0562 | .9997 | 1.5242 | 1.2826 | 1.3769 |
| Avg | 1.6053 | 1.8576 | 1.3406 | 1.0500 | 1.8747 | 1.3802 | 1.4355 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 202 / 11KV Vidyanagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9814 | | 2.0957 | 1.6766 | | 1.9052 | 1.9433 |
| 2 | 1.829 | | 2.0957 | 1.6385 | | 1.8671 | 1.829 |
| 3 | 1.6766 | | 1.9052 | 1.5623 | | 1.7147 | 1.7147 |
| 4 | 1.6004 | | 1.9052 | 1.5242 | | 1.7147 | 1.6766 |
| 5 | 1.6385 | | 1.8671 | 1.448 | | 1.6766 | 1.6766 |
| 6 | 1.6766 | | 1.7147 | 1.4098 | | 1.7147 | 1.6385 |
| 7 | 1.6194 | | 1.448 | 1.3336 | | 1.6766 | 1.6194 |
| 8 | 1.5813 | 1.5623 | 1.3336 | 1.467 | | 1.6766 | 1.6194 |
| 9 | | 1.7147 | | | 1.4861 | | |
| 10 | | 1.7147 | 1.2765 | | 1.5242 | 1.6385 | |
| 11 | | 1.5242 | 1.2955 | | 1.7147 | 1.5242 | |
| 12 | | 1.7147 | 1.2574 | | 1.7147 | 1.448 | |
| 13 | | 1.3336 | 1.1812 | | 1.5242 | | |
| 14 | | 1.7147 | 1.2574 | | 1.7147 | | |
| 15 | | 1.7147 | | | 1.5242 | | |
| 16 | | 1.7147 | 1.2955 | | 1.5242 | | |
| 17 | | 1.7147 | 1.3146 | | 1.5242 | | |
| 18 | | 1.5242 | 1.3336 | | 1.448 | 1.9243 | |
| 19 | | 1.5242 | 1.3336 | | 1.467 | 2.0005 | |
| 20 | | 1.8099 | 1.6004 | | 1.9052 | 2.0576 | |
| 21 | | 1.7147 | 1.7528 | | | 2.0957 | |
| 22 | | 1.6766 | 1.7337 | | 2.0957 | | |
| 23 | | 1.7147 | 1.7909 | | 2.0957 | | |
| 24 | 2.0576 | | 3.2769 | 1.7337 | | 1.9052 | 1.9814 |
| Max | 2.0576 | 1.8099 | 3.2769 | 1.7337 | 2.0957 | 2.0957 | 1.9814 |
| Min | 1.5813 | 1.3336 | 1.1812 | 1.3336 | 1.448 | 1.448 | 1.6194 |
| Avg | 1.7401 | 1.6492 | 1.6393 | 1.5326 | 1.6616 | 1.7838 | 1.7443 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 203 / 11KV Bajaj Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8484 | | 2.0957 | 1.1694 | | 1.9052 | 1.3769 |
| 2 | 1.8296 | | 2.0957 | 1.1883 | | 1.9052 | 1.4146 |
| 3 | 1.7918 | | 1.9052 | 1.1883 | | 1.8671 | 1.4146 |
| 4 | 1.7541 | | 1.7147 | 1.1694 | | 1.8671 | 1.4335 |
| 5 | 1.7353 | | 1.7147 | 1.1883 | | 1.7147 | 1.4712 |
| 6 | 1.6975 | | 1.5242 | 1.2071 | | 1.5242 | 1.5089 |
| 7 | 1.8484 | | 1.4861 | 1.2071 | | 1.6194 | 1.7164 |
| 8 | 1.9993 | 2.0957 | .9526 | 1.8296 | | 1.467 | 1.8107 |
| 9 | | 2.934 | | | 3.1055 | | |
| 10 | | 3.0483 | 1.0562 | | 3.2388 | 1.905 | |
| 11 | | 3.2388 | 1.0751 | | 3.2388 | 1.9239 | |
| 12 | | 2.2291 | 1.0562 | | 3.3913 | 1.905 | |
| 13 | | 2.2862 | .9808 | | 2.6673 | 1.8107 | |
| 14 | | 2.4768 | 1.0185 | | 3.4294 | 1.8861 | |
| 15 | | 3.0483 | 1.0562 | | 3.3341 | 1.8107 | |
| 16 | | 3.1626 | 1.0562 | | 3.3341 | 1.6975 | |
| 17 | | 3.0483 | 1.0374 | | 3.0483 | 1.5089 | |
| 18 | | 2.8578 | 1.0185 | | 2.6673 | 1.5089 | |
| 19 | | 2.6673 | 1.0185 | | 2.4768 | 1.4335 | |
| 20 | | 2.3815 | 1.0374 | | 2.2862 | 1.3957 | |
| 21 | | 2.2862 | 1.0751 | | 2.191 | 1.358 | |
| 22 | | 2.2862 | 1.0751 | | 2.0957 | | |
| 23 | | 2.2862 | 1.094 | | 2.0957 | | |
| 24 | 1.905 | | 3.8104 | 1.1694 | | 2.0195 | 1.358 |
| Max | 1.9993 | 3.2388 | 3.8104 | 1.8296 | 3.4294 | 2.0195 | 1.8107 |
| Min | 1.6975 | 2.0957 | .9526 | 1.1694 | 2.0957 | 1.358 | 1.358 |
| Avg | 1.8233 | 2.6458 | 1.3893 | 1.2574 | 2.8400 | 1.7159 | 1.5005 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 204 / 11 KV FEEDER NO. 4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4289 | | 1.448 | 1.094 | | 1.1431 | 1.0185 |
| 2 | 1.448 | | 1.448 | 1.1317 | | | 1.0185 |
| 3 | 1.448 | | | 1.1317 | | .9526 | 1.0562 |
| 4 | 1.4289 | | 1.3717 | 1.094 | | .9526 | 1.0562 |
| 5 | 1.4861 | | 1.3717 | 1.094 | | 1.0669 | 1.094 |
| 6 | 1.5432 | | 1.3336 | 1.0562 | | 1.0669 | 1.0751 |
| 7 | 1.3717 | | 1.3336 | 1.0751 | | 1.0669 | 1.0185 |
| 8 | 1.0562 | 1.1241 | 1.0669 | 1.0562 | | .8764 | .9997 |
| 9 | | 1.2765 | | | 1.4289 | | |
| 10 | | 1.2955 | .9997 | | 1.4289 | .9054 | |
| 11 | | 1.3336 | 1.0185 | | 1.3336 | .7922 | |
| 12 | | 1.2574 | .9997 | | 1.4861 | .8865 | |
| 13 | | 1.1431 | 1.0751 | | 1.1431 | .9242 | |
| 14 | | 1.2574 | .9808 | | 1.2574 | .9997 | |
| 15 | | 1.7147 | 1.1694 | | 1.2574 | .9808 | |
| 16 | | 1.7147 | 1.1317 | | 1.3336 | .9808 | |
| 17 | | 1.7147 | 1.0374 | | 1.1431 | .9242 | |
| 18 | | 1.4289 | .9431 | | 1.1431 | .8488 | |
| 19 | | 1.3336 | 1.0374 | | .9526 | .8676 | |
| 20 | | 1.3336 | 1.0185 | | 1.1431 | .8676 | |
| 21 | | 1.1431 | .9808 | | 1.3717 | .8488 | |
| 22 | | 1.2574 | .9619 | | 1.3336 | | |
| 23 | | 1.3336 | 1.0185 | | 1.1431 | | |
| 24 | 1.4098 | | 1.4289 | 1.094 | | 1.1431 | .9808 |
| Max | 1.5432 | 1.7147 | 1.448 | 1.1317 | 1.4861 | 1.1431 | 1.094 |
| Min | 1.0562 | 1.1241 | .9431 | 1.0562 | .9526 | .7922 | .9808 |
| Avg | 1.4023 | 1.3539 | 1.1443 | 1.0919 | 1.2600 | .9548 | 1.0353 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 205 / 11 KV FEEDER NO. 5-WATER NON SHEDDABLE WATER SUPPLY AND
WORK- Feeder KV- 11 / OUTGOING UTILITY

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | .9945 |
| Max | .9945 |
| Min | .9945 |
| Avg | .9945 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284027 / 33/11KV SUBSTN - II

Feeder No / Name : 206 / 11 KV FEEDER NO. 6

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6292 | | 2.6673 | 2.0005 | | 2.5911 | 2.21 |
| 2 | 2.5911 | | 2.5911 | 1.9814 | | 2.5911 | 2.191 |
| 3 | 2.5911 | | 2.4768 | 1.9624 | | 2.4768 | 2.191 |
| 4 | 2.553 | | 2.4006 | 1.9624 | | 2.4768 | 2.21 |
| 5 | 2.553 | | 2.3243 | 1.9433 | | 2.3624 | 2.2291 |
| 6 | 2.5149 | | 2.2862 | 1.9243 | | 2.3624 | 2.2291 |
| 7 | 2.6863 | | 2.3053 | 1.9433 | | 2.3053 | 2.3815 |
| 8 | 2.8197 | 2.6863 | | 2.4006 | | 2.1719 | 2.6101 |
| 9 | | 3.6199 | | | 3.3913 | | |
| 10 | | 4.0009 | 2.1529 | | 3.3913 | 2.3053 | |
| 11 | | 4.0009 | 2.1719 | | 3.4294 | 2.3624 | |
| 12 | | 3.9247 | 2.1338 | | 3.4294 | 2.4577 | |
| 13 | | 3.4294 | 1.9814 | | 2.6673 | 2.0957 | |
| 14 | | 4.0009 | 2.0576 | | 3.4294 | 2.3053 | |
| 15 | | 4.0009 | 2.0195 | | 3.6199 | 2.3243 | |
| 16 | | 4.0009 | 2.0576 | | 3.6199 | 2.2862 | |
| 17 | | 3.8104 | 2.0195 | | 3.4294 | 2.2672 | |
| 18 | | 3.6199 | 2.0576 | | 3.2388 | 2.191 | |
| 19 | | 3.2388 | 2.0386 | | 2.9721 | 2.1338 | |
| 20 | | 2.8769 | 2.0005 | | 2.8197 | 2.0957 | |
| 21 | | 2.8578 | 1.9433 | | 2.6673 | 2.0576 | |
| 22 | | 2.6673 | 1.9052 | | 2.6673 | | |
| 23 | | 2.6673 | 1.9433 | | 2.6673 | | |
| 24 | 2.6673 | | 2.6863 | 2.0005 | | 2.5911 | 2.1338 |
| Max | 2.8197 | 4.0009 | 2.6863 | 2.4006 | 3.6199 | 2.5911 | 2.6101 |
| Min | 2.5149 | 2.6673 | 1.9052 | 1.9243 | 2.6673 | 2.0576 | 2.1338 |
| Avg | 2.6228 | 3.4627 | 2.1918 | 2.0132 | 3.1627 | 2.3243 | 2.2651 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)

Feeder No / Name : 201 / 11 FEEDER NO. 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.4331 | 2.4143 | 2.3765 | 1.2637 | 1.8861 | 1.9616 | 1.8484 |
| 2 | 2.3954 | 2.4143 | 2.2634 | 1.2637 | 1.8861 | 1.9239 | 1.8296 |
| 3 | 2.3577 | 2.3954 | 2.0748 | 1.2637 | 1.8484 | 1.9239 | 1.8107 |
| 4 | 2.3011 | 2.3011 | 1.9805 | 1.2826 | 1.8296 | 1.9616 | 1.7353 |
| 5 | 2.2634 | 2.2634 | 1.8861 | 1.2637 | 1.8107 | 1.9239 | 1.8861 |
| 6 | 2.3011 | 2.1879 | 1.6975 | 1.226 | 1.8107 | 3.9798 | 2.0748 |
| 7 | 2.32 | 2.3765 | 1.5089 | 1.358 | 1.8107 | 1.9993 | 2.1879 |
| 8 | 2.32 | 2.3954 | 1.1883 | 1.8107 | 1.8484 | 1.8484 | 1.9805 |
| 9 | 2.6029 | 2.7161 | 1.2449 | 2.0748 | 2.2634 | 1.9616 | 2.2634 |
| 10 | 3.0933 | 3.2065 | 1.2637 | 2.4897 | 2.7161 | 1.6975 | 3.2819 |
| 11 | 2.9613 | 3.3762 | 1.2826 | 2.5086 | 2.2634 | 1.9427 | 3.2442 |
| 12 | 2.9801 | 3.3951 | 1.1506 | 2.452 | 2.8292 | 1.9805 | 3.3573 |
| 13 | 2.8292 | 2.9047 | 1.1883 | 2.3765 | 2.0748 | 1.8484 | 2.3577 |
| 14 | 2.7915 | 2.9801 | 1.1506 | 2.2634 | 2.8481 | 2.0748 | 2.999 |
| 15 | 2.7349 | 3.3573 | 1.226 | 2.2257 | 2.2634 | 1.9805 | 2.2634 |
| 16 | 2.8481 | 3.263 | 1.1883 | 2.0748 | 2.6217 | 1.9993 | 3.0178 |
| 17 | 2.8858 | 3.0367 | 1.1694 | 2.0182 | 2.584 | 1.9427 | 2.9047 |
| 18 | 2.5274 | 2.8292 | 1.226 | 2.0182 | 2.2257 | 1.8107 | 2.6406 |
| 19 | 2.4897 | 2.5652 | 1.2071 | 2.037 | 2.1125 | 1.8107 | 2.4143 |
| 20 | 2.4143 | 2.5652 | 1.226 | 2.037 | 1.9993 | 1.773 | 2.6029 |
| 21 | 2.6029 | 2.5463 | 1.226 | 2.0748 | 2.037 | 1.7353 | 2.452 |
| 22 | 2.452 | 2.5463 | 1.2071 | 2.1502 | 1.9993 | 1.6975 | 2.6406 |
| 23 | 2.452 | 2.452 | 1.226 | 2.1125 | 1.9805 | 1.773 | 2.6029 |
| 24 | 2.4331 | 2.4897 | 2.3765 | 1.2449 | 2.0748 | 1.9993 | 1.8484 |
| Max | 3.0933 | 3.3951 | 2.3765 | 2.5086 | 2.8481 | 3.9798 | 3.3573 |
| Min | 2.2634 | 2.1879 | 1.1506 | 1.226 | 1.8107 | 1.6975 | 1.7353 |
| Avg | 2.5746 | 2.7074 | 1.4806 | 1.8704 | 2.1510 | 1.9812 | 2.4269 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 202 / 11 KV FEEDER NO. 2
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4146 | 1.4901 | 1.358 | 1.0562 | 1.3203 | 1.3014 | 1.1694 |
| 2 | 1.3769 | 1.4335 | 1.3203 | 1.0562 | 1.358 | 1.2826 | 1.1506 |
| 3 | 1.3392 | 1.3957 | 1.3203 | 1.0185 | 1.3769 | 1.2637 | 1.1317 |
| 4 | 1.3203 | 1.358 | 1.2826 | 1.0185 | 1.358 | 1.226 | 1.1694 |
| 5 | 1.3014 | 1.3203 | 1.1694 | 1.0374 | 1.3769 | 1.2637 | 1.226 |
| 6 | 1.3203 | 1.2637 | 1.1317 | 1.0185 | 1.358 | 1.2826 | 1.226 |
| 7 | | 1.3957 | 1.0374 | 1.0374 | 1.3957 | 1.1694 | 1.226 |
| 8 | 1.4146 | 1.4335 | .8865 | 1.2449 | 1.6032 | 1.2449 | 2.1691 |
| 9 | 1.4712 | 1.8107 | .9054 | 1.8484 | 1.905 | 1.3392 | 2.2634 |
| 10 | 2.037 | 2.1313 | .9054 | 1.9239 | 2.1313 | 1.3014 | 2.1879 |
| 11 | 2.0559 | 2.1879 | .9997 | 1.9239 | 2.0748 | 1.5844 | 2.2634 |
| 12 | 1.9805 | 2.1125 | 1.0751 | 1.905 | 1.9805 | 1.6032 | 2.0748 |
| 13 | 1.9993 | 1.9427 | 1.1694 | 1.9427 | 1.9239 | 1.5466 | 1.9805 |
| 14 | 1.9805 | 2.0559 | 1.0185 | 1.8861 | 2.1313 | 1.3014 | 2.0182 |
| 15 | 2.037 | 2.1313 | .8865 | 1.8673 | 2.0748 | 1.5466 | 2.1691 |
| 16 | 2.2068 | 1.8861 | 1.1317 | 1.7918 | 2.037 | 1.4335 | 2.037 |
| 17 | 2.1125 | 1.8484 | 1.0751 | 1.7541 | 2.037 | 1.3957 | 2.0559 |
| 18 | 1.8484 | 1.6975 | 1.0374 | 1.7164 | 1.7353 | 1.3203 | 1.9616 |
| 19 | 1.5844 | 1.5466 | 1.0185 | 1.6032 | 1.6221 | 1.2826 | 1.6598 |
| 20 | 1.6221 | 1.5655 | 1.0185 | 1.5089 | 1.4523 | 1.2449 | 1.5089 |
| 21 | 1.5844 | 1.5278 | 1.094 | 1.4146 | 1.5466 | 1.226 | 1.5089 |
| 22 | 1.5466 | 1.5089 | .9808 | 1.3392 | 1.5466 | 1.2637 | 1.5466 |
| 23 | 1.5089 | 1.4712 | 1.0185 | 1.3203 | 1.4335 | 1.226 | 1.5278 |
| 24 | 1.4523 | 1.4712 | 1.3769 | 1.0751 | 1.3014 | 1.358 | 1.1694 |
| Max | 2.2068 | 2.1879 | 1.3769 | 1.9427 | 2.1313 | 1.6032 | 2.2634 |
| Min | 1.3014 | 1.2637 | .8865 | 1.0185 | 1.3014 | 1.1694 | 1.1317 |
| Avg | 1.6746 | 1.6661 | 1.0924 | 1.4712 | 1.6700 | 1.3337 | 1.6834 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 203 / 11 KV FEEDER NO. III
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.226 | 1.1506 | .9808 | .6036 | 1.0562 | 1.1506 | .811 |
| 2 | 1.1883 | 1.1317 | .9431 | .5847 | 1.0374 | 1.094 | .7922 |
| 3 | 1.1694 | 1.1317 | .9431 | .5658 | 1.0185 | 1.0751 | .7733 |
| 4 | 1.1506 | 1.0185 | .8865 | .5658 | .9997 | 1.0562 | .7545 |
| 5 | 1.1317 | 1.094 | .8488 | .5847 | .9808 | 1.0751 | .7922 |
| 6 | 1.094 | 1.1694 | .7545 | .7545 | .9619 | 1.0751 | .8488 |
| 7 | .9431 | 1.1317 | .6602 | .6979 | .9431 | 1.0185 | .8865 |
| 8 | .9054 | 1.094 | .5658 | .8488 | 1.0751 | .9431 | .9054 |
| 9 | 1.2071 | 1.2449 | .6224 | 1.094 | 1.3014 | .9808 | .9431 |
| 10 | 1.3392 | 1.3392 | .6602 | 1.2826 | 1.4335 | 1.0374 | 1.4146 |
| 11 | 1.4335 | 1.5466 | .7545 | 1.226 | 1.1128 | 1.0751 | 1.5089 |
| 12 | 1.3392 | 1.3957 | .547 | 1.1883 | 1.5466 | .9431 | 1.4901 |
| 13 | 1.3014 | 1.358 | .6602 | 1.1506 | 1.4901 | .9808 | 1.5089 |
| 14 | 1.5089 | 1.3203 | .5847 | 1.1694 | 1.5655 | .9997 | 1.4523 |
| 15 | 1.358 | 1.2826 | .5658 | 1.1694 | 1.226 | 1.094 | 1.4146 |
| 16 | 1.3203 | 1.4146 | .5847 | 1.1883 | 1.4712 | 1.0374 | 1.4712 |
| 17 | 1.3769 | 1.4335 | .6224 | 1.2071 | 1.4146 | 1.0562 | 1.4523 |
| 18 | 1.226 | 1.3203 | .6413 | 1.2449 | 1.2826 | .8676 | 1.3203 |
| 19 | 1.1694 | 1.226 | .6413 | 1.1694 | 1.2826 | .8299 | 1.2449 |
| 20 | 1.1694 | 1.1694 | .6413 | 1.1317 | 1.2449 | .811 | 1.2071 |
| 21 | 1.2071 | 1.1317 | .6224 | 1.094 | 1.2071 | .7922 | 1.226 |
| 22 | 1.2071 | 1.0751 | .6224 | 1.0751 | 1.2449 | .811 | 1.1694 |
| 23 | 1.1694 | 1.0374 | .6224 | 1.0562 | 1.226 | .811 | 1.1506 |
| 24 | 1.226 | 1.1694 | .9997 | .6224 | 1.094 | 1.2071 | .811 |
| Max | 1.5089 | 1.5466 | .9997 | 1.2826 | 1.5655 | 1.2071 | 1.5089 |
| Min | .9054 | 1.0185 | .547 | .5658 | .9431 | .7922 | .7545 |
| Avg | 1.2236 | 1.2244 | .7073 | .9698 | 1.2174 | .9926 | 1.1396 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 205 / 11KV SHIVAJINAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5089 | 1.5278 | 1.4712 | 1.1317 | 1.6032 | 1.4901 | 1.4146 |
| 2 | 1.5089 | 1.4901 | 1.4335 | 1.1694 | 1.5655 | 1.4335 | 1.3769 |
| 3 | 1.4523 | 1.4523 | 1.4146 | 1.0562 | 1.5466 | 1.4712 | 1.358 |
| 4 | 1.4146 | 1.5278 | 1.3203 | 1.0185 | 1.5089 | 1.5466 | 1.3203 |
| 5 | 1.3769 | 1.5089 | 1.226 | 1.1317 | 1.4712 | 1.4712 | 1.3014 |
| 6 | 1.358 | 1.5278 | 1.1317 | 1.1694 | 1.3957 | 1.3957 | 1.2826 |
| 7 | 1.3392 | 1.5089 | .9431 | 1.1317 | 1.358 | 1.2071 | 1.2826 |
| 8 | 1.3203 | 1.4712 | .8299 | 1.1317 | 1.4146 | 1.2071 | 1.4146 |
| 9 | 1.3957 | 1.4901 | .9242 | 1.358 | 1.4146 | 1.2826 | 1.5655 |
| 10 | 1.5278 | 1.7353 | .9619 | 1.5844 | 1.5655 | 1.1694 | 1.6032 |
| 11 | 1.6032 | 1.7164 | .9431 | 1.5844 | 1.6032 | 1.226 | 1.5655 |
| 12 | 1.5278 | 1.6032 | 1.0751 | 1.358 | 1.6975 | 1.1694 | 1.7353 |
| 13 | 1.4523 | 1.5089 | .9619 | 1.226 | 1.7918 | 1.1506 | 1.6975 |
| 14 | 1.5089 | 1.4335 | .9808 | 1.3014 | 1.6787 | 1.1694 | 1.6221 |
| 15 | 1.6787 | 1.7353 | .9431 | 1.358 | 1.5089 | 1.226 | 1.4146 |
| 16 | 1.5844 | 1.5278 | .9808 | 1.5089 | 1.6787 | 1.1883 | 1.4712 |
| 17 | 1.5466 | 1.4712 | .8488 | 1.5278 | 1.6032 | 1.2449 | 1.5089 |
| 18 | 1.5844 | 1.4146 | .8676 | 1.5466 | 1.5089 | 1.2449 | 1.5466 |
| 19 | 1.6598 | 1.3203 | .8676 | 1.5655 | 1.5089 | 1.2826 | 1.358 |
| 20 | 1.4712 | 1.358 | .9808 | 1.5844 | 1.5278 | 1.358 | 1.4335 |
| 21 | 1.6598 | 1.4146 | 1.3014 | 1.6032 | 1.6221 | 1.3957 | 1.5089 |
| 22 | 1.773 | 1.5089 | 1.2637 | 1.6221 | 1.5844 | 1.4523 | 1.5278 |
| 23 | 1.6975 | 1.4712 | 1.2449 | 1.6221 | 1.5844 | 1.4335 | 1.5089 |
| 24 | 1.6975 | 1.6221 | 1.4712 | 1.2449 | 1.6032 | 1.6032 | 1.3717 |
| Max | 1.773 | 1.7353 | 1.4712 | 1.6221 | 1.7918 | 1.6032 | 1.7353 |
| Min | 1.3203 | 1.3203 | .8299 | 1.0185 | 1.358 | 1.1506 | 1.2826 |
| Avg | 1.5270 | 1.5144 | 1.0995 | 1.3557 | 1.5561 | 1.3258 | 1.4663 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 206 / 11 KV AARTI DRUGS (T 150) NON SHEDDABLE EXPRESS HV FEEDERS
EXPR Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1509 | .132 | .1509 | .1509 | .2829 | .2075 |
| 2 | | .1509 | | .1509 | .132 | .2641 | .1886 |
| 3 | | .1509 | | .1509 | .132 | .2829 | .1698 |
| 4 | | .1509 | | .1509 | .132 | .2641 | .1886 |
| 5 | | .1509 | | .1509 | .1132 | .2641 | .2075 |
| 6 | | .1509 | | .1509 | | .2452 | .1886 |
| 7 | | .0754 | | .1132 | | .2263 | .2075 |
| 8 | | .0754 | | .0943 | | .2263 | .2075 |
| 9 | | | | .0377 | | .2075 | .2058 |
| 10 | | | | .1886 | | .1886 | .2075 |
| 11 | | | | | .1698 | .2075 | .1698 |
| 12 | .0566 | | | | .1886 | .1698 | .2263 |
| 13 | | .1509 | | | .2452 | .2075 | .2075 |
| 14 | | | | | .2829 | 1.2826 | .2263 |
| 15 | | | | | .2263 | .1886 | .1886 |
| 16 | | | .2641 | | .3395 | .2075 | .2452 |
| 17 | | | | | .3206 | .2829 | .2452 |
| 18 | | | | | | .2263 | .2263 |
| 19 | .1509 | .1509 | | | .3206 | .2452 | .1698 |
| 20 | .1509 | .1509 | .1509 | .2263 | .3395 | .2641 | .1509 |
| 21 | .1509 | .1698 | .1509 | .2829 | .3772 | .2829 | .1509 |
| 22 | .1509 | .1509 | .1509 | .3018 | .3584 | .2263 | .1509 |
| 23 | .1509 | .1509 | .1509 | .1509 | .3395 | .2075 | .1698 |
| 24 | | .1509 | .1509 | .1698 | .1509 | .2829 | .2263 |
| Max | .1509 | .1698 | .2641 | .3018 | .3772 | 1.2826 | .2452 |
| Min | .0566 | .0754 | .132 | .0377 | .1132 | .1698 | .1509 |
| Avg | .1352 | .1421 | .1644 | .1647 | .2400 | .2806 | .1972 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 207 / 11KV AARTI INDUSTRIES K18 NON SHEDDABLE EXPRESS HV FEEDERS
Expr Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5655 | 1.5089 | 1.4335 | 1.358 | 1.358 | 1.5466 | 1.6221 |
| 2 | 1.5278 | 1.4335 | 1.4146 | 1.358 | 1.3392 | 1.5089 | 1.5844 |
| 3 | 1.5089 | 1.3957 | 1.4146 | 1.3392 | 1.3203 | 1.3957 | 1.5655 |
| 4 | 1.4901 | 1.5278 | 1.3957 | 1.3392 | 1.3203 | 1.2826 | 1.5466 |
| 5 | 1.4146 | 1.358 | 1.3769 | 1.2826 | 1.2826 | 1.358 | 1.4146 |
| 6 | 1.4146 | | 1.358 | 1.3957 | 1.3014 | 1.4712 | 1.4146 |
| 7 | 1.4335 | 1.358 | 1.4146 | 1.2071 | 1.3014 | 1.358 | 1.358 |
| 8 | 1.4146 | 1.4146 | 1.4335 | 1.4523 | 1.358 | 1.2826 | 1.5089 |
| 9 | 1.5089 | 1.5655 | 1.4146 | 1.5278 | 1.5278 | 1.4523 | 1.6598 |
| 10 | 1.5278 | 1.5655 | 1.4335 | 1.6221 | 1.6787 | 1.226 | 1.5655 |
| 11 | 1.5278 | 1.6221 | 1.4146 | 1.5844 | 1.3014 | 1.4712 | 1.4146 |
| 12 | 1.5089 | 1.6409 | 1.4901 | 1.5089 | 1.3014 | 1.4146 | 1.5089 |
| 13 | 1.2826 | 1.6598 | 1.4335 | 1.4146 | 1.5278 | 1.3769 | 1.3203 |
| 14 | 1.3014 | 1.6032 | 1.358 | 1.4335 | 1.2826 | 1.4146 | 1.4146 |
| 15 | 1.4335 | 1.6221 | 1.4146 | 1.4523 | 1.5278 | 1.6032 | 1.5089 |
| 16 | 1.3392 | 1.6409 | 1.5278 | 1.3957 | 1.5466 | 1.5466 | 1.6598 |
| 17 | 1.4146 | 1.6032 | 1.4146 | 1.4146 | 1.6032 | 1.5089 | 1.3957 |
| 18 | 1.358 | 1.5089 | 1.4146 | 1.4146 | 1.4712 | 1.4523 | 1.3957 |
| 19 | 1.3392 | 1.3769 | 1.2449 | 1.3957 | 1.4712 | 1.4335 | 1.3203 |
| 20 | 1.4901 | 1.3769 | 1.3957 | 1.3769 | 1.4523 | 1.3957 | 1.5089 |
| 21 | 1.4335 | 1.358 | 1.3392 | 1.358 | 1.3957 | 1.3769 | 1.3957 |
| 22 | 1.3957 | 1.4901 | 1.358 | 1.3392 | 1.3957 | 1.4146 | 1.3957 |
| 23 | 1.4712 | 1.4712 | 1.3957 | 1.3203 | 1.4146 | 1.5089 | 1.4335 |
| 24 | 1.5844 | 1.5089 | 1.4335 | 1.3957 | 1.358 | 1.4146 | 1.6221 |
| Max | 1.5844 | 1.6598 | 1.5278 | 1.6221 | 1.6787 | 1.6032 | 1.6598 |
| Min | 1.2826 | 1.358 | 1.2449 | 1.2071 | 1.2826 | 1.226 | 1.3203 |
| Avg | 1.4453 | 1.5048 | 1.4052 | 1.4036 | 1.4099 | 1.4256 | 1.4806 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 208 / 11 KV GALAXY FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1883 | 1.1694 | 1.1317 | .5847 | 1.1506 | 1.1694 | .7167 |
| 2 | 1.1694 | 1.2071 | 1.0751 | .5658 | 1.1694 | 1.1506 | .6979 |
| 3 | 1.1506 | 1.2449 | 1.0185 | .5847 | 1.1317 | 1.1317 | .679 |
| 4 | 1.1317 | 1.2071 | .9431 | .5658 | 1.1694 | 1.1317 | .7545 |
| 5 | 1.1128 | 1.226 | .8865 | .5658 | 1.226 | 1.1317 | .7545 |
| 6 | 1.1317 | 1.2449 | .7922 | .5658 | 1.3014 | 1.094 | .7545 |
| 7 | 1.226 | 1.226 | .7545 | .6413 | 1.3203 | 1.0185 | .7545 |
| 8 | 1.3203 | .7922 | .6979 | .8676 | 1.3014 | 1.0185 | .7733 |
| 9 | 1.7353 | 1.6975 | .6036 | 1.5844 | 1.7164 | .8299 | .8488 |
| 10 | 1.905 | 1.7353 | .6602 | 1.5844 | 1.7541 | .7545 | 1.094 |
| 11 | 2.037 | 1.8673 | .5093 | 1.6221 | 1.8296 | .8676 | 1.226 |
| 12 | 2.0748 | 1.7164 | .547 | 1.6598 | 1.6975 | .7545 | 1.358 |
| 13 | 1.7918 | 1.8484 | .6602 | 1.6975 | 1.8484 | .7733 | 1.226 |
| 14 | 1.8861 | 2.037 | .5658 | 1.773 | 1.9805 | .8488 | 1.1883 |
| 15 | 1.8861 | 1.8484 | .547 | 1.8673 | 1.8484 | .7922 | 1.2826 |
| 16 | 1.9427 | 1.9616 | .5658 | 1.8861 | 2.0182 | .7545 | 1.2637 |
| 17 | 1.7164 | 1.8861 | .547 | 1.9239 | 1.9616 | .7356 | 1.3203 |
| 18 | 1.4335 | 1.6975 | .5093 | 1.9427 | 1.6598 | .5658 | 1.0185 |
| 19 | 1.358 | 1.4712 | .5281 | 1.8861 | 1.5844 | .5847 | .9431 |
| 20 | 1.1317 | 1.3203 | .5658 | 1.6975 | 1.1317 | .6224 | .8865 |
| 21 | 1.1694 | 1.226 | .547 | 1.3203 | 1.3014 | .6413 | .9054 |
| 22 | 1.2449 | 1.1128 | .547 | 1.226 | 1.1317 | .7167 | .8676 |
| 23 | 1.2637 | 1.1317 | .547 | 1.226 | 1.1694 | .7167 | .8676 |
| 24 | 1.2071 | 1.2449 | 1.1317 | .5658 | 1.1694 | 1.2637 | .7167 |
| Max | 2.0748 | 2.037 | 1.1317 | 1.9427 | 2.0182 | 1.2637 | 1.358 |
| Min | 1.1128 | .7922 | .5093 | .5658 | 1.1317 | .5658 | .679 |
| Avg | 1.4673 | 1.4633 | .7034 | 1.2669 | 1.4822 | .8778 | .9541 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284028 / 33/11 KV SUBSTN NO.III(N
ZONE)Feeder No / Name : 301 / 33KV O/G Feeder No-1
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 5.8282 | 5.2058 | 5.6584 | 3.2253 | 4.5268 | 4.8663 | 4.1872 |
| 2 | 5.7716 | 5.3189 | 5.0926 | 3.1687 | 4.4136 | 4.7531 | 4.1307 |
| 3 | 5.6584 | 5.2675 | 5.0926 | 3.2253 | 4.357 | 4.7531 | 4.0741 |
| 4 | 5.3755 | 4.8663 | 4.5268 | 3.1687 | 4.2438 | 4.7531 | 4.0741 |
| 5 | 5.2624 | 4.5268 | 4.5268 | 3.1687 | 4.1307 | 4.5268 | 3.9609 |
| 6 | 5.1492 | 4.4136 | 3.9609 | 3.1687 | 4.0741 | 4.3004 | 3.9609 |
| 7 | 5.036 | 4.4136 | 3.8477 | 3.3951 | 4.0175 | 4.1872 | 4.0175 |
| 8 | 4.9228 | 4.8097 | 3.7912 | 3.8477 | 4.6399 | 4.3004 | 5.0926 |
| 9 | 5.8282 | 5.5453 | 3.5082 | 4.6399 | 5.3755 | 4.6965 | 5.9414 |
| 10 | 6.0545 | 5.6584 | 3.4517 | 4.0741 | 5.4887 | 4.2438 | 4.8097 |
| 11 | 6.3375 | 5.9414 | 3.3951 | 3.9609 | 5.0926 | 4.0175 | 5.0926 |
| 12 | 5.6584 | 6.1677 | 3.2819 | 3.5082 | 5.4887 | 4.3004 | 5.8282 |
| 13 | 5.3189 | 5.0926 | 3.5082 | 3.2819 | 5.9414 | 4.1307 | 5.9414 |
| 14 | 6.3375 | 6.3375 | 3.4517 | 3.3951 | 5.715 | 4.2438 | 6.2809 |
| 15 | 5.4887 | 5.6584 | 3.678 | 3.678 | 5.9414 | 4.5268 | 6.5072 |
| 16 | 6.0545 | 6.1111 | 3.0556 | 3.8477 | 5.5453 | 4.4702 | 5.6584 |
| 17 | 6.2243 | 5.9414 | 3.1121 | 3.9609 | 5.8282 | 4.357 | 5.998 |
| 18 | 5.6584 | 5.6584 | 3.0556 | 4.0741 | 5.8848 | 4.1307 | 6.1111 |
| 19 | 5.7716 | 4.7531 | 3.1687 | 4.2438 | 5.0926 | 4.0741 | 5.4321 |
| 20 | 5.8848 | 5.0926 | 3.1121 | 4.3004 | 5.1492 | 4.1307 | 5.4321 |
| 21 | 4.8663 | 5.0926 | 2.9424 | 4.5268 | 4.7531 | 4.2438 | 4.7531 |
| 22 | 5.6584 | 5.1492 | 3.1687 | 4.6965 | 5.5453 | 4.1872 | 6.2243 |
| 23 | 5.4321 | 5.4321 | 3.2253 | 4.6399 | 5.0926 | 4.1307 | 5.8848 |
| 24 | 5.8848 | 5.0926 | 5.715 | 3.2819 | 4.5268 | 4.8663 | 4.2438 |
| Max | 6.3375 | 6.3375 | 5.715 | 4.6965 | 5.9414 | 4.8663 | 6.5072 |
| Min | 4.8663 | 4.4136 | 2.9424 | 3.1687 | 4.0175 | 4.0175 | 3.9609 |
| Avg | 5.6443 | 5.3144 | 3.8053 | 3.7699 | 5.0360 | 4.3829 | 5.1515 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 201 / 11 KV WADILAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 2.6406 | | | | |
| 4 | 2.5463 | | 2.0748 | | |
| 6 | 2.6406 | | 1.8861 | | |
| 8 | 2.3577 | | 1.5089 | | 2.3577 |
| 9 | | | | | 3.0178 |
| 10 | 3.2065 | | 1.4146 | | 3.2065 |
| 16 | | 3.2065 | | | |
| 20 | | 2.5463 | | | |
| 23 | | 2.452 | 2.0919 | | |
| 24 | 2.6406 | 2.452 | 3.6865 | 2.6406 | 2.1691 |
| Max | 3.2065 | 3.2065 | 3.6865 | 2.6406 | 3.2065 |
| Min | 2.3577 | 2.452 | 1.4146 | 2.6406 | 2.1691 |
| Avg | 2.6721 | 2.6642 | 2.1105 | 2.6406 | 2.6878 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 202 / 11 KV I.D.I. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------------|---------------|---------------|---------------|---------------|---------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 4.0552 | | | | |
| 4 | 3.7723 | | 3.3951 | | |
| 6 | 3.678 | | 3.2065 | | |
| 8 | 3.5837 | | 3.0178 | | 3.4894 |
| 9 | | | | | 3.678 |
| 10 | 3.8666 | | 3.0178 | | 3.9609 |
| 16 | | 3.3951 | | | |
| 20 | | 3.3008 | | | |
| 23 | | 3.5837 | | | |
| 24 | 4.1495 | 3.5837 | 3.7723 | 3.5837 | 3.4894 |
| Max | 4.1495 | 3.5837 | 3.7723 | 3.5837 | 3.9609 |
| Min | 3.5837 | 3.3008 | 3.0178 | 3.5837 | 3.4894 |
| Avg | 3.8509 | 3.4658 | 3.2819 | 3.5837 | 3.6544 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 207 / 11 KV CHEMICAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 4.2438 | | | | | |
| 4 | 4.2438 | | 3.8666 | | | |
| 6 | 4.0552 | | 3.4894 | | | |
| 8 | 3.9609 | | 2.7349 | 2.8669 | | 3.678 |
| 9 | | | | | | 4.1118 |
| 10 | 4.5268 | | 3.0178 | | | 4.5268 |
| 16 | | 4.6965 | | 4.5268 | | |
| 20 | | 4.1495 | | | | |
| 23 | | 3.9798 | | | | |
| 24 | 4.1495 | 4.1495 | 3.8477 | 2.8292 | 4.0364 | 3.8666 |
| Max | 4.5268 | 4.6965 | 3.8666 | 4.5268 | 4.0364 | 4.5268 |
| Min | 3.9609 | 3.9798 | 2.7349 | 2.8292 | 4.0364 | 3.678 |
| Avg | 4.1967 | 4.2438 | 3.3913 | 3.4076 | 4.0364 | 4.0458 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 208 / 11 KV TIE LINE FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 3.6969 | | | | |
| 4 | 3.5837 | | 3.3951 | | |
| 6 | 3.546 | | 3.5082 | | |
| 8 | 3.4139 | | 3.546 | | 3.5271 |
| 9 | | | | | 3.5837 |
| 10 | 3.1121 | | 3.3762 | | 3.5082 |
| 16 | | 3.0933 | | | |
| 20 | | 3.7723 | | | |
| 23 | | 3.81 | | | |
| 24 | 3.7912 | 3.5271 | 3.5837 | 3.7723 | 4.3381 |
| Max | 3.7912 | 3.81 | 3.5837 | 3.7723 | 4.3381 |
| Min | 3.1121 | 3.0933 | 3.3762 | 3.7723 | 3.5082 |
| Avg | 3.5240 | 3.5507 | 3.4818 | 3.7723 | 3.7393 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 209 / 11 KV JINDAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 2.5463 | | | | | |
| 4 | 2.3577 | | 2.7349 | | | |
| 6 | 2.2634 | | | | | |
| 8 | 2.5463 | | 1.8861 | 2.6029 | | 2.452 |
| 9 | | | | | | 3.4328 |
| 10 | 4.1872 | | | | | 4.0552 |
| 11 | | | | | | 4.6106 |
| 12 | | | | | | 4.4963 |
| 13 | | | | | | 4.401 |
| 14 | | | | | | 4.3439 |
| 15 | | | | | | 4.2486 |
| 16 | | 4.3759 | | 4.5268 | | 4.2486 |
| 17 | | | | | | 3.8485 |
| 19 | | | | | | 3.1055 |
| 20 | | 3.0556 | | | | 2.7244 |
| 21 | | | | | | 2.7435 |
| 22 | | | | | | 2.7054 |
| 23 | | 2.6217 | | | | 2.7625 |
| 24 | 2.8292 | 2.6029 | 2.4897 | 1.5655 | 2.9801 | 2.0748 |
| Max | 4.1872 | 4.3759 | 2.7349 | 4.5268 | 2.9801 | 4.6106 |
| Min | 2.2634 | 2.6029 | 1.8861 | 1.5655 | 2.9801 | 2.0748 |
| Avg | 2.7884 | 3.1640 | 2.3702 | 2.8984 | 2.9801 | 3.5159 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 210 / 11 KV N ZONE FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------------|---------------|---------------|---------------|---------------|---------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 6.0357 | | | | |
| 4 | 5.8471 | | 5.0926 | | |
| 6 | 5.4698 | | 4.3381 | | |
| 8 | 5.4698 | | 3.7723 | | 5.6584 |
| 9 | | | | | 6.6015 |
| 10 | 6.9787 | | 4.1495 | | 6.7901 |
| 16 | | 7.1674 | | | |
| 20 | | 5.4698 | | | |
| 23 | | 5.6584 | | | |
| 24 | 6.0357 | | 5.6584 | 5.8471 | 5.4698 |
| Max | 6.9787 | 7.1674 | 5.6584 | 5.8471 | 6.7901 |
| Min | 5.4698 | 5.4698 | 3.7723 | 5.8471 | 5.4698 |
| Avg | 5.9728 | 6.0985 | 4.6022 | 5.8471 | 6.1300 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 211 / 11 KV ENGINEERING FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 2.7349 | | | | | |
| 4 | 2.6406 | | 2.452 | | | |
| 6 | 2.5463 | | 2.2634 | | | |
| 8 | 2.5463 | | 1.7918 | 2.3954 | | 2.6406 |
| 9 | | | | | | 2.9801 |
| 10 | 3.0933 | | | | | 3.1121 |
| 11 | | | | | | 3.1817 |
| 12 | | | | | | 3.2388 |
| 13 | | | | | | 3.2388 |
| 14 | | | | | | 3.3341 |
| 15 | | | | | | 3.3341 |
| 16 | | 3.2442 | | 3.3951 | | 3.4675 |
| 17 | | | | | | 3.4484 |
| 18 | | | | | | 3.2007 |
| 19 | | | | | | 3.0293 |
| 20 | | 2.9801 | | | | 2.8197 |
| 21 | | | | | | 2.7054 |
| 22 | | | | | | 2.6292 |
| 23 | | 2.32 | | | | 2.572 |
| 24 | 2.7349 | 2.6406 | 2.3954 | 1.9427 | 2.6029 | 2.452 |
| Max | 3.0933 | 3.2442 | 2.452 | 3.3951 | 2.6029 | 3.4675 |
| Min | 2.5463 | 2.32 | 1.7918 | 1.9427 | 2.6029 | 2.452 |
| Avg | 2.7161 | 2.7962 | 2.2257 | 2.5777 | 2.6029 | 3.0226 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 212 / 11 KV CAMLIN FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 2.452 | | | | | |
| 4 | 2.0748 | | 2.2634 | | | |
| 6 | 2.0748 | | 2.0748 | | | |
| 8 | 2.0748 | | 1.5089 | 1.8861 | | 2.2634 |
| 9 | | | | | | 2.5463 |
| 10 | 2.7349 | | 1.6032 | | | 2.7349 |
| 16 | | 3.0178 | | 3.0178 | | |
| 20 | | 2.6406 | | | | |
| 23 | | 2.452 | | 1.6032 | | |
| 24 | 2.6406 | 2.3577 | 2.5463 | 1.6032 | 2.452 | 2.2634 |
| Max | 2.7349 | 3.0178 | 2.5463 | 3.0178 | 2.452 | 2.7349 |
| Min | 2.0748 | 2.3577 | 1.5089 | 1.6032 | 2.452 | 2.2634 |
| Avg | 2.3420 | 2.6170 | 1.9993 | 2.0276 | 2.452 | 2.452 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 213 / 11 KV GINI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 3.3951 | | | | | |
| 4 | 3.2065 | | 3.1121 | | | |
| 6 | 3.1121 | | 2.7349 | | | |
| 8 | 2.9235 | | 2.2634 | 2.3388 | | 2.2634 |
| 9 | | | | | | 2.7915 |
| 10 | 4.225 | | 2.452 | | | 2.8292 |
| 16 | | 4.225 | | 4.5268 | | |
| 20 | | 3.0178 | | | | |
| 23 | | 3.1687 | | | | |
| 24 | 3.4894 | 3.1687 | 3.2442 | 2.037 | 3.0933 | 2.8292 |
| Max | 4.225 | 4.225 | 3.2442 | 4.5268 | 3.0933 | 2.8292 |
| Min | 2.9235 | 3.0178 | 2.2634 | 2.037 | 3.0933 | 2.2634 |
| Avg | 3.3919 | 3.3951 | 2.7613 | 2.9675 | 3.0933 | 2.6783 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 217 / 11 KV AUXILLARY FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 2.0748 | | | | |
| 4 | 1.8861 | | 1.8861 | | |
| 6 | 1.7918 | | 1.7918 | | |
| 8 | 1.6975 | | 1.5089 | | 1.6032 |
| 9 | | | | | 1.9805 |
| 10 | 2.0748 | | 1.5089 | | 2.2634 |
| 16 | | 2.2634 | | | |
| 20 | | 1.8861 | | | |
| 23 | | 1.8861 | | | |
| 24 | 1.8861 | 2.0748 | 2.0748 | 1.8861 | 1.7918 |
| Max | 2.0748 | 2.2634 | 2.0748 | 1.8861 | 2.2634 |
| Min | 1.6975 | 1.8861 | 1.5089 | 1.8861 | 1.6032 |
| Avg | 1.9019 | 2.0276 | 1.7541 | 1.8861 | 1.9097 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 218 / 11KV Nirwan Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 1.0562 | | | | | |
| 4 | 1.0185 | | 1.3203 | | | |
| 6 | 1.1317 | | 1.226 | | | |
| 8 | .9808 | | | .7356 | | 1.1694 |
| 9 | | | | | | 1.1317 |
| 10 | 1.2071 | | | | | 1.2449 |
| 11 | | | | | | 1.1622 |
| 12 | | | | | | 1.3527 |
| 13 | | | | | | 1.2955 |
| 14 | | | | | | 1.3336 |
| 15 | | | | | | 1.2765 |
| 16 | | 1.2071 | | 1.2449 | | 1.3717 |
| 17 | | | | | | 1.6004 |
| 18 | | | | | | 1.3717 |
| 19 | | | | | | 1.2574 |
| 20 | | | | | | 1.1431 |
| 21 | | | | | | 1.1622 |
| 22 | | | | | | 1.1431 |
| 23 | | 1.3014 | | | | 1.086 |
| 24 | 1.094 | 1.2826 | 1.358 | | 1.1128 | 1.2449 |
| Max | 1.2071 | 1.3014 | 1.358 | 1.2449 | 1.1128 | 1.6004 |
| Min | .9808 | 1.2071 | 1.226 | .7356 | 1.1128 | 1.086 |
| Avg | 1.0814 | 1.2637 | 1.3014 | .9903 | 1.1128 | 1.2557 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284613 / 11 KV SWITCHING S/stn No.4

Feeder No / Name : 219 / AARTI EXPRESS FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 1.226 | | | | | |
| 4 | 1.1694 | | 1.2071 | | | |
| 6 | 1.226 | | 1.1694 | | | |
| 8 | 1.094 | | 1.1694 | 1.1506 | | 1.2637 |
| 9 | | | | | | 1.3392 |
| 10 | 1.2071 | | 1.2826 | | | 1.3392 |
| 11 | | | | | | 1.4098 |
| 12 | | | | | | 1.1622 |
| 13 | | | | | | 1.2003 |
| 14 | | | | | | 1.2384 |
| 15 | | | | | | 1.2955 |
| 16 | | 1.3957 | | 1.3203 | | 1.1812 |
| 17 | | | | 1.358 | | 1.1812 |
| 18 | | | | 1.358 | | 1.1812 |
| 19 | | | | | | 1.1812 |
| 20 | | 1.3957 | | | | 1.0479 |
| 21 | | | | | | 1.0669 |
| 22 | | | | | | 1.1241 |
| 23 | | 1.1694 | | | | 1.1812 |
| 24 | 1.1883 | 1.1506 | 1.1883 | 1.2071 | 1.3014 | 1.2071 |
| Max | 1.226 | 1.3957 | 1.2826 | 1.358 | 1.3014 | 1.4098 |
| Min | 1.094 | 1.1506 | 1.1694 | 1.1506 | 1.3014 | 1.0479 |
| Avg | 1.1851 | 1.2779 | 1.2034 | 1.2788 | 1.3014 | 1.2118 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284616 / 33/11 KV S/S NO:05,P-100/1

SUT

Feeder No / Name : 201 / 11 KV FEEDER NO;1 AFTAB

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8589 | .7468 | .7095 | .5792 | .9054 | .9808 | .7095 |
| 2 | .8215 | .7095 | .7468 | .5853 | .9054 | .9431 | .6535 |
| 3 | .8402 | .7316 | .7023 | .543 | .9431 | .9431 | .5914 |
| 4 | .8501 | .7762 | .6653 | .5792 | .9431 | .8865 | .6099 |
| 5 | .8316 | .7468 | .5914 | .4908 | .8775 | .7922 | .6584 |
| 6 | .8413 | .7023 | .5601 | .4961 | .7468 | .7922 | .6584 |
| 7 | .8501 | .7392 | .5658 | .5792 | .7468 | .7545 | .7842 |
| 8 | .7842 | .7023 | .4527 | .7468 | 1.0374 | .5487 | .7922 |
| 9 | .9997 | .8962 | .5281 | 1.0185 | 1.1317 | .5658 | 1.0185 |
| 10 | .9808 | .9431 | .6602 | 1.1317 | 1.1317 | .7167 | 1.094 |
| 11 | .9431 | 1.226 | .7167 | 1.2071 | 1.1317 | .6602 | 1.2449 |
| 12 | 1.1694 | 1.2826 | .5792 | 1.2637 | 1.226 | .7167 | 1.2637 |
| 13 | .7733 | 1.0562 | .5792 | 1.0562 | .9431 | .6602 | .9054 |
| 14 | .8488 | 1.226 | .5973 | 1.2637 | 1.226 | .679 | 1.2637 |
| 15 | .9431 | 1.2449 | .7922 | 1.3203 | 1.226 | .679 | 1.4712 |
| 16 | .9997 | 1.2826 | .6602 | 1.2637 | 1.226 | .6224 | 1.4146 |
| 17 | 1.0185 | 1.226 | .5914 | 1.2071 | 1.2449 | .7167 | 1.4335 |
| 18 | .9054 | .9242 | .6036 | 1.226 | 1.1317 | .6602 | 1.226 |
| 19 | .9431 | .9431 | .5068 | 1.226 | .9431 | | 1.094 |
| 20 | .8299 | .9054 | .543 | 1.0374 | 1.0374 | | .8676 |
| 21 | .8488 | .9431 | .5792 | .9997 | .9431 | .7167 | .9054 |
| 22 | .6224 | .9054 | .5487 | .8316 | .8402 | .6602 | .8299 |
| 23 | .7545 | .8676 | .5784 | .8488 | .8316 | .679 | .9619 |
| 24 | .9054 | .7922 | .7545 | .5792 | .9431 | .9431 | .7733 |
| Max | 1.1694 | 1.2826 | .7922 | 1.3203 | 1.2449 | .9808 | 1.4712 |
| Min | .6224 | .7023 | .4527 | .4908 | .7468 | .5487 | .5914 |
| Avg | .8818 | .9383 | .6172 | .9200 | 1.0110 | .7417 | .9677 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 284616 / 33/11 KV S/S NO:05,P-100/1

SUT

Feeder No / Name : 202 / 11 KV FEEDER NO:02 TULSI SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0082 | .9709 | .9335 | .7621 | .9774 | .9955 | .8775 |
| 2 | .9896 | .9335 | .8871 | .7468 | 1.0317 | 1.0136 | .8775 |
| 3 | .9511 | .8779 | .8589 | .7316 | .9774 | .9774 | .9979 |
| 4 | .924 | .8501 | .8779 | .6097 | .905 | .9412 | 1.0349 |
| 5 | .8962 | .8962 | .924 | .7164 | .9412 | .9774 | .8779 |
| 6 | .9979 | .9511 | .9709 | .7468 | 1.0136 | .8859 | .9145 |
| 7 | 1.0456 | 1.0185 | .9335 | .7316 | .9412 | .8573 | 1.0082 |
| 8 | 1.094 | 1.1203 | .8676 | 1.086 | 1.2936 | .9116 | 1.1506 |
| 9 | 1.2449 | 1.4712 | .8507 | 1.6221 | 1.6032 | .7859 | 1.3203 |
| 10 | 1.4901 | 1.4523 | .8573 | 1.6975 | 1.6975 | 1.0185 | 1.3203 |
| 11 | 1.4146 | 1.4146 | .8718 | 1.8107 | 1.6975 | 1.0185 | 1.4712 |
| 12 | 1.4146 | 1.4712 | .7621 | 1.6975 | 1.5089 | 1.0185 | 1.5089 |
| 13 | 1.0185 | 1.1694 | .9054 | 1.4784 | 1.4003 | .9619 | 1.2637 |
| 14 | 1.094 | 1.4146 | .8421 | 1.905 | 1.6975 | .9431 | 1.6032 |
| 15 | 1.1694 | 1.4712 | .7773 | 1.8861 | 1.6975 | .9619 | 1.6409 |
| 16 | 1.6221 | 1.4335 | .8097 | 1.8861 | 1.8296 | .9808 | 1.5844 |
| 17 | 1.2071 | 1.3957 | .7773 | 1.4335 | 1.5089 | .8676 | 1.4712 |
| 18 | 1.1317 | 1.2449 | .7773 | 1.4146 | 1.3203 | .8865 | 1.1128 |
| 19 | .8676 | .9619 | .7611 | 1.1203 | 1.3203 | .9054 | 1.0751 |
| 20 | .9431 | .9431 | .6716 | .9955 | .8573 | .9054 | .9431 |
| 21 | .9808 | 1.0185 | .759 | 1.0317 | 1.0631 | .8865 | 1.094 |
| 22 | 1.0185 | .9431 | .7773 | 1.086 | 1.086 | .8865 | .9242 |
| 23 | .9997 | .9808 | .7164 | .9431 | .8573 | .8676 | 1.0185 |
| 24 | 1.0374 | 1.0185 | .9997 | .7316 | .9955 | .9955 | .8865 |
| Max | 1.6221 | 1.4712 | .9997 | 1.905 | 1.8296 | 1.0185 | 1.6409 |
| Min | .8676 | .8501 | .6716 | .6097 | .8573 | .7859 | .8775 |
| Avg | 1.1067 | 1.1426 | .8404 | 1.2029 | 1.2592 | .9354 | 1.1657 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 202 / 132/11KV LV SIDE OF 25 MVA NON SHEDDABLE EXPRESS HV FEEDERS
T/F Feeder KV- 11 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.0576 |
| Max | 2.0576 |
| Min | 2.0576 |
| Avg | 2.0576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 401 / 33 KV FEEDER NO 1
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 7.7161 |
| Max | 7.7161 |
| Min | 7.7161 |
| Avg | 7.7161 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 402 / 33 KV FEEDER NO.2
Feeder KV- 33 / INCOMINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 4.1152 |
| Max | 4.1152 |
| Min | 4.1152 |
| Avg | 4.1152 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 403 / 33 KV FEEDER NO.3
Feeder KV- 33 / INCOMINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 4.3724 |
| Max | 4.3724 |
| Min | 4.3724 |
| Avg | 4.3724 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 405 / 33 KV FEEDER NO.5

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 6.2757 |
| Max | 6.2757 |
| Min | 6.2757 |
| Avg | 6.2757 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 406 / 33 KV FEEDER NO. 6

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 7.2017 |
| Max | 7.2017 |
| Min | 7.2017 |
| Avg | 7.2017 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 287003 / 132/33/11 KV BOISAR-I SUBSTN

Feeder No / Name : 407 / 33 KV FEEDER NO. 7 NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 33 / OUTGOING (NON CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.6584 |
| Max | 5.6584 |
| Min | 5.6584 |
| Avg | 5.6584 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 403 / 33 KV FEEDER NO. - 3
Feeder KV- 33 / INCOMINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 6.2243 |
| Max | 6.2243 |
| Min | 6.2243 |
| Avg | 6.2243 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 404 / 33 KV FEEDER NO. 4

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 8.2305 |
| Max | 8.2305 |
| Min | 8.2305 |
| Avg | 8.2305 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 405 / 33KV FEEDER NO.5 TAPS

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 3.6214 |
| Max | 3.6214 |
| Min | 3.6214 |
| Avg | 3.6214 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 407 / 33 KV FEEDER NO. 7

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.0412 |
| Max | 5.0412 |
| Min | 5.0412 |
| Avg | 5.0412 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 408 / 33 KV FEEDER NO. 8

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 6.2757 |
| Max | 6.2757 |
| Min | 6.2757 |
| Avg | 6.2757 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 409 / 33 KV Feeder No.9 (INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
TO Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.4887 |
| Max | 5.4887 |
| Min | 5.4887 |
| Avg | 5.4887 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 701 / 132 KV LUPIN LTD 220KV (T- NON SHEDDABLE EHV INDUSTRIAL FEEDERS

142) Feeder KV- 132 / OUTGOING (NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0412 |
| Max | .0412 |
| Min | .0412 |
| Avg | .0412 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 702 / 132 KV JSW STEEL COATED NON SHEDDABLE EHV INDUSTRIAL FEEDERS

PRODUC Feeder KV- 132 / OUTGOING (NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0412 |
| Max | .0412 |
| Min | .0412 |
| Avg | .0412 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 703 / 132 KV TATA STEEL LTD

(220KV) Feeder KV- 132 /
OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .1029 |
| Max | .1029 |
| Min | .1029 |
| Avg | .1029 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MIDC(BOISAR) S/DN.[163] BU 4163

Substation No/ Name :- 288013 / 220/132/33 KV BOISAR-II

SUBSTN

Feeder No / Name : 704 / 132 KV VIRAJ PROFILES LTD NON SHEDDABLE EHV INDUSTRIAL FEEDERS

FEED Feeder KV- 132 / OUTGOING (NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0412 |
| Max | .0412 |
| Min | .0412 |
| Avg | .0412 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MOKHADA S/DN.[824] BU 4824

Substation No/ Name :- 284038 / 33/22 KV MOKHADA SUBSTATION

Feeder No / Name : 300 / MOKHADA SUBSTAION
TRANSFORMER Feeder KV- 22 /
OUTGOING

| DATE | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 7 | | .0572 |
| 9 | | .0343 |
| 11 | | .0343 |
| 13 | .0457 | |
| 14 | | .0305 |
| 15 | .0495 | |
| 18 | .0419 | |
| 20 | .0762 | |
| 24 | | .0686 |
| Max | .0762 | .0686 |
| Min | .0419 | .0305 |
| Avg | .0533 | .0450 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MOKHADA S/DN.[824] BU 4824

Substation No/ Name :- 284038 / 33/22 KV MOKHADA SUBSTATION

Feeder No / Name : 301 / 22 KV MOKHADA FEEDER SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | .381 | | | .4191 | | | .4191 |
| 8 | .3429 | | .3429 | .3429 | .3429 | | |
| 9 | .4954 | | | .3429 | .4572 | .3429 | .6859 |
| 10 | .5335 | | .4954 | .4954 | | | |
| 11 | | | .5335 | | | .381 | .4572 |
| 12 | | | .4572 | | | | |
| 13 | | | | | | .3429 | |
| 14 | | | .3048 | | | | .3429 |
| 15 | | .4954 | .4572 | .381 | | .381 | |
| 16 | .724 | | .4954 | | | | |
| 17 | | | .3429 | | | | |
| 18 | | | | | | .3048 | |
| 19 | | | .3429 | .3429 | | | |
| 20 | .4572 | .4954 | .4191 | .4572 | .4572 | .4572 | |
| 21 | | | .4572 | | | | |
| 23 | | | .4191 | | | | |
| 24 | .381 | .4191 | .4191 | .381 | .4191 | .4191 | .381 |
| Max | .724 | .4954 | .5335 | .4954 | .4572 | .4572 | .6859 |
| Min | .3429 | .4191 | .3048 | .3429 | .3429 | .3048 | .3429 |
| Avg | .4736 | .4700 | .4221 | .3953 | .4191 | .3756 | .4572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MOKHADA S/DN.[824] BU 4824

Substation No/ Name :- 284038 / 33/22 KV MOKHADA SUBSTATION

Feeder No / Name : 302 / 22 KV KHODALA FEEDER SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | .9907 | | | .9907 | | | .9907 |
| 8 | .7621 | | .7621 | .8002 | .6097 | | |
| 9 | .6859 | | | .724 | .724 | .6097 | .6859 |
| 10 | .5716 | | .6478 | .6478 | | | |
| 11 | | | .6097 | | | .4954 | .5716 |
| 12 | | | .5716 | | | | |
| 13 | | | | | | .4954 | |
| 14 | | | .5716 | | | | .5335 |
| 15 | | .5335 | .5716 | .4572 | | .4572 | |
| 16 | .6097 | | .5716 | | | | |
| 17 | | | .6097 | | | | |
| 18 | | | | | | .5716 | |
| 19 | | | 1.0288 | .8764 | | | |
| 20 | 1.3717 | 1.3336 | 1.4098 | 1.2193 | 1.2574 | 1.2574 | |
| 21 | | | 1.4098 | | | | |
| 23 | | | 1.2193 | | | | |
| 24 | 1.1431 | 1.1431 | 1.1812 | 1.1812 | 1.105 | 1.0669 | 1.105 |
| Max | 1.3717 | 1.3336 | 1.4098 | 1.2193 | 1.2574 | 1.2574 | 1.105 |
| Min | .5716 | .5335 | .5716 | .4572 | .6097 | .4572 | .5335 |
| Avg | .8764 | 1.0034 | .8588 | .8621 | .9240 | .7077 | .7773 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

MOKHADA S/DN.[824] BU 4824

Substation No/ Name :- 284038 / 33/22 KV MOKHADA SUBSTATION

Feeder No / Name : 303 / 22 KV ASA FEEDER SHEDDABLE RURAL
Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | .4572 | | | .4191 | | | .4572 |
| 8 | .3429 | | .3429 | .3429 | .3048 | | |
| 9 | .3048 | | | .3048 | .2667 | .3048 | .3429 |
| 10 | | | .2667 | .3048 | | | |
| 11 | | | .2286 | | | .2286 | .2667 |
| 12 | | | .2286 | | | | |
| 13 | | | | | | .2286 | |
| 14 | | | | | | | .2667 |
| 15 | | .2286 | .2667 | .2286 | | .2286 | |
| 16 | .2286 | | .2667 | | | | |
| 17 | | | .2667 | | | | |
| 18 | | | | | | .2667 | |
| 19 | | | .4572 | .4191 | | | |
| 20 | .5716 | .6859 | .6097 | .6478 | .6859 | .6478 | |
| 21 | | | .6478 | | | | |
| 23 | | | .5335 | | | | |
| 24 | .4954 | .4954 | .4954 | .4954 | .5335 | .5716 | .5335 |
| Max | .5716 | .6859 | .6478 | .6478 | .6859 | .6478 | .5335 |
| Min | .2286 | .2286 | .2286 | .2286 | .2667 | .2286 | .2667 |
| Avg | .4001 | .4700 | .3842 | .3953 | .4477 | .3538 | .3734 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 201 / 11 KV NAVALI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.8578 |
| Max | 2.8578 |
| Min | 2.8578 |
| Avg | 2.8578 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 202 / 11 KV MASWAN FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.2862 |
| Max | 2.2862 |
| Min | 2.2862 |
| Avg | 2.2862 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 203 / 11 KV GENSIS FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 3.0102 |
| Max | 3.0102 |
| Min | 3.0102 |
| Avg | 3.0102 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 204 / 11 KV DIWAN & SONS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.6673 |
| Max | 2.6673 |
| Min | 2.6673 |
| Avg | 2.6673 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 205 / 11 KV EBCO FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 2.3434 |
| Max | 2.3434 |
| Min | 2.3434 |
| Avg | 2.3434 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 206 / FREDUN EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 05-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 15 | 2.5911 |
| Max | 2.5911 |
| Min | 2.5911 |
| Avg | 2.5911 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284022 / 33/11 KV GENESIS SUBSTN

Feeder No / Name : 207 / 11 KV VEOOR FEEDR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 2.8578 |
| Max | 2.8578 |
| Min | 2.8578 |
| Avg | 2.8578 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162]

BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 201 / 11 KV GANESH KUND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 2.4958 | | | 2.8006 | 2.572 |
| 2 | | | 2.3243 | | | 2.6139 | 2.2672 |
| 3 | | | 2.0576 | | | 2.4272 | 2.1529 |
| 4 | | | 1.9243 | | | 2.2405 | 1.829 |
| 5 | | | 1.8861 | | | 2.0538 | 1.848 |
| 6 | | | 1.8671 | | | 1.9418 | 1.848 |
| 7 | | | 1.7337 | | 1.7718 | 1.8671 | 1.7337 |
| 9 | 1.6004 | | 1.6385 | 1.6004 | | | |
| 10 | | | | | | | 1.6766 |
| 11 | 1.6004 | 1.7528 | 1.6766 | | | | |
| 12 | 1.6385 | | 1.7337 | | 1.8099 | | |
| 13 | | 1.6956 | 1.7718 | | | | |
| 14 | | 1.7909 | | 1.7718 | | | |
| 15 | 1.7528 | 1.6766 | 1.848 | 1.9052 | | 1.9624 | |
| 16 | | 1.6956 | 1.7718 | | | | |
| 17 | | 1.6804 | 1.643 | | 1.6991 | | |
| 18 | | 1.6244 | | | 1.6804 | | |
| 19 | | 1.9044 | | | 1.8858 | | |
| 20 | | 2.2405 | | | 2.3152 | | |
| 23 | | | | 2.8769 | | | |
| 24 | 2.8387 | 2.6673 | 2.7244 | | 2.8578 | | 2.8769 |
| Max | 2.8387 | 2.6673 | 2.7244 | 2.8769 | 2.8578 | 2.8006 | 2.8769 |
| Min | 1.6004 | 1.6244 | 1.6385 | 1.6004 | 1.6804 | 1.8671 | 1.6766 |
| Avg | 1.8862 | 1.8729 | 1.9398 | 2.0386 | 2.0029 | 2.2384 | 2.0894 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162]

BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 202 / 11 KV KHAREKURAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.0098 | | | 1.0269 | .8954 |
| 2 | | | .8764 | | | .9335 | .8383 |
| 3 | | | .8192 | | | .8402 | .8192 |
| 4 | | | .6859 | | | .7468 | .8002 |
| 5 | | | .6668 | | | .7842 | .8573 |
| 6 | | | .6668 | | | .7655 | .9145 |
| 7 | | | .6097 | | .6668 | .6535 | .9145 |
| 9 | 1.6956 | | .6097 | 1.6194 | | | |
| 10 | | | | | | | 1.7718 |
| 11 | 1.8099 | 1.7337 | .5906 | | | | |
| 12 | 1.8861 | | .5906 | | 2.0957 | | |
| 13 | | 1.7528 | .5906 | | | | |
| 14 | | 1.9624 | | 2.0195 | | | |
| 15 | 1.7909 | 1.8671 | .6668 | 2.0576 | | .7811 | |
| 16 | | 1.848 | .6478 | | | | |
| 17 | | 1.6244 | | | 1.7737 | | |
| 18 | | 1.2696 | .5975 | | 1.531 | | |
| 19 | | 1.1203 | | | 1.1576 | | |
| 20 | | 1.307 | | | 1.3256 | | |
| 23 | | | | 1.2384 | | | |
| 24 | 1.0479 | 1.0479 | 1.0098 | | 1.1431 | 1.1203 | .9717 |
| Max | 1.8861 | 1.9624 | 1.0098 | 2.0576 | 2.0957 | 1.1203 | 1.7718 |
| Min | 1.0479 | 1.0479 | .5906 | 1.2384 | .6668 | .6535 | .8002 |
| Avg | 1.6461 | 1.5533 | .7092 | 1.7337 | 1.3848 | .8502 | .9759 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 203 / 11 KV UMROLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | 2.0957 |
| Max | 2.0957 |
| Min | 2.0957 |
| Avg | 2.0957 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162]

BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 204 / 11 KV PALGHAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.9433 | | | 1.8671 | 1.5432 |
| 2 | | | 1.5432 | | | 1.7177 | 1.3717 |
| 3 | | | 1.3717 | | | 1.4937 | |
| 4 | | | 1.2574 | | | 1.3443 | 1.0288 |
| 5 | | | 1.1431 | | | 1.3443 | .8573 |
| 6 | | | 1.1431 | | | 1.3443 | .8573 |
| 7 | | | 1.1431 | | 1.1431 | 1.1203 | .6859 |
| 9 | .8573 | | 1.2574 | 1.2003 | | | |
| 10 | | | | | | | 1.1431 |
| 11 | 1.1431 | 1.5432 | 1.6004 | | | | |
| 12 | 1.1431 | | 1.7147 | | 1.829 | | |
| 13 | | 1.7147 | 1.7147 | | | | |
| 14 | | 1.7147 | | 1.829 | | | |
| 15 | 1.1431 | 1.7147 | 1.7147 | 1.8861 | | 2.0576 | |
| 16 | | 1.6575 | 1.6575 | | | | |
| 17 | | 1.5684 | 1.5684 | | 2.5766 | | |
| 18 | | 1.5684 | 1.6244 | | 2.4086 | | |
| 19 | | 1.7924 | 1.8484 | | 2.5206 | | |
| 20 | | 1.9044 | 1.9044 | | 2.8006 | | |
| 21 | | | 1.8484 | | | | |
| 23 | | | 1.9605 | 2.0576 | | | |
| 24 | 1.829 | 1.7718 | 1.9433 | | 2.0576 | 2.0165 | 1.6575 |
| Max | 1.829 | 1.9044 | 1.9605 | 2.0576 | 2.8006 | 2.0576 | 1.6575 |
| Min | .8573 | 1.5432 | 1.1431 | 1.2003 | 1.1431 | 1.1203 | .6859 |
| Avg | 1.2231 | 1.6950 | 1.5951 | 1.7433 | 2.1909 | 1.5895 | 1.1431 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 205 / 11 KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .7621 | | | .6722 | .381 |
| 2 | | | .6859 | | | .5975 | .381 |
| 3 | | | .5335 | | | .5228 | .362 |
| 4 | | | .4191 | | | .4854 | .362 |
| 5 | | | .381 | | | .4481 | .3429 |
| 6 | | | .381 | | | .3921 | .3429 |
| 7 | | | .381 | | .4572 | .3734 | .381 |
| 9 | 1.0479 | | .4763 | .9526 | | | |
| 10 | | | | | | | 1.2384 |
| 11 | 1.3336 | 1.4289 | .5144 | | | | |
| 12 | 1.2955 | | .5716 | | 1.1812 | | |
| 13 | | 1.1431 | .4763 | | | | |
| 14 | | 1.3336 | | 1.1812 | | | |
| 15 | 1.2955 | 1.467 | .5716 | 1.4861 | | .4382 | |
| 16 | | 1.4289 | .5144 | | | | |
| 17 | | 1.3443 | .4108 | | 1.1203 | | |
| 18 | | 1.0082 | .3921 | | 1.0269 | | |
| 19 | | .8589 | .3734 | | .6535 | | |
| 20 | | .9709 | .3734 | | 1.0082 | | |
| 21 | | | .3734 | | | | |
| 22 | | | .3734 | | | | |
| 23 | | | .3734 | .6478 | | | |
| 24 | .7049 | .7621 | .7621 | | .6478 | .7095 | .381 |
| Max | 1.3336 | 1.467 | .7621 | 1.4861 | 1.1812 | .7095 | 1.2384 |
| Min | .7049 | .7621 | .3734 | .6478 | .4572 | .3734 | .3429 |
| Avg | 1.1355 | 1.1746 | .4810 | 1.0669 | .8707 | .5155 | .4636 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 206 / 11 KV TEMBHODE FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 2.572 | | | 2.2405 | 2.3434 |
| 2 | | | | | | 2.0538 | 2.2481 |
| 3 | | | 2.2291 | | | 1.9605 | 2.0576 |
| 4 | | | 2.1148 | | | 1.9044 | 2.0576 |
| 5 | | | 2.0005 | | | 1.9044 | 2.0005 |
| 6 | | | 2.0005 | | | 1.9044 | 2.0005 |
| 7 | | | 1.8861 | | 1.8861 | 1.8484 | 1.8861 |
| 9 | 2.0576 | | 1.829 | 2.1148 | | | |
| 10 | | | | | | | 2.1719 |
| 11 | 2.1719 | 2.1148 | 1.7147 | | | | |
| 12 | 2.1719 | | 1.7718 | | 2.2291 | | |
| 13 | | 1.9433 | 1.7147 | | | | |
| 14 | | 2.0005 | | 2.1148 | | | |
| 15 | 2.0576 | 2.1719 | 1.8861 | 2.2291 | | 1.7147 | |
| 16 | | 2.3434 | 1.8861 | | | | |
| 17 | | 2.1845 | 1.6804 | | 2.0725 | | |
| 18 | | 2.0165 | | | 2.0165 | | |
| 19 | | 2.1845 | | | 2.1285 | | |
| 20 | | 2.5206 | | | 2.5206 | | |
| 23 | | | | 2.572 | | | |
| 24 | 2.572 | 2.572 | 2.572 | | 2.5149 | 2.4086 | 2.4577 |
| Max | 2.572 | 2.572 | 2.572 | 2.572 | 2.5206 | 2.4086 | 2.4577 |
| Min | 2.0576 | 1.9433 | 1.6804 | 2.1148 | 1.8861 | 1.7147 | 1.8861 |
| Avg | 2.2062 | 2.2052 | 1.9898 | 2.2577 | 2.1955 | 1.9933 | 2.1359 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284023 / 33/11 KV PALGHAR SUBSTN

Feeder No / Name : 207 / DIVISION OFFICE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 05-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 15 | 1.9052 |
| Max | 1.9052 |
| Min | 1.9052 |
| Avg | 1.9052 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 201 / 11 KV KOTHARI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3258 | .3086 | .4115 | .2572 | .3601 | .3429 | .2572 |
| 2 | .3258 | .3258 | .4115 | .2401 | .3429 | .3258 | .2743 |
| 3 | .3086 | .3429 | .4115 | .2229 | .3429 | .3086 | .2743 |
| 4 | .3086 | .3086 | .3772 | .2229 | .3258 | .3086 | .2572 |
| 5 | .2743 | .3086 | | .2401 | .3258 | .3086 | .2401 |
| 6 | .2743 | .3429 | .3258 | .2401 | .3258 | .2915 | .2572 |
| 7 | .3086 | | .3086 | .2572 | .3086 | .2915 | .3086 |
| 8 | .3258 | .3258 | .2572 | .2743 | .3086 | .2229 | .2915 |
| 9 | .4458 | .4287 | .2572 | .3772 | .463 | .2401 | .4287 |
| 10 | | .5144 | .2229 | .4801 | | .2401 | .4287 |
| 11 | .5487 | .5487 | .2401 | .6001 | .6001 | .2229 | |
| 12 | .6001 | .583 | .2572 | .583 | .6001 | .2401 | .583 |
| 13 | .4458 | | .2401 | | .4458 | .2058 | |
| 14 | .6173 | | .2229 | .583 | .583 | .2058 | .5144 |
| 15 | .5487 | | .2229 | | .6001 | .2401 | .5316 |
| 16 | .4801 | .5144 | .2229 | .5316 | | .2401 | .4973 |
| 17 | .5487 | .4973 | .2229 | | | .2401 | .4973 |
| 18 | .5144 | .4115 | .2229 | .4801 | | .2401 | .5144 |
| 19 | .463 | .463 | .2401 | .4115 | .4115 | .2572 | .4287 |
| 20 | .4115 | .4115 | .2401 | .3258 | .3772 | .2743 | .3944 |
| 21 | .3429 | .3601 | .2401 | .3429 | .3601 | .2743 | .3258 |
| 22 | .3258 | .3772 | .2401 | .3772 | .3429 | .2743 | |
| 23 | .3429 | .3944 | .2401 | .3601 | .3772 | .2743 | |
| 24 | .3601 | .3258 | .3944 | .2572 | .3601 | .3429 | .2572 |
| Max | .6173 | .583 | .4115 | .6001 | .6001 | .3429 | .583 |
| Min | .2743 | .3086 | .2229 | .2229 | .3086 | .2058 | .2401 |
| Avg | .4108 | .4047 | .2796 | .3650 | .4081 | .2672 | .3781 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 202 / 11 KV CHINTUPADA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 3.0102 |
| Max | 3.0102 |
| Min | 3.0102 |
| Avg | 3.0102 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 203 / 11 KV ALLYALI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6289 | 1.749 | 1.8861 | .9774 | 1.7833 | 1.8861 | 1.0631 |
| 2 | 1.6118 | 1.7147 | 1.9719 | .9602 | 1.749 | 1.7147 | 1.1145 |
| 3 | 1.5947 | 1.6804 | 1.8519 | .9431 | 1.6975 | 1.6118 | 1.0974 |
| 4 | 1.5432 | 1.6461 | 1.7147 | .9431 | 1.6461 | 1.5947 | .9431 |
| 5 | 1.5089 | 1.6461 | 1.6804 | .9259 | 1.5775 | 1.5775 | 1.0288 |
| 6 | 1.4575 | 1.5775 | 1.406 | .8916 | 1.5604 | 1.5089 | 1.0631 |
| 7 | 1.6804 | | 1.2517 | .9259 | 1.6975 | 1.3717 | 1.2003 |
| 8 | 1.749 | 1.7661 | .9088 | 1.3717 | 1.7833 | 1.0631 | 1.3032 |
| 9 | 2.4863 | 2.5892 | .8916 | 2.2119 | 2.4348 | 1.1488 | 2.332 |
| 10 | | 3.0864 | .8745 | 2.8807 | | 1.3375 | 3.1893 |
| 11 | 3.3951 | 3.1379 | .9774 | 3.2579 | 3.3265 | 1.3889 | 3.2579 |
| 12 | 3.4465 | 3.1893 | .9774 | 2.1948 | 3.0007 | 1.3375 | 3.3093 |
| 13 | 2.1091 | 2.7435 | .9602 | | 2.7435 | 1.2517 | |
| 14 | 3.155 | | .9602 | 3.3093 | 2.9492 | 1.2689 | 3.2579 |
| 15 | 3.2579 | | .9259 | | 3.1893 | 1.3717 | 3.3436 |
| 16 | 3.3436 | 3.4808 | .9431 | 3.3093 | | 1.3375 | 3.2407 |
| 17 | 3.1379 | 3.0178 | .9259 | | | 1.0631 | 3.3093 |
| 18 | 2.7949 | 2.5034 | .8573 | 3.0864 | | 1.0288 | 3.0007 |
| 19 | 2.4006 | 2.332 | .8573 | 2.3663 | 2.2119 | .9774 | 2.3663 |
| 20 | 2.1605 | 2.0576 | .8916 | 2.1262 | 2.0576 | .9945 | 2.2634 |
| 21 | 1.9204 | 1.9376 | .9945 | 1.9204 | 1.9376 | 1.0288 | 1.8519 |
| 22 | 1.6975 | 1.8519 | .9602 | 1.8861 | 1.6461 | 1.0288 | |
| 23 | 1.6975 | 1.6975 | .9945 | 1.7833 | 2.0233 | 1.0288 | |
| 24 | 1.7661 | 1.869 | 1.6804 | .9774 | 1.9204 | 1.9376 | 1.1317 |
| Max | 3.4465 | 3.4808 | 1.9719 | 3.3093 | 3.3265 | 1.9376 | 3.3436 |
| Min | 1.4575 | 1.5775 | .8573 | .8916 | 1.5604 | .9774 | .9431 |
| Avg | 2.2410 | 2.2511 | 1.1810 | 1.8690 | 2.1468 | 1.3275 | 2.1270 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 204 / 11 KV SAWARA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1145 | 1.0631 | 1.0631 | .8916 | 1.1145 | 1.166 | .7888 |
| 2 | 1.0974 | 1.0288 | 1.0631 | .8745 | 1.0631 | | .7545 |
| 3 | 1.0974 | 1.0288 | 1.0288 | .823 | 1.0631 | 1.0974 | .7888 |
| 4 | .9945 | .9945 | .9945 | .823 | 1.0288 | .9945 | .7545 |
| 5 | .9259 | .9945 | .4973 | .7888 | 1.0288 | .9945 | .7545 |
| 6 | .9431 | 1.0288 | .9602 | .7888 | 1.0288 | .9774 | .7888 |
| 7 | 1.0631 | | .8745 | .823 | .9945 | .703 | .8916 |
| 8 | 1.2517 | 1.2346 | .7888 | 1.1145 | 1.2517 | .7545 | 1.1145 |
| 9 | 1.8519 | 1.9547 | .7202 | 1.749 | 1.8861 | .7888 | 1.8004 |
| 10 | | 2.332 | .7373 | 2.1776 | | .823 | |
| 11 | 2.4863 | 2.4006 | .8573 | 2.4006 | 2.5377 | .8059 | 2.5377 |
| 12 | 2.572 | 2.5034 | .7888 | 2.5377 | 2.4863 | .823 | 2.6749 |
| 13 | 2.2462 | 2.0748 | .6859 | | 2.0576 | .823 | |
| 14 | 2.3663 | | .6516 | 2.572 | 2.3148 | .7888 | 2.2462 |
| 15 | 2.4348 | | .7202 | | 2.4348 | .7888 | 2.2977 |
| 16 | 2.4348 | 2.2634 | .6859 | 2.3148 | | .7716 | 2.4863 |
| 17 | 2.1262 | 2.3663 | .7716 | | | .7716 | 2.6063 |
| 18 | 1.9376 | 1.8861 | .7888 | 1.8861 | | .7202 | 2.1091 |
| 19 | 1.3032 | 1.4918 | .7545 | 1.5432 | 1.5432 | .7373 | 1.6632 |
| 20 | 1.2003 | 1.3717 | .8573 | 1.4403 | 1.4232 | .7716 | 1.406 |
| 21 | 1.0974 | 1.2346 | .8573 | 1.166 | 1.1145 | .7888 | 1.1831 |
| 22 | 1.0288 | 1.2689 | .8573 | 1.0974 | 1.0631 | .7888 | |
| 23 | 1.1317 | 1.0631 | .8059 | 1.0288 | 1.2003 | .7888 | |
| 24 | 1.1317 | 1.0288 | 1.0631 | .8573 | 1.1317 | 1.0802 | .7545 |
| Max | 2.572 | 2.5034 | 1.0631 | 2.572 | 2.5377 | 1.166 | 2.6749 |
| Min | .9259 | .9945 | .4973 | .7888 | .9945 | .703 | .7545 |
| Avg | 1.5581 | 1.5530 | .8281 | 1.4142 | 1.4883 | .8499 | 1.5201 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 205 / 11 KV BHARWAD PADA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | .703 | .7202 | .4801 | .703 | .7202 | .6173 |
| 2 | .6859 | .6859 | .6859 | | .6859 | .703 | .6001 |
| 3 | .6516 | .6859 | .6859 | .4801 | .6859 | .6516 | .6344 |
| 4 | .6516 | .6516 | .6516 | .4801 | .6687 | .6516 | .6001 |
| 5 | .6516 | .6173 | .6516 | .463 | .6516 | .6001 | .6173 |
| 6 | .6516 | .6173 | .583 | .4801 | .6516 | .583 | .6173 |
| 7 | .7716 | | .4801 | .6001 | .6516 | .6001 | .6516 |
| 8 | .7716 | .7716 | .4115 | .6859 | .7888 | .4801 | .7202 |
| 9 | 1.0631 | 1.046 | .4115 | 1.0631 | 1.166 | .5487 | 1.0974 |
| 10 | | 1.3032 | .4287 | 1.3889 | | .5316 | 1.5432 |
| 11 | 1.4232 | 1.5089 | .4973 | 1.6118 | 1.5432 | .5487 | 1.5604 |
| 12 | 1.4575 | 1.5432 | .5144 | 1.5947 | 1.6461 | .5316 | 1.5947 |
| 13 | 1.3889 | 1.166 | | | 1.2346 | .5316 | |
| 14 | 1.4403 | | .4801 | 1.5947 | 1.5432 | .5487 | 1.4746 |
| 15 | | | .4801 | | 1.5947 | .5144 | 1.5261 |
| 16 | 1.5261 | 1.5089 | .4801 | 1.5947 | | .5144 | 1.5261 |
| 17 | 1.5089 | 1.3717 | .5144 | | | .5144 | 1.4746 |
| 18 | 1.1831 | 1.2174 | .4801 | 1.2174 | | .4973 | 1.3203 |
| 19 | .9259 | .9602 | .4801 | .9602 | .9431 | .4801 | 1.0631 |
| 20 | .8573 | .8573 | .4801 | .8745 | .9259 | .5144 | .9602 |
| 21 | .8573 | .8059 | .4801 | .823 | .823 | .5144 | .8916 |
| 22 | .8059 | .823 | .4973 | .823 | .8059 | .4801 | |
| 23 | .8573 | .823 | .4973 | .7716 | .7888 | .0514 | |
| 24 | .7373 | .7202 | .7888 | .4801 | .703 | .7888 | .6001 |
| Max | 1.5261 | 1.5432 | .7888 | 1.6118 | 1.6461 | .7888 | 1.5947 |
| Min | .6516 | .6173 | .4115 | .463 | .6516 | .0514 | .6001 |
| Avg | .9797 | .9708 | .5383 | .9234 | .9602 | .5458 | 1.0329 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162]

BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 207 / 11 KV WIRE RING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 2 | .0343 | | .0343 | .0343 | .0343 | .0343 | .0343 |
| 3 | | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 4 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 5 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 6 | .0343 | .0171 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 7 | .0171 | | .0343 | .0343 | .0343 | .0343 | .0343 |
| 8 | .0343 | .0171 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 9 | .0343 | .0171 | .0343 | .0343 | .0343 | .0514 | .0343 |
| 10 | | .0514 | .0343 | .0514 | | .0514 | .0514 |
| 11 | .0343 | .0514 | .0343 | .0514 | .0514 | .0514 | .0514 |
| 12 | .0343 | .0514 | .0343 | .0514 | .0343 | .0514 | .0514 |
| 13 | .0343 | .0343 | .0343 | | .0343 | .0343 | |
| 14 | .0343 | | .0343 | .0686 | .0514 | .0514 | .0514 |
| 15 | .0343 | | .0343 | | .0514 | .0343 | .0514 |
| 16 | .0343 | .0343 | .0343 | .0514 | | .0343 | .0343 |
| 17 | .0343 | .0343 | .0343 | | | .0343 | .0343 |
| 18 | .0343 | .0343 | .0343 | .0343 | | .0343 | .0343 |
| 19 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 20 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 21 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 22 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | |
| 23 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | |
| 24 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| Max | .0343 | .0514 | .0343 | .0686 | .0514 | .0514 | .0514 |
| Min | .0171 | .0171 | .0343 | .0343 | .0343 | .0343 | .0171 |
| Avg | .0335 | .0343 | .0343 | .0392 | .0369 | .0379 | .0376 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 401 / 33 KV Outgoing Bliss
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6687 | .6173 | .5658 | .3601 | .6687 | .7202 | .3601 |
| 2 | .6173 | .5658 | .6173 | .3601 | .6687 | .6173 | .3086 |
| 3 | .6173 | .5658 | .6173 | .3086 | .6173 | .6687 | .3086 |
| 4 | .6173 | .5144 | .5144 | .3086 | .6173 | .6173 | .3601 |
| 5 | .6687 | .5658 | .5658 | .3086 | .6173 | .5658 | .3601 |
| 6 | .6687 | .6173 | .5144 | .3601 | .6173 | .463 | .3086 |
| 7 | .6687 | | .4115 | | .5658 | .5658 | .3601 |
| 8 | .6173 | .5658 | .3601 | .6173 | .6687 | .3601 | .6687 |
| 9 | .7202 | .7202 | .3601 | .7202 | .823 | .4115 | .7716 |
| 10 | | | .3086 | .7202 | | .4115 | .823 |
| 11 | .823 | | .3601 | .9774 | .9259 | .463 | .9259 |
| 12 | .8745 | .8745 | .3086 | .8745 | .8745 | .4115 | .9259 |
| 13 | .6687 | .7716 | .3086 | | .823 | .4115 | |
| 14 | .7202 | | .3086 | .9259 | .823 | .4115 | .9259 |
| 15 | .7202 | | .3601 | | 1.0288 | .463 | .9259 |
| 16 | .7202 | .6687 | .3601 | .9259 | | .4115 | .9259 |
| 17 | .6687 | .7202 | .3601 | | | .463 | .823 |
| 18 | .5658 | .7202 | .3086 | .823 | | .463 | .7716 |
| 19 | .6173 | .5658 | .2572 | .7202 | .5658 | .3601 | .6687 |
| 20 | .7202 | .6173 | .3086 | .7202 | .5658 | .3086 | .7202 |
| 21 | .6687 | .6173 | .3086 | .7202 | .6173 | .3601 | .7716 |
| 22 | .5658 | .6173 | .3086 | .7202 | .6687 | .3601 | |
| 23 | .7202 | .6173 | .3086 | .6687 | .6687 | .3601 | |
| 24 | .7202 | .6173 | .6173 | .3601 | .6687 | .7202 | .3601 |
| Max | .8745 | .8745 | .6173 | .9774 | 1.0288 | .7202 | .9259 |
| Min | .5658 | .5144 | .2572 | .3086 | .5658 | .3086 | .3086 |
| Avg | .6799 | .6389 | .4008 | .6250 | .7047 | .4737 | .6369 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284024 / 33/11 KV ALLYALI SUBSTN

Feeder No / Name : 405 / 33 KV Allyali Incomer
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 6.6873 | 6.7387 | 6.893 | 4.5782 | 6.9445 | 7.2017 | 4.9383 |
| 2 | 6.4815 | 6.5329 | 6.9959 | 4.4239 | 6.7901 | 6.7901 | 4.9383 |
| 3 | 6.3786 | 6.4301 | 6.7387 | 4.2696 | 6.6873 | 6.3786 | 4.8354 |
| 4 | 6.1214 | 6.1728 | 6.4301 | 4.2181 | 6.4815 | 6.07 | 4.6296 |
| 5 | 7.9218 | 5.9671 | 5.4527 | 4.1667 | 6.3786 | 5.9156 | 4.6811 |
| 6 | 5.9156 | 5.9671 | 5.7099 | 4.321 | 6.3786 | 5.8128 | 4.7325 |
| 7 | 6.6873 | | 4.8868 | | 6.07 | 5.0926 | 5.0412 |
| 8 | 6.893 | 6.5844 | 4.0638 | 5.7613 | 7.0473 | 4.2696 | 5.9156 |
| 9 | 9.465 | 8.8477 | 3.9095 | 8.7963 | 10.0823 | 4.6811 | 9.2593 |
| 10 | | | 3.7037 | 11.1626 | | 5.1955 | 9.5165 |
| 11 | 12.2428 | | 4.0124 | 12.3457 | 12.8087 | 5.2469 | 12.5515 |
| 12 | 12.6029 | 12.1914 | 3.9095 | 11.214 | 12.4486 | 5.144 | 12.8087 |
| 13 | 9.5165 | 9.8766 | 3.8066 | | 10.2881 | 5.0412 | |
| 14 | 11.6255 | | 3.7037 | 12.6029 | 11.7799 | 5.0412 | 12.1914 |
| 15 | 11.8313 | | 3.7551 | | 12.5515 | 5.144 | 12.4486 |
| 16 | 11.9856 | 11.7799 | 3.8066 | 12.0371 | | 4.9383 | 12.4486 |
| 17 | 11.6255 | 11.3169 | 3.8066 | | | 4.784 | 12.5515 |
| 18 | 9.9794 | 9.6708 | 3.8066 | 10.5967 | | 4.4239 | 10.8539 |
| 19 | 8.3333 | 8.0761 | 3.7037 | 8.5391 | 7.4589 | 4.321 | 8.6934 |
| 20 | 7.8704 | 7.6646 | 4.0638 | 8.0761 | 7.356 | 4.6296 | 8.642 |
| 21 | 7.1502 | 7.4074 | 4.2696 | 7.2531 | 7.4589 | 4.7325 | 7.5617 |
| 22 | 6.7901 | | 4.3724 | 7.3045 | 7.0988 | 4.784 | |
| 23 | 7.2017 | 6.9445 | 4.4239 | 7.0988 | 7.6646 | 4.9383 | |
| 24 | 6.9959 | 6.7901 | 6.7901 | 4.5782 | 7.3045 | 7.4589 | 5.0926 |
| Max | 12.6029 | 12.1914 | 6.9959 | 12.6029 | 12.8087 | 7.4589 | 12.8087 |
| Min | 5.9156 | 5.9671 | 3.7037 | 4.1667 | 6.07 | 4.2696 | 4.6296 |
| Avg | 8.6219 | 8.0533 | 4.7089 | 7.6672 | 8.3539 | 5.3348 | 8.3015 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 201 / 11 KV Industrial Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .4801 | | | .5847 |
| 2 | .4801 | .4801 | | .463 | .4801 | | |
| 3 | .4801 | | | .4287 | | | .5658 |
| 4 | .4801 | | | .4287 | | | .5144 |
| 5 | .5281 | | | .5281 | | | .5487 |
| 6 | .5093 | | | .4715 | | | |
| 7 | | | | | .3772 | | .5144 |
| 8 | .4801 | | .4458 | .4527 | | | |
| 9 | .547 | .4973 | .5144 | | | | |
| 10 | | | .4801 | | .4801 | .4801 | |
| 11 | | | | .4801 | | .6224 | |
| 12 | .5487 | | .6602 | | | .6036 | |
| 13 | | | .6413 | | | .4973 | |
| 14 | | | | | | .5281 | |
| 15 | | | | .5487 | | | |
| 16 | | .6001 | .6602 | | | | |
| 18 | | | .4904 | .3772 | | .4904 | |
| 19 | | | | | | .4527 | |
| 21 | | | .583 | | | | |
| 22 | | | | | | .6224 | |
| 23 | | | .5847 | | | | |
| 24 | | .5144 | | .5144 | .5144 | .4458 | 1.5844 |
| Max | .5487 | .6001 | .6602 | .5487 | .5144 | .6224 | 1.5844 |
| Min | .4801 | .4801 | .4458 | .3772 | .3772 | .4458 | .5144 |
| Avg | .5067 | .5230 | .5622 | .4703 | .4630 | .5270 | .7187 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 202 / 11 KV DEKHALE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 1.2689 | | | 1.4335 |
| 2 | 1.3032 | 1.3203 | | 1.2689 | 1.2346 | | |
| 3 | 1.3032 | | | 1.2003 | | | 1.3769 |
| 4 | 1.3203 | | | 1.2689 | | | 1.2689 |
| 5 | 1.4901 | | | 1.4523 | | | 1.2517 |
| 6 | 1.4712 | | | 1.6221 | | | |
| 7 | | | | | 1.2689 | | 1.406 |
| 8 | 1.2689 | | 1.166 | 1.2826 | | | |
| 9 | 1.4146 | 1.2517 | 1.1145 | | | | |
| 10 | | | 1.1145 | | | 1.2003 | |
| 11 | | | | 1.1317 | | .6036 | |
| 12 | 1.3375 | | 1.2826 | | | .811 | |
| 13 | | | 1.3203 | | | .6516 | |
| 14 | | | | | | .7545 | |
| 15 | | | | 1.0288 | | | |
| 16 | | 1.0974 | 1.2449 | | | | |
| 17 | | | | | | 1.4523 | |
| 18 | | | 1.2637 | 1.166 | | 1.4523 | |
| 19 | | | | | | 1.4901 | |
| 21 | | | 1.5432 | | | | |
| 22 | | | | | | 1.905 | |
| 23 | | | 1.6032 | | | | |
| 24 | 1.3717 | 1.3717 | | 1.3375 | 1.3032 | 1.286 | |
| Max | 1.4901 | 1.3717 | 1.6032 | 1.6221 | 1.3032 | 1.905 | 1.4335 |
| Min | 1.2689 | 1.0974 | 1.1145 | 1.0288 | 1.2346 | .6036 | 1.2517 |
| Avg | 1.3645 | 1.2603 | 1.2948 | 1.2753 | 1.2689 | 1.1607 | 1.3474 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162]

BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 203 / 11 KV BHOPOLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .9259 | | | 1.094 |
| 2 | 1.0288 | .8916 | | .8916 | 1.0288 | | |
| 3 | .9431 | | | .8916 | | | .811 |
| 4 | .9259 | | | .8573 | | | .9259 |
| 5 | .5281 | | | .8676 | | | .7888 |
| 6 | .9054 | | | .7733 | | | |
| 7 | | | | | .6516 | | .583 |
| 8 | .6516 | | .6859 | .6413 | | | |
| 9 | .9054 | 2.452 | .8573 | | | | |
| 10 | | | .823 | | 1.0974 | .7545 | |
| 11 | | | | .9259 | | 1.0562 | |
| 12 | .7888 | | .9054 | | | .9808 | |
| 13 | | | .7545 | | | .6516 | |
| 14 | | | | | | .7356 | |
| 15 | | | | .823 | | | |
| 16 | | 1.0288 | .811 | | | | |
| 17 | | | | | | .811 | |
| 18 | | | .679 | .7888 | | | |
| 19 | | | | | | .9242 | |
| 21 | | | 1.0631 | | | | |
| 22 | | | | | | 1.2637 | |
| 23 | | | .8676 | | | | |
| 24 | 1.0974 | .8573 | | .9602 | 1.0288 | .7202 | |
| Max | 1.0974 | 2.452 | 1.0631 | .9602 | 1.0974 | 1.2637 | 1.094 |
| Min | .5281 | .8573 | .679 | .6413 | .6516 | .6516 | .583 |
| Avg | .8638 | 1.3074 | .8274 | .8497 | .9517 | .8775 | .8405 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 204 / 11 KV MANOR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 2.9492 | | | 3.4139 |
| 2 | 2.8807 | 2.8292 | | 2.8807 | 2.8807 | | |
| 3 | 2.8121 | | | 2.6406 | | | 3.131 |
| 4 | 2.7435 | | | 2.7435 | | | 2.8635 |
| 5 | 2.8481 | | | 3.0556 | | | 2.8292 |
| 6 | 3.3573 | | | 3.2819 | | | |
| 7 | | | | | 2.7435 | | 3.0007 |
| 8 | 2.6749 | | 2.2291 | 2.6406 | | | |
| 9 | 2.7915 | 2.452 | 2.332 | | | | |
| 10 | | | 1.3717 | | 2.4348 | 2.5377 | |
| 11 | | | | 1.9547 | | | |
| 12 | 2.3834 | | 2.4331 | 1.989 | | | |
| 13 | | | 2.4143 | | | | |
| 15 | | | | 2.2291 | | | |
| 16 | | 2.1948 | 2.7349 | | | | |
| 18 | | | 2.5652 | 2.332 | | | |
| 19 | | | | | | 3.546 | |
| 21 | | | 3.1893 | | | | |
| 22 | | | | | | 3.9609 | |
| 23 | | | 3.5082 | | | | |
| 24 | 3.1207 | 2.9835 | | 3.0521 | 3.0007 | 2.9664 | |
| Max | 3.3573 | 2.9835 | 3.5082 | 3.2819 | 3.0007 | 3.9609 | 3.4139 |
| Min | 2.3834 | 2.1948 | 1.3717 | 1.9547 | 2.4348 | 2.5377 | 2.8292 |
| Avg | 2.8458 | 2.6149 | 2.5309 | 2.6458 | 2.7649 | 3.2528 | 3.0477 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 302 / 22 KV KUNAL HOUSEWARE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .2401 | | | .2641 |
| 2 | .3772 | .2401 | | .2401 | .2743 | | |
| 3 | .2743 | | | .2401 | | | .2641 |
| 4 | .2401 | | | .2401 | | | .2401 |
| 5 | | | | | | | .2401 |
| 7 | | | | | .2058 | | .2401 |
| 8 | .4115 | | .2401 | | | | |
| 9 | | | .2058 | | | | |
| 10 | | | .2058 | | | | |
| 11 | | | | 1.0288 | | .3018 | |
| 12 | | | | .8916 | | .3018 | |
| 13 | | | | | | .2743 | |
| 14 | | | | | | .3018 | |
| 15 | | | | 1.0288 | | | |
| 16 | | .9602 | | | | | |
| 17 | | | | | | .3018 | |
| 18 | | | | .7545 | | | |
| 19 | | | | | | .3018 | |
| 21 | | | .2401 | | | | |
| 22 | | | | | | .2641 | |
| 24 | .3772 | .2743 | | .2401 | .2401 | .3086 | |
| Max | .4115 | .9602 | .2401 | 1.0288 | .2743 | .3086 | .2641 |
| Min | .2401 | .2401 | .2058 | .2401 | .2058 | .2641 | .2401 |
| Avg | .3361 | .4915 | .2230 | .5449 | .2401 | .2945 | .2497 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284025 / 33/11 Manor Substation

Feeder No / Name : 401 / 33KV INCOMING FEEDER
Feeder KV- 33 / INCOMING

SHEDDABLE RURAL

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | 16.1523 | 15.9465 | | | 16.358 | |
| 4 | 16.2552 | | | | | |
| 7 | | | | | 15.7408 | |
| 8 | | | 13.3745 | | | |
| 9 | | | 12.5 | | | |
| 11 | | | | 16.4609 | | 9.9023 |
| 12 | | | | 14.6605 | | 3.8477 |
| 14 | | | | | | 8.7706 |
| 15 | | | | 15.0206 | | |
| 16 | | 13.0659 | | | | |
| 17 | | | | | | 6.2243 |
| 18 | | | | 14.4033 | | |
| 24 | 17.0782 | 16.1008 | | | 16.9753 | 17.2325 |
| Max | 17.0782 | 16.1008 | 13.3745 | 16.4609 | 16.9753 | 17.2325 |
| Min | 16.1523 | 13.0659 | 12.5 | 14.4033 | 15.7408 | 3.8477 |
| Avg | 16.4952 | 15.0377 | 12.9373 | 15.1363 | 16.3580 | 9.1955 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284602 / 33/11 KV VALAN SUB STATION

Feeder No / Name : 201 / 11 KV AMBIKA UDYOG FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6289 | 1.5775 | 1.6289 | | | | |
| 2 | 1.5604 | 1.5261 | 1.5775 | | | | |
| 3 | 1.4575 | 1.4575 | 1.5432 | | | | |
| 4 | 1.4403 | 1.3375 | 1.4746 | | | | |
| 5 | 1.2346 | 1.2689 | 1.406 | | | | |
| 6 | 1.166 | 1.166 | 1.2689 | | | | |
| 7 | 1.1145 | 1.1317 | .9774 | 1.2003 | | 1.1488 | |
| 8 | 1.4403 | 1.6118 | 1.3717 | 1.7147 | 1.869 | | |
| 9 | 2.1605 | 2.3834 | 1.3203 | 1.9204 | | | |
| 10 | 2.5892 | 2.8807 | 1.4232 | 2.7778 | | | 2.915 |
| 11 | 2.8635 | 3.1036 | 1.4403 | 3.1207 | 3.5665 | | 2.9835 |
| 12 | 3.0864 | 2.8978 | 1.406 | 2.8807 | 3.5837 | | |
| 13 | 1.9204 | 1.9547 | 1.1831 | 1.9033 | | | |
| 14 | 2.7435 | 2.692 | | | 3.1207 | | |
| 15 | 2.5206 | 2.8121 | | 3.1036 | 3.2579 | | |
| 16 | 2.7435 | 2.915 | 1.3032 | 3.2922 | 3.1207 | | 2.915 |
| 17 | 2.2805 | 2.6578 | | 3.2407 | 2.8464 | | |
| 18 | 2.0062 | 2.2977 | | 2.5892 | | | |
| 19 | 1.749 | 1.6975 | | 1.7147 | | | |
| 20 | 1.6632 | 1.7833 | 1.2517 | 1.7833 | | | |
| 21 | 1.6804 | 1.7833 | 1.2003 | | | | |
| 22 | 1.6975 | 1.749 | | 1.869 | 1.9204 | | |
| 23 | 1.5947 | 1.749 | 1.3546 | | | | |
| 24 | 1.6975 | 1.6289 | 1.6975 | 1.0802 | 1.7318 | | |
| Max | 3.0864 | 3.1036 | 1.6975 | 3.2922 | 3.5837 | 1.1488 | 2.9835 |
| Min | 1.1145 | 1.1317 | .9774 | 1.0802 | 1.7318 | 1.1488 | 2.915 |
| Avg | 1.9183 | 2.0026 | 1.3794 | 2.2794 | 2.7797 | 1.1488 | 2.9378 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284602 / 33/11 KV VALAN SUB STATION

Feeder No / Name : 202 / 11 KV SHIRGAON FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5775 | 1.5604 | 1.5432 | | | | |
| 2 | 1.5432 | 1.5089 | 1.5089 | | | | |
| 3 | 1.5089 | 1.4575 | 1.4575 | | | | |
| 4 | 1.4403 | 1.406 | 1.3717 | | | | |
| 5 | 1.4746 | 1.4403 | 1.406 | | | | |
| 6 | 1.6804 | 1.5432 | 1.4746 | | | | |
| 7 | 1.5261 | 1.5604 | 1.5432 | 1.4918 | | 1.6632 | |
| 8 | 1.4575 | 1.4918 | 1.5089 | 1.3717 | 1.4232 | | |
| 9 | 1.3889 | 1.3717 | 1.406 | 1.286 | | | |
| 10 | 1.2346 | 1.3546 | 1.3546 | 1.286 | | | |
| 11 | | 1.3203 | 1.3717 | 1.3717 | | | 1.6118 |
| 12 | 1.3717 | 1.406 | 1.4575 | 1.3717 | 1.6289 | | |
| 13 | 1.3032 | 1.3203 | 1.4403 | 1.406 | | | |
| 14 | 1.3375 | 1.4232 | | | 1.5089 | | |
| 15 | 1.4232 | 1.4232 | | 1.4403 | 1.5261 | | |
| 16 | 1.4232 | 1.4918 | 1.5775 | 1.4575 | 1.4575 | | 1.5432 |
| 17 | 1.3889 | 1.4403 | | 1.4232 | 1.5432 | | |
| 18 | 1.2689 | 1.3032 | | 1.3717 | | | |
| 19 | 1.3717 | 1.3889 | | 1.6118 | | | |
| 20 | 1.6118 | 1.6804 | 1.7147 | 1.749 | | | |
| 21 | 1.6975 | 1.7147 | 1.7147 | 1.7318 | | | |
| 22 | 1.6632 | 1.7147 | | 1.7661 | 1.9547 | | |
| 23 | 1.6632 | 1.6975 | 1.6632 | | | | |
| 24 | 1.6289 | 1.6289 | 1.5947 | 1.5604 | 1.6118 | | |
| Max | 1.6975 | 1.7147 | 1.7147 | 1.7661 | 1.9547 | 1.6632 | 1.6118 |
| Min | 1.2346 | 1.3032 | 1.3546 | 1.286 | 1.4232 | 1.6632 | 1.5432 |
| Avg | 1.4776 | 1.4853 | 1.5061 | 1.4810 | 1.5818 | 1.6632 | 1.5775 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

PALGHAR S/DN.[162] BU 4162

Substation No/ Name :- 284602 / 33/11 KV VALAN SUB STATION

Feeder No / Name : 203 / 11 KV MAHIM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3375 | 1.286 | 1.286 | | | | |
| 2 | 1.3032 | 1.2174 | 1.2689 | | | | |
| 3 | 1.2689 | 1.1831 | 1.2346 | | | | |
| 4 | 1.2174 | 1.166 | 1.1831 | | | | |
| 5 | 1.2517 | 1.2003 | 1.166 | | | | |
| 6 | 1.3032 | 1.2346 | 1.2003 | | | | |
| 7 | 1.3203 | 1.286 | 1.2517 | 1.2346 | | 1.3717 | |
| 8 | 1.3203 | 1.3546 | 1.3889 | 1.3203 | 1.3203 | | |
| 9 | 1.5432 | 1.5604 | 1.6118 | 1.4232 | | | |
| 10 | 1.6289 | 1.6118 | 1.6632 | 1.5432 | | | |
| 11 | 1.5604 | 1.3546 | 1.5947 | 1.5432 | 1.6632 | | 1.7147 |
| 12 | 1.406 | 1.3546 | 1.4918 | 1.4232 | 1.4575 | | |
| 13 | 1.0802 | 1.3203 | 1.3032 | 1.3889 | | | |
| 14 | 1.1831 | 1.286 | | | 1.286 | | |
| 15 | 1.4746 | 1.5089 | | 1.6118 | 1.5775 | | |
| 16 | 1.5432 | 1.5432 | 1.5775 | 1.4746 | 1.6804 | | 1.1488 |
| 17 | 1.5261 | 1.5775 | | 1.5261 | 1.6975 | | |
| 18 | 1.3717 | 1.3546 | | 1.2689 | | | |
| 19 | 1.3375 | 1.2689 | | 1.2174 | | | |
| 20 | 1.5604 | 1.4403 | 1.5261 | 1.4746 | | | |
| 21 | 1.4918 | 1.4403 | 1.4403 | 1.406 | | | |
| 22 | 1.406 | 1.4232 | | 1.3889 | 1.4746 | | |
| 23 | 1.3375 | 1.3889 | 1.3546 | | | | |
| 24 | 1.3717 | 1.3032 | 1.3203 | 1.2689 | | | |
| Max | 1.6289 | 1.6118 | 1.6632 | 1.6118 | 1.6975 | 1.3717 | 1.7147 |
| Min | 1.0802 | 1.166 | 1.166 | 1.2174 | 1.286 | 1.3717 | 1.1488 |
| Avg | 1.3810 | 1.3610 | 1.3813 | 1.4071 | 1.5196 | 1.3717 | 1.4318 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

SAFALA S/DN.[164] BU 4164

Substation No/ Name :- 284021 / 33/11 KV RAMBAG SUBSTN

Feeder No / Name : 202 / 11 KV RAMBAG FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 03-MAY-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3491 | 1.2696 | 1.2986 | 1.2803 |
| 2 | 1.2803 | 1.2012 | 1.2803 | 1.2489 |
| 3 | | 1.2254 | | 1.2489 |
| 4 | 1.2986 | 1.2752 | | 1.2803 |
| 5 | 1.2986 | 1.2803 | | 1.3032 |
| 6 | 1.3306 | 1.3169 | | 1.3394 |
| 7 | 1.262 | 1.3121 | | 1.3213 |
| 8 | 1.3032 | 1.1706 | 1.2489 | 1.1641 |
| 9 | 1.3575 | | | |
| 10 | 1.3575 | | | |
| 11 | .9214 | | | |
| 12 | 1.1694 | | | |
| 13 | 1.1694 | | | |
| 14 | 1.2536 | | | |
| 15 | 1.2357 | | | |
| 16 | 1.2894 | | | |
| 17 | 1.3213 | | | |
| 18 | 1.267 | | | |
| 19 | 1.4266 | | | |
| 20 | 1.5546 | | | |
| 21 | 1.5154 | | | |
| 22 | 1.4415 | | | |
| 23 | 1.3491 | | | |
| 24 | 1.39 | 1.307 | 1.3169 | 1.2986 |
| Max | 1.5546 | 1.3169 | 1.3169 | 1.3394 |
| Min | .9214 | 1.1706 | 1.2489 | 1.1641 |
| Avg | 1.3105 | 1.2620 | 1.2862 | 1.2761 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 200 / DAPCHARI SUBSTATION

TRANSFORMER Feeder KV- 11 /

OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0326 |
| Max | .0326 |
| Min | .0326 |
| Avg | .0326 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 201 / 11 KV UDHAVA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.1488 |
| Max | 1.1488 |
| Min | 1.1488 |
| Avg | 1.1488 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 202 / 11 KV MAHALASHMI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.1488 |
| Max | 1.1488 |
| Min | 1.1488 |
| Avg | 1.1488 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 203 / 11 KV VASA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .7202 |
| Max | .7202 |
| Min | .7202 |
| Avg | .7202 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 204 / 11 KV TALASARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .5144 |
| Max | .5144 |
| Min | .5144 |
| Avg | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 205 / 11 KV DAPCHERI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .703 |
| Max | .703 |
| Min | .703 |
| Avg | .703 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 206 / 11 KV VADOLI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | .0686 |
| Max | .0686 |
| Min | .0686 |
| Avg | .0686 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 207 / 11 KV ALCAN EXPORTS FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .2572 |
| Max | .2572 |
| Min | .2572 |
| Avg | .2572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 208 / 11 KV Maharastra Border NON SHEDDABLE EXPRESS HV FEEDERS
Check Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .1029 |
| Max | .1029 |
| Min | .1029 |
| Avg | .1029 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 401 / 33 KV ACHHAD FEEDER

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 4.784 |
| Max | 4.784 |
| Min | 4.784 |
| Avg | 4.784 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284035 / 33/11 KV DAPCHARI SUBSTN

Feeder No / Name : 402 / 33KV Dolarpada
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.749 |
| Max | 1.749 |
| Min | 1.749 |
| Avg | 1.749 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284036 / 33/11 KV ACHHAD SUBSTN

Feeder No / Name : 200 / ACHHAD SUBSTATION
TRANSFORMER Feeder KV- 11 /
OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0224 |
| Max | .0224 |
| Min | .0224 |
| Avg | .0224 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284036 / 33/11 KV ACHHAD SUBSTN

Feeder No / Name : 201 / 11 KV KB AIRTEX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .7964 |
| Max | .7964 |
| Min | .7964 |
| Avg | .7964 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284036 / 33/11 KV ACHHAD SUBSTN

Feeder No / Name : 202 / 11 KV Tema

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.0387 |
| Max | 1.0387 |
| Min | 1.0387 |
| Avg | 1.0387 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284036 / 33/11 KV ACHHAD SUBSTN

Feeder No / Name : 203 / 11 KV HINDUSTAN FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| | |
|------|-----------|
| DATE | 01-MAY-18 |
| HR | Load (MW) |
| 24 | .1791 |
| Max | .1791 |
| Min | .1791 |
| Avg | .1791 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284036 / 33/11 KV ACHHAD SUBSTN

Feeder No / Name : 204 / 11 KV UPLAT FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAY-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.0517 |
| Max | 1.0517 |
| Min | 1.0517 |
| Avg | 1.0517 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284610 / 33/11 KV AMGAON SUB STATION

Feeder No / Name : 200 / AMGAON SUBSTATION
 TRANSFORMER Feeder KV- 11 /
 OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | | .0187 | .0187 | | | | |
| 9 | | | | | | | .8215 |
| 12 | .0187 | | | | | | |
| 16 | | | | | .0187 | | |
| 24 | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 |
| Max | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 | .8215 |
| Min | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 |
| Avg | .0187 | .0187 | .0187 | .0187 | .0187 | .0187 | .4201 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284610 / 33/11 KV AMGAON SUB STATION

Feeder No / Name : 201 / 11 KV AMGAON FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .5975 | .4854 | .4854 | .5975 | .5975 | .2801 |
| 2 | .5041 | .3361 | .5228 | .4294 | .5415 | .5975 | .2801 |
| 3 | .2987 | .3174 | .5228 | .5228 | .5228 | .6348 | .2801 |
| 4 | .2801 | .3547 | .5041 | .5415 | .5228 | .6348 | .2614 |
| 5 | .2801 | .3734 | .4854 | .5788 | .4854 | .3547 | .2614 |
| 6 | .5601 | .4481 | .4481 | .5415 | .4854 | .2801 | .3361 |
| 7 | .5415 | .7095 | .6161 | .5601 | .5041 | .2427 | .2427 |
| 8 | .4294 | .3921 | .6535 | .4668 | .5415 | .4481 | .2987 |
| 9 | .8215 | .5041 | .4481 | .5601 | .8215 | | .2801 |
| 10 | .3547 | .8962 | .5041 | .8775 | .9335 | | .3395 |
| 11 | | .5041 | .5975 | .8962 | .5601 | | .3018 |
| 12 | .8962 | .6908 | .6535 | .5601 | .5041 | | .4338 |
| 13 | .3921 | .4294 | .5415 | .6535 | .4854 | | .3395 |
| 14 | .8962 | .9709 | .5228 | .6722 | .7095 | | .3018 |
| 15 | | .8962 | .5415 | 1.2323 | .4481 | .2987 | .3018 |
| 16 | .4108 | .4481 | .5788 | .6535 | .4854 | .2987 | .3395 |
| 17 | .5788 | .6161 | .5228 | .6908 | .8775 | .2987 | .415 |
| 18 | .6161 | .7282 | .6535 | .4108 | .3921 | .2987 | .4715 |
| 19 | .5601 | .6908 | .3734 | .3734 | .6348 | .2987 | .3395 |
| 20 | .7095 | .5041 | .4294 | .4668 | .4108 | .2987 | .6602 |
| 21 | .5975 | .6348 | .6722 | .6161 | .6908 | .2987 | .6602 |
| 22 | .2801 | .4481 | .4668 | .7095 | .4294 | .2801 | .6036 |
| 23 | .6348 | .4854 | | .6161 | .5601 | .2801 | .3395 |
| 24 | | .6161 | .5228 | .2801 | .6722 | .5601 | .2801 |
| Max | .8962 | .9709 | .6722 | 1.2323 | .9335 | .6348 | .6602 |
| Min | .2801 | .3174 | .3734 | .2801 | .3921 | .2427 | .2427 |
| Avg | .5335 | .5663 | .5333 | .5998 | .5757 | .3890 | .3603 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284610 / 33/11 KV AMGAON SUB STATION

Feeder No / Name : 202 / 11 KV SAWAROLI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7282 | .7095 | .7468 | .4294 | .7842 | .7468 | .4481 |
| 2 | .7282 | .6722 | .7282 | .3921 | .7842 | .7095 | .4294 |
| 3 | .7468 | .6722 | .7282 | .3921 | .7282 | .7095 | .4294 |
| 4 | .7468 | .7095 | .6722 | .4294 | .6722 | .7095 | .4294 |
| 5 | .7468 | .7095 | .5601 | .4294 | .7095 | .7095 | .4294 |
| 6 | .7095 | .7282 | .5415 | .4481 | .6722 | .6722 | .4108 |
| 7 | .6722 | .7095 | .3734 | .4854 | .6535 | .3734 | .5228 |
| 8 | .8029 | .7282 | .3734 | .7468 | .7468 | .3547 | .5228 |
| 9 | .8402 | .9335 | .3921 | .7282 | .9709 | | .6722 |
| 10 | .9149 | .9896 | .3547 | .7842 | .9149 | | .7356 |
| 11 | | .7655 | .3547 | | .9896 | | .7356 |
| 12 | .8775 | .7468 | .2987 | .8029 | .8029 | | .6979 |
| 13 | .6722 | .6348 | .3547 | .6722 | .7842 | | .6602 |
| 14 | .6908 | .7655 | .3361 | .7282 | .8215 | | .679 |
| 15 | .8962 | .9149 | .3361 | .7655 | .7095 | .3921 | .7733 |
| 16 | .9149 | .7655 | .3921 | .7842 | .8775 | .3547 | .7545 |
| 17 | .8402 | .8215 | .4294 | .7655 | .7842 | .3547 | .7733 |
| 18 | .8215 | .8962 | .3921 | .8029 | .8402 | .3547 | .7733 |
| 19 | .8029 | .7842 | .4481 | .7655 | .7468 | .4481 | .7922 |
| 20 | .9335 | .9335 | .4854 | .8962 | .8589 | .5601 | .9054 |
| 21 | .9896 | .9149 | .5041 | .9335 | .8962 | .5228 | .9242 |
| 22 | .8589 | .8589 | .4854 | .8775 | .8962 | .5041 | .8488 |
| 23 | .7842 | .7842 | .5228 | .7282 | .8029 | .4668 | .7545 |
| 24 | .7095 | .7468 | .7282 | .4108 | .8215 | .7655 | .4481 |
| Max | .9896 | .9896 | .7468 | .9335 | .9896 | .7655 | .9242 |
| Min | .6722 | .6348 | .2987 | .3921 | .6535 | .3547 | .4108 |
| Avg | .8012 | .7873 | .4808 | .6608 | .8029 | .5394 | .6479 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284610 / 33/11 KV AMGAON SUB STATION

Feeder No / Name : 203 / 11 KV DONGARI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .5228 | .5788 | .5601 | .5415 | .5228 | .4668 |
| 2 | .5601 | .5601 | .5788 | .5415 | .5415 | .5415 | .4854 |
| 3 | .5601 | .5788 | .5788 | .5415 | .5601 | .5415 | .5041 |
| 4 | .5601 | .5601 | .5601 | | .5788 | .5415 | .5601 |
| 5 | .5601 | .5415 | .5788 | .5975 | .6161 | .5415 | .5788 |
| 6 | .5041 | .4854 | .5788 | .6161 | .5975 | .5975 | .5041 |
| 7 | .6722 | .6348 | .5601 | .6161 | .5975 | .5041 | .5788 |
| 8 | .6535 | .6348 | .4668 | .5041 | .5228 | .5601 | .7095 |
| 9 | .7655 | .8402 | .5041 | .6348 | .6535 | | .8215 |
| 10 | .8215 | .8589 | .5228 | .8402 | .8589 | | .7545 |
| 11 | | .7095 | .5228 | .8962 | .7842 | | .9997 |
| 12 | .6908 | .8029 | .4854 | .8775 | .7655 | | .8676 |
| 13 | .6161 | .7282 | .5041 | .7095 | .7468 | | .6979 |
| 14 | .5788 | .8029 | .5415 | .7842 | .6722 | | .8676 |
| 15 | .7842 | .7282 | .5228 | .8029 | .7468 | .4294 | .8676 |
| 16 | .8402 | .7282 | .5041 | .7655 | .8029 | .3734 | .8488 |
| 17 | .8589 | .7842 | .5415 | .8215 | .5975 | .3174 | .9054 |
| 18 | .7655 | .8029 | .5788 | .7655 | .6348 | .3547 | .8676 |
| 19 | .9335 | .8029 | .5975 | .7842 | .8775 | .3547 | .7922 |
| 20 | .8215 | .8402 | .5601 | .8029 | .7842 | .4481 | .7545 |
| 21 | .8215 | .8402 | .6348 | .6535 | .7095 | .5041 | .5658 |
| 22 | .7655 | .7842 | .5601 | .7468 | .6908 | .5041 | .5658 |
| 23 | .5228 | .4854 | .5415 | .5788 | .5041 | .4668 | .5658 |
| 24 | .5601 | .4854 | .5788 | .5601 | .5601 | .5041 | .4668 |
| Max | .9335 | .8589 | .6348 | .8962 | .8775 | .5975 | .9997 |
| Min | .5041 | .4854 | .4668 | .5041 | .5041 | .3174 | .4668 |
| Avg | .6859 | .6893 | .5492 | .6957 | .6644 | .4782 | .6915 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284618 / 33/11 KV DOLARPADA SUB

STATION

Feeder No / Name : 201 / 11 KV DOLARPADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7373 | .7888 | .8676 | .8299 | .8865 |
| 2 | | .7716 | .8865 | .8215 | .8676 |
| 3 | | .7545 | .8865 | .811 | .8865 |
| 4 | | .7545 | .9054 | .8299 | .9054 |
| 5 | .7888 | .7716 | .9242 | .8962 | .9054 |
| 6 | .8402 | .8059 | .9808 | .9054 | .9619 |
| 7 | .7888 | .7716 | .9808 | .8865 | .9431 |
| 8 | .6859 | .7373 | .8488 | .7922 | .8488 |
| 9 | .6344 | .6516 | .7545 | .811 | .7733 |
| 10 | .6001 | .7167 | .7356 | .7167 | |
| 11 | | .7167 | | | |
| 12 | .6344 | .679 | | | |
| 13 | .6001 | .6602 | | | |
| 14 | .6001 | .6413 | | | |
| 15 | .583 | .6602 | | | |
| 16 | .583 | .679 | | .7167 | |
| 17 | .6001 | .7167 | | .7733 | |
| 18 | .6344 | .7922 | | .7922 | |
| 19 | .7202 | .8488 | | .9054 | |
| 20 | .7716 | .9808 | | .9997 | |
| 21 | .823 | .9808 | | 1.0185 | |
| 22 | | | | .9808 | |
| 23 | | .9431 | | .9431 | |
| 24 | .7545 | .7888 | .9054 | .8488 | .9054 |
| Max | .8402 | .9808 | .9808 | 1.0185 | .9619 |
| Min | .583 | .6413 | .7356 | .7167 | .7733 |
| Avg | .6878 | .7657 | .8796 | .8568 | .8884 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284618 / 33/11 KV DOLARPADA SUB

STATION

Feeder No / Name : 202 / 11KV GIRGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4973 | .5144 | .547 | .6161 | .6036 |
| 2 | .4801 | .4973 | .5281 | .6224 | .6036 |
| 3 | .4801 | .4801 | .5281 | .6413 | .6224 |
| 4 | .4801 | .5144 | .547 | .6602 | .6036 |
| 5 | .5144 | .5487 | .5847 | .679 | .6413 |
| 6 | .5658 | .6001 | .6413 | .679 | .6413 |
| 7 | .5487 | .6173 | .679 | .679 | .6224 |
| 8 | .5144 | .5487 | .6036 | .4904 | .5658 |
| 9 | .4458 | .5144 | .5658 | .5658 | .5281 |
| 10 | .4287 | .5281 | .4904 | .5658 | |
| 11 | .463 | .5093 | | .4904 | |
| 12 | .3772 | .4904 | | .5281 | |
| 13 | .3772 | .4527 | | .4527 | |
| 14 | .3601 | .4338 | | | |
| 15 | .3429 | .4527 | | | |
| 16 | .3601 | .4527 | | .4904 | |
| 17 | .3772 | .4904 | | .5281 | |
| 18 | .4115 | .5093 | | .5281 | |
| 19 | .5144 | .5658 | | .5847 | |
| 20 | .583 | .679 | | .679 | |
| 21 | .6001 | .679 | | .679 | |
| 22 | .583 | .6413 | | .679 | |
| 23 | | .6036 | | .6413 | |
| 24 | .5144 | .5316 | .5658 | .6413 | .6224 |
| Max | .6001 | .679 | .679 | .679 | .6413 |
| Min | .3429 | .4338 | .4904 | .4527 | .5281 |
| Avg | .4704 | .5356 | .5710 | .5964 | .6055 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

TALASARI S/DN.[165] BU 4165

Substation No/ Name :- 284618 / 33/11 KV DOLARPADA SUB

STATION

Feeder No / Name : 203 / 11 KV VEVAJI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5487 | .5658 | .6036 | .6224 | .6602 |
| 2 | .5144 | .5144 | .5847 | .6036 | .6224 |
| 3 | .5144 | .5144 | .6036 | .6036 | .6413 |
| 4 | .5316 | .5487 | .5847 | .6036 | .6224 |
| 5 | .5487 | .5658 | .6036 | .6224 | .6413 |
| 6 | .583 | .6001 | .6979 | .6224 | .679 |
| 7 | .583 | .5658 | .679 | .6602 | .6602 |
| 8 | .5658 | .6001 | .6413 | .5658 | .5847 |
| 9 | .4973 | .5316 | .6224 | .5658 | .5658 |
| 10 | .463 | .5658 | .5658 | .5658 | |
| 11 | | .5658 | | .5093 | |
| 12 | .4458 | .5281 | | | |
| 13 | .4458 | .4904 | | | |
| 14 | .4287 | .4715 | | | |
| 15 | .4458 | .5093 | | | |
| 16 | .4287 | .5281 | | .6036 | |
| 17 | .4458 | .5093 | | .6224 | |
| 18 | .463 | .4904 | | .5847 | |
| 19 | .5658 | .5847 | | .6224 | |
| 20 | | .6602 | | .6979 | |
| 21 | | .679 | | .7167 | |
| 22 | | .679 | | .6979 | |
| 23 | | .679 | | .679 | |
| 24 | .583 | .583 | .6224 | .6413 | .679 |
| Max | .583 | .679 | .6979 | .7167 | .679 |
| Min | .4287 | .4715 | .5658 | .5093 | .5658 |
| Avg | .5054 | .5638 | .619 | .6205 | .6356 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

VIKRAMAGAD S/DN.[825] BU 4825

Substation No/ Name :- 284039 / 33/22 KV ONDA S/S VIKRAMGAD

Feeder No / Name : 300 / STATION TRANSFORMER FEEDER

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5 | .0191 | | | | .0191 | .0191 |
| 6 | | .0191 | | | | |
| 12 | | | | | .0191 | |
| 24 | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Max | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Min | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Avg | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

VIKRAMAGAD S/DN.[825] BU 4825

Substation No/ Name :- 284039 / 33/22 KV ONDA S/S VIKRAMGAD

Feeder No / Name : 301 / 22 KV ALONDA FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.5911 | 2.5911 | 2.7054 | 2.5911 | 2.6673 | 2.5911 | |
| 2 | 2.553 | 2.553 | 2.6292 | 2.6292 | 2.5911 | 2.553 | |
| 3 | 2.553 | 2.553 | 2.553 | 2.553 | 2.5149 | 2.7435 | |
| 4 | 2.6673 | 2.7435 | 2.5911 | 2.5911 | 2.6292 | 2.7816 | |
| 5 | 2.8959 | 2.8197 | 2.8578 | 2.7054 | 2.8578 | 2.8578 | |
| 6 | 3.4294 | 3.2388 | 2.6673 | | 3.0102 | 3.0102 | |
| 7 | | 2.8578 | 2.6292 | 2.6292 | 2.934 | 2.7816 | |
| 8 | 2.4006 | | | | 3.1245 | | |
| 9 | | | | 2.5911 | 2.5911 | | |
| 10 | | 2.7435 | 2.1719 | 2.8959 | 2.7435 | 2.8578 | 2.9721 |
| 11 | | 2.7435 | 2.3243 | | 2.934 | | |
| 12 | | 2.5149 | 2.0195 | | 2.7054 | 2.4006 | 2.7054 |
| 13 | | 2.4768 | | | 2.2862 | 2.3243 | 2.4006 |
| 14 | | 2.4387 | | | 2.1719 | | 2.3624 |
| 15 | | | | | 2.3624 | 2.2481 | |
| 16 | | | 2.21 | | 2.3624 | | |
| 17 | | 2.3624 | 2.5149 | | 2.6292 | | |
| 18 | | 2.4768 | 1.6766 | 2.8959 | 1.8671 | | 2.7435 |
| 19 | | 2.9721 | 2.7054 | | 2.7435 | | |
| 20 | | | | | 2.7435 | | |
| 21 | | | | | 2.6673 | | |
| 22 | | | 2.6673 | 2.7435 | 2.4387 | | |
| 23 | | | | | 2.7435 | | |
| 24 | 2.6292 | 2.7054 | 2.6673 | 2.6673 | 2.8578 | 2.5911 | |
| Max | 3.4294 | 3.2388 | 2.8578 | 2.8959 | 3.1245 | 3.0102 | 2.9721 |
| Min | 2.4006 | 2.3624 | 1.6766 | 2.553 | 1.8671 | 2.2481 | 2.3624 |
| Avg | 2.7149 | 2.6744 | 2.4744 | 2.6812 | 2.6324 | 2.6451 | 2.6368 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

VIKRAMAGAD S/DN.[825] BU 4825

Substation No/ Name :- 284039 / 33/22 KV ONDA S/S VIKRAMGAD

Feeder No / Name : 302 / 22 KV VIKRAMGAD FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7528 | 1.829 | 1.7909 | 1.9052 | 1.7909 | 1.9052 | |
| 2 | 1.7528 | 1.7528 | 1.7147 | 1.7909 | 1.6766 | 1.829 | |
| 3 | 1.7528 | 1.7147 | 1.7909 | 1.8671 | 1.7147 | 1.7909 | |
| 4 | 1.7528 | 1.7528 | 1.8671 | 1.829 | 1.7147 | 1.7909 | |
| 5 | | 1.7528 | 1.9052 | 1.8671 | 1.7528 | 1.829 | |
| 6 | 1.8671 | 1.8671 | 1.9052 | 1.9052 | 1.7528 | 1.7147 | |
| 7 | 1.7147 | 1.6766 | 1.6004 | 1.6385 | 1.6004 | 1.6385 | |
| 8 | 1.4861 | | | | 1.5242 | | |
| 9 | | 1.5623 | | 1.5242 | 1.6004 | | |
| 10 | | 1.4861 | 1.3717 | 1.5242 | 1.6766 | 1.3717 | 1.6766 |
| 11 | | 1.5623 | 1.5242 | | 1.6766 | | |
| 12 | | 1.5242 | 1.5242 | | 1.5623 | 1.3717 | 1.5623 |
| 13 | | 1.4861 | | | 1.448 | 1.3336 | 1.448 |
| 14 | | 1.4861 | | | 1.5623 | | 1.4098 |
| 15 | | | | | 1.4861 | | |
| 16 | | | 1.5242 | | 1.5242 | | |
| 17 | | 1.5242 | 1.6004 | | 1.6004 | | |
| 18 | | 1.4861 | 1.5242 | 1.5623 | 1.6004 | | 1.6385 |
| 19 | | 1.6766 | 1.9052 | | 1.829 | | |
| 20 | | | | | 2.2862 | | |
| 21 | | | | | 2.21 | | |
| 22 | | | 2.0957 | 2.0957 | 2.0957 | | |
| 23 | | | | | 1.9814 | | |
| 24 | 1.829 | 2.0195 | 1.829 | 1.9814 | 1.829 | 1.9052 | |
| Max | 1.8671 | 2.0195 | 2.0957 | 2.0957 | 2.2862 | 1.9052 | 1.6766 |
| Min | 1.4861 | 1.4861 | 1.3717 | 1.5242 | 1.448 | 1.3336 | 1.4098 |
| Avg | 1.7385 | 1.6564 | 1.7171 | 1.7909 | 1.7290 | 1.6800 | 1.5470 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

VIKRAMAGAD S/DN.[825] BU 4825

Substation No/ Name :- 284039 / 33/22 KV ONDA S/S VIKRAMGAD

Feeder No / Name : 303 / 22 KV SAKHARA FEEDER
Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2955 | 1.2574 | 1.1812 | .8002 | 1.7909 | 1.448 | |
| 2 | 1.2955 | 1.2193 | 1.1431 | .7621 | 1.3336 | 1.4098 | |
| 3 | 1.2955 | 1.2574 | 1.2193 | .8002 | 1.3336 | 1.4098 | |
| 4 | 1.3336 | 1.2955 | 1.2574 | .7621 | 1.3336 | 1.4098 | |
| 5 | 1.3336 | 1.3336 | 1.3717 | .8002 | 1.3336 | 1.4098 | |
| 6 | | | 1.2955 | .8764 | 1.4098 | | |
| 7 | 1.1812 | 1.1812 | 1.0288 | .8764 | 1.2193 | 1.2193 | |
| 8 | .9907 | | .8383 | | 1.105 | | |
| 9 | | .9526 | | .6097 | .8764 | | |
| 10 | | .9526 | .7621 | .8002 | .9145 | .8002 | .9907 |
| 11 | | .9526 | .7621 | | .9145 | | |
| 12 | | .724 | .7621 | | .9145 | .8002 | .8764 |
| 13 | | .6859 | | | .8383 | .8383 | .8383 |
| 14 | | .724 | | | .7621 | | .8383 |
| 15 | | | | | .8002 | | |
| 16 | | | .8002 | | .8764 | | |
| 17 | | .8383 | .8764 | | .9145 | | |
| 18 | | .8002 | .8002 | .8383 | .8383 | | 1.105 |
| 19 | | 1.1431 | .724 | | 1.2193 | | |
| 20 | | | | | 1.6385 | | |
| 21 | | | | | 1.6766 | | |
| 22 | | | .7621 | 1.1431 | 1.6004 | | |
| 23 | | | | | 1.4861 | | |
| 24 | 1.3336 | 1.2574 | 1.2574 | .8764 | 1.3717 | 1.448 | |
| Max | 1.3336 | 1.3336 | 1.3717 | 1.1431 | 1.7909 | 1.448 | 1.105 |
| Min | .9907 | .6859 | .724 | .6097 | .7621 | .8002 | .8383 |
| Avg | 1.2574 | 1.0359 | .9907 | .8288 | 1.1876 | 1.2193 | .9297 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-APR-18 and 05-MAY-18

KALYAN ZONE[054]

PALGHAR (MINI) CIRCLE[541]

PALGHAR DIVISION[543]

VIKRAMAGAD S/DN.[825] BU 4825

Substation No/ Name :- 284039 / 33/22 KV ONDA S/S VIKRAMGAD

Feeder No / Name : 304 / 22 KV KHAND WATER SUPPLY

EXPRES Feeder KV- 22 / OUTGOING

| DATE | 29-APR-18 | 30-APR-18 | 01-MAY-18 | 02-MAY-18 | 03-MAY-18 | 04-MAY-18 | 05-MAY-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0381 | | .0381 | .0381 | .0381 | .0381 | |
| 2 | .0381 | | .0381 | .0381 | .0381 | .0381 | |
| 3 | .0381 | | .0381 | .0381 | .0381 | .0381 | |
| 4 | .0381 | | .0381 | .0381 | .0381 | .0381 | |
| 5 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 6 | .0381 | | .0381 | .0381 | .0381 | .0381 | |
| 7 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 8 | .0381 | | .0381 | | .0381 | | |
| 9 | | .0381 | | .0381 | .0381 | | |
| 10 | | .0381 | | .0381 | .0381 | .0381 | |
| 11 | | .0381 | | | .0381 | | .0381 |
| 12 | | .0381 | .0381 | | .0381 | .0381 | .0381 |
| 13 | | .0381 | | | .0381 | .0381 | |
| 14 | | .0381 | | | .0381 | | |
| 15 | | | | | .0381 | | |
| 16 | | | .0381 | | .0381 | | |
| 17 | | .0381 | .0381 | | .0381 | | |
| 18 | | .0381 | .0381 | .0381 | .0381 | | .0381 |
| 19 | | .0381 | .0381 | | .0381 | | |
| 20 | | | | | .0381 | | |
| 21 | | | | | .0381 | | |
| 22 | | | | .0381 | .0381 | | |
| 23 | | | | | .0381 | | |
| 24 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| Max | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Min | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Avg | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |