

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 302 / MIDC FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6434	3.4979	3.7723	3.4294	3.7952	2.0233	3.6694
2	3.5295	3.4294	3.7037	3.3265	3.6434	1.989	3.6008
3	3.4156	3.3265	3.6351	3.1893	3.5295	2.0233	3.4979
4	3.3397	3.2236	3.4294	3.0864	3.4156	1.9547	3.3951
5	3.3018	3.0864	3.3951	2.8464	3.3777	2.0233	3.2579
6	3.3397	3.0521	3.3608	3.0178	3.15	2.1262	3.4979
7	3.3777	3.1893	3.3265	3.0178	2.7705	2.0919	3.2579
8	3.947	2.6063	3.4979	3.3608	2.4669	2.8807	3.6008
9	5.0755	4.6639	5.2126	5.1614	2.0919	4.7668	4.9383
10	6.1043	5.8642	6.1386	6.262	2.2291	5.727	6.5158
11	6.2414	6.07	6.4815	6.5277	2.1948	6.2757	6.7215
12	6.7558	6.3443	6.7215	6.8313		4.8354	6.9616
13	5.9328	5.3841	5.7956	6.4138		5.9671	6.1386
14	6.4129	5.6927	6.2414	6.1482		6.4815	6.6873
15	6.2414	6.2071	6.2414	6.4897		6.5158	6.4815
16	6.4472	6.1728	6.5501	6.7174		6.5844	6.7901
17	6.1043	5.8985	6.3443	6.2241		6.4472	6.8244
18	5.3841	5.8299	5.6584	5.9204	1.4746	6.0014	6.2414
19	5.0412	5.6584	5.4184	5.465	1.6118	5.487	5.6584
20	4.2181	4.6982	4.3896	4.4783	1.6461	4.2867	4.5268
21	4.1152	4.5268	4.2524	4.4403	2.0233	4.2867	4.4925
22	3.7037	4.2181	3.9438	4.3644	2.0919	4.0466	4.4582
23	3.6351	4.1152	3.6694	4.1367	2.0233	3.7037	3.8409
24	3.7952	3.6008	3.8752	3.4979	3.8711	2.0919	3.738
Max	6.7558	6.3443	6.7215	6.8313	3.8711	6.5844	6.9616
Min	3.3018	2.6063	3.3265	2.8464	1.4746	1.9547	3.2579
Avg	4.7126	4.5982	4.7940	4.7647	2.6337	4.1924	4.9497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 303 / KULGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.5775		1.5432	1.7193	.8573	.7888
2	1.5729	1.5089	1.4403	1.4746	1.6461	.7888	.7545
3	1.5364	1.406	1.3717	1.3717	1.5729	.7545	.7545
4	1.4998	1.3717	1.5432	1.406	1.5364	.7545	.7545
5	1.4632	1.6118	1.8861	1.4403	1.4998		1.4403
6	1.9753	1.8861	2.0576	1.9204	2.0119	.9259	.7888
7	2.1582	2.1262	2.0919	2.1262	2.2314	.9945	.8916
8	2.4143	2.5034	2.4006	2.5034	2.7435	1.2689	1.166
9	2.1605	2.3663	2.4691	2.6134	2.4691	1.2346	1.3375
10	1.989	2.1605	2.0576	2.2453	2.2977	.9602	1.1317
11	1.9547	2.0576	2.0576	2.3189	2.0576	.9259	.9602
12	1.749	1.9204	1.8861	2.2085		.8573	.9259
13	1.6118	1.8176	1.8176	2.0981		.7545	.823
14	1.5432	1.5775	1.6118	1.73		.7545	.7545
15	1.3717	1.4746	1.5089	1.6932		.6173	.6859
16	1.2689	1.4403	1.4746	1.6196		.583	.6516
17	1.5089	1.6118	1.6804	1.73		.6173	.6516
18	1.8176	1.8519	1.8861	1.9877	1.3032	.7202	.7888
19	2.332	2.3663	2.5034	2.6134	1.4403	1.0974	1.0631
20	2.3663	2.4348	2.4348	2.7238	1.2689	1.0974	1.0974
21	2.332	2.3663	2.7092	2.6337	1.2003	1.1317	1.1317
22	2.0576	2.1262	2.1605	2.3045	1.1317	1.0288	1.0288
23	1.8519	1.9204	1.8861	2.0485	.9945	.9602	.9602
24	1.6461	1.6118	1.6118	1.6461	1.7924	.8573	.823
Max	2.4143	2.5034	2.7092	2.7238	2.7435	1.2689	1.4403
Min	1.2689	1.3717	1.3717	1.3717	.9945	.583	.6516
Avg	1.8246	1.8790	1.9368	2.0000	1.7176	.8931	.9231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 304 / WANGANI FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2588	1.989	1.8519	1.7833	2.1502	1.9547	2.0919
2	2.1835	1.8861	1.8861	1.749	2.1125	1.9204	2.0919
3	2.0706	1.8519	2.0576	1.6461	2.0748	1.8861	2.1262
4	1.9953	1.749	2.0576	1.6118	2.037	1.7833	1.8519
5	1.8823	2.0233	2.572	1.7833	2.0748	2.0576	1.8519
6	2.4847	2.2977	2.8464	2.2634	2.6406	2.572	2.1262
7	3.1623	2.8121	2.9492	2.7435	3.2065	2.7778	2.5034
8	3.1623	2.9492	2.8121	2.7778	3.3573	3.0178	2.915
9	2.7778	2.6406	2.8121	3.0617	2.9835	3.0178	3.1893
10	2.6063	2.572	2.7092	3.3641	2.6406	2.915	2.9835
11	2.4006	2.2977	2.4691	3.1751	2.332	2.9835	2.915
12	2.5377	2.4006	2.2291	3.0239		2.7435	2.6749
13	2.2291	1.989	2.4006	2.6837		2.4691	2.2291
14	1.8519	1.9204	1.749	2.1168		1.9547	2.0576
15	1.9547	1.9547	1.8519	2.2302		1.7147	2.1262
16	1.8861	2.0919	1.6461	2.5325		2.4691	2.0919
17	2.2291	1.9547	2.3663	2.6459		2.5377	2.1605
18	2.1948	2.0576	2.5377	2.7971	3.0521		2.332
19	2.8464	2.915	2.9492	3.2507	3.3951	2.8464	3.0521
20	2.6749	2.7778	2.8121	3.1373	3.2236	2.8807	2.8807
21	2.5377	2.6406	3.155	3.2065	3.155	3.0864	2.7435
22	2.572	2.5034	2.7435	3.0178	2.7435	2.7778	2.8121
23	2.3663	2.1948	2.4006	2.5652	2.2634	2.332	2.5034
24	2.3341	1.989	1.8861	1.8519	2.1502	1.9547	2.0576
Max	3.1623	2.9492	3.155	3.3641	3.3951	3.0864	3.1893
Min	1.8519	1.749	1.6461	1.6118	2.037	1.7147	1.8519
Avg	2.3833	2.2691	2.4063	2.5424	2.6440	2.4632	2.4320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 305 / 18MLD MJP DRINKING WATER NON SHEDDABLE WATER SUPPLY AND
SUPPL Feeder KV- 22 / OUTGOING UTILITY

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4919	1.0974	1.0631	1.2193	1.2169
2	.4919	1.1317	1.0631	1.2574	1.2169
3	.4919	1.0974	1.0631	1.2193	1.1789
4	.4919	1.0974	1.0974	1.2574	1.1789
5	.4919	1.2346	1.0974	1.2193	1.1789
6	.4919	1.2346	1.1317	1.3336	1.2929
7	.4919	1.166	1.1317	1.3717	1.331
8	.5297	1.1317	1.1317	1.0669	1.2929
9	.4801	1.1317	1.0974	1.1397	.8916
10	.4801	1.0288	1.2689	1.2916	.9259
11		1.0974	.9602	1.4436	.9259
12		1.2689	1.1431	1.4436	
13		1.2003	1.3336	1.4056	
14		1.2003	1.2955	1.3676	
15		.9945	1.3717	1.4056	
16			1.3717	1.3676	
17		1.2689	1.3336	1.1017	
18	.3772	.9602	1.3717	1.1397	
19	.3429	1.2346	1.3717	1.3676	
20	.3772	1.2689	1.3336	1.3676	
21	.3429	1.2346	1.2955	1.369	
22	.3429	1.2003	.9145	1.0648	
23	.9602	1.1317	.9526	1.1408	
24		1.1317	1.0631	1.2193	1.2549
Max	.9602	1.2689	1.3717	1.4436	1.331
Min	.3429	.9602	.9145	1.0648	.8916
Avg	.4798	1.1541	1.1774	1.2742	1.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 306 / Mankivali MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.1719	2.2862	2.2862	1.9814	1.1812	2.3243
2	2.0576	2.0195	2.21	2.21	1.9052	1.1812	2.2862
3	2.0576	1.9814	2.0957	2.1338	1.829	1.2574	2.21
4	2.0195	1.9052	2.0576	2.0957	1.7909	1.1431	2.1719
5	1.9814	1.9052	2.0957	2.1719	1.7528	1.1431	2.1338
6	1.9814	1.9433	2.0957	1.829	1.6385	1.1812	2.1719
7	1.9814	2.1338	2.0957	2.0957	1.448	1.2574	1.9814
8	2.1338	2.21	2.21	2.0195	1.2574	1.5242	2.1719
9	2.6292	2.553	2.5149	2.5149	1.1812	1.9433	2.553
10	2.7816	2.8959	3.2007	2.8578	1.1431	2.8197	2.8578
11	3.2388	3.2388	3.1626	2.8959	1.0669	2.7816	3.0483
12	3.2769	3.2007	3.1626	2.9721		3.0102	3.1245
13	2.8197	2.7435	2.6292	2.8578		2.4768	2.7816
14	3.0864	3.0102	3.2007	2.7816		2.7816	3.0483
15	3.1245	3.0864	3.315	2.7054		3.315	2.9721
16	3.2769	3.4294	3.5056	2.7435		3.0864	3.0483
17	3.0102	3.5056	3.2007	2.6673		2.8578	2.9721
18	2.8578	3.5056	3.2007	2.6292	.9907	2.8959	2.7816
19	2.8578	2.8197	2.8197	2.7054	1.0669	2.4387	2.5911
20	2.4768	2.7435	2.5911	2.0576	1.1812	2.0195	2.2481
21	2.3624	2.8578	2.7054	2.0576	1.1812	2.4387	2.1338
22	2.1719	2.6673	2.2862	1.9814	1.1812	2.3624	2.1338
23	2.2481	2.4768	2.3624	1.9814	1.2574	2.3624	2.1719
24	2.21	2.2481	2.4387	2.4006	2.0195	1.2574	2.3624
Max	3.2769	3.5056	3.5056	2.9721	2.0195	3.315	3.1245
Min	1.9814	1.9052	2.0576	1.829	.9907	1.1431	1.9814
Avg	2.5323	2.6355	2.6435	2.4021	1.4374	2.1132	2.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 028364 / 22 KV KHARVAI SW/STN

Feeder No / Name : 307 / 22 KV KHARVAI FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1836	.1905	.1524	.1677	.1844	.2096	.1677
2	.1669	.1905	.1372	.1524	.2012	.2096	.1677
3	.1832	.1715	.1372	.1524	.1844	.2096	.1677
4	.1665	.1715	.1372	.1372	.1715	.1905	.1677
5	.1665	.2096	.1829	.1524	.1715	.1905	.1677
6	.2498	.2477	.2134	.1981	.2229	.2667	.1829
7	.2664	.362	.2439	.2286	.2572	.2667	.2134
8	.267	.2858	.2439	.2286	.2915	.2858	.2591
9	.3239	.3239	.1981	.2817	.2667	.2439	.2286
10	.2667	.362	.1981	.3169	.2667	.2134	.1981
11	.2286	.1981	.2134	.2817	.2286	.2134	.3201
12	.2858	.2743	.1829	.2112		.2591	.1981
13	.0953	.2439	.1829	.2279		.2439	.1981
14	.2096	.1829	.1829	.1928		.1829	.2134
15	.2096	.1829	.1829	.2103		.1829	.1829
16	.2286	.1829	.1829	.1928		.1981	.1829
17	.2858	.1829	.1981	.2454		.2743	.1981
18	.2286	.1829	.2286	.2804	.2667	.2134	.1981
19	.362	.2286	.3048	.333	.3048	.3048	.3048
20	.2477	.2896	.2591	.2443	.2858	.2286	.2439
21	.2477	.2134	.2896	.2401	.2667	.2286	.3048
22	.2286	.2439	.1981	.2229	.2858	.2591	.1981
23	.2286	.2439	.1829	.2254	.2858	.2439	.1981
24	.1661	.2096	.1981	.1677	.198	.2286	.1829
Max	.362	.362	.3048	.333	.3048	.3048	.3201
Min	.0953	.1715	.1372	.1372	.1715	.1829	.1677
Avg	.2289	.2323	.2013	.2205	.2411	.2312	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 283394 / 22KV KATRAP SW/S

Feeder No / Name : 301 / INCOMER 22KV KATRAP SW/S NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0287	3.8809	4.2875	4.0657	4.0657	4.4353	5.4702
2	4.0287	3.6961	4.1027	3.8809	3.9548	4.1027	5.3963
3	4.0657	3.6961	3.9179	3.8439	3.8439	4.0287	5.2484
4	4.1396	3.733		3.9548	3.9179	4.1766	5.0636
5	4.4353	3.8439	4.0657	4.1396	3.9918		5.2854
6	4.9897		4.5092	4.5831	4.8419	5.2484	5.4702
7	5.3963	5.4332	5.5072	5.5441	5.5072	6.653	6.0616
8	5.8029	5.9877	5.8398	5.9507	6.0246	7.3922	6.8747
9	5.3593	5.6181	5.6181		5.5441	7.2813	7.577
10	5.4332	5.0636	5.4702	5.655		6.5478	7.54
11	4.8788	4.6201	4.9528	4.8788	4.9897	6.4682	7.2074
12	4.5092	4.2135	4.5831	4.5831		6.1725	6.7269
13	4.1027	4.095	4.2505	4.2875	4.8049	5.7289	6.2833
14	3.8809	3.9918	3.8809	3.9548	5.5072	5.2854	5.4702
15	3.6961	3.9179	3.77	3.807	3.9179	5.0267	5.1376
16	3.5482	3.8439	3.9918	3.9548	3.6961	5.1006	5.2484
17	3.733	4.0287	4.0657	4.1396	3.733	5.4332	5.655
18	4.1766	4.5831	4.6571	4.9897		6.7638	6.1725
19	5.8398	6.3573	6.3942	6.2094	7.9836	6.8747	8.0205
20	5.8398	6.2833	6.2833	6.2833	7.8357	7.3183	8.2053
21	5.692	6.2464	6.9486	6.5051	7.7618	7.9096	8.2053
22	5.3224	6.2833	6.0246	5.9137	7.2813	7.3183	7.4661
23	4.8788	4.9528	5.1745	5.3593	6.579	6.1355	6.653
24	4.1396	4.2875	4.2875	4.5092	4.5092	4.8788	5.7659
Max	5.8398	6.3573	6.9486	6.5051	7.9836	7.9096	8.2053
Min	3.5482	3.6961	3.77	3.807	3.6961	4.0287	5.0636
Avg	4.6632	4.7242	4.8949	4.8258	5.2520	5.9252	6.3419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 283394 / 22KV KATRAP SW/S

Feeder No / Name : 302 / KATRAP

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2197	1.4045	1.1827	1.2936	1.3306	1.4784
2	1.3306	1.1827	1.3306	1.1088	1.2567	1.2567	1.4784
3	1.2936	1.1827	1.2567	1.1088	1.2197	1.2197	1.4415
4	1.2936	1.1827	1.2197	1.1458	1.2197	1.2936	1.4045
5	1.4045	1.2197	1.3306	1.1827	1.2567	1.3306	1.4415
6	1.7002	1.4784	1.4784	1.4784	1.4784	1.3306	1.4784
7	1.8111	1.7741	1.7372	1.4784	1.7741	1.7741	1.5893
8	1.885	1.9959	1.922	1.8111	1.848	1.9589	1.848
9	1.6632	1.848			1.848	1.885	1.9959
10	1.7372	1.848	1.7372	1.885		1.7372	2.0698
11	1.6263	1.6632	1.8111	1.7002	1.7372	1.848	1.9589
12	1.4784	1.6263	1.6263	1.6632		1.7372	1.848
13		1.5524	1.5524	1.5893	1.7372	1.6632	1.7002
14	1.3306	1.4784	1.4784	1.4784	1.5524	1.4415	1.5524
15	1.2567	1.2936	1.3306	1.3676	.1848	1.4415	1.4045
16	1.2197	1.3306	1.2936	1.3306	.1848	1.3676	1.3306
17	1.2567	1.3676	1.3676	1.3676	.1478	1.4415	1.4045
18	1.4045	1.5524	1.6263	1.922		1.8111	1.7372
19	1.9589	2.3285	1.6263	2.2177	2.4764	2.0328	2.2177
20	1.9959	2.3285	2.1807	2.2916	2.3655	2.2177	2.3285
21	1.922	2.3285	2.2546	2.2177	2.2177	2.2177	2.2177
22	1.7372	2.3411	2.0698	1.7741	1.9959	1.9959	2.0328
23	1.5893	1.6263	1.6632	1.8111			1.7372
24	1.3306	1.3676	1.4045	1.4415	1.4415	1.4784	1.4784
Max	1.9959	2.3411	2.2546	2.2916	2.4764	2.2177	2.3285
Min	1.2197	1.1827	1.2197	1.1088	.1478	1.2197	1.3306
Avg	1.5443	1.6299	1.5958	1.5893	1.4618	1.6440	1.7156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 283394 / 22KV KATRAP SW/S

Feeder No / Name : 303 / CHIKHLOLI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4435	.5175	.4805	.4805	.4805	.5175
2	.4066	.4435	.4805	.4435	.4435	.4435	.5175
3	.4066	.4435	.4435	.4435	.4066	.4435	.4805
4	.4435	.4435	.4435	.4066	.4435	.4435	.4805
5	.4805	.4435	.5175	.4435	.4805	.4805	.5175
6	.5914	.5544	.5914	.5175	.5544	.5544	.5175
7	.5914	.6283	.6653	.6653	.6283	.6653	.5544
8	.6653	.6653	.6653	.7392	.7023	.7392	.5914
9	.6283	.6653	.6283		.6653	.6653	.7392
10	.6283	.6283	.6283	.7392		.6653	.8131
11	.5914	.5914	.6283	.5914	.5914	.6283	.7392
12	.5175	.4435	.5544	.5544		.5914	.6283
13		.4435	.5175	.4805	.5914	.5914	.6283
14	.4435	.4435	.4435	.4066	.4435	.4805	.4805
15	.4066	.4435	.4435	.4066	.4435	.4805	.4805
16	.4066	.4435	.4805	.4066	.4805	.4805	.5544
17	.4066	.4435	.4805	.4435	.4066	.4805	.4805
18	.4805		.5175	.4805		.5175	.5175
19	.6653	.7023	.7023	.6283	.6283	.5914	.6283
20	.6283	.6653	.6653	.7023	.6653	.6653	.7023
21	.6283	.6653	.7023	.7392	.7023	.7392	.7023
22	.6283	.6653	.7023		.6653	.7392	.7023
23	.5544	.6283	.5914	.5914			.6283
24	.4805	.4805	.5175	.5175	.5175	.5544	.5544
Max	.6653	.7023	.7023	.7392	.7023	.7392	.8131
Min	.4066	.4435	.4435	.4066	.4066	.4435	.4805
Avg	.5271	.5399	.5637	.5376	.5470	.5705	.5898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (E) S/DN.[149] BU 4405

Substation No/ Name :- 283394 / 22KV KATRAP SW/S

Feeder No / Name : 304 / SHIRGAON

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2916	1.9959	2.3655	2.3655	2.2916	2.5133	3.4743
2	2.2177	1.922	2.2916	2.2916	2.2177	2.3655	3.4004
3	2.2916	1.922	2.2177	2.2916	2.1437	2.2916	3.3265
4	2.2177	1.922	2.1437	2.3655	2.1437	2.3655	3.1786
5	2.4394	1.9959	2.2177	2.3655	2.2177	2.4394	3.3265
6	2.809	2.5133	2.4394	2.5873	2.6612	3.2526	3.4743
7	2.9569	2.809	3.1047		3.0308	3.9179	3.9179
8	3.2526	3.1786	3.219	3.2526	3.3265	4.4353	4.4353
9	3.0308	2.8829	3.1786		3.0308	4.2875	4.6091
10	3.0308	2.5873	3.0308	3.0308		4.2135	
11	2.6612	2.3655	2.5133	2.5873	2.6612	3.9918	
12	2.3655	2.1437	2.3655	2.3655		3.8439	4.2505
13		2.0698	2.1437	2.2177	2.4764	3.4743	3.9548
14	2.0698	1.9959	1.848	2.0698	3.5113	3.1047	3.4374
15	1.848	1.9959	1.922	1.922	3.2895	3.1047	3.2526
16	1.7741	2.0698	2.1437	2.0698	3.0308	2.9569	3.3634
17	1.9959	2.2177	2.2177	2.2916	3.1047	3.2526	3.4743
18	2.0698	2.5873	2.3655	2.5133		4.0657	3.77
19	2.9569	3.3265	3.2526	3.2526	4.8049	4.2505	4.8788
20	3.0308	3.2526	3.3265	3.3265	4.8049	4.4353	4.9528
21	2.8829	3.2526	3.77	3.5482	4.8049	4.9528	5.1006
22	2.809	3.2526	3.3265	3.4004	4.4353	4.5359	4.731
23	2.5133	2.7351	2.809	2.9569			4.1396
24	2.2916	2.2177	2.3655	2.5133	2.4394	2.6612	3.4743
Max	3.2526	3.3265	3.77	3.5482	4.8049	4.9528	5.1006
Min	1.7741	1.922	1.848	1.922	2.1437	2.2916	3.1786
Avg	2.5133	2.4672	2.6074	2.6175	3.1214	3.5092	3.9056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (W) S/DN.[755] BU 4755

Substation No/ Name :- 283065 / 22KV SONIVALI SW/STN

Feeder No / Name : 301 / Eranjad

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0165	2.089	2.1791	2.1285	2.1636	2.2382	2.3501
2	1.9418	1.9771	1.9517	2.0165	2.0517	2.1393	2.2382
3	1.8671	1.9398	1.9953	2.0538	1.9771	2.0517	2.1636
4	1.9044	2.089	2.0664	2.1285	2.1636	2.1263	2.2755
5	2.0911	2.2755	2.5548	2.3899	2.5367	2.574	2.5367
6	2.4272	3.0589	3.0777	2.9874	3.1335	3.0962	2.6859
7	3.062	3.3946	3.3916	3.3981	3.432	3.3946	3.0589
8	3.3608	3.3946	3.3404	3.5101	3.3946	3.9169	3.4693
9	2.8006	3.0589	2.9813	3.0247	3.0962	3.2454	3.446
10	2.7232	2.7266	2.7633	2.8724	2.7605	2.9843	3.2521
11	2.5897	2.4713	2.4646	2.4994	2.3874	2.5367	2.7548
12	2.3128	2.2221	2.3152	2.2755	2.1636	2.7978	2.545
13	2.089	2.025	2.0165	2.089	2.0517	2.6113	2.4534
14	1.9025	1.9286	1.8671	2.0517	1.9025	2.3874	2.2453
15	1.8652	1.9826	1.9791	2.0144	1.9771	2.3501	2.1695
16	1.9771	2.0819	2.0911	2.0144	2.0517	2.3501	2.1327
17	2.0517	2.1222	2.1658	2.1263	2.089	2.574	2.3338
18	2.2382	2.433	2.3152	2.4621	2.2009	2.6486	2.49
19	2.8351	3.1089	3.0994	3.0962	2.9097	3.2081	3.209
20	2.9097	3.0117	2.9127	3.0962	3.0216	3.1708	3.2442
21	2.9097	3.1247	3.2114	3.2081	3.0962	3.1335	3.1687
22	2.7605	2.8612	2.8753	2.9843	2.947	3.0589	3.0209
23	2.4994	2.6029	2.5766	2.6859	2.6859	2.7605	2.8669
24	2.1285	2.2382	2.2588		2.3874	2.3874	2.4621
Max	3.3608	3.3946	3.3916	3.5101	3.432	3.9169	3.4693
Min	1.8652	1.9286	1.8671	2.0144	1.9025	2.0517	2.1327
Avg	2.3860	2.5091	2.5188	2.5701	2.5242	2.7393	2.6905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (W) S/DN.[755] BU 4755

Substation No/ Name :- 283065 / 22KV SONIVALI SW/STN

Feeder No / Name : 302 / Badlapurgaon

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.2386	1.105	.9335	1.2761	.9383	1.0134
2	1.1203	1.126	1.0669	1.0082	1.1635	.9008	.9383
3	1.1203	1.0134	.9526	1.1203	1.0884	.9008	.9758
4	1.1949	.9008	1.105	1.2696	1.1635	1.0134	1.0884
5	1.2696	1.0509	1.1812	1.2323	1.2386	1.126	1.2761
6	1.3443	1.5388	1.2955	1.267	1.5388	1.2761	1.5013
7	1.307	1.3887	1.4861	1.6057	1.4262	1.3887	1.3512
8	1.3443	1.4638	1.6303	1.7924	1.5764	1.4638	1.5388
9	1.531	1.4262	1.4998	1.5684	1.5388	1.5388	1.7784
10	1.4638	1.677	1.4563	1.5013	1.4262	1.5388	1.586
11	1.201	1.2145	1.419	1.3136	1.2386	1.2386	1.4306
12	1.0884	1.1305	1.2696	1.3136	1.1635	1.5764	1.3901
13	1.0134	1.1659	1.1949	1.201	1.0884	1.0509	1.2411
14	.8632	1.2096	1.0082	1.0134	.9008	1.0509	1.1317
15	.9355	1.0973	1.9791	1.4262	.9383	1.4638	1.2696
16	1.0509	1.1635	1.2323	1.5764	.9008	1.4638	1.2335
17	1.0509	1.2722	1.1203	1.4262	.9008	1.5388	1.2373
18	1.126	1.1363	1.1576	1.1635	.9383	1.5388	1.2047
19	1.4262	1.448	1.419	1.5013	1.3512	1.764	1.4653
20	1.3512	1.448	1.3817	1.3512	1.2761	1.5013	1.448
21	1.2761	1.2574	1.419	1.3512	1.2761	1.3887	1.3336
22	1.126	1.2193	1.2323	1.2386	1.201	1.3512	1.2839
23	1.0884	1.105	1.0829	1.1635	1.126	1.2761	2.8843
24	1.2323	1.0509	1.0288	.9335	1.3512	1.0134	1.0884
Max	1.531	1.677	1.9791	1.7924	1.5764	1.764	2.8843
Min	.8632	.9008	.9526	.9335	.9008	.9008	.9383
Avg	1.1951	1.2393	1.2801	1.3030	1.2120	1.3043	1.3621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (W) S/DN.[755] BU 4755

Substation No/ Name :- 283065 / 22KV SONIVALI SW/STN

Feeder No / Name : 303 / BAZARPETH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6139	2.726	2.6513	2.838	2.7978	4.0661	4.3645
2	2.4646	2.6513	2.5819	2.726	2.7232	3.9542	4.2899
3	2.3899	2.5393	2.5444	2.6513	2.6113	4.0288	4.2153
4	2.4272	2.95	2.8929	2.6886	2.7605	4.3645	4.3272
5	2.726	3.6595	3.5547	3.3234	3.3946	4.7749	4.4392
6	3.4355	4.0329	3.8462	3.9209	3.9542	4.9987	4.5138
7	3.7715	5.3772	4.3272	4.3317	4.3645	5.4837	4.8495
8	4.1076	4.369	4.5371	4.5557	4.5511	5.4091	5.5583
9	3.8836	4.1823	4.3184	4.145	4.178	5.3344	5.9602
10	3.8089	3.8558	3.8462	4.0703	3.8796	5.1852	5.9285
11	3.453	3.5812	3.6595	3.8462	3.6185	4.7003	5.7281
12	3.2487	3.3357	3.4728	3.3234	3.805	4.8868	5.2974
13	2.95	3.1229	3.0556	3.2487	4.2899	4.4019	5.094
14		2.9081	3.0247	2.9127	4.1407	4.2526	4.565
15		2.7656	2.9127	2.947	3.9542	4.0661	4.3449
16	2.5393		3.0247	2.8351	3.7304	4.2526	4.1576
17			3.0994	3.0216	4.178	4.2153	4.4063
18	4.1076	3.3114	3.3981	3.4693	4.4019	4.6257	4.9191
19	4.4437	4.4392	4.3317	4.663	5.5583	5.7821	6.1929
20	4.3317	4.481	4.481	4.5884	5.6329	5.9313	6.0864
21	4.3317	4.481	4.9291	4.5884	5.521	5.7075	6.0926
22	3.8836	3.8756	4.0703	4.2899	5.2598	5.0733	5.6094
23	3.4355	3.276	3.5848	3.6558	4.4765	4.7749	4.6682
24	2.838	3.0247	2.947	3.3234	3.1708	4.2899	4.4765
Max	4.4437	5.3772	4.9291	4.663	5.6329	5.9313	6.1929
Min	2.3899	2.5393	2.5444	2.6513	2.6113	3.9542	4.1576
Avg	3.3901	3.5884	3.5455	3.5818	4.0397	4.7733	5.0035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

BADLAPUR (W) S/DN.[755] BU 4755

Substation No/ Name :- 283065 / 22KV SONIVALI SW/STN

Feeder No / Name : 304 / Baravi

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	1.2145	1.0895	1.0185	1.1765	.8703	.8738
2	.6036	1.0648	1.0165	.8299	.9887	.6036	.7994
3	.6036	.9887	.9478	.7167	.8366	.6426	.724
4	.5975	.8383	.8316	.6413	.724	.6066	
5	.6413	.7621	.8316	.7167	.724	.6783	.7914
6	.7922	.7978	.9099	.7922	.7606	.7146	.7826
7	.9431	.9497	1.0648	.9431	1.0268	.9035	.9135
8	.9431	.9867	1.1718	.9808	1.0268	.9136	1.1397
9	1.3203	1.3283	1.3943	1.094	1.1765	.9516	1.1753
10	2.1146	1.8576	1.773	1.6237	1.773	1.7587	2.3885
11	2.6326	2.2034	1.6598	1.2865	1.4364	1.3649	1.7712
12	2.0685	1.5924	2.037	1.4757	1.4335	1.5668	2.4118
13	1.73	1.3887	1.2826	1.0594	1.4601	1.0669	1.2813
14	1.0573	1.1374	1.358	1.4378	.945	1.2361	1.1017
15	1.4349	1.5924	1.8484	1.737	1.5444	1.5828	
16	1.6615	1.6581	1.6975	1.6615	1.11	1.6179	1.1635
17	1.3594	1.6514	1.6598	1.4349	1.0552	.9516	1.3943
18	.9818	1.1397	.9808	.9818	.8002	1.2269	1.0584
19	1.2839	1.6352	1.5089	1.3594	1.331	1.8055	1.1753
20	1.4757	1.8615	1.4335	1.6237	1.4861	1.4056	
21	1.4378	1.3226	1.358	1.5104	1.0402	1.1431	1.0995
22	1.173	1.2157	1.1317	1.3243	1.0216	1.18	.9858
23	1.2145	1.4407	1.094	1.5104	1.142	1.0278	.8316
24	.6413	1.2904	1.1225	1.0562	1.1351	.9897	.9516
Max	2.6326	2.2034	2.037	1.737	1.773	1.8055	2.4118
Min	.5975	.7621	.8316	.6413	.724	.6036	.724
Avg	1.2215	1.3299	1.3001	1.2007	1.1314	1.1170	1.1816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283251 / GOVELI SWITCHING STATION

Feeder No / Name : 301 / Falegaon

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.7621	.7621	.9145	.9907	.8383
2	.6097	.6859	.6859	.9145	.8383	.9145	.7621
3	.6097	.6859	.6859	.8383	.8383	.8383	.7621
4	.6097	.6859	.6859	.8383	.7621	.7621	.7621
5	.7621	.8383	.9145	.9907	.7621	.7621	.7621
6	.9907	1.0669	1.0669	1.2955	.9907	.9907	1.1431
7	1.2955	1.5242	1.1431	1.5242	1.3717	1.448	1.2955
8	1.6766	1.6004	1.2955	1.5242	1.5242	1.6004	1.448
9	1.9052	1.5242	1.5242	1.448	1.448	1.6766	1.2955
10	1.6766	1.2193	1.5242	1.7528	1.5242	1.6004	1.1431
11	1.5242	1.1431	1.448	1.448	1.3717	1.5242	.9907
12	1.448	1.2955	1.3717	1.448	.9907	1.5242	.9145
13	1.0669	1.2193	1.1431	1.5242	.9907	1.3717	.7621
14	1.0669	.9907	.7621	1.2955	.8383	1.1431	.6097
15	1.0669	1.0669	.9907	1.2955	.9907	1.2193	.7621
16	1.0669	1.448	1.0669	1.3717	1.1431	1.2955	.8383
17	1.1431	1.5242	.7621	1.3717	1.1431	1.2193	.8383
18	1.2955	1.7528	1.3717	1.448	1.3717	1.1431	1.0669
19	1.448	1.5242	1.5242	1.5242	1.7528	1.5242	1.3717
20	1.6004	1.3717	1.5242	1.448	1.7528	1.6766	1.2955
21	1.448	1.5242	1.829	1.6766	1.6766	1.448	1.2193
22	1.0669	1.0669	1.2193	1.448	1.2955	1.1431	.9907
23	.8383	.8383	.9145	1.2193	1.1431	.9907	.8383
24	.6859	.7621	.9145	.7621	.9907	1.2193	.9907
Max	1.9052	1.7528	1.829	1.7528	1.7528	1.6766	1.448
Min	.6097	.6859	.6859	.7621	.7621	.7621	.6097
Avg	1.1495	1.1717	1.1304	1.2987	1.1844	1.2511	.9875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283251 / GOVELI SWITCHING STATION

Feeder No / Name : 302 / Goveli Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242	1.448	1.448	1.448	1.448	1.6004
2	1.448	1.448	1.448	1.448	1.3717	1.448	1.5242
3	1.3717	1.448	1.448	1.448	1.3717	1.448	1.5242
4	1.3717	1.448	1.448	1.448	1.3717	1.448	1.5242
5	1.5242	1.6004	1.6004	1.5242	1.5242	1.5242	1.6766
6	1.829	2.0576	1.9814	1.829	1.829	1.9052	1.829
7	2.5149	2.4387	2.4387	2.4387	2.4387	2.4387	2.4387
8	2.5911	2.5911	2.6673	2.5149	2.5911	2.6673	2.7435
9	2.4387	2.5149	2.5149	2.5911	2.5911	2.4387	2.5911
10	2.3624	2.2862	2.0576	2.21	2.2862	2.1338	2.5149
11	2.1338	2.1338	1.9814	2.1338	1.9814	2.0576	2.21
12	2.0576	1.9814	1.9052	2.0576	2.1338	2.0576	1.9052
13	1.6766	1.7528		1.829	1.9814	1.829	1.6766
14	1.5242	1.6004	1.7528	1.6004	1.6766	1.6766	1.6004
15	1.6004	1.6004	1.7528	1.7528	1.5242	1.7528	1.6004
16	1.7528	1.829	1.829	1.829	1.7528	1.7528	1.9052
17	2.0576	1.9814		2.1338	1.9814	1.9814	2.0576
18	2.1338	2.21	1.9814	2.21	2.1338	2.1338	2.1338
19	2.6673	2.6673	2.5911	2.7435	2.6673	2.6673	2.6673
20	2.4387	2.4387	2.2862	2.4387	2.3624	2.5149	2.5149
21	2.21	2.1338	2.21	2.21	2.1338	2.2862	2.21
22	1.9814	1.829	2.0576	1.9814	1.9052	2.0576	1.9814
23	1.7528	1.6004	1.6766	1.7528	1.6766	1.829	1.7528
24	1.5242	1.5242	1.448	1.5242	1.5242	1.5242	1.6766
Max	2.6673	2.6673	2.6673	2.7435	2.6673	2.6673	2.7435
Min	1.3717	1.448	1.448	1.448	1.3717	1.448	1.5242
Avg	1.9370	1.9433	1.9329	1.9624	1.9274	1.9592	1.9941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283251 / GOVELI SWITCHING STATION

Feeder No / Name : 303 / Manda Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.144	5.5251	5.1821	5.3346	5.6394	5.6394	5.868
2	4.9535	5.2965	5.0297	5.1059	5.4489	5.487	5.6394
3	4.8773	5.1059	4.9535	5.0297	5.3727	5.3346	5.5632
4	4.8011	4.9535	4.9535	5.1059	5.3727	5.3346	5.487
5	5.7918	5.6394	5.5632	5.6394	5.5251	5.6394	5.6394
6	6.4777	6.5539	6.3253	6.8587	6.7825	6.7063	6.2491
7	7.3922	7.5065	7.6208	7.5446	7.697	7.3541	6.9349
8	7.7351	7.9256	7.7732	7.7732	7.9256	8.0018	7.7732
9	7.5446	7.5446	7.0111	7.316	7.6208	7.7732	7.8494
10	7.0111	6.9349	6.7825	7.0111	7.0111	7.4684	8.0018
11	6.5539	6.5539	6.0966	6.592	6.4015	6.9349	7.3541
12	6.0966	5.9442	6.3253	6.1728	6.0966	6.7063	6.973
13	5.868	5.868	5.868	6.0585	6.0204	6.4015	6.7825
14	5.3346	5.3346	5.4108	5.6394	5.6394	5.868	6.3253
15	5.2202	5.1821	5.1821		5.3727	5.7156	6.1347
16	5.3346	5.3346	5.2584	5.5251	5.4108	5.5632	6.211
17	5.4108	5.487	5.4108	5.4489	5.4108	5.7918	6.211
18	6.0204	5.868	5.5632	6.2491	5.9061	6.4015	6.5539
19	8.1543	8.078	7.7732	8.0399	7.8494	8.3829	8.3448
20	8.078	8.2305	7.9256	8.3829	8.078	8.5353	8.4591
21	7.8494	7.9256	8.3067	8.1924	8.0018	8.0018	8.1543
22	7.4303	7.316	7.5446	7.6208	7.5446	7.7732	7.7732
23	6.5158	6.4015	6.6301	6.9349	6.7063	7.0111	7.0492
24	5.4489	5.7918	5.6394	5.7918	5.9442	5.9442	6.1728
Max	8.1543	8.2305	8.3067	8.3829	8.078	8.5353	8.4591
Min	4.8011	4.9535	4.9535	5.0297	5.3727	5.3346	5.487
Avg	6.2935	6.3459	6.2554	6.4942	6.4491	6.6571	6.8127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283251 / GOVELI SWITCHING STATION

Feeder No / Name : 304 / Khadwali Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.0669		1.1431	1.1431	1.1431	1.2193
2	.9145	.9907	1.1431	1.1431	1.0669	1.0669	1.2193
3	.9145	.9907	1.1431	1.1431	.9907	1.0669	1.2193
4	.9145	.9907	1.1431	1.1431	.9907	1.0669	1.2193
5	1.0669	1.1431	1.2955	1.2193	1.1431	1.1431	1.2955
6	1.448	1.448	1.6004	1.5242	1.448	1.6766	1.6004
7	1.829	1.829	1.9814	1.829	1.9814	2.0576	1.9052
8	1.9814	1.9814	1.9814	1.9052	1.9052	2.0576	2.0576
9	1.7528	1.829	1.6766	1.6766	1.6766	1.6766	1.829
10	1.5242	1.5242	1.5242	1.5242	1.6004	1.6004	1.6766
11	1.2955	1.3717	1.448	1.2193	1.448	1.5242	1.2193
12	1.1431	1.3717	1.3717	1.2955	1.3717	1.5242	1.5242
13	1.2955	1.2955	1.2193	1.2193	1.2955	1.3717	1.3717
14	1.1431	1.2193	1.1431	1.1431	1.1431	1.2955	1.2193
15	1.1431	1.0669	1.1431	1.1431	1.1431	1.2193	1.1431
16	1.2193	1.2193	1.2193	1.2193	1.2193	1.2955	1.2955
17	1.2955	1.2193	1.2193	1.2193	1.2955	1.3717	1.448
18	1.6004	1.5242	1.5242	1.5242	1.5242	1.6766	1.6004
19	2.0576	2.0576	2.0576	2.21	2.1338	2.0576	2.0576
20	1.9052	1.9814	2.0576	2.0576	1.9814	2.0576	2.0576
21	1.6766	1.829	1.9814	1.829	1.829	1.6766	1.7528
22	1.5242	1.6004	1.6004	1.6004	1.5242	1.6766	1.6004
23	1.2193	1.2955	1.3717	1.3717	1.2955	1.448	1.3717
24	.9907	1.0669	1.2193	1.2193	1.1431	1.2193	1.2955
Max	2.0576	2.0576	2.0576	2.21	2.1338	2.0576	2.0576
Min	.9145	.9907	1.1431	1.1431	.9907	1.0669	1.1431
Avg	1.3686	1.4130	1.4811	1.4384	1.4289	1.4988	1.5083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283251 / GOVELI SWITCHING STATION

Feeder No / Name : 305 / KDMC

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905	.1905	.1905	.1905
3	.1905	.1905	.1905	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	.1905
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	.1905	.1905	.1905
12	.1905	.1905	.1905	.1905	.1905	.1905	.1905
13	.1905	.1905	.1905	.1905	.1905	.1905	.1905
14	.1905	.1905	.1905	.1905	.1905	.1905	.1905
15	.1905	.1905	.1905	.1905	.1905	.1905	
16	.1905	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.1905
18	.1905	.1905	.1905	.1905	.1905	.1905	.1905
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.1905	.1905	.1905	.1905	.1905	.1905	.1905
21	.1905	.1905	.1905	.1905	.1905	.1905	.1905
22	.1905	.1905	.1905	.1905	.1905	.1905	.1905
23	.1905	.1905	.1905	.1905	.1905	.1905	.1905
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.1905	.1905	.1905	.1905	.1905	.1905	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283252 / Sarwali Swtiching Staion KON

Feeder No / Name : 301 / Pimpalghar SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.724	.7621	.6859	.7621	.7621	.8383
2	.6859	.7621	.7621	.724	.8002	.8002	.8002
3	.6478	.8383	.724	.7621	.8002	.8002	.8002
4	.6859	.8764	.724	.8002	.7621		.8002
5	.6478	.9145	.7621	.8383	.7621		.8002
6	.9526	1.0669	.9907	.9145	1.0669		.8383
7	1.0669	1.2193	1.105	.9526	1.1812		1.0669
8	.9526	1.1812	1.2193	1.0288	.9526		
9	.8002	.9526	1.0288	.9907	.7621	.5716	1.1431
10	.8764	.8383	.9145	.8002	.8764	.724	.8002
11	.8002	.8383	.9145	.8383	.8383		.8383
12	.8002	.7621	.8002	.7621	.724		.8383
13	.8002	.6859	.6859	.6859	.6859		.6859
14	.6097	.6859	.6859	.6859	.6859		.6097
15	.724	.6859	.724	.724	.724	.8383	.6859
16	.724	.6859	.7621	.7621	.724	.8002	.6478
17	.724	.8002	.8383	.7621	.8002	.9526	.724
18	.8383	.9526	4.7249	.9526	1.0288	.9907	.724
19	1.1812	1.1431	1.1812	1.1812	1.1812	1.0669	1.0288
20		1.1431	1.105	1.1431	1.105	1.105	1.105
21	.9907	1.0288	1.105	1.0669	.9907	.9907	.9145
22	.8764	.8764	.9526	1.0288	.9145	.8764	.8764
23	.8383	.8383	.8764	.8764	.8383	.8383	.8002
24	.6859	.7621	.7621		.7621	.8002	.8002
Max	1.1812	1.2193	4.7249	1.1812	1.1812	1.105	1.1431
Min	.6097	.6859	.6859	.6859	.6859	.5716	.6097
Avg	.8085	.8859	1.0463	.8681	.8637	.8612	.8333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283252 / Sarwali Swtiching Staion KON

Feeder No / Name : 302 / New Kon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	1.1431	1.1812	1.2574	1.2193	1.3336
2	1.1431	.9907	1.1431	1.1812	1.2193	1.1812	1.3336
3	1.105	1.0669	1.105	1.2193	1.2193	1.105	1.2574
4	1.1431	1.1431	1.105	1.2574	1.1812	1.0288	1.2193
5	1.105	1.1812	1.105	1.2955	1.1431	.9907	1.1812
6	1.105	1.2193	1.2574	1.3336	1.2193	1.0288	1.1431
7	1.1812	1.2193	1.3336	1.3336			1.2955
8	1.4098	1.5242	1.4861	1.4861	1.2955	1.4861	
9	1.5623	1.5242	1.4861	1.448	1.1812		1.6385
10	1.4861	1.6004	1.6385	1.3717	1.5242	1.7528	1.5623
11	1.5242	1.6766	1.6004	1.2574	1.6385	1.8671	1.4098
12	1.5623	1.5242		1.5242	1.5623	1.7147	1.5242
13	1.3336	1.4861	1.3336	1.2574	1.448	1.6004	1.3717
14	1.3717	1.448	1.3336	1.2955	1.3717	1.448	1.4098
15	1.448	1.4098	1.448	1.3717	1.2574	1.5242	1.3336
16	1.3717	1.3717	1.4861	1.3717	1.2193	1.5623	1.2955
17	1.3717	1.2574	1.5242	1.448	1.2574	1.6766	1.2193
18	1.4861	1.3717	1.5242	1.7909	1.4861	1.6004	1.105
19	1.7147	1.5623	1.448	1.6004	1.6766	1.7528	1.4098
20	1.448	1.4861	1.4861	1.5623	1.6004	1.6004	1.448
21	1.3717	1.4098	1.5623	1.5242	1.448	1.448	1.5623
22	1.448	1.3717	1.5242	1.448	1.4861	1.448	1.4098
23	1.3717	1.2955	1.4861	1.4098	1.4098	1.4098	1.448
24	1.1812	1.2193	1.1812	1.1431	1.2574	1.2574	1.4098
Max	1.7147	1.6766	1.6385	1.7909	1.6766	1.8671	1.6385
Min	1.105	.9907	1.105	1.1431	1.1431	.9907	1.105
Avg	1.3495	1.3527	1.3800	1.3797	1.3635	1.4410	1.3618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

KALYAN CC O&M S/DN[539] BU 4073

Substation No/ Name :- 283252 / Sarwali Swtiching Staion KON

Feeder No / Name : 304 / PIMPLAS SHEDDABLE URBAN
Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.2193	1.2193	1.2193	1.2193	1.2193	1.3336
2	1.105	1.1431	1.2193	1.105	1.2193	1.1812	1.3336
3	1.0669	1.105	1.1812	1.0669	1.1812	1.1431	1.2955
4	1.0288	1.2193	1.1431	1.1431	1.1431	1.1431	1.2955
5	1.0669	1.3336	1.2193	1.3336	1.1431	.8002	1.2574
6	1.2574	1.448	1.5242	1.5242	1.448	1.0288	1.3336
7	1.6004	1.6004	1.6385	1.6766	1.6385		1.7147
8	1.829	1.7528	1.7909	1.3336	1.6766	1.6766	
9	1.6385	1.7528	1.7528	1.6004	1.6385	1.7528	1.6004
10		1.9433	1.9052	1.6004	1.5623	1.829	1.3717
11	1.9433	1.9052	2.0576	1.6385	1.6385	1.9052	1.2955
12	1.8671	1.829	1.9052	1.7528	1.6004	1.7147	1.2574
13	1.4098	1.6385	1.4861	1.2955	1.2574	1.5242	.9907
14	1.6766	1.6766	1.6385	1.7528	1.6004	1.6004	1.0288
15	1.6766	1.7528	1.9814	1.8671	1.7909	1.7147	.9145
16	1.7909	1.8671	1.9433	1.8671	1.7528	1.9433	1.0669
17	1.9433	2.0195	1.9814	1.829	1.5623	1.9814	1.1431
18	1.9814	1.9052	1.9433	1.9052	1.8671	2.0195	.8764
19	2.0957	2.0195	2.0957	1.7147	1.9814	2.1338	1.5242
20	1.829	1.7909	1.6385	1.7147	1.829	1.9814	1.448
21		1.7147	1.8671		1.6385	1.8671	1.2574
22	1.4861	1.5623	1.6766	1.6385	1.448	1.6385	
23	1.4861		1.3717	1.2955	1.2955	1.5242	.9907
24	1.105	1.3336	1.2955	1.2574	1.2193	1.2193	1.3717
Max	2.0957	2.0195	2.0957	1.9052	1.9814	2.1338	1.7147
Min	1.0288	1.105	1.1431	1.0669	1.1431	.8002	.8764
Avg	1.5449	1.6318	1.6448	1.5275	1.5146	1.5888	1.2592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283255 / kudawali switching station

Feeder No / Name : 301 / 22Kv Pawale Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1494	.1509	.0754	.1509	.1132
2	.1132	.1509	.1494	.1132	.0754	.1509	.1509
3	.1509	.1509	.1494	.1132	.0754	.1509	.1494
4	.1509	.1509	.1509	.1132	.1509	.1509	.1509
5	.1509	.1886	.1886	.1509	.1509	.1886	.1848
6	.1886	.2263	.2263	.1867	.1886	.2263	.2218
7	.1886	.3018	.2614	.2614	.2641	.2641	.2263
8	.1886	.2641	.2641	.2987	.2263	.2641	.3734
9	.2263	.3395	.3018	.2614	.1509	.2641	.3772
10	.3018	.2614	.3018	.3734	.1509	.3361	.3018
11	.2263	.1886	.2641	.2614		.2263	.2263
12	.1886	.1867		.2241		.2641	.1886
13	.1132	.1509	.1509	.1132	.1509	.1494	.1509
14	.1132	.1494	.2263	.0747	.1509	.1494	.1509
15	.1509	.2614	.2263	.0754	.1132	.1867	.1886
16	.1509	.1867	.1886	.1509	.1509	.2241	.1886
17	.1509	.2614	.1886	.2614	.1132	.1132	.1886
18	.1867	.2641	.2263	.2241	.1132		.2263
19	.2987	.2614	.2641	.2614	.2263	.3018	.3018
20	.2987	.2614	.2641	.2614	.2263	.2641	.3018
21	.2614	.2241	.2641	.2614	.2263	.2263	.2641
22	.2614	.1886	.2263	.2614	.2263	.1886	.2263
23	.1867	.1886	.1509	.1886	.1886	.1867	.1886
24	.1509	.1886	.1494	.1509	.0754	.1886	.1494
Max	.3018	.3395	.3018	.3734	.2641	.3361	.3772
Min	.1132	.1494	.1494	.0747	.0754	.1132	.1132
Avg	.1896	.2145	.2145	.1997	.1577	.2094	.2163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283255 / kudawali switching station

Feeder No / Name : 302 / 22KV Tiger Steel

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4025	2.3011	2.5393	2.6406	2.1502	.8299	2.2634
2	2.5873	2.3011	2.6783	2.8669	2.0748	.7545	2.6513
3	2.2916	2.3011	2.8006	2.8669	2.037	.7922	2.8006
4	2.5503	2.7161	2.9127	2.9047	2.1502	.7922	2.838
5	2.4025	2.7161	3.0994	2.9127	2.2634	.8299	3.0556
6	2.4394	2.7161	3.062		2.2634	.7545	3.0308
7	2.3525	2.9047	3.0556	2.3899	2.452	.7545	3.0678
8	1.307	1.4712	1.5466	1.3817	1.2071	.8299	1.5089
9	2.6612	2.5274	2.7633	1.6804	.8676	1.4335	2.4143
10	2.452	2.3899	2.7435	1.7924	.8299	2.3525	3.0361
11	2.6783	2.4272	2.7435	2.3525		2.0485	2.7149
12	2.037	2.3011	2.6703	2.1658		2.8669	2.2455
13	1.094	1.9418	1.3676	1.3203		1.2071	1.012
14	2.6406	2.8487	1.1088	1.7551		2.1658	2.6882
15	2.5652	3.062	1.9589	2.3388		2.7538	2.1628
16	2.6406	2.8006	2.4874	2.3388		2.6139	2.6425
17	2.5274	2.2177	2.4615	2.726		2.6029	2.8654
18	2.9127	2.5652	2.7069	2.5019		3.062	2.9012
19	2.8006	2.8006	3.0045	2.726		2.9424	3.1493
20	1.6804	1.531	1.6095	1.6804		1.5524	2.7435
21	2.3525	2.838		2.3525	.679	2.2779	2.0485
22	1.9418	2.7538		1.8298	.679	2.6886	2.8166
23	1.9044	2.5274	2.3655	2.1879		2.3152	2.5339
24	2.3285	2.3388	2.3899	2.5503	2.2634	.7545	2.1285
Max	2.9127	3.062	3.0994	2.9127	2.452	3.062	3.1493
Min	1.094	1.4712	1.1088	1.3203	.679	.7545	1.012
Avg	2.3146	2.4708	2.4580	2.2723	1.6859	1.7490	2.5550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283255 / kudawali switching station

Feeder No / Name : 303 / 22KV Shirgaon Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3395	.2987	.2641	.3395	.3772	.2987
2	.2263	.3395	.2987	.2641	.3395	.3395	.3018
3	.2263	.3395	.3018	.2641	.3395	.3772	.3018
4	.2641	.3395	.3018	.3018	.3395	.3772	.2641
5	.3772	.3395	.4527	.3361	.3772	.415	.3395
6	.4527	.3772	.4904		.415	.4527	.4527
7	.4904	.5281	.5228	.5228	.4904	.5281	.5281
8	.4904	.4904	.4854	.4854	.5281	.5281	.5281
9	.3395		.4108	.4108	.4527	.4527	.415
10	.3772		.415	.2987	.415	.415	.4527
11	.3018	.3772	.3772			.3018	.415
12	.3018	.3734	.3018	.2614		.3361	.3395
13	.3018	.3018	.2641	.1886	.2641	.3018	.2641
14	.2263	.2614	.1886	.2987	.2263	.2614	.3018
15	.3395	.3018	.1886	.3395	.3395	.2218	.1886
16	.3772	.2987	.2263		.3772	.3361	.2641
17	.3772	.3734	.2263	.3734	.415	.3326	.3772
18	.4854	.5601	.3395	.5228	.5281	.3734	.415
19	.6722	.6348	.3018	.6722	.679	.6036	.6036
20	.5975	.5601	.3395	.6348	.6036	.5601	.5658
21	.5601	.4904		.5601	.5658	.5228	.4904
22	.4854	.415		.4481	.4904	.415	.415
23	.3734	.3361	.3395	.3772	.7545	.3395	.3018
24	.3018	.3395	.2587	.3018	.3395	.3772	.3772
Max	.6722	.6348	.5228	.6722	.7545	.6036	.6036
Min	.2263	.2614	.1886	.1886	.2263	.2218	.1886
Avg	.3837	.3962	.3332	.3870	.4372	.3977	.3834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283255 / kudawali switching station

Feeder No / Name : 304 / 22KV Bhagwandas Feeder
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893	1.6221	1.6598	1.5466	1.5844	.9808	1.5089
2	1.4784	1.5466	1.5684	1.5466	1.5844	.9431	1.5466
3	1.5684	1.5466	1.6221	1.4712	1.5844	.9808	1.5466
4	1.6057	1.5844	1.5466	1.4712	1.5844	.9431	1.5844
5	1.5893	1.5089	1.4937	1.4712	1.5844	.9808	1.6221
6	1.5154	1.4712	1.4563	1.531	1.5844	1.0562	1.5466
7	1.531	1.5844	1.419	1.4563	1.358	.9808	1.5089
8	1.3676	1.6598	1.4712	1.531	1.358	1.3957	1.773
9	1.5524	2.2257	1.7924	1.7177	1.3203	1.8107	1.9993
10	1.8107	2.3011	2.0698	2.3899	1.0562	1.9044	2.3655
11	2.0748	2.6139	2.1068	2.3525		2.4272	2.3045
12	2.3011	2.95	2.0485	2.3899		2.6513	2.1033
13	1.6975	2.0911	2.0328	2.1125	1.0562	1.9044	1.7364
14	2.6029	2.2779	1.9589	2.2032	1.0562	2.1658	2.3388
15	1.9239	2.4272	2.4394	2.5652	1.0562	2.3765	2.0633
16	2.5274	2.2779	1.922	1.4335	1.094	2.4394	1.9909
17	2.2634	2.2779	2.0328	2.4272	1.0562	2.1437	2.0271
18	2.0538	1.9993	1.922	1.8671	1.0562	2.1879	1.9185
19	1.643	1.6057	1.7002	1.6057	1.0562	1.8107	1.4998
20	1.8671	1.6057	1.6263	1.531	1.0185	1.6804	1.5524
21	1.6804	1.7924		1.7177	1.0562	1.7924	1.6095
22	1.7924	1.7177	1.7372	1.6804	1.094	1.7551	1.7372
23	1.643	1.6975	1.6632	1.8861	1.0185	1.6221	1.5524
24	1.8107	1.8484	1.6057	1.5893	1.6221	.9808	1.6975
Max	2.6029	2.95	2.4394	2.5652	1.6221	2.6513	2.3655
Min	1.3676	1.4712	1.419	1.4335	1.0185	.9431	1.4998
Avg	1.8121	1.9264	1.7780	1.8123	1.2654	1.6631	1.7972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283256 / mhasa switching station

Feeder No / Name : 301 / 22 KV Agashi feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283256 / mhasa switching station

Feeder No / Name : 302 / 22KV Narivali feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283256 / mhasa switching station

Feeder No / Name : 303 / 22KV Patgaon feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.6413
Max	.6413
Min	.6413
Avg	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283256 / mhasa switching station

Feeder No / Name : 304 / 22KV Sasne Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.3395
Max	.3395
Min	.3395
Avg	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283257 / 22/22kV UMROLI SWITCHING

STATI

Feeder No / Name : 302 / 22KV DHASAI FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9054	1.0185	.9054	.8676	1.1317	.9808
2	.9054	.9054	.9431	.9054	.8676	1.0562	.9431
3	.9808	.9054	1.094	.9431	.8676	.9431	.9054
4	1.0185	.9054	1.2071	.9808	.8676	.9054	.8676
5	1.0562	.9808	1.2826	1.0562	.9054	.9431	1.0562
6	1.3203	1.1317	1.3203	1.1694	1.0562	1.2826	1.2826
7	1.7353	1.6598	1.6598	1.7353	1.7353	1.6975	1.6221
8	1.7353	1.6598	1.6598	1.6598	1.6975	1.6975	1.6975
9	1.5466	1.3957	1.3203	1.3957	1.5466	1.5466	1.2826
10	1.2826	1.2449	1.1694	1.2071	1.2071	1.358	1.094
11	.9431	1.0562	.9808	1.094			.9808
12	.9054	.9431	.9808	.9431		1.0562	.8676
13	.8299	.8299	.9054	.8676		.9808	.8676
14	.8299	.7922	.8676	.8299		.9808	.8676
15	.9054	.7922	.8676	.9054		1.0562	.6413
16	.9808	.9808	1.0185	.4527	.6036	1.1694	1.094
17	1.1317	1.0562	1.2071	1.2826	.8299	1.2071	1.2449
18	1.358	1.358	1.2449	1.3957	1.6975	1.4712	1.4335
19	1.8484	1.8484	1.9239	1.9239	2.0748	1.8484	1.8484
20	1.6221	1.7353	1.7353	1.7353	1.8861	1.7353	1.7353
21	1.5089	1.4335	1.6221	1.5466	1.5844	1.5844	1.5466
22	1.2826	1.3203	1.3957	1.358	1.3203	1.4335	1.2449
23	1.2071	1.094	1.094	1.1317	1.2449	1.094	1.1317
24		.9808	1.0562		.9054	1.2071	1.0185
Max	1.8484	1.8484	1.9239	1.9239	2.0748	1.8484	1.8484
Min	.8299	.7922	.8676	.4527	.6036	.9054	.6413
Avg	1.2121	1.1631	1.2323	1.1924	1.2508	1.2777	1.1773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283257 / 22/22kV UMROLI SWITCHING

STATI

Feeder No / Name : 303 / 22KV TOKAWADE FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4527	.415	.415	.415	.4904	.415
2	.3772	.415	.415	.415	.415	.4527	.3772
3	.3772	.415	.4527	.415	.415	.415	.415
4	.415	.415	.4904	.4527	.415	.3772	.415
5	.4527	.4527	.5281	.4527	.4527	.415	.4527
6	.5281	.6036	.5658	.5281	.5281	.5658	.5658
7	.7167	.7545	.7167	.8299	.7922	.7545	.7167
8	.7545	.8299	.7922	.7167	.7922	.8299	.7922
9	.7545	.679	.6413	.6036	.6413	.6413	.5281
10	.4904	.4527	.5281	.5281	.4904	.5281	.4527
11	.415	.4527	.415	.4527	.4527		.4527
12	.3395	.3772	.3018	.3772	.3772	.4527	.4527
13	.3395	.415	.3395	.3772	.415	.3772	.4527
14	.3395	.3772	.3395	.3772	.3772	.415	.3772
15	.3772	.3772	.3395	.415	.3772		.415
16	.3772	.3395	.415	.4527	.4527	.415	.3772
17	.4527	.415	.4904	.4904	.415	.4904	.4527
18	.6036	.5281	.3772	.5658	.5281	.6036	.6036
19	.7922	.7545	.7922	.7922	.7922	.7545	.8299
20	.7545	.679	.7545	.7545	.7545	.7167	.7922
21	.679	.679	.679	.679	.679	.679	.7167
22	.6036	.6036	.5658	.6036	.6036	.6036	.6036
23	.5281	.4904	.4527	.5281	.5281	.4904	.5281
24	.415	.4527	.4527	.415	.4527	.5281	.4527
Max	.7922	.8299	.7922	.8299	.7922	.8299	.8299
Min	.3395	.3395	.3018	.3772	.3772	.3772	.3772
Avg	.5124	.5171	.5108	.5266	.5234	.5453	.5266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 283257 / 22/22kV UMROLI SWITCHING

STATI

Feeder No / Name : 304 / 22 KV NEHYADI INCOMER

SHEDDABLE RURAL

Feeder KV- 22 / INCOMING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8676	.8676	.679	.7922	.9054	.7922
2	.7922	.8299	.8299	.6413	.7545	.7545	.7545
3	.7545	.8299	.8676	.6413	.7545	.7167	.7167
4	.7922	.8299	.9054	.679	.7922	.679	.7167
5	.8299	.8676	.9808	.7167	.7922	.7545	.7922
6	.9808	.9808	1.0562	.7545	.823	.9431	.9431
7	1.1694	1.094	1.2449	.9808	1.2071	1.1694	1.094
8	1.1694	1.1317	1.1694	.8676	1.1317	1.1317	1.1317
9	1.0185	.9808	1.0185	.4527	.9808	.9808	.8676
10	.9431	.7922	.8676	.6413	.8676	.6036	.7545
11	.7922	.7167	.7922	.6413	.7167		.7545
12	.7167	.7167	.7545	.6036	.7167	.7545	.7167
13	.6413	.679	.7545	.679		.7545	.6413
14	.6413	.6413	.679	.679		.679	.6413
15	.6413	.6413	.6036	.7545	.5658		.6413
16	.5281	.7545		.7545	.7545	.7545	.7922
17	.679	.8299	.7922	.7922	.7922	.8676	.679
18	.9054	.8676	.8299	.9054	.8299	.9054	.9808
19	1.3957	1.358	1.3203	1.358	1.2826	1.2449	1.2826
20	1.358	1.2826	1.358	.7545	1.358	1.3203	1.3203
21	1.2449	1.3203	1.2826	1.2826	1.2449	1.2071	1.2826
22	1.094	1.2071	.9431	1.2071	1.094	1.1317	1.0562
23	.9808	1.0185	.7545	.9808	1.0185	.9054	1.0185
24	.9054	.9054	.9054	.679	.7922	.9808	.8299
Max	1.3957	1.358	1.358	1.358	1.358	1.3203	1.3203
Min	.5281	.6413	.6036	.4527	.5658	.6036	.6413
Avg	.9085	.9226	.9382	.7969	.9119	.9157	.8834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 301 / SARALGAON

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	2.9424
Max	2.9424
Min	2.9424
Avg	2.9424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 302 / MIDC-1

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	4.9794
Max	4.9794
Min	4.9794
Avg	4.9794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 303 / MIDC II

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18
HR	Load (MW)	Load (MW)
24	4.3759	3.8477
Max	4.3759	3.8477
Min	4.3759	3.8477
Avg	4.3759	3.8477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 304 / MURBAD TOWN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	3.6214
Max	3.6214
Min	3.6214
Avg	3.6214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 305 / kudawali incomer

Feeder KV- 22 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	4.3381
Max	4.3381
Min	4.3381
Avg	4.3381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 306 / HINDUSTAN GAS
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.8292
Max	2.8292
Min	2.8292
Avg	2.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 307 / UMROLI INCOMER

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.9424
Max	2.9424
Min	2.9424
Avg	2.9424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 308 / LOYAD STEEL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.1509
Max	.1509
Min	.1509
Avg	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 309 / Balbir Alloys

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	7.8087
Max	7.8087
Min	7.8087
Avg	7.8087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150] BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 310 / MHASA INCOMER

Feeder KV- 22 / INCOMING

SHEDDABLE RURAL

DATE	01-FEB-18
HR	Load (MW)
24	1.773
Max	1.773
Min	1.773
Avg	1.773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

MURBAD[150]

BU 4456

Substation No/ Name :- 286008 / 100/22 KV MURBAD

Feeder No / Name : 311 / 22 KV KISHOR FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	1.1317
Max	1.1317
Min	1.1317
Avg	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028353 / 22/22 KV SHAHAPUR S/S

Feeder No / Name : 302 / ATGAON

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2779	2.3011	2.0485	2.2862	2.3011	1.9022	2.4272
2	2.2779	2.3011	1.9387	2.3624	2.452	1.829	2.4646
3	2.2405	2.452	1.9387	2.4768	2.4143	1.829	2.4272
4	2.2405	2.5019	1.9753	2.5911	2.5274	1.9022	2.4646
5	2.2405	2.7538	2.268	2.6673	2.7538	2.1948	2.5393
6	2.5019	2.9424	2.7435	2.7054	3.0556	2.7435	2.6139
7	3.0994	3.3196	3.1459	2.8578	3.131	2.7435	3.0994
8	3.2114	3.2065		2.9721	2.9047	3.1824	3.5475
9	3.2114	2.9874		3.1245	2.3011		3.546
10	3.0556	2.6703	2.9721	3.2819	2.037	3.1367	3.0178
11	2.6612	2.5606	1.7528	2.8753		2.7633	2.8292
12	2.5274	2.7435	2.8578	2.9801	2.0119	2.7633	2.6406
13	2.2257	2.1948		2.3525			1.9239
14	2.6783	2.3045	2.4387	2.4143		2.3152	2.3899
15	2.4143	2.3411	2.5911	2.452		2.3525	2.6029
16	2.3765	2.3909	2.4387	2.4143		2.8006	2.5274
17	2.7915	2.4874	2.553	2.5652	2.0119	2.9874	2.6406
18	2.9801	2.7435	2.8959	2.9424	2.268	3.2114	2.9424
19	3.6591	3.219	3.658	3.6969	2.8292	3.9582	3.6214
20	3.546	3.4019	3.4675	3.3196	2.9995	3.4355	3.2114
21	3.0556	2.7435	3.2388	1.9239	2.7435	3.4355	2.8292
22	2.6406	2.6337	2.8578	2.4143	2.4874	2.8292	2.7161
23	2.4143	2.3411	2.3243	2.7915	2.0485	2.6139	2.7538
24	2.1658	2.452	2.1948		2.3765	2.0119	2.4272
Max	3.6591	3.4019	3.658	3.6969	3.131	3.9582	3.6214
Min	2.1658	2.1948	1.7528	1.9239	2.0119	1.829	1.9239
Avg	2.6872	2.6664	2.5857	2.7160	2.5081	2.6791	2.7585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028353 / 22/22 KV SHAHAPUR S/S

Feeder No / Name : 304 / Dhasai Shenva Feeder
Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5154	1.3443	1.4937	1.643	1.6057
2	1.4784	1.3817	1.419	1.6804	
3	1.5154	1.3676	1.419	1.848	
4	1.5154		1.4563	1.9418	
5	1.5154	2.0911	1.9418	2.4272	
6	1.848	2.4025	2.3525	2.6886	
7	2.809	2.838	2.7721	2.8006	
8	2.6981	2.6139	2.7721	2.726	
9	2.3285	1.9791	2.4272	2.4764	
10	2.1807	1.9418	2.0911	2.1285	
11	2.0538	1.8671	1.7002	2.0538	
12	1.9791	1.9044	1.8111	1.9791	
13	1.7177	1.8671	1.643	1.7002	
14		1.6057	1.6057	1.7177	
15		1.8671	1.643	1.7551	
16	1.4563	1.8671	1.643	1.7924	
17	1.3443	2.2405	2.0538	1.6804	
18	2.0165	2.7721	2.3525	2.2779	
19	2.9874	3.1047	3.3265	3.2114	
20		2.9569	3.1741	2.8753	
21	2.4646	2.6513	2.7351	2.6513	
22	1.9791	2.2405	2.3152	2.1285	
23	1.7177	1.8298	1.9044	1.8671	
24	1.5154	1.531	1.643	1.643	1.531
Max	2.9874	3.1047	3.3265	3.2114	1.6057
Min	1.3443	1.3443	1.419	1.643	1.531
Avg	1.9351	2.0985	2.0706	2.1539	1.5684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028353 / 22/22 KV SHAHAPUR S/S

Feeder No / Name : 305 / ASANGAON

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.9774	.9877	1.1431	.9774	.9877	1.0608
2	.8779	.9412	.9867	1.2193	.9774	.9145	1.0242
3	.9145	1.0498	.9145	1.2574	1.1222	.9145	1.0608
4	.8779	1.1946	.9511	1.3336	1.1946	.9877	.9877
5	.9145	1.4118	1.0674	1.4098	1.3394	.9877	1.0608
6	1.0242	1.4842	1.39	1.448	1.4118	1.2437	1.0608
7	1.6095	1.5927	1.7558	1.6004	1.5203	1.6827	
8	1.6827	1.7375		1.6766	1.5927		1.6827
9	1.3535	1.3756		1.4098	1.267	1.39	1.3756
10	1.267	1.2071	1.2955	1.1584	1.1584	1.134	1.1222
11	1.0498	1.0242	1.0669	.9412		1.134	1.1222
12	.9412	.9877		.9774	1.0974		1.1584
13	1.0136	.9877		1.0498			1.0498
14	.905	.9202		1.0498		1.0242	1.0136
15	.9774	.9877		.9774		1.0608	1.0136
16	.9774	.9214	1.3717	.9774		1.0456	1.0136
17	.9774	.9877	1.3336	1.0136	1.419	1.1576	1.0974
18	1.1584	1.0608	1.3336	1.1584	1.4632	1.1706	1.1584
19	1.4842	1.2803	1.7147	1.5203	1.6095	1.5364	1.448
20	1.448	1.4998	1.6004	1.4842	1.5729	1.4632	1.4118
21	1.3756	1.4355	1.5242	1.4118	1.4632	1.3535	1.267
22	1.2308	1.3169	1.3717	1.267	1.4266	1.3169	1.3032
23	1.1222	1.0974	1.1431	1.1222	1.2071	1.1706	1.1584
24	.9511	.9774	1.0608		1.0498	1.0974	1.0608
Max	1.6827	1.7375	1.7558	1.6766	1.6095	1.6827	1.6827
Min	.8779	.9202	.9145	.9412	.9774	.9145	.9877
Avg	1.1255	1.1857	1.2705	1.2438	1.3089	1.1797	1.1614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 301 / Incommmer feeder Khardi

SHEDDABLE RURAL

Express Feeder KV- 22 / INCOMING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2411	1.3203	1.1203	1.2035	1.2826	1.1949	1.2826
2	1.2411	1.4335	1.1203	1.2035	1.3203	1.1576	1.2449
3	1.2411	1.3203	1.0829	1.201	1.3957	1.0829	1.3203
4	1.2411	1.358	1.0829	1.201	1.358	1.0829	1.2826
5	1.28	1.3957	1.1203	1.201	1.2826	1.1576	1.3957
6	1.3943	1.5466	1.307	1.3887	1.358	1.307	1.358
7	1.4712	1.7353	1.531	1.5388	1.3203	1.6057	1.4335
8	1.5074	1.4712		1.3887	1.3957	1.6598	1.4335
9	1.358	1.2071	1.2826	1.2761	1.1576	1.4712	1.3203
10	1.2826	1.4563	1.2826	1.3136	1.0456	1.5089	1.1949
11	1.3203	1.3443	1.2826	1.3512	1.2323	1.3957	1.0829
12	1.3203	1.1949	1.358	1.2761		1.3957	1.0456
13	1.1694	1.0456	1.094	1.0884		1.2071	.8589
14	1.0185	1.0082	.9808	1.1317		1.2826	.8962
15	1.1694	.9709	1.0884	1.1694		1.3203	.8962
16	1.1694	1.0456	1.0134	1.1317	.5228	1.4335	.9709
17	1.2449	1.0082	1.0509	1.094	.8962	1.4712	.9335
18	1.2449	1.1576	1.3136	1.1317	1.3817	1.358	1.0082
19	1.4335	1.6804	1.4638	1.4712	1.8671	1.5844	1.6057
20	1.5466	1.6804	1.689	1.6598	1.8298	1.6598	1.6057
21	1.4335	1.4937	1.6139	1.773	1.5684	1.6221	1.531
22	1.4335	1.3443	1.5013	1.4335	1.419	1.4335	1.3817
23	1.5089	1.1949	1.3539	1.2826	1.307	1.358	1.2696
24	1.2398	1.5466	1.1576	1.2035	1.3957	1.2323	1.3957
Max	1.5466	1.7353	1.689	1.773	1.8671	1.6598	1.6057
Min	1.0185	.9709	.9808	1.0884	.5228	1.0829	.8589
Avg	1.3130	1.3317	1.2561	1.2964	1.3168	1.3743	1.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 302 / Back Feed Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4463	.4527	.4066	.4099	.4527	.4066	.4527
2	.4463	.4904	.4066	.4099	.4527	.4066	.415
3	.4463	.4527	.3696	.4091	.4904	.3696	.415
4	.4463	.4527	.3696	.4091	.4527	.3696	.4527
5	.4835	.4904	.3696	.4091	.4527	.4066	.4904
6	.4835	.5281	.4435	.4463	.415	.4435	.4527
7	.5207	.5658	.5175	.5207	.4904	.5175	.4904
8	.4835	.4904	.5281	.484	.4527	.5658	.4904
9	.4527	.415	.4527	.4463	.4066	.4527	.4527
10	.415	.4066	.415	.3727	.4066	.415	.4066
11	.3772	.4066	.3772	.3719	.4066	.415	.4066
12	.3395	.4066	.3772	.3347		.3395	.4066
13	.3395	.3696	.3395	.3719		.3395	.3982
14	.3018	.3696	.3395	.3395		.3772	.3696
15	.3395	.2957	.3719	.3395		.3395	.3326
16	.3395	.3696	.3347	.3772		.3772	.3361
17	.415	.3696	.3719	.3395		.415	.3326
18	.4527	.4481	.4463	.3772	.5175	.3772	.3326
19	.5281	.5975	.5207	.5281	.6653	.5281	.5544
20	.5658	.5975	.5578	.6036	.6653	.5658	.5792
21	.4904	.5228	.5578	.5658	.5914	.5281	.5175
22	.5281	.4481	.5223	.5281	.5175	.4904	.4805
23	.4904	.4108	.4849	.4904	.4805	.4527	.4435
24	.4463	.5658	.4108	.4099	.4904	.4435	.4904
Max	.5658	.5975	.5578	.6036	.6653	.5658	.5792
Min	.3018	.2957	.3347	.3347	.4066	.3395	.3326
Avg	.4407	.4551	.4288	.4289	.4893	.4309	.4375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 303 / Vaitarana

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.415	.3696	.3361	.3772	.3696	.3772
2	.3361	.415	.3696	.3361	.415	.3326	.3395
3	.3361	.3772	.3326	.3361	.415	.3326	.415
4	.3361	.415	.3326	.3361	.415	.3326	.3772
5	.4091	.4527	.3326	.3361	.3772	.3696	.415
6	.4463	.4904	.4435	.4481	.4904	.4066	.4527
7	.4463	.5658	.5175	.5228	.4527	.5544	.5281
8	.5601	.4527	.5281	.4845	.5281	.5281	.4904
9	.4527	.3395	.415	.4481	.3696	.415	.415
10	.3772	.4066	.3395	.4108	.3696	.3772	.4435
11	.415	.3326	.3395	.3734	.3696	.3772	.3696
12	.3395	.2957	.3395	.3361		.415	.4066
13	.3018	.3326	.3395	.2987		.2641	.2587
14	.2641	.2218	.3018	.2641		.3018	.2218
15	.3018	.2587	.2987	.3018		.3018	.2587
16	.2641	.2587	.2614	.2641	.3696	.3395	.2957
17	.2641	.2957	.3361		.4066	.3772	.2957
18	.3395	.3734	.4108	.3772	.4435	.4527	.3326
19	.415	.5228		.4527	.6653	.6036	.5544
20	.4527	.5601	.5228	.5658	.5914	.5281	.5544
21	.4527	.5228	.4854	.5281	.4805	.4904	.5175
22	.415	.4108	.4481	.4527	.4435	.4527	.4435
23	.4527	.3734	.3734	.3772	.4066	.3772	.4108
24	.3361	.4904	.3696	.3361	.415	.3696	.415
Max	.5601	.5658	.5281	.5658	.6653	.6036	.5544
Min	.2641	.2218	.2614	.2641	.3696	.2641	.2218
Avg	.3771	.3991	.3829	.3879	.4401	.4029	.3995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 304 / Kasara Feeder

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3426	.3395	.3395	.3426	.3395	.3395	.3395
2	.3426	.415	.3395	.3426	.3395	.3395	.3772
3	.3426	.3772	.3018	.3419	.3772	.3395	.3772
4	.3426	.3772	.3018	.3419	.3772	.3395	.3395
5	.3426	.3395	.3018	.3419	.3395	.3395	.415
6	.3426	.3772	.3395	.3799	.3395	.3772	.3395
7	.6091	.3772	.3395	.3807	.3018	.3772	.3772
8	.3395	.3018	.3018	.3039	.3395	.3772	.3772
9	.2641	.2641	.2641	.2665	.2641	.3395	.3395
10	.2641	.3018	.2641	.2279	.1132	.2641	.3018
11	.2263	.2641	.2641	.2659	.2263	.2641	.2641
12	.2263	.2587	.2263	.2659		.2641	.2263
13	.1886	.1886	.1886	.1899		.2641	.2641
14	.1886	.1886	.1886	.1886		.2263	.2263
15	.2263	.2263	.2279	.2263		.3018	.2263
16	.2641	.2263	.1899	.1886	.1886	.3018	.2263
17	.2641	.2641	.2279	.2263	.3018	.3395	.2263
18	.3018	.3018	.3419	.3018	.3395	.3772	.2641
19	.3772	.4527	.3799	.415	.4904	.4904	.4904
20	.415	.4904	.4949	.4904	.5658	.4527	.4904
21	.415	.4527	.4568	.4527	.4527	.4904	.4527
22	.3772	.415	.4187	.415	.415	.415	.415
23	.4527	.3395	.3799	.3772	.3772	.415	.3772
24	.3419	.3772	.3395	.3419	.3772	.3772	.3772
Max	.6091	.4904	.4949	.4904	.5658	.4904	.4904
Min	.1886	.1886	.1886	.1886	.1132	.2263	.2263
Avg	.3249	.3299	.3091	.3173	.3433	.3505	.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 305 / Triveni

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0735	.0754	.0724	.0735	.0754	.0747	.0754
2	.0735	.0754	.0724	.0735	.0754	.0747	.0754
3	.0735	.0754	.0724	.0735	.0754	.0747	.0754
4	.0735	.0754	.0724	.0735	.0754	.0747	.0754
5	.0735	.0754	.0724	.0735	.0754	.0747	.0754
6	.0735	.0754	.0724	.0735	.0754	.0747	.0754
7	.0735	.1886	.0724	.0735	.0754	.0747	.0754
8	.0735	.1886	.0754	.0735	.0754	.2263	.0754
9		.1132	.1509	.0735	.0747	.2641	.0754
10		.2896	.2263	.2577	.1867	.3395	.0747
11		.2896	.2641	.2571	.3258	.3018	.0724
12	.3772	.2172	.2263	.0735		.3395	.0724
13	.3018	.1086	.1509	.1837		.3018	.0724
14	.2263	.2172	.1509	.2641		.3395	.0724
15	.3395	.1086	.1884	.3018		.3395	.0724
16	.3395	.2172	.1507	.2641	.0747	.3772	.0724
17	.2641	.1086	.1507	.2263	.2987	.3018	
18	.1132	.0724	.0754	.0754	.0747	.0754	.0724
19	.0754	.0724	.0735	.0754	.0747	.0754	.0724
20	.0754	.0724	.0735	.0754	.0747	.0754	.0724
21	.0754	.0724	.0735	.0754	.0747	.0754	.0724
22	.0754	.0747	.0736	.0754	.0747	.0754	.0724
23	.0754	.0724	.0739	.0754	.0747	.0754	.0739
24	.0735	.0754	.0724	.0738	.0754	.0747	.0754
Max	.3772	.2896	.2641	.3018	.3258	.3772	.0754
Min	.0735	.0724	.0724	.0735	.0747	.0747	.0724
Avg	.1429	.1255	.1149	.1257	.1044	.1742	.0739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028354 / 22/22 KV KHARDI S/S

Feeder No / Name : 306 / Modaksagar

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0349	.0377	.0377	.0349	.0377	.0377	.0377
2	.0349	.0377	.0377	.0349	.0377	.0377	.0377
3	.0349	.0377	.0377	.0349	.0377	.0377	.0377
4	.0349	.0377	.0377	.0349	.0377	.0377	.0377
5	.0349	.0377	.0377	.0349	.0377	.0377	.0377
6	.0349	.0377	.0377	.0349	.0377	.0377	.0377
7	.0349	.0377	.0377	.0349	.0377	.0377	.0377
8	.0349	.0377	.0377	.0349	.0377	.0377	.0377
9		.0377	.0377	.0349	.0377	.0377	.0377
10		.0377	.0377	.0349	.0377	.0377	.0377
11		.0377	.0377	.0349	.0377	.0377	.0377
12	.0377	.0377	.0377	.0349		.0377	.0377
13	.0377	.0377	.0377	.0349		.0377	.0377
14	.0377	.0377	.0377	.0377		.0377	.0377
15		.0377	.0349	.0377		.0377	.0377
16		.0377	.0349	.0377	.0377	.0377	.0377
17	.0377	.0377	.0349	.0377	.0377	.0377	.0377
18	.0377	.0377	.0349	.0377	.0377	.0377	.0377
19	.0377	.0377	.0349	.0377	.0377	.0377	.0377
20	.0377	.0377	.0349	.0377		.0377	.0377
21	.0377	.0377	.0349	.0377	.0377	.0377	.0377
22	.0377	.0377	.0349	.0377	.0377	.0377	.0377
23	.0377	.0377	.0349	.0377	.0377	.0377	.0377
24	.0349	.0377	.0377	.0349	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0349	.0377	.0349	.0349	.0377	.0377	.0377
Avg	.0364	.0377	.0367	.0361	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028355 / 22/22 KV SHENWA S/S

Feeder No / Name : 301 / CHONDA

Feeder KV- 22 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6097
2				.4572	.6097
3				.4572	.6097
4				.4572	.6478
5				.5335	.6478
6				.6859	.8002
7				.7621	.8764
8				.6478	.8764
9				.5335	.6097
10				.6859	.5716
11				.4954	.5335
12				.4954	.4954
13	.7621			.4954	.4572
14				.381	.4191
15				.4191	.4191
16				.4572	.4954
17	.6478			.5335	.5716
18				.6097	.6097
19				1.0669	.9907
20				.9907	.9145
21				.9145	.8383
22				.8764	.8002
23	.5716		.6478	.724	.6097
24		.5716		.5335	.6859
Max	.7621	.5716	.6478	1.0669	.9907
Min	.5716	.5716	.6478	.381	.4191
Avg	.6605	.5716	.6478	.6180	.6541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028355 / 22/22 KV SHENWA S/S

Feeder No / Name : 302 / KINHAVALI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.6385	1.7147	1.6385	.8383	1.6385	1.7909
2	1.5242	1.6004		1.6385	1.6004	1.6004	1.7147
3	1.5242	1.6004	1.6004	1.5242	1.5242	1.5623	1.6766
4	1.7909	1.6385	1.6766	1.829	1.9814	1.5623	1.7147
5	2.1719	1.9814	1.9052	2.2862	2.2862	1.9814	1.7528
6	2.3624	2.4387	2.3624	2.5149	2.553	2.4387	2.21
7	3.0483	2.934	3.2007	2.9721	3.0102	2.9721	2.7816
8	2.934	3.1245	3.1626		2.9721	3.1245	3.1626
9	2.9721	3.0102	2.9721	2.8197	2.8197	2.934	2.3624
10	1.7147	2.7435	2.7054	2.6292	1.5242	2.8197	2.7435
11	2.1719	2.553	2.6292	2.6292	2.2862	2.5149	2.4387
12	2.4006	2.553	2.5911	2.4006	2.0957	1.6766	2.21
13	2.3243	2.3243	2.3243	2.21	2.0957	2.0576	1.9433
14	2.0195	2.0957	1.9052	1.9814	1.9814	2.0195	1.829
15	1.9814	1.7528	2.2862	1.7147	1.9433	2.0576	1.8671
16	2.0576	1.9814	2.2862	2.3243	2.0195	2.1338	1.9814
17	2.2862	2.2481	2.6673	2.4387	2.2862	2.4387	2.21
18	2.7054		2.7054	2.4387	2.7816	2.6673	2.5149
19	3.5056	3.5437	3.6199	3.5056	3.5818	3.5056	3.315
20	3.2388	3.4294	3.3532	3.3532	3.315	3.2769	2.9721
21	2.8578	2.9721	2.6673	2.9721	2.8959	2.8959	2.7054
22	2.4006	2.553	2.4768	2.4768	2.5149	2.5911	2.3243
23	1.9433	2.0195	1.9052	2.0195	1.9814	2.0957	1.829
24	1.6004	1.6766	1.7909	1.7528	1.829	1.7147	1.8671
Max	3.5056	3.5437	3.6199	3.5056	3.5818	3.5056	3.315
Min	1.5242	1.6004	1.6004	1.5242	.8383	1.5623	1.6766
Avg	2.2942	2.3658	2.4569	2.3509	2.2799	2.3450	2.2465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028355 / 22/22 KV SHENWA S/S

Feeder No / Name : 303 / DOLKHAMB

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8383	.8002	.6097	.8383	.8002	.8764
2	.724	.8383	.7621	.6097	.8002	.7621	.8764
3	.724	.8002	.8002	.6097	.7621	.8002	.8383
4	.8002	.8383	.8002	.6859	.7621	.8383	.8764
5	.8764	.9145	.8002	.6859	.9145	.9145	.9145
6	1.1812	1.0288	.9526	.7621	.9526	1.0288	1.0288
7	1.3336	1.2574	1.2193	.9145	1.1431	1.1812	1.2574
8	1.1812	1.1431	1.0288		.9907	1.105	1.1431
9	.9526	.9145	.8764	.8002	.8764	.9145	.8764
10	.9145	.724	.7621	.9526	.5335	.8002	.9145
11	.8002	.6859	.6859	.9526	.6859	.724	.7621
12	.7621	.6478	.7621	.8002	1.1812	.6859	.724
13	.6478	.6478	.4954	.7621	.6097	.724	.724
14	.6478	.4572	.381	.6097	.5716	.6097	.6097
15	.8383	.4572	.5335	.6097	.6478	.6097	.6859
16	1.2193		1.1431	.5716	.6478	.6478	.6859
17	1.1431			1.1812	.724	.7621	.8002
18	.9907	.8383	1.105	.8764	.9907	.9907	1.0669
19	1.5242	.9526	1.448	1.4098	1.3717	1.4861	1.3336
20	1.4098		1.3336	1.3717	1.4098	1.448	1.3336
21	1.2955	.9526	1.1431	1.2193	1.2193	1.2955	1.3336
22	1.105	1.0288	1.0288	1.0288	1.0669	1.1812	1.0669
23	.9526	.8764	.9526	.9145	.9145	.9907	1.0669
24	.9526	.8764	.8002	.8002	.8764	.8383	.9145
Max	1.5242	1.2574	1.448	1.4098	1.4098	1.4861	1.3336
Min	.6478	.4572	.381	.5716	.5335	.6097	.6097
Avg	.9971	.8437	.8963	.8582	.8955	.9224	.9463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153] BU 4448

Substation No/ Name :- 028355 / 22/22 KV SHENWA S/S

Feeder No / Name : 304 / ANSAL FEEDER

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
3	.0762		
5	.0762		
7	.0762		
8	.0762		
9	.0762	.0762	
23			.0762
24	.0762		
Max	.0762	.0762	.0762
Min	.0762	.0762	.0762
Avg	.0762	.0762	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028355 / 22/22 KV SHENWA S/S

Feeder No / Name : 305 / INCOMMER FEEDER SHENVA

SHEDDABLE RURAL

S/STN Feeder KV- 22 / INCOMING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0102	3.1245	2.8959	2.7435	3.0483	3.0102	3.2388
2	2.7435	3.0483	2.7054	2.6673	2.8959	2.8959	3.1245
3	2.6673	2.9721	2.7435	2.6292	2.7816	2.8197	3.0483
4	3.1245	3.1626	2.8197	3.0483	3.3532	2.9721	3.1626
5	3.658	3.6199	3.2007	3.5818	3.9628	3.5056	3.2388
6	4.3439	4.3058	3.8485	3.9628	4.4201	4.2295	4.0009
7	5.3346	5.144	5.0678	4.6487	5.144	4.9916	4.9535
8	4.9535	5.1059	4.8392		4.8392	4.9535	5.0297
9	4.6487	4.5344	4.4201	4.4201	4.4963		3.7342
10	3.315	4.039	3.9628	4.9535	2.4387	4.1533	4.2295
11	3.5437	3.7342	3.7342	4.3058	3.5437	3.658	3.7342
12	3.7342	3.658	3.8104	3.6961	3.9247	3.0102	3.4294
13	3.4675	3.4294	3.2388	3.5056	3.315	3.2388	3.1245
14	3.0483	2.934	2.6673	3.0102	3.1626	3.0483	2.8578
15	3.315	2.2481	3.2007	2.7816	3.315	3.0864	2.9721
16	3.8485	2.0576	3.9628	3.3913	3.3532	3.3532	3.1626
17	4.039	2.6292	3.4294	4.1533	3.658	3.8104	3.5818
18	4.382	1.448	4.4201	4.039	4.3058	4.382	4.1914
19	6.0585	5.1821	5.9442	5.9442	5.8299	5.868	5.6394
20	5.6775	4.0771	5.5251	5.7156	5.6013	5.7156	5.2202
21	5.0297	4.5344	4.9535	5.1059	4.9535	5.0297	4.8773
22	4.3439	4.1533	4.2676	4.2676	4.3439	4.5344	4.1914
23	3.6199	3.3532	3.4294	3.6199	3.6199	3.7342	3.5056
24	3.1626	3.2388	3.0483	3.1245	3.315	3.1626	3.3532
Max	6.0585	5.1821	5.9442	5.9442	5.8299	5.868	5.6394
Min	2.6673	1.448	2.6673	2.6292	2.4387	2.8197	2.8578
Avg	3.9612	3.5722	3.8390	3.8833	3.9009	3.8767	3.8167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028356 / 22/22 KV ASANGAON SWITCHING

Feeder No / Name : 301 / ESSEL FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2779	2.3243	2.1879	1.7147	1.4632	1.7741	2.3388
2	2.2405	2.2862	2.2257	1.7147	1.5565	1.7372	2.2634
3	2.2032	2.2862	2.1502	1.6385	1.6476	1.7741	2.2779
4	2.1285	2.21	2.0911	1.8671	1.5939	1.8111	2.3525
5	2.1658	2.2481	2.1879	1.9052	1.56	1.848	2.3388
6	2.0911	2.2862	2.1719	1.9433	1.704	1.885	2.4006
7	2.1658	2.2862	2.1338	1.9814	1.6385	1.922	2.4387
8	2.2405	2.5911	2.0576	1.9993	1.4243	2.3655	2.6406
9	2.9127	2.6673	2.6673	2.2634	1.387	2.6612	2.8578
10	2.9721	3.2007	2.7054	1.8107	1.5242	3.2442	3.2769
11	2.8197	2.8959	2.8197	1.9616	1.5089	3.3196	3.2007
12	3.1245	2.9127	2.7435	1.6975		3.5818	3.1245
13	2.7435	2.7435	2.7435	1.5089		3.062	2.9721
14	2.8578	3.0933	2.7816	.8025	1.5089	3.4294	3.1245
15	2.9721	3.0483	2.7435	1.773	1.6598	3.3951	3.2007
16	3.0483	3.0483	2.7816	1.773	1.4327	3.0483	2.8959
17	2.7435	3.2769	2.7435	1.7551	1.5043	3.3532	2.8578
18	2.4387	2.9424	2.7816	1.5844	1.6263	3.3196	2.8197
19	2.8197	2.8959	2.5149	2.0748	1.7002	2.9721	3.0483
20	2.7435	2.4897	2.4387	1.8656	1.7002	3.0178	3.0483
21	2.6673	2.7161	2.2862	1.7737	1.9959	2.4143	2.8578
22	2.6673	2.4897	2.2862	1.7375	1.9959	2.6406	2.8197
23	2.5911	2.5652	2.1719	1.5927	1.8671	2.6406	2.4387
24	2.2405	2.3624	2.2634	1.829	1.531	1.7741	2.4143
Max	3.1245	3.2769	2.8197	2.2634	1.9959	3.5818	3.2769
Min	2.0911	2.21	2.0576	.8025	1.387	1.7372	2.2634
Avg	2.5782	2.6611	2.4449	1.7737	1.6150	2.6246	2.7504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028356 / 22/22 KV ASANGAON SWITCHING

Feeder No / Name : 302 / ASANGAON INDUSTRIAL
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2257	2.2481	2.1502	2.2481	2.3045	1.1317	2.3011
2	2.1879	2.21	2.0748	2.21	2.1616	1.1694	2.2257
3	2.1502	1.9052	2.0911	2.1719	2.0332	1.1317	2.1285
4	2.1125	2.1719	2.1658	2.1719	1.9669	1.1694	2.1879
5	2.1502	2.1719	2.1502	2.21	1.8652	1.1317	2.2634
6	2.0748	2.1338	2.0957	2.2862	1.6872	1.2071	2.2481
7	2.1125	2.1338	2.1338	2.2862	1.5653	1.2449	2.2862
8	1.9993	2.2481	1.4754	2.452	1.07	1.5466	2.0748
9	2.5274	2.8578	2.553	2.6783	.5857	2.0698	2.7054
10	3.2769	3.2007	3.0864	3.2065	1.105	3.0178	2.9721
11	3.3913	3.2442	3.0864	3.3951	1.105	3.1245	3.2769
12	3.3532	3.3951	3.0864	3.546		3.5818	3.3913
13	2.8959	2.7915	2.8578	2.95		3.0864	2.9721
14	3.2007	3.1687	3.0102	3.4728	1.105	3.1245	3.2007
15	3.1626	3.2442	3.3913	3.4328	1.0288	3.4294	3.315
16	3.2007	3.131	3.2769	3.3951	.3909	3.5818	3.2388
17	3.2388	3.2442	3.0483	3.4385	.4054	3.4294	3.2388
18	3.0483	2.9424	3.0102	3.2861	1.0349	3.1626	3.1626
19	3.0483	2.8669	2.7816	3.3573	1.2197	3.2442	3.0864
20	2.6673	2.7161	2.8197	2.8006	1.2071	2.9424	2.7054
21	2.5911	2.4897		2.726	1.1203	2.8292	2.6673
22	2.3624	2.3011	2.2862	2.4646	1.2071	2.452	2.4768
23	2.4387	2.2634	2.21	2.5393	1.0562	2.6029	2.6292
24	2.1879	2.2862	2.2257	2.2862	2.4272	1.1317	2.3765
Max	3.3913	3.3951	3.3913	3.546	2.4272	3.5818	3.3913
Min	1.9993	1.9052	1.4754	2.1719	.3909	1.1317	2.0748
Avg	2.6502	2.6403	2.5681	2.7921	1.3478	2.3560	2.7138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028356 / 22/22 KV ASANGAON SWITCHING

Feeder No / Name : 303 / MANAS MANDIR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.1203	1.0974	1.1576	1.1694	.8962	1.0974
2	1.1949	1.0456	1.0174	1.1203	1.1694	.9335	1.0517
3	1.2323	1.0456	1.0867	1.0829	1.0513	.8871	1.1104
4	1.1949	1.0082	1.182	1.0829	1.0486	.924	1.1946
5	1.1576	1.0829	1.1584	1.1203	.9998	.8871	1.1827
6	1.1576	1.1576	1.2567	1.1949	.9808	.924	1.182
7	1.1949	1.2696	1.3443	1.307	.9179	.924	1.2826
8	1.2696	1.419	1.1469	1.4563	.7788	1.2323	1.2971
9	1.8298	1.9791	1.6057	1.5684	.6036	1.5154	1.5684
10	2.1807	2.2916	2.0165	2.4272	.8676	1.9044	2.1285
11	2.3655	2.5274	2.2779	2.4272	.9054	2.21	2.4272
12	2.4764	2.4387	2.2779	2.2779		2.2862	2.2405
13	1.5154	1.5927	1.6804	1.5364		1.643	1.531
14	2.1285	2.4646	2.0911	2.2634	.7922	1.9433	2.2405
15	2.2405	2.6029	2.3899	2.3011	.7922	2.1338	2.2405
16	2.3152	2.6292	2.3525	2.3152	.6036	2.0576	2.3525
17	2.5019	2.2405	2.2032	2.2779	.631	2.4143	2.2405
18	2.2779	1.829	2.2032	2.1125	.924	2.1125	1.9791
19	1.8671	1.848	1.9418	2.0165	.9979	1.6632	1.7924
20	1.7177	1.7002	1.5684	1.643	.9979	1.8107	1.6057
21	1.3443	1.4632	1.4563	1.419		1.4998	1.4563
22	1.307	1.2003	1.3443	1.1869	.961	1.3611	1.3817
23	1.1949	1.166	1.307	1.2209	.9709	1.3032	1.3443
24	1.2696	1.1576	1.1919	1.2323	1.2071	.8871	1.1401
Max	2.5019	2.6292	2.3899	2.4272	1.2071	2.4143	2.4272
Min	1.1576	1.0082	1.0174	1.0829	.6036	.8871	1.0517
Avg	1.6736	1.6783	1.6332	1.6562	.9224	1.5147	1.6278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028356 / 22/22 KV ASANGAON SWITCHING

Feeder No / Name : 304 / WASHIND

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3285	2.4272	2.4764	2.5393	2.4272	2.5873	2.5393
2	2.3655	2.3152	2.4272	2.4272	2.3525	2.6242	2.4025
3	2.4025	2.2405	2.95	2.4272	2.5766	2.5873	3.0308
4	2.4394	2.4272	3.2114	2.6139	3.062	2.6612	3.2526
5	2.5873	4.1076	3.6969	3.1741	3.6595	2.6981	3.6222
6	3.807	4.5931	4.145	3.3608	4.225	4.1396	3.9209
7	4.6201	4.8171	4.481	4.4437	5.0172	4.4723	4.1823
8	4.8419	4.9665	5.0412	4.6571	5.0172	4.768	4.9291
9	3.9956	4.5557	4.1076	4.1396	4.0329	4.0657	4.5557
10	3.3981	3.2487	3.3608	3.3608	3.3573	3.5101	3.9209
11	3.1367	2.9127	2.8006	2.9127	2.5766	3.2156	3.2861
12	2.6886	2.8006	2.6513	2.7069		3.062	3.2114
13		2.6886	2.6513	2.6242		2.963	2.9127
14	2.95	2.0911	2.2779	2.3045	2.9047	2.4977	2.3525
15	2.6139	2.0165	2.0911	2.1582	2.3899	2.3777	2.3525
16	2.3152	2.2779	2.2779	2.4764	2.4097	2.4646	2.5393
17	2.6886	2.6139	2.2405	2.6981	2.5514	2.8166	2.726
18	3.2487	3.6961	3.0247	3.2895	3.1786	3.3265	3.1741
19	4.369	4.5931	4.4063	4.7798	4.4262	4.3983	4.4063
20	4.1823	4.5931	4.369	4.5931	4.4353	4.5462	4.4063
21	3.8836	3.8836	4.1076	4.0329	3.9918	3.9956	3.9209
22	3.4728	3.4355	3.3608	3.3634	3.4004	3.4728	3.5101
23	2.8753	2.8753	2.8006	8.2423	2.9569	3.0994	3.2114
24	2.3899	2.5393	2.4646	2.5766	2.4764	2.6242	
Max	4.8419	4.9665	5.0412	8.2423	5.0172	4.768	4.9291
Min	2.3152	2.0165	2.0911	2.1582	2.3525	2.3777	2.3525
Avg	3.2000	3.2798	3.2259	3.4126	3.3375	3.2906	3.4072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

KALYAN RURAL DIVISION[003]

SHAHAPUR[153]

BU 4448

Substation No/ Name :- 028356 / 22/22 KV ASANGAON SWITCHING

Feeder No / Name : 305 / INCOMMER FEEDER

Feeder KV- 22 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.2305	8.1924	8.0727	7.7351	7.5823	6.4883	8.4122
2	8.1543	7.9256	7.8841	7.5446	7.5446	6.4975	8.0727
3	8.1543	7.8494	8.4122	7.3922	7.7332	6.4883	8.626
4	8.0399	7.8875	8.7007	7.8113	8.1779	6.6095	9.0367
5	8.2305	9.7165	9.3736	8.4972	8.4499	6.6095	9.4685
6	9.3355	10.2881	9.7927	8.8782	9.3728	8.2152	9.907
7	10.3262	10.631	10.2119	10.1357	10.1098	8.626	10.2881
8	10.5929	11.355	10.2119	10.7834	9.0158	10.072	11.2026
9	11.4693	12.1933	11.0502	10.8596	7.431	10.4184	11.8122
10	11.9647	12.079	11.2788	10.974	6.8968	11.8503	12.4219
11	11.8503	11.6979	11.0883	10.8596	6.1728	12.0028	12.3076
12	11.7741	11.6979	10.8596	10.3361		12.5743	12.079
13	9.9451	9.9832	10.0214	8.7517		10.8642	10.4786
14	11.2407	10.974	10.25	9.1667	6.3634	11.1264	11.0121
15	11.0883	11.0121	10.7072	9.7325	5.9442	11.4693	11.2026
16	10.974	11.1645	10.7834	10.0343	5.8029	11.2026	11.1264
17	11.2788	11.5074	10.3262	10.269	6.0985	12.1552	11.1645
18	11.1264	11.6598	11.1264	10.269	6.7638	11.9582	11.2407
19	12.1552	12.3838	11.7741	12.1735	8.5631	12.4981	12.46
20	11.4312	11.5809	11.3169	11.0528	8.4393	12.4109	11.8884
21	10.5929	10.6379	10.631	10.1098	8.1779	10.9358	11.0121
22	9.907	9.5816	9.3736	8.9621	7.6955	10.1357	10.2881
23	9.1831	9.0158	8.5734		6.5261	9.7325	9.7165
24		8.421	8.2613	8.0018	7.7709	6.5261	8.7517
Max	12.1552	12.3838	11.7741	12.1735	10.1098	12.5743	12.46
Min	8.0399	7.8494	7.8841	7.3922	5.8029	6.4883	8.0727
Avg	10.3063	10.3932	10.0034	9.5796	7.5742	9.8945	10.5823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 303 / NMRL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.1463
Max	.1463
Min	.1463
Avg	.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 304 / AN-4

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	3.6892
Max	3.6892
Min	3.6892
Avg	3.6892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 305 / KHARWAI INCOMER

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	11.5055
Max	11.5055
Min	11.5055
Avg	11.5055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 306 / AN-6

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	5.2904
Max	5.2904
Min	5.2904
Avg	5.2904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 307 / Gaikwadpada II

SHEDDABLE RURAL

Feeder KV- 22 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	4.4925
Max	4.4925
Min	4.4925
Avg	4.4925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 308 / U.P.TWIGA

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 309 / ASB INTERNATIONAL
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.0814
Max	1.0814
Min	1.0814
Avg	1.0814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 310 / MIDC I

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	10.4024
Max	10.4024
Min	10.4024
Avg	10.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 311 / WATSON PHARMA

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.9907
Max	.9907
Min	.9907
Avg	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 312 / Inventia Healthcare
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.1694
Max	1.1694
Min	1.1694
Avg	1.1694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 313 / M/S VISTA PACKAGING
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
13	.7762
24	.7762
Max	.7762
Min	.7762
Avg	.7762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 314 / Perrigo API

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.1317
Max	1.1317
Min	1.1317
Avg	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 315 / Godrej Industries
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.6004
Max	1.6004
Min	1.6004
Avg	1.6004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 316 / M/s Bharat Serum
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 317 / Ferring

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 319 / Gaikwadpada I

Feeder KV- 22 / INCOMING

SHEDDABLE RURAL

DATE	01-FEB-18
HR	Load (MW)
24	9.2402
Max	9.2402
Min	9.2402
Avg	9.2402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(EAST)S/DN.[754] BU 4754

Substation No/ Name :- 288062 / ANANDNAGAR

Feeder No / Name : 320 / CEAT

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 303 / KANSAI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.219	2.9683	2.963	2.9264	3.1493	3.2922
2		3.1824	2.7511	2.9995	2.7801	3.0769	3.3653
3		3.1093	2.7149	3.1093	2.8532	2.9321	3.3288
4		3.3288	2.7873	3.2922	2.8898	2.8959	3.2922
5		3.3653	2.8959	3.2922	2.9995	3.0407	3.1824
6		3.7311	3.2217	3.3653	3.1459	3.2217	3.0727
7		3.7311	3.7677	3.8043	3.2922	3.8733	3.5113
8		3.658	3.4019	3.4751	3.3653	3.4389	3.4389
9	3.3653	3.5117	3.4385	3.658	3.4027	3.4389	3.6561
10	3.3288	3.2922	3.4751	3.4389	3.1131	3.6199	
11	3.3653	3.219	3.4385	3.0769	3.0769	3.6923	
12	3.0727	2.7801	3.4019	3.1855		3.6199	
13	3.0727	3.219	3.1093	3.1493		3.2941	
14	3.0361	3.2922	3.0361	3.0407	3.2217	3.2217	3.2556
15	2.5972	2.9995	2.9264	3.1131	2.7873	3.4389	3.3653
16	2.8532	2.8532	2.8898	2.9321	2.7149	3.2579	3.3653
17	2.5606	3.0407	3.1824	3.0727	2.8597	3.1459	3.2941
18	3.1824	3.2579	3.219	3.1093	3.2556	3.4385	3.2941
19	4.2067	4.1629	4.3896	3.7311	4.0543	4.353	4.1991
20	4.1335	4.1991	4.4262	4.2798	3.9457	4.4993	4.3077
21	4.0238	4.0543	4.4627	4.0238	3.9095	4.2798	4.2067
22	3.8409	3.7647	3.9506	3.8043	3.6199	3.9506	
23	3.4385	3.4027	3.5848	3.5482	3.4389	3.658	3.6199
24		3.1824	3.1855	3.2579	3.1093	3.2217	3.3653
Max	4.2067	4.1991	4.4627	4.2798	4.0543	4.4993	4.3077
Min	2.5606	2.7801	2.7149	2.9321	2.7149	2.8959	3.0727
Avg	3.3385	3.3982	3.3594	3.3634	3.2165	3.4900	3.4954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 304 / CHINCH PADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.1093	2.963	3.0361	3.0727	3.2556	3.2922
2		3.1459	2.8166	3.0727	2.9264	3.1824	3.1093
3		3.0361	2.7435	3.1093	2.9995	3.1093	3.1459
4		3.1093	2.7435	3.219	3.0727	3.1459	2.9995
5		3.1824	2.9995	3.1824	3.1824	3.1824	2.9995
6		3.3288	3.2922	3.2556	3.2922	3.2922	2.9995
7		3.3288	3.3653	3.3288	3.3653	3.3653	3.2922
8		3.2922	3.4019	3.4385	3.5117	3.4389	3.4751
9	3.2922	3.1459	3.1459	3.3653	3.5475	3.1493	3.5482
10	3.0727	3.219	3.0727	3.2217	3.1131	3.1131	
11	2.7801	3.1459	3.0361	3.0769		3.0407	
12	2.6703	3.0361	3.0361	3.0045	3.2217	3.0045	
13	2.6703	2.7435	3.0361	3.0045	3.1493	3.1131	
14	2.6337	2.6337	2.9995	2.6425	2.4253	3.0407	3.0407
15	2.524	2.6337	3.0361	2.9683	2.4253	3.0407	3.1131
16	2.5606	2.5606	2.9995	2.8597	2.3529	3.0045	3.0045
17	2.6337	2.7801	2.963	2.9264	2.8532	2.8898	3.1093
18	2.8898	3.2556	3.0361	2.963	3.1824	3.1824	3.1824
19	3.6214	3.6946	3.658	3.5117	3.7311	3.8409	3.8409
20	3.6946	3.7677	3.7311	3.8043	3.6946	3.9506	3.914
21	3.5848	3.914		3.8409	3.7311	3.9506	4.0969
22	3.4751	3.8409	3.8409	3.7311	3.658	3.9872	3.914
23	3.2922	3.658	3.5848	3.658	3.6214	3.6946	3.7677
24		3.0727	3.1459	3.1459	3.219	3.2922	3.4751
Max	3.6946	3.914	3.8409	3.8409	3.7311	3.9872	4.0969
Min	2.524	2.5606	2.7435	2.6425	2.3529	2.8898	2.9995
Avg	3.0264	3.1931	3.1586	3.2236	3.1891	3.3028	3.366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 305 / CHEMICAL ZONE

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.5725	4.6487	4.8011	4.1152	2.7435	3.8104
2		4.382	4.8392	4.5725	3.7723	2.6673	3.7342
3		4.4963	4.7249	4.6106	3.7342	2.6292	3.6961
4		4.5344	4.5725	4.382	3.5818	2.7054	3.658
5		4.4582	4.4201	4.1914	3.4294	2.553	3.6199
6		4.5725	4.1914	4.0771	3.3532	2.5911	
7		4.4582	4.3058	4.2295	3.2769	2.6292	3.3913
8		4.8773	4.4963	4.382	2.8578	3.0864	3.8485
9	5.1821	5.1059	5.144	5.2202	3.0483	4.2295	4.6106
10	5.7537	5.6394	5.6394	6.0966	2.8959	4.9154	
11	6.2872	6.0204	6.3634	6.7063	2.8578	5.2965	
12	6.592	6.4396	6.0966	6.8587	2.7816	5.6775	
13	6.1728	5.6013	5.7537	5.9823	2.8578	4.8011	
14	5.7156	5.6775	5.7156	5.4489	2.7435	3.9247	4.8011
15	5.7537	5.9823	5.7918	5.4489	2.7435	4.8392	5.487
16	5.868	6.1347	5.8299	5.2584	2.4768		5.4108
17	6.4015	5.9061	5.9061	5.3346	2.4387	5.5251	5.2584
18	6.0966	5.8299	5.4108	5.6013	2.5911	5.0678	5.1059
19	6.0585	6.1728	5.2965	5.0297	2.5911	4.5725	5.3346
20	5.4108	5.6394	4.9154	4.8392	2.553	4.3058	4.5725
21	5.3727	5.0297	4.763	4.6487	2.7435	3.9628	4.4201
22	4.1914	4.5344	4.3439	4.4201	2.7435	3.7723	4.1533
23	4.5725	4.8773	4.5725	4.3058	2.7816	4.2676	3.8866
24		4.763	4.5725	4.763	4.2676	2.7816	4.0771
Max	6.592	6.4396	6.3634	6.8587	4.2676	5.6775	5.487
Min	4.1914	4.382	4.1914	4.0771	2.4387	2.553	3.3913
Avg	5.6953	5.2377	5.0964	5.0504	3.0515	3.8932	4.3619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 307 / Siemens_Entity

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.2195	.2987	.2987	.2926	.2987
2		.2987	.2195	.2987	.2241	.2926	.2987
3		.2987	.2195	.2987	.2241	.2926	.2987
4		.2987	.2195	.2987	.2241	.2926	.2987
5		.2987	.2195	.2987	.2241	.2926	.2987
6		.2987	.2926	.2987	.2241	.2926	.2987
7		.2987	.2926	.2987	.2987	.2926	.3018
8		.2987	.2926	.2987	.2987	.2896	.2987
9	.2987	.2987	.2987	.2987	.2896	.2896	.2987
10	.2987	.2987	.2987	.2896	.2896	.2896	
11	.2987	.2987	.2987	.2896		.2896	
12	.2987	.2987	.2987	.2896	.2896	.2896	
13	.2987	.2987	.2987	.2896	.2896	.2896	
14	.2987	.2987	.2987	.2896	.2896	.2896	.2896
15	.2987	.2987	.2987	.2896	.2896	.2896	.2896
16	.2987	.2987	.2987	.2896	.2896	.2896	.2896
17	.2987	.2926	.2987	.2987	.2926	.2987	.2926
18	.2987	.2926	.1494	.2987	.2926	.2987	.2926
19	.2987	.2926	.2987	.2987	.2172	.2987	.2926
20	.2987	.2926	.2987	.2987	.2926	.2987	.2926
21	.2987	.2172	.2987	.2987	.2926	.2987	.2896
22	.2987	.2172	.2987	.2987	.2926	.2987	.2926
23	.2987	.2195	.2987	.2987	.2926	.2987	.2926
24		.2987	.2172	.2987	.2987	.2926	.2987
Max	.2987	.2987	.2987	.2987	.2987	.2987	.3018
Min	.2987	.2172	.1494	.2896	.2172	.2896	.2896
Avg	.2987	.2876	.2718	.2960	.2746	.2933	.2952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 310 / VANDANA THEATER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5121	.5914	.439	.5914	.5914	.5853
2		.5121	.5175	.439	.5914	.5544	.5853
3		.5121	.5175	.439	.6653	.5544	.5853
4		.5121	.5175	.439	.5544	.5175	.5121
5		.5121	.5544	.5121	.5544	.5175	.5121
6		.5121	.5914	.5853	.5544	.5175	.5121
7		.5121	.5175	.439	.5544	.5175	.5121
8		.5853	.6283	.5853	.5914	.5792	.5853
9	.6653	.6584	.5914	.6584	.6516	.6516	.6219
10	.7392	.7392	.7392	.7964	.8688	.8688	
11	.8131	.8131	.8871	.905		.9412	
12	.8501	.924	.8871	.9412	.9774	.9774	
13	.8413	.924	.8501	.905	.9412	.905	
14	.8413	.8871	.8131	.905	.8688	.9412	.8871
15	.7316	.8871	.8501	.9412	.9412	.905	.8871
16	.8048	.924	.8871	.905	.905	.905	.8871
17	.8779	.8871	.8779	.961	.924	.9511	.924
18	.8779	.924	.9145	.9979	.961	.9877	.961
19	.9511	1.0719	.9877	1.0719	1.1827	1.1706	1.1827
20	.9511	1.0349	.9511	1.1088	1.1088	.0739	1.1706
21	.8779	.924	.961	.961	.9979	.9877	1.0719
22	.7316	.7023	.8413	.8131	.8413	.8413	.8871
23	.5853	.6653	.6584	.7023	.6283	.6584	.6653
24		.5121	.5914	.5853	.5914	.5914	.5853
Max	.9511	1.0719	.9877	1.1088	1.1827	1.1706	1.1827
Min	.5853	.5121	.5175	.439	.5544	.0739	.5121
Avg	.8093	.7354	.7385	.7515	.7846	.7378	.7560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 311 / I.T.I. EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO
STAGGERING)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0701	.0362	.0351	.0709	.0362	.0701
2		.0701	.0366	.0343	.0354	.0362	.0701
3		.0351	.0362	.0343	.0354	.0362	.0701
4		.0351	.0362	.0343	.0354	.0362	.0701
5		.0351	.0362	.0339	.0354	.0362	.0701
6		.0351	.0362	.0339	.0709	.0362	.0701
7		.0351	.0362	.0343	.0709	.0362	.0724
8		.0351	.0362	.0686	.0709	.0362	.0724
9	.0709	.0701	.0709	.0686	.0724	.0724	.0701
10	.0709	.0709	.0709	.0724	.0724	.0724	
11	.0709	.0709	.0709	.0724		.0724	
12	.0709	.0709	.0732	.0724	.0724	.0724	
13	.0701	.0709	.0709	.0724	.0724	.0724	
14		.0709		.0724	.0724	.0724	.037
15	.0701	.0709	.0709	.0724	.0362	.0362	.037
16	.0701	.0709	.0709	.0724	.0362	.0362	.037
17	.0701	.0724	.0366	.0709	.0362	.0351	.0362
18		.0362	.0701	.0709	.0362	.0701	.0362
19	.0701	.0362	.0701	.0709	.0362	.0739	.0362
20	.0671	.0362	.0701	.0709	.0362		.0362
21	.0686	.0362	.0671	.0709	.0362	.0724	.0362
22	.0686	.0362	.0701	.0709	.0362	.0724	.0362
23	.0343	.0362	.0701	.0709	.0362	.0724	.0362
24		.0701	.0362	.0343	.0709	.0362	.0739
Max	.0709	.0724	.0732	.0724	.0724	.0739	.0739
Min	.0343	.0351	.0362	.0339	.0354	.0351	.0362
Avg	.0671	.0532	.0556	.0589	.0515	.0534	.0537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
ST

Feeder No / Name : 313 / M.J.P EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1524	.1524	.1524	.1524
2		.1524	.1524	.1524	.1524	.1524	.1524
3		.1524	.1524	.1524	.1524	.1524	.1524
4		.1524	.1524	.1524	.1524	.1524	
5		.1524	.1524	.1524	.1524	.1524	.1524
6		.1524	.1524	.1524	.1524	.1524	.1524
7		.1524	.1524	.1524	.1524	.1524	.1524
8		.1524	.1524	.1524	.1524	.1524	.1524
9	.0762	.1524	.1143	.1524	.1524	.1524	.1524
10	.0762	.1524	.1524	.1524	.1524	.1524	
11	.0762	.1524	.1524	.1524		.1524	
12	.0762	.1524	.1524	.1524	.1524	.1524	
13	.0762	.1524	.1524	.1524	.1524	.1524	
14	.0762	.1524	.1524	.1524	.1524	.1524	.1524
15	.0762	.1524	.1524	.1524	.1524	.1524	.1524
16	.0762	.1524	.1524	.1524	.1524	.1524	.1524
17	.0762	.1524	.1524	.1524	.1524	.1524	.1524
18		.1524	.1524	.1524	.1524	.1524	.1524
19		.1524	.1524	.1524	.1524	.1524	.1524
20		.1524	.1524	.1524	.1524	.1524	.1524
21	.0762	.1524	.1524	.1524	.1524	.1524	.1524
22		.1524	.1524	.1524	.1524	.1524	.1524
23	.0762	.1524	.1524	.1524	.1524	.1524	.1524
24		.1524	.1524	.1524	.1524	.1524	.1524
Max	.0762	.1524	.1524	.1524	.1524	.1524	.1524
Min	.0762	.1524	.1143	.1524	.1524	.1524	.1524
Avg	.0762	.1524	.1508	.1524	.1524	.1524	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 283005 / 22 KV A AMBERNATH SWITCHING
STFeeder No / Name : 314 / Auxiliary Station T/F -
Amb Sw Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	.7316
Max	.7316
Min	.7316
Avg	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 302 / BADLAPUR (VAHINI-2)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	5.1821
Max	5.1821
Min	5.1821
Avg	5.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 303 / Sonivali i/c

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	7.9256
Max	7.9256
Min	7.9256
Avg	7.9256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 304 / Morivali MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
24	3.2769
Max	3.2769
Min	3.2769
Avg	3.2769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 305 / M/s. SPENTA Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.2667
Max	.2667
Min	.2667
Avg	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 306 / Ambernath East

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	5.4871
Max	5.4871
Min	5.4871
Avg	5.4871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 307 / M/s. ICM Express

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.4191
Max	.4191
Min	.4191
Avg	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 308 / OUTGOING 8

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	11.4693
Max	11.4693
Min	11.4693
Avg	11.4693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 309 / OUTGOING 9

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	4.2676
Max	4.2676
Min	4.2676
Avg	4.2676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 311 / Morivali 11 RCI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	2.4768
Max	2.4768
Min	2.4768
Avg	2.4768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 312 / MJP EXPRESS BHENDIPADA NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 22 / OUTGOING UTILITY

DATE	01-FEB-18
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 315 / KATRAP INCOMER

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
11	6.0204
Max	6.0204
Min	6.0204
Avg	6.0204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 286011 / 100/22 KV MORIVALI SUB STN.

Feeder No / Name : 316 / ITC Express

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

AMBERNATH(WEST)S/DN.[175] BU 4175

Substation No/ Name :- 288061 / 220/100 KV JAMBHUL SUB STN

Feeder No / Name : 602 / JAMBHUL WW MIDC LINE II NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 100 / OUTGOING UTILITY

DATE	01-FEB-18
HR	Load (MW)
24	12.124
Max	12.124
Min	12.124
Avg	12.124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 303 / 22KV Ashele Feeder-I

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.77	3.8043	3.9179	3.7677	3.9179	3.6961	4.3896
2	3.6222	3.5848	3.77	3.658	3.77	3.6961	3.8409
3	3.5482	3.4385	3.6961	3.5848	3.6222	3.6591	3.6214
4	3.5482	3.3653	3.5113	3.4751	3.5113	3.5848	3.6946
5	3.6222	3.5848	3.4004		3.8809	3.5482	3.8043
6	3.6961	4.1396	3.7342	4.0238	3.8809	3.5482	3.9506
7	3.9209	4.4513	3.9956	4.4262	3.8089	3.77	4.1396
8	4.0329	4.2196	3.9582	4.3317	3.9582	4.3317	4.1076
9	4.481	4.2627	4.4723	4.0703	4.1076	4.6201	4.257
10	4.3317	4.1076	4.5557	4.0329	3.8836	4.768	4.6677
11	4.4063	4.0703	4.4437	4.1076		4.6571	4.7798
12	4.1076	4.0329	4.6201	4.1076	3.9506	4.8049	4.6304
13	4.1766	3.8439	4.3614	4.1076	3.733	4.6201	4.3317
14	4.1027	3.6222	4.1766	4.0329	3.9179	4.1766	4.257
15	3.5482	3.6961	4.0287	3.7342	3.5852	4.0287	4.1076
16	3.6961	3.77	3.9548	3.8089	3.4374	4.0329	3.8836
17	3.8809	3.8439	4.0657	3.77	3.5852	4.353	3.9179
18	3.9918	3.9918	4.3244	4.2875	3.807	4.6456	4.1396
19	5.487	5.5072	5.7289	5.4702	4.9383	5.7065	5.2484
20	5.655	5.2484	5.6699	5.6181	4.9017	6.0357	5.4702
21	5.1745	5.0267	5.7659	5.1006	4.8285	5.8162	5.3224
22	4.8419	4.6201	5.3041	5.0267	4.6571	5.2675	5.0267
23	4.6571	4.2505	4.8285	4.5831	4.3983	5.0114	4.6571
24	3.8809	3.9506	3.9918	4.3164	4.1396	4.2505	4.6456
Max	5.655	5.5072	5.7659	5.6181	4.9383	6.0357	5.4702
Min	3.5482	3.3653	3.4004	3.4751	3.4374	3.5482	3.6214
Avg	4.1742	4.1014	4.3448	4.2366	4.0096	4.4429	4.3705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 304 / NETAJI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.809	2.7633	2.9874	2.8006	2.9424	2.8753	2.9874
2	2.6612	2.6139	2.838	2.6139	2.8669	2.8006	2.9127
3	2.6612	2.5393	2.726	2.3899	2.8669	2.6886	2.6513
4	2.5503	2.3899	2.6139	2.4646	2.7915	2.6139	2.6139
5	2.6612	2.4646	2.5393	2.6886	2.6783	2.5019	2.6139
6	2.726	2.5274	2.6406	2.838	2.5652	2.5393	2.5766
7	2.6406	2.5274	2.7161	3.0994	2.5911	2.6029	2.5274
8	2.6406	2.5652	2.5652	2.6029	2.6406	2.6029	2.7538
9	3.0933	3.0178	3.1741	2.9801	2.8669	3.2114	3.0933
10	3.3608	3.4355	3.3234	3.6222	3.0933	3.3608	3.5101
11	3.6222	3.7342	3.4728	3.7342	3.2487	3.9209	4.0329
12	3.6595	3.8089	3.9582	4.0329	3.1367	4.1076	4.1076
13	3.77	3.9179	3.5848	3.9956	2.9874	3.9209	4.5557
14	3.3634	3.7342	3.5475	3.8089	2.9424	3.4728	4.0329
15	3.0178	3.2487	3.2442	3.3951	2.6406	3.3981	3.6595
16	3.4743	3.3608	3.5101	3.7342	2.5274	3.7342	3.9582
17	3.3608	3.5101	3.3981	3.5848	2.6029	3.3981	3.5848
18	3.5475	3.6222	3.4355	3.9582	2.6783	3.6595	3.7342
19	4.0238	4.5092	4.2135	4.6571	3.4374	4.4723	4.5831
20	4.1027	4.6571	4.2135	4.731	3.4743	4.4353	4.4353
21	3.8836	4.3983	4.3614	4.4353	3.3265	4.3983	4.6571
22	3.5482	3.8439	3.8809	4.0657	3.2526	3.733	4.2135
23	3.1047	3.7342	3.3981	3.4355	3.1741	3.2895	3.5475
24	2.8829	2.9127	3.062	3.0247	3.0933	3.0247	3.2114
Max	4.1027	4.6571	4.3614	4.731	3.4743	4.4723	4.6571
Min	2.5503	2.3899	2.5393	2.3899	2.5274	2.5019	2.5274
Avg	3.2152	3.3265	3.3085	3.4456	2.9344	3.3651	3.5231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 305 / SHOBHRAJ GARDEN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.7177	1.9052	1.7909	1.9433	1.7353	1.9052
2	1.7909	1.5684	1.7909	1.7528	1.829	1.6975	1.8671
3	1.6766	1.4937	1.7353	1.6766	1.7909	1.6598	1.7909
4	1.7528	1.419	1.6598	1.7147	1.7147	1.6221	1.7528
5	1.7528	1.4937	1.6221	1.6766	1.6766	1.5844	1.7528
6	1.9052		1.643	1.6004	1.7147	1.531	1.7147
7	1.7528	1.8107	1.7177	1.448	1.7528	1.4784	1.6766
8	1.6766	1.8107	1.7193	1.6766	1.6766	1.4632	2.0195
9	2.1338	2.8669	2.3388	2.6029	2.1338	2.0748	2.934
10	3.3196	4.145	3.6969	4.4437	2.6673	3.3951	4.2943
11	4.481	4.7798	4.5931	5.0785	3.2065	4.4513	5.2279
12	4.8049	5.0785	5.0267	5.1532	3.3196	5.0038	5.3026
13	4.8419	5.1006	5.1532	5.3026	3.1245	4.8918	5.2279
14	3.8836	4.0741	4.4136	4.1152	2.7915	4.3004	4.0009
15	3.3573	4.1152	3.5818	3.5818	2.3152	3.5056	3.9232
16	4.7908	4.4063	4.7798	4.9291	2.0911	4.8918	5.1532
17	4.481	4.8049	5.0636	5.1532	2.0748	4.8544	5.2279
18	4.5831	4.9291	4.8918	5.4146	2.037	5.2652	5.4146
19	4.7051	5.3026	5.3026	5.5266	2.4387	5.3026	5.6013
20	4.8049	5.3963	5.2854	5.3026	2.4006	5.2279	5.6013
21	4.2627	4.9158	5.0038	4.8544	2.2481	4.9158	5.1745
22	3.3608	3.4728	3.6222	3.7723	2.0195	3.6969	3.9582
23	2.0165	3.0178	2.9721	2.2481	1.8671	2.3624	2.3624
24	1.9052	1.7924	1.9814	1.9052	2.0576	1.7909	1.9814
Max	4.8419	5.3963	5.3026	5.5266	3.3196	5.3026	5.6013
Min	1.6766	1.419	1.6221	1.448	1.6766	1.4632	1.6766
Avg	3.1628	3.4570	3.3958	3.4467	2.2038	3.2793	3.5777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 306 / 22KV Ashele Feeder-II

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.922	1.8671	1.9044	1.9791	1.9418	2.2405
2	1.7924	1.7924	1.8298	1.8671	1.9418	1.8671	2.0911
3	1.7924	1.6804	1.8298	1.7177	1.7924	1.8298	1.8671
4	1.8298	1.7177	1.7924	1.7551	1.7551	1.7924	1.9418
5	1.7924	1.7924	1.7924	1.8298	1.8298	1.8671	2.0165
6	1.8671	1.9418	1.9418	2.0165	1.8671	1.9418	2.0911
7	1.9616	2.0911	2.1125	2.2405	2.037	2.0911	2.1658
8	2.1125	2.2862	2.2405	2.2779	2.1125	2.1658	2.3525
9	2.1879	2.2405	2.0911	2.2779	2.1125	2.2779	2.3899
10	2.1879	2.1285	2.1285	2.3777	1.9418	2.0698	2.3152
11	2.0911	2.0538	2.0328	2.1658	1.7177	2.1807	2.3152
12	2.0165	1.9959	2.1658	2.0911	1.6263	2.2916	2.1285
13	1.848	1.885	1.9959	1.9418	1.5524	2.0698	2.1068
14	1.8298	1.885	2.0328	1.7002	1.922	1.9959	2.0911
15	1.7924	1.8111	1.885	1.922	1.848	2.0328	1.9959
16	1.8111	1.8111	1.885	1.922	1.7002	1.9589	2.0165
17	1.9418	1.8111	1.848	1.9418	1.848	2.2546	2.1437
18	1.9589	2.0165	2.2177	2.0698	1.9589	2.3045	2.1437
19	2.7351	2.4764	2.809	2.5393	2.4394	2.7351	2.5393
20	2.7351	2.6612	2.7351	2.6139	2.4394	2.8829	2.4646
21	2.4646	2.4764	2.7351	2.4646	2.3655	2.8829	2.4764
22	2.2177	2.3152	2.5393	2.3899	2.3285	2.4394	2.3525
23	2.3285	2.0538	2.4025	2.2032	2.2032	2.4394	2.2032
24	1.9418	2.0698	1.9418	2.1437	2.0911	2.0538	2.2546
Max	2.7351	2.6612	2.809	2.6139	2.4394	2.8829	2.5393
Min	1.7924	1.6804	1.7924	1.7002	1.5524	1.7924	1.8671
Avg	2.0429	2.0381	2.1188	2.0989	1.9754	2.1820	2.1960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 307 / DOODHNAKA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.531	1.6057	1.448	1.5623	1.419	1.5242
2	1.3717	1.419	1.531	1.3717	1.4861	1.3817	1.5242
3	1.2955	1.3443	1.4937	1.3336	1.4861	1.3443	1.4861
4	1.1812	1.3443	1.419	1.4098	1.448	1.307	1.4861
5	1.2193	1.3817	1.3817	1.4098	1.3717	1.307	1.448
6	1.3717	1.419	1.3443	1.3717	1.3336	1.307	1.4098
7	1.3717	1.419	1.307	1.3336	1.3336	1.3817	1.3717
8	1.3717	1.5684	1.4937	1.448	1.448	1.419	1.3717
9	1.9814	2.1125	2.0165	1.9433	2.0576	1.7924	2.0195
10	2.9569	3.3234	3.1824	3.1786	2.5652	2.7721	3.3265
11	3.5848	3.9209	3.77	3.7342	3.0994	3.5113	3.9506
12	3.8836	4.0329	4.0969	4.2875	3.2114	3.8809	4.5359
13	3.8836	4.481	4.0238	4.5092	2.8753	4.0238	4.4353
14	2.7633	3.1367	3.2487	3.0483	2.2779	3.2065	3.1245
15	2.3011	2.7633	2.5149	2.8197	1.9418	2.5133	2.8578
16	3.3634	3.1741	3.6946	4.0657	1.8298	3.807	4.2135
17	3.6222	4.2943	4.0287	4.2875	1.7551	3.8009	4.4353
18	3.8439	4.5557	3.9506	4.4353	1.6975	4.1396	4.4353
19	3.5113	4.4437	6.6095	4.5092	2.1285	4.3381	4.7051
20	3.9872	4.6304	4.2798	4.4353	2.0911	4.3983	4.731
21	3.8439	4.257	3.9872	4.2875	1.8298	4.0969	4.3896
22	3.1047	3.2114	3.2556	3.4743	1.6057	3.2217	3.5848
23	1.8671	2.0538	1.7909	1.9814	1.4937	1.829	1.9814
24	1.6004	1.6057	1.6804	1.6004	1.7147	1.4563	1.5623
Max	3.9872	4.6304	6.6095	4.5092	3.2114	4.3983	4.731
Min	1.1812	1.3443	1.307	1.3336	1.3336	1.307	1.3717
Avg	2.5304	2.8093	2.8211	2.8218	1.9018	2.6523	2.9129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 308 / O.T.

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.1317	1.1317	1.1431	1.2193	1.0562	1.2193
2	1.0288	1.094	1.094	1.1431	1.1812	1.0562	1.1431
3	.9907	1.0562	1.0562	1.0669	1.105	1.0185	1.105
4	.9907	1.0562	1.0185	1.105	1.105	1.0562	1.105
5	.9526	1.094	.9808	1.105	1.0669	1.0562	1.105
6	1.0288	1.1317	1.0185	1.1431	1.0669	1.094	1.1431
7	1.1431	1.1317	1.094	1.1431	1.105	1.1317	1.1431
8	1.1812	1.2826	1.2071	1.2955	1.2574	1.2071	1.2574
9	1.4098	1.5466	1.4712	1.6385	1.3717	1.3957	1.5242
10	1.7353	1.8861	1.8484	1.8671	1.448	1.6975	1.9993
11	2.0195	2.1125	2.0165	2.0165	1.5466	1.9239	2.2405
12	1.9616	2.037	1.9616	2.0165	1.3957	1.5466	2.2405
13	1.9616	1.8861	1.9418	2.1125	1.2449	2.0538	2.1285
14	1.5089	1.358	1.5623	1.5242	1.1317	1.6598	1.7147
15	1.3203	1.4712	1.3336	1.4098	1.0562	1.4861	1.448
16	1.9418	1.5089	1.9993	1.8861	1.0185	2.0538	2.0165
17	1.9616	1.9616	2.0195	2.0748	.9808	1.9791	2.1658
18	2.1125	2.1125	1.9616	2.1125	.9431	2.0911	2.2405
19	2.1879	2.2257	2.0748	2.2634	1.2449	2.3011	2.2634
20	2.1807	2.1502	2.0538	2.2634	1.1317	2.3152	2.3388
21	2.1502	2.2257	2.0911	2.1125	1.1694	2.3243	2.2405
22	1.9616	1.8107	1.9239	1.9616	1.2071	2.0165	1.9616
23	1.3203	1.3203	1.3717	1.4861	1.1694	1.5623	1.5242
24	1.1812	1.2071	1.1317	1.6384	1.2193	1.1317	1.2955
Max	2.1879	2.2257	2.0911	2.2634	1.5466	2.3243	2.3388
Min	.9526	1.0562	.9808	1.0669	.9431	1.0185	1.105
Avg	1.5557	1.5749	1.5568	1.6470	1.1827	1.5923	1.6901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR V S/DN.[174] BU 4174

Substation No/ Name :- 283051 / 22KV SW.STN.GAIKWADPADA

Feeder No / Name : 309 / GEMNANI COMPOUND

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0754	.0381	.0762	.0762	.0381	.0762
2	.0381	.0381	.0381	.0762	.0381	.0381	.0762
3	.0381	.0377	.0381	.0381	.0381	.0381	.0762
4	.0381	.0373	.0381	.0381	.0381	.0381	.0762
5	.0762	.0381	.0381	.0381	.0762	.0381	.0762
6	.0762	.0754	.0381	.0381	.0381	.0377	.0762
7	.0762	.0754	.0762	.0762	.0381	.0381	.0762
8	.0762	.0754	.0762	.0762	.0762	.0381	.0762
9	.1524	.0754	.1524	.1524	.0762	.1143	.0762
10	.2667	.2987	.3048	.3048	.0762	.1905	.2667
11	.381	.381	.4191	.4191	.0762	.381	.381
12	.381	.4572	.381	.4191	.1143	.4191	.4191
13	.4191	.4572	.4572	.4191	.0762	.381	.4572
14	.4191	.3429	.381	.2667	.0762	.381	.3048
15	.3048	.3048	.3048	.1905	.0381	.3048	.2667
16	.4572	.381	.4572	.381	.0381	.4572	.381
17	.4527	.4572	.4572	.4191	.0381	.4954	.4572
18	.3772	.4954	.4191	.4191	.0381	.4954	.381
19	.3361	.381	.4191	.381	.0381	.4191	.381
20	.3326	.3429	.381	.381	.0381	.381	.3429
21	.3018	.2667	.3429	.3048	.0381	.3048	.3048
22	.2263	.1905	.2286	.2286	.0381	.2286	.1905
23	.1132	.1143	.1143	.1143	.0381	.1143	.1143
24	.0762	.0754	.0762	.0762	.0762	.0381	.0762
Max	.4572	.4954	.4572	.4191	.1143	.4954	.4572
Min	.0381	.0373	.0381	.0381	.0381	.0377	.0762
Avg	.2289	.2281	.2365	.2223	.0556	.2254	.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR IV S/DN.[173] BU 4173

Substation No/ Name :- 283052 / ASHELEPADA SW/STN

Feeder No / Name : 304 / KURLA CAMP

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4004	3.77	3.7739	3.6222	3.77	4.233	3.6961
2	3.2895	3.5482	3.6259	3.4374	3.5113	3.7545	3.6222
3	3.1786	3.1786	3.5149	3.3265	3.3265	3.644	3.5113
4	3.3265	3.3265	3.4039	3.2526	3.3196	3.6072	3.3265
5	3.4743	3.6961	3.5519	3.6222	3.4004	3.7545	3.4743
6	3.6591	3.9918	4.0329	4.1027	3.6214	4.0857	3.6222
7	3.8439	4.1396	4.1439	4.5092	3.6591	4.233	4.1396
8	3.8809	3.9918	3.9959	4.1396	3.8462	4.0489	3.8439
9	4.1766		4.2919	3.9918	3.8809	4.3434	4.1823
10	4.2135	3.9918	4.4029	3.9179	3.733	4.6747	4.5557
11	4.1396	3.9874	4.2875	4.0703		4.5831	4.7051
12	3.9918	3.9502	4.5092	4.1823	4.1594	4.5831	4.5557
13	3.9918	3.7638	4.1396	3.9582	3.7177	4.1396	4.257
14	3.6591	3.5775	4.0657	3.8836	3.644	3.9918	4.145
15	3.5482	3.5402	3.8439	3.7715	3.6072	3.8439	4.0703
16	3.5482	3.503	3.807	3.6969	3.5336	3.8439	3.9956
17	3.77	3.8011	3.9179	3.77	3.46	4.1396	3.9582
18	4.1396	3.9421	4.1396	4.2875	3.7545	4.4353	4.1076
19	5.3224	5.4408	5.6181	5.1532	4.7115	5.4702	5.3026
20	5.3224	5.5153	5.4702	5.3224	5.006	5.4702	5.5266
21	5.1745	4.9191	5.6181	5.1745	4.9691	5.6181	5.3399
22	4.8049	4.77	5.1376	4.9158	4.7483	5.1745	5.0038
23	4.5831	4.3974	4.5831	4.4353	4.3802	4.8788	4.7051
24	3.5482	3.9918	3.9219	4.1396	3.9918	4.0857	4.4353
Max	5.3224	5.5153	5.6181	5.3224	5.006	5.6181	5.5266
Min	3.1786	3.1786	3.4039	3.2526	3.3196	3.6072	3.3265
Avg	3.9995	4.0319	4.2416	4.1118	3.9022	4.3599	4.2534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION II[403]

ULHASNAGAR IV S/DN.[173] BU 4173

Substation No/ Name :- 283052 / ASHELEPADA SW/STN

Feeder No / Name : 309 / SHRIRAM

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.9753	1.8557	1.848	1.922	1.9319	1.9022
2	1.5893	1.829	1.7814	1.7741	1.848	1.8204	1.9022
3	1.5524	1.7558	1.6701	1.7002	1.7741	1.7461	1.829
4	1.4784	1.7558	1.633	1.6263	1.7002	1.709	1.829
5	1.6263	1.829	1.7072	1.848	1.7741	1.8947	1.9022
6	1.8111	1.9022	1.9299	2.1437	1.848	2.1176	1.9753
7	1.9589	2.0485	2.1155	2.2546	1.922	2.2291	
8	2.1437	2.1216	2.1897	2.2546	1.9959	2.1548	2.1948
9	2.1437	2.1948	2.0041	2.2916	2.0328	2.1919	2.3777
10	2.0328	2.0485	1.967	2.1437	1.8111	2.1548	2.3034
11	1.9022	2.0433	2.0328	2.0911	1.6718	2.0485	2.1919
12	1.9022	1.9319	2.0698	2.0165	1.6347	2.1948	2.1176
13	1.7558	1.8204	1.9589	1.8298	1.5975	***	2.1548
14	1.7558	1.7833	1.9589	1.9418	1.8204	1.9022	2.0433
15	1.7558	1.7833	1.885	1.9239	1.7833	1.9022	2.0062
16	1.7558	1.7461	1.885	1.8671	1.6718	1.9022	2.0433
17	1.9022	1.7833	1.848	1.8671	1.5604	2.1948	2.0805
18	2.0485	1.8947	2.1807	2.0538	1.969	2.3411	2.1176
19	2.6337	2.4891	2.7721	2.5019	2.4148	2.6337	2.5263
20	2.6337	2.6749	2.7351	2.5393	2.452	2.7069	2.5263
21	2.5606	2.452	2.7351	2.4025	2.3777	2.7801	2.452
22	2.1948	2.3034	2.5133	2.3655	2.3405	2.4874	2.3405
23	2.1948	2.0805	2.4025	2.1807	2.1548	2.3411	2.2291
24	1.7741	2.0485	1.9299	2.1807	1.9959	2.0433	2.1948
Max	2.6337	2.6749	2.7721	2.5393	2.452	233.5623	2.5263
Min	1.4784	1.7461	1.633	1.6263	1.5604	1.709	1.829
Avg	1.9487	2.0123	2.0734	2.0686	1.9197	11.7913	2.1409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR II S/DN.[171] BU 4171

Substation No/ Name :- 283171 / 22 Kv Saibaba Switching
StatioFeeder No / Name : 300 / Station transformer
Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
23	.1097
Max	.1097
Min	.1097
Avg	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR II S/DN.[171] BU 4171

Substation No/ Name :- 283171 / 22 Kv Saibaba Switching
StatioFeeder No / Name : 302 / 22 KV O. T. FEEDER
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2588	1.3203	1.6941	1.6975	1.6975	1.6941	1.7147
2	2.2588	1.3203	1.6358	1.5089	1.5089	1.6941	1.5242
3	1.8823	1.1317	1.6941	1.5089	1.5089	1.6941	1.5242
4	1.8823	1.1317	1.6941	1.5089	1.3203	1.7113	1.5242
5	1.6941	1.1317	1.6941	1.5089	1.3203	1.6941	1.5242
6	1.6804	1.1317	1.6941	1.5089	1.3203	1.807	1.5242
7	1.6941	1.1317	1.6941	1.5089	1.5089	1.807	1.5242
8	1.6941	1.5089	1.6941	1.6975	1.5089	1.807	1.5242
9	1.8842	1.9052	2.2862	1.8861	1.807	2.0706	1.5089
10	2.6379	2.2862	3.0483	2.6406	1.8823	2.4768	2.452
11	3.2032	2.8578	3.2388	3.2065	1.8823	3.0483	3.0178
12	3.3916	3.4294	3.4294	3.2065	2.0706	3.4294	3.5837
13	3.3916	3.4294	3.4294	3.2065	1.8823	3.4294	3.2065
14	3.0148	3.2388	3.2388	3.3951	1.6941	3.4294	3.2065
15	2.8264	2.8578	3.0483	3.0178	1.8823	3.4294	3.0178
16	2.8264	3.0483	3.2388	3.0178	1.8823	3.2388	3.0178
17	3.0178	3.2	3.0483	3.2065	1.8823	3.0483	3.2065
18	3.0178	3.3608	3.4294	3.0178	3.0117	3.2388	3.2065
19	3.2065	3.3882	3.6199	3.7723	2.0706	3.4294	4.1495
20	3.2065	3.5764	3.4294	3.7723	1.8823	3.4294	3.7723
21	3.0178	3.2	3.0483	3.2065	1.6941	3.2388	3.2065
22	2.2634	2.8235	2.2862	2.6406	1.9033	2.4768	2.452
23	1.8861	1.8823	2.0957	2.2634	1.6941	1.9052	2.2634
24	2.6406	1.5089	1.8823	1.9052	1.8861	1.807	1.9052
Max	3.3916	3.5764	3.6199	3.7723	3.0117	3.4294	4.1495
Min	1.6804	1.1317	1.6358	1.5089	1.3203	1.6941	1.5089
Avg	2.5199	2.3250	2.5538	2.4921	1.7792	2.5431	2.4815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR II S/DN.[171] BU 4171

Substation No/ Name :- 283171 / 22 Kv Saibaba Switching
StatioFeeder No / Name : 321 / 22 KV MARKET FEEDER
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	1.5775	1.4038	1.5775	1.9281	1.7604	1.9052
2	1.8823	1.4022	1.5059	1.5775	1.7528	1.7547	1.5242
3	1.6941	1.2269	1.5059	1.4022	1.5775	1.9014	1.5242
4	1.6941	1.2269	1.3176	1.4022	1.4022	1.807	1.5242
5	1.6941	1.2269	1.3176	1.4022	1.2269	1.6941	1.5242
6	1.6941	1.2269	1.3176	1.4022	1.2269	1.6941	1.5242
7	1.6941	1.0517	1.4937	1.4022	1.4022	1.6838	1.5242
8	1.6941	1.2269	1.5059	1.4022	1.4022	1.8823	1.5242
9	1.7528	1.7147	1.8671	1.7528	2.56	1.7547	1.7528
10	2.4539	2.2862	2.4768	2.4539	3.7647	2.4768	2.1033
11	3.8561	3.0483	2.8578	3.8561	4.2113	4.1914	3.8561
12	5.2584	4.1914	4.9535	5.2584	5.2705	5.3346	5.2584
13	5.7842	4.1914	5.7156	5.4336	5.2641	5.5251	5.6089
14	5.4336	4.0009	5.3346	5.6089	4.9185	5.7156	6.31
15	4.382	3.0483	4.9535	5.2584	4.2113	5.3346	5.9595
16	4.5572	2.8578	4.9535	5.2584	4.9131	5.7156	5.7842
17	5.2584	2.2811	5.3346	5.4336	5.2641	5.9061	5.6089
18	5.4336	2.447	5.9061	5.6089	5.788	6.2872	6.31
19	6.6606	2.6353	6.0966	6.6606	6.4502	7.0492	6.6606
20	5.9595	2.8235	6.2872	6.6606	5.7905	6.8587	6.8359
21	5.4336	2.4566	5.144	5.6089	5.0823	6.0966	6.31
22	3.8561	2.1056	3.8104	3.8561	4.7257	4.5725	4.5572
23	2.1033	1.9385	2.4768	3.155	2.632	2.6673	2.8045
24	2.452	1.7528	1.5792	5.4679	2.1033	1.8823	2.2862
Max	6.6606	4.1914	6.2872	6.6606	6.4502	7.0492	6.8359
Min	1.6941	1.0517	1.3176	1.4022	1.2269	1.6838	1.5242
Avg	3.5384	2.2477	3.3798	3.7042	3.5362	3.8144	3.7742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR II S/DN.[171] BU 4171

Substation No/ Name :- 283171 / 22 Kv Saibaba Switching
StatioFeeder No / Name : 322 / 22 KV PUNJABI COLONY
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	29-JAN-18	30-JAN-18	31-JAN-18	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.924	1.1203	.924	.924	.9412	1.1431
2	.9412	.7392	1.1294	.924	.924	.9335	1.1431
3	.9412	.7392	.9412	.924	.7392	.9412	.9526
4	.9412	.7392	.9412	.924	.7392	.9412	.9526
5	.9412	.7392	.9412	.924	.7392	.9412	.9526
6	.9412	.7392	.9412	.924	.7392	.9412	.9526
7	.9335	.7392	2.0706	.924	.7392	1.1294	.9526
8	1.1294	.7392	.9412	.924	.7392	1.1294	.9526
9	1.1088	.7621	1.1431	.924	.9412	1.1294	.924
10	1.4784	.9526	1.3336	1.1088	1.142	1.3336	1.1088
11	1.4784	1.5242	1.3336	1.4784	1.1294	1.3336	1.4784
12	1.4784	1.5242	1.3336	1.4784	1.0288	1.3336	1.6632
13	1.4784	1.5242	1.3336	1.4784	.9507	1.3336	1.4784
14	1.4784	1.3336	1.3336	1.4784	.7529	1.5242	1.4784
15	1.4784	1.3336	1.3336	1.4784	.8773	1.3336	1.4784
16		1.3336	1.3336	1.4784	.9059	1.3336	1.4784
17	1.4784	1.4967	1.3336	1.6632	.9412	1.5242	1.6632
18	1.6632	1.6941	1.7147	1.4784	.9412	1.7147	1.6632
19	1.848	1.6941	1.7147	1.848	1.3176	1.9052	1.848
20	1.848	2.0706	1.9052	2.0328	1.3176	2.0957	2.0328
21	1.6632	2.0706	1.7147	1.848	.9507	1.9052	1.848
22	1.4784	1.8823	1.5242	1.4784	1.3176	1.9052	1.6632
23	1.4784	1.3176	1.3336	1.4784	.9412	1.5242	1.6632
24	1.4784	1.1088	1.3176	7.4875	1.1088	.9335	1.3336
Max	1.848	2.0706	2.0706	7.4875	1.3176	2.0957	2.0328
Min	.9335	.7392	.9412	.924	.7392	.9335	.924
Avg	1.3393	1.2384	1.3360	1.5671	.9520	1.3359	1.3669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR III S/DN.[172] BU 4172

Substation No/ Name :- 283172 / 17 SECTION SW/STN

Feeder No / Name : 301 / Feeder No.1

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	8.4019
Max	8.4019
Min	8.4019
Avg	8.4019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR III S/DN.[172] BU 4172

Substation No/ Name :- 283172 / 17 SECTION SW/STN

Feeder No / Name : 302 / 22kV WALDHUNI Feeder No.II
Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18
HR	Load (MW)
23	2.0576
24	4.1152
Max	4.1152
Min	2.0576
Avg	3.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-JAN-18 and 04-FEB-18

KALYAN ZONE[054]

KALYAN CIRCLE - II[545]

ULHASNAGAR DIVISION I[402]

ULHASNAGAR III S/DN.[172] BU 4172

Substation No/ Name :- 283172 / 17 SECTION SW/STN

Feeder No / Name : 303 / OUT GO FEEDER NO 3

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723