

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 201 / KIRPE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.4115	.5144	.3429	.0343	.0343	.0343
2	.0343	.4115	.4973	.3086	.0343	.0343	.0343
3	.0343	.4115	.4973	.3086	.0343	.0343	.0343
4	.0343	.4115	.5144	.3086	.0343	.0343	.0343
5	.0343	.4458	.5316	.3601	.0343	.0343	.0343
6	.0343	.4801	.5487	.4458	.0343	.0343	.0343
7	.0343	.583	.6344	.5316	.0343	.0343	.0343
8	.0343	.6173	.6687	.6344	.0343	.0343	.0343
9	.0343	.6173	.6344	.6173	.0343	.0343	.0343
10	.823	.0343	.0343	.0343	.7888	.7011	.823
11	.8916	.0343	.0343	.0343	.7716	.7621	.823
12	.7202	.0343	.0343	.0343	.8402	.7773	.823
13	.7202	.0343	.0343	.0343	.823	.6859	.7888
14	.6859	.0343	.0343	.0343	.8059	.6859	.7545
15	.7888	.0343	.0343	.0343	.8059	.6554	.7202
16	.7202	.0343	.0343	.0343	.7716	.6401	.6859
17	.6859	.0343	.0343	.0343	.0343	.6344	.6516
18	.0343	.0343	.0343		.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.4115	.5144	.3601	.0343	.0343	.0343
Max	.8916	.6173	.6687	.6344	.8402	.7773	.823
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2744	.2201	.2515	.2028	.2579	.2538	.2758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 202 / CHACHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343	.0343	.0343
16	.0343	.0343	.0343	.0343	.0343	.0343	.0343
17	.0343	.0343	.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0343	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 203 / DHEBEWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.3086	.3086	.3772	.3086	.3772
2	.2743	.2743	.3086	.3086	.3429	.3086	.3086
3	.2743	.2743	.3258	.3086	.3086	.3086	.3086
4	.2743	.2743	.3429	.3429	.3086	.3429	.3429
5	.3086	.3086	.4115	.3601	.3086	.4115	.4115
6	.5144	.3772	.4801	.4115	.5487	.4801	.4801
7	.7202	.583	.7202	.583	.6516	.6173	.6249
8	.6516	.6173	.6516	.6097	.6516	.6173	.6401
9	.583	.583	.583	.6173	.6516	.5487	.6001
10	.4115	.4801	.4973	.6859	.583	.4801	.5144
11	.4801	.4458	.4801	.6173	.5144	.4458	.4801
12	.4801	.4115	.583	.5487	.4458	.4115	.4458
13	.4115	.3772	.3944	.4115	.4115	.4115	.4115
14	.3772	.3086	.3601	.4458	.3772	.3944	.4458
15	.4115	.3429	.4115	.5144	.583	.4801	.4801
16	.4801	.3772	.4458	.5144	.6173	.4458	.5144
17	.4801	.4801	.4801	.5144	.7202	.5658	.5144
18	.4801	.5144	.5144	.5144	.7202	.6516	.6516
19	.0343	.6859	.6344	.6859	.7545	.6344	.6859
20	.6859	.7888	.6859	.823	.8573	.7468	.7545
21	.6859	.7202	.6554	.7545	.7202	.6859	.7888
22	.6173	.583	.6001	.6516	.6516	.6687	.6516
23	.4115	.3772	.4287	.6516	.4458	.5316	.5144
24	.3086	.3429	.3086	.3429	.3772	.3429	.4287
Max	.7202	.7888	.7202	.823	.8573	.7468	.7888
Min	.0343	.2743	.3086	.3086	.3086	.3086	.3086
Avg	.4429	.4515	.4838	.5219	.5387	.4934	.5157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 204 / KOLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.1543	.1715	.1715	.1715	.1715
2	.12	.1372	.1543	.1543	.1372	.1715	.1715
3	.0343	.1372	.1372	.1372	.1372	.1715	.1715
4	.12	.1372	.1715	.1715	.1372	.2058	.1886
5	.1543	.1715		.2058	.1715	.2572	.2058
6	.2401	.2058	.2743	.2572	.2743	.2743	.2743
7	.3086	.3429	.3429	.3429	.3429	.3429	.3601
8	.3086	.3086	.3086	.3258	.3429	.3601	.3258
9	.2743	.2743	.2915	.3086	.3086	.2743	.2743
10	.2401	.2229	.2743	.2743	.2401	.2572	.2058
11	.2229	.2229	.2915	.2401	.2401	.2572	.2401
12	.2401	.2229	.2401	.2401	.2401	.2401	.2401
13	.2401	.2572	.2743	.2401	.2401	.2572	.2058
14	.2401	.2401	.2401	.2401	.2572	.2572	.2058
15	.2401	.2229	.2401	.2401	.2401	.2572	.2058
16	.2401	.2401	.2743	.16	.2572	.2401	.2058
17	.2401	.2572	.2572	.2401	.2743	.2229	.2401
18	.2058	.2401	.2229	.2401	.2915	.2401	.2058
19	.3086	.3086	.3086	.3086	.2915	.2915	.3086
20	.3772	.3772	.3772	.4115	.3944	.3429	.3772
21	.3429	.3429	.3772	.3772	.3601	.3772	.3086
22	.3086	.3258	.3086	.3429	.3258	.3429	.3086
23	.2401	.2229	.2401	.2743	.2572	.2572	.2743
24	.1372	.1715	.1715	.1886	.2058	.2229	.2229
Max	.3772	.3772	.3772	.4115	.3944	.3772	.3772
Min	.0343	.1372	.1372	.1372	.1372	.1715	.1715
Avg	.2293	.2386	.2579	.2539	.2558	.2622	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 205 / CHACHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.0343	.0343	.0343	.7545	.7373	.6401
2	.6516	.0343	.0343	.0343	.6859	.7202	.6401
3	.6516	.0343	.0343	.0343	.6859	.7202	.6249
4	.6516	.0343	.0343	.0343	.6859	.7545	.6249
5	.6859	.0343	.0343	.0343	.6859	.7888	.6401
6	.7545	.0343	.0343	.0343	.7545	.823	.7011
7	.823	.0343	.0343	.0343	.8916	.8573	.8535
8	.0343	.0343	.0343	.0343	.9602	1.0117	.945
9	.0343	.0343	.0343	.0343	.8916	.9755	.9431
10	.0343	1.4232	1.0974	1.166	.0343	.0343	.0343
11	.0343	1.4575	1.1279	1.166	.0343	.0343	.0343
12	.0343	1.4746	1.2346	1.166	.0343	.0343	.0343
13	.0343	1.4232	1.1431	1.2346	.0343	.0343	.0343
14	.0343	1.3717	1.1279	1.166	.0343	.0343	.0343
15	.0343	1.3546	1.1126	1.0974	.0343	.0343	.0343
16	.0343	1.3032	1.0974	1.0974	.0343	.0343	.0343
17	.0343	1.3032	1.0364	.9602	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.6859	.0343	.0343	.0343	.7888	.7373	.6554
Max	.823	1.4746	1.2346	1.2346	.9602	1.0117	.945
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.2544	.4858	.3969	.4001	.3444	.3586	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 206 / TALMAVALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	1.6461	1.7147	1.5394	.0343	.0343	.0343
2	.0343	1.6461	1.7147	1.5242	.0343	.0343	.0343
3	.0343	1.6461	1.7661	1.5242	.0343	.0343	.0343
4	.0343	1.6461	1.7661	1.5394	.0343	.0343	.0343
5	.0343	1.7147	1.8004	1.6004	.0343	.0343	.0343
6	.0343	1.7833	1.8347	1.7071	.0343	.0343	.0343
7	.0343	2.0576	2.1776	1.9357	.0343	.0343	.0343
8	.0343	2.2634	2.2291	1.9966	.0343	.0343	.0343
9	.0343	2.0576	1.7985	2.1948	.0343	.0343	.0343
10	3.2922	.0343	.0343	.0343	3.0178	2.6825	3.0178
11	3.0864	.0343	.0343	.0343	3.2407	2.774	3.155
12	3.3608	.0343	.0343	.0343	3.2922	2.774	3.0178
13	3.155	.0343	.0343	.0343	3.1722	2.7435	2.8807
14	3.155	.0343	.0343	.0343	2.9664	2.6063	2.8807
15	3.155	.0343	.0343	.0343	2.8635	2.6063	2.8807
16	2.7435	.0343	.0343	.0343	2.9492	2.5911	2.8807
17	2.7435	.0343	.0343	.0343	2.6749	2.4387	1.0288
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	1.7147	1.7318	1.5394	.0343	.0343	.0343
Max	3.3608	2.2634	2.2291	2.1948	3.2922	2.774	3.155
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	1.0517	.7773	.7922	.7326	1.0302	.9069	.9288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 201 / YELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.8916	.9259	1.0974	.6908	.7202	.8215
2	.5041	.8745	.8573	1.0631	.6722	.6344	.7468
3	.5041	.9088	.823	1.0631	.6535	.6344	.6722
4	.5228	.9431	.823	1.0631	.6908	.6344	.6722
5	.5601	1.0288	.9259	1.0631	.7842	.6344	.6908
6	.8962	1.1317	1.2003	1.3717	.9149	.8059	.9335
7	1.1016	1.6461	1.7833	1.7833	1.2136	.8916	1.0082
8	1.1203	1.6461	1.7833	1.8351	1.1576	.9602	1.0082
9	.8962	1.1317	1.5261	1.5729	.9522	.7545	.7842
10	3.0001	.8215	.6722	.7095	3.2579	3.2579	3.1824
11	3.1824	.7468	.7468	.7095	3.514	3.6523	3.3979
12	3.0498	.7842	.7468	.6348	3.5968	3.3436	3.2156
13	2.7183	.8402	.7468	.7095	3.63	3.2065	3.083
14	2.652	.7468	.6722	.7468	5.6687	3.1893	2.8178
15	2.3537	.7095	.6722	.7468	3.1161	2.6235	2.7515
16	2.2542	.6908	.6722	.7468	3.1824	3.0521	2.8344
17	2.0885	.6722	.6161	.7842	2.8841	2.8121	2.6023
18	.7468	.7842	.7045	.8215	.6859	.9149	.6859
19	1.2136	1.3443	1.5023	1.2136	1.2689	1.4937	1.448
20	1.7177	1.7737	1.7551	1.7924	1.7375	1.8298	1.8671
21	1.6057	1.6244	1.6289	1.6804	1.6289	1.643	1.7177
22	1.251	1.3443	1.267	1.307	1.3756	1.4003	1.4377
23	.8029	.8589	.823	.9522	.8573	.9522	.9412
24	.5601	.9088	1.0288	1.0974	.6908	.823	.8775
Max	3.1824	1.7737	1.7833	1.8351	5.6687	3.6523	3.3979
Min	.5041	.6722	.6161	.6348	.6535	.6344	.6722
Avg	1.4927	1.0355	1.0376	1.1069	1.8677	1.7027	1.6749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 202 / YEWATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.3772	.3944	.4801	1.2742	1.3203	1.1317
2	.8718	.3944	.3772	.4801	1.2574	1.2003	1.0802
3	.8453	.3601	.3601	.4801	1.2574	1.2003	1.046
4	.8951	.3944	.3601	.4801	1.2407	1.2003	1.046
5	.9945	.4287	.463	.4801	1.3413	1.2346	1.0442
6	1.1934	.5144	.6516	.6173	1.4083	1.5775	1.4255
7	1.757	.8573	.9259	.8916	1.9616	2.1262	1.8351
8	.7956	.8916	.8402	.823	1.9784	2.0576	1.9334
9		.7202	.6344	.7545	1.7101	1.6461	1.4419
10	.6344	2.6155	1.6078	2.4366	.5487	.6001	.4801
11	.5487	3.0167	2.4366	2.652	.4801	.5144	.4801
12	.5316	2.6686	2.4531	2.5029	.4287	.5144	.4801
13	.4973	2.8841	2.6023	2.4531	.463	.5144	.463
14	.4973	2.9172	2.304	2.4366	.463	.5144	.4801
15	.5144	2.7349	2.4531	2.2377	.463	.5316	.5144
16	.5316	2.5692	2.2874	2.2045		.5658	.5487
17	.5487	2.7183	2.2542	2.0885		.5487	.5144
18	.4115	.6687	.583	.5316	.7545	.5658	.5487
19	.8573	.8402	.9602	.8916	1.0288	.9088	.8916
20	1.0631	1.2003	1.0974	1.1317	1.2346	1.1317	1.2346
21	.9259	1.1488	1.0288	1.0802	1.166	1.1949	1.0974
22	.823	.9088	.823	.8573	.9602	.9602	.9602
23	.5658	.6516	.6173	.6344	.6516	.6859	.6516
24	1.0802	.3944	.463	.5144	1.291	1.3717	1.2346
Max	1.757	3.0167	2.6023	2.652	1.9784	2.1262	1.9334
Min	.4115	.3601	.3601	.4801	.4287	.5144	.463
Avg	.7952	1.3698	1.2074	1.2558	1.0619	1.0286	.9402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 203 / UNDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.9945	1.166	1.5432		.7545	.8589
2	.5788	.9774	1.0974	1.4403	.7842	.7202	.7842
3	.5601	.9774	1.0974	1.4403	.7842	.7202	.7655
4	.6161	.9945	1.0974	1.4403	.8215	.7202	.7655
5	.6722	1.1145	1.2003	1.4403	.8962	.7545	.7842
6	1.0082	1.2003	1.6461	1.5775	1.0269	.9602	1.0642
7	1.307	1.6975	2.1262	2.0317	1.2323	1.166	1.2883
8	1.1576	1.869	2.2977	2.2283	1.2323	1.0288	1.1576
9	.9896	1.5432	1.3375	1.8351	1.1203	.8916	.8962
10	2.1548	.8589	.8029	.9522	2.7949	2.6063	2.1216
11	2.0388	.8402	.8775	.8775	2.7515	2.692	2.1714
12	2.0056	.8215	.8589	.9522	2.7183	2.5549	2.1548
13	1.9227	.8215	.8215	.8962	2.7018	2.4177	2.0056
14	1.7901	.8215	.8215	.8775	2.4034	2.1605	1.8896
15	1.7238	.8775	.8589	.8775	2.4531	2.0748	1.8233
16	1.6409	.8775	.9335	.8775	2.2874	2.0576	1.7901
17	1.326	.8775	.8962	.9709	2.1879	1.749	1.6907
18	.9149	.8962	.852	1.0642	.8916	.7655	.8916
19	1.2883	1.307	1.3756	1.3256	1.2003	1.4937	1.448
20	1.475	1.4937	1.4937	1.5684	1.5927	1.643	1.643
21	1.363	1.3443	1.3756	1.4937	1.448	1.475	1.5684
22	1.1576	1.1389	1.1584	1.307	1.3032	1.3443	1.3443
23	.8589	.8589	.823	1.0456	.9602	1.0082	1.0136
24	.6535	1.0117	1.286	1.6461	.8215	.823	.9335
Max	2.1548	1.869	2.2977	2.2283	2.7949	2.692	2.1714
Min	.5601	.8215	.8029	.8775	.7842	.7202	.7655
Avg	1.2417	1.0923	1.1792	1.3212	1.5832	1.4409	1.3689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 201 / TAMBVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	.3292	.3772	.4481	1.3435	1.4563	1.4632
2	1.419		.3772	.4108	1.2944	1.419	1.4632
3	1.419	.2926	.3772	.3734	1.3108	1.419	1.4632
4	1.4563	.2926	.3772	.4108	1.3108	1.4563	1.4632
5	1.531	.3658	.415	.4481	1.3763	1.4937	1.4632
6	1.643	.5121	.6602	.5975	1.5893	1.4937	1.7375
7	1.9044	.6584	.811	.7468	1.8842	1.7924	2.0485
8	.7095	.6602	.6161	.6722	1.8187	2.0165	2.0485
9	.5121	.5658	.5228	.4755	1.7924	1.7101	1.6766
10	.3841	2.6543	2.6886	2.4905	.439	.4294	.3841
11	.3841	2.6543	2.7435	2.2283	.3658	.4108	.4066
12	.3475	2.5232	2.5377	2.4577	.3658	.4108	.3734
13	.3109			2.2283	.4024	.3734	.3734
14	.3841	2.5232	2.0576	2.2611	.439	.4207	.3361
15	.439	2.5888	2.4691	2.2283		.439	.2614
16	.3658	2.4249	2.4006	2.0153	.4755	.439	.2801
17	.4024	2.2119		1.9334	.4481	.4938	.5228
18	.439	.3292	2.0165	.5853	.4481	.5658	.5068
19	.6767	.5228	.8215	.7682	.7468	.7316	.7468
20	.8413	.9709	.9709	.9328	.9335	.9145	.9335
21	.8048	.9242	.9335	.8779	.9335	.9511	.9335
22	.7316	.811	.8215	.823	.8962	.8413	.8589
23	.4572	.547	.5975	.5735	.6722	.6584	.6722
24	1.6057	.3658	.415	.4854	1.4091	1.4937	1.5729
Max	1.9044	2.6543	2.7435	2.4905	1.8842	2.0165	2.0485
Min	.3109	.2926	.3772	.3734	.3658	.3734	.2614
Avg	.8609	1.1695	1.1822	1.1447	.9868	.9929	.9996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 202 / SAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.1097	.0943	.112	.639	.6722	.695
2	.4854	.1097	.0943	.0934	.6554	.6348	.695
3	.5228	.1097	.0943	.112	.6554	.6348	.695
4	.5228	.1097	.0943	.112	.6554	.6722	.695
5	.5601	.1097	.1132	.1307	.6554	.7095	.6584
6	.5601	.1463	.1886	.168	.7209	.7842	.7865
7	.6154	.2378	.2263	.1867	.8356	.8962	.9145
8	.1307	.2075	.1867	.1867	.7537	1.0082	.8779
9	.1097	.1509	.1494	.1311	.8962	.8383	.7377
10	.0914	1.0814	1.2003	1.278	.128	.1307	.1097
11	.0732	1.1469	1.3717	1.1305	.1463	.1307	.1663
12	.0732	1.1469	1.1576	1.2289	.128	.1494	.1494
13	.1463			1.2452	.1463	.1494	.1494
14	.1463		.9259	1.1797	.128	.1646	.1494
15	.1463	1.1797	1.2346	1.065	.1463	.1463	.1494
16	.1463	1.2616	1.2689	.9995	.1463	.1463	.1307
17	.1463	1.1305		.9503	.1307	.1463	.1307
18	.1463	1.0852	.9602	.1829	.1494	.1646	.168
19	.2195	.2427	.2427	.2195	.2241	.2561	.2241
20	.2303	.2614	.2614	.2561	.2427	.2577	.2614
21	.2378	.2452	.2427	.2561	.2614	.2561	.2614
22	.2195	.2263	.2241	.2195	.2241	.2195	.2241
23	.1463	.1509	.1494	.1646	.1867	.1646	.1494
24	.6348	.128	.1132	.1307	.6062	.7095	.7316
Max	.6348	1.2616	1.3717	1.278	.8962	1.0082	.9145
Min	.0732	.1097	.0943	.0934	.128	.1307	.1097
Avg	.2847	.4808	.4816	.4891	.3942	.4184	.4129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 203 / AREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.0732	.0754	.0747	.3932	.4854	.5121
2	.4481	.0732	.0754	.056	.3932	.4481	.3521
3	.4481	.0732	.0754	.056	.3932	.4108	.5121
4	.4481	.0732	.0754	.0747	.3932	.4481	.5121
5	.5228	.0732	.0754	.0934	.3932	.4854	.4961
6	.5601	.0914	.1132	.112	.4752	.5228	.5121
7	.5975	.128	.132	.1494	.5898	.6348	.6584
8	.0934	.0943	.1307	.1307	.639	.7095	.6584
9	.1097	.1132	.0934	.1097	.6036	.5365	.57
10	.0914	.7209	.6859	.7209	.0914	.0934	.1097
11	.0366	.7209	.7545	.7701	.0732	.0934	.112
12	.0914	.7209	.6859	.8029	.1097	.112	.112
13	.0914				.1097	.112	.112
14	.1097	.7209		.7701	.1097	.1097	.112
15	.1097	.7209	.6859	.7373	.1097	.1097	.112
16	.0914	.7209	.6859	.6882	.1417	.1097	.112
17	.0914	.5079		.639	.112	.1097	.1494
18	.0914	.1463	.5487	.1463	.112	.1518	.168
19	.1646	.2241	.2241	.1829	.2241	.2195	.2241
20	.2195	.2241	.2614	.2378	.2241	.2195	.2427
21	.1829	.2263	.2241	.2378	.2172	.2195	.2241
22	.1646	.1886	.1867	.1829	.2054	.1829	.2241
23	.0914	.1132	.1307	.128	.1494	.1463	.1494
24	.4854	.0732	.0754	.0934	.3932	.5228	.5121
Max	.5975	.7209	.7545	.8029	.639	.7095	.6584
Min	.0366	.0732	.0754	.056	.0732	.0934	.1097
Avg	.2412	.2966	.2855	.3128	.2773	.2997	.3108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 204 / TAMBAVE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1638	.1097	.1867	.1147	.3475
2	.4481	.3277	.2561	.3734	.3768	.3475
3	.8589	.3768	.2561	.4481	.4424	.0549
4	.8962	.3768	.2561	.4481	.4424	.0549
5	1.3443	.9995	.8596	.4481	.4424	.0549
6	1.3817	1.0322	.8596	.4481	.4915	.4207
7	1.4377	1.0814	.8596	.4481	.5735	.7499
8	1.4003	1.1157	.8775	.5228	.5243	.9328
9	1.3169	.7499	.8589	.4588	.5853	.8596
10	1.2289	.7499	.8573	.2785	.6219	1.0242
11	1.1633		.9259	.4424	.6401	1.0974
12	1.1961	.7499	.3772	.5243	.6401	1.134
13	1.1961	.7499	1.0288	.5243	.567	1.2803
14	1.1797	.7499	1.166	.5243	.5853	1.2803
15	1.1961	.7499	1.3032	.5243	.5487	1.3169
16	.2785	.128	.2743	.2458	.1829	.2012
Max	1.4377	1.1157	1.3032	.5243	.6401	1.3169
Min	.2241	.128	.1097	.1867	.1147	.0549
Avg	1.0467	.6734	.6954	.4279	.4862	.6973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254056 / 33/11 KV KALE

Feeder No / Name : 202 / PACHWAD

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.0069	.0091		.0131	1.1561
2	.0145	.0069		.0109	.0131	1.1561
3	.0143	.0069	.0097	.0109	.0133	1.1561
4	.0143	.0072	.0097	.0114	.0131	1.1561
5	.0143	.0072	.0109	.012	.0133	1.1561
6	.0143	.0076	.0103	.0126	.0131	1.2003
7	.0143	.0103	.0107	.0126	.0131	1.1574
8	.0143	.0097	.0099		.0131	1.1561
9	.0143	.0097	.0099	.0097	.012	1.1561
10	.1947	.0097	.0107	.0097	.012	1.1717
11	.0053	.0091	.0126	.0086	.0097	1.1873
12	.0053	.0091	.0126	.0107	.0097	1.1574
13	.0053	.0091	.0114	.0099	.04	1.1431
14	.0053	.0091	.0114		.8642	1.1574
15	.0057	.0103	.0114	.0099	1.1561	1.1717
16	.0057	.0091	.012	.0107	.0122	.0109
Max	.1947	.0103	.0126	.0126	1.1561	1.2003
Min	.0053	.0069	.0091	.0086	.0097	.0109
Avg	.0223	.0086	.0108	.0107	.1388	1.0906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254056 / 33/11 KV KALE

Feeder No / Name : 204 / KODOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1561	.0747	.0943	.1132	1.2498	1.1574	1.3125
2	1.1111	.0747	.0754	.0943	1.2029	1.1111	1.2967
3	1.0517	.0747	.0754	.0754	1.1873	1.0648	1.1736
4	1.0059	.0747	.0754	.0754	1.2186	1.1111	1.1736
5	1.0059	.112	.0943	.0754	1.2651	1.1574	1.3123
6	1.1248	.112	.1132	.1132	1.5524	1.3889	1.5181
7	1.4706	.1294	.1509	.1829	2.0317	2.1136	1.8564
8	.1433	.1629	.1463	.1991	2.0081	2.1136	1.7869
9	.1402	.1646	.1848	.2018	1.6964	1.8461	1.7341
10	.1075	.9842	2.8841	3.0849	.1094	.1254	.0886
11	.1448		2.8841	3.1327	.1086	.1417	.104
12	.1267		3.0996	3.0001		.1254	.1075
13	.1402	3.219	3.0333	2.7349	.1075	.1109	.1214
14	.1052	3.152	2.9835	2.7349	.1075	.1267	.1075
15	.1254	2.9675	2.6852	2.7035	.1402	.1448	.1463
16	.12	2.6658	2.5724	2.5724	.1417	.1448	.124
17	.1417	2.5819	2.7018	2.3758	.1595	.1734	.1663
18	.128	.0747	.1402	.116	.1753	.1526	.1595
19	.1629	.1629	.1463	.1612	.1791	.1448	.1646
20	.1663	.1646	.1663	.181	.181	.1629	.1829
21	.1663	.1478	.1478	.1646	.1629	.1463	.1829
22	.1307	.1307	.1478	.1629	.1629	.1478	.1646
23	.112	.112	.1294	.1448	.181	.1267	.1478
24	1.2334	.0747	.0943	.1132	1.2498	1.3426	1.3599
Max	1.4706	3.219	3.0996	3.1327	2.0317	2.1136	1.8564
Min	.1052	.0747	.0754	.0754	.1075	.1109	.0886
Avg	.4717	.7917	1.0344	1.0214	.7208	.6825	.6872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 201 / 11 KV Wing AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9804	.0686	.0924	.0943	.9393	.8802	.6405
2	.9602	.0686	.0914	.0943	.9393	.8642	.6405
3	.9393	.0686	.1097	.0943	.9175	.8642	.6405
4	.9393	.0686	.1097	.0943	.9503	.8482	.6562
5	.9717	.0686	.1267	.1132	1.0159	.9393	.6874
6	1.085	.0857	.1267	.1132	1.0814	.9922	.7811
7	1.2308	.1029	.1267	.1509	1.2955	1.2003	.9061
8	.1187	.12	.1402	.1698	1.2323	1.0883	.9217
9	.1357	.132	.0829	.1475	.8855	1.0719	.8684
10	.1402	1.6049	1.6644	1.4419	.132	.104	.1372
11	.1227	1.6964	1.7741	1.5729	.1132	.1006	.1029
12	.1307	1.6964	1.8107	1.6221	.0943	.12	.0857
13	.1307	1.6446	1.701	1.4746	.0924	.1017	.1029
14	.1254	1.6129	1.6644	1.4419	.3326	.1187	.0857
15	.12	1.5844	1.6278	1.3272	.1109	.1372	.12
16	.1147	1.4723	1.4998	1.2944	.132	.1372	.1372
17	.1372	1.3123	1.3125	1.3535	.12	.1886	.1187
18	.12	.0838	.1294	.0983	.12	.1698	.1357
19	.12	.1052	.1698	.1296	.1543	.1698	.1772
20	.12	.124	.1509	.1417	.1543	.2075	.1772
21	.12	.1433	.1698	.1448	.1372	.1509	.1629
22	.1029	.1097	.1509	.1463	.12	.1509	.1629
23	.0686	.0924	.0943	.128	.1029	.1132	.1448
24	1.0562	.0686	.0739	.1132	.9282	.8802	.6173
Max	1.2308	1.6964	1.8107	1.6221	1.2955	1.2003	.9217
Min	.0686	.0686	.0739	.0943	.0924	.1006	.0857
Avg	.4204	.5890	.6250	.5626	.5042	.4833	.3838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 202 / 11 KV Wing Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2056	.1886	.2957	.2279	.1943	.2229	.2534
2	.1739	.1886	.2926	.2103	.1781		.2328
3	.176	.1886	.3292	.2103	.1802	.2058	.2328
4	.1781	.1886	.3658	.2103	.1966	.2058	.2328
5	.2105	.2401	.3982	.2303	.2622	.2572	.2686
6	.3239	.3086	.4163	.3403	.3277	.3258	.362
7	.3887	.4287	.4525	.4607	.3887	.3772	.4656
8	.4578	.4973	.4733	.463	.4161	.4287	.4115
9	.4409	.4287	.4475	.4115	.4161	.4435	.4115
10	.4207	.4409	.4572	.2915	.3932	.4161	.4287
11	.394	.3768	.439	.3772	.3441	.3856	.4115
12	.3734	.3768	.3841	.3944	.3563	.3429	.3944
13	.4108	.3563	.3439	.3429	.3239	.3222	.3601
14	.3582	.2881	.3292	.3429	.3018	.3391	.3429
15	.3601	.2753	.3292	.3601	.2915	.3429	.3429
16	.3441	.2915	.3475	.3601	.3077	.3429	.3601
17	.3801	.3841	.3441	.4572	.3944	.3725	.407
18	.12	.4024	.3725	.426	.3944	.421	.4409
19	.4887	.443	.4973	.4858	.4458	.5201	.5493
20	.4801	.4477	.5258	.5316	.4973	.5138	.567
21	.3944	.4477	.4835	.4887	.463	.4835	.5068
22	.3429	.4024	.394	.439	.4115	.4477	.4344
23	.2572	.3696	.3045	.3292	.3429	.362	.362
24	.208	.2058	.3326	.2454	.2241	.2401	.2715
Max	.4887	.4973	.5258	.5316	.4973	.5201	.567
Min	.12	.1886	.2926	.2103	.1781	.2058	.2328
Avg	.3287	.3403	.3898	.3599	.3355	.3617	.3771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 203 / 11 KV YERAVALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9172	.0686	.0554	.0754	1.0202	1.0562	1.012
2	.8962	.0686	.0549	.0754	1.0202	1.0402	.9686
3	.8745	.0686	.0549	.0754	1.0159	1.0402	.953
4	.8745	.0686	.0732	.0754	1.0486	1.0082	.953
5	.9393	.0686	.0905	.0943	1.0814	1.0242	.953
6	.9717	.0857	.1086	.0943	1.0978	1.0562	1.012
7	1.0364	.1029	.1267	.132	1.166	1.1843	1.1405
8	.0848	.0857	.1052	.1132	1.1203	1.1043	.5093
9	.1017	.1509	.0995	.0838	.5155	1.1827	.4801
10	.0876	.7116	1.2071	1.1305	.0943	.0693	.0857
11	.0895	.7343	.8413	1.2944	.1132	.0671	.0857
12	.0747	.7811	.823	1.1797	.0747	.0686	.0686
13	.0747	.7253	1.3575	1.2289		.0678	.1029
14	.0716	.679	1.3717	1.2289	.0739	.0678	.0857
15	.0857	.6483	1.3717	1.2289	.0924	.0686	.0857
16	.0819	.6249	1.3535	1.2452	.1132	.1029	.0686
17	.0857	.5921	1.0957	1.3717	.12	.0943	.1017
18	.1029	.0671	.0924	.0655	.0857	.1132	.1017
19	.12	.0876	.132	.081	.0857	.1132	.124
20	.12	.1063	.132	.0886	.1029	.132	.124
21	.0857	.1075	.1132	.1086	.12	.1132	.1267
22	.0686	.0914	.0943	.1097	.1029	.1132	.1267
23	.0686	.0739	.0754	.0732	.1029	.0943	.1086
24	.9602	.0686	.0739	.0754	1.0082	1.0562	1.0242
Max	1.0364	.7811	1.3717	1.3717	1.166	1.1843	1.1405
Min	.0686	.0671	.0549	.0655	.0739	.0671	.0686
Avg	.3697	.2861	.4543	.4721	.4946	.5016	.4334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 201 / 11 KV Kasarshirambe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	1.0059	1.0898	1.0185	.156	.1753	.1753
2	.1267	1.0059	1.073	.9979	.156	.1715	.1753
3	.1267	1.0059	1.073	.9979	.156	.1715	.1715
4	.1629	1.0227	1.0562	1.0349	.156	.1715	.1715
5	.1612	1.0562	1.1736	1.0903	.1734	.1715	.1886
6	.1791	1.1401	1.1736	1.1827	.1734	.1886	.2058
7	.197	1.1271	1.5746	1.6263	.2075	.2229	.2454
8	.2378	1.5415	1.6221	1.8296	.2452	.2374	.2427
9	.2054	1.4083	1.4413	1.6448	.1696	.1509	.1867
10	1.3203	.1663	.1543	.1187	2.0302	2.0485	1.8671
11	2.32	.1646	.1006	.1526	2.2546	2.0851	2.0538
12	2.2822	.1646	.1017	.1509	2.2916	2.1538	2.2634
13	2.3011	.1132	.1174	.1174	2.1582	2.0814	2.0668
14	2.2257	.088	.1174	.1174	2.0485	1.9547	1.957
15	2.0936	.0975	.1187	.1174	1.9959	1.7924	
16	2.037	.0914	.1357	.1187	2.1437	1.8107	1.9978
17	1.7353	.1543	.116	.1357	1.8107	1.3717	1.6409
18	.1174	.1658	.1433	.1475	.1492	.1629	.16
19	.2353	.2328	.2378	.2149	.2353	.2353	.2126
20	.2614	.2402	.2427	.2353	.2587	.2987	.2587
21	.2427	.2427	.2452	.2402	.2801	.2614	.2772
22	.2054	.2263	.2263	.2427	.2614	.2641	.2641
23	.1867	.2054	.1886	.1867	.2263	.2263	.2263
24	.168	1.046	1.0402	.9602	.1698	.1886	.2263
Max	2.32	1.5415	1.6221	1.8296	2.2916	2.1538	2.2634
Min	.1174	.088	.1006	.1174	.1492	.1509	.16
Avg	.8023	.5714	.6068	.6116	.8295	.7749	.7493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 202 / 11 KV Malkhed

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.3521	1.1317		.8939	.9816
2	.0503	.4862	2.0144	1.5604	1.6118	.8939
3	.0503	.4862	2.0328	1.6297	1.6118	.8573
4	.0503	.4862	2.0328	1.6297	1.6461	1.286
5	.1174	.4862	2.0883	1.6297	1.6632	1.3032
6	.1677	.503	2.1437	1.6297	1.6461	1.3203
7	.1174	.5138	2.1992	1.8861	1.6632	1.3146
8	.3812	.5079	1.9774	1.8107	1.7465	1.5777
9	.503	.583	1.9035	1.7295	1.6766	1.8298
10	.5544	1.4232	1.7635	1.8839	1.7741	1.1157
11	.5304	1.9951	1.7465	1.922	1.957	1.829
12	.5304	2.0348	1.6933	1.885	1.9004	1.8473
13	.1257	1.9951	1.6933	1.8656	1.8823	.7682
14	.1257	1.9951	1.6933	1.8656	1.9004	2.3045
15	.1219	2.0348	1.6766	1.8665	1.9022	2.2862
16	.1143	1.543	.9496	.9979	1.7558	1.2986
23			.1867			
24		.16			.1886	
Max	.5544	2.0348	2.1992	1.922	1.957	2.3045
Min	.0503	.16	.1867	.9979	.1886	.7682
Avg	.2244	1.0345	1.7016	1.7195	1.6129	1.4259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 203 / 11KV Kalawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0671	.0838	.1132	.104	.1227	.1052
2	.0724	.0671	.0838	.0924	.104	.12	.1052
3	.0724	.0671	.0838	.0924	.104	.12	.1029
4	.0895	.0671	.0838	.0924	.104	.12	.1029
5	.1254	.1006	.1006	.1294	.1214	.12	.12
6	.1433	.116	.1174	.1478	.1214	.1372	.1543
7	.1612	.1677	.1492	.1663	.1886	.1543	.1753
8	.1829	.1492	.1638	.2218	.2263	.1696	.1734
9	.1494	.1509	.1457	.1663	.1696	.1677	.1867
10	.132	.1478	.12	.1187	.1463	.1463	.1463
11	.1132	.1646	.1174	.1357	.1478	.1646	.1463
12	.132	.1463	.1187	.1509	.1663	.181	.128
13	.1509	.1006	.1174	.1174	.1463	.1629	.1494
14	.132	.1006	.1341	.1341	.1463	.1629	.1463
15	.1132	.0975	.1017	.1341	.1294	.1646	.1463
16	.1132	.0914	.1357	.1357	.1478	.1646	.128
17	.1509	.1029	.1326	.1526	.1698	.1219	.1698
18	.1509	.1658	.1433	.1475	.1658	.1448	.16
19	.1829	.2149	.2195	.2149	.2172	.1991	.2126
20	.2054	.2033	.2075	.2353	.2218	.2241	.2218
21	.1867	.1867	.2075	.2218	.2241	.2054	.2218
22	.168	.1698	.1698	.2054	.2054	.1886	.1886
23	.112	.112	.132	.1494	.132	.132	.1132
24	.0747	.0857	.08	.1029	.1132	.132	.1132
Max	.2054	.2149	.2195	.2353	.2263	.2241	.2218
Min	.0724	.0671	.08	.0924	.104	.12	.1029
Avg	.1328	.1268	.1312	.1491	.1551	.1553	.1507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 203 / NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	1.2346	1.5278		.5415	.547	.547
2	.4207	1.2346	1.5123		.5415	.547	.547
3	.4207	1.1883	1.4327		.5228	.547	.5281
4	.4207	1.2346	1.4022		.5093	.547	.547
5	.5093	1.2963	1.4022		.5281	.6036	.6036
6	.7356	2.0965	1.7078		.7356	.7356	.7356
7	.9997	2.0965	2.2297		.9896	.8865	.9896
8	.811	1.2346	2.4669		.9055	.7468	.7947
9	.7023	1.8435	2.0153		.5249	.5914	.6036
10	2.6566	.4938	.5175	.567	2.609	2.6246	2.5459
11	2.9447	.4706	.4706	.5121	2.8241		2.6886
12	2.9927	.4706	.3801	.4706	2.9571	2.0399	2.6406
13	2.8147	.4656	.3841	.4298	2.7989	2.6566	2.2862
14	2.5617	.4656	.499	.4938	2.6882	2.6092	2.3765
15	2.3403	.4706	.5175	.4887	2.6402	2.6715	2.3403
16	2.2965	.4298	.4887	.543	2.5143	2.4371	2.3434
17	1.9599	.5359	.5611	.5731	2.2565	2.1403	2.1872
18	.567	.6154	.5973	.5249	.5552	.5544	.5552
19	.8215	.7947	.9335	.8131	.9055	.9979	.7947
20	.9149	.8962	.8962	.9335	.9335	.9896	.961
21	.8488	.8589	.8962	.8589	.8962	.9335	.924
22	.7545	.7545	.811	.8299	.8775	.8775	.8686
23		.547	.6413	.6602	.6979	.679	.679
24	.4755	1.2809	1.5623		.5975	.5847	.5847
Max	2.9927	2.0965	2.4669	.9335	2.9571	2.6715	2.6886
Min	.4207	.4298	.3801	.4298	.5093	.547	.5281
Avg	1.3213	.9587	1.0772	.6213	1.3563	1.2412	1.2780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 205 / RETHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	1.3889	1.3546	1.4232	.7049	.7049	.7049
2	.5525	1.3546	1.3375	1.3904	.6859	.6859	.7049
3	.5525	1.3375	1.3056	1.3735	.6668	.6859	.7049
4	.5335	1.3546	1.3395	1.3735	.6668	.6478	.6668
5	.6097	1.3889	1.3735	1.3904	.6478	.6859	.679
6	.811	1.6118	1.5775	1.56	.7733	.7922	.7922
7	.9431	1.8313	1.9113	1.8351	.9242	.8676	.9431
8	.8488	2.0287		1.9433	.9335	.8775	.8775
9	.6908	1.8067	.6478	1.749	.6348	.6348	.6468
10	2.5692	.5544	.6099	.6468	2.4863	2.5652	2.5316
11	2.561	.4938	.6401	.6219	2.6322	2.7664	2.6993
12	2.7681	.4572	.5914	.5487	2.536	2.8012	2.7469
13	2.5434	.6584	.6099	.6335	2.5692	2.652	2.649
14	2.3868	.6219	.6348	.7392	2.4863	2.5692	2.5029
15	2.3868	.679	.6722	.6099	2.3266	2.1792	2.4478
16	2.304	.6468	.6653	.6838	2.4034	2.2939	2.4086
17	2.1382	.6767	.6036	.5914	2.2542	2.2611	2.1548
18	.5601	.6584	.6468	.6584	.6219	.6838	.6099
19	1.0185	.9709	1.2071	1.0269	1.0082	1.1203	1.0456
20	1.1506	1.1389	1.1506	1.1576	1.1883	1.226	1.251
21	1.0562	1.1128	1.1694	1.1317	1.1694	1.226	1.2136
22	.9619	1.0185	1.0374	1.094	1.1317	.9431	1.094
23	.811	.811	.8488	.8488	.9242	.8676	.9054
24	.6097	1.3889	1.4232	1.4403	.7356	.7733	.7545
Max	2.7681	2.0287	1.9113	1.9433	2.6322	2.8012	2.7469
Min	.5335	.4572	.5914	.5487	.6219	.6348	.6099
Avg	1.3300	1.0829	1.0156	1.1030	1.3796	1.3963	1.4056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 206 / KALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	1.8351	1.9662	1.8679	.9431	.909	.9808
2	.724	1.7859	1.8947	1.8515	.9054	.9054	.9619
3	.724	1.7695		1.8023	.8865	.8954	.9619
4	.724	1.7859	1.8785	1.8351	.8865	.8865	.9808
5	.8676	1.7859	1.9989	1.9227	1.0185	.9808	1.0751
6	1.1763	2.1216	2.2542	2.1548	1.3014	1.2071	1.3203
7	1.4901	2.5692	2.4905	2.3685	1.358	1.4146	1.4523
8	1.1883	2.5101	2.4486	2.4036	1.1949	1.2136	1.2883
9	.9425	2.3482	2.1247	2.1032	.7762	.8686	.9425
10	3.7029	.7207	.7133	.8501	3.3753	3.3813	3.4408
11	4.0575	.7207	.6838	.7392	3.6466	3.5555	1.5524
12	3.5883	.7316	.7133	.6283	3.6466	1.692	3.834
13	3.9158	.7947	.7577	.7133	3.4656	1.7078	3.6717
14	3.3288	.8215	.7655	.6838	3.4818	3.0769	3.3916
15	3.3036	.8676	.7655	.6653	3.4979	1.5154	3.2388
16	3.1579	.543	.7762	.6767	3.3522	1.5278	
17	2.9312	.823	.8145	.7964	3.1579	1.3735	3.3753
18	1.7375	.8507	.8131	.8326	.9328	1.1157	.9593
19	1.307	1.363	1.531	1.2883	1.3443	1.6804	1.475
20	1.5278	1.6057	1.6244	1.6244	1.6409	1.7177	1.8298
21	1.4712	1.5089	1.6409	1.6032	1.6221	1.6991	1.7541
22	1.3014	1.3957	1.4335	1.4901	1.6032	1.6221	1.5466
23	1.0562	1.0185	1.1128	1.1694	1.2637	.9997	1.3203
24	.811	1.8679	2.0153	1.8515	.9997	1.0374	1.0751
Max	4.0575	2.5692	2.4905	2.4036	3.6466	3.5555	3.834
Min	.724	.543	.6838	.6283	.7762	.8686	.9425
Avg	1.9074	1.4227	1.4442	1.4134	1.9292	1.5410	1.8447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 401 / 33 kv malkapur

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 402 / 33 KV UNDALE

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 404 / 33 KV kale

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 405 / 33 kv kalawade

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 201 / 11 KV NAGARPALIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.7164	.6584	.7522	.7842	.7164	.8596
2		.6805	.5853	.7164	.7468	.6447	.788
3	.6878	.6805	.5853	.7164	.7468	.6516	.788
4	.7316	.6805	.5853	.7164	.7282	.7011	.788
5	.8048	.6805	.6219	.7164	.7282	.8413	.788
6	.8413	.7164	.7316	.7522	.8215	.9511	.8596
7	.9145	.788	.9145	.8596	.8215	1.0608	1.0029
8	.9877	.9313	1.0719	1.0029	1.0242	.9877	1.0387
9	.9145	.9313	.9145	1.0029	1.0534	.9511	.9313
10	.8779	.9511	.9955	1.0242	.9313	.8962	.9511
11	.9145	1.3321	.9774	.9877	.9671	.8596	1.0242
12	.9511	.9593	1.0317	1.0136	.9671	.8688	1.0136
13	.9511	1.0029	.9313	.9774	1.0745	.8779	1.0425
14	.8779	.9313	.9593	.9145	1.0029	.7964	1.0242
15	.9145	.8869	.9328	.9145	1.0608	.8145	.8048
16	.9145	.8688	.9145	.9145	1.0029	.8145	.9774
17	.961	.9511	.9955	.9511	1.0387		1.0791
18	1.1088	1.0242	1.0679	1.086	1.0498	.9511	1.4685
19	1.4685	1.4632	1.5043	1.448	1.6095	1.4327	1.5402
20	1.4327	1.4632	1.4685	1.5203	1.5729	1.2894	1.576
21	1.1462	1.1706	1.2536	1.267	1.3394	1.1104	1.3969
22	1.0029	1.0242	1.0745	1.1157	1.1706	1.0745	1.182
23	.8596	.8871	.9671	1.0349	1.0387	1.0029	1.0029
24	.7316	.7522	.7392	.788	.8775	.8688	.8954
Max	1.4685	1.4632	1.5043	1.5203	1.6095	1.4327	1.576
Min	.6584	.6805	.5853	.7164	.7282	.6447	.788
Avg	.9415	.9364	.9367	.9664	1.0066	.9202	1.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 202 / 11 KV KRISHNA GHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7164	.6584	.7164	.8029	.7316	.7164
2	.5853	.7164	.5853	.6805	.7655	.6584	.6805
3	.5853	.7164	.5853	.6805	.7468	.6447	.6805
4	.6584	.7164	.5853	.6805	.7468	.695	.6805
5	.6878	.7164	.6219	.6805	.7468	.7682	.7164
6	.7316	.7164	.7316	.7522	.8589	.8779	.7522
7	.7316	.7164	.8413	.8596	.9896	.9511	.8596
8	.9511	.8238	.8413	1.0029	.9328	.9511	.8596
9	.8413	.8238	.8048	.9313	.9425	.8779	.8954
10	.9877	.9877	1.0059	.9877	1.0745	.961	.9774
11	.9877		1.0679	1.086	1.1104	.961	1.0974
12	.9877	1.0498	1.0425	1.0242	1.0745	.4835	1.0498
13	.9511	.9671	1.0498	.9877	1.0745	.4755	1.0608
14	.9511	.8596	1.0498	1.0242	1.0745	.5121	1.0974
15	.9511	.8962	1.0608	.9511	1.0974	.4938	1.0974
16	.9511	.905	.9877	.9511	1.0029	.5068	.9877
17	.961	.8779	1.0242	.9145	1.0745	.9511	1.0242
18	1.0349	.9877	.9795	.9412	1.1222	1.0242	1.182
19	1.2894	1.2567	1.2178	1.3032	1.448	1.2894	1.3611
20	1.2536	1.3169	1.3253	1.3535	1.3756	1.1462	1.3611
21	1.0745	1.1706	1.1104	1.1888	1.2437	1.1104	1.1462
22	.9671	1.0242	1.0745	1.1157	1.1104	1.0029	1.0029
23	.8954	.9145	.9313	1.0534	1.0608	.9313	.9313
24	.7316		.7316	.7522	.8775	.8688	.7522
Max	1.2894	1.3169	1.3253	1.3535	1.448	1.2894	1.3611
Min	.5853	.7164	.5853	.6805	.7468	.4755	.6805
Avg	.8916	.9035	.9131	.9425	1.0148	.8281	.9571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 203 / 11 KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.7682	.6584	.9511	.8962	.7682	.8954
2	.6584	.7316	.5853	.9145	.8299	.695	.8779
3	.695	.7316	.5853	.9145	.8215	.7316	.8779
4	.7682	.7316	.5853	.9145	.8299	.8048	.8779
5	.8779	.7316	.6219	.9145	.8676	.8779	.8779
6	.9511	.7682	.7316	.9877	1.0562	.9877	.9145
7	1.0242	.9511	1.0242	1.1706	1.2071	1.0608	1.2437
8	.9412	.9877	.9877	1.1706		.9877	1.134
9	.9145	.9511	.9709	1.0974	1.0185	.9877	1.0608
10	.8962	1.0456	1.0608	1.086	.9511	.9877	1.134
11	.9145	.9774	1.1157	1.0608	1.0974	.961	1.134
12	.9877	1.0562	1.1523	.9877	1.0974	.9511	1.2071
13	.9877	1.0242	1.134	.9145	1.0974	.9511	1.134
14	.9511	.924	1.1088	.8688	1.0829	.439	1.1523
15	.9511	.924	1.1088	.905	1.0608	.439	.8779
16	.9511	.9328	1.1888	.8688	1.0242	.7682	1.1157
17	.9979	.8779	1.1706	.9145	1.0974	.7316	1.134
18	1.1458	1.0608	1.1706	1.1088	1.1462	1.3535	1.4998
19	1.2894	1.4632	1.5364	1.5546	1.6095	1.4998	1.6461
20	1.267	1.39	1.4632	1.4415	1.4632	1.39	1.4632
21	1.086	1.1706	1.3169	1.2567	1.3169	1.3535	1.3535
22	1.0242	.9877	1.1706	1.2136	1.2071	1.2803	1.2071
23	.9412	.8779	1.0974	1.1317	1.0608	1.134	1.0974
24	.7602	.8048	.7316	.9877	.9619	.905	.9877
Max	1.2894	1.4632	1.5364	1.5546	1.6095	1.4998	1.6461
Min	.6584	.7316	.5853	.8688	.8215	.439	.8779
Avg	.9446	.9529	1.0115	1.0557	1.0783	.9603	1.1210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 205 / 11 KV WAKHAN ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.362	.2926	.362	.3547	.3658	.3258
2	.2172	.3258	.2561	.3258	.3206	.3292	.2896
3	.2195	.3258	.2561	.3258	.3206	.2926	.2896
4	.2561	.3224	.2561	.3258	.3174	.2507	.2896
5	.2926	.3258	.2926	.3258	.3206	.2926	.2896
6	.3292	.3258	.3292	.3258	.3395	.3292	.3258
7	.3658	.3403	.3658	.362	.3961	.3258	.4344
8	.439	.3439	.4755	.4344	.3841	.362	.543
9	.4755	.362	.4755	.543	.5041	.2926	.5068
10	.439	.3403	.4572	.5121	.4344	.2629	.4163
11	.4755	.3012	.439	.5014	.4344	.2835	.4024
12	.4755	.2915	.4572	.4706	.4344	.3189	.439
13	.439	.2947	.4706	.4344	.4344	.2743	.439
14	.439	.2774	.4525	.439	.4706	.3155	
15	.439	.2947	.4251	.3982	.439	.2804	
16	.4024	.3155	.462	.3658	.4344	.2629	.4755
17	.9979	.3326	.4572	.4344	.4344	.3292	.4755
18	.4435	.3292	.4572	.4572	.4706	.2926	.6154
19	.5068	.5121	.6516	.6283	.6219	.4706	.6516
20	.5068	.5121	.6154	.6348	.6154	.4706	.6516
21	.5068	.439	.5373	.6161	.5792	.4706	.6154
22	.4706	.439	.5068	.5601	.5068	.4344	.6154
23	.4344	.3658	.4706	.4715	.4706	.3982	.5068
24	.3292	.3982	.3292	.4344	.4527	.4298	.362
Max	.9979	.5121	.6516	.6348	.6219	.4706	.6516
Min	.2172	.2774	.2561	.3258	.3174	.2507	.2896
Avg	.4231	.3532	.4245	.4454	.4371	.3390	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 206 / 11 KV COTTAGE HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.8215	.695	.7842	.811	.7316	.8589
2	.6516	.7468	.6219	.7468	.7733	.6584	.8215
3	.695	.7468	.6219	.7468	.7545	.6584	.8215
4	.7682	.7468	.6219	.7468	.7356	.7316	.8215
5	.8413	.7468	.6584	.7468	.7356	.8048	.8215
6	.8779	.8215	.8413	.8215	1.0562	.9145	1.0456
7	.9877	.9709	.9145	.9335	1.1506	.9877	1.0456
8	.9877	1.0829	.9511	1.0456	1.1203	1.0974	1.0829
9	1.0136	.9709	1.0349	1.1203	1.1883	1.0349	1.1576
10	1.2437	1.0642	1.251	1.1706	1.307	1.1088	1.267
11	1.2803		1.2883	1.1706	1.307	.9979	1.39
12	1.2437	1.1706	1.363	1.1946	1.3817	1.0164	1.3394
13	1.2437	1.1041	1.2696	1.134	1.307	1.0059	1.3169
14	1.2071	1.0242	1.251	1.0974	1.2696	.9425	1.3169
15	1.2071	1.0164	1.2637	1.0136	1.2437	.9055	1.3352
16	1.1888	.9709	1.2323	1.0498	1.307	.8871	1.2437
17	1.2197	.9145	1.2696	1.086	1.251	.9145	1.3169
18	1.2936	.9877	1.251	1.2826	1.3032	.9511	1.4937
19	1.531	1.3535	1.5684	1.531	1.5729	1.2696	1.6804
20	1.531	1.3169	1.5684	1.6057	1.5074	1.2696	1.6804
21	1.3443	1.0974	1.307	1.4563	1.3969	1.2323	1.4563
22	1.307	1.0608	1.251	1.3769	1.2803	1.1576	1.3817
23	1.0082	.9145	1.0456	.9997	1.1765	1.0456	1.1203
24	.7682	.8589	.7316	.8215	.9054	.8688	.8962
Max	1.531	1.3535	1.5684	1.6057	1.5729	1.2696	1.6804
Min	.6516	.7468	.6219	.7468	.7356	.6584	.8215
Avg	1.0884	.9787	1.0780	1.0701	1.1601	.9664	1.1963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 207 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2614	.3475	.2987	.2641	.2561	.2614
2	.2561	.2614	.3292	.2987	.2641	.2561	.2241
3	.2195	.2614	.3292	.2241	.1663	.2561	.2241
4	.2195	.2614	.3292	.2241	.1663	.2926	.2241
5	.2195	.2614	.3292	.2241	.1646	.2926	.2241
6	.2561	.2614	.3475	.2987	.1829	.3077	.2614
7	.2926	.2987	.2378	.3361	.1663	.3109	.2987
8	.2926	.2987	.3475	.3361	.2641	.2926	.1829
9	.2926	.1829	.3511	.3361	.2641	.2926	.2987
10	.3475	.3547	.3511	.3258	.1463	.2987	.2896
11	.2926	.2614	.3511	.3224	.2561	.2987	.1829
12	.3475	.3584	.3361	.2353	.1494	.2075	.2926
13	.3475	.3395	.3326	.2534	.2561	.2926	.2926
14	.3475	.3395	.3326	.1463	.1463	.2987	.1448
15	.3292	.3326	.2075	.2353	.2561	.2987	.2561
16	.3109	.3326	.1402	.2896	.2614	.2772	.2534
17	.3292	.3292	.1387	.2561	.1463	.1829	.1463
18	.3326	.2926	.1027	.2641	.2534	.2926	.2241
19	.3292	.3475	.2561	.2641	.2718	.2987	.2614
20	.2926	.3475	.3292	.2641	.2012	.1829	.1463
21	.2987	.3475	.2378	.2641	.2896	.2987	.2614
22	.2561	.3292	.3292	.2641	.2534	.2987	.2241
23	.2012	.2378	.3292	.2452	.2896	.1829	.2614
24	.2534	.2987	.3475	.3361	.168	.2926	.2987
Max	.3475	.3584	.3511	.3361	.2896	.3109	.2987
Min	.2012	.1829	.1027	.1463	.1463	.1829	.1448
Avg	.2891	.2999	.2946	.2726	.2187	.2733	.2390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 208 / 11 KV Chawadi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2195	.2561	.2195	.2452	.2195	.2561
2	.1791	.2195	.2195	.2195	.2263	.1829	.2195
3	.1991	.2195	.2195	.2195	.2263	.1829	.2195
4	.2195	.2195	.2195	.2195	.2263	.1829	.2195
5	.2328	.2195	.2378	.2195	.2263	.2195	.2195
6	.2561	.2195	.2743	.2561	.2641	.2561	.2561
7	.2926	.2743	.2926	.2926	.3206	.3109	.3109
8	.3403	.3292	.3475	.3658	.3206	.3292	.3109
9	.3292	.3292	.3395	.3475	.3206	.2926	.3109
10	.3109	.3584	.3395	.3658	.3475	.6036	.3582
11	.3475	.3772	.415	.394	.4207	.2829	.7642
12	.4024	.3961	.3961	.4024	.3658	.2452	.3841
13	.3658	.3961	.3772	.4163	.4207	.2561	.4024
14		.3772	.3395	.3475	.3658	.2263	.4024
15	.3475	.3395	.3772	.3258	.3841	.2829	.4024
16	.3881	.3772	.3961	.4024	.3841	.2452	.3658
17	.3696	.3658	.3961	.3475	.3658	.2378	.4024
18	.4435	.439	.415	.4338	.3982	.2926	.5121
19	.5853	.5853	.6219	.6413	.6447	.439	.6036
20	.567	.5853	.6219	.6602	.6219	.3841	.6401
21	.439	.439	.439	.5093	.4755	.3658	.4938
22	.2926	.3109	.2926	.3395	.3109	.3109	.3292
23	.2561	.2743	.2561	.3395	.2865	.3292	.2743
24	.2195	.2378	.2926	.2561	.2641	.2561	.2561
Max	.5853	.5853	.6219	.6602	.6447	.6036	.7642
Min	.1791	.2195	.2195	.2195	.2263	.1829	.2195
Avg	.3290	.3379	.3493	.3559	.3514	.2889	.3714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 201 / OGALEWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5658	.583	.6516	.6859	.6516	.6859
2	.5487	.5144	.5487	.6173	.6516	.6173	.6516
3	.5144	.5144	.5487	.6173	.6173	.583	.6173
4	.5144	.5144	.5144	.6173	.6173	.583	.6173
5	.6516	.6516	.6859	.6859	.6859	.7202	.7545
6	.8059	.8059	.823	.823	.8745	.8916	.9259
7	1.1145	1.1488	1.2346	1.1317	1.3032	1.0631	1.046
8	1.166	1.0802	1.1317	1.2174	1.2003	1.0974	1.2346
9	1.2174	1.1488	1.166	1.2003	1.0974	1.2689	1.2003
10	1.2174	1.2003	1.1317	1.2174	1.3546	1.1317	1.166
11	1.2689	1.1488	1.2174	1.1831	1.2689	.9602	1.1317
12	1.2517	.9774	1.1831	1.2407	1.2689	.7888	1.0631
13	1.046	.7545	1.0802	1.1831		.6859	1.0288
14	.9774	.8573	1.1145	.9602	1.1145	.8059	1.1145
15	1.406	.8745	1.1488	1.166	1.2346		
16	.9774	.8402	1.166	1.2003	1.3032	.8573	.9088
17	.7202	.5487	1.2003	1.2174	1.3375	.823	1.2174
18	.9945	.8573	1.2346	1.0117	1.286	.9602	1.2003
19	1.2517	1.286	1.3032	1.286	1.4746	1.2174	1.3717
20	1.1488	1.2689	1.2517	1.2003	1.3546	1.0974	1.286
21	1.0802	1.1145	1.1831	1.1145	1.2174	1.0974	1.2346
22	.9602	.9431	.9774	.9088	1.0117	1.0288	1.1317
23	.7545	.7202	.8059	.7716	.8916		.8402
24	.6859	.6344	.6173	.7545	.7202	.7716	.7545
Max	1.406	1.286	1.3032	1.286	1.4746	1.2689	1.3717
Min	.5144	.5144	.5144	.6173	.6173	.583	.6173
Avg	.9538	.8738	.9938	.9991	1.0683	.8955	1.0079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 202 / SAIDAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.2346	1.2346	1.2689	1.3032	1.406	1.3889
2	1.166	1.166	1.166	1.2003	1.2174	1.3546	1.3375
3	1.1145	1.1317	1.1317	1.1831	1.2003	1.3032	1.3032
4	1.1145	1.1145	1.1317	1.1831	1.2003	1.286	1.2517
5	1.4403	1.4575	1.5089	1.406	1.4403	1.4746	1.4575
6	1.8347	1.6975	1.749	1.6461	1.6632	1.9033	1.9547
7	2.7435	2.5549	2.6749	2.3834	2.6063	2.5206	2.572
8	2.8121	2.7435	2.6749	2.5034	2.4006	2.5549	2.7435
9	2.4691		2.4691	2.2977	2.2634	2.452	2.4691
10	2.1262	2.3148	2.1948	2.1948	1.6804	1.9033	2.1262
11	1.989	2.0748	1.989	1.9204	1.7147	1.6804	1.989
12	1.8176	1.8861	1.9033	1.7661	1.749	1.5775	1.8861
13	1.6118	1.7833	1.8176	1.6461	1.7147	1.5432	1.7833
14	1.7147	2.0576	1.749	1.6461	1.6975	1.4746	1.6289
15	1.6118		1.7661	1.6289	1.6804	1.5261	1.8519
16	1.6804	1.6804	1.7147	1.5775	1.7147		1.8519
17	1.749	1.6118	1.6804	1.5604	1.6632		1.9204
18	1.6975	1.6289	1.6975	1.7147	1.8176	1.9376	2.0062
19	2.2119	2.2291	2.1948	2.1605	2.2805	2.572	2.332
20	2.0919	2.1262	2.1776	2.0576	2.2291	2.2977	2.3834
21	1.989	1.989	1.989	1.989	2.2119	2.1434	2.2805
22	1.8861	1.8861	1.8861	1.8176	2.0576	1.9547	2.1605
23	1.6289	1.6461	1.5947	1.7147	1.8347	1.8519	1.8519
24	1.3717	1.4403	1.4403	1.4232	1.4575	1.5432	1.5432
Max	2.8121	2.7435	2.6749	2.5034	2.6063	2.572	2.7435
Min	1.1145	1.1145	1.1317	1.1831	1.2003	1.286	1.2517
Avg	1.7947	1.7934	1.8140	1.7454	1.7833	1.8300	1.9197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 203 / Surli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	2.915	2.915	2.0919	.2401	.2401	.2401
2	.2229	2.8978	2.8807	2.0576	.2058	.2229	.2229
3	.2229	2.8978	2.8292	2.0062	.2058	.2229	.2229
4	.2229	2.915	2.8292	2.0062	.2058	.2229	.2229
5	.2743	2.9492	3.0007	2.0062	.2743	.2401	.2401
6	.3601	3.0182	3.2236	2.0062	.3429	.2743	.2743
7	.4287	3.0967	3.3779	2.1605	.3944	.3258	.3258
8	.4973	2.0645	3.2407	2.34	.4115	.3429	.3944
9	.4115	2.0645	2.8292		.4115	.2743	.3258
10	3.2407	.2683	.3222	.2035	3.0514	4.1543	4.441
11	3.7304	.3391	.3856	.218	4.0695	.3561	4.4239
12	3.4252	.3521	.3391	.2713	.3052	.373	4.3724
13	4.1289	.407	.2883	.2543		2.8317	2.6578
14	3.2526	.39	.3391	.2515	2.7639	1.4922	2.4741
15	3.4294	.3561	.3521	.2883	1.1869		2.982
16	3.6626	.3353	.373	.3185	.8718	3.3404	3.1623
17	3.2217	.3561	.407	.3353	3.0521	3.3573	2.9165
18	.3944	.3521	.3601	.3222	.2883	.2915	.3601
19	.4115	.4287	.3772	.3944	.463	.463	.4115
20	.4115	.4115	.4287	.3772	.3772	.4115	.4458
21	.3772	.3944	.3944	.3429	.3601	.3601	.4115
22	.3944	.3772	.3772	.3258	.3601	.3429	.3944
23	.3429	.3429	.3944	.3086	.2915	.3086	.3601
24	.2915	2.8995	2.9664	2.0687	.2572	.2743	.2743
Max	4.1289	3.0967	3.3779	2.34	4.0695	4.1543	4.441
Min	.2229	.2683	.2883	.2035	.2058	.2229	.2229
Avg	1.4005	1.3679	1.4680	.9981	.8865	.9010	1.3565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 204 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.3086	.2743	.2743	.2743	.3086
2	.2743	.2401	.2743	.2401	.2743	.2401	.2743
3	.2401	.2401	.2743	.2401	.2743	.2401	.2743
4	.2401	.2401	.2401	.2401	.2401	.2401	.2401
5	.2743	.2743	.2743	.2743	.2743	.2743	.2743
6	.2743	.3429	.3086	.3086	.3086	.3086	.2743
7	.3086	.3429	.3429	.3086	.3429	.3086	.3086
8	.3086	.3429	.3086	.2743	.4115	.3086	.3429
9	.4801	.4115	.4458	.4801	.583	.3086	.4115
10	.583	.4458	.4458	.4801	.583	.2743	.5144
11	.5144	.3772	.5144	.5144	.6173	.3086	.4458
12	.4458	.4115	.4801	.4458	.5144	.3086	.4115
13	.4458	.3429	.3772	.4801	.4115	.3086	.4115
14	.5144	.4801	.4458	.5144	.583	.3086	.4458
15	.4801			.4801	.5487	.3086	.5144
16	.5144	.4458	.5487	.4458	.5144	.2743	.4801
17	.4458	.3772	.4458	.4801	.4801	.2743	.4458
18	.3429	.3429	.4115	.3772	.5144	.3086	.3772
19	.3429	.3429	.3772	.3429	.4801	.3086	.3429
20	.3086	.3429	.2401	.3429	.3772	.3429	.3772
21	.3086	.3429	.2743	.3086	.3429	.3429	.3086
22	.2743	.3429	.3086	.3086	.3086	.3429	.2743
23	.3086	.3086	.3086	.3086	.3086	.3429	.2743
24	.3086	.3086	.3086	.3086	.3086	.2743	.3086
Max	.583	.4801	.5487	.5144	.6173	.3429	.5144
Min	.2401	.2401	.2401	.2401	.2401	.2401	.2401
Avg	.3672	.3444	.3593	.3658	.4115	.2972	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 205 / KOPARDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3772	.3772	.3601	.3772
2	.3258	.3258	.3258	.3429	.3429	.3429	.3429
3	.3258	.3086	.3258	.3429	.3429	.3429	.3429
4	.3086	.3086	.3086	.3429	.3429	.3429	.3429
5	.4287	.4115	.4287	.4287	.4287	.4287	.4458
6	.5487	.4973	.6687	.4801	.4973	.5487	.5658
7	.703	.6687	.7888	.6687	.6859	.6687	.6859
8	.7202	.6516	.6859	.6859	.6001	.6173	.6859
9	.6516	.6173	.5487	.583	.5144	.4801	.5144
10	.583	.5487	.583	.583	.5144	.4458	.4458
11	.5316	.5087	.4801	.5935	.4801	.463	.4115
12	.6516	.5365	.463	.5365	.4801	.4801	.4287
13	.4973	.5144	.4458	.4917	.4801	.4458	.4458
14	.4801	.5316	.4287	.4409	.4801	.4458	.4115
15	.4458	.4801	.4458	.5144	.463	.463	.4458
16	.4973	.5144	.4458	.5144	.4458	.4458	.4801
17	.5144	.5487	.4458	.5487	.5144	.5144	.583
18	.3429	.5487	.4801	.4801	.4801	.4801	.5487
19	.6516	.6516	.7202	.703	.6687	.6344	.6859
20	.6344	.6859	.6859	.6859	.6859	.6001	.6859
21	.583	.6173	.6173	.6173	.6173	.5658	.6173
22	.5316	.5144	.5487	.5487	.6173	.5316	.5658
23	.4458	.4458	.4801	.5144	.5144	.5144	.4973
24	.3772	.3772	.3772	.4115	.4115	.4115	.4287
Max	.7202	.6859	.7888	.703	.6859	.6687	.6859
Min	.3086	.3086	.3086	.3429	.3429	.3429	.3429
Avg	.5051	.5065	.5030	.5182	.4994	.4822	.4994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 206 / PARLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	.0686	.0686	.0686	1.406	1.6632	1.5775
2	1.5775	.0686	.0686	.0686	1.3717	1.6461	1.5432
3	1.5432	.0686	.0686	.0686	1.3717	1.6289	1.5432
4	1.5432	.0686	.0686	.0686	1.3717	1.6289	1.5089
5	1.6289	.0686	.0686	.0686	1.6289	1.6975	1.6975
6	1.6804	.0686	.0857	.0686	1.8004	1.749	1.8347
7	1.749	.0857	.0857	.0857	1.246	2.0405	1.9204
8	.0857	.1029	.1029	.0857	1.8347	2.0919	1.989
9	.0857	.1029	.12	.1029	1.8176	2.0233	1.9204
10	.0857	3.0352	3.2217	3.1708	.0848	.0678	.0857
11	.0857	3.2047	3.4034	3.086	.0671	.0678	.0857
12	.0686	3.4202	3.4252	3.1893	.0848	.0678	.0857
13	.0686	3.5778	3.4082	3.2047		.0678	.0857
14	.0857	3.3913	3.3779	3.1687	.0678	.0678	.0857
15	.0686	3.2579	3.2579	3.0182	.0848	.0678	.0857
16	.0686	3.2236	3.1207	2.6993	.0848	.0678	.1029
17	.0857	3.1207	2.1704	2.713	.0848	.0848	.1029
18	.1029	.0848	.1029	.0848	.0848	.1029	.0857
19	.0857	1.286	.0857	.0857	.0857	.1029	.1029
20	.0857	.0857	.1029	.0857	.1029	.1029	.0857
21	.0857	.0857	.0857	.0857	.0857	.1029	.0857
22	.0857	.0857	.0857	.0857	.0857	.1029	.0857
23	.0686	.0686	.0686	.0686	.1029	.1029	.1029
24	1.6289	.0686	.0686	.0686	1.4575	1.6804	1.6289
Max	1.749	3.5778	3.4252	3.2047	1.8347	2.0919	1.989
Min	.0686	.0686	.0686	.0686	.0671	.0678	.0857
Avg	.5937	1.1958	1.1135	1.0625	.7136	.7928	.7680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 207 / 11 KV VADOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.8402	.7202	.7545			
2	.0171	.823	.6859	.6859			
3	.0171	.7202	.6859	.6859			
4	.0171	.7202	.6516	.6859			
5	.0343	.7202	.7716	.703			
6	.0343	.7373	.8745	.703			
7	.0343	.7888	.9431	.7888		.0343	
8	.0343	.823	.8573	.8916	.0343	.0343	
9	.0343	.7545	.8745	.823	.0343	.0343	
10	1.286			.0339	1.286	1.4089	1.3717
11	1.2346			.017	.4801	1.2407	1.4403
12	1.1488		.0168	.017	1.2266	1.17	1.3717
13	1.0802		.0335	.017		1.17	1.2174
14	1.0288		.0332	.0335		1.1022	1.2003
15	1.0802		.0332	.0339	1.1768	1.1768	1.1488
16	1.1488		.0332	.0168	1.1736	1.21	.4458
17	1.0631		.0332	.017	1.2407	1.2039	.3944
18	.0343		.0343	.017	.0335	.0343	
19	.0343	.0343	.0343	.0171	.0343	.0343	
20		.0343	.0343	.0171	.0343	.0343	.0343
21	.0343	.0343	.0343			.0343	
22	.0343	.0343	.0343			.0171	
23	.0343	.0171					
24		.8573	.7888	.7716			
Max	1.286	.8573	.9431	.8916	1.286	1.4089	1.4403
Min	.0171	.0171	.0168	.0168	.0335	.0171	.0343
Avg	.4318	.5293	.3909	.3681	.6140	.6212	.9583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 403 / 33 KV KARAD TOWN

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6923	3.8146	3.8255	4.137	4.0181	3.9506	4.137
2	3.2236	3.5997	3.4568	3.8683	3.8009	3.5665	3.8683
3	3.4568	3.5997	3.4568	3.7609	3.7311	3.5117	3.8683
4	3.8009	3.546	3.4928	3.8009	3.6763	3.8409	3.8683
5	4.0295	3.546	3.6763	3.7609	3.7311	4.2798	3.922
6	4.2981	3.8146	4.3896	4.1907	4.4445	4.7737	4.2444
7	4.9411	4.6205	5.048	4.8354	5.104	5.1578	5.2652
8	5.3224	5.1578	5.3772	5.3189	5.0497	5.2126	5.2652
9	4.9931	4.8354	5.2669	5.4801	5.104	4.8285	5.2115
10	5.2675	5.0497	5.487	5.5384	5.2115	4.8285	5.487
11	5.487	3.2773	5.6516	5.5418	5.5876	4.6091	5.7065
12	5.5418	5.2669	5.7013	5.487	5.5876	4.1152	5.8162
13	5.5418	5.2126	5.5384	5.4321	5.8025	4.225	5.7613
14	5.3772	4.7239	5.487	5.1578	5.4801	3.4751	5.1578
15	5.3772	4.6696	5.2669	4.9411	5.6516	3.4751	4.9931
16	5.4321	4.6696	5.2669	4.9954	5.5876	3.7466	5.6516
17	5.4887	4.7737	5.4321	4.9954	5.5338	3.4568	5.7613
18	6.0985	5.2675	5.4321	5.5418	6.0357	5.3224	6.7696
19	7.0919	7.0233	7.5217	7.4074	7.7915	6.6621	7.5755
20	6.877	7.2428	7.4143	7.5172	7.6818	6.3397	7.6292
21	6.1786	6.2552	6.3397	6.5295	6.9136	6.0711	6.7696
22	5.5876	5.5967	5.8562	5.9259	6.1454	5.8025	6.0174
23	4.8354	4.8285	5.3727	5.1583	5.5927	5.1578	5.2652
24	3.9638	4.2981	4.3244	4.6205	4.3896	4.6091	4.6205
Max	7.0919	7.2428	7.5217	7.5172	7.7915	6.6621	7.6292
Min	3.2236	3.2773	3.4568	3.7609	3.6763	3.4568	3.8683
Avg	5.0793	4.7787	5.1701	5.1643	5.3188	4.6258	5.3597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 201 / KRISHNA HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2829	.2743	.3018	.3395	.3395	.3772
2	.3395	.2829	.2743	.3018	.3018	.3206	.3772
3	.3395	.2829	.2743	.3018	.3018	.3206	.3772
4	.3395	.2829	.2743	.3018	.3018	.3206	.3772
5	.3395	.3018	.3086	.3206	.3395	.3395	.3772
6	.3772	.3584	.3772	.3395	.5093	.3961	.415
7	.5281	.3772	.4115	.3772	.5281	.5093	.5658
8	.4115	.4338	.5144	.4338	.5281	.6413	.5847
9	.4115	.415	.6602	.415	.6413	.6602	.6413
10	.3944	.5281	.679	.4904	.7733	.7733	.7545
11	.4801	.5093	.679	.4338	.7545	.7922	.8299
12	.5487	.4527	.6413	.3772	.7167	.6602	.7545
13	.6001	.4527	.6224	.3961	.6979	.6224	.7167
14	.5487	.4527		.3772	.6224	.6413	.6602
15	.583	.4338	.5847	.3772	.7545	.7167	.7922
16	.4801	.4904	.6036	.415	.679	.7545	.811
17	.5658	.4458	.4904	.3584	.5847	.5847	.5144
18	.4527	.4115	.4715	.415	.547	.5658	.5144
19	.4904	.4115	.5093	.4338	.5658	.5658	.4801
20	.4904	.3772	.4904	.4527	.5847	.547	.4801
21	.4338	.3429	.4338	.3772	.5847	.5093	.4801
22	.3961	.3429	.3961	.3772	.5281	.4904	.4115
23	.3395	.3086	.3584	.3584	.415	.4338	.4115
24	.3772	.2829	.3086	.3395	.3395	.3961	.415
Max	.6001	.5281	.679	.4904	.7733	.7922	.8299
Min	.3395	.2829	.2743	.3018	.3018	.3206	.3772
Avg	.4420	.3859	.4625	.3780	.5391	.5376	.5466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 202 / MALKAPUR Gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.0456	1.0974	1.1389	1.2449	1.1949	1.2071
2	1.0185	1.0456	1.0974	1.1203	1.2071	1.1576	1.2071
3	1.0185	1.0456	1.0974	1.1203	1.2071	1.1576	1.2071
4	1.0185	1.0456	1.0974	1.1203		1.1576	1.2071
5	1.1317	1.0829	1.2003	1.1949	1.2826	1.1949	1.2826
6	1.4335	1.3256	1.6118	1.4003	1.5844	1.4003	1.6598
7	2.1125	1.7551	1.8861	1.7924	2.1125	1.8298	2.0748
8	1.8861	1.9605	1.8861	1.9404	2.1125	1.9791	2.1125
9	1.7833	1.905	1.9239	1.9022	1.8484	1.7741	1.8861
10	1.6804	1.9805	1.9239	2.1125	1.8861	1.773	2.1125
11	1.6804	1.9616	1.9239	1.9805	1.8861	1.7353	2.0748
12	.3258	1.9616	1.8861	1.8107	1.8107	1.5466	1.8861
13	1.7147	1.7918	1.8107	1.8107	1.8861	1.5844	1.7353
14	1.7147	1.6598		1.7353	1.773	1.5089	1.8861
15	1.6975	1.6975	1.9616	1.6787	1.9616	1.4335	1.8484
16	1.6461	1.773	1.8107	1.7353	1.8861	1.6032	2.037
17	1.6834	1.6804	1.7551	1.8296	1.9163	1.6221	
18	1.6655	1.749	1.7013	1.773	1.8088	1.8107	1.8861
19	2.0271	2.0405	2.0995	2.2634	2.2081	2.037	2.0233
20	1.8839	2.0576	2.1948	2.2257	2.1948	2.1502	2.1262
21	1.7375	1.8861	1.9387	2.1125	2.0883	1.9616	1.9547
22	1.5893	1.6461	1.7551	1.8861	1.885	1.8861	1.6804
23	1.2936	1.3375	1.4937	1.6221	1.6057	1.5844	1.4403
24	1.2456	1.1203	1.0974	1.2323	1.358	1.3443	1.4335
Max	2.1125	2.0576	2.1948	2.2634	2.2081	2.1502	2.1262
Min	.3258	1.0456	1.0974	1.1203	1.2071	1.1576	1.2071
Avg	1.5018	1.6065	1.6631	1.6891	1.7719	1.6011	1.7378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 203 / Goleshwar Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.2915	.2743	.2743	.0566	.0716	.0754
2	.0566	.2915	.2439	.2401	.0566	.0537	.0754
3	.0566	.2915	.2439	.2401	.0566	.0537	.0566
4	.0566	.3086	.2439	.2401	.0566	.0537	.0566
5	.0566	.3258	.3086	.2401	.0566	.0537	.0754
6	.0754	.3772	.3353	.2915	.0754	.0716	.0754
7	.0943	.463	.4115	.3429	.0754	.0895	.0943
8	.0857	.3944	.4458	.3944	.0754	.0895	.0943
9	.0857	.415	.0566	.3772	.0754	.0716	.0754
10	.583	.0754	.0754	.0754	.6036	.5658	.6224
11	.6001	.0754	.0566	.0566	.679	.6979	.679
12	.6173	.0754	.0566	.0754	.6602	.679	.6224
13	.583	.0566	.0754	.0566	.6224	.7167	.6413
14	.5487	.0566		.0566	.6224	.6602	.6602
15	.5144	.0754	.0566	.0377	.5658	.6036	.6036
16	.5144	.0566	.0754	.0377	.5658	.5658	.5658
17	.463	.0514	.0526	.0566	.4801	.4904	.4973
18	.0514	.0514	.0716	.0566	.0876	.0754	.0514
19	.0526	.0514	.0895	.0754	.0701	.0754	.0686
20	.0686	.0686	.0716	.0754	.0716	.0943	.0857
21	.0701	.0686	.0716	.0943	.0716	.0943	.0857
22	.0716	.0514	.0716	.0943	.0895	.0754	.0686
23	.0537	.1715	.0537	.0566	.0716	.0566	.0686
24	.0566	.2743	.2743	.2743	.0566	.0716	.0754
Max	.6173	.463	.4458	.3944	.679	.7167	.679
Min	.0514	.0514	.0526	.0377	.0566	.0537	.0514
Avg	.2280	.1841	.1616	.1592	.2459	.2555	.2531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 204 / Goleshwar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3921	.3086	.4481	.4527	.4481	.4527
2	.3772	.3734	.3086	.4108	.415	.4108	.415
3	.3772	.3734	.3086	.4108	.415	.4108	.415
4	.3772	.3734	.3086	.4108	.415	.4108	.415
5	.415	.3921	.3772	.4481	.4527	.4481	.4527
6	.5658	.5788	.6173	.5601	.6036	.5975	.6413
7	.7545	.7282	.6859	.8029	.7922	.7468	.7922
8	.6516	.8316	.6859	.8048	.7545	.7762	.7545
9	.583	.7545	.679	.695	.5658	.6401	.6413
10	.5144	.6036	.6224	.6602	.5281	.5093	.5281
11	.4801	.5658	.547	.6036	.4904	.4527	.5093
12	.4458	.5281	.5281	.5281	.5093	.4527	.4904
13	.4115	.5281	.5281	.4904		.4715	.5281
14	.4115	.4715		.4715	.4715	.4715	.4527
15	.4287	.4527	.4715	.4527	.4527	.4527	.4527
16	.4115	.4527	.4715	.4904	.4904	.4715	.4904
17	.4656	.4458	.4656	.5281	.4477	.5093	.463
18	.5014	.5144	.5014	.5658	.5194	.5658	.5144
19	.6878	.6859	.6697	.679	.6878	.7167	.6516
20	.695	.6859	.7602	.7167	.7421	.7167	.6859
21	.695	.5144	.7316	.679	.7316	.679	.6859
22	.6219	.4115	.6468	.6413	.695	.6413	.583
23	.4938	.3429	.5788	.5281	.5601	.5658	.5144
24	.3772	.4108	.3772	.4854	.4527	.4668	.4527
Max	.7545	.8316	.7602	.8048	.7922	.7762	.7922
Min	.3772	.3429	.3086	.4108	.415	.4108	.415
Avg	.5050	.5172	.5295	.5630	.5498	.5430	.5409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 205 / AAGASHIVNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.9896	.6859	1.1576	1.094	.7842	.7922
2	.9054	.9896	.6859	1.1576	1.094	.7842	.7922
3	.9054	.9896	.6859	1.1203	1.094	.7842	.7922
4	.9054	.9896	.6859	1.1203	1.094	.7842	.7922
5	.9808	.9896	.8573	1.1576	1.1694	.7842	.8676
6	1.1317	1.1389	1.0288	1.2883	1.2826	.8402	.9808
7	1.4335	1.0456	1.2003	1.4563	1.5089	1.0829	1.2071
8	1.3717	1.251	1.166	1.5893	1.5844	1.1576	1.2071
9	1.4403	1.3014	1.094	1.6448	1.7353	1.2437	
10	1.3717	1.2826	1.226	1.5466	1.6975	1.0562	.2641
11	1.406	1.2826	1.5089	1.5655	1.5089	.9431	1.358
12	1.0974	1.0562	1.5089	1.5089	1.4523	.9997	1.5089
13	1.2689	1.0562		1.4335	1.4523	.9054	1.6221
14	1.3717	.9997		1.4523	1.4712	.9054	1.6221
15	1.3717		1.5089	1.4712	1.3957	.9054	1.5844
16	1.3375	1.0562	1.4146	1.4712	1.3957	.9054	1.5466
17	1.4685	1.0288	1.4864	1.5089		.9054	1.3717
18	1.1462	1.0974	1.4327	1.5089	1.4506	1.0185	1.3717
19	1.5565	1.166	1.6651	1.5089	1.7013	1.2071	1.3717
20	1.5364	1.2003	1.6832	1.5844	1.7924	1.2826	1.406
21	1.39	1.0288	1.6644	1.5089	1.3169	1.2071	1.3717
22	1.3535	.8573	1.5339	1.358	1.1827	1.0974	1.2003
23	1.2197	.7545	1.3817	1.2826	1.0456	.9808	1.0288
24	1.0867	1.0642	.6859	1.251	1.1317	.8962	.8299
Max	1.5565	1.3014	1.6832	1.6448	1.7924	1.2826	1.6221
Min	.9054	.7545	.6859	1.1203	1.0456	.7842	.2641
Avg	1.2516	1.0702	1.2178	1.4022	1.3761	.9775	1.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 206 / Koyana Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3018	.2401	.3018	.3018	.3018	.2641
2	.2452	.2641	.2401	.3018	.3018	.3018	.2641
3	.2452	.2641	.2401	.2641	.3018	.3018	.2641
4	.2452	.3018	.2401	.2641	.3018	.3018	.2641
5	.2452	.3018	.2401	.3018	.3018	.3018	.2641
6	.2641	.3018	.2401	.3018	.3018	.3018	.2641
7	.2641	.3018	.2572	.3018	.3018	.3018	.2641
8	.2743	.3018	.2572	.2641	.3395	.3395	.2641
9	.3086	.3395	.3395	.3018	.3206	.3395	.2829
10	.3601	.3772	.3772	.3772	.3395	.3018	.3395
11	.3086	.415	.4527	.415	.415	.3018	.3772
12	.3086	.3395	.3772	.3395	.3772	.3018	.3772
13	.2915	.3395	.3772	.3395	.3772	.3395	.3395
14	.3086	.3772		.3772	.3772	.3395	.415
15	.3086	.3772	.415	.415	.415	.3395	.3395
16	.2743	.4527	.415	.3395	.4527	.3395	.415
17	.3772	.3772	.415	.415	.415	.2641	.3601
18	.3395	.3429	.3772	.3772	.3772	.2641	
19	.3395	.3258	.3772	.3395	.3772	.2641	.3086
20	.3395	.3086	.3395	.3206	.3395	.2641	.3086
21	.3206	.3086	.3395	.3206	.3395	.2829	.3086
22	.3206	.2915	.3018	.3018	.3018	.2641	.2743
23	.3018	.2743	.3018	.3206	.3018	.2641	.2743
24	.2641	.2641	.2572	.3018	.3206	.3018	.2641
Max	.3772	.4527	.4527	.415	.4527	.3395	.415
Min	.2452	.2641	.2401	.2641	.3018	.2641	.2641
Avg	.2966	.3271	.3225	.3293	.3458	.3010	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 207 / 11 KV Malkapur water works NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.168	.0514	.168	.1698	.0366	.0377
2	.0189	.0549	.0171	.0366	.0377	.0366	.0377
3	.0189	.0183	.0171	.0366	.0377	.0366	.0377
4	.0189	.0366	.0686	.0366	.0377	.0366	.0377
5	.1698	.168	.1543	.2012	.1886	.0366	.0377
6	.1886	.1867	.1715	.1867	.1886	.168	.1886
7	.1886	.168	.1715	.1867	.2263	.2054	.1886
8	.2058	.1867	.1886	.1867	.2075	.2241	.2075
9	.2743	.2263	.1886	.2054	.3206	.2987	.3018
10	.3258	.3395	.3395	.3395	.3772	.2829	.2829
11	.3086	.3206	.3395	.3584	.3584	.3395	.3395
12	.3258	.3206	.3395	.3206	.3395	.3395	.3395
13	.3086	.3018	.3206	.3206	.3206	.3395	.3395
14	.2915	.3206		.3206	.3206	.3395	.3395
15	.2743	.3018	.3584	.3206	.3206	.3395	.3395
16	.2572	.1698	.1698	.2641	.3206	.3206	.3395
17	.3174	.1543	.168	.2452	.3174	.3206	.3086
18	.3174	.1543	.168	.2263	.2241	.3395	.2915
19	.2614	.1715	.1867	.0943	.056	.3395	.2572
20	.168	.1715	.168	.1698	.0366	.1886	.1715
21	.1867	.1543	.168	.1886	.168	.1886	.1715
22	.168	.1372	.168	.1698	.168	.1886	.1543
23	.1867	.1543	.168	.1698	.168	.1698	.1372
24	.1698	.1867	.0514	.168	.1698	.168	.1698
Max	.3258	.3395	.3584	.3584	.3772	.3395	.3395
Min	.0189	.0183	.0171	.0366	.0366	.0366	.0377
Avg	.2087	.1905	.1801	.2050	.2117	.2201	.2107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 201 / Supane AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	.1067	.096	.1296	1.491	1.4449	1.5043
2	1.4575	.1067	.096	.1296	1.4582	1.4118	1.4883
3	1.3927	.0914	.096	.1296	1.5074	1.3696	1.4243
4	1.3927	.0914	.096	.1134	1.491	1.4148	1.3763
5	1.3603	.0926	.096	.1134	1.5402	1.4632	1.4243
6	1.4899	.1054		.1619	1.6549	1.5699	1.5043
7	1.749	.1204	.128	.1781	2.1136	1.8362	1.7604
8	.1457	.1355	.16	.1619	1.9498	1.8212	1.8404
9	.176	.16	.1656	.1475	1.8515	1.7328	1.5202
10	.208	2.8807	2.1824	2.6052	.1147	.1457	.1355
11	.16	2.9607	2.9275	2.9797	.1311	.1296	.1505
12	.144	3.1527	3.0102	2.8664	.144	.1311	.1372
13	.16	3.2007	2.8532	2.834	.144	.1638	.1372
14	.144	3.0087	2.6898	2.6882	.112	.1781	.1067
15	.144	2.9767	2.6006	2.6073	.144	.1619	.1219
16	.128	2.8487	2.4834	2.5749	.16	.1943	.1204
17	.1355	2.7046	2.4777	2.3644	.1505	.176	.1296
18	.1054	.16	.1781	.1457	.1372	.192	
19	.1524	.192	.1943	.1802	.1656	.208	.1781
20	.1829	.144	.1781	.1802	.1505	.176	.1781
21	.1505	.144	.1781	.1638	.1656	.176	.1457
22	.1219	.144	.1619	.1475	.1505	.16	.1134
23	.1219	.112	.1296	.1147	.1219	.128	.1134
24	1.5223	.1067	.096	.1296	1.5074	1.475	1.5684
Max	1.749	3.2007	3.0102	2.9797	2.1136	1.8362	1.8404
Min	.1054	.0914	.096	.1134	.112	.128	.1067
Avg	.5945	1.0728	1.0119	.9936	.7732	.7442	.7469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 202 / Khodashi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.8238	.7095	.8775	.8775	.8059	.8029
2	.7468	.8059	.6908	.7842	.7655	.7701	.8215
3	.7095	.788		.7842	.7095	.8238	.7842
4	.7468	.7164	.7095	.7655	.8029	.8145	.8029
5	.8215	.7522	.7655	.8589	.8962	.8596	.8215
6	1.0829	.8859	1.0082	1.0829	1.1016	1.0985	1.0642
7	1.419	1.134	1.3443	1.2136	1.363	1.262	1.3256
8	1.3256	1.134	1.2696	1.307	1.2883	1.2757	1.3443
9	1.2696	1.1576	1.1694	1.3256	1.2136	1.2012	1.3289
10	1.1949	1.0829	1.1043	1.3256	1.2197	1.2197	1.1163
11	1.1389	1.0164		1.2136	1.1088	1.0903	1.0985
12	1.0456	.9979	1.0631	1.1273	1.2136	1.1389	.9391
13	1.0642	1.0164	1.0631	1.0719	1.1203	.7865	1.0517
14	.9149	.9055	.985	1.0349	.9522		.9214
15	1.1016	.8871	1.1871	.9795	1.0829	.8686	1.134
16	1.2136	.8686	1.0631	1.1088	1.1203	.6468	1.258
17	.9214	.9896	1.1203	1.2136	1.0099	.9896	1.2696
18	1.0745	1.0456	1.3817	1.2323	1.2445	1.1203	1.2323
19	1.379	1.419	1.419	1.4377	1.4175	1.363	1.531
20	1.2934	1.4563	1.6244	1.5684	1.5061	1.419	1.587
21	1.1517	1.307	1.3443	1.3443	1.3643	1.3443	1.363
22	1.134	1.3256	1.4003	1.419	1.3289	1.307	1.531
23	1.2357	1.0642	1.2136	1.251	1.1641	1.1203	1.2883
24	.8775	.8775	.8402	.9709	1.0269	.9492	.8402
Max	1.419	1.4563	1.6244	1.5684	1.5061	1.419	1.587
Min	.7095	.7164	.6908	.7655	.7095	.6468	.7842
Avg	1.0686	1.0191	1.1126	1.1374	1.1208	1.0554	1.1357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 203 / SAHYADRI HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0716	.0754	.0754	.0943	.0709	.0943
2	.0943	.0716	.0754	.0754	.0943	.0716	.0754
3	.0943	.0716	.0754	.0754	.0943	.0716	.0754
4	.0943	.0716	.0754	.0754	.0943	.0716	.0566
5	.0943	.0724		.0754	.0943	.0716	.0566
6	.0943	.0716	.0943	.0754	.0943	.0709	.0943
7	.0943	.1772	.2263	.1509	.1132	.2126	.1698
8	.0754	.1595	.1698	.1698	.1132	.197	.0943
9	.1509	.0754	.0709	.0754	.2263	.0943	.0886
10	.2075	.0943	.1075	.0754	.1698	.0943	.1254
11	.0943	.0943	.0886	.0943	.1132	.1109	.1254
12	.0943	.0943	.0895	.1132	.1132	.1132	.1063
13	.1132	.0943	.1075	.0754	.1132	.1132	.2303
14	.0754	.1132	.1063		.1132	.1132	.1063
15	.679	.2263	.2279		.2263	.2075	.1075
16	.1886	.2075	.124	.1509	.0943	.2075	.1254
17	.1063	.1132	.1132	.2075	.0895	.0943	.132
18	.0886	.0943	.0754	.0943	.0895	.0943	.2075
19	.1075	.1132	.0943	.1132	.1063	.1698	.2075
20	.0886	.1132	.2075	.0943	.1254	.1132	.132
21	.0886	.0943	.0943	.0943	.0895	.0943	.0943
22	.1949	.2075	.1509	.1698	.1772	.2075	.0943
23	.0716	.0754	.0943	.2075	.0716	.1509	.2263
24	.0943	.0716	.0754	.0943	.0943	.0895	.0943
Max	.679	.2263	.2279	.2075	.2263	.2126	.2303
Min	.0716	.0716	.0709	.0754	.0716	.0709	.0566
Avg	.1317	.1104	.1139	.1106	.1169	.1211	.1217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 204 / WARUNJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.0857	.0857	.0857	.7716	.602	.4515
2	.5316	.0857	.0857	.0857	.7545	.587	.4572
3	.5487	.0857	.0857	.0857	.703	.5796	.4784
4	.5487	.0857	.0857	.0857	.703	.6097	.4167
5	.5658	.1029	.0857	.0857	.7202	.6859	.4321
6	.5658	.1029	.1029	.1029	.7545	.6923	.4877
7	.6344	.12	.12	.1029	.8745	.7827	.6622
8	.1372	.1294	.1372	.12	.9259	.743	.7074
9	.1372	.12	.0857	.0857	.8402	.7225	.6321
10	.12	1.3032	1.2003	1.3203	.1029	.0903	.1067
11	.132	1.4746	1.3889	1.3546	.0857	.1067	.1067
12	.1372	1.4918	1.5432	1.4232	.0857	.1067	.1067
13	.12	1.5089	1.4918	1.3717	.0686	.0617	.0903
14	.1029	1.4232	1.406	1.3546	.0686	.0772	.1204
15	.1029	1.4575	1.4232	1.3717	.0514	.061	.1204
16	.1029	1.3375	1.406	1.286	.0686	.0762	.1204
17	.12	1.2346	1.0117	1.046	.0686	.0753	.1219
18	.1372	.0686	.1029	.0686	.0857	.0914	.1219
19	.1543	.12	.12	.0857	.1029	.0914	.1054
20	.12	.12	.1029	.0857	.0686	.0753	.0753
21	.12	.1029	.1029	.0857	.0686	.0762	.0914
22	.1372	.0857	.0857	.0857	.0686	.0762	.0762
23	.0857	.0857	.0857	.0686	.0857	.4877	.0762
24	.6001	.0857	.0857	.0857	.7545	.6097	.4877
Max	.6344	1.5089	1.5432	1.4232	.9259	.7827	.7074
Min	.0857	.0686	.0857	.0686	.0514	.061	.0753
Avg	.2727	.5341	.5180	.4972	.3701	.3403	.2772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 205 / Sangam LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.1402	.3174	.1509	.1509	
2	.415	.3681	.3921	.2263	.2263	
3	.415	.3681	.3921	.2263	.2263	
4	.415	.3721	.3921	.2263	.2263	
5	.415	.3681	.3921	.2263	.2829	
6	.415	.3641	.3921		.415	.2452
7	.3961	.3681	.3921	.415	.4338	.4108
8	.3961	.3641	.3921	.3961	.415	.4108
9	.3961	.3921	.3681	.3921	.4108	.3856
10	.3921	.3921	.3681	.3921	.3921	.3641
11	.3961	.3961	.3856	.415	.3921	.3681
12	.3921	.3961	.3814	.4108	.3921	.3641
13	.3921	.3961	.3814	.3921	.3961	.3641
14	.3921	.3921	.3641	.3921	.3921	.3681
15	.3361	.3921	.3856	.3921	.3921	.3681
16	.2054	.2263	.1928	.2987	.2241	.208
Max	.415	.3961	.3921	.415	.4338	.4108
Min	.2054	.1402	.1928	.1509	.1509	.208
Avg	.3865	.3560	.3681	.3301	.3355	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 206 / Supane Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3761	.3961		.4435	.4784	.4715
2	.3326	.3582	.3584	.4251	.4251	.4656	.4527
3	.3142	.3582	.3395	.4805	.4066	.4525	.415
4	.3881	.3403	.3584	.499	.4251	.5249	.3961
5	.4805	.3898	.4527	.5359	.4435	.5552	.4338
6	.6838	.5493	.6413	.7023	.6468	.7164	.6979
7	.9328	.8059	.8402	.9425	.8686	.9745	.9425
8	.9511	.8417	.9511	1.2071	.9425	.9568	.9328
9	.8779	.7602	.8328	.8954	.8869	.905	.9214
10	.7796	.724	.691	.7522	.6447	.7602	.7087
11	.7619	.6516	.6805	.7964	.724	.4887	.6984
12	.7186	.6036	.7265	.6516	.6241	.4938	.6447
13	.7011	.5304	.567	.6908	.631	.5249	.691
14	.6201	.543	.591	.5792	.6556	.4344	.6626
15	.631	.543	.5373	.5973	.6201	.4706	.6201
16	.4207	.6036	.5373	.543	.5493	.4344	.5847
17	.6024	.5533	.6447	.5731	.6379	.6036	.6089
18	.6805	.6485	.6984	.5552	.7265	.8238	.7522
19	.8328	.9231	.8954	.9134	.9492	.9328	.8954
20	.8954	.9335	.9328	1.0059	.9568	1.1016	.9492
21	.7796	.8676	.8779	.9145	.8775	.9335	.8962
22	.7164	.7733	.7682	.823	.815	.8865	.8048
23	.5194	.5847	.6036	.6584	.6447	.6979	.6584
24	.462	.4119	.4338		.4938	.4961	.5281
Max	.9511	.9335	.9511	1.2071	.9568	1.1016	.9492
Min	.3142	.3403	.3395	.4251	.4066	.4344	.3961
Avg	.6438	.6115	.6398	.7155	.6683	.6713	.6820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 201 / VAHAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2146	.0543	.0543	.0543	2.1548	1.7147	1.4899
2	1.1469	.0532	.0554	.0543	2.0081	1.8861	1.406
3	1.1336	.0526	.0554	.0543	1.9433	1.8861	1.406
4	1.1469	.0526	.0554	.0543	1.9662	1.9204	1.3599
5	1.1469	.0686	.0543	.0543	2.0317	1.8861	1.4251
6	1.2146	.0701	.0701	.0543	2.1628	1.9719	1.5384
7	1.2803	.0701		.0543	2.2672	2.0748	1.7368
8	.0532	.0709	.0709	.0543	2.2672	2.1434	1.7814
9	.0526	.0514	.0532	.0543	2.17	1.8404	1.8023
10	.0503	3.2579		3.2579	.0693	.0532	.0716
11	.0514	3.3665		3.6214	.0526	.0526	.0716
12	.0671	3.5294		3.6214		.0526	.0716
13	.0492	3.4389	3.4389	3.5837	.0497	.0526	.0537
14	.0503	3.4751	3.5475	3.6214	.0503	.0532	.0537
15	.0514	3.4751	3.5475	3.3653	.0678	.0526	.0537
16	.0497	3.3665	3.5848	3.3303	.0655	.0526	.0537
17	.0503	3.2922	3.5482	3.2579	.0033	.052	.0537
18	.052	.0686	.0549	.0686	.0716	.0514	.0532
19	.0716	.0693	.0543	.0701	.0716	.0914	.0701
20	.0732	.0709	.0549	.0732	.0716	.0724	.0867
21	.0924	.0905	.0543	.0905	.0716	.0732	.0701
22	.0732	.0709	.0543	.0701	.0537	.0739	.0526
23	.0709	.0724	.0543	.0532	.0537	.0532	.0532
24	1.3565	.0526	.0543	.0543	2.0972	1.6632	1.4575
Max	1.3565	3.5294	3.5848	3.6214	2.2672	2.1434	1.8023
Min	.0492	.0514	.0532	.0532	.0033	.0514	.0526
Avg	.4416	1.1767	.9259	1.1928	.9487	.826	.6780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 202 / Vahagaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2926	.3292	.3258	.3475	.3142	.3475
2	.2658	.2926	.2743	.3292	.3292	.3174	.3292
3	.2686	.2561	.2926	.3109	.3292	.2957	.3292
4	.2835	.2926	.2926	.3109	.3658	.3361	.3292
5	.3155	.3292	.3292	.3292	.4024	.3734	.3658
6	.4161	.4207		.4024	.5121	.462	.4755
7	.5316	.5121	.5487	.5304	.5487	.5914	.5487
8	.5201	.5304	.5729	.5304	.5487	.5601	.5487
9	.4161	.4755	.439	.4572	.4755	.4668	.5487
10		.4024	.3801	.3658	.439	.333	.4481
11	.4024	.439	.3658		.4207	.3988	.4108
12	.3696	.4207	.362	.3658	.4572	.3641	.3881
13	.3326	.3841	.3801	.3547	.439	.3366	.3921
14	.3511	.3658	.3801	.3475	.3658	.333	.4481
15	.3881	.3841	.4024	.3658	.4024	.3641	.4066
16	.3696	.4024	.3841	.3658	.4024	.3467	.4251
17	.3696	.3658	.4163	.4207	.439	.3155	.4668
18	.4024	.3658	.3982	.3292	.4251	.3841	.4031
19	.499	.5121	.5975	.499	.5914	.5175	.5144
20	.6468	.5853	.6219	.6653	.6653	.6099	.5596
21	.5544	.5487	.543	.5914	.5853	.6468	.5144
22	.4755	.4755	.4706	.5544	.5975	.5359	.5201
23	.3658	.4024	.3982	.4024	.4251	.3841	.4207
24	.2804	.3109	.3292	.3658	.3841	.2926	.3292
Max	.6468	.5853	.6219	.6653	.6653	.6468	.5596
Min	.2658	.2561	.2743	.3109	.3292	.2926	.3292
Avg	.3959	.4070	.4134	.4139	.4541	.4117	.4362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 203 / ALFA-LAVAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.003	.0032	.0033	.0032	.0034	.0021	.0034
2		.0033	.0032	.0032	.0033	.0021	.0033
3	.003	.0033	.0032	.0032	.0032	.0021	.0033
4		.0034	.0034	.0032	.0033	.0021	.0032
5	.003	.0034	.0033	.0032	.0033	.0021	.0049
6		.0033	.0034	.0032	.0033	.0021	.0049
7	.003	.0034	.0032	.0032	.0032	.0025	.0033
8		.0032	.0033	.0032	.0034	.0021	.0049
9	.003	.0033	.0033	.0032	.0034	.0023	.005
10	.0034	.0032	.0032	.0032	.0033	.003	.0023
11	.0034	.0032	.0032	.0032	.0034	.003	.0031
12	.0033	.0032	.0032	.0032	.0033	.0031	.0031
13	.0034	.0032	.0032	.0032	.0034	.0033	.0025
14	.0033	.0032	.0032	.0032	.0034	.0032	.0031
15	.0034	.0032	.0032	.0032	.0033	.0032	.0031
16	.0034	.0032	.0032	.0032	.0034		.0031
17	.0034	.0032	.0032	.0032	.0033	.0033	.0031
18	.0033	.0034	.0032	.0034	.0027	.0033	.0049
19	.0034	.0034	.0032	.0034	.0026	.0051	.0049
20	.0033	.0034	.0032	.0033	.0026	.0051	.0048
21	.0032	.0034	.0032	.0034	.0017	.0051	.0049
22	.0033	.0034	.0032	.0034	.0021	.0051	.0049
23	.0033	.0034	.0032	.0034	.0017	.0034	.0049
24	.003	.0032	.0033	.0032	.0034	.0021	.0051
Max	.0034	.0034	.0034	.0034	.0034	.0051	.0051
Min	.003	.0032	.0032	.0032	.0017	.0021	.0023
Avg	.0032	.0033	.0032	.0032	.0031	.0031	.0039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 204 / Taswade East

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2629	.1829	.2926	.1943	.2241	.1875
2	.2614	.2458	.1429	.2743	.1875	.2429	.1524
3	.2218	.2294	.1429	.2743	.1524	.216	.1524
4	.1867	.1943	.1334	.2561	.1524	.2321	.1467
5	.1848	.1943	.1372	.2561	.1943	.2155	.1875
6	.1867	.1524	.1334	.2561	.1966	.1806	.1943
7	.2218	.1524	.1372	.2195	.1429	.1315	.1524
8	.2614	.1943	.1524	.2926	.2401	.1334	.1829
9	.3658	.2401	.3121	.2926	.3982	.1619	.3292
10	.439	.2926	.362	.3658	.4805	.2241	.3258
11	.5228	.3292	.4024	.4024	.4024	.2561	.3582
12	.4904	.3292	.3658	.3658	.5281	.2587	.3326
13	.4904	.3292	.439	.3658	.6036	.2957	.3696
14	.4024	.3292	.4024	.3292	.4854	.2987	.3734
15	.3189	.2561	.3292	.2926	.4904	.2614	.2987
16	.3189	.2926	.3292	.3292	.4481	.2587	.3881
17	.2804	.2561	.3292	.3292	.3292	.2587	.2218
18	.2155	.1715	.3658	.2715	.2587	.1715	.2926
19	.3155	.2774	.2614	.2303	.2614	.208	.2587
20	.2804	.1966	.2801	.2427	.2402	.2134	.2926
21	.2012	.1619	.2743	.1715	.2587	.1715	.2587
22	.3258	.1943	.3292	.2804	.2374	.1783	.2957
23	.3086	.2294	.3292	.2835	.2683	.1715	.2957
24	.2957	.2683	.1943	.2926	.2012	.2439	.1715
Max	.5228	.3292	.439	.4024	.6036	.2987	.3881
Min	.1848	.1524	.1334	.1715	.1429	.1315	.1467
Avg	.3065	.2408	.2695	.2903	.3063	.2170	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 205 / Taswade West

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	1.0456	.8299	.8962	.9709	.7392	.4382
2	.905	.9709	.7545	.8589	.8676	.7392	.4382
3	.8779	.8962	.7545	.8048	.8299	.7392	.3772
4	.8048	.9054	.679	.7682	.7545	.7392	.3429
5	.8131	.7922	.5601	.7316	.7545	.7392	.3429
6	.7095	.679	.5068	.5121	.7167	.7343	.3086
7	.7392	.8299	.5281	.5041	.6413	.8775	.3856
8	.7392	.8299	.543	.5359	.7545	.5601	.4525
9	.7023	.7545	.5975	.5853	.7545	.4435	.6413
10	1.0242	.9694	.8215	.8413	.9335	.3696	.8686
11	1.1827	1.0974	.9335	.8596	1.1088	.3696	.9709
12	1.2803	1.0642	.8413	.7682	1.1827	.439	1.0456
13	1.1088	.8779	.823	.7316	.9709	.439	.924
14	1.2308	.9328	1.1016	.823	1.0456	.3696	1.1576
15	1.2308	1.0269	.9522	.9694	1.0456	.3696	1.1576
16	1.0456	.9694	1.0425	1.0974	1.0456	.439	1.4937
17	.9808	.8962	.9522	.9877	1.0082	.3696	1.419
18	.8488	.5014	.6908	.9054	.7392	.2743	1.1584
19	1.0456	.679	.6767	1.0562	.8871	.2743	1.1706
20	.9808	.7545	.7842	.9709	.7468	.2572	1.0242
21	.8676	.7545	.7682	.9431	.7392	.2515	.7392
22	.9808	.7167	.7682	.9808	.7468	.2347	.8779
23	1.0562	.7545	.9877	1.0829	.7023	.3429	.8048
24	.8779	1.0456	.7545	.9145	1.0456	.7392	.4115
Max	1.2803	1.0974	1.1016	1.0974	1.1827	.8775	1.4937
Min	.7023	.5014	.5068	.5041	.6413	.2347	.3086
Avg	.9577	.8643	.7771	.8387	.8747	.4938	.7896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 206 / 11 KV Talbid Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0936	.3963	1.3169			
2		1.1092	.3567	1.3169			
3		1.0364	.3567	1.3535			
4		1.0669	.381	1.3394			
5		1.1561	.3963	1.39			
6		1.2651	.4374	1.4266			
7		1.5565	.5535	1.5364			
8		1.4737	.5312	1.5729			
9		1.3123	.5376	1.4661			
10	2.0972				1.6385	1.8501	1.9433
11	2.2211				3.498	1.8982	2.0388
12	2.1628				3.9324	1.1336	1.873
13	2.0719				1.9989	.7865	1.9062
14	1.9227				2.0153	1.8404	1.8233
15	1.7859				1.9334	1.7654	1.8399
16	1.7901				1.8351	1.7341	1.7736
17	1.5238				1.7004	1.6324	1.6078
20						.128	
24		1.1248	.3858	1.3352			
Max	2.2211	1.5565	.5535	1.5729	3.9324	1.8982	2.0388
Min	1.5238	1.0364	.3567	1.3169	1.6385	.128	1.6078
Avg	1.9469	1.2195	.4333	1.4054	2.319	1.4187	1.8507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 207 / MIDC-III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.4715	.4527	.4938	.5658	.5228	.3772
2	.4108	.4527	.415	.4938	.5281	.5041	.3584
3	.3881	.7545	.415	.4755	.4715	.4854	.3395
4	.3921	.415	.3772	.4854	.4904	.4668	.3206
5	.3921	.3772	.3961	.4572	.4527	.4668	.3584
6	.4294	.3772	.4338	.4435	.4527	.3734	.3772
7	.4435	.415	.4527	.3658	.4715	.3696	.3395
8	.3696	.4527	.4527	.4024	.4527	.2614	.3584
9	.4251	.4904	.4527	.4481	.5658	.3361	.4338
10	.6979	.5487		1.1157	.7167	.2957	.7545
11	1.3203	.7133	.7682	1.3443	1.3014	.3292	.7762
12	1.3014	.6401	.8413	1.1157	1.2071	.4024	1.1643
13	1.2574	.6219	.8779	.7655	.9808	.2957	1.1763
14	1.2826	.6401	.9145	.8962	1.0374	.3174	1.2136
15	1.3957	.6584	1.2437	1.2071	1.1317	.3109	.8775
16	1.2449	.6401	1.1706	1.2803	1.1694	.2926	1.2696
17	1.1317	.6535	1.1888	1.1523	.9054	.2772	1.2136
18	.7167	.4338	.7655	.724	.7207	.3395	.543
19	.4904	.3584	.6161	.679	.7762	.3018	.543
20	.4763	.3018	.5853	.7356	.462	.2452	.3658
21	.415	.3395	.5853	.6036	.7023	.2452	.3881
22	.4763	.415	.6219	.547	.5041	.3018	.4755
23	.4904	.4338	.5853	.547	.5175	.3961	.462
24	.4435	.4904	.4338	.5304	.5658	.5175	.3395
Max	1.3957	.7545	1.2437	1.3443	1.3014	.5228	1.2696
Min	.3696	.3018	.3772	.3658	.4527	.2452	.3206
Avg	.7007	.5040	.6542	.7212	.7146	.3606	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 208 / MIDC- IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3018	.2829	.2195	.3018	.2614	.2075
2	.2402	.3018	.2641	.2195	.2829	.2614	.1886
3	.2241	.2829	.2641	.2033	.2641	.2427	.1886
4	.2402	.2452	.2263	.2012	.3018	.2614	.2075
5	.2427	.2829	.2641	.2218	.3018	.2614	.2263
6	.2218	.2641	.2829	.2378	.2641	.2587	.2263
7	.2241	.2641	.3206	.2614	.2641	.2587	.2263
8	.2427	.2452	.3018	.2378	.2829	.2614	.2075
9	.3109	.3018	.3206	.3109	.3395	.2614	.3206
10	.4715	.2743	.439	.4435	.5281	.2402	.5788
11	.4527	.2743	.439	.5121	.4715	.2218	.5601
12	.4527	.2561	.4207	.4435	.4527	.2033	.462
13	.4338	.2378	.4024	.3475	.415	.2054	.5415
14	.415	.2561	.4108	.4572	.4715	.2218	.4854
15	.3961	.2378	.4481	.4755	.5281	.2033	.5228
16	.4527	.2561	.4525	.439	.5281	.1848	.5788
17	.3772	.2378	.3921	.4938	.4904	.1867	.5415
18	.3395	.2641	.2987	.3772	.3326	.2263	.3475
19	.3018	.2452	.2801	.3395	.3174	.2263	.2561
20	.3206	.2641	.2801	.3584	.2772	.2075	.2957
21	.3018	.2452	.2561	.3395	.2427	.2263	.2614
22	.2829	.2829	.2561	.3018	.2427	.2075	.2402
23	.2641	.3018	.2378	.3018	.2614	.2075	.2587
24	.2614	.3018	.3018	.2378	.3018	.2614	.2075
Max	.4715	.3018	.4525	.5121	.5281	.2614	.5788
Min	.2218	.2378	.2263	.2012	.2427	.1848	.1886
Avg	.3219	.2677	.3268	.3326	.3527	.2316	.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 401 / HINDUSTAN

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5766	2.32	2.6595	3.1824	3.6214	3.6969	1.6975
2	2.5503	2.2634	2.5463	3.1367	3.678	3.6408	1.5844
3	2.4646	2.1502	2.5463	3.0727	3.5082	3.6969	1.4146
4	2.5206	2.1502	2.6029	3.0807	3.678	3.6969	1.4146
5	2.5206	2.2634	2.7161	3.0807	3.4517	3.7529	1.358
6	2.5503	2.3765	2.8858	3.0247	3.5648	3.77	1.358
7	2.6612	2.7161		3.1367	3.7346	3.8809	1.8673
8	2.7721	2.4331	2.8858	3.0727	3.6214	2.7446	2.7161
9	2.9687	2.5463	2.9424	3.0807	3.678	1.2197	3.2819
10	2.2634	2.0725	2.8006	3.0247	3.1687	.7282	2.6886
11	2.4331	2.0725	2.6606	2.963	3.6214	.7207	2.8829
12	2.1502	2.0302	2.5206	2.8532	3.3385	.7762	2.9687
13	2.1502	2.1845	2.9127	2.8532	3.5082	.7282	3.1927
14	2.5463	2.4086	3.0807	3.0807	4.0741	.8316	3.6969
15	2.7161	2.4646	3.2487	2.9127	3.7346	1.1643	3.3608
16	2.7161	2.5766	3.4208	3.5848	3.7912	1.0642	
17	2.5463	2.4646	3.4208	3.5117	4.0741	1.2197	3.5288
18	2.7161	2.6595	3.3608	3.4517	3.4928	1.4146	3.1927
19	2.7726	2.8292	3.4019	3.6214	3.6969	1.7541	3.2156
20	2.4897	2.5463	3.2487	3.6214	3.5848	1.6975	3.271
21	2.3765	2.4897	3.2487	3.5082	3.6037	1.6975	3.1367
22	2.6595	2.7726	3.3048	3.3951	3.7529	1.6975	3.4374
23	2.7161	2.6595	3.3048	3.5648	3.7146	1.8107	3.6037
24	3.0716	2.4331	2.7726	3.3608	3.7912	3.6969	1.6975
Max	3.0716	2.8292	3.4208	3.6214	4.0741	3.8809	3.6969
Min	2.1502	2.0302	2.5206	2.8532	3.1687	.7207	1.358
Avg	2.5795	2.4118	2.9780	3.2156	3.6452	2.1292	2.6333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 402 / 33 KV Khodashi Power plant NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0914
Max	.0914
Min	.0914
Avg	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching
Station

Feeder No / Name : 201 / KARVE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	1.0105	.9829	1.0364	.2534	.2012	.197
2	.2103	.9976	.9808	1.0059	.2126	.1867	.1991
3	.1949	.9976	.9682	1.0059	.1928	.1867	.2172
4	.2149	1.0551	1.0105	1.0494	.2149	.1867	.2195
5	.2534	1.2041	1.0536	1.1248	.2743	.2012	.2195
6	.2926	1.3904	1.2811	1.4373	.3734	.2218	.2987
7	.3841	1.5851	1.4815	1.5623	.4527	.3658	.362
8	.4024	1.5306	1.3847	1.2971	.415	.3292	.2804
9	.2926	1.3203	1.3176	1.1431	.2987	.2534	.2401
10	2.1822	.2229	.2401	.2427	1.829	2.0062	2.0729
11	2.2455	.218	.218	.2149	2.0873	2.0062	2.1872
12	2.1822	.218	.1989	.2126	1.8427	1.9814	2.1759
13	2.1247		.2012	.2204	1.8964	2.0216	1.9052
14	1.9925	.2652	.218	.2454	1.8427	1.9509	2.0622
15	1.9292	.2713	.2058	.2543	1.9022	1.8747	2.0466
16	1.8122	.2804	.2374	.2204	1.7833	1.9566	
17	1.6004	.2427	.2279	.2652	1.6707	1.8663	1.8519
18	.2035	.2591	.2126	.2229	.2012	.2126	.208
19	.2835	.3258	.2865	.3155	.2804	.2915	.2865
20	.3045	.3012	.2896	.3224	.2865	.2835	.2835
21	.3045	.2865	.2896	.3077	.2896	.2865	.3439
22	.3258	.2715	.2926	.3109	.2926	.2865	.3077
23	.2303	.2149	.2195	.2561	.2195	.2103	.2534
24	.2303	1.0084	.9934	1.0364	.2561	.2218	.2058
Max	2.2455	1.5851	1.4815	1.5623	2.0873	2.0216	2.1872
Min	.1949	.2149	.1989	.2126	.1928	.1867	.197
Avg	.8504	.6729	.6163	.6379	.807	.8162	.8011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching
Station

Feeder No / Name : 202 / TEMBHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1222	2.0508	2.021	1.6857	1.7071	1.3817
2	2.1251	2.021	2.0359	1.7071	1.6347	1.3817
3	2.0953	2.0469	2.0359	1.6857	1.6556	1.438
4	2.1222	2.0508	2.077	1.7071	1.768	1.7833
5	2.1373	2.0921	2.0805	1.6857	1.7985	1.7665
6	2.1491	2.1338	2.21	1.7071	1.9052	1.7833
7	2.0978	2.1251	2.271	1.8595	1.9509	2.0005
8	2.1285	2.1994	1.7341	1.8719	1.9662	2.0862
9	2.1418	2.2298	2.3628	1.8924	2.0271	2.0851
10	2.2142	2.1285	2.2727	2.0098	1.9913	2.0416
11	2.2298	2.1272	2.392	2.2298	2.0119	2.1523
12	1.5912	2.1565	2.6852			2.5436
13	2.2862	2.2298	2.3034		1.1111	1.7535
14	2.2434	2.0538	2.5758		2.0685	2.5606
15	2.2588	2.0359	1.6871	1.1934	2.2298	2.5301
16	.7964	1.0717	1.0856	.727	1.2742	1.1439
21				.3077		
Max	2.2862	2.2298	2.6852	2.2298	2.2298	2.5606
Min	.7964	1.0717	1.0856	.3077	1.1111	1.1439
Avg	2.0462	2.0471	2.1144	1.5907	1.8067	1.9020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching
StationFeeder No / Name : 206 / 11 KV Karve Gaothan
Feeder KV- 11 / OUTGOING**GAOTHAN FEEDER**

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2829	.3018	.3018	.3395	.3395	.3206
2	.3018	.2829	.2987	.3018	.3206	.3395	.3018
3	.3206	.2801	.2987	.2987	.3395	.3174	.3206
4	.3206	.3174	.3395	.3772	.3772	.3547	.3772
5	.4527	.4481	.5093	.5281	.5281	.4481	.5281
6	.811	.7922	.8299	.8402	.8488	.7842	.8299
7	.9808	.9335	.9522	.9709	.9808	.9709	.9335
8	.8215	.7947	.8402	.7947	.8215	.8316	.7499
9	.5975	.4525	.5792	.6089	.5249	.5487	.543
10	.3982	.4298	.4908	.4961	.3898	.4755	.3856
11	.4207	.3506	.4557	.4252	.4557	.3982	.3814
12	.362	.3506	.4207	.4298	.3856	.394	.3856
13	.4656		.4252	.3582	.3544	.394	.3155
14	.3582	.3856	.4298	.362	.3582	.3761	.3294
15	.362	.3506	.4607	.3761	.4031	.3982	.4557
16	.3582	.4252	.362	.394	.4031	.3582	.4207
17	.4298	.4908	.3898	.4161	.4207	.3761	.4784
18	.4508	.4917	.4801	.4458	.4961	.4252	.4733
19	.6219	.6733	.6335	.6516	.6516	.6878	.6283
20	.6401	.695	.695	.695	.695	.695	.7023
21	.5729	.6584	.6653	.6584	.6767	.6722	.6722
22	.5415	.6161	.6161	.4715	.6219	.6283	.6348
23	.3921	.4108	.4527	.4715	.4572	.4527	.4904
24	.3206	.2987	.3361	.3206	.3584	.3772	.3734
Max	.9808	.9335	.9522	.9709	.9808	.9709	.9335
Min	.3018	.2801	.2987	.2987	.3206	.3174	.3018
Avg	.4835	.4875	.5110	.4998	.5087	.5018	.5013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106]

BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 201 / 11 KV VADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2587	.2743	.2772	.2801	.3142	.2957
2	.2801	.2587	.2743	.2772	.2801	.2957	.2957
3	.2641	.2587	.2743	.2772	.2801	.2957	.2957
4	.2829	.3292	.3142	.3361	.3547	.3696	.3361
5	.3961	.4024	.4066	.4108	.4481	.4481	.4481
6	.4904	.5121	.5359	.5228	.5601	.5544	.5601
7	.5359	.6099	.5544	.5914	.5729	.5729	.6099
8	.4024	.3982	.4477	.5068	.5068	.4525	.4755
9	.3224	.3429	.3814	.3988	.3856	.3641	.3681
10	.2774	.3353	.2949	.39	.3561	.3561	.3353
11	.2743	.3018	.3113	.3258	.3521	.3521	.3258
12		.3018	.2984	.3222	.3315	.3353	.3353
13		.2984	.285	.3018	.3052	.3149	.285
14		.2515	.285	.3052	.3086	.285	.2883
15		.2683	.2713	.3222	.2883	.2713	.2915
16		.2652	.3052	.3222	.3086	.2883	.2915
17	.2743	.2652	.3353	.3429	.3222	.3086	.2915
18		.3018	.3561	.3258	.3052	.3429	.2883
19		.4075	.4733	.4477	.4252	.4119	.443
20		.4607	.4961	.4525	.4656	.4656	.4656
21	.5014	.4525	.4706	.4572	.4706	.4525	.4344
22	.4755	.4024	.439	.439	.4572	.4525	.4207
23	.3258	.3439	.3475	.3475	.3841	.3841	.3801
24	.2772	.2743	.2743	.2957	.2957	.3511	.3326
Max	.5359	.6099	.5544	.5914	.5729	.5729	.6099
Min	.2641	.2515	.2713	.2772	.2801	.2713	.285
Avg	.3538	.3459	.3628	.3748	.3769	.3766	.3706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 202 / 11 KV VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.9568	.9145	.7773	.1494	.1867	.1698
2	.1698	.9145	.9145	.7621	.1307	.1867	.1698
3	.132	.9145	.873	.7526	.132	.1867	.168
4	.132	.9259	.873	.7926	.1494	.1867	.1867
5	.132	.9414	.884	.823	.1509	.1867	.1886
6	.1509	.9414	.9332	.8535	.1509	.2075	.1886
7	.168	1.0084	1.0517	.9214	.1509	.2241	.2075
8	.168	1.0122	1.0536	.9214	.1663	.2054	.1867
9	.1663	.9808	.9633	.9633	.1307	.1867	.1867
10		.2218	.168	.1509	1.0212	1.0185	1.0212
11	1.1248	.2054	.2241	.1867	1.1561	1.1092	1.078
12		.2054	.2241	.1494	1.1883	1.1561	1.0957
13		.2054	.2054	.1494	1.1574	1.1888	1.0669
14		.2054	.2427	.1494	1.1574	1.1584	1.0185
15		.2054	.2054	.1494	1.1126	1.1138	.9755
16		.2054	.2218	.1494	1.0494	1.0837	.9482
17		.1494	.2218	.1848	.9659	1.0212	.945
18		.1848	.2218	.2054	.2054	.2054	.1478
19		.1867	.2054	.2054	.2241	.2054	.168
20		.1848	.2054	.2054	.2241	.2054	.1867
21	.132	.1867	.2075	.2054	.2241	.2054	.1848
22	.9105	.1867	.1886	.168	.2054	.1991	.168
23	.9568	.1494	.1698	.168	.2054	.1867	.168
24	.1698	.9602	.9568	.7926	.1494	.1867	.1867
Max	1.1248	1.0122	1.0536	.9633	1.1883	1.1888	1.0957
Min	.132	.1494	.168	.1494	.1307	.1867	.1478
Avg	.3345	.5100	.5137	.4495	.4816	.5000	.4588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256011 / 110 KV TEMBHU

Feeder No / Name : 204 / TEMBHU Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1646	.1867	.1698	.2218	.2054	.2218
2	.1509	.1663	.1663	.1698	.2033	.1867	.2218
3	.1509	.1463	.1646	.1867	.2012	.1886	.2054
4	.168	.1629	.1867	.2241	.2218	.2263	.2075
5	.2378	.2328	.2033	.2172	.2715	.2614	.2075
6	.3361	.3721	.3801		.3841	.3174	.3658
7	.4298	.4382	.4557	.394	.4525	.4066	.4382
8	.3721	.3688	.407	.3189	.4344	.3475	.4115
9		.3605	.3481	.4115	.3887	.3258	.3441
10	.362	.3239	.3521	.2721	.3858	.2818	.3281
11	.2328	.2591	.3163	.2401	.2881		.2881
12	.2507	.2372	.3041	.285	.2743	.2347	.2743
13	.2149	.2401	.2515	.2374	.2846	.2012	
14	.2126	.2267	.2294	.208	.2812	.2058	.2785
15	.2328	.2543	.2515	.213	.2401	.2103	.3052
16	.3224	.3315	.3795	.2881	.3795	.2818	.2846
17	.2401	.3481	.3605	.3077	.3887	.2743	.3768
18	.3018	.3521	.426	.3361	.3812	.3086	.4096
19	.3814	.463	.4031	.4161	.4557	.3224	.4973
20	.3258	.3681	.394	.3258	.394	.3292	.4119
21	.2772	.3077	.3439	.3258	.3077	.2926	.3326
22	.2896	.2772	.2801	.3077	.2926	.3109	.3292
23	.2172	.2218	.2452	.2743	.2402	.2772	.2801
24	.2308	.1848	.2033	.1698	.2218	.2218	.2587
Max	.4298	.463	.4557	.4161	.4557	.4066	.4973
Min	.1509	.1463	.1646	.1698	.2012	.1867	.2054
Avg	.2655	.2837	.3016	.2739	.3165	.2704	.3165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256011 / 110 KV TEMBHU

Feeder No / Name : 206 / 11 KV SWITCH YARD
Feeder KV- 11 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.0305
Max	.0305
Min	.0305
Avg	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 201 / Rethare Gaonthan
(Karkhana) Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
23	.3944
24	.1467
Max	.3944
Min	.1467
Avg	.2706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 203 / RETHARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.3963
Max	.3963
Min	.3963
Avg	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 204 / SHENOLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 209 / Rethare LIS

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	.0457
Max	.0457
Min	.0457
Avg	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 201 / MUNDHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.1219	.1075	.1052	1.6804	1.6156	2.0683
2	1.2193	.1219	.1097	.1052	1.6804	1.6156	2.0683
3	1.3717	.1219	.1075	.1052	1.8861	1.5851	2.0683
4	1.4403	.1219	.1075	.1052	1.8861	.5335	2.0683
5	1.5775	.1067	.1075	.1052	1.8861	.5487	1.4373
6	1.6975	.1067	.1075	.1052	1.9719	.6859	2.1033
7	1.7147	.1067	.1075	.1029	2.2291	.9602	2.3663
8	1.9033	.1067	.1646	.12	2.2291	.9145	2.1605
9	1.6118	.1372	.1254	.1067	1.7147	1.0566	1.7985
10	.1448	2.572	2.915	2.4844	.1715	.1075	.1067
11	.197		3.155	2.5301	.1715	.1612	.1219
12	.197	2.3834	2.9835	2.6368	.2058	.1612	.1219
13	.197	2.4348	2.7435	2.5453	.1715	.1433	.0914
14	.1791	2.7092	2.7435	2.4387	.12	.1433	.0914
15	.1086	2.7092	2.6749	2.2253	.12	.1791	.1067
16	.1075	2.7092	2.6749	2.4387	.12	.197	.0914
17	.0716	2.758	2.5549	2.452	.1372	.2572	.1372
18	.1097	.1254	.12	.1715	.1219	.2058	.1372
19	.1219	.1612	.1372	.1715	.1524	.1928	.1372
20	.1219	.1433	.1372	.1715	.1067	.1928	.1372
21	.1219	.1075	.1578	.1715	.1219	.1402	.1372
22	.1219	.1097	.1928	.1372	.1067	.1402	.1372
23	.1067	.1075	.1753	.1372	.1067	.1402	.12
24	1.4575	.1067	.1097	.1578	1.6804	1.6309	2.0683
Max	1.9033	2.758	3.155	2.6368	2.2291	1.6309	2.3663
Min	.0716	.1067	.1075	.1029	.1067	.1075	.0914
Avg	.7197	.8778	1.0217	.9096	.8658	.5629	.9118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.3224	.3506			
2		.2743	.3292	.3506			
3		.2743	.3292	.3506			
4		.2743	.3224	.3506			
5		.3048	.3258	.3506			
6		.3353	.3658	.3506			
7		.3658	.4525	.3772			
8		.3963	.4477	.4115			
9		.3944	.4119	.3201			
10	.6626				.463	.5014	.503
11					.6344	.6805	.381
12	.6447				.6516	.7343	.5792
13	.6268				.6516	.7164	.5792
14	.6089				.6344	.6805	.5792
15	.5731				.6344	.6268	.4877
16	.5194				.583	.591	.442
17	.5304				.4877	.5784	.3963
24	.0343	.1372	.3403	.3506			
Max	.6626	.3963	.4525	.4115	.6516	.7343	.5792
Min	.0343	.1372	.3224	.3201	.463	.5014	.381
Avg	.5250	.3031	.3647	.3563	.5925	.6387	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 204 / MARALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2195	.2103	.1372	.2401	.2454
2	.1715	.2058	.2195	.2103	.2058	.2401	.2454
3	.1715	.2058	.2195	.2103	.2058	.2401	.2454
4	.2401	.2058	.2149	.2103	.2401	.2401	.2454
5	.2743	.2401	.2686	.2629	.3086	.2743	.2629
6	.3258	.3429	.362	.3429	.3429	.3601	.3681
7	.3772	.3944	.4656	.3772	.3772	.4115	.4382
8	.4458	.4458	.4298	.4458	.4115	.4458	.4458
9	.4298	.3772	.4119	.4115	.3944	.4119	.4115
10	.4298	.3944	.3258	.3944	.3429	.4298	.3429
11	.394	.3772	.3601	.3944	.3601	.3761	.3772
12	.4656	.3772	.3601	.3601	.3601	.3582	.4458
13	.3403	.3772	.3429	.3772	.3601	.3582	.3944
14	.3582	.3429	.3429	.3772	.3086	.3582	.3772
15	.3761	.3429	.3258	.3944	.3086	.3761	.4115
16	.3761	.3772	.3258	.3601	.3772	.394	.4287
17	.3841	.394	.3601	.3601	.3429	.3681	.4287
18	.3801	.4119	.3856	.4287	.3944	.4207	.4801
19	.5487	.6268	.5487	.5487	.5658	.5784	.5487
20	.583	.5731	.5434		.6001	.5784	.6516
21	.4458	.4835	.4733	.583	.5316	.4908	.5144
22	.3601	.394	.4207	.4458	.463	.4557	.4458
23	.2572	.3224	.3155	.3258	.3258	.3155	.3429
24	.2058	.2058	.2507	.2279	.2401	.2572	.2454
Max	.583	.6268	.5487	.583	.6001	.5784	.6516
Min	.1715	.2058	.2149	.2103	.1372	.2401	.2454
Avg	.3547	.3593	.3539	.3591	.3544	.3741	.3893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 206 / SOMAIDEVI LIS EXPRESS

PURELY LIS FEEDERS

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1524	.1463	.1052	.1524	.0351
2	.1029	.1524	.1463	.1052	.2058	.0351
3	.1029	.1524	.1463	.1052	.2058	.0351
4	.1029	.1524	.1433	.1052	.2058	.0351
5	.1029	.1524	.1463	.1052	.2058	.1227
6	.12	.1524	.4344	.1052	.2058	.3429
7	.1715	.5335	.6154	.2629	.2743	.6344
8	.7888	.7773	1.1104	.9945	1.1488	.8059
9	1.0136	1.0117	1.2715	.9907	1.2003	1.0517
10	1.0498	1.0631	1.046	1.0974	1.2003	.9145
11	1.0387	1.166	1.2346	1.1126	1.1831	.9145
12	1.0387	1.166	1.2346	1.0974	1.1831	.8993
13	1.0387	1.166	1.2003	1.0822	1.1831	.8993
14	1.0208	1.1488	1.0974	1.0822	1.166	.8993
15	1.0029	1.1488	1.0117	1.0059	1.166	.9145
16	.8954	1.1488	.9945	.8993	.8916	.3353
Max	1.0498	1.166	1.2715	1.1126	1.2003	1.0517
Min	.1029	.1524	.1433	.1052	.1524	.0351
Avg	.6058	.7028	.7487	.6410	.7361	.5547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 201 / 11 KV Kalgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1475	.1677	.1526	.1509	.1619	.1715
2	.12	.1475	.1677	.1526	.1509	.1619	.1715
3	.12	.1475	.1677	.1526	.1509	.1619	.1715
4	.12	.1475	.1715	.1526	.1509	.1619	.1715
5	.1402	.1886	.1928	.2572	.1715	.1823	.2804
6	.2896	.2865	.3224	.3012	.2896	.3012	.3258
7	.4706	.4119	.4706	.443	.3932	.4525	.4525
8	.4733	.4119		.4607	.5014	.3761	.4119
9	.3391	.333	.3601	.3467	.3641	.3582	.333
10	.2804	.3224	.3121	.3721	.3467	.2601	.3155
11	.2804	.3155	.2743	.3155	.298	.2804	.2947
12	.208	.2601	.2743	.3155	.2572	.2254	.2254
13	.2058	.2652	.2229	.2915	.2401	.2401	.1886
14	.2401	.2035		.2427	.2058	.2427	.2058
15	.2058	.2279	.2629	.2572	.2035	.1865	.2058
16	.2374	.2774	.2683	.2294	.2543	.2035	.2155
17	.2713	.2774	.2469	.2515	.2984	.2204	.2155
18	.285	.2949	.3121	.3048	.3125	.2753	.2984
19	.4607	.5014	.5083	.4784	.5014	.5083	.4477
20	.5068	.5068	.5792	.4887	.5487	.5552	.5611
21	.4477	.4656	.5194	.4835	.4961	.5068	.5121
22	.3224	.3544	.3681	.3681	.3721	.3898	.3982
23	.213	.2454	.218	.2294	.2486	.2683	.2715
24	.1372	.1475	.1677	.1696	.1677	.1677	.1907
Max	.5068	.5068	.5792	.4887	.5487	.5552	.5611
Min	.12	.1475	.1677	.1526	.1509	.1619	.1715
Avg	.2706	.2870	.2980	.3007	.2948	.2854	.2932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 202 / 11 KV Jinti Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0819	.0838	.0848	.1006	.0972	.0857
2	.0857	.0819	.0838	.0848	.1006	.0972	.0857
3	.0857	.0819	.0838	.0848	.1006	.0972	.0857
4	.0857	.0819	.0857	.0848	.1006	.0972	.0857
5	.0857	.0857	.0876	.1029	.1029	.0995	.1052
6	.1086	.0895	.1254	.124	.1267	.124	.1267
7	.181	.197	.1991	.2303	.1802	.1991	.2172
8	.2629	.197	.2126	.2303	.197	.1791	.2149
9	.2035	.1753	.3449	.1734	.156	.1612	.1402
10	.1227	.1433	.1052	.124	.1214	.0867	.1227
11	.1227	.1052	.1372	.1402	.1227	.0876	.104
12	.104	.104		.1052	.1029	.0867	.0693
13	.12	.0995	.1372	.1029	.1029	.1029	.0857
14	.12	.1017	.12	.1214	.1029	.104	.0857
15	.12	.0876	.1227	.1372	.1187	.0848	.1029
16		.1214	.1174	.1311	.1187	.0848	.1326
17	.1526	.104	.1698	.1509	.1492	.1357	.1492
18	.1677	.1475	.156	.1981	.1562	.1619	.1658
19	.2126	.2149	.2454	.2481	.197	.1753	.2149
20	.2353	.2715	.2715	.2534	.2012	.197	.2715
21	.2507	.2328	.2686	.2507	.1949	.1991	.2743
22	.197	.1949	.1928	.2279	.1772	.2126	.2172
23	.1311	.1578	.1341	.1475	.1326	.1509	.1448
24	.0857	.0819	.0838	.0848	.1006		.104
Max	.2629	.2715	.3449	.2534	.2012	.2126	.2743
Min	.0857	.0819	.0838	.0848	.1006	.0848	.0693
Avg	.1446	.1350	.1551	.1510	.1360	.1314	.1413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 203 / SANBUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1311	.1509	.1526	.1677	.1619	.1543
2	.1543	.1311	.1509	.1526	.1677	.1619	.1543
3	.1543	.1311	.1509	.1526	.1677	.1619	.1543
4	.1543	.1311	.1715	.1526	.1677	.1619	.1543
5	.1753	.1715	.333	.2401	.1886	.1989	.2454
6	.3258	.2686	.3045	.2835	.2896	.3012	.2896
7	.4887	.4477	.4525	.4607	.4096	.4344	.4344
8	.4908	.4477	.4252	.4607	.4298	.4835	.4477
9	.407	.4207	.3814	.4334	.3814	.3403	.2804
10	.4207	.3582	.3988	.3721	.3121	.2774	.3155
11	.3681	.3506	.3601	.333	.2804	.2804	.2774
12	.3121	.3294	.3086	.3155	.2401	.2427	.2947
13	.2743	.2486	.3086	.2915	.2401	.2743	.2572
14	.2401	.2543	.2229	.2601	.2229	.2774	.2401
15	.2401	.2804	.2629	.2401	.2543	.2713	.2915
16	.2543	.2947	.2683	.2294	.2883	.3052	.2652
17	.3222	.3294	.2623	.285	.2818	.3052	.2818
18	.285	.3441	.3121	.3201	.3593	.3239	.2984
19	.4252	.5194	.4557	.4938	.5194	.5083	
20	.4887	.5249	.5068	.5249	.5304	.5373	.543
21	.4477	.4835	.4477	.5014	.4784	.4887	.5068
22	.3403	.3544	.3506	.3506	.3721	.3544	.3982
23	.213	.2103	.2347	.2294		.2347	.2534
24	.1715	.1638	.1509	.1696	.1844	.1844	.156
Max	.4908	.5249	.5068	.5249	.5304	.5373	.543
Min	.1543	.1311	.1509	.1526	.1677	.1619	.1543
Avg	.3045	.3053	.3072	.3086	.3015	.3030	.2910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 204 / TALMAVALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1638	.1844	.2035	.1844	.1781	.2058
2	.1543	.1638	.1844	.2035	.1844	.1781	.2058
3	.1543	.1966	.1844	.2035	.1844	.1781	.2058
4	.1543	.1638	.1886	.2035	.1844	.1781	.2058
5	.1753	.2058	.2103	.3086	.2058	.2155	.2804
6	.3077	.3045	.3761	.3366	.362	.3544	.3258
7	.4525	.5194	.4887	.4961	.4752	.4706	.4525
8	.5249	.5731	.5138	.567	.5194	.5194	.4656
9	.39	.4557	.3988	.4508	.4334	.4835	.3856
10	.3856	.4477	.3814	.4784	.4161	.4334	.4382
11	.333	.4031	.3429	.4207	.3856	.3681	.4161
12	.2774	.3467	.3086	.3856	.3429	.3641	.3641
13	.2743	.2984	.2743	.3601	.3086	.3429	.3086
14	.2743	.3052	.2401	.3121	.3086	.3429	.3086
15	.2743	.298	.2629	.3086	.3222	.2883	.3258
16	.2883	.3294	.2683	.2949	.3052	.2713	.3315
17	.3052	.3814	.2932	.3185	.2984	.3052	.3149
18	.2683	.3113	.3814	.3048		.3077	.3812
19	.4784	.5194	.4908	.4961	.4656	.4207	.3149
20	.4706	.5249	.543	.543	.4938	.5014	.543
21	.4298	.4298	.4835	.4656	.443	.4706	.5068
22	.3582	.3721	.3856	.3856	.3721	.4075	.4706
23	.2458	.2804	.285	.2622	.2652	.285	.3077
24	.1715	.1966	.1844	.2204	.2012	.2012	.2254
Max	.5249	.5731	.543	.567	.5194	.5194	.543
Min	.1543	.1638	.1844	.2035	.1844	.1781	.2058
Avg	.3043	.3413	.3273	.3554	.3331	.3361	.3454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 205 / Sanbur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2294	.218	.2035			
2		.1966	.218	.2035			
3		.1966	.218	.2035			
4		.1966	.1715	.2035			
5		.2229	.1753	.2229			
6		.2507	.2328	.2481			
7		.3224	.3439	.3544			
8		.2865	.3544	.3366			
9		.2454	.2743	.2601			
10	.7186				.7108	.7628	.6836
11	.7537				.7362	.7537	
12	.5721				.6859	.6762	.5721
13	.5487				.6687	.6344	.6687
14	.4801				.6516	.5028	.583
15	.4287				.5426	.4917	.5658
16	.39				.4917	.4917	.4973
17	.3561				.4641	.4917	.4807
24		.2294	.218	.2374			
Max	.7537	.3224	.3544	.3544	.7362	.7628	.6836
Min	.3561	.1966	.1715	.2035	.4641	.4917	.4807
Avg	.531	.2377	.2424	.2474	.6190	.6006	.5787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 206 / 11 KV Kalgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115				.4024	.2915	.3429
2					.3688	.2915	.3429
3	.4115				.3688	.2915	.3429
4	.4115				.3688	.2915	.3429
5	.4207				.3429	.3149	.3681
6	.362				.362	.4252	.4163
7	.4525				.4915	.5068	.4706
8	.4557				.5731	.5194	.4656
9	.4239				.4334	.4656	.3856
10		.9492	1.0229	.9568			
11		.9816	.9945	.9991			
12		.9882		.9816			
13		.8453	.8916	.9431			
14		.9665	.8916	.9015			
15		.964	.9114	.8573			
16		.9189	.788	.6226			
17		.8149	.6173	.6036			
24	.4115				.4024	.3521	.3467
Max	.4557	.9882	1.0229	.9991	.5731	.5194	.4706
Min	.362	.8149	.6173	.6036	.3429	.2915	.3429
Avg	.4179	.9286	.8739	.8582	.4114	.375	.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254077 / 33/11 KV Marul Haveli

Feeder No / Name : 201 / 11 KV Nawadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.0305	.0305	.0305	.6706	.6554	.6554
2	.7011	.0305	.0305	.0305	.6554	.6554	.6401
3	.6097	.0305	.0305	.0305	.6554	.6554	.6097
4	.6249	.0305	.0305	.0305	.7545	.6706	.5944
5	.6554	.0305	.0305	.0305	.7316	.6706	.5944
6	.7164	.0305	.0305	.0305	.8078	.7011	.5944
7	.7468	.0305	.0305	.0305	.503	.884	.7468
8	.6859	.0305	.0305	.0305	.823	.9297	.823
9	.5792	.0305	.0305	.0305	.7926	.8383	.7011
10	.0305	1.448	1.3717	1.3413	.0305	.0305	.0305
11	.0305	1.5699	1.4784	1.3565	.0305	.0305	.0457
12	.0305	1.6004	1.4784	1.4632	.0457	.0305	.0457
13	.0305	1.4632	1.4327	1.4022	.0457	.0305	.0305
14	.0305	1.448	1.3565	1.3565	.0457	.0305	.0457
15	.0305	1.4327	1.3108	1.3565		.0305	.0305
16	.0305	1.326	1.2498	1.2803		.0305	.0305
17	.0305	1.2193	1.0974	1.1736	.0457	.0305	.0457
18	.0305	.0305	.0305	.0305	.0457	.0457	.0457
19	.0305	.0305	.0305	.0305	.0457	.0457	.0305
20	.0305	.0305	.0305	.0305	.0457	.0457	.0305
21	.0305	.0305	.0457	.0305	.0457	.0305	.0305
22	.0305	.0305	.0305	.0305	.0457	.0305	.0305
23	.0305	.0305	.0305	.2804	.0457	.0457	.0305
24	.6249	.0305	.0305	.0305	.6554	.6859	.6401
Max	.7468	1.6004	1.4784	1.4632	.823	.9297	.823
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.2915	.4998	.4700	.4778	.3440	.3264	.2959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254077 / 33/11 KV Marul Haveli

Feeder No / Name : 202 / 11 KV Marul Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1578	.2103	.2103	.1928	.1928	.2279
2	.1578	.1578	.1578	.1578	.1578	.1578	.1753
3	.1578	.1578	.1578	.1578	.1578	.1578	.1578
4	.1578	.1753	.1753	.2103	.1753	.1753	.1578
5	.2103	.2103	.2454	.2454	.2103	.2279	.2454
6	.3155	.2804	.3506	.3681	.2804	.333	.3155
7	.4382	.3681	.4733	.4733	.4207	.4557	.4733
8	.4382	.4557	.4908	.4557	.4031	.4382	.4382
9	.3506	.4031	.3856	.3856	.3681	.3681	.3506
10	.3155	.3506	.333	.3506	.333	.3155	.333
11	.2804	.3155	.298	.3155	.3155	.2804	.2804
12	.2804	.2804	.298	.2804	.2629	.298	.2629
13	.2629	.3155	.2454	.298	.2629	.2629	.2629
14	.2454	.2629	.2454	.298	.2629	.2454	.1928
15	.2454	.2454	.2279	.298		.2279	.1928
16	.2454	.2454	.1928	.2804		.2279	.298
17	.2804	.298	.298	.2804	.2804	.333	.3681
18	.3155	.3506	.3506	.3506	.4207	.3506	.4031
19	.4733	.4908	.5258	.5258	.5784	.5434	.5609
20	.5083	.5959	.4382	.5434	.6135	.5784	.5959
21	.4557	.5258	.4557	.4854	.5784	.5083	.5258
22	.3856	.4557	.4382	.4031	.4557	.4382	.4733
23	.2454	.3155	.3155		.3155	.298	.3155
24	.1928	.1753	.2279	.2454	.2279	.2454	.2454
Max	.5083	.5959	.5258	.5434	.6135	.5784	.5959
Min	.1578	.1578	.1578	.1578	.1578	.1578	.1578
Avg	.2972	.3162	.3141	.3313	.3306	.3192	.3272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254077 / 33/11 KV Marul Haveli

Feeder No / Name : 203 / 11 kv Divashi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052		.8842	.9189	.052	.052	.052
2	.052	1.2136	.9015	.9015	.052	.052	.052
3	.052	1.2136	.9015	.9015	.052	.052	.052
4	.052	1.2483	.9015	.9015	.052	.052	.052
5	.052	1.2483	.9362	.9189	.052	.052	.052
6	.052	1.283	.9362	.9362	.052	.052	.052
7	.052	1.3003	.9709	.9882	.052	.052	.052
8	.052	1.3176	.9362	.9882	.052	.052	.052
9	.052	.2427	.9362	.1907	.052	.052	.052
10	1.4217	.052	.052	.052	1.387	1.439	1.387
11	1.5083	.052	.052	.052	1.4737	1.5083	1.387
12	1.491	.052	.052	.052	1.5257	1.1616	1.4043
13	1.4563		.052		1.5083	1.491	1.4217
14	1.439	.052	.052	.052	1.4737	1.4737	1.4043
15	1.439	.052	.052	.052	1.4043	1.4217	1.4217
16	1.4217	.052	.052	.052	1.4043	1.4043	1.4217
17	1.4043	.052	.052	.052	1.3696	1.387	1.387
18	.052	.052	.052	.052	.052	.052	.052
19	.052	.052	.052	.052	.052	.052	.052
20	.052	.052	.052	.052	.052	.052	.052
21	.052	.052	.052	.052	.052	.052	.052
22	.052	.052	.052	.052	.052	.052	
23	.052	.052	.052	.052	.052	.052	.052
24	.052	1.2483	.8842	.9189	.052	.052	.052
Max	1.5083	1.3176	.9709	.9882	1.5257	1.5083	1.4217
Min	.052	.052	.052	.052	.052	.052	.052
Avg	.5172	.4996	.4132	.4018	.5158	.5049	.5224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 258015 / 220/33 KV MALHARPETH

Feeder No / Name : 400 / AUXILLORY SUPPY

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 258015 / 220/33 KV MALHARPETH

Feeder No / Name : 401 / 33 KV PATAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 258015 / 220/33 KV MALHARPETH

Feeder No / Name : 403 / 33 KV KOLEWADI (LIS)

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 258015 / 220/33 KV MALHARPETH

Feeder No / Name : 404 / 33 KV UMBRAJ

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 258015 / 220/33 KV MALHARPETH

Feeder No / Name : 409 / 33 KV MALHARPETH

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 201 / 11 KV Mandure Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1578	.1772	.2103	.1772	.1595	.1829
2	.1433	.1357	.1772	.1753	.1417	.1402	.1829
3	.1417	.1357	.1417	.1753	.1417	.1402	.1886
4	.1417	.1357	.1463	.1753	.1417	.1402	.181
5	.1772	.1543	.1829	.2103	.181	.1772	.2195
6	.2561	.2126	.2195	.2804	.2896	.2507	.4706
7	.3841		.3658	.3856	.3658	.4706	.5792
8	.439		.3658	.4207	.4024	.4207	.6447
9	.4024		.3292	.3506	.3582	.3688	.6024
10	.2658		.3292	.3506	.3189	.3391	.6733
11	.2915	.2984	.2743	.2804	.2896	.2949	.5258
12	.2785	.2713	.2743	.2804	.2469	.2915	.2195
13	.2623	.2984	.2743	.2804	.25	.2622	.3155
14	.2623	.2294	.2658	.2804	.2469	.2214	.3189
15	.2591	.2187	.2835	.3155	.2439	.2881	.3544
16	.2656	.2812	.298	.3155	.2229	.3239	
17	.3077	.2949	.3366	.3506	.2543	.3563	.4961
18	.3441	.3605	.4607	.4557	.407	.3932	.5853
19	.5365	.5853	.6516	.5609	.5175	.5792	.567
20	.5729	.5914	.695	.5959	.5544	.6283	.6584
21	.5175	.5544	.5853	.5258	.5175	.5487	.5316
22	.4435	.4066	.4382	.3856	.4435	.4344	.443
23	.2507	.2534	.3189	.2454	.2715	.2534	.3544
24	.197	.1753	.1829	.2103	.1772	.1791	.2195
Max	.5729	.5914	.695	.5959	.5544	.6283	.6733
Min	.1417	.1357	.1417	.1753	.1417	.1402	.181
Avg	.3050	.2876	.3239	.3257	.2984	.3192	.4137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0486				1.4918	1.2597	1.2407
2	1.0159				1.4586	1.2289	1.1736
3	.9831				1.4586	1.2289	1.1736
4	.9503				1.4586	1.2308	1.1736
5	.9503				1.4586	1.326	1.2407
6	.9503				1.5912	1.3592	1.2407
7	.9503				1.6575	1.4089	1.5089
8	.852				1.7101	1.5424	1.4746
9	.852				1.5424	1.4091	1.0562
10		2.1795	2.1616	2.0576			
11		2.1026	2.2786	2.4006			
12		2.2634	2.2786	2.2977			
13		2.1605	2.3034	2.2634			
14		1.933	2.3411	2.1605			
15		1.8778	2.268	1.989			
16		2.0348	2.3411	2.0233			
17		2.0008	2.1434	1.8861			
24	1.1317				1.4918	1.2929	1.2407
Max	1.1317	2.2634	2.3411	2.4006	1.7101	1.5424	1.5089
Min	.852	1.8778	2.1434	1.8861	1.4586	1.2289	1.0562
Avg	.9685	2.0691	2.2645	2.1348	1.5319	1.3287	1.2523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 203 / ADUL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582		.3189	.3155	.3898	.3506	.3155
2	.3189		.2926	.3155	.3544	.3121	
3	.3189		.2896	.3155	.3544	.3121	.3224
4	.3189		.2926	.3506	.3544	.3121	.3224
5	.362		.3189	.3856	.4298	.3506	.3582
6	.439		.4252	.4557	.5014	.4344	
7	.5914		.5316	.5959	.6584	.6335	
8	.6283		.5316	.7011	.6584	.6805	
9	.5175		.4961	.5959	.5792	.5144	
10	.543		.4961	.5258	.4801	.4409	
11	.4801	.5365	.4607	.4908	.421	.4458	
12	.4409	.4458	.5258	.4908	.4049	.1296	.5487
13	.4191	.407	.5487	.5258	.431	.1296	.5853
14	.3856	.373	.5487	.5609	.421	.3429	.5853
15	.3978	.426	.5153	.5258	.4428	.4801	.6219
16	.3887	.4641	.5121	.5959	.4096	.5487	.6219
17	.4428	.503	.567	.5959	.4024	.5201	.6024
18	.5304	.4748	.6379	.5609	.5087	.5258	.6413
19	.6584	.6516	.6584	.6661	.6447	.6584	.6733
20	.6283	.7023	.695	.6661	.695	.695	.7712
21	.5914	.6283	.6024	.631	.695	.6154	.7316
22	.5121	.6219	.5487	.5609	.6219	.5792	.6024
23	.3898	.4656	.4607	.5258	.4344	.4656	.5121
24	.3898		.3544	.3856	.394	.3582	.3429
Max	.6584	.7023	.695	.7011	.695	.695	.7712
Min	.3189	.373	.2896	.3155	.3544	.1296	.3155
Avg	.4605	.5154	.4845	.5141	.4869	.4515	.5388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 204 / HELWAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126		.3189	.4207	.3544	.3506	.3292
2	.2103		.2835	.3856	.3155	.3086	.3292
3	.2103		.2481	.3506	.3155	.3086	.3292
4	.2103		.2481	.3506	.3155	.3086	.3292
5	.2507		.2835	.4207	.3898	.3506	.3658
6	.3696		.3189	.4908	.4656	.394	.439
7	.6838		.6201	.631	.6878	.6154	.6661
8	.7316		.6733	.7888	.7964	.6379	.8779
9	.7973		.7712	.8859	.8596	.7011	.9671
10	.8063		.7682	.8682		.7362	.9145
11	.7545	.7202	.823	.8859		.7461	.7087
12	.78	.6661	.7087	.7442		.6516	.7316
13	.7127	.6935	.7316	.6859		.583	.7087
14	.6962	.5087	.7087	.6661	.7537	.503	.7316
15	.5868	.6299	.7316	.7011	.7449	.8139	.695
16	.5868	.6962	.7265		.7773	.7202	.0914
17	.5935	.7122	.8048	.7011	.7545	.8573	.1052
18	.4917	.7545	.8413	.9114	.823	.823	1.0425
19	1.0608	.9979	1.0498	1.0517	1.1403	1.134	1.134
20	.9522	1.0456	1.0631	1.0517	1.0974	1.1458	1.1218
21	.8775	.8589	1.0242	.9465	.9511	1.0349	.9922
22	.6838	.7095	.7865	.7011	.8413	.8413	.7796
23	.3841	.439	.5853	.5258	.543	.543	.5548
24	.2481		.3544	.4557	.3898	.3898	.4024
Max	1.0608	1.0456	1.0631	1.0517	1.1403	1.1458	1.134
Min	.2103	.439	.2481	.3506	.3155	.3086	.0914
Avg	.5788	.7256	.6447	.6792	.6658	.6458	.6394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 205 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218		.2126	.2103	.2587	.2772	.2126
2	.1848		.1772	.1753	.1829	.2561	.1772
3	.1478		.1772	.1753	.181	.1791	.1772
4	.1478		.1772	.1402	.1772	.181	.1829
5	.1478		.1772	.1402	.1772	.2033	.1829
6	.2054		.2126	.2103	.2126	.2195	.2126
7	.2402		.2126	.2454	.2534	.2218	.2126
8	.2614		.2835	.2629	.2561	.2561	.2481
9	.2614		.3189	.3155	.3658	.2926	.3292
10	.2614		.3544	.3681	.3982	.3326	.3544
11	.4805	.3658	.3898	.3856	.4525	.2957	.4024
12	.4572	.4066	.4075	.4207	.4706	.3696	.4024
13	.4294	.4435	.4207	.4207	.4572	.4066	.3658
14	.4481	.4066	.439	.4207	.462	.1417	.3658
15	.2957	.2957	.4024	.2804	.2957	.1029	.3189
16	.2926	.2587	.3475		.3109		.2561
17	.2534	.2587	.2658		.2534		.2481
18	.2353	.2172	.2303	.2103	.2328	.0377	.2303
19	.2353	.2218	.2195		.1907	.1772	.2126
20	.1791	.2172	.2195		.1949	.1791	.1928
21	.2172	.181	.2378		.2054	.2195	.2126
22	.2587	.2534	.2743		.2801	.2926	.2378
23	.2561	.2987	.2743		.3206	.2957	.2743
24	.2743		.2481	.2804	.2957	.2987	.2561
Max	.4805	.4435	.439	.4207	.4706	.4066	.4024
Min	.1478	.181	.1772	.1402	.1772	.0377	.1772
Avg	.2664	.2942	.2783	.2743	.2869	.2380	.2611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 206 / 11 KV Mandure Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155		.0377	.0373	.5609	.3856	.4252
2	.2774		.0377	.0373	.5258	.3814	.4024
3	.2427		.0366	.0373	.5258	.3814	.3658
4	.2427		.0354	.0373	.5258	.3814	.3544
5	.2427		.0354	.0373	.5258	.4161	.3658
6	.2804		.0377	.0373	.5609	.4161	.4024
7	.2804		.0377	.0373	.6024	.4161	.439
8	.2103		.0354	.0373	.567	.3814	.4252
9	.2103		.0377	.0373	.4908	.3506	.3544
10	.0377		.9568	1.2971	.0377	.0377	.0377
11	.0377	1.1218	1.0974	1.3717	.0377	.0377	.0377
12	.0377	1.1919	1.3672	1.1317	.0377	.0377	.0354
13	.0377	1.2971	1.3535	1.166	.0377	.0377	.0354
14	.0377	1.262	1.2403	1.0867	.0377	.0377	.0377
15	.0377	1.1919	1.2403	1.0288		.0377	.0354
16	.0377	1.2136	1.2048	.9602	.0377	.0377	.0377
17	.0377	1.0867	1.2437	.8573	.0377	.0377	.0377
18	.0377	.0377	.0377	.0373	.0377	.0377	.0377
19	.0377	.0377	.0377	.0373	.0377	.0377	.0377
20	.0377	.0377	.0377	.0373	.0377	.0377	.0354
21	.0377	.0377	.0377	.0373	.0377	.0377	.0366
22	.0377	.0377	.0377	.0373	.0377	.0377	.0377
23	.0377	.0377	.0366	.0373	.0377	.0377	.0377
24	.3544		.0377	.0373	.5609	.3856	.4252
Max	.3544	1.2971	1.3672	1.3717	.6024	.4161	.439
Min	.0377	.0377	.0354	.0373	.0377	.0377	.0354
Avg	.1327	.6609	.4291	.3957	.2581	.1843	.1866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 207 / 11 KV Helwak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.6588	.6706	.6516	.0377	.0377	.0377
2	.0377	.6344	.7087	.6516	.0377	.0377	.0377
3	.0377	.6344	.6733	.6516	.0377	.0377	.0377
4	.0377	.6516	.6379	.6173	.0377	.0377	.0377
5	.0377	.6859	.6379	.6516	.0377	.0377	.0377
6	.0377	.6935	.6379	.6859	.0377	.0377	.0377
7	.0377	.7282	.7125	.6859	.0377	.0377	.0377
8	.0377	.7628	.7461	.7545	.0377	.0377	.0354
9	.0377	.7628	.567	.6859	.0377	.0377	.0377
10	1.1789	.0377	.0377	.0373	1.2003	.9709	.9389
11	1.3176	.0377	.0354	.0373	1.2003	1.1789	1.134
12	1.3032	.0377	.0354	.0373	1.166	1.1789	1.134
13	1.3032	.0377	.0377	.0373	1.166	1.1789	1.134
14	1.1869	.0377	.0354	.0373	1.166	1.166	1.073
15	1.0852	.0377	.0354	.0373	1.166	1.0974	1.073
16	.5365	.0377	.0377		1.1022	1.1096	1.0852
17	.4641	.0377	.0377		1.0631	1.0402	.407
18	.0377	.0377	.0377		.0377	.0377	.0377
19	.0377	.0377	.0377	.0373	.0377	.0377	.0377
20	.0377	.0377	.0366	.0373	.0377	.0377	.0377
21	.0377	.0377	.0366	.0373	.0377	.0377	.0377
22	.0377	.0377	.0354	.0373	.0377	.0377	.0377
23	.0377	.0377	.0366	.0373	.0377	.0377	.0377
24	.0377	.6935	.6706	.6859	.0377	.0377	.0377
Max	1.3176	.7628	.7461	.7545	1.2003	1.1789	1.134
Min	.0377	.0377	.0354	.0373	.0377	.0377	.0354
Avg	.3741	.3097	.2990	.3396	.4097	.3968	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 208 / Patan Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439		.4024	.3109	.2557	.2976	.3658
2	.2126		.3658	.2591	.2362	.2705	.3544
3	.2126		.3658	.2591	.2324	.2705	.3658
4	.2126		.3658	.2667	.2324	.2705	.3658
5	.2439		.4344	.3467	.2789	.3517	.439
6	.3292		.5316	.4001	.4321	.439	.5853
7	.6573		.7442	.5601	.6036	.5639	.7682
8	.5898		.6733	.4934	.5068	.5275	.7682
9	.4934		.6044	.4801	.4664	.4047	.6584
10	.4405		.5487	.4668	.421	.3429	.6219
11	.3772	.631	.5853		.378	.2873	.6584
12	.3839	.4854	.567		.3429	.3094	.6584
13	.3361	.5201	.5316		.3597	.3041	.6584
14	.3715	.5201	.567		.3597	.3536	.6584
15	.3898	.4854	.567	.5959	.3822	.3372	.6379
16	.3721	.4854	.567	.5182	.3909	.3487	.6379
17	.3719	.5201	.6219	.4923	.3757	.3978	.695
18	.3081	.5609	.2378		.4161	.3909	.7316
19	.5641	.8326	.7682	.6219	.6161	.5533	.9036
20	.503	.8048	.8779	.5959	.6219	.6047	.9036
21	.4778	.6878	.8048	.5441	.4978	.4995	.7973
22	.4087	.6447	.695	.4664	.4978	.4733	.539
23	.3018	.4961	.5853	.3887	.4275	.3734	.6379
24	.3982		.4252	.3368	.2641	.3286	.4024
Max	.6573	.8326	.8779	.6219	.6219	.6047	.9036
Min	.2126	.4854	.2378	.2591	.2324	.2705	.3544
Avg	.3833	.5903	.5599	.4423	.3998	.3875	.6172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 402 / MARALI

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.5658				.679
11	.8002	.8002	.6173		.7922
12	.8002	.8002	.7202		.8002
13	.8002	.8002	.7202	.3961	.7922
14	5.6013		.7202	.8002	.7922
15	.8002		.6173	.743	.7922
16	.0566		.3086	.1143	.1698
Max	5.6013	.8002	.7202	.8002	.8002
Min	.0566	.8002	.3086	.1143	.1698
Avg	1.3464	.8002	.6173	.5134	.6883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 201 / Rasati Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0518	.1006	.1006	.0937	.0892	.0949	.0949
2	.0526	.096	.096	.0949	.0857	.0914	.0914
3	.0533	.0594	.0655	.0937	.0556	.061	.061
4	.0549	.0594	.0594	.0937	.0572	.061	.0617
5	.0857	.064	.064	.0983	.0892	.096	.0983
6	.0914	.1372	.1109	.1372	.125	.1638	.104
7	.1296	.208	.1029	.1791	.1966	.1734	.181
8	.1734	.2401	.2347	.2126	.2454	.2347	.2507
9	.1677	.2347	.16	.2401	.1734	.2561	.1715
10	.1943	.208	.2012	.2401	.1486	.1875	.1966
11	.1898	.2035	.2374	.2035	.1448	.1562	.1829
12	.1852	.1966	.1989	.2012	.1353	.1505	
13	.1829	.1898	.1658	.2321	.1391	.1505	.192
14	.1448	.1189	.1638	.1966	.1467		.1296
15	.1219	.1189	.16	.192	.1296		.141
16	.1486	.1677	.1658	.1898	.1124		.1448
17	.1429	.1357	.2058	.1875	.1257	.125	
18	.1852	.1898		.1852	.2347	.1943	.1966
19	.2534	.2401	.2865	.2481	.2481	.2743	.2804
20	.2865	.2865	.2534	.2481	.2481	.2481	.2507
21	.2507	.2835	.2507	.2561	.2172	.2126	.2149
22	.2103	.1772	.2058	.1791	.1734	.1772	.2058
23	.1715	.1734	.1715	.1417	.1341	.1402	.1638
24	.08	.1006	.1006	.128	.0914	.0949	.0983
Max	.2865	.2865	.2865	.2561	.2481	.2743	.2804
Min	.0518	.0594	.0594	.0937	.0556	.061	.061
Avg	.1504	.1662	.1635	.1780	.1478	.1592	.1596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 202 / KOYANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0533	.0983	.0983	.0594	.08	.1174	.1174
2	.0495	.0937	.0937	.0579	.0518	.0857	.0857
3	.048	.0564	.0671	.0579	.0526	.0857	.0857
4	.0472	.0846	.0564	.0869	.0533	.0857	.0892
5	.0743	.0926	.061	.096	.0549	.088	.0892
6	.088	.1341	.0995	.1311	.0857	.1189	.0983
7	.1296	.1658	.0949	.1715	.1619	.1326	.1417
8	.1696	.1989	.1806	.1753	.2103	.1989	.1753
9	.1619	.1852	.1734	.2058	.1029	.1974	.1638
10	.1174	.1753	.1341	.1696	.1334	.1715	.192
11	.1158	.1619	.1326	.1341	.1315	.1372	.1829
12	.1158	.1204	.1326	.1326	.1276	.1372	.1783
13	.0423	.1204	.1296	.1326	.1391	.1334	.1509
14	.1334	.1143	.128	.16	.1429		.1124
15	.1204	.1353	.128	.128	.1463		.1334
16	.1429	.1006	.1311	.1619	.1547		.141
17	.1578	.0972	.1619	.1524	.2012	.1467	
18	.2134	.1052	.2012	.1429	.2881	.176	.1783
19	.2804	.1943	.2743	.2683	.3052	.2683	.2347
20	.2743	.2774	.3155	.2481	.2713	.2743	.2804
21	.2454	.2743	.2804	.2481	.2622	.2401	.2743
22	.2035	.1524	.192	.2058	.2267	.1658	.2347
23	.16	.16	.1524	.1357	.1562	.1372	.1638
24	.0777	.096	.0983	.1219	.0857	.1174	.0914
Max	.2804	.2774	.3155	.2683	.3052	.2743	.2804
Min	.0423	.0564	.0564	.0579	.0518	.0857	.0857
Avg	.1342	.1414	.1465	.1493	.1511	.1531	.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254079 / Marali

Feeder No / Name : 201 / 11 kv Marali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2534	.3403	.2507	.2865	.2507	.3045
2	.2172	.2534	.2507	.2507	.2865	.2507	.3045
3	.2172	.2534	.2507	.2507	.2865	.2686	.3045
4	.2172	.2534	.3582	.2507	.2865	.2686	.2686
5	.2534	.2896	.394	.3045	.3403	.3403	.2865
6	.3439	.4163	.4835	.6626	.4477	.4119	.4298
7	.5068	.5611	.6268	.7343	.6268	.6024	.5731
8	.5611	.5611	.5373	.7701	.6268	.6556	.5731
9	.4887	.5249	.394	.7164	.4835	.5316	.4835
10	.3982	.543	.3582	.5373	.3582	.4784	.394
11	.362	.543	.3403	.4656	.4477	.4477	.3898
12	.362	.5249	.3224	.4298	.4656	.394	.2303
13	.2896	.4298	.3045	.4656	.4298	.3761	.3012
14	.2896	.394	.2865	.4119	.4119	.4477	.2303
15	.2896	.394	.2865	.4656	.4119	.3582	.2658
16	.2896	.4119	.3224	.5373	.4298	.3761	.3012
17	.3258	.4835	.394	.5373	.5014	.4119	.3189
18	.3982	.5731	.4656	.6089	.5014	.4525	.4075
19	.543	.788	.6089	.6447	.6626	.6626	.6201
20	.591	.8059	.6805	.7343	.6805	.6805	.6733
21	.591	.7164	.6268	.6089	.6447	.5731	.6024
22	.4835	.6089	.4835	.5552	.5731	.5194	.5316
23	.3439	.4835	.3582	.4119	.4119	.3406	.3898
24	.2507	.2534	.4119	.2865	.3224	.3224	.3045
Max	.591	.8059	.6805	.7701	.6805	.6805	.6733
Min	.2172	.2534	.2507	.2507	.2865	.2507	.2303
Avg	.3679	.4717	.4119	.4955	.4552	.4342	.3954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254079 / Marali

Feeder No / Name : 202 / 11 kv Morgiri AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9709	.9362	.9709			
2		.9362	.9189	.9536			
3		.9189	.9536	.9536			
4		.8669	.9362	.9536			
5		.8149	.9362	.8842			
6		.7975	.9709	.7975			
7		.8149	1.0056	.7628			
8		.8149	.9536	.8842			
9		.8495	.7802	.6935			
10	1.0576				1.1789	1.2309	1.0923
11					1.2136	1.1616	.9709
12	1.2483				1.3176	1.0923	.9015
13	1.1269				1.2656	1.0576	.9536
14	1.1963				1.2309	1.0229	.7455
15	1.1963				1.1096	1.0576	.7628
16	1.1616				1.0402	.9015	.7455
17	1.1096				.9709	.7975	.6935
23	.9709	.7802					
24		1.0229	.9536	1.0056			
Max	1.2483	1.0229	1.0056	1.0056	1.3176	1.2309	1.0923
Min	.9709	.7802	.7802	.6935	.9709	.7975	.6935
Avg	1.1334	.8716	.9345	.8860	1.1659	1.0402	.8582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254079 / Marali

Feeder No / Name : 203 / 11 kv Marali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503				.5256	.5596	.4527
2	.503				.5256	.5426	.4694
3	.4024				.5256	.5426	.4694
4	.4024				.5256	.5256	.4694
5	.4191				.5596	.5087	.4527
6	.4694				.5596	.5426	.4527
7	.4527				.5765	.5765	.57
8					.5765	.6104	.5197
9					.5256	.5087	.503
10		.9556	1.073	.9221			
11		1.1233	1.1233	1.0004			
12		1.2209	1.1568	.9665			
13		1.2039	1.1401	1.0343			
14		1.17	1.1233	.9665			
15		.9665	.9892	.8987			
16		.9156	.8551	.8478			
17		.9496	.7712	.763			
24	.57				.5426	.5765	.4527
Max	.57	1.2209	1.1568	1.0343	.5765	.6104	.57
Min	.4024	.9156	.7712	.763	.5256	.5087	.4527
Avg	.4653	1.0632	1.029	.9249	.5443	.5494	.4812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 201 / CHAFAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0686	.0686	.1029	.1029	.0857
2	.1029	.0686	.0686	.0686	.1029	.0857	.0686
3	.1029	.0686	.0686	.0857	.1029	.0857	.0857
4	.0857	.0686	.0686	.0857	.0857	.0857	.0686
5	.0857	.0857	.0686	.0857	.0857	.1029	.0857
6	.1372	.1029	.1372	.1029	.1372	.12	.12
7	.1543	.1543	.1715	.1543	.1715	.1543	.1543
8	.2229	.2058	.2058	.2058	.2058	.2058	.2229
9	.1715	.1715	.1886	.2058	.1715	.1886	.2058
10	.1543	.1886	.1886	.2058	.1886	.1886	.2058
11	.1543	.1715	.1543	.1543	.12	.1372	.2058
12	.1886	.12	.1372	.1715	.1029	.1715	.1715
13	.1543	.1715	.1372	.1715	.1372	.1372	.1715
14	.1543	.1715	.1372	.1715	.1543	.1372	.1543
15	.1372	.1715	.1372	.1715	.1543	.12	.823
16	.1372	.1543	.1543	.1543	.1543	.1372	.1715
17	.1543	.1543	.1715	.1715	.1543	.1543	.1715
18	.2058	.1715	.2058	.2058	.1543	.1886	.1886
19	.2058	.2058	.2058	.2401	.2572	.2229	.2229
20	.2401	.2229	.2229	.2229	.2401	.2401	.2401
21	.1715	.1886	.1886	.1886	.2229	.2229	.1886
22	.1543	.1715	.1543	.1543	.1715	.1715	.1543
23	.12	.12	.12	.12	.1372	.1372	.12
24	.1029	.0857	.0857	.1029	.1029	.1029	.1029
Max	.2401	.2229	.2229	.2401	.2572	.2401	.823
Min	.0857	.0686	.0686	.0686	.0857	.0857	.0686
Avg	.1500	.1450	.1436	.1529	.1508	.1500	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 202 / MASUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6173	.6173	.6173	.7373	.6859	.6516
2	.583	.5487	.6001	.6173	.7202	.6516	.6173
3	.583	.5487	.6001	.583	.7202	.6173	.6001
4	.6001	.5487	.6344	.5144	.6859	.6173	.583
5	.6173	.6173	.703	.5658	.6859	.6859	.6516
6	.7545	.7545	.8573	.7716	.8916	.8916	.7545
7	1.1317	1.0974	1.0631	1.0288	1.1317	1.0631	1.0974
8	1.166	1.1317	1.1317	1.166	1.166	1.1145	1.0631
9	.9945	1.0288	1.0288	1.0288	.9945	1.0631	1.0288
10	1.0974	1.0974	1.0974	1.0288	1.0288	.9602	.9945
11	.9259	.8573	.8573	.9259	.9431	.9259	.8916
12	.9088	.7716	.8573	.823	.7716	.823	.9602
13	.7545	.7716	.7888	.8573	.7545	.7888	.8916
14	.7202	.7716	.7888	.8573	.823	.7888	.8573
15	.823	.7545	.7888	.7888	.823	.823	.823
16	.8573	.8402	.7888	.8573	.8573	.8573	.8573
17	.823	.9259	.8573	.9088	.9431	.8573	.8916
18	.9945	.9431	.9259	1.0631	.8916	1.0288	.9602
19	1.1831	1.286	.9431	1.3032	1.3032	1.166	1.2689
20	1.2346	1.3032	1.0288	1.2689	1.3032	1.2003	1.2689
21	1.1317	1.166	1.0288	1.166	1.2346	1.0288	1.166
22	1.0288	1.046	1.0288	1.0631	1.0974	1.0288	1.0974
23	.823	.823	.8402	.9259	.9259	1.0288	.9259
24	.6173	.6516	.6687	.6859	.7545	.7545	.6859
Max	1.2346	1.3032	1.1317	1.3032	1.3032	1.2003	1.2689
Min	.583	.5487	.6001	.5144	.6859	.6173	.583
Avg	.8731	.8709	.8552	.8923	.9245	.8938	.8995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 203 / PAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.5775	1.4575	1.3375	1.3032	1.3717	1.2346
2	1.3032	1.5432	1.4575	1.3032	1.3032	1.3375	1.2517
3	1.3032	1.5089	1.4403	1.2346	1.3032	1.3032	1.2517
4	1.2689	1.5089	1.4403	1.2003	1.286	1.3032	1.2689
5	1.2689	1.5775	1.4403	1.2517	1.286	1.3375	1.2689
6	1.3032	1.6461	1.4746	1.3203	1.406	1.406	1.3032
7	1.4746	1.749	1.6461	1.5089	1.5432	1.6804	1.5775
8	.0343	1.6804	1.6289	.7716	1.5775	.2401	1.6118
9	.0343	1.5775	1.5432	.7545	1.5089	1.2689	1.5775
10	2.452	2.5377	2.1434	2.1262	2.1948	2.4691	2.4006
11	2.5034	2.6749	2.2977	2.6063	2.2634	2.6406	2.6406
12	2.5377	2.5377	2.6063	2.4691	2.332	2.572	2.5034
13	2.5377	2.7435	2.4348	2.4348	2.4006	2.572	2.6063
14	2.4863	2.6063	2.4006	2.3663	2.572	2.5034	2.4348
15	2.3491	2.5377	2.3663	2.2291	2.4006	2.4348	2.3663
16	2.2977	2.4006	2.2291	2.1262	2.1948	2.332	2.1948
17	2.0576	2.0062	2.1605	2.0233	2.1948	2.2291	2.0233
18	.12	.12	.0343	.0686	.1372	.1372	.1543
19	.1372	.1372	.1029	.12	.1715	.1543	.1372
20	.1372	.12	.1029	.1372	.1543	.12	.1372
21	.12	.1029	.12	.1029	.1543	.1372	.1372
22	.0686	.0343	.0857	.0343	.0857	.0686	.0857
23	.0343	.0343	.1029	.0343	.0686	.0686	.0686
24	1.3717	1.6118	1.4746	1.3203	1.3375	1.406	1.2346
Max	2.5377	2.7435	2.6063	2.6063	2.572	2.6406	2.6406
Min	.0343	.0343	.0343	.0343	.0686	.0686	.0686
Avg	1.2717	1.5239	1.4246	1.2867	1.3825	1.3789	1.3946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 204 / PERLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2572	.2058	.2572	.3086	.2743
2	.2058	.1715	.2572	.2058	.2401	.2743	.2058
3	.2058	.1715	.2401	.2058	.2401	.2743	.2229
4	.2058	.1715	.2401	.1886	.2401	.2743	.2572
5	.2743	.2401	.3086	.2743	.3086	.3086	.2743
6	.4458	.4458	.4801	.4287	.4458	.4287	.4801
7	.583	.6516	.6173	.6173	.583	.5144	.6173
8	.583	.6859	.6859	.6173	.5487	.583	.6173
9	.4801	.5487	.4973	.4801	.4458	.4458	.4287
10	.463	.4115	.3944	.3772	.3772	.4458	.4115
11	.3944	.3429	.3429	.4458	.3772	.3772	.3772
12	.3772	.4115	.3429	.3429	.2743	.3429	.4115
13	.4115	.3772	.3429	.3086	.3429	.3429	.3429
14	.3429	.3772	.3429	.3086	.3429	.3086	.2743
15	.3429	.3429	.3429	.3772	.3429	.3429	.2743
16	.3429	.3429	.3429	.3772	.3429	.3086	.3429
17	.3429	.4287	.4115	.4115	.3429	.3429	.4115
18	.4115	.3772	.4458	.4458	.3429	.3772	.4458
19	.5658	.6001	.5144	.583	.6173	.5487	.583
20	.6173	.6173	.6173	.6173	.6516	.6173	.6173
21	.5144	.5487	.5487	.5144	.6001	.5487	.5487
22	.4115	.4801	.4115	.4801	.5487	.4801	.4801
23	.3086	.3429	.3601	.3429	.4115	.3772	.3429
24	.2401	.2572	.2743	.3429	.2743	.3086	.2743
Max	.6173	.6859	.6859	.6173	.6516	.6173	.6173
Min	.2058	.1715	.2401	.1886	.2401	.2743	.2058
Avg	.3872	.3979	.4008	.3958	.3958	.3951	.3965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 205 / VARADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	1.2003	1.1317	.8916	.1029	.0857	.0857
2	.1029	1.166	1.1145	.9602	.1029	.0686	.0857
3	.1029	1.1317	1.0974	.8916	.1029	.0343	.0686
4	.0857	1.1317	1.0974	.8573	.1029	.0343	.0857
5	.1029	1.2003	1.0974	.9088		.0343	.0686
6	.1029	1.2346	1.1831	1.0288	.1029	.0343	.0857
7	.1029	1.3375	1.3032	1.166	.1543	.0857	.1029
8	.12	1.406	1.3375	1.166	.12	.12	.1029
9	.12	1.3032	1.2689	1.166	.12	.1372	.12
10	1.8176	.1372	.1029	.1372	1.8861	1.6632	1.6804
11	1.9376	.1715	.1372	.1715	1.9204	1.8519	1.8519
12	1.9204	.1715	.1543	.1715	1.8519	1.8861	1.8176
13	1.8861	.1715	.1372	.1886	1.7833	1.5089	1.989
14	1.869	.1543	.1372	.1715	1.8519	1.4746	1.8176
15	1.8176	.1543	.1372	.12	1.7833	1.4403	1.8004
16	1.7147	.1543	.12	.1543	1.7833	1.6289	1.6975
17	1.6461	.1886	.1715	.1543	1.6461	1.4746	1.6461
18	.1029	.1715	.1543	.1715	.1715	.1543	.1372
19	.0857	.1715	.1372	.1543	.1715	.1372	.1372
20	.1029	.1715	.12	.1715	.12	.1029	.12
21	.1029	.1372	.12	.1372	.1029	.1029	.12
22	.1029	.12	.1029	.1372	.12	.1029	.12
23	.0686	.12	.12	.1372	.1029	.1029	.12
24	.1029	1.2346	1.1145	.9774	.1029	.0857	.0857
Max	1.9376	1.406	1.3375	1.166	1.9204	1.8861	1.989
Min	.0686	.12	.1029	.12	.1029	.0343	.0686
Avg	.6759	.6059	.5666	.5080	.7090	.5980	.6644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 206 / CHAFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.0857	.0686	.0857	.6859	.9259	.8916
2	.823	.0686	.0686	.0686	.6516	.8573	.8745
3	.8059	.0686	.0686	.0686	.6516	.823	.8573
4	.7716	.0686	.0857	.0686	.6344	.8573	.8402
5	.7545	.0857	.12	.0857	.6344	.9259	.823
6	.7888	.1029	.1029	.1029	.7716	.9602	1.166
7	.9945	.1029	.12	.1029	1.0288	1.166	1.166
8	.1543	.1372	.1372	.12	1.0288	1.1317	1.1831
9	.1543	.1372	.0857	.0857	.8573	.9945	1.0288
10	.1372	1.749	1.6975	1.5089	.0686	.1029	.0857
11	.1029	1.9204	1.8861	1.8176	.0857	.12	.0857
12	.1029	1.9204	1.8176	1.749	.0686	.12	.12
13	.0857	1.8519	1.6461	1.5775	.0857	.12	.1029
14	.0857	1.749	1.5432	1.5432	.1372	.12	.1029
15	.1029	1.6461	1.406	1.4403	.1029		.1372
16	.1029	1.5775	1.286	1.3032	.12		.1372
17	.12	1.4403	1.2003	1.2003	.1372		.1715
18	.1372	.1543	.12	.12	.12	.1372	.12
19	.1372	.1372	.1029	.1372	.1372	.12	.1372
20	.1715	.12	.1029	.1029	.12	.12	.1029
21	.1372	.12	.1029	.12	.1029	.1029	.1029
22	.1029	.1372	.1029	.1029	.1029	.1029	.1029
23	.1029	.1029	.0857	.0857	.0857	.0686	.0857
24	.9259	.0857	.0857	.1029	.7202	.9602	.9602
Max	.9945	1.9204	1.8861	1.8176	1.0288	1.166	1.1831
Min	.0857	.0686	.0686	.0686	.0686	.0686	.0857
Avg	.3608	.6487	.5851	.5708	.3808	.5160	.4744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 401 / UMESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1543			
2	.1029	.1029	.1543		.5144	.9774
3	1.0288	.4115	.1543		.5144	.9774
4	1.0288	1.4403	1.0288	1.4918	1.5432	1.0288
5	1.5432	1.749	2.2119	1.6975	2.0062	1.286
6	1.9033	1.8519	2.3148	2.0062	2.0576	1.286
7	1.9033	1.9547	2.3663	2.2119	2.2119	1.4403
8	1.9033	1.9547	2.3663	2.2634	2.1605	1.4918
9	1.8519	1.9033	2.3148	2.2119	2.1605	1.4918
10		2.3663	2.2634	2.2634	2.2119	2.2119
11	2.3148	2.2634	2.2634	2.3663	2.2634	2.3148
12	2.3663	2.3148	2.2119	2.2634	2.2634	2.3148
13	2.3148	2.3148	2.2119	2.2634	2.2119	2.2634
14	2.3148	2.2634	2.2119	2.2119	2.2119	2.2634
15	2.3148	2.2634	2.2119	2.2119	2.1605	2.2634
16	.1543	.3601	.2058	.1029	.2058	.1543
24				.1029		
Max	2.3663	2.3663	2.3663	2.3663	2.2634	2.3148
Min	.1029	.1029	.1543	.1029	.2058	.1543
Avg	1.5432	1.6011	1.6654	1.8335	1.7798	1.5844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 201 / shamgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1797	.0179	.016	.0173	1.6766	1.6385	1.5384
2	1.1305	.0179	.016	.0171	1.6575	1.6194	1.448
3	1.1174	.0177	.0162	.0179	1.6194	1.5432	1.4661
4	1.1174	.0177	.0162	.0181	1.6194	1.6575	1.5746
5	1.1174	.0177	.0162	.0175	1.6549	1.6712	1.5729
6	1.1174		.0168	.0179	1.7269	1.6842	1.5524
7	1.1683	.0166	.0175	.0185	1.8778	1.713	1.6804
8	.0187	.0152	.0187	.0177	1.8842	1.9006	1.7328
9	.0185	.017	.0181	.0185	1.9839	1.9006	1.6575
10	.0187	1.933	2.2119	2.3137	.0175	.017	
11	.0189		2.3739	2.2801	.0158	.017	.017
12	.0185	2.5434	2.7496	2.431	.017	.0173	.0168
13	.0183	2.1534	2.652	2.34	.0179	.0173	.0166
14	.0183	2.2043	2.6621	2.3472	.0179	.0173	.0154
15	.0181	2.079	2.5484	2.2043	.017	.0173	.0177
16	.0179	2.1795	2.4478	2.1125	.017		.0175
17	.0173	2.0119	2.4691	2.0119	.0175	.0171	.017
18	.0171	.0164	.0168	.0175	.0158	.0152	.0549
19	.0177	.0177	.0181	.0181	.016	.0168	.0177
20	.0183	.0173	.0162	.0183	.0162	.017	.0164
21	.0183	.0156	.0175	.0183	.0171	.0164	.0156
22	.0181	.016	.0177	.0183	.0171	.0162	.0156
23	.0183	.0152	.0175	.017	.017	.0158	.0152
24	1.2452	.0179	.0158	.0173	1.7772	1.6907	1.4998
Max	1.2452	2.5434	2.7496	2.431	1.9839	1.9006	1.7328
Min	.0171	.0152	.0158	.017	.0158	.0152	.0152
Avg	.3952	.6981	.8494	.7636	.7381	.7494	.6946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 202 / Helgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	1.5623	1.5384	1.5223	.0693	.0594	.0617
2	.0663	1.6446	1.5384	1.5223	.0724	.0617	.061
3	.0671	1.6644	1.5384	1.5402	.0716	.061	.0648
4	.0671	1.6644	1.5061	1.5912	.0732	.0648	.061
5	.0678	1.6842	1.5061	1.7436	.0686	.0617	.0617
6	.0678	1.704	1.5061	1.7901	.0716	.061	.0625
7	.0633	2.0454	1.917	2.0885	.0716	.0594	.0617
8	.0633	1.9006	1.9725	2.1963	.0625	.0602	.061
9	.061	1.8313	1.873	1.873	.0617	.0549	.0693
10	2.0748	.0671	.0572	.0655	1.8991	1.9006	
11	2.3663	.0533	.0709	.0655	2.2043	2.1365	1.9281
12	2.1026	.0693	.0678	.0693	2.323	2.1051	2.1956
13	2.0687	.0709	.0678	.0686	2.2382	2.0517	2.2043
14	2.2969	.0716	.0693	.0678	2.3739	2.0348	2.9334
15	2.34	.0693	.0686	.0663	2.2298	2.2177	2.9843
16	2.1704	.0686	.0709	.0678	2.2043		2.6993
17	1.8515	.0709	.0732	.0732	2.0119	1.8299	2.431
18	.0488	.0648	.0663	.0678	.0594	.0617	.0549
19	.0678	.0617	.0663	.0693	.0617	.0625	.0587
20	.0678	.0579	.0648	.0693	.0655	.0648	.0564
21	.0678	.0503	.064	.0678	.0686	.0617	.0533
22	.0663	.0572	.0671	.0693	.0693	.064	.0602
23	.0648	.0541	.0678	.0678	.064	.0625	.0572
24	.0663	1.3889	1.587	1.5546	.0716	.0602	.0602
Max	2.3663	2.0454	1.9725	2.1963	2.3739	2.2177	2.9843
Min	.0488	.0503	.0572	.0655	.0594	.0549	.0533
Avg	.7630	.7490	.7260	.7657	.7736	.6634	.7975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 203 / KONEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	.0173	.0351	.0343	1.4632	1.358	1.3889
2	1.1591	.0173	.0351	.0362	1.4815	1.3413	1.3108
3	1.1443	.0175	.0351	.0358	1.5546	1.4251	1.3108
4	1.1443	.0175	.0354	.0347	1.5912	1.3413	1.3927
5	1.1294	.0177	.0354	.0343	1.4937	1.4403	1.3426
6	1.1294	.0177	.0532	.0526	1.5971	1.5912	1.3565
7		.0181	.0716	.0686	1.7394	1.6194	1.5306
8	.0537	.0351	.0686	.0474	1.6644	1.7284	1.6707
9	.061	.0347	.0509	.052	1.8275	1.6766	1.7974
10	.0343	2.4166	2.6791	2.4291	.0532	.1227	.0905
11	.0509	2.4006	2.7496	2.5101	.0857	.1254	.0895
12	.0492		2.649	2.6113	.104	.1254	.0819
13	.052	2.5652	2.4806	2.5911			.0867
14	.0514	2.5819	2.2996	2.4326	.104		.0876
15	.0343	2.4646	2.3685	2.3365	.0857		.0876
16	.0282	2.4486	2.4291	2.2771	.0177		.064
17	.0347	2.3482	2.2771	2.0241	.0857	.1075	.0486
18	.0732	.0509	.0693	.0701	.0876	.1063	
19	.0183	.0532	.0332	.0724	.0914	.0876	.0895
20	.0554	.0716	.0354	.0724	.0914	.0895	.0701
21	.0366	.0532	.0537	.0526	.0905	.0895	.0709
22	.0354	.0526	.0351	.0732	.0339	.052	.0532
23	.0347	.0347	.0351	.0724	.0339	.0514	.0532
24	1.2186	.0171	.0351	.0343	1.5623	1.3546	1.3496
Max	1.2186	2.5819	2.7496	2.6113	1.8275	1.7284	1.7974
Min	.0183	.0171	.0332	.0343	.0177	.0514	.0486
Avg	.3834	.7718	.8604	.8356	.7365	.7917	.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 204 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0141	.0137	.0141			
2		.0141	.0133	.0137			
3		.0141	.0133	.0145			
4		.0141	.0124				
5		.0141	.0124	.0149			
6		.0141	.0128	.0145			
7		.0126	.0131	.0124			
8		.013	.0126	.0135			
9		.0111	.0147	.0133			
10	.0135				.0143	.0139	.0135
11	.0135				.0139		.0135
12	.0135				.0135		.0137
13	.0133				.0135		.0133
14	.0133				.0133		.0137
15	.0137				.0122		.0135
16	.0133				.013		.0131
17	.013				.0122	.0143	.0128
24		.0141	.0143	.0145			
Max	.0137	.0141	.0147	.0149	.0143	.0143	.0137
Min	.013	.0111	.0124	.0124	.0122	.0139	.0128
Avg	.0134	.0135	.0133	.0139	.0132	.0141	.0134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 205 / MASUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2587	.3048	.3258	.3395	.3429	.3429
2	.2561	.2641	.3048	.3292	.3395	.3395	.3429
3	.2561	.2641	.3048	.3189	.3395	.3395	.3395
4	.2587	.2667	.3048	.3086	.3395	.3395	.3395
5	.3052	.3429	.3429	.3467	.381	.3395	.415
6	.415	.4191	.4572	.4835	.4763	.4191	.5093
7	.6036	.5658	.6036	.6154	.6413	.6097	.6413
8	.5601	.5975	.5975	.6154	.5914	.5228	.6653
9	.4854	.5175	.5544	.5544	.5601	.4805	.5853
10	.4435	.4481	.5175	.4805	.4755	.439	.4706
11	.5228	.4908	.4706	.4344	.4854	.4435	.5121
12	.3982	.5014	.4656	.4435	.4706	.4298	.4706
13	.4435	.4805	.4706	.4805	.4435	.3982	.439
14	.3982	.4344	.4481	.4854	.4066	.3982	.4755
15	.4706	.362	.4435	.439	.4854		.4805
16	.5487	.4108	.4481	.4435	.4805		.439
17	.4961	.4344	.5041	.4755	.5068	.4908	.4656
18	.5609	.5258	.5487	.543	.567	.5316	.567
19	.7133	.5601	.7421	.6722	.7023	.7316	.7392
20	.6584	.6722	.6241	.7095	.7468	.7095	.7468
21	.5914	.6036		.679	.6413	.6722	.6722
22	.5487	.5658	.5731	.6036	.6413	.6036	.6413
23	.4344	.407	.4656	.5335	.5335	.5281	.5335
24	.3258	.3086	.3429	.3467	.3772	.3772	.3772
Max	.7133	.6722	.7421	.7095	.7468	.7316	.7468
Min	.2534	.2587	.3048	.3086	.3395	.3395	.3395
Avg	.4562	.4459	.4713	.4862	.4988	.4767	.5088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 206 / Kalgaon Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.181	.1829	.1829	.1715	.2172	.2149
2	.1417	.181	.1829	.1791	.181	.208	.2195
3	.1433	.1829	.1867	.181	.1829	.1943	.2172
4	.1433	.1848	.1867	.1867	.1848	.208	.2149
5	.2149	.2587	.2241	.2481	.2241	.2534	.2561
6	.2865	.2957	.2987	.2957	.3018	.3224	.2896
7	.4115	.3982	.3982	.4207	.3982	.4024	.4207
8	.4207	.373	.3814	.4024	.4359	.4207	.4748
9	.3086	.3277	.3814	.3688	.373	.426	.3201
10	.2683	.2652	.2683		.253	.2683	.3277
11	.2972	.2622	.3052	.2622	.253		.2317
12	.2713	.2606	.2591	.2683	.2846		.2949
13	.2949	.3018	.2622	.2591	.2622		.2591
14	.2591	.2622	.2591	.3086	.2591		.2622
15	.3052	.2214	.2622	.2949	.253		.2881
16	.2561	.25	.2683	.2949	.2622		.1943
17		.2347	.2469	.2241	.3086	.3429	.253
18	.2984	.2683	.2683	.2743	.2949	.4108	.3277
19	.3429	.4961	.5014	.4656	.5014	.5792	.5373
20	.5068	.5068	.5068	.5544	.5228	.5487	.5853
21	.4435	.5228	.4755	.4854	.439	.5175	.4854
22	.3658	.3734	.4066	.3696	.3734	.4481	.4108
23	.2534	.2987	.2957	.2987	.3326	.3326	.3361
24	.1949	.2149	.2195	.208	.2218	.2507	.2454
Max	.5068	.5228	.5068	.5544	.5228	.5792	.5853
Min	.1417	.181	.1829	.1791	.1715	.1943	.1943
Avg	.2857	.2968	.3012	.3058	.3031	.3528	.3195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 207 / Satyam Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0091	.0093			
2			.0091				
3			.0091				
4			.0095				
5			.0095				
6			.0189				
14							.5544
15							.5544
16							.5544
17							.3403
18							.1595
19	.0191	.0189	.0191	.0095	.0191		.1848
20	.0175	.0091	.0177	.0189	.0187	.5304	.3647
21	.0183	.009	.0095				.1475
22	.0181	.0091	.0101				
23	.0187	.017	.0189				
24		.0181	.0091	.0181			
Max	.0191	.0189	.0191	.0189	.0191	.5304	.5544
Min	.0175	.009	.0091	.0093	.0187	.5304	.1475
Avg	.0183	.0135	.0125	.0140	.0189	.5304	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 208 / kharade ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0602	1.5546	1.7695	1.6095	.0686	.0549	.0914
2	.0594	1.6358	1.7901	1.5729	.0693	.0533	.0926
3	.0594	1.656	1.7901	1.5729	.0701	.0579	.0937
4	.0587	1.6762	1.7695	1.5546	.0716	.0564	.0914
5	.0587	1.6964	1.7695	1.6244	.0724	.0533	.0926
6	.0579	1.7166	1.7695		.0701	.0572	.0914
7	.0526	1.8785	1.8023	1.5278	.0678	.0743	.0934
8	.0625	1.8884	1.7166	1.656	.0754		.0709
9	.0602	1.7711	1.7295	1.6129	.1097	.0789	.0686
10	1.6446	.0564	.0465		2.6825	3.155	3.12
11		.0766	.0572	.0518	2.6825	.2883	2.1795
12	2.6452	.0526	.0549		2.8502	3.1878	2.4926
13	2.8826	.064	.0724	.0457	3.086		2.2801
14	2.6825	.0381	.0472	.0572	2.9473		3.1539
15	2.7469	.0217	.0472	.0846	3.0521		2.8826
16	2.649	.0427	.0244	.0549	3.0521		2.9843
17	2.42	.0556	.0349	.0518	2.8502	3.1207	2.7496
18	.0686	.0655	.0406	.0305	.0834	.0903	.0541
19	.0886	.0579	.0753	.0282	.0869	.0914	.0625
20	.0834	.0541	.0714	.0663	.088	.088	.0587
21	.0789	.0564	.064	.0655	.0857	.0834	.0617
22	.0676	.0594	.0633	.0671	.0926	.0549	.0625
23	.0695	.0602	.1006	.0663	.0926	.0564	.0655
24	.0602	1.5051	1.8233	1.6575	.0678	.0541	.0754
Max	2.8826	1.8884	1.8233	1.6575	3.086	3.1878	3.1539
Min	.0526	.0217	.0244	.0282	.0678	.0533	.0541
Avg	.8138	.7392	.7721	.7171	1.0198	.5661	.9612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 201 / BAMBAWADE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1753	.1753	.1928	.2058	.2279	.1753
2	.1543	.1753	.1753	.1753	.1715	.2279	.1753
3	.1543	.1753	.1753	.1753	.1715	.2279	.1753
4	.1543	.1753	.1753	.1753	.1715	.2279	.1753
5	.1715	.1753	.1753	.1753	.1886	.2279	.1753
6	.2743	.2454	.2629	.298	.3086	.2804	.333
7	.4287	.4207	.4207	.4557	.463	.4207	.4557
8	.5487	.5258	.4908	.5609	.5415	.5609	.4908
9	.3944	.4382	.4557	.4908	.5144	.5258	.4908
10	.3155	.4207	.3944	.4382	.4382	.4733	.3772
11	.3856	.3681	.3772	.3856	.4207	.4207	.4115
12	.4207	.3856	.3561	.4733	.4557	.4207	.4973
13	.4207	.3506	.3258	.4207	.3681	.4382	.1886
14	.3856	.333	.2543	.3681	.3155	.4031	.1715
15	.4382	.3506	.2229	.3155	.333	.4031	.2401
16	.4382	.333	.3601	.2103	.4733	.4382	.2401
17	.4382	.3506	.333	.1029	.4733	.4557	.2572
18	.4557	.4557	.3506	.4801	.5258	.4908	.4458
19	.6485	.5083	.5258	.7716	.5784	.7011	.6001
20	.631	.5784	.6135	.7545	.6836	.6485	.7202
21	.6485	.5258	.5434	.6344	.6661	.631	.6344
22	.5434	.4031	.4207	.5487	.4908	.5258	.4801
23	.333	.2629	.2804	.3772	.3506	.3155	.3258
24	.1715	.2454	.1928	.2103	.2572	.2279	.2103
Max	.6485	.5784	.6135	.7716	.6836	.7011	.7202
Min	.1543	.1753	.1753	.1029	.1715	.2279	.1715
Avg	.3795	.3491	.3357	.3830	.3986	.4134	.3520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 202 / TARALE -VG-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1227	.1402	.1578	.1417	.1402	.1578
2	.1417	.1227	.1402	.1578	.1417	.1402	.1578
3	.1417	.1227	.1402	.1578	.1417	.1402	.1578
4	.1417	.1227	.1402	.1578	.1417	.1402	.1578
5	.1417	.1402	.1402	.1578	.1417	.1402	.1578
6	.2126	.2279	.1402	.1753	.1772	.1753	.1753
7	.3544	.298	.3506		.3544	.3506	.3506
8	.3982	.333	.3856	.3856	.3544	.3856	.3856
9	.3189	.2804	.3155	.3506	.3189	.3155	.3155
10	.3155	.3155	.3189	.2454	.3155	.2454	.2835
11	.2804	.2804	.2835	.2454	.3155	.1753	.2835
12	.3155	.2103	.2126	.2629	.2804	.1753	.2835
13	.2804	.1753	.2652	.2629	.2103	.1753	.2481
14	.1753	.1753	.2743	.2279	.2103	.1753	.2126
15	.1753	.2103	.2835	.2279	.2103	.1753	.2835
16	.1753	.2103	.2481	.2454	.2804	.1753	.2652
17	.2804	.2454	.3155	.2835	.2804	.2454	.2652
18	.3155	.3506	.3155	.3544	.3155	.2804	.2652
19	.3155	.3506	.3856	.3856	.3856	.3856	.3506
20	.3506	.3856	.3856	.3856	.3856	.3856	.3982
21	.3155	.3856	.3856	.3856	.3506	.3681	.362
22	.2454	.3155	.3155	.3224	.3155	.3155	.2984
23	.1753	.1753	.2454	.1772	.1753	.2103	.2172
24	.1772	.1402	.1753	.1753	.1417	.1402	.1753
Max	.3982	.3856	.3856	.3856	.3856	.3856	.3982
Min	.1417	.1227	.1402	.1578	.1417	.1402	.1578
Avg	.2452	.2374	.2626	.2560	.2536	.2315	.2587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 203 / DUSALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0701	.0701	.0701	.0724	.0701	.0701
2	.0724	.0701	.0701	.0701	.0724	.0701	.0701
3	.0724	.0701	.0701	.0701	.0724	.0701	.0701
4	.0724	.0701	.0701	.0701	.0724	.0701	.0701
5	.0724	.0701	.0701	.0701	.0724	.0701	.0701
6	.0724	.0701	.0701	.0701	.0724	.0701	.1052
7	.1086	.1052	.1052	.1052	.1086	.1052	.1227
8	.1097	.1227	.1052	.1227	.1086	.1052	.1402
9	.1086	.1052	.1052	.1402	.1086	.1052	.1227
10	.1052	.1227	.1086	.1227	.1052	.0701	.1086
11	.1052	.1052	.1086	.1052	.1052	.0701	.1086
12	.1052	.1052	.1086	.1052	.1052	.1052	.0724
13	.0701	.0876	.1086	.0876	.1052	.0701	.1086
14	.0701	.0701	.1086	.0876	.0701	.0701	
15	.0701	.0701	.0724	.0701	.0701	.0701	.0724
16	.0701	.0701	.0724	.0701	.0876	.0701	.0724
17	.0701	.0701	.0876	.0724	.0701	.0701	.0724
18	.0876	.0701	.1052	.1086	.0701	.1052	.0724
19	.1052	.1052	.1402	.1417	.1052	.1402	.1086
20	.1402	.1402	.1402	.1417	.1402	.1402	.1463
21	.1402	.1402	.1402	.1448	.1402	.1402	.1463
22	.1052	.1402	.1227	.1086	.1052	.1227	.1463
23	.0876	.0701	.1052	.0724	.1052	.1052	.0724
24	.0724	.0701	.0701	.0876	.0724	.0701	.0876
Max	.1402	.1402	.1402	.1448	.1402	.1402	.1463
Min	.0701	.0701	.0701	.0701	.0701	.0701	.0701
Avg	.0902	.0913	.0973	.0965	.0924	.0898	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 204 / BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3923	1.2955	1.2631			
2		1.3923	1.4022	1.247			
3		1.3923	1.2955	1.247			
4		1.3923	1.4022	1.2631			
5		1.4089	1.2955	1.2631			
6		1.5746	1.2955	1.2631			
7		1.7072	1.5061	1.4575			
8		1.6575	1.4575	1.4899			
9		1.4089	1.4899	1.3603			
10	2.3805				2.0405	1.8461	1.9334
11	2.3644				2.3158	.0648	2.0891
12	2.4129				2.332	2.0567	
13	2.2672				2.2996	2.1735	2.0481
14	2.0729				2.3158	2.1559	1.9595
15	2.1376				2.2348	2.1559	1.9919
16	2.0081				2.1052	2.0081	1.8842
17	1.989	.1402			1.9433	1.7814	1.7204
24		1.4089	1.3117	1.2631			
Max	2.4129	1.7072	1.5061	1.4899	2.332	2.1735	2.0891
Min	1.989	.1402	1.2955	1.247	1.9433	.0648	1.7204
Avg	2.2041	1.3523	1.3752	1.3117	2.1984	1.7803	1.9467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 205 / TARALE -AG-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5893				1.6712	1.3927	1.247
2	1.5565				1.6549	1.3279	
3	1.5402				1.6221	1.3279	1.247
4	1.5402				1.5893	1.3279	1.2631
5	1.5238				1.5729	1.3279	1.2631
6	1.5238				1.5565	1.3279	1.2793
7	1.6712				1.6194	1.5223	1.4899
8					1.6194	1.6194	1.5223
9					1.6057	1.6194	1.5061
10		2.3644	2.2834	2.2874			
11		2.5911	2.3644	2.3205			
12		2.3158	2.2996	2.3537			
13		2.2834	2.3644	2.42			
14		2.4939	2.4291	2.4697			
15		1.2308	2.2672	2.4034			
16		2.3967	2.2024	2.3537			
17		2.2672	2.1862	2.1214			
24	1.6221				1.704	1.3927	1.2631
Max	1.6712	2.5911	2.4291	2.4697	1.704	1.6194	1.5223
Min	1.5238	1.2308	2.1862	2.1214	1.5565	1.3279	1.247
Avg	1.5709	2.2429	2.2996	2.3412	1.6215	1.4186	1.3423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 201 / 11kv CHORE VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5544	.5316	.5544	.5228	.4801	.4854
2	.5228	.5359	.4908	.5175	.5228	.4801	.4854
3	.4801	.5175	.4607	.5175	.3734	.4801	.5228
4	.5601	.5175	.4508	.5914	.5601	.5144	.5228
5	.6722	.5175	.5144	.6838	.5975	.5487	.5601
6	.8402	.5359	.6241	.7207	.7095	.583	.5975
7	.9145	.9055	.9214	.3696	.7842	.7545	.7095
8	.9709	.9795	.8764	.7207	1.0082	.7545	.8215
9	.9335	1.0164	.8322	.6283	.9709	.6859	.8215
10	.7468	1.1273	.815	.8871	.8215	.6722	.7468
11	.6516	1.0164	1.0719	.9877	.7545	.6722	.8505
12	.6859	.9816	.8871	.9335	.7716	.5975	.788
13	.7202	.8063	.8871	.7842	.7716	.5601	.631
14	.6859	.7442	.7023	.8215	.7545	.4854	.8505
15	.7202	.815	.9795	.7468	.7202	.4854	.788
16	.6468	.7522	.8686	.7095	.7202	.5975	.8238
17	.7023	.8859	.7577	.9335	.8916	.5975	.8596
18	.7762	.7442	.9795	1.0082	.9259	.7468	.9922
19	.9795	1.0631	1.1643	1.1576	.8916	.8589	1.1462
20	.9795	1.0166	1.0534	1.0082	.9602	1.0829	1.0631
21	.8131	.9922	.9055	.8962	.8573	.8215	.9214
22	.8501	.9114	.9425	.8962	.8059	.7842	.9568
23	.6468	.6661	.7207	.7095	.6173	.5601	.7796
24	.5228	.6838	.815	.6099	.5228	.5144	.5228
Max	.9795	1.1273	1.1643	1.1576	1.0082	1.0829	1.1462
Min	.4801	.5175	.4508	.3696	.3734	.4801	.4854
Avg	.7310	.8036	.8022	.7664	.7432	.6382	.7603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 202 / 11kv VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	.0328	.0328	.0328	2.1795	1.9547	1.8442
2	1.8107	.0328	.0332	.0328	2.0729	2.0576	1.8442
3	1.8107	.0328	.0335	.0328	2.146	2.0576	1.8778
4	1.8442	.0328	.0328	.0328	2.1795	2.0576	1.9113
5	1.8351	.0328	.0328	.0328	2.2634	2.2291	1.9113
6	1.9113	.0328	.0332	.0328	2.2801	2.2977	1.9113
7	1.9006	.0328	.0328	.0328	2.3137	2.332	2.2131
8	.0686	.0328	.0343	.0328	2.3807	2.4006	2.2801
9	.0686	.0328	.0663	.0328	2.2131	2.2291	2.332
10	.0686	2.9001	2.8807	2.9165	.0686	.0686	.0457
11	.0686	3.1131	3.1878	3.5208	3.3436	.0686	.0347
12	.0686	3.0045	3.0312	3.5879	3.4294	.0686	.0343
13	.0686	3.1687		3.6214	3.4294	.0686	.0343
14	.0686	2.9729	.8356	3.1855	3.3436	.0686	.0678
15	.0686	3.1047	.852	3.2236	3.2922	.0686	.0686
16	.0164	2.8807	1.704	3.1184	3.2579	.0686	.0693
17	.0164	2.878	2.5724	2.8837	2.915	.0686	.0686
18	.0164	.0343	.0328	.0686	.1029	.0686	.0686
19	.0328	.0343	.0655	.0686	.1029	.0686	.0663
20	.0328	.0663	.0655	.0686	.0686	.0686	.0663
21	.0655	.0671	.0655	.0686	.0686	.0686	.0671
22	.0328	.0671	.0328	.0457	.0686	.0686	.0686
23	.0328	.0671	.0328	.0686	.0686	.0686	1.6964
24	1.8442	.0328	.0686	.0328	2.1795	1.8861	1.989
Max	1.9113	3.1687	3.1878	3.6214	3.4294	2.4006	2.332
Min	.0164	.0328	.0328	.0328	.0686	.0686	.0343
Avg	.6516	1.0286	.6852	1.1156	1.9070	.9359	.9405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 203 / 11kv SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	2.2939	2.119	2.2939	.1029	.1029	.1029
2	.1029	2.2939	2.1765	2.2611	.1029	.0686	.1029
3	.1029	2.2939	1.9608	2.2119	.1029	2.0576	.1029
4	.1029	2.2611	1.9292	2.2119	.1029	.0686	.1029
5	.1029	2.2611	2.0165	2.2119	.1029	.0686	.1029
6	.1029	2.2611	2.0557	2.1464	.1029	.0686	.1029
7	.1029	2.5396	2.3403	2.4086	.1029	.1372	.1029
8	.1372	2.5069	2.5934	2.5396	.1029	.1029	.1029
9	.0686	2.2447	2.4036	2.3922	.1029	.0686	.1029
10	3.0148	.0983	.0693	.0655	3.1855	3.2693	3.152
11	3.2579	.1311	.0655	.1029	3.3436	3.152	
12	2.572	.1402	.0655	.1029	3.4294	3.1184	2.9767
13	3.4294	.1372	.0655	.1029	3.4294	3.1184	3.0445
14	3.3265	.0343	.0328	.1029	3.3436	2.9843	2.9447
15	3.2579	.1387	.0655	.1029	3.2922	2.9508	3.1493
16	3.0476	.1326	.0057	.1029	3.2579	2.8502	2.6558
17	2.6216	.1387	.0983	.1029	2.915	2.8837	2.4646
18	.0819	.1387	.0819	.1029	.1029	.1029	.0678
19	.1147	.1357	.0983	.1029	.1029	.1029	.0671
20	.0819	.1006	.1147	.1029	.1029	.1029	.1006
21	.0983	.0995	.0983	.1029	.1029	.1029	.0995
22	.0819	.0995	.0983	.1029	.1029	.1029	.1017
23	.0983	2.2138	.1311	.1029	.1029	.1029	.1029
24	.1029	2.343	2.3087	2.4086	.1029	.1029	.1029
Max	3.4294	2.5396	2.5934	2.5396	3.4294	3.2693	3.152
Min	.0686	.0343	.0057	.0655	.1029	.0686	.0671
Avg	1.0881	1.1266	.9581	1.0204	1.1601	1.1580	.9546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 201 / Charegaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	.0747	.1132	.0934	1.0166	.9945	.6516
2	1.0229	.0747	.0943	.0934	.9816	.9945	.6173
3	1.0166	.0747	.0943	.0934	.9465	.9945	.6173
4	.9991	.0747	.0943	.0934	.9015	.9602	.6173
5	.964	.0934	.1132	.112	.8669	.9602	.6859
6	.9015	.112	.1698	.1494	.8495	.9602	.8059
7	1.2094	.168	.2075	.1867	.8764	1.1145	.9945
8	.1494	.168	.1698	.1867	.964	1.166	.9945
9	.1867	.1494	.2263	.2241	.964	1.046	.8745
10	.2054	1.8004	1.8347	1.5775	.168	.168	.0943
11	.168	1.8861	1.8347	1.5775	.168	.2075	.1509
12	.1867	1.9033	1.6632	1.5775	.1494	.1698	.1494
13	.1494	1.9204	1.6461	1.6124	.0934	.1698	.1494
14	.1494	1.7833	1.5775	1.5604	.0934	.1509	.1307
15	.168	1.6975	1.406	1.4899	.0747	.1509	.1307
16	.168	1.6632	1.286	1.4022	.0934	.1698	.1307
17	.1494	1.5432	1.1145	1.2656	.0934	.1698	.1307
18	.1494	.1886	.1307	.1494	.1307	.1886	.1494
19	.1494	.1509	.1307	.1494	.1307	.1886	.1494
20	.1494	.1698	.1494	.1494	.1307	.1886	.1307
21	.112	.1509	.1494	.1494	.112	.1698	
22	.1307	.1509	.1494	.1307	.0934	.1132	.1307
23	.112	.132	.0934	.0747	.056	.1132	.112
24	1.0402	.0934	.1132	.0934	1.0517	.9945	.7716
Max	1.2094	1.9204	1.8347	1.6124	1.0517	1.166	.9945
Min	.112	.0747	.0934	.0747	.056	.1132	.0943
Avg	.4449	.6760	.6067	.5913	.4586	.5210	.4074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 202 / charegaon vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3258	.3292	.3109	.3439	.3801	.3292
2	.3109	.3258	.3109	.3109	.3258	.3258	.3292
3	.2926	.3258	.3109	.3109	.3077	.3258	.3292
4	.2926	.3258	.3109	.3109	.3077	.3258	.3292
5	.3292	.362	.3475	.362	.362	.3982	.3658
6	.4938	.4706	.5068	.4706	.4938	.543	.5068
7	.724	.724	.7701	.6878	.7316	.7421	.7522
8	.8869	.7421	.8238	.8145	.7316	.7964	.7701
9	.6516	.724	.4572	.6697	.6516	.6154	.5731
10		.6154	.5487	.5792	.5249	.4887	.5249
11	.5249	.5792	.4525	.5487	.4163	.4706	
12	.5249	.543	.4887	.5121	.4163	.4706	
13	.4887	.4938	.4706	.4938	.4344	.4024	.4024
14	.4706	.4572	.4344	.4755	.4344	.4207	
15	.5068	.4572	.3982	.4755	.4163	.4024	.4024
16	.5792	.4755	.5068	.439	.4525	.3841	.439
17	.6154	.5792		.5853	.5068	.4572	.5487
18	.6697	.5611	.6335	.695	.6335	.6154	.5853
19	.7421	.788	.8688	.7964	.7964	.7628	.7316
20	.7602	.8238	.8238	.8413	.8688	.8417	.823
21	.724	.7701	.7164	.8048	.8145	.8059	.7682
22	.6516	.6626	.6697	.6516	.7059	.6878	.5487
23	.4525	.4525	.4887	.4525	.5249	.4887	.4938
24	.3292	.3439	.3658	.362	.362	.3801	.3658
Max	.8869	.8238	.8688	.8413	.8688	.8417	.823
Min	.2926	.3258	.3109	.3109	.3077	.3258	.3292
Avg	.5370	.5387	.5232	.5400	.5235	.5222	.5199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 203 / Mazgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	1.406	1.2346	1.2003	.0373	.0377	.0377
2	.0373	1.406	1.2003	1.2346	.0373	.0358	.0377
3	.0373	1.406	1.2003	1.2346	.0373	.0377	.0377
4	.0373	1.406	1.2003	1.2346	.0373	.0377	.0377
5	.0373	1.4403	1.2346	1.2689	.0373	.0377	.0377
6	.0373	1.5089	1.3032	1.2689	.0373	.0377	.0377
7	.0373	1.6118	1.5775	1.3032	.0373	.0754	.0377
8	.056	1.6118	1.6118	1.4575	.0373	.0566	.0377
9	.056	1.4232	1.2003	1.3717	.0373	.0377	.0377
10	2.4188	.0373	.0377	.0373	2.4619	2.4006	2.2977
11	2.1776	.0377	.0377	.0373	2.3491	2.3663	2.2365
12		.0377	.0377	.0373	2.2119	2.1776	2.1672
13	2.2634	.0377	.0377	.0373	2.2977	2.2462	2.0805
14	2.1091	.0377	.0377	.0373	2.1605	2.1434	
15	1.8861	.0377	.0377	.0373	2.1262	2.2291	
16	1.8004	.0377	.0377	.0373	1.8861	2.0748	
17	1.6461	.0377	.0377	.0373	1.8347	1.8347	
18	.0373	.0377	.0377	.0373	.0373	.0377	.056
19	.056	.0566	.0373	.0373	.0373	.0377	
20	.056	.0566	.056	.0373	.056	.0377	
21	.056	.0754	.0373	.0373	.0373	.0377	
22	.056	.0377	.0377	.0373	.0373	.0377	.0373
23	.0373	.0377	.0377	.0373	.0373	.0377	.0373
24	.0373	1.4232	1.2346	1.2003	.0373	.0377	.0377
Max	2.4188	1.6118	1.6118	1.4575	2.4619	2.4006	2.2977
Min	.0373	.0373	.0373	.0373	.0373	.0358	.0373
Avg	.6526	.6353	.5643	.5540	.7477	.7554	.5464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 201 / Shahapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.2667	.2858		.3048	.3048
2	.2286	.2286	.2286	.2858		.2858	.2858
3	.2286	.2286	.2286	.2858		.2858	.2858
4	.2477	.2477	.2477	.3239		.2858	
5	.2858	.2667	.2858	.381		.3048	.1143
6	.4763	.4382	.4854	.4954		.4763	.1143
7	.5914	.5601	.6099	.5975		.6161	.1334
8	.5359	.5487	.567	.5544		.5487	.462
9	.4887	.4938	.4344	.5121	.4887	.439	.5068
10	.4119	.4298	.3761	.394	.3761	.3403	.4656
11	.3189	.3467	.3721	.3582	.3761	.3582	.4298
12	.3189	.4161	.298	.4252	.3189	.2835	.3721
13	.298	.3294	.2686	.3506	.3544	.3012	.3366
14	.3155	.2947	.3224	.3506	.298		.3544
15	.3366	.3121	.3582	.3506	.298	.3544	.3721
16	.3544	.3544	.3582	.3506	.3761	.3366	.3898
17	.4119	.3721	.4119	.3681	.4119	.3761	.4298
18	.3841	.5731	.439	.5552	.5068	.4031	.4733
19	.6219	.6878	.6099	.6878	.6219	.7023	.7059
20		.6468	.7095	.6468	.6767	.6908	.6036
21	.5906	.5975	.6161	.6161	.6161	.5975	.6535
22	.4763	.5281	.5228	.4904	.5525	.547	.5658
23	1.0031	.362	.4001	.4001	.4001	.4191	.4191
24	.2667	.2858	.2858	.3239	.3239	.3239	.3429
Max	1.0031	.6878	.7095	.6878	.6767	.7023	.7059
Min	.2286	.2286	.2286	.2858	.298	.2835	.1143
Avg	.4096	.4090	.4043	.4329	.4373	.4166	.3966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 202 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0936	.0572	.0572	.0953		1.1248	1.0623
2	1.0494	.0572	.0572	.0953		1.0936	1.0031
3	1.0364	.0572	.0572	.0953		1.0623	.945
4	.9907	.0572	.0572	.0953		1.0311	.8993
5	.9907	.0572	.0762	.0953		.9998	.8993
6	1.0364	.0572	.0762	.0953		.953	.8993
7	1.0974	.0762	.0762	.0762		1.0648	1.1873
8	.0572	.0953	.0762	.0762		1.0822	
9	.0953	.1334	.0953	.0762	.9602	1.0517	1.1717
10	.0953	1.704	1.9044	1.6872	.0572	.0762	.1524
11	.0762	1.9292	1.9845	1.8122	.0572	.0953	.1905
12	.0762	1.821	1.8185	1.7901	.1143	.1334	.1715
13	.0762	1.821	1.8404	1.6918	.1143	.1334	.1715
14	.0762	1.8519	1.7078	1.6461	.1143		.1715
15	.0762	1.7901	1.6446	1.5699	.1143	.1715	.1524
16	.0381	1.7593	1.6129	1.4175	.1334	.1524	.1524
17	.0572	1.6309	1.4998	1.3108	.1334	.1524	.1143
18	.0953	.0762	.0762	.0762	.1143	.1334	.0953
19	.0762	.0762	.0953	.0762	.0953	.1334	.0762
20	.0953	.0572	.0762	.0762	.0953	.1334	.0762
21	.0762	.0572	.0762	.0572	.0762	.1334	.0762
22	.0762	.0572	.0762	.0572	.0762	.0572	.0762
23	.5335	.0572	.0953	.0572	.0762	.0762	.0762
24	1.6011	.0572	.0572	.0953	.8993	1.1405	1.078
Max	1.6011	1.9292	1.9845	1.8122	.9602	1.1405	1.1873
Min	.0381	.0572	.0572	.0572	.0572	.0572	.0762
Avg	.4405	.6414	.6331	.5926	.2020	.5298	.4738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 203 / Riswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.3108	1.3923	1.4575		.0953	.0953
2	.0953	1.278	1.3603	1.3599		.0953	.0953
3	.0953	1.2452	1.3279	1.2967		.0953	.0762
4	.0953	1.2125	1.3272	1.2186		.0953	.0762
5	.0953	1.1797	1.3927	1.1717		.0953	.0953
6	.0953	1.3763	1.4251	1.2029		.1143	.1143
7	.1143	1.7328	1.917	1.0155		.1334	.1143
8	.1334	1.749	1.9685	1.7976		.1143	.1143
9	.0953	1.4737	1.6716	1.6549	.1524	.1143	.1334
10	2.5888	.1143	.0953	.0953	2.556	2.5069	2.2939
11	2.7199	.1334	.1143	.0953	2.9492	2.5692	2.5526
12	2.8837	.1143	.0953	.0953	2.8675	2.6189	1.8896
13	2.6871	.1334	.0953	.1143	2.8178	2.6355	2.3703
14	2.5396	.1334	.0953	.1143	2.7681		2.3205
15	2.4086	.1334	.1143	.1143	2.5194	2.2283	2.2211
16	2.2447	.1334	.1524	.1143	2.3266	2.2939	2.304
17	2.0481	.1143	.1334	.1143	2.2119	2.0481	2.0222
18	.1334	.1334	.1334	.1143	.1143	.0953	.1524
19	.1334	.1524	.1334	.1143	.1334	.1143	.1334
20	.1334	.1334	.1143	.1143	.1143	.0953	.1334
21	.1524	.1334	.1334	.1143	.1143	.0953	.1143
22	.1334	.1334	.1143	.1143	.1143	.0953	.1143
23	.1334	1.4413	.0953	.1143	.0953	.0953	.0953
24	.0953	1.3272	1.4737	1.5061	.1143	.0953	.0953
Max	2.8837	1.749	1.9685	1.7976	2.9492	2.6355	2.5526
Min	.0953	.1143	.0953	.0953	.0953	.0953	.0762
Avg	.9146	.7093	.7032	.6344	1.3731	.8061	.8220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 300 / AUXILLARY SUPPLY FEEDER
SHINDE Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.037
Max	.037
Min	.037
Avg	.037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 301 / 22 KV WING GAO

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.2926	.125	.2957	.1677	.2587	.2587
2	.2587	.2926	.125	.2957	.1341	.2587	.2587
3	.2587	.2195		.2957	.1677	.2218	.2587
4	.2587	.2195	.125	.2957	.2012	.2218	.2587
5	.2957	.2195	.1562	.2957	.2012	.2218	.2957
6	.2957	.2195	.25	.2957	.3018	.2957	.2957
7	.4066	.3647	.3749	.4435	.3018	.4435	.407
8	.4344	.4557	.4908	.4607	.4344	.4854	.4435
9	.7023	.431	.5853	.6516	.4805	.6283	.4805
10	.7392	.543	.5258	.8131	.5544	.7468	.6348
11	.7762	.5068	.724	.7023		.7468	.6348
12	.7762	.5068		.6283	.5914	.6584	.7023
13	.7762	.6516	.543	.6283	.5914	.6219	.6348
14	.6653	.2896	.5853	.5544	.5175	.6219	.6283
15	.5914	.3258		.5914	.5544	.6219	.6653
16	.6283	.362	.6584	.5544	.5792	.6219	.5914
17	.7023	.5792	.6584	.5914	.6283	.6219	.5175
18	.5175	.543	.5544	.5544	.6348	.5544	.4854
19	.4805	.5487	.5175	.4805	.6283	.4066	.4805
20	.4805	.4374	.4805	.4161	.5068	.4066	.4066
21	.4435	.3932	.4435	.3898	.4435	.4066	.3696
22	.4066	.3239	.4066	.3467	.3734	.3326	.3696
23	.2926	.208	.3326	.2401	.2987	.2507	.2987
24	.3326	.2926	.1486	.3326	.1715	.2957	.2587
Max	.7762	.6516	.724	.8131	.6348	.7468	.7023
Min	.2587	.208	.125	.2401	.1341	.2218	.2587
Avg	.4923	.3844	.4196	.4647	.4115	.4563	.4431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 302 / 22 KV SHINDEWADI GAO

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1829	.0625	.2218	.1006	.1478	.1848
2	.1478	.1463	.0625	.1848	.0671	.1109	.1848
3	.1109	.1463	.0937	.1848	.1006	.1109	.1848
4	.1109	.1463	.0937	.1848	.1341	.1109	.1848
5	.1478	.1463	.125	.1848	.1341	.1478	.2218
6	.1848	.1463	.1562	.1848	.1677	.1848	.2218
7	.1848	.2321	.1562	.1848	.2012	.2587	.2374
8	.2172	.2103	.2103	.2126	.181	.2241	.2957
9	.2218	.1989	.2195	.2172	.1478	.2587	.2218
10	.2218	.2172	.2454	.2218	.1848	.2614	.2987
11	2.4025	.2896	.181	.2218	.2218	.2241	.2614
12	.1848	.2534	.2534	.1848	.2218	.2195	.2587
13	.1109	.2172	.181	.2218	.2218	.2195	.1867
14	.1109	.2172	.1829	.2218	.2218	.2195	.2587
15	.1109	.2172	.1829	.1848	.2587	.1829	.2587
16	.1109	.2534	.1829	.2218	.181	.1829	.1848
17	.1109	.2534	.1829	.1478	.2957	.2926	.1478
18	.2218	.181	.1848	.2218	.2987	.2561	.1494
19	.2957	.2743	.2587	.2587	.2957	.2957	.2587
20	.2957	.2187	.2587	.2774	.2896	.2957	.2957
21	.2218	.1966	.2218	.2481	.2587	.2587	.2587
22	.2218	.2267	.2587	.1734	.2614	.2218	.2957
23	.1829	.1486	.2218	.1715	.2241	.1791	.2614
24	.1478	.1829	.1189	.2218	.1029	.1478	.1848
Max	2.4025	.2896	.2587	.2774	.2987	.2957	.2987
Min	.1109	.1463	.0625	.1478	.0671	.1109	.1478
Avg	.2677	.2043	.1790	.2066	.1989	.2088	.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 303 / 22 KV INDUSTRIAL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6263	1.6827	.6249	1.7741	1.6766	1.848	1.848
2	1.5154	1.5364	.5937	1.7002	1.643	1.6632	1.7741
3	1.5154	1.5364	.8124	1.7002	1.2742	1.6632	1.7741
4	1.4784	1.4632	.9061	1.7741	1.643	1.5893	1.7002
5	1.4045	1.39	.7811	1.7741	1.576	1.5154	1.7002
6	1.5154	1.3169	.9061	1.848	1.6766	1.6632	1.4784
7	1.4784	1.4586	.9374	1.7741	1.5089	1.6263	1.5939
8	1.5927	1.0517	1.4022	1.382	1.5927	1.6804	1.7372
9	2.0698	1.094	.5853	1.8099	1.9959	1.7741	2.1437
10	1.9589	1.5927	2.1384	2.0698	1.9959	2.0165	2.3152
11	2.4025	1.3394	2.4253	2.1437	2.4025	1.9044	2.6139
12	2.3285	1.3032	2.3529	1.7372	2.1068	1.9387	2.1437
13	1.848	1.0498	2.1719	1.6632	1.9959	1.9753	1.9418
14	2.2916	1.267	2.5606	1.9959	2.2916	2.0119	2.1068
15	2.4764	1.2308	2.3777	2.0328	2.4025	1.7924	2.2916
16	2.2546	1.2308	2.3045	2.0328	2.4615	1.829	2.1068
17	2.5133	1.1946	2.0485	1.885	2.2916	1.829	2.5133
18	1.885	1.0136	1.848	1.6263	1.7551	1.922	1.9418
19	1.922	.9602	1.7741	1.6263	1.848	1.6263	1.6632
20	1.7002	.8749	1.6263	1.595	1.5927	1.7002	1.922
21	1.7002	.8848	1.5893	1.4883	1.6632	1.7741	1.7741
22	1.5524	.8421	2.0698	1.4217	1.7924	1.7002	1.7741
23	1.6827	.7727	1.7741	1.5089	1.7924	1.7909	1.7924
24	1.7017	1.6827	.7133	1.7741	1.7147	1.922	1.848
Max	2.5133	1.6827	2.5606	2.1437	2.4615	2.0165	2.6139
Min	1.4045	.7727	.5853	1.382	1.2742	1.5154	1.4784
Avg	1.8506	1.2404	1.5552	1.7557	1.8622	1.7815	1.9374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 304 / 22 KV TUBE EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.5121	.6249	.961	.7042	.924	.924
2	.6653	.5121	.7499	.961	.7377	.8501	1.0349
3	.6653	.5121	.6562	.924	.6036	.8501	1.0349
4	.6283	.4755	.6874	.924	.57	.7762	1.1088
5	.6653	.4755	.6249	.961	.7377	.9979	1.1088
6	.7392	.4755	.6562	.9979	.7377	1.0349	1.3676
7	.7762	.431	.6562	.7762	.7377	.7023	.7461
8	.3982	.4207	.8764	.7087	.8688	.9335	1.0349
9	.4805		.695	.6878	.6653	.8501	1.2197
10	.4805	1.0498	.6661	.7023	.6653	1.0456	1.2696
11	.4805	.8326	.6516	.7023	1.4045	1.3443	1.0829
12	.4805	.8688	.6878	.7762	1.1827	1.1706	.8131
13	.4805	.8326	.724	.7023	.8131	1.1706	1.1576
14	.4805	.724	.695	.6653	1.0349	1.1706	1.1827
15	.4805	.724	.8048	.7392	.7023	1.0974	.7023
16	.4435	.8326	1.134	.7392	.8326	1.134	1.5893
17	.4805	.5792	1.0974	.7392	1.1458	1.134	1.5154
18	.4805	.7602	1.2567	.7762	1.1576	1.5524	1.1576
19	.5175	.6859	1.0719	.8131	1.4045	1.7741	1.3676
20	.5175	.6562	1.2567	.7628	.905	1.3676	1.1088
21	.5175	.6882	1.1458	.7796	.7762	1.5154	1.1458
22	.5914	.6154	.7762	.7628	.8589	1.2936	1.2567
23	.6219	.6241	.961	.7545	.6348	.8238	.7842
24	.7023	.5121	.5944	.961	.7545	.6653	.924
Max	.7762	1.0498	1.2567	.9979	1.4045	1.7741	1.5893
Min	.3982	.4207	.5944	.6653	.57	.6653	.7023
Avg	.5600	.6435	.8229	.8032	.8598	1.0908	1.1099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 402 / 33 KV GODREJ EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.3292		1.3306	1.1065	1.4415	1.4415
2	.2218	.3292		1.3306	1.1065	1.386	1.3306
3	.2772	.3292		1.2197	.9054	1.2752	1.3306
4	.2218	.3292		1.2197	1.0059	1.386	1.2197
5	.2218	.3292		1.1088	1.1065	1.2752	1.1088
6	.2218	.1097		1.1088	1.1065	1.1088	1.1088
7	.2772	.2984		.9979	.2012	.9425	.8648
8	.3801	.3155	1.4723	1.4883	1.6289	1.7364	1.6632
9	.3326	.0995	1.5364	1.6289	1.5524	1.7187	1.5524
10	.3326		1.3146	1.6632	1.4969	1.6804	2.0725
11	.3326		1.6289	1.3306	2.0513	1.9044	1.7924
12	.3326		1.6289	1.2197	1.5524		1.386
13	.3326		1.4118	1.4415	1.5524	1.6461	1.6804
14	.3326		1.5364	1.4415	1.5524	1.5364	1.5524
15	.3326		1.4266	1.6632	1.6632	1.6461	1.4969
16	.3326		.7682	.6653	.6516	1.6461	.8316
17	.3326		.7682	.6653	.7762	1.5364	.6653
18	.3326		.7762	.7762	.6722	.6653	.6161
19	.3326		.6653	.7762	.7762	.7762	.6653
20	.3326		.7762	.6241	.7602	.7762	.7207
21	.3326		.6653	.6379	.7207	.7762	.8316
22	.3326		.8871	.7282	.7842	.9979	.7762
23	.1097		1.3306	1.2346	1.3443	1.5043	1.2883
24	.2772	.3292		1.3306	1.1317	1.1643	1.4415
Max	.3801	.3292	1.6289	1.6632	2.0513	1.9044	2.0725
Min	.1097	.0995	.6653	.6241	.2012	.6653	.6161
Avg	.2953	.2798	1.1621	1.1513	1.1336	1.3272	1.2266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 403 / 33 KV SUSSEN ASIA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.4266	.9374	1.3306	.8048	1.386	1.4969
2	.9979	1.4266	1.0311	1.2197	.8551	1.4969	1.4969
3	.9979	1.3169	.9842	1.2197	.7545	1.386	1.4415
4	.9425	1.3169	1.1717	1.1088	.7042	1.2752	1.4415
5	.9979	1.0974	1.4529	1.1088	.503	1.386	1.386
6	1.0534	1.0974	.9374	1.1088	.6036	1.2752	1.386
7	1.386	1.2929	1.1248	.8871	1.1065	1.4969	1.4243
8	1.3575	1.5775	1.5249	.9036	1.5203	1.6804	1.6632
9	1.4415		1.5912	.9231	1.386	1.4969	1.4969
10	1.4415	1.4661	1.5775	1.0534	1.6078	1.6804	1.7364
11	1.4415	1.4118	1.5746	1.1088	1.5524	1.5123	1.5123
12	1.4969	1.5203	1.6289	.9425	1.5524	1.6461	1.5524
13	1.4969	1.5746	1.7375	1.0534	1.6632	1.701	1.6244
14	1.6632	1.6832	1.8107	1.1088	1.6078	1.6461	1.7741
15	1.4415	1.3575	1.7558	.8316	1.386	1.4266	1.386
16		1.6289	1.7558	.8871	1.7375	1.5364	1.7187
17	1.5524	1.4661	1.6461	.9425	1.6632	1.4266	1.4969
18	1.6078	1.6289	1.5524	.9979	1.7364	1.5364	1.6804
19	1.6632	1.6461	1.6632	.9979	1.6632	1.7741	1.6632
20	1.4415	1.2186	1.3306	.8842	1.2489	1.2197	1.386
21	1.5524	1.5061	1.6632	.9036	1.6078	1.6632	1.6632
22	1.6632	1.5061	1.6632	.7802	1.5123	1.6632	1.6632
23	1.4266	1.1591	1.3306	.7202	1.5123	1.4506	1.6244
24	1.2752	1.4266	.9808	1.3306	.5144	1.5524	1.4969
Max	1.6632	1.6832	1.8107	1.3306	1.7375	1.7741	1.7741
Min	.9425	1.0974	.9374	.7202	.503	1.2197	1.386
Avg	1.3697	1.4240	1.4344	1.0147	1.2835	1.5131	1.5505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / 33/22 KV SHINDEWADI

Feeder No / Name : 404 / 33 KV UMICORE EXPRESS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.439	.0937	.3326	.1509	.2772	.3326
2	.2772	.439	.0937	.3326	.1006	.2772	.3326
3	.2772	.3292	.1406	.2772	.1509	.2218	.2772
4	.2218	.3292	.1406	.2218	.2012	.2772	.2772
5	.2218	.3292	.1875	.2218	.1509	.2772	.2772
6	.2772	.2743	.1406	.2218	.2012	.3326	.2218
7	.2772	.2984	.1406	.2218	.1509	.2772	.5087
8	.2172	.2629	.2103	.2126	.1629	.3361	.6653
9	.6099		.1646	.3258	.2218	.4435	.6653
10	.6099	.2715	.1578	.3326	.7207	.3921	1.1763
11	.5544	.3258	.1086	.2772	.7207	.3361	1.1203
12	.499	.4344	.2715	.3881	.8316	.6036	1.1643
13	.4435	.2715	.1086	.499	.8871	.6036	1.1763
14	.4435	.3258	.2743	.2218	.8871	.5487	.9979
15	.5544	.2715	.3292	.3881	1.1643	.7133	.7762
16	.6653		.439	.2772	1.0317	.6584	1.1643
17	.6099	.3258	.3292	.2772	1.2197	.5487	.7762
18	.6099	.3258	.4435	.4435	.7282	.6036	.5601
19	.6099	.2058	.4435	.4435	.9425	.9425	1.1643
20	.499	.1875	.3881	.208	.4344	.499	.6653
21	.4435	.2949	.4435	.5316	.3881	.3881	.7762
22	.4435	.1943	.2772	.2601	.3361	.3881	.5544
23	.439	.1783	.3326	.1543	.3361	.3761	.6161
24	.2772	.439	.1783	.3326	.3086	.3326	.3326
Max	.6653	.439	.4435	.5316	1.2197	.9425	1.1763
Min	.2172	.1783	.0937	.1543	.1006	.2218	.2218
Avg	.4293	.3070	.2432	.3085	.5178	.4439	.6908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 301 / 22 KV AHIRE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	1.4937	1.4403	1.8671	.2058	.3361	.3086
2	.2743	1.5684	1.4746	1.9418	.2058	.3734	.3086
3	.3086	1.5684	1.4403	2.0165	.2058	.3361	.3086
4	.3086	1.6057	1.4746	2.0165	.2743	.3361	.3086
5	.3429	1.643	1.5089	2.0119	.2743	.3361	.3429
6	.3429	1.643	1.749	2.0538	.3429	.3734	.3429
7	.4458	2.2405	2.2291	2.4646	.4115	.3658	.4458
8	.3429	.2987	.3429	.3734	.3772	.3734	.4115
9	.2743	.3086	.2987	.3086	.2987		.2743
10	2.2405	.1029	.2987	.2743	2.2405	.3429	.2743
11	2.7633	.1029	.2614	.2743	3.1741	3.0178	2.5034
12	3.1741	.1029	.2614		3.2487	3.1893	2.7092
13	2.9995	.1029	.2614		2.9874	3.2236	3.0178
14	2.9995	.1029	.2614	.3429	3.2114	3.0178	2.6406
15	2.8753	.1029	.2614		3.0994	2.8464	2.4348
16	2.726	.1029	.2926	.2743	3.0247	2.7435	2.8464
17	1.829	.1029	.2951	.2058	2.8753	2.5377	2.6749
18	2.2405	.1372	.2926	.1372	2.5339	2.572	2.332
19	.2241	.1372	.3292	.2743	.3361	.3086	.3429
20	.2987	.2058	.3292	.2743	.3658	.3429	.3772
21	.2987	.1715	.3658	.2743	.3734	.3086	.3772
22		1.7147	1.4632	1.6118	.3361	.3429	
23	.2195	1.7147	1.7924	1.4403	.2987	.3429	.2743
24	.2743	1.531	1.5432	1.9044	1.3717	.3361	.3086
Max	3.1741	2.2405	2.2291	2.4646	3.2487	3.2236	3.0178
Min	.2195	.1029	.2614	.1372	.2058	.3086	.2743
Avg	1.2208	.7836	.8445	1.0639	1.3364	1.2306	1.1376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 302 / 22 KV KHANDALA GAO

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	1.4937	.6859	1.4937	.9602	1.4937	1.1317
2	.9259	1.39	.6859	1.419	1.0288	1.39	1.166
3	1.0631	1.531	.7545	1.419	1.0288	1.4937	1.166
4	1.1317	1.4937	.7545	1.4937	1.0974	1.3817	1.0974
5	.8573	1.4632	.823	1.419	1.2346	1.3443	1.3032
6	1.0974	1.643	.9602	1.3817	1.3375	1.419	1.3032
7	1.1317	1.4632	1.3032	1.2803	1.4403	1.9387	1.3717
8	1.3032	1.5684	1.6461	1.419	1.3375	1.9044	1.3032
9	1.8176	1.3032	2.2405	1.2689	1.6057	1.5089	1.4403
10	2.5393	1.1317	1.419	1.4746	2.0165	1.5432	1.3717
11	2.0165	.8573	1.7924	1.3717	1.9791	1.0974	1.3717
12	1.2323	.823	1.8671	1.3717	2.0538	1.2689	1.2689
13	1.0974	.6859	1.643	1.2003	2.0911	1.1317	1.749
14	1.2696	.7202	1.2696	.8573	1.0456	1.2346	1.4403
15	1.531	.7545	1.4937	.8916	2.0911	1.166	1.6804
16	1.4937	.7202	1.307	.9602	1.2696	1.0974	.8916
17	1.531	.7545	1.3535	.8916	1.8671	1.1317	1.7833
18	1.4632	.7545	1.4632	1.0288	2.3152	1.3032	1.8519
19	1.5729	1.0974	1.3535	1.5089	1.4632	1.6118	1.2346
20	1.531	1.0631	1.2437	1.2689	1.5684	1.3717	1.7147
21	1.2696	.9945	1.3169	1.2003	1.531	1.1317	1.6461
22	.9877	.8916	1.4632	1.0974	1.4937	1.0631	
23	1.0974	.7888	1.3032	1.0288	.9709	1.1317	1.3375
24	.8573	1.4998	.7545	1.531	.8573	1.4998	1.3032
Max	2.5393	1.643	2.2405	1.531	2.3152	1.9387	1.8519
Min	.7888	.6859	.6859	.8573	.8573	1.0631	.8916
Avg	1.3169	1.1203	1.2874	1.2616	1.4869	1.3608	1.3882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 303 / 22 KV AHIRE GAO

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.643	.8573	1.4937	.7202	1.8671	1.3717
2	1.3375	1.6804	.8573	1.531	.7545	1.6804	1.3032
3	1.2346	1.643	.8916	1.4998	.7545	1.7177	1.3717
4	1.3032	1.5684	.8916	1.531	.8573	1.7551	1.3717
5	.1372	1.5684	.9602	1.419	1.0288	1.7924	1.4746
6	1.4403	1.6057	1.0631	1.3443	1.2689	1.7924	1.6118
7	1.4403	1.419	1.2003	1.4233	1.4403	1.8656	1.6461
8	1.7833	1.2696	1.3375	1.5684	1.7147	1.6804	1.5432
9	1.6804	1.166	1.6804	1.5432	1.9044	1.8861	2.1262
10	2.2779	1.166	2.2405	1.7147	2.3899	1.6118	2.1262
11	2.2779	1.2003	2.0911	1.8519	2.4646	1.3717	2.0576
12	2.1658	1.0631	2.3899	1.7147	2.1658	1.3032	1.5089
13	1.9044	.8916	1.0974		2.0538	1.2003	.8916
14	1.643	.8573	2.3899	1.7147	1.5729	.9602	1.8861
15	2.2032	.8573		1.749	2.5766	1.1317	1.8519
16	2.1285	.8916	2.1285	1.4403	2.3899	1.3032	1.5432
17	2.0911	.8573	2.0851	1.7147	2.1658	1.2003	1.406
18	1.8671	.9259	2.0485	1.3375	2.3152	1.0631	1.8176
19	1.7551	1.166	2.0485	1.7147	2.3899	1.4746	1.989
20	1.531	1.166	1.6827	1.6804	2.2405	1.3717	2.0576
21	1.643	1.0631	1.7193	1.5432	1.9044	1.406	1.4746
22	1.4563	1.0288	1.6095	1.2689	1.8671	1.2689	
23	1.39	.8916	1.6827	1.2689	1.6057	1.3032	1.3375
24	1.4746	1.643	.9602	1.531	1.0288	1.9044	1.4403
Max	2.2779	1.6804	2.3899	1.8519	2.5766	1.9044	2.1262
Min	.1372	.8573	.8573	1.2689	.7202	.9602	.8916
Avg	1.6517	1.2180	1.5614	1.5478	1.7323	1.4963	1.6178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 304 / 22 KV TBK EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1867	.1715	.2241	.0686	.2241	.1372
2	.2058	.2241	.1715	.2195	.0686	.2241	.1372
3	.2401	.2241	.1715	.1867	.0686	.1867	.1372
4	.2401	.1867	.1715	.1867	.0686	.1867	.1715
5	.2058	.1867	.2058	.1829	.0686	.2241	.1715
6	.2401	.1867	.1715	.1867	.0686	.1867	.1715
7	.1715	.2195	.2058		.0686	.2195	.1715
8	.1372	.1494	.1029	.112	.1029	.1715	.1029
9	.2058	.2401	.3361	.1029	.2987	.2401	.2743
10	.1494	.2401	.2614	.1029	.2987	.2401	.2743
11	.2241	.2743	.2614	.1029	.2987	.2401	.2743
12	.1463	.1715	.1509	.1372	.1829	.2401	.1715
13	.2241	.2743	.2614	.1029	.2614	.2743	.2743
14	.1867	.2743	.2614	.1372	.2195	.2743	.2401
15	.1867	.2401	.2614	.1029	.2195	.2743	.2743
16	.1494	.2401	.2241	.0686	.2241	.1715	.2401
17	.1867	.2058	.2614	.0686	.2641	.2058	.2058
18	.1494	.2058	.2614	.0686	.2561	.2058	.2401
19	.1867	.2401	.2561	.1029	.2987	.2058	.2401
20	.1867	.1715	.1829	.0686	.2614	.2058	.1715
21	.1463	.2401	.2195	.0686	.2241	.2058	.2401
22	.1772	.2401	.2195	.0686	.2241	.2058	
23	.1829	.2401	.6219	.1029	.1867	.2058	.1715
24	.2401	.1867	.2058	.1867	.1029	.2241	.1715
Max	.2401	.2743	.6219	.2241	.2987	.2743	.2743
Min	.1372	.1494	.1029	.0686	.0686	.1715	.1029
Avg	.1906	.2187	.2341	.1257	.1835	.2185	.2028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 305 / 22 KV HITECH EXPRESS

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5121	.4115	.5975	.4801	.5601	.5487
2	.4458	.5121	.4115	.5853	.4801	.5601	.5487
3	.4115	.5281	.3772	.5601	.4801	.5975	.6516
4	.4115	.5487	.4115	.5601	.5144	.5975	.6516
5	.4801	.5121	.4115	.5601	.5144	.6348	.6859
6	.5487	.2972	.4801	.6584	.5487	.6348	.6859
7	.5144	.3734	.4115	.543	.5487	.5853	.6859
8	.4458	.4108	.4115	.439	.5144	.5487	.583
9	.583	.4801	.5601	.4801	.5975	.583	.6173
10	.6722	.4801	.5228	.583	.5228	.583	.6173
11	.4854	.5487	.5601	.583	.5975	.6859	.6859
12	.4024	.5487	.5228	.4801	.7095	.6859	.7202
13	.6348	.5144	.5601	.5144	.5975	.7202	.6516
14	.4854	.4801	.5228	.5487	.5975	.7545	.1029
15	.5975	.4801	.5228	.5487	.5975	.7202	.5487
16	.5601	.5144	.6348	.4801	.7842	.7202	.6173
17	.5487	.4458	.5121	.4115	.6348	.5144	.4115
18	.5121	.5144	.5121	.3429	.5658	.5487	.7202
19	.5121	.4115	.5487	.4801	.5228	.5144	.583
20	.4024	.4801	.6219	.4458	.5228	.6173	.7202
21	.5228	.4801	.6584	.4801	.5228	.6516	.5144
22	.3658	.4801		.5144	.4854	.7545	
23	.439	.3429	.6219	.5487	.4481	.6516	.5487
24	.4458	.5601	.4115	.5487	.5487	.5487	.7202
Max	.6722	.5601	.6584	.6584	.7842	.7545	.7202
Min	.3658	.2972	.3772	.3429	.4481	.5144	.1029
Avg	.4961	.4773	.5052	.5206	.5557	.6239	.6009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 306 / 22 KV MOLD TECH NON EXP

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2195	.2401	.1867	.2743	.2641	.2058
2	.2743	.2614	.2401	.1867	.2401	.2614	.2058
3	.3086	.2614	.2401	.2241	.2058	.2561	.2058
4	.2743	.2614	.2743	.2241	.2058	.2241	.2058
5	.3086	.2241	.2743	.1829	.2058	.2195	.2058
6	.3086	.2241	.2743	.2241	.2401	.2195	.2401
7	.0686	.2241	.2401	.2241	.2401	.2561	.2401
8	.0686	.2241	.2743	.2614	.3086	.2987	.2743
9	.0686	.2743	.3361	.3772	.3361	.3086	.2743
10	.1494	.3086	.3772	.3429	.2614	.2743	.2743
11	.1867	.3086	.2987	.3429	.2987	.2743	.3086
12	.1829	.2743	.2241	.3429	.2614	.2743	.3086
13	.1494	.3086	.2614	.3429	.2614	.3429	.2401
14	.3361	.2743	.2614	.3772	.2987	.3429	
15	.2987	.2743	.2241	.3086	.2987	.3429	.3429
16	.2614	.3086	.2987	.3086	.2241	.3086	.2743
17	.1463	.2743	.2926	.3086	.2614	.2058	.3086
18	.1829	.2401	.2561	.2743	.2614	.2743	.2401
19	.2926	.3086	.2561	.2743	.2241	.3086	.3086
20	.2614	.2743	.2561	.2743	.2241	.2058	.2401
21	.1829	.2743	.1829	.3086	.1867	.2058	.2058
22	.2241	.2743	.2195	.3086	.1867	.2058	
23	.2195	.2401	.1829	.2743	.2614	.2743	.2401
24	.3086	.2195	.2058	.1867	.2743	.2614	.2401
Max	.3361	.3086	.3772	.3772	.3361	.3429	.3429
Min	.0686	.2195	.1829	.1829	.1867	.2058	.2058
Avg	.2238	.2641	.2580	.2778	.2517	.2671	.2541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 400 / AUXILLARY SUPPLY FEEDER
MHAVSH Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / 33/22 KV MHAVASHI

Feeder No / Name : 401 / 33 KV PANACHE EXPRESS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3292	.2058	.2801	.1543	.2801	.2572
2	.3601	.2743	.2058	.2801	.1029	.2801	.2572
3	.3086	.2801	.2058	.2241	.1029	.3361	.2572
4	.3086	.2801	.2058	.2241	.1029	.3361	.2058
5	.3086	.3292	.2572	.2241	.1029	.2801	.2058
6	.3601	.3361	.1543	.2801	.1029	.3361	.2058
7	.3086	.3292	.2058	.2801	.1029	.3292	.2058
8	.2058	.3361	.1543	.2241	.1543	2.4086	.1543
9	.3601	.2058	.3921	.3086	.4481	.3086	.3086
10	.3921	.1543	.3921	.3086	.3921	.3601	.3086
11	.4481	.1543	.3921	.3086	.3921	.5144	.3601
12	.3921	.1029	.3292	.3601	.3921	.5144	.3601
13	.3921	.1029	.3361	.2572	.3921	.6687	.3086
14	.4481	.1029	.3361	.3086	.439	.4115	.463
15	.4481	.1029	.3841	.3086	.4481	.4115	.463
16	.4481	.1029	.3921	.3086	.3921	.3086	.5658
17	.3921	.1029	.3292	.3086	.2801	.3086	.5658
18	.3841	.1029	.3361	.2572	.3361	.3601	.463
19	.3921	.1029	.3292	.3086	.4481	.5144	.3086
20	.4481	.1029	.439	.1543	.3361	.3086	.3086
21	.439	.1029	.3292	.1543	.3292	.2058	.2572
22	.3361	.1543	.2743	.1543	.3361	.2058	
23	.3841	.2058	.2743	.1543	.2801	.2058	.2058
24	.3601	.3361	.1543	.2801	.1029	.2801	.3086
Max	.4481	.3361	.439	.3601	.4481	2.4086	.5658
Min	.2058	.1029	.1543	.1543	.1029	.2058	.1543
Avg	.3744	.1972	.2923	.2607	.2779	.4364	.3176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 301 / 22 KV WAI INDUSTRIAL
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.7888
Max	.7888
Min	.7888
Avg	.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 302 / 22 KV KHANDALA AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1125
Max	2.1125
Min	2.1125
Avg	2.1125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 303 / 22 KV SHIRWAL INDUSTRIAL
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	1.7353
Max	1.7353
Min	1.7353
Avg	1.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 304 / 22 KV SHIRWAL GAO

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3395
Max	.3395
Min	.3395
Avg	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 305 / 22 KV LAWKIM EXPRESS

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.5281
Max	.5281
Min	.5281
Avg	.5281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 306 / 22 KV BHADE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.9808
Max	.9808
Min	.9808
Avg	.9808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 307 / 22 KV JAWALE GAO

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 308 / 22 KV WATHAR COLONY GAO

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.4527
Max	.4527
Min	.4527
Avg	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 309 / EHV AUXILARY SUPPLY

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0377
Max	.0377
Min	.0377
Avg	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 401 / 33 KV SHINDEWADI I/C
Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.1132
Max	.1132
Min	.1132
Avg	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 402 / 33 KV CAPSUL EXPRESS
Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.2449
Max	1.2449
Min	1.2449
Avg	1.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 403 / 33 KV MHAVASHI I/C

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	.0566
Max	.0566
Min	.0566
Avg	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 404 / 33 KV ASIAN PAINT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 405 / 33 KV THERMAX EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1132
Max	.1132
Min	.1132
Avg	.1132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 407 / 33 KV DATWYLER PHARMA
EXPRESS Feeder KV- 33 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2829
Max	.2829
Min	.2829
Avg	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 408 / 33 KV FINOLEX EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.1698
Max	.1698
Min	.1698
Avg	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 409 / 33 KV KSB EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2829
Max	.2829
Min	.2829
Avg	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / 132/33/22 KV SHIRWAL EHV

Feeder No / Name : 709 / 132/11 KV NIPRO EHV NON SHEDDABLE EHV INDUSTRIAL FEEDERS
EXPRESS Feeder KV- 132 / (CONTINUOUS PROCESS)(NO STAGGERING
INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 300 / Auxilliary Supply

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 301 / 22 KV MUKUND EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4854	.5658	.5975	.679	.5228	.679
2	.5281	.4481	.6036	.5601	.6413	.5975	.6413
3	.5281	.4481	.5281	.5228	.6413	.5601	.679
4	.4527	.4854	.5281	.4481	.6036	.6348	.6036
5	.2641	.4108	.3395	.4854	.6036	.5228	.5281
6	.4527	.4481	.4527	.4854	.679	.6348	.5658
7	.2641	.3734	.2263	.4481	.6036	.3734	.5281
8	.1886	.3361	.4904	.4481	.415	.2987	.679
9	.3772	.2987	.3018	.4481	.3395	.4481	.679
10	.3018	.3772	.3734	.4904	.4904	.3395	.6036
11	.3395	.4527	.4854	.5281	.6036	.4904	.7545
12	.3772	.4527	.2987	.7167	.7922	.7545	.7167
13	.3772	.4527	.4481	.5281	.6036	.4904	.5658
14	.3772	.3772	.2987	.5281	.3018	.4527	.5658
15	.4904	.4527	.2987	.4527	.4904	.4904	.679
16	.415	.4527	.3734	.3772	.4904	.5281	.5658
17	.415	.3772	.4854	.4904	.415	.4527	.7167
18	.2987		.4481	.6348	.3361	.7167	.4854
19	.2987		.5228	.6722	.4481	.5281	.7468
20	.4108		.5601	.5975	.4481	.679	.7468
21	.4854		.6722	.5975	.4108	.7167	.6722
22	.3361		.4108	.7095	.4854	.679	.8589
23	.3734	.4904	.4481	.5228	.2987	.5658	.6348
24	.3395	.4481	.5281	.4108	.6036	.4108	.5658
Max	.5281	.4904	.6722	.7167	.7922	.7545	.8589
Min	.1886	.2987	.2263	.3772	.2987	.2987	.4854
Avg	.3810	.4246	.4453	.5292	.5177	.5370	.6442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 302 / 22 KV ANDHURI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7346	.3361	.3395	.2987	4.4513	5.0465	5.3189
2	3.6591	.3361	.3395	.2987	4.3004	4.9482	5.168
3	3.6214	.3361	.3395	.2987	4.225	4.8499	4.8663
4	3.6214	.3734	.3772	.2987	4.3759	4.7843	4.7531
5	3.7723	.4108	.4527	.3734	4.904	4.8826	4.7908
6	4.1495	.4481	.4527	.4108	5.4698	5.0137	5.3189
7	4.9417	.4481	.5281	.4481	6.2997	5.4035	5.9225
8	.3018	.3734	.4527	.4481	.3772	.3361	.3772
9	.3018	.3734	.3772	.3734	.3772	.3361	.3772
10	.4527	.3772	.3734	.3395	.1509	.1886	.4527
11	.415	6.0951	6.8953	7.3594	.1509	.1509	.3395
12	.3018	6.4883	7.3594	7.6909	.1509	.3772	.3395
13	.3658	6.7505	7.1274	7.3594	.3395	.3772	.415
14	.3772	6.7505	7.0611	7.0942	.3395	.3772	.3772
15	.3395	1.8564	6.829	7.0611	.3018	.4527	.3772
16	.3395	6.3649	6.6964	6.8621		.3395	.3772
17	.3395	6.4643	6.4643	6.5306	.3772	.3772	.3772
18	.3326		5.9671	7.1296	.3734	.3395	.3734
19	.3734		.3361	.3772	.4108	.3772	.4108
20	.4481		.3734	.4527	.4481	.4527	.4481
21	.4108		.3734	.4527	.4481	.4527	.4108
22	3.408		.3734	.3772	5.112	5.9602	4.5222
23	3.2769	.3772	.3361	.3772	5.5361	6.0357	4.9394
24	3.81	3.1459	.3395	.3361	.3772	5.1448	5.7339
Max	4.9417	6.7505	7.3594	7.6909	6.2997	6.0357	5.9225
Min	.3018	.3361	.3361	.2987	.1509	.1509	.3395
Avg	1.7956	2.5319	2.5235	2.6270	2.1433	2.3752	2.3661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 303 / 22 KV LONAND MIDC
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.0165	1.2071	1.8671	1.4335	1.8298	1.6975
2	1.9239	2.0538	1.1317	1.7924	1.4335	1.6057	1.6598
3	1.8484	1.8671	1.1694	1.6804	1.5089	1.6804	1.6975
4	1.9616	1.8298	1.2071	1.643	1.4712	1.7924	1.773
5	2.0748	1.5684	1.2826	1.7551	1.5089	1.643	1.8861
6	2.0748	1.4937	1.3957	1.643	1.6221	1.7924	1.9616
7	1.9616	1.3443	1.2826	1.5684	2.452	1.643	2.1125
8	2.2634	1.307	3.5837	1.6804	2.452	1.6057	3.8855
9	2.9424	1.2696	2.3388	2.838	2.5274	1.7551	4.0741
10	3.3951		2.1658	2.6029	2.9047	2.0748	4.489
11	3.3196	1.2826	2.8006	4.1495	3.2065	2.2634	4.2627
12	3.4705	1.2826	2.8006	3.6591	4.1118	2.037	3.0178
13	3.2442	1.2826	3.9956		4.489	2.1125	3.2819
14	3.2819	1.2071	4.7798	2.8292	3.1687	2.1502	4.9794
15	3.6969	1.1317	3.4355	2.7161	4.1495	2.1125	3.0178
16	3.6591	.9808	3.5848	2.7538	4.8663	2.3765	3.0933
17	4.1495	1.094	2.1658	3.81	2.037	1.9239	5.3189
18	3.8462		2.3525	1.8861	1.8298	1.8484	2.3152
19	2.1285		2.1658	1.773	1.9044	1.7353	2.5019
20	2.1658		2.0165	1.6221	1.8298	1.6975	2.2032
21	1.9044		2.0538	1.6598	1.8671	1.8861	2.3152
22	2.1285		2.1285	1.5466	1.7924	1.8484	2.1285
23	2.1658	1.1317	2.0538	1.6221	2.1285		1.9791
24	1.9239	2.0538	1.0288	1.9418	1.4712	2.0911	1.6975
Max	4.1495	2.0538	4.7798	4.1495	4.8663	2.3765	5.3189
Min	1.8484	.9808	1.0288	1.5466	1.4335	1.6057	1.6598
Avg	2.6424	1.4554	2.2553	2.2191	2.4236	1.8915	2.8062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 304 / 22 KV KHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3361	.3772	.4108	.3772	.4108	.4527
2	.415	.3361	.3395	.4108	.415	.4108	.415
3	.4527	.3734	.3395	.4108	.415	.4108	.415
4	.4904	.4481	.4904	.4854	.5281	.5228	.5281
5	.5281	.5601	.6036	.5601	.6036	.6722	.6036
6	.7545	.7468	.7922	.7095	.7545	.7468	.7545
7	.9431	.8589	.9808	.8589	.9431	.9709	.9431
8	.7545	.6722	.7922	.7842	.679	.7842	.679
9	.6036	.6348	.6036	.5975	.6036	.6348	.6036
10	.4904	.5281	.4854	.4527		.415	.4904
11	.4527	.415	.4481	.415		.4904	.415
12	.4527	.3772	.3734	.3395	.5281		.415
13	.415	.415	.2987	.3772	.3772	.415	
14	.4527	.4527	.2987	.415	.4527	.4527	.3772
15	.3018	.4527	.3361	.4527	.4904	.415	.4527
16	.3018	.4527	.3734	.415	.4527	.3772	.415
17	.4904	.4527	.4481	.4527	.4904	.4527	.4527
18	.4854		.4481	.5658		.5281	.5601
19	.6348		.7095	.6036	.8215	.8676	.7468
20	.7095		.6722	.6036	.8589	.7922	.8589
21	.4108		.7468	.6036	.7468	.7545	.6348
22	.5228		.6348	.6036	.6722	.6413	.5975
23	.3734	.415	.4854	.4527	.5228	.4904	.4854
24	.3772	.3361	.3772	.4854	.3772	.4481	.4527
Max	.9431	.8589	.9808	.8589	.9431	.9709	.9431
Min	.3018	.3361	.2987	.3395	.3772	.3772	.3772
Avg	.5079	.4876	.5190	.5194	.5767	.5698	.5543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 300 / Auxilliary Supply

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
17	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 301 / 22 KV PADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 302 / 22KV LONAND URBAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 303 / 22KV TARADGAON AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
17	.8383
Max	.8383
Min	.8383
Avg	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 304 / 22 KV TAMBAVE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 306 / 22/22 Nira switching I/c
Feeder Feeder KV- 22 / INCOMING

DATE	02-MAR-18
HR	Load (MW)
24	2.5606
Max	2.5606
Min	2.5606
Avg	2.5606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 307 / 22KV TARADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.724
Max	.724
Min	.724
Avg	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 310 / 22 KV Hingangoan Ag.

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.5335
Max	.5335
Min	.5335
Avg	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 801 / SONA ALLOYS

Feeder KV- 220 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	5.2812
Max	5.2812
Min	5.2812
Avg	5.2812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 301 / 22 KV SOMANTHALI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4115	.3086	.6478	.4115	.6173	.5716
2	.4801	.3772	.3086	.6097	.4115	.6173	.5335
3	.4458	.3772	.3086	.5716	.4115	.6173	.4954
4	.5144	.3772	.3429	.5716	.4458	.6173	.5335
5	.5144	.4115	.3429	.5716	.4458	.6173	.5716
6	.4801	.5144	.4458	.6859	.4801	.6173	.6478
7	.4115	.583	.4458	.6478	.5487	.6516	.6859
8	.4458	.4801	.4115	.6097	.4458	.6173	.4954
9	.4115	.5144	.5487	.6859		.6173	.4572
10	.583	.6859	.5487	.6478	.8383	.7202	.4954
11	.6859	.4954	.5487	.6173	.9145	.7202	.583
12	.6173	.5716	.6516	.4801	.2667	.7888	.4801
13	.5144	.4191	.6173	.4801	.6859	.7545	.4801
14	.5144	.4191	.583	.4115	.6859	.7202	.4801
15	.4801	.4572	.583	.3772	.6478	.6173	.4458
16	.5144	.4572	.583	.3772	.724	.5487	.4458
17	.5144	.7621	.583	.3772	.6097	.5144	.4458
18	.4801	.583	.4801	.4458	.6516	.583	.4801
19	.5144	.4458	.7621	.4458	.6516	.724	.5144
20	.5487	.6173	.7621	.6516	.7202	.6859	.583
21	.6173	.6173	.8383	.6516	.8573	.7621	.6173
22	.5487	.583	.8764	.6516	.8573	.8383	.6859
23	.5487	.3772	.7621	.583	.7545	.7621	.6173
24	.4458	.4458	.3772	.6097	.4801	.7202	.6097
Max	.6859	.7621	.8764	.6859	.9145	.8383	.6859
Min	.4115	.3772	.3086	.3772	.2667	.5144	.4458
Avg	.5130	.4993	.5425	.5587	.6064	.6687	.5398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 302 / 22 KV KAMBALESHWAR

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	.1372	.2058	.2667	1.8595	2.1948	2.2862
2	2.0576	.1715	.2058	.2286	1.8595	2.1605	
3	2.0576	.1715	.2058	.2286	1.89	2.1605	2.2481
4	2.1262	.1715	.2743	.2667	1.9509	2.1605	2.2862
5	2.1948	.2401	.3429	.3429	2.0729	2.2634	2.3243
6	2.2977	.3086	.4115	.4191		2.4006	2.4768
7	2.6406	.3772	.4458	.4954	2.4996	2.6063	2.7816
8	.3429	.3772	.3772	.381	.3429	.3429	.4191
9	.2401	.2743	.2058	.3429	.3086	.2401	.2667
10	.2058	.2667		.2667	.2667	.2058	.2286
11	.2058	3.658	3.2922	3.2236	.2667	.1715	.1715
12	.2058	4.0009	3.4294	3.2579	.1524	.1715	.2058
13	4.7325	3.658	3.4294	3.2579	.1524	.1715	.2058
14	.2058	3.6199	2.8464	3.2922	.1524	.1715	.1715
15	.1029	3.4294	3.0178	3.155	.1905	.2058	.2401
16	.1372	3.5437	3.0178	3.0864	.2286	.2401	.2401
17	.2401	3.4294	2.7778	3.0178	.2286	.2401	
18	.2743	2.8807	2.7435	2.8807	.2401	.3086	.3086
19	.3429	.3086	.381	.4115	.3086	.381	.4115
20	.3086	.3429	.381	.4115	.3772	.381	.3772
21	.3086	.3086		.3429	.3429	.3429	.3429
22	2.0576	.2401	.3048	.2743	2.2634	2.2481	1.8595
23	1.989	.2058	.2667	.2743	2.2977	2.3624	1.829
24	2.0576	1.9547	.2058	.2667	.2401	2.2977	2.3243
Max	4.7325	4.0009	3.4294	3.2922	2.4996	2.6063	2.7816
Min	.1029	.1372	.2058	.2286	.1524	.1715	.1715
Avg	1.2246	1.4199	1.3077	1.2663	.8910	1.1012	1.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 303 / 22 KV SASTEWADI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	2.0576	2.7435	2.8197	.4458	.5144	.4954
2	.4115	2.0576	2.8807	2.7816	.4458	.5144	.4572
3	.4115	2.0576	3.0864	2.6673	.4458	.4801	.4572
4	.4801	2.0919	3.2922	2.6673	.4801	.4801	.4954
5	.5487	2.2977	3.4637	2.8197	.5487	.5487	.5335
6	.6173	2.6749	3.4637	3.315	.6173	.6516	.724
7	.7202	3.6694	4.6296	4.0771	.6859	.7202	.8002
8	.6516	.6516	.6516	.6859	.583	.6173	.6859
9	.4458	.5144	.4458	.5335	.5144	.4458	.5335
10	.4115	.4954	.4115	.5335	.4572	4.7325	.4954
11	3.155	.4572	.4115	.4458	4.9154		4.5953
12	4.5268	.4954	.4115	.3429		4.4582	4.5953
13		.4954	.4115	.4115	4.8392	4.8697	4.4925
14	4.6296	.4572		.3429	4.8011	4.5268	4.321
15	4.6639	.4572	.3429	.3772	5.0297	4.5268	4.4239
16	4.5953	.4954	.4115	.3772	4.9535	4.4925	4.561
17	4.2524	.5335	.4115	.4801	4.8773	4.2181	4.1495
18	3.6694	.5487	.4458	.4801	4.1495	3.4141	2.5606
19	.6173	.583	.6859	.6859	.5144	.6478	.7202
20	.6516	.6859	.8002	.6859	.7202	.7621	.7545
21	.6516	.6173	.7621	.6097	.7202	.724	.7202
22	.583	2.6406	3.2007	2.1948	.6516	.6859	.6859
23	.4801	2.572	3.0483	2.0729	.5487	.5716	.583
24	.4115	.4458	2.572	2.8578	2.2291	.5144	.5335
Max	4.6639	3.6694	4.6296	4.0771	5.0297	4.8697	4.5953
Min	.4115	.4458	.3429	.3429	.4458	.4458	.4572
Avg	1.6521	1.2522	1.6950	1.4694	1.9206	1.9181	1.8073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 304 / 22 KV SANGAVI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2286	1.3413	1.9204	2.21
2	.2058	.2058	.2058	.2286	1.3413	1.9204	2.21
3	.2058	.2058	.2058	.2286	1.3413	1.989	2.2481
4	.2743	.2058	.2743	.2667	1.5242	2.0576	2.3243
5	.3429	.2743	.2743	.3048	1.768	2.2634	2.4387
6	.4115	.4115	.4801	.4572	2.0119	2.7435	2.8959
7	.4115	.5487	.5487	.5716	2.5606	3.155	3.1245
8	.583	.5487	.4801	.4954	.4801	.4801	.4954
9	.3772	.4115	.3429	.381	.3772	.3429	.3429
10		.381	.3429	.2667	.3048	.2743	.3429
11		3.8866	3.7037	3.3608	.2286	.2058	.2058
12		4.1152	3.5665	3.4294	.2667	.2401	.2058
13		3.5818	3.4294	3.4294	.1905	.2058	
14		3.5818	2.8807	3.0178	.2286	.2058	.2058
15		3.8104	2.332	3.0178	.2286	.2058	.2058
16		3.6961	3.155	2.8807	.3048	.2401	.2058
17	.2743	3.5056	2.8121	2.8807	.2667	.2743	.2743
18	.4801		2.5377	2.6063	.2743	.2743	.2743
19	.5487	.4801	.4572	.4115	.4115	.4572	.4115
20	.4115	.4801	.4191	.4115	.4115	.4572	.4115
21	.4115	.3429	.381	.3772	.3429	.4191	.3429
22	1.9204	.2743	.3048	.2743	2.0576	2.553	1.829
23	1.8519	.2058	.2667		2.0576	2.4387	1.989
24	.2058	1.7147	.2058	.2286	.2401	1.9204	2.3243
Max	1.9204	4.1152	3.7037	3.4294	2.5606	3.155	3.1245
Min	.2058	.2058	.2058	.2286	.1905	.2058	.2058
Avg	.5366	1.4380	1.2422	1.2937	.8567	1.1352	1.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 305 / 22 KV SOMANTHALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	1.0288	1.4403	1.4861	.3086	.3429	.381
2	.2743	1.0974	1.6461	1.448	.3086	.3429	.381
3	.2743	1.0974	1.7147	1.448	.3086	.3429	.381
4	.3429	1.0974	1.8519	1.4861	.3429	.3429	.4191
5	.4115	1.2346	1.989	1.6004	.4115	.4115	.4572
6	.4801	1.5089	2.0576	1.9433	.5144	.5487	.3048
7		1.8519	2.1948	2.4768	.583	.5487	.6859
8		.4801	.4801	.5335	.4801	.4801	.5335
9	.3772	.3429	.3429	.4572	.3772	.3429	.4191
10	.3772	.381	.2743	.381	.381	.3429	
11	2.4006	.3429	.2743	.3429	2.7054	2.2634	2.4006
12		.3429	.2743	.3429	2.6673	2.2634	2.332
13	2.1262	.3048	.2743	.2743	2.4387	2.2291	
14	2.1262	.3048	.2401	.2743	2.7054	2.1262	2.2634
15	2.1262	.3429	.2743	.2743	2.6673	2.1262	2.2634
16	2.0576	.3429	.2743	.3429	2.5911	2.1948	2.2634
17	1.989		.3086	.3429	2.4006	2.0576	2.1948
18	1.7147	.3429	.3429	.3429	2.1262	1.9204	1.7071
19	.4801	.4801	.5716	.4801	.5487	.5716	.5487
20	.4115	.4801	.4954	.4801	.4801	.6097	.5144
21	.4115	.4115	.4191	.4115	.4801	.5335	.4801
22	.3429	1.3032	1.6385	1.2803	.4115	.4954	.4801
23	.2743	1.2346	1.5623	1.2193	.3429	.4191	.4115
24	.2743	.2743	1.2346	1.5242	1.1584	.3429	.4191
Max	2.4006	1.8519	2.1948	2.4768	2.7054	2.2634	2.4006
Min	.2743	.2743	.2401	.2743	.3086	.3429	.3048
Avg	.9308	.7230	.9240	.8831	1.1558	1.0083	1.0110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 306 / 22 KV somawar peth

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
12		.1029
23	.2058	
Max	.2058	.1029
Min	.2058	.1029
Avg	.2058	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 401 / 33KV Maharashtra Food
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2058	.2058	.2286	.2058	.2058	.1715
2	.1029	.1543	.2058	.2286	.1543	.2058	.1715
3	.1543	.1543	.1029	.1715	.1029	.2058	.1715
4	.1029	.1029	.1029	.1143	.1029	.2058	.1715
5	.1029	.1029	.1029	.1143	.1029	.1029	.1143
6	.1029	.1029	.1029	.1143	.1029	.1029	.1143
7	.1029	.1029	.1029	.1143		.1029	.1143
8	.1029	.1543	.1543	.1143		.1029	.1143
9	.1029	.1029	.1029	.1143	.1029	.1029	.1143
10	.1029	.1143	.1543	.1715	.1143	.1029	.1143
11	.1029	.1143	.1543	.1543	.2286	.1029	.1029
12	.1029	.1715	.1029	.1029	.1143	.1029	.1029
13	.1029	.1143	.1029	.1029	.1143	.1029	.1029
14	.1029	.1143	.1029	.1029	.1143	.1029	.1029
15	.1029	.1143	.1543	.1543	.2286	.1029	.1029
16	.1029	.1143	.1029	.1543	.2286	.1029	.1029
17	.1029	.1143	.1029	.1543	.1715	.1029	.1029
18	.1029		.1029	.2572	.1029	.1029	.1029
19	.1543	.1029	.1143	.2572	.1543	.1143	.1029
20	.2058	.1029	.1143	.1029	.1543	.1143	.1543
21	.1543	.1029	.1143	.1029	.1029	.1143	.1543
22	.2572	.1029	.1715	.1029	.1543	.1143	.2058
23	.2572	.2058	.1715		.1543	.1715	.1543
24	.1029	.2058	.1543	.1715	.2058	.1543	.1715
Max	.2572	.2058	.2058	.2572	.2286	.2058	.2058
Min	.1029	.1029	.1029	.1029	.1029	.1029	.1029
Avg	.1286	.1295	.1293	.1481	.1463	.1270	.1308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 300 / Auxilliary Supply

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 301 / 22KV PHALTAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 302 / 22KV Y. C. HIGHSCHOOL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 303 / 22 KV SAINAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 305 / 22 KV MORAYA MILK FEEDER
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 401 / 33KV Surwadi

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 301 / SAKHARWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 303 / NIMBHORE AG FEEDER

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 304 / WATHAR -NIMBLAK- AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 305 / SWARAJ EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5716	.8383	.8002	.8002	.5335	.8002
2	.6859	.5716	.6859	.7621	.8002	.5716	.724
3	.6859	.5716	.6859	.6859	.6859	.5335	.8002
4	.6097	.5335	.724	.724	.7621	.4954	.8002
5	.6859	.4954	.7621	.724	.724	.4954	.8383
6	.6859	.5335	.7621	.5716	.724	.5335	.7621
7	.7621	.5335	.7621	.4572	.724	.4954	.7621
8	.6097	.4191	.7621	.3429	.724	.4954	.724
9	.6859	.3048	.7621	.4572	.8002	.5716	.7621
10	.6478	.3429	.8764	.3429	.381	.5716	.7621
11	.6859	.381	.6859	.2286	.8002	.5716	.7621
12	.4191	.3048	.6097	.3048	.6097	.5335	.6478
13	.4191	.3429	.6478	.381	.381	.5335	.724
14	.381	.3048	.6097	.5335	.3429	.3429	.6097
15	.381	.2286	.6097	.5716	.381	.3048	
16	.381	.2286	.4572	.6859	.4572	.381	
17	.3048	.2286	.4191	.6859	.381	.3048	
18	.3429	.3048	.3429	.6478	.3429	.2667	
19	.3429	.5716	.381	.6478	.381	.381	
20	.4191	.6859	.4572	.6478	.381	.6859	
21	.4191	.6478	.381	.7621	.4191		
22	.5716	.8383	.5335	.8383	.4191		
23	.4572	.8383	.5335	.6478	.5335	.7621	
24	.4572	.6478	.8383	.6097	.8383	.5335	.7621
Max	.7621	.8383	.8764	.8383	.8383	.7621	.8383
Min	.3048	.2286	.3429	.2286	.3429	.2667	.6097
Avg	.5335	.4763	.6303	.5859	.5747	.4954	.7494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 307 / 22 KV SAKHARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.6478	.6859	.6173
2	.6097	.6173	.6097	.6097	.5487
3	.5716	.6516	.6478	.6097	.5487
4	.6859	.6516	.6478	.724	.6516
5	.8383	.7202	.7621	.8002	.7545
6	1.0288	.9602	.9335	.9145	.9945
7	1.0669	1.166	.9979	1.0669	1.0288
8	1.0288	.9945		.8764	.9259
9	.9145	1.0669	.8002	.7545	.9145
10	.8962	.9526	.8573	.6516	.8764
11	.8215	.9526	.7888	.6859	.8764
12	.724	.8002	.7888	.7202	.9145
13	.724	.9526	.7888	.6859	.9145
14	.8215	.8764	.7888	.6859	.9145
15	.8215	.8764	.7888	.6859	.9526
16	.8676	.9526	.7888	.6516	
17	.8764	.9526	.823	.7202	
18	.8764	.9907	.823	.7545	
19	1.0288	.9907	.9945	.9259	
20	.8916	1.105	1.0669	.9945	
21	.8916	.9907	1.0669	.9945	
22	.823	.9145	.9907	.8916	
23	.6859	.7621	.8002	.7888	
24	.6478	.6173	.6478	.724	.6859
Max	1.0669	1.166	1.0669	1.0669	1.0288
Min	.5716	.5144	.6097	.6097	.5487
Avg	.8262	.8762	.8196	.7751	.8200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 308 / 22 KV NANDAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 309 / 22 KV NIMBHORE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 403 / cummines india limited

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4572	.4001	.4572	.2858	.3429	.4001
2	.4001	.4572	.4572	.4001	.2858	.4001	.3429
3	.4001	.4001	.4001	.4001	.2858	.3429	.4001
4	.4001	.4001	.4001	.4001	.2858	.3429	.3429
5	.4572	.4001	.4001	.4001	.2858	.4001	.4001
6	.5144	.4572	.4572	.4001	.3429	.4001	.4572
7	.5716	.5716	.5716	.4572	.4572	.4572	.5144
8	.5144	.5144	.5144	.3429	.5144	.4572	.4572
9	.5144	.5716	.4572	.3429	.4572	.5144	.5144
10	.5716	.5144	.5144	.2858	.4572	.4572	.4572
11	.5716	.4572	.4572	.2286	.4001	.4572	.5716
12	.4001	.4001	.3429	.2286	.3429	.4572	.4572
13	.4572	.5716	.4001	.2286	.2858	.5144	.4572
14	.4572	.5144	.4572	.2286	.3429	.4001	.5716
15	.4572	.5716	.5144	.2858	.4001	.4572	.5144
16	.6287	.5716	.5716	.4001	.5716	.5716	.6287
17	.6287	.6287	.5716	.4001	.4572	.6287	.8002
18	.5144	.5144	.5716	.4572	.4001	.4572	.6287
19	.5144	.5144	.6859	.4572	.4001	.5716	.6287
20	.4572	.5144	.6287	.5144	.4001	.5716	.5716
21	.4572	.4572	.5144	.5144	.4001	.5144	.5716
22	.5144	.4001	.5144	.4001	.4001	.5144	.5716
23	.4001	.4572	.5144	.2858	.4001	.4572	.5144
24	.4001	.4001	.4572	.4572	.2858	.4001	.4001
Max	.6287	.6287	.6859	.5144	.5716	.6287	.8002
Min	.4001	.4001	.3429	.2286	.2858	.3429	.3429
Avg	.4834	.4882	.4906	.3739	.3810	.4620	.5073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 404 / tata cumines ltd

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.2003	1.2574	1.7147	1.2003	1.6004	1.6004
2	1.1431	1.2574	1.2574	1.2003	1.0288	1.5432	1.5432
3	1.0288	1.1431	1.2003	1.1431	.9145	1.2574	1.2574
4	1.086	1.3146	1.1431	1.086	.8573	1.4289	1.3717
5	1.1431	1.2574	1.2003	1.086	.8573	1.2574	1.3146
6	1.2003	1.2574	1.2574	1.2003	1.086	1.3146	1.2003
7	1.2574	1.3146	1.2574	1.2574	1.2003	1.3146	1.3717
8	1.2574	1.1431	1.2003	1.0288	1.4861	1.5432	1.6575
9	1.2003	1.2574	1.2574	1.0288	1.7718	1.6004	1.6004
10	1.6575	1.3146	1.2574	1.086	1.6004	1.6004	1.6575
11	1.5432	1.6575	1.7147	1.4861	1.6004	1.6575	1.7147
12	1.7147	1.7147	1.7147	1.4289	1.7147	1.5432	1.6575
13	1.6575	1.6004	1.6575	1.4289	1.6004	1.4861	1.4861
14	1.5432	1.6004	1.6004	1.3146	1.6004	1.5432	1.6575
15	1.7147	1.6004	1.6575	1.2003	1.4289	1.6575	1.7718
16	1.7147	1.7718	1.829	1.1431	1.5432	1.6004	1.6575
17	1.6575	1.4861	1.6004	1.2003	1.5432	1.5432	1.7147
18	1.6575	1.829	1.5432	1.2003	1.6575	1.7147	1.6575
19	1.6575	1.6004	1.7147	1.2574	1.6575	1.6004	1.6575
20	1.829	1.6575	1.7147	1.2574	1.6575	1.7147	1.7147
21	1.6575	1.6575	1.5432	1.0288	1.4861	1.6575	1.6575
22	1.6575	1.4861	1.3146	.9145	1.7147	1.6575	1.7147
23	1.7718	1.1431	1.6004	1.2574	1.6004	1.6575	1.7147
24	1.6575	1.7718	1.1431	1.7147	1.2574	1.7147	1.6004
Max	1.829	1.829	1.829	1.7147	1.7718	1.7147	1.7718
Min	1.0288	1.1431	1.1431	.9145	.8573	1.2574	1.2003
Avg	1.4860	1.4599	1.4432	1.2360	1.4194	1.5504	1.5813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 301 / 22KV BARAD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.1886	.1509	.1886	.9431	1.3957	1.3203
2	1.1317	.1886	.1509	.1509	.9431	1.3203	1.2826
3	1.1317	.1886	.1509	.1886	.9431	1.3203	1.2449
4	1.2826	.2263	.1886	.1886	1.094	1.5466	1.1694
5	1.4335	.2263	.2641	.2263	1.2826	1.6598	1.6221
6	1.5466	.2263	.3018	.2641	1.4712	1.8861	2.4143
7	2.4143	.3018	.3772	.3018	1.9616	2.4143	2.5274
8	.3018	.2263	.3395	.2641	.3018	.2641	.3395
9	.2263	.2263	.2641	.1886	.1886	.2263	.1886
10	.1886	.2641	.2263	.1509	.1509	.1886	.1886
11	.1886	3.3196	2.8292	2.6029	.1509		.1509
12	.2263	3.2065	3.0178	.2905	.1886		.1509
13	.1886	3.0933	2.8669	2.1879	.1886	.1886	.1509
14	.1886		2.6029	2.2257	.1886	.1886	.1886
15	.1886		2.5274	2.3011	.1886	.2263	.1886
16	.1886	3.2442	.1886	2.6029	.1886	.1886	.2263
17	.2641	2.9047	2.2257	2.1502	.1886	.1886	.1886
18	.1886	2.2634	1.9616	1.358	.1509	.1886	.1886
19	.2263	.3018	.3018	.2641	.2641	.3772	.3018
20	.2263	.3018	.3018	.3018	.2641	.3772	.3395
21	.2641	.3018	.2263	.2263	.2263	.3395	.3018
22	1.1694	.2263	.1886	.1886	1.5089	1.7353	1.3957
23	1.1694	.1886	.1886	.1886	1.6598	1.5089	1.7353
24	.8573	1.1317	.1886	.1886	.1509	1.5089	1.358
Max	2.4143	3.3196	3.0178	2.6029	1.9616	2.4143	2.5274
Min	.1886	.1886	.1509	.1509	.1509	.1886	.1509
Avg	.6802	1.0340	.9179	.7996	.6161	.8745	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 302 / MUNJAWADI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 303 / ANDHRUD AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 304 / Barad Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4904	.415	.415	.4904	.415	.5281
2	.4904	.415	.3772	.415	.4904	.415	.5281
3	.4904	.415	.3772	.415	.4904	.415	.5281
4	.6413	.4904	.415	.5658	.6036	.5281	.5658
5	.7922	.5658	.5658	.7545	.7545	.679	.7545
6	.9808	.6413	.9808	.9054	.8676	.7922	.9808
7	1.1694	1.094	.9808	.8676	.9431	.9054	.9808
8	.9431	1.0185	.7545	.7922	.7545	.7545	.7922
9	.7922	.6036	.5658	.679	.5658	.6036	.6413
10	.6413	.6036	.4904	.6413	.5281	.5281	.6413
11	.6036	.6036	.4527	.6036	.5281		.5658
12	.5658	.5658	.4527	.5281	.5281		
13	.5281	.4527	.415	.4527		.5658	.5281
14	.5281	.415	.415	.4527	.4904	.4904	.4527
15	.5658	.415		.4527	.4904	.3018	.4904
16	.5281	.415	.4527	.4904	.5281	.4527	.5281
17	.5281	.4904	.5281	.5281		.679	.5658
18	.6413	.6036	.5281	.5658	.5281	.6413	.679
19	.9808	.7922	.7922	.8676	.7545	.9054	.8299
20	.8676	.7545	.8299	.8299	.7922	.8676	.8299
21	.7922	.679	.7545	.7545	.7167	.8299	.7545
22	.7922	.6036	.6413	.679	.6413	.7922	.7167
23		.4904	.5281	.5658	.4904	.6413	.6036
24		.5658	.4527	.4904	.4904	.4527	.5658
Max	1.1694	1.094	.9808	.9054	.9431	.9054	.9808
Min	.4904	.415	.3772	.415	.4904	.3018	.4527
Avg	.6979	.5910	.5724	.6130	.6121	.6207	.6544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 305 / 22 KV GUNAWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5658	.5281	.6036	.5658	.5658	.5658
2	.4904	.4527	.4904	.5281	.5658	.4904	.5658
3	.4904	.4527	.5281	.4527	.5658	.4904	.5658
4	.679	.6036	.6036	.679	.679	.6413	.7167
5	.8299	.7922	.7922	.9054	.8299	.7922	.9054
6	1.0185	.9808	1.0562	1.1694	.9808	.9808	1.1317
7	1.094	1.0562	1.1694	1.1694	1.0562	1.0562	1.2449
8	.9808	1.0185	1.0562	1.0562	.9054	.9808	1.094
9	.8299	.8299	.7922	.9054	.7167	.7167	.8299
10	.7167	.7545	.6036	.7167	.6036	.6413	.7545
11	.7167	.6413	.6413	.6413	.5281		.6036
12	.6413	.6413	.5658	.6036	.5281		
13	.4904	.5658	.5281	.4904		.6413	.4904
14	.6036	.5281	.4904	.4904	.4527	.5281	.4527
15	.6413	.5658	.5658	.5281	.4527	.415	.4904
16	.6413	.5658	.5281	.4527	.4904	.5658	.4904
17	.6036	.5658	.5658	.4904		.5658	.5658
18	.5658	.7167	.5658	.6413	.5658	.679	.679
19	.9431	1.0562	1.0562	1.0562	.8676	1.0562	1.0185
20	.9431	1.0185	1.1317	1.0185	1.0562	1.0562	1.0562
21	.8676	.9054	.9431	.8676	.9054	.9431	.9054
22	.7167	.7545	.7922	.7545	.7545	.7922	.7922
23	.6036	.6036	.6413	.679	.6036	.679	.679
24	.4904	.5658	.5658	.6413	.6036	.6036	.6036
Max	1.094	1.0562	1.1694	1.1694	1.0562	1.0562	1.2449
Min	.4904	.4527	.4904	.4527	.4527	.415	.4527
Avg	.7120	.7167	.7167	.7309	.6944	.7219	.7479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 306 / 22 KV RAJURI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1132	.1132	.1509
2	.1132	.0754	.0754	.0754	.1132	.0754	.1132
3	.1132	.1132	.0754	.1132	.1132	.0754	.1132
4	.1509	.1509	.1132	.1509	.1509	.1509	.1509
5	.1886	.1886	.1886	.1509	.1886	.1886	.1886
6	.1886	.2263	.2263	.2263	.2641	.2263	.2641
7	.2263	.2641	.2641	.2641	.2641	.2641	.2641
8	.2263	.2263	.2263	.2263	.2263	.2263	.2263
9	.1509	.1886	.1886	.1886	.1509	.1886	.1509
10	.1509	.1886	.1509	.1886	.1132	.1886	.1509
11	.1509	.1886	.1886	.1509	.1132	.1132	.1886
12	.1886	.1886	.1886	.1509	.1132		
13	.1509	.1509	.1509	.1509		.1509	.1509
14	.1509	.1509	.1509	.1132	.1132	.1509	.1509
15	.1132	.1132	.1509	.1509		.1509	.1509
16	.1509	.1132	.1509	.1132	.1509	.1886	.1132
17	.1886	.1132	.1509	.1509		.1509	.1509
18	.1509	.1132	.1886	.1509	.1509	.1509	.1509
19	.2263	.2263	.3018	.2263	.2263	.2641	.2263
20	.2263	.1886	.1886	.1886	.2641	.2641	.2263
21	.1509	.1886	.1509	.1886	.1886	.1509	.2263
22	.1509	.1886	.1509	.1886	.1509	.1886	.1886
23	.1509	.1509	.1509	.1509	.1509	.1886	.1509
24	.1132	.1132	.1509	.1132	.1509	.1132	.1509
Max	.2263	.2641	.3018	.2641	.2641	.2641	.2641
Min	.1132	.0754	.0754	.0754	.1132	.0754	.1132
Avg	.1619	.1635	.1682	.1619	.1653	.1706	.1739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 KV BARAD

Feeder No / Name : 307 / 22 KV Nimblak AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 301 / ADARKI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0732	.0343	.0686
2		.0686	.0366	.0343
3		.0732	.0373	.0686
4		.0732	.0358	.0686
5		.1463	.0358	.1029
6		.1097	.0732	.1372
7		.1715	.037	.1715
8		.0732	.037	.1029
9		.0366	.037	.1029
10		.1029	.1715	.1029
11		2.0405	1.9547	1.6956
12		2.0729	2.0576	1.9448
13		2.1052	2.0576	2.0348
14		1.9757	2.0576	1.9784
15		1.9433	2.0576	1.643
16		1.9109	2.0919	2.0008
17		1.3927	1.5432	1.933
18		1.3279	1.4403	1.5424
19		.1463	.1372	.0686
20		.0686	.1715	.0686
21		.1463	.1372	.0686
22			.1372	.1715
23		.0686	.1029	.1372
24	.8573	.8745	.0732	.0686
Max	.8573	2.1052	2.0919	2.0348
Min	.8573	.0366	.0343	.0343
Avg	.8573	.7392	.6898	.6798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 302 / BIBI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.037	.7209	.8573
2		.037	.7209	.8573
3		.5304	.7209	.8916
4		.5636	.7537	.9259
5		.7293	.852	.9945
6		.8951	.9831	1.0974
7		1.0608	1.0814	.9602
8		.037	.0373	.0343
9		.037	.0373	.0343
10		.037	.0343	.0343
11		.037	.0343	.0343
12		.037	.0343	.0343
13		.0358	.0343	.0343
14		.037	.0373	.0343
15		.037	.0343	.0343
16		.037	.0343	.0343
17		.037	.0343	.0343
18		.037	.0343	.0343
19		.0366	.0343	.0343
20		.037	.0343	.0343
21		.0373	.0343	.0343
22		.0358	.823	.7461
23		.7865	.8573	.9724
24	.8573	.037	.7537	.9259
Max	.8573	1.0608	1.0814	1.0974
Min	.8573	.0358	.0343	.0343
Avg	.8573	.2179	.3648	.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 303 / MULIKWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2984	.3315	.3429
2		.2652	.3315	.3429
3		.2652	.3315	.3429
4		.2984	.3647	.3772
5		.3315	.3978	.4115
6		.4641	.5304	.4801
7		.663	.6962	.6859
8		.0373	.037	.0343
9		.0373	.037	.0343
10		.037	.0343	.0343
11		.0373	.0343	.0343
12		.0373	.0343	.0343
13		.0373	.0343	.0343
14		.0373	.0343	.0343
15		.0373	.0343	.0343
16		.0373	.0343	.0343
17		.0358	.0343	.0343
18		.0358	.0343	.0343
19		.0358	.0373	.0343
20		.0373	.0343	.0343
21		.0373	.0343	.0343
22		.3315	.4115	.3353
23		.3315	.3772	.373
24	.8573	.0373	.3315	.3429
Max	.8573	.663	.6962	.6859
Min	.8573	.0358	.0343	.0343
Avg	.8573	.1585	.1914	.1881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 304 / ADARKI GOANTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715
2		.1372	.1715
3		.1372	.1715
4		.1715	.1715
5		.1715	.1715
6		.1715	.2058
7		.2401	.2401
8		.2743	.2401
9		.2743	.2401
10		.2743	.2743
11		.3086	.3086
12		.2058	.2743
13		.1715	.2058
14		.1715	.2401
15		.1715	.2743
16		.1372	.2401
17		.2058	.2058
18		.2401	.3086
19		.3429	.3429
20		.3086	.3429
21		.2743	.3086
22		.2401	.2743
23		.2401	.2743
24	.0686	.1715	.2058
Max	.0686	.3429	.3429
Min	.0686	.1372	.1715
Avg	.0686	.2172	.2443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 305 / BIBI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0366	.0343	.0343
2	.0343	.0343	.0358	.0343	.0343
3	.0343	.0343	.0358	.0343	.0343
4	.0343	.0343	.0347	.0343	.0343
5	.0343	.0343	.0347	.0343	.0343
6	.0343	.0343	.0358	.0343	.0343
7	.0343	.0343	.0347	.0343	.0343
8	.0343	.0343	.0347	.0343	.0343
9	.0343	.0358	.0347	.0343	.0343
10	.0343	.0358	.0343	.0343	.0343
11	.0343	.0358	.0343	.0343	.0343
12	.0343	.032	.0343	.0343	.0343
13	.0343	.0354	.0343	.0343	.0343
14	.0343	.0351	.0343	.0343	.0343
15	.0343	.0358	.0343	.0343	
16	.0343	.0358		.0343	
17	.0343	.0347		.0343	
18	.0343	.0358		.0343	
19	.0343	.0358		.0343	
20	.0343	.0351		.0343	
21	.0343	.0351		.0343	
22	.0343	.0347		.0343	
23	.0343	.0358		.0343	.0343
24	.0343	.0343	.0358	.0343	.0343
Max	.0343	.0358	.0366	.0343	.0343
Min	.0343	.032	.0343	.0343	.0343
Avg	.0343	.0349	.0349	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 306 / Siddhivinayak Bio-Energy NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0037	.0037	.0343	.0343
2		.0037	.0037	.0343	.0343
3		.0037	.0037	.0343	.0343
4		.0037	.0037	.0343	.0343
5		.0037	.0037	.0343	.0343
6		.0037	.0034	.0343	.0343
7		.0037	.0037	.0343	.0343
8		.0037	.0034	.0343	.0343
9		.0037	.0034	.0343	.0343
10				.0343	.0343
11		.0037		.0343	.0343
12		.0037		.0343	.0343
13		.0037		.0343	.0343
14		.0037		.0343	.0343
15		.0037		.0343	.0343
16		.0037		.0343	.0343
17		.0037		.0343	.0343
18		.0037		.0343	.0343
19		.0037		.0343	.0343
20		.0037		.0343	.0343
21		.0037		.0343	.0343
22		.0037		.0343	.0343
23		.0037		.0343	.0343
24	.0686	.0037	.0037	.0343	.0343
Max	.0686	.0037	.0037	.0343	.0343
Min	.0686	.0037	.0034	.0343	.0343
Avg	.0686	.0037	.0036	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 301 / GOKHALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 302 / ASU AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 303 / 22 KV GOKHALI GAOTHAN
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 304 / 22 KV ASU GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 305 / 22 KV Sarade AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5699	.1753	.1981		1.4708	1.749
2	1.6118	.1715	.202	.1943	1.6156	1.7223
3	1.6194	.1753	.1943	.1905	1.8747	1.7642
4	1.7375	.202	.1943	.2096	1.9319	1.9585
5	1.9243	.3277	.3125		2.5758	2.2824
6	2.2558	.381	.3849	.3239	2.5758	2.4882
7	2.8807	.381	.4572	.4344	2.6673	2.6254
8	.4344	.3963	.3201	.3506		.3696
9	.3048	.2743	.2667	.2439		.2591
10	.3353			.2058	.2134	.2096
11		3.5056		3.3455	.1905	.1486
12		3.7799	***	3.4294	.1677	.1753
13		3.094		3.1779	.2058	.1981
14		3.5894		3.1093	.1905	.16
15		3.3913		3.0102	.2134	.2058
16		3.5513		2.9797		.1524
17		3.2998		2.5606		
18		2.8959		2.5987		
19		.3582		.381		
20				.3734		
21		.3125		.4039		
22		.2058		.3391		
23		.1981		.2896		
24	1.7299	1.7299	.2134	.2439	.2439	1.8138
Max	2.8807	3.7799	35.8178	3.4294	2.6673	2.6254
Min	.3048	.1715	.1943	.1905	.1677	.1486
Avg	1.4913	1.4726	3.5056	1.2907	1.1527	1.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 301 / Wathar- N Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 302 / Upalwe Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 303 / Tathawada Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 304 / Wathar-N Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2641
2	.1886	.2263	.2641
3	.1886	.2263	.2641
4	.1886	.2263	.2641
5	.2641	.3018	.2641
6		.3018	.3395
7	.3018	.3395	.3772
8	.2641	.3429	.3395
9	.2641	.3048	.2641
10	.2263	.381	.2641
11	.3018	.3395	.3018
12	.2641	.3395	.2641
13	.3772	.3395	.2641
14	.2641	.3395	.2641
15	.3018	.3395	.2641
16	.3018	.3395	.3018
17	.3018	.3395	
18	.2286	.2641	
19	.3429	.3772	
20	.381	.3395	
21	.3429	.3395	
22	.3395	.3018	
23	.3018	.2641	
24	.2263	.2641	.2641
Max	.381	.381	.3772
Min	.1886	.2263	.2641
Avg	.2761	.3085	.2841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 305 / Upalawe Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754
2	.0754	.0754	.0754
3	.0754	.0754	.0754
4	.0754	.0754	.0754
5	.0754	.0754	.0754
6	.1132	.1132	.1132
7	.1509	.1509	.1509
8	.1132	.1143	.1132
9	.1132	.1143	.0754
10	.1132	.0762	.0754
11	.0754	.0754	.1132
12	.0754	.0754	.1132
13	.0377	.0754	.0754
14	.0754	.0754	.1132
15	.0754	.0754	.1132
16	.1132	.0754	.0754
17	.0754	.0754	
18	.1143	.0754	
19	.1143	.1132	
20	.1143	.1132	
21	.1143	.1132	
22	.1132	.1132	
23	.0754	.0754	
24	.0754	.0754	.0754
Max	.1509	.1509	.1509
Min	.0377	.0754	.0754
Avg	.0929	.0897	.0932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 306 / Tathawada Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.132	.1132		.1509
2	.1132	.1132	.1132	.1283	.1132		.1509
3	.1132	.1132	.1132	.1283	.1132	.1509	.1509
4	.1132	.1132	.1132	.1962	.1509	.1886	.1886
5	.1509	.1509	.1509	.2527	.1886	.1886	.2263
6	.2641	.2641	.2263	.2829	.2263	.2641	.2641
7	.2641	.3018	.2641	.2867	.3395	.3018	.3395
8	.1886	.2667	.2641	.2829	.1886	.2263	.2641
9	.1886	.1905	.1886	.166	.1886	.1886	.2263
10	.1886	.1143	.1886	.1509	.1509	.1132	.2263
11	.1132	.1132	.1509	.1132	.1509	.1132	.0754
12	.1509	.1132	.1132	.1132	.1132	.1132	.1132
13	.1509	.1132	.1132	.1132	.1132	.1132	.0754
14	.1132	.1132	.1509	.0754	.1132	.1132	.1132
15	.1509	.1132	.1132	.0754	.1132	.1132	.1132
16	.1132	.1132	.1132	.0754	.1132	.1132	.0754
17	.1132	.1132	.1132	.0754	.1132	.1132	.1132
18	.1524	.1509	.1509			.1132	.1143
19	.1905	.2263	.2075	.1886	.2263	.3018	.2286
20	.2286	.2641	.215	.2263	.2641	.3018	.2286
21	.1905	.2263	.2112	.1886	.2641	.2641	.2286
22	.1886	.1886	.2075		.1886	.2263	.2263
23	.1509	.1132	.1999		.1509	.1886	.1886
24	.1132	.1132	.1132	.1509	.1132		.1509
Max	.2641	.3018	.2641	.2867	.3395	.3018	.3395
Min	.1132	.1132	.1132	.0754	.1132	.1132	.0754
Avg	.1591	.1590	.1629	.1620	.1657	.1814	.1764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 301 / 22 Kv Giravi Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 302 / 22 Kv Vinchurni Ag
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 303 / 22 Kv Giravi Gaothan
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
23	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 304 / 22 KV Wadale AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
1	1.0669
2	1.0669
3	1.1431
4	1.2574
5	1.3336
6	1.448
7	2.4006
8	.8002
9	.5335
10	.439
11	.3292
12	.3292
24	.9907
Max	2.4006
Min	.3292
Avg	1.0106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 305 / 22 KV Dudhebavi AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 306 / 22 KV Dudhebavi Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 301 / JANAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6868	.1728	.208	.2337	1.4019	1.754	1.754
2	1.6644	.1696	.208	.2305	1.4467	1.7444	1.7444
3	1.7028	.192	.2048	.2369	1.4979	1.7412	1.7284
4	1.754	.1984	.208	.2497	1.562	1.7444	1.738
5	1.8724	.2177	.2465	.2785	1.6548	1.834	1.7732
6	2.1989	.2689	.3265	.3489	1.7988	2.2917	2.2405
7	2.5798	.3841	.4449	.4673	1.8692	2.3909	2.3877
8	.3873	.3841	.4449	.4865	.3777	.4353	.4129
9	.3265	.3297	.2817	.3073	.3681	.3585	.3361
10	.2657		.2561	.3937	.3681	.3585	.3137
11	.3265	3.1463	3.1143	2.6534	.3553	.3073	.2657
12	.3169		3.1271		.3777	.1984	.2721
13		2.1189	2.7814	3.0343	.2433	.2241	.2497
14		2.1381		3.0439	.2337	.2433	.2656
15		2.823		2.647		.2369	.2881
16		2.9607	2.9639	2.6022		.2369	.2721
17		2.9959	2.6758	2.2757		.2337	.2529
18	.2817	2.7366	2.5478	2.1157		.2721	.2849
19	.3681	.3873	.3969	.3425	.3585	.3073	.3585
20	.3489	.3585	.4257	.3137	.3841	.3713	.3617
21	.3137	.3137	.3713	.3009	.3521	.3265	.3745
22	1.4787	.2625	.3169	.2753	1.7028	1.6932	1.9556
23	1.4339	.2305	.2433	.2305	1.7348	1.7956	1.9076
24	1.7316	1.4051	.2112	.2401	.2177	1.738	1.7604
Max	2.5798	3.1463	3.1271	3.0439	1.8692	2.3909	2.3877
Min	.2657	.1696	.2048	.2305	.2177	.1984	.2497
Avg	1.1073	1.0997	1.0002	1.0134	.9153	.9516	.9708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 302 / SATE PHATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2656	1.2955	1.5935	1.587	.2591	.3244	.2656
2	.2656	1.3085	1.5967	1.5806	.2623	.3206	.2591
3	.2688	1.3312	1.5935	1.6	.2688	.3169	.2623
4	.2753	1.3765	1.5967	1.6194	.2753	.3697	.2721
5	.298	1.4899	1.5935	1.6291	.3142	.3692	.3109
6	.4146	1.6615	1.7263	1.8559	.3984	.4437	.3951
7	.4696	1.9854	2.0178	2.0081	.4988	.4761	.4826
8	.421	.4308	.3887	.4161	.4275	.434	.4113
9	.3271	.3822	.3012	.3498	.3822	.2785	.3239
10	.2721	.3466	.2462	.2591	.2721	.2364	.2462
11	2.5554	.3304	.285	.2364	2.5619	2.3093	2.4615
12	2.6235	.3109	.3077	.2397	2.7498	2.4162	2.455
13	2.5716	.3174	.2623	.2688	2.6202	2.455	2.3158
14	2.5716	.2656	.2591	.2332	2.7141	2.5295	2.2931
15	2.4842	.2591		.1976	2.6073	2.5069	2.2186
16	2.3611	.2526	.2429	.2591	2.6299	2.3935	2.183
17	2.2478	.298	.3045	.2202	2.4032	2.2186	1.9886
18	1.8947	.285	.298	.3174	2.0502	1.9627	1.804
19	.3109	.353	.3498	.3628	.3498	.353	.3789
20	.2915	.3498	.3628	.3725	.3336	.3336	.3433
21	.2947	.3271	.3045	.3304	.3012	.3109	.3174
22	.2688	1.5611	1.6	1.4672	.2753	.2883	.2915
23	.2559	1.5903	1.5967	1.4478	.2721	.2721	.2785
24	.2462	.2397	1.5903	1.5935	1.3538	.2688	.2688
Max	2.6235	1.9854	2.0178	2.0081	2.7498	2.5295	2.4615
Min	.2462	.2397	.2429	.1976	.2591	.2364	.2462
Avg	1.0107	.7645	.8877	.8522	1.1075	1.0078	.9511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 303 / RAJALE GAON

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1811	.1886	.2791	.3018	.2716	.298	.3093
2	.1773	.1924	.2829	.3018	.2678	.2942	.3018
3	.1773	.177	.2942	.2867	.2829	.298	.3018
4	.1848	.215	.3357	.298	.3093	.3093	.3206
5	.2188	.2565	.381	.381	.3923	.3621	.3584
6	.3659	.3546	.5206	.4715	.5017	.513	.5206
7	.4187	.4602	.596	.5696	.5998	.5772	.43
8	.3697	.3508	.5545	.4979	.5168	.4489	.3244
9	.3659	.2942	.4942	.4753	.415	.3282	
10	.3169		.4263	.4074	.4225	.3621	.3018
11	.3584	.2867	.381	.3999	.4187	.3471	.3433
12	.3282	.2414	.3659	.3772	.3357	.2791	.3131
13	.3018	.1886	.2226	.3395	.2754	.2565	.2905
14	.3131	.1848	.3244	.3395	.2942	.2263	.332
15	.3659	.2075	.3735	.2623	.3697	.2678	.3056
16	.3244		.4074	.3304	.3621	.3206	.3357
17	.3131	.3471	.4112	.3885	.3546	.3961	.249
18	.3433	.415	.4414	.4036	.4074	.3961	.4112
19	.4414		.5017	.5243	.5394	.5093	.4979
20	.4036	.4979	.4829	.4979	.5772	.4866	.4979
21	.3433	.4753	.4376	.4527	.4942	.4187	.4979
22	.3018	.3848	.3659	.381	.3628	.3772	.3885
23	.2716	.3169	.3093	.3169	.3169	.3169	.3131
24	.1962	.2037	.2754	.3056	.2867	.2829	.3131
Max	.4414	.4979	.596	.5696	.5998	.5772	.5206
Min	.1773	.177	.2226	.2623	.2678	.2263	.249
Avg	.3076	.2971	.3944	.3879	.3906	.3613	.3590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 400 / Auxilary Supply

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 402 / 33 kv tata cumines ltd
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 405 / 33 kv cummins india ltd

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 406 / 33 KV CUMMINES Technology NON SHEDDABLE EXPRESS HV FEEDERS
indi Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 701 / 132 KV Sharayu Agro
Industries Feeder KV- 132 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
23	.4115
Max	.4115
Min	.4115
Avg	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 801 / SWARAJ INDIA AGRO LTD CO-
GEN Feeder KV- 220 / OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 201 / KATHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	.0572	.0686	.0152	1.9204	1.8679	1.5242
2	1.1736	.0572	.0686	.0152	1.9204	1.8351	1.4937
3	1.1584	.0762	.0686	.0152	1.8442	1.8023	1.4632
4	1.1431	.0762	.0686	.0152	1.7985	1.8023	1.448
5	1.1126	.0762	.0686	.0152	1.7528	2.0911	1.4022
6		.0762	.0686	.0152	1.8747	1.8679	1.3717
7		.0762	.0686	.0152	2.0881	2.0809	1.5851
8	1.1736	.0762	.0686	.0152	2.1338	2.1464	1.6461
9	1.2616	.0514	.061	.0191	2.1792	1.8595	1.8679
10	.0572	.12	.0762	.0381	.0381	.0457	.0381
11	.0762	3.1379	2.774	3.0639	.0381	.0457	.0762
12	.0191	3.2236	2.8197	3.1786	.0572	.0457	.0572
13	.0191	2.1776	2.774	2.6052	.0381	.0457	.0572
14	.0381	3.2407	2.4082	2.7854	.0381	.0305	.0381
15	.0572	2.2977	2.9569	2.8509	.0762	.0305	.0572
16	.0572	2.692	.6249	2.8182	.0381	.0305	.0572
17	.0762	2.7949	.5944	2.4844	.0381	.0305	.0762
18	.0762	2.2291	.5639	2.3167	.0572	.0305	.0572
19	.0762	.0857			.0762	.061	.0572
20	.0762	.0857	.0305	.0457	.0762	.061	.0762
21	.0762	.0857	.0305	.0457	.0572		.0762
22	.0762	.0857	.0305	.0457	.0572	.0457	.0762
23	.0572	.0686	.0305	.0305	.0762	.0305	.0762
24	3.0445	.0497	.0686	.0152	1.9509	1.8679	1.5546
Max	3.0445	3.2407	2.9569	3.1786	2.1792	2.1464	1.8679
Min	.0191	.0497	.0305	.0152	.0381	.0305	.0381
Avg	.5498	.9582	.7127	.9767	.8427	.8589	.6764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 202 / EKAMBE -SANGVI- AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	1.6057	1.7147	1.4784	.061	.0572	.061
2	.0457	1.5893	1.7318	1.4784	.061	.0572	.061
3	.0457	1.5565	1.6804	1.448	.061	.0492	.061
4	.0457	1.5565	1.6975	1.448	.061	.0762	.061
5	.061	1.5729	1.6632	1.448	.061	.0572	.061
6	.061	1.5893	1.7147	1.4175	.0762	.0762	.061
7	.0762	1.9662	2.0062	1.5242	.0762	.0762	.061
8	.0762	1.9989	2.2634	1.7528	.0762	.0762	.061
9	.0953	2.0405	1.829	1.8842	.0762	.061	.0762
10	.0572	.0686	.0457	.0572	.0953	.061	.0953
11	2.769	.0686	.0457	.0572	2.2939	2.1491	2.13
12	2.8018	.0686	.0457	.0572	2.5069	2.271	
13	2.6052	.0686	.0457	.0762	2.5888	2.271	2.3594
14	2.5396	.0514	.0457	.0762	2.4741	2.1186	2.0645
15	2.5888	.0514	.0457	.0762	2.4086	1.9662	2.0153
16	2.5396	.0514	.0457		2.3922	1.8747	3.8013
17	2.343	.0514	.0457	.061	2.1956	1.7833	2.1136
18	1.917	.0514	.0457	.0762	2.0481	1.6613	1.8351
19	.0762	.0686	.061	.0762	.0572	.0762	.0762
20	.0953	.0686	.061	.0914	.0572	.0762	.1143
21		.0686	.061	.0762	.0762		.0953
22	.0762	.0686	.061	.0762	.0762	.061	.0762
23	1.5497	.0686	.061	.061	.0762	.061	.0762
24	.0457	1.5497	1.8107	1.4632	.061	.0762	.061
Max	2.8018	2.0405	2.2634	1.8842	2.5888	2.271	3.8013
Min	.0457	.0514	.0457	.0572	.0572	.0492	.061
Avg	.9807	.7458	.7845	.7070	.8341	.7432	.7599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 203 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0373	.0514	.0343	.0343	.0373	.0343
2	.0343		.0343	.0343	.0343	.0373	.0171
3	.0343	.0373	.0171	.0171	.0171	.0187	.0343
4	.0343	.0373	.0183	.0343	.0343	.0373	.0171
5	.0343	.0373	.0366	.0343	.0343	.0373	.0343
6	.0343	.056	.0366	.0343	.0343	.0187	.0343
7	.0343	.0377	.0366	.0343	.0343	.056	.0343
8	.0343	.8402	.0549	.0171	.0343	.0187	.0343
9	.0187	.0366	.0514	.0187	.0373	.0171	.0373
10	.0373	.0732	.0343	.0747	.056	.0343	.0747
11	.056	.0549	.0857	.0934	.0747	.0343	.0934
12	.0747	.0732	.0686	.0747	.056	.0343	.056
13	.0747	.0549	.0686	.0747	.0373	.0343	.056
14	.0187	.0686	.0343	.0373	.0373	.0343	.0373
15	.056	.0514	.0343	.056	.0373	.0343	.056
16	.0373	.0549	.0514	.0747	.056	.0343	.0934
17	.056	.0549	.0686	.0514	.0747	.0171	.0373
18	.0747	.0366	.0857	.0686	.0747	.0171	.056
19	.056	.0189	.0343	.0514	.0747	.0171	.0187
20	.056	.0183	.0514	.0514	.0373	.0171	.0747
21	.0373	.0366	.0343	.0343	.0187		.0373
22	.0566	.0183	.0343	.0343	.0373	.0171	.0373
23	.056	.0183	.0171	.0171	.0187	.0343	.0187
24	.0514	.0373	.0366	.0343	.0343	.056	.0343
Max	.0747	.8402	.0857	.0934	.0747	.056	.0934
Min	.0171	.0183	.0171	.0171	.0171	.0171	.0171
Avg	.0448	.0778	.0449	.0453	.0425	.0302	.0441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 204 / EKAMBE -SANGVI- VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3174	.2926	.2743	.2572	.2614	.2572
2	.2401	.2987	.2743	.2572	.2401	.2241	.2401
3	.2229	.2614	.2926	.2572	.2401	.2241	.2229
4	.2401	.2241	.3292	.2743	.2572	.2987	.2401
5	.2743	.3734	.3658	.3086	.2915	.3361	.3086
6	.3944	.4481	.5304	.4287	.4287	.4854	.4287
7	.6001	.6535	.6767	.5658	.6001	.6348	.6001
8	.583	.6161	.5853	.5316	.5144	.5788	.5144
9	.4294	.4973	.4287	.5601	.5228	.3772	.5415
10	.4108	.3658	.3601		.3361	.3258	.4108
11	.3547	.3475	.2915	.3547	.3174	.2915	.3174
12	.3361	.3292	.2915	.3547	.2427	.2743	.3174
13	.3174	.2926	.2915	.3174	.2987	.2743	.3174
14	.3361	.2926	.2915	.3361	.3361	.2915	.3361
15	.3174	.2926	.2915	.1867	.2614	.2743	.2987
16	.3174	.2926	.3429	.0747	.2614	.2572	.3361
17	.2427	.3658	.2743	.3429	.2801	.2915	.2987
18	.3921	.4024	.3772	.3944	.3734	.3772	.3547
19	.4854	.567	.5658	.5487	.5415	.5316	.4854
20	.5788	.5853	.5658	.5487	.5788	.5658	.6161
21	.5601	.5487	.5316	.5316	.5041		.4668
22	.4854	.4938	.4287	.4287	.4854	.4287	.4481
23	.3734	.439	.3601	.3429	.3361	.3086	.3174
24	2.5034	.3174	.3109	.2915	.2743	.2614	.2743
Max	2.5034	.6535	.6767	.5658	.6001	.6348	.6161
Min	.2229	.2241	.2743	.0747	.2401	.2241	.2229
Avg	.4682	.4009	.3896	.3701	.3658	.3554	.3729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 205 / 11KV KATAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3361	.3292	.3601	.2572	.3734	.3601
2	.2743	.2987	.3109	.3258	.2401	.3361	.3258
3	.2743	.2614	.3292	.2915	.2401	.2987	.3258
4	.2915	.2241	.439	.4115	.2743	.4108	.3772
5		.4854	.5487	.4801	.4287	.5975	.5487
6	.6516	.7842	.7865	.6687	.6173	.7655	.6859
7	.8402	.8775	.9694	.8745	.8916	.8589	.8916
8	.8059	.823	.7865	.8745	.7373	.8402	.823
9	.6535	.7682	.583	.6535	.7468	.6344	.7655
10	.5788	.5853	.5144		.5788	.4973	.5788
11	.4854	.4938	.4458	.5228	.4481	.463	.4668
12	.4854	.5121	.3944	.5228	.2427	.4458	.5975
13	.4668	.4938	.3429	.4668	.2801	.4115	.3734
14	.4481	.5121	.3429	.4481	.2614	.3944	.4668
15	.3921	.5121	.4115	.4481	.168	.4287	.4481
16	.5041	.4938	.4458	.3734	.2054	.463	.4854
17	.5415	.5304	.4458	.4801	.5041	.4287	.5975
18	.6535	.695	.6173	.6001	.5975	.5487	.6722
19	.5788	.9145	.8916	.8573	.9522	.6859	.8589
20	.7842	.7682	.9088	.9088	.8589	.8573	.9709
21	2.7858	.6584	.7888	.8059	.8589		.8488
22	.6161	.567	.6173	.5658	.6348	.6516	.7282
23	.4294	.4938	.4458	.4801	.5601	.4801	.5228
24	2.5377	.3547	.3475	.3944	.2743	.4108	.3944
Max	2.7858	.9145	.9694	.9088	.9522	.8589	.9709
Min	.2743	.2241	.3109	.2915	.168	.2987	.3258
Avg	.7118	.5602	.5435	.5572	.4941	.5340	.5881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 206 / Shirambe-Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	.0572	.0343	.0457	1.1431	1.4746	1.4022
2	1.326	.0572	.0343	.0457	1.1584	1.4419	1.3565
3	1.2955	.0762	.0343	.0457	1.1126	1.4419	1.326
4	1.2955	.0762	.0514	.0457	1.0669	1.4091	1.2955
5	1.2955	.0762	.0514	.0457	1.0669	1.4582	
6	1.326	.1143	.0686	.0457	1.1888	1.4091	1.2193
7	1.5242	.1143	.0514	.0457	1.387	1.6385	1.4632
8	1.5699	.0572	.0514	.0457	1.448	1.6221	3.4156
9	1.5729	.0514	.0457	.0572	1.5238	1.5089	1.7695
10	.0572	.0686	.0457	.0572		.0457	.0381
11	.0572	2.4177	2.2862	.0164	.0572	.0457	.0572
12	.0572	2.8121	2.2558	2.3266	.0572	.0457	
13	.0572	2.8898	2.21	2.2939	.0572	.0457	.0572
14	.0572	2.7618	2.0881		.0572	1.2651	.0381
15	.0572	2.5549	2.1033	2.1136	.0762	.0457	.0572
16	.0572	2.4177	1.9204	2.0481	.0762	.0457	.0572
17	.0953	2.3663	1.8747	1.7833	.0762	.0457	.0572
18	.0762	2.1434	1.7528	1.6461	.0572	.0305	.0762
19	.0762	.0514	.061	.0457	.0572	.0762	.0762
20	.0762	.0514	.061	.0457	.0572	.0762	.0762
21	.1334	.0514	.0457	.0457	.0572		.0572
22	.0572	.0514	.0457	.0457	.0572	.0152	.0572
23	.0762	.0514	.0457		.0572	.0152	.0572
24	3.7266	.0492	.0343	.0457	1.1584	1.4746	1.4022
Max	3.7266	2.8898	2.2862	2.3266	1.5238	1.6385	3.4156
Min	.0572	.0492	.0343	.0164	.0572	.0152	.0381
Avg	.7219	.8924	.7189	.5880	.5676	.7251	.7006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 301 / 22 kv market yard

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	4.8011
Max	4.8011
Min	4.8011
Avg	4.8011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 201 / 11KV CHIMANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.905	.7343	.9145	.9774	.8954	.759
2	.905	.9412	.6984	.6718	.9412	.8954	.7373
3	.905	.9412	.6447	.7682	.9412	.8238	.6327
4	.9593	1.0631	.5731	.6483	1.0679	.8238	.6882
5	1.0679	1.2851	.7522	.6554	1.1222	1.0387	.6481
6	1.267	1.2851	1.2357	.7499	1.2851	1.3253	1.0494
7	1.8461		1.8446	1.1871		1.7013	1.5061
8	1.5939	1.7551		1.6124	1.7193	1.5043	1.7193
9	1.4506		1.3073	1.2934		1.2437	1.4022
10	1.2403	1.1104	.9259		1.0566	.8684	1.2851
11	1.134	1.0745	.8848	1.2894	1.0387	.9722	1.0317
12	1.0454	.8775	.8259		.8954	.9374	1.0317
13	1.0679	.8596	.8223		.7701	.9665	1.0136
14		.8596	.7716		.8417	.9536	1.0136
15	.9492	.8596	.8619		.9134	.8684	.9955
16	.9774	.9492		1.1222	.9313	.8848	.9774
17	.9593	1.0029	.9259		1.0029		
18	1.1765	1.0029	1.1443		1.1104	1.4266	
19	1.6289	1.4685	1.2963		1.4506	1.2967	
20	1.5223	1.5223	1.4091		1.5402	1.5061	
21		1.2883	.8488	1.3394	1.4327	1.2492	
22		1.1203	.9328		1.3253	1.1157	1.1104
23	.9593	.8775	.8002		.9134	.8179	.8688
24	2.4006	.8507	.7343	1.0608	.9231	.8417	.7373
Max	2.4006	1.7551	1.8446	1.6124	1.7193	1.7013	1.7193
Min	.905	.8507	.5731	.6483	.7701	.8179	.6327
Avg	1.2362	1.0863	.9534	1.0241	1.1000	1.0851	1.0109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 202 / 11 KV CHIMANGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.379	.1267	.112	.081	.9412	1.0974	1.134
2	1.2894	.1267	.1307	.0633	.9279	1.0974	1.134
3	1.267	.1267	.112	.0655		1.0802	1.1269
4	1.267		.1307	.0648	.9774	1.1145	1.0467
5	1.2894	.128	.1307	.0983	1.0317	1.1641	1.1069
6	1.2894	.1267	.1494	.1463	1.1584	1.166	1.1265
7	1.3756		.168	.1463		1.2346	1.2176
8		.1267	.112	.1214	1.3466	1.286	1.2186
9			.112	.1147		1.2125	1.1789
10	.0905	.1006	.0937		.0934	.0819	.128
11		1.9033	1.9044	1.9521	.112	.116	.1267
12		2.0748	1.9669		.1307	.0983	.1267
13		2.1312	1.8351		.1307	.1017	
14		1.9547	1.7532		.1307	.0983	.1267
15	.1267	2.1098	1.7465		.1494	.104	.1267
16	.1267	1.8861	1.5524		.1494	.0914	.1267
17	.1267	1.6975	1.5203		.1494	.0625	.128
18	.1267	1.6289		1.4148	.1307	.1227	
19		.112	.1147		.112	.1463	
20	.128	.1307	.0983		.112	.1094	
21		.1006	.0983	.1267	.112	.0949	
22		.1006	.0819		.112	.0709	
23	2.4006	.0838	.0772		.112	.0709	.1267
24	2.4006	.1267	.112	.0819	1.0317	1.0802	1.0576
Max	2.4006	2.1312	1.9669	1.9521	1.3466	1.286	1.2186
Min	.0905	.0838	.0772	.0633	.0934	.0625	.1267
Avg	.9789	.8049	.6136	.3444	.4358	.5376	.6869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 204 / 11 KV Khed Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2894	.1463	.0671	.0709	.9412	.9709	.8025
2	1.267	.1463	.0838	.0617	.9774	.9882	.8539
3	1.2536	.1463	.0838	.0732	.9671	.9882	1.0317
4	1.2536	.1463	.1006	.0747	.9412	1.0208	.9488
5	1.2894	.1463	.1006	.0648	.9774	1.0056	1.0242
6	1.3253	.1086	.0838	.081	1.0924	1.0576	1.0753
7	1.4327		.0838	.0791		1.2174	1.2757
8	1.4883	.1097	.0838	.0791		1.3203	1.2967
9			.0838	.0791		1.2289	1.3272
10		.1307	.0819		.112	.0655	.0905
11		2.0062	1.9498	1.9909	.112	.0791	.0905
12		1.989	1.8747		.0934	.0886	.0914
13		2.0748	1.9136		.0934	.0886	.0905
14		2.1262	1.9662		.0934		.0905
15		2.1262	1.8818		.0934		.0905
16	.0905	2.0062	1.8652		.0747		.0905
17	.1267	1.9033	1.7711		.0934		.0905
18	.1448	1.7147		1.6118	.0934		
19	.1463	.0934	.0655		.0934		
20	.1448	.112	.0972		.0838	.0819	
21		.0838	.0781	.1267		.0762	
22		.0838	.0625		.0934	.0772	
23		.0671	.0819		.112	.0678	.0905
24	1.3253	.1448	.0838	.0678	1.0317	.9015	.9145
Max	1.4883	2.1262	1.9662	1.9909	1.0924	1.3203	1.3272
Min	.0905	.0671	.0625	.0617	.0747	.0655	.0905
Avg	.8984	.8005	.6324	.3431	.4085	.6291	.5982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 205 / 11KV Shendurjane AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	1.182	1.5261	1.3435	.1097	.0934	.0886
2	.1267	1.1946	1.5089	1.4091	.1097	.0747	.0633
3	.1267	1.2308	1.4918	1.3904	.1086	.0747	.0633
4	.1267	1.267	1.5432	1.406	.1097	.0934	.0633
5	.128	1.3213	1.4403	1.5939	.1086	.0934	.0633
6	.1267	1.3213	1.5604	1.6876	.1086	.112	.0655
7	.1267		1.8176	2.6873		.112	.0633
8		1.7556	1.7147	1.8673	.1629	.0934	.0791
9	2.2502		1.5432	1.8107		.0492	.0886
10		.112	.0625		.112	.0625	.0905
11		.112	.0701		2.4177	1.9216	2.268
12	2.4097	.0934	.0633	.1086	2.3663		2.1616
13		.112	.064		2.3148	2.5133	2.1971
14		.112	.0617		2.2977	2.0645	2.2502
15	2.1262	.1307	.0648		2.2805	1.7924	2.1439
16		.112	.0655		2.2977	1.8781	2.1262
17		.1307	.064		2.1605	1.6512	2.1262
18	.1086	.1494		.1086	1.7147	1.6057	
19		.0747	.0655		.1307	.0701	
20	.1086	.1494	.0655		.112	.0701	
21		.1307	.0655	.1086	.1494	.0709	
22		.112	.0848		.1307	.0655	
23		.0934	.0914		.1494	.0867	.0905
24	.1267	1.1462	1.4746	1.3108	.1086	.1307	.0867
Max	2.4097	1.7556	1.8176	2.6873	2.4177	2.5133	2.268
Min	.1086	.0747	.0617	.1086	.1086	.0492	.0633
Avg	.6169	.5474	.7178	1.2948	.8891	.6426	.8515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 206 / 11KV Bhatamwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.8417	.8916	.8223	.1097	.112	.0949
2	.1463	.8775	.9313	.9503	.1097	.112	.0937
3	.1463	.9231	.9671	.9503	.1097	.1307	.1063
4	.1463	.9412	1.0208	.9503	.1097	.1307	.0949
5	.1448	1.0498	1.0288	.9831	.1097	.1494	.1107
6	.1463	1.0679	1.0802	.9831	.1097	.1307	.1107
7	.1646		1.2346	.9831		.1494	.1235
8		1.2178	1.166	1.012	.1267	.1494	.1265
9			1.0974	.7716		.1311	.1235
10	1.382	.1509	.1097		.1006	.0949	.1448
11		.1307	.0633			1.1174	1.3253
12	1.3643	.1307	.0914	.1086		1.2209	1.3466
13		.1307	.0633		1.406	1.2452	2.1616
14		.1494	.0848		1.3717	1.2289	1.382
15		.1494	.0772		1.3546	1.166	1.3112
16	1.267	.1494	.0819		1.3717	1.1203	1.2536
17		.1494	.0937		.9945	1.2178	1.2403
18	.1267			.1086	.9602	.9722	
19		.1867	.1094		.1307	.1147	
20	.1267	.1867	.1107		.1494	.124	
21		.168	.0983	.1097	.1494	.1417	
22		.168	.112	.1086	.1307	.124	
23		.168	.1097		.1307	.1417	.1448
24	1.6766	.7964	.8745	.7865	.1086	.1307	.1107
Max	1.6766	1.2178	1.2346	1.012	1.406	1.2452	2.1616
Min	.1267	.1307	.0633	.1086	.1006	.0949	.0937
Avg	.5372	.4635	.4999	.6877	.4572	.4732	.6003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 201 / TARAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	1.2654	1.4251	1.2651	.2641	.2477	.2829
2	.168	1.2346	1.4251	1.2342	.2641	.2286	.2641
3	.168	1.2041	1.4083	1.2186	.2641	.2286	.2452
4	.168	1.1888	1.4419	1.2186	.2641	.2286	.2452
5	.2427	1.2654	1.6598	1.2498	.2641	.2477	.2829
6	.3174	1.4083	1.6598	1.3916	.3206	.3018	.3206
7	.4108	1.6964	1.7939	1.5779	.4338	.3961	.3772
8		1.8185	1.8143	1.6288	.3584	.3206	.3395
9	.3206	1.5242	1.6324	1.4998	.2801	.3018	
10	.2452	.1867	.2263	.2641	.2054	.2452	
11	2.4034	.2218	.2075	.2452	2.3102		2.5724
12	2.4453	.2402	.2263	.2641	2.3205	2.3061	2.5126
13	2.4453	.2772	.2829	.2641	2.3967		2.4453
14	2.2672	.2614	.3206	.2641	2.2186	2.5095	2.3644
15	2.251	.2829	.3018	.3018	2.1376	2.4417	2.0325
16	2.1445	.3142	.3018	.2801	2.0165	2.34	2.0325
17	1.8435	.3174	.3174	.2614	1.8461		1.9271
18	1.7328	.2987	.2801	.2587	1.6248	2.0517	1.7976
19	.4527	.5415	.4904	.4904	.4904	.5281	.5041
20	.547	.5228	.5658	.5658	.5658	.6036	
21	.5093	.5041	.5658	.547	.6036	.6036	.5601
22	.4191	.4294	.4527	.4715	.4904	.5093	.4668
23	.2641	.2801	.3395	.3395	.3395	.3395	.3361
24	.2054	1.2498	1.4419	1.2967	.2829	.2667	.3018
Max	2.4453	1.8185	1.8143	1.6288	2.3967	2.5095	2.5724
Min	.168	.1867	.2075	.2452	.2054	.2286	.2452
Avg	.9634	.7722	.8576	.7666	.9401	.8213	1.0577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 202 / KIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7974	.1509		.1698	1.9662	1.5364	1.8023
2	1.7436	.132		.1698	1.7652	1.4883	1.7328
3	1.7436	.132		.1698	1.7004	1.4548	1.7166
4	1.7436	.132		.1698	1.7004	1.4232	1.7004
5	1.7604	.1886		.1886	1.7652	1.4232	1.7328
6	1.8482	.2667	.3921	.3206	1.989	1.4083	1.8351
7	1.9113	.415	.4481	.4904	2.0719	1.5844	1.9498
8		.4338	.4294	.4715	2.0809	1.6964	1.9989
9	.2801	.3395		.3772	1.9109	1.6484	1.8461
10		.2263	.2263	.2641	.2641	.2263	.2075
11	.2075	2.3868	2.7018	2.5526	.2241		.2075
12	.2263	2.7183	2.9172	2.5526	.2075	.2075	.2263
13	.2452	2.9172	2.6825	2.6355	.2402	.2263	.2241
14	.2829	2.7496	2.6322	2.5526	.2218	.2641	.2614
15	.2641	2.7161	2.6658	2.5526	.2614	.2829	.2241
16	.3018	2.7496	2.5149	2.3868	.2587	.2452	.2987
17	.2427	2.6993	2.4981	2.3205	.2614	.2641	.2427
18	.2614	2.5484	2.3975	2.3537	.2218	.2641	.2801
19	.3772	.4854	.4715	.4715	.415	.4527	.4854
20	.4715	.4668	.4904	.5658	.5093	.4715	
21	.4338		.5281	.5093	.5093	.4904	.4854
22	.381	.3734	.415	.4338	.4527	.415	.4108
23	.2075	.2241	.2641	.2641	.3018	.2641	.2801
24	2.0165	.1509	.168	.1886	2.0317	1.587	1.873
Max	2.0165	2.9172	2.9172	2.6355	2.0809	1.6964	1.9989
Min	.2075	.132	.168	.1698	.2075	.2075	.2075
Avg	.8522	1.1132	1.3802	1.0472	.9721	.8402	.9575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 203 / WATHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	1.9448	2.0348	1.8275	.4338	.4338	.4527
2	.3174	1.9062	1.9839	1.8107	.4338	.415	.4527
3	.3174	1.8896	1.9839	1.7939	.415	.3772	.4338
4	.2987	1.9062	2.0348	1.7939	.4338	.3772	.4338
5	.5228	1.9951	2.0517	1.8652	.4715	.415	.4904
6	.6722	2.1534	2.0622	1.9951	.6979	.6224	.679
7	.7468	2.3304	2.1795	2.3137	.8865	.7922	.7733
8		2.3304	2.2466	2.3472	.7545	.7356	.7356
9	.5415	2.2131	2.0454	2.1963	.5601	.5281	.4904
10	.4854	.5041	.5281	.5093	.5228	.5093	.4854
11	3.1017	.4251	.4338	.4527	3.1036		2.713
12	3.0178	.5121		.4854	2.9673	2.8826	2.7328
13	2.9843	.499		.4854	3.0182	2.9334	2.6825
14	2.9843	.4251	.4904	.5041	3.0182	2.9334	2.649
15	2.8669	.5175	.5093	.5601	2.9334	2.8995	2.7161
16	2.7999	.5544	.547	.5729	2.8837	2.9334	2.5149
17	2.5692	.5544	.5359	.4938	2.9675	2.6282	2.2801
18	2.4034	.5359	.5359	.5121	2.0553	2.3739	
19	.7922	.8962	.811	.8775	.811	.8139	.8962
20	.8488	.8962	.9619	.9619	.9619	.9808	
21	.811	.7842		.9242	.9808	.9619	.9896
22	.6602	.6908	.7167	.7922	.7922	.8488	.8402
23	.4527	.4668	.5281	.5658	.5658	.5658	.5975
24	.3734	1.9616	2.0119	1.861	.4527	.4715	.4904
Max	3.1017	2.3304	2.2466	2.3472	3.1036	2.9334	2.7328
Min	.2987	.4251	.4338	.4527	.415	.3772	.4338
Avg	1.3437	1.2039	1.2968	1.1876	1.3801	1.2797	1.2513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 204 / ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8652	.2829	.2801	.3395	1.4922	1.7604	1.6956
2	1.7804	.2641	.2801	.3206	1.4413	1.7072	1.6095
3	1.7465	.2641	.2987	.3018	1.3916	1.6385	1.5424
4	1.7465	.2641	.3361	.3018	1.3916	1.5893	1.5089
5	1.7804	.3206	.4294	.3584	1.3916	1.6244	1.5424
6	1.8652	.4527	.5975	.4715	1.5769	1.7072	1.6933
7	2.0008	.5847	.5601	.6036	1.7604	2.0056	1.8991
8		.547	.5415	.5658	1.8778	2.0056	2.1293
9	.3961	.415	.2829	.4338	1.5424	1.7901	1.8107
10	.2987	.3395	.3395	.3772	.3584	.2486	.3584
11	.2263	2.7831	2.8166	2.5652	.3018		.2263
12	.3206	2.8502	2.934	2.8012	.3206	.3584	.3206
13	.3961	2.9843	2.8502	2.6189	.3174	.3584	.3361
14	.3584	2.649	2.934	2.5029	.3361	.3772	.3361
15	.3206	2.7328	2.6658	2.4697	.3206	.3206	.3361
16	.3018	2.7161	2.5819	2.304	.3511	.3584	.3547
17	.2772	2.5987	2.5819	2.0119	.3547	.2452	.3174
18	.3881	2.364	1.9616	1.8107	.3511	.3584	.3547
19	.5847	.6539	.6413	.679	.6413	.679	.7095
20	.7167	.7282	.811	.7922	.7545	.7545	
21	.679	.6535	.7545	.7545	.7167	.7167	.7655
22	.547	.5788	.6036	.6224	.6036	.6224	.6535
23	.3584	.3734	.4527	.4338	.4527	.4527	.4668
24	1.9669	.3018	.3174	.3584	1.4922	1.8821	1.7635
Max	2.0008	2.9843	2.934	2.8012	1.8778	2.0056	2.1293
Min	.2263	.2641	.2801	.3018	.3018	.2452	.2263
Avg	.9096	1.1959	1.2022	1.1166	.8974	1.0244	.9883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 205 / PWV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191		.0191		.0191	.0191
2		.0191		.0191		.0191	.0191
3		.0191		.0191		.0191	.0191
4		.0191		.0191		.0191	.0191
5		.0191		.0191		.0191	.0191
6		.0191		.0191		.0191	.0191
7		.0191		.0191		.0191	.0191
8		.0191				.0191	.0191
9		.0191		.0191	.0191		
10		.0191		.0191	.0191		
11		.0191		.0191	.0191		
12		.0191		.0191	.0191		
13		.0191		.0191	.0191		
14		.0191		.0191	.0191		
15		.0191		.0191	.0191		
16		.0191		.0191	.0191		
17	.0191		.0191		.0191		
18	.0191		.0191		.0191		
19	.0191		.0191		.0191		
20	.0191		.0191		.0191		
21	.0191		.0191		.0191		
22	.0191		.0191		.0191	.0191	
23	.0191		.0191		.0191	.0191	
24	.0686	.0191		.0191		.0191	.0191
Max	.0686	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0253	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 206 / 11KV Mohitewadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846			
2	.2688			
3	.2688			
4	.2688			
5	.2688			
6	.3041			
7	.3321			
8	.3361			
11		.4752	.4748	.4588
12		.4858	.5087	.4696
13		.5407	.5256	.4801
14		.5243	.5256	.4858
15		.502	.5426	.4161
16		.4858	.5256	.4428
17		.502	.4748	.4321
18		.4481	.4748	.4321
24	.2881			
Max	.3361	.5407	.5426	.4858
Min	.2688	.4481	.4748	.4161
Avg	.2911	.4955	.5066	.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 201 / PIMPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	1.6385	1.6385	1.7166	.0709	.0526	.064
2	.0701	1.6194	1.6385	1.7004	.0701	.0532	.048
3	.0716	1.6194	1.7238	1.6804	.0716	.0537	.0474
4	.0701	1.6956	1.8652	1.6964	.0724	.0537	.0469
5	.0914	1.6518	1.8299	1.749	.0724	.0526	.0633
6	.0886	1.9433	1.9784	1.8023	.0895	.0537	.081
7	.0895	2.13	2.0972	1.8351	.0886	.0537	.081
8	.0914	2.2131	2.2045	2.1792	.0876	.0532	.0983
9	.0886	2.1538	2.0856	2.1136	.1063	.0514	.0983
10	.1075	.0686	.0716	.096	.0701	.0514	.0655
11	2.2565	.0693	.0655	.081	2.7109	2.9165	2.8147
12	2.9165	.0848	.0648		3.2057		2.9172
13	2.8502	.0693	.081		2.6871		2.6707
14	2.8995	.0709	.064		2.5484		2.7328
15	2.915	.0732	.0648		2.7515	2.769	2.7183
16	2.8086	.0895	.081		2.8292	2.9329	2.556
17	2.4806	.1063	.08		2.536	2.8346	2.5095
18	2.3777	.1075	.08	.0848	2.4587	2.343	2.3205
19	.0537	.1267	.0972	.0701	.104	.1134	.0895
20	.0701	.0876	.081	.0709	.1075	.096	.0886
21	.0709	.1063	.08	.0716		.0983	.1052
22	.0709	.104	.0983	.0724		.081	.0886
23	.0709	.1254	.064	.0716		.096	.0876
24	.0895	1.6712	1.7857	1.7532	.0701	.0537	.081
Max	2.9165	2.2131	2.2045	2.1792	3.2057	2.9329	2.9172
Min	.0537	.0686	.064	.0701	.0701	.0514	.0469
Avg	.9487	.8177	.8300	1.0469	1.0861	.7078	.9364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 202 / BRAMHAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4239	.4239	.439	.4681	.4477	.4525
2	.4784	.4096	.4239	.4344	.4287	.4784	.4525
3	.4298	.4239	.4287	.4525	.4239	.5201	.4656
4	.5138	.4382	.4854	.4656	.4854	.5014	.4961
5	.5895	.5014	.5658	.543	.5609	.567	.5731
6	.7888	.8063	.6836	.6584	.6733	.6201	.7316
7	.8764	.8596	.8495	.8871	.6952	.6805	.924
8	.8916	.8238	.7969	.9149	.8322	.724	2.8753
9	.8238	.823	.6241	.8596	.703	.6447	.8048
10	.703	.7783	.7265	.7522	.6836		.7964
11	.6935	.7011		.6335	.7442	.5731	.7186
12	.7164	.6588	.6626	.5959	.7343		.7202
13	.724	.6068	.6733	.6935	.6443	.6024	.7282
14	.7316	.6443	.7087	.6588	.5895	.6379	.7186
15	.7316	.6935	.7186	.7011	.6443	.7087	.7011
16	.7577	.6516	.6762	.6762	.6661	.5959	.7802
17	.5973	.5959	.631	.6001	.6516	.6068	.7202
18	.5731	.6173	.6068	.5895	.5721	.6859	.7186
19	.9145	.8063	.8326	.8916	.7373	1.0059	.8402
20	.9412	.8842	.9425	.7969	.9362	1.0456	.8149
21	.8507	.7202	.8871	.7545		.9335	.763
22	.7316	.6762	.7577	.6539		.8501	.7545
23	.5853	.567	.6099	.5609		.6584	.6415
24	.4508	.4409	.463	.499	.5138	.4801	.567
Max	.9412	.8842	.9425	.9149	.9362	1.0456	2.8753
Min	.4298	.4096	.4239	.4344	.4239	.4477	.4525
Avg	.6911	.6480	.6599	.6547	.6375	.6622	.7816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 203 / SAP

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.0509	.0549	.0514	.8669	.8987	.7449
2	.7628	.0503	.0543	.0503	.8402	.8192	.7449
3	.763	.0503	.0526	.0497	.8648	.8215	.7116
4	.7625	.0503	.0537	.0497	.964	.763	.7522
5	.8215	.0503	.0543	.0492	1.0387	.8059	.7935
6	.9709	.0503	.0549	.0503	1.0402	.8589	.852
7	1.0682	.0514	.0537	.0514	1.0562	1.073	.9339
8	1.0402	.0509	.0543	.0526	1.1488	1.1869	1.1142
9	.8916	.0514	.0537	.056	1.0341	1.1336	1.0486
10	.0549	.0514	.0532	.0543	.0537	.0514	.0503
11	.0537	1.6575	1.4419	1.7375	.0543	.0514	.0503
12	.0526	1.8347	1.6057	1.7318	.0549	.0509	.0532
13	.0532	1.7465	1.4575	1.6817	.0532	.0509	.0537
14	.0537	1.7002	1.5402	1.5775	.052	.0509	.0537
15	.0543	1.7909	1.5893	1.491	.0509	.0526	.0537
16		1.7002	1.5402	1.6476	.0526	.0526	.0543
17		1.7541	1.4746	1.5257	.0532	.052	.0549
18		1.1616	1.3108	1.4022	.0537	.0509	.0537
19	.0486	.0549	.0526	.0549	.0543	.0526	.0532
20	.0492	.0543	.0532	.0537	.0532	.0532	.0537
21	.0509	.0532	.0532	.0549		.0514	.0537
22	.0503	.0526	.0532	.0526		.0509	.0526
23	.0514	.0532	.0514	.0537		.0503	.0537
24	.8238	.0514	.0537	.0514	.8764	.929	.7373
Max	1.0682	1.8347	1.6057	1.7375	1.1488	1.1869	1.1142
Min	.0486	.0503	.0514	.0492	.0509	.0503	.0503
Avg	.4412	.5905	.5340	.5680	.4913	.4172	.3824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 204 / SASURVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5851
Max	1.5851
Min	1.5851
Avg	1.5851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 205 / VELU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1097	.1254	.1478	.1578	.0532	.1663
2	.1075	.1075	.1214	.1478	.1595	.1227	.1663
3	.1448	.1075	.12	.1463	.1791	.1433	.1646
4	.1949	.1086	.1865	.1629	.1991	.1772	.1791
5	.2279	.1254	.2035		.2195	.9114	.2195
6	.2686	.3258	.2601		.2402	.3045	.2772
7	.333	.362	.3149		.2534	.3582	.3734
8	.3601	.3292	.2785	.3734	.333	.3506	.3734
9	.2427	.2926	.2035	.3292	.2481	.2896	.2772
10	.2126	.2353	.2279	.2401	.1928	.2534	.2195
11	.1949	.2126	.2328		.1595	.2172	.2374
12	.1791	.1612	.1612			.197	.2279
13	.1267	.1791	.1772	.2804	.1907	.1791	.1772
14	.1829	.1928	.1578	.2481	.1753	.2126	.1791
15	.1646	.2012	.1753	.2629	.2743	.2328	.1991
16	.1478	.1612	.2601	.2915	.2454	.2686	.2149
17	.2103	.181	.2254	.333	.3086	.1928	.2534
18	.2172	.2481	.1886	.3544	.2454	.2601	.3155
19	.3258	.3155	.3475	.3856	.3366	.3658	.0543
20	.3841	.4075	.4294	.3366	.4161	.4294	.2401
21	.3109	.3403	.3921	.2915		.4108	.3544
22	.2195	.2629	.2772	.2629		.3547	.3121
23	.1646	.1928	.2054	.197		.2402	.2058
24	.128	.1267	.1463	.168	.1734	.1433	.2054
Max	.3841	.4075	.4294	.3856	.4161	.9114	.3734
Min	.1075	.1075	.12	.1463	.1578	.0532	.0543
Avg	.2155	.2203	.2258	.2610	.2354	.2779	.2330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 206 / 11KV Dhamner Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254081 / 33/11 KV Sasurve

Feeder No / Name : 201 / 11 KV Dughi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	.6663
Max	.6663
Min	.6663
Avg	.6663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254081 / 33/11 KV Sasurve

Feeder No / Name : 202 / 11 KV Apshinge AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.0159
Max	1.0159
Min	1.0159
Avg	1.0159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254081 / 33/11 KV Sasurve

Feeder No / Name : 203 / 11 KV Sasurve Gavthan

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.1017
Max	.1017
Min	.1017
Avg	.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 301 / 22KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.4937	1.8671	1.5684	1.5844	1.6804	1.6804
2	1.4335	1.419	1.5684	1.5684	1.5089	1.5684	1.643
3	1.3957	1.419	1.4937	1.5684	1.5089	1.4937	1.6221
4	1.5089	1.419	1.4937	1.5684	1.6221	1.5684	1.6221
5	1.8861	1.4563	1.5684	1.8107	1.7353	1.6975	1.6975
6	2.2634	1.9616	1.8861	2.1125	2.3011	2.3011	2.1879
7	2.7915	2.3011	2.6139		2.6139	2.6783	2.7538
8	3.131	2.8669	2.7538	2.6783	3.0247	3.0933	3.2065
9	2.8753	2.8669		2.9047	2.8292	2.6406	2.9047
10	2.4646	2.6513	2.4646	2.6139	2.5019	2.4272	2.9874
11	2.4646	2.4272	2.452	2.5019	2.3285	2.3011	2.6139
12	2.3011	2.3152	2.3011	2.2546	2.3655	2.3011	2.5503
13	2.3011	2.2032	2.2405	2.2546	2.4025	2.3765	2.4394
14	2.1068	2.0698	2.1285	2.1437	2.1582	2.2032	2.3285
15	2.0698	2.0698	2.0748	1.9959	2.1437		2.2546
16	2.0851	1.9791	2.0748	1.922	2.1068		2.2177
17	2.2546	2.1658	2.4025	2.037	2.2916	2.95	2.4143
18	2.3285	2.3152	2.6612	2.5652	2.4764	2.8006	2.9047
19	3.2861	3.2114	3.1417	3.3634	3.4743	3.5101	3.5848
20	3.1367	3.1741	3.2156	3.2442	3.3981	3.3608	3.3634
21	2.7633	2.838	2.9127	2.8669	3.0247	2.9874	2.9874
22	2.4272	2.1502	2.6886	2.5393	2.6886	2.6886	2.6139
23	2.0538	2.1502	2.2032		2.3525	2.3152	
24	1.643	1.643	2.1125	1.6804	1.7177	1.7924	1.7551
Max	3.2861	3.2114	3.2156	3.3634	3.4743	3.5101	3.5848
Min	1.3957	1.419	1.4937	1.5684	1.5089	1.4937	1.6221
Avg	2.2700	2.1903	2.2748	2.2619	2.3400	2.3971	2.4493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 302 / 22KV SANGAM NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	1.0185	1.1317	.9431	.9431	.9808	1.0562
2	.9431	.9808	1.0562	.9431	.9431	.9808	1.0562
3	.9054	.9808	1.0185	.9431	.9431		1.0185
4	1.0185	1.0185	1.0185	.9431	.9808	.9054	1.0185
5	1.0562	1.0562	1.0562	1.0185	1.0185	.9808	1.0562
6	1.1694	1.0562	1.1317	1.1317	1.2071	1.1317	1.1317
7	1.358	1.1317	1.2449	1.2071	1.3203	1.3203	1.3203
8	1.3817	1.3203	1.358	1.2826	1.3957	1.3957	1.4335
9	1.4563	1.3957		1.4335	1.4712	1.3957	1.5089
10	1.531	1.3957	1.5844	1.3957	1.5684	1.5466	1.5844
11	1.773	1.3957	1.7353	1.3957	1.8107	1.6975	1.8861
12	1.6975	1.358	1.8107	1.3957	1.8484	1.7353	1.9239
13	1.7353	1.358	1.8107	1.2449	1.8107	1.6975	1.8107
14	1.6221		1.8107	1.2449	1.6598	1.5466	1.8861
15	1.6598	1.2826	1.7353	1.2449	1.7551	1.5089	1.8484
16	1.7353	1.2826	1.2449	1.2071	1.773	1.5466	1.8484
17	1.5844	1.2826	1.6221	1.2449	1.773	1.6598	1.8484
18	1.4335	1.2449	1.5466	1.3203	1.5844	1.5466	1.6221
19	1.7353	1.5844	1.773	1.6598	1.8107	1.6975	1.8484
20	1.5466	1.5844	1.7353	1.6221	1.7353	1.6598	1.6598
21	1.773	1.4335	1.5089	1.4712	1.5089	1.5089	1.6221
22	1.2826	1.3203	1.4335	1.358	1.4335	1.358	1.5089
23	1.1317		1.2071		1.2449	1.2071	
24	.9808	1.0185	1.3203	1.0185	1.0562	1.0562	1.1317
Max	1.773	1.5844	1.8107	1.6598	1.8484	1.7353	1.9239
Min	.9054	.9808	1.0185	.9431	.9431	.9054	1.0185
Avg	1.3955	1.2500	1.4302	1.2465	1.4415	1.3941	1.5056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 303 / 22 KV GOLIBAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	1.0456	1.1317	1.1203	1.1317	1.2696	1.2696
2	1.094	1.0456	1.0562	1.1203	1.1317	1.1949	1.1949
3	.9808	1.0082	1.0456	1.1203	1.1317	1.1203	1.1317
4	1.0456	1.0082	1.1203	1.1203	1.1694	1.1203	1.1203
5	1.5089	1.1203	1.1317	1.2696	1.2071	.6413	1.1317
6	1.5466	1.2449	1.2071	1.5089	1.4335	1.1694	1.2449
7	2.1879	1.6221	1.9616	1.6975	1.9993	1.4335	1.9993
8	2.1879	1.9993	2.0748	1.8861	2.037	1.5089	2.037
9	1.9044	1.9993		1.7353	1.8298	1.9044	1.8107
10	1.643	1.6804	1.531	1.6804	1.5927	1.4937	1.5684
11	1.5154	1.5684	1.1317	1.6804	1.5154	1.3817	1.5893
12	1.0719	1.4937	1.3203	1.4415	1.4415	.5975	1.4784
13	1.4415	1.3443	1.2826	1.3306	1.39	1.531	1.4045
14	1.4045	1.2936	1.3203	1.2567	1.39	1.419	1.3676
15	1.3306	1.2936	1.307	1.2197	1.2936		1.4045
16	1.3306	1.2197	1.2449	1.2197	1.2696		1.3676
17	1.4415	1.3443	1.3443	1.3203	1.4937	1.4563	1.4712
18	1.5524	1.531	1.5154	1.5844	1.5524	1.7177	1.7353
19	1.9418	1.9418	1.9589	2.0748	2.0698	2.0911	2.1285
20	1.9418	1.9791	1.9959	1.9616	2.0165	2.0165	1.643
21	1.7551	1.8671	1.9044	1.8671	1.9418	1.9589	1.9791
22	1.6804	1.643	1.7177	1.773	1.7924	1.848	1.8484
23	1.3443	1.3817	1.4563		1.531	1.5524	
24	1.1317	1.1203	1.2826	1.1949	1.1949	1.2696	1.3306
Max	2.1879	1.9993	2.0748	2.0748	2.0698	2.0911	2.1285
Min	.9808	1.0082	1.0456	1.1203	1.1317	.5975	1.1203
Avg	1.5027	1.4498	1.4366	1.4862	1.5232	1.4407	1.5329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 304 / 22KV CIVIL HOSPITAL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381	.0381	.0381	.0381
6	.0381	.0381	.0762	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381		.0762	.0762	.0381	.0762
10	.0762	.0381	.0762	.0762	.1143	.0381	.0762
11	.0762	.0381	.0762	.0381	.0762	.0381	.0762
12	.0762	.0381	.0762	.0381	.0762	.0381	.0762
13	.0762	.0381	.0381	.0381	.0762	.0381	.0762
14	.0381	.0381	.0381	.0381	.0381	.0381	.0762
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0762	.0381	.0381	.0381	.0762	.0381
22	.0381	.0762	.0381	.0381	.0762	.0381	.0381
23	.0381	.0381	.0381		.0381	.0381	
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0762	.0762	.0762	.0762	.1143	.0762	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0445	.0413	.0447	.0414	.0492	.0397	.0480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 301 / 22KV OLD MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6584	.8131	.8131	.7011	.5365
2			.6722	.6722	.724	.6516	.4534
3			.631	.679	.6584	.6584	.4054
4			.6516	.6722	.6653	.6722	.3574
5			.695	.8215	.7468	.6653	.4146
6			.6584	.6653	.7316	.6447	.3902
7			.7316	.8215	.7964	.6584	.4458
8			.8131	.7545	.6478	.7392	.5792
9			.9907	.9808	.9054	.5014	.9808
10			1.2071	1.2071	1.2826	.4816	1.2696
11			1.1317	1.3306	1.358	.5365	1.358
12			1.1949	1.1576	1.358	.5418	1.5089
13		1.0669	1.1431	1.1317	.9808	.535	1.2826
14		.9907	1.2071	1.419	1.0456	.4374	1.419
15		1.0562	1.358	1.2567	1.2696	.4641	1.2696
16		.9808	1.1317	1.3443	1.2826	.5731	1.0562
17		.9808	1.2826	1.2071	1.0456	.5068	1.2826
18		.9054	.9808	1.1431	.9808	.4801	1.0562
19		.8131	.9054	.9808	.8215	.5365	.9907
20		.7392	.8299	.8131	.6653	.5304	.7468
21		.6722		.8048	.7468	.583	.7545
22		.6722	.8299	.8779	.7316	.5365	.8299
23		.6722	.8299	.8779	.7392	.6241	.8215
24	.8299		.7087	.8048	.8779	.7468	.5487
Max	.8299	1.0669	1.358	1.419	1.358	.7468	1.5089
Min	.8299	.6722	.631	.6653	.6478	.4374	.3574
Avg	.8299	.8682	.9236	.9682	.9114	.5836	.8649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 302 / 22 KV KARMVEER NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9054	.9431	.9431	.9335	.9145
2			.8676	.8962	.9054	.9054	.8871
3			.8299	.9054	.8962	.9431	.8871
4			.9054	.9808	.9709	1.0185	.9335
5			1.0456	1.0562	1.1203	1.0562	1.0242
6			1.4712	1.4335	1.4937	1.2826	1.4045
7			1.9418	1.9616	2.0165	1.9993	
8			1.9044	1.8671	1.9993	1.9616	2.037
9			1.6221	1.773	1.531	1.531	1.6221
10			1.4045	1.419	1.2071	1.1827	1.2071
11			1.0719	1.2696	1.0608	.9979	1.0974
12			1.1203	1.3169	.9877	.8589	1.0498
13		1.0402	1.0242	1.0608	.9979	.9709	.9774
14		.961	1.094	.9877	.9979	.8962	1.0242
15		.961	.9335	.9465	.924	.9431	.8871
16		.9979	1.0082	1.086	.961	.9054	1.0456
17		1.0719	1.0974		.9877	.961	1.1706
18		1.0498	1.1458	1.2071	1.0608	1.0719	1.2197
19		1.6095	1.5684	1.7002	1.5729	1.1706	1.6221
20		1.7741	1.4784	1.7177	1.7551	1.6095	1.773
21		1.7177	1.307	1.7924	1.6804	1.5684	1.7353
22		1.5089	1.2071	1.5089	1.5684	1.5844	1.5466
23		1.2449	1.1694	1.2826	1.2323	1.1949	1.307
24	1.7924		.9431	1.0185	1.0185	1.0185	.9979
Max	1.7924	1.7741	1.9418	1.9616	2.0165	1.9993	2.037
Min	1.7924	.961	.8299	.8962	.8962	.8589	.8871
Avg	1.7924	1.2670	1.2111	1.3100	1.2454	1.1902	1.2335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 303 / 22KV MAHARASHTRA SCOOTERS

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.643	1.182	1.5844	1.358	1.6057	1.773	.4938
2	1.643	1.2308	1.5844	1.4335	1.6263	1.7177	.5075
3	1.6221	1.3443	1.6221	1.4784	1.5893	1.6804	.5053
4	1.5844	1.4335	1.5844	1.531	1.5684	1.6598	.5182
5	1.6057	1.419	1.6221	1.5524	1.5684	1.5844	.5556
6	1.6598	1.4712	1.6598	1.5684	1.5893	1.5089	.6009
7	1.6975	1.4937	1.6975	1.4998	1.643	1.5684	.6009
8	1.2826	1.4632	1.4335	1.5893	1.6263	1.1694	1.6263
9	1.8484	1.9239	1.9616	1.9616	1.9993	.7522	1.9239
10	2.2257	2.0195	2.2862	2.1719	2.1502	.6192	2.1879
11	2.1879	1.9616	2.1879	2.2481	2.2257	.5952	2.3243
12	2.037	1.7353	2.2257	2.0576	2.3011	.5121	2.21
13	1.9993	1.7353	1.9616	1.8107	1.9616	.5365	1.419
14	2.1879	1.9993	2.2862	2.3388	1.9616	.4801	1.5089
15	2.1125	2.0748	2.2634	2.2481	1.9993	.4961	2.1719
16	1.8861	1.6057	1.9616	2.0748	2.0748	.3887	2.1879
17	1.8484	2.0748	2.037	1.8861	1.9993	.3582	2.3624
18	1.9616	1.9616	1.3306	.9774	1.9993	.3772	2.3011
19	1.8671	1.7924	1.8107	1.8107	2.1879	.3887	2.2634
20	1.9239	1.6598	1.8107	1.4784	1.6975	.4649	1.6975
21	1.8107	1.643	1.8484	1.6975	1.9239	.3487	1.8861
22	1.8484	1.7353	1.8861	1.134	2.037	.3841	1.8484
23	1.8107	1.7353	1.8861	1.6221	1.6598	.4489	1.773
24	1.7353	1.134	1.6221	1.3203	1.5844	1.773	.4534
Max	2.2257	2.0748	2.2862	2.3388	2.3011	1.773	2.3624
Min	1.2826	1.134	1.3306	.9774	1.5684	.3487	.4534
Avg	1.8345	1.6596	1.8398	1.7020	1.8575	.8994	1.4970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 304 / 22KV DOBURG

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7346	3.0178	1.4563	3.5082	3.5837	3.0994	1.5089
2	3.6214	2.9424	1.5089	3.4705	3.5101	3.2065	1.531
3	3.6214	2.8669	1.5844	3.3951	3.4355	3.2861	1.5684
4	3.6214	2.7915	1.7353	3.4705	3.3265	3.2442	1.531
5	3.6591	2.7915	1.9418	3.3265	3.4004	3.2487	1.5089
6	3.6969	2.7915	2.1879	3.4705	3.5101	3.3951	1.531
7	3.6969	2.8292	2.4897	3.546	3.6214	3.3196	1.5684
8	2.4143	1.6221	1.9616	3.0178	2.8753	1.6598	1.4937
9	2.7538	2.6139	2.452	3.3951	3.2065	1.6598	2.9569
10	3.81	3.131	4.1118	3.658	4.5645	1.7147	3.4328
11	4.1118	3.4705	4.5268	4.3439	3.3913	1.6598	4.225
12	4.7154	3.3573	4.225	4.2295	3.8866	1.6598	4.2627
13	4.3381	3.0933	3.9609	3.3196	3.8104	1.6975	4.0364
14	4.5645	2.5911	3.5082	4.3759	3.8477	1.6598	3.546
15	4.5645	3.2007	4.3759	4.489	4.5645	1.6598	4.3381
16	4.4136	2.4768	3.8477	4.6106	3.9232	1.6598	4.0364
17		2.2862	4.3004	3.7346	4.2627	1.6766	3.81
18	3.8855	2.0957	4.1118	4.0364	3.8855	1.6004	3.546
19	3.1687	2.934	4.0741	4.2627	3.3196	1.5844	4.3381
20	3.0556	2.6029	3.5837	4.0364	2.8669	1.6004	2.9424
21	2.8292	2.5274	3.3951	3.7723	3.6214	1.2071	3.0178
22	3.546	2.5652	3.2442	3.4705	2.8292	1.358	2.9424
23	3.546	2.5652	2.9047	3.5082	3.2065	1.5089	2.4897
24	2.9801	3.131	1.5844	3.546	3.6591	3.7346	1.4712
Max	4.7154	3.4705	4.5268	4.6106	4.5645	3.7346	4.3381
Min	2.4143	1.6221	1.4563	3.0178	2.8292	1.2071	1.4712
Avg	3.6673	2.7623	3.0447	3.7497	3.5879	2.1709	2.8181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 301 / 22KV KARANJE MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.2058	.2957	.2401	.2743	.2058
2	.2561	.2743	.2058	.2957	.2401	.2743	.2058
3	.2926	.2743	.2058	.2957	.2743	.2743	.2058
4	.2926	.3086	.2058	.2957	.2743	.2743	.2058
5	.2561	.3086	.2058	.2957	.2401	.2743	.2058
6	.2926	.3086	.2058	.2957	.2743	.2743	.2401
7	.2926	.3086	.2401	.2957	.2743	.2743	.2401
8	.2743	.2743	.3086	.3326	.3086	.2401	.3086
9	.3772	.3086	.4066	.3772	.3429		.3696
10	.3772	.3658	.4435	.3772	.3429		.3696
11	.3772	.3772	.4805	.439	.3429		.3696
12	.3772	.3429	.4066	.3429	.3772		.3696
13	.3772	.3429	.4435	.439	.3772		.3696
14	.3772	.3086	.4435	.4024	.3772		.4435
15	.3772	.3086	.4435	.3772	.4115		.4066
16	.3658	.3429	.4435	.4115	.4115		.3696
17	.3772	.3429	.3696	.3429	.4458	.2058	.4066
18	.3772	.3086	.3696	.3429	.4458	.2058	.4435
19	.3429	.3086	.3696	.3772	.3086	.2058	.3696
20	.3086	.2743	.3326	.3429		.2058	.2587
21	.3086	.2743	.2957	.3429	.3086	.2058	.2957
22	.3086	.2401	.2957	.3086	.3086	.2058	.2957
23	.2743	.2401	.2957	.3292	.2743	.2058	.2587
24	.2743	.2743	.2401	.2957	.2743	.2743	.2058
Max	.3772	.3772	.4805	.439	.4458	.2743	.4435
Min	.2401	.2401	.2058	.2957	.2401	.2058	.2058
Avg	.3240	.3038	.3276	.3438	.3250	.2422	.3092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 302 / 22KV PRATAPGANJ PETH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.0288	1.0631	1.2567	1.2346	1.0974	1.2346
2	1.0631	1.0288	1.0288	1.2197	1.2803	1.0974	1.1317
3	1.0631	1.0288	1.0288	1.2197	1.166	1.0974	1.0974
4	1.0974	1.2003	1.166	1.2197	1.2803	1.3032	1.2003
5	1.166	1.3717	1.3375	1.3306	1.3032	1.3717	1.3717
6	1.5775	1.5432	1.6461	1.7372	1.6975	1.5432	1.6118
7	2.1216	1.7147	2.0576	2.1437	2.1582	1.8861	2.0576
8	2.2634	2.1262	2.0233	2.1807	2.2291	2.2291	2.4006
9	1.989	1.9204	1.922	1.9547	1.9547		1.7741
10	1.7833	1.6804	1.5893	1.7833	1.7833		1.6632
11	1.829	1.5432	1.4045	1.6118	1.5432		1.4045
12	1.6461	1.5775	1.2936	1.5775	1.3717		1.2567
13	1.4632	1.4746	1.3676	1.406	1.2346		.5914
14	1.1706	1.4403	1.3676	1.3717	1.0974		1.3676
15	1.0974	1.3375	1.4045	1.3375	1.0974		1.3676
16	1.0974	1.3375	1.4784	1.3717	1.0974		1.5154
17	1.1317	1.4746	1.5524	1.3717	1.3717	1.2003	1.5893
18	1.2003	1.7147	1.5893	1.4403	1.4403	1.3717	1.5893
19	1.9204	2.0233	2.3285	1.989	2.0576	2.0576	2.4764
20	1.9547	2.1262	2.3285	2.1605		2.2291	2.4025
21	1.7833	1.8861	2.1807	2.0576	2.0576	2.1262	2.2546
22	1.7147	1.7147	1.922	2.0485	2.0576	1.8861	2.0698
23	1.6118	1.0974	1.5524	1.6461	1.7147	1.5089	1.7002
24	1.39	1.0974	1.1317	1.2936	1.2689	1.2346	1.3375
Max	2.2634	2.1262	2.3285	2.1807	2.2291	2.2291	2.4764
Min	1.0631	1.0288	1.0288	1.2197	1.0974	1.0974	.5914
Avg	1.5127	1.5203	1.5735	1.6137	1.5434	1.5775	1.6027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 303 / 22KV SUSHAMA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.3772	.3696	.4115	.4115	.4115
2	.3429	.4801	.3429	.3696	.4527	.4115	.3772
3	.3658	.5487	.3429	.3696	.439	.4115	.3772
4	.3772	.6173	.4115	.3696	.439	.4801	.4115
5	.4115	.6516	.5144	.4805	.5121	.5487	.5144
6	.5487	.6859	.6516	.6283	.6219	.6173	.6173
7	.9145	.7202	.7888	.8501	.8779	.6859	.7545
8	.8573	.9259	.7888	.8871	.9877	.9259	.8916
9	.7888	.8573	.7762	.7888	.823		.7392
10	.6859	.8573	.6653	.7545	.6859		.7392
11	.6173	.7545	.7023	.7202	.6173		.7023
12	.583	.6859	.6653	.6859	.5487		.6283
13	.5144	.6173	.5175	.6173	.4801		.5914
14	.3772	.5487	.5544	.6173	.4801		.5544
15	.4801	.5144	.5544	.6173	.4801		.5914
16	.4801	.5144	.6283	.5144	.4801		.6653
17	.5487	.583	.5914	.5144	.583	.5144	.6653
18	.6173	.6859	.5914	.5144	.6859	.5487	.6653
19	.7545	.7202	.8131	.7682	.7545	.6859	.8871
20	.7202	.7545	.7392	.7202		.7545	.8131
21	.6859	.6859	.6653	.7316	.6859	.7202	.7762
22	.6173	.6173	.6283	.6859	.6859	.6173	.7023
23	.5487	.5144	.5175	.5853	.583	.5144	.5914
24	.3772	.3772	.4115	.4066	.4458	.4115	.4458
Max	.9145	.9259	.8131	.8871	.9877	.9259	.8916
Min	.3429	.3772	.3429	.3696	.4115	.4115	.3772
Avg	.5649	.6373	.5933	.6069	.5983	.5787	.6297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 304 / 22 KV MANGALWAR TALE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.0288	1.0974	1.2936	1.3535	1.0288	1.2003
2	1.2346	1.0288	1.0288	1.2567	1.3169	1.0288	1.1317
3	1.2003	1.0288	1.0288	1.2567	1.2803	1.0288	1.0974
4	1.2003	1.166	1.2003	1.2567	1.2803	1.3032	1.2346
5	1.3535	1.3717	1.3717	1.3306	1.4266	1.4403	1.3717
6	1.6804	1.5089	1.7833	1.885	1.7924	1.7147	1.8861
7	2.1262	1.7833	2.1262	2.2177	2.3045	1.989	2.0576
8	2.4874	2.2727	2.1605	2.2916	2.524	2.1948	2.332
9	2.1948	2.2291	2.2916	2.2977	2.332		2.2916
10	1.9547	2.1262	1.9959	2.2291	2.0576		2.2177
11	1.9547	2.0576	2.0328	2.1262	2.0576		2.2177
12	1.9547	1.9547	1.9589	1.989	2.0576		2.1437
13	1.7833	1.749	1.8111	1.9204	1.989		1.9959
14	1.7147	1.6804	1.7741	1.829	1.7147		1.922
15	1.7147	1.6461	1.7002	1.7924	1.7833		1.922
16	1.7147	1.749	1.7372	1.7147	1.7833		1.922
17	1.7147	2.0233	1.885	1.8861	1.7833	1.7833	2.1068
18	1.8519	2.2291	2.2546	2.1605	2.0576	1.8861	2.6242
19	2.572	2.6749	2.809	2.963	2.7435	2.0576	3.1047
20	2.5377	2.572	2.5873	2.9264		2.572	2.846
21	2.1605	2.1948	2.2916	2.3777	2.1948	2.3663	2.3655
22	1.8519	1.9547	1.9959	2.1216	2.0576	2.0576	2.0698
23	1.6804	1.5775	1.6263	1.7558	1.7833	1.7147	1.7372
24	1.2689	1.3717	1.2003	1.3676	1.3375	1.0288	1.3375
Max	2.572	2.6749	2.809	2.963	2.7435	2.572	3.1047
Min	1.2003	1.0288	1.0288	1.2567	1.2803	1.0288	1.0974
Avg	1.7976	1.7908	1.8229	1.9269	1.8701	1.6997	1.9640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 305 / 22 KV S. T. STAND

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0288	1.0288	1.1458	1.2003	1.0974	
2	1.0631	1.0288	1.0288	1.1458	1.2437	1.0974	1.1317
3		1.0288	1.0288	1.1458	1.2437	1.0974	1.0974
4	1.0631	1.5432	1.166	1.1458	1.3203	1.3717	1.1317
5	1.1317	1.3717	1.3032	1.2567	1.39	1.5089	1.3032
6	1.4403	1.5432	1.4746	1.5154	1.5729	1.5775	1.5432
7	1.9547	1.6118	1.9547	1.9959	2.1216	1.7147	1.8861
8	2.1216	1.9204	1.9204	2.1068	2.1948		2.1262
9	1.8519	1.7833	1.848	1.8176	1.749		1.848
10	1.7147	1.7833	1.6632	1.6461	1.5432		1.8111
11	1.5432	1.6827	1.7002	1.6804	1.3717		1.3306
12	1.3717	1.5089	1.6632	1.6461	1.2346		1.922
13	1.2346	1.5432	1.6632	1.5775	1.0974		1.8111
14	1.0974	1.5432	1.6263	1.5089	1.0974		1.6632
15	1.0288	1.4403	1.5893	1.4746	1.0974		1.7372
16	1.0288	1.4403	1.7372	1.3717	1.0974		1.7002
17	1.4746	1.5432	1.7372	1.4403	1.6118	1.5432	1.848
18	1.6461	1.7147	1.885	1.5432	1.7147	1.7147	1.922
19	1.9547	2.0919	2.2546	2.1582	2.2291	1.8861	2.5133
20	1.9547	2.0576	2.2177	2.1582		2.1262	2.3285
21	1.7833	1.9204	2.0698	1.9753	2.0576	2.0233	2.1068
22	1.7147	1.749	1.7372	1.9022	1.7833	1.8861	1.848
23	1.4746	1.3717	1.4415	1.6095	1.6461	1.5432	1.5154
24	1.0974	1.0288	1.0974	1.2567	1.2346	1.2346	1.2346
Max	2.1216	2.0919	2.2546	2.1582	2.2291	2.1262	2.5133
Min	1.0288	1.0288	1.0288	1.1458	1.0974	1.0974	1.0974
Avg	1.4714	1.5533	1.6182	1.5927	1.5153	1.5615	1.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 403 / 33 KV MEDHA OUTGOING
Feeder KV- 33 / INCOMINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7778	1.5432	1.5432	.6653	2.524	1.9547	2.0576
2	2.4691	1.5432	1.3889	.6653	2.7435	1.9547	1.8004
3	2.7778	1.5432	1.286	.6653	2.6337	1.9547	1.8004
4	3.0864	2.0576	1.1831	.6653	2.4691		2.0576
5	3.2922	2.572	1.0288	.7207	2.6886	2.5206	2.572
6	3.2407	3.0864	.9259	1.1088	2.9081	2.6749	2.9835
7	4.8868	4.1667	1.6461	1.7187	4.7188	2.7778	4.1152
8	6.2003	5.7613	1.9547	1.9959	5.487	3.7551	4.8354
9	6.1214	3.2922	2.2177	2.0062	4.9897	3.858	5.2115
10	3.2407	3.1379	2.3285	2.1399	4.8354		.2772
11	4.8354	4.8868	2.2177	6.8587	4.8354		1.1088
12	5.0412	1.0288	2.0513	6.0357	5.4012		1.7187
13	4.9383	1.6409	1.6632	5.487	5.5041		1.4415
14	4.5268	1.6461	1.6632	5.487	5.144		1.1088
15		1.6975	1.6632	5.3224	5.144		1.3306
16	3.2922	1.6975	2.0513	4.9383	5.144		1.1088
17	5.0412	2.0576	1.4969	5.4321	5.2469	3.3436	1.386
18	4.9897	2.2119	1.9404	5.2469	4.9383	2.6749	1.6078
19	3.2922	2.3663	2.3285	3.1276	3.4465	2.6749	2.1622
20	3.2922	2.3148	2.0513	3.5117		2.9321	1.8296
21	2.9835	2.2119	1.4969	2.9081	2.8807	2.7263	1.4415
22	2.6749	2.0576	1.1643	2.3045	2.5206	2.572	.7207
23	1.9547	1.8004	.8316	1.7558	1.9033	2.3148	.4435
24	2.7778	1.6461	1.6461	.6653	2.0576	2.0576	2.0576
Max	6.2003	5.7613	2.3285	6.8587	5.5041	3.858	5.2115
Min	1.9547	1.0288	.8316	.6653	1.9033	1.9547	.2772
Avg	3.8145	2.4153	1.6570	2.9764	3.9202	2.6717	1.9657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 301 / 22 KV PIRWADI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5975	.5853	.6584	.5228	.6584	.7392
2	.5544	.4481	.5853	.5914	.4805	.6219	.7468
3	.3696	.4527	.5544	.5914	.4904	.6283	.5658
4	.3696	.4527	.5487	.5914	.415	.6283	.4904
5	.5853	.4481	.5853		.5544	.6653	.4854
6	.8501	.6653	.8871	.7468	1.0082	.8962	.8131
7	1.2323	.924	1.1827	.9979	1.2567	1.1203	1.3306
8	1.307	1.2323	1.2323	1.1088	1.1576	1.1458	1.2323
9	1.0829	1.0829	1.0829	1.134	1.0456	1.1088	1.0829
10	.924	.961	.924	1.0456	1.0185	.9511	1.094
11	.8589	.8501	.8871	.924	.9054	.5281	.9979
12	.7842	.8131	.924	.8871	.8871	.4854	.8676
13	.7842	.7762	.8501	.7095	.8215	.9808	.8215
14	.7842	.7023	.8048	.7095			.8299
15	.7842	.7023	.8048	.7682	.8589	.9431	.8215
16	.7842	.7023	.8131	.7842	.8215	.8676	.8299
17	.8215	.7023	.8215	.9431	.8215	.8962	.8676
18	.8589	.7842	.8501	.8871	.8962	.8962	.9335
19	1.0829	1.0829	1.1088	1.0456	1.1088	1.2696	1.1949
20	1.0719	1.1088	1.1706	1.1949	1.2197	1.2696	1.2197
21	1.0829	1.0608	1.0974	1.1458	1.134	1.1949	1.1827
22	.9979	.9877	.924	1.1203	1.0608	1.0719	1.1203
23	.8589	.8871	.8871	.9335	.924	.9335	.9335
24	.695	.6653	.6584	.695	.7392	.7392	.7842
Max	1.307	1.2323	1.2323	1.1949	1.2567	1.2696	1.3306
Min	.3696	.4481	.5487	.5914	.415	.4854	.4854
Avg	.8379	.7954	.8654	.8788	.8760	.8913	.9161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 302 / 22 KV SADAR BAZAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7468	.8413	.8048	.9709	.8779	.924
2	.7023	.7468	.7682	.7762	.8871	.8048	.8962
3	.6653	.679	.7392	.7762	.9054	.8131	.9431
4	.6584		.7316	.7762	.8299	.8131	1.0185
5	.7316	.5975	.7316	.8215	.924	.8501	.9709
6	.961	.8131	1.0719	.9335	1.2323	1.0082	.9979
7	1.4937	1.0349	1.4415	1.1088	1.5524	1.4563	1.5154
8	1.531	1.4563	1.419	1.4415	1.4937	1.4415	1.4563
9	1.4563	1.419	1.3817	1.5729	1.3676	1.3676	1.39
10	1.0829	1.2567	1.0829	1.2696	1.1694	1.0829	1.1458
11	.9335	1.1088	.9709	1.1458	1.0185	.9709	1.0185
12	.8962	1.0349	.961	1.0456	.961	.8299	.9335
13	.8589	.924	.8501	.8048	.8871	.8131	.9145
14	.8589	.8871	.8501	.8131	.8962	.8501	.8589
15	.8589	.8871	.8131	.8962	.9054	.8299	.9145
16	.8962	.8501	.8871	.924	.9431	.8215	.9335
17	1.0082	.8501	.9709	.9335	1.0082	.8589	.9431
18	1.0456	1.0082	.9979	1.0719	1.0829	1.0082	1.0829
19	1.307	1.307	1.3306	1.3817	1.4415	1.4045	1.3817
20	1.2936	1.3676	1.4266	1.4563	1.4784	1.4563	1.4459
21	1.2323	1.2437	1.3169	1.4415	1.3535	1.4937	1.4045
22	1.1949	1.2071	1.1827	1.3443	1.3169	1.2936	1.3443
23	1.0082	1.0719	1.0719	1.1949	1.1827	1.1576	1.1576
24	.8048	.8131	.9145	.9145		.961	.9709
Max	1.531	1.4563	1.4415	1.5729	1.5524	1.4937	1.5154
Min	.6584	.5975	.7316	.7762	.8299	.8048	.8589
Avg	1.0088	1.0135	1.0314	1.0687	1.1221	1.0527	1.1068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 302 / 22 KV POWAI NAKA

Feeder KV- 22 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	2.7538
Max	2.7538
Min	2.7538
Avg	2.7538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 303 / 22 KV RADHAKRISHNA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	2.7915
Max	2.7915
Min	2.7915
Avg	2.7915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 304 / 22KV ARISTOCRAT

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	.3326
Max	.3326
Min	.3326
Avg	.3326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 305 / 22KV OKASA PHARMA
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	5.4698
Max	5.4698
Min	5.4698
Avg	5.4698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 402 / 33KV SIDDHIVINAYAK

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
24	6.2243
Max	6.2243
Min	6.2243
Avg	6.2243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 406 / 33 KV COOPER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	2.999
Max	2.999
Min	2.999
Avg	2.999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 411 / 33 KV OLD MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	8.2613
Max	8.2613
Min	8.2613
Avg	8.2613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 201 / PARALI-SATARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2075	.2054	.2058	.2075	.2241	.2075
2	.2401	.1886	.1867	.2058	.2075	.2054	.1886
3	.2401	.1886	.1867	.2058	.2075	.2054	.1886
4	.2401	.1886	.2987	.2572	.2075	.2054	.1886
5	.3086	.2054	.4108	.3429	.2263	.2241	.2054
6	.3944	.3174	.5788	.4287	.3174	.3361	.2987
7		.5175	.5788	.5316	.5121	.4854	.5175
8		.5544	.5788		.5487	.5228	
9	.4668	.4805	.5041	.5975	.4251	.4668	.5144
10	.4294	.499	.4115	.4108	.462	.4805	.5487
11	.4481	.4481	.3772	.4481	.4805	.462	.4801
12	.4805	.4108	.3772	.4481	.4066	.4251	.4801
13	.4668	.3734	.3772	.4108	.3511	.4251	.3772
14	.2957	.3547	.3429	.3734	.3696	.3881	.3772
15	.3142	.3361	.3429	.3361	.4066	.3326	.3944
16	.3361	.3361	.3258	.3361	.3511	.3696	.3944
17	.4294	.4294	.4287	.3547	.4481	.3696	
18	.5975	.5228	.5487	.4251	.4481	.4108	
19	.5975	.6161	.6516	.5788	.5601	.5601	
20	.5601	.6161	.6001	.5975	.6722	.6348	
21	.5601	.5228	.5144	.5788		.6161	
22	.4108	.4854	.463	.5228		.5228	
23	.3018	.2987	.3086	.3206		.3772	
24	.1372	.2452	.2427	.2058	.2452	.2641	.2452
Max	.5975	.6161	.6516	.5975	.6722	.6348	.5487
Min	.1372	.1886	.1867	.2058	.2075	.2054	.1886
Avg	.3862	.3893	.4101	.3966	.3838	.3964	.3504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 202 / THOSEGHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1509	.168	.1372	.1509	.168	.1698
2	.1372	.1509	.168	.1372	.1509	.168	.1698
3	.1372	.1509	.1509	.1372	.1509	.1494	.1698
4	.1715	.1509	.2241	.2058	.1509	.1494	.1698
5	.1886	.1698	.3547	.2401	.1698	.2241	.1886
6	.2229	.2452	.4294	.3086	.2614	.2987	.2614
7		.3361	.4294	.3601	.3696	.4108	.3696
8		.4668	.4294	.4108	.4066	.4294	.4668
9	.3921	.4481	.3734	.3734	.3361	.3921	.3086
10	.3734	.3174	.3086	.3734	.2987	.3174	.3429
11	.2987	.2801	.2401	.3361	.2987	.3174	.2401
12	.2614	.2427	.2401	.2987	.2801	.3174	.2401
13	.2801	.2241	.2401	.2987	.2427	.2427	.2401
14	.2427	.2054	.2401	.2987	.2614	.2427	.2401
15	.2241	.2241	.2401	.2987	.2801	.2614	.2915
16	.2241	.2427	.2401	.2987	.2427	.2987	.2915
17	.2614	.2801	.2401	.2987	.2987	.2614	
18	.2587	.3734	.3772	.3361	.3547	.3174	
19	.4108	.4481	.463	.5041	.3921	.5041	
20	.4854	.4668	.4287	.4854	.4668	.5228	
21	.4108	.3734	.3772	.4481	.3361	.4668	
22	.4108	.3361	.3086	.3734		.3772	
23	.2075	.2427	.1886	.2263		.2263	
24	.2058	.1698	.1867	.1372	.1698	.1867	
Max	.4854	.4668	.463	.5041	.4668	.5228	.4668
Min	.1372	.1509	.1509	.1372	.1509	.1494	.1698
Avg	.2701	.2790	.2936	.3051	.2759	.3021	.2600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 203 / Nitral Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0189	.0373	.0343	.0189	.0187	.0189
2	.0343	.0189	.0187	.0343	.0189	.0187	.0189
3	.0343	.0189	.0187	.0343	.0189	.0187	.0189
4	.0343	.0189	.0373	.0514	.0189	.0187	.0189
5	.0343	.0189	.056	.0686	.0189	.0187	.0189
6	.0514	.0566	.112	.0857	.0566	.056	.056
7		.0747	.112	.1029	.0934	.0934	.4668
8			.1307	.0934	.0934	.0934	.112
9	.056	.056	.0934	.112	.0934	.0747	.0686
10	.0747	.056	.0686		.0747	.056	.0343
11	.0373	.056	.0514	.0747	.056	.0373	.0514
12	.0747		.0514	.0373	.056	.0373	.0514
13	.056	.056	.0514	.056	.0373	.0373	.0514
14	.0747	.056	.0514	.056	.056	.0373	.0514
15	.0747	.056	.0514	.056	.056	.0373	.0686
16	.0747	.0747	.0514	.056	.056	.0373	.0686
17	.0934	.056	.0686	.056	.056	.056	
18	.0934	.0747	.0857	.056	.056	.0934	
19	.0934	.112	.1029	.0934	.0747	.0934	
20	.1307	.112	.0857	.112	.112	.0934	
21	.0934	.0747	.0686	.0934		.0747	
22	.0754	.0747	.0514	.0747		.0754	
23	.0377	.056	.0343	.0377		.0377	
24	.0686	.0189	.056	.0343	.0377	.0187	.0189
Max	.1307	.112	.1307	.112	.112	.0934	.4668
Min	.0343	.0189	.0187	.0343	.0189	.0187	.0189
Avg	.0651	.0553	.0644	.0657	.0552	.0514	.0702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 204 / PARALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0395	.8916	.9431			
2		1.0059	.8573	.9431			
3		1.0059	.8764	.9431			
4		.9945	.9465	.9431			
5		.9945	1.0631	1.0288			
6		1.0277	1.3565	1.1145			
7		1.1142	1.3565	1.2517			
8		1.1797	1.3735	1.3546			
9		1.2452	1.1191	1.1488			
11	1.8747				1.7147	1.5655	1.7147
12	1.8747				1.7833	1.8138	1.7147
13	1.8435				1.8519	1.6821	1.7147
14	1.8435				1.8519	1.8023	1.7147
15	1.7497				1.8347	1.6446	1.7147
16	1.7185				1.4746	1.5546	1.7147
17	1.3927				1.4575	1.4074	
18	1.2574				1.4575	1.2803	
24	.0686	1.0159	.9431				
Max	1.8747	1.2452	1.3735	1.3546	1.8519	1.8138	1.7147
Min	.0686	.9945	.8573	.9431	1.4575	1.2803	1.7147
Avg	1.5137	1.0623	1.0784	1.0745	1.6783	1.5938	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 205 / Bhondawade Lis

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
1		.1307
2		.1307
3		.112
4		.1307
5		.1494
6		.1494
7		.1494
8		.1494
9		.1494
10		.1372
11		.1372
12		.1372
13		.1372
14	.0747	.1372
15	.0747	.1372
16	.2054	.1372
17	.1867	.1372
18	.2054	.1372
19	.2241	.1372
20	.1494	
21	.1494	
22	.1867	
23	.1867	
24		.1494
Max	.2241	.1494
Min	.0747	.112
Avg	.1643	.1386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 401 / 33 kv avalon power

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.7726	2.8006	2.4691	2.6029	2.8292	2.6326
2	2.0576	2.7726	2.8006	2.4691	2.6029	2.8292	2.6326
3	2.0576	2.7726	2.8006	2.4691	2.6029	2.8292	2.6326
4	2.0576	2.7726	2.8006	2.4691	2.6029	2.8292	2.6326
5		2.7726	2.8006	2.4691		2.8292	2.6326
6		2.7726	2.8006	2.4691	2.6029	2.8292	2.6326
7		2.7726	2.8567	2.4691	2.7161	2.8292	2.6326
8		2.7726	2.8567	2.6886	2.7161		2.6326
9	2.2405	2.7446	2.8567	2.6886		2.8292	2.4177
10	2.2405	2.7446	2.572	2.6886		2.9127	2.4177
11	2.3525	2.7446	2.572	2.6886	2.6595	2.8829	2.5206
12	2.2965	2.7446	2.572	2.6886	2.6595	2.9384	2.5206
13	2.2965	2.7446	2.572	2.6886	2.6595	2.8567	2.5206
14	2.3525	2.7446	2.572	2.6886	2.6595	2.8567	2.5206
15	2.3525	2.8006	2.572	2.6326	2.6595	2.9127	2.5206
16	2.3525	2.8006	2.572	2.6886	2.6595	2.8006	2.5206
17	2.8006	2.8006	2.572	2.6886	2.8292	2.8006	
18	2.9127	2.6886	2.572	2.6886	2.9424	2.6326	
19	2.8006	2.8006	2.572		2.8858	2.6326	
20	2.6886	2.7446	2.4691	2.5766	2.8858	2.6326	
21	2.6886	2.7446	2.4691	2.5766		2.6326	
22	2.6886	2.7446	2.4691	2.5766		2.6326	
23	2.7161	2.6886		2.6029		2.6326	
24	2.0576	2.7726	2.8006	2.4691	2.6029		2.6595
Max	2.9127	2.8006	2.8567	2.6886	2.9424	2.9384	2.6595
Min	2.0576	2.6886	2.4691	2.4691	2.6029	2.6326	2.4177
Avg	2.4034	2.7598	2.6653	2.5915	2.6972	2.7905	2.5694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 201 / 11 KV ANGAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	1.6024	1.4779	1.3173		.128	.1195
2	.1097	1.6078	1.4484	1.3108		.1244	.127
3	.1166	1.5813	1.4124	1.3141		.1183	.1232
4	.12	1.5565	1.3763	1.3501		.128	.127
5	.12	1.5533	1.4091	1.3894		.1317	.1344
6	.1029	1.578	1.455	1.4124		.139	.1456
7	.1132	1.7101	1.6336	1.4467		.1294	.1419
8	.1372	1.7684	1.7564	1.5236		.1083	.1195
9	.152	1.7028	1.6907	1.451	.1456	.0671	.1024
10	.1665	.112	.0983	.1134	.127	.0777	.0988
11	2.7985	.1438	.0738	.152	2.4006	2.6216	2.7206
12	2.7887	.0896	.0872	.1353	2.4966	2.6118	2.7718
13	2.7428	.1046	.1286	.1207	2.4582	2.6019	
14	2.5943	.1232	.1166	.1317	2.4454	2.5626	
15	2.5331	.1288	.1097	.1412	2.3173	2.6189	2.3449
16	2.4446	.1214	.1166	.1171	2.2917	.2429	2.5953
17	2.332	.1122	.1232	.1267	2.1895		2.5691
18	2.3135	.0977	.1046	.1231	2.1038	2.1253	2.4905
19	.1898	.15	.1307	.1536	.1536	.1344	.1235
20	.1629	.1339	.1419	.1756	.1484	.1419	.1006
21	.1975	.1303	.14	.1866	.1536	.1531	.1174
22	.15	.1267	.127	.1701	.1331	.1288	.1029
23	.1463	.1267	.1195	.1376	.1146	.1232	.1085
24	.1029	1.6188	1.5008	1.2931	.1448	.1146	.112
Max	2.7985	1.7684	1.7564	1.5236	2.4966	2.6216	2.7718
Min	.1029	.0896	.0738	.1134	.1146	.0671	.0988
Avg	.9474	.7492	.6991	.6581	1.2390	.7536	.7907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 202 / 11 KV ANGAPUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1904	.2063	.2158		.1904	.1866
2	.1774	.1867	.2027	.2085		.183	.1792
3	.1626	.183	.1991	.2012		.1718	.1719
4	.1867	.1718	.2136	.2158		.168	.1792
5	.2483	.1942	.2353	.2305		.1942	.2268
6	.3918	.3031	.3837	.2968		.3105	.3077
7	.5563	.407	.4217	.394		.3987	.4012
8	.4694	.414	.4463	.4513		.4033	.394
9		.3475	.3384	.3473	.3113	.3632	.3361
10		.2524	.3418	.3323	.2914	.326	.3286
11		.2932	.2172	.3099	.2341	.2658	.2763
12		.2896	.2126	.239	.2122	.2606	.2661
13		.2787	.1981	.2203	.2451	.2349	.2016
14		.2634	.2347	.2054	.2085	.2281	.2875
15		.278	.2212	.2181	.2048	.2254	.2539
16		.2743	.2435	.2763	.2305	.208	.2539
17	.3174	.286	.2652	.2425			.2846
18	.2763	.3656	.3185	.3113	.3099	.3765	.3381
19	.3734	.4235	.3976	.4308	.4316	.4226	.4253
20	.3992	.3928	.4262	.3801	.4145	.4549	.4908
21	.3548	.3511	.3761	.3547	.3361	.3707	.3801
22	.3062	.3077	.3294	.3113	.2987	.3294	.3475
23	.2241	.2407	.2643	.2208	.2166	.2414	.2476
24	.2054	.1979	.2118	.2231	.1955	.1792	.1939
Max	.5563	.4235	.4463	.4513	.4316	.4549	.4908
Min	.1626	.1718	.1981	.2012	.1955	.168	.1719
Avg	.3023	.2872	.2877	.2849	.2761	.2829	.2899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 204 / 11 KV JIHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1405	.1531	.1504	.1756		.1904	.1975
2	.1382	.1494	.1484	.1683		.183	.1866
3	.1509	.1456	.1433	.161		.1774	.1756
4	.168	.1419	.1683	.1646		.1718	.1792
5	.1999	.1643	.2027	.1902		.1979	.1939
6	.3471	.3142	.3098	.2643		.3216	.333
7	.4481	.439	.4959	.4191		.4706	.4585
8	.4066	.4103	.439	.4334		.4103	.4191
9	.3149	.3728	.3292		.3149	.3439	.2987
10	.3113	.2751	.2686	.3025	.2487	.2481	.3256
11	.2896	.2643	1.9891	.2689	.1902	.2401	.2698
12	.2787	.2751	.2622	.2651	.2305	.2366	.295
13	.2353	.2451	.2382	.2587	.2085	.2058	.2465
14	.2317	.2378	.2331	.2315	.1975	.2058	.3025
15	.2244	.2414	.2229	.2439	.2268	.2195	.2614
16	.2172	.2817	.2812	.2328	.2231	.2331	.2577
17	.2476	.2842	.2968	.2896	.3179		.2401
18	.2809	.3294	.3475	.3149	.3622	.2968	.2878
19	.3881	.4923	.4191	.4163	.5104	.4334	.4706
20	.3877	.429	.4334	.4742	.4778	.4441	.4706
21	.3548	.333	.3692	.4054	.3797	.3833	.3987
22	.2772	.3023	.3366	.3294	.3326	.351	.3658
23	.1904	.1864	.2085	.2534	.2278	.2451	.2587
24	.1494	.1606	.1557	.1792	.2027	.1922	.2048
Max	.4481	.4923	1.9891	.4742	.5104	.4706	.4706
Min	.1382	.1419	.1433	.161	.1902	.1718	.1756
Avg	.2658	.2762	.3520	.2801	.2907	.2783	.2957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 205 / 11 KV VIJAY NAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1904					1.0656	1.1523
2	1.1469					1.1006	1.1459
3	1.1174					1.0814	1.1395
4	1.1142					1.0716	1.1331
5	1.1142					1.0945	1.1235
6	1.1239					1.1961	1.1139
7	1.1465					1.3379	1.2195
8	1.2809					1.4121	1.1107
9	1.1895				1.4156	1.3108	1.2682
11		1.7988	1.966	2.1333			
12		1.7796	2.0729	2.284			
13		1.8788	2.3266	2.2545			
14		1.9076	2.3045	2.1182			
15		1.9268	2.284	2.1005			
16		1.7316	2.0317	1.9822			
17		1.881	1.5908	1.9924			
18		1.7231		1.8202			
23	1.1895						
24	1.1731				1.337	1.0663	1.1863
Max	1.2809	1.9268	2.3266	2.284	1.4156	1.4121	1.2682
Min	1.1142	1.7231	1.5908	1.8202	1.337	1.0656	1.1107
Avg	1.1624	1.8284	2.0824	2.0857	1.3763	1.1737	1.1593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 206 / Tasgaon Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0194	.0411	.0434	.0448		.8316	.852
2	.9831	.0373	.0398	.0411		.845	.8455
3	.9976	.0336	.0398	.0373		.8321	.8258
4	.9393	.0336	.0434	.0373		.8254	.8061
5	.9667	.0373	.0507	.0411		.8387	.7865
6	1.0159	.0411	.0585	.0523		.852	.7799
7	1.2125	.0523	.0579	.0635		.9328	.8881
8	1.0559	.0444	.0543	.056		1.0409	.9666
9	1.0267	.0523	.0251	.0373	.8422	.9389	.9978
10	.0471	.0485	.0335	.0373	.0336	.0203	.0336
11	.0439	1.5171	1.5384	1.5303	.0411	.0332	.0373
12	.0434	1.7636	1.7101	1.562	.0336	.0343	.037
13	.0434	1.562	1.7202	1.0343	.0448	.0335	.0411
14	.0434	1.4947	1.6032	1.3251	.0485	.0285	.0336
15	.0434	1.4779	1.492	1.2835	.0448	.0251	.0373
16	.0434	1.5959	1.438	1.302	.0411	.017	.0373
17	.0591	1.55	1.3861	1.2583	.0411		.0343
18	.0373	1.4156		1.1174	.0373	.0523	.0285
19	.0407	.0471	.0523	.0579	.0336	.0523	.0171
20	.0373	.0471	.056	.0579	.0411	.0485	.0206
21	.0373	.0471	.0523	.0543	.0373	.0485	.0291
22	.0336	.0471	.0485	.0543	.0373	.0485	.0251
23	.0407	.0434	.0485	.0543	.0411	.0448	.0251
24	1.0044	.0373	.0434	.0448	.8291	.7799	.8586
Max	1.2125	1.7636	1.7202	1.562	.8422	1.0409	.9978
Min	.0336	.0336	.0251	.0373	.0336	.017	.0171
Avg	.4506	.5445	.5059	.4660	.1392	.4002	.3768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 201 / 11 KV VALASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	1.8347	2.0062		.0857	.0514	.0686
2	.0514	1.8004	1.989		.0857	.0514	.0686
3	.0514	1.8004	1.9547		.0514	.0514	.0686
4	.0514	1.8519	1.9547		.0514	.0514	.0686
5	.0686	1.9376	1.9547		.0686	.0686	.0686
6	.0686	2.0233	2.1605		.0857	.0686	.0857
7	.0857	2.0576	2.1091		.0857	.0686	.0857
8	.0857	2.1434	2.332		.0857	.0686	.0857
9	.0686	1.9547	2.2291		.0857	.0514	.0857
10	.0686	.0686	.0514	.0514	.0857	.0514	.0686
11	1.9033	.0857	.0686	.0686	2.3834	2.7435	2.5034
12	1.5775	.0857	.0857	.0686	2.572	2.8292	
13	1.9204	.0857	.0857	.0686	2.5206	2.8121	2.572
14	1.7318	.0857	.0857	.0514	2.6749	2.5206	2.7092
15	2.4006	.0857	.0857	.0514	2.5206		2.7435
16	2.6235	.0857	.0857	.0514	2.0576	2.6235	2.7092
17	2.3663	.0857	.0857	.0514	2.3148	2.3663	2.5549
18	2.1091			.0514	2.2634	2.2634	2.4348
19	.0514	.1543		.1029	.0514	.0686	.1029
20	.0514	.2229		.1029	.0514	.1029	.1029
21	.0686	.2058		.1029	.0686	.1029	.1029
22	.0686	.2058		.0857	.0686	.1029	.1029
23	.1372	.1372		.0857	.0686	.1029	.0857
24	.0686	1.869	1.8861		.0857	.0514	.1029
Max	2.6235	2.1434	2.332	.1029	2.6749	2.8292	2.7435
Min	.0514	.0686	.0514	.0514	.0514	.0514	.0686
Avg	.7395	.9073	1.1784	.0710	.8530	.8380	.8514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 203 / SUGARMILL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18
HR	Load (MW)
23	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 204 / 11 KV SHENDRE-VECHALE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9376	.0686	.0857		2.0062	1.5775	1.7147
2	1.9204	.0514	.0857		1.9719	1.5432	1.7147
3	1.9204	.0514	.0857		1.989	1.5947	1.6975
4	1.9547	.0514	.0857		1.989	1.6804	1.6804
5	1.9719	.0686	.0857		1.989	1.749	1.6975
6	2.0576	.0686	.0857		2.0405	1.8347	1.7318
7	2.2805	.0857	.0857		2.1776	1.9376	2.0405
8	2.2119	.0857	.0857		2.4459	2.0233	2.2634
9	2.1262	.0857	.0857		2.1262	1.9204	2.1262
10	.0686	.0686	.0686	.0857	.0686	.0686	.0857
11	.0857	2.9664	2.8464	2.915	.0686	.0686	.0857
12	.0686	3.1893	3.0864	2.8635	.0686	.0686	.0857
13	.0857	3.0178	3.0521	2.8292	.0686	.0686	.0857
14	.0857	3.2407	3.0521	2.7778	.0686	.0686	.0857
15	.0857	3.0693	3.0178	2.8121	.0686		.0686
16	.1029	3.155	2.9835	2.8464	.0686	.0686	.0686
17	.0857	3.1379	2.8464	2.7778	.0686	.0686	.0857
18	.1029	2.8464		2.2977	.0857	.0686	.0857
19	.1029	.0857		.0857	.0857	.0686	.1372
20	.1029	.0857		.0857	.0857	.0686	.12
21	.1029	.0857		.0857	.0857	.0686	.1029
22	.1029	.0857		.0857	.0857	.0686	.0857
23	.0857	.0857		.0857	.0857	.0686	.0686
24	1.9204	.0686	.0857		2.0405	1.6289	1.6804
Max	2.2805	3.2407	3.0864	2.915	2.4459	2.0233	2.2634
Min	.0686	.0514	.0686	.0857	.0686	.0686	.0686
Avg	.8988	1.0752	1.2117	1.6167	.9100	.7992	.8166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 205 / VALASE (GAONTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2229	.2058		.2743	.2058	.2743
2	.2743	.1715	.1715		.2743	.1715	.2572
3	.2058	.1886	.1715		.2743	.1715	.2058
4	.3258	.2572	.1886		.2743	.1886	.1886
5	.3429	.3429	.2401		.2743	.2401	.2058
6	.3429	.3772	.4458		.2743	.3086	.3429
7	.4287	.4458	.5316		.5144	.3772	.4973
8	.4973	.4458	.5144		.4973	.4287	.463
9	.4115	.4287	.5316		.4287	.4287	.4287
10	.3944	.4115	.4287	.4287	.463	.4115	.3772
11	.3772	.4287	.3944	.3944	.4115	.3944	.3772
12	.3944	.3258	.4115	.3772	.3944	.3944	.3772
13	.3258	.3086	.3429	.3601	.3944	.3601	.3601
14	.2915	.3429	.3772	.3429	.3429	.3086	.3429
15	.3601	.3772	.3601	.3429	.3601		.3944
16	.3086	.3772	.3601	.3429	.2058	.3258	.4115
17	.3601	.3601	.3772	.3601	.3944	.3429	.4287
18	.4115	.4287		.3944	.4287	.3772	.4115
19	.463	.5144		.3601	.5144	.4801	.4458
20	.4801	.5487		.4115	.5316	.5144	.3944
21	.4287	.4801		.5144	.5144	.4801	.4287
22	.3601	.4287		.463	.463	.4458	.4458
23	.3601	.3429		.3258	.3429	.3429	.3429
24	.3086	.2572	.2572		.2743	.2058	.2915
Max	.4973	.5487	.5316	.5144	.5316	.5144	.4973
Min	.2058	.1715	.1715	.3258	.2058	.1715	.1886
Avg	.3644	.3672	.3506	.3870	.3801	.3437	.3622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 206 / 11 KV SHENDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3772		.3601	.3429	.3944
2	.3258	.2915	.3601		.3429	.3086	.3944
3	.3258	.2915	.3601		.3258	.3258	.3944
4	.3258	.3429	.3601		.3258	.3772	.3944
5	.4287	.4801	.3601		.463	.4801	.4287
6	.6001	.6344	.5316		.583	.5658	.5316
7	.703	.7545	.7545		.7545	.703	.6859
8	.7716	.7545	.703		.703	.7716	.7545
9	.7888	.7888	.7373		.7716	.7716	.7545
10	.7888	.7545	.6859	.6859	.8916	.6173	.823
11	.7888	.7202	.6001	.6173	.6173	.6516	.7716
12	.7716	.6173	.6516	.5487	.3429	.5487	.6859
13	.6001	.5487	.4973	.5316	.3601	.4973	.6516
14	.7202	.5144	.4801	.4801	.6859	.5487	.6173
15	.703	.5658	.463	.6516	.8402		.6687
16	.7373		.4973	.7202	.8402	.6001	.703
17	.6687	.6344	.5144	.703	.7202	.583	.6516
18	.6859	.6173		.6344	.7373	.5144	.583
19	.7202	.6859		.7202	.7716	.6687	.7373
20	.703	.703		.6344	.7716	.7545	.8059
21	.6344	.5658		.6173	.6859	.703	.7888
22	.5658	.583		.5144	.6516	.583	.823
23	.3772	.4973		.463	.5144	.4973	.6001
24	.4287	.3429	.4115		.3944	.4115	.4287
Max	.7888	.7888	.7545	.7202	.8916	.7716	.823
Min	.3258	.2915	.3601	.463	.3258	.3086	.3944
Avg	.6044	.5651	.5192	.6087	.6023	.5576	.6280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 401 / 33 KV AJINKYATARA
 SUTGIRANI EX Feeder KV- 33 /
 OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
 (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2119	2.1605			2.1605	1.8004	2.1605
2	2.1605	2.0576			2.1605	1.8004	2.3148
3	2.0576	2.0576			2.2119	1.8519	2.2634
4	2.0576	2.1091			2.2119	1.9547	2.3148
5	2.0576	2.3148			2.1605	2.0576	2.1605
6	2.1091	2.3148			2.1605	2.2119	2.3148
7	2.0576	2.3663			2.3148	2.3148	2.4691
8	2.0576		.1543		2.1091	2.3663	2.3148
9	2.3148		1.6975		2.3148	2.3148	1.8004
10			2.5206	1.6975	2.1605	2.3148	2.0062
11	2.3148		2.1605	2.0062	1.8519	2.2634	2.1605
12	2.2119	.1543		2.1605	2.3148	2.1091	2.2119
13	2.3148		2.1605	2.2119	2.4691	2.0576	2.3148
14	2.5206		2.1605	2.3148	2.3148	2.3148	2.3148
15	2.1091		2.1605	2.3148	2.1605		
16	2.1091		2.3148	2.3663	2.3148	2.2634	2.3663
17	2.1605		2.3148	1.6461	2.3148	2.2634	2.3148
18	1.749			1.9033	2.3663	2.3148	2.3148
19	1.749			2.3148	2.4691	2.1605	2.4177
20	1.8004			2.2634	2.4691	2.1605	2.3148
21	2.1605			2.3148	2.3148	2.3148	2.2119
22	2.3663			2.1605	2.1605	2.3148	2.2119
23	2.3663			2.1605	2.0062	2.1605	2.2119
24	2.3148	2.3148			2.1091	1.9547	2.3148
Max	2.5206	2.3663	2.5206	2.3663	2.4691	2.3663	2.4691
Min	1.749	.1543	.1543	1.6461	1.8519	1.8004	1.8004
Avg	2.1448	1.9833	1.9604	2.1311	2.2334	2.1583	2.2522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 302 / LIMB

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3696	.3395	.4435	.4108	.4066	.3658
2	.3734	.3326	.3018	.4066	.3696	.3696	.3658
3	.3395	.3326	.3018	.4066	.3696	.3696	.3292
4	.3395	.3326	.3018	.3696	.3734	.3696	.3292
5	.3734	.3326	.3018	.3696	.4108	.3696	.3658
6	.4108	.3696	.2987	.4435	.4481	.4066	.3658
7	.4854	.3696	.3361	.5175	.7023	.4435	.3658
8	.4481	.4066	.4108	.5228	.7095	.4435	.5228
9	.7316	.4854	.6653		.8962	.4108	.6653
10	.8596	.4854	.8871	1.1458	1.3817	.4066	.924
11	1.0387	.5228	.5914	1.3306	1.531	.4108	1.2567
12	.9465	.4108	1.0349	1.2567	1.7551	.1494	1.1458
13	1.0985	.4066	1.1088	1.1088	1.1949	.1326	1.1827
14	1.134	.4854	.924	1.1827	1.2696	.1238	1.0719
15	1.2048	.5601	1.2567	1.2323	1.307	.1174	1.0349
16	1.0985	.4481	1.3676	1.2936	1.307	.1189	1.3306
17	1.0719	.2896	1.1203	.9945	1.1458	.3326	1.1949
18	.6283	.3189	.8589	.6722	.8871	.3658	.7762
19	.6283	.3658	.6348	.5544	.5914	.439	.5914
20	.5175	.4066	.5975	.5228	.5544	.439	.5228
21	.3696	.4108	.6722	.5228	.5544	.4024	.6348
22	.4435	.3395	.6348	.5544	.5914	.3658	.5544
23	.4435	.3018	.5228		.5544	.4024	.5175
24	.5716	.4435	.3395	.4435	.4481	.4805	.3658
Max	1.2048	.5601	1.3676	1.3306	1.7551	.4805	1.3306
Min	.3395	.2896	.2987	.3696	.3696	.1174	.3292
Avg	.6637	.3970	.6587	.7407	.8235	.3449	.6992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 303 / 22 KV VARYE MIX

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9412	.9054	.9511	.9511	.8688	.8238
2	.9054	.8688	.8676	.9145	.905	.7964	.788
3	.9054	.8688	.8676	.8688	.9145	.7964	.7522
4	.9054	.8688	.8676	.8688	.9145	.8326	.7522
5	.9335	.9774	.9335	.9412	.9412	.905	.9145
6	1.2696	1.2178	1.1949	1.2437	1.4118	1.3756	1.2197
7	1.9022	1.8461	1.9044	1.8656	2.0119	1.9547	1.922
8	2.3411	2.2923	2.2405	2.268	2.3167	2.0774	2.3655
9	2.3891	2.0485	2.0058	2.2923	2.2314	1.3169	2.1491
10	2.3411	2.3411	2.0271	2.1849	2.1216		2.0416
11	2.1357	2.2314	2.1491	2.0058	2.0485		2.0774
12	2.0774	2.3045	2.0416	2.1491	1.9753		2.0058
13	1.8625	2.3045	1.9342	2.0774	1.7878		1.9342
14	1.7718	2.1948	1.97	1.9342	1.7558		1.8267
15	1.8427	2.1948	2.0058	1.9909	1.829		1.7909
16	1.701	2.2314	2.0774	2.0271	1.8656		1.9022
17	2.0058	2.2081	2.3411	1.9753	1.8625	1.5524	1.9185
18	1.7193	2.1971	2.1948	2.1582	1.8267	2.1216	2.0271
19	2.0774	2.4143	2.2314	2.1357	2.1491	2.268	2.268
20	1.9342	2.3655	2.1216	2.1948	1.9342	2.1216	2.2081
21	1.7193	2.0538	1.9022	1.9022	1.7193	1.8656	1.7375
22	1.5043	1.7353	1.6827	1.4842	1.3756	1.576	1.4632
23	1.267	1.1317	1.2437	1.2696	1.1222	1.1706	1.1706
24	1.0745	1.1222	.9431	1.0608	1.1088	.8688	.9313
Max	2.3891	2.4143	2.3411	2.2923	2.3167	2.268	2.3655
Min	.9054	.8688	.8676	.8688	.905	.7964	.7522
Avg	1.6455	1.7900	1.6939	1.6985	1.6283	1.4393	1.6246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 304 / 22 KV RAMNAGAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2407	.0995	.1166	.1207	1.2929	1.1603	1.2536
2	1.1736	.0829	.1122	.1073	.9945	1.094	1.2536
3	1.166	.0829	.1097	.1061	1.2266	1.094	1.2178
4	1.166	.0862	.1085	.1061	1.2266	1.094	1.2178
5	1.166	.0928	.1166	.1326	1.2597	1.1934	1.2894
6	1.2689	.1028	.1235	.1459	1.326	1.4255	1.4327
7	1.576	.1392	.1628	.1475	1.7238	1.757	1.7909
8	1.643	.1525	.1578	.1591	1.7238	1.8233	1.8983
9	1.2452	.1475	.1425	.1558	1.6118	1.848	1.4255
10	.1475	.1475	.1425	.1492	.1408		.1459
11	.1475	3.1878	1.9559	1.6004	.1475		.1658
12	.1357	3.3311	2.9835	2.6852	.1542		.1425
13	.1357	3.2594	2.9172	2.652	.1408		.1558
14	.1274	3.2236	2.9172	2.652	.1274		.1558
15	.1475	3.152	2.9504	2.5526	.1193		.1425
16	.1542	3.152	2.8509	2.4531	.1127		.1326
17	.1724	2.5194	2.758	2.1879	.1326	.126	.1326
18	.1923	2.2466	2.4356	1.8896	.1558	.0862	.1326
19	.2122	.1677	.1878	.1326	.1591	.126	.1326
20	.2122	.1509	.1811	.1326	.1691	.1475	.1326
21	.1823	.1628	.1744	.1326	.1558	.1408	.1658
22	.1425	.1424	.1677	.1326	.1459	.1341	.1326
23	.1061	.1303	.1475		.1425	.126	.0995
24	1.2266	.0995	.1153	.1274	1.2929	1.1603	1.2536
Max	1.643	3.3311	2.9835	2.6852	1.7238	1.848	1.8983
Min	.1061	.0829	.1085	.1061	.1127	.0862	.0995
Avg	.6286	1.0858	1.0015	.8983	.6534	.8551	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 305 / WADHE AG 22KV

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
10			1.2887
11	1.4083	1.4632	1.4243
12	1.3904	1.3535	1.4922
13	1.4582	1.3535	1.4582
14	1.4083	1.39	1.4243
15	1.3413		1.2548
16	1.5432	1.4266	1.419
17	1.4582	1.2887	1.3394
18	1.6278	1.4922	1.39
Max	1.6278	1.4922	1.4922
Min	1.3413	1.2887	1.2548
Avg	1.4545	1.3954	1.3879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 201 / KOPARDE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5729	1.1984	1.1218			
2			1.1984	1.1218			
3		1.5729	1.2125	1.0974			
4		1.5729	1.2125	1.0974			
5		1.6461	1.2452	1.1145			
6		1.6827	1.2631	1.262			
7		1.7924	1.3763	1.3146			
8		1.829	1.3603	1.4175			
9		1.7318	1.3763	1.4266			
11	2.0972					2.2436	2.3045
12	2.2283				.8573		2.4508
13	2.2672				.9602		2.4874
14	2.0317				.9774		2.4508
15	1.9662				.9945	2.3137	
16	2.0972				1.0288	2.4356	2.396
17	2.1399				1.0974	2.332	2.191
18	1.9387				1.8107	2.332	
24		1.5729	1.1797	1.1218			
Max	2.2672	1.829	1.3763	1.4266	1.8107	2.4356	2.4874
Min	1.9387	1.5729	1.1797	1.0974	.8573	2.2436	2.191
Avg	2.0958	1.6637	1.2623	1.2095	1.1038	2.3314	2.3801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 202 / VENEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1646	.2075	.2103	.2103	.1829	.2743
2	.1595	.1463	.1886	.1928	.2103	.1829	.2572
3	.1595	.1463	.1886	.1753	.1791	.1829	.2572
4	.1595	.1463	.1886	.1928	.1772	.1829	.2572
5	.2103	.2378	.3395	.2629	.2126	.2926	.3086
6	.4607	.439	.4435	.4207	.4706	.439	.4801
7	.691	.6584	.695	.5784	.6697	.5853	.6516
8	.6219	.6584	.6584	.6024	.5973	.6584	.5487
9	.5373	.5487	.5853	.5121	.4801	.5083	.5121
10	.4298	.4115	.3506	.439	.4115		.439
11	.3544	.3772	.3189	.439	.3944	.3506	.2926
12	.3189	.3944	.3012	.3658	.3086	.298	.2926
13	.2804	.3258	.2454	.2926	.2743	.3189	.2926
14	.2454	.3258	.2454	.2926	.3086		.2926
15	.2835	.3258	.2686	.2926	.3086	.2865	.2926
16	.3155	.3429	.2865	.2926	.2915	.298	.2926
17	.2926	.3982	.298	.3224	.2743	.3086	.298
18	.3658	.4344	.333	.3721	.439	.3944	.3506
19	.5121	.6154	.591	.6154	.5121	.6173	.6516
20	.6584	.695	.6268	.6626	.6767	.6516	.6697
21	.6584	.5853	.5847	.6036	.695	.6001	.6089
22	.439	.4805	.5258	.4835	.5121	.4973	.567
23	.2926	.3326	.3258	.3189	.3658	.3601	.3761
24	.2149	.2195	.2427	.2454	.2507	.2561	.3086
Max	.691	.695	.695	.6626	.695	.6584	.6697
Min	.1595	.1463	.1886	.1753	.1772	.1829	.2572
Avg	.3683	.3921	.3766	.3827	.3846	.3842	.3988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 203 / NANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8604		.0189	.0351	1.8267	2.1948	1.9376
2	1.8604	.0549	.0189	.0351	1.8073	2.1948	1.9547
3		.0549	.0189	.0351	1.8267	2.2634	1.9376
4	1.8804	.0549	.0189	.0351	1.8229	2.1948	1.9376
5	1.8404	.0549	.0189	.0351	1.8604	2.1948	1.9204
6	1.858	.0549	.0377	.0351	1.8804	2.1948	1.9033
7	2.0058	.0549	.0377	.0351	1.9342	2.3411	2.0748
8	1.97	.0549	.0377	.0526	1.97	2.3777	2.0919
9	1.7695	.0514	.0566	.0549	1.8004	2.1209	2.1948
10	.0377	.0514	.0351	.0549	.0514		.0549
11	.0566	2.8464	3.0445	3.1459	.0514		.0549
12	.0566	2.9321	3.2579	3.219	.0514	.0351	.0549
13	.0566	3.0178	3.2236	3.219	.0343	.0351	.0549
14	.0566	3.0521	3.1878	3.1093	.0343		.0549
15	.0566	3.0693	3.1131	3.0727	.0343	.0351	.0549
16	.0566	2.9835	2.9729	2.9264	.0343	.0351	.0549
17	.0549	2.6397	2.8833	2.7286	.0514	.0343	.0532
18	.0549	2.4615	2.6642	2.4535	.0549	.0343	.0532
19	.0549	.0189	.0526	.0526	.0549	.0514	.0532
20	.0549	.0189	.0351	.0537	.0549	.0514	.0526
21	.0549	.0189	.0351	.0351	.0549	.0514	.0532
22	.0549	.0377	.0351	.0351	.0549	.0514	.0526
23	.0549	.0377	.0351	.0354	.0549	.0514	.0549
24	1.8804	.0549	.0377	.0351	1.8427	2.1948	1.9204
Max	2.0058	3.0693	3.2579	3.219	1.97	2.3777	2.1948
Min	.0377	.0189	.0189	.0351	.0343	.0343	.0526
Avg	.7690	1.0294	1.0366	1.0221	.8018	1.0828	.8596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 204 / KHODAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 201 / 11 KV DEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.9804	.9922	.7472	.0754	.0754	.056
2	.0566	.9374	.9804	.7232	.0754	.0754	.056
3	.0566	.9374	.9962	.7133	.0754	.0754	.0566
4	.0566	.9105	.9922	.6899	.0754	.0754	.0566
5	.0566	.9105	.9804	.751	.0754	.0754	.056
6	.0566	.9105	.9374	.7981	.0943	.0754	.0566
7	.0754	1.142	1.2003	.9875	.0943		.0747
8	.0732	1.2811	1.1439	1.0014	.0934	.0943	.0924
9	.0566	.9482	.9875	1.1279	.0554	.0747	.0924
10	.0377	.0543	.0732	.0739	.056	.037	.0914
11	1.8084	.0373	.0554	.0747	1.692	1.8515	1.8724
12	1.3441	.037	.0554	.056	1.9845	1.8187	1.8185
13	1.4563	.037	.0362	.056	1.7604	2.0243	1.8027
14	1.3094	.0366	.0373	.0554	1.692	1.9919	1.6604
15	1.5546	.0554	.056	.0554	1.8724	1.8138	1.3923
16	1.2967	.056	.0366	.0747	1.8084	1.7814	1.439
17	1.3916	.0732	.056	.0914	1.6404	1.7004	1.1265
18	1.3443	.0934	.0754	.0716	1.5043	1.4723	1.142
19	.0747	.0934	.0754		.0943	.0754	.0754
20	.0943	.0754	.0754	.0934	.0943	.0754	.0754
21	.0943	.0934	.0943	.0943	.0943	.0566	.0566
22	.0754	.0754	.0934	.0943	.0943	.0566	.0754
23	.0754	.056	.0754	.0754	.0943	.0566	.0754
24	.0566	.9804	.9842	.7964	.0943	.0943	.0566
Max	1.8084	1.2811	1.2003	1.1279	1.9845	2.0243	1.8724
Min	.0377	.0366	.0362	.0554	.0554	.037	.056
Avg	.5241	.4505	.4621	.4045	.6371	.6751	.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 202 / VARNE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.2263	.1886	.1698	.503	.5304	.4784
2	.6299	.2075	.1867	.1698	.4862	.503	.4744
3	.5967	.2075	.168	.1698	.4641	.4641	.4687
4	.5735	.2075	.1698	.168	.4475	.4641	.4586
5	.5571	.2263	.1886	.2075	.4475	.4641	.4744
6	.5735	.2641	.2075	.2452	.503	.5304	.4586
7	.779	.2987	.2614	.3018	.5935	.6944	.6722
8	.9069	.2987	.2427	.3174	.7545	.7926	.8333
9	.6882	.3696	.2427	.3174	.6472	.7209	.7042
10	.168	.2218	.2427	.2427	.2427	.0934	.1867
11	.1494	1.3441	1.094	1.012	.1663	.056	.2033
12	.0934	1.3441	1.065	1.0595	.1663	.056	.1848
13	.2033	1.2643	.9779	.9804	.2218	.0747	.1848
14	.2218	1.0936	.8886	.9061	.2241	.168	.1848
15	.1867	1.0402	.8551	.8383	.2614	.1867	.1867
16	.2218	1.0402	.8122	.8951	.2241	.1867	.1663
17	.2427	.8539	.8048	.8383	.2054	.2427	.1663
18	.2427	.7186	.6133	.6718	.2218	.2614	.1478
19		.2241	.1886	.2829	.2054	.1867	.1494
20	.2241	.1886	.2075	.2614	.2241	.1867	.1494
21	.2263	.1867	.1698	.2452	.2075	.168	.1494
22	.2075	.2263	.2075	.2075	.2241	.1886	.1509
23	.2075	.1886	.1886	.2075	.2241	.503	.1698
24	.7291	.2263	.1886	.1698	.5426	.5636	
Max	.9069	1.3441	1.094	1.0595	.7545	.7926	.8333
Min	.0934	.1867	.168	.168	.1663	.056	.1478
Avg	.4043	.5195	.4317	.4536	.3503	.3453	.3219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 203 / DEGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2218	.2402	.2452	.2829	.2801	.2987
2	.2218	.2218	.2402	.2452	.2829	.2614	.2801
3	.2241	.2033	.2241	.2241	.2614	.2427	.2829
4	.2241	.2054	.2402	.2241	.2614	.2452	.3018
5	.2427	.2427	.3696	.2641	.2987	.2829	.3734
6	.4715	.4066	.4854	.4904	.5093	.4338	.5093
7	.6602	.695	.6348	.6602	.679	.6653	.5853
8	.6154	.6697	.5853	.6161	.6348	.695	.6154
9	.4075	.5249	.5249	.4835	.4835	.543	.5068
10	.3898	.4607	.4298	.4161	.4075	.4607	.3856
11	.3506	.4382	.3898	.3429	.3761	.4207	.3772
12	.3721	.3601	.3155	.4334	.2126	.3898	.3641
13	.3582	.3506	.3506	.4161	.3012	.3721	.3467
14	.3814	.3506	.3721	.3988	.3155	.3506	.3506
15	.4207	.3898	.3721	.3721	.3506	.3467	.362
16	.4252	.3856	.3898	.3681	.3544	.3258	.3467
17	.4409	.4287	.4557	.4031	.373	.3856	.3506
18	.3944	.407	.4075	.4252	.4031	.4607	.3544
19	.5373	.5258	.5729	.6468	.5083	.5847	.6036
20	.5611	.5853	.6283	.6535	.567	.6335	.6348
21	.5121	.5304	.5359	.6099	.5304	.567	.5788
22	.462	.4805	.462	.5175	.4755	.5415	.5093
23	.2987	.3174	.3206	.3772	.4024	.3881	.3395
24	.3458	.2402	.2614	.2641	.3018	.2987	.3326
Max	.6602	.695	.6348	.6602	.679	.695	.6348
Min	.2218	.2033	.2241	.2241	.2126	.2427	.2801
Avg	.3982	.4018	.4087	.4207	.3989	.4240	.4163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 204 / 11 KV CHINCHNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0732	.056	.056	.0754	.0754	.0747
2	.0554	.0739	.0566	.056	.0754	.0754	.0554
3	.0554	.0739	.0754	.0566	.0566	.0566	.0739
4	.0554	.0739	.0754	.0566	.0566	.0566	.0754
5	.0739	.0924	.0754	.0566	.0754	.0754	.0747
6	.112	.112	.0943	.1132	.1307	.112	.1132
7	.2054	.2195	.2427	.2054	.2427	.2195	.1867
8	.168	.2218	.2012	.2054	.2033	.1829	.1848
9	.1478	.1829	.1448	.1629	.1448	.1417	.1448
10	.1086	.1402	.124	.1433	.1227	.1063	.1063
11	.1612	.0857	.1052	.1227	.0886	.1052	.0857
12	.1086	.104	.12	.1227	.0848	.1227	.104
13	.0895	.0876	.1052		.0876	.1052	.104
14	.1052	.0857	.1267	.1052	.1052	.104	.0876
15	.1075	.0876	.0886	.0876	.0867	.12	.0724
16	.0867	.0886	.0716	.1052	.0867	.0876	.0876
17	.0514	.0867	.1052	.1214	.1029	.1017	.1006
18	.12	.1326	.124	.116	.104	.1187	.1372
19	.2012	.156	.1772	.1991	.1772	.1949	.2126
20	.181	.1829	.2172	.2012	.1949	.2172	.2172
21	.1307	.1478	.1448	.1663	.1663	.1829	.1629
22		.1494	.1494	.1294	.1294	.1307	.1494
23		.0934	.1109	.0934	.0914	.0924	.112
24	.0732	.0739	.0754	.0747	.0754	.0754	.0747
Max	.2054	.2218	.2427	.2054	.2427	.2195	.2172
Min	.0514	.0732	.056	.056	.0566	.0566	.0554
Avg	.1115	.1177	.1195	.1199	.1152	.1192	.1166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 205 / 11KV VARNE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0914	.1097	.0934	.0934	.0934	.1307
2	.0732	.0739	.1109	.0924	.0934	.0934	.1307
3	.0739	.0924	.0914	.0924	.0924	.0924	.1109
4	.0739	.0914	.1109	.0924	.0924	.1109	.1307
5	.1109	.128	.1478	.112	.112	.1307	.1307
6	.168	.1848	.2172	.1867	.2054	.2241	.2241
7	.3292	.3475	.3403	.2587	.3142	.3292	.4024
8	.3801	.3658	.362	.2957	.3077	.3258	.3258
9	.3045	.3012	.2454	.2715	.2957	.2279	.2715
10	.2374	.2401	.1943	.2507	.2195	.0678	.1772
11	.2012	.218	.1943	.2103	.1907	.0829	.2058
12	.1677	.2035	.1943	.1753	.1543	.0693	.208
13	.1372	.1886	.2012	.1753		.0686	.208
14	.1509	.1734	.1543	.1753	.1372	.1886	.1949
15	.1865	.1753	.1696	.1578	.1526	.1865	.181
16	.1715	.1886	.1907	.1753	.1677	.1886	.2103
17	.1886	.2035	.1781	.1696	.2058	.1907	.208
18	.2401	.2012	.1989	.2321	.156	.2401	.1928
19	.2534	.2481	.2835	.2507	.2629	.3294	.3077
20	.2715	.2926	.2743	.3077	.3366	.3721	.3224
21	.2402	.2743	.2561	.2587	.2957	.3292	.2865
22	.1848	.2402	.2218	.2218	.2378	.2957	.2402
23	.1294	.1294	.1494	.1494	.1646	.1829	.1663
24	.0914	.0924		.112	.112	.1109	.1478
Max	.3801	.3658	.362	.3077	.3366	.3721	.4024
Min	.0732	.0739	.0914	.0924	.0924	.0678	.1109
Avg	.1849	.1977	.1998	.1882	.1913	.1888	.2131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 201 / 11 kv BHATMARALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.0381	.0343	.0328	1.1145	1.2193	.9945
2	1.1145	.0381	.0343	.0332	1.1317	1.2003	1.0208
3	1.1145	.0381	.0343	.0332	1.0974	1.2003	.9069
4	1.1145	.0381	.0343	.0312	1.0802	1.1812	.9945
5	1.1488	.0381	.0343	.0335	1.1488	1.2193	.9804
6	1.2003	.0381	.0343	.0497	1.2003	1.2384	1.0898
7	1.3203	.0381	.0343	.0486	1.2689	1.6385	1.4419
8	1.4232	.0381	.0343	.0503	1.3032	1.7147	1.4419
9	1.2517	.0497	.0343	.0381	1.0288	1.406	1.6766
10	.0343	.0474	.0343	.0381	.0343	.0343	.0381
11	.0343	2.0972	1.9204	1.8755		.0343	.0381
12	.0343	1.4529	.1972	1.9281		.0343	.0381
13	.0343	2.2923	2.0062	1.9281		.0343	.0381
14	.0343	1.9685	1.9547	1.858	.0343	.0857	.0381
15	.0343	2.0481	2.0919	1.8823	.0343	.0343	.0381
16	.0343	1.9989	1.8347	1.6651	.0343	.0343	.0381
17	.0381	1.9376	1.7318	1.5432	.0381	.0328	.0343
18	.0381	1.7661	1.5775	1.406	.0381	.0332	.0343
19	.0381	.0343	.0492		.0381	.0492	.0343
20	.0572	.0343	.0497	.0343	.0572	.0469	.0343
21	.0572	.0343	.0469	.0343	.0572	.0492	.0343
22	.0572	.0343	.0492	.0343	.0572	.0474	.0343
23	.0381	.0343	.0332	.0857	.0572	.0492	.0343
24	1.0631	.0381	.0343	.0328	1.2003	1.2193	.9995
Max	1.4232	2.2923	2.0919	1.9281	1.3032	1.7147	1.6766
Min	.0343	.0343	.0332	.0312	.0343	.0328	.0343
Avg	.5179	.6739	.5800	.6390	.5740	.5765	.5022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 202 / 11 KV KUSAVADE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3048	.2572	.3052	.2572	.3048	.298
2	.2229	.3048	.2229	.2896	.2229	.2858	.2804
3	.2229	.2858	.2229		.2058	.2858	.2658
4	.2058	.2667	.2229	.2835	.2058	.2858	.2804
5	.1715	.3429	.2401	.298	.2915	.3429	.3189
6	.3258	.4382	.2915	.3982	.3258	.4191	.4344
7	.0343	.4954	.3258	.4887	.463	.5525	.5434
8	.4801	.4954	.3944	.4755	.463	.4763	.5316
9	.3944	.4207	.4115	.4763	.3258	.3086	.4001
10	.3772	.3475	.3429	.4763	.3772	.3258	.362
11	.4115	.3292	.3258	.4954	.3086	.3429	.4191
12	.3772	.4557	.3429	.4954	.3086	.3601	.4001
13	.4115	.4031	.3601	.4763	.3086	.3429	.381
14	.4115	.3721	.3601	.4191	.2915	.2915	.3429
15	.3429	.439	.4287	.381	.2058	.3086	.3239
16	.3429	.3982	.3429	.4191	.2401	.3258	.3048
17	.4001	.3944	.3429	.4287	.381	.3292	.3086
18	.362	.3601	.439	.4458	.4572	.333	.3429
19	.4763	.5144	.4784		.5716	.4755	.463
20	.5906	.5144	.5068	.5144	.6097	.4607	.5316
21	.5906	.463	.5258	.4973	.5144	.4607	.4458
22	.4572	.3429	.4163	.3601	.4572	.3982	.4287
23	.3429	.2915	.373	.3429	.381	.3801	.3258
24	.2572	.3239	.2743	.3439	.3086	.3239	.3155
Max	.5906	.5144	.5258	.5144	.6097	.5525	.5434
Min	.0343	.2667	.2229	.2835	.2058	.2858	.2658
Avg	.3528	.3877	.3520	.4141	.3534	.3634	.3770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 203 / 11 kv PADALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.8383	.6859	.788	.0343	.0762	.1006
2	.0343	.8383	.7202	.7116	.0343	.0762	.1029
3	.0514	.8192	.7202	.6958	.0343	.0762	.0949
4	.0343	.8002	.7202	.7449	.0343	.0762	.0995
5	.0343	.8383	.7373	.8059	.0343	.0953	.0937
6	.0343	.9526	.7716	.852	.0343	.0953	.1029
7	.0514	1.1431	.8402	.9878	.0343	.0953	.0983
8	.0343	1.1431	1.0117	1.0978	.0343	.0953	.1326
9	.0343	.8539	1.166	1.2384	.0343	.0343	.0953
10	.0343	.0949	.0343	.0953	.0343	.0343	.0953
11	2.2977	.0876	.0343	.0953	2.0919	2.0748	1.989
12	2.3148	.1372	.0343	.0953	2.332	2.1776	2.1384
13	2.1776	.0949	.0343	.0953	2.0919	2.3148	2.1033
14	2.0062	.0983	.0343	.0953	2.0919	2.1948	2.3434
15		.0949	.0343	.0953	2.2291	2.0748	2.1091
16	2.0576	.0983	.0343	.0953	2.332	2.1262	2.1735
17	1.9433	.0343	.0343	.0343	2.1434	1.9616	2.0919
18	1.6956	.0343	.1006	.0343	1.893	1.8023	.1938
19	.0953	.0343	.1052		.0953	.0983	.0343
20	.0953	.0343	.0949	.0343	.0953	.1107	.0343
21	.0953	.0343	.0972	.0343	.0953	.116	.0343
22	.0953	.0343	.0949	.0343	.0953	.1107	.0343
23	.0953	.0343	.0972	.0343	.0953	.1006	.0343
24	.0514	.8573	.6859	.8215	.0343	.0953	.0995
Max	2.3148	1.1431	1.166	1.2384	2.332	2.3148	2.3434
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.6695	.4179	.3718	.4181	.7525	.7547	.6846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 204 / 11 KV NINAM GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2286	.2058	.1829	.1715	.1905	.1829
2	.2572	.1905	.2058	.1829	.1715	.1715	.1829
3	.2743	.1715	.2058	.1629	.1543	.1524	.1663
4	.2572	.1524	.1715	.1612	.1543	.1524	.181
5	.3086	.2286	.1543	.2587	.2743	.2286	.2481
6	.4287	.3048	.1372	.3155	.3086	.381	.3189
7	.4973	.4763	.2058	.499	.6173	.6097	.4733
8	.5144	.4763	.3258	.695	.7716	.4572	.439
9	.7202	.5121	.4973	.7049	1.3032	.3944	.5335
10	.5316	.4163	.6859	.6859	.6344	.3258	.6478
11	.5658	.3077	.6001	.7049	.7202	.2915	.6287
12	.6001	.2126	.5487	.8383	.7202	.2229	.7811
13	.6859	.2353	.6001	.8764	.8573	.2058	.6478
14	.6344	.2103	.4115	.8002	1.0288	.2058	1.105
15	.5658	.2353	.3086	.9526	.4801	.1715	1.105
16	.4458	.2534	.3258		.4287	.4115	.9526
17	.6668	.2401	.5487	.9602	.9907	.3012	1.1488
18	.4954	.2915	.4801	.583	.8383	.2587	.9431
19	.4763	.4287	.567		.6859	.4207	.8573
20	.5335	.4458	.5373	.4458	.6097	.4382	.5658
21	.5335	.4458	.4908	.463	.4763	.4382	.5144
22	.4382	.4115	.8504	.3429	.4191	.3982	.4801
23	.3239	.3772	.5372	.3429	.3048	.2743	.3258
24	.2572	.2667	.3258	.4206	.2058	.1905	.1949
Max	.7202	.5121	.8504	.9602	1.3032	.6097	1.1488
Min	.2058	.1524	.1372	.1612	.1543	.1524	.1663
Avg	.4674	.3133	.4136	.5264	.5553	.3039	.5677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 201 / 11 KV KHOJEWADI SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 202 / 11 KV SATARA SINGLE PH. SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0305
Max	.0305
Min	.0305
Avg	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 203 / 11 KV UMBRAJ SINGLE PH.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 204 / 11 KV KAY PULP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 403 / 33 KV KIRLOSKAR EXPRESS
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
23	.2058
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 407 / 33kv Targaon S/Stn

Feeder KV- 33 / INCOMING

PURELY LIS FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 408 / 33 KV SHAHU LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 300 / Auxallary feeder

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1334		.1307	.1334	.1235	.1494
2	.1097	.1334		.1307	.1334	.1235	.1344
3	.1097	.1334		.1307	.1334	.1235	.1008
4	.1097	.1334		.1307	.1334	.1235	.1307
5	.1132			.127	.1334	.1235	.1382
6	.1132	.1334		.1083	.1334	.1235	.1083
7	.0412	.0457		.0448	.1334	.0446	.0448
8	.0412	.0457		.0448	.0457	.0412	.0448
9	.0412	.0457		.0448	.0457	.0412	.0448
10	.0457		.0448	.0448	.0412	.0448	.0485
11	.0457		.0448	.0457	.0412	.0448	
12	.0457		.0597	.0457	.0412	.0448	
13	.0572		.0523	.0457	.0412	.0448	
14	.0457		.0523	.0457	.0549	.0448	
15	.0457		.0597		.0549	.0448	
16	.0457		.0597	.0457	.0549	.0448	
17	.0457		.0597	.0457	.0446	.0485	
18	.0457		.0523	.0457	.0446	.0448	
19	.1334		.0747	.1334	.0789	.0485	
20	.1334		.1456	.1334	.1269	.1494	
21	.1334		.183	.1334	.1269	.1344	
22	.1334		.1494	.1334	.1269	.1307	
23	.1334		.1494	.1334	.1269	.1456	
24	.1122	.1334		.1344	.1334	.1235	.1494
Max	.1334	.1334	.183	.1344	.1334	.1494	.1494
Min	.0412	.0457	.0448	.0448	.0412	.0412	.0448
Avg	.0830	.1042	.0848	.0895	.0902	.0836	.0995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 301 / PIMPODE Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0562		1.1012			
2		1.0242		1.0364			
3		1.0242		1.0364			
4		1.1523		1.0364	.16		
5	.1372	1.2803		1.1012	.192	.1372	.1296
6	.1715	1.4083		1.3603	.192	.2058	.1943
7	.2401	1.7924		2.0729	.2241	.2401	.2267
8	.2058	1.8884		2.2024	.2561	.2401	.1943
9	.1715	1.7284		1.8785	.2241	.2401	.1296
10	.128		.1619	.1619	.2401	.1943	.1619
11	2.6886		.1619		2.7778	2.3644	2.4508
12	2.8166		.1619		2.572	2.3967	2.6337
13	2.7526		.1296		2.6749	2.2996	2.1948
14			.1619		2.6406		2.0851
15	2.5606		.1619		2.4006	2.2672	2.1948
16	2.4966		.1619	.128	2.7435	2.3644	
17	1.7284		.1943		1.8861	2.332	
18	1.6324		.1619		1.6461	1.9109	
19	.16		.1619	.16		.1943	
20	.16		.1619	.16	.1715	.1943	
21	.192		.1619	.16	.2058	.1619	
22	.16		.1296	.16	.1715	.1296	
23	.128				.1372		
24		1.0562		1.0364			
Max	2.8166	1.8884	.1943	2.2024	2.7778	2.3967	2.6337
Min	.128	1.0242	.1296	.128	.1372	.1296	.1296
Avg	1.0294	1.3411	.1594	.9245	1.1324	1.0513	1.1451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 302 / 22KV PIMPODE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2241		.1886	.2614	.2401	.2641
2	.1715	.1867		.1886	.2241	.2058	.2263
3	.1715	.1867		.1886	.2241	.2058	.2263
4	.1715	.2241		.2263	.2241	.2058	.2263
5	.2058	.3734		.3018	.2614	.2401	.3361
6	.3429	.4481		.4481	.2987	.4115	.5601
7	.4801	.5975		.5601	.4481	.5144	.4854
8	.4801	.5601		.5601	.6348		.6722
9	.4801	.4481		.5228	.4854	.4458	.4108
10	.2987		.2987	.4481	.3772	.3361	.4481
11	.2987		.2987	.3361	.2743	.3734	
12	.3734		.2987	.3361	.2058	.2614	
13	.2614		.2987	.3361	.2401	.2987	
14	.2614		.2241	.2987	.2401	.2614	
15	.3361		.3361		.2058		
16	.3361		.3361	.2614	.2058	.2987	
17	.4108		.3734	.2987	.2743	.2614	
18	.4854		.3734	.4108	.3429	.3734	
19	.5228		.5601	.5601	.5144	.5975	
20	.5601		.5975	.5975	.6516	.6722	
21	.5228		.5228	.5228	.5487	.5975	
22	.4108		.4904	.4108	.4115	.4854	
23	.2987		.3018	.3734	.3086	.3734	
24	.2058	.2172		.2263	.2614	.2401	.2987
Max	.5601	.5975	.5975	.5975	.6516	.6722	.6722
Min	.1715	.1867	.2241	.1886	.2058	.2058	.2263
Avg	.3455	.3466	.3793	.3740	.3385	.3591	.3777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 303 / SONKE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2241		.2263	.2614	.2401	.2263
2	.1715	.1867		.2263	.2241	.2058	.2263
3	.1715	.1867		.1886	.2241	.2058	.2263
4	.1715	.2241		.2263	.2241	.2058	.2263
5	.2401	.2987		.3395	.2614	.2401	.3395
6	.4458	.4481		.4854	.3734	.3772	.5228
7	.6859	.6348		.7095	.7095	.583	.7095
8	.6173	.6348		.6722	.6348	.5487	.6722
9	.4458	.5228		.4854	.6348	.4458	.4854
10	.4108		.2987	.3734	.3086	.3734	.4108
11	.4108		.2614	.3361	.2743	.3361	
12	.2614		.2987	.3361	.2743	.2614	
13	.2614		.2987	.2614	.2401	.2614	
14	.2241		.2614	.2241	.2401	.2241	
15	.2241		.2241		.2401	.2241	
16	.2614		.2614	.2614	.2401	.2614	
17	.3734		.2614	.2614	.2743	.2614	
18	.3361		.3361	.3361	.2743	.3361	
19	.4481		.5601	.6348	.5144	.5601	
20	.4854		.5975	.6348	.5144	.5975	
21	.4481		.5601	.5228	.4458	.5601	
22	.3734		.4527	.4854	.4115	.4481	
23	.2987		.3018	.3734	.3086	.2987	
24	.2058	.2241		.2263	.2614	.2401	.2614
Max	.6859	.6348	.5975	.7095	.7095	.5975	.7095
Min	.1715	.1867	.2241	.1886	.2241	.2058	.2263
Avg	.3393	.3585	.3553	.3838	.3487	.3457	.3915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 304 / 22 KV SONAKE AG FEEDER
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2622		.1989	.3932	.4115	.4588
2	.6516	.1966		.1989	.3277	.4115	.4588
3	.6516	.1966		.1989	.3277	.3772	.4588
4	.6516	.2622		.1989	.3932	.4115	.426
5	.7202	.2622		.2321	.4588	.5487	.426
6	.823	.2622		.2321	.5243	.7202	.4915
7	1.0631	.2949		.3315	.5898	.9602	.852
8	.823	.2949		.2652	.5898	.823	.9831
9	.2401	.2622		.2321	.5571	.7888	.8848
10	.1311		.2652	.1989	.1715	.1638	.1638
11	.1966		1.1934	1.1469	.2058	.1638	.2195
12	.2949		1.3923	1.3763	.1715	.1966	.2561
13	.2622		1.3923	1.3763	.2058	.2294	.1829
14	.2949		1.3592	1.2452	.1715	.1966	.1829
15	.3605		1.2266	1.1142	.2058	.2294	.2561
16	.3605		1.1603	1.0486	.2058	.2294	
17	.2949		1.094	1.0814	.2058	.2294	
18	.2622		.8951	.8848	.2058	.2622	
19	.2949		.1989	.1966	.2401	.2622	
20	.2949		.2652	.2294	.2401	.2622	
21	.2622		.2652	.1966	.2401	.2294	
22	.2949		.2652	.1966	.2401	.2294	
23	.2622		.2321	.1638	.2058	.1966	
24	.7202	.2622		.2321	.3605	.4801	.4588
Max	1.0631	.2949	1.3923	1.3763	.5898	.9602	.9831
Min	.1311	.1966	.1989	.1638	.1715	.1638	.1638
Avg	.4541	.2556	.8004	.5323	.3099	.3755	.4475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 305 / 22 KV WATHAR (GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5601		.5228	.5975	.5487	.5601
2	.4115	.5228		.3734	.5601	.4801	.5228
3	.4115	.5228		.3734	.5228	.4801	.5228
4	.4115	.5975		.3734	.5228	.4801	.5228
5	.5487	.6722		.4854	.5975	.5487	.5975
6	.6516	.7468		.6348	.7468	.6173	.6722
7	.6859	.8962		.7842	.7842	.6516	.7468
8	.5487	.6348		.7468	.6722	.5144	.5975
9	.4801	.5601		.6348	.5228	.5144	.5601
10	.4481		.4108	.7468	.3772	.6348	.4481
11	.4108		.3734	.8215	.4115	.5601	.6584
12	.4108		.3734	.7842	.3772	.4481	.6219
13	.6722		.4108	.6722	.3772	.3361	.3292
14	.4108		.3734	.4108	.3429	.3734	.3658
15	.3734		.4108	.6722	.3429	.5228	.3292
16	.5975		.4108	.7095	.3772	.5228	
17	.4108		.4108	.6722	.3429	.5228	
18	.4108		.5228	.6722	.5144	.6722	
19	.6348		.6722	.7468	.6859	.7095	
20	.6348		.7095	.7468	.6516	.7095	
21	.5601		.5975	.6722	.6516	.6348	
22	.4854		.7468	.8962	.6859	.8589	
23	.4481		.7095	.7468	.6173	.6722	
24	.4801	.5601		.5975	.5975	.5487	.6348
Max	.6859	.8962	.7468	.8962	.7842	.8589	.7468
Min	.3734	.5228	.3734	.3734	.3429	.3361	.3292
Avg	.4993	.6273	.5095	.6457	.5367	.5651	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 306 / 22 KV WATHAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.8192		1.1142	.2949	.2743	.2294
2	.2401	.7865		1.0814	.2622	.2743	.2294
3	.2401	.7865		1.0814	.2622	.2743	.2294
4	.2401	.852		1.0814	.2622	.2743	.2294
5	.2743	.9175		1.1142	.3277	.3086	.2949
6	.3429	1.0486		1.2452	.3932	.3772	.3277
7	.4458	1.3108		1.704	.4588	.4458	.3932
8	.3772	1.3108		1.8351	.3932	.4115	.3932
9	.4115	1.1797		1.5402	.3605	.3086	.2622
10	.3605		.1966	.2622	.3086	.2622	.2622
11	2.3594		.2622	.2622	2.6063	1.9989	2.1948
12	2.3594		.2949	.2949	2.6749	2.0645	2.1948
13	2.3594		.2622	.2622	2.6063	2.0972	2.0119
14	2.2283		.2294	.2622	2.5377	1.9989	1.3169
15	2.0972		.2294		2.332	1.9006	1.9022
16	1.9662		.2622	.3277	2.332	1.8679	
17	1.4419		.2622	.2622	1.8519	1.704	
18	1.3108		.3277	.2622	1.5775	1.4746	
19	.3277		.3277	.3932	.3772	.3605	
20	.3605		.3277	.3932	.4115	.3605	
21	.3277		.3277	.3932	.4115	.3277	
22	.3277		.3277	.3605	.3772	.3277	
23	.2949		.2622	.3277	.3086	.2622	
24	.2401	.8192		1.1469	.2949	.2743	.2294
Max	2.3594	1.3108	.3277	1.8351	2.6749	2.0972	2.1948
Min	.2401	.7865	.1966	.2622	.2622	.2622	.2294
Avg	.8822	.9831	.2786	.7395	1.0010	.8429	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 307 / 22 KV Nandwal AG Feeder
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916				.426	.4801	.583
2	.8916				.3932	.4115	.5182
3	.8573	.1638			.3932	.4115	.5182
4	.8573	.1638			.3932	.4458	.5182
5	.9602	.1638		.1509	.6554	.5487	.5506
6	1.0974	.1966		.1886	.8192	.9602	.7125
7	1.7833	.2622		.3018	1.0486	1.4403	1.2955
8	1.406	.2622		.2263	1.0159	1.2003	1.4899
9	.2058	.1638			.8192	.9602	1.2308
10	.1311		.1886	.1886			
11	.1638		1.6194	1.4746			
12	.1638		1.6194	1.7368			
13	.1638		1.6842	1.5729			
14	.1638		1.6194	1.4746			
15	.1311		1.5546				
16	.1638		1.5546	1.2125			
17	.1966		1.3603	1.1469			
18	.1966		1.0364	.9175	.1715	.1509	
19	.1638		.2641	.2294	.2058	.2263	
20	.1966		.2641	.1638	.2058	.2263	
21	.1638		.1886	.1638	.2058	.2641	
22			.1509	.1311	.2058	.1886	
23				.1311			
24	.8916				.426	.4801	.6154
Max	1.7833	.2622	1.6842	1.7368	1.0486	1.4403	1.4899
Min	.1311	.1638	.1509	.1311	.1715	.1509	.5182
Avg	.5382	.1966	1.0080	.6712	.4923	.5597	.8032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 300 / Auxallary feeder

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.1905
Max	.1905
Min	.1905
Avg	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 301 / 22KV Koregaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3772	.3429	.3772	.3353	.4115	.0381
2	.3048	.3772	.3429	.3772	.3963	.3429	.0343
3	.3048	.3772	.3429	.3429	.3963	.3772	.0305
4	.3048	.3429	.3429	.3429	.4572	.3772	.0381
5	.4572	.5144	.4801	.4801	.5792	.6173	.0572
6	.6706	.7545	.7202	.7545	.7621	.7545	.08
7	.9145	.9602	1.0631	1.0974	1.0059	1.0631	.1181
8	.945	1.1317	.9602	1.0288	.945	.9945	.1105
9	.823	.8535	.7011	.8573	.0953	.7621	.8573
10	.7202	.7316	.6401	.7545	.08		.6859
11	.583	.6706	.6401	.6859	.0724	.7621	.583
12		.5792	.6097	.6173	.0648	.6097	.4115
13	.2401	.5182	.5487	.4801	.0572	.5182	.4801
14		.5182	.5182	.4801	.0533	.5182	.4801
15	.3772	.5182	.4877	.4801	.0495	.4572	.5487
16	.4458	.4572	.2743	.5144	.0533	.3963	.6516
17	.6173	.583	.4115	.4572	.6173	.0648	.6097
18	.823	.6859	.6516	.5182	.823	.061	.6401
19	.9602	.9945	.9602	.7621	1.0288	.1105	.8535
20	.8916	.8573	.8916	.884	.8916	.1105	.823
21	.823	.7202	.823	.7621	.6859	.0953	.7621
22	.6173	.6173	.7202	.6401	.6173	.0724	.6706
23	.4801	.4801	.5144	.5182	.5144	.061	.4877
24	3.0484	.4115	.4115	.4115	.4268	.4458	.0572
Max	3.0484	1.1317	1.0631	1.0974	1.0288	1.0631	.8573
Min	.2401	.3429	.2743	.3429	.0495	.061	.0305
Avg	.7117	.6263	.6000	.6093	.4587	.4341	.4212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 303 / 22 KV DEURGAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2058	.2058	.2058	.2134	.2401	.0267
2	.1524	.2058	.2058	.2058	.2134	.2058	.0267
3	.1524	.2058	.2058	.2058	.2134	.2058	.0229
4	.2134	.1715	.2058	.2058	.2743	.2058	.0267
5	.2743	.2743	.2401	.2401	.3963	.2743	.0305
6	.4572	.3772	.4115	.4115	.4572	.4115	.0419
7	.5792	.4115	.6859	.6516	.5487	.5487	.0686
8	.4877	.5487	.6173	.6173	.5182	.5144	.0648
9	.4458	.4877	.4572	.5144	.0533	.4268	.5144
10	.3429	.3658	.3658	.3772	.0457	.3658	.3429
11	.3086	.3048	.3353	.3429	.0381	.3048	.2743
12	.2401	.2439	.2439	.3086	.0305	.2439	.2743
13	.2743	.2743	.2743	.2743	.0305	.2439	.2743
14	.2401		.2743	.2743	.0305	.2439	.2743
15	.2743	.2743	.2743	.2401	.0267	.2439	.2743
16	.2401	.2439	.2743	.2743	.0305	.2134	.3086
17	.2743	.2743	.3086	.2743	.3429	.0343	.2743
18	.6173	.3772	.3086	.3353	.4115	.0343	.3658
19	.6516	.583	.583	.4572	.6173	.0648	.5182
20	.4801	.5144	.6859	.4877	.5487	.061	.4877
21	.4115	.4458	.4801	.4572	.5144	.0572	.4572
22	.4115	.3429	.4458	.4268	.3429	.0419	.4268
23	.2401	.2743	.3086	.3048	.3086	.0381	.2743
24	.1829	.2058	.2401	.2401	.2439	.2401	.0305
Max	.6516	.583	.6859	.6516	.6173	.5487	.5182
Min	.1524	.1715	.2058	.2058	.0267	.0343	.0229
Avg	.3377	.331	.3599	.3472	.2688	.2277	.2367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 304 / 22KV KINHAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2743	.3429	.3429	.3353		.0381
2	.2439	.2743	.3086	.3086	.3353		.0305
3	.2439	.2743	.3429	.3086	.3353		.0305
4	.3048	.2401	.3086	.3086	.4572		.0343
5	.3658	.3429	.3772	.3772	.6097		.0381
6	.5792	.583	.6173	.583	.7316		.0762
7	.8535	.7545	.9259	.9259	.8535	.8916	.0991
8	.823	.8916	.823	.8916	.7011	.823	.0838
9	.7202	.5487	.6097	.7545	.0762	.6401	.6859
10	.583	.5182	.5182	.6859	.061	.5487	.5144
11	.4801	.4572	.4572	.4801	.0533	.4572	.4801
12	.4458	.4268	.3658	.4115	.0419	.3658	.4115
13	.3772		.3658	.3772	.0381	.3658	.3772
14	.3429		.3353	.3772	.0381	.3658	.3772
15	.4458	.2134	.3353	.3772	.0419	.3353	.3772
16	.4801	.2439	.3658	.3772	.0419	.2439	.3772
17	.6173	.2743	.4115	.3963	.5144	.0343	.3658
18	.6859	.6173	.5144	.4572	.8573	.0572	.4572
19	.8916	.9259	.6859	.6706	.9602	.0914	.7316
20	.823	.823	.8573	.7316	.8573	.0953	.7621
21	.7202	.7545	.7888	.7621	.6859	.08	.7011
22	.5144	.583	.6516	.5487	.5144	.0686	.6097
23	.3772	.4458	.4458	.4268	.4115	.0533	.4268
24	.2743	.3429	.3772	.3772	.3353	.3429	.0419
Max	.8916	.9259	.9259	.9259	.9602	.8916	.7621
Min	.2439	.2134	.3086	.3086	.0381	.0343	.0305
Avg	.5182	.4914	.5055	.5107	.4120	.3256	.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 301 / WATHAR i.e. 22KV KINHAI SEPARATED AG FEEDERS HAVING SPECIAL
 AG. Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	6.0174	.1715	.1715	.1715	4.9417	4.6639	.503
Max	6.0174	.1715	.1715	.1715	4.9417	4.6639	.503
Min	6.0174	.1715	.1715	.1715	4.9417	4.6639	.503
Avg	6.0174	.1715	.1715	.1715	4.9417	4.6639	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 303 / 22 KV COOPER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6805	.9602	.6859	.583	1.5466	1.0288	.0762
Max	.6805	.9602	.6859	.583	1.5466	1.0288	.0762
Min	.6805	.9602	.6859	.583	1.5466	1.0288	.0762
Avg	.6805	.9602	.6859	.583	1.5466	1.0288	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 304 / 22KV BHUINJ i.e. 22KV SEPARATED AG FEEDERS HAVING SPECIAL
DEUR AG Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2507	3.9095	4.321	4.1495	.3018	.2743	.0267
Max	.2507	3.9095	4.321	4.1495	.3018	.2743	.0267
Min	.2507	3.9095	4.321	4.1495	.3018	.2743	.0267
Avg	.2507	3.9095	4.321	4.1495	.3018	.2743	.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 308 / 22 KV Mafco (22KV
Satararoad S Feeder KV- 22 /
INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8954	.9259	.9602	1.0288	1.2071	.9945	.1219
Max	.8954	.9259	.9602	1.0288	1.2071	.9945	.1219
Min	.8954	.9259	.9602	1.0288	1.2071	.9945	.1219
Avg	.8954	.9259	.9602	1.0288	1.2071	.9945	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 400 / AUXILIARY FEEDER

Feeder KV- 22 / OUTGOING

DATE	02-MAR-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 407 / 33KV VASANA

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	07-MAR-18
HR	Load (MW)
24	.0057
Max	.0057
Min	.0057
Avg	.0057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 408 / 33 KV WADACHIWADI

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.2773	2.2862	1.6461	3.2922	3.3951	.6173	.3487
Max	3.2773	2.2862	1.6461	3.2922	3.3951	.6173	.3487
Min	3.2773	2.2862	1.6461	3.2922	3.3951	.6173	.3487
Avg	3.2773	2.2862	1.6461	3.2922	3.3951	.6173	.3487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 201 / 11 KV Aundh Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0537	.056	.056	.0537	.0566
2	.0377	.0377	.0549	.0572	.0549	.0543	.0566
3	.0377	.0377	.0549	.0572	.056	.0532	.0566
4	.0377	.0377	.0543	.0754	.056	.0526	.056
5	.0754	.0566	.0549	.0943	.0747	.0895	.0747
6	.1132	.0747	.0532	.1109	.1132	.1063	.0924
7	.132	.1109	.1097	.1307	.132	.1254	.1294
8	.1294	.1478	.1097	.1509	.1509	.1294	.1109
9	.0924	.0747	.0732		.112	.0914	.0724
10	.0943		.0537		.0747	.0554	.0554
11	.0754		.0549	.0924		.0543	.0543
12	.0549		.056	.0724		.0549	.0549
13	.0549		.037	.0732		.0549	.1494
14	.0549		.0373	.0732		.0554	.1109
15	.0549		.0373	.0732		.0554	.0732
16	.0554		.0554	.0732		.0554	.0747
17	.0543		.0747	.0732		.056	
18	.1097			.0732		.0537	.1097
19	.1307		.1109	.1463		.1478	.1294
20	.1132		.1867	.1829		.1509	.1867
21	.0943		.112	.1867		.132	.112
22	.0754		.0934	.1463		.112	.0762
23	.0566		.0754	.0747		.0747	.0572
24	.0377	.0377	.0532	.056	.0747	.0532	.056
Max	.132	.1478	.1867	.1867	.1509	.1509	.1867
Min	.0377	.0377	.037	.056	.0549	.0526	.0543
Avg	.0754	.0653	.0720	.0968	.0868	.0801	.0872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 202 / 11 KV Aundh AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.2401	.3086	.3048	.0377	.0543	
2	.0373	.2469	.3121	.3048	.0362	.0532	.0354
3	.0373	.2435	.3856	.2972	.0366	.0537	.0358
4	.0366	.2534	.5014	.3715	.0377	.0543	.0362
5	.0373	.2743	.5847	.4923	.0377	.0732	.0362
6	.037	.3001	.591	.5068	.0377	.0716	.0543
7	.0377	.3286	.7087	.5573	.0566	.0709	.0716
8	.0366	.3715	.8402	.8253	.0566	.0709	.0724
9	.0366	.3616	.8573		.0377	.0532	.0358
10	.0366		.7865		.0377	.0537	.0362
11	.7468		.0543	.0362		.5639	.5357
12	.7968		.0554	.0362		.643	.5647
13	.8253		.0549	.0366		.6081	.5075
14	.8253		.0554	.0366		.6081	.543
15	.8215		.0747	.0366		.6308	.6161
16	.8253		.0739	.0366		.6836	.6748
17	.8471		.056	.0362		.6602	
18	.695			.0362		.5937	.4401
19	.0514		.0554	.0549		.0724	.0457
20	.0709		.0732	.0549		.0895	.0686
21	.0537		.0739	.0543		.0724	.0686
22	.0358		.056	.0537		.0724	.0732
23	.0354		.0566	.0354		.0532	.056
24	.0339	.0358	.0537	.056	.0354	.0549	.0543
Max	.8471	.3715	.8573	.8253	.0566	.6836	.6748
Min	.0339	.0358	.0537	.0354	.0354	.0532	.0354
Avg	.2931	.2656	.2900	.1937	.0407	.2506	.2119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 303 / BHOSARE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.6173	.5487	.6097	.0732	.0716	.0724
2	.0754	.6325	.5967	.6097	.0732	.0732	.0732
3	.0754	.6249	.6036	.5944	.0747	.0716	.0724
4	.0754	.6249	.5898	.743	.0754	.0716	.0732
5	.0754	.6325	.9717	.8573	.0732	.0732	.0724
6	.0754	.6401	1.1203	1.0936	.0732	.1075	.1097
7	.0754		1.2018	1.1873	.0732	.1086	.1086
8	.0754	.7042	1.4403	1.3375	.0754	.1052	.1097
9	.0747	.6325	1.326	1.2193	.0732	.1097	.1086
10	.0747		1.2003	1.086	.0732	.1075	.1097
11	1.4403		.112	.0724		1.2651	1.2498
12	1.5623		.1463	.0732		1.406	1.3717
13	1.5813		.1097	.0732		1.4232	1.4266
14	1.6004		.112	.0732		1.2651	1.3717
15	1.4232		.1109	.0732		1.2498	1.3108
16	1.6004		.1097	.0724		1.4232	1.286
17	1.5813		.112	.0732		1.2498	1.2193
18	1.2803		.1509	.0732		1.1069	1.0002
19	.1029		.112	.0747		.1086	.1086
20	.112		.1097	.0732		.1086	.1494
21	.1132		.112	.0747		.1097	.1494
22	.0754		.1132	.0747		.1097	.1132
23	.0754		.0739	.0747		.0724	.1143
24	1.2757	.0754	.0716	.0754	.0754	.0724	.0716
Max	1.6004	.7042	1.4403	1.3375	.0754	1.4232	1.4266
Min	.0747	.0754	.0716	.0724	.0732	.0716	.0716
Avg	.6074	.5760	.4648	.4321	.0739	.4946	.4939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 304 / BHOSARE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018			.2534	.3395
2	.3018	.2987			.2561	.3395
3	.3018	.3018			.2587	.3395
4		.3018			.2561	.3361
5	.4527	.3772			.2896	.4481
6	.7545	.5658			.3582	.7468
7	.9054				.4961	.8299
8	.7545	.6653			.6584	.7545
9	.5658	.5601			.5544	.5658
10	.4527	.5601			.4527	.4527
11	.3772	.3658			.4481	.3734
12	.2587	.2957			.4481	.5175
13	.2561	.2865			.3734	.4755
14	.3696	.2896			.3772	.4435
15	.3734	.2926			.3772	.4854
16	.3734	.3658			.362	.4527
17	.3658	.3734			.362	.4706
18	.362	.4435			.3734	.5121
19	.5601	.5228			.5601	.5914
20	.6722	.5487			.679	.8299
21	.4527	.5731			.679	.7468
22	.3772	.543			.5658	.679
23	.3772	.4755	.4755		.4527	.5281
24	1.2308	.3395		.2926	.2865	.3772
Max	1.2308	.6653	.4755	.2926	.679	.8299
Min	.2561	.2865	.4755	.2926	.2534	.3361
Avg	.4885	.4195	.4755	.2926	.4241	.5265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 305 / KHATAV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3361	.3544	.4572	.3772	.2957	.4527
2	.3018	.3395	.3658	.4572	.3772	.2926	.3772
3	.3018	.3395	.3544	.4481	.3772	.2865	.381
4	.3395	.3395	.4298	.5601	.3772	.2835	.3772
5	.4527	.415	.4961	.679	.5658	.3582	.5281
6	.679	.7545	.5853	.7316	.7167	.4344	.7621
7	1.0185	.9054	.7087	.9431	.8676	.6584	.9054
8	.9431	.8215	.8954	.8215	.7545	.8954	.8676
9	.7545	.7095	.7316	.7545	.5975	.7316	.6722
10	.6036		.5544	.6653	.4755	.6653	.5853
11	.5281		.4481	.5228		.5853	.4854
12	.3696		.4481	.4481		.543	.439
13	.3658		.3772	.4481		.5175	.3658
14	.5175		.4481	.4481		.4481	.3658
15	.4481		.3772	.439		.4527	.3772
16	.4481		.3772	.4481		.4481	
17	.5121		.5175	.4854		.5175	.5068
18	.5487		.5175	.5544		.4854	.5853
19	.7468		.6584	.9709		.8962	.6653
20	.8299		1.0082	.9431		.9709	.9054
21	.7167		.8299	.7922		.9054	.7545
22	.5658		.7545	.679		.7545	.6722
23	.4191		.5335	.4904		.5658	.5228
24	1.4731	.3772	.439	.4572	.415	.3658	.4527
Max	1.4731	.9054	1.0082	.9709	.8676	.9709	.9054
Min	.3018	.3361	.3544	.439	.3772	.2835	.3658
Avg	.5911	.5338	.5504	.6102	.5365	.5566	.5655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 306 / KHATAV AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.0747	.1075	.0754	1.8122	2.0332	1.4998
2	1.7901	.0754	.1063	.0754	1.7078	2.0576	1.4548
3	1.6872	.0754	.1052	.0747	1.6194	2.2539	1.4198
4	1.749	.0754	.1075	.112	1.4403	2.2874	1.4998
5	1.9204	.0754		.1143	1.4232	2.5263	1.5813
6	2.0729	.112	.1075	.1524	1.4723	3.2156	1.7711
7	2.7526	.1509	.1052	.1524	1.768	3.3608	2.5911
8	3.0361	.1132	.1063	.1132	1.7238	3.2922	3.0727
9	3.0361	.112	.2172	.0747	1.7833	3.4294	2.9447
10	2.3472		.1097	.0732	1.7017	2.6246	2.3472
11	.0747		3.3425	3.0445		.1132	.112
12	.1097		3.6488	3.7571		.1132	.1132
13	.1109		3.6808	3.7494		.112	.1097
14	.1143		3.5421	3.4789		.112	.0732
15	.1132		3.2575	3.3333		.112	.0747
16	.1132		3.5303	3.2716		.1132	.064
17	.1132		3.2648	3.0864		.112	.1097
18	.1132		2.6566	2.6216		.1132	.112
19	.1524		.1097	.112		.1509	.1109
20	.1132		.1509	.0732		.1494	.1509
21	.1132		.1509	.0732		.1132	.1463
22	.0754		.112	.0732		.1132	.1097
23	.0754		.112	.0732		.1132	.112
24	2.476	.0754	.1075	.0754	.0747	.1097	.1132
Max	3.0361	.1509	3.6808	3.7571	1.8122	3.4294	3.0727
Min	.0747	.0747	.1052	.0732	.0747	.1097	.064
Avg	1.0870	.0940	1.2495	1.1600	1.5024	1.1971	.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 301 / 22 KV R Kurle AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	1.2125	1.3435	1.4746	.1509	.1509	.1886
2	.1509	1.1469	1.3108	1.4746	.1509	.1509	.1886
3	.1509	1.1469	1.3108	1.4746	.1509	.1509	.1886
4	.1509	1.1469	1.3108	1.4746	.1509	.1509	.1886
5	.1886	1.1469	1.3108	1.5074	.1509	.1509	.2263
6	.2614	1.1469	1.5729	1.6194	.3018	.2641	.2641
7	.3361	1.278	2.0317	1.9433	.4527	.3018	.3395
8	.3361	1.4091	2.1956	2.2996	.3772	.3395	.3018
9	.2987	1.5402	2.2939	2.2024	.2641	.2263	.2263
10	.2263	1.4746	2.0222	1.9006	.2641	.3018	.1509
11	2.556	.2263	.2614	.2641	2.2996	2.4905	2.3266
12	2.8509	.2641	.2614	.2641	2.7854	2.7199	2.556
13	3.0148	.2641	.2241	.2263	2.8826	2.9165	2.6216
14	3.0476	.1509	.2241	.2641	2.8178	2.8182	2.5888
15	2.8837	.2263	.2614	.2263	2.753	2.6216	2.5232
16	2.7199	.2263	.2263	.2263	2.5587	3.0178	2.4249
17	2.4249	.3018	.1886	.2641	2.4249	2.3922	2.2283
18	2.0317	.1132	.2263	.2641	2.0972	2.1052	1.9006
19	.2263	.3395	.2641	.3395	.2641	.3018	.2641
20	.2263	.3018	.2641	.3018	.2263	.2641	.2641
21	.2263	.2641	.2641	.3018	.2263	.2641	.2263
22	.1886	.2263	.2641	.2641	.2263	.2263	.2263
23	.1509	.1886	.1886	.1132	.1886	.1886	.1886
24	.1509	.1509	.1509	.1509	.1509	.1509	.1886
Max	3.0476	1.5402	2.2939	2.2996	2.8826	3.0178	2.6216
Min	.1509	.1132	.1509	.1132	.1509	.1509	.1509
Avg	1.0396	.6622	.8322	.8684	1.0132	1.0277	.9496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 302 / 22 KV Pusesavali Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3395	.3772	.3772	.415	.415	.415
2	.3361	.3395	.3772	.3772	.415	.415	.415
3	.3361	.3395	.3772	.3772	.415	.415	.415
4	.3361	.3395	.3772	.3772	.415	.415	.415
5	.4108	.3395	.3772	.4527	.415	.4527	.4904
6	.6722	.5658	.6413	.5658	.7545	.6584	.6413
7	.9709	.8676	.9431	.8589	1.0185	.9709	.924
8	.8589	.9054	.8299	.8589	.9431	.8215	.8871
9	.7468	.679	.679	.7167	.6413	.6036	.6413
10	.5658	.5281	.5601	.6036	.5281	.5281	.6036
11	.6036	.5281	.4854	.5658	.415	.4904	.4904
12	.4527	.5281	.4481	.5281	.4904	.4904	.5658
13	.4904		.4481	.4904	.4527	.4527	.4904
14	.5281	.415	.4854	.4527	.4527	.4527	.3772
15	.5281	.4904	.5228	.4904	.4527	.4527	.4904
16	.4527	.4527	.5281	.4904	.4904	.4527	.5281
17	.3772	.5281	.6036	.5281	.4527	.4904	.5281
18	.5658	.5658	.5281	.5281	.6036	.5658	.4904
19	.7167	.7545	.7468	.7922	.8676	.7468	.7922
20	.7545	.7545	.8871	.8299	.7762	.7468	.8299
21	.679	.7545	.7468	.7922	.7545	.679	.7167
22	.6036	.6413	.6413	.7167	.679	.679	.679
23	.4527	.4904	.4904	.5658	.4904	.5281	.5281
24	.3734	.3772	.415	.415	.415	.4527	.415
Max	.9709	.9054	.9431	.8589	1.0185	.9709	.924
Min	.3361	.3395	.3772	.3772	.415	.415	.3772
Avg	.5478	.5445	.5632	.5730	.5731	.5573	.5737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 303 / 22 KV Vadgaon AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2801	.2286	.2263	.2641	1.7695	1.9989	2.13
2	2.2801	.2286	.2263	.2641	1.7695	1.9989	2.13
3	2.2801	.2286	.2263	.2641	1.7695	1.9989	2.13
4	2.2801	.2286	.2263	.2641	1.7695	1.9989	2.13
5	2.3205	.2286	.2263	.3018	1.7695	2.0972	2.2283
6	2.4531	.2641	.3772	.3395	1.8351	2.3922	2.4291
7	3.2712	.415	.415	.4527	2.2939	3.2007	3.3608
8	3.8542	.3772	.3772	.4527	2.6871	3.6687	3.7769
9	3.3684	.3395	.3395	.0754	2.5232	3.6488	3.5848
10	2.7526	.3772	.0377	.0754	2.2939	3.1786	3.1093
11	.2263	3.5528		3.7247	.0377	.2641	.2641
12	.2641	4.545	3.9838	4.4696	.0754		.2641
13	.2263	4.545	4.2105	4.2379	.1132		.2641
14	.2641	4.449	4.34	4.289	.0754		.2641
15	.2641	4.1133	3.9514	4.0798	.3018		.1886
16	.3018	4.1133	4.34		.3395		
17	.3395	4.1289	3.8866	3.408	.3772	.3772	.3018
18	.3018	3.7685	3.6599	3.546	.3395	.415	.2641
19	.3395	.3395	.3018	.3018	.415	.415	.415
20	.3395	.3772	.3395	.3018	.415	.415	.3772
21	.3018	.3395	.3395	.3018	.3772	.415	.3395
22	.2641	.3018	.3018	.2641	.3395	.3395	.3018
23	.2263		.2641	.2263	.3018	.3395	.2641
24	2.2542	.2286	.2263	.2641	.2263	.2641	.2641
Max	3.8542	4.545	4.34	4.4696	2.6871	3.6687	3.7769
Min	.2263	.2286	.0377	.0754	.0377	.2641	.1886
Avg	1.3772	1.6399	1.4271	1.3986	1.0090	1.5487	1.3383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 304 / 22 KV Pusesavali AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.7293	1.0486	.9831	.0754	.1132	.0754
2	.1132	.6554	1.0486	.9831	.0754	.1132	.0754
3	.1132	.663	1.0486	.9831	.0754	.1132	.0754
4	.1132	.663	1.0486	.9831	.0754	.1132	.0754
5	.1509	.6554		1.0486	.0754	.1132	.1132
6	.1886	.6962	1.2452	1.1142	.1886	.1509	.1509
7	.2241	.78	1.5402	1.4899	.2263	.1886	.1886
8	.1886	.7956	1.6057	1.6518		.1886	.1886
9	.1509	.8288	1.5074	1.704	.1886	.1509	.1886
10	.1509	.7956	1.4419	1.5402	.1509	.1132	.0754
11	1.8023	.1132	.1132	.0754	1.587	1.6057	1.4746
12	1.8351	.0754	.1509	.0377	1.8785	1.9334	1.7368
13	1.7695	.0754	.1509	.1132	2.0405	1.9662	1.9006
14	1.704	.1132	.1509	.1132	1.8461	1.9662	1.8679
15	1.6712	.0754	.1132	.1132	1.7814	1.9989	1.6057
16	1.6057	.1132	4.34	.0754	1.7814	1.9662	1.7368
17	1.6712	.1509	.1132	.0754	1.704	1.5729	1.7695
18	1.3108	.1509	.0754	.1509	1.3435	1.3927	1.7353
19	.1132	.1509	.1886	.1886	.1132	.1509	.1509
20	.1132	.1886	.1886	.1132	.1509	.1509	.1509
21	.0754	.1509	.1509	.1132	.1132	.1132	.1132
22	.0754	.1509	.1509	.1132	.1132	.1132	.1132
23	.0754	.1132	.1132	.1132	.1132	.1132	.1132
24	.1132	.0754	.1132	.1132	.1132	.1132	.0754
Max	1.8351	.8288	4.34	1.704	2.0405	1.9989	1.9006
Min	.0754	.0754	.0754	.0377	.0754	.1132	.0754
Avg	.6434	.3733	.7673	.5829	.6874	.6881	.6563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 306 / 22 KV Vadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1886	.1886	.1886	.1886	.1886
2	.1509	.1509	.1886	.1886	.1886	.1886	.1886
3	.1509	.1509	.1886	.1886	.1886	.1886	.1886
4	.1509	.1509	.1886	.1886	.1886	.1886	.1886
5	.2241	.1509	.1886	.2263	.1886	.1886	.2263
6	.2987	.2263	.3018	.2641	.2641	.2263	.2641
7	.3734	.3395	.415	.3395	.3772	.3395	.3395
8	.2987	.3018	.3395	.3395	.3395	.3018	.3395
9	.2614	.2263	.2263	.2263	.2263	.2263	.2263
10	.1886	.1886	.1886	.2263	.2263	.2263	.1509
11	.1886	.1886	.1509	.1509	.1886	.1886	.1509
12	.1886	.1886	.1886	.1886	.1886	.1886	.1509
13	.1886	.1886	.1886	.1509	.1509	.1886	.1509
14	.1509	.1886	.1886	.1509	.1509	.1886	.1509
15	.1886	.1886	.1886	.1509	.1886	.1886	.1509
16	.1509	.1509	.1886	.1509	.1886	.0754	.1509
17	.1886	.1509	.1509	.1509	.1886	.1509	.1509
18	.1886	.2263	.2263	.1886	.2195	.1886	.2263
19	.3018	.3018	.3018	.3292	.3018	.2641	.3018
20	.3395		.415	.415	.415	.3772	.3772
21	.3395	.3395	.415	.3772	.3772	.3772	.3772
22		.3018	.3395	.3395	.3395	.3395	.3772
23	.1886	.2263	.2263	.2641	.2641	.3018	.2641
24		.1886	.1886	.2263	.1886	.2263	.2263
Max	.3734	.3395	.415	.415	.415	.3772	.3772
Min	.1509	.1509	.1509	.1509	.1509	.0754	.1509
Avg	.2205	.2116	.2405	.2338	.2386	.2295	.2295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 201 / Ladegaon High School

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.0747	.0739	.0747	.0747	.0747
2	.0566	.056	.056	.0554	.0747	.0747	.0747
3	.0566	.056	.056	.0554	.0747	.0747	.0747
4	.0566	.0566	.0754	.0554	.0747	.0747	.0747
5	.0754	.0943	.0747	.0739	.0934	.0747	.0739
6	.0943	.1132	.1109	.0747	.112	.0924	.0924
7	.112	.1307	.1307	.0732	.1307	.1109	.1097
8	.1109	.1097	.132	.0732	.1307	.1294	.1086
9	.1109	.1307	.1294	.0732	.1478	.0914	.0914
10	.1097	.1109	.0739	.0549	.1097	.0732	.0732
11	.0934	.1109	.0747		.0934	.0914	.0739
12	.0914	.0724	.0747		.1294	.0732	.1109
13	.0732	.0732	.0724		.112	.0732	.1109
14	.0724	.0739	.0732		.0914	.0914	
15	.1109	.0905	.0739		.1086	.0914	.0934
16	.1097	.0924	.0914	.0732	.1463	.0914	.112
17	.1294	.0924	.0914	.1463	.1494	.0924	.112
18	.0914	.112	.0934	.1848	.128	.112	.1132
19	.1433	.1494	.1307	.1663	.1448	.1307	
20	.128	.168	.1494	.1663	.128	.1494	.132
21	.1294		.1109	.1494	.1294	.1494	.1494
22	.112		.0914	.1494	.112	.112	.1494
23	.0914		.0732	.112	.0924	.0934	.0934
24	.056	.0739	.0747	.0732	.0747	.0732	.0747
Max	.1433	.168	.1494	.1848	.1494	.1494	.1494
Min	.056	.056	.056	.0549	.0747	.0732	.0732
Avg	.0946	.0972	.0912	.0992	.1110	.0956	.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 202 / 11 KV Yeliv AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.4999	.506	.7202	.1143	.0953	.0924
2	.1143	.4801	.4572	.7611	.1143	.0943	.0924
3	.0953	.4915	.4374	.7701	.1143	.0953	.0914
4	.0953	.5182	.4531	.8192	.1143	.1143	.0914
5	.1143	.5218	.6859	.8192	.1334	.1334	.0924
6	.1334	.5468	1.1069	.8583	.1524	.128	.112
7	.1494	.5761	1.1385	1.1797	.1905	.1307	.1307
8	.1307	.583	1.2498	1.3923	.1867	.1448	.1307
9	.112	.6249	1.2651	1.491	.168	.128	.1463
10	.1494	.6405	1.0364	1.166	.1848	.128	.1463
11	1.3117	.0701	.1463	.112	1.531	1.5364	1.1702
12	1.6964	.1086	.128	.112	1.7924	1.6518	1.3441
13	1.8084	.128	.1294	.1494	1.7695	1.7695	1.5466
14	1.7497	.1109	.1097	.168	1.8884	1.4403	1.6129
15	1.8244	.1109	.1109	.168	1.7654	1.6842	1.4864
16	1.8724	.132	.112	.1307	1.5741	1.7204	1.3748
17	1.6716	.132	.1307	.1494	1.5935	1.5844	1.3441
18	1.2176	.1132	.1463	.1494	1.3426	1.4255	1.1227
19	.1372	.1509	.1463	.1867	.1372	.1097	.1132
20	.1227	.112	.1463	.1867	.1075	.1294	.112
21	.1075		.128	.168	.1402	.1307	.112
22	.0914		.1294	.1494	.1254	.112	.0934
23	.1267		.1109	.1494	.1086	.112	.0943
24	.7642	.6097	.1294	.112	.1307	.1109	.112
Max	1.8724	.6405	1.2651	1.491	1.8884	1.7695	1.6129
Min	.0914	.0701	.1097	.112	.1075	.0943	.0914
Avg	.6546	.3458	.4225	.5028	.6450	.6129	.5319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 204 / Trimali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1646	.1867	.2241	.2241	.2241	.2263
2	.1715	.168	.168	.2241	.2054	.2054	.2263
3	.1715	.1494	.1698	.2241	.2054	.2054	.2075
4	.1715	.1494	.1886	.2427	.2054	.2054	.2075
5	.2096	.2075	.3361	.2772	.2427	.2427	.2263
6	.2987	.2829	.4066	.3174	.3174	.3142	.2829
7	.3881	.3696	.4854	.3511	.4024	.3841	.3921
8	.3292	.3109	.4527	.4024	.3696	.3547	.3109
9	.3292	.2957	.3772	.3696	.3511	.2957	.2534
10	.3109	.2218	.3734	.3292	.2743	.2772	.2686
11	.2507	.2402	.2926	.3292	.2743	.2772	.2534
12	.2896	.2427	.2926	.3696	.2402	.2614	.2218
13	.2772	.2263	.2743	.2987	.2427	.2614	.1867
14	.2263	.1848	.2743	.2402	.2218	.2054	.1867
15	.2614	.1886	.2743	.2743	.2241	.2427	.2263
16	.2195	.2054	.2715	.2926	.2561	.2195	.2614
17	.2801	.2427	.2195	.2743	.2801	.2402	.2614
18	.2686	.3018	.2957	.2743	.2587	.2427	.2587
19	.3841	.3547	.4481	.3696	.4207	.3734	.3511
20	.3881	.4338	.4854	.4251	.3881	.415	.3921
21	.3658		.4481	.3841	.3734	.3961	.3881
22	.2715		.3772	.3326	.3475	.3584	.3326
23	.2149		.2829	.2801	.2772	.3018	.2587
24	.1867	.1867	.2075	.2452	.2427	.2427	.2452
Max	.3881	.4338	.4854	.4251	.4207	.415	.3921
Min	.1715	.1494	.168	.2241	.2054	.2054	.1867
Avg	.2688	.2442	.3162	.3063	.2852	.2811	.2678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 205 / 11 KV Karkhana AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.4999	.5535	.6401	.1494	.0747	.112
2	.0934	.4801	.506	.6154	.1307	.0747	.112
3	.0934	.4915	.4999	.6154	.112	.0747	.112
4	.0934	.4973	.5468	.6478	.112	.1494	.1109
5	.1307	.5668	.7316	.7287	.1494	.1867	.1294
6	.1867	.6249	1.1248	.8802	.1867	.2241	.168
7	.2561	.6562	1.4706	1.3603	.2614	.2772	.2561
8	.2218	.6874	1.4706	1.5684	.2218	.2561	.2195
9	.1848	.7042	1.5023	1.5546	.1848	.1109	.1829
10	.1848	.6642	1.2176	1.1961	.1463	.1478	.1463
11	1.3592	.1294	.1463		1.5466	1.4403	1.2492
12	1.7604	.1663	.1463		1.8724	1.6032	1.3757
13	1.7814	.1478	.1463		2.0317	1.5844	1.4685
14	1.6975	.1448	.1463		1.8278	1.6518	
15	1.5779	.1478	.1463		1.6964	1.4563	1.4232
16	1.6004	.1494	.1294	.0905	1.4998	1.4575	1.3748
17	1.6409	.1478	.1494	.1463	1.3272	1.3443	1.2651
18	1.2163	.1867	.168	.1829	1.1043	1.1961	1.2018
19	.1543	.2241	.1867	.2195	.2058	.1829	
20	.1646	.2054	.2054	.2195	.1867	.1848	.1448
21	.1663		.168	.1848	.1402	.168	.1478
22	.1086		.1509	.1663	.1433	.1663	.1478
23	.0924		.1307	.168	.1307	.1307	.1294
24	.7281	.5487	.1132	.112	.1494	.1097	.112
Max	1.7814	.7042	1.5023	1.5684	2.0317	1.6518	1.4685
Min	.0924	.1294	.1132	.0905	.112	.0747	.1109
Avg	.6502	.3843	.4899	.5946	.6465	.5939	.5268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 206 / 11 KV Kharsinge AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3437	.056	.037	.056	.1943	.2343	.3201
2	.3125	.0566	.0373	.056	.2429	.1943	.3239
3	.3239	.0566	.0373	.056	.2458	.1943	.3077
4	.3239	.0924	.0566	.056	.2458	.3277	.3239
5	.4049	.112	.0566	.056	.2949		.3441
6	.4961	.1097	.0934	.0747	.3239	.4915	.4534
7	.7274	.128	.1109	.0914	.3201	.8482	.7522
8	.6882	.1494	.112	.0905	.4049	.9217	.8583
9	.8097	.1294	.1132	.0914	.4372	.7748	.8356
10	.583	.0739	.112	.0732	.4049	.7042	.6964
11	.0686		.7362	.7748	.0686	.0549	.0377
12	.0701	.7811	.8097	.8065	.1227	.0549	.0566
13	.0914	.828	.7682	.8482	.0934	.0549	.0747
14	.0895	.8855	.8684	.8482	.0739	.0739	.0739
15	.0914	.9061	.8002	.8097	.0732	.0747	.0739
16	.1075	.9145	.8745	.7287	.0739	.0747	.0732
17	.1086	.8436	.8848	.7045	.0747	.0747	.0924
18	.0739	.759	.7522	.6554	.0739	.0747	.112
19	.128	.112	.0914	.0709	.1086	.0914	.1132
20	.1086	.1132	.0914	.1086	.0924	.0924	.112
21	.0934		.0732	.0905	.0934	.0934	.0934
22	.0732		.0549	.0549	.0924	.0747	.0934
23			.0549	.0549	.0747	.0747	.0747
24	.3353	.0747	.037	.0554	.0554	.0732	.056
Max	.8097	.9145	.8848	.8482	.4372	.9217	.8583
Min	.0686	.056	.037	.0549	.0554	.0549	.0377
Avg	.2806	.3591	.3193	.3047	.1786	.2491	.2647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 257020 / 132/33 KV EHV Aundh

Feeder No / Name : 400 / Auxilliary Supply

Feeder KV- 33 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	3.0407
Max	3.0407
Min	3.0407
Avg	3.0407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 257020 / 132/33 KV EHV Aundh

Feeder No / Name : 407 / 33 KV Haranai Express FDR NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	3.0407
Max	3.0407
Min	3.0407
Avg	3.0407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 257020 / 132/33 KV EHV Aundh

Feeder No / Name : 702 / 132 KV GPSL Gopuj CO Gen NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18
HR	Load (MW)
24	12.1628
Max	12.1628
Min	12.1628
Avg	12.1628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 201 / 11 KV VAR-MALAWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6024	.0732	.0543	.0732	.5359	.4973
2	.3772	.5959	.0739	.0549	.0739	.567	.547
3	.4239	.6135	.0732	.0549	.0739	.6036	.5735
4	.5087	.6556	.0732	.0732	.0914	.695	.5967
5	.5533	.6836	.0914	.0914	.0914	.7087	.663
6	.6783	.7011	.128	.128	.1463	.815	.8029
7	.8551	.9214	.1463	.1267	.1463	1.1043	1.0978
8	1.0985	1.0341	.128	.1086	.128	1.1871	1.0774
9	1.0745	1.4352	.0739	.0914	.0732		1.0343
10	.8859	.9667	.0543	.0739	.0362	.8619	.8817
11	.0366	.663	1.0288	.6796	.0366	.0554	.0549
12	.0366	.9339	1.1736	.8356	.0549	.037	.0549
13	.0549	.9995	1.1736	.9945	.0554	.0549	.0543
14	.0724	.9995	1.2071	.9831	.0549	.0554	.0549
15	.0739	.9831	1.1361	1.0159	.0549	.0554	.0724
16	.0732	.9667	1.0802	1.0322	.0549	.0554	.0543
17	.0905	.9831	1.0802	.9945	.0724	.0732	.0549
18	.0732	.6133	.9496	.9012	.0914	.0914	.0914
19	.1109	.128	.1463	.1475	.128	.128	.128
20	.1097	.128	.1629	.1646	.1478	.1463	.1629
21	.1109	.1097	.128	.128	.128	.128	.1267
22	.0732	.0924	.0905	.1097	.1109	.0914	.1097
23	.0732	.0739	.0914	.0739	.0914	.0914	.0905
24	.3944	.0549	.0732	.0724	.0924	.0732	.0739
Max	1.0985	1.4352	1.2071	1.0322	.1478	1.1871	1.0978
Min	.0366	.0549	.0543	.0543	.0362	.037	.0543
Avg	.3438	.6641	.4349	.3746	.0878	.3572	.3731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 202 / 11 KV SHENAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.5261
Max	1.5261
Min	1.5261
Avg	1.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 203 / 11 KV VAR-MALAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0886	.0924	.0754	.0924	.0724	.0924
2	.0739	.1052	.0924	.0747	.0924	.0914	.0924
3	.0747	.0886	.0924	.0747	.0924	.1097	.0924
4	.0934	.1063	.0924	.0934	.0924	.1086	.0924
5	.1307	.1227	.1109	.1109	.1109	.128	.1109
6	.1848	.124	.1294	.1463	.1478	.128	.1478
7	.1663	.1417	.1478	.1294	.1478	.1097	.1463
8	.128	.1227	.1109	.1097	.1109	.1097	.1294
9	.1097	.0732	.0924	.0924	.0732	.0739	.0739
10	.1086	.0739	.0924	.0924	.0724	.0554	.0739
11	.0732	.0739	.0732	.0739	.0554	.0739	.0914
12	.0739	.0739	.0554	.0554	.0549	.0554	.0732
13	.0549	.0554	.0554	.0739	.0549	.0739	.0554
14	.0543	.0554	.0739	.0554	.0543	.0739	.0543
15	.0732	.0554	.0549	.0739	.0549	.0739	.0739
16	.0724	.0924	.0554	.0739	.0543	.0554	.0739
17	.0914	.0924	.0739	.0739	.0732	.0739	.0924
18	.0924	.0914	.0914	.0924	.0924	.0924	.0924
19	.128	.1463	.1478	.1294	.1463	.1478	.1478
20	.1478	.1646	.1663	.1646	.128	.1478	.168
21	.128	.1478	.1478	.1478	.1463	.1294	.1494
22	.1097	.1109	.112	.1294	.128	.1294	.112
23	.0914	.1109	.112	.1109	.1097	.0924	.112
24	.1132	.0905	.0924	.0943	.0924	.0905	.0924
Max	.1848	.1646	.1663	.1646	.1478	.1478	.168
Min	.0543	.0554	.0549	.0554	.0543	.0554	.0543
Avg	.1028	.1003	.0986	.0979	.0949	.0957	.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 204 / 11 KV SHENAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0886	.0732	.0566	.0914	.0543	.0554
2	.0566	.0876	.0732	.0566		.0732	.0554
3	.0747	.0709	.0732	.0566	.0739	.0724	.0732
4	.0934	.1063	.0732	.0934	.1097	.0732	.0732
5	.1307	.1402	.0914	.1307	.1463	.0732	.1097
6	.2218	.1772	.1463	.1848	.2012	.128	.1629
7	.2561	.1829	.1829	.2378	.2353	.2195	.181
8	.2012	.1646	.1448	.2012	.181	.1463	.1097
9	.128	.1463	.1463	.1448	.128	.0905	.1294
10	.1086	.1097	.1294	.1463	.1097	.1086	.1109
11	.128	.1097	.0914	.1097	.1109	.0914	.1097
12	.1109	.1097	.0914	.1097	.0732	.0905	.0914
13	.1097	.1097	.0914	.1097	.0732	.0914	.0924
14	.0914	.1097	.0914	.1267	.0724	.0914	.0914
15	.0914	.0914	.0924	.128	.0549	.0914	.0924
16	.1294	.0914	.0914	.128	.1086	.0914	.0905
17	.1097	.0732	.1097	.1097	.0905	.1097	.1294
18	.1478	.0914	.1109	.0914	.0739	.1086	.1294
19	.1829	.1448	.1848	.181	.1097	.1629	.1848
20	.1848	.1448	.2218	.1991	.128	.181	.2241
21	.1463	.1097	.1848	.1646	.1294	.128	.168
22	.0914	.0914	.1307	.128	.0732	.128	.1307
23	.0924	.0914	.1132	.1097	.0739	.0739	.0943
24	.0754	.0724	.0732	.0943	.0914	.0549	.0732
Max	.2561	.1829	.2218	.2378	.2353	.2195	.2241
Min	.0566	.0709	.0732	.0566	.0549	.0543	.0554
Avg	.1258	.1131	.1172	.1291	.1104	.1056	.1151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 205 / 11 KV Jambhulni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	1.2048	.2561	.2012	.2743	.6379	.7045
2	.5087	1.2445	.2378	.2012	.2561	.8589	.779
3	.4801	1.382	.2378	.2172	.2561	1.2048	.8192
4	.5144	1.4352	.2743	.2353	.2743	1.262	.8848
5	.5658	1.4899	.3109	.2534	.3109	1.382	1.065
6	.7377	1.5424	.3982	.4163	.4024	1.7878	1.4091
7	1.4419	2.1262	.3982	.439	.4572	2.6578	2.17
8	2.5869	2.2085	.362	.4344	.4163	2.6993	2.0222
9	2.5431	2.4097	.2926	.3258	.3292	2.332	2.0454
10	1.9136	2.0972	.3077	.3258	.3475	1.8023	1.7295
11	.2378	1.3592	1.8313	1.9989	.3326	.1646	.3258
12	.2587	2.3102	2.5819	2.5911	.3841	.2012	.3658
13	.2743	2.5425	2.8502	2.7526	.5175	.4024	.3658
14	.2743	2.5888	2.5194	2.5263	.4706	.3982	.362
15	.3292	2.5888	2.2466	2.3266	.439	.4163	.4344
16	.3292	2.3758	2.3472	2.4086	.4525	.4163	.4887
17	.3475	2.2283	1.5939	2.4086	.439	.3841	.4344
18	.3258	1.5746	1.5261	1.704	.4251	.3475	.4344
19	.3475	.3841	.3801	.4024	.4938	.4163	.4525
20	.4024	.4163	.4024	.4706	.5175	.4344	.5249
21	.3658	.4024	.3658	.4024	.439	.4024	.4706
22	.3109	.3292	.2926	.3658	.3326	.2926	.362
23	.2926	.2926	.2561	.3109	.2926	.2561	.3258
24	.823	.2743	.2561	.2195	.2926	.2534	.2378
Max	2.5869	2.5888	2.8502	2.7526	.5175	2.6993	2.17
Min	.2378	.2743	.2378	.2012	.2561	.1646	.2378
Avg	.6976	1.5336	.9386	.9974	.3814	.8921	.8006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 201 / 11 KV DEVAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	1.2003	1.4217	1.4575		.2058	.3086
2	.2926	1.166	1.4563	1.406		.2058	.2743
3	.2743	1.1145	1.491	1.406	.1646	.2058	
4	.2743	1.2003	1.5257	1.406	.2195	.2229	.2743
5	.3109	1.2689	1.5604	1.5432	.2743	.2572	.3086
6	.2561	1.3203	1.6124		.3475	.3086	.3601
7	.3658		2.1971	2.3663	.4207		.4458
8	.3475	1.749	2.2857	2.572	.3475	.3772	.4287
9	.2591	1.9719	1.9033	2.4863	.3944	.0373	.3086
10	.1981	1.8004	1.7318	2.3663	.3944		.2572
11		.3429	.2561	.2401	2.572	2.3491	1.9547
12	.381	.3258	.2743	.3944	2.9835	2.692	2.4691
13	.2743	.3429	.439	.3086	1.5261	2.7606	2.0233
14		.3086	.439	.3772	1.8861	1.989	2.0062
15	1.6991	.2572	.439	.2401	2.6063	2.6406	1.989
16	1.893		.0373	.3772	2.2291	1.5947	2.3663
17	1.8861	.2591			2.1091	2.0919	2.0576
18	.8059	.2591	.4287		1.4403	2.1948	1.6632
19	.0343	.2743	.3944		.2401	.3429	.3109
20	.2401	.2591			.3258	.3429	.3109
21	.2401	.2743	.3258		.2915	.4115	.2926
22	.2401	.2896	.3086		.2572	.3772	.2926
23	.2743	.2743	.2915		.3086	.3772	.3109
24	.3475	.2915		.3086		.1886	.3429
Max	1.893	1.9719	2.2857	2.572	2.9835	2.7606	2.4691
Min	.0343	.2572	.0373	.2401	.1646	.0373	.2572
Avg	.5085	.7523	.9914	1.2035	1.0161	1.0079	.9285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 202 / 11 KV DHULDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	.3944	.6299	.6173		2.0062	1.9204
2	1.9033	.3772	.6133	.6173		1.9719	1.9719
3	1.7833	.3772	.6226	.6173	1.9376	1.9719	1.9719
4	1.7147	.3944	.6299	.6173	1.869	2.0576	1.9719
5	1.8347	.4115	.6241	.6173	2.5377	2.2291	2.0576
6	2.1434	.4458	.6401	.6173	2.7778	2.4863	2.2462
7	2.9492		.7209	.7716	2.9664		2.8464
8	3.5151	.4973	.6722	.7202	3.2922	2.7778	2.8464
9	3.0121	.3772	.5121	.6001	.3944	2.5206	2.3834
10	1.6804	.3086	.4755	.3086	.3944		2.1948
11	.3201		3.2065	2.9664	.0343	.4024	.3429
12	.4115	1.4575	.4973	3.9781	.0343	.4755	.3772
13	.381	1.406	.4973	3.8752	.0343	.6401	.4801
14	.503	3.3951	.4973	4.0124	.0343	.4572	
15	.4115	1.3375	3.8923	3.9952	.0343	.439	.5487
16	.4725		4.1667	3.8752	.2058	.7865	.703
17	.583	1.1963	3.9781		.7373	.823	.7316
18	.5144	2.4097	3.4294		.7545	.8573	.6401
19	.5487	.5344	.6859		.8573	.7373	.6036
20	.5487	.7045			.7202	.7202	.6219
21	.5144	.7362	.5658		.6516	.6859	.5973
22	.5144	.7202	.583		.583	.4973	.5853
23	.5144	.7045	.6173		.5316	.4287	.4572
24	1.7318	.3772	.6226	.6173		.4115	.4287
Max	3.5151	3.3951	4.1667	4.0124	3.2922	2.7778	2.8464
Min	.3201	.3086	.4755	.3086	.0343	.4024	.3429
Avg	1.2642	.8839	1.2774	1.7308	1.0182	1.1992	1.2838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 203 / 11 kv khadki bhataki Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1096	1.0631		.2229	.2401
2			1.1963	1.0288		.2229	
3			1.283	1.0288	.1829	.2058	
4			1.4043	1.0288	.2378	.2572	
5			1.5257	1.2346	.3109	.3429	.2743
6			1.6827	1.7661	.439	.3429	.463
7			2.3388	2.5034	.5121		.5144
8			2.5869	2.5892	.4755	.4458	.4458
9			1.2689	2.1948	.3086	.3475	.2572
10			.9774	1.6804	.3086		.1886
11			.1463	.1715	2.4348	1.5947	1.3546
12			.1463	.0343	2.3148	2.1434	2.0576
13			.1646	.1543	2.2119	2.692	2.0062
14			.1646	.1543	2.3663	1.6289	1.8176
15			.1646	.1372	2.2977	2.1262	1.749
16	2.4451		.0373	.1372	2.0748	2.2805	1.6632
17		.1524	.1543		2.0576	1.6975	1.7318
18		.1524	.1543		1.5775	1.6461	1.4918
19		.3353	.4115		.3944	.3944	.439
20		.3963			.463	.3429	.4024
21		.2743	.3429		.3601	.3086	.3292
22		.2591	.3086		.2743		.2743
23		.2134	.2572			.2743	.2561
24			.1981	.2743		.2058	.2401
Max	2.4451	.3963	2.5869	2.5892	2.4348	2.692	2.0576
Min	2.4451	.1524	.0373	.0343	.1829	.2058	.1886
Avg	2.4451	.2547	.7837	1.0107	1.0801	.9392	.8665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 204 / 11 kv Dhuldeo Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2572	.2439	.3429		.3086	.2915
2	.2926	.2401	.2439	.3429		.2743	.2915
3	.2561	.2401	.2591	.3429	.2195	.2743	.2915
4	.3109	.2743	.2896	.3429	.2743	.3086	.2915
5	.4024	.3429	.3201	.3429	.3109	.3429	.3429
6	.4938	.4287	.381	.4287	.3658	.4115	.4458
7	.4572		.3963	.5144	.4207		.5144
8	.4938	.4973	.3658	.4973	.3292	.4801	.3772
9	.3506	.3944	.3292	.4115	.3429	.2195	.3086
10	.2896	.5487	.4024	.2915	.3429		.3429
11	.3506	.3429	.3841	.3258	.2572	.3841	.3601
12	.3963	.3258	.3658	.3772	.2572	.3658	.3258
13	.2591	.2915	.3475	.3086	.2401	.3475	.3429
14	.1372	.3258	.3658	.2743	.2229	.3109	.2743
15	.2743	.2915	.2743	.2572	.2572	.3658	.2915
16	.2743		.1829	.3086	.2058	.3841	.2572
17	.3429	.2896	.3772		.2401	.3601	.3109
18	.2915	.3353	.3429		.2572	.3429	.2743
19	.2229	.4531	.4458		.4458	.3258	.4938
20	.4287	.4115			.4801	.3429	.4938
21	.4115	.3858			.463	.3944	.4572
22	.3772	.3201	.3944		.4287	.3772	.4207
23	.3429	.3048	.3772		.3601	.3429	.3658
24	.3658	.3086	.2743	.3429		.3429	.2915
Max	.4938	.5487	.4458	.5144	.4801	.4801	.5144
Min	.1372	.2401	.1829	.2572	.2058	.2195	.2572
Avg	.3396	.3459	.3347	.3560	.3201	.3458	.3524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 205 / 11 KV Mhaswad (U) Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.6173	.6516	.5144		.6859	.6859
2	.5792	.6173	.6226	.4801		.6516	.6516
3	.5792	.6173	.639	.4801		.6516	.6516
4	.6516	.823	.7625	.4801	.7421	.7716	.6859
5	.7964	.9259	.8951	.8573	.8869	.8573	.8916
6	1.1222	1.0288	.9922	.9945	1.0498	1.0974	1.0974
7	1.267		1.2309	1.0802	1.2851		1.2689
8	1.1584	1.1488	1.1616	1.046	1.2489	1.1317	1.1145
9	1.0288	1.0288	.9511	.9945	1.0288	.9593	.8573
10	.8573	.8916	.9412	.8916	1.0288		.8059
11	.8573	.9945	.9231	.8573	.9431		.7373
12	.823	1.0117	.9231	.9088	.9774	1.2489	.7716
13	.8059	.9774	.9231	.7716	.9259	1.1041	.8059
14	.8573	.8745	.9412		.8916	1.0498	.7888
15	.8059	.9774	.9231	.8745	.9259	1.086	.823
16	.823		.9593	.8916	1.0117	.9593	.8745
17	.9431		.9945		1.046	.9431	.905
18	.8573	1.0117	.9259		1.0288	.9431	1.0317
19	1.1317	1.2309	1.0974		1.2174	1.3375	1.3575
20	1.0974	1.2483			1.2174	1.2346	1.2851
21	1.046	1.166			1.1145	1.1831	1.1946
22	.9259	1.0117	.9259		.9945	.8573	1.1222
23	.7888	.823	.7545		.8059	.8573	.9774
24	.6697	.6859	.703	.6687		.703	.7373
Max	1.267	1.2483	1.2309	1.0802	1.2851	1.3375	1.3575
Min	.5792	.6173	.6226	.4801	.7421	.6516	.6516
Avg	.8787	.9387	.9019	.7995	1.0185	.9673	.9218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 202 / 11 kv Kukudwad gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.3258
Max	.3258
Min	.3258
Avg	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 204 / 11 KV DIWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.4022
Max	1.4022
Min	1.4022
Avg	1.4022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 205 / 11 kv Naravane Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.326
Max	1.326
Min	1.326
Avg	1.326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 206 / 11 KV NARAWANE GAVTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	.3258
Max	.3258
Min	.3258
Avg	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22/11 KV SHINGANAPUR

Feeder No / Name : 301 / 11 KV SHINGANAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
 (SHINGNA Feeder KV- 22 / DESIGN TRANSFORMER
 OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	.1524	.1524	.1524	.8002	.8322	.9069
2	1.1012	.1524	.1509	.1524	.8002		.8322
3	1.1797	.1905	.1886	.1905	.8002		.8223
4	1.3603	.3048	.2286	.2263	.8421		.8962
5	1.6575	.381	.381	.3048	.8951	1.326	1.1523
6	2.0317	.4572	.4191	.3772	1.0059	1.704	1.3763
7	2.5232	.4191	.415	.415	1.1065	2.3922	2.1765
8	3.0498	.4572	.4527	.3772	1.2597	2.9492	2.625
9	2.7515	.3018	.3018	.3395	1.4586	2.3594	2.5286
10	1.9559	.1905	.1848	.2263	1.2452	2.1628	1.9204
11	.381	2.6871	2.6543	2.6871	.1509	.1524	.1524
12	.1524	2.6246	3.0148	3.1131	.1494	.1524	.1524
13	.1524	3.131	3.0803	3.0445	.1509	.1524	.1524
14	.1524	3.3745	3.2769	2.9473	.1524	.1524	.1524
15	.1509	3.3524	3.2114	2.8826	.1524	.1509	.1509
16	.1524	3.2648	3.0769	2.8837	.1524	.1524	.1509
17	.1524	3.1626	3.0121	2.8182	.1886	.1509	.1905
18	.1905	2.5286	2.3967	2.2542	.3018	.2987	.1886
19	.3395	.2957	.3772	.3772	.4481	.3772	.3395
20	.4527	.4481	.3772	.3772	.415	.3772	.415
21	.3018	.381	.3018	.3772	.3772	.381	.3395
22	.2263	.2286	.2263	.2263	.3018	.3018	.2286
23	.1886	.1905	.1886	.1886	.1886	.2286	.1905
24	1.1523	.1524	.1524	.1886	.1886	.1886	.1905
Max	3.0498	3.3745	3.2769	3.1131	1.4586	2.9492	2.625
Min	.1509	.1524	.1509	.1524	.1494	.1509	.1509
Avg	.9519	1.2012	1.1759	1.1303	.5638	.8068	.7596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22/11 KV SHINGANAPUR

Feeder No / Name : 302 / 22 KV MARDI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.4481	.6325	.5761	.1478	.1509	.1524
2	.1494	.5376	.6401	.6478	.1463	.1494	.1524
3	.1509	.5376	.583	.6478	.1463	.1509	.1524
4	.1905	.6154	.7773	.6554	.1867	.1905	.1524
5	.2286	.6882	.9175	.7865	.2641	.2286	.2286
6	.3048	.7461	1.1271	.9945	.3772	.3048	.3048
7	.4572	.9015	1.4723	1.5912	.4572	.4572	.381
8	.3429	.8421	1.7814	1.6194	.3395	.3048	.381
9	.2263	.6882	1.5074	1.3443	.2263	.1886	
10	.1524	.6481	1.2037	1.0494	.1886	.1494	.1524
11	1.3916	.1524	.1402	.1478	1.3756	1.2803	1.2125
12	1.6004	.1509	.1478	.1494	1.5043	1.3763	1.3435
13	1.7078	.1509	.1509	.1494	1.5684	1.3599	1.4373
14	1.6004	.1524	.1509	.1509	1.5364	1.3916	1.3123
15	1.4723	.1524	.1494	.1509	1.5181	1.4083	1.3123
16	1.5813	.1494	.1494	.1509	1.4864	.9804	1.4232
17	1.6129	.1524	.1509	.1509	1.5623	1.2193	1.3717
18	1.2498	.1524	.1886	.2286	1.3123	1.1873	1.1888
19	.2286	.2667	.3018	.3048	.2286	.2667	.2667
20	.2286	.3048	.3018	.3048	.2667	.2667	.3048
21	.1905	.2286	.2263	.2641	.2286	.2286	.2286
22	.1509	.1905	.2263	.2263	.1509	.1886	.1494
23	.1524	.1494	.1886	.1886	.1478	.1524	.1478
24	.1509	.1478	.1494	.1886	.1886	.1494	.1509
Max	1.7078	.9015	1.7814	1.6194	1.5684	1.4083	1.4373
Min	.1494	.1478	.1402	.1478	.1463	.1494	.1478
Avg	.6530	.3814	.5527	.5279	.6481	.5721	.6047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22/11 KV SHINGANAPUR

Feeder No / Name : 303 / 11 KV SHINGANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1307	.1307	.1307	.132	.1494	.1294
2	.112	.1294	.1307	.1307	.1334	.1509	.1294
3	.1307	.1463	.1646	.1307	.1334	.1698	.1494
4	.1524	.2033	.2012	.1509	.1524	.1905	.1867
5	.2096	.2427	.2402	.2075	.2096	.2286	.2241
6	.2858	.2926	.2772	.2829	.3206	.2829	.2772
7	.3734	.2957	.2801	.3018	.415	.3921	.2743
8	.2587	.3174	.3018	.3174	.2987	.3142	.2743
9	.3361	.2402	.2772	.2801	.2587	.2926	.2926
10	.3475	.2241	.3077	.2987	.2534	.2561	.3326
11	.2401	.1928	.2865	.2865	.2195	.3012	.3366
12	.3012	.2601		.2507	.2715	.298	.298
13	.2686	.2401	.2896	.2126	.2328	.2507	.2254
14	.3258	.208	.2172	.1949	.2149	.3012	.2774
15	.3045	.1886	.2149	.1791	.2534	.2507	.2454
16	.2328	.1402	.2149	.197	.2378	.3045	.2126
17	.1949	.2149	.2172	.2328	.2743	.3012	.333
18	.2454	.1991	.2353	.2715	.3077	.2772	.3366
19	.3142	.3142	.3109	.3326	.3326	.3734	.3109
20	.3547	.3174	.3142	.3174	.3361	.3142	.3511
21	.2987	.2641	.2801	.3018	.2957	.2987	.2987
22	.2641	.2263	.2263	.2452	.2263	.2452	.2614
23	.1867	.2075	.1886	.1886	.1867	.1886	.2054
24	.132	.1478	.1509	.1509	.1509	.1698	.168
Max	.3734	.3174	.3142	.3326	.415	.3921	.3511
Min	.112	.1294	.1307	.1307	.132	.1494	.1294
Avg	.2493	.2226	.2373	.2330	.2436	.2626	.2554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22/11 KV SHINGANAPUR

Feeder No / Name : 304 / 22 KV MARDI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.1524	.3048	.3048	.3048	.2667
2	.2667	.2667	.1143	.3048	.3048	.3048	.2667
3	.3048	.2286	.1524	.3048	.3048	.3429	.3048
4	.381	.5335	.2286	.3048	.381	.381	.381
5	.4572	.6859	.3048	.381	.5335	.5335	.5335
6	.6097	.8383	.381	.6097	.7621	.6478	.724
7	.9145	.9526	.5335	.8383	.9145	.8383	.6097
8	.724	.3429	.5716	.6097	.724	.724	.5335
9	.5716		.381	.4954	.4572	.4954	.2286
10	.4572	.3048	.3048	.4191	.3429	.4572	.3429
11		.2286	.2667	.3429	.3048	.3429	.3429
12	.381	.1905	.2667	.2667	.1905	.2667	.2667
13	.381	.2286	.1524	.2667	.2667	.3048	.2667
14	.3429	.1905	.1524	.2667	.2667	.2667	.2667
15	.381	.2667	.2667	.2667	.2667	.2286	.2667
16	.381	.1524	.3048	.2667	.2286	.2667	.2667
17	.4191	.2667	.2286	.2286	.2286	.2286	.2286
18	.5335	.2667	.3429	.3048	.4191	.4191	.3429
19	.6097	.4572	.4572	.4954	.6859	.6859	.6478
20	.6097	.6097	.6478	.724	.5716	.6097	.6097
21	.4954	.5335	.5716	.6097	.4954	.6097	.6097
22	.4191	.4191	.4572	.4191	.381	.4954	.4572
23	.3429	.3048	.3429	.3429	.381	.381	.381
24	1.4022	.3048	.2667	.3048	.3048	.3048	.3429
Max	1.4022	.9526	.6478	.8383	.9145	.8383	.724
Min	.2667	.1524	.1143	.2286	.1905	.2286	.2286
Avg	.5066	.3843	.3270	.4033	.4175	.4350	.3953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 301 / 22 KV PARKANDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	.1494	.2241	.2263		.9831	.6706
2	.6706	.1509	.2263	.1886	.6036	.9175	.7209
3	.7209	.1509	.2263	.2263	.5898	.9282	.7377
4	.852	.1509	.2263	.2614		.9831	.9496
5	1.0059	.381		.2987	.8048	1.0608	1.0486
6	1.3565	.381	.4527	.415	.9015	1.3413	1.3923
7	2.0081	.4572	.5281	.5281	1.1401	2.0972	1.8351
8	1.8976	.3772	.3772	.415	1.2308	2.5339	1.989
9	1.5623	.2263	.2263	.2987	1.2163	2.0317	1.7695
10	1.1736	.2195	.1509	.1886	1.2597	1.5074	1.3927
11	.0762	1.7695	1.704	1.6842	.0754	.0754	.0754
12	.0762	2.0729	2.1216	1.9662	.0747	.0754	.0754
13	.0754	1.9845	1.6049	1.6644	.0739	.1509	.0754
14	.0754	2.2024	1.8351	1.6644		.1494	.0754
15	.0754	2.0485	1.6907	1.7284	.0747	.1509	.0754
16	.0762	1.4083	1.8233	1.6644	.0754	.1478	.0754
17		1.8747	1.9662	1.6842	.0762	.1463	.0754
18	.1494	1.4998	1.6907		.0762	.1509	.1509
19	.2987	.2263	.2614	.3018	.2263	.3018	.2987
20	.3048	.3772	.3772	.3772	.3772	.3772	.3361
21	.3048	.3018	.3361	.3395	.3018	.3018	.3361
22	.2263	.2263	.2263	.2667	.2263	.2263	.2614
23	.1509	.2263	.2263	.1886	.1509	.2263	.1886
24	.7125	.1509	.2263	.2263	.1886	.1509	.1509
Max	2.0081	2.2024	2.1216	1.9662	1.2597	2.5339	1.989
Min	.0754	.1494	.1509	.1886	.0739	.0754	.0754
Avg	.6335	.7922	.8143	.7306	.4640	.7090	.6149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 302 / 22 KV BHANDAWALI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.2835	.4115	.5144	.1372	.1509	.2241
2	.1372	.2652	.4207	.4557	.1387	.2218	.2218
3	.1402	.2622	.4508	.4207	.1448	.2241	.2241
4	.1715	.2622	.4801	.4458	.2195	.2103	.2241
5	.2561	.2743	.6173	.5087	.2987	.2103	.2195
6	.3326	.5068	.9015	.6962	.4108	.2957	.3734
7	.4904	.6584	1.4586	1.4091	.4527	.4527	.5281
8	.3772	.5967	1.7635	1.6907	.3429	.3772	.3734
9	.2241	.5365	1.3763	1.5074	.2641	.1463	.2987
10	.3734	.4268	1.1523	1.0608	.1478	.2241	.1829
11	1.166	.2263	.2195	.2195	1.3923	1.3108	1.2955
12	1.3108	.2263	.2241	.1417	1.8351	1.6575	1.5249
13	1.1523	.2263	.1509	.1433	1.8351	1.5729	1.4091
14	1.5546	.2195	.1886	.1867	1.5729	1.4586	1.326
15	1.4251	.2241	.1509	.1848	1.5546	1.3763	1.278
16	1.5729	.2241	.2241	.1478	1.6385	1.4419	1.2803
17		.2263	.2195	.2263	1.6004	1.5249	1.3108
18	1.3916	.3018	.1509	.3048	1.2651	1.1873	1.3592
19	.381	.3772	.3772	.381	.3018	.3772	.3361
20	.4527	.3018	.3772	.3772	.4527	.3772	.3361
21	.3772	.3018	.3361	.3772	.2987	.3734	
22	.2241	.3018	.2614	.2561	.2957	.3018	.2926
23	.2195	.2263	.2263	.2263	.2926	.2241	.1886
24	.1341	.2195	.1463	.1886	.181	.2172	.2195
Max	1.5729	.6584	1.7635	1.6907	1.8351	1.6575	1.5249
Min	.1341	.2195	.1463	.1417	.1372	.1463	.1829
Avg	.6087	.3198	.5119	.5030	.7114	.6631	.6533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 303 / 22 KV MALAWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1494	.1132	.1132	.1132	.0754	.1132
2	.1086	.1132	.112	.1132	.1132	.0754	.112
3	.1052	.1132	.1109	.112	.112	.0754	.112
4	.1075	.1132	.112	.112	.112	.112	.1132
5	.1097	.1097	.1478	.112	.1886	.1086	.1494
6	.1478	.1494	.1886	.1886	.2286	.1905	.1886
7	.2263	.1494	.2263	.2263	.2263	.1886	.2263
8	.2218	.2241	.1886	.1886	.1867	.1524	.1509
9	.1463	.1509	.2263	.2263	.1829	.1478	.1509
10	.1372	.1086	.1509	.1132	.112	.1494	.1463
11	.1143	.1494	.1886	.1132	.1132	.1848	.112
12	.1478	.1509	.1509	.1132	.1829	.1509	.1494
13	.0762	.2241	.1132	.1132	.1829	.2241	.1109
14	.1478	.1478	.1494	.1132	.0747	.1886	.1463
15	.1848	.1494	.1494	.1132	.0732	.1867	.1886
16	.112	.1509	.1109	.1132	.0686	.1478	.1886
17		.112	.112	.1886	.181	.1494	.1109
18	.1494	.1494	.1886	.2103	.1772	.2263	.1494
19	.1886	.2263	.1886	.2218	.2561	.1867	.2263
20	.1509	.1886	.1886	.2241	.1524	.2263	.2218
21	.1509	.1886	.1886	.3772	.1509	.2263	.1886
22	.1132	.1886	.1494	.1524	.1494	.1509	.1494
23	.1132	.1494	.1109		.112	.1509	.1109
24	.112	.0754	.1478	.1109	.1132	.0739	.1509
Max	.2263	.2263	.2263	.3772	.2561	.2263	.2263
Min	.0762	.0754	.1109	.1109	.0686	.0739	.1109
Avg	.1383	.1513	.1547	.1596	.1485	.1562	.1528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 304 / 22 KV KULAKJAI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1132	.0747	.0747	.0732	.0754	.0732
2	.0747	.112	.0732	.0754	.0732	.0739	.0739
3	.0747	.0754	.0739	.0754	.0732	.0754	.0732
4	.0747	.0754	.0732	.112	.0724	.1132	.0739
5	.0747	.0754	.1463	.1109	.0747	.1132	.1097
6	.1509	.1848	.1867	.1886	.1886	.1886	.1867
7	.4526	.1886	.2195	.2263	.2263	.1867	.1848
8	.1509	.1132	.1478	.1494	.1886	.1509	.1494
9	.0754	.0754	.112	.1109	.1494	.1132	.1829
10	.1509	.112	.1097	.0747	.2263	.112	.1097
11	.0747	.1478	.112	.0709	.0754	.1463	.1109
12	.1132	.1097	.1097	.0732	.1132	.1478	.1109
13	.0754	.1109	.0747	.0732	.1494	.112	.0747
14	.0754	.1463	.0754	.0732	.0754	.1829	.0732
15		.1478	.0754	.0732	.112	.1478	.0747
16	.0754	.1097	.0747	.0732	.1509	.1097	.0747
17		.1109	.0754	.0732	.1509	.1494	.0747
18	.0754	.112	.0754	.112	.1478	.1478	.1109
19	.1509	.1829	.1463	.1494	.1886	.1478	.1886
20	.1848	.2218	.1886	.1867	.1886	.1829	.2241
21	.1509	.1829	.1509	.1494	.1509	.1494	.1886
22	.0754	.1494	.1494	.112	.0754	.1478	.1494
23	.0747	.1478	.1109	.0732	.1132	.1109	.1109
24	.0732	.0754	.1097	.0747	.0732	.0739	.112
Max	.4526	.2218	.2195	.2263	.2263	.1886	.2241
Min	.0732	.0754	.0732	.0709	.0724	.0739	.0732
Avg	.1160	.1284	.1144	.1069	.1296	.1316	.1207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 305 / 22 KV BIDAL (Andhali) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.5898	.7209	.9945	.0732	.0754	.0747
2	.0724	.5898	.7625	1.0608	.0747	.0754	.0747
3	.0724	.5967	.7712	1.0486	.0739	.0739	.0739
4	.1109	.6226	.8619	1.0814	.112	.112	.0747
5	.1494	.6226	.9614	1.1142	.1509	.1509	.1509
6	.1886	.6962	1.0486	1.3108	.1886	.1886	.2241
7	.2641	.7865	1.326	1.3763	.2263	.2241	.2241
8	.1886	.9503	1.3435	1.3435	.1494	.1509	.1478
9	.112	1.1469	1.1271	1.326	.112	.1132	.112
10	.0754	1.1142	1.2125	1.2742	.0754	.1132	.0747
11	1.3763	.1132	.0747		1.4091	1.5424	1.4091
12	1.5912	.1132	.0747		1.2929	1.7695	1.326
13	1.6057	.1132	.0754	.0732	1.2452	1.7901	1.4403
14	1.6385	.1132			1.5729	1.6712	1.5912
15	1.6907	.1132	.0754			1.8896	1.6964
16	1.3763	.112				1.5402	1.6057
17		.1109	.0754	.112	1.2125	1.8107	1.8564
18	1.1797	.1132	.1132	.112	1.278	1.6244	1.7238
19	.1132	.1509	.1132	.1132	.1509	.0754	.1132
20	.1132	.1509	.1509	.1509	.1509	.1132	.1132
21	.0754	.1132	.1509	.112	.1509	.1132	.1509
22	.0732	.1132	.1132	.0732	.112		.1132
23	.0754	.1132	.1132	.0732	.1132	.1132	.1132
24	3.0567	.0754	.0747	.0754	.0732	.1132	.1132
Max	3.0567	1.1469	1.3435	1.3763	1.5729	1.8896	1.8564
Min	.0724	.0754	.0747	.0732	.0732	.0739	.0739
Avg	.6640	.3889	.5155	.6750	.4545	.6715	.6082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 306 / 22 KV TONDALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 201 / 11 KV PALASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.4801	.6802	.6802	.3582	.3658	
2	.2926	.4801	.7125	.7125	.3582	.3658	
3	.2926	.5441	.7449	.7537	.3582	.3658	
4	.3292	.6722	.8097	.8848	.3982	.439	
5	.4572	.7682	1.004	1.1437	.5068	.5121	
6	.6447	.8642	1.3603	1.1934	.7164	.7023	
7	.788	.9717	1.8842	1.5364	.7602	.6653	
8	.6556	.9393	1.9006	2.0165	.6268	.6283	
9	.4961	.9069	1.5546	1.6842	.3898	.4024	
10	.298	.8097	1.1603	1.2631	.2149	.1433	
11	1.4918	.2896	.1791		1.2597	1.0883	
12	1.704	.2865	.1791	.2103	1.7368	1.2483	1.4723
13	1.5546		.181	.1928	1.7368	1.4083	1.5074
14	1.5546	.1772	.3258	.208	1.4899	1.3927	1.4419
15	1.587	.2126	.181	.1402	1.3603	1.2631	1.2452
16	1.587	.1772	.1829	.1928	1.4251	1.1469	1.3763
17	1.4575	.2481	.2195	.2481	1.1984	1.1469	1.2125
18	1.0883	.2835	.2561	.2865	1.1336	.8288	.9922
19	.5544	.567	.4805	.5194	.5914	.394	.4207
20	.5175	.5544	.5175	.5731	.6283	.5068	.4961
21	.439	.4755	.4298	.4835	.5121	.439	.4298
22	.4024	.3658	.5014	.3582	.439	.4024	.3582
23	.3658	.3658	.3258	.362	.4024	.3658	.3224
24	.3077	.3292	.3658	.3258	.3582	.4024	
Max	1.704	.9717	1.9006	2.0165	1.7368	1.4083	1.5074
Min	.2926	.1772	.1791	.1402	.2149	.1433	.3224
Avg	.7990	.5117	.6724	.6943	.7900	.6927	.9396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 202 / 11 KV DHAMANI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.3258	.2896	.3475	.6001	.7042	
2	.852	.2896	.2896	.4024	.6173	.7362	
3	.8848	.2896	.3258	.499	.6173	.7682	
4	.9012	.3258	.3258	.5548	.6687	.8745	
5	1.0159	.4755	.5121	.6447	.7716	.9717	
6	1.2125	.6283	.6283	.6447	.9614	1.2631	
7	1.8945	.7468	.7023	.6805	1.0774	1.8023	
8	2.0454	.5914	.5175	.5068	1.1437	1.8023	
9	1.861	.439	.4755	.362	1.0442	1.8023	
10	1.4586	.439	.4706	.362	.9779	1.2631	
11	.2804	1.7695	1.8564		.2454	.2507	
12	.3658	1.7368	2.1125	1.9113	.2507	.2507	.2896
13	.3258		2.1052	1.7736	.2507	.2507	.2896
14	.3258	2.0645	2.1052	1.7436	.2507	.2896	.3258
15	.3658	1.8679	2.0081	1.8233	.2507	.3258	.3258
16	.4024	2.2542	2.0972	1.7772	.2865	.2926	.4024
17	.439	1.9334	1.9662	1.7939	.3258	.4024	.4024
18	.4024	1.6876	1.6244	1.0277	.4024	.4435	.439
19	.5544	.5544	.5014	.5194		.6283	.5914
20	.5914	.7207	.5373	.543	.6283	.5373	.5121
21	.4805	.4024	.4706	.4835	.5544	.4656	.439
22	.4024	.4024	.3982	.3506	.439	.3982	.4024
23	.3658	.3258	.3292	.3582	.4024	.362	.3658
24	.7373	.3658	.3258	.3292	.362	.3658	.3292
Max	2.0454	2.2542	2.1125	1.9113	1.1437	1.8023	.5914
Min	.2804	.2896	.2896	.3292	.2454	.2507	.2896
Avg	.7910	.8972	.9573	.8452	.5708	.7188	.3934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 203 / 11 KV GONDAWALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2507	.2149		.3511	.6283	
2	.2801	.2507	.1791		.3361	.5544	
3	.2987	.2507	.2149		.3361	.5304	
4	.3361	.2865	.2865		.3511	.5304	
5	.4481	.439	.2591		.4938	.5359	
6	.6535	.5914	.362		.7059	.7282	
7	.724	.7655	.3658		.7783	.7468	
8	.5731	.6838	.3258		.6447	.6099	
9	.5373	.5914	.2896		.4835	.6099	
10	.443	.5121	.4805		.3898	.4207	
11	.2804	.439	.3696		.3439	.4207	
12	.3658	.4024	.2772	.3403	.3439	.2743	.3258
13	.3439		.2614	.2804	.3258	.2926	.2507
14	.3258	.3077	.2801	.3012	.2896	.3326	.2865
15	.3658	.2353	.3547	.2328	.3077	.3326	.2686
16	.3658	.2534	.2686	.2629	.2507	.2772	.2507
17	.3841	.3077	.2896	.3189	.3258	.3142	.3658
18	.439	.3439	.3258	.4119	.4572	.4108	.5304
19	.5914	.7023	.543	.7059	.6653	.5975	.6283
20	.6653	.7282	.724	.7316	.7655	.6516	.7842
21	.5544	.5544	.5304	.6219	.6535	.5249	.5914
22	.4755	.4572	.4938	.4572	.4938	.4755	.5359
23	.3439	.3658	.4066	.3841	.5544	.4938	.439
24	.2987	.2896	.2149	.3696	.3696	.6653	.3326
Max	.724	.7655	.724	.7316	.7783	.7468	.7842
Min	.2801	.2353	.1791	.2328	.2507	.2743	.2507
Avg	.4322	.4352	.3466	.4168	.4590	.4983	.4300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 204 / 11 kv Mhaswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.192	.4744	.7125	.9995	.1097	
2	.128	.1875	.5218	.7125	1.0277	.0724	
3	.128	.1875	.5376	.8029	.9945	.0724	
4	.1463	.25	.6081	.8848	.1267	.1097	
5	.1646	.3841	.7209	1.1271	.1433	.1478	
6	.2149	.4161	.9069	1.1603	.1433	.1867	
7	.1772	.5121	1.1012	1.1523	.1612	.1867	
8	.1772	.6802	1.166	1.2163	.1402	.1478	
9	.1595	.6478	1.1012	1.1012	.1227	.1097	
10	.1052	.5761	.7956	.8421	.1063	.0716	
11	1.0814	.1097	.0716		1.0814	1.0242	
12	1.166	.1097	.0716	.1052	1.5074	1.3923	1.1523
13	1.4419				1.6575	1.5364	1.0059
14	1.4419	.0724	.0724	.1086	1.4586	1.4251	.852
15	1.3108	.0724	.0732	.1417	1.3108	1.2308	.8848
16	1.1142	.0716	.0732	.1063	1.0364	1.2452	.9175
17	.7125	.0716	.1463	.0886	1.0364	1.1142	.7865
18	.7773	.1478	.1478	.1075	.8962	.9282	.6299
19	.1478	.1478	.1478	1.8778	.2241	.1433	.1402
20	.2241	.2241	.2241	1.8778	.2241	.1075	.1772
21	.2241	.2241	.2149	1.8442	.2241	.2149	.1772
22	.1478	.1478	.1448	.1433	.1867	.1448	.1791
23	.1478	.1478	.1448	.1433	.1478		.1612
24	.1463	.1478	.1478	.3258	1.0486	.1478	.1463
Max	1.4419	.6802	1.166	1.8778	1.6575	1.5364	1.1523
Min	.1052	.0716	.0716	.0886	.1063	.0716	.1402
Avg	.4846	.2490	.418	.7537	.6669	.5161	.5546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 205 / 11 KV Gondawale Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.1791		.2172	.7202	.6081	
2	.6882	.1433		.2896	.7202	.6081	
3	.6882	.1433		.3292	.703	.6722	
4	.7537	.1791		.4024	.703	.7682	
5	.852	.2149		.4024	.7888	.8642	
6	1.0159	.2507		.3881	.8288	1.1336	
7	1.576	.2896		.394	.9614	1.6385	
8	1.8442	.3258		.3582	1.0442	1.8023	
9	1.5424	.3258		.2896	1.0277	1.6385	
10	1.21	.2896	.2507	.2172	.9945	1.3279	
11	.4024	.2507	1.5364		.1402	.1791	
12	.1433	1.5546	1.8244	1.8442	.1433	.2149	.1791
13	.1433	1.7166	1.8461	1.8945	.1433	.1433	.1417
14	.1791	1.6356	1.9433	1.9448	.1791	.1417	.1595
15	.2507	1.6964	1.8679	1.8107	.1791	.2507	.1772
16	.2896	1.9845	1.8679	1.7436	.1791	.1791	.1772
17	.2896	1.6964	1.7238	1.7604	.2149	.4024	.2126
18	.2896	1.2803	1.4586	1.1768	.2507	.2896	.2481
19	.4024	.3856	.2865	.3012	.3658	.2896	.3224
20	.3658	.3898	.3224	.3224	.3258	.3258	.2865
21	.2896	.3189	.2507	.3045	.2507	.2507	.2534
22	.2149	.2126	.2534	.1791	.2507	.2149	.2149
23	.1791	.2263	.2172	.181	.2149	.1791	.2149
24	.6226	.2149		.2172	.181	.2149	
Max	1.8442	1.9845	1.9433	1.9448	1.0442	1.8023	.3224
Min	.1433	.1433	.2172	.1791	.1402	.1417	.1417
Avg	.6203	.6627	1.1178	.7378	.4796	.5974	.2156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 201 / 11 KV PINGALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1296	.181	.1791	.1578
2			.1296	.1848	.1848	.1578
3			.1296	.1848	.1829	.1578
4			.1296	.2012	.2054	.1578
5			.1296	.2218	.2402	.1526
6			.1943	.3544	.362	.2035
7			.3277	.5975	.5601	.2543
8			.3605	.5359	.4572	.2543
9			.2458	.3801	.3801	.2374
10		.2103	.2155	.2804	.3121	.2035
11		.1928	.1658	.2454	.2481	
12		.1715	.1372	.2481		
13		.1715	.1734	.2149	.2126	
14		.1715	.1734	.2279	.2103	
15		.1715	.1715	.2294	.2279	
16		.1886	.1387	.2429	.2454	
17		.2229	.1966	.2294	.2804	
18		.2229	.2683	.2778	.298	
19		.3121	.4557	.4557	.3506	
20		.3121	.4656	.4835	.3506	
21		.2774	.439	.4119	.3155	
22		.1829	.3511	.3366	.2454	
23		.1524	.2353	.2454	.1928	
24	.1052		.1311	.1991	.2172	.1578
Max	.1052	.3121	.4656	.5975	.5601	.2543
Min	.1052	.1524	.1296	.181	.1791	.1526
Avg	.1052	.2115	.2289	.2987	.2808	.1904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 202 / 11 KV KIRAKSAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6173	.7287	.1417	.1509
2			.6173	.7202	.1463	.1509
3			.6173	.7407	.1463	.1509
4			.631	.7716	.1433	.1509
5			.7888	.8749	.1991	.2058
6			1.262	1.078	.2835	.2401
7			1.5775	1.5546	.3584	.2058
8			2.1033	1.8679	.2378	.1543
9			2.2436	1.5741	.1612	.1715
10		.6802	1.7177	1.3757	.144	.1715
11		.0983	.1052	.1214	1.6057	
12		.0983	.1006	.104	1.9334	
13		.0983	.1006	.1372	2.0645	
14		.0983	.1187	.1341	1.9989	
15		.0983	.116	.1372	1.9204	
16		.1147	.1326	.1219	1.9204	
17		.1475	.1341	.1204	1.9845	
18		.1475	.1147	.1372	1.5524	
19		.213	.1696	.1865	.1844	
20		.1638	.2229	.2279	.1844	
21		.1638	.2303	.2507	.1844	
22		.1677	.197	.1772	.1844	
23		.1341	.1448	.1387	.1844	
24	.1357		.1341	.1372	.1372	.1509
Max	.1357	.6802	2.2436	1.8679	2.0645	.2401
Min	.1357	.0983	.1006	.104	.1372	.1509
Avg	.1357	.1731	.5915	.5591	.7500	.1730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 203 / 11 KV PINGALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0152	.0189	.048	.0671
2			.0152	.0189	.0492	.0671
3			.0152	.0189	.0503	.0671
4			.0152	.0189	.0497	.0838
5			.0152	.0189	.0486	.1006
6			.0152	.0377	.064	.1006
7			.0152	.0377	.0829	.3353
8			.0152	.0189	.1781	.3772
9			.0156	.0189	.208	.2915
10		.0189	.0156	.0189	.2056	.2915
11		.2561	.3149	.2915	.0189	
12		.3658	.421	.3841	.0189	
13		.439	.4321	.3521	.0189	
14		.5121	.3841	.3321	.0179	
15		.4755	.4534	.2688	.0179	
16		.4572	.3887	.2241	.0179	
17		.5121	.426	.2846	.0179	
18		.3841	.3725	.2743	.0179	
19			.0377	.0377	.0179	
20			.0377	.0377	.0179	
21			.0189	.0189	.0179	
22			.0189	.0189	.0179	
23			.0189	.0189	.0179	
24	.1132			.0189	.0189	.0179
Max	.1132	.5121	.4534	.3841	.208	.3772
Min	.1132	.0189	.0152	.0189	.0179	.0179
Avg	.1132	.3801	.1512	.1162	.0516	.1636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 401 / 33 KV MANDESHI SOOT GIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054		.679	.9054	.9054	.8488
2			.7356	.8488	.8488	.9054
3			.7356	.8488	.8488	.8488
4			.7922	.9054	.9054	.8488
5			.8488	.9619	.9054	.9054
6			.9054	1.0185	.9619	.8488
7			.9054	.9619	.9619	.9054
8			.9619	1.0185	1.0751	.9054
9			1.0185	.8488	.9054	.7356
10		.7356	.7922	.8488	.7922	.7356
11		.7922	.9054	.8488	1.1317	
12		.7922	.7922	.9619	.9054	
13		.8488	.9054	.9619	.9619	
14		.8488	.7356	.9054	.9619	
15		.8488	.6224	.9054	.9054	
16		.8488	.9054	.9054	.9054	
17		.7922	.8488	.8488	.9054	
18		.8488	.9619	.7922	.8488	
19		.5658	.7356	.9054	.7922	
20		.7922	.7922	.9054	.8488	
21		.7922	.679		.8488	
22		.7922	.9054	.9054	.9054	
23		.679	.9054	.8488	.8488	
24	.9054		.679	.8488		.9619
Max	.9054	.8488	1.0185	1.0185	1.1317	.9619
Min	.9054	.5658	.6224	.7922	.7922	.7356
Avg	.9054	.7841	.8228	.9005	.9078	.8591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254075 / 33/11 KV RANJANI

Feeder No / Name : 201 / 11 kv Waki Varkute Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.1189	.1677	.0189	.0377	.0377
2	.0189	.1696	.1526	.2187	.0373	.0377	.0377
3	.0189	.1486	.1581	.2743	.0189	.0377	.0566
4	.0377	.1781	.1656	.3437	.0373	.0566	.0566
5	.0377	.1875	.253	.3953	.0566	.0754	.0754
6	.1132	.1943	.4049	.4161	.0747	.1132	.0943
7	.132	.2683	.6562	.7127	.112	.0943	.1132
8	.1132	.2753	.8162	.788	.0943	.0943	.0943
9	.0754	.2429	.6642	.7209	.0377	.0747	.0754
10	.0754	.208	.0358	.583	.0549	.056	.0732
11	.5921	.0566	.0187		.5937	.6325	.5944
12	.8356	.0566		.0566	.8697	.8907	.7682
13	.7773	.0358		.0377	.9555	.8223	.852
14	.7287	.0377		.0566	.8802	.7522	.7773
15	.7935	.0358	.0187	.0377	.7274	.68	.663
16	.7125	.056	.0554	.1267	.7202	.68	.6706
17	.7274	.0514	.056	.0377	.6958	.6173	.5967
18	.5281	.0895	.0566	.0895	.4586	.6009	.4816
19	.0366	.0716	.0934	.1097	.0747	.0886	.1052
20	.0739	.056	.0943	.1448	.0943	.0747	.0905
21	.056	.0537	.0747	.1463	.0754	.0934	.0934
22	.0377	.0187	.0566	.0373	.0566	.056	.0566
23	.0189	.0187	.0377	.0189	.0377	.0566	.0373
24	.0189		.0617	.0377	.0187	.0377	.0377
Max	.8356	.2753	.8162	.788	.9555	.8907	.852
Min	.0189	.0187	.0187	.0189	.0187	.0377	.0373
Avg	.2852	.1165	.1928	.2416	.2834	.2817	.2725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254075 / 33/11 KV RANJANI

Feeder No / Name : 202 / 11 KV Waki Varkute Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0747	.0747	.0934	.0943	.0934	.0943
2	.0754	.0943	.0848	.0943	.0747	.112	.0943
3	.0747	.0754	.0934	.0934	.0934	.1109	.1132
4	.0943	.112	.0943	.1132	.132	.1109	.1132
5	.132	.1509	.132	.0754	.0754	.132	.132
6	.2263	.2241	.1886	.2054	.2054	.2075	.1698
7	.2801	.2452	.2427	.2801	.2452	.1663	.2075
8	.2218	.2218	.2033	.2054	.1848	.1663	.1848
9	.1448	.1463	.1086	.1478	.128	.1448	.1463
10	.1063	.1086	.0716	.1097	.0867	.0914	.0686
11	.0895	.1075	.0709		.0663	.0678	.0602
12	.0701	.1075		.0709	.0335	.0693	.0312
13	.0532	.0716		.0857	.0526	.0693	.0663
14	.0543	.0716		.0693	.0354	.0537	.0503
15	.0724	.0686	.0678	.052	.0503	.0701	.0514
16	.0895	.0895	.0701	.0663	.052	.0526	.0526
17	.0905	.0671	.0886	.081	.0633	.0819	.0895
18	.1063	.0886	.1075	.0655	.0867	.0693	.0857
19	.1629	.1417	.1612	.1646	.1478	.1646	.1463
20	.1663	.1663	.197	.181	.1663	.2012	.1578
21	.168	.1663	.0747	.168	.1463	.168	.1829
22	.1307	.132	.1494	.0934	.1307	.132	.1663
23	.0934	.0934	.112	.112	.112	.112	.1463
24	.0934	.0747	.0747	.0934	.0747	.0934	.0934
Max	.2801	.2452	.2427	.2801	.2452	.2075	.2075
Min	.0532	.0671	.0678	.052	.0335	.0526	.0312
Avg	.1204	.1208	.1175	.1183	.1057	.1142	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254075 / 33/11 KV RANJANI

Feeder No / Name : 203 / 11 KV Ranjani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2641	.2829	.2829	.3189	.5426	.4862
2	.5487	.2452	.3174	.3361	.333	.6036	.5197
3	.6344	.2641	.3222	.3772	.3506	.6718	.5967
4	.6935	.3206	.3772	.5281	.2641	.788	.6706
5	.9774	.4527	.5093	.6036	.5249	.9496	.7969
6		.7545	.679	.679	.8865	1.283	1.358
7	1.7101	.811	.8676	.8676	1.1517	1.6461	1.7857
8	1.8564	.5975	.6224	.7095	1.0513	1.9204	1.869
9	1.4413	.4854	.4338	.5359	.9054	1.56	1.543
10	1.0227	.3881	.2957	.4108	.7537	.9724	.2075
11	.2241	1.2597	.7042		.2075	.2054	.1219
12	.2075	1.7436		1.7939	.1698	.1867	.1187
13	.1886	.9995		2.0119	.168	.1478	.168
14	.2402	1.9113		1.6876	.1886	.1698	.1307
15	.2427	1.8067	1.4752	1.5746	.1886	.168	.1307
16	.2801	1.8442	2.3137	1.5893	.2402	.2054	.1848
17	.3206	1.4419	2.0517	1.5402	.2218	.2587	.2427
18	.3772	1.0442	1.7147	.5801	.3326	.3734	.3326
19	.4668	.4854	.5415	.5601	.5788	.5788	.5601
20	.4904	.5847	.6602	.6348	.6036	.6348	.5975
21	.3772	.4527	.5093	.4904	.4904	.5093	.4715
22	.3206	.3772	.3395	.3206	.3772	.3584	.3772
23	.2829	.2829	.2987	.2641	.3018	.2829	.3361
24	.4801	.2452	.2641	.2829	.3189	.2829	.2829
Max	1.8564	1.9113	2.3137	2.0119	1.1517	1.9204	1.869
Min	.1886	.2452	.2641	.2641	.168	.1478	.1187
Avg	.6043	.7943	.7419	.8114	.4553	.6375	.5787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254075 / 33/11 KV RANJANI

Feeder No / Name : 204 / 11 KV MARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0762	.1355	.0914	.0366	.0543	.0549
2	.0543	.0781	.1134	.125	.0747	.0543	.0549
3	.0537	.0686	.1357	.1372	.0543	.052	.0732
4	.0739	.0762	.1174	.1406	.0754	.0732	.0739
5	.0754	.0983	.144	.1875	.0739	.0739	.0934
6	.112	.1372	.2321	.208	.1132	.132	.1307
7	.1494	.1619	.3281	.3401	.1494	.1097	.1494
8	.1097	.1265	.3725	.3521	.1097	.1097	.0914
9	.0709	.0972	.2656	.2469	.0701	.056	.0693
10	.048	.0705	.0532	.1718	.0446	.0162	.0503
11	.1875	.0324	.0332		.1614	.1128	.1276
12	.25	.0514		.0351	.2378	.1932	.1509
13	.3321	.0332		.0316	.2968	.2054	.2134
14	.3163	.0328		.0497	.2932	.2258	.2006
15	.3125	.0286	.0312	.0305	.2591	.2107	.1989
16	.2812	.0514	.0328	.0278	.25	.2408	.2058
17	.2143	.0469	.0497	.0469	.1715	.1858	.208
18	.1423	.0709	.0671	.0678	.1505	.1467	.1132
19	.0905	.1063	.1097	.0895	.1109	.1097	.0829
20	.0914	.0895	.0914	.0543	.1097	.0895	.0857
21	.0701		.0732	.0895	.0905	.0905	.0895
22	.0537	.0543	.0724	.0693	.0914	.0732	.0732
23	.0543	.0554	.0549	.0549	.0549	.1109	.0549
24	.0543	.0532	.0781	.0549	.0366	.0554	.0554
Max	.3321	.1619	.3725	.3521	.2968	.2408	.2134
Min	.048	.0286	.0312	.0278	.0366	.0162	.0503
Avg	.1355	.0738	.1234	.1175	.1298	.1159	.1126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254083 / 33/11 KV BIJAWADI

Feeder No / Name : 201 / 11KV PACHWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.5487
Max	.5487
Min	.5487
Avg	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254083 / 33/11 KV BIJAWADI

Feeder No / Name : 202 / 11KV RAJAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.8402
Max	.8402
Min	.8402
Avg	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254083 / 33/11 KV BIJAWADI

Feeder No / Name : 203 / 11KV HATANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 301 / 22 KV DAHIWADI

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.2291
Max	2.2291
Min	2.2291
Avg	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 302 / 22 KV BIDAL AG (DAHIWADI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
23	3.2922
Max	3.2922
Min	3.2922
Avg	3.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 304 / 22 KV MOGARALE AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.9835
Max	2.9835
Min	2.9835
Avg	2.9835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 305 / 22 KV DEVAPUR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.9835
Max	2.9835
Min	2.9835
Avg	2.9835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 306 / 22 KV MHASWAD

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.6216
Max	2.6216
Min	2.6216
Avg	2.6216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 201 / 11 KV LALGUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.6104	.7545	.6321	.0351	.0366	.0762
2	.0366	.6036	.7377	.6241	.0343	.037	.0762
3	.0351	.5735	.7377	.6241	.0351	.0366	.0762
4	.0343	.5735	.7377	.639	.0358	.0366	.0762
5	.0351	.5735	.7377	.6622	.0366	.037	.0762
6	.0358	.583	1.1736	.8482	.0351	.0366	.1143
7	.0366	.7045	1.358	1.0957	.0358	.0514	.0754
8	.0373	.9503	1.6975	1.4352	.0366	.0377	.0754
9	.0366	1.0159	1.5432	1.5384	.0373	.0377	.0762
10	.0373	1.0814	1.6461	1.4091	.0366	.1132	.0373
11	1.7368	.0335	.0754	.0335	1.3599	1.4883	1.5203
12	1.9826	.0339	.0754	.0343	1.5971	1.3765	1.5074
13	2.0645	.0343	.0754	.0351	1.7966	1.5023	1.576
14	1.8138	.0343	.0754	.0358	1.704	1.5023	1.4582
15	1.7072	.0366	.0754	.0366	1.5565	1.439	1.4922
16	1.7204	.0366	.0754	.0373	1.6712	1.4723	1.4255
17	1.5546	.0366	.0754	.0351	1.5708	1.3735	1.291
18	1.3603	.0366	.0747	.0358	1.3927	.945	1.0883
19	.0366	.0366	.0754	.0366	.0377	.1132	.0328
20	.0549	.0366	.1132	.0373	.037	.0754	.0335
21	.0549	.0366	.0754	.0366	.0366	.1132	.0343
22	.0366	.0366	.0762	.0351	.0366	.0762	.0335
23	.0366	.0366	.0762	.0351	.0366	.0762	.0343
24	.0351	.037	.0366	.0762	.0358	.0362	.0762
Max	2.0645	1.0814	1.6975	1.5384	1.7966	1.5023	1.576
Min	.0343	.0335	.0366	.0335	.0343	.0362	.0328
Avg	.6065	.3238	.5075	.4187	.5511	.5021	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 202 / 11 KV MANJARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2378	.2195	.2641	.1829	.2195	.2452
2	.1829	.2218	.2686	.2452	.1791	.2033	.2452
3	.1753	.2012	.2686	.2263	.1753	.1829	.2263
4	.1715	.2195	.4287	.2218	.197	.2033	.2263
5	.2279	.2926	.5144	.2829	.2561	.2218	.3018
6	.4477	.4572	.5487	.4568	.4854	.5304	.547
7	.6401	.6348	.5144	.5729	.679	.5601	.6224
8	.5975	.5853	.4973	.5792	.5121	.5847	.5175
9	.5281	.4207	.4287	.4572	.4854	.4207	.4338
10	.4435	.3292	.3944	.5041	.3841	.3475	.3856
11	.3841	.3582	.3561	.4572	.3475	.2543	.2772
12	.3475	.3506	.3294	.3174	.2012	.2172	.2614
13	.2926	.2572	.3121	.3109	.2743	.2686	.2829
14	.3475	.2926	.3155	.3361	.2317	.2686	.2743
15	.3326	.3658	.3121	.3475	.2926	.2454	.2801
16	.3109	.3601	.3544	.3361	.3475	.3045	.298
17	.4207	.3944	.39	.4108	.3475	.3052	.3475
18	.4207	.4287	.4191	.4572	.3841	.3475	.4108
19	.5853	.5121	.5601	.5601	.6036	.5729	.6036
20	.6036	.5487	.6908	.6722	.6219	.6838	.5784
21	.5853	.5487	.6584	.4755	.6036	.6283	.6089
22	.439	.4572	.4904	.3582	.4572	.462	.4557
23	.3109	.2743	.3395	.2561	.2561	.3018	.3224
24	.2012	.2561	.2195	.2572	.2241	.2195	.2587
Max	.6401	.6348	.6908	.6722	.679	.6838	.6224
Min	.1715	.2012	.2195	.2218	.1753	.1829	.2263
Avg	.3834	.3752	.4096	.3901	.3637	.3564	.3755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 204 / 11 kv Mol Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.0526	.0514	.0526	.2294	.2715	.2086
2	.2401	.0526	.0514	.0526	.2241	.2606	.2195
3	.2458	.052	.0514	.0514	.2241	.2606	.2225
4	.2683	.0693	.0514	.0514	.2458	.2679	.2256
5	.2785	.0876	.0686	.0514	.2515	.2921	.2462
6	.3772	.0876	.0686	.0732	.2743	.4481	.3963
7	.7045	.1029	.0686	.1097	.4096	.9175	.7186
8	1.0227	.1029	.0686	.1052	.4527	.9842	.9962
9	.852	.0514	.0686	.0924	.5144	.8905	.9282
10	.0671	.0503	.6093	.0983	.4096	.6859	.7449
11	.0663	.8139	.6093	.8802	.0328		.0554
12	.0686	1.3717	.8768		.0332	.0526	.056
13	.0857	1.3969	.8509	1.0159	.0514	.0549	.0549
14	.0762	1.379	.9998	1.0059	.0509	.0876	.056
15	.0762	1.2536	1.0883	.9339	.0732	.0709	.0732
16	.0762	1.286	1.166	1.0898	.0655	.0537	.0934
17	.0857	1.166	.9962	.9175	.0848	.064	.0914
18	.0876	1.166	.6249	.7377	.0857	.0895	.0934
19	.0905	.0549	.0701	.0686	.0848	.0914	.0914
20	.0886	.0549	.1052	.0876	.1029	.0895	.0895
21	.0876	.0549	.0693	.0716	.1029	.0701	.0526
22	.0716	.0549	.0716	.0732	.0701	.0732	.0526
23	.0686	.0549	.0693	.0549	.0686	.0943	.0537
24	.2561	.0532	.0549	.0509	.056	.0514	.0532
Max	1.0227	1.3969	1.166	1.0898	.5144	.9842	.9962
Min	.0663	.0503	.0514	.0509	.0328	.0514	.0526
Avg	.2335	.4529	.3671	.3359	.1749	.2705	.2447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 205 / 11 KV BUDH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.0819	.0366	.0564	.1638	.2774	.2804
2	.2915	.0838	.0358	.0549	.16	.2743	.2804
3	.2683	.0829	.0358	.0556	.1638	.2543	.2601
4	.2881	.0838	.0358	.0488	.176	.2343	.2629
5	.3277	.0914	.0351	.0648	.1966	.2622	.2947
6	.3856	.1029	.0343	.0762	.218	.373	.3155
7	.7373	.1187	.0351	.1006	.3441	.7461	.5801
8	1.0562	.0983	.0343	.0995	.4191	.4862	.7935
9	.8059	.1017	.0343	.1017	.4096	.5426	.7537
10	.0876	.1017	.0343	.0983	.3856	.4527	.5967
11	.0857	.1029	.5967	.6874	.1097	.1052	.061
12			.8619	.8848	.0857	.1006	.0686
13		.7716	.3052	.9221	.0995	.0791	.0876
14		.823	.8802	1.0974	.1147	.1006	.0716
15			.9555	.852	.0848	.0762	.112
16	.061	.5144	.9503	.8718	.096	.08	.0732
17		.7716	.7611	.7701	.096	.0791	.0747
18	.1254	.7716	.6964	.6203	.0983	.0457	.0943
19	.0983	.0366	.0617	.0857	.1017	.0743	.1307
20	.1029	.0366	.0676	.0876	.0983	.096	.1097
21	.0972	.0366	.0949	.0857	.0949	.096	.0914
22	.1097	.0366	.0714	.0876	.1017	.0762	.0934
23	.0848	.0366	.0734	.0914	.0914	.0757	.0716
24	.2785	.1006	.0366	.0549	.0747	.0914	.0857
Max	1.0562	.823	.9555	1.0974	.4191	.7461	.7935
Min	.061	.0366	.0343	.0488	.0747	.0457	.061
Avg	.2944	.2266	.2818	.3315	.166	.2116	.2351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 303 / Budh Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.1463	.2195	.1886	.0732	.1463	.1905
2	.0732	.1109	.2195	.1905	.0747	.1478	.1886
3	.0701	.1097	.2149	.1905	.0701	.1463	.1886
4	.0716	.1097	.2149	.1905	.0716	.1829	.1886
5	.1463	.2195	.2804	.2286	.1463	.2218	.2641
6	.2987	.3658	.3429	.3772	.2987	.439	.3772
7	.4298	.4755	.3429	.4854	.415	.5121	.5228
8	.3658	.439	.3429	.439	.2926	.3658	.4066
9	.2241	.362	.2804	.3696	.1867	.3018	.3292
10	.2195	.2926	.2149	.2987	.1715	.2561	.2195
11	.2926	.2149	.2534	.2195	.2195	.2534	.2218
12	.2561	.2149	.2561	.1494	.2195	.2218	.1867
13	.2241	.2149	.1829	.1509	.2561	.1848	.1886
14	.2195	.2103	.1886	.1463	.2195	.2241	.1463
15		.2058	.2218	.2241	.2195	.2195	.1494
16	.1829	.2149	.2587	.2195	.2195	.2587	.2195
17	.2195	.2149	.2195	.2241	.2561	.2561	.2241
18	.2926	.2865	.1848	.2195	.2195	.2561	.2263
19	.439	.3582	.1867	.3734	.439	.3696	.394
20	.4024	.4298	.4108	.439	.4435	.4481	.3658
21	.2926	.3658	.3772	.3734	.439	.3734	.3658
22	.2561	.3658	.3018	.2926	.2926	.3395	.2987
23	.1829	.2926	.2641	.1753	.2195	.2263	.2195
24	.1463	.1463	.2195	.2263	.1433	.2218	.1905
Max	.439	.4755	.4108	.4854	.4435	.5121	.5228
Min	.0701	.1097	.1829	.1463	.0701	.1463	.1463
Avg	.2339	.2653	.2583	.2663	.2336	.2739	.2614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 305 / 22 KV KATEWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	1.2209	1.0974	.9717	.0701	.0732	.0693
2	.0701	1.1736	1.0974	.9717	.0716	.0739	.0686
3	.0686	1.1271	1.073	.9282	.0732	.0732	.0678
4	.0701	1.1401	1.073	.9282	.0701	.0732	.0686
5	.0716	1.0814	1.1869	.9717	.0716	.0739	.0678
6	.0732	1.1469	1.5261	1.073	.0732	.0732	.1489
7	.0701	1.1984	1.5432	1.1984	.0747	.0747	.1478
8	.0716	1.278	2.1033	1.2186	.0732	.0754	.0739
9	.0732	1.3108	2.2786	1.6575	.0701	.0732	.0747
10	.0747	1.278	1.7147	1.4754	.0716	.0686	.0701
11	1.7368	.0671	.0716	.0686	2.0972	1.9006	2.0222
12	1.9989	.0678	.0709	.0701	2.4577	2.1548	2.2801
13	2.13	.0686	.0709		2.5232	2.0317	2.3663
14	2.2939	.0686	.0701		2.4863	2.0081	2.0317
15	2.1879	.0732	.0671	.0747	2.2611	2.0317	1.9784
16	2.0729	.0732	.0739	.0732	2.1628	2.0317	1.9006
17	2.0972	.0732	.0747	.0747	2.0972	1.8027	1.9448
18	1.9433	.0732	.0762	.0732	1.9662	1.2483	1.6712
19	.0754	.0732	.0754	.0747	.0701	.0747	.0671
20	.0732	.0732	.0747	.0732	.0701	.0747	.0686
21	.0732	.0732	.0739	.0701	.0732	.0747	.0686
22	.0732	.0732	.0693	.0716	.0732	.0739	.0701
23	.0732	.0732	.0648	.0747	.0732	.0716	.0716
24	.0716	.0732	.0732	.2263	.0732	.0732	.0686
Max	2.2939	1.3108	2.2786	1.6575	2.5232	2.1548	2.3663
Min	.0686	.0671	.0648	.0686	.0701	.0686	.0671
Avg	.7340	.5400	.6542	.5645	.8002	.6827	.7278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 201 / 11 KV Pusegaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.5041	.4481	.4854	.5228	.5228	.5788
2	.4108	.4854	.4481	.4854	.4854	.5228	.5788
3	.4108	.4854	.4294	.4668	.4854	.5228	.5601
4	.4481	.4854	.4294	.5228	.4854	.5228	.5601
5	.4668	.5228	.5228	.6908	.5788	.5601	.6722
6	.7282	.8402	.8962	.9709	.8029	.8402	.8589
7	1.0829	1.0642	1.1949	1.1949	1.2323		1.1203
8	1.0456	1.0642	.9896	1.0829	1.1389	1.1203	1.1016
9	.8962	.9335	.8589	.9522	.9335	1.0082	.8775
10	.7655	.7842	.8402	.8775	.7842	.9149	.7842
11	.7468	.8029	.7842	.7468	.7468	.7468	.8402
12	.7282	.7842	.7842	.7655	.7842	.7842	.7655
13		.7095	.7468	.7842	.7842	.6722	.6722
14	.7468	.6722	.6722	.6161	.7655	.6348	.7282
15	.7655	.6908	.6722	.6722	.7655	.6722	.8402
16		.7095	.7468	.7095	.8215	.7282	.8029
17	.7842	.6908	.8215	.6722	.7655	.8215	.8029
18	.8029	.8029	.8962	.7095	.8402	.7842	.8029
19	.9522	.9709	1.1016	1.0269	1.1016	1.0829	1.0829
20	.9335	.9709	1.0642	1.0829	1.0829	1.0456	1.1016
21	.9149	.9149	.9896	1.0642	.9709	1.0642	1.0082
22	.7842	.7655	.8589	.8775	.8589	.8775	.9522
23	.6161	.5975	.6535	.6908	.6161	.6722	.7282
24	.4668	.5041	.4854	.5601	.5788	.5415	.5975
Max	1.0829	1.0642	1.1949	1.1949	1.2323	1.1203	1.1203
Min	.4108	.4854	.4294	.4668	.4854	.5228	.5601
Avg	.7231	.7398	.7640	.7795	.7888	.7680	.8091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 202 / 11 KV PUSEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	.0164	.0164	.0164	.5243	.4915	.4752
2	.5407	.0164	.0164	.0164	.5079	.4915	.4752
3	.5407	.0164	.0164	.0164	.4915	.4915	.4588
4	.5571	.0164	.0164	.0164	.4915	.4752	.4424
5	.5735	.0164	.0164	.0164	.5079	.4752	.4588
6	.6226	.0164	.0164	.0164	.5243	.5243	.5407
7	.7701	.0164	.0164	.0164	.6882		.852
8	.8848	.0164	.0164	.0164	.7209	1.0159	.9995
9	.8684	.0164	.0164	.0164	.7373	.9503	.9503
10	.0164	.0164	.0164	.0164	.6882	.8684	.8192
11	.0164	1.0814	1.0322	1.065	.0164	.0164	.0164
12	.0164	1.2125	1.278	1.2616	.0164	.0164	.0164
13	.0164	1.2289	1.2452	1.2452	.0164	.0164	.0164
14	.0164	1.2616	1.2452	.9175	.0164	.0164	.0164
15	.0164	1.3435	1.2125	1.0322	.0164	.0164	.0164
16	.0164	1.3763	1.2125	1.0978	.0164	.0164	.0164
17	.0164	1.3599	1.0814	1.065	.0164	.0164	.0164
18	.0164	1.1142	.9175	.9831	.0164	.0164	.0164
19	.0328	.0164	.0328	.0164	.0328	.0655	.0164
20	.0328	.0328	.0328	.0328	.0328	.0328	.0492
21	.0164	.0328	.0164	.0328	.0328	.0328	.0492
22	.0164	.0164	.0164	.0328	.0164	.0164	.0164
23	.0164	.0164	.0164	.0164	.0164	.0164	.0164
24	.5571	.0164	.0164	.0164	.0164	.0164	.0164
Max	.8848	1.3763	1.278	1.2616	.7373	1.0159	.9995
Min	.0164	.0164	.0164	.0164	.0164	.0164	.0164
Avg	.2806	.4281	.3967	.3741	.2567	.2650	.2820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 203 / 11 KV VARDHANGAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.5533	.5868	.6036	.0168	.0168	.0168
2	.0168	.5533	.5868	.6036	.0168	.0168	.0168
3	.0168	.5533	.57	.6203	.0168	.0168	.0168
4	.0168	.5365	.57	.6371	.0168	.0168	.0168
5	.0168	.5197	.57	.7042	.0168	.0168	.0168
6	.0168	.5197	.7042	.8215	.0168	.0168	.0168
7	.0168	.5533	.9556	1.0562	.0168		.0671
8	.0168	.8215	1.1904	1.1401	.0168	.0168	.0164
9	.0168	.8718	1.1233	1.0395	.0168	.0168	.0168
10	.0168	.9054	.9221	.9389	.0168	.0168	.0168
11	1.2407	.0168	.0168	.0168	1.3748	1.1401	1.073
12	1.1736	.0168	.0168		1.576	1.4251	1.1736
13	1.1233	.0168	.0168	.0168	1.5424	1.4419	1.4083
14	.9556	.0168	.0168	.0168	1.3916	1.4419	1.3413
15	1.358	.0168	.0168	.0168	1.4083	1.358	1.3077
16	1.073	.0168	.0168	.0168	1.358	1.3077	1.2742
17	1.2742	.0168	.0168	.0168	1.3077	1.1065	1.3413
18	1.1401	.0168	.0168	.0168	1.2071	.9221	1.1568
19	.0335	.0838	.0335	.0838	.0335	.0335	.0503
20	.0335	.0838	.0335	.0671	.0335	.0671	.0503
21	.0168	.0671	.0335	.0671	.0335	.0671	.0503
22	.0168	.0335	.0335	.0335	.0168	.0671	.0168
23	.0168	.0168	.0168	.0168	.0168	.0335	.0168
24	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Max	1.358	.9054	1.1904	1.1401	1.576	1.4419	1.4083
Min	.0168	.0168	.0168	.0168	.0168	.0168	.0164
Avg	.4017	.2843	.3367	.3725	.4785	.4600	.4373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 301 / 22 KV Nidhal GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.1132	.0754	.0754	.1509	.0754	.0754	.0754
6	.1509	.1132	.1132	.1886	.1132	.1509	.1132
7	.1886	.1886	.1509	.1886	.1509		.1509
8	.1509	.1509	.1509	.1509	.1886	.1509	.1509
9	.0754	.1132	.0754	.1132	.1132	.1132	.1132
10		.1132	.0754	.1132	.0754	.0754	.0754
11	.1132	.0754	.0754	.0754	.0754	.0754	.0754
12	.0754	.0754	.0754	.0754	.0754	.0754	.0754
13	.0754	.0754	.0754	.0754	.0754	.0754	.0754
14	.0754	.0754	.0754	.0377	.0754	.0754	.0754
15	.0754	.0754	.0754	.0754	.0754	.0754	.0754
16	.0754	.0754	.0754	.0754	.0754	.0754	.0754
17	.0754	.1132	.0754	.0754	.0377	.0754	.0377
18	.1132	.1132	.1132	.1509	.0754	.0754	.1132
19	.1132	.1132	.1509	.1509	.1132	.1509	.1509
20	.0754	.1509	.1509	.1509	.1509	.1509	.1509
21	.1132	.1132	.1132	.1509	.1132	.1509	.1509
22	.1132	.1132	.1132	.1132	.1132	.1132	.1132
23	.0754	.1132	.0754	.0754	.0754	.0754	.1132
24	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Max	.1886	.1886	.1509	.1886	.1886	.1509	.1509
Min	.0754	.0754	.0754	.0377	.0377	.0754	.0377
Avg	.0967	.1006	.0943	.1069	.0927	.0951	.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 302 / 22 KV DARUJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	.3018	.2641	.2641	1.4419	1.3435	1.2742
2	1.3435		.2641	.2641	1.4419	1.3435	1.2742
3	1.3435	.3018	.2641	.2641	1.3413	1.3108	1.2407
4	1.3763	.3018	.2641	.3018	1.2742	1.3108	1.2407
5	1.4419	.3018	.3395	.3395	1.2742	1.3435	1.2742
6	1.5402	.3395	.4904	.415	1.3077	1.4419	1.3748
7	2.0729	.4527	.5281	.4527	1.643		2.079
8	2.2348	.4904	.4527	.415	1.7436	2.1052	2.3137
9	2.1628	.3395	.3018	.3395	1.7436	1.9845	2.2542
10	1.8785	.3018	.3018	.3018	1.4864	1.2803	1.8564
11	.2263	2.2801	2.3594	2.0805	.1886	.2263	.3018
12	.2641	2.7161	2.5587	2.4326	.2641	.2263	.3395
13	.2641	2.8502	2.5587	2.4966	.3395	.2641	.3395
14	.2641	2.9508	2.4291	1.9925	.3426	.2641	.3395
15	.2263	2.8837	2.332	2.1506	.3395	.2641	.3395
16	.3018	3.0849	2.4291	2.3087	.3395	.3018	.3018
17	.3018	2.8166	2.4615	2.2455	.3018	.3018	.3395
18	.3018	2.4478	2.0729	2.0241	.2641	.2641	.3772
19	.415	.3772	.3887	.3395	.5281	.3772	.4527
20	.415	.415	.4527	.415	.5281	.4527	.4527
21	.415	.3395	.3772	.3772	.4527	.415	.3772
22	.3395	.3395	.3772	.3018	.3772	.3772	.3395
23	.3018	.3395	.2641	.2641	.3395	.3395	.3018
24	1.3763	.3018	.3018	.2641	.2641	.3018	.3018
Max	2.2348	3.0849	2.5587	2.4966	1.7436	2.1052	2.3137
Min	.2263	.3018	.2641	.2641	.1886	.2263	.3018
Avg	.9243	1.1858	1.0347	.9604	.8153	.7757	.8786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 303 / 22 KV Nidhal AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.6371	.8718	.7865	.1132	.0754	.1132
2	.0754	.6371	.8718	.7537	.1132	.0754	.0754
3	.0754	.6371	.8718	.7537	.1132	.0754	.0754
4	.0754	.6036	.8718	.7865	.1132	.0754	.0754
5	.0754	.6036	.9054	.8848	.1132	.0754	.0754
6	.1132	.695	1.1065	1.0562	.1509	.1132	.1132
7	.1509	.6722	1.2742	1.3763	.1509		.1509
8	.1132	.7682	1.4232	1.5043	.1509	.1509	.1132
9	.1132	.7362	1.3283	.9922	.1132	.1132	.1132
10		.7042	1.0437	.9922	.1132	.0754	.1132
11	1.3443	.0754	.0754	.1132	1.6975	1.3435	1.4091
12	1.3763	.1132	.0754	.0754	1.6004	1.4685	1.3435
13	1.3763	.0754	.0754	.0754	1.7604	1.406	1.4419
14	1.4403	.1132	.1132	.1509	1.6644	1.3435	1.3763
15	1.5684	.0754	.1132	.1132	1.5364	1.3748	1.3763
16	1.4723	.0754	.1132	.0754		1.5935	1.4419
17	1.4723	.0754	.1132	.0754	1.3123	1.3123	
18	1.2803	.1132	.0754	.1132	1.1203	1.142	.9503
19		.1509	.1886	.1509	.1509	.1132	.1132
20	.1132	.1509	.1509	.1509	.1509	.1509	.1509
21	.1132	.1509	.1509	.1509	.1509	.1509	.1509
22	.1132	.1132	.1132	.1509	.1132	.1132	.1132
23	.0754	.1132	.0754	.1132	.1132	.1132	.1132
24	.0754	.6371	.1132	.1132	.1132	.0754	.1132
Max	1.5684	.7682	1.4232	1.5043	1.7604	1.5935	1.4419
Min	.0754	.0754	.0754	.0754	.1132	.0754	.0754
Avg	.5767	.3636	.5048	.4795	.5534	.5448	.4831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 201 / GOPUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.0953		.6554		.639
2		.1905	.0953		.6226		.6718
3		.1905	.0953		.6226		.6718
4		.2286	.0953		.6226		.7537
5		.2286	.1143	.2667	.6554		.9012
6	.9831	.3048	.1715	.3048	.7209		1.065
7	1.4746	.3048	.2858	.4572	.8848		1.4255
8	1.4746	.3429	.2096	.4191	1.0159		1.704
9	1.5565	.2096	.2096	.2286	1.0486	1.5402	.9831
10	1.2616	.1715	.1143	.1715	.9667		1.0486
11	.1143	1.6712	1.6385	1.6385	.1143	.1143	.1715
12	.1334	1.5565	1.9334	1.7532	.1524	.1334	.1334
13	.1334	1.3435	1.9334	1.8842	.1905	.1334	.1334
14	.1143		1.9334	1.7368	.1524	.1334	.1524
15	.1143		1.9006	1.7695	.1143	.1524	.1715
16	.1334	1.8842	1.9989	1.6712	.1524	.1715	.1524
17		2.0645		1.5565		.1524	.1715
18		1.1469	1.4746	1.4419		.1905	.1905
19		.1524		.1524		.1905	.2286
20		.1524		.1524		.1715	.2096
21		.1524	.381	.1524		.1715	.2096
22		.1524		.1524		.1715	.1715
23		.1334	.3048	.1334	.3048	.1524	.1524
24	.6882	.2667	.1143		.1143	.2286	.1334
Max	1.5565	2.0645	1.9989	1.8842	1.0486	1.5402	1.704
Min	.1143	.1334	.0953	.1334	.1143	.1143	.1334
Avg	.6818	.5927	.7550	.8444	.5062	.2538	.5102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 202 / VADUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1715		.4588		.4915
2		.1905	.1715		.426		.5243
3		.2286	.1715		.426		.5243
4		.2667	.1715		.4424		.5571
5		.2667	.1905	.2667	.4915		.6226
6	.9503	.3429	.3239	.3048	.5735		.8192
7	1.3108	.3048	.381	.381	.8029		1.2289
8	1.3763	.381	.381	.381	1.065		1.3599
9	1.3272	.4382	.3429	.4572	1.0814	1.3599	
10	.9831	.4001	.3048		.9667	1.1633	.7045
11	.3048	1.0814	1.1961	1.0814	.2477	.2667	.3048
12	.362	1.1797	1.5074	1.1469		.2286	.2667
13	.362	1.5565	1.3599	1.2944		.2096	.2667
14	.362		1.278	1.3927	.2667	.2286	.2477
15	.3429		1.2452	1.4255	.2477	.2477	.2858
16	.381	1.6712	1.2944	1.3435	.2858	.2667	.1143
17		1.6385		1.2944		.2477	.3048
18		1.4746	1.278	1.2944		.2286	.3048
19		.3048		.3048		.362	.4191
20		.3429		.3048		.3429	.4191
21		.3048	.3429	.2858		.3429	.381
22	.2667	.2477		.2667		.3048	.3239
23	.2667	.2096	.3048	.2286	.2667	.2667	.3048
24	.5898		.1715		.1905		.2286
Max	1.3763	1.6712	1.5074	1.4255	1.0814	1.3599	1.3599
Min	.2667	.1905	.1715	.2286	.1905	.2096	.1143
Avg	.6561	.6201	.6294	.7475	.5150	.4044	.4785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 203 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0655		.0492		.0492
2			.0655		.0492		.0492
3		.0492	.0655		.1147		.0492
4		.0492	.0983		.1147		.0492
5		.1147	.0983	.1147	.0492		.0492
6	.1638	.1147	.1638	.1147	.1638		.1638
7	.1638	.1638	.1638	.1638	.1638		.1638
8	.1638	.1638	.1638	.1638	.1638		.1638
9	.1638	.1638	.1638	.1638	.1638	.1638	.1638
10		.1638	.1638	.1638	.1638	.1638	.1638
11		.1638	.1638	.0983	.1638	.1638	.1638
12		.1638	.1638	.0983	.0983	.1638	.1638
13	.1638	.1638	.1638	.1638	.0983	.1638	.0983
14	.1638		.1638	.1638	.0983	.1638	.0983
15	.0983		.0983	.1638	.1638	.1638	
16	.0983	.0492	.1638	.1638	.1638	.1638	.0492
17		.1147		.1147		.1638	.1147
18		.1147	.1638	.1147		.1638	.1638
19		.1147		.1638		.1638	.1638
20		.1147		.1638		.1147	.1638
21		.1147	.1147	.1638		.1147	.1638
22		.0492		.1638		.1638	.1638
23		.0492	.0655	.1638	.0492	.1638	.0492
24	.0492		.0655		.0492	.0492	.0492
Max	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Min	.0492	.0492	.0655	.0983	.0492	.0492	.0492
Avg	.1365	.1156	.1269	.1466	.1156	.1505	.1161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 204 / VADUJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4755	.5611		.6335		.6697
2		.4706	.543		.6036		.6335
3		.5068	.543		.6036		.6335
4		.5068	.5792		.6036		.6335
5		.543	.6154	.6516	.6516		.6697
6	.9412		.9231	.8048	.8869		.9231
7	1.2308	.9412	1.2851	1.134	1.267		1.2851
8	1.1222	1.1584	.9774	1.1222	1.2127		1.2308
9	1.086		.9774	1.086	1.0136	1.086	
10	.8688		.7964	.9412	.9412	.9774	.9412
11	.8688	.905	.8688	.8688	.9412	.9774	.9412
12	.9412	.8688	.905	.8688	.9774	.905	.9412
13	.8688	.7602	.8688	.8688	1.0136	.8688	.905
14	.8326		.8326	.8688	1.0136	.8688	.8688
15	.8326		.905	.8326	1.0136	.8688	.905
16	.8326	.9412	.9774	.8688	.905	.9412	.9412
17		.9412		.9231		.9593	.8688
18		.905	.9877	.9231		.9593	1.0136
19		1.1946	1.1584			1.3032	1.267
20		1.1222		1.2127		1.2127	1.3213
21		1.0498		1.1403		1.1222	1.2308
22	.8688	.9231		1.0136		1.0498	1.0498
23	.5121	.7964	.7682	.905	.724	.905	.8869
24			.5973		.724		.724
Max	1.2308	1.1946	1.2851	1.2127	1.267	1.3032	1.3213
Min	.5121	.4706	.543	.6516	.6036	.8688	.6335
Avg	.9082	.8339	.8335	.9463	.8739	1.0003	.9341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 205 / GOPUJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543	.0905		.0724		.128
2		.0549	.0732		.0732		.1097
3		.0543	.0732		.0732		.0914
4		.0543	.0732		.0732		.0914
5		.0905	.0732	.0905	.0732		.0914
6	.0905	.1086	.1463	.1086	.1463	.0905	.128
7	.181	.1086	.1629	.181	.1629		.181
8	.1463	.1086	.1629	.1448	.1629		.1991
9	.1646	.1629	.1267	.1448	.0905	.1612	.181
10	.128	.1448	.1086	.1267	.0905	.1086	.1448
11	.1478	.1448	.1448	.1646	.1267	.1417	.1629
12	.2054	.1448		.1097	.1267	.1267	.1629
13	.1595	.1448	.1448	.1097	.1267		.1629
14	.1417		.1417	.1097	.1267		.181
15	.0886		.1448	.0914	.1086		.1463
16	.0709	.1097	.1448	.0543	.1086	.0934	.1097
17		.1097		.0724		.128	.1097
18		.1097	.1097	.0724		.1463	.1463
19		.1448		.1086		.2012	.2353
20		.181		.2172		.1829	.2534
21		.181	.1629	.181		.1829	.2172
22	.1267	.1267		.1448		.1646	.181
23		.1448	.1448	.1448	.1097	.1646	.1991
24	.0732	.0914	.1086		.1267	.0905	.128
Max	.2054	.181	.1629	.2172	.1629	.2012	.2534
Min	.0709	.0543	.0732	.0543	.0724	.0905	.0914
Avg	.1326	.1170	.1230	.1251	.1099	.1417	.1559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 206 / 11KV KUMTHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5243	.9503		.2477		.2477
2		.5898	.9503		.2286		.2286
3		.5898	.9339		.2286		.2286
4		.6226	.9175		.2286		.2286
5		.7865	.9175	.9831	.2667		.2667
6	.2667	.7865	1.1469	1.1142	.362		.362
7	.3048	.7865	1.6549	1.6385	.4572		.4954
8	3.1055	1.0814	1.8351	1.8023	.4572		.4763
9	.3429	1.0159	1.8023	1.7204	.2858	.4001	.4191
10	.2667	1.0159	1.065	1.5402	.2477	.3048	.3239
11	1.7532	.3048	.2667	.2477	1.9989	1.6712	1.5402
12	2.1956	.3048	.2667	.2667	2.13	1.7368	1.8515
13	2.2119	.2667	.2477	.3048	2.2611	1.8842	1.8842
14	2.2283		.2477	.2858	2.0809	1.8023	1.9334
15	2.2611		.2667	.2667	2.1136	1.7859	1.917
16	2.3102	.2477	.3429	.3048		1.8679	1.8515
17		.3429		.3048		1.8023	1.7859
18		.2667	.2667	.3048		1.5729	1.6712
19		.4572		.3429		.362	.3239
20		.4001		.4191		.4001	.3429
21		.381	.3429	.381		.381	.3429
22	.2667	.3429		.3239		.3239	.3239
23		.2667	.3048	.2858	.3048	.3048	.2477
24	.2286	.2667	.2477		.2477	.2667	.2667
Max	3.1055	1.0814	1.8351	1.8023	2.2611	1.8842	1.9334
Min	.2286	.2477	.2477	.2477	.2286	.2667	.2286
Avg	1.3648	.5294	.7487	.6757	.8322	1.0542	.8150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 201 / 11 KV BANPURI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632		.2286	.2096	2.934	1.8176	1.8176
2	1.749		.3429	.2096	2.9721	1.8176	1.8176
3	1.749		.1905	.2096	2.7435	1.8176	1.8004
4	1.8861		.1905	.2858	2.9321	1.8004	1.8519
5	1.8004		.2858	.2858	2.572	1.8347	1.9204
6	***		.3429	.3048	2.3834	1.8861	1.989
7	1.9719		.4382	.362	2.1948	2.1091	2.6406
8	2.1434	.381	.4191	.4001	2.2977	2.452	2.6063
9			.3429	.2667	2.3148		2.5034
10		.2667	.2858	.2858		2.2291	2.4348
11	.2096	2.572	3.1893	2.934		.2286	.2477
12		2.8464	3.275	3.6008		.2667	.2667
13		2.9492	2.6578	2.9912	.3048	.2286	.2286
14	.2667		2.7435	3.0293		.2286	.2286
15			2.8978	2.915		.2286	.2286
16			2.9321	2.9664	.2667	.2667	.2286
17	.2667		3.0007	2.7092	.2858	.2286	.2286
18		2.572	2.2291	2.5892	.3048	.2477	.3048
19		.3429	.3048	.3239	.2667	.3048	.3429
20		.3239	.3048	.362	.3239	.3429	.3239
21		.3239	.2858	.3429	.3048	.3239	.2667
22		.2667	.2667	.2858	.2667	.2858	.2286
23		.2286	.2096		.2096	.2286	.2286
24	1.6632	.2096	.2286	.2096	.2477	.2096	.2286
Max	74.0742	2.9492	3.275	3.6008	2.9721	2.452	2.6406
Min	.2096	.2096	.1905	.2096	.2096	.2096	.2286
Avg	7.4536	1.1069	1.1497	1.2208	1.3750	.9297	1.0401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 202 / 11 KV BARAGAON Water
Supply Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	02-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
10		.0191
24	.0953	
Max	.0953	.0191
Min	.0953	.0191
Avg	.0953	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 203 / 11 KV Palasgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.6859	.5144	.5144	.1905	.1905
2	.1524		.6859	.5144	.5144	.1905	.1905
3	.1524		.6859	.5144	.5144	.1905	.1905
4	.1905		.6859	.5487	.5487	.1905	.2286
5	.3048		.6859	.6001	.6001	.2286	.3429
6	.3429		.7545	.6687	.6687	.3429	.4191
7	.5335		1.166	.9945	.823	.5525	.5335
8	.4191	.6516	1.0974	1.0974	1.0288	.4954	.4572
9			.9259	.9259	.9259		.3429
10		.5487	.7202	.8383		.3048	.3048
11	.7545	.381	.2858	.2667		.5487	.6001
12		.3239	.1905	.1905		.2286	.7545
13		.2096	.2096	.1905	.8573	.8002	.7545
14	.9907		.2286	.1905		.823	.7545
15			.1524	.1524		.8573	.7373
16		.2667	.1524	.1524	.7888	.8573	.8059
17	1.0974		.1905	.1905	.7545	.8573	.6859
18		.2096	.2667	.381	.823	.7545	.6001
19		.381	.4191	.381	.2667	.4191	.3048
20		.4191	.4572	.4572	.4572	.4191	.3048
21		.3429	.3048	.4191	.4191	.381	.2667
22		.2477	.2667	.3048	.2858	.2667	.2286
23		.1905	.1524		.2286	.3048	.2286
24	.1524	.1715	.1524	.1524	.1905	.1905	.1905
Max	1.0974	.6516	1.166	1.0974	1.0288	.8573	.8059
Min	.1524	.1715	.1524	.1524	.1905	.1905	.1905
Avg	.4369	.3341	.4801	.4629	.5900	.4519	.4341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 301 / PIMPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1524	.1524	.1524	.1524	.1524
2	.1143		.1524	.1143	.1524	.1524	.1524
3	.1143			.1143		.1524	.2286
4	.1143		.1524	.1143		.1524	.2286
5	.1524		.1524	.1524		.1905	.1524
6	.1524		.2286	.1524		.2286	.2286
7	.1524		.3048	.3048		.3048	.2286
8	.1524	.2286	.3048	.3048		.2667	.2286
9			.2286	.2286			.2286
10		.1905	.1905	.2286		.2286	.1524
11	.1905	.2286	.1905	.1524		.2286	
12		.2286	.1524	.1524		.1524	
13		.1905	.1524	.1524	.1905	.1524	
14	.1524		.1524	.1524		.1524	
15			.1524	.1524		.1524	
16		.1905	.1524	.1524	.1905	.1524	
17	.1524	.1905	.1524	.1524	.1905	.1524	
18		.2286	.2286	.1524	.2286	.1524	
19		.2667	.2286	.2286	.2286	.1524	
20		.2286	.2286	.2286	.2667	.1524	
21			.2286	.2286	.2667	.1524	
22		.2286	.2286	.2286	.2286	.1524	
23		.2286	.1524		.1905	.1524	
24	.1143	.1524	.1905	.1524	.1524	.1524	.1524
Max	.1905	.2667	.3048	.3048	.2667	.3048	.2286
Min	.1143	.1524	.1524	.1143	.1524	.1524	.1524
Avg	.1397	.2139	.1938	.1806	.2032	.1756	.1940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 302 / ENKUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1143	.1143	.1143	.1143	.1143
2	.1143		.1143	.1143	.1143	.1143	.1143
3	.1143		.1143	.1143	.1143	.1143	.1524
4	.1524		.1143	.1143	.1524	.1143	.1524
5	.1524		.1143	.1524	.1524	.1143	.1143
6	.1524		.1524	.1524	.2286	.1524	.1524
7	.2286		.2667	.2286	.2286	.2286	.1524
8	.2286	.1905	.1905	.1524	.2286	.1905	.1524
9			.1524	.1524	.1524		.1524
10		.1905	.1524	.1143	.1524	.1524	.1143
11	.1905	.1524	.1524	.1143		.1524	
12		.1524	.1524	.1143		.1143	
13		.1524	.1143	.1143	.1524	.1143	
14	.1524		.1143	.1143		.1143	
15			.2286	.1143		.1524	
16		.1524	.1524	.1143		.1524	
17	.1905	.1524	.1143	.1143	.1905	.1524	
18		.1524	.3048	.1143	.1905	.1524	
19		.2286	.1524	.1143	.2286	.1524	
20		.1905	.1524	.1143	.1905	.1524	
21		.1524	.1143	.1524	.1905	.1524	
22		.1524	.1143	.1524	.1524	.1524	
23		.1524	.1143		.1524	.1143	
24	.1143	.1524	.1524	.1143	.1143	.1143	.1143
Max	.2286	.2286	.3048	.2286	.2286	.2286	.1524
Min	.1143	.1524	.1143	.1143	.1143	.1143	.1143
Avg	.1588	.1660	.1508	.1292	.1684	.1408	.1351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 303 / MANDVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.1143	.1143	.1143	.1143	.1143
2	.1143		.0762	.0762	.1143	.0762	.1143
3	.1143		.0762	.0762	.1143	.0762	.1143
4	.1143		.0762	.0762	.1143	.0762	.1143
5	.1143		.1143	.1143	.1143	.0762	.1143
6	.1143		.1143	.1143	.1143	.1143	.1143
7	.1143		.1524	.1524	.1143	.1524	
8	.1143	.1524	.1143	.1143	.1143	.1143	
9			.1143	.1143	.1143		.1143
10		.1905	.1143	.1143	.1143	.1143	.1143
11	.1905	.1524	.1143	.1143		.1143	
12		.1143	.1143	.1143		.1143	
13		.1143	.1143	.1143	.1143	.1143	
14	.1143		.1143	.1143		.1143	
15			.1143	.1143		.1143	
16		.1143	.1143	.1143		.1143	
17	.1143	.1143	.1143		.1524	.1143	
18		.1143	.1143		.1905	.1143	
19		.1143	.1143		.1905	.1143	
20		.1143	.1143		.1143	.1143	
21		.1143	.1143	.1143	.1143	.1143	
22		.1143	.1143	.1143	.1143	.1143	
23		.1143	.1143		.1143	.1143	
24	.1143	.2286	.1143	.1143	.1143	.1143	.1143
Max	.1905	.2286	.1524	.1524	.1905	.1524	.1143
Min	.1143	.1143	.0762	.0762	.1143	.0762	.1143
Avg	.1207	.1334	.1111	.1103	.1243	.1093	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 306 / 22 KV Bombale AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		1.3717	1.0288	1.0974	.4572	.381
2	.4572		1.3717	1.0288	1.0974	.4572	.381
3	.5335		1.3717	1.0288	1.0974	.4572	.381
4	.6097		1.3717	1.2003	1.2346	.4954	.4954
5	.6097		1.3717	1.2003	1.2346	.5716	.5716
6	.7621		1.4403	1.3717	1.4403	.7621	.7621
7	.8383		2.1605	1.2346	1.5089	.9145	.8383
8	.8383	1.0288	2.4348	2.1948	1.7833	.7621	.7621
9			2.2634	1.8519	1.989		.6097
10		1.0288	1.8519	1.5775	1.7147	.4572	.5335
11	1.8176	.4572	.5716	.3048			1.7147
12		.4191	.381	.3048			1.9547
13		.4191	.381	.3048	1.4403		1.9204
14	2.2862		.3048	.3048			1.7833
15			.4191	.3048			1.8176
16		.4191	.381	.3048	1.7833		1.8519
17	2.2634	.4572	.381	.4572	2.1338		1.8519
18		.6097	.381	.381	1.7833		1.7147
19			.6097	.7621	.6859		.5335
20		.6478	.1524	.6859	.6478		.6097
21		.5716	.5335	.6859	.6478		.5335
22		.5716	.5335	.6097	.5716		.4572
23		.5335	.381		.4954		.4572
24	.381	.381	.4954	.381	.4572	.4572	
Max	2.2862	1.0288	2.4348	2.1948	2.1338	.9145	1.9547
Min	.381	.381	.1524	.3048	.4572	.4572	.381
Avg	.9879	.5803	.9548	.8482	1.2422	.5792	.9963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 201 / AMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7045	.0829	.0663	.0663	.5243	.6802	.6802
2	.7045	.0829	.0663	.0663	.5243	.6802	.6802
3	.7045	.0829	.0655	.0663	.5243	.6802	.7125
4	.7287	.0819	.0819	.0829	.5243	.6401	.7682
5	.7287	.0655	.0995	.0995	.5571	.6964	.7682
6	1.0364	.1147	.1326	.116	.5571	.9069	.8421
7	1.5546	.213	.1989	.1823	.6554	1.1961	1.1523
8	1.5546	.1802	.1966	.1823	.7537	1.2616	1.2323
9	1.4251	.213	.1658	.1658	.7045	1.1797	1.166
10	1.1822	.1638	.116	.1658	.6718	1.085	.9602
11	.213	1.3763	1.4089	1.3108	.0972	.0829	.1326
12	.213	1.6194	1.6518	1.4746	.0972	.1492	.1658
13	.2105	1.587	1.6356	1.6221		.1475	.1492
14	.2105	1.587	1.6194	1.5402	.1475	.1311	.1326
15	.1802	1.4575	1.5708	1.3763	.1802	.1326	.1492
16	.1638	1.3763	1.5546	1.2944		.1311	.1658
17	.1638	1.3279	1.2793	1.3108		.1658	.1658
18	.1638	1.3123	1.0364	1.2125		.1638	.1658
19	.1638	.1658	.1658	.1492	.1638	.1966	.1326
20	.1638	.1492	.1326	.1492	.1311	.1658	.116
21	.1638	.1475	.1492	.1658	.1132	.1658	.0995
22	.1326	.1326	.0995	.1658	.0829	.1311	.0663
23	.0829	.0983	.0829	.1326	.0943	.1326	.0663
24	.7045	.0829	.0663	.0663	.0995	.0663	.0983
Max	1.5546	1.6194	1.6518	1.6221	.7537	1.2616	1.2323
Min	.0829	.0655	.0655	.0663	.0829	.0663	.0663
Avg	.5522	.5709	.5684	.5485	.3602	.4570	.4487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 204 / 11 KV MORALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0351	.0351	.0351	.0351	.0351	.0351
2	.0351	.0351	.0351	.0351	.0351	.0351	.0354
3	.0351	.0351	.0351	.0351	.0351	.0351	.0351
4	.0351	.0351	.0351	.0526	.0351	.0351	.0351
5	.0351	.0351	.0526	.0701	.0351	.0351	.0709
6	.1227	.0876	.1052	.0876	.0876	.0876	.1227
7	.1578	.1578	.1753	.1052	.1402	.1402	.1402
8	.1227	.1227	.1227	.0701	.1402	.1227	.0701
9	.0701	.1052	.0876	.0701	.0701	.0876	.0701
10	.0701	.0876	.0701	.0701	.0351	.0351	.0526
11	.0351	.0701	.0351	.0351	.0351	.0351	.0351
12	.0351	.0526	.0351	.0351	.0351	.0351	.0351
13	.0351	.0351	.0351	.0351	.0351	.0351	.0351
14	.0351	.0351	.0351	.0351	.0351	.0351	.0351
15	.0351	.0351	.0351	.0351	.0351	.0351	.0351
16	.0351	.0351	.0351	.0351	.0351	.0709	.0351
17	.0351	.0351	.0526	.0351	.0351	.0701	.0351
18	.0351	.0701	.0876	.0362	.0701	.0701	.0701
19	.0876	.1227	.1052	.0701	.1402	.1052	.1402
20	.1227	.1402	.0876	.1402	.1227	.1227	.0876
21	.1052	.1052	.0701	.1052	.1052	.1052	.0701
22	.0876	.0701	.0526	.0701	.0876	.0876	.0351
23	.0351	.0526	.0351	.0351	.0526	.0701	.0351
24	.0351	.0351	.0526	.0351	.0351	.0351	.0526
Max	.1578	.1578	.1753	.1402	.1402	.1402	.1402
Min	.0351	.0351	.0351	.0351	.0351	.0351	.0351
Avg	.0614	.0679	.0628	.0570	.0628	.0651	.0585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 207 / 11 KV Goregaon (N) AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	1.1633	1.1336	1.1498	.0829	.0829	.0995
2	.0995	1.1469	1.1385	1.1336	.0829	.0819	.0829
3	.0995	1.1469	1.166	1.1174	.0829	.0829	.0819
4	.0995	1.1336	1.1843	1.1012	.0829	.0829	.0995
5	.1326	1.166	1.2308	1.1984	.116	.1326	.1326
6	.2155	1.2308	1.2955	1.3279	.1989	.1989	.1638
7	.2652	1.3599	1.6644	1.6194	.2321	.2458	.2652
8	.2652	1.4255	1.8138	1.4899	.2321	.1823	.2321
9	.1989	1.4091	1.7814	1.6194	.1658	.1638	.1638
10	.1658	1.3603	1.6194	1.5708	.1326	.1311	.1326
11	1.6518	.1326	.116	.116	1.5223	1.7814	1.8623
12	1.8623	.1326	.0995	.1492	1.8623	1.9845	2.0567
13	1.9433	.0995	.0829	.1492	1.9595	2.0485	1.9433
14	1.9433	.0995	.0663	.1326	1.9271	2.0243	1.8299
15	1.9595	.0983	.0829	.1326	2.0081	1.9109	1.7976
16	1.9433	.0995	.0995	.1658	1.5708	2.0645	1.8947
17	1.9433	.1326	.0995	.1492	1.9826	1.9433	1.9271
18	1.8785	.1311	.0995	.1326	1.8023	1.7814	1.9595
19	.1326	.1658	.1658	.1989	.1823	.1658	.1989
20	.1658	.1638	.1326	.1658	.1658	.1638	.1658
21	.1326	.1658	.0995	.1492	.1326	.1638	.1492
22	.116	.1326	.0829	.1492	.1147	.1326	.116
23	.0829	.0983	.0663	.116	.0983	.116	.0995
24	.0995	.0819	.0819	.0663	.0829	.0829	.0983
Max	1.9595	1.4255	1.8138	1.6194	2.0081	2.0645	2.0567
Min	.0829	.0819	.0663	.0663	.0829	.0819	.0819
Avg	.7290	.5948	.6418	.6375	.7009	.7395	.7314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 302 / MHASURNE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322	.1509	.1132	.1886	.8745	1.166	.7773
2	.8322	.1132	.1132	.1509	.8745	1.1797	.7773
3	.8322	.1132	.1132	.1509	.8745	1.166	.8322
4	.9069	.1132	.1509	.1509	.8745	1.1336	.8421
5	.9069	.1509	.1886	.2263	.9069	1.1336	.9069
6	1.2125	.2263	.2641	.2641	.9069	1.2955	.9717
7	1.6194	.3772	.3772	.3772	1.1271	1.587	1.4403
8	1.9109	.4527	.3772	.3772	1.1934	1.7814	1.749
9	1.5813	.3772	.3395	.3772	1.0883	1.6194	1.8244
10	1.3599	.3772	.2641	.3772	.9922	1.4251	1.5364
11		1.704	1.8461	1.4251	.2641	.2641	.2263
12	.1886	2.0405	1.9433	1.749	.3395	.2641	.2641
13	.2641	1.9989	1.9109	1.9433	.2641	.2641	.2641
14	.2641	2.0729	1.8785	1.7284	.2641	.2263	.2641
15	.3018	1.9204	1.749	1.6004	.1886	.3018	.2641
16	.3018	1.9757	1.6518	1.6324	.2263	.3018	.2641
17	.3395	1.9006	1.587		.2263	.3018	.3018
18	.3395	1.6385	1.5223	1.4083	.2263	.3018	.3018
19	.3395	.3018	.2641	.2641	.3018	.2641	.2641
20	.3018	.2641	.2641	.2263	.3018	.2641	.2641
21	.2641	.2641	.2641	.2263	.2641	.2263	.2263
22	.2263	.2263	.2263	.2263	.2263	.1886	.1886
23	.1886	.1509	.1886	.2263	.1886	.1509	.1509
24	.8322	.1509	.1132	.1886	.1509	.1509	.1132
Max	1.9109	2.0729	1.9433	1.9433	1.1934	1.7814	1.8244
Min	.1886	.1132	.1132	.1509	.1509	.1509	.1132
Avg	.7020	.7942	.7379	.6733	.5477	.7066	.6256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 303 / NIMSOD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7377	.7125	.9069	.1509	.1509	.1509
2	.1509	.7042	.7209	.8745	.1509	.1509	.1509
3	.1509	.6882	.7773	.8421	.1509	.1509	.1509
4	.1509	.6962	.8421	.9393	.1509	.1509	.1509
5	.1886	.7125	.8962	1.166	.1509	.1886	.1886
6	.2263	.7625	.9717	1.2955	.2641	.2641	.2263
7	.3395	.8192	1.4575	1.4251	.3395	.3395	.3395
8	.3018	.7537	1.7604	1.587	.3018	.2641	.3395
9	.2263	.8848	1.5546	1.7166	.1886	.2263	.2641
10	.2263	.9282	1.3603	1.4899		.1509	.2263
11	1.8107	.2241		.2263	1.5074	1.6518	1.8138
12	2.1216	.2641	.2263	.2641	2.2283	1.8785	1.8461
13	1.9109	.2641		.2641	2.17	1.9433	1.8785
14	1.8785	.2641		.2263	1.9757	1.9757	1.8785
15	1.749	.2641	.2641	.2263	1.4899	1.8138	1.8461
16	1.7814	.2641	.2641	.3018	1.749	1.8564	1.8785
17	1.7695	.3361	.2641	.2641	1.8785	1.6842	1.5546
18	1.3435	.3018	.2641	.2263	1.6385	1.4251	1.4575
19	.2263	.2641	.2641	.2926	.2641	.2263	.3018
20	.1886	.2263	.2641	.2641	.2641	.2641	.2641
21	.2263	.2263	.2641	.2263	.2263	.2263	.3018
22	.2263	.2263	.1886	.1886	.3395	.1886	.2641
23	.1886	.1886	.1886	.1886	.2263	.1886	.2263
24	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Max	2.1216	.9282	1.7604	1.7166	2.2283	1.9757	1.8785
Min	.1509	.1509	.1509	.1509	.1509	.1509	.1509
Avg	.7623	.4647	.6503	.6481	.7807	.7296	.7438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 305 / SHIRASWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0754	.0754	.0754	.0754
2	.0754	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.1132	.1509	.0754	.0754	.1132
6	.1509	.1886	.1886	.1886	.1509	.1509	.1886
7	.2641	.2641	.2263	.2263	.1886	.2641	.2641
8	.2263	.2263	.2263	.1886		.2263	.2641
9	.1886	.1886	.1886	.1509		.1886	.2263
10	.1886	.1509	.1509	.0754		.1886	.1886
11	.1886	.1509		.0754	.0754	.1509	.1509
12	.1886	.1132	.1509	.0754	.0754	.1509	.1509
13	.1509	.1132		.0754	.0754	.1509	.0754
14	.1509	.1132		.0754	.0754	.1509	.0754
15	.0754	.0754	.0754	.0754	.0754	.1132	.0754
16	.0754	.1132	.0754	.0754	.0754	.1509	.0754
17	.0754	.1509	.0754	.0754	.0754	.1509	.0754
18	.0754	.1509	.1509	.1509	.1509	.1886	.1509
19	.1886	.2263	.1886	.1886	.2263	.2263	.3018
20	.2263	.2263	.1886	.1886	.2641	.2263	.2641
21	.1886	.1886	.2263	.1886	.2263	.1886	.2263
22	.1509	.1509	.1886	.1509	.1886	.1509	.1886
23	.0754	.1132	.0754	.0754	.1132	.1509	.1886
24	.0754	.0754	.0754	.0754	.0754	.0754	.1132
Max	.2641	.2641	.2263	.2263	.2641	.2641	.3018
Min	.0754	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.1367	.1399	.1365	.1179	.1185	.1509	.1525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 306 / PUNWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2263	.2263	.2263	.2263	.2263
2	.1886	.2263	.2263	.1886	.2263	.2263	.2263
3	.1886	.1886	.1886	.1886	.2263	.2263	.2263
4	.2641	.1886	.2263	.1509	.2263	.2263	.2263
5	.2641	.2641	.3018	.2263	.3018	.3018	.3018
6	.415	.415	.5281	.3018	.415	.415	.4527
7	.5658	.6036	.6036	.4527	.5658	.6036	.6413
8	.4904	.5281	.5281		.4904	.5281	.6036
9	.3772	.4527	.4527	.5281	.3018	.4527	.5281
10	.3018	.3772	.3772	.3395	.3018	.3772	.4527
11	.3018	.3018	.3018	.2641	.3018	.3018	.3395
12	.2641	.2641	.2263	.2263	.2641	.2641	.2641
13	.2263	.2641	.2263	.2263	.2641	.2641	.2641
14	.2263	.2641	.2263	.2263	.2641	.2641	.2641
15	.2263	.3018	.2263	.2263	.2263	.2641	.2641
16	.2641	.2641	.2263	.2263	.2641	.3018	.2641
17	.2641	.3018	.1509		.2641	.3018	.2641
18	.3395	.3018	.0754	.2641	.3395	.3395	.3018
19	.3772	.4527	.5658	.4527	.4904	.5281	.3772
20	.4527	.5281	.5281	.4904	.4527	.4527	.4904
21	.415	.4527	.4527	.415	.4527	.4527	.4527
22	.3395	.3772	.3772	.3018	.3772	.3772	.3772
23	.2263	.3018	.3018	.3018	.3018	.3018	.3018
24	.1886	.2263	.2641	.2263	.2263	.2263	.2641
Max	.5658	.6036	.6036	.5281	.5658	.6036	.6413
Min	.1886	.1886	.0754	.1509	.2263	.2263	.2263
Avg	.3065	.3364	.3253	.2932	.3238	.3427	.3489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 301 / PACHWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.1132	.0754	.0754	.0754	.1132
2	.0754	.0754	.0754	.0754	.0754	.0754	.1132
3	.0754	.0754	.0754	.0754	.0754	.0754	.0754
4	.0754	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.1132	.0754	.0754	.0754	.0754	.0754
6	.1132	.1509	.0754	.1509	.0754	.0754	.0754
7	.1886	.1886	.0754	.1886	.1509	.1509	.0754
8	.1509	.1886	.0754	.1886	.1132	.1886	.1132
9	.1132	.1509	.0754	.0754	.0754	.1886	.1509
10	.0754	.2641	.0754	.0754	.0754	.1886	.1132
11	.0754	.1509	.0754	.0754	.0754	.1886	.0754
12	.0754	.1509	.0754	.0754	.0754	.1509	.0377
13	.0754	.1509	.0754	.1132	.0754	.1509	.0377
14	.0754	.1509	.0754	.1132	.0754	.1509	.0377
15	.0754	.1509	.0377	.0754	.0754	.1509	
16	.0754	.1886	.0377	.0754	.0754	.1509	.0377
17	.0754	.1886	.0377	.0754	.0754	.1132	.0377
18	.1132	.1509	.0754	.0754	.1132	.1132	.0754
19	.1509	.1132	.1132	.0754	.1509	.1132	.1509
20	.1886	.1132	.1509	.1132	.1886	.1132	.1509
21	.1509	.1132	.1132	.1132	.1509	.1132	.1132
22	.1132	.1132	.1132	.0754	.1132	.1132	.1132
23	.0754		.0754	.0754	.0754	.1132	
24	.0754	.0754	.1132	.0754	.0754	.0754	.1132
Max	.1886	.2641	.1509	.1886	.1886	.1886	.1509
Min	.0754	.0754	.0377	.0754	.0754	.0754	.0377
Avg	.1006	.1378	.0817	.0943	.0943	.1242	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 302 / PADAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0754	.0754	.0377	.0754	.0754	.1132
2	.0377	.0754	.0754	.0377	.0754	.0754	.1132
3	.0377	.0754	.0754	.0377	.0754	.0754	.0754
4	.0377	.0754	.0754	.0377	.0754	.0754	.0754
5	.0377	.1132	.0754	.0377	.0754	.0754	.0754
6	.0754	.1509	.0754	.1509	.0754	.1132	.0754
7	.1509	.1886	.0754	.2263	.1509	.1509	.0754
8	.1132	.1886	.0754	.1509	.1132	.1886	
9	.0754	.1509	.0754	.1132	.0754	.1886	.1509
10	.0754	.1509	.0754	.0754	.0754	.1886	.1132
11	.0754	.1509	.0754	.0754	.0754	.1886	.0754
12	.0754	.1509	.0377	.0754	.0754	.1509	.0377
13	.0754	.1509	.0377	.0754	.0754	.1509	.0377
14	.0754	.1509	.0377	.0754	.0754	.1509	.0377
15	.0754	.1509	.0377	.0377	.0754	.1509	
16	.0754	.1886	.0377	.0377	.0754	.1509	.0377
17	.0754	.1886	.0377	.0377	.0754	.1132	.0378
18	.1132	.1509	.0754	.0377	.1132	.1132	.0754
19	.1509	.1132	.1132	.0377	.1886	.1132	.1509
20	.1886	.1132	.1886	.1132	.1886	.1132	.1509
21	.1509	.1132	.1509	.1132	.1509	.1132	.1132
22	.1132	.1132	.1132	.0754	.1132	.1132	.1132
23	.0754		.0754	.0754	.0754	.1132	
24	.0377	.0754	.1132		.0754	.0754	.1132
Max	.1886	.1886	.1886	.2263	.1886	.1886	.1509
Min	.0377	.0754	.0377	.0377	.0754	.0754	.0377
Avg	.0849	.1328	.0786	.0771	.0959	.1257	.0880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 303 / KALEDHON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1509	.1132	.1132	.1132	.1886
2	.1132	.1509	.1509	.1132	.1132	.1132	.1509
3	.1132	.1509	.1509	.1132	.1132	.1132	.1509
4	.1132	.1509	.1509	.1132	.1132	.0754	.1509
5	.1509	.1886	.1509	.1132	.1132	.1132	.1509
6	.1886	.2263	.1509	.2641	.1132	.1509	.1509
7	.3395	.2641	.1509	.3395	.3018	.2641	.1509
8	.3018	.2641	.1509	.2263	.1509	.3395	.1509
9	.2263	.2263	.1509	.1509	.1132	.3018	.1886
10	.1509	.2263	.1509	.1509	.1132	.3018	.1886
11	.1132	.2263	.1509	.1132	.1132	.3018	
12	.1132	.1509	.1135	.1132	.1132	.2641	.1132
13	.1132	.1509	.1132	.1132	.1132	.2641	.1132
14	.1132	.1509	.1132	.1132	.1132	.2641	.1132
15	.1509	.2263	.1135	.1132	.1132	.2641	
16	.1509	.2263	.1132	.1132	.1509	.2641	.1132
17	.1509	.2263	.1132	.0754	.1509		.1132
18	.1886	.2263	.1509	.0754	.1886	.2641	.1886
19	.3395	.1886	.1509	.0754	.2641	.2641	.3018
20	.3395	.1886	.2641	.0754	.3018	.2641	.2641
21	.3018	.1886		.1132	.3018	.2263	.1886
22	.2641	.1509	.1509	.1132	.2641	.2263	.1509
23	.2263		.1132	.1132	.2263	.2263	
24	.1132	.1886	.3395	.1132	.1132	.1509	
Max	.3395	.2641	.3395	.3395	.3018	.3395	.3018
Min	.1132	.1509	.1132	.0754	.1132	.0754	.1132
Avg	.1871	.1952	.1526	.1305	.1619	.2231	.1641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 304 / STATIONERY POINT

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.5658	.3018	.3772	.0377	.415	.3772
2	.3772	.5658	.3018	.3772	.0377	.4904	.3772
3	.3395	.6036	.3018	.3395	.0377	.5281	.3395
4	.3395	.679	.3018	.3395	.0377	.5281	.3395
5	.3395	.7545	.3018	.3395	.0377	.5281	.3772
6	.3772	.7545	.3018	.3018	.0377	.5281	.3395
7	.4527	.679	.3395	.3018	.0377	.4527	.4527
8	.3772	.6036	.3395	.3772	.0377	.4527	.3395
9	.3395	.6036	.3772	.4527	.0377	.4527	.4527
10	.3395	.3395	.3772	.6036	.0377	.4527	.4527
11	.3395	.3018	.4527	.3772	.0377	.3772	.5281
12	.3395	.3018	.415	.4527	.0377	.415	.4527
13	.415	.3018	.5281	.3018	.0377	.1886	.3018
14	.4904	.3018	.4527	.3018	.0377	.3395	.5281
15	.5281	.3018	.6036	.1509	.0377	.3018	
16	.5281	.3018	.4527	.3772	.0754	.3772	.6036
17	.5281	.2641	.6036	.1509	.0754	.3395	.6036
18	.4527	.3018	.5281	.1509	.2263	.3395	.4904
19	.4904	.3018	.6036	.1509	.2263	.3395	.415
20	.5281		.4527	.0377	.2641	.3395	.4527
21	.5658		.4527	.0377	.2263	.3395	.415
22	.5658		.4527	.0377	.3018	.3395	.415
23	.5658		.3772	.0377	.3395	.415	
24	.4527	.5658	.3018	.415	.0377	.3395	.3772
Max	.5658	.7545	.6036	.6036	.3395	.5281	.6036
Min	.3395	.2641	.3018	.0377	.0377	.1886	.3018
Avg	.4370	.4697	.4134	.2829	.0974	.4008	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 305 / GHARUDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.3018	.3395	.3018	.4344	.4973	.3395
2	.6173	.3018	.3772	.3018	.4344	.5304	.3395
3	.631	.3395	.3772	.3018	.4344	.6036	.3772
4	.8413	.3395	.415	.3018	.5959	.6783	.4904
5	1.0166	.3395	.4904	.4527	.6516	.7461	.6036
6	1.1218	.4949	.5658	.679	.6859	.823	1.0456
7	1.7436	.7545	.7545	.7545	.9069	.5487	1.7375
8	2.0485	.679	.6413	.6413	.8745	1.9227	2.4451
9	1.7284	.5281	.5658	.4904	.8139	1.9227	2.2565
10	1.6644	.5281	.415	.4527	.8139	1.6712	1.8099
11	.3395	1.5402	1.3565	1.5074	.3772	.3395	.3018
12		2.1445	1.4403	1.9433	.415	.3395	.3018
13		2.2405	1.8027	1.9757	.3395	.3018	.3395
14	.3395	2.3365	2.0241	1.9433	.3018	.3018	.3772
15	.3772	2.2405	1.4723	1.8785	.3018	.8871	
16	.415	2.1765	2.0622	2.0081	.2641	.8871	.3772
17		1.7814	2.1033	1.6118	.3018	.8501	.3018
18		1.7166	1.9204	1.5775	.4527	.7762	.3772
19	.5281	.5658	.4904	.4904	.5281	.6036	.4527
20	.5281		.5658	.5281	.5281	.4527	.5281
21	.4904		.5281	.4904	.4904	.4527	.415
22	.415		.4527	.415	.3772	.3772	.3772
23	.3395		.3772	.3395	.3018	.3018	
24	.6173	.3018	.3395	.3395	.3018	.2641	.3395
Max	2.0485	2.3365	2.1033	2.0081	.9069	1.9227	2.4451
Min	.3395	.3018	.3395	.3018	.2641	.2641	.3018
Avg	.8210	1.0826	.9116	.9053	.4970	.7116	.7243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 306 / KANERWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2321	.3018	.4115	.1509	.2641	.2641
2	.2641	.2321	.3361	.4207	.2641	.2641	.3018
3	.2641	.2622	.3361	.4115	.2641	.2641	.3018
4	.2641	.2949	.3734	.4115	.3018	.3018	.3395
5	.3395	.3605	.4854	.4115	.3772	.3772	.415
6	.4904	.4588	.5975	.5765	.5281	.4527	.4904
7	.7167	.6401	1.1458	1.1336	.7922	.679	.679
8	.679	.6478	.9877	1.2498	.5658	.6036	.5281
9	.4527	.5182	.9145	1.1065	.4904	.4527	.4527
10	.415		.7023	.8573	.4527	.3018	.3018
11	.9175	.4588	.3018	.3772	.9922	.7392	.788
12	.9069	.2641	.2641	.3395	1.1012	.8501	.7087
13	.9069	.2641	.2641	.3395	1.0364	.8501	.8916
14	.9393	.2641	.3018	.2641	.9393	.8501	.7011
15	.9393	.2641	.3018	.3018	1.004	.8501	
16	.9717	.3018	.3018	.3018	1.0364	.8501	.8288
17	1.0364	.2641	.3395	.3395	.9717	.7762	.8048
18	.8642	.3395	.3772	.3772	.7449	.7392	.7545
19	.4527	.5658	.5281	.5281	.5281	.4904	.4531
20	.4527		.5281	.5658	.5281	.2641	.5658
21	.415		.4527	.4527	.4904	.2641	.4527
22	.3395		.415	.415	.415	.2641	.3772
23	.3018		.3772	.3772	.3395	.2263	
24	2.2862	.2641	.2641	.3018	.3395	.3018	.2641
Max	2.2862	.6478	1.1458	1.2498	1.1012	.8501	.8916
Min	.2641	.2321	.2641	.2641	.1509	.2263	.2641
Avg	.6617	.3630	.4666	.5113	.6106	.5115	.5302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 307 / VIKHALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.2622	.1886	.3155	.1132	.1132	.1886
2	.1132	.2622	.2987	.3224	.1132	.1132	.2263
3	.1132	.2591	.2987	.3224	.1132	.1132	.2263
4	.1132	.2591	.3361	.3189	.1509	.1886	.2641
5	.1509	.3239	.4108	.4207	.1886	.2263	.2641
6	.2641	.3563	.8215	.583	.2641	.2641	.3018
7	.3395	.3887	1.0349	.6882	.415	.3772	.415
8	.3772	.4161		.7682	.3772	.3772	.3395
9	.2641	.3521	1.0349	.7186	.2641	.3018	.3018
10	.2641	.3521	.8589	.6516	.2641	.7023	.3018
11	.7773	.2263	.2263	.1886	.7042	.7023	.7888
12	.8421	.2641	.2263	.1886	.7682	.8871	.8288
13	.8421	.2641	.2263	.1509	.8002	.5228	.8192
14	.8745	.2641	.1886	.1509	.8002	.8131	.8288
15	.8745	.2641	.1896	.1509	.8002	.8501	
16	.9069	.3018	.1886	.1886	.7682	.8501	.7202
17	.7449	.2641	.1886	.1886	.7682	.7762	.7956
18	.7362	.2263	.3018	.2641	.6401	.7392	.7956
19	.2263	.3395	.3395	.2641	.2641	.3018	.1509
20	.2263		.3395	.2641	.2641	.2641	.2263
21	.1886		.3018	.2263	.2641	.2641	.1886
22	.1509		.2641	.1509	.1886	.2641	.1509
23	.1132		.2641	.1509	.1509	.2263	
24	.1509	.1132	.1886	.2641	.1509	.1132	.1886
Max	.9069	.4161	1.0349	.7682	.8002	.8871	.8288
Min	.1132	.1132	.1886	.1509	.1132	.1132	.1509
Avg	.4070	.2880	.3790	.3292	.3998	.4313	.4233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254076 / 33/11 KV Mandave S/S

Feeder No / Name : 201 / 11 KV MANADVE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5079	.1475	.1311	.1147	.2622	.4588	.4752
2	.5079	.1475	.1311	.0983	.2785	.4424	.4915
3	.5407	.1475	.1311	.0983	.2785	.4588	.4915
4	.6062	.1475	.1311	.1311	.2949	.4588	.5571
5	.6718	.1966	.1475	.1802	.3277	.6882	.7865
6	.852	.2949	.3441	.2785	.4096	.8192	1.0322
7	1.3435	.3932	.4134	.4096	.6226	1.3435	1.2125
8	1.6057	.3441	.3277	.3277	.6718	1.491	1.3599
9	1.3435	.2949	.1966	.2458	.7537	1.4091	1.278
10	1.0978	.213	.1311	.1802	.7537	1.1797	1.0322
11	.1311	1.2944	1.2289	.9448	.0983	.1147	.1147
12	.1311	1.4255	1.4091	1.1768	.0983	.1147	.0983
13	.1311	1.2616	1.4091	1.1437	.0983	.0983	.0983
14	.1311	1.0814	1.3927	1.21	.0983	.0983	.1147
15	.1475	1.1633	1.3927	1.2266	.1311	.1147	.0983
16	.1638	1.3435	1.1469	1.2289	.1147	.1311	.1147
17	.1638	1.3272	1.2289	1.2944	.1147	.1475	.1311
18	.1638	1.0978	1.0322	1.1961	.1475	.1802	.1802
19	.2294	.2785	.2949	.2622	.2458	.2622	.3277
20	.2785	.2949	.2785	.3113	.3113	.2622	.2622
21	.1966	.2294	.2622	.2622	.2458	.2622	.2294
22	.1966	.1802	.1966	.213	.2294	.213	.213
23	.1802	.1475	.1638	.1802		.1638	.1638
24	.4915	.1475	.1311	.1311	.1311	.1475	.1475
Max	1.6057	1.4255	1.4091	1.2944	.7537	1.491	1.3599
Min	.1311	.1475	.1311	.0983	.0983	.0983	.0983
Avg	.4922	.5666	.5689	.5352	.2921	.4608	.4588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254076 / 33/11 KV Mandave S/S

Feeder No / Name : 202 / 11 KV SATEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.8954	.8383		.0762	.0762	.1132
2	.0572	.8764	.8192	.8676	.0762	.0762	.0943
3	.0572	.8764	.8192	.9054	.0762	.0762	.0943
4	.0762	.8764	.8383	.9619	.0762	.0953	.0943
5	.0953	.8954	.9717	1.0374	.1334	.1334	.132
6	.1715	.9335	1.1431	1.1506	.1715	.1715	.1886
7	.2096	1.0669	1.6385	1.6032	.1905	.2477	.2641
8	.1524	1.086	1.7337	1.7164	.1905	.2286	.2075
9	.1715	1.1812	1.7337	1.7353	.1143	.1905	.1698
10	.1143	1.1622	1.467	1.4901	.1143	.1143	.1509
11	1.6004	.0572	.0754	.0953	2.0195	1.8861	1.6766
12	1.9052	.0953	.0754	.0953	2.2481	2.1691	1.6766
13	2.0576	.0953	.0754	.0953	2.2862	2.1691	1.848
14	2.1338	.0953		.1143	2.0005	2.1691	1.7909
15		.0953	.0754	.1143	2.0957	2.0748	1.8861
16	2.0957	.0953	.0754	.0953	2.1529	1.9427	1.8671
17	1.9433	.0953		.0953	2.0195	1.8673	1.8671
18		.0953	.1132	.0762	2.0576	1.6409	1.6956
19	.1143	.1334	.132	.1334	.1334	.1698	.1715
20	.1334	.1524	.132	.1524	.1524	.1698	.1524
21	.1334	.1334	.132	.1334	.1334	.1509	.1524
22	.1143	.1143	.1132	.1143	.1143	.1509	.1334
23	.0953	.0953	.0943	.0953	.0953	.132	.1143
24	.0762	.0762	.0762	.0754	.0762	.0953	.1132
Max	2.1338	1.1812	1.7337	1.7353	2.2862	2.1691	1.8861
Min	.0572	.0572	.0754	.0754	.0762	.0762	.0943
Avg	.6166	.4700	.5988	.5632	.7835	.7582	.6939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254076 / 33/11 KV Mandave S/S

Feeder No / Name : 203 / 11 KV PEDGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381		.0189	.0381	.0381	.0377
2	.0191	.0381	.0381	.0189	.0381	.0381	.0377
3	.0191	.0381	.0381	.0189	.0381	.0381	.0377
4	.0381	.0381	.0381	.0377	.0381	.0381	.0377
5	.0572	.0572	.0381	.0566	.0572	.0572	.0566
6	.0953	.0762	.0953	.0754	.0762	.0762	.0754
7	.0191	.0953	.0953	.0943	.0953	.1143	.0943
8	.0953	.0953	.0762	.0754	.0762	.0762	.0754
9	.0572	.0762	.0381	.0566	.0381	.0572	.0377
10	.0381	.0572	.0572	.0566	.0381	.0381	.0189
11	.0381	.0381	.0377	.0572	.0381	.0189	.0191
12	.0381	.0381	.0189	.0381	.0191	.0189	.0191
13	.0381	.0381	.0189	.0191	.0191	.0189	.0381
14	.0381	.0381	.0189	.0381	.0381	.0189	.0381
15	.0381	.0381	.0189	.0381	.0381	.0189	.0191
16	.0381	.0381	.0377	.0191	.0191	.0189	.0191
17	.0381	.0381	.0377	.0191	.0381	.0189	.0381
18	.0381	.0191	.0377	.0191	.0381	.0377	.0381
19	.0572	.0572	.0754	.0572	.0381	.0566	.0762
20	.0572	.0762	.0754	.0762	.0762	.0566	.0572
21	.0572	.0762	.0754	.0572	.0762	.0754	.0572
22	.0572	.0572	.0566	.0572	.0572	.0566	.0572
23	.0572	.0381	.0566	.0381	.0572	.1132	.0381
24	.0381	.0381	.0381	.0377	.0381	.0381	.0377
Max	.0953	.0953	.0953	.0943	.0953	.1143	.0943
Min	.0191	.0191	.0189	.0189	.0191	.0189	.0189
Avg	.0461	.0516	.0486	.0450	.0468	.0474	.0442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254076 / 33/11 KV Mandave S/S

Feeder No / Name : 204 / 11 KV TADAWALE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0754	.0943	.0943	.1132
2	.0566	.0377	.0377	.0377	.0943	.0943	.0943
3	.0566	.0377	.0377	.0377	.0943	.0943	.0754
4	.0566	.0377	.0377	.0377	.0943	.0943	.0754
5	.0754	.0572	.0566	.0566	.0943	.0943	.0943
6	.0943	.0754	.0943	.0754	.1132	.1132	.132
7	.132	.132	.1509	.132	.132	.1698	.1509
8	.1132	.1132	.132	.1132	.1698	.132	.1132
9	.0943	.0754	.0943	.0943	.0943	.0943	.0754
10	.0754	.0754	.1132	.0754	.1132	.0943	.0566
11	.0566	.0943	.0943	.132	.0754	.0943	.0943
12	.0754	.0953	.0943	.132	.0566	.1132	.0754
13	.0754	.0566	.0943	.1509	.0566	.0754	.0754
14	.0377	.0377	.0754	.0943	.0377	.0566	.0566
15	.0566	.0377	.0754	.1132	.0943	.0566	.0566
16	.0754	.0566	.0943	.1132	.0754	.0754	.0566
17	.0754	.0754	.0943	.0943	.0943	.0943	.0754
18	.0566	.0566	.1132	.0943	.1132	.1132	.1132
19	.0943	.1132	.1509	.132	.1698	.1698	.132
20	.0943	.1132	.1509	.1698	.1509	.1509	.132
21	.0943	.1132	.1509	.1509	.132	.132	.1132
22	.0943	.0943	.1509	.1132	.1132	.1509	.1132
23	.0754	.0754	.0943	.1132			.1132
24	.0754	.0566	.0566	.0754	.0943	.0943	.0943
Max	.132	.132	.1509	.1698	.1698	.1698	.1509
Min	.0377	.0377	.0377	.0377	.0377	.0566	.0566
Avg	.0770	.0739	.0959	.1006	.1025	.1066	.0951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254076 / 33/11 KV Mandave S/S

Feeder No / Name : 205 / 11 KV HINGANE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3479	.0949	.0791	.0633	.1739	.2214	.2688
2	.3479	.0791	.0791	.0633	.1898	.2372	.2688
3	.3321	.0791	.0791	.0474	.1898	.2372	.2846
4	.3637	.0791	.0791	.0633	.1898	.253	.3479
5	.3953	.0949	.0949	.0791	.2056	.3953	.427
6	.4586	.1265	.1265	.1107	.2372	.4428	.5376
7	.7116	.1581	.1581	.1581	.2688	.7274	.5693
8	.8539	.1739	.1581	.1581	.3479	.8065	.6958
9	.759	.1739	.1107	.1265	.3321	.6958	.6167
10	.7116	.1423	.1107	.0949	.3479	.5218	.5218
11	.0791	.6958	.5376	.5441	.0633	.0791	.0791
12	.0949	.8381	.68	.7202	.0633	.0633	.0949
13	.0791	.7907	.7116	.7842	.0633	.0633	.0949
14	.0633	.7432	.7116	.7202	.0633	.0791	.0949
15	.0633	.7432	.6958	.7202	.0474	.0791	.0949
16	.0791	.7432	.6958	.6958	.0791	.0949	.0949
17	.0791	.7432	.68	.7907	.0791	.0949	.0949
18	.0791	.68	.5693	.6958	.1107	.0949	.1107
19	.1265	.1265	.1509	.0949	.1265	.1423	.1265
20	.1265	.1423	.1265	.1265	.1265	.1581	.1107
21	.1265	.1423	.1265	.1265	.1265	.1581	.1107
22	.1107	.1265	.132	.1107	.1265	.1265	.0949
23	.1107	.1107	.0949	.0949	.1107	.1107	.0791
24	.3321	.0949	.0949	.0949	.0791	.0949	.0949
Max	.8539	.8381	.7116	.7907	.3479	.8065	.6958
Min	.0633	.0791	.0791	.0474	.0474	.0633	.0791
Avg	.2847	.3301	.2951	.3035	.1562	.2491	.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi

Feeder No / Name : 201 / 11 KV Anphale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.3391		.3561	.1357	.1187	.1187
2	.1017	.4239		.3856	.1357	.1357	.1187
3	.1017	.4239		.3521	.1357	.1357	.1187
4	.1017	.5087		.3856	.1357	.1696	.1187
5	.1357	.5087		.4191	.1696	.1696	.1187
6	.1865	.2883		.4694	.2035	.2035	.1696
7	.2374	.4239		.7042	.2883	.2374	.2543
8	.2883	.5087		.6706	.2883	.2883	.2374
9	.2374	.4239		.8551	.2204	.2374	.2374
10	.2035	.3052		.6874	.1865	.2374	.1696
11	.7122		.1174	.1341	.9326	.78	.5765
12	.763		.1677	.1677	.9326	.9835	.8478
13	.7969		.1677	.1677	.9156	.9496	.8478
14	.8478		.1341	.1509	.8987	.9156	.7291
15	.8987		.1677	.1677	.8987	.8817	.763
16	.8987		.1844	.1509	.8478	.8309	.7969
17	.8478		.2012	.1844	.8478	.763	.6783
18	.78		.218	.218	.7461	.6613	.5087
19	.1357		.2347	.2347	.1696	.2035	.2543
20	.1865		.2347	.2347	.2035	.2035	.2374
21	.1696		.1844	.2204	.2035	.1865	.2204
22	.1357		.1509	.1696	.1865	.1526	.1696
23	.1187			.1357	.1526	.1357	.1696
24	.1017	.1017		.1187	.1357	.1187	.1187
Max	.8987	.5087	.2347	.8551	.9326	.9835	.8478
Min	.1017	.1017	.1174	.1187	.1357	.1187	.1187
Avg	.3787	.3869	.1802	.3225	.4154	.4041	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi

Feeder No / Name : 202 / 11 kv Anphale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377		.0373	.0189	.0189	.0377
2	.0377	.0377		.0373	.0189	.0189	.0377
3	.0377	.0377		.0373	.0189	.0189	.0377
4	.0377	.0377		.0373	.0189	.0377	.0377
5	.0566	.0377		.0373	.0377	.0754	.0377
6	.0754	.0754		.0566	.0754	.0943	.0754
7	.0943	.0754		.0754	.1132	.0754	.1132
8	.0754	.0754		.0754	.0943	.0566	.0754
9	.0566	.0377		.0566	.0566	.0377	.0566
10	.0377	.0377		.0377		.0377	.0377
11	.0377		.0377	.0377	.0377	.0377	.0377
12	.0377		.0377	.0189	.0377	.0377	.037
13	.0377		.0377	.0189	.0189	.0377	.0189
14	.0377		.0377	.0189	.0189	.0377	.0189
15	.0189		.0377	.0189	.0189	.0377	.0189
16	.0189		.0377	.0189	.0377	.0377	.0189
17	.0377		.0373	.0377	.0377	.0566	.0377
18	.0566		.0373	.0566	.0566	.0566	.0754
19	.0754		.0747	.0943	.0754	.0754	.0943
20	.1132		.0747	.0754	.0943	.0754	.0754
21	.0754		.0754	.0754	.0754	.0754	.0754
22	.0377		.0754	.0566	.0566	.0566	.0566
23	.0189		.0373	.0377	.0377	.0377	.0377
24	.0377	.0189		.0373	.0189	.0189	.0377
Max	.1132	.0754	.0754	.0943	.1132	.0943	.1132
Min	.0189	.0189	.0373	.0189	.0189	.0189	.0189
Avg	.0495	.0463	.0491	.0455	.0467	.0479	.0495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi

Feeder No / Name : 203 / 11 KV Dhondewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7274	.1406		.096	.7362	.6401	.5535
2	.7116	.1406		.096	.7042	.7202	.5851
3	.703	.1562		.096	.7042	.7202	.6167
4	.7499	.1875		.096	.7522	.8002	.6483
5	.7811	.1875		.112	.8002	.8322	.7274
6	1.1248	.25		.144	.8802	.9602	.9646
7	1.656	.3125		.2721	1.1683	1.4403	1.5339
8	1.7341	.3593		.2561	1.2163	1.8244	1.6446
9	1.5779	.3125		.2721	1.2483	1.6004	1.5655
10	1.406	.25		.2241	1.1363	1.3443	1.3441
11	.2031		1.4083	1.6964	.16	.1423	.1423
12	.2031		1.6644	1.7924	.176	.1581	.2056
13	.2187		1.7284	1.8884	.16	.1581	.1898
14	.2187		1.7604	1.8884	.16	.1739	.1265
15	.2031		1.8244	1.8404	.16	.1898	.1581
16	.2031		1.9044	1.7764	.192	.2056	.1739
17	.2187		1.7604	1.6804	.208	.2372	.1739
18	.2656		1.6804	1.5364	.2561	.253	.1898
19	.2343		.208	.2561	.2561	.3005	.253
20	.2656		.208	.2241	.2561	.2846	.2372
21	.2343		.192	.176	.2241	.2688	.2214
22	.1718		.16	.144	.192	.2543	.1898
23	.1562		.112	.112	.16	.2214	.1581
24	.6958	.1406		.096	.112	.128	.4902
Max	1.7341	.3593	1.9044	1.8884	1.2483	1.8244	1.6446
Min	.1562	.1406	.112	.096	.112	.128	.1265
Avg	.6110	.2216	1.1239	.6988	.5008	.5774	.5456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254080 / 33/ 11 KV Dhondewadi

Feeder No / Name : 204 / 11 KV Dhondewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307		.1109	.1109	.1478	.1478
2	.112	.1307		.1109	.1294	.1478	.1294
3	.112	.1307		.1109	.1109	.1848	.1478
4	.112	.1867		.1109	.1294		.1478
5	.168	.2241		.1294	.1478	.2218	.1663
6	.2801	.2801		.2772	.2218	.2957	.2957
7	.3547	.2801		.3696	.3881	.2957	.4251
8	.2427	.3361		.3511	.3696	.2772	.3326
9	.1867	.2241		.2218	.1663	.1848	.2033
10	.1494	.2054		.1478	.1294	.1663	.1294
11	.1494		.1294	.1478	.1109	.1294	.1478
12			.1109	.1294	.1109	.1109	.1478
13	.112		.1109	.1109	.1109	.1109	.1109
14			.0739	.1109	.1109	.1109	.0924
15			.0924	.1109	.1109	.1109	.1109
16			.1109	.1109	.1294	.0924	.1109
17	.112		.1294	.1294	.1294	.1109	.1294
18	.1494		.1294	.1478	.1478	.1294	.1478
19	.2241		.2772	.2772	.2218	.2957	.2957
20	.2987		.2587	.3142	.2957	.2957	.2957
21	.2241		.2587	.2402	.2587	.2772	.2957
22	.1867		.2218	.1848	.2402	.2402	.2218
23	.1307		.1478	.1478	.1848	.1663	.1663
24	.112	.1307		.1109	.1294	.1478	.132
Max	.3547	.3361	.2772	.3696	.3881	.2957	.4251
Min	.112	.1307	.0739	.1109	.1109	.0924	.0924
Avg	.1764	.2054	.1578	.1756	.1748	.1848	.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 256007 / 110 KV MAYANI

Feeder No / Name : 301 / KATARKHATAV AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.7011
Max	.7011
Min	.7011
Avg	.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 256007 / 110 KV MAYANI

Feeder No / Name : 302 / PUSESAVALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	1.7071
Max	1.7071
Min	1.7071
Avg	1.7071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 256007 / 110 KV MAYANI

Feeder No / Name : 303 / MAYANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 301 / MAHABALESHWAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.9526	.9526	.9907	.8048	.8383	.8383
2	.7545	.9145	.8764	.8764	.7316	.8002	.7922
3	.679	.8299	.8383	.7621	.7545	.7621	.8002
4	.679	.8299	.8764	.8383	.679	.8383	.8383
5	.7167	.8299	.9907	.9145	.7316	.9145	.9054
6	.7545	.9431	1.1431	1.1431	.8048	1.0288	.9145
7	1.3203	1.2955	1.5242	1.4861	1.134	1.2574	1.1694
8	1.5089	1.6598	2.0195	1.7147	1.5364	1.5242	
9	1.5844	1.6385	1.9052	1.7528	1.4266	1.5242	
10	1.6221	1.7147	1.7147	1.6598	1.4632	1.5242	
11	1.3717	1.5242	1.5242	1.6221	1.3336	1.2574	1.5242
12	1.358	1.2955	1.4098	1.2826	1.2193	1.0562	1.2955
13	1.2955	1.3336	1.4098	1.2449	1.1431	1.1317	1.105
14	1.1812	1.1812	1.2955	1.2449	1.0669	.9907	1.105
15	1.1694	1.1812	1.2574	2.3011	1.0669	1.0562	1.1431
16	1.1317	1.2193	1.3336	1.1317	1.0669	1.105	1.0719
17	1.1317	1.3336	1.4098	1.2449	1.2574	1.2955	1.1576
18	1.3336	1.4861	1.5242	1.2449	1.2955	1.3717	1.2936
19	1.6766	1.7909	1.7909	1.5089	1.6385	1.5242	1.4937
20	1.5844	1.9814	1.9052	1.4632	1.6004	1.5242	1.4415
21	1.5089	1.5242	1.6766	1.3169	1.448	1.358	1.419
22	1.4335	1.1431	1.5242	1.3203	1.3717	1.2955	1.1949
23	1.1431	1.2955	1.3336	1.094	1.1431	1.0669	.961
24	.9431	.9431	1.0669	1.1431	.9054	.9145	.9145
Max	1.6766	1.9814	2.0195	2.3011	1.6385	1.5242	1.5242
Min	.679	.8299	.8383	.7621	.679	.7621	.7922
Avg	1.1963	1.2851	1.3876	1.3043	1.1510	1.1650	1.1133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 302 / Moleshwar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0762	.0762	.0732	.0762	.0754
2	.0754	.0754	.0762	.0762	.0754	.0762	.0754
3	.0754	.0762	.0762	.0762	.0732	.0762	.0762
4	.0754	.0754	.0762	.0762	.0754	.0762	.0762
5	.0754	.0754	.0762	.0762	.0732	.0762	.0762
6	.0754	.0754	.1143	.1905	.0732	.0762	.1143
7	.1886	.2286	.1905	.2667	.1829	.1905	.1905
8	.3395	.2263	.2667	.2667	.2926	.2667	
9	.2641	.2286	.3048	.2667	.2561	.2667	
10	.2263	.1905	.2667	.2641	.2195	.2286	
11	.1886	.1524	.2286	.2263	.1905	.1886	.2286
12	.1886	.1143	.1905	.1886	.1524	.0754	.1524
13	.0754	.1143	.1143	.0754	.1143	.0754	.1143
14	.0754	.0762	.0762	.0754	.1143	.0754	.0762
15	.0754	.0762	.0762	.0754	.0762	.0754	.0747
16	.0762	.0762	.0762	.0754	.0762	.0754	.0739
17	.0754	.1524		.1886	.0762	.0762	.1867
18	.2263	.1905	.2286	.2263	.0762	.2241	.2587
19	.2263	.2667	.2667	.2641	.2667	.2987	.3361
20	.2263	.2667	.2667	.2641	.2286	.3048	.2561
21	.2263	.2286	.2286	.2263	.2286	.3048	.1867
22	.1886	.1905	.2286		.1524	.1905	.1867
23	.1886	.1143	.1905	.1463	.1143	.0754	.0747
24	.0754	.0754	.1143	.1143	.0732	.0762	.0762
Max	.3395	.2667	.3048	.2667	.2926	.3048	.3361
Min	.0754	.0754	.0762	.0754	.0732	.0754	.0739
Avg	.1493	.1426	.1657	.1644	.1390	.1469	.1412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 303 / Metgutad

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.679	.8383	.8764	.6584	.6859	.6859
2	.6036	.7167	.7621	.7621	.5853	.6478	.6478
3	.6072	.6097	.6859	.6859	.5487	.6097	.6478
4	.6036	.6097	.6859	.6859	.5487	.6097	.679
5	.679	.6859	.7621	.8383	.5853	.6859	.6859
6	.7545	.7922	.8383	.9907	.5853	.7621	.7922
7	.9808	1.0288	1.0669	1.1431	1.0242	.9526	.9526
8	1.2449	1.2449	1.448	1.4098	1.2071	.9526	
9	1.2449	1.6766	1.5242	1.448	1.2071	1.2955	
10	1.1694	1.1812	1.3336	1.2826	1.1706	1.1431	
11	1.1431	1.2193	1.3336	1.2826	1.2193	1.1317	1.1812
12	.9145	1.1812	.9907	.9431	1.1431	.7842	1.105
13	.7545	.9526	.9526	.9054	.7621	.7621	.9907
14	.7167	.9907	.9526	.8299	.7621	.724	.924
15	.7621	1.0288	.9526	.9054	.7621	.7606	.7468
16	.7621	.9526	.9526	.7545	.7621	.7545	.8589
17	.8764	1.0669	1.0288	.7545	.7621	.7545	.7392
18	.8383	1.105	1.1431	.9054	.9526	.9054	.924
19	.9907	1.2955	1.2955	1.1317	1.1431	1.0288	1.0082
20	.9526	1.2193	1.0288	1.0242	1.0288	.8962	.924
21	.8299	1.0669	.9526	.8048	.9526	.8764	.8131
22	.7545	.9907	.9907	.8048	.7621	.7545	.695
23	.6413	.7621	.8383	.7316	.6097	.6859	.5975
24	.7167	.0754	.9145	.9526	.7316	.7621	.7545
Max	1.2449	1.6766	1.5242	1.448	1.2193	1.2955	1.1812
Min	.6036	.0754	.6859	.6859	.5487	.6097	.5975
Avg	.8425	.9638	1.0113	.9522	.8531	.8302	.8263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 304 / Venna Lake

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6413	.6859	.7621	.5853	.6097	.6859
2	.5281	.6036	.6478	.6859	.5121	.5716	.6097
3	.5281	.5658	.6097	.6097	.4755	.5335	.6036
4	.5658	.5716	.6859	.724	.4755	.5335	.6859
5	.5658	.6036	.724	.7621	.5487	.5716	.6859
6	.6036	.679	.7621	.8764	.5853	.5716	.6859
7	.6413	.7922	.9526	.9526	.7316	.6859	.679
8	.9054	.9431	1.1431	1.2193	.8048	.8764	
9	.9054	.9907	1.1812	1.1431	.9145	.9145	
10	.8916	1.1431	1.1431	1.1317	.9145	.9526	
11	.9808	1.105	1.1431	1.1694	.9526	.8299	1.105
12	.9431	1.1431	1.105	1.0562	.9526	.8299	.9145
13	.9431	1.1431	1.105	.9808	.9145	.7922	.9145
14	.9431	.9526	1.105	.9431	.8383	.724	.7762
15	.9054	1.1431	1.105	.9431	.7621	.8299	.7468
16	.9054	1.0669	1.0288	.9431	.7621	.7621	.7468
17	.9054	.9907	1.0288	.9054	.9526	.6859	.7316
18	.9145	1.105	1.0288	.9054	.9145	.8383	.7842
19	.9054	1.3717	1.4098	1.2449	1.2193	1.094	1.1576
20	1.3203	1.6004	1.3717	1.3203	1.2193	1.1949	1.1222
21	1.3203	1.448	1.3336	1.134	1.1431	1.1317	1.1458
22	.8299	1.2955	1.2955	1.0608	.9526	.9054	.961
23	.8299	.9907	1.0288	.8048	.8383	.8676	.7468
24	.6036	.6036	.7621	.9145	.6584	.6859	.6859
Max	1.3203	1.6004	1.4098	1.3203	1.2193	1.1949	1.1576
Min	.5281	.5658	.6097	.6097	.4755	.5335	.6036
Avg	.8329	.9789	1.0161	.9664	.8178	.7914	.8178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 305 / Bramha Corp Hotels &
Resorts Feeder KV- 22 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.381	.4191	.3018	.3048	.381
2	.2641	.3048	.3429	.381	.2641	.2667	.3429
3	.2641	.2641	.3048	.3048	.2641	.2667	.3429
4	.3018	.2641	.3048	.3048	.2926	.3048	.3429
5	.3395	.2641	.3048	.3048	.3018	.3429	.3395
6	.3395	.3018	.3429	.3429	.2926	.381	.381
7	.3772	.3429	.381	.381	.3018	.381	.3772
8	.3395	.381	.381	.4191	.3292	.4191	
9	.3772	.4191	.4954	.4572	.3658	.4191	
10	.3772	.4572	.5335	.5281	.4024	.4954	
11	.415	.4572	.5335	.415	.381	.4572	
12	.381	.4191	.4572	.415	.4191	.3018	.381
13	.381	.4572	.4572	.415	.4191	.3395	.3429
14	.3429	.4191	.4954	.415	.4572	.3395	.3326
15	.4954	.4572	.5335	.3429	.4191	.381	.2987
16	.4572	.4954	.4954	.3772	.4572	.3772	.3361
17	.415	.4572	.4572	.3772	.4191	.4191	.4108
18	.4527	.4954	.4954	.415	.4191	.381	.4108
19	.4572	.4954	.5716	.5281	.381	.3429	.4435
20	.4527	.5716	.5716	.3772	.381	.3395	.4024
21	.4527	.4572	.4954	.3658	.3429	.4191	.4435
22	.4572	.4572	.4572	.4024	.3429	.381	.4066
23	.3292	.381	.381	.3658	.381	.3018	.3734
24	.3018	.3395	.4191	.4191		.381	.381
Max	.4954	.5716	.5716	.5281	.4572	.4954	.4435
Min	.2641	.2641	.3048	.3048	.2641	.2667	.2987
Avg	.3780	.4041	.4414	.3947	.3624	.3643	.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 306 / Pratapgad

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1143	.1524	.1524	.1463	.1524	.1524
2	.1509	.1132	.1524	.1524	.1463	.1524	.1524
3	.1509	.1132	.1524	.1524	.1463	.1143	.1132
4	.1509	.112	.1524	.1524	.1463	.1143	.1132
5	.1463	.112	.1905	.1524	.1463	.1524	.1524
6	.1509	.1132	.1905	.1905	.1463	.1524	.1524
7	.1886	.1143	.1905	.1905	.1463	.1524	.1524
8	.1886	.1132	.1905	.1905	.1463	.1524	
9	.1886	.1143	.1905	.1905	.1463	.1905	
10	.1886	.1143	.1905	.1886	.1463	.1524	
11	.1905	.1143	.1524	.1509	.2667	.1143	.1524
12	.1886	.1905	.1905	.1509	.1143	.1143	.1524
13	.1886	.1905	.1524	.1509	.1524	.1132	.1143
14	.1509	.1905	.1524	.1509	.1524	.112	.1494
15	.1509	.1524	.1524	.1509	.1524	.1524	.1494
16	.1509	.1905	.1524	.1509	.1524	.112	.1132
17	.1524	.1905	.1524	.1509	.1905	.1524	.1448
18	.1886	.1905	.1905	.1886	.1524	.1524	.1448
19	.1886	.3048	.2286	.2263	.2286	.2241	.2241
20	.1886	.3048	.2667	.2561	.2667	.2987	.2534
21	.1132	.2667	.2286	.2195	.2286	.2263	.2195
22	.1143	.2286	.2286	.1829	.1905	.1886	.1848
23	.1132	.1905	.1905	.1509	.1524	.1509	.1478
24	.1463	.1143	.1524	.1524	.1509	.1524	.1524
Max	.1905	.3048	.2667	.2561	.2667	.2987	.2534
Min	.1132	.112	.1524	.1509	.1143	.112	.1132
Avg	.1617	.1647	.1810	.1727	.1673	.1562	.1567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 303 / TAPOLA

SHEDDABLE URBAN

Feeder KV- 22 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0762	.0762	.0754	.0716	.0747	.0381
2	.0373	.0747	.0381	.0377	.0362	.0747	.0377
3	.0747	.0754	.0381	.0373	.0358	.0754	.0373
4	.0747	.0754	.0381	.0377	.0358	.0747	.0381
5	.0747	.0739	.0754	.0762	.0724	.0747	.0754
6	.112	.1132	.0754	.0762	.1433	.112	.0762
7	.1494	.1132	.1509	.1509	.181	.1494	.112
8	.1494	.1132	.1478	.1509	.1478	.1494	.1509
9	.0739	.1867	.1109	.1867	.1494	.0747	.112
10	.1132	.112	.1132	.112	.0739	.1132	.112
11	.112	.1109	.112	.1086	.0739	.112	.1109
12	.1509	.1097	.112	.0724	.0739		.1109
13	.1132	.1109	.1132	.0724	.0739	.2987	.1086
14	.112	.1109	.112	.0724	.0739	.3018	.1086
15	.1132	.1109	.1132		.0739	.3018	.1086
16	.1132	.1109	.1132	.0739	.0739	.3326	.1097
17	.1132	.112	.1132	.0732	.0747	.112	.1097
18	.1132	.1829	.1886	.1478	.0747	.1132	.1417
19	.1886	.1829	.2263	.2241	.1494	.1848	.181
20	.1886	.2218	.2641	.1867	.1867	.2263	.1478
21	.1886	.1848	.2241	.1829	.1867	.1886	.1478
22	.1524		.1886	.1086	.0747	.1509	.1109
23	.0739	.112	.1509		.0747	.0754	.0754
24	.0747	.0754	.0754	.0762	.0724	.0747	
Max	.1886	.2218	.2641	.2241	.1867	.3326	.181
Min	.0373	.0739	.0381	.0373	.0358	.0747	.0373
Avg	.1143	.1196	.1238	.1064	.0952	.1498	.1027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 304 / KELGHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.2263	.1886	.1886	.1867	.1867	.1886
2	.1478	.1494	.1509	.1867	.1494	.1886	.1867
3	.1478	.1494	.1524	.1509	.1494	.1886	.1886
4	.1478	.1478	.1524	.1494	.1494	.1867	.1867
5	.2957	.1478	.1886	.1905	.2241	.3018	.1867
6	.3696	.2263	.2614	.2614	.3772	.3734	.2614
7	.4435	.3696	.4481	.3734	.4854	.4108	.4481
8	.6653	.5914	.5914	.5975	.6348	.4108	.6348
9		.6283	.6653	.5914	.6348	.5228	.5601
10	.5487	.5121	.6219	.5975	.4481	.5601	.5601
11	.4805	.5121	.5175	.5601	.4481	.5228	.4854
12	.5121	.4805	.1829	.4854	.4481		.4481
13	.4435	.3696	.439	.4481	.3734		.4481
14	.4024	.3658	.3734	.3734	.3734		.3326
15	.4066	.4024	.4108	.3734	.3734		.3734
16	.4805	.4435	.5228	.4481	.3696		.4481
17	.5544		.7095	.4854	.4481	.6348	.5228
18	.5601	.6584	.6722	.6348	.5228	.7842	.7023
19	.5914	.6584	.7842	.7468	.5228	.7842	.7468
20	.5544	.7023	.7095	.6722	.5975	.7095	.6722
21	.5228	.5914	.6348	.3734	.5228	.5601	.5228
22	.4527		.4854	.4854	.3734	.3734	.4854
23	.2926	.2987	.2987	.2614	.2241	.2614	.2614
24	.2241	.2987	.2241	.2241	.1867	.1867	.2263
Max	.6653	.7023	.7842	.7468	.6348	.7842	.7468
Min	.1478	.1478	.1509	.1494	.1494	.1867	.1867
Avg	.4084	.4059	.4327	.4108	.3843	.4288	.4199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 305 / NIZARE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1524	.1886	.1509	.1791	.1509	.1524
2	.1509	.1494	.1524	.1132	.1448	.1509	.112
3	.1524	.1509	.1524	.1132	.1086	.1509	.112
4	.1494	.1478	.1524	.112	.1075	.1494	.1143
5	.2241	.1478	.1509	.1143	.181	.2241	.1509
6	.2987	.1886	.1494	.1524	.2561	.3018	.1524
7	.2987	.2614	.3734	.2641	.3326	.3361	.2614
8	.3734	.4108	.4066	.4108	.4108	.4108	.2641
9	.439	.4805	.5175	.4805	.4481	.3734	.2218
10	.6219	.5914	.5544	.5975	.4066	.4805	.4435
11	.6348	.6653	.6283	.5175	.3696	.4854	.5914
12	.6283	.6283	.6219	.4481	.4435	.4904	.5914
13	.5601	.5853	.5914	.439	.4435	.4805	.5487
14	.5853	.5914	.3326	.4755	.4435	.4805	.5853
15	.5544	.5544	2.0538		.4435	.4108	.5853
16	.5975	.5121	.5544	.4755	.4435	.4435	.6219
17	.5914	.5914	.6283	.4805	.4481	.1109	.6219
18	.5658	.6584	.6283	.5228	.4435	.1494	.6584
19	.5544	.695	.6348	.5975	.5228	.5544	.5853
20	.5175	.5914	.4435	.5601	.5228	.4904	.5914
21	.415	.4805	.3734	.4854	.4481	.415	.4435
22	.3429		.3395	.3658	.3734	.3361	.1478
23	.2218	.2241	.2641		.2241	.1494	.1509
24	.1494	.1509	.1886	.1905	.2172	.1494	
Max	.6348	.695	2.0538	.5975	.5228	.5544	.6584
Min	.1494	.1478	.1494	.112	.1075	.1109	.112
Avg	.4074	.4178	.4617	.3667	.3484	.3281	.3786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 306 / BHANANG

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2667	.2263	.2641		.2241	.2667
2	.2241	.2263	.1905	.2263	.1791	.2263	.2614
3	.2241	.2263	.1905	.2241	.181	.2263	.2241
4	.2241	.2241	.1886	.2263	.181	.2263	.2667
5	.2987	.2218	.2263	.2641	.2896	.2987	.2641
6	.3734	.3018	.2614	.3429	.3696	.3734	.3048
7	.5228	.4481	.5228	.4904	.4854	.3734	.5228
8	.6722	.5975	.6653	.5975	.5601	.5228	.5658
9	.7316	.5914	.6283	.6283	.5975	.5601	.7023
10	.7392	.6653	.7023	.6722	.5914	.5175	5.5811
11	.7468	.8131	.7023	.5975	.6653	.6722	.7392
12	.7023	.7392	.695	.7468	.7392	.6036	.5914
13	.6413	.5914	.6283	.7468	.4435	.6283	.5487
14	.6219	.4435	.5175	.6348	.5914	.5914	.5853
15	.6653	.4805	.6722		.5914	.5975	.5853
16	.7842	.5175	.6283	.5601	.5914	.5544	.5853
17	.7392	.5914	.7023	.5853	.5914	.5544	.6584
18	.7167	.5853	.6413	.6722	.5975	.6348	.6584
19	.7392	.695	.7842	.7468	.6722	.7023	.695
20	.5914	.6283	.7023	.6348	.5975	.5658	.5914
21	.5658	.5544	.6348	.5175	.4481	.4904	.5175
22	.4954		.4904	.4805	.4481	.4481	.4066
23	.3696	.3734	.415		.2241	.2987	.3018
24	.2241	.3018	.2641	.3429	.2896	.2241	
Max	.7842	.8131	.7842	.7468	.7392	.7023	5.5811
Min	.2241	.2218	.1886	.2241	.1791	.2241	.2241
Avg	.5349	.4819	.5117	.5092	.4750	.4631	.7141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 301 / GOGAVE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0724	.0762	.0724	.061	.0648
2	.061	.061	.0648	.0724	.0686	.0572	.061
3	.0572	.0572	.0762	.08	.0648	.0572	.0572
4	.061	.0572	.0838	.0876	.0686	.0648	.061
5	.0648	.061	.0953	.0953	.0762	.061	.061
6	.0953	.0648	.1029	.0991	.0838	.08	.0724
7	.1181	.08	.1105	.1067	.0953	.0953	.1067
8	.1372	.1448	.0991	.1334	.1486	.1448	.1067
9	.1753	.1486	.1372	.1257	.1486	.1486	.1105
10	.1943	.1257	.141	.1257	.141	.1677	.1372
11	.1562	.1524	.1219	.1334	.1372	.1257	.0991
12	.1638	.16	.1181	.1029	.1105	.0724	.0876
13	.141	.1524	.1219	.0686	.0953	.1067	.0762
14	.0953	.16	.1181	.0724	.1029	.1143	.0724
15	.0991	.1296	.1143	.0686	.08	.0838	.08
16	.0914	.2134	.1219	.1067	.0876	.1296	.1143
17	.1143	.221	.1334	.0914	.0914	.1181	.1143
18	.0762	.1296	.1296	.1219	.0838	.16	.141
19	.1562	.1677	.1715	.1562	.202	.1829	.1905
20	.1638	.16	.1715	.1486	.2286	.1638	.1753
21	.141	.1524		.141	.1715	.1486	.1677
22	.1143	.1105		.1105	.1334	.1029	.1029
23	.0762	.1105	.061	.0953	.0838	.08	.0762
24	.0572	.061	.0762	.08	.08	.0648	.0572
Max	.1943	.221	.1715	.1562	.2286	.1829	.1905
Min	.0572	.0572	.061	.0686	.0648	.0572	.0572
Avg	.1113	.1226	.1110	.1042	.1107	.1080	.0997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 302 / SHINDI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0876	.0762	.0724	.0953	.0686	.0724
2	.08	.0876	.0648	.0686	.0762	.0686	.0686
3	.0686	.0724	.0686	.0762	.0648	.061	.061
4	.0724	.0724	.0953	.0838	.0724	.061	.0648
5	.0762	.0762	.1105	.0914	.0838	.0876	.0724
6	.0953	.1181	.1334	.0991	.1029	.1029	.0914
7	.1029	.1334	.1562	.1067	.1181	.1105	.1219
8	.1372	.1562	.1334	.1181	.1562	.141	.1486
9	.1448	.202	.1181	.1524	.1715	.0953	.1334
10	.1715	.1753	.1486	.1029	.1524	.0838	.1181
11	.1219	.1486	.0991	.08	.1638	.08	.0953
12	.1219	.1524	.1143	.0762	.1219	.061	.0762
13	.1105	.1448	.1257	.0686	.1181	.0991	.0724
14	.1029	.1296	.1143	.061	.1296	.0991	.0724
15	.0914	.1257	.0953	.0572	.0914	.1029	.0838
16	.0953	.1067	.1219	.08	.1067	.1219	.1181
17	.1029	.1105	.1486	.1067	.1257	.0724	.1181
18	.1067	.1143	.1715	.1715	.1524	.1257	.1677
19	.221	.2477	.2591	.2477	.2591	.2553	.2553
20	.2705	.282	.2782	.2286	.2553	.2591	.282
21	.2515	.2477		.16	.2058	.2286	.2362
22	.2172	.1981			.1638	.1448	.1372
23	.1524	.141	.08	.1334	.1143	.0914	.0953
24	.0838	.1143	.1105	.0686	.1105	.0914	.0762
Max	.2705	.282	.2782	.2477	.2591	.2591	.282
Min	.0686	.0724	.0648	.0572	.0648	.061	.061
Avg	.1283	.1435	.1283	.1092	.1338	.1130	.1183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 301 / ANEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.3048	.3292	.3048	.2926	.2195
2	.2926	.3292	.2667	.2926	.2667	.2926	.2195
3	.3292	.3292	.2667	.3292	.2667	.3292	.2195
4	.3658	.3189	.3048	.3658	.3048	.3658	.2195
5	.439	.3292	.3048	.439	.3048	.439	.3292
6	.5121	.439	.4572	.5121	.4481	.5121	.4755
7	.695	.5853	.6653	.6219	.6283	.6219	
8	.695	.6584	.6653	.6584	.7095	.6219	.5853
9	.6219	.695	.6653	.6584		.5182	.6584
10	.5121	.5761	.5121	.5121	.4801	.3841	.5441
11	.5121	.5121	.5121		.4481	.3841	.5121
12	.439	.4801	.4161	.4801	.3841	.3201	.5121
13	.439	.4801	.3841	.3201	.3841	.2881	.4481
14	.3658	.4481	.3521	.3563	.2881	.3201	.3521
15	.3658	.4161	.4481	.3841	.3201	.3201	.3841
16	.3658	.4161	.4161	.3521	.3841	.2561	.4161
17	.4755	.4481	.3841	.4801	.3841	.4024	.5228
18	.4755	.5601	.6219	.7023	.5121	.3292	.6653
19	.6584	.6722	.6584	.8131	.6219	.6219	.7762
20	.6584	.7023	.6584	.7392	.695	.6219	.7392
21	.5853	.6348	.5853	.7023	.6219	.5853	.6722
22	.439	.5228	.5487	.4854	.5487	.5487	.6348
23	.4024	.4527	.3658	.4191	.439	.4024	.4527
24	.3292	.3292	.381	.3658	.381	.3292	.3292
Max	.695	.7023	.6653	.8131	.7095	.6219	.7762
Min	.2926	.3189	.2667	.2926	.2667	.2561	.2195
Avg	.4694	.4860	.4644	.4921	.4403	.4211	.4734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 302 / ANEWADI AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1509	.1143	.8048	.9145	.8779	.7682
2	.1029	.1463	.1143	.8779	.9145	.9511	.7682
3	.1029	.1509	.1143	1.0242	.9145	1.0242	.7682
4	.1029	.1463	.1143	1.0242	.9511	1.2071	.7682
5	.1372	.1509	.1524	1.1706	.9511	1.3169	.7682
6	.1715	.1886	.1905	1.3169	1.2071	1.4632	.9145
7	.2058	.1829	.2286	1.4632	1.6827	1.6095	1.2071
8	.2058		.2286	.1829	1.9022	1.6461	1.5729
9	.1372	.1829	.1905	.1509	1.9387	1.4632	1.8656
10	.1509	.16	.128	.1463	.1463	.1097	.1829
11	1.7558	1.6964	.128	2.7435	.1509	.1097	2.0851
12	2.2634	2.0165		.0732	.1097	.1132	2.0851
13	2.1948	1.9204	.1097	.1463	.1097	.1097	2.0119
14	2.0119	1.8244	.1029	.1097	.1132	.1097	1.8656
15	2.0851	1.7604	.1029	.1463	.1097	.1097	1.8656
16	2.0851	1.7924	.1029	.1463	.1463	.1097	1.9022
17	1.9022	1.7284	.1029	.1463	.1097	.1097	1.8656
18	1.5364	1.7013	.1372		.1463	.1097	
19	.0732	.1905	.1715	.2561	.2195	.2195	
20	.1829	.2286	.2058	.2561	.2195	.2195	1.7193
21	.1829	.1905	.1715	.2195	.2195	.2195	.1886
22	.1829	.1905	.1715	.2195	1.3535	.2195	.1829
23	.1509	.1524	.7888	.1829	.1463	.2195	.1829
24	.1029	.1463	.9572		.9511	.8048	.7682
Max	2.2634	2.0165	.9572	2.7435	1.9387	1.6461	2.0851
Min	.0732	.1463	.1029	.0732	.1097	.1097	.1829
Avg	.7554	.7391	.2099	.5822	.6512	.6022	1.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 303 / Kudal Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5853	.6283	.5853	.6219	.5853	.5853
2	.6219	.5853	.5601	.5853	.5853	.6584	.695
3	.6584	.5853	.5601	.6584	.5853	.8048	.5853
4	.7316	.5853	.5975	.7316	.6219	.8779	.5853
5	.8779	.5853	.7392	.8048	.6219	.9511	.5853
6	1.0608	.8413	1.0136	1.0242	.9145	1.0242	.9877
7	1.3535	1.134		1.3535	1.2437	1.2437	1.39
8	1.39		1.3611	1.3535	1.4632	1.3169	1.39
9	1.4998	1.39	1.3756	1.3535	1.3535	1.2071	1.39
10	1.39	1.0562	1.1203	1.0974	1.134	1.1706	1.2437
11	1.3169	1.1843	.9922	1.2071	1.0242	1.0974	1.2437
12	1.134	1.0883	1.1706	1.0242	.9877	.9877	1.0974
13	1.134	.8322	1.0242	.9511	.9511	.8779	.9877
14		.8642	1.0242	.9511	.9145	.8413	.8413
15	.9511	.9282	1.0974	.9145	1.0242	.9145	.9877
16	1.134	1.0562	1.0608	.9511	1.0242	.8779	1.0242
17	1.3169	1.1843	1.2437	1.0608	.9877	1.0608	
18	1.1706	1.4842	1.0974	1.134	1.1706	.9877	1.2071
19	1.5729	1.5203	1.3169	1.39	1.3169	1.39	1.4998
20	1.4632	1.5203	1.3535	1.39	1.3535	1.3535	1.5364
21	1.2803		1.2071	1.2437	1.1706	1.2071	1.39
22	1.0974	1.0974	1.0608	.9877	.9511	1.0608	1.1706
23	.7682	.8779	.6219	.7682	.7682	.8048	.9145
24	.6219	.6219	.6653		.6219	.5853	.6219
Max	1.5729	1.5203	1.3756	1.39	1.4632	1.39	1.5364
Min	.5853	.5853	.5601	.5853	.5853	.5853	.5853
Avg	1.0926	.9822	.9953	1.0227	.9755	.9953	1.0417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 304 / KUDAL AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.3169	1.3611	.1029	.0762	.0686	.0754
2	1.5775	1.3169	1.3394	.1029	.0762	.0686	.0754
3	1.6461	1.3169	1.3394	.1029	.0762	.0686	.0732
4	1.6461	1.3169	1.3253	.1029	.0762	.0686	.0732
5	1.7147	1.3169	1.3756	.1029	.0762	.1029	.0754
6	1.8519	1.5364	1.4685	.1372	.1143	.1029	.0732
7	2.0576	1.829	1.6476	.1372	.1143	.1029	
8	2.332		1.7295	.1029	.1143	.1029	.0732
9	2.4348	2.4874	1.8427	.0686	.096	.064	.0732
10		.064	.096	.064	.096	.064	.064
11	.0754	.064	1.4083	2.2405	1.9845	1.8244	.064
12	.0754	.064	2.0485	2.4006	2.4326	2.0805	.096
13	.0732	.096	2.2405	2.4006	2.5286	2.2725	.096
14	.0732	.064	2.2725	2.3045	2.4006	2.1125	.064
15	.0732	.064	2.4326	2.2725	2.4326	2.1125	.064
16	.0732	.064	2.3365	2.1445	2.2405	1.9204	.064
17	.0754	.064	2.0485	2.0165	2.2725	2.0851	.1143
18	.0732	.0762	1.7833	2.0683	2.0919	1.829	.1524
19	.0732	.1143	.1029	.1143	.0686	.0754	.0762
20	.0732	.1143	.1029	.1143	.0686	.0754	.1143
21	.0732	.0762	.0686	.1143	.0686	.0754	.1143
22	.0754	.0762	.1029	.1143	.0686	.0732	.1143
23	.0754	.1143	.1029	.0762	.0686	.0754	.1143
24	.0686	1.3169	1.3969	.1029	.0762	.0686	.0732
Max	2.4348	2.4874	2.4326	2.4006	2.5286	2.2725	.1524
Min	.0686	.064	.0686	.064	.0686	.064	.064
Avg	.7754	.6465	1.3322	.8129	.8216	.7289	.0860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 305 / KARHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3292	.3429	.3292	.3048	.3292	.3658
2	.2926	.3292	.3048	.2926	.3048	.2926	.3662
3	.3292	.3292	.2667	.3292	.3048	.3292	.3658
4	.3658	.3292	.2667	.3658	.3429	.3658	.3658
5	.439	.3292	.3048	.439	.3429	.439	.4024
6	.5121	.4024	.4191	.5121	.4191	.5121	.439
7	.6584	.6219	.5601	.5853	.5975	.6584	.6584
8	.7316	.8048	.6283		.7392	.5853	.7316
9	.8413	.7682	.7762	.8048	.6081	.6081	.7682
10	.8048	.7362	.6401	.7042	.6401	.6081	.6081
11	.9511	.7682	.7362	.7682	.6081	.6401	.7042
12	.7316	.7042	.6401	.6722	.5441	.5441	.5761
13	.695	.6081	.4481	.5761	.5441	.5121	.5121
14	.6584	.6401	.5121	.5441	.4801	.4801	.5121
15	.6219	.6401	.5441	.6081	.4801	.4801	.5121
16	.7682	.6722	.6722	.6081	.4801	.5441	.5121
17	.9145	.7682	.8002	.7042	.6401	.1376	.8131
18	.7682	.9145	.9511	.9145	.7682	.695	.9511
19	.9145	.8779	.8779	.9877	.8413	.8779	.9145
20	.8048	.7762	.8413	.8413	.8413	.8413	.8131
21	.6584	.7023	.7316	.7023	.7316	.7316	.7023
22	.5487	.5228	.5853	.5601	.5487	.6219	.5601
23	.439	.415	.439	.4481	.4755	.4755	.4527
24	.4024	.3292	.3429	.4024	.3429	.4024	.3658
Max	.9511	.9145	.9511	.9877	.8413	.8779	.9511
Min	.2926	.3292	.2667	.2926	.3048	.1376	.3658
Avg	.6325	.5966	.5680	.5956	.5388	.5297	.5822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / 33/22 KV PANCHGANI

Feeder No / Name : 301 / 22 KV BHILAR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6219	.7468	.724	.6348	.6413	.6584
2	.4801	.6036	.6878	.695	.5975	.6036	.6653
3	.4458	.5975	.6722	.695	.5601	.5658	.6283
4	.4458	.5914	.6722	.695	.5601	.5658	.6283
5	.4801	.5731	.6722	.7167	.5601	.5601	.7316
6	.6859	.7087	1.0387	.8779	.8779	.9054	.8131
7	1.3717	1.2346	1.531	1.3535	1.2346	1.3817	1.3535
8	1.7147	1.7878	1.7147	1.9753	1.6095	1.7177	1.7924
9	1.6827	1.7909	1.8313	1.9753	1.7737	1.7177	1.829
10	1.6095	1.7147	1.6095	1.8671	1.6827	1.5089	1.7177
11	1.6095	1.2346	1.4403	1.7924	1.6095	1.4754	1.5684
12	1.39	1.2346	1.3969	1.4563	1.4266	1.0631	1.419
13	1.2308	1.0974	1.2452	1.1203	1.1706	1.0288	1.3203
14	1.1706	.9602	1.2536	.7842	1.1706	1.0517	1.1576
15	1.0974	1.1317	1.1568	1.1694	1.2071	1.086	.8676
16	1.2437	1.1317	1.4403	1.4937	1.3535	1.0867	1.2696
17	1.5364	1.3032	1.8671	1.7924	1.4998	1.2971	1.5684
18	1.6118	1.8983	1.9022	1.7551	1.6804	1.7558	1.6827
19	1.6476	1.9547	2.0119	1.6834	1.8671	1.829	
20	1.448	1.6118	1.6827	1.5592	1.643	1.4998	1.3169
21	1.2071	1.4327	1.5364	1.2178	1.3817	1.2803	1.1706
22	1.0974	1.1827	1.39	.9774	1.1203	1.0608	1.2071
23	.7164	.8779	1.0974	.7095	.7922	.8413	.924
24	.7545	.7095	.7842	.8413	.7095	.679	.7316
Max	1.7147	1.9547	2.0119	1.9753	1.8671	1.829	1.829
Min	.4458	.5731	.6722	.695	.5601	.5601	.6283
Avg	1.1330	1.1661	1.3076	1.2470	1.1968	1.1335	1.1748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / 33/22 KV PANCHGANI

Feeder No / Name : 302 / PACHGANI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5609	.583	.9145	.7888	.9054	.8413
2	.6173	.5258	.583	.924	.7545	.8299	.7762
3	.5487	.5373	.5548	.9145	.7362	.7922	.8131
4	.5487	.5258	.5609	.924	.7362	.7922	.8131
5	.583	.5258	.5609	.9511	.7522	.7922	.924
6	.823	.8505	.8954	1.1088	.9922	1.0829	1.0974
7	1.0974	.9816	1.2403	1.3756	1.4327	1.5089	1.5729
8	1.0974	1.086	1.1946	1.7737	1.3756	1.5684	1.5524
9	1.086	1.0029	1.0387	1.7737	1.2536	1.4937	1.2437
10	1.0242	.9602	1.0517	1.7924	1.5203	1.2003	1.419
11	1.0136	.9602	1.0867	1.643	1.3032	1.2136	1.3443
12	.9412	.9602	.9393	1.4937	1.267	.9709	1.2696
13	.7964	.7202	.9114	1.3443	1.134	.9114	1.2323
14	.7316	.6859	.8779	1.2071	.9412	.8764	1.1949
15	.8688	.6859	.8596	1.2449	1.182	.9114	1.2071
16	.8688	.7202	1.4327	1.2696	1.2071	.9313	1.2323
17	.7964	1.0288	1.4784	1.2071	1.3169	1.1462	1.2696
18	1.0745	1.0387	1.3032	1.2803	1.4937	1.2437	1.2437
19	1.1568	1.3321	1.6651	1.5089	1.6804	1.5927	1.39
20	1.0745	1.2536	1.7375	1.166	1.643	1.6289	1.5203
21	.9313	1.0387	1.5729	1.326	1.5844	1.6095	1.4842
22	.823	.8916	1.448	1.073	1.3817	1.3394	1.3169
23	1.2292	.7964	1.2803	.9602	1.2071	1.134	1.1088
24	1.1774	.583	.7545	1.0136	.9145	.9709	.9145
Max	1.2292	1.3321	1.7375	1.7924	1.6804	1.6289	1.5729
Min	.5487	.5258	.5548	.9145	.7362	.7922	.7762
Avg	.8984	.8438	1.0671	1.2579	1.1916	1.1436	1.1992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / 33/22 KV PANCHGANI

Feeder No / Name : 303 / WATER SUPPLY

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.112	.112	.1463	.1463	.1132	.112
2	.0686	.112	.112	.1097	.112	.1132	.1132
3	.0686	.0747	.1132	.1097	.1097	.112	.1132
4	.0686	.0716	.112	.1097	.112	.1132	.112
5	.1029	.0724	.112	.1463	.1075	.1132	.1478
6	.2058	.0709	.2172	.2195	.2149	.1886	.1867
7	.3429	.3506	.4207	.2957	.3258	.3734	.2587
8	.2743	.4298	.4207	.3696	.4207	.3361	.3326
9	.2957	.4298	.4458	.4024	.3856	.2987	.4066
10	.2218	.4115	.3582	.3361	.1848	.2743	.2614
11	.2218	.1372	.3155	.2614	.2218	.2804	.2241
12	.2195	.1372	.2683	.2241	.2195	.2743	.2263
13	.1791	.2058	.2058	.1886	.1848	.2103	.1886
14	.2507	.2058	.2241	.1509	.1829	.1753	.1494
15	.1829	.2058	.2103	.1494	.1463	.1791	.1509
16	.0732	.2058	.2149	.2263	.1463	.1791	.1494
17	.2865	.2058	.2957	.2241	.1848	.2507	.2263
18	.1433	.2454	.2957	.3772	.2641	.2587	.2218
19	.3582	.3506	.4066	.4115	.3734	.2587	.2957
20	.4298	.4252	.3326	.4115	.3361	.2587	.3734
21	.3582	.3856	.2896	.3506	.3018	.2218	.3292
22	.2865	.3361	.2587	.2865	.2263	.1848	.2241
23	.1791	.1867	.1829	.2241	.1867	.1478	.112
24	.1372	.1433	.1494	.1829	.1494	.1509	.1109
Max	.4298	.4298	.4458	.4115	.4207	.3734	.4066
Min	.0686	.0709	.112	.1097	.1075	.112	.1109
Avg	.2108	.2297	.2531	.2464	.2185	.2111	.2094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / 33/22 KV PANCHGANI

Feeder No / Name : 304 / 22 KV DANDEGHAR

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2172	.2926		.0373	.0377	
2	.1715	.1867	.2561		.0373	.0377	
3	.2401	.1867	.2149		.0373	.0377	
4	.2401	.1867	.2218		.0373	.0377	
5	.2401	.1829	.2126		.0373	.0377	
6	.3086	.2987	.4557		.0347	.0747	
7	.4115	.3982	.5228		.0351	.0747	
8	.3772	.4298	.543		.0358	.0754	
9	.3224	.362	.4207		.0362	.1132	
10	.3696	.3429	.4298	.0747		.0373	.0754
11	.3326	.3429	.4115	.0747		.0354	.0754
12	.2926	.3429	.4207	.0747		.0362	.0373
13	.2561	.2743	.3856	.0747		.0373	.0377
14	.2507	.2743	.3582	.0754		.0373	.0747
15	.2957	.2743		.0377		.0358	.0377
16	.2896	.3086		.0747		.0362	.0747
17	.2865	.3429		.0747		.0358	.0377
18	.2865	.3506		.0343	.0754		
19	.3582	.4298		.0343	.0747		
20	.362	.394		.0343	.0747		
21	.2987	.3856		.0343	.0754		
22	.2896	.4108		.0358	.0373		
23	.2614	.3734		.0373	.0377		
24	.2058	.2534	.3361			.0754	
Max	.4115	.4298	.543	.0754	.0754	.1132	.0754
Min	.1715	.1829	.2126	.0343	.0347	.0354	.0373
Avg	.2883	.3146	.3655	.0551	.0469	.0496	.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 301 / SURUR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.2915	.3795
2	.0377	.0754	.0377	.0377	.0377	.2881	.3841
3	.0377	.1132	.0377	.0377	.0377	.2949	.3841
4	.0377	.0377	.0377	.0377	.0377	.2915	.3749
5	.0377	.0377	.0377	.0377	.0377	.3201	.4687
6	.0377	.0377	.0377	.0377	.0377	.3605	.5376
7	.0377	.0377	.0377	.0377	.0377	.5506	.9282
8	.0377	.0377	.0377	.0377	.0377	1.0364	1.1873
9	.0377	.0377	.0377	.0377	.0377	1.1523	1.2955
10	.0377	1.3443	.0377	.0377	.0377	.0377	.0377
11	1.0364		1.1012	1.2308	.0377		.0377
12	1.1012	1.6644	1.5043	1.2308	.0377	.0377	.0377
13	1.2955	1.6248	1.4864	1.2955	.0377	.0377	.0377
14	1.4251	1.6446	1.358	1.3603	.0377	.0377	.0377
15	1.4899	1.5813	1.358	1.4373	.0377	.0377	.0377
16	1.1336	1.4998	1.3748	1.3748	.0377	.0377	.0377
17	1.166	1.4198	1.4232	1.3123	.0377	.0377	.0377
18	.9717	1.1584	1.1385	1.1248	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0754	.0377	.0377	.0377	.0377	.0377
21	.0377	.0754	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.037	.0377	.0377	.0377
23	.0377	.0377	.0377	.0373	.2241	.3437	.4428
24	.0377	.0377	.0377	.0377	.0377	.2915	.4111
Max	1.4899	1.6644	1.5043	1.4373	.2241	1.1523	1.2955
Min	.0377	.0377	.0377	.037	.0377	.0377	.0377
Avg	.4259	.5518	.4728	.4570	.0455	.2467	.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 302 / NEW KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.3163	.3841	.3163	.0377	.0377
2	.0377	.0377	.3749	.3704	.3163	.0377	.0377
3	.0377	.0377	.3704	.3795	.3163	.0377	.0377
4	.0377	.0377	.3932	.4161	.3163	.0377	.0377
5	.0377	.0377	.4428	.4858	.3479	.0377	.0377
6	.0377	.0377	.4999	.5898	.3795	.0377	.0377
7	.0377	.0377	.8124	.9922	.7773	.0377	.0377
8	.0377	.0377	1.2803	1.2163	.9717	.0377	.0377
9	.0377	.0377	1.3603	1.2163	.9831	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	1.1012	.0377	.0377	.0377	1.2631	1.0364	1.1012
12	1.2826	.0377	.0377	.0377	1.3763	1.2163	1.2163
13	1.166	.0377	.0377	.0377	1.2803	1.2803	1.2651
14	1.2308	.0377	.0377	.0377	1.278	1.2018	1.2498
15	1.166	.0377	.0377	.0377	1.2308	1.0311	1.2018
16	1.2308	.0377	.0377	.0377	1.1469	1.0753	1.0883
17	1.1012	.0377	.0377	.0377	1.1203	1.0669	.9259
18	.8421	.0377	.0377	.0377	.9922	.8642	.8535
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.037	.0377	.0377	.0377
23	.0377	.3239	.0377	.0373	.0377	.0377	.0377
24	.0377	.0377	.3201	.421	.3932	.0377	.0377
Max	1.2826	.3239	1.3603	1.2163	1.3763	1.2803	1.2651
Min	.0377	.0377	.0377	.037	.0377	.0377	.0377
Avg	.4052	.0496	.2791	.2916	.6263	.3906	.3960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 303 / NEW KENJAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2263	.2263	.2263	.1886	.2263
2	.2641	.1886	.2263	.2263	.1886	.1886	.2263
3	.2641	.1886	.2263	.2263	.1886	.1886	.1886
4	.2641	.1886	.2641	.2263	.1886	.1886	.1886
5	.2641	.1886	.2641	.2641	.1886	.2263	.2641
6	.3018	.2263	.3018	.3018	.3395	.3018	.3018
7	.3395	.3018	.3395	.3395	.3395	.3395	.3395
8	.3395	.3395		.3395	.3772	.3395	.3395
9	.3395	.4527	.5281	.5281	.3018	.3018	.3018
10	.3395	.4527	.4527	.2641	.2641	.2641	.3772
11	.415	.3772	.3018	.3018	.3018	.2263	.415
12	.3772	.415	.3395	.3018	.3772	.2263	.3395
13	.3395	.2263	.2263	.2263	.2263	.2263	.2263
14	.3018	.2263	.2263	.1886	.2263	.2263	.2263
15	.1886	.1886	.3395	.2641	.3395	.2263	.3018
16	.3018	.1886	.3772	.3018	.2263	.2641	.3772
17	.3395	.3395	.415	.3018	.2641	.2263	.3395
18	.2641	.3772	.2641	.2641	.2641	.2263	.2263
19	.3395	.3395	.3395	.3395	.3395	.3018	.3018
20	.3772	.3772	.3772	.3772	.3772	.3772	.3772
21	.3772	.3772	.3772	.3395	.3395	.3395	.3772
22	.3018	.3018	.034	.3395	.3018	.3395	.3395
23	.2641	.2641	.2641	.2641	.2641	.2641	.2641
24	.2641	.2641	.2641	.2641	.2641	.2263	.2641
Max	.415	.4527	.5281	.5281	.3772	.3772	.415
Min	.1886	.1886	.034	.1886	.1886	.1886	.1886
Avg	.3097	.2939	.3033	.2924	.2798	.2593	.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 304 / SURUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.2263	.2641	.2641	.2641	.2641
2	.2263	.2263	.2263	.2263	.2641	.2641	.2641
3	.2263	.2263	.2263	.2263	.2263	.2263	.2263
4	.2263	.2263	.2641	.2263	.2263	.2263	.2263
5	.2641	.2263	.2641	.2641	.2263	.2641	.2641
6	.3018	.2641	.3395	.3018	.3018	.3018	.3018
7	.415	.3772	.415	.3772	.3018	.415	.415
8	.415	.415	.4527	.415	.4527	.415	.4527
9	.415	.415	.415	.415	.415	.3772	.3772
10	.3772	.415	.415	.3395	.415	.3772	.3772
11	.3395	.3772	.3772	.3395	.3772		.3772
12	.3395	.3395	.3018	.3395	.3018	.3395	.3772
13	.3018	.3018	.3395	.3395	.3018	.3395	.3395
14	.3018	.3018	.3018	.3018	.3018	.3395	.3395
15	.3018	.3395	.3018	.3018	.3018	.3018	.3395
16	.2641	.3772	.3395	.3395	.3018	.3018	.3018
17	.3018	.3018	.3395	.3395	.2641	.3018	.3018
18	.3395	.3395	.3395	.3395	.3395	.3018	.3395
19	.5658	.4904	.4904	.5658	.5658	.415	.415
20	.5658	.5281	.5658	.6036	.5658	.4527	.4904
21	.5281	.4904	.3772	.5281	.5281	.4904	.4904
22	.415	.415	.4527	.4904	.4527	.4527	.4527
23	.3395	.3395	.3772	.415	.3772	.3395	.3772
24	.2641	.2641	.2641	.3018	.3018	.3018	.3018
Max	.5658	.5281	.5658	.6036	.5658	.4904	.4904
Min	.2263	.2263	.2263	.2263	.2263	.2263	.2263
Avg	.3442	.3477	.3505	.3584	.3489	.3395	.3505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 305 / OZARDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3018	.2641	.2641	.2263	.2641	.3018
2	.2641	.1886	.2641	.2641	.2263	.2641	.2641
3	.2641	.1886	.2641	.2641	.2263	.2641	.2641
4	.2641	.1886	.3018	.2641	.2263	.2641	.2641
5	.3772	.1886	.3772	.3018	.3018	.3772	.415
6	.5281	.2641	.4904	.4904	.5281	.5658	.5281
7	.7167	.7167	.679	.679	.7167	.7167	.679
8	.7167	.7545	.679	.7167	.679	.7167	.8299
9	.4904	.679	.6036	.6413	.6036	.6413	.6036
10	.5658	.6036	.5281	.6036	.4904	.5658	.5281
11	.4527	.4904	.5281	.6036	.4904	.5658	.4527
12	.4527	.5658	.4904	.6413	.4527	.5281	.415
13	.4024	.4527	.415	.6036	.3772	.415	.3772
14	.415	.4527	.3772	.3772	.3395	.3395	.3772
15	.415	.4904	.3018	.3018	.3018	.3395	.3772
16	.415	.4904	.3395	.3018		.3772	.3772
17	.3772	.6036	.3772	.3395	.3395	.3772	.4527
18	.4904	.4904	.415	.415	.4904	.4527	.6036
19	.7167	.679	.6036	.3395	.8299	.679	.679
20	.7167	.6413	.7167	.6036	.8299	.7167	.7922
21	.6036	.6036	.6413	.5658	.6413	.6413	.6413
22	.4904	.4527	.5658	.3772		.6036	.6036
23	.3772	.3395	.3772	.3772	.415	.415	.415
24	.3018	.3018	.3018	.3018	.2641	.3018	.3395
Max	.7167	.7545	.7167	.7167	.8299	.7167	.8299
Min	.2641	.1886	.2641	.2641	.2263	.2641	.2641
Avg	.4616	.4637	.4543	.4433	.4544	.4747	.4826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 201 / 11 KV WAI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6194	1.3336	2.0767	1.9427	1.7147	1.2955
2	1.4712	1.3336	1.2384	1.9814	1.9616	1.5242	1.2955
3	1.4712	1.2955	1.2384	1.8671	1.9616	1.3336	1.2384
4	1.4523	1.2384	1.3336	1.9433	1.9616	1.3336	1.2384
5	1.3957	1.3336	1.3336	1.9624	1.9616	1.5242	1.2765
6	1.3392	1.3336	1.4289	2.0195	1.7353	1.6194	1.1622
7	1.6598	1.6575	1.5242	2.0386	2.2257	1.5242	1.2765
8	1.9805	1.2384	1.6194	2.1529	2.4331	1.2384	1.7909
9	2.2862	1.7147	2.2672	2.6406	2.2862	1.2765	2.0195
10	2.8006	2.0957	2.6101	2.7915	2.0957	1.3336	2.3815
11	2.8006	1.9052	2.6673	2.7915	1.9052	1.3527	2.7625
12	2.5149	1.8671	2.9531	2.3954	2.0957	1.3527	2.4768
13	2.6673	1.8099	2.5911	2.5652	2.3815	1.3336	2.2862
14	2.7435	1.8099	2.5149	2.9047	2.2862	1.2193	2.553
15	2.6482	1.7147	2.3243	2.8858	2.3815	1.2193	2.4387
16	2.4958	1.6766	2.7625	2.6406	2.4768	1.3908	2.4768
17	2.4006	1.7147	2.7625	2.9047	2.2862	1.1622	2.6863
18	.6287	1.7147	2.7816	2.5274	2.4768	1.2193	2.2291
19	2.0195	1.5242	2.553	2.5463	2.2862	1.2765	2.1719
20	1.9052	1.4289	2.3053	2.452	2.0957	1.2193	1.9433
21	2.0005	1.5242	1.9052	1.7918	1.8099	1.2193	1.9624
22	2.1148	1.5242	2.0386	1.7918	1.7147	1.2193	1.7909
23	2.0957	1.7147	2.4196	2.1691		1.2765	2.21
24	1.5278	1.6956	1.5242	2.1148	1.8861	2.0005	1.3336
Max	2.8006	2.0957	2.9531	2.9047	2.4768	2.0005	2.7625
Min	.6287	1.2384	1.2384	1.7918	1.7147	1.1622	1.1622
Avg	1.9970	1.6035	2.0846	2.3315	2.1151	1.3702	1.9290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 202 / 11 KV MANDHARDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	.0175
Max	.0175
Min	.0175
Avg	.0175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 203 / 11 KV WAI NAGARPALIKA PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0753	.0762	.0602	.0781	.0762	.0602
2	.0937	.0602	.0762	.0602	.0781	.0762	.0602
3	.0937	.0602	.0762	.0602	.0937	.0762	.0602
4	.0937	.0753	.0762	.0602	.0937	.0762	.0602
5	.1094	.0903	.0762	.0753	.0937	.0953	.0753
6	.1094	.1054	.0953	.0753	.1094	.0953	.0753
7	.0781	.0753	.0953	.0753	.1094	.0953	.0753
8	.0781	.0753	.0953	.0753	.0625	.0953	.0753
9	.0753	.0953	.0753	.1094	.0953	.0753	.0753
10	.0903	.0953	.0753	.0937	.0953	.0753	.0753
11	.0753	.0953	.0602	.1094	.0953	.6923	.0753
12	.0753	.0953	.0753	.0937	.0953	.0602	.0753
13	.0753	.0953	.0602	.0625	.0953	.0753	.0753
14	.0753	.0953	.0602	.0781	.0953	.0753	.0753
15	.0753	.0953	.0762	.0625	.0953	.0753	.0753
16	.0602	.0953	.0753	.0781	.0953	.0753	
17	.0452	.0953	.0753	.0625	.0953	.0753	.0753
18	.0301	.0953	.0602	.0781	.0953	.0753	.0753
19	.0602	.0953	.0602	.0937	.0953	.0753	.0753
20	.0903	.0953	.0753	.0781	.0953	.0753	.0753
21	.0753	.0953	.0753	.0781	.0953	.0753	.0753
22	.0753	.0953	.0753	.0625	.0953	.0753	.0753
23	.0753	.0953	.0753	.0781		.0753	.0753
24	.0781	.0753	.0953	.0753	.0791	.0953	.0753
Max	.1094	.1054	.0953	.1094	.1094	.6923	.0753
Min	.0301	.0602	.0602	.0602	.0625	.0602	.0602
Avg	.0778	.0884	.0757	.0765	.0927	.1047	.0727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 204 / 11 KV MAPRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1143	.0762	.2286	.2829	.2286	.1334
2	.2641	.0762	.0762	.2286	.2829	.1905	.1334
3	.2641	.0953	.0762	.2477	.2641	.1905	.1334
4	.2641	.0953	.0762	.2477	.2641	.1905	.1143
5	.2641	.1143	.1143	.2286	.2641	.2286	.1143
6	.2263	.1334	.1143	.2286	.2452	.2286	.1143
7	.1509	.1143	.1524	.2667	.2829	.2667	.0953
8	.0754	.0191	.2858	.2858	.2829	.1143	.0953
9	.0762	.1905	.2286	.3584	.2667	.0191	.0381
10	.2286	.2286	.2096	.2452	.2667	.2096	.0953
11	.2858	.1905	.2286	.2263	.2477	.3048	.1715
12	.2667	.1905	.2286	.2075	.2286	.3429	.1905
13	.2477	.1905	.1905	.1886	.2286	.2667	.2096
14	.2477	.1715	.1905	.2263	.1905	.2286	.0953
15	.1715	.1524	.2096	.3584	.2667	.2096	.1524
16	.1334		.4001	.3395	.3048	.1143	.1524
17	.0572	.1143	.4191	.4338	.381	.0381	.1905
18	.0762	.1143	.4001	.4715	.4382	.1334	.2286
19	.0762	.1524	.3429	.415	.381	.1143	.2858
20	.1334	.1715	.3048	.3395	.3429	.1143	.2286
21	.1334	.1715	.2858	.3206	.3239	.1143	.2286
22	.1334	.1524	.2858	.3395	.3048	.1143	.2667
23	.1334	.1524	.3048	.3109		.0953	.2667
24	.2829	.1143	.1143	.2667	.3018	.3048	.1143
Max	.2858	.2286	.4191	.4715	.4382	.3429	.2858
Min	.0572	.0191	.0762	.1886	.1905	.0191	.0381
Avg	.1865	.1400	.2215	.2921	.2888	.1818	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 205 / 11 KV MANDHARDEV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1478	.1905	.1663	.1646	.1905	.1848
2	.1646	.1478	.1524	.1478	.1646	.1905	.1478
3	.1646	.1478	.1524	.1478	.1646	.1905	.1478
4	.1646	.1848	.1905	.1478	.1646	.2286	.1478
5	.2012	.2033	.2286	.1848	.2012	.2667	.1848
6	.2926	.3696	.3239	.2772	.3292	.3048	.2772
7	.4572	.462	.381	.4435	.4207	.3429	.4066
8	.439	.4435	.4572	.462	.4755	.4382	.4435
9	.3881	.381	.3696	.3841		.3142	.3696
10	.3142	.3048	.2957	.3109	.3429	.2772	.2957
11	.3142	.2286	.2587	.3109	.3048	.2402	.2402
12	.2957	.2286	.2218	.2378	.2667	.2218	.2033
13	.2033	.2286	.2218	.2378	.2477	.2218	.1848
14	.2033	.2096	.2218	.2378	.2286	.1848	.2033
15	.1663	.2286	.1848	.2195	.2667	.1848	.2033
16	.1848	.2286	.2218	.1829	.3048	.2033	.2218
17	.2402	.2667	.2587	.2743	.3048	.2218	.2402
18	.2587	.2858	.2402	.2926	.3239	.2587	.3142
19	.4066	.381	.4435	.3658	.4572	.4435	.462
20	.4572	.5335	.4805	.4207	.4191	.462	.462
21	.381	.381	.462	.4024	.4191	.4066	.4805
22	.3239	.3048		.3475	.381	.3696	.3326
23	.2096	.2667	.2587	.2195		.2772	.2402
24	.1646	.1663	.1905	.2033	.1829	.1905	.2218
Max	.4572	.5335	.4805	.462	.4755	.462	.4805
Min	.1646	.1478	.1524	.1478	.1646	.1848	.1478
Avg	.2733	.2805	.2785	.2760	.2971	.2763	.2757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 301 / 22 KV DHAGE ALI (WAI CITY
ALT) Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3048	.3048	.2667	.3292	.3048	.3048
2	.2561	.3048	.3048	.2667	.3292	.3048	.3048
3	.2561	.3048	.3048	.2286	.3292	.3048	.3048
4	.2561	.3429	.3048	.2667	.3292	.3048	.3048
5	.2926	.3429	.381	.3048	.3292	.381	.381
6	.4024	.4191	.4954	.381	.4024	.381	.4572
7	.5853	.6478	.6097	.4572	.5487	.5335	.5716
8	.7316	.8002	.8002	.7621	.695	.7621	.6859
9	.8383	.7621	.7621	.8413	.6097	.724	.724
10	.8383	.7621	.724	.8048	.6097	.6097	.6859
11	.724	.7621	.6859	.6584	.6097	.6097	.724
12	.3048	.7621	.7621	.5487	.5335	.6097	.6859
13	.6478	.8383	.6859	.5487	.5335	.4572	.6097
14	.5716	.8002	.6478	.3292	.5335	.5335	.5716
15	.6478	.7621	.6478	.3658	.5335	.4572	.6097
16	.6478	.7621	.4572	.4024	.6097	.4572	.6097
17	.724	.7621	.6478	.695	.6097	.5716	.6478
18	.724	.724	.7621	.695	.6859	.6478	.6859
19	.8002	.7621	.7621	.7316	.7621	.8002	.724
20	.724	.8002	.7621	.7682	.7621	.8002	.7621
21	.6478	.6859	.6478	.7682	.6859	.6859	.7621
22	.5716	.5335	.6097	.6219	.6097	.6097	.6097
23	.4191	.4572	.4572	.4755		.4572	.4954
24	.3292	.3429	.381	.3048	.3658	.381	.381
Max	.8383	.8383	.8002	.8413	.7621	.8002	.7621
Min	.2561	.3048	.3048	.2286	.3292	.3048	.3048
Avg	.5499	.6144	.5795	.5206	.5368	.5287	.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 302 / 22 KV MENAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4435	.4572	.4435	.5121	.5335	.4435
2	.4024	.4191	.381	.3696	.5121	.4572	.4066
3	.4024	.4066	.381	.3696	.5121	.4572	.4066
4	.4024	.4805	.381	.3696	.5121	.4572	.4066
5	.4024	.5175	.4572	.4066	.5121	.5335	.4435
6	.5487	.6283	.6859	.5544	.6584	.6097	.5914
7	.8413	.9979		.8501	1.0974	.8383	.8871
8	1.0242	1.1088	1.2955	1.0719	1.2437	1.0669	1.0349
9	.8131	1.1431	1.1088	1.0242	1.1431	.9979	1.0349
10	.8501	1.105	1.0719	1.0608	1.0669	.9979	.961
11	.8131	.9907	1.1088		.9907	.8871	.961
12	.9979	.9145	.9979		.9145	.8131	.8871
13	.924	.8383	.924	1.0608	.8383	.7762	.8131
14	.8501	.8002	.8501	.9145	.7621	.7392	.7392
15	.924	.9145	.6653	.8413	.7621	.4805	.7762
16	.924	.9145	.7023	.8413	.8383	.6653	.8131
17	.961	.9145	.8871	1.0608	.9145	.7762	.924
18	1.0349	.9907	.924	1.2437	1.0669	.961	1.1088
19	1.4045	1.448	1.4045	1.4998	1.3717	1.3676	1.4784
20	1.4415	1.6004	1.6632	1.6461	1.5242	1.4784	1.5524
21	1.2197	1.3717	1.4415	1.4632	1.4098	1.2567	1.4415
22	.961	.9145	1.1088	1.2071	1.1431	.9979	1.1827
23	.6283	.724	.7392	.7682		.6653	.7023
24	.4755	.4805	.5335	.5544	.5487	.6097	.5175
Max	1.4415	1.6004	1.6632	1.6461	1.5242	1.4784	1.5524
Min	.4024	.4066	.381	.3696	.5121	.4572	.4066
Avg	.8187	.8778	.8769	.8919	.9067	.8093	.8547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 303 / 22 KV PASARNI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	.1063	.1143	.1075	.1063	1.1431	.8596
2	.1063	.1063	.1143	.1075	.1063	.9907	.8954
3	.1063	.1063	.1143	.1075	.1063	.9145	.8954
4	.1063	.1063	.1143	.1075	.1063	.9145	.9313
5	.1063	.1063	.1524	.1433	.1063	.9907	1.0029
6	.1417	.1063	.1524	.1433	.1063	1.2955	1.0745
7	.1417	.1417	.1524	.1433	.1417	1.6766	1.5402
8	.1417	.1417	.1524	.128	.1417	1.5242	1.7551
9	.1417	.1524	.1433	.1063	.1524	1.7909	1.6301
10	.1417	.1524	.1433	.1063	.1524	.1433	.1417
11	3.2247	3.0483	3.0803		.1524	.1433	.1417
12	3.7209	3.3532	3.1878		.1524	.1433	.1417
13	3.7917	3.4294	3.1161	2.8121	.1524	.1433	.1417
14	3.65	3.5056	3.0803	2.8121	.1524	.1433	.1417
15	3.3311	3.4294	2.7221	2.7435	.1524	.1433	.1417
16	2.8349	3.3532	2.0416	2.6406	.1524	.1433	.1417
17	2.7286	3.0483	2.4356	2.6063	.1524	.1433	.1417
18	2.3388	2.8959	2.3998	2.2977	.1524	.1433	.1417
19	.1417	.1524	.1433	1.0867	.1524	.1433	.1417
20	.1417	.1524	.1433	.1417	.1524	.1433	.1417
21	.1417	.1524	.1433	.1417	.1524	.1433	.1433
22	.1417	.1524	.1433	.1063	.1524	.1433	.1433
23	.1417	.1524	.1433	.1063		.1433	.1417
24	.1063	.1417	.1524	.1433	.1063	1.5242	.8596
Max	3.7917	3.5056	3.1878	2.8121	.1524	1.7909	1.7551
Min	.1063	.1063	.1143	.1063	.1063	.1433	.1417
Avg	1.1531	1.1747	1.0119	.8563	.1374	.6155	.5596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 401 / 33 KV PACHGANI

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4883	1.6575	1.7147	2.0005	1.7558	1.829	1.829
2	1.4352	1.5432	1.7147	1.829	1.701	1.7147	1.6004
3	1.4352	1.5432	1.7147	1.6004	1.5947	1.6004	1.6004
4	1.4352	1.6575	1.9433	1.7147	1.5947	1.6004	1.829
5	1.4352	1.829	2.0576	1.829	1.5947	1.829	1.9433
6	1.9667	2.3434	2.4006	2.2291	2.073	2.1719	2.1148
7	2.8172	3.315	3.1436	3.0864	2.9767	2.4006	3.0864
8	3.5082	3.7723	4.0009	4.2295	3.5082	3.4865	3.7151
9	3.4294	3.658	4.0009	3.774	3.4294	3.4294	4.9154
10	3.2579	3.4865	3.8866	3.6677	3.315	3.3722	3.3722
11	3.315	3.2007	3.4294	3.4019	3.0864	2.9721	7.4303
12	2.8006	2.9721	3.4294	2.8704	2.8578	2.8006	2.7435
13	2.6292	2.8578	3.2007	2.4983	2.572	2.4006	2.6863
14	2.4577	2.7435	2.8578	1.3289		2.3434	2.5149
15	2.572	2.8578	2.3434	2.3388	2.8578	2.4006	2.1148
16	2.8578	3.2007	3.0864	2.8172	2.9721	2.572	2.4006
17	3.1436	3.4294	3.6008	3.0298	3.0864	2.915	3.0293
18	3.2007	3.658	3.658	3.1361	3.0864	3.2579	3.2007
19	3.658	3.7723	4.2867	3.4551	3.1436	3.7151	2.9721
20	3.315	3.8866	4.0581	3.5082	3.0864	3.4865	3.5437
21	2.9721	2.9721	3.4865	2.9767	3.1436	3.2007	3.2007
22	2.6292	2.8578	3.0864	2.4983	3.2007	2.7435	2.8006
23	2.1148	2.572	2.6292	2.1262		2.2291	2.2862
24	1.5947	1.7718	1.829	2.1148	1.7541	1.9433	1.9433
Max	3.658	3.8866	4.2867	4.2295	3.5082	3.7151	7.4303
Min	1.4352	1.5432	1.7147	1.3289	1.5947	1.6004	1.6004
Avg	2.5612	2.8149	2.9816	2.6692	2.6541	2.6006	2.8697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 402 / 33 KV GARWARE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.999	2.6292	2.6292	3.0864	2.8292	2.5149	2.8578
2	2.9424	2.5149	2.6292	2.9721	2.8858	2.5149	2.8578
3	2.8858	2.6292	2.6292	2.9721	2.8292		2.7435
4	2.7161	2.6292	2.7435	2.9721	2.8858		2.7435
5	2.5463	2.6292	2.7435	2.8578	2.8292	2.572	2.6292
6	2.6595	2.6292	2.8006	2.8578	2.9424	2.6292	2.6292
7	2.6029	2.4577	2.8578	2.8578	2.6595	2.7435	2.6292
8	2.4897	2.5149	2.8578	2.8578	3.1687	2.5149	2.8578
9	2.915	2.7435	2.9721	3.0556	3.1436	3.0293	2.915
10	3.0293	3.0293	3.1436	2.999	3.2007	3.0864	2.7435
11	2.915	2.8578	3.4294	3.0556	3.2007	3.2007	3.1436
12	2.9721	2.8578	3.2007	2.9424	3.0864	2.8578	3.1436
13	3.0293	2.7435	3.1436	2.9424	3.2579	2.9721	3.1436
14	2.4577	2.7435	3.0864	2.9424	3.2007	2.9721	3.315
15	2.8006	2.6292	2.5149	2.9424	3.0864	3.0864	2.9721
16	2.8006	2.6292	2.4577	2.999	3.1436	3.0293	2.9721
17	2.8006	2.7435	2.8006	2.9424	3.2007	2.572	2.915
18	2.8006	2.8006	3.0864	2.8858	3.1436	2.9721	2.8578
19	2.8006	2.7435	3.0293	2.8858	3.0864	3.0293	2.8578
20	2.8006	2.7435	3.0864	3.1121	3.0864	2.6863	2.6292
21	2.8578	2.8578	3.1436	3.0556	3.0864	2.9721	2.9721
22	3.0864	2.7435	3.0864	3.1687	2.9721	3.1436	3.315
23	2.7435	2.8578	3.315	2.8292		2.9721	3.2007
24	2.6595	2.6863	2.7435	***	2.8292	2.6292	2.9721
Max	3.0864	3.0293	3.4294	31.2072	3.2579	3.2007	3.315
Min	2.4577	2.4577	2.4577	2.8292	2.6595	2.5149	2.6292
Avg	2.8046	2.7102	2.9221	4.1416	3.0328	2.8500	2.9173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 404 / 33 KV ATHARVA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2819	3.4294	.5716	4.2867	6.3375	2.8578	3.1436
2	3.5082	3.5437	.6287	3.7151	5.2624	2.0576	4.1152
3	3.2253	3.8295	.6859	3.2007	4.8663	3.8295	3.7151
4	3.3951	4.0009	.9145	4.1152	5.4321	5.144	4.0009
5	3.3385	3.9438	1.7147	2.6863	5.715	4.4582	3.8866
6	2.999	3.2579	3.1436	4.3439	4.8097	4.5725	5.8299
7	2.999	.8573	1.8861		3.0556	2.8006	5.5441
8	1.5278	.8573	4.2867	4.6868	5.6019	.9145	4.6868
9	4.9154	.6859	3.5437	3.7912	4.5725	4.2295	6.2872
10	4.1724	.743	2.2862	7.1296	4.401	2.1148	5.9442
11	6.23	.6859	2.6292	4.6965	3.7723	4.9154	6.3443
12	4.6868	.6859	3.8866	3.9043	2.8578	2.8006	
13	3.4294	.743	2.4006	3.9609	2.2291	3.315	5.8299
14	3.0864	.743	2.1148	4.4702	2.7435	4.5153	5.144
15	2.1719	.6859	3.4294	3.2253	3.7723	1.829	3.3722
16	3.2007	.6859	3.7723	3.3951	5.144	4.0581	3.658
17	.9145	.6287	3.0293	3.6214	4.5725	4.6296	1.9433
18	2.0005	.6287	1.9433	4.6965	5.2584	2.2291	2.2291
19	3.5437	.6859	2.5149	4.6965	4.5725	4.7439	4.2295
20	.9145	.6287	1.0288	1.358	4.0009	4.0009	1.086
21	3.0864	.6859	4.6868	2.4897	4.1152	3.658	2.8578
22	5.0297	.6287	6.3443	3.6214	4.0009	5.0869	2.8006
23	3.5437	.6859	3.3722	5.7716		4.401	4.1724
24	3.3385	3.1436	.5716	3.658	4.7531	4.5725	3.658
Max	6.23	4.0009	6.3443	7.1296	6.3375	5.144	6.3443
Min	.9145	.6287	.5716	1.358	2.2291	.9145	1.086
Avg	3.2725	1.5456	2.5577	3.9792	4.4281	3.6556	4.1078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 301 / BHUINJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.9052	1.6004	.1524	.1143	.2286	.1143
2	1.8671	1.6766	1.5623	.1905	.1143	.2286	.1143
3	1.9052	1.6004	1.5623	.1905	.1524	.2286	.1143
4	1.9433	1.5242	1.5242	.1143	.1143	.2286	.1524
5	1.9433	1.6004	1.5242	.1143	.1524	.3429	
6	2.0576	1.829	1.6766	.1524	.1905	.3429	.1905
7	2.5911	2.21	2.1338	.1905	.2286	.381	.1905
8	2.8197	2.7435	2.4768	.1905	.1143	.3048	.1143
9	3.0102	2.8197	2.8959	.1143	.1143	.3048	.1143
10	3.0102	.3048	.3048	.1905	.1143	.2667	.0762
11	.1143	.2286	2.9165	3.5818	3.4675		2.2466
12	.1143	.1524	3.2114	3.658	3.8485		2.5819
13	.1143	.1524	3.2769	3.3913	3.5818	3.0102	.0762
14	.1143	.1524	3.2114	3.315	3.5056	3.4294	.0762
15	.1524	.1524	3.1786	3.1245	3.4294	3.5056	.0762
16	.1524	.1524	2.9492	2.9721	3.2769	3.4294	.1143
17	.1905	.1524	2.8509	2.5149	3.3532	3.3532	.1524
18	.1905	.2667	2.649	2.4387	2.8197	2.9721	.1143
19	.3429	.2667	.2286	.2286	.2667	.3429	.1524
20	.3048	.3048	.2667	.2286	.3048	.3429	.2667
21	.3048	.3048	.2667	.2667	.3048	.2667	.1905
22	.2667	.3048	.2667	.1905	.3048	.2286	.1143
23	.1905	.2667	.2286	.1524	.3048	.1524	.2286
24	.1905	1.9052	1.6004	.1905	.1143	.2286	.1143
Max	3.0102	2.8197	3.2769	3.658	3.8485	3.5056	2.5819
Min	.1143	.1524	.2286	.1143	.1143	.1524	.0762
Avg	1.0733	.9574	1.8485	1.1606	1.2622	1.0963	.3342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 302 / JAMB AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.448	.9526	.0381	.0762	.0381	.0381
2	.9907	1.448	.9145	.0381	.0381	.0381	.0381
3	1.0288	1.4098	.8764	.0381	.0381	.0381	.0381
4	1.0669	1.448	.8764	.0381	.0381	.0381	.0381
5	1.0669	1.5242	.8764	.0381	.0381	.0381	.0381
6	1.1431	1.5623	1.0288	.0381	.0381	.0762	.0762
7	1.4861	1.5242	1.2193	.0381	.0762	.0762	.0762
8	1.7147	1.6385	1.3717	.0381	.0381	.0762	.0381
9	1.829	1.9052	1.7909	.0381	.0381	.0762	.0381
10	1.829	.0381	.0381	.0381	.0381	.0381	.0762
11	.0762	.0381	1.7695	2.2481	2.1338	2.0957	.0762
12	.0381	.0381	1.8351	2.4006	2.21	2.21	.0762
13	.0381	.0381	1.8679	2.2862	2.2862	2.3624	.0381
14	.0381	.0381	1.9334	2.3624	2.21	2.3624	.0381
15	.0381	.0381	1.7772	1.9052	2.0576	2.2862	.0762
16		.0381	1.8107	1.9052	1.9052	2.2862	.0381
17	.0762	.0381	1.643	1.6766	1.8671	2.2862	.0381
18	.0762	.0762	1.8107	1.6766	1.7528	2.2862	.0381
19	.0762	.0762	.0762	.0762	.0762	.1905	.0381
20	.0762	.0762	.0762	.0762	.0762	.1524	.0381
21	.0381	.0762	.0762	.0762	.0762	.0762	.0381
22	.0381	.0762	.0381	.0762	.0762	.0762	.0381
23	.0381	.0762	.0381	.0381	.0762	.0381	.0762
24		1.5242	.9526	.0381	.0762	.0381	.0381
Max	1.829	1.9052	1.9334	2.4006	2.2862	2.3624	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.6304	.6748	1.0688	.7176	.7224	.8033	.0492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 303 / BHUINJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4572	.3658	.381	.4572	.4572
2	.381	.4191	.4191	.3658	.4191	.4572	.381
3	.381	.4191	.4191	.3658	.4191	.4572	.3429
4	.3429	.3429	.4191	.4024	.4191	.4572	.3429
5	.4191	.381	.4191	.439	.4572	.4572	.4954
6	.5335	.6097	.6097	.5121	.5716	.5716	.5716
7	.8764	.9145	.9145	.7316	.8764	.9145	.8002
8	.9145	.8383	.8764	.8413	.8383	.8383	.7621
9	.6859	.7621	.6478	.8002	.6859	.6859	.6859
10	.6097	.6097	.5121	.6097	.5716	.5335	.5853
11	.6859	.6097	.439	.4954	.4954	.6097	.5121
12	.6478	.5335	.3605	.5716	.5335	.5335	.5487
13	.6097	.5335	.4024	.4572	.4572	.5335	.4755
14	.5716	.4572	.4755	.4954	.4572	.4954	.439
15	.6478	.4572	.439	.4572	.4572	.4572	.439
16	.6097	.4954	.439	.5716	.4572	.4954	.439
17	.724	.4954	.4755	.5335	.4954	.6859	
18	.9145	.8764	.5121	.5335	.5716	.724	.5853
19	.9526	.8383	.7316	.8002	.7621	.9145	.6584
20	.9526	.7621	.788	.8002	.8383	.9526	.788
21	.9145	.7621	.7316	.8002	.7621	.8383	.8238
22	.7621	.6097	.695	.6859	.724		.695
23	.6859	.5335	.5121	.6097	.5716	.6859	.5853
24		.4572	.4572	.4024	.4191	.4572	.4954
Max	.9526	.9145	.9145	.8413	.8764	.9526	.8238
Min	.3429	.3429	.3605	.3658	.381	.4572	.3429
Avg	.6610	.5874	.5480	.5687	.5684	.6180	.5613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 304 / JAMB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.3658	.3658	.381	.4191	.3429
2	.381	.3429	.3658	.3292	.381	.381	.3429
3	.381	.3429	.3658	.3658	.381	.381	.3048
4	.381	.381	.3658	.4024	.4191	.381	.3429
5	.4572	.4191	.439	.5121	.4572	.4954	.4572
6	.7621	.6859	.695	.6584	.6859	.6859	.6097
7	.9145	.8383	.8596	.8238	.8764	.8383	.8764
8	.8383	.9145	.8238	.8596	.8383	.8002	.8383
9	.724	.724	.6584	.724	.724	.6859	7.3922
10	.6859	.5335	.6584	.8002	.8002	.5335	.7316
11	.8383	.5716	.5853	.724	.724	.5716	.7316
12	.7621	.4954	.5487	.7621	.724	.4954	.6584
13	.6859	.4954	.6219	.724	.6478	.4572	.695
14	.6097	.4954	.695	.724	.6097	.4572	.5853
15	.5716	.4954	.5853	.6478	.6097	.4954	.6584
16	.5716	.4954	.6584	.724	.6859	.4572	.5853
17	.6097	.5335	.6219	.7621	.6478	.4572	.6219
18	.724	.724	.6584	.8002	.6859	.5335	.695
19	1.0669	.8764	.9313	1.0288	.9907		.7522
20	1.1431	.9145	1.0387	.8764	1.105		1.0745
21	1.1431	.7621	.9671	.8383	.9526	.9526	.9313
22	1.0288	.6478	.788	.6478	.6859	.6859	.8238
23	.7621	.4954	.5853	.5335	.4954	.6097	.6584
24		.4572	.3658	.4024	.4191	.4191	.381
Max	1.1431	.9145	1.0387	1.0288	1.105	.9526	7.3922
Min	.381	.3429	.3658	.3292	.381	.381	.3048
Avg	.7140	.5843	.6354	.6682	.6637	.5542	.9205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 305 / 22 KV KHADAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762	.1524	1.0745	1.1431	1.0669	.0762
2	.1143	.0762	.1524	1.0387	1.0669	1.0669	.0762
3	.1143	.0762	.1143	1.0387	1.105	1.0288	.0762
4	.0762	.0762	.1143	1.1462	1.1431	1.0288	.0762
5	.0762	.0762	.1524		1.2574	1.0288	.0762
6	.1143	.1524	.1905	1.3969	1.2955	1.2193	.0762
7	.1524	.1524	.1905	1.6118	1.6004	1.3336	.0762
8	.1524	.1524	.2286	1.8107	1.9052	1.6385	.0762
9	.1524	.1524	.1524	2.0576	1.829	1.9052	.0762
10	2.934	.1524	.2286	.1143	.0762	.0762	.0762
11	2.9721	2.8959	.2286	.1143	.1143	2.2862	2.2466
12	2.934	3.1245	.1143	.0762	.1143	2.3624	2.5819
13	2.6673	3.0483	.0762	.0762	.1143	2.3624	2.4813
14	2.6292	2.7435	.1143	.0762	.1143	2.4387	2.4143
15	2.6292	2.7435	.0762	.0762	.1524	2.4387	2.3807
16	2.6673	2.6292	.0762	.1143	.1143	2.3624	2.2131
17	2.4387	2.4768	.1143	.0762	.1524	2.2862	2.0454
18	2.2862	2.2862	.1524	.0762	.1143	2.2862	1.8442
19	.1524	.2286	.1143	.1905	.2286	.1524	.1143
20	.1143	.2286	.1905	.1905	.2667	.1524	.2286
21	.1524	.1905	.1905	.1905	.2286	.0762	.1143
22	.1524	.1905	.1524	.1524	.2286	.0762	.0762
23	.1524	.1905	.1143	.1143	.2286	.0762	.1905
24		.0762	.1524	1.1462	1.2193	1.0669	.0762
Max	2.9721	3.1245	.2286	2.0576	1.9052	2.4387	2.5819
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.1299	1.0082	.1476	.6069	.6589	1.3257	.8237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254084 / 33/22 KV Asale-Pachwad

Substat

Feeder No / Name : 301 / 22KV KADEGAON GAOVTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.0686	.1029	.1143	.1029	.0686
2	.0762	.0686	.0686	.1029	.1143	.0686	.0686
3	.0762	.0686	.0686	.1029	.0762	.0686	.0686
4	.0762	.0686	.1029	.1372	.1143	.1029	.0686
5	.1524	.1029	.1029	.1372	.1143	.1029	.1029
6	.2286	.1372	.1715	.1372	.1143	.1715	.1372
7	.2667	.2058	.2058	.2401	.2286	.2401	.2401
8	.2667	.2401	.2058	.2401	.2667	.2401	.2401
9	.2667	.2058	.1715	.2058	.2286	.1715	.2058
10	.3048	.2058	.2058	.3048	.2743	.1715	.2401
11	.3048	.1372	.4115	.3048	.2401	.1372	.2743
12	.3429	.1372	.2743	.3048	.2401	.1029	.2401
13	.1372	.1029	.2058	.3048	.2743	.1029	.1715
14	.1372	.1029	.1372	.1524	.1715	.0686	.1029
15	.3086	.1372	.2058	.1524	.2743	.0686	.2743
16	.3086	.1029	.2401	.2667	.2743	.0686	.2743
17	.1372	.1029	.1715	.3048	.3429	.1029	.2058
18	.1372	.1372	.1715	.1905	.2058		
19	.2058	.2058	.2401	.1905	.2058	.2058	.2058
20	.1715	.2058	.2058	.2286	.2058	.2058	.1715
21	.1715	.1715	.2058	.1905	.1715	.1715	.1715
22	.1372	.1372	.1715	.1524	.1372	.1372	.1372
23	.1029	.1029	.1372	.1143	.1029	.1029	.1029
24	.0762	.0686	.0686	.1029	.0762	.0686	.0686
Max	.3429	.2401	.4115	.3048	.3429	.2401	.2743
Min	.0762	.0686	.0686	.1029	.0762	.0686	.0686
Avg	.1862	.1343	.1758	.1946	.1904	.1297	.1670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254084 / 33/22 KV Asale-Pachwad

Substat

Feeder No / Name : 302 / 22KV UDATARE GAOVTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 22 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1715	.2058	.2743	.3048	.2401	.2401
2	.2286	.1715	.1715	.2743	.2286	.2058	.2401
3	.2286	.1715	.1715	.3086	.2286	.2058	.2401
4	.2286	.1715	.1715	.3086	.3048	.2401	.2743
5	.3048	.2743	.2058	.3429	.3429	.2743	.3086
6	.4572	.3429	.3086	.3429	.4572	.3772	.3429
7	.7621	.6173	.5144	.583	.7621	.4801	.6516
8	.6859	.6859	.6173	.6516	.7621	.6516	.6516
9	.6173	.6173	.6516	.583	.5335	.5144	.5487
10	.5487	.583	.5487	.5716	.4115	.5144	.5144
11	.4458	.5487	.5487	.4954	.3772	.4801	.4458
12	.4458	.4801	.4458	.4954	.3429	.4458	.3772
13	.4801	.3429	.4458	.4954	.3429	.4115	.4115
14	.4458	.3429	.4458	.5335	.3086	.3429	.4115
15	.4801	.3086	.4458	.4954	.3086	.3086	.3772
16	.4801	.3086	.5144	.4954	.3086	.3086	.3772
17	.4115	.3429	.3429	.4954	.5144	.3086	.4115
18	.4801	.3429	.4115	.5716	.583		
19	.4801	.5144	.5487	.5716	.6516	.4801	.6173
20	.5487	.5144	.5144	.6097	.5487	.5144	.5487
21	.4801	.4801	.4801	.4954	.4801	.4458	.5144
22	.3772	.3772	.4115	.3429	.4458	.4115	.4458
23	.2743	.2743	.3429	.3048	.3429	.3429	.3429
24	.3048	.2058	.2401	.2743	.3048	.2743	.2743
Max	.7621	.6859	.6516	.6516	.7621	.6516	.6516
Min	.2286	.1715	.1715	.2743	.2286	.2058	.2401
Avg	.4375	.3829	.4044	.4549	.4248	.3817	.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254084 / 33/22 KV Asale-Pachwad

Substat

Feeder No / Name : 303 / 22KV UDATARE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.1029	.1029	.9145	.6859	.6859
2	.0762	.0686	.0686	.1029	.8002	.6859	.6859
3	.0762	.0343	.0686	.1029	.7621	.6516	.6516
4	.0762	.0686	.0686	.1029	.6859	.6859	.6516
5	.0762	.0686	.0686	.1029	.7621	.7202	.6516
6	.0762	.1029	.1029	.1029	.8002	.7545	.6516
7	.1143	.1029	.1029	.1029	.9526	.9945	.8916
8	.0381	.1029	.1029	.1029	.9907	1.0631	1.0631
9	.1143	.1029	.0686	.1029	.9145	1.0631	1.0631
10	.1143	.1029	.1029	.1143	.0686	.1029	.1029
11	1.7528	1.8861	1.7147	1.9814	.1029	.0686	.1029
12	2.1719	2.0919	1.8861	2.0957	.0686	.1029	.0686
13	1.8861	2.0919	1.7833	1.9814	.1029	.0686	
14	1.7833	2.1605	1.7147	1.9433	.1029	.0686	
15		1.9547	1.6118	2.0576	.1029	.0686	
16		1.8519	1.5432	1.7528	.0686	.0686	.1029
17		1.7833	1.406	1.5242	.1029	.1029	.1029
18		1.5775	1.2689	1.4098	.0686		
19	.1029	.1029	.1029	.1143	.1029	.1029	.1372
20	.1372	.1029	.1372	.1143	.1029	.1372	.1372
21	.1029	.1029	.1029	.1143	.1029	.1372	.1372
22	.1029	.1029	.1029	.1143	.1029	.1029	.1372
23	.0686	.1029	.1029	.1143	.1029	.1029	.1372
24	.1143	.0686	.1029	.1029	.1143	.6516	.6859
Max	2.1719	2.1605	1.8861	2.0957	.9907	1.0631	1.0631
Min	.0381	.0343	.0686	.1029	.0686	.0686	.0686
Avg	.4531	.7002	.6016	.6859	.3750	.3996	.4424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254084 / 33/22 KV Asale-Pachwad

Substat

Feeder No / Name : 304 / 22KV KADEGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0343	.0686	.0686	.381	.1715	.1372
2	.0381	.0343	.0343	.0686	.4572	.1715	.1372
3	.0381	.0343	.0343	.0686	.3048	.2058	.1372
4	.0381	.0343	.0343	.0686	.2286	.2058	.1372
5	.0381	.0343	.0343	.0686	.2286	.2058	.1715
6	.0381	.0343	.0686	.0686	.3048	.2401	.1715
7	.0762	.0686	.0686	.0686	.3429	.3429	.2401
8	.0762	.0686	.0686	.0686	.381	.4115	.3086
9	.0762	.0686	.0686	.0686	.3048	.4115	.3086
10	.0686	.0686	.0686	.5335	.0686	.0343	.0343
11	.5487	.583	.5487	.5335	.0686	.0343	.0343
12	.583	.6859	.583	.5716	.0686	.0343	.0343
13	.6173	.7202	.583	.6097	.0686	.0343	.0343
14	.583	.6859	.5144	.6097	.0686	.0343	.0343
15	.5487	.6516	.4801	.6097	.0686	.0343	.0343
16	.5487	.583	.4801	.5335	.0686	.0343	.0343
17	.5144	.5144	.3772	.5335	.0686	.0343	.0343
18	.4458	.4801	.3429	.4954	.0343		
19	.0686	.0686	.0686	.1143	.0343	.0343	.0343
20	.0686	.0686	.0686	.1143	.0343	.0343	.0343
21	.0686	.0686	.0686	.1143	.0343	.0343	.0343
22	.0686	.0686	.0686	.0762	.0343	.0343	.0343
23	.0686	.0686	.0686	.0762	.0343	.0343	.0343
24	.0762	.0343	.0686	.0686	.0762	.1715	.1372
Max	.6173	.7202	.583	.6097	.4572	.4115	.3086
Min	.0381	.0343	.0343	.0686	.0343	.0343	.0343
Avg	.2223	.2401	.2029	.2588	.1569	.1297	.1014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 302 / 22 KV COLLEGE ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.3011
Max	2.3011
Min	2.3011
Avg	2.3011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 303 / 22 KV BAVDHAN AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1502
Max	2.1502
Min	2.1502
Avg	2.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 304 / 22 KV WAI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.3765
Max	2.3765
Min	2.3765
Avg	2.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 305 / 22 KV KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18
HR	Load (MW)
24	2.1502
Max	2.1502
Min	2.1502
Avg	2.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 306 / 22 KV BAVDHAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.9616
Max	1.9616
Min	1.9616
Avg	1.9616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 307 / 22 KV SHAHABAUG GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	2.0748
Max	2.0748
Min	2.0748
Avg	2.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 402 / 33 KV MIDC

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.715
Max	5.715
Min	5.715
Avg	5.715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 405 / 33KV ASALE PACHWAD FEEDER

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	3.7346
Max	3.7346
Min	3.7346
Avg	3.7346