

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 201 / 11 KV LONKHEDI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 10 | .3429 | .4287 | 1.3717 |
| 11 | | | 2.915 |
| 12 | | | 3.0007 |
| 13 | | | 2.8292 |
| 14 | | | 2.6578 |
| 15 | | | 2.8292 |
| 16 | | | 2.6578 |
| 17 | | | 2.4006 |
| Max | .3429 | .4287 | 3.0007 |
| Min | .3429 | .4287 | 1.3717 |
| Avg | .3429 | .4287 | 2.5828 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 202 / 11 KV SHIRDHANE AG 1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3429 | .4287 | .5144 | |
| 2 | | .3429 | .5144 | .5144 | |
| 3 | | .5144 | .7716 | .5144 | |
| 4 | | .8573 | .8573 | .6859 | |
| 5 | | 1.3717 | 1.286 | .9431 | |
| 6 | | 1.7147 | 1.7147 | 1.1145 | |
| 7 | | 1.9719 | 2.0576 | 1.2003 | |
| 8 | | 1.3717 | 2.2291 | 1.6289 | 2.1434 |
| 9 | | 1.7147 | 2.0576 | | 2.1434 |
| 24 | .4239 | | | | |
| Max | .4239 | 1.9719 | 2.2291 | 1.6289 | 2.1434 |
| Min | .4239 | .3429 | .4287 | .5144 | 2.1434 |
| Avg | .4239 | 1.1336 | 1.3241 | .8895 | 2.1434 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 203 / 11 KV DEUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1715 | .1715 | .1715 | |
| 2 | | .1715 | .1715 | .1715 | |
| 3 | | .1715 | .1715 | .1715 | |
| 4 | | .1715 | .1715 | .1715 | |
| 5 | | .1715 | .1715 | .1715 | |
| 6 | | .1715 | .1715 | .1715 | |
| 7 | | .1715 | .1715 | .1715 | |
| 8 | | .1715 | .1715 | .1715 | .1715 |
| 9 | | .1715 | .1715 | | .1715 |
| 10 | | .3429 | .3429 | | .3429 |
| 11 | | | | | 1.8861 |
| 12 | | | | | 1.7147 |
| 13 | | | | | 1.4575 |
| 14 | | | | | 1.3717 |
| 15 | | | | | 1.3717 |
| 16 | | | | | 1.2003 |
| 17 | | | | | 1.3717 |
| 24 | .4239 | | | | |
| Max | .4239 | .3429 | .3429 | .1715 | 1.8861 |
| Min | .4239 | .1715 | .1715 | .1715 | .1715 |
| Avg | .4239 | .1886 | .1886 | .1715 | 1.1060 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 204 / 11 KV NER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3429 | .3429 | .3429 | |
| 2 | | .3429 | .4287 | .3429 | |
| 3 | | .4287 | .5144 | .3429 | |
| 4 | | .5144 | .5144 | .5144 | |
| 5 | | .6859 | .6001 | .5144 | |
| 6 | | .6859 | .6001 | .6859 | |
| 7 | | .6859 | .6859 | .8573 | |
| 8 | | .6859 | .7716 | .8573 | .6859 |
| 9 | | .6859 | .8573 | | .7716 |
| 24 | .4239 | | | | |
| Max | .4239 | .6859 | .8573 | .8573 | .7716 |
| Min | .4239 | .3429 | .3429 | .3429 | .6859 |
| Avg | .4239 | .5620 | .5906 | .5573 | .7288 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 205 / 11 KV NER-GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0762 | .0762 | .0762 | |
| 2 | .0762 | .0762 | .0762 | |
| 3 | .0762 | .0762 | .0762 | |
| 4 | .1143 | .1143 | .0762 | |
| 5 | .1524 | .1524 | .1143 | |
| 6 | .1524 | .1715 | .1524 | |
| 7 | .2096 | .2134 | .1715 | |
| 8 | .1905 | .1638 | .1334 | .1524 |
| 9 | .1524 | .1219 | .1143 | .1334 |
| 10 | .0953 | .0953 | .1143 | .1143 |
| 11 | | | | .0953 |
| 12 | | | | .0953 |
| 13 | | | | .0762 |
| 14 | | | | .0762 |
| 15 | | | | .0762 |
| 16 | | | | .0762 |
| 17 | | | | .0953 |
| Max | .2096 | .2134 | .1715 | .1524 |
| Min | .0762 | .0762 | .0762 | .0762 |
| Avg | .1296 | .1261 | .1105 | .0991 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 206 / 11 KV NANDRE SINGLE
PHASING Feeder KV- 11 /
OUTGOING SINGLE PHASING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .4239 |
| Max | .4239 |
| Min | .4239 |
| Avg | .4239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 207 / 11 KV SHIRDHANE GAOTHAON

GAOTHAN FEEDER

FSS Feeder KV- 11 / OUTGOING

| DATE | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .0572 | .0572 | |
| 2 | .2572 | .0572 | .0572 | |
| 3 | .0572 | .0572 | .0572 | |
| 4 | .0762 | .0762 | .0572 | |
| 5 | .1143 | .0953 | .1143 | |
| 6 | .1524 | .1334 | .1143 | |
| 7 | .1905 | .1524 | .1524 | |
| 8 | .1143 | .1334 | .1143 | .1143 |
| 9 | .0762 | .0953 | .0762 | .0762 |
| 10 | .0572 | .0762 | .0762 | .0572 |
| 11 | | | | .0572 |
| 12 | | | | .0572 |
| 13 | | | | .0572 |
| 14 | | | | .0572 |
| 15 | | | | .0572 |
| 16 | | | | .0572 |
| 17 | | | | .0572 |
| Max | .2572 | .1524 | .1524 | .1143 |
| Min | .0572 | .0572 | .0572 | .0572 |
| Avg | .1153 | .0934 | .0877 | .0648 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 208 / 11 KV DEUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .0572 | .0572 | |
| 2 | .0572 | .0572 | .0572 | |
| 3 | .0572 | .0572 | .0572 | |
| 4 | .0762 | .0762 | .0572 | |
| 5 | .0953 | .0953 | .0762 | |
| 6 | .1524 | .1334 | .1143 | |
| 7 | .1524 | .1524 | .1143 | |
| 8 | | .0953 | .1143 | .0762 |
| 9 | .0953 | .0762 | .0762 | .0572 |
| 10 | .0762 | .0572 | | .0572 |
| 11 | | | | .0572 |
| 12 | | | | .0572 |
| 13 | | | | .0572 |
| 14 | | | | .0572 |
| 15 | | | | .0572 |
| 16 | | | | .0572 |
| 17 | | | | .0572 |
| Max | .1524 | .1524 | .1143 | .0762 |
| Min | .0572 | .0572 | .0572 | .0572 |
| Avg | .0910 | .0858 | .0805 | .0591 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 209 / 11 KV SHIRDHANE AG-2
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1715 | .1715 | .2572 | |
| 2 | | .1715 | .2572 | .2572 | |
| 3 | | .2572 | .2572 | .2572 | |
| 4 | | .3429 | .3429 | .3429 | |
| 5 | | .5144 | .5144 | .6001 | |
| 6 | | .6859 | .8573 | .8573 | |
| 7 | | .8573 | 1.1145 | 1.286 | |
| 8 | | .6859 | 1.2003 | 1.5432 | 1.5432 |
| 9 | | .7716 | 1.0631 | | 1.5432 |
| 10 | | .1715 | .8916 | | |
| 24 | .4239 | | | | |
| Max | .4239 | .8573 | 1.2003 | 1.5432 | 1.5432 |
| Min | .4239 | .1715 | .1715 | .2572 | 1.5432 |
| Avg | .4239 | .4630 | .667 | .6751 | 1.5432 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 201 / 11 KV BORKUND AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .2591 | .2543 | .2143 |
| 2 | | | | | .2591 | .2543 | .2143 |
| 3 | | | | | .2439 | .2713 | .2143 |
| 4 | | | | | .2949 | .3052 | |
| 5 | | | | | .2846 | .3391 | .2286 |
| 6 | | | | | .3163 | .407 | .2572 |
| 7 | | | | | .3277 | .4409 | .4001 |
| 10 | .373 | .2858 | .2572 | .3018 | | | |
| 11 | .5087 | .3429 | .3144 | .3688 | | | |
| 12 | .5935 | .3715 | .3715 | .503 | | | |
| 13 | .5765 | .3429 | .3715 | .503 | | | |
| 14 | .5087 | .3429 | .3286 | .3688 | | | |
| 15 | .4748 | .3429 | .3144 | .3688 | | | |
| 16 | .4239 | .3572 | .2858 | .3353 | | | |
| 17 | .4239 | .3001 | .3144 | .3353 | | | |
| 22 | | | | .3018 | .2713 | .2713 | .2987 |
| 23 | | | | .2683 | .2458 | .2543 | .2 |
| 24 | | | | | .2622 | .2543 | .2143 |
| Max | .5935 | .3715 | .3715 | .503 | .3277 | .4409 | .4001 |
| Min | .373 | .2858 | .2572 | .2683 | .2439 | .2543 | .2 |
| Avg | .4854 | .3358 | .3197 | .3655 | .2765 | .3052 | .2491 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 202 / 11 KV SHIRUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2035 | .1966 | .2143 | .2683 | .0328 | .0343 | .0366 |
| 2 | .2035 | .1966 | .2143 | .2683 | .0328 | .0343 | .0366 |
| 3 | .2713 | .2214 | .2286 | .3018 | .0328 | .0343 | .0366 |
| 4 | .2713 | .2812 | .2572 | .3688 | .0328 | .0343 | |
| 5 | .3052 | .3563 | .2858 | .4024 | .0328 | .0343 | .0366 |
| 6 | .373 | .3932 | .3286 | .503 | | .0343 | .0366 |
| 7 | .5087 | .6706 | .6001 | .7209 | | .0343 | .0366 |
| 8 | | | | | | .0343 | .0366 |
| 9 | | | | | | .0343 | .0366 |
| 10 | | | | | .3277 | .4409 | .3429 |
| 11 | | | | | .852 | .6783 | |
| 12 | | | | | 1.0753 | .8817 | .643 |
| 13 | | | | | 1.1869 | .8478 | .7716 |
| 14 | .0343 | | .0366 | .0168 | .8539 | .78 | .6144 |
| 15 | .0686 | .0328 | .0366 | .0335 | .8097 | .7461 | .543 |
| 16 | .0686 | .0328 | .0366 | .0335 | .6642 | .4748 | .4755 |
| 17 | .0686 | .0339 | .0366 | .0335 | .4409 | .4748 | .4144 |
| 18 | .0343 | .0305 | .0366 | .0335 | | | |
| 19 | .0343 | .0328 | .0732 | .0335 | | | |
| 20 | .0686 | .0328 | .0914 | .0335 | | | |
| 21 | .0686 | .0366 | .0732 | .0335 | | | |
| 22 | .3391 | .2 | .4207 | .0335 | | | |
| 23 | .2713 | .2 | .2715 | .0335 | | | |
| 24 | .4239 | .2294 | .2143 | .2683 | .0328 | .0343 | .0366 |
| Max | .5087 | .6706 | .6001 | .7209 | 1.1869 | .8817 | .7716 |
| Min | .0343 | .0305 | .0366 | .0168 | .0328 | .0343 | .0366 |
| Avg | .2009 | .1869 | .1920 | .1900 | .4577 | .3149 | .2584 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 203 / 11 KV I.O.C.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .112 | .112 | .0549 | .0566 | .112 | .112 | .1463 |
| 2 | .112 | .1132 | .0549 | .0566 | .1132 | .112 | .124 |
| 3 | .112 | .0943 | .0549 | .0566 | .1017 | .112 | .128 |
| 4 | .112 | .0914 | .0532 | .0566 | .1097 | .1307 | .124 |
| 5 | .112 | .0934 | .0549 | .0566 | .1097 | .1307 | .128 |
| 6 | .0747 | .0914 | .0549 | .0566 | .1357 | .1307 | .128 |
| 7 | .112 | .0754 | .0914 | .0171 | .1147 | .1307 | .128 |
| 8 | .112 | .0732 | .1097 | .0189 | .1147 | .112 | .128 |
| 9 | .0934 | .0732 | .1463 | .0754 | .1698 | .112 | .2012 |
| 10 | .2241 | .0754 | .0732 | .0754 | .2378 | .2054 | 1.3535 |
| 11 | .2241 | .0754 | .1463 | .0754 | .2829 | .2241 | .2195 |
| 12 | .2427 | .0943 | .1463 | .0943 | .3109 | .2427 | .2195 |
| 13 | .2241 | .0732 | .1097 | .0943 | .2263 | .2241 | .2195 |
| 14 | .2241 | .0754 | .1646 | .0943 | .2743 | .168 | .2012 |
| 15 | .1867 | .0732 | .1646 | .0943 | .2263 | .168 | .1646 |
| 16 | .112 | .0339 | .1646 | .0943 | .1886 | .2241 | .1646 |
| 17 | .112 | .0366 | .0732 | .0943 | .1509 | .1494 | .128 |
| 18 | .112 | .0943 | .0183 | .0943 | .1509 | .168 | .1097 |
| 19 | .1307 | .0732 | .0914 | .0943 | .1463 | .168 | .1463 |
| 20 | .112 | .0732 | .0914 | .0943 | .1463 | .2054 | .1463 |
| 21 | .112 | .0732 | .1097 | .0943 | .1509 | .1307 | .128 |
| 22 | .1494 | .0732 | .0914 | .0566 | .1463 | .1307 | .128 |
| 23 | .1307 | .0549 | .0914 | .0566 | .1494 | .1494 | .1463 |
| 24 | .112 | .0934 | .0549 | .0566 | .0934 | .112 | .1646 |
| Max | .2427 | .1132 | .1646 | .0943 | .3109 | .2427 | 1.3535 |
| Min | .0747 | .0339 | .0183 | .0171 | .0934 | .112 | .1097 |
| Avg | .1400 | .0788 | .0944 | .0714 | .1651 | .1564 | .2031 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 204 / 11 KV NIMGUL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0509 | .0549 | .0267 | .0335 | | | |
| 2 | .0509 | .0549 | .0267 | .0335 | | | |
| 3 | .0509 | .0566 | .0267 | .0335 | | | |
| 4 | .0509 | .0492 | .0267 | .0335 | | | |
| 5 | .0509 | .0549 | .04 | .0335 | | | |
| 6 | .0509 | .0754 | .04 | .0503 | | | |
| 7 | .0678 | .128 | .08 | .0838 | | | |
| 10 | | | | | .0655 | .0678 | .0533 |
| 11 | | | | | .1097 | .0678 | .0667 |
| 12 | | | | | .1463 | .0848 | .0667 |
| 13 | | | | | .128 | .0848 | .0667 |
| 14 | | | | | .1132 | .0678 | .0714 |
| 15 | | | | | .0819 | .0678 | .0667 |
| 16 | | | | | .0914 | .0509 | .04 |
| 17 | | | | | .0509 | .0509 | .0533 |
| 22 | .0509 | .0267 | .0667 | | | | |
| 23 | .0509 | .0267 | .04 | | | | |
| 24 | .4239 | .0514 | .0267 | .0335 | | | |
| Max | .4239 | .128 | .08 | .0838 | .1463 | .0848 | .0714 |
| Min | .0509 | .0267 | .0267 | .0335 | .0509 | .0509 | .04 |
| Avg | .0899 | .0579 | .0400 | .0419 | .0984 | .0678 | .0606 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 205 / 11 KV BORKUND GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4805 | .4854 | .4287 | .5093 | .4755 | .4805 | .4854 |
| 2 | .4805 | .5228 | .4668 | .5093 | .4755 | .4805 | .4854 |
| 3 | .4805 | .5228 | .4668 | .5281 | .4755 | .462 | .4854 |
| 4 | .5175 | .6722 | .5487 | .7545 | .5121 | .5544 | |
| 5 | .5914 | .7842 | 1.0242 | .9389 | .7316 | .8215 | 1.0456 |
| 6 | 1.2696 | 1.2696 | 1.1576 | 1.3203 | 1.2071 | 1.0456 | 1.307 |
| 7 | 1.307 | 1.307 | 1.307 | 1.2449 | 1.2803 | 1.1203 | 1.2071 |
| 8 | 1.1203 | 1.0456 | 1.0456 | 1.0751 | 1.0608 | .8589 | .9511 |
| 9 | .7095 | .7468 | .6161 | .7356 | .567 | .6161 | .6722 |
| 10 | .5544 | .5853 | .5975 | .5658 | .5281 | .4805 | .5487 |
| 11 | .4805 | .4572 | .5121 | .5281 | .4854 | .4435 | .4572 |
| 12 | .3696 | .4572 | .4207 | .4904 | .4252 | .3696 | .4207 |
| 13 | .4066 | .439 | .4024 | .4904 | .439 | .4066 | .439 |
| 14 | .4435 | .439 | .4207 | .4904 | .4668 | .4435 | .4572 |
| 15 | .4435 | .439 | .4294 | .4904 | .4668 | .4435 | .4572 |
| 16 | .4435 | .4755 | .439 | .4904 | .4572 | .4805 | .5041 |
| 17 | .5544 | .5487 | .4755 | .5281 | .5121 | .5544 | .4938 |
| 18 | .7468 | .6219 | .5853 | .6036 | .5853 | .5975 | .7133 |
| 19 | .9709 | .5258 | .9145 | .7922 | .6226 | .8962 | .8962 |
| 20 | .8962 | .8048 | .8402 | .8676 | .7316 | .8215 | .8589 |
| 21 | .6348 | .8413 | .6535 | .7545 | .695 | .6722 | .5853 |
| 22 | .5544 | .5975 | .5788 | .6413 | .5853 | .5914 | .5975 |
| 23 | .5175 | .4572 | .5041 | .5658 | .5121 | .5175 | .5601 |
| 24 | .5175 | .4864 | .4668 | .5093 | .3734 | .4805 | .4864 |
| Max | 1.307 | 1.307 | 1.307 | 1.3203 | 1.2803 | 1.1203 | 1.307 |
| Min | .3696 | .439 | .4024 | .4904 | .3734 | .3696 | .4207 |
| Avg | .6455 | .6472 | .6376 | .6843 | .6113 | .6099 | .6572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 206 / 11 KV SHIRUD GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .4239 |
| Max | .4239 |
| Min | .4239 |
| Avg | .4239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 207 / 11 KV NIMGUL GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .4239 |
| Max | .4239 |
| Min | .4239 |
| Avg | .4239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 208 / 11 KV VINCHUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1017 | .1311 | .0892 | .1006 | | | |
| 2 | .1017 | .1311 | .0857 | .1006 | | | |
| 3 | .1357 | .1311 | .0857 | .1132 | | | |
| 4 | .1357 | .1296 | .1 | .1174 | | | |
| 5 | .1696 | .1638 | .1143 | .1509 | | | |
| 6 | .2035 | .1898 | .1143 | .1844 | | | |
| 7 | .2374 | .2294 | .1858 | .2515 | | | |
| 10 | | | | | .1898 | .2035 | .2 |
| 11 | | | | | .2294 | .2035 | .2143 |
| 12 | | | | | .253 | .1696 | .2 |
| 13 | | | | | .2439 | .1696 | .2143 |
| 14 | | | | | .2591 | .1357 | .2143 |
| 15 | | | | | .2286 | .1696 | .2143 |
| 16 | | | | | .2134 | .2035 | .1858 |
| 17 | | | | | .2543 | .2035 | .1715 |
| 22 | .1696 | .0572 | .1286 | | | | |
| 23 | .1357 | .0572 | .1429 | | | | |
| 24 | .1017 | .1357 | .0572 | .1006 | | | |
| Max | .2374 | .2294 | .1858 | .2515 | .2591 | .2035 | .2143 |
| Min | .1017 | .0572 | .0572 | .1006 | .1898 | .1357 | .1715 |
| Avg | .1492 | .1356 | .1104 | .1399 | .2339 | .1823 | .2018 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 209 / 11 KV RATANPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .2591 | .2713 | .2 |
| 2 | | | | | .2622 | .2713 | .2143 |
| 3 | | | | | .2591 | .2713 | .2 |
| 4 | | | | | .2846 | .3052 | |
| 5 | | | | | .2949 | .3391 | .2134 |
| 6 | | | | | .4096 | .407 | .2667 |
| 7 | | | | | .4915 | .5596 | .4001 |
| 10 | .407 | | .2801 | .3353 | | | |
| 11 | .5765 | | .2801 | .3688 | | | |
| 12 | .78 | .6554 | .3067 | .503 | | | |
| 13 | .7122 | .6226 | .3201 | .4694 | | | |
| 14 | .5765 | .5898 | .3467 | .4694 | | | |
| 15 | .5087 | .5243 | .3334 | .4694 | | | |
| 16 | .407 | .5243 | .3334 | .4359 | | | |
| 17 | .407 | .4409 | .3734 | .4359 | | | |
| 22 | | | | .3018 | .3109 | | .2934 |
| 23 | | | | .2683 | .2713 | .2713 | .2667 |
| 24 | .4239 | | | | .2622 | .2713 | .2134 |
| Max | .78 | .6554 | .3734 | .503 | .4915 | .5596 | .4001 |
| Min | .407 | .4409 | .2801 | .2683 | .2591 | .2713 | .2 |
| Avg | .5332 | .5596 | .3217 | .4057 | .3105 | .3297 | .252 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 201 / 11 KV AKALAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8383 | 1.166 | 1.0288 | .9431 | .3086 | .3601 | .3429 |
| 2 | .8535 | 1.166 | 1.0288 | .9431 | .3086 | .3601 | .3429 |
| 3 | .884 | 1.166 | 1.0631 | 1.1145 | .3429 | .3772 | .3429 |
| 4 | .8993 | 1.2003 | 1.1145 | 1.1145 | .3429 | .3944 | .4115 |
| 5 | .8993 | 1.2689 | 1.286 | 1.2003 | .4115 | .4458 | .4458 |
| 6 | 1.0364 | 1.406 | 1.3375 | 1.2346 | .4458 | .5144 | .5144 |
| 7 | 1.0822 | 1.4575 | 1.3203 | 1.166 | .4973 | .5316 | .5316 |
| 8 | .3429 | .3429 | .3258 | .2572 | .3429 | .3429 | .3429 |
| 9 | .2229 | .2401 | .2229 | .2401 | .2058 | .2229 | .2401 |
| 10 | .2229 | .2743 | .2058 | .1715 | 1.3413 | 1.166 | .8916 |
| 11 | .2401 | .2743 | .2058 | .1715 | 1.8176 | 1.749 | 1.6156 |
| 12 | .2401 | .2572 | .2058 | .1886 | 1.9033 | 1.8861 | 1.6004 |
| 13 | .2572 | .2401 | .2058 | .1715 | 1.9376 | 1.8519 | 1.5242 |
| 14 | .2572 | .2743 | .2401 | .1715 | 1.7833 | 1.7147 | 1.387 |
| 15 | .2572 | .3086 | .2572 | .2058 | 1.7147 | 1.5775 | 1.326 |
| 16 | .2572 | .2743 | .2572 | .2572 | 1.6632 | 1.5432 | 1.2803 |
| 17 | .2743 | .2572 | .3086 | .2058 | 1.5947 | 1.5432 | 1.1431 |
| 18 | .2915 | .2572 | .2229 | .2229 | .2401 | .2058 | .2058 |
| 19 | .4801 | .3944 | .3086 | .3429 | .3429 | .3429 | .4115 |
| 20 | .463 | .4115 | .4115 | .4115 | .4287 | .4115 | .4458 |
| 21 | .4115 | .4287 | .4115 | .4115 | .3944 | .4115 | .4287 |
| 22 | 1.1145 | .823 | .823 | .3772 | | .4115 | .4115 |
| 23 | 1.166 | .9774 | .8573 | | .3944 | .3601 | .3944 |
| 24 | .8383 | 1.166 | .8688 | .8573 | .3086 | .3772 | .3429 |
| Max | 1.166 | 1.4575 | 1.3375 | 1.2346 | 1.9376 | 1.8861 | 1.6156 |
| Min | .2229 | .2401 | .2058 | .1715 | .2058 | .2058 | .2058 |
| Avg | .5762 | .6680 | .6049 | .5383 | .8292 | .7959 | .7052 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 202 / 11 KV KUSUMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5487 | | | .2439 | .2743 | .2439 |
| 2 | .5487 | | | .2743 | .2743 | .2439 |
| 3 | .5658 | | | .2439 | .2915 | .2439 |
| 4 | .5658 | | | .3048 | .3086 | .2743 |
| 5 | .583 | | | .3353 | .3258 | .3048 |
| 6 | .7716 | | | .3658 | .3429 | .3506 |
| 7 | 1.0117 | | | .3506 | .463 | .3506 |
| 8 | .7716 | .7202 | .703 | .7716 | .7373 | .6859 |
| 9 | .583 | .583 | .6173 | .583 | .583 | .583 |
| 10 | .2591 | .2743 | .3048 | .5658 | .5144 | .5144 |
| 11 | .2896 | .2743 | .3353 | .5487 | | .5658 |
| 12 | .3048 | .2896 | .3506 | .6344 | | .5658 |
| 13 | .2743 | .3201 | .3048 | .5487 | | .5658 |
| 14 | .3048 | .2743 | .3201 | .5487 | | .583 |
| 15 | .3048 | .2743 | .3048 | .5658 | | .583 |
| 16 | .3048 | .2591 | .3201 | .6173 | | .6001 |
| 17 | .2743 | | | .5487 | | .5487 |
| 18 | .6516 | | | .6687 | | .6173 |
| 19 | .6859 | | | .7373 | | .7888 |
| 20 | .7373 | | | .7545 | | .7716 |
| 21 | .7202 | | | .703 | | .7545 |
| 22 | .6687 | | | .3258 | | .2591 |
| 23 | .6001 | | | .2915 | | .2439 |
| 24 | .5487 | | .5658 | .2439 | .2915 | .2439 |
| Max | 1.0117 | .7202 | .703 | .7716 | .7373 | .7888 |
| Min | .2591 | .2591 | .3048 | .2439 | .2743 | .2439 |
| Avg | .5366 | .3632 | .4127 | .4907 | .4006 | .4786 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 203 / 11 KV EXP WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .0857 | .0514 | .0514 | .0514 | .0343 | .0857 |
| 2 | .0514 | .0857 | .0514 | .0514 | .0514 | .0171 | .0857 |
| 3 | .0514 | .0857 | .0514 | .0514 | .0686 | .0171 | .0857 |
| 4 | .0686 | .1029 | .0514 | .0514 | .0686 | .0343 | .12 |
| 5 | .0686 | .1372 | .0343 | .0514 | .0686 | .0343 | .12 |
| 6 | .0514 | .1372 | .0343 | .0514 | .0686 | .0343 | .12 |
| 7 | .0686 | .1543 | .0343 | .0514 | .0857 | .0514 | .1372 |
| 8 | .0857 | .0686 | .0514 | .0514 | .0686 | .0514 | .12 |
| 9 | .0857 | .0686 | .0686 | .0343 | .0857 | .0514 | .0857 |
| 10 | .0686 | .0686 | .0514 | .0514 | .0686 | .0857 | .0686 |
| 11 | .1029 | .0857 | .0514 | .0514 | .0514 | .1029 | .0857 |
| 12 | .1372 | .0343 | .0514 | .0343 | .0514 | .1029 | .0514 |
| 13 | .1372 | .0514 | .0343 | .0343 | .0514 | .0857 | .0514 |
| 14 | .1029 | .0343 | .0343 | .0343 | .0514 | .0857 | .0514 |
| 15 | .1029 | .0343 | .0343 | .0343 | .0514 | .0686 | .0343 |
| 16 | .1372 | .0343 | .0514 | .0343 | .0514 | .1372 | .0343 |
| 17 | .1372 | .0343 | .0343 | .0343 | .0686 | .1372 | .0857 |
| 18 | .1372 | .0343 | .0514 | .0343 | .0343 | .1029 | .0514 |
| 19 | .1029 | .0343 | .0514 | .0514 | .0343 | .1029 | .0686 |
| 20 | .1029 | .0343 | .0514 | .0343 | .0343 | .1372 | .0686 |
| 21 | .0857 | .0514 | .0514 | .0514 | .0343 | .1029 | .0686 |
| 22 | .0857 | .0514 | .0514 | .0514 | .0343 | .0857 | .0686 |
| 23 | .1029 | .0514 | .0514 | | .0343 | .0857 | .0686 |
| 24 | .0686 | .0857 | .0514 | .0514 | .0514 | .0343 | .0857 |
| Max | .1372 | .1543 | .0686 | .0514 | .0857 | .1372 | .1372 |
| Min | .0514 | .0343 | .0343 | .0343 | .0343 | .0171 | .0343 |
| Avg | .0922 | .0686 | .0471 | .0447 | .055 | .0743 | .0793 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 204 / 11 KV SUNLINE EXPRESS 1 NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6001 | | | .583 | .6001 | .6668 |
| 2 | .6668 | | | .583 | .6001 | .6668 |
| 3 | .7049 | | | .5658 | .6173 | .6668 |
| 4 | .7049 | | | .6001 | .6173 | .724 |
| 5 | .7049 | | | .6173 | .6344 | .7621 |
| 6 | .7049 | | | .6173 | .6344 | .7621 |
| 7 | .7621 | | | .6344 | .6173 | .7049 |
| 8 | .6859 | .6859 | .6287 | .6173 | .5658 | .7049 |
| 9 | .6478 | | .6859 | .6687 | .5487 | .6859 |
| 10 | .6859 | | .724 | .6859 | .6344 | .6478 |
| 11 | .7621 | | .8002 | .7373 | | .8002 |
| 12 | .7621 | | .8383 | .7202 | | .8192 |
| 13 | .7621 | | .8002 | .703 | | .8002 |
| 14 | .8002 | | .8192 | .6859 | | .7811 |
| 15 | .8383 | .0381 | .8383 | .6344 | | .7621 |
| 16 | .8383 | .0572 | .8383 | .6516 | | .7621 |
| 17 | | | | .6173 | | .7049 |
| 18 | | | | .5487 | | .6478 |
| 19 | | | | .5906 | | .6478 |
| 20 | | | | .5906 | | .6478 |
| 21 | | | | .5716 | | .6478 |
| 22 | | | | .5316 | | .6859 |
| 23 | | | | .5487 | | .6859 |
| 24 | .6668 | | .0953 | .6287 | .6001 | .6668 |
| Max | .8383 | .6859 | .8383 | .7373 | .6344 | .8192 |
| Min | .6001 | .0381 | .0953 | .5316 | .5487 | .6478 |
| Avg | .7234 | .2604 | .7068 | .6222 | .6064 | .7105 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 205 / 11 KV GOTANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8383 | | | .2915 | .3086 | .3258 |
| 2 | .823 | | | .3086 | .3086 | .3258 |
| 3 | .8078 | | | .3086 | .3086 | .3258 |
| 4 | .8745 | | | .3429 | .3258 | .3429 |
| 5 | .7621 | | | .3772 | .3772 | .3429 |
| 6 | 1.0364 | | | .3772 | .4458 | .3944 |
| 7 | 1.3108 | | | .3944 | .4115 | .3944 |
| 8 | .3086 | .2572 | .2915 | .3258 | .3086 | .2915 |
| 9 | .2229 | .2401 | .2058 | .2401 | .2229 | .1886 |
| 10 | .1886 | .2743 | .1715 | 1.3717 | .9431 | .9145 |
| 11 | .1715 | .1543 | .1715 | 2.0576 | | 1.829 |
| 12 | .1715 | .1715 | .1543 | 2.1091 | | 1.9357 |
| 13 | .1886 | .1715 | .1715 | 2.0919 | | 1.829 |
| 14 | .1715 | .1372 | .2058 | 1.9033 | | 1.6918 |
| 15 | | .1543 | .1715 | 1.9033 | | 1.5242 |
| 16 | .1372 | .1543 | .1715 | 1.9719 | | 1.1279 |
| 17 | .1372 | | | 1.7833 | | 1.4327 |
| 18 | .2058 | | | .2058 | | .2058 |
| 19 | .3086 | | | .3258 | | .3429 |
| 20 | .3258 | | | .3772 | | .3601 |
| 21 | .3086 | | | .3429 | | .3429 |
| 22 | .823 | | | .3258 | | .3258 |
| 23 | .9145 | | | .3258 | | .3258 |
| 24 | .823 | | .7926 | .2915 | .3086 | .3258 |
| Max | 1.3108 | .2743 | .7926 | 2.1091 | .9431 | 1.9357 |
| Min | .1372 | .1372 | .1543 | .2058 | .2229 | .1886 |
| Avg | .5156 | .1905 | .2508 | .8481 | .3881 | .7269 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 206 / 11 KV KAWATHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5658 | .583 | .6001 | .6173 | .6097 | .8916 | 1.1488 |
| 2 | .5658 | .583 | .583 | .6173 | .6859 | .8573 | 1.1488 |
| 3 | .583 | .583 | .6173 | .6859 | .7621 | .8573 | 1.1488 |
| 4 | .6173 | .6173 | .823 | .7716 | .9145 | .9431 | 1.2003 |
| 5 | .6859 | .6859 | .8916 | .7716 | .9907 | 1.0288 | 1.2689 |
| 6 | .9088 | .8745 | .9945 | .9431 | 1.0364 | 1.1488 | 1.406 |
| 7 | .8745 | .9774 | .9774 | .9259 | 1.0974 | 1.4403 | 1.4575 |
| 8 | .8573 | .7716 | .7716 | .8573 | .8573 | .7373 | .4115 |
| 9 | .6516 | .6173 | .5316 | .5658 | .5658 | .4973 | .583 |
| 10 | 1.0517 | .884 | .9145 | .7716 | .4287 | .3944 | .4801 |
| 11 | 1.9814 | 1.9509 | 1.6766 | 1.8004 | .4801 | .3772 | .4801 |
| 12 | 2.2253 | 1.829 | 1.6004 | 1.8004 | .4458 | .3772 | .463 |
| 13 | 2.1948 | 1.8138 | 1.5851 | 1.7147 | .4287 | .3772 | .463 |
| 14 | 2.1643 | 1.829 | 1.5242 | 1.5432 | .463 | .3601 | .4801 |
| 15 | 2.0729 | 1.6766 | 1.5242 | 1.6289 | 4.7325 | .3601 | .4801 |
| 16 | 1.9814 | 1.3717 | 1.5089 | 1.2689 | .4973 | .3772 | .5144 |
| 17 | 1.7528 | 1.2003 | 1.3717 | 1.2689 | .4973 | .4287 | .463 |
| 18 | .6516 | .6001 | .5487 | .6859 | .5658 | .6001 | .5487 |
| 19 | .823 | .7202 | .6516 | .7716 | .8402 | .8916 | .8059 |
| 20 | .823 | .7888 | .7202 | .7888 | .8573 | .8573 | .823 |
| 21 | .7545 | .7716 | .7888 | .7202 | .7373 | .7716 | .7888 |
| 22 | .6859 | .6859 | .6859 | .6344 | .6001 | 1.0288 | .7164 |
| 23 | .6173 | .6001 | .6001 | | 1.0117 | 1.1488 | .8535 |
| 24 | .5658 | .583 | .6001 | .6173 | .6097 | .9431 | 1.1488 |
| Max | 2.2253 | 1.9509 | 1.6766 | 1.8004 | 4.7325 | 1.4403 | 1.4575 |
| Min | .5658 | .583 | .5316 | .5658 | .4287 | .3601 | .4115 |
| Avg | 1.1107 | .9833 | .9621 | .9900 | .8631 | .7373 | .8034 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 207 / 11 KV SUNLINE EXPRESS 2
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0098 | | | .9945 | .9088 | 1.0669 |
| 2 | 1.0288 | | | .9945 | .9259 | 1.0669 |
| 3 | 1.0479 | | | 1.0288 | .9431 | 1.1431 |
| 4 | 1.0479 | | | 1.046 | .9431 | 1.2003 |
| 5 | 1.0479 | | | 1.0631 | .9602 | 1.1431 |
| 6 | 1.1622 | | | 1.0802 | .9602 | 1.105 |
| 7 | 1.1812 | | | 1.0974 | .9774 | 1.086 |
| 8 | 1.0098 | 1.0288 | .7811 | .9088 | .9088 | 1.105 |
| 9 | 1.0669 | | 1.0669 | 1.0631 | .9945 | 1.105 |
| 10 | 1.105 | | 1.2384 | 1.0631 | 1.0802 | 1.1431 |
| 11 | 1.2193 | | 1.2193 | 1.0631 | | 1.3336 |
| 12 | 1.2574 | | 1.2765 | 1.046 | | 1.3146 |
| 13 | 1.2574 | | 1.2574 | 1.1488 | | 1.2384 |
| 14 | 1.2193 | | 1.2384 | 1.1145 | | 1.1431 |
| 15 | 1.2193 | .0381 | 1.2384 | 1.0631 | | 1.1812 |
| 16 | 1.2574 | .0381 | 1.2193 | 1.0974 | | 1.2193 |
| 17 | | | | 1.1317 | | 1.2193 |
| 18 | | | | .9945 | | 1.1241 |
| 19 | | | | .9602 | | 1.1622 |
| 20 | | | | 1.086 | | 1.1431 |
| 21 | | | | 1.105 | | 1.1241 |
| 22 | | | | 1.0117 | | 1.105 |
| 23 | | | | .9259 | | 1.1241 |
| 24 | .9907 | | .0381 | 1.0288 | .9088 | 1.0669 |
| Max | 1.2574 | 1.0288 | 1.2765 | 1.1488 | 1.0802 | 1.3336 |
| Min | .9907 | .0381 | .0381 | .9088 | .9088 | 1.0669 |
| Avg | 1.1252 | .3683 | 1.0574 | 1.0465 | .9555 | 1.1526 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0884 | | .6097 | .5487 | 1.0534 | 1.0884 | 1.0288 |
| 2 | 1.0884 | .7882 | .5792 | .6097 | 1.0903 | 1.1072 | 1.0117 |
| 3 | 1.1072 | .8257 | .6097 | .5792 | 1.1088 | 1.1635 | .9945 |
| 4 | 1.1635 | .8445 | .6554 | .6859 | 1.1643 | 1.2198 | 1.0802 |
| 5 | 1.4638 | .9008 | .7316 | .7316 | 1.3121 | 1.4638 | 1.1317 |
| 6 | 1.6702 | .9195 | .8078 | .8383 | 1.5154 | 1.6702 | 1.5432 |
| 7 | 1.8016 | 1.3136 | 1.0669 | .9907 | 1.7556 | 1.4664 | 1.7147 |
| 8 | 1.313 | 1.201 | .823 | 1.166 | 1.2382 | 1.1595 | 1.406 |
| 9 | 1.1447 | 1.1831 | .8402 | .961 | .8014 | .823 | 1.0719 |
| 10 | .648 | .7716 | .823 | .7762 | .7673 | .5335 | .6036 |
| 11 | .7506 | .8573 | .7202 | .8131 | .7503 | .6401 | .7762 |
| 12 | .7332 | .7545 | .8573 | .8316 | .8526 | .7468 | .7762 |
| 13 | .7882 | .7716 | .7888 | .8686 | .9037 | .7011 | .8962 |
| 14 | .8185 | .823 | .7888 | .8501 | .9208 | .7316 | .8596 |
| 15 | .8526 | .823 | .823 | .7947 | .8526 | .7164 | .823 |
| 16 | .7673 | .8402 | .7888 | .8316 | .8014 | .7468 | .8596 |
| 17 | .6193 | .8573 | .823 | .961 | .7162 | .7926 | .7865 |
| 18 | .9378 | .8916 | .8745 | .961 | .7506 | .7888 | .7865 |
| 19 | 1.2765 | 1.2517 | 1.2689 | 1.3676 | 1.1936 | 1.2346 | 1.3717 |
| 20 | 1.4638 | 1.3375 | 1.3203 | 1.386 | 1.33 | 1.4575 | 1.39 |
| 21 | 1.3887 | 1.3032 | 1.2346 | 1.386 | 1.4075 | 1.4232 | 1.3717 |
| 22 | .7506 | .6859 | .6706 | 1.3306 | 1.3512 | 1.2689 | 1.4266 |
| 23 | .7694 | .6554 | .6554 | 1.2567 | 1.1635 | 1.2003 | 1.2986 |
| 24 | | .7506 | 1.0791 | .5792 | 1.1088 | 1.126 | 1.0631 |
| Max | 1.8016 | 1.3375 | 1.3203 | 1.386 | 1.7556 | 1.6702 | 1.7147 |
| Min | .6193 | .6554 | .5792 | .5487 | .7162 | .5335 | .6036 |
| Avg | 1.0611 | .9283 | .8433 | .9210 | 1.0796 | 1.0529 | 1.0863 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV EKVIRA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0512 | .0514 | .0686 | .0857 | .0739 | .0514 | .1029 |
| 2 | .0512 | .0514 | .0514 | .0686 | .0554 | .0857 | .0857 |
| 3 | .0563 | .0686 | .0514 | .0857 | .0554 | .0514 | .0857 |
| 4 | .0563 | .0514 | .0514 | .0514 | .0924 | .0857 | .0857 |
| 5 | .0751 | .0686 | .0686 | .0343 | .0554 | .0686 | .0857 |
| 6 | .0938 | .0343 | .0857 | .1029 | .037 | .0343 | .0857 |
| 7 | .1314 | .0343 | .0686 | .0514 | .0924 | .0343 | .0514 |
| 8 | .0682 | .0514 | .0514 | .0343 | .1109 | .0686 | |
| 9 | .0341 | .12 | .0514 | .1109 | .0857 | .0514 | .0739 |
| 10 | .0341 | .0514 | .12 | .0924 | .12 | .12 | .037 |
| 11 | .1126 | .0514 | .0514 | .037 | .1029 | .1029 | .0554 |
| 12 | .1194 | .0514 | .0857 | .1109 | .1029 | .1029 | .037 |
| 13 | .1194 | .0686 | .0343 | .1294 | .0686 | .0857 | .037 |
| 14 | .1194 | .0857 | .0514 | .0739 | .0686 | .0686 | .0554 |
| 15 | .0512 | .0857 | .12 | .0554 | .1029 | .1029 | |
| 16 | .0682 | .0514 | .0514 | .1294 | .0514 | .1029 | .1109 |
| 17 | .0341 | .0514 | .1029 | .0554 | .12 | .0514 | .0554 |
| 18 | .0682 | .0514 | .0514 | .037 | .0343 | .0514 | .0554 |
| 19 | .0514 | .0514 | .0343 | .0554 | .0514 | .1029 | .037 |
| 20 | .0686 | .0514 | .0343 | .1294 | .0514 | .1029 | .0554 |
| 21 | .0857 | .0686 | .0686 | .0739 | .0686 | .0514 | .0554 |
| 22 | .1029 | .0686 | .0514 | .0554 | .0343 | .1029 | .0739 |
| 23 | .0686 | .0686 | .0686 | .0554 | .0343 | .1029 | .0554 |
| 24 | .1126 | .0514 | .0514 | .0343 | .0554 | .0343 | .1029 |
| Max | .1314 | .12 | .12 | .1294 | .12 | .12 | .1109 |
| Min | .0341 | .0343 | .0343 | .0343 | .0343 | .0343 | .037 |
| Avg | .0764 | .0600 | .0636 | .0729 | .0719 | .0757 | .0673 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 203 / 11 KV HENDRUN SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6381 | .6173 | .5658 | .5914 | .5818 | .5335 |
| 2 | | .5968 | .6001 | .583 | .5914 | .6005 | .5182 |
| 3 | | .6756 | .6516 | .5658 | .5914 | .6005 | .4877 |
| 4 | | .9758 | .7202 | .6344 | .6099 | .7131 | .6401 |
| 5 | | 1.0509 | .8573 | .823 | .6653 | .8445 | .7316 |
| 6 | | 1.1072 | 1.1145 | 1.0117 | .8686 | .9383 | .7316 |
| 7 | | 1.2198 | 1.1145 | 1.0631 | 1.1643 | 1.2277 | 1.1584 |
| 8 | | 1.0884 | .7888 | .9431 | .8316 | .7332 | .823 |
| 9 | | .583 | .5487 | .6838 | .5286 | .5144 | .7762 |
| 10 | | .7164 | .5792 | .5914 | | .2572 | .4938 |
| 11 | | .8383 | .7011 | .8316 | .5627 | .3086 | .2772 |
| 12 | | .8535 | .7316 | .8686 | .4774 | .4287 | .3326 |
| 13 | | .8383 | .7011 | .8316 | .4263 | .4287 | .2772 |
| 14 | | .823 | .7164 | .6283 | .4774 | .4287 | .5544 |
| 15 | | .7926 | .6706 | .6283 | .4774 | .5144 | |
| 16 | | .7621 | .6097 | .7947 | .5115 | .4801 | .499 |
| 17 | | .5487 | .6097 | 7.6879 | .5115 | .4458 | .5175 |
| 18 | | .5658 | .4801 | .4805 | 1.5005 | .4801 | .5729 |
| 19 | | .8059 | .4458 | .8871 | .7673 | .7373 | .7947 |
| 20 | .9195 | .8573 | .8059 | .9425 | .8014 | .823 | .8501 |
| 21 | .9195 | .8402 | .7545 | .8686 | .8445 | .7716 | .7762 |
| 22 | .7882 | .7716 | .703 | .6468 | .7131 | .6097 | .7577 |
| 23 | .6756 | .6859 | .6516 | .6099 | .6381 | .5792 | .6401 |
| 24 | | .6381 | .6516 | .6001 | .5729 | .563 | .5487 |
| Max | .9195 | 1.2198 | 1.1145 | 7.6879 | 1.5005 | 1.2277 | 1.1584 |
| Min | .6756 | .5487 | .4458 | .4805 | .4263 | .2572 | .2772 |
| Avg | .8257 | .8031 | .7010 | 1.0322 | .6837 | .6088 | .6214 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SONEWADI SINGLE SINGLE PHASING
PHASING Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3003 | .6005 | .5792 | .5792 | .2772 | .3378 | .3086 |
| 2 | .3003 | .6193 | .5487 | .6554 | .2957 | .3378 | .2915 |
| 3 | .319 | .7131 | .5792 | .6859 | .3142 | .3566 | .2743 |
| 4 | .3941 | .8445 | .6401 | .6554 | .3326 | .4692 | .3429 |
| 5 | .6005 | .8632 | .7316 | .7926 | .499 | .5456 | .4287 |
| 6 | .7131 | .9008 | .8078 | .8688 | .7023 | .6381 | .6687 |
| 7 | .8069 | 1.126 | 1.0669 | 1.1431 | .5914 | .7506 | .7716 |
| 8 | .4879 | .4504 | .5144 | .6344 | .6468 | .5627 | .5658 |
| 9 | .4129 | .3258 | .4115 | .462 | .4263 | .3601 | .439 |
| 10 | .9383 | .3258 | .2915 | .2772 | .5968 | .5792 | .6584 |
| 11 | 1.0134 | .2743 | .2058 | .2587 | .6005 | .884 | .7865 |
| 12 | 1.126 | .2058 | .1372 | .1848 | 1.0231 | .9145 | .961 |
| 13 | 1.1072 | .1886 | .1715 | .1848 | 1.0913 | .7316 | 1.1273 |
| 14 | .7131 | .1715 | .2058 | .1848 | 1.1072 | .7621 | .9055 |
| 15 | .8014 | .2058 | .1715 | .2033 | .9549 | .6859 | .9055 |
| 16 | .8257 | .2743 | .1886 | .2402 | .9719 | .6706 | .7392 |
| 17 | .7694 | .2743 | .2058 | .2772 | 1.0321 | .6401 | .7947 |
| 18 | .3753 | .3086 | .2229 | .3326 | .1705 | .2401 | .3696 |
| 19 | .5818 | .5487 | .4458 | .5544 | .5115 | .4801 | .462 |
| 20 | .4504 | .5144 | .5144 | .5175 | .563 | .5144 | .5359 |
| 21 | .341 | .4115 | .5658 | .462 | .6005 | .4287 | .3696 |
| 22 | .563 | .7202 | .6554 | .3881 | .4129 | .3772 | |
| 23 | .563 | .6859 | .6706 | .3511 | .0375 | .3429 | .3475 |
| 24 | .7429 | .5818 | .6516 | .6249 | .2772 | .3378 | .3086 |
| Max | 1.126 | 1.126 | 1.0669 | 1.1431 | 1.1072 | .9145 | 1.1273 |
| Min | .3003 | .1715 | .1372 | .1848 | .0375 | .2401 | .2743 |
| Avg | .6353 | .5056 | .4660 | .4799 | .5849 | .5395 | .5810 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV KULTHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1194 | .3753 | .3258 | .3258 | .2218 | .2387 | .2286 |
| 2 | .1194 | .341 | .3086 | .3601 | .2218 | .2387 | .2286 |
| 3 | .1194 | .3941 | .3086 | .3429 | .2218 | .2815 | .2439 |
| 4 | .1501 | .4504 | .4287 | .3944 | .2402 | .2899 | .2743 |
| 5 | .1877 | .4879 | .4801 | .4801 | .2772 | .3378 | .2743 |
| 6 | .2252 | .5067 | .5487 | .5144 | .3142 | .3753 | .2896 |
| 7 | .7162 | .6005 | .583 | .6001 | .5359 | .6756 | .5182 |
| 8 | .3922 | .5255 | .4801 | .4801 | .4066 | .4129 | .3086 |
| 9 | .2728 | .2572 | .2743 | .3142 | .2558 | .2058 | .2743 |
| 10 | .1705 | .2743 | .2286 | .3326 | .2252 | .1886 | .2012 |
| 11 | .1535 | .381 | .3048 | .3881 | .2046 | .1715 | .1829 |
| 12 | .1364 | .442 | .1524 | .3511 | .1705 | .1543 | .1829 |
| 13 | .1364 | .4268 | .3201 | .3696 | .1813 | .2058 | .2378 |
| 14 | .244 | .3963 | .2896 | .3511 | .2142 | .2401 | .2378 |
| 15 | .2558 | .3658 | .2591 | .3511 | .2558 | .2058 | .2378 |
| 16 | .2387 | .3048 | .2896 | .3511 | .2217 | .2058 | .2743 |
| 17 | .2387 | .2743 | .2439 | .3326 | | .2229 | .2378 |
| 18 | .2501 | .2229 | .1372 | .2402 | .2558 | .2572 | .2926 |
| 19 | .4092 | .4287 | .3944 | .4435 | .3751 | .3772 | .4024 |
| 20 | .5067 | .4458 | .4458 | .462 | .4263 | .4458 | .4572 |
| 21 | .5255 | .4287 | .4287 | .462 | .4504 | .4287 | .4755 |
| 22 | .4692 | .3772 | .4115 | .2587 | .2627 | .2743 | .2561 |
| 23 | .3941 | .3429 | .3772 | .2587 | .2627 | .2439 | .2378 |
| 24 | | .3753 | .3429 | .3258 | .2402 | .244 | .2286 |
| Max | .7162 | .6005 | .583 | .6001 | .5359 | .6756 | .5182 |
| Min | .1194 | .2229 | .1372 | .2402 | .1705 | .1543 | .1829 |
| Avg | .2796 | .3927 | .3485 | .3788 | .2801 | .2884 | .2826 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 206 / 11 KV ERCON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0222 | .0343 | .0274 | .0257 | .024 | .0343 | |
| 2 | .0244 | .0343 | .0274 | .0257 | .024 | .0343 | .0274 |
| 3 | .0244 | .0343 | .0274 | .0274 | .024 | .0343 | .0274 |
| 4 | .0244 | .0343 | .0274 | .0257 | | .0343 | .0274 |
| 5 | .0244 | .0343 | .0274 | .0274 | .0222 | .0343 | .0274 |
| 6 | .0225 | .0343 | .0257 | .0257 | .0222 | .0343 | .0274 |
| 7 | | .0343 | | | | .0343 | |
| 19 | .0375 | .0326 | .0274 | .024 | .0343 | .0274 | .0245 |
| 20 | .0343 | .0291 | .0274 | .024 | .0343 | .0274 | .0245 |
| 21 | .0343 | .0274 | .0257 | .0259 | .0343 | .0274 | .0245 |
| 22 | .0343 | .0274 | .0257 | .0245 | .0343 | .0274 | .0245 |
| 23 | .0343 | .0274 | .0274 | .024 | .0343 | .0274 | .0238 |
| 24 | .0244 | .0343 | .0274 | .0274 | .0245 | .0343 | .0274 |
| Max | .0375 | .0343 | .0274 | .0274 | .0343 | .0343 | .0274 |
| Min | .0222 | .0274 | .0257 | .024 | .0222 | .0274 | .0238 |
| Avg | .0285 | .0322 | .0270 | .0256 | .0284 | .0316 | .0260 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 201 / 11 KV MUKTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | .4755 | .4161 | .421 | .0732 | .061 | .0732 |
| 2 | .4572 | .4755 | .4161 | .421 | .0732 | .061 | .0732 |
| 3 | .4572 | .4161 | .4161 | .421 | .0732 | .061 | .0701 |
| 4 | .5335 | .4877 | .4161 | .4534 | .0732 | .061 | .0671 |
| 5 | .5792 | .4877 | .4458 | .4858 | .0732 | .061 | .0716 |
| 6 | .6097 | .5624 | .535 | .5506 | .0732 | .0579 | .1086 |
| 7 | .6859 | .7682 | .7133 | .7125 | .0732 | .0579 | .1086 |
| 8 | .0762 | .061 | .0594 | .0648 | .0663 | .0556 | .1086 |
| 9 | .0572 | .061 | .0594 | .061 | .0633 | .0556 | .0633 |
| 10 | .0579 | .061 | .0446 | .0701 | .6173 | .5418 | .3795 |
| 11 | .0617 | .0457 | .0446 | .0701 | .5243 | .8429 | .6325 |
| 12 | .0693 | .0457 | .0446 | .0701 | .8124 | .8128 | .8855 |
| 13 | .0716 | .0457 | .0446 | .0701 | .8951 | .7225 | .8223 |
| 14 | .0716 | .0457 | .0446 | .0663 | .884 | .5418 | .8223 |
| 15 | .0716 | .0457 | .0446 | .0663 | .7316 | .6321 | .6874 |
| 16 | .0549 | .0457 | .0446 | .0663 | .3384 | .6622 | .6874 |
| 17 | .0549 | .0457 | .0446 | .0663 | .4512 | .7225 | .6249 |
| 18 | .0465 | .0914 | .0446 | .0747 | .6203 | .0914 | .0533 |
| 19 | .1158 | .1219 | .0446 | .2054 | .1006 | .1097 | .0655 |
| 20 | .1158 | .1219 | .0446 | .2054 | .1006 | .0823 | .0625 |
| 21 | .1158 | .1219 | .0446 | .1448 | .1067 | .0823 | .1219 |
| 22 | .5418 | .5335 | .5647 | .0579 | .061 | .0823 | .064 |
| 23 | .4816 | .5487 | .4755 | .0579 | .061 | .0823 | .0671 |
| 24 | .4239 | .4816 | .4268 | .4458 | .0633 | .0655 | .0949 |
| Max | .6859 | .7682 | .7133 | .7125 | .8951 | .8429 | .8855 |
| Min | .0465 | .0457 | .0446 | .0579 | .061 | .0556 | .0533 |
| Avg | .2612 | .2582 | .2283 | .2220 | .2921 | .2753 | .2840 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 202 / 11 KV ANCHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .1806 | .1875 | .2241 | .125 | .1219 | .1619 |
| 2 | .1372 | .1505 | .1875 | .2241 | .1094 | .125 | .1619 |
| 3 | .1524 | .1505 | .1875 | .2241 | .1094 | .125 | .1619 |
| 4 | .1524 | .1505 | .1875 | .2241 | .125 | .1524 | .1791 |
| 5 | .1677 | .1806 | .2187 | .2881 | .1875 | .1829 | .2149 |
| 6 | .1677 | .2107 | .25 | .3201 | .2656 | .2286 | .2686 |
| 7 | .1981 | .286 | .3437 | .3201 | .3125 | .2591 | .2686 |
| 8 | .2439 | .1067 | .1406 | .08 | .1875 | .1372 | .2149 |
| 9 | .1372 | .1067 | .1406 | .08 | .125 | .1219 | .1791 |
| 10 | .1219 | .1067 | .1406 | .08 | .2187 | .1829 | .1791 |
| 11 | .0914 | .1067 | .1406 | .08 | .3125 | .3048 | .2401 |
| 12 | .0762 | .1067 | .0781 | .096 | .3125 | .3048 | .3201 |
| 13 | .0762 | .1067 | .0937 | .096 | | .2286 | .2688 |
| 14 | .0914 | .1067 | .0937 | .08 | .3125 | .2286 | .2688 |
| 15 | .0762 | .1067 | .0937 | .112 | .3125 | .2286 | .253 |
| 16 | .1219 | .1067 | .0937 | .128 | .3125 | .1829 | .3163 |
| 17 | .1219 | .1219 | .0937 | .112 | .2187 | .2134 | .2214 |
| 18 | .1067 | .1219 | .125 | .08 | .2343 | .1524 | .0914 |
| 19 | .2439 | .1829 | .25 | .128 | .2343 | .2286 | .2134 |
| 20 | .2591 | .1829 | .25 | .2241 | .2031 | .2286 | .2134 |
| 21 | .2134 | .1829 | .25 | .2241 | .1875 | .1829 | .1677 |
| 22 | .2107 | .2439 | .2343 | .192 | .1562 | .1524 | .1524 |
| 23 | .2408 | .2439 | .2343 | .16 | .1562 | .1524 | .1219 |
| 24 | .1372 | .2408 | .1829 | .2187 | .128 | .125 | .1524 |
| Max | .2591 | .286 | .3437 | .3201 | .3125 | .3048 | .3201 |
| Min | .0762 | .1067 | .0781 | .08 | .1094 | .1219 | .0914 |
| Avg | .1534 | .1580 | .1749 | .1665 | .2107 | .1896 | .2080 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 203 / 11 KV MUKTI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .5975 | .5601 | .5601 | .5975 | .6036 | .6602 |
| 2 | .5601 | .5975 | .5601 | .5487 | .5601 | .6036 | .6602 |
| 3 | .5601 | .6722 | .6036 | .5601 | .5601 | .6413 | .6602 |
| 4 | .9335 | .8299 | .679 | .7468 | .7468 | .7167 | .8299 |
| 5 | 1.419 | 1.1694 | 1.1317 | 1.1203 | 1.2696 | 1.2449 | 1.3203 |
| 6 | 1.7924 | 1.6221 | 1.6598 | 1.643 | 1.7551 | 1.5278 | 1.6975 |
| 7 | 1.7737 | 1.6598 | 1.6975 | 1.6032 | 1.7551 | 1.6975 | 1.6975 |
| 8 | 1.419 | 1.4937 | 1.3203 | 1.3392 | 1.1949 | .6348 | 1.3203 |
| 9 | 1.3575 | 1.1203 | .9808 | 1.1317 | .9709 | 1.0082 | 1.2826 |
| 10 | 1.086 | .9709 | .8402 | 1.0269 | .924 | .8402 | .9431 |
| 11 | .9335 | .9709 | .7468 | .9709 | .924 | .7468 | .8048 |
| 12 | .7468 | .7842 | .5601 | .7468 | .7392 | .7095 | .695 |
| 13 | .7468 | .7468 | .5975 | .8048 | .8413 | .7095 | .7023 |
| 14 | .7392 | .6722 | .5975 | .7316 | .8688 | .8215 | .7023 |
| 15 | .8131 | .6722 | .6722 | .7316 | .8048 | .8402 | .7095 |
| 16 | .9145 | .6722 | .6722 | .7392 | .8413 | .8215 | .7095 |
| 17 | .7842 | .7468 | .7468 | .7392 | .9145 | .8215 | .7842 |
| 18 | .8954 | .9335 | .7468 | .7087 | .788 | .8589 | .7316 |
| 19 | 1.2696 | 1.2696 | 1.1576 | 1.1163 | 1.1458 | 1.1203 | 1.1949 |
| 20 | 1.1576 | 1.2136 | 1.0269 | 1.1203 | 1.1088 | 1.0829 | 1.1576 |
| 21 | .8589 | .9335 | .8215 | .7964 | .8402 | .8402 | .8962 |
| 22 | .7468 | .7468 | .7468 | .7316 | .7468 | .7468 | .7468 |
| 23 | .7095 | .5975 | .6722 | .6722 | .6348 | .6535 | .6722 |
| 24 | .6348 | .6348 | .5601 | .6036 | .6219 | .5975 | .6602 |
| Max | 1.7924 | 1.6598 | 1.6975 | 1.643 | 1.7551 | 1.6975 | 1.6975 |
| Min | .5601 | .5975 | .5601 | .5487 | .5601 | .5975 | .6602 |
| Avg | .9755 | .9303 | .8483 | .8956 | .9231 | .8704 | .9266 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 204 / 11 KV EXP.WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .0335 |
| 2 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .0335 |
| 3 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .032 |
| 4 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .0339 |
| 5 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .0358 |
| 6 | .0514 | .0343 | .0351 | .0335 | .0286 | .0271 | .0358 |
| 7 | .0343 | .0343 | .0351 | .0335 | .0429 | .0406 | .0358 |
| 8 | .0343 | .0343 | .0351 | .0335 | .0194 | .0232 | .0362 |
| 9 | .0332 | .0343 | .0351 | .0503 | .0286 | .0316 | |
| 10 | .0332 | .0343 | .0351 | .0335 | .0463 | .0316 | |
| 11 | .0349 | .0343 | .0351 | .0701 | .0463 | .0633 | .0305 |
| 12 | .0232 | .0343 | .0351 | .0537 | .0293 | .0602 | .0457 |
| 13 | .0372 | .0343 | .0526 | .0469 | .0293 | .0549 | .032 |
| 14 | .0372 | .0343 | .0526 | .0663 | .0457 | .0564 | .032 |
| 15 | .052 | .0343 | .0526 | .0429 | .0463 | .0274 | .0373 |
| 16 | .0446 | .0343 | .0526 | .0429 | .0267 | .0274 | .0373 |
| 17 | .0446 | .0343 | .0526 | .0754 | .0274 | .0274 | .0373 |
| 18 | .0347 | .0343 | .0526 | .0566 | .0412 | .0274 | .0373 |
| 19 | .0347 | .0343 | .0526 | .056 | .0532 | .0293 | .0747 |
| 20 | .0347 | .0343 | .0526 | .056 | .0532 | .0293 | .0747 |
| 21 | .0347 | .0343 | .0701 | .0316 | .056 | .0274 | .0747 |
| 22 | .0347 | .0343 | .0701 | .0316 | .0412 | .0278 | .0343 |
| 23 | .0347 | .0343 | .0526 | .0316 | .0412 | .0286 | .0335 |
| 24 | .0514 | .0347 | .0343 | .0526 | .0316 | .0457 | .0316 |
| Max | .052 | .0347 | .0701 | .0754 | .056 | .0633 | .0747 |
| Min | .0232 | .0343 | .0343 | .0316 | .0194 | .0232 | .0305 |
| Avg | .0407 | .0343 | .0445 | .0444 | .0366 | .0343 | .0404 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 201 / 11 KV SANJORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3338 | .4149 | .3978 | .4315 | .4158 | .9658 | .9824 |
| 2 | .3342 | .3651 | .4315 | .448 | .4995 | .9991 | .8659 |
| 3 | .3672 | .4501 | .4646 | .4486 | .751 | 1.0146 | .7493 |
| 4 | .4172 | .484 | .5156 | .4984 | .8335 | .9647 | .6487 |
| 5 | .5841 | .518 | .5988 | .5988 | .9824 | 1.2308 | .8815 |
| 6 | .7938 | .5848 | .6827 | .7318 | 1.0002 | 1.3306 | 1.2142 |
| 7 | .7499 | .5359 | .6501 | .716 | 1.0288 | 1.4637 | 1.4304 |
| 8 | .5687 | .4359 | .5674 | .6168 | .515 | .5156 | .499 |
| 9 | .3772 | .3189 | .4005 | .4001 | .3647 | .3659 | .4158 |
| 10 | 1.6448 | 1.5442 | 1.0861 | .9669 | 1.0288 | .2661 | .3035 |
| 11 | 2.0903 | 1.7436 | 1.719 | 1.5364 | .2658 | .2828 | .2498 |
| 12 | 2.0106 | 1.8568 | 1.6504 | 1.5354 | .2658 | .2498 | .2498 |
| 13 | 1.9861 | 1.7023 | 1.5135 | 1.5021 | .2495 | .2664 | .2498 |
| 14 | 1.615 | 1.6318 | 1.3789 | 1.3352 | .2661 | .2498 | .2498 |
| 15 | 1.5706 | 1.5284 | 1.2446 | 1.1683 | .2994 | | .2667 |
| 16 | 1.5135 | 1.4586 | 1.21 | 1.0848 | .316 | .2498 | .2664 |
| 17 | 1.2568 | 1.3064 | 1.1424 | 1.0348 | .316 | .2498 | .333 |
| 18 | .4115 | .396 | .3638 | 1.0348 | .316 | .3663 | .333 |
| 19 | .5438 | .5775 | .5298 | .5007 | .4496 | .4829 | .5668 |
| 20 | .5115 | .5623 | .4636 | .4506 | .4329 | .4668 | .5335 |
| 21 | .4961 | .5292 | .4973 | .4673 | .4673 | .4834 | .4834 |
| 22 | .4801 | .4801 | .4807 | .5815 | .9991 | 1.0336 | .8835 |
| 23 | .4475 | .445 | .431 | .6479 | 1.0157 | 1.3336 | 1.0836 |
| 24 | .4172 | .4315 | .4641 | .6147 | .5835 | .9991 | 1.1823 |
| Max | 2.0903 | 1.8568 | 1.719 | 1.5364 | 1.0288 | 1.4637 | 1.4304 |
| Min | .3338 | .3189 | .3638 | .4001 | .2495 | .2498 | .2498 |
| Avg | .8967 | .8459 | .7868 | .8063 | .5693 | .6883 | .6218 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 203 / 11 KV KUNDANE (WAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6602 | .4828 | .4854 | .442 | .4904 | .5877 | .5865 |
| 2 | .7545 | .569 | .5201 | .4799 | .6036 | .5687 | .6628 |
| 3 | .8505 | .6538 | .5578 | .5171 | .7545 | .5313 | .7189 |
| 4 | .9017 | .6187 | .6471 | .5558 | .945 | .5693 | .8127 |
| 5 | .9808 | .6882 | .7746 | .6669 | 1.0384 | .7211 | 1.0226 |
| 6 | 1.0206 | .9967 | .9273 | .8794 | 1.0573 | .9678 | 1.2499 |
| 7 | .8659 | .9452 | 1.0252 | .9969 | 1.0751 | 1.1363 | 1.2878 |
| 8 | .677 | .7963 | .797 | .8901 | .7204 | .797 | .8349 |
| 9 | .454 | .6036 | .4749 | .6256 | .547 | .5497 | .5693 |
| 10 | .4554 | .5292 | .3985 | .4934 | .4438 | .3077 | .2701 |
| 11 | .3969 | .454 | .378 | .4175 | .7546 | .6562 | .8154 |
| 12 | .3784 | .4373 | .3757 | .3961 | .9819 | .7344 | .8807 |
| 13 | .4198 | .4554 | .3371 | | .8292 | .6919 | .9442 |
| 14 | .3957 | .4554 | .4124 | .4175 | .8991 | .7423 | .7611 |
| 15 | .4518 | .4536 | .4145 | | .7656 | .4005 | .6331 |
| 16 | .499 | .5041 | .4518 | .4329 | .6508 | .5501 | .6401 |
| 17 | .6361 | .5051 | .2083 | .4137 | .6041 | .3864 | .6507 |
| 18 | .7378 | .6011 | .5448 | .5658 | .5313 | .6205 | .6413 |
| 19 | .9289 | .9214 | .8901 | .872 | .8522 | .9459 | .891 |
| 20 | .8341 | .8883 | .8531 | .8068 | .7575 | .909 | .8539 |
| 21 | .8151 | .8676 | .7575 | .739 | .7954 | .8324 | .8341 |
| 22 | .6221 | .6387 | .5286 | .7598 | .6831 | .7386 | .7204 |
| 23 | .5524 | .5684 | .4368 | .7182 | .6256 | .6249 | .6249 |
| 24 | .415 | .5345 | .4528 | .5888 | .5888 | .5687 | .5877 |
| Max | 1.0206 | .9967 | 1.0252 | .9969 | 1.0751 | 1.1363 | 1.2878 |
| Min | .3784 | .4373 | .2083 | .3961 | .4438 | .3077 | .2701 |
| Avg | .6543 | .6320 | .5687 | .6216 | .7498 | .6724 | .7706 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 204 / 11 KV GHV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3158 | .2275 | .0139 | .3765 | .2432 | .0205 | .0322 |
| 2 | .2778 | .2654 | .014 | .3753 | .1871 | .0205 | .033 |
| 3 | .2795 | .2849 | .014 | .4049 | .2259 | .0206 | .0338 |
| 4 | .1859 | .3416 | .0133 | .4715 | .2263 | .0211 | .0326 |
| 5 | .0374 | .3799 | .0132 | .5004 | .2646 | .0214 | .0141 |
| 6 | .0374 | .3412 | .0207 | .4904 | .0566 | .0144 | .0177 |
| 7 | .0374 | .0215 | .0228 | .0217 | .0464 | .0146 | .0179 |
| 8 | .0376 | .0142 | .0232 | .0284 | .0464 | .0166 | .0496 |
| 9 | .0935 | .0187 | .0571 | .0561 | .0373 | .2966 | .057 |
| 10 | .4673 | .021 | .5123 | .0208 | .0132 | .0151 | .0761 |
| 11 | .5233 | .021 | .2222 | .3528 | .0571 | .3612 | .0571 |
| 12 | .4692 | .021 | .1047 | .4904 | .0096 | .3654 | .0761 |
| 13 | .4711 | .021 | .4744 | .5093 | .0258 | .3206 | .043 |
| 14 | .0722 | .0124 | .5129 | .4715 | .0086 | .3006 | .0517 |
| 15 | .0672 | .018 | .5647 | .4904 | .0361 | .1046 | .057 |
| 16 | .4522 | .0181 | .4904 | .4596 | .0758 | .1768 | .0544 |
| 17 | .0206 | .0232 | .4914 | .4045 | .0919 | .0569 | .0348 |
| 18 | .0151 | .0181 | .4639 | .4904 | .0129 | .238 | .0758 |
| 19 | .0306 | .0181 | .5303 | .472 | .0284 | .2277 | .042 |
| 20 | .0195 | .0182 | .4692 | .3772 | .0292 | .2094 | .0418 |
| 21 | .2115 | .0529 | .4321 | .3961 | .0293 | .0275 | .0298 |
| 22 | .299 | .0344 | .4969 | .2519 | .0206 | .0307 | .2282 |
| 23 | .2635 | .0345 | .4611 | .0249 | .0205 | .0298 | .2849 |
| 24 | .3206 | .2469 | .0138 | .0352 | .0374 | .0205 | .032 |
| Max | .5233 | .3799 | .5647 | .5093 | .2646 | .3654 | .2849 |
| Min | .0151 | .0124 | .0132 | .0208 | .0086 | .0144 | .0141 |
| Avg | .2086 | .1031 | .2680 | .3322 | .0763 | .1221 | .0614 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 201 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .015 | .0267 | .015 | | .0934 | .0896 | |
| 2 | .0149 | .0267 | .015 | .0343 | .0934 | .0896 | .1886 |
| 3 | .015 | .0267 | .0149 | | .0934 | .0896 | |
| 4 | .0149 | .0267 | .015 | .0343 | .1067 | .1195 | .1886 |
| 5 | .0149 | .0267 | .0149 | | .1334 | .1494 | |
| 6 | .0149 | .0267 | .015 | .0343 | .16 | .2091 | .3086 |
| 7 | .0149 | .0267 | .015 | .0343 | .1867 | .239 | .3944 |
| 8 | .0149 | .0267 | .015 | | .0171 | .0149 | |
| 9 | .0171 | .0171 | .015 | .0343 | | | .0171 |
| 10 | .2429 | .3201 | .2743 | .1334 | .0149 | | .0133 |
| 11 | .5335 | .7467 | .4801 | .3868 | .0149 | .0343 | .0133 |
| 12 | .5868 | .8257 | .4801 | | .0149 | | .0133 |
| 13 | .6001 | .7467 | .5487 | | .0149 | .0171 | .0133 |
| 14 | .6001 | .766 | .5487 | .3201 | .0149 | | .0133 |
| 15 | | .7327 | .5144 | .3201 | .0149 | .0171 | .0133 |
| 16 | | .6818 | .3601 | .3067 | .0149 | | .0133 |
| 17 | | .5975 | .3601 | .2934 | .015 | .0857 | .0133 |
| 18 | .0171 | .0167 | .0343 | .0171 | .0149 | | .0133 |
| 19 | .0343 | .0167 | | .0343 | .0149 | .0171 | .0343 |
| 20 | .0343 | .0167 | .0343 | .0343 | .0149 | | .0343 |
| 21 | .0343 | .0167 | | .0343 | .0149 | .0171 | .0343 |
| 22 | .0267 | .0167 | .0343 | .08 | .0896 | .1715 | .12 |
| 23 | .0267 | .0167 | .0343 | .08 | .0896 | .2058 | .1334 |
| 24 | .0135 | .0267 | .0149 | .0343 | .08 | .0896 | .2058 |
| Max | .6001 | .8257 | .5487 | .3868 | .1867 | .239 | .3944 |
| Min | .0135 | .0167 | .0149 | .0171 | .0149 | .0149 | .0133 |
| Avg | .1375 | .2406 | .1752 | .1248 | .0575 | .0974 | .0890 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 202 / 11 KV NIMGUL AG-2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .3734 | .3286 | | | | |
| 2 | .3286 | .3734 | .4481 | .5144 | | | |
| 3 | .3594 | .4001 | .5377 | | | | |
| 4 | .3889 | .4268 | .5975 | .5144 | | | |
| 5 | .5377 | .5335 | .6871 | | | | |
| 6 | .5975 | .6401 | .717 | .8573 | | | |
| 7 | .6289 | .7602 | .7468 | .9259 | | | |
| 10 | | | | | .4182 | .4458 | .3734 |
| 11 | | | | | .6871 | .8745 | .8402 |
| 12 | | | | | 1.099 | | .9869 |
| 13 | | | | | 1.1949 | .5658 | .9869 |
| 14 | | | | | 1.2248 | .5144 | .9069 |
| 15 | | | | | .9858 | .4458 | .7735 |
| 16 | | | | | .956 | | .6668 |
| 17 | | | | | .7468 | .5144 | .5868 |
| 22 | .3868 | .1792 | .5316 | | | | |
| 23 | .4001 | .2091 | .6344 | | | | |
| 24 | .2396 | .4001 | .2689 | .5144 | | | |
| Max | .6289 | .7602 | .7468 | .9259 | 1.2248 | .8745 | .9869 |
| Min | .2396 | .1792 | .2689 | .5144 | .4182 | .4458 | .3734 |
| Avg | .4166 | .4296 | .5498 | .6653 | .9141 | .5601 | .7652 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 203 / 11 KV VELHANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .08 | .1195 | |
| 2 | | | | | .08 | .1195 | .1543 |
| 3 | | | | | .08 | .1195 | |
| 4 | | | | | .1067 | .1497 | .1543 |
| 5 | | | | | .1334 | .2091 | |
| 6 | | | | | .1734 | .2689 | .3429 |
| 7 | | | | | .2134 | .3585 | .5487 |
| 10 | .2801 | .2 | .7202 | .1334 | | | |
| 11 | .6135 | | 1.0288 | .3467 | | | |
| 12 | | .5377 | 1.166 | .4534 | | | |
| 13 | .5335 | .6661 | 1.166 | .4134 | | | |
| 14 | .6401 | .6273 | 1.166 | .3868 | | | |
| 15 | .7068 | .766 | 1.166 | .3601 | | | |
| 16 | .6401 | .766 | 1.166 | .3201 | | | |
| 17 | .5068 | .7327 | 1.166 | .2934 | | | |
| 22 | | | | .0667 | .0896 | .1886 | .12 |
| 23 | | | | .0667 | .1195 | .2058 | .1334 |
| 24 | | | | | .0667 | .1195 | .1715 |
| Max | .7068 | .766 | 1.166 | .4534 | .2134 | .3585 | .5487 |
| Min | .2801 | .2 | .7202 | .0667 | .0667 | .1195 | .12 |
| Avg | .5601 | .6137 | 1.0931 | .2841 | .1143 | .1859 | .2322 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 201 / 11 KV VINCHUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .811 | .8215 | .7781 | .8488 | | .8215 | .8488 |
| 2 | .8488 | .8589 | .7673 | .8676 | | .8402 | .8865 |
| 3 | .9619 | .8215 | .8444 | .8488 | | .8402 | .9431 |
| 4 | 1.2071 | 1.2323 | 1.1093 | 1.2449 | | 1.2136 | |
| 5 | 1.9239 | 1.9605 | 1.6887 | 1.9239 | | 1.8858 | 1.8861 |
| 6 | 2.6783 | 2.5579 | 2.2698 | 2.5652 | | 2.2592 | 2.4897 |
| 7 | 2.9613 | 2.5579 | 2.4172 | 2.8104 | | 2.5206 | 2.5652 |
| 8 | 2.1691 | 2.1472 | 1.8377 | 2.1879 | | 1.9978 | 1.9239 |
| 9 | 1.8107 | 1.8484 | 1.4073 | 1.7918 | | 1.4563 | 1.6598 |
| 10 | 1.3769 | 1.4563 | 1.1755 | 1.3769 | | 1.0829 | 1.3203 |
| 11 | 1.0562 | 1.1016 | .8632 | 1.0562 | | .7842 | .9808 |
| 12 | .811 | .9335 | .745 | .7545 | | .7282 | .811 |
| 13 | .6602 | .8215 | .596 | .6979 | | .6722 | .7167 |
| 14 | .7545 | .8029 | .6622 | .7545 | | .6535 | .679 |
| 15 | .3584 | .8215 | .6622 | .7545 | | .6908 | .6979 |
| 16 | | .8589 | .745 | .7922 | | .7468 | .811 |
| 17 | 1.1128 | .9709 | .7947 | .9431 | | .8029 | .9242 |
| 18 | 1.6409 | 1.1317 | 1.6225 | 1.1317 | | 1.1576 | 1.2826 |
| 19 | 2.3577 | 2.0351 | 1.6556 | 1.8484 | | 2.0538 | 2.2822 |
| 20 | 2.1313 | 1.9978 | 1.7881 | 1.9427 | | 1.9605 | 2.0182 |
| 21 | 1.3957 | 1.4377 | 1.2748 | 1.358 | | 1.3817 | 1.3769 |
| 22 | 1.1694 | 1.1389 | 1.2748 | 1.1506 | | 1.1389 | 1.1506 |
| 23 | .9619 | .9709 | .9934 | .9242 | | .9149 | .9242 |
| 24 | .8865 | .8676 | .8962 | .7947 | .8676 | .8402 | .8589 |
| Max | 2.9613 | 2.5579 | 2.4172 | 2.8104 | .8676 | 2.5206 | 2.5652 |
| Min | .3584 | .8029 | .596 | .6979 | .8676 | .6535 | .679 |
| Avg | 1.3933 | 1.3397 | 1.2029 | 1.3071 | .8676 | 1.2268 | 1.3060 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 202 / 11 KV TARWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1635 | .2286 | .2483 | .2972 | | |
| 2 | .1635 | .2515 | .2483 | .2972 | | |
| 3 | .1635 | .2286 | .2912 | .3269 | | |
| 4 | .1783 | .2515 | .2649 | .3121 | | |
| 5 | .2229 | .2743 | .33 | .3418 | | |
| 6 | .2972 | .3201 | .4305 | .3567 | | |
| 7 | .4904 | .6401 | .9437 | .5053 | | |
| 8 | | .6287 | 1.0265 | .6241 | | |
| 9 | | .423 | .8444 | .5201 | | |
| 10 | | | | | .2401 | .381 |
| 11 | | | | | .5144 | .6859 |
| 12 | | | | | .5258 | .8078 |
| 13 | | | | | .503 | .8688 |
| 14 | | | | | .4001 | .7164 |
| 15 | | | | | .4801 | |
| 16 | | | | | .2972 | .6097 |
| 17 | | | | | .3887 | .5639 |
| 23 | .4239 | | | | | |
| 24 | .1486 | .2317 | .1715 | .2475 | | |
| Max | .4904 | .6401 | 1.0265 | .6241 | .5258 | .8688 |
| Min | .1486 | .2286 | .1715 | .2475 | .2401 | .381 |
| Avg | .2502 | .3478 | .4799 | .3829 | .4187 | .6619 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 203 / 11 KV SITANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | | .0476 | .08 |
| 2 | | | | | | .0476 | .08 |
| 3 | | | | | | .0476 | .0914 |
| 4 | | | | | | .0667 | |
| 5 | | | | | | .0953 | .0686 |
| 6 | | | | | | .0953 | .0686 |
| 7 | | | | | | .1143 | .16 |
| 8 | | | | | | .1048 | |
| 9 | | | | | .1115 | .1048 | |
| 10 | .1303 | .0953 | .149 | .0914 | | | |
| 11 | .2751 | .1429 | .2483 | .1829 | | | |
| 12 | .2896 | .1715 | .1987 | .2286 | | | |
| 13 | .2896 | .1619 | .2152 | .16 | | | |
| 14 | .2027 | .1143 | .1987 | .1257 | | | |
| 15 | .1882 | .1143 | .1656 | .1257 | | | |
| 16 | .1882 | .1048 | .1656 | .1257 | | | |
| 17 | .1738 | .1048 | .1656 | .1257 | | | |
| 22 | | | | | | .0762 | .1257 |
| 23 | | | | | | .0667 | .1143 |
| 24 | .4239 | | | | | .0476 | .0667 |
| Max | .4239 | .1715 | .2483 | .2286 | .1115 | .1143 | .16 |
| Min | .1303 | .0953 | .149 | .0914 | .1115 | .0476 | .0667 |
| Avg | .2402 | .1262 | .1883 | .1457 | .1115 | .0762 | .0950 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 201 / 11KV AJANALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1041 | .1715 | .209 | .2229 | .1886 | .2083 | .2058 |
| 2 | .1043 | .1715 | .2266 | .2058 | .1715 | .2085 | .2229 |
| 3 | .1044 | .1543 | .2264 | .2401 | .1715 | .2083 | .2229 |
| 4 | .1401 | .2058 | .2441 | .2401 | .2229 | .2259 | .2572 |
| 5 | .1928 | .2401 | .2443 | .2743 | .2743 | .3138 | .2743 |
| 6 | .2641 | .2401 | .333 | .2572 | .3944 | .4031 | .3944 |
| 7 | .3701 | .3086 | .4929 | .4115 | .4115 | .2777 | .4287 |
| 8 | .3155 | .2094 | .2092 | .3429 | .2915 | .2777 | .2743 |
| 9 | .2401 | .1046 | .1715 | .1886 | .2229 | .1907 | .2058 |
| 10 | .0857 | .122 | .1372 | .12 | .298 | .2401 | .1886 |
| 11 | .0857 | .1041 | .0857 | .1029 | .4929 | .3944 | .3601 |
| 12 | .1029 | .1216 | .1029 | .1029 | .4924 | .4801 | .4458 |
| 13 | .1029 | .1043 | .1372 | .12 | .4391 | .463 | .4115 |
| 14 | .0857 | .1216 | .1715 | .0857 | .4567 | .4287 | .3944 |
| 15 | .0857 | .1041 | .1886 | .1715 | .4567 | .4115 | .3601 |
| 16 | .2058 | .1043 | .1886 | .1886 | .4387 | .3944 | .3772 |
| 17 | .2058 | .0868 | .2058 | .1886 | .333 | .3601 | .3429 |
| 18 | .2229 | .0868 | .2229 | .2229 | .2266 | .1715 | .2401 |
| 19 | .2401 | .333 | .3086 | .2743 | .3316 | .3601 | .3429 |
| 20 | .3086 | .3506 | .3429 | .3086 | .3141 | .3086 | .3601 |
| 21 | .3429 | .3323 | .3086 | .2915 | .3138 | .2915 | .3258 |
| 22 | .4115 | .1922 | | .2229 | .2606 | .2572 | .2743 |
| 23 | .5144 | .1751 | | .2058 | .2256 | .2401 | .2572 |
| 24 | .1044 | .1029 | | .2572 | .1886 | .2083 | .2229 |
| Max | .5144 | .3506 | .4929 | .4115 | .4929 | .4801 | .4458 |
| Min | .0857 | .0868 | .0857 | .0857 | .1715 | .1715 | .1886 |
| Avg | .2059 | .1770 | .2265 | .2186 | .3174 | .3052 | .3079 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 202 / 11 KV CHOUGAON 1 PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3312 | .2229 | .3475 | | .9088 | 1.0974 | .9088 |
| 2 | .3312 | .2229 | .3483 | .4115 | .8573 | 1.0785 | .8573 |
| 3 | .3319 | .2401 | .3479 | .4801 | .8573 | 1.0773 | .8573 |
| 4 | .3856 | .3258 | .4198 | .5487 | .9602 | 1.0243 | .6001 |
| 5 | .4929 | .4115 | .6135 | .6173 | 1.0802 | 1.2403 | 1.0288 |
| 6 | .6873 | .6173 | .5972 | .6516 | 1.4403 | 1.6834 | 1.3546 |
| 7 | .527 | .5487 | .527 | .583 | 1.8347 | 2.0819 | 2.0062 |
| 8 | .3155 | .463 | .4018 | .4458 | .3772 | .3661 | .4115 |
| 9 | .3429 | .2789 | .2058 | .2743 | .3086 | .2954 | .2572 |
| 10 | 2.7435 | 1.5424 | 1.3717 | 1.3717 | .2083 | .1715 | .2401 |
| 11 | 2.8635 | 2.8974 | 2.7606 | 2.5377 | .2083 | .1543 | .1886 |
| 12 | 2.572 | 3.051 | 2.8292 | 2.572 | .2259 | .1886 | .2058 |
| 13 | 2.8635 | 3.0151 | 2.6749 | 2.4691 | .2256 | .1886 | .2229 |
| 14 | 3.0178 | 2.6863 | 2.572 | 2.3834 | .2433 | .2058 | .1543 |
| 15 | 2.9321 | 1.9239 | 2.4177 | 2.3491 | .2609 | .2229 | .2401 |
| 16 | 2.2291 | 2.5198 | 2.452 | 2.3148 | .2435 | .2058 | .2401 |
| 17 | 2.4006 | 2.3108 | 2.3148 | 2.1605 | .2435 | .2058 | .2229 |
| 18 | .3429 | .2798 | .2401 | .2229 | .2609 | .2401 | .2572 |
| 19 | .3429 | .4207 | .3772 | .3429 | .3487 | .3772 | .3772 |
| 20 | .3429 | .4557 | .4458 | .4115 | .4031 | .4115 | .4115 |
| 21 | | .4557 | .4458 | .3944 | .3856 | .4115 | .4458 |
| 22 | .3258 | .4027 | .3772 | .8745 | .9194 | .9602 | .9602 |
| 23 | .3086 | .3677 | .3601 | .9431 | 1.1199 | .9259 | 1.0288 |
| 24 | .3298 | .3429 | .3483 | | .9431 | 1.134 | .9259 |
| Max | 3.0178 | 3.051 | 2.8292 | 2.572 | 1.8347 | 2.0819 | 2.0062 |
| Min | .3086 | .2229 | .2058 | .2229 | .2083 | .1543 | .1543 |
| Avg | 1.1896 | 1.0835 | 1.0748 | 1.1527 | .6194 | .6645 | .6001 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 201 / CHINCHKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2572 | .3887 | .381 | .3277 | .1886 | .1524 | .2429 |
| 2 | .2572 | .3563 | .381 | .3201 | .1886 | .1524 | .2429 |
| 3 | .2572 | .3401 | .381 | .3277 | .2058 | .1524 | .2429 |
| 4 | .3258 | .3401 | .4572 | .4096 | .2572 | .2286 | .3239 |
| 5 | .4287 | .421 | .5335 | .4049 | .3772 | .3048 | .3563 |
| 6 | .4801 | .4858 | .5335 | .4973 | .463 | .4572 | .4096 |
| 7 | .4973 | .3887 | .4858 | .5182 | .4287 | .3048 | .421 |
| 8 | .2058 | .2429 | .2458 | .3563 | .3258 | .2743 | .2622 |
| 9 | .2429 | | .2429 | .2743 | .2286 | .1638 | .2058 |
| 10 | .1781 | .1524 | .1638 | .1886 | .3048 | .2343 | .2743 |
| 11 | .1619 | .1524 | .1475 | .1543 | .5335 | .6478 | .6859 |
| 12 | .1457 | .1524 | .1311 | .1372 | .7011 | .6554 | .6859 |
| 13 | .1457 | .1524 | .1311 | .1372 | .6097 | .6154 | .6344 |
| 14 | .1296 | .1524 | .1296 | .1372 | .6097 | .5668 | .583 |
| 15 | .1134 | .1524 | .1457 | .1372 | .5639 | .5243 | .5316 |
| 16 | .1296 | .1524 | .1457 | .1543 | .5639 | .4858 | .4973 |
| 17 | .1619 | .1524 | .1638 | .1543 | .5335 | .4915 | .463 |
| 18 | | .1829 | .1638 | | .1524 | .1943 | .1543 |
| 19 | | .2439 | .3277 | .3772 | .2286 | .3239 | .3601 |
| 20 | .3401 | .3048 | .2818 | .3258 | .3048 | .3239 | .3086 |
| 21 | .2915 | .3048 | .2572 | .3086 | .2439 | .2591 | .2915 |
| 22 | .421 | .381 | .4096 | .2743 | .1524 | .2429 | .2401 |
| 23 | .4534 | .381 | .4144 | .2229 | .1524 | .2429 | .2229 |
| 24 | .2743 | .381 | .3953 | | .1524 | .2429 | |
| Max | .4973 | .4858 | .5335 | .5182 | .7011 | .6554 | .6859 |
| Min | .1134 | .1524 | .1296 | .1372 | .1524 | .1524 | .1543 |
| Avg | .2681 | .2766 | .2937 | .2793 | .3529 | .3434 | .3757 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 202 / VAJIRKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .1457 | | .1619 | .3601 | .3048 | .3239 |
| 2 | .1543 | .1457 | .1524 | .1619 | .3601 | .3048 | .3239 |
| 3 | .1543 | .1457 | .1524 | .1562 | .3601 | .3048 | .3239 |
| 4 | .2401 | .1781 | .1829 | .1989 | .4115 | .381 | .3605 |
| 5 | .2572 | .2267 | .2286 | .2429 | .4287 | .4572 | .3906 |
| 6 | .2572 | .2591 | .3048 | .3277 | .4973 | .6097 | .4534 |
| 7 | .2915 | .2591 | .2286 | .2753 | .4973 | .4572 | .4687 |
| 8 | .2058 | .2105 | .1638 | .213 | .1886 | .1524 | .1943 |
| 9 | | .1829 | .1638 | .1715 | .1524 | .1638 | .1372 |
| 10 | | .4572 | .3239 | .3601 | .1524 | .1107 | .12 |
| 11 | .6316 | .5335 | .7625 | .6516 | .1524 | .0983 | .1029 |
| 12 | .7449 | .6097 | .7293 | .6859 | .1524 | .0972 | .0857 |
| 13 | .7611 | .6859 | .6478 | .6001 | .1524 | .0983 | .1029 |
| 14 | .7287 | .6097 | .6299 | .6173 | .1524 | .0983 | .0857 |
| 15 | .6316 | .6097 | .6062 | .6001 | .1524 | .0983 | .1029 |
| 16 | .6802 | .5487 | .5992 | .6001 | | .0995 | .1029 |
| 17 | .6154 | .4572 | .5182 | .5316 | .1524 | .0983 | .1029 |
| 18 | .6154 | .1524 | .1311 | .1372 | .1524 | .1147 | .1372 |
| 19 | .2429 | .2134 | .2572 | .2401 | .2286 | .2458 | .2229 |
| 20 | .2267 | | .2155 | .2058 | .2743 | .1943 | .2058 |
| 21 | .1781 | .2286 | .2035 | .2058 | .1829 | .1802 | .1886 |
| 22 | .1781 | .1524 | .1696 | .3086 | .3048 | .3277 | .463 |
| 23 | .1619 | .1524 | .1619 | .3772 | .3048 | .3239 | .5144 |
| 24 | .1543 | .1524 | .1638 | | .3048 | .3277 | |
| Max | .7611 | .6859 | .7625 | .6859 | .4973 | .6097 | .5144 |
| Min | .1543 | .1457 | .1311 | .1372 | .1524 | .0972 | .0857 |
| Avg | .3757 | .3181 | .3346 | .3492 | .2642 | .2354 | .2397 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094072 / Chinchkhede

Feeder No / Name : 401 / 33 KV INCOMMER
Chinchkhede Feeder KV- 33 /
INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | .1543 | .6316 | 1.0688 | .5344 | .1543 | 1.2803 | .4801 |
| 24 | .2572 | | | | | | |
| Max | .2572 | .6316 | 1.0688 | .5344 | .1543 | 1.2803 | .4801 |
| Min | .1543 | .6316 | 1.0688 | .5344 | .1543 | 1.2803 | .4801 |
| Avg | .2058 | .6316 | 1.0688 | .5344 | .1543 | 1.2803 | .4801 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 201 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.4577 | 2.4863 | 2.2939 | 2.6216 | .4096 | .3315 | .3315 |
| 2 | 2.4577 | 2.4863 | 2.13 | 2.6216 | .4096 | .3315 | .3315 |
| 3 | 2.2939 | 2.7721 | 2.13 | 2.4577 | .4096 | .3315 | .3315 |
| 4 | 2.2939 | 2.4863 | 2.3205 | 2.3758 | .3277 | .4144 | .3315 |
| 5 | 2.2405 | 2.5692 | 2.4863 | 2.2939 | .5735 | .4973 | .3323 |
| 6 | 2.6406 | 2.652 | 2.5911 | 2.6216 | .6554 | .5735 | .3315 |
| 7 | 2.915 | 2.9835 | 2.915 | 3.4408 | .5735 | .3315 | .3315 |
| 8 | .4858 | .3315 | .4915 | .4915 | .4096 | .4144 | .4973 |
| 9 | .3277 | .2486 | .3315 | | .3315 | .1658 | .3315 |
| 10 | .2486 | .2458 | .2458 | | 2.7349 | 2.5692 | 2.4863 |
| 11 | .2486 | .2458 | .1638 | .3315 | 3.4808 | 3.5637 | 3.4808 |
| 12 | .1658 | .1638 | .1638 | .1638 | 3.8123 | 3.5637 | 3.6466 |
| 13 | .1658 | .1638 | .1638 | .1658 | 3.8123 | 3.5637 | 3.8123 |
| 14 | .2486 | .1638 | .2458 | .1658 | 3.8952 | 3.315 | 3.9781 |
| 15 | .2486 | .2458 | .2458 | .2486 | 3.9781 | 3.8952 | 3.3979 |
| 16 | .3315 | .2458 | .2458 | .2486 | 3.8123 | 4.1914 | 3.315 |
| 17 | .1658 | .2458 | .2458 | .2486 | 3.4808 | 3.8952 | 3.4808 |
| 18 | .3315 | .3277 | .2458 | .3315 | .3315 | .3315 | .2486 |
| 19 | .4973 | .3277 | .3277 | .4973 | .3315 | .4973 | .3315 |
| 20 | .4973 | .3277 | .4915 | .4915 | .4144 | .2486 | .3315 |
| 21 | .4144 | .3277 | .4096 | .3277 | .4144 | .3315 | .3315 |
| 22 | 2.3205 | 2.652 | 2.4577 | .3277 | .4096 | .3315 | .3315 |
| 23 | 2.3205 | 2.7349 | 2.7854 | .3277 | .3277 | .3315 | .3315 |
| 24 | 2.5396 | 2.3205 | 2.6216 | 2.7035 | .3277 | .3315 | |
| Max | 2.915 | 2.9835 | 2.915 | 3.4408 | 3.9781 | 4.1914 | 3.9781 |
| Min | .1658 | .1638 | .1638 | .1638 | .3277 | .1658 | .2486 |
| Avg | 1.2024 | 1.2398 | 1.1979 | 1.1593 | 1.4860 | 1.4313 | 1.4197 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 202 / 11 KV BALHANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.8502 | 2.4863 | 2.2634 | 2.5987 | .4191 | .4191 | .4191 |
| 2 | 2.6825 | 2.4863 | 2.1795 | 2.5987 | .4191 | .3353 | .4144 |
| 3 | 2.4863 | 2.4034 | 2.1795 | 2.5987 | .3353 | .3353 | .4144 |
| 4 | 2.652 | 2.4034 | 2.3472 | 2.5987 | .503 | .4191 | .4144 |
| 5 | 2.6216 | 2.5692 | 2.431 | 2.5987 | .5868 | .503 | .4973 |
| 6 | 2.7854 | 2.7349 | 2.6825 | 2.7664 | .6706 | .6706 | .663 |
| 7 | 3.3589 | 3.1493 | 3.2693 | 3.3532 | .5868 | .6706 | .5801 |
| 8 | .4915 | .5801 | .503 | .503 | .4191 | .503 | .4973 |
| 9 | .4096 | .4144 | .3353 | | .3315 | .1677 | .3315 |
| 10 | .3315 | .3315 | .3353 | | .9116 | .9945 | 3.1369 |
| 11 | .2486 | .2515 | .2515 | .2486 | 4.2267 | 4.3096 | 3.8152 |
| 12 | .2486 | .2515 | .1677 | .1658 | 4.5582 | 4.1438 | 4.4086 |
| 13 | .2486 | .2515 | .1677 | .1658 | 4.6411 | 3.8123 | 4.3591 |
| 14 | .2486 | .2515 | .1677 | .1658 | 4.8068 | 4.0609 | 4.3591 |
| 15 | .3315 | .2486 | .1677 | .1658 | 4.8897 | 4.1438 | 2.1795 |
| 16 | .3315 | .2486 | .2515 | .2486 | 4.8068 | 4.3096 | 4.2753 |
| 17 | .3315 | .3315 | .2515 | .2486 | 4.2267 | 4.2753 | 3.7723 |
| 18 | .4144 | .3315 | .3353 | .3734 | .3315 | .3315 | .4191 |
| 19 | .4144 | .4973 | .5868 | .5601 | .4973 | .4973 | .5868 |
| 20 | .4973 | .4973 | .503 | .5868 | .503 | .5801 | .5868 |
| 21 | .4973 | .503 | .503 | .503 | .503 | .4973 | .5087 |
| 22 | 2.4863 | 2.5149 | 2.5149 | .4191 | .4191 | .4144 | .5087 |
| 23 | 2.652 | 2.5987 | 2.5987 | .4191 | .4191 | .4144 | .4239 |
| 24 | 2.8502 | 2.5692 | 2.5987 | 2.5987 | .4191 | .4191 | .4144 |
| Max | 3.3589 | 3.1493 | 3.2693 | 3.3532 | 4.8897 | 4.3096 | 4.4086 |
| Min | .2486 | .2486 | .1677 | .1658 | .3315 | .1677 | .3315 |
| Avg | 1.3529 | 1.2877 | 1.2330 | 1.2039 | 1.6846 | 1.5512 | 1.5827 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 203 / 11 KV SAMODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .5601 | .5658 | .5658 | 2.6406 | 3.0178 | 2.894 |
| 2 | .3772 | .5601 | .4715 | .5658 | 2.6406 | 2.8292 | 2.894 |
| 3 | .4715 | .5601 | .3772 | .5658 | 2.6406 | 3.0178 | 2.894 |
| 4 | .5658 | .5601 | .5658 | .5601 | 2.8292 | 3.1121 | 2.894 |
| 5 | .6602 | .6535 | .7545 | .7468 | 2.9235 | 3.2065 | 3.0807 |
| 6 | .8488 | .7468 | .9431 | .8402 | 3.2065 | 3.4894 | 3.4541 |
| 7 | .8488 | .8402 | .9431 | .8402 | 3.678 | 3.9609 | 4.481 |
| 8 | .8488 | .8402 | .7545 | .7468 | .8488 | .7545 | .8402 |
| 9 | .5658 | .4668 | .4715 | | .5601 | .6602 | .5801 |
| 10 | 3.6408 | 4.0552 | 3.3008 | | .5601 | .5601 | .4715 |
| 11 | 5.4146 | 5.1869 | 4.6211 | 5.3212 | .4668 | .4668 | .3772 |
| 12 | 4.8544 | 4.904 | 4.904 | 4.3877 | .4668 | .4668 | .4715 |
| 13 | 5.0412 | 4.9983 | 5.0926 | 4.6677 | .4668 | .4668 | .3772 |
| 14 | 5.8814 | 4.904 | 4.8097 | 4.3877 | .4668 | .4668 | .4715 |
| 15 | 5.1345 | 4.5268 | 4.7154 | 4.2943 | .5601 | .4668 | .4715 |
| 16 | 4.8544 | 4.2438 | 4.6211 | 4.8544 | .4668 | .4668 | .4715 |
| 17 | 4.5744 | 4.2438 | 4.2438 | 4.0143 | .5601 | .5601 | .4715 |
| 18 | | .5658 | .4715 | .6535 | .5601 | .6535 | .5658 |
| 19 | .7468 | .7545 | .9431 | .7468 | .7468 | .7468 | .7545 |
| 20 | .8402 | .7545 | .8488 | .7545 | .7545 | .8402 | .8488 |
| 21 | .7468 | .7545 | .7545 | .6602 | .6602 | .7468 | .7545 |
| 22 | .6535 | .6602 | .7545 | 2.5463 | 2.1691 | 3.0807 | 2.9235 |
| 23 | .5601 | .5658 | .5658 | 2.6406 | 3.2065 | 3.0807 | 2.9235 |
| 24 | .4715 | .5601 | .4715 | .5658 | 2.6406 | 3.1121 | 3.0807 |
| Max | 5.8814 | 5.1869 | 5.0926 | 5.3212 | 3.678 | 3.9609 | 4.481 |
| Min | .3772 | .4668 | .3772 | .5601 | .4668 | .4668 | .3772 |
| Avg | 2.1295 | 1.9778 | 1.9569 | 2.0876 | 1.53 | 1.6763 | 1.6436 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 204 / 11 KV SUKAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .4715 | .4715 | .4715 | 1.186 | 1.4232 | 1.6032 |
| 2 | .3772 | .4715 | .3772 | .4715 | 1.186 | 1.3441 | 1.6032 |
| 3 | .3772 | .4668 | .3772 | .4715 | 1.186 | 1.4232 | 1.4251 |
| 4 | .4715 | .4668 | .4715 | .4715 | 1.186 | 1.5023 | 1.4918 |
| 5 | .4715 | .4668 | .4715 | .4715 | 1.2651 | 1.5023 | 1.6766 |
| 6 | .5658 | .5658 | .4715 | .4715 | 1.5565 | 1.8404 | 1.8442 |
| 7 | .6602 | .6535 | .5658 | .5658 | 2.1795 | 2.3472 | 2.9874 |
| 8 | .6602 | .6602 | .6602 | .5658 | .5658 | .6602 | .5658 |
| 9 | .5658 | .6535 | .6602 | | .5658 | .6602 | .5658 |
| 10 | 2.3339 | 2.2634 | 1.8404 | | .5658 | .6535 | .6602 |
| 11 | 4.0609 | 3.6046 | 3.2693 | 3.1855 | .5658 | .5601 | .5658 |
| 12 | 3.8123 | 3.1855 | 3.3589 | 3.3532 | .5658 | .5601 | .5658 |
| 13 | 4.201 | 3.1855 | 3.1855 | 3.2217 | .5601 | .4668 | .5658 |
| 14 | 4.1076 | 2.4863 | 3.1017 | 3.0178 | .5601 | .5658 | .5658 |
| 15 | 3.3532 | 2.4577 | 2.934 | 2.8502 | .5601 | .5658 | .5658 |
| 16 | 2.934 | 2.4863 | 2.652 | 2.7664 | .5601 | .5601 | .5658 |
| 17 | 2.6825 | 2.2672 | 2.3758 | 2.5149 | .5658 | .4668 | .5658 |
| 18 | .5658 | .4096 | .4715 | .3734 | .6535 | .6535 | .6602 |
| 19 | .6535 | .5801 | .6602 | .5601 | .6602 | .6602 | .6602 |
| 20 | .5658 | .6602 | .6602 | .6602 | .6602 | .6602 | .6602 |
| 21 | .5601 | .6602 | .6602 | .5658 | .5658 | .5601 | .5658 |
| 22 | .5658 | .5658 | .5658 | 1.186 | 1.7918 | | 1.1336 |
| 23 | .4668 | .4715 | .4715 | 1.2651 | 1.5813 | 1.6975 | .4049 |
| 24 | .4715 | .4668 | .4715 | .4715 | 1.186 | 1.5023 | 1.6804 |
| Max | 4.201 | 3.6046 | 3.3589 | 3.3532 | 2.1795 | 2.3472 | 2.9874 |
| Min | .3772 | .4096 | .3772 | .3734 | .5601 | .4668 | .4049 |
| Avg | 1.4942 | 1.2761 | 1.3002 | 1.3615 | .9366 | .9929 | 1.0062 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 205 / 11 KV PIMPALNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .7468 | .7392 | .8316 | .823 | .724 | .7468 |
| 2 | .5601 | .7468 | .5544 | .8316 | .7316 | .543 | .7468 |
| 3 | .7392 | .7468 | .6468 | .8402 | .7392 | .5487 | .7468 |
| 4 | .8402 | .7468 | .7468 | .8402 | .8316 | .7316 | .8402 |
| 5 | .9335 | .9335 | .9335 | .8402 | .924 | .8145 | .9335 |
| 6 | 1.1203 | 1.1203 | 1.226 | 1.1203 | 1.2136 | 1.1765 | 1.1203 |
| 7 | 1.307 | 1.307 | 1.4146 | 1.3203 | 1.3203 | 1.4003 | 1.4003 |
| 8 | 1.3575 | 1.4003 | 1.3717 | 1.2136 | 1.267 | 1.307 | 1.4003 |
| 9 | 1.2403 | 1.4003 | 1.1517 | | 1.2136 | 1.0517 | 1.2136 |
| 10 | 1.307 | 1.1203 | 1.1269 | | 1.2136 | 1.1203 | 1.1641 |
| 11 | 1.1203 | 1.1088 | 1.1517 | 1.7737 | 1.1203 | 1.1203 | 1.1393 |
| 12 | 1.1203 | 1.1088 | 1.0631 | 1.307 | 1.1203 | 1.1203 | 1.0517 |
| 13 | 1.0269 | .9536 | .9745 | 1.2136 | 1.1203 | 1.0269 | 1.0745 |
| 14 | 1.0269 | .8059 | .985 | 1.1203 | 1.1203 | 1.1203 | 1.0164 |
| 15 | 1.1203 | .8859 | .985 | 1.0269 | 1.1203 | 1.1203 | 1.0631 |
| 16 | 1.1203 | .985 | .985 | 1.1203 | 1.1203 | 1.1203 | 1.2269 |
| 17 | .9335 | .9536 | 1.0402 | 1.1203 | 1.1203 | 1.0269 | 1.1641 |
| 18 | 1.1203 | .9031 | 1.0031 | 1.226 | 1.1203 | 1.1203 | 1.0898 |
| 19 | 1.2136 | 1.0402 | 1.1393 | 1.2136 | 1.2136 | 1.307 | 1.2536 |
| 20 | 1.2136 | 1.1145 | 1.1269 | 1.0745 | 1.0745 | 1.2136 | 1.1641 |
| 21 | 1.1203 | 1.0898 | 1.0898 | 1.0631 | .9745 | 1.1203 | 1.086 |
| 22 | 1.0269 | 1.0269 | 1.1088 | 1.0059 | .9745 | 1.0269 | .9955 |
| 23 | .8402 | .9335 | .9335 | .9145 | .8316 | .8402 | .8402 |
| 24 | .7545 | .7537 | .7545 | .8402 | .823 | .7392 | .7468 |
| Max | 1.3575 | 1.4003 | 1.4146 | 1.7737 | 1.3203 | 1.4003 | 1.4003 |
| Min | .5601 | .7468 | .5544 | .8316 | .7316 | .543 | .7468 |
| Avg | 1.0301 | .9972 | 1.0105 | 1.0845 | 1.0472 | 1.0184 | 1.0510 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 206 / 11 KV SUKAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3772 | .3772 | .3772 | .3772 | .3772 |
| 2 | .3772 | .3772 | .3772 | .3772 | .3772 | .3696 |
| 3 | .3772 | .3772 | .3772 | .3772 | .3772 | .3696 |
| 4 | .4715 | .4668 | .3772 | .3772 | .3772 | .4668 |
| 5 | .4715 | .5601 | .4715 | .3772 | .4715 | .4668 |
| 6 | .7545 | .7468 | .7545 | .6602 | .7545 | .8316 |
| 7 | .9431 | .9335 | .8488 | .8488 | .9431 | .9431 |
| 8 | .8488 | .8402 | .8488 | .7545 | .7468 | .8488 |
| 9 | .7468 | .7468 | .6602 | | .5601 | .7468 |
| 10 | .5601 | .5544 | .4668 | | .5601 | |
| 11 | .5601 | .5658 | .4668 | .4534 | .4668 | |
| 12 | .5601 | .4715 | .4668 | .4668 | .4668 | |
| 13 | .4668 | .4715 | .3734 | .4668 | .3734 | |
| 14 | .5601 | .3772 | .3734 | .3315 | .4668 | |
| 15 | .5601 | .3772 | .3734 | .3734 | .4668 | |
| 16 | .5601 | .4715 | .3734 | .3734 | .5601 | |
| 17 | .6535 | .462 | .462 | .4668 | .5601 | |
| 18 | .6535 | .7392 | .6468 | .5601 | .6535 | |
| 19 | .6535 | .7392 | .8402 | .7468 | .7468 | |
| 20 | .6535 | .6401 | .6468 | .5658 | .6602 | |
| 21 | .4715 | .543 | .5487 | .5658 | .5601 | |
| 22 | .5658 | .4715 | .4715 | .4715 | .4668 | |
| 23 | .4668 | .3772 | .4715 | .3772 | .4668 | |
| 24 | .3772 | .3734 | .3772 | .3772 | .3772 | .3734 |
| Max | .9431 | .9335 | .8488 | .8488 | .9431 | .9431 |
| Min | .3772 | .3734 | .3734 | .3315 | .3734 | .3696 |
| Avg | .5704 | .5442 | .5188 | .4885 | .5349 | .5794 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 201 / 11 KV KUDASHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2709 | .2743 | .2915 | | | |
| 2 | | .2743 | .2774 | .2915 | | | |
| 3 | | .2968 | .3086 | .3121 | | | |
| 4 | | .3401 | .3086 | .3258 | | | |
| 5 | | .3563 | .3222 | .3467 | | | |
| 6 | | .3688 | .3315 | .3772 | | | |
| 7 | .5624 | | | | .6706 | .5624 | .5487 |
| 8 | .8035 | | | | .9259 | .8543 | .6626 |
| 9 | .8488 | | | | .945 | .9568 | .6447 |
| 10 | .6763 | | | | .9069 | .7613 | .3321 |
| 11 | .78 | | | | .5106 | .6173 | .583 |
| 14 | | .8048 | .9945 | .852 | | | |
| 15 | | .78 | 1.0395 | .8421 | | | |
| 16 | | .763 | 1.0682 | .9995 | | | |
| 17 | | .7712 | .9614 | .9069 | | | |
| 18 | | .703 | .8223 | .7287 | | | |
| 19 | .5898 | | | | .5999 | .5817 | .506 |
| 20 | 1.1584 | | | | .4371 | .4601 | .4687 |
| 21 | 1.0856 | | | | .3702 | .3702 | .4111 |
| 22 | 1.073 | | | | .3064 | .3191 | .3163 |
| 23 | .3563 | | | | .2683 | .2926 | .2881 |
| 24 | .2553 | .3163 | | | | .2553 | .2976 |
| Max | 1.1584 | .8048 | 1.0682 | .9995 | .945 | .9568 | .6626 |
| Min | .2553 | .2709 | .2743 | .2915 | .2683 | .2553 | .2881 |
| Avg | .7445 | .5038 | .6099 | .5704 | .5941 | .5483 | .4599 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 202 / 11 KV VARSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5992 | .4801 | .4854 | | | |
| 2 | | .6316 | .4801 | .4801 | | | |
| 3 | | .6299 | .4973 | .6068 | | | |
| 4 | | .6783 | .5801 | .6299 | | | |
| 5 | | .7122 | .6133 | .6962 | | | |
| 6 | | .7802 | .6554 | .7625 | | | |
| 7 | 1.4243 | | | | 1.5089 | 1.3923 | 1.4723 |
| 8 | 2.0719 | | | | 1.9951 | 2.0388 | 1.8991 |
| 9 | 2.1534 | | | | 1.9113 | 1.933 | 1.8991 |
| 10 | 1.6804 | | | | 1.6278 | 1.4864 | 1.8143 |
| 11 | | | | | 1.2654 | 1.0562 | 1.3413 |
| 14 | | 1.5261 | 1.5592 | 1.5971 | | | |
| 15 | | 1.8652 | 2.1365 | 1.95 | | | |
| 16 | | 1.8991 | 2.2043 | 2.1704 | | | |
| 17 | | 1.7101 | 1.9559 | 2.1026 | | | |
| 18 | | 1.4232 | 1.4575 | 1.5023 | | | |
| 19 | 1.6518 | | | | 1.5524 | 1.6244 | 1.3765 |
| 20 | 1.8461 | | | | 1.2037 | 1.2498 | 1.1385 |
| 21 | 1.6324 | | | | .9191 | 1.142 | .9717 |
| 22 | 1.5257 | | | | .9259 | .7846 | .852 |
| 23 | .8817 | | | | .7754 | .7133 | .7625 |
| 24 | .6255 | .7461 | | | | .6447 | .5916 |
| Max | 2.1534 | 1.8991 | 2.2043 | 2.1704 | 1.9951 | 2.0388 | 1.8991 |
| Min | .6255 | .5992 | .4801 | .4801 | .7754 | .6447 | .5916 |
| Avg | 1.5493 | 1.1001 | 1.1472 | 1.1803 | 1.3685 | 1.2787 | 1.2835 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 203 / 11 KV MALGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2936 | | | | .4365 | .2553 | .2553 |
| 2 | .3319 | | | | .442 | .2553 | .2553 |
| 3 | .3319 | | | | .4744 | .2841 | .2892 |
| 4 | .3944 | | | | .5376 | .2976 | .3246 |
| 5 | .4075 | | | | .5182 | .2808 | .3567 |
| 6 | .4329 | | | | .5765 | .2936 | .217 |
| 7 | | | 1.2631 | 1.0774 | | | |
| 8 | | 1.4413 | 1.4723 | 1.3904 | | | |
| 9 | | 1.5565 | .7865 | | | | |
| 10 | | 1.3748 | 1.3748 | | | | |
| 11 | | 1.0059 | 1.0402 | .9709 | | | |
| 12 | | | | .8817 | | | |
| 13 | | | | .8383 | 1.0715 | | |
| 14 | 1.3375 | | | | 1.1873 | 1.4243 | 1.2003 |
| 15 | 1.5091 | | | | 1.4403 | 1.4403 | 1.5432 |
| 16 | | | | | 1.4403 | 1.5249 | 1.4922 |
| 17 | 1.6095 | | | | 1.406 | 1.5746 | 1.2209 |
| 18 | 1.2498 | | | | .4512 | .9739 | 1.0279 |
| 19 | | 1.2003 | 1.1248 | 1.2334 | | | |
| 20 | 1.8461 | .9717 | .9374 | .8951 | | | |
| 21 | 1.6324 | .7611 | .8619 | .7977 | | | |
| 22 | 1.5257 | .6516 | .6539 | .6802 | | | |
| 23 | | .6068 | .6001 | .6802 | | | |
| 24 | | | .5201 | .5548 | .5407 | | |
| Max | 1.8461 | 1.5565 | 1.4723 | 1.3904 | 1.4403 | 1.5746 | 1.5432 |
| Min | .2936 | .6068 | .5201 | .5548 | .4365 | .2553 | .217 |
| Avg | .9925 | 1.0633 | .9668 | .9091 | .8094 | .7822 | .7439 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 201 / 11 KV DIGHAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.166 | .945 | 1.1203 | .9922 | .0762 | .0754 | .0762 |
| 2 | 1.1012 | .9686 | 1.1203 | .9602 | .0762 | .0754 | .0762 |
| 3 | 1.0364 | 1.0311 | 1.166 | .9602 | .0953 | .0754 | .0953 |
| 4 | .9602 | 1.1069 | 1.1984 | .9282 | .0953 | .0754 | .1143 |
| 5 | 1.1142 | 1.2955 | 1.3108 | 1.1142 | .1143 | .0754 | .1143 |
| 6 | 1.278 | 1.576 | 1.4918 | 1.3592 | .1334 | .1132 | .1334 |
| 7 | 1.757 | 2.0119 | 1.989 | 1.8778 | | | |
| 10 | | | | | 1.704 | 1.6842 | 1.5912 |
| 11 | | | | | 3.083 | 2.9492 | 1.8564 |
| 12 | | | | | 2.5194 | 2.8509 | 2.5857 |
| 13 | | | | | 2.4531 | 2.5149 | 2.3868 |
| 14 | | | | | 2.649 | 2.4478 | 2.2542 |
| 15 | | | | | 2.5149 | 2.3205 | 2.2211 |
| 16 | | | | | 2.4478 | 1.989 | 2.3205 |
| 17 | | | | | 2.5149 | 1.5623 | 2.1548 |
| 18 | | | | | | .1448 | .0995 |
| 19 | .0381 | .0953 | .1132 | .0762 | .0076 | .0762 | |
| 20 | .0762 | .1143 | .1132 | .0953 | .0754 | .1143 | |
| 21 | .0762 | .1143 | .0747 | .0953 | .0754 | .1143 | |
| 22 | 1.2803 | 1.3927 | 1.0623 | .0762 | .0754 | .0953 | |
| 23 | 1.3279 | 1.3927 | 1.0883 | .0953 | .0754 | .0953 | |
| 24 | 1.2955 | 1.3279 | 1.3123 | 1.0242 | .0953 | .0754 | .0762 |
| Max | 1.757 | 2.0119 | 1.989 | 1.8778 | 3.083 | 2.9492 | 2.5857 |
| Min | .0381 | .0953 | .0747 | .0762 | .0076 | .0754 | .0762 |
| Avg | .9621 | 1.0286 | 1.0124 | .7427 | 1.0441 | .9297 | 1.1348 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 202 / 11 KV VITAI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1509 | .1905 | .0152 | .2829 | .535 | .9145 | .884 |
| 2 | .1509 | .1905 | .0152 | .2263 | .535 | .8322 | .884 |
| 3 | .1509 | .1905 | .0191 | .2263 | .6097 | .8322 | .9374 |
| 4 | .1509 | .2286 | .0191 | .2263 | .6173 | .8322 | .9998 |
| 5 | .2263 | .2286 | .0191 | .2263 | .679 | .9877 | 1.0883 |
| 6 | .2263 | .2667 | | .2263 | 1.0494 | 1.5181 | 1.5074 |
| 7 | | | | | 1.5813 | 2.0972 | 2.0553 |
| 10 | 1.5181 | 1.2346 | 1.0364 | | | | |
| 11 | 2.652 | 2.3685 | 1.989 | 1.9662 | | | |
| 12 | 2.6216 | 2.0729 | 2.0972 | 2.0972 | | | |
| 13 | 2.1628 | 1.7078 | 1.4548 | 1.8785 | | | |
| 14 | 1.9433 | 1.6446 | 1.4373 | 1.6872 | | | |
| 15 | 1.7711 | 1.6446 | 1.4373 | 1.6049 | | | |
| 16 | 2.0241 | 1.7711 | 1.7078 | 1.5242 | | | |
| 17 | 1.7814 | 1.6446 | 1.4373 | 1.3672 | | | |
| 18 | .0724 | .0732 | | .0709 | | | |
| 19 | .1905 | .1905 | .2263 | .1905 | .1509 | .1905 | |
| 20 | .2286 | .2286 | .1509 | .2286 | .1509 | .2286 | |
| 21 | .2286 | .2286 | .2263 | .2286 | | .1905 | |
| 22 | .2286 | .2286 | .2263 | .6097 | .9877 | 1.0364 | |
| 23 | .1905 | .2286 | .2263 | .6173 | 1.0623 | 1.0753 | |
| 24 | .1509 | .1905 | .0191 | .2241 | .5487 | .9755 | 1.012 |
| Max | 2.652 | 2.3685 | 2.0972 | 2.0972 | 1.5813 | 2.0972 | 2.0553 |
| Min | .0724 | .0732 | .0152 | .0709 | .1509 | .1905 | .884 |
| Avg | .8962 | .7977 | .7242 | .7855 | .7089 | .9008 | 1.1710 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 203 / 11 KV VITAI-DIGHAVE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2957 | .2926 | .2926 | .2957 | .3258 | .2926 | .2957 |
| 2 | .2957 | .3292 | .3292 | .2957 | .3292 | .2926 | .3326 |
| 3 | .3361 | .3696 | .3658 | .3361 | .3658 | .3326 | .3361 |
| 4 | .4527 | .5228 | .4024 | .3734 | .4435 | .4066 | .4108 |
| 5 | .679 | .6348 | .5853 | .6036 | .6413 | .6036 | .6036 |
| 6 | .9808 | .9907 | .9877 | .8676 | .9907 | .9431 | .9907 |
| 7 | 1.0185 | 1.1317 | 1.0349 | 1.094 | 1.1431 | 1.0562 | 1.1431 |
| 8 | .695 | .7316 | .7316 | .7392 | .695 | .7023 | .6348 |
| 9 | .4207 | .4755 | .439 | | .5487 | .4557 | .4481 |
| 10 | .439 | .3658 | .3292 | | .3982 | .362 | .3696 |
| 11 | .3658 | .3258 | .3258 | .4805 | .2957 | .2715 | .3326 |
| 12 | .3658 | .3258 | .3258 | .3982 | .3292 | .2561 | .2926 |
| 13 | .3258 | .3258 | .2804 | .3224 | .3258 | .2896 | .2865 |
| 14 | .2865 | .3544 | .2865 | .3224 | .4024 | .2896 | .2507 |
| 15 | .3544 | .3544 | .3189 | .3544 | .4024 | .3012 | .2865 |
| 16 | .4607 | .3856 | .3814 | .3429 | .5068 | .3544 | .3544 |
| 17 | .5316 | .3658 | .4024 | .4115 | .5068 | .3429 | .3814 |
| 18 | .7011 | .5487 | .5376 | .4915 | .6104 | .4858 | .5765 |
| 19 | .7442 | .7087 | .7316 | .7362 | .7316 | .7011 | |
| 20 | .6089 | .5959 | .5731 | .567 | .5373 | .6653 | |
| 21 | .4755 | .4755 | .4458 | .4252 | .4458 | .4805 | |
| 22 | .415 | .4108 | .3696 | .3582 | .3658 | .3734 | |
| 23 | .3734 | .3326 | .2469 | .362 | .3326 | .3361 | |
| 24 | .2987 | .3326 | .2926 | .2987 | .3258 | .3326 | .2957 |
| Max | 1.0185 | 1.1317 | 1.0349 | 1.094 | 1.1431 | 1.0562 | 1.1431 |
| Min | .2865 | .2926 | .2469 | .2957 | .2957 | .2561 | .2507 |
| Avg | .4967 | .4869 | .4590 | .4762 | .5000 | .4553 | .4538 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 205 / 11 KV KALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2263 | .2195 | .16 | .1886 | .3948 | .4287 | .5182 |
| 2 | .2263 | .2218 | .16 | .1886 | .4001 | .4001 | .5182 |
| 3 | .2641 | .2957 | .2241 | .2263 | .4287 | .4401 | .5556 |
| 4 | .3018 | .3361 | .2561 | .2641 | .4458 | .4988 | .5937 |
| 5 | .3395 | .3772 | .3201 | .3395 | .6097 | .759 | .8002 |
| 6 | .415 | .4191 | .3521 | .3772 | .8421 | 1.166 | 1.1469 |
| 7 | | | | | .9717 | 1.757 | 1.8233 |
| 10 | 1.4419 | .9602 | .9922 | | | | |
| 11 | 2.1548 | 1.6194 | 1.6575 | 1.4918 | | | |
| 12 | 1.6907 | 1.4091 | 1.4091 | 1.4746 | | | |
| 13 | 1.5249 | .9922 | 1.0883 | 1.1984 | | | |
| 14 | 1.3108 | .8223 | .8436 | .9804 | | | |
| 15 | 1.3108 | .8539 | .8124 | .8749 | | | |
| 16 | 1.3279 | .8539 | .9804 | .9488 | | | |
| 17 | .9945 | .8436 | .9998 | .7907 | | | |
| 18 | .3429 | .2347 | | .1619 | | | |
| 19 | .3467 | .3429 | .3696 | .3086 | .4066 | .181 | |
| 20 | .3155 | .3429 | .3544 | .3544 | .362 | .3881 | |
| 21 | .2926 | .2804 | .2743 | .2507 | .3052 | .2926 | |
| 22 | .2614 | .2452 | .2241 | .487 | .6923 | .7811 | |
| 23 | .2263 | .2263 | .2263 | .4858 | .6622 | .7274 | |
| 24 | .2263 | .2241 | .2263 | .2263 | .4512 | .5117 | .6249 |
| Max | 2.1548 | 1.6194 | 1.6575 | 1.4918 | .9717 | 1.757 | 1.8233 |
| Min | .2263 | .2195 | .16 | .1619 | .3052 | .181 | .5182 |
| Avg | .7400 | .5772 | .5965 | .5809 | .5363 | .6409 | .8226 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 206 / 11 KV PRATAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3666 | .4572 | .6097 | .4841 | .1143 | .132 | .0762 |
| 2 | .3666 | .4458 | .6097 | .4841 | .1143 | .132 | .0762 |
| 3 | .3948 | .4755 | .7716 | .4988 | .1524 | .132 | .0762 |
| 4 | .5268 | .6097 | .8124 | .5721 | .1524 | .0152 | .1143 |
| 5 | .587 | .7621 | .9686 | .6773 | .1905 | .0171 | .1334 |
| 6 | .7926 | .9259 | 1.0623 | .9842 | .2286 | .0171 | .1524 |
| 7 | 1.0936 | 1.2651 | 1.3757 | 1.2809 | | | |
| 10 | | | | | | .9145 | .7499 |
| 11 | | | | | 1.5384 | 1.7368 | 1.2803 |
| 12 | | | | | 1.7328 | 1.6842 | 1.6004 |
| 13 | | | | | 1.5466 | 1.4723 | 1.5339 |
| 14 | | | | | 1.5203 | 1.4232 | 1.4548 |
| 15 | | | | | 1.4575 | 1.3435 | 1.3283 |
| 16 | | | | | 1.5364 | 1.4232 | 1.3441 |
| 17 | | | | | 1.2186 | 1.2193 | 1.1574 |
| 18 | | | | | | .112 | .1494 |
| 19 | .1463 | .1524 | .2452 | .168 | .2075 | .1143 | |
| 20 | .1905 | .1905 | .1867 | .1905 | .1886 | .1334 | |
| 21 | .1524 | .1524 | .1478 | .1524 | .168 | .1334 | |
| 22 | .6097 | .7716 | .6371 | .1307 | .132 | .0953 | |
| 23 | .5864 | .679 | .6241 | .112 | .1254 | .0762 | |
| 24 | .4458 | .5487 | .6173 | .5428 | .1143 | .132 | .0762 |
| Max | 1.0936 | 1.2651 | 1.3757 | 1.2809 | 1.7328 | 1.7368 | 1.6004 |
| Min | .1463 | .1524 | .1478 | .112 | .1143 | .0152 | .0762 |
| Avg | .4815 | .5720 | .6668 | .4829 | .6547 | .5933 | .7065 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 201 / 11 KV VASAMAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0059 | 1.0227 | 1.0562 | .9892 | .0876 | .0701 | |
| 2 | .9724 | 1.0395 | .9724 | .9724 | .0876 | .0876 | |
| 3 | .9724 | 1.0395 | .9556 | 1.0059 | .0876 | .0876 | |
| 4 | 1.0395 | 1.0227 | 1.0059 | 1.0562 | .0876 | .0876 | |
| 5 | 1.1736 | 1.1233 | 1.1233 | 1.1233 | .0876 | .0876 | |
| 6 | 1.358 | 1.3077 | 1.3077 | 1.1904 | .1052 | .1052 | |
| 7 | 1.4083 | 1.5089 | 1.3923 | 1.6095 | .1052 | .0876 | |
| 8 | .1052 | .1052 | .0838 | .1052 | .0701 | .0701 | .0876 |
| 9 | .0876 | .0876 | .0876 | | .0876 | | .0701 |
| 10 | .0876 | .0701 | .0701 | | .9054 | | 1.1568 |
| 11 | .0701 | .0701 | .0701 | .0701 | 1.4586 | | 1.6766 |
| 12 | .0701 | .0526 | .0701 | .0701 | 1.7604 | | 1.5927 |
| 13 | .0701 | .0526 | .0701 | .0876 | 1.4922 | | 1.6598 |
| 14 | .0526 | .0526 | .0701 | .0526 | 1.5424 | | 1.643 |
| 15 | .0526 | .0526 | .0701 | .0876 | 1.5927 | | 1.6263 |
| 16 | .1052 | | .0701 | .0526 | 1.6095 | | 1.6263 |
| 17 | .1052 | .0701 | .0526 | .0526 | 1.4922 | | 1.4586 |
| 18 | .1052 | .0701 | .0701 | .0876 | .0503 | | .0701 |
| 19 | .1227 | .1052 | .1227 | .1227 | .1227 | | .1227 |
| 20 | .1227 | .1227 | .1052 | .1227 | .1052 | | .1052 |
| 21 | .1052 | .0876 | .0876 | .1052 | .1052 | | .0876 |
| 22 | .9054 | 1.1233 | .9892 | .0876 | .0876 | | .0701 |
| 23 | 1.0562 | 1.1904 | | .1052 | .0876 | | .0701 |
| 24 | 1.0562 | 1.0562 | 1.1401 | .9892 | .0876 | .0701 | .0701 |
| Max | 1.4083 | 1.5089 | 1.3923 | 1.6095 | 1.7604 | .1052 | 1.6766 |
| Min | .0526 | .0526 | .0526 | .0526 | .0503 | .0701 | .0701 |
| Avg | .5088 | .5406 | .4801 | .4612 | .5544 | .0837 | .7761 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 202 / 11 KV MHASADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3353 | .3353 | .3353 | .3353 | .3856 | .3688 | .3353 |
| 2 | .3185 | .4024 | .3521 | .3688 | .3856 | .3688 | |
| 3 | .3521 | .4191 | .4024 | .4024 | .4191 | .4024 | |
| 4 | .4024 | .4359 | .4527 | .4694 | .4862 | .5197 | |
| 5 | .6036 | .57 | .5365 | .57 | .5868 | .6036 | |
| 6 | .8886 | .7377 | .7042 | .7209 | .788 | 1.0059 | |
| 7 | 1.073 | .9556 | .8886 | .9724 | .8383 | .9892 | |
| 8 | .9221 | .8048 | .8048 | .9054 | .8215 | .6874 | .9221 |
| 9 | | .6036 | .6874 | | .6371 | | .6203 |
| 10 | .5197 | .4862 | .5533 | | .4862 | | .5365 |
| 11 | .4862 | .3856 | .4694 | .6036 | .3856 | | .4694 |
| 12 | .4694 | .3521 | .4862 | .503 | .3521 | | .4359 |
| 13 | .4694 | .4191 | .4359 | .4694 | .3856 | | .3521 |
| 14 | .4191 | .3018 | .3688 | .3688 | .4527 | | .3856 |
| 15 | .4191 | .3018 | .3856 | .4024 | .4527 | | .4359 |
| 16 | .503 | | .5788 | .4024 | .4862 | | .4527 |
| 17 | .5365 | .4191 | .57 | .4527 | .4862 | | .4862 |
| 18 | .788 | .6371 | .5197 | .5197 | .6203 | | .5868 |
| 19 | .8215 | .7545 | .7545 | .7209 | .7209 | | .7377 |
| 20 | .6203 | .57 | .6706 | .6371 | .6036 | | .6203 |
| 21 | .5365 | .5197 | .57 | .5533 | .5533 | | .5533 |
| 22 | .4527 | .4359 | .5228 | .4862 | .4527 | | .4862 |
| 23 | .4191 | .3521 | .4024 | .4191 | .4024 | | .4191 |
| 24 | .3185 | .4024 | .3353 | .3688 | .4024 | .3688 | .3856 |
| Max | 1.073 | .9556 | .8886 | .9724 | .8383 | 1.0059 | .9221 |
| Min | .3185 | .3018 | .3353 | .3353 | .3521 | .3688 | .3353 |
| Avg | .5511 | .5044 | .5328 | .5296 | .5246 | .5905 | .5123 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 203 / 11 KV KAKANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3856 | .4733 | .4207 | .4031 | 1.1233 | 1.1233 | |
| 2 | .4031 | .4733 | .4207 | .4557 | 1.1401 | 1.1401 | |
| 3 | .4382 | .5083 | .4908 | .5434 | 1.1736 | 1.2407 | |
| 4 | .5434 | .5609 | .5434 | .5609 | 1.2407 | 1.3748 | |
| 5 | .5959 | .6485 | .6135 | .631 | 1.3077 | 1.5592 | |
| 6 | | | | | 1.4754 | 2.2131 | |
| 7 | | | | | 1.7101 | 2.364 | |
| 8 | .4908 | .5784 | | | .5959 | | .631 |
| 9 | .4733 | .5083 | .4557 | | .4207 | | |
| 10 | 1.6766 | 1.576 | 1.4083 | | .3155 | | .3856 |
| 11 | 2.5819 | 2.3807 | | 2.2801 | .2629 | | .2629 |
| 12 | 2.5819 | 2.5484 | 2.6155 | 2.5652 | .2279 | | |
| 13 | 1.643 | 2.6155 | 2.5484 | 2.2634 | | | |
| 14 | 2.4813 | 2.4478 | | 1.7772 | | | .2454 |
| 15 | 2.5987 | 2.3807 | 2.3807 | 2.0287 | .333 | | .2454 |
| 16 | | | 2.3975 | 2.1293 | .333 | | .2454 |
| 17 | 2.3137 | | 2.3137 | 1.9113 | .3506 | | .2629 |
| 18 | | .5083 | 1.9281 | .3856 | .4382 | | |
| 19 | .5609 | .6485 | .5959 | .5434 | .5434 | | .631 |
| 20 | .5609 | .5258 | .5784 | .5434 | .5258 | | .5959 |
| 21 | .5083 | .5083 | .5434 | .4382 | .4557 | | .5083 |
| 22 | .4733 | .4908 | .5083 | 1.2407 | 1.3077 | | 1.3748 |
| 23 | .4733 | .4382 | .4733 | 1.3077 | 1.4754 | | 1.4754 |
| 24 | .4031 | .4733 | .3856 | .4207 | 1.2742 | 1.2071 | 1.4586 |
| Max | 2.5987 | 2.6155 | 2.6155 | 2.5652 | 1.7101 | 2.364 | 1.4754 |
| Min | .3856 | .4382 | .3856 | .3856 | .2279 | 1.1233 | .2454 |
| Avg | 1.1094 | 1.0647 | 1.1380 | 1.1805 | .8196 | 1.5278 | .6402 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 204 / 11 KV DHAMNAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0316 | .0492 | .048 | .0486 | .6401 | .8322 | |
| 2 | .0474 | .0492 | .048 | .0486 | .6241 | .8322 | |
| 3 | .0474 | .0492 | .064 | .0486 | .6562 | .8642 | |
| 4 | .0474 | .0492 | .064 | .0486 | .7042 | .9282 | |
| 5 | .0633 | .0655 | .08 | .0648 | .7522 | 1.1043 | |
| 6 | .0791 | .0655 | .096 | .081 | 1.0311 | 1.4083 | |
| 7 | .0791 | .0655 | .064 | .081 | 1.3592 | 1.6004 | |
| 8 | .0474 | .0328 | .048 | .0648 | .0469 | .064 | .048 |
| 9 | .0492 | .032 | .048 | | .048 | | .0469 |
| 10 | 1.0159 | 1.0242 | .9282 | | .048 | | .0312 |
| 11 | 2.4086 | 1.7924 | 2.0005 | 1.8299 | .048 | | .0312 |
| 12 | 2.2775 | 2.1605 | 1.7124 | 1.8947 | .032 | | .0312 |
| 13 | 2.3266 | 2.0165 | 1.7284 | 1.8947 | .032 | | .0312 |
| 14 | 2.1464 | 1.9524 | 1.8564 | 1.668 | .032 | | .0312 |
| 15 | 2.0809 | 1.9204 | 2.0538 | 1.7166 | .032 | | .0312 |
| 16 | 2.0317 | 1.8884 | 1.6004 | 1.6842 | .032 | | .0312 |
| 17 | 1.7368 | 1.6964 | 1.5524 | 1.5384 | .048 | | .0312 |
| 18 | .0492 | .064 | .032 | .0324 | .048 | | .032 |
| 19 | .0819 | .08 | .064 | .0648 | .064 | | .064 |
| 20 | .0655 | .08 | .064 | .0648 | .08 | | .08 |
| 21 | .0492 | .08 | .048 | .0486 | .048 | | .048 |
| 22 | .0655 | .064 | .048 | .5992 | .8962 | | .9335 |
| 23 | .0492 | .064 | .048 | .6964 | .9122 | | .9282 |
| 24 | .048 | .0492 | .048 | .048 | .664 | .8802 | .8592 |
| Max | 2.4086 | 2.1605 | 2.0538 | 1.8947 | 1.3592 | 1.6004 | .9335 |
| Min | .0316 | .032 | .032 | .0324 | .032 | .064 | .0312 |
| Avg | .7052 | .6413 | .5977 | .6485 | .3699 | .946 | .1935 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 205 / 11 KV CHINCHKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.105 | 1.2384 | 1.1949 | 1.2003 | .362 | .3174 | |
| 2 | 1.0479 | 1.2384 | 1.1203 | 1.1431 | .381 | .3361 | |
| 3 | 1.086 | 1.1812 | 1.1016 | 1.1812 | .4001 | .3361 | |
| 4 | 1.1431 | 1.1812 | 1.1203 | 1.2193 | .4191 | .3734 | |
| 5 | 1.2955 | 1.2955 | 1.3256 | 1.3717 | .4382 | .4108 | |
| 6 | 1.4289 | 1.7528 | 1.8298 | 1.8671 | .5335 | .5228 | |
| 7 | 1.848 | 2.1529 | 2.1098 | 1.9433 | .4954 | .4854 | |
| 8 | .4191 | .4382 | .3734 | .4382 | .5144 | .4481 | .5041 |
| 9 | .2667 | .2427 | .2614 | | .3361 | | .3429 |
| 10 | .1905 | .168 | .1867 | | 1.1949 | | 1.3336 |
| 11 | .1905 | .1494 | .1494 | | 2.5019 | | 2.5911 |
| 12 | .1715 | .168 | .168 | .2477 | 2.3899 | | 2.4006 |
| 13 | .1715 | .168 | .1307 | .2096 | 2.3152 | | 2.1529 |
| 14 | .1334 | .168 | .1494 | .1905 | 2.2965 | | 2.0957 |
| 15 | .1524 | .1867 | .1509 | .1715 | 2.2405 | | 2.2672 |
| 16 | .1715 | .2054 | .168 | .1715 | 2.2218 | | 2.2481 |
| 17 | .1715 | .3361 | .168 | .1905 | 2.0538 | | 2.1529 |
| 18 | .4954 | .3734 | .2054 | .4572 | .4854 | | .3547 |
| 19 | .5716 | .5228 | .5041 | .5335 | .5041 | | .5415 |
| 20 | .5716 | .5975 | .5788 | .5906 | .5228 | | .4854 |
| 21 | .5335 | .5788 | .5601 | .6287 | .5601 | | .4207 |
| 22 | 1.2384 | 1.2696 | 1.4003 | .4382 | .3921 | | .3361 |
| 23 | 2.3891 | 1.4377 | 1.3443 | .4001 | .3361 | | .298 |
| 24 | 1.1016 | 1.3527 | 1.307 | 1.2136 | .381 | .3174 | .2987 |
| Max | 2.3891 | 2.1529 | 2.1098 | 1.9433 | 2.5019 | .5228 | 2.5911 |
| Min | .1334 | .1494 | .1307 | .1715 | .3361 | .3174 | .298 |
| Avg | .7456 | .7668 | .7337 | .7527 | 1.0115 | .3942 | 1.2250 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 201 / 11 KV MALPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3655 | .3756 | .4045 | .4211 | .3987 | .3668 | .4307 |
| 2 | .3969 | .3756 | .4045 | .4225 | .3969 | .3626 | .4303 |
| 3 | .4285 | .4423 | .4738 | .5205 | .3996 | .5243 | .4924 |
| 4 | | .542 | .598 | .7331 | | .6922 | .5313 |
| 5 | .8197 | .8194 | .9209 | .9435 | .6097 | .8376 | .834 |
| 6 | | | | | .9074 | | |
| 9 | .7026 | .6935 | .7327 | | .7496 | .7511 | .7413 |
| 10 | .5988 | .6028 | .5696 | | .5621 | .4578 | .6492 |
| 11 | .4334 | .4984 | .4742 | .6767 | .4881 | .4716 | .5274 |
| 12 | .3852 | .4608 | .4141 | .5058 | .4854 | .4067 | .4206 |
| 13 | | .4177 | .3324 | .4033 | .4527 | .3672 | .3754 |
| 14 | .3182 | .3889 | .3261 | | .4785 | .364 | .3549 |
| 15 | .4186 | .3777 | .3182 | .3443 | .4567 | .3558 | .3745 |
| 16 | .5306 | .4087 | .3772 | .3294 | .515 | .3982 | .3823 |
| 17 | .5975 | .4438 | .4246 | .4975 | | .3667 | .4518 |
| 18 | .7587 | .5176 | .5589 | .5525 | .6417 | .5085 | .6255 |
| 19 | .7242 | .7965 | .7426 | .8001 | .767 | .7913 | .8186 |
| 20 | .6509 | .7439 | .6687 | | .6668 | .6996 | .6682 |
| 21 | .5785 | .6442 | .6224 | .6313 | .5775 | .5998 | .5875 |
| 22 | .478 | .5522 | .5066 | | .5347 | .5235 | .4861 |
| 23 | .4301 | .4671 | .4401 | .4453 | | .4401 | .4188 |
| 24 | .4182 | .376 | .4315 | .4193 | .4033 | .4144 | .4193 |
| Max | .8197 | .8194 | .9209 | .9435 | .9074 | .8376 | .834 |
| Min | .3182 | .3756 | .3182 | .3294 | .3969 | .3558 | .3549 |
| Avg | .5281 | .5212 | .5115 | .5404 | .5522 | .5095 | .5248 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 202 / 11 KV NAWADNE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7613 | .038 | .0359 | .0167 | 1.5421 | 1.615 | 1.7947 |
| 2 | 1.6557 | .038 | .0352 | .0166 | 1.4661 | 1.6315 | 1.7663 |
| 3 | 1.5833 | .038 | .0354 | .0166 | 1.5004 | 1.6277 | 1.7569 |
| 4 | | .038 | .0359 | .0166 | | 1.6289 | 1.7966 |
| 5 | 1.7044 | .0759 | .0359 | .0166 | 1.415 | 1.6414 | 1.7871 |
| 6 | 1.7981 | .0759 | .036 | .0166 | 1.4934 | 1.6246 | 1.8764 |
| 7 | 2.0082 | | | | 1.8002 | 1.9244 | 1.9343 |
| 10 | | 1.9559 | 1.8607 | | | | |
| 11 | | 2.5006 | 2.5849 | 2.6422 | | | |
| 12 | | 2.3285 | 2.4785 | 2.5966 | | | |
| 13 | | 2.4863 | 2.3786 | 2.332 | | | |
| 14 | | 2.001 | 2.5206 | | | | |
| 15 | | 2.3259 | 2.4115 | 1.9943 | | | |
| 16 | | 2.3259 | 2.1474 | 2.1046 | | | |
| 17 | | 2.2377 | 2.2083 | 1.9411 | | | |
| 18 | | .036 | .0163 | 1.8592 | | | |
| 19 | .038 | .0359 | .0326 | .056 | .0372 | .0352 | .0327 |
| 20 | .0757 | .0357 | .0166 | | .0759 | .036 | .0327 |
| 21 | .0757 | .0359 | .0167 | .0568 | .0759 | .0359 | .0327 |
| 22 | .0759 | .0357 | .0333 | | 1.5721 | 1.6507 | .0327 |
| 23 | .0567 | .0359 | .0167 | 1.3248 | | 1.7547 | .0327 |
| 24 | 1.7348 | .0378 | .0359 | .0333 | 1.4934 | 1.6479 | 1.7585 |
| Max | 2.0082 | 2.5006 | 2.5849 | 2.6422 | 1.8002 | 1.9244 | 1.9343 |
| Min | .038 | .0357 | .0163 | .0166 | .0372 | .0352 | .0327 |
| Avg | 1.0473 | .8914 | .9035 | 1.0024 | 1.1338 | 1.2965 | 1.1257 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 203 / 11 KV GANESHPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0536 | 1.1358 | 1.5364 | 1.41 | .0517 | .0872 | .0528 |
| 2 | .0527 | 1.166 | 1.5364 | 1.4117 | .0508 | .0872 | .0528 |
| 3 | .0508 | 1.1913 | 1.5638 | 1.41 | .0507 | .0867 | .0521 |
| 4 | | 1.2337 | 1.6706 | 1.442 | | .1046 | .0528 |
| 5 | .0702 | 1.3047 | 1.6706 | 1.4386 | .0525 | .1216 | .0526 |
| 6 | .0716 | 1.7593 | 1.667 | 1.7263 | .0713 | .1425 | .0706 |
| 7 | | 2.0525 | 1.9759 | 2.0558 | | | |
| 10 | 1.9022 | | | | 1.627 | 1.4266 | 1.418 |
| 11 | 2.1647 | | | | 2.652 | 2.7129 | 2.6398 |
| 12 | 2.7926 | | | | 2.5465 | 2.5497 | 2.5466 |
| 13 | | | | | 2.5737 | 2.5636 | 2.3449 |
| 14 | 2.2698 | | | | 2.5174 | 2.3948 | 2.3449 |
| 15 | 2.2192 | | | | 2.559 | 2.2405 | 2.2485 |
| 16 | 2.0773 | | | | 2.321 | 2.2405 | 2.2348 |
| 17 | 2.0607 | | | | | 2.073 | 2.0309 |
| 18 | | | | | .0697 | .0267 | .0381 |
| 19 | .0644 | .0473 | .0677 | .066 | .0941 | | .0504 |
| 20 | .0969 | .0616 | .0652 | | .0932 | .0525 | .0493 |
| 21 | .1288 | .0607 | .0646 | .0774 | .1096 | .0512 | .0494 |
| 22 | .9634 | 1.4661 | 1.355 | | .1096 | .051 | .8342 |
| 23 | 1.074 | 1.5167 | 1.4776 | .053 | | .0508 | .7897 |
| 24 | .0717 | 1.1413 | 1.6118 | 1.41 | .0527 | .0975 | .0521 |
| Max | 2.7926 | 2.0525 | 1.9759 | 2.0558 | 2.652 | 2.7129 | 2.6398 |
| Min | .0508 | .0473 | .0646 | .053 | .0507 | .0267 | .0381 |
| Avg | 1.0103 | 1.0875 | 1.2510 | 1.1364 | .9779 | .9581 | .9526 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 204 / 11 KV KASARE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2977 | .2902 | .3059 | .3222 | .338 | .3414 | .3229 |
| 2 | .3307 | .2902 | .3056 | .3222 | .338 | .3414 | .3243 |
| 3 | .3638 | .3243 | .3391 | .3561 | .4056 | .4083 | .3225 |
| 4 | | .3573 | .4609 | .4748 | | .4758 | .3429 |
| 5 | .6284 | .5444 | .6152 | .5596 | .5256 | .6465 | .5448 |
| 6 | | | | | .6104 | | |
| 9 | .6119 | .6487 | .5988 | | .5765 | .6295 | .6337 |
| 10 | .5548 | .531 | .5804 | | .4409 | .4906 | .4906 |
| 11 | .4344 | .478 | .5121 | .6472 | .4409 | .4394 | .4568 |
| 12 | .4161 | .4282 | .4438 | .545 | .4097 | .4583 | .4906 |
| 13 | | .4785 | .4097 | .4423 | .4758 | .4249 | .4056 |
| 14 | .3966 | .4609 | .3414 | | .4268 | .4097 | .3718 |
| 15 | .4051 | .4258 | .3926 | .3904 | .3756 | .376 | .338 |
| 16 | .478 | .4277 | .4097 | .407 | .4578 | .4258 | .3882 |
| 17 | .5121 | .4111 | .4409 | .4742 | | .4448 | .4726 |
| 18 | .5804 | .4573 | | .5414 | .5292 | .495 | .5402 |
| 19 | .5463 | .581 | .5921 | .5577 | .5438 | .5438 | .557 |
| 20 | .4764 | .5469 | .5245 | | .5104 | .5087 | .4895 |
| 21 | .4423 | .4758 | .4906 | .507 | .4764 | .478 | .4558 |
| 22 | .4083 | .3896 | .406 | | .4423 | .4244 | .3718 |
| 23 | .3403 | .3399 | .3391 | .3549 | | .3726 | .3549 |
| 24 | .3307 | .3059 | .3052 | .3222 | .3211 | .3414 | .3233 |
| Max | .6284 | .6487 | .6152 | .6472 | .6104 | .6465 | .6337 |
| Min | .2977 | .2902 | .3052 | .3222 | .3211 | .3414 | .3225 |
| Avg | .4502 | .4377 | .4407 | .4515 | .4550 | .4513 | .4285 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 205 / 11 KV KOKALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .08 | 1.1149 | 1.2453 | 1.4294 | .0642 | .0796 | .0961 |
| 2 | .08 | 1.1309 | 1.2394 | 1.4134 | .0642 | .0796 | .0805 |
| 3 | .08 | 1.1786 | 1.223 | 1.4134 | .0642 | .0796 | .0798 |
| 4 | | 1.173 | 1.2772 | 1.4134 | | .0793 | .0967 |
| 5 | .096 | 1.1786 | 1.3061 | 1.4134 | .0964 | .0791 | .1124 |
| 6 | .128 | 1.2901 | 1.4972 | 1.6061 | .1124 | .0951 | .1119 |
| 7 | | 1.4335 | 1.6804 | 1.6061 | | | |
| 10 | 1.5938 | | | | 1.4175 | 1.4056 | 1.551 |
| 11 | 2.2592 | | | | 1.9909 | 2.1225 | 2.1998 |
| 12 | 2.0805 | | | | 2.1343 | 2.1624 | 2.216 |
| 13 | | | | | 2.0899 | 2.0558 | |
| 14 | 1.975 | | | | 2.1605 | 2.0631 | |
| 15 | 1.909 | | | | 1.8863 | 1.9872 | |
| 16 | 1.8591 | | | | 1.9548 | 2.047 | |
| 17 | 1.8157 | | | | | 1.7828 | 2.0057 |
| 18 | | | | | .0637 | .1131 | .1132 |
| 19 | .0956 | .0969 | .1283 | .1606 | .1115 | .1568 | .1294 |
| 20 | .1123 | .0974 | .1283 | | .1283 | .1254 | .1294 |
| 21 | .1268 | .1119 | .1123 | .1445 | .1268 | .1102 | .1132 |
| 22 | 1.0303 | 1.1289 | 1.2673 | | .1126 | .1104 | 1.0676 |
| 23 | 1.1254 | 1.3796 | 1.3956 | .0803 | | .0944 | 1.1323 |
| 24 | .096 | 1.1176 | 1.259 | 1.4277 | .0642 | .0959 | .0939 |
| Max | 2.2592 | 1.4335 | 1.6804 | 1.6061 | 2.1605 | 2.1624 | 2.216 |
| Min | .08 | .0969 | .1123 | .0803 | .0637 | .0791 | .0798 |
| Avg | .9190 | .9563 | 1.0584 | 1.1008 | .8135 | .8059 | .6664 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 206 / 11 KV MALPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.012 | .0478 | .0631 | .0642 | .9293 | .9282 | .9127 |
| 2 | .9488 | .0478 | .0631 | .0642 | .8973 | .9293 | .8655 |
| 3 | .8855 | .0478 | .0629 | .0642 | .8332 | .9304 | .8676 |
| 4 | | .0637 | .0634 | .0642 | | .9397 | .8603 |
| 5 | .9488 | .0796 | .0627 | .0642 | .8332 | .9716 | .8813 |
| 6 | 1.012 | .0796 | .0627 | .0803 | .942 | 1.0267 | .9385 |
| 7 | 1.1385 | | | | 1.1176 | 1.2352 | 1.1317 |
| 10 | | 1.2119 | 1.4134 | | | | |
| 11 | | 1.2352 | 1.7688 | 1.7246 | | | |
| 12 | | 1.5966 | 1.6884 | 1.6924 | | | |
| 13 | | 1.7325 | 1.5597 | 1.6382 | | | |
| 14 | | 1.644 | 1.5758 | | | | |
| 15 | | 1.5995 | 1.5597 | 1.5097 | | | |
| 16 | | 1.6213 | 1.4954 | 1.4937 | | | |
| 17 | | 1.4498 | 1.3507 | 1.4134 | | | |
| 18 | | .0798 | .0802 | 1.3139 | | | |
| 19 | .0641 | .0802 | .0642 | .0641 | .0798 | .0944 | .0953 |
| 20 | .0966 | .0966 | .0802 | | .0963 | .0812 | .0953 |
| 21 | .0956 | .0802 | .0802 | .0801 | .0804 | .0787 | .0794 |
| 22 | .0799 | .0805 | .0642 | | .8663 | .9442 | .0636 |
| 23 | .0637 | .0802 | .0642 | .8652 | | .9659 | .0636 |
| 24 | .9804 | .0634 | .0802 | .0642 | .8973 | .9293 | .9785 |
| Max | 1.1385 | 1.7325 | 1.7688 | 1.7246 | 1.1176 | 1.2352 | 1.1317 |
| Min | .0637 | .0478 | .0627 | .0641 | .0798 | .0787 | .0636 |
| Avg | .6105 | .6199 | .6335 | .7212 | .6884 | .7734 | .6026 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 201 / 11 KV SHEWAGE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2286 | .3018 | .3206 | .2818 | .9145 | 1.267 | 1.2178 |
| 2 | .2439 | .3206 | .3206 | .2818 | .8993 | 1.2308 | 1.182 |
| 3 | .2743 | .3206 | .3395 | .3222 | .9145 | 1.2308 | 1.182 |
| 4 | .3353 | .3395 | .3772 | .3812 | .9145 | 1.2489 | 1.1946 |
| 5 | .4725 | .5093 | .5281 | .431 | 1.0974 | 1.4118 | 1.4118 |
| 6 | .6554 | .8865 | .7922 | .7291 | 1.2193 | 1.7013 | 1.5939 |
| 7 | .823 | .8676 | 1.0185 | .8619 | 1.4175 | 1.9547 | 1.825 |
| 8 | .6097 | .5658 | .7167 | .7202 | .6097 | .6224 | .7356 |
| 9 | | .4338 | .4904 | .4877 | .4715 | .4904 | .3961 |
| 10 | 2.2502 | 1.7718 | | 1.3413 | .3961 | .3584 | .3887 |
| 11 | 2.392 | 2.3579 | 2.3537 | 1.9052 | .3395 | .3018 | .3222 |
| 12 | 2.4364 | 2.2885 | 2.1548 | 1.9052 | .2641 | .2263 | .2374 |
| 13 | 2.3838 | 2.0631 | 1.8652 | 1.6766 | .3018 | .2263 | .2204 |
| 14 | 2.0111 | 1.8551 | 1.8652 | 1.5242 | .2829 | .2452 | .213 |
| 15 | 2.0508 | 1.6297 | 1.6956 | 1.4784 | .3206 | .2641 | .2374 |
| 16 | 1.949 | 1.9105 | 1.6712 | 1.5242 | .3395 | .2452 | .2883 |
| 17 | 1.7511 | 1.8378 | 1.7238 | 1.4937 | .3584 | .2641 | |
| 18 | .5847 | .4338 | .3647 | .3048 | .415 | .3772 | |
| 19 | .6224 | .6602 | .431 | .6706 | .6036 | .6413 | .3315 |
| 20 | .5093 | .547 | .4475 | .5639 | .6036 | .6413 | .39 |
| 21 | .5093 | .5093 | .4588 | .4725 | .4715 | .5093 | .4807 |
| 22 | .4338 | .415 | .3315 | .884 | 1.4148 | 1.3611 | .6443 |
| 23 | .3395 | .3772 | .2984 | .9755 | 1.3611 | 1.4352 | .8453 |
| 24 | .2439 | .3206 | .3395 | .2915 | .945 | 1.3112 | 1.3289 |
| Max | 2.4364 | 2.3579 | 2.3537 | 1.9052 | 1.4175 | 1.9547 | 1.825 |
| Min | .2286 | .3018 | .2984 | .2818 | .2641 | .2263 | .213 |
| Avg | 1.0483 | .9801 | .9089 | .8962 | .7032 | .8153 | .7576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 202 / 11 KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2743 | .415 | .3961 | .4854 | .1067 | .1132 | .1109 |
| 2 | .2591 | .415 | .3772 | .407 | .1067 | .1132 | .1109 |
| 3 | .2743 | .4338 | .3772 | .3932 | .1219 | .1132 | .1109 |
| 4 | .2896 | .4338 | .3772 | .4161 | .1372 | .132 | .1478 |
| 5 | .3353 | .5281 | .4527 | .407 | .1524 | .2075 | .1848 |
| 6 | .4877 | .679 | .6224 | .7343 | .2134 | .3395 | .2587 |
| 7 | .8383 | .8676 | 1.0185 | .9835 | .2591 | .3961 | .2957 |
| 8 | .2286 | .2452 | .1886 | .2321 | .2286 | .3018 | .2772 |
| 9 | | .1886 | .2263 | .2286 | .1509 | .2075 | .2033 |
| 10 | .1307 | .1132 | .5935 | .1524 | 1.0185 | .4854 | .2486 |
| 11 | .0724 | .0566 | .0509 | .1524 | 1.3203 | 1.1016 | .5138 |
| 12 | .1086 | .0566 | .0509 | .0762 | 1.3957 | 1.1949 | |
| 13 | .1267 | .0566 | .052 | .061 | 1.0562 | 1.0829 | .8785 |
| 14 | .1578 | .0566 | .0526 | .061 | .9808 | .8589 | .8648 |
| 15 | .1578 | .0566 | .0532 | .061 | .9149 | .6722 | .7291 |
| 16 | .1387 | .0754 | .0663 | .061 | .9149 | .7468 | .663 |
| 17 | .156 | .0754 | .0655 | .061 | .8299 | .7282 | .5898 |
| 18 | .156 | .1132 | .0819 | .1067 | .1509 | .1109 | .1187 |
| 19 | .1734 | .2075 | .1017 | .2286 | .2452 | .2218 | .1187 |
| 20 | .1448 | .2641 | .116 | .1981 | .2452 | .2587 | .1357 |
| 21 | .1448 | .1698 | .1311 | .2134 | .1698 | .1848 | .1372 |
| 22 | .4715 | .4527 | .3481 | .1372 | .1509 | .1663 | .2486 |
| 23 | .4715 | .4527 | .4409 | .1219 | .132 | .1478 | .3315 |
| 24 | .3353 | .4338 | .4338 | .4854 | .0914 | .1132 | .1109 |
| Max | .8383 | .8676 | 1.0185 | .9835 | 1.3957 | 1.1949 | .8785 |
| Min | .0724 | .0566 | .0509 | .061 | .0914 | .1109 | .1109 |
| Avg | .2580 | .2853 | .2781 | .2694 | .4622 | .4166 | .3213 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 203 / 11 KV SHEWDIPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0457 | .048 | .0474 | .0497 | .2439 | .427 | .3479 |
| 2 | .0457 | .048 | .0474 | .0497 | .5639 | .4111 | .3321 |
| 3 | .0457 | .048 | .0474 | .0526 | .2286 | .427 | .3321 |
| 4 | .0457 | .048 | .0474 | .052 | .2286 | .427 | .3321 |
| 5 | .0457 | .048 | .0474 | .052 | .3658 | .4744 | .3637 |
| 6 | .0457 | .064 | .0633 | .0509 | .3658 | .5693 | .4902 |
| 7 | .061 | .064 | .0633 | .0686 | .6097 | .759 | .759 |
| 8 | .061 | .048 | .0633 | .0663 | .0457 | .0633 | .0474 |
| 9 | | .048 | .0474 | .0457 | .0474 | .0474 | .0474 |
| 10 | .9431 | .5121 | .2984 | .4572 | .0474 | .0474 | .0497 |
| 11 | 1.1105 | .7682 | .9054 | .6859 | .0474 | .0474 | .0497 |
| 12 | 1.1142 | .9762 | .8987 | .7621 | .0474 | .0474 | |
| 13 | 1.0898 | .8962 | .9114 | .6401 | .0474 | .0474 | .0497 |
| 14 | | .8322 | .8288 | .5487 | .0474 | .0474 | .0497 |
| 15 | .8684 | .7202 | .8139 | .4877 | .0474 | .0474 | .0497 |
| 16 | .8097 | .7682 | .78 | .3353 | .0474 | .0474 | .0509 |
| 17 | .6882 | .7042 | .7461 | .5335 | .0474 | .0474 | .0497 |
| 18 | .048 | .0474 | .0509 | .0457 | .0474 | .0474 | .0509 |
| 19 | .064 | .0633 | .0655 | .061 | .0633 | .0633 | .0497 |
| 20 | .064 | .0791 | .0678 | .061 | .0633 | .0633 | .0497 |
| 21 | .064 | .0633 | .0678 | .061 | .0474 | .0474 | .0509 |
| 22 | .064 | .0633 | .0509 | .2286 | .4428 | .3953 | .2486 |
| 23 | .048 | .0474 | .0497 | .3048 | .4744 | .427 | .2883 |
| 24 | .0457 | .048 | .0474 | .0497 | .2591 | .4428 | .3795 |
| Max | 1.1142 | .9762 | .9114 | .7621 | .6097 | .759 | .759 |
| Min | .0457 | .0474 | .0474 | .0457 | .0457 | .0474 | .0474 |
| Avg | .3372 | .2939 | .2940 | .2396 | .1865 | .2280 | .1965 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 204 / 11 KV UMBHARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3506 | .3109 | .4207 | .3315 | .5792 | .8131 | .7392 |
| 2 | .3353 | .3206 | .4207 | .3315 | .5639 | .8131 | .7023 |
| 3 | .3658 | .3292 | .439 | .3481 | .5792 | .8316 | .7023 |
| 4 | .3963 | .3658 | .4755 | .3978 | .5944 | .8316 | .7392 |
| 5 | .4572 | .4755 | .5853 | .4748 | .7621 | .9795 | .9055 |
| 6 | .5487 | .7133 | .6584 | .5079 | .8535 | 1.423 | 1.2012 |
| 7 | .6097 | .7682 | | .6299 | 1.0669 | 1.3121 | 1.5154 |
| 8 | .4572 | .5853 | .5853 | .4915 | .4572 | .5175 | .6099 |
| 9 | | .4024 | .4572 | .4572 | .2957 | .3696 | .499 |
| 10 | 1.7177 | 1.0974 | .5935 | .8383 | .1663 | .2772 | .3315 |
| 11 | 2.2177 | 1.7924 | 1.5249 | 1.5242 | .1848 | .2033 | .1326 |
| 12 | 1.922 | 1.7558 | 1.3426 | 1.2193 | .2033 | .1478 | |
| 13 | 1.9959 | 1.3717 | 1.0682 | .9907 | .2218 | .1478 | .1658 |
| 14 | .8316 | 1.2437 | 1.046 | .9907 | .2402 | .1478 | .1492 |
| 15 | 1.4266 | 1.2254 | 1.0174 | .9602 | .2587 | .1848 | .1492 |
| 16 | 1.5181 | 1.39 | 1.0277 | .6859 | .2772 | .1478 | .1696 |
| 17 | 1.4266 | 1.1706 | 1.1191 | .9907 | .3326 | .1478 | .2155 |
| 18 | .4572 | .2378 | .3222 | .2439 | .3696 | .3142 | .3647 |
| 19 | .5487 | .5487 | .3561 | .4572 | .5914 | .5544 | .3812 |
| 20 | .439 | .439 | .39 | .4268 | .5359 | .5544 | .407 |
| 21 | .4572 | .5121 | .4409 | .381 | .462 | .462 | .3978 |
| 22 | .4024 | .4572 | .3944 | .5944 | .8871 | .8871 | .5138 |
| 23 | .4024 | .4207 | .3561 | .6249 | .8871 | .924 | .6562 |
| 24 | .3658 | .3292 | .4024 | .3391 | .5792 | .8316 | .7762 |
| Max | 2.2177 | 1.7924 | 1.5249 | 1.5242 | 1.0669 | 1.423 | 1.5154 |
| Min | .3353 | .2378 | .3222 | .2439 | .1663 | .1478 | .1326 |
| Avg | .8543 | .7610 | .6715 | .6349 | .4979 | .5760 | .5402 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 205 / 11 KV VIRKHEL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6249 | .7042 | .6958 | .7291 | .2896 | .3206 | .3772 |
| 2 | .6097 | .7202 | .7442 | .6588 | .3048 | .3395 | .3772 |
| 3 | .6249 | .7125 | .6249 | .6984 | .3201 | .3206 | .3961 |
| 4 | .6249 | .7449 | .5937 | .6796 | .3353 | .3395 | .4338 |
| 5 | .7164 | .8421 | .6173 | .7122 | .4268 | .415 | .5658 |
| 6 | .945 | 1.0526 | .8259 | .8573 | .5792 | .7922 | .7545 |
| 7 | 1.2041 | 1.3108 | 1.2955 | 1.3923 | .6097 | .811 | .7922 |
| 8 | .4877 | .6036 | .679 | .6104 | .4725 | .6224 | .6036 |
| 9 | | .4904 | .5093 | .381 | .4338 | .3772 | .4904 |
| 10 | .3395 | .2641 | .285 | .2286 | 1.4883 | 1.1092 | .503 |
| 11 | .2829 | .2075 | .1823 | .1524 | 1.7814 | 1.5971 | 1.5415 |
| 12 | .2263 | .1886 | .1823 | .1524 | 1.8299 | 1.5181 | |
| 13 | .2829 | .1698 | .1823 | .1219 | 1.6404 | 1.531 | 1.6078 |
| 14 | .3206 | .1698 | .1658 | .1219 | 1.4864 | 1.3748 | 1.5912 |
| 15 | .3584 | .1886 | .1492 | .1219 | 1.4864 | 1.439 | 1.5939 |
| 16 | .4527 | .2452 | .1989 | .1829 | 1.5181 | 1.4232 | 1.3923 |
| 17 | .4715 | .2641 | .2155 | .1981 | 1.3889 | 1.4232 | 1.3094 |
| 18 | .4338 | .3772 | .3315 | .3048 | .4715 | .3961 | .4144 |
| 19 | .4715 | .5658 | .3647 | .4115 | .547 | .547 | .3978 |
| 20 | .3772 | .5281 | .3768 | .381 | .4527 | .4715 | .3812 |
| 21 | .3772 | .3961 | .3812 | .3201 | .415 | .4338 | .3812 |
| 22 | .703 | .759 | .5596 | .3201 | .3772 | .415 | .3315 |
| 23 | .7499 | .759 | .6796 | .2896 | .3584 | .3584 | .2949 |
| 24 | .6249 | .7202 | .7432 | .763 | .2896 | .3206 | .3584 |
| Max | 1.2041 | 1.3108 | 1.2955 | 1.3923 | 1.8299 | 1.5971 | 1.6078 |
| Min | .2263 | .1698 | .1492 | .1219 | .2896 | .3206 | .2949 |
| Avg | .5352 | .5410 | .4826 | .4496 | .8043 | .779 | .7343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 401 / 33 KV INCOMMER I BALHANE

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9231 | 1.0974 | 1.0517 | 1.0174 | 1.2631 | 1.5746 | 1.5415 |
| 2 | .9231 | 1.086 | 1.0517 | .8848 | 1.2631 | 1.5203 | 1.5415 |
| 3 | .9717 | 1.0745 | .9991 | .7956 | 1.3117 | 1.5203 | 1.5415 |
| 4 | 1.0202 | 1.1283 | .9991 | 1.0322 | 1.3117 | 1.5746 | 1.5947 |
| 5 | 1.2631 | 1.3969 | 1.2094 | 1.094 | 1.6032 | 1.7918 | 1.9342 |
| 6 | 1.7004 | 1.9879 | 1.6301 | 1.5238 | 1.8947 | 2.4434 | 2.3594 |
| 7 | 2.1376 | 2.2325 | 2.4434 | 2.2377 | 2.1376 | 2.7149 | 2.6612 |
| 8 | 1.166 | 5.2058 | 1.3289 | 1.278 | 1.1174 | 1.2449 | 1.2894 |
| 9 | | .9054 | .9568 | .9231 | .9054 | .8488 | .8505 |
| 10 | 2.6063 | 2.1285 | 1.6278 | 1.6518 | 1.8461 | 1.6461 | .9156 |
| 11 | 2.7149 | 2.6886 | 2.536 | 2.1862 | 2.0885 | 2.1399 | 1.8399 |
| 12 | 2.7149 | 2.5789 | 2.3102 | 2.1862 | 2.0165 | 1.9753 | |
| 13 | 2.6863 | 2.2325 | 2.0348 | 1.8947 | 1.9433 | 2.0302 | 1.8821 |
| 14 | 2.364 | 2.0953 | 2.0348 | 1.749 | 1.7976 | 1.8656 | 1.7901 |
| 15 | 2.4434 | 1.8604 | 1.7901 | 1.7004 | 1.7764 | 1.9204 | 1.7404 |
| 16 | 2.364 | 2.2028 | 1.8679 | 1.7976 | 1.8461 | 1.8656 | 1.6278 |
| 17 | 2.2085 | 2.1262 | 1.9839 | 1.7976 | 1.9753 | 1.9204 | 1.6278 |
| 18 | 1.0082 | .7362 | .6962 | .6316 | .8488 | .7362 | .407 |
| 19 | 1.0751 | 1.1568 | .7865 | 1.0688 | 1.1317 | 1.1043 | .7122 |
| 20 | .8488 | .9991 | .7865 | 1.0202 | 1.0185 | 1.0517 | .763 |
| 21 | .8488 | .8413 | .8453 | .8745 | .8488 | .8939 | .8648 |
| 22 | 1.1946 | 1.2094 | .8356 | 1.2631 | 1.7918 | 1.773 | .9665 |
| 23 | 1.1946 | 1.2094 | .9448 | 1.3603 | 1.6832 | 1.7541 | 1.17 |
| 24 | .9231 | 1.0974 | 1.1568 | 1.0174 | 1.3117 | 1.6461 | 1.6478 |
| Max | 2.7149 | 5.2058 | 2.536 | 2.2377 | 2.1376 | 2.7149 | 2.6612 |
| Min | .8488 | .7362 | .6962 | .6316 | .8488 | .7362 | .407 |
| Avg | 1.6218 | 1.7199 | 1.4128 | 1.3744 | 1.5305 | 1.6482 | 1.4465 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 402 / 33 KV INCOMMER II BALHANE

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7373 | .7362 | .8505 | .8453 | .9831 | 1.3432 | 1.2357 |
| 2 | .6882 | .7362 | .7973 | .7459 | .9831 | 1.3432 | 1.182 |
| 3 | .7373 | .7362 | .8505 | .7865 | .9831 | 1.3969 | 1.182 |
| 4 | .7865 | .7888 | .8505 | .8648 | 1.0322 | 1.3969 | 1.2357 |
| 5 | .8848 | .9991 | 1.0631 | .8951 | 1.278 | 1.6655 | 1.4506 |
| 6 | 1.1797 | 1.3672 | 1.2757 | 1.2431 | 1.5238 | 2.3102 | 1.9879 |
| 7 | 1.6221 | 1.5775 | 1.773 | 1.6409 | 2.0645 | 2.4714 | 2.5789 |
| 8 | .7865 | .8413 | .8059 | .6962 | .7865 | 2.0416 | .9134 |
| 9 | | .5784 | .6984 | .7865 | .4835 | .591 | .7522 |
| 10 | 2.6818 | 1.773 | 1.4586 | 1.5729 | 1.182 | .8059 | .6104 |
| 11 | 3.3128 | 2.6006 | 2.4926 | 2.5263 | 1.4506 | 1.2894 | .7122 |
| 12 | 3.1024 | 2.8475 | 2.2377 | 2.2119 | 1.5581 | 1.3432 | |
| 13 | 3.155 | 2.4177 | 1.9393 | 1.8187 | 1.2357 | 1.2357 | 1.1191 |
| 14 | .9362 | 2.2028 | 1.9113 | 1.7204 | 1.182 | 1.0208 | 1.0682 |
| 15 | 2.3926 | 2.0416 | 1.8399 | 1.6221 | 1.182 | .8596 | .8951 |
| 16 | 2.4714 | 2.2611 | | .9831 | 1.182 | .9134 | .8453 |
| 17 | 2.2611 | 1.9879 | 1.933 | 1.7204 | 1.1283 | .9134 | .8648 |
| 18 | .631 | .3721 | .4372 | .4424 | .5373 | .4835 | .5087 |
| 19 | .7362 | .7973 | .5087 | .7865 | .8596 | .8059 | .5596 |
| 20 | .6241 | .7442 | .547 | .7373 | .8059 | .8596 | .547 |
| 21 | .631 | .7442 | .5967 | .8848 | .6447 | .6984 | .547 |
| 22 | .8939 | .9671 | .7373 | 1.0322 | 1.5043 | 1.4506 | 1.0174 |
| 23 | .8413 | .9134 | .7956 | 1.1305 | 1.5043 | 1.5043 | 1.3226 |
| 24 | .7865 | .7362 | .8596 | .8648 | .9831 | 1.3969 | 1.2894 |
| Max | 3.3128 | 2.8475 | 2.4926 | 2.5263 | 2.0645 | 2.4714 | 2.5789 |
| Min | .6241 | .3721 | .4372 | .4424 | .4835 | .4835 | .5087 |
| Avg | 1.4296 | 1.3237 | 1.1852 | 1.1899 | 1.1274 | 1.2559 | 1.0620 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 201 / 11 KV PINJARZADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8916 | .6706 | .9145 | .9602 | .7716 | 1.0288 | .8916 |
| 7 | | | | | 1.2193 | 1.1431 | 1.5432 |
| 8 | | | | | 1.3717 | 1.5432 | 1.6118 |
| 9 | | | | | 1.3717 | 1.2193 | 1.4403 |
| 11 | 1.2803 | 1.4632 | 1.7147 | 1.3717 | | | |
| 12 | 1.5242 | 1.4632 | 1.4575 | 1.448 | | | |
| 13 | 1.3717 | | 1.3717 | 1.3717 | | | |
| 14 | 1.3717 | 1.3717 | 1.286 | 1.3717 | | | |
| 15 | 1.3717 | | 1.0974 | 1.3717 | | | |
| 16 | 1.1279 | 1.2803 | 1.2689 | 1.3717 | | | |
| 18 | | | | | 1.5432 | 1.5089 | 1.5089 |
| 19 | .8535 | 1.2193 | 1.3717 | 1.286 | 1.4575 | 1.5432 | 1.3032 |
| 20 | .823 | 1.0669 | 1.286 | 1.2003 | 1.3717 | 1.4403 | 1.2346 |
| 21 | .8535 | 1.0669 | 1.166 | 1.1145 | 1.286 | 1.2689 | 1.2003 |
| 22 | .823 | .9755 | 1.0631 | 1.1145 | 1.2003 | .823 | 1.166 |
| 23 | .7926 | .9907 | 1.0288 | .8573 | 1.1145 | .9259 | 1.0974 |
| 24 | 1.0288 | .6859 | .9755 | 1.0288 | .7716 | 1.0288 | .9259 |
| Max | 1.5242 | 1.4632 | 1.7147 | 1.448 | 1.5432 | 1.5432 | 1.6118 |
| Min | .7926 | .6706 | .9145 | .8573 | .7716 | .823 | .8916 |
| Avg | 1.0857 | 1.1140 | 1.2309 | 1.2206 | 1.2254 | 1.2249 | 1.2657 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 202 / 11 KV MALANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5432 | 1.2955 | 1.5242 | 1.7147 | .1372 | .1372 | .12 |
| 2 | 1.3717 | 1.2955 | 1.5242 | 1.7147 | .1372 | .1372 | .12 |
| 3 | 1.3717 | 1.2955 | 1.5242 | 1.7147 | .1372 | .1372 | .12 |
| 4 | 1.5775 | 1.2955 | 1.5242 | 1.7147 | .1372 | .1372 | .1372 |
| 5 | 1.7147 | 1.3717 | 1.5242 | 1.749 | .1372 | .1543 | .1543 |
| 6 | 2.0576 | 1.5242 | 1.6766 | 1.8004 | .1543 | .1715 | .1715 |
| 7 | 2.4006 | 2.1338 | 2.1338 | 2.4006 | | | |
| 8 | 2.2291 | 2.21 | 2.2862 | 2.3148 | | | |
| 9 | | | | | 1.3717 | 1.5242 | 1.8861 |
| 10 | | | | | 2.7435 | 3.0007 | 3.0864 |
| 11 | | | | | 2.8197 | 2.8292 | 3.0864 |
| 12 | | | | | 2.2862 | 3.0007 | 3.0864 |
| 13 | | | | | 2.8959 | 2.7435 | 3.0864 |
| 14 | | | | | 2.7435 | 2.7435 | 2.915 |
| 15 | | | | | 2.7435 | 2.572 | 2.8292 |
| 16 | | | | | 2.7435 | 2.7435 | 2.572 |
| 19 | .1219 | .1219 | .1372 | .1372 | .1372 | .1543 | .1715 |
| 20 | .1219 | .1219 | .1372 | .1543 | .1715 | .1715 | .1543 |
| 21 | .1219 | .1219 | .12 | .1543 | .1715 | .1715 | .1543 |
| 22 | .1219 | .1219 | .12 | .1372 | .1715 | .1543 | .0686 |
| 23 | 1.3717 | 1.6766 | 1.8861 | .1372 | .1543 | .1543 | .1372 |
| 24 | 3.2217 | 1.3717 | 1.6766 | 1.8004 | .1372 | .1372 | .1543 |
| Max | 3.2217 | 2.21 | 2.2862 | 2.4006 | 2.8959 | 3.0007 | 3.0864 |
| Min | .1219 | .1219 | .12 | .1372 | .1372 | .1372 | .0686 |
| Avg | 1.3819 | 1.1398 | 1.2711 | 1.2603 | 1.1066 | 1.1488 | 1.2106 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 203 / 11 KVDAHIWEL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | .061 | .061 | .0514 | 1.2003 | 1.2003 | 1.2003 |
| 2 | .0514 | .061 | .061 | .0514 | 1.2003 | 1.2003 | 1.2689 |
| 3 | .0514 | .061 | .061 | .0514 | 1.2003 | 1.2003 | 1.406 |
| 4 | .0514 | .061 | .061 | .0514 | 1.2003 | | 1.4403 |
| 5 | .0514 | .061 | .061 | .0686 | 1.2003 | 1.2003 | 1.5432 |
| 6 | .0686 | .061 | .061 | .0686 | 1.5432 | 1.5432 | 1.5432 |
| 7 | | | | | 1.9814 | 1.9814 | 2.4691 |
| 8 | | | | | 1.9052 | 1.9052 | 2.2634 |
| 9 | 1.5242 | 1.5242 | 1.768 | | | | |
| 10 | 1.829 | 2.5911 | 2.7435 | | | | |
| 11 | 2.4387 | 2.652 | 2.6749 | 1.9814 | | | |
| 12 | 2.4387 | 2.4387 | 2.4348 | 2.4387 | | | |
| 13 | 2.1643 | 2.2558 | 2.1605 | 2.21 | | | |
| 14 | 1.9204 | 2.4006 | 2.0576 | 1.9814 | | | |
| 15 | 1.829 | | 2.0233 | 1.9814 | | | |
| 16 | 1.829 | 1.768 | 2.2977 | 2.21 | | | |
| 19 | .061 | .061 | .0686 | .0514 | .0514 | .0686 | .0686 |
| 20 | .061 | .061 | .0686 | .0686 | .0514 | .0686 | .0686 |
| 21 | .061 | .061 | .0686 | .0514 | .0514 | .0514 | .0686 |
| 22 | .061 | .061 | .0686 | .0514 | .0514 | .0514 | .0686 |
| 23 | .061 | .061 | .0686 | 1.2003 | 1.2003 | 1.3032 | 1.166 |
| 24 | 3.1369 | .061 | .061 | .0686 | 1.2003 | 1.2003 | |
| Max | 3.1369 | 2.652 | 2.7435 | 2.4387 | 1.9814 | 1.9814 | 2.4691 |
| Min | .0514 | .061 | .061 | .0514 | .0514 | .0514 | .0686 |
| Avg | .9870 | .8612 | .9465 | .8132 | 1.0027 | .9980 | 1.1211 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 204 / 11 KV DAHIWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .4801 | .4801 | .4801 | .5144 | .5144 | .4801 |
| 2 | .3601 | .4801 | .4801 | .4801 | .5144 | .5144 | .4801 |
| 3 | .3772 | .4801 | .4801 | .5144 | .5144 | .5144 | .5144 |
| 4 | .5144 | .583 | .4801 | .5487 | .6001 | .5144 | .823 |
| 5 | .8402 | .6859 | .5144 | .823 | .6859 | .6859 | .8916 |
| 6 | 1.0288 | .583 | .9259 | .9774 | 1.0288 | .8916 | 1.0631 |
| 7 | 1.166 | 1.286 | 1.3203 | 1.3203 | 1.1431 | 1.0669 | 1.286 |
| 8 | .8916 | 1.0631 | 1.1145 | 1.2346 | .9145 | 1.0288 | 1.1317 |
| 9 | | .8573 | .8916 | | .7621 | .6097 | .8745 |
| 10 | | .7888 | .7202 | | .6097 | .6173 | .7373 |
| 11 | .5487 | .7202 | .703 | .7621 | .5335 | .703 | .6173 |
| 12 | .8059 | .6173 | .5487 | .6859 | .5335 | .6344 | .4801 |
| 13 | .7545 | .6173 | .5487 | .6097 | .5335 | .583 | .5487 |
| 14 | .7202 | .6173 | .583 | .5335 | .5335 | .583 | .5487 |
| 15 | .7716 | | .6173 | .5792 | .5792 | .5487 | .6173 |
| 16 | .6859 | .6173 | .6859 | .5792 | .5335 | .5487 | .6344 |
| 17 | .9259 | .6859 | .6859 | .6859 | .7716 | .6859 | .6859 |
| 18 | .8059 | .7888 | .7888 | .6859 | .6859 | .8059 | .7545 |
| 19 | .9774 | .9945 | .9431 | .9431 | .8573 | .9945 | .8916 |
| 20 | .6859 | .7888 | .7202 | .8573 | .6859 | .7716 | |
| 21 | .6173 | .6859 | .6173 | .6859 | .6516 | .6516 | |
| 22 | .6173 | .6173 | .5487 | .6859 | .6001 | .6173 | |
| 23 | .6173 | .5487 | .4801 | .6001 | .5487 | .5487 | .4801 |
| 24 | .3772 | .4801 | .4801 | .4801 | .5144 | .5144 | .4801 |
| Max | 1.166 | 1.286 | 1.3203 | 1.3203 | 1.1431 | 1.0669 | 1.286 |
| Min | .3601 | .4801 | .4801 | .4801 | .5144 | .5144 | .4801 |
| Avg | .7030 | .6986 | .6816 | .7160 | .6604 | .6729 | .7153 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 205 / 11 KV MALANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2058 | .1715 | .2058 | .2229 | .1886 | .1543 |
| 2 | .1543 | .2058 | .1715 | .2058 | .2229 | .1886 | .1543 |
| 3 | .1543 | .2058 | .1715 | .1715 | .2229 | .1715 | .1543 |
| 4 | .1543 | .2058 | .1715 | .1715 | .2229 | .1715 | .1543 |
| 5 | .1715 | .2058 | .1715 | .1886 | .2229 | .1715 | .1715 |
| 6 | .1715 | .2401 | .2401 | .2058 | .2572 | .1543 | .1715 |
| 7 | .2058 | .2401 | .2401 | .2572 | .2439 | .1829 | .2058 |
| 8 | .1886 | .2401 | .2058 | .2572 | .2286 | .2058 | .1886 |
| 9 | .2401 | .2058 | .1715 | | .2134 | .1981 | .1886 |
| 10 | .2743 | .2058 | .2401 | | .1829 | .1886 | .2058 |
| 11 | .2401 | .2058 | .1715 | .2134 | .1372 | .1715 | .2058 |
| 12 | .2058 | .1715 | .1715 | .2286 | .1219 | .1715 | .1886 |
| 13 | .1372 | .2058 | .2058 | .2134 | .1524 | .1715 | .1715 |
| 14 | .1715 | .2058 | .2058 | .2286 | .1524 | .1543 | .1715 |
| 15 | .2058 | | .1886 | .2134 | .1372 | .1543 | .1886 |
| 16 | .2058 | .1715 | .1715 | .2286 | .1677 | .1715 | .2058 |
| 17 | .2058 | .2401 | .2743 | .2743 | .2401 | .2572 | .2401 |
| 18 | .2058 | .2058 | .2743 | .2572 | .2572 | .2401 | .2572 |
| 19 | .2058 | .2743 | .1715 | .2401 | .2058 | .2058 | .2058 |
| 20 | .2058 | .2401 | .1715 | .2743 | .2743 | .2058 | .1715 |
| 21 | .2401 | .2401 | .1715 | .2743 | .2572 | .1886 | .1715 |
| 22 | .2401 | .2058 | .1715 | .2743 | .2229 | .1543 | .1715 |
| 23 | .2058 | .2058 | .1715 | .2401 | .2229 | .1543 | .1543 |
| 24 | .1543 | .2058 | .1715 | .1715 | .2229 | .1886 | .1543 |
| Max | .2743 | .2743 | .2743 | .2743 | .2743 | .2572 | .2572 |
| Min | .1372 | .1715 | .1715 | .1715 | .1219 | .1543 | .1543 |
| Avg | .1958 | .2147 | .1936 | .2271 | .2089 | .1838 | .1836 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 206 / 11 KV GHODADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | | 1.2193 | 1.3717 | .1029 | .1029 | .0857 |
| 2 | 1.2003 | 1.2689 | 1.2193 | 1.4575 | .1029 | .1029 | .0857 |
| 3 | 1.3717 | 1.286 | 1.2193 | 1.5775 | .1029 | .1029 | .0857 |
| 4 | 1.4575 | 1.286 | 1.2193 | 1.6289 | .1029 | .1029 | .1029 |
| 5 | 1.6289 | 1.3717 | 1.448 | 1.7147 | .1029 | .1029 | .1029 |
| 6 | 1.7833 | 1.7147 | 1.6156 | 1.7147 | .1029 | .1029 | .1029 |
| 7 | 2.3663 | 2.4863 | 2.2862 | 2.5034 | | | |
| 8 | 2.1262 | 1.9814 | 2.0729 | 2.4348 | | | |
| 9 | | | | | 1.6766 | 1.5242 | 1.5089 |
| 10 | | | | | .0857 | 2.8121 | 2.572 |
| 11 | | | | | 1.9814 | 3.155 | 2.572 |
| 12 | | | | | 2.5911 | 2.8807 | 2.6063 |
| 13 | | | | | 3.0007 | 2.5377 | 2.332 |
| 14 | | | | | 2.5911 | 2.2634 | 2.1262 |
| 15 | | | | | 2.4387 | 2.1605 | 2.0919 |
| 16 | | | | | 2.3624 | 2.2634 | 2.2291 |
| 19 | .0914 | .0762 | .1029 | .1029 | .1029 | .0857 | .1029 |
| 20 | .0914 | .0914 | .1029 | .1029 | .1029 | .0857 | .1029 |
| 21 | .0914 | .0762 | .1029 | .1029 | .1029 | .1029 | .1029 |
| 22 | .0762 | .061 | .1029 | .1029 | .1029 | .0857 | .0686 |
| 23 | 1.1431 | 1.2193 | 1.3717 | .1029 | .1029 | .0686 | .0686 |
| 24 | 2.4587 | 1.1584 | 1.2193 | 1.3717 | .1029 | .1029 | .0686 |
| Max | 2.4587 | 2.4863 | 2.2862 | 2.5034 | 3.0007 | 3.155 | 2.6063 |
| Min | .0762 | .061 | .1029 | .1029 | .0857 | .0686 | .0686 |
| Avg | 1.2205 | 1.0829 | 1.0930 | 1.1635 | .8981 | 1.0373 | .9559 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 207 / 11 KV JAMBHORE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0288 | 1.0669 | | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| 2 | 1.0288 | | | | | | |
| 7 | | | | | 1.5242 | 1.5242 | 1.8861 |
| 8 | | | | | 1.829 | 1.829 | 2.0576 |
| 9 | | | | | 1.829 | 1.5242 | 1.7147 |
| 11 | 2.1338 | 2.1338 | 2.2291 | 1.9052 | | | |
| 12 | 1.9814 | 1.829 | 2.2291 | 1.9814 | | | |
| 13 | 1.829 | 1.9052 | 2.2291 | 1.9052 | | | |
| 14 | 1.829 | 1.6766 | 2.1434 | 1.7528 | | | |
| 15 | 1.829 | | 1.8004 | 1.829 | | | |
| 16 | 1.6766 | 1.6766 | 2.0576 | 1.6766 | | | |
| 18 | | | | | 1.9719 | 2.2291 | 1.9719 |
| 19 | 1.5242 | 1.829 | 2.0576 | 1.8861 | 1.8861 | 2.0576 | 1.5432 |
| 20 | 1.2193 | 1.5242 | 1.8861 | 1.7147 | 1.5432 | 1.8861 | 1.2003 |
| 21 | 1.1431 | 1.5242 | 1.5432 | 1.5432 | 1.3717 | 1.5432 | 1.1145 |
| 22 | 1.0669 | .7621 | 1.4575 | 1.5432 | 1.286 | 1.5432 | .9431 |
| 23 | 1.0669 | .9145 | 1.3717 | 1.3717 | 1.2003 | 1.286 | .8573 |
| 24 | 1.2003 | 1.0669 | .9145 | 1.286 | 1.2003 | 1.2003 | 1.2346 |
| Max | 2.1338 | 2.1338 | 2.2291 | 1.9814 | 1.9719 | 2.2291 | 2.0576 |
| Min | 1.0288 | .7621 | .9145 | 1.2003 | 1.2003 | 1.2003 | .8573 |
| Avg | 1.4684 | 1.4924 | 1.8266 | 1.6612 | 1.5311 | 1.6203 | 1.4294 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 301 / 33 KV DAHIWEL I/C - I

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 23 | | | 10.2881 | 4.784 | 3.4465 |
| 24 | 8.6934 | 8.8477 | 9.2593 | .0051 | |
| Max | 8.6934 | 8.8477 | 10.2881 | 4.784 | 3.4465 |
| Min | 8.6934 | 8.8477 | 9.2593 | .0051 | 3.4465 |
| Avg | 8.6934 | 8.8477 | 9.7737 | 2.3946 | 3.4465 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 302 / 33 KV DAHIWEL I/C -II

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | 8.0761 | | | | | |
| 23 | | | 8.8477 | | 8.5391 | 8.4362 |
| 24 | 8.0761 | 7.8704 | 8.7449 | .0103 | .0103 | |
| Max | 8.0761 | 7.8704 | 8.8477 | .0103 | 8.5391 | 8.4362 |
| Min | 8.0761 | 7.8704 | 8.7449 | .0103 | .0103 | 8.4362 |
| Avg | 8.0761 | 7.8704 | 8.7963 | .0103 | 4.2747 | 8.4362 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 201 / 11 KV ROSGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | 3.9323 | 4.1781 | 3.6046 |
| 2 | | | | | 3.9323 | 3.6866 | 3.8504 |
| 3 | | | | | 3.9323 | 3.6046 | 4.0143 |
| 4 | | | | | 4.0143 | 3.6046 | 4.0962 |
| 5 | | | | | 4.0962 | 3.7685 | 4.342 |
| 6 | | | | | 4.0962 | 3.8504 | 4.0962 |
| 7 | 5.2431 | 5.407 | | 5.2431 | | | |
| 8 | 6.4929 | 6.1443 | 5.8166 | 6.2262 | | | |
| 9 | 6.1271 | 5.8166 | 4.9973 | 5.9804 | | | |
| 10 | 5.2431 | 5.325 | 5.325 | | | | |
| 11 | 5.2431 | 4.7516 | 5.0793 | 4.9973 | | | |
| 14 | | | | | 4.9973 | 4.8335 | 3.5227 |
| 15 | | | | | 5.1612 | 5.5708 | 5.9804 |
| 16 | | | | | 5.407 | 5.7347 | 5.5708 |
| 17 | | | | | 5.325 | 5.1612 | 5.1612 |
| 18 | | | | | 5.0793 | 4.7516 | 4.5058 |
| 20 | 3.9323 | 4.5058 | 4.26 | 4.1781 | | | |
| 21 | 4.0143 | 4.26 | 3.3589 | 4.26 | | | |
| 22 | 4.0962 | 4.0962 | 4.4239 | 4.0962 | | | |
| 23 | 4.0143 | 3.9323 | 4.342 | 4.0143 | | | |
| 24 | | 3.9323 | 3.8504 | 4.1781 | 4.0143 | | |
| Max | 6.4929 | 6.1443 | 5.8166 | 6.2262 | 5.407 | 5.7347 | 5.9804 |
| Min | 3.9323 | 3.9323 | 3.3589 | 4.0143 | 3.9323 | 3.6046 | 3.5227 |
| Avg | 4.9340 | 4.8171 | 4.6059 | 4.7971 | 4.4990 | 4.4313 | 4.4313 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 202 / 11 KV NIJAMPUR GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0974 | .9145 | .9145 | .9145 | .9145 | .9145 | .9145 |
| 2 | 1.0059 | .7316 | .7316 | .823 | .9145 | .9145 | .823 |
| 3 | .9145 | .823 | 1.0059 | 1.0059 | 1.1888 | 1.2803 | 1.0059 |
| 4 | 1.5546 | 1.0974 | 1.1888 | 1.2803 | 1.4632 | 1.6461 | 1.1888 |
| 5 | 2.1948 | 1.5546 | 1.5546 | 1.5546 | 1.9204 | 2.1033 | 1.4632 |
| 6 | 2.5606 | 2.4691 | 2.5606 | 2.3777 | 2.2862 | 2.3777 | 2.3777 |
| 7 | 2.3777 | 2.2862 | 2.4691 | 2.3777 | 2.1948 | 2.2862 | 2.1948 |
| 8 | 2.1033 | 2.0119 | 2.0119 | 2.0119 | 1.829 | 1.9204 | 2.0119 |
| 9 | 1.829 | 1.829 | 1.829 | 1.9204 | 1.6461 | 1.6461 | 1.7375 |
| 10 | 1.6461 | 1.6461 | 1.4632 | 1.6461 | 1.5546 | 1.4632 | 1.5546 |
| 11 | 1.6461 | 1.6461 | 1.6461 | 1.4632 | 1.5546 | 1.4632 | 1.4632 |
| 12 | 1.5546 | | 1.5546 | 1.4632 | 1.4632 | 1.2803 | 1.4632 |
| 13 | 1.4632 | | 1.3717 | 1.3717 | 1.4632 | 1.2803 | 1.2803 |
| 14 | 1.4632 | 1.6461 | 1.2803 | 1.2803 | 1.3717 | 1.2803 | 1.3717 |
| 15 | 1.5546 | 1.6461 | 1.2803 | 1.2803 | 1.4632 | 1.2803 | 1.3717 |
| 16 | 1.6461 | 1.5546 | 1.2803 | 1.3717 | 1.4632 | 1.2803 | 1.3717 |
| 17 | 1.9204 | 1.4632 | 1.2803 | 1.3717 | 1.4632 | 1.4632 | 1.4632 |
| 18 | 2.1033 | 1.5546 | 1.6461 | 1.5546 | 1.6461 | 1.6461 | 1.5546 |
| 19 | 2.3777 | 2.2862 | 2.1948 | 1.9204 | 1.829 | 2.0119 | 2.0119 |
| 20 | 1.9204 | 2.1948 | 1.829 | 1.9204 | 2.0119 | 2.0119 | 2.1033 |
| 21 | 1.6461 | 1.829 | 1.5546 | 1.5546 | 1.6461 | 1.7375 | 1.5546 |
| 22 | 1.2803 | 1.4632 | 1.2803 | 1.2803 | 1.2803 | 1.4632 | 1.2803 |
| 23 | 1.0974 | 1.1888 | 1.1888 | 1.0974 | 1.0974 | 1.1888 | 1.0974 |
| 24 | 1.0974 | 1.0059 | 1.0974 | 1.0974 | 1.0059 | 1.0059 | 1.0974 |
| Max | 2.5606 | 2.4691 | 2.5606 | 2.3777 | 2.2862 | 2.3777 | 2.3777 |
| Min | .9145 | .7316 | .7316 | .823 | .9145 | .9145 | .823 |
| Avg | 1.6689 | 1.5837 | 1.5089 | 1.4975 | 1.5280 | 1.5394 | 1.4899 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 203 / 11 KV VASKHEDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.13 | 2.2119 | 1.9662 | 1.8842 | | | |
| 2 | 2.5396 | 2.2939 | 2.0481 | 2.0481 | | | |
| 3 | 2.6216 | 2.3758 | 2.2119 | 1.9662 | | | |
| 4 | 2.4577 | 2.2119 | 2.2939 | 2.13 | | | |
| 5 | 2.2119 | 2.0481 | 2.3758 | 2.2119 | | | |
| 6 | 2.0481 | 2.13 | 2.2939 | 2.13 | | | |
| 7 | | | | | 3.195 | 2.6216 | 3.195 |
| 8 | | | | | 3.4408 | 3.6046 | 3.7685 |
| 9 | | | | | 3.6866 | 3.7685 | 3.6046 |
| 10 | | | | | 3.5227 | 3.6046 | 3.5227 |
| 11 | | | | | 3.5227 | 3.6046 | 3.4408 |
| 14 | 2.4577 | 3.9323 | 3.1131 | | | | |
| 15 | 2.9492 | 3.4408 | 3.0312 | 3.4408 | | | |
| 16 | 3.7685 | 3.9323 | 3.6046 | 3.3589 | | | |
| 17 | 3.3589 | 3.8504 | 3.4408 | 3.2769 | | | |
| 18 | 3.0312 | 3.2769 | 2.9492 | 2.8673 | | | |
| 19 | | | | | 3.0312 | 2.7854 | 2.8673 |
| 20 | | | | | 2.5396 | 2.7035 | 2.6216 |
| 21 | | | | | 2.3758 | 2.6216 | 2.4577 |
| 22 | | | | | 2.2119 | 2.5396 | 2.3758 |
| 23 | | | | | 2.13 | 2.4577 | 2.2119 |
| 24 | 2.2939 | | | | | 2.13 | 2.2939 |
| Max | 3.7685 | 3.9323 | 3.6046 | 3.4408 | 3.6866 | 3.7685 | 3.7685 |
| Min | 2.0481 | 2.0481 | 1.9662 | 1.8842 | 2.13 | 2.13 | 2.2119 |
| Avg | 2.6557 | 2.8822 | 2.6662 | 2.5314 | 2.9656 | 2.9492 | 2.9418 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 204 / 11 KV DUSANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | 1.8842 | 2.2119 | 2.3758 |
| 2 | | | | | 1.8023 | 2.13 | 2.4577 |
| 3 | | | | | 1.8023 | 1.9662 | 2.7035 |
| 4 | | | | | 2.0481 | 1.9662 | 3.0312 |
| 5 | | | | | 2.2119 | 2.13 | 3.195 |
| 6 | | | | | 2.2939 | 2.3758 | 3.1131 |
| 7 | | | | | 2.3758 | 2.4577 | 2.9492 |
| 10 | 2.3758 | 2.2939 | 2.6216 | 2.2939 | | | |
| 11 | 3.2769 | 3.1131 | 2.8673 | 2.9492 | | | |
| 12 | 3.2769 | | 2.9492 | 2.8673 | | | |
| 13 | 2.9492 | | 2.7035 | 2.6216 | | | |
| 14 | 2.9492 | 2.8673 | 2.5396 | 2.4577 | | | |
| 15 | 2.7854 | 3.0312 | 2.6216 | 2.4577 | | | |
| 16 | 2.7854 | 2.9492 | 2.4577 | 2.6216 | | | |
| 17 | 2.7035 | 2.7035 | 2.4577 | 2.5396 | | | |
| 18 | | 2.4577 | | | | | |
| 22 | | | | 1.8023 | 2.13 | 2.2119 | 1.8023 |
| 23 | | | | 1.8842 | | 2.2939 | 1.8842 |
| 24 | 3.3065 | | | | 1.8842 | 2.2119 | 2.13 |
| Max | 3.3065 | 3.1131 | 2.9492 | 2.9492 | 2.3758 | 2.4577 | 3.195 |
| Min | 2.3758 | 2.2939 | 2.4577 | 1.8023 | 1.8023 | 1.9662 | 1.8023 |
| Avg | 2.9343 | 2.7737 | 2.6523 | 2.4495 | 2.0481 | 2.1956 | 2.5642 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 205 / 11 KV DUSANE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3658 | .3658 | .3658 | .3658 | .2743 | .2743 | .3658 |
| 2 | .3658 | .3658 | .3658 | .3658 | .2743 | .2743 | .3658 |
| 3 | .4572 | .4572 | .4572 | .4572 | .4572 | .3658 | .3658 |
| 4 | .6401 | .6401 | .6401 | .6401 | .6401 | .4572 | .4572 |
| 5 | .823 | .823 | .9145 | .823 | .7316 | .7316 | .6401 |
| 6 | .9145 | .9145 | .823 | .7316 | .7373 | .823 | .823 |
| 7 | .823 | | .823 | .7316 | .7316 | .9145 | .8192 |
| 8 | .7316 | .5487 | .6401 | .5487 | | | |
| 9 | .4572 | .4572 | .4572 | .4572 | | | |
| 10 | .4572 | .4572 | .3658 | .3658 | | | |
| 11 | .3658 | .3658 | .3658 | .3658 | | | |
| 12 | .3658 | | .3658 | .3658 | .4572 | .3658 | .4572 |
| 13 | .4572 | | .2743 | .2743 | .3658 | .3658 | .3658 |
| 14 | .3658 | .3658 | .3658 | .2743 | .3658 | .3658 | .3658 |
| 15 | | | .2743 | .3658 | .3658 | .3658 | .3658 |
| 16 | | | .2743 | .3658 | .4572 | .3658 | .3658 |
| 17 | | | .2743 | .3658 | .4572 | .3277 | .3658 |
| 18 | .7316 | | .4572 | .4572 | .4572 | .5487 | .4572 |
| 19 | .7316 | | .5487 | .6401 | .5487 | .6401 | .6401 |
| 20 | .5487 | .5487 | .5487 | .5487 | .5487 | .5487 | .5487 |
| 21 | .7316 | .5487 | .4572 | .5487 | .4572 | .5487 | .4572 |
| 22 | .4572 | .4572 | .5487 | .4572 | .4572 | .4572 | .4572 |
| 23 | .3658 | .4572 | .4572 | .4572 | .3658 | .3658 | .3658 |
| 24 | .3658 | .3658 | .3658 | .3658 | .3658 | .3658 | .3658 |
| Max | .9145 | .9145 | .9145 | .823 | .7373 | .9145 | .823 |
| Min | .3658 | .3658 | .2743 | .2743 | .2743 | .2743 | .3658 |
| Avg | .5487 | .5087 | .4763 | .4725 | .4758 | .4736 | .4708 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 206 / 11 KV KHUDANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.7854 | 2.6216 | 3.0312 | 2.5396 | .4096 | .4096 | .3277 |
| 2 | 2.7035 | 2.5396 | 2.5396 | 2.6216 | .3277 | .3277 | .4096 |
| 3 | 2.6216 | 2.7035 | 2.8673 | 2.7035 | .3277 | .3277 | .4915 |
| 4 | 2.5396 | 2.9492 | 2.7854 | 2.9492 | .3277 | .3277 | .4915 |
| 5 | 2.4577 | 2.7854 | 2.9492 | 3.0312 | .4096 | .4096 | .5735 |
| 6 | 2.4577 | 2.4577 | 2.7854 | 2.6216 | .4096 | .4915 | .5735 |
| 7 | 2.3758 | 2.2939 | 2.9492 | 2.9492 | .4096 | .4915 | .4915 |
| 8 | | | | | .3277 | .4915 | .4915 |
| 9 | | | | | .3277 | .4915 | .4096 |
| 10 | | | | | 2.4577 | 2.7035 | 2.13 |
| 11 | | | | | 3.6046 | 3.9323 | 3.8504 |
| 12 | | | | | 3.6866 | 3.7685 | 3.7685 |
| 13 | | | | | 3.6046 | 3.3589 | 3.5227 |
| 14 | | | | | 3.6866 | 3.1131 | 3.4408 |
| 15 | .4096 | .4915 | .4915 | .4096 | 3.6046 | 3.195 | 3.4408 |
| 16 | .5735 | .5735 | .4915 | .4915 | 3.5227 | 3.2769 | 3.5227 |
| 17 | .4096 | .5735 | .5735 | .4915 | 3.4408 | 3.195 | 2.8673 |
| 18 | .5735 | .4915 | .5735 | .5735 | .4096 | .2458 | .3277 |
| 19 | .4915 | .5735 | .5735 | .5735 | .4096 | .4096 | .4096 |
| 20 | .4915 | .4915 | .4915 | .4915 | .4096 | .3277 | .4915 |
| 21 | .4915 | .4915 | .4915 | .4915 | .4096 | .3277 | .4915 |
| 22 | 2.7035 | 3.2769 | 2.7854 | .4096 | .4096 | .4096 | .4915 |
| 23 | 2.8673 | 3.3589 | 2.9492 | .4096 | .4096 | .4096 | .4915 |
| 24 | 2.8673 | 2.8673 | 3.1131 | 2.7854 | .4096 | .4096 | .3277 |
| Max | 2.8673 | 3.3589 | 3.1131 | 3.0312 | 3.6866 | 3.9323 | 3.8504 |
| Min | .4096 | .4915 | .4915 | .4096 | .3277 | .2458 | .3277 |
| Avg | 1.7541 | 1.8553 | 1.9083 | 1.5614 | 1.4063 | 1.3688 | 1.4098 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 207 / 11 KV WASDARA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.13 | 2.13 | 1.9662 | 2.0481 | | | |
| 2 | 2.4577 | 2.2119 | 1.9662 | 2.2119 | | | |
| 3 | 2.6216 | 2.2939 | 2.0481 | 2.2939 | | | |
| 4 | 2.5396 | 2.13 | 2.13 | 2.3758 | | | |
| 5 | 2.2939 | 1.9662 | 2.2119 | 2.6216 | | | |
| 6 | 2.13 | 2.0481 | 2.2939 | 2.4577 | | | |
| 7 | | | | | 2.8673 | 2.6216 | 2.6216 |
| 8 | | | | | 3.2769 | 3.4408 | 3.1131 |
| 9 | | | | | 3.4408 | 3.5227 | 3.2769 |
| 10 | | | | | 3.4408 | 3.4408 | 3.2769 |
| 11 | | | | | 3.1131 | 3.195 | 3.0312 |
| 14 | 2.8673 | 3.3589 | 1.8842 | 3.3589 | | | |
| 15 | 3.3589 | 3.2769 | 3.5227 | 3.6046 | | | |
| 16 | 2.9492 | 3.2769 | 3.6046 | 3.3589 | | | |
| 17 | 2.9492 | 3.1131 | 3.5227 | 3.1131 | | | |
| 18 | 2.8673 | 2.9492 | 2.9492 | 2.7854 | | | |
| 19 | | | | | 2.8673 | 3.0312 | 2.7854 |
| 20 | | | | | 2.3758 | 2.7035 | 2.5396 |
| 21 | | | | | 2.4577 | 2.6216 | 2.3758 |
| 22 | | | | | 2.3758 | 2.5396 | 2.2939 |
| 23 | | | | | 2.2939 | 2.2939 | 2.2119 |
| 24 | 2.2939 | | | | | 2.2119 | 2.13 |
| Max | 3.3589 | 3.3589 | 3.6046 | 3.6046 | 3.4408 | 3.5227 | 3.2769 |
| Min | 2.13 | 1.9662 | 1.8842 | 2.0481 | 2.2939 | 2.2119 | 2.13 |
| Avg | 2.6216 | 2.6141 | 2.5545 | 2.7482 | 2.8509 | 2.8748 | 2.6960 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 208 / 11 KV FOFADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8842 | 1.9662 | 1.8842 | 1.8023 | | | |
| 2 | 2.0481 | 1.8842 | 2.0481 | 1.7204 | | | |
| 3 | 2.2939 | 2.0481 | 2.13 | 1.9662 | | | |
| 4 | 2.5396 | 2.3758 | 2.3758 | 2.2119 | | | |
| 5 | 2.2119 | 2.4577 | 2.2939 | 2.5396 | | | |
| 6 | 2.0481 | 2.13 | 2.2119 | 1.9662 | | | |
| 7 | 1.9662 | 1.8842 | 2.4577 | 2.4577 | | | |
| 10 | | | | | 2.6216 | 2.7035 | 2.0481 |
| 11 | | | | | 3.6046 | 3.4408 | 3.3589 |
| 12 | | | | | 3.3589 | 3.4408 | 3.2769 |
| 13 | | | | | 3.4408 | 3.0312 | 3.2769 |
| 14 | | | | | 3.6866 | 2.6216 | 2.9492 |
| 15 | | | | | 3.0312 | 2.7035 | 3.0312 |
| 16 | | | | | 3.0312 | 2.8673 | 2.7035 |
| 17 | | | | | 2.7035 | 2.4577 | 2.4577 |
| 22 | 1.9662 | 1.9662 | 1.6385 | | | | |
| 23 | 2.13 | 2.0481 | 1.8023 | | | | |
| 24 | 3.2217 | 2.0481 | 1.9662 | 1.8842 | | | |
| Max | 3.2217 | 2.4577 | 2.4577 | 2.5396 | 3.6866 | 3.4408 | 3.3589 |
| Min | 1.8842 | 1.8842 | 1.6385 | 1.7204 | 2.6216 | 2.4577 | 2.0481 |
| Avg | 2.2310 | 2.0809 | 2.0809 | 2.0686 | 3.1848 | 2.9083 | 2.8878 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 303 / 33 KV JAITANE I/C - III
(10 MV Feeder KV- 33 / OUTGOING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | 8.139 | 8.902 | 8.3934 | 7.8847 | 8.1104 | 8.902 | 8.6477 |
| 16 | 6.6129 | 7.1216 | 7.6303 | 6.1043 | 6.1043 | 7.1216 | 6.6129 |
| 24 | 5.8499 | 5.3412 | 5.3412 | 5.5956 | 5.3412 | 5.5956 | 5.8499 |
| Max | 8.139 | 8.902 | 8.3934 | 7.8847 | 8.1104 | 8.902 | 8.6477 |
| Min | 5.8499 | 5.3412 | 5.3412 | 5.5956 | 5.3412 | 5.5956 | 5.8499 |
| Avg | 6.8673 | 7.1216 | 7.1216 | 6.5282 | 6.5186 | 7.2064 | 7.0368 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 201 / 11 KV CHHADWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.3765 | 1.5384 | 1.6194 | 1.5384 | 1.5384 | 1.5546 |
| 2 | 1.5546 | 1.3765 | 1.6194 | 1.5384 | | 1.5384 | 1.4899 |
| 9 | 2.4531 | | | | 2.2119 | 2.4863 | 2.3868 |
| 10 | 2.4034 | | | | 2.5692 | 2.4863 | 2.4863 |
| 11 | 2.4531 | | | | 2.3205 | 2.4034 | 2.3205 |
| 12 | 2.1548 | | | | 1.9662 | 2.1879 | 2.0972 |
| 13 | | 2.5692 | 2.5692 | 2.4863 | | | |
| 14 | | 2.4531 | 2.4863 | 2.3205 | | | |
| 15 | | 2.3205 | 2.4034 | 2.0481 | | | |
| 16 | | 2.2939 | 2.2939 | 2.13 | | | |
| 19 | 1.6194 | 1.8842 | 1.8023 | 1.9662 | 1.9662 | 1.8351 | 1.5546 |
| 20 | 1.5384 | 1.8023 | 1.7204 | 1.8023 | 1.8023 | 1.8023 | 1.4575 |
| 21 | 1.4575 | 1.7204 | 1.6194 | 1.8023 | 1.6194 | 1.7695 | 1.4251 |
| 22 | 1.4575 | 1.5384 | 1.6194 | 1.6194 | 1.6194 | 1.6194 | 1.3603 |
| 23 | 1.4575 | 1.6194 | 1.6194 | 1.6194 | 1.6194 | 1.6194 | 1.2955 |
| 24 | 2.9673 | 1.3765 | 1.5384 | 1.6194 | 1.5384 | 1.5384 | 1.4575 |
| Max | 2.9673 | 2.5692 | 2.5692 | 2.4863 | 2.5692 | 2.4863 | 2.4863 |
| Min | 1.4575 | 1.3765 | 1.5384 | 1.5384 | 1.5384 | 1.5384 | 1.2955 |
| Avg | 1.9561 | 1.8609 | 1.9025 | 1.8810 | 1.8883 | 1.9021 | 1.7405 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 202 / 11 KV BRAMANWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.42 | 1.6194 | 2.13 | 2.2377 | 2.13 | 2.3205 | 1.9662 |
| 2 | 2.1628 | 1.6194 | 2.13 | 2.13 | 2.0481 | 2.2377 | 1.9662 |
| 9 | | 3.3532 | 3.6885 | 3.437 | | | |
| 10 | | 3.5208 | 3.5208 | 3.3532 | | | |
| 11 | | 3.1855 | 3.3532 | 2.3205 | | | |
| 12 | | 1.9662 | 2.8178 | 2.2119 | | | |
| 13 | 3.6885 | | | | 3.8561 | 3.6885 | 3.6885 |
| 14 | 3.5208 | | | | 3.3532 | 3.4873 | 3.2861 |
| 15 | 3.3532 | | | | 3.4873 | 3.0498 | 3.3532 |
| 16 | 3.1017 | | | | | 2.9172 | 3.0178 |
| 17 | 2.652 | | | | | 2.7349 | |
| 19 | | 2.9007 | 2.9835 | 3.0178 | | 2.3868 | 2.2775 |
| 20 | 1.9662 | 2.7349 | 2.652 | 2.9007 | 2.5692 | 2.3868 | 2.3205 |
| 21 | 1.5384 | 2.5692 | 2.3205 | 2.652 | 2.7035 | 2.3868 | 2.3205 |
| 22 | 1.6194 | 2.2377 | 2.3205 | 2.652 | | 2.3205 | 2.2283 |
| 23 | 1.6194 | 2.2119 | 2.2377 | 2.4863 | 2.4034 | 2.2542 | 2.1879 |
| 24 | 2.1506 | 1.6194 | 2.13 | 2.2377 | 2.2939 | 2.3205 | 2.2211 |
| Max | 3.6885 | 3.5208 | 3.6885 | 3.437 | 3.8561 | 3.6885 | 3.6885 |
| Min | 1.5384 | 1.6194 | 2.13 | 2.13 | 2.0481 | 2.2377 | 1.9662 |
| Avg | 2.4828 | 2.4615 | 2.6904 | 2.6364 | 2.7605 | 2.6532 | 2.5695 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 203 / 11 KV Titane

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2308 | 1.2146 | 1.166 | 1.2955 | 1.1984 | 1.2146 | 1.166 |
| 2 | 1.2308 | 1.2146 | 1.166 | 1.2146 | 1.1984 | 1.1336 | 1.166 |
| 9 | | 2.0481 | 1.9662 | 1.8842 | | | |
| 10 | | 2.0481 | 1.8842 | 1.8842 | | | |
| 11 | | 1.8842 | 1.7204 | 1.7204 | | | |
| 12 | | 1.5384 | 1.5384 | 1.4575 | | | |
| 13 | 2.1879 | | | | 1.9662 | 1.9006 | 2.0481 |
| 14 | 1.9662 | | | | 1.8023 | 1.7368 | 1.8679 |
| 15 | 1.8023 | | | | 1.6194 | 1.5546 | 1.704 |
| 16 | 1.7204 | | | | 1.6194 | .9717 | 1.4899 |
| 19 | 1.4575 | 1.7204 | 1.7204 | 1.7204 | 1.5384 | 1.587 | 1.4899 |
| 20 | 1.2955 | 1.6194 | 1.6194 | 1.4575 | 1.3765 | 1.5223 | 1.1984 |
| 21 | 1.2955 | 1.4575 | 1.4575 | 1.4575 | 1.3765 | 1.4575 | 1.1984 |
| 22 | 1.2955 | 1.3765 | 1.4575 | 1.4575 | 1.2955 | 1.2955 | 1.1984 |
| 23 | 1.2146 | 1.2955 | 1.3765 | 1.3765 | 1.2955 | 1.2955 | 1.1336 |
| 24 | 2.7978 | 1.2146 | 1.2146 | 1.2955 | 1.2955 | 1.2146 | 1.2308 |
| Max | 2.7978 | 2.0481 | 1.9662 | 1.8842 | 1.9662 | 1.9006 | 2.0481 |
| Min | 1.2146 | 1.2146 | 1.166 | 1.2146 | 1.1984 | .9717 | 1.1336 |
| Avg | 1.6246 | 1.5527 | 1.5239 | 1.5184 | 1.4652 | 1.4070 | 1.4076 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 204 / 11 KV BASAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7773 | .8421 | .7773 | .8421 | .8421 | .8421 | .8421 |
| 2 | .8421 | .8421 | .7773 | .8421 | .7773 | .8421 | .8421 |
| 9 | 1.6712 | | | | 1.5384 | 1.5384 | 1.6194 |
| 10 | 1.5546 | | | | 1.6194 | 1.4575 | 1.4575 |
| 11 | 1.5546 | | | | 1.2955 | 1.3765 | 1.4575 |
| 12 | 1.2146 | | | | 1.2955 | 1.2955 | 1.3603 |
| 13 | | 1.6194 | 1.4899 | 1.6194 | | | |
| 14 | | 1.4899 | 1.4575 | 1.3765 | | | |
| 15 | | 1.5546 | 1.2955 | 1.4575 | | | |
| 16 | | 1.3765 | 1.2955 | 1.3765 | | | |
| 19 | 1.2955 | 1.2146 | 1.1336 | 1.2146 | 1.2955 | 1.2308 | .9717 |
| 20 | .9069 | 1.166 | 1.0364 | .9717 | 1.0364 | 1.1336 | .8421 |
| 21 | .8421 | 1.1012 | .8421 | .9069 | .9717 | .9717 | .9069 |
| 22 | .8421 | .9069 | .8421 | .9069 | .9717 | .7773 | .8421 |
| 23 | .8421 | .9069 | .8421 | .8421 | .9069 | .9069 | .7125 |
| 24 | 2.0348 | .8421 | .8421 | .8421 | .8421 | .9069 | .8745 |
| Max | 2.0348 | 1.6194 | 1.4899 | 1.6194 | 1.6194 | 1.5384 | 1.6194 |
| Min | .7773 | .8421 | .7773 | .8421 | .7773 | .7773 | .7125 |
| Avg | 1.1982 | 1.1552 | 1.0526 | 1.0999 | 1.1160 | 1.1066 | 1.0607 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 205 / 11 KV CHHADWEL KORDE

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .3239 | .2915 | .2915 | .2915 | .2915 | .3239 |
| 2 | .3239 | .3239 | .2915 | .2915 | .2915 | .2591 | .3239 |
| 3 | .3887 | .3563 | .2915 | .3239 | .3239 | .3239 | .3887 |
| 4 | .4534 | .421 | .3239 | .4049 | .3887 | .3887 | .421 |
| 5 | | | .3239 | | | | |
| 6 | | | .3563 | | | | |
| 7 | | | .3887 | | | | |
| 8 | | | .3887 | | | | |
| 9 | .5506 | .4858 | | .5182 | .5182 | .5182 | .5506 |
| 10 | .583 | .421 | | .421 | .3239 | .3887 | .4858 |
| 11 | .3887 | .3887 | .3563 | .3563 | .3239 | .3239 | .4534 |
| 12 | .3239 | .3239 | .2429 | .2915 | .2591 | .2591 | .3239 |
| 13 | .2915 | .2591 | .2267 | .2915 | .2591 | .2591 | .2591 |
| 14 | .2591 | .2591 | .2267 | .2429 | .2591 | .2267 | .2267 |
| 15 | .2915 | .2915 | .2267 | .2915 | .3239 | .2267 | .2267 |
| 16 | .3563 | .2753 | .2429 | .2429 | .3239 | .2591 | .2591 |
| 17 | .421 | .3239 | .2915 | .1886 | .3239 | .2591 | .3239 |
| 18 | .421 | .3563 | .3401 | .3563 | .4049 | .3887 | .421 |
| 19 | .4858 | .4534 | .4858 | .4858 | .4534 | .5506 | .5182 |
| 20 | .4858 | .4534 | .4858 | .5182 | .421 | .5506 | .5506 |
| 21 | .4858 | .4534 | .4858 | .4858 | .421 | .4858 | .5182 |
| 22 | .4534 | .4049 | .4049 | .4534 | .3563 | .4858 | .4534 |
| 23 | .4049 | .3239 | .3239 | .4049 | .3239 | .4534 | .3563 |
| 24 | | .3239 | .2915 | .2915 | .3239 | .2915 | .3887 |
| Max | .583 | .4858 | .4858 | .5182 | .5182 | .5506 | .5506 |
| Min | .2591 | .2591 | .2267 | .1886 | .2591 | .2267 | .2267 |
| Avg | .4031 | .3611 | .3313 | .3576 | .3458 | .3595 | .3887 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 301 / 33 KV CHHADWEL I/C -I

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.987 |
| Max | 1.987 |
| Min | 1.987 |
| Avg | 1.987 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 302 / 33 KV BRAMHANWEL I/C - II

Feeder KV- 33 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAR-18 |
| HR | Load (MW) |
| 24 | *** |
| Max | 43.2174 |
| Min | 43.2174 |
| Avg | 43.2174 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 304 / 33 KV O/G SUZLON BLADE
FACTROY Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.2012 |
| Max | 5.2012 |
| Min | 5.2012 |
| Avg | 5.2012 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 401 / 33 KV CHHADWEL TO
SHIVAJINAGAR Feeder KV- 33 /
OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.3289 |
| Max | 1.3289 |
| Min | 1.3289 |
| Avg | 1.3289 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212] BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADWEL

Feeder No / Name : 403 / 33 KV CHHADWEL TO SUZLON
GEN Feeder KV- 33 / OUTGOING

| | |
|------|-----------|
| DATE | 01-MAR-18 |
| HR | Load (MW) |
| 24 | .763 |
| Max | .763 |
| Min | .763 |
| Avg | .763 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 201 / 11 KV CHAUPALE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0139 | 1.1317 | .8478 | .7587 | | 1.0374 | .845 |
| 2 | 1.0174 | 1.1317 | .8478 | .9326 | | 1.0751 | .9305 |
| 3 | 1.1022 | 1.1694 | .9431 | .9431 | | 1.1883 | .9378 |
| 4 | 1.1145 | 1.226 | | 1.1133 | | 1.2136 | 1.0277 |
| 5 | 1.2069 | 1.3203 | | 1.2003 | | 1.307 | 1.117 |
| 6 | 1.3017 | 1.4146 | | 1.4607 | | | |
| 7 | 1.5552 | 1.5089 | | 1.6271 | | | |
| 15 | | | | | 1.9805 | 1.3519 | 1.9071 |
| 16 | | | | | 2.2634 | 1.7804 | 2.0805 |
| 17 | 2.2405 | | 2.0302 | | 2.452 | 2.2068 | 1.9071 |
| 18 | 2.2405 | 1.6956 | 2.11 | | 2.3577 | 2.1994 | 1.8724 |
| 19 | 1.7737 | 1.5261 | 2.1195 | | 2.2405 | 2.0348 | 1.7337 |
| 20 | 1.5684 | 1.3565 | 1.7984 | | 1.8671 | 1.8757 | 1.647 |
| 21 | 1.4003 | 1.2717 | 1.6289 | | 1.6804 | 1.5398 | 1.5604 |
| 22 | 1.3491 | | | | | | |
| 23 | 1.226 | | | | | | |
| 24 | .7587 | 1.1317 | | | | .9054 | .6828 |
| Max | 2.2405 | 1.6956 | 2.1195 | 1.6271 | 2.452 | 2.2068 | 2.0805 |
| Min | .7587 | 1.1317 | .8478 | .7587 | 1.6804 | .9054 | .6828 |
| Avg | 1.3913 | 1.3237 | 1.5407 | 1.1480 | 2.1202 | 1.5166 | 1.4038 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 202 / 11 KV ROHOD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5053 | .362 | .281 | .4225 | | .4904 | .5121 |
| 2 | .5064 | .3658 | .4239 | .423 | | .5281 | .5138 |
| 3 | .6001 | | | .5121 | | .5281 | .5144 |
| 4 | .6035 | .4024 | .5087 | .5144 | | .5601 | .6008 |
| 5 | .6943 | .439 | .5935 | .6035 | | .7468 | .5995 |
| 6 | | | | | | .8316 | .7759 |
| 7 | | | | | | .8779 | .7759 |
| 8 | | | | | | | .6859 |
| 15 | 1.307 | | .5928 | | | | |
| 16 | 1.4937 | .5087 | .8478 | | | | |
| 17 | 1.307 | .1187 | .7716 | | 1.4937 | 1.1022 | 1.0517 |
| 18 | 1.1203 | | .7707 | | 1.4937 | 1.2717 | 1.2269 |
| 19 | .8402 | 1.0174 | 1.2003 | | 1.307 | 1.1133 | .964 |
| 20 | .6535 | | .9431 | | .9335 | .8573 | .7888 |
| 21 | .4854 | | .8535 | | .7468 | .6828 | .5784 |
| 22 | .4805 | | | | | .5928 | |
| 23 | .439 | | | | | .5935 | |
| 24 | | .3582 | | .4239 | | | .5075 |
| Max | 1.4937 | 1.0174 | 1.2003 | .6035 | 1.4937 | 1.2717 | 1.2269 |
| Min | .439 | .1187 | .281 | .4225 | .7468 | .4904 | .5075 |
| Avg | .7883 | .4465 | .7079 | .4832 | 1.1949 | .7698 | .7211 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 203 / 11 KV SHIRSOLE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.1172 | 1.6804 | 1.5261 | 1.4316 | | | |
| 2 | 1.9478 | 1.6278 | 1.5261 | 1.5226 | | | |
| 3 | 1.8757 | 1.6108 | | 1.5261 | | | |
| 4 | 1.9412 | 1.5089 | | 1.6271 | | | |
| 5 | 2.0553 | 1.5927 | | 1.7166 | | 1.3927 | 1.3763 |
| 6 | | | | | | 1.7804 | 1.9113 |
| 7 | | | | | | 2.713 | 2.7648 |
| 8 | | | | | | 2.915 | 2.8292 |
| 9 | | | | | | 2.3205 | 2.572 |
| 14 | 2.3739 | | 2.3712 | | | | |
| 15 | 2.713 | 3.2217 | 2.5434 | | | | |
| 16 | 2.3739 | | 2.8858 | | | | |
| 17 | | 2.8317 | 2.8355 | | | | |
| 18 | | 2.5434 | 2.7282 | | 3.1369 | 2.915 | 2.9473 |
| 19 | 2.5095 | | 2.6578 | | 2.7978 | 2.8355 | 2.6006 |
| 20 | 2.0576 | | | | 2.1195 | 2.4863 | 2.3405 |
| 21 | 1.8652 | | | | 1.989 | 2.1338 | 2.1672 |
| 22 | 1.8652 | | | | 1.8233 | 1.9478 | 2.0805 |
| 23 | 1.8004 | | | | 1.6575 | 1.8652 | 1.9938 |
| 24 | 2.1124 | 1.8671 | | | | | |
| Max | 2.713 | 3.2217 | 2.8858 | 1.7166 | 3.1369 | 2.915 | 2.9473 |
| Min | 1.8004 | 1.5089 | 1.5261 | 1.4316 | 1.6575 | 1.3927 | 1.3763 |
| Avg | 2.1149 | 2.0538 | 2.3843 | 1.5648 | 2.254 | 2.3005 | 2.3258 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 301 / 33 KV JAMKHEL I/C - I

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24 | 2.2685 | 4.5268 | 2.7161 | 1.5106 |
| Max | 2.2685 | 4.5268 | 2.7161 | 1.5106 |
| Min | 2.2685 | 4.5268 | 2.7161 | 1.5106 |
| Avg | 2.2685 | 4.5268 | 2.7161 | 1.5106 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 302 / 33 KV JAMKHEL I/C - II

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 24 | 6.3229 | 5.6584 |
| Max | 6.3229 | 5.6584 |
| Min | 6.3229 | 5.6584 |
| Avg | 6.3229 | 5.6584 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 201 / 11 KV vehergaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.3739 | | | | 1.829 | 1.5242 | 2.0885 |
| 2 | 2.13 | | | | 1.8595 | 1.5242 | 2.0885 |
| 3 | 2.13 | | | | 1.1622 | 1.6004 | 2.0553 |
| 4 | 2.1628 | | | | 1.89 | 1.6766 | 2.0388 |
| 5 | 2.3061 | | | | 1.9204 | 1.7071 | 2.0388 |
| 7 | | 3.0967 | 3.0331 | 2.9329 | | | |
| 8 | | 3.3753 | 3.3532 | 3.5063 | | | |
| 9 | | | 2.3472 | | | | |
| 10 | | 3.7193 | 3.0788 | | | | |
| 11 | | 2.6825 | 3.2606 | 3.1623 | | | |
| 12 | | 2.8654 | 2.9492 | 2.7435 | | | |
| 13 | 3.4899 | | | | 2.9721 | 3.3425 | |
| 14 | 3.7193 | | | | 2.8959 | 3.4408 | 3.3532 |
| 15 | 3.6702 | | | | 2.8807 | 3.5227 | 3.1245 |
| 16 | 3.408 | | | | 2.7892 | 3.4408 | 3.2465 |
| 17 | | | | | 2.6825 | 2.982 | 2.9264 |
| 18 | | | 2.8841 | | | | 2.5758 |
| 19 | | 2.9874 | 2.8841 | 2.8349 | | | |
| 20 | | 2.713 | 2.4863 | 2.4996 | | | |
| 21 | | 2.5911 | 2.304 | 2.2253 | | | |
| 22 | | 2.7435 | 1.6244 | 2.1948 | | | |
| 23 | 2.2611 | 1.6918 | 2.0553 | 1.9662 | 1.5851 | 2.13 | 1.9509 |
| 24 | 3.5608 | 2.1792 | | | 1.829 | 1.5546 | 2.1382 |
| Max | 3.7193 | 3.7193 | 3.3532 | 3.5063 | 2.9721 | 3.5227 | 3.3532 |
| Min | 2.13 | 1.6918 | 1.6244 | 1.9662 | 1.1622 | 1.5242 | 1.9509 |
| Avg | 2.8375 | 2.7859 | 2.6884 | 2.6740 | 2.1913 | 2.3705 | 2.4688 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 202 / 11 KV Lonkhedi Gaonthan

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1017 | .1526 | .1524 | .1357 | .1372 | .1524 | .1357 |
| 2 | .1017 | .1526 | .1372 | .1357 | .1524 | .1524 | .1357 |
| 3 | .1357 | .1696 | .1677 | .1357 | .1677 | .1524 | .1696 |
| 4 | .1357 | .2035 | .1981 | .1696 | .1524 | .1829 | .2035 |
| 5 | .1696 | .2204 | .2286 | .2058 | .1981 | .2439 | .2543 |
| 6 | | .1865 | .2591 | .1696 | .1677 | | |
| 9 | .1696 | .1696 | .2439 | | | .1677 | .2035 |
| 10 | .1526 | | .1524 | | | .1677 | .1865 |
| 11 | .1187 | .1524 | .1865 | .1696 | | .1865 | .1865 |
| 12 | .1187 | | .1017 | .1829 | | .1017 | .0914 |
| 16 | .1357 | .1981 | | .1524 | | .1526 | .1524 |
| 17 | | .2134 | .2204 | .0914 | .1981 | .1526 | .1677 |
| 18 | | .1677 | .2543 | .0914 | .1981 | .1865 | .1524 |
| 19 | | .2896 | .2543 | .2591 | .1981 | .2543 | .1677 |
| 20 | .1865 | .2439 | .2035 | .1981 | .2134 | .2543 | .1677 |
| 21 | .2035 | .2134 | .2035 | .2134 | .2134 | .2035 | .1372 |
| 22 | .1696 | .1829 | .1865 | .0914 | .1677 | .1865 | .1372 |
| 23 | .1865 | .1524 | .1526 | .1372 | .1677 | .1526 | .1372 |
| 24 | .1017 | .1526 | .1524 | .1357 | .1372 | .1524 | .1357 |
| Max | .2035 | .2896 | .2591 | .2591 | .2134 | .2543 | .2543 |
| Min | .1017 | .1524 | .1017 | .0914 | .1372 | .1017 | .0914 |
| Avg | .1458 | .1895 | .1920 | .1573 | .1764 | .1779 | .1623 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 203 / 11 KV Ghanegaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1311 | 1.1469 | .6097 | 1.1469 | .1219 | .1067 | .116 |
| 2 | .1311 | 1.1469 | .6859 | 1.1603 | .1372 | .1067 | .116 |
| 3 | .1638 | 1.1469 | .7316 | 1.1603 | .1372 | .1067 | .116 |
| 4 | .1638 | 1.1797 | .7621 | 1.1271 | | .1524 | .1492 |
| 5 | .213 | 1.1797 | .9145 | 1.1105 | .1524 | .1981 | .1492 |
| 7 | 1.6385 | | | | 1.4327 | 1.4784 | 1.989 |
| 8 | 2.7199 | | | | 1.6156 | 2.2558 | |
| 9 | 2.6543 | | | | 2.3624 | 2.4996 | 2.4863 |
| 10 | 1.278 | | | | 2.3929 | 2.1795 | 2.5194 |
| 11 | 2.3922 | | | | 2.1186 | 2.3205 | 2.2211 |
| 12 | 2.2283 | | | | 3.4141 | 1.7238 | 1.6461 |
| 13 | | 2.7282 | 2.5396 | 2.4082 | | | |
| 14 | | 2.5911 | 2.6052 | 2.2862 | | | |
| 15 | | 2.2862 | 2.4577 | 2.1948 | | | |
| 16 | | 2.1643 | 2.13 | 2.1491 | | | |
| 17 | | | 2.2447 | 1.7985 | | | |
| 18 | | 1.0974 | 2.0972 | 1.448 | | | |
| 19 | | | | 1.448 | 1.5242 | 1.8679 | 2.1186 |
| 20 | 1.4419 | | | | 1.3413 | 1.8023 | 1.448 |
| 21 | 1.1797 | | | | 1.3717 | 1.5893 | 1.4327 |
| 22 | 1.2289 | | | | 1.3413 | 1.5238 | 1.387 |
| 23 | 1.2452 | .5944 | 1.1934 | .945 | .8993 | 1.0608 | 1.2803 |
| 24 | .1326 | 1.1797 | .6097 | 1.1934 | .1219 | .1219 | .1326 |
| Max | 2.7199 | 2.7282 | 2.6052 | 2.4082 | 3.4141 | 2.4996 | 2.5194 |
| Min | .1311 | .5944 | .6097 | .945 | .1219 | .1067 | .116 |
| Avg | 1.1839 | 1.5368 | 1.5063 | 1.5412 | 1.2803 | 1.2408 | 1.2067 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 201 / 11 KV DATARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4715 | .2949 | .4175 | .3605 | 1.4746 | 1.5192 | 1.6575 |
| 2 | .415 | .2949 | .3419 | .3277 | 1.4746 | 1.3842 | 1.5424 |
| 3 | .4715 | .3605 | .3799 | .3277 | 1.4091 | 1.3166 | 1.3413 |
| 4 | .4715 | .426 | .4554 | | 1.4746 | 1.2154 | 1.4251 |
| 5 | .5658 | .4588 | .5303 | .4096 | 1.5729 | 1.3489 | 1.643 |
| 6 | .6224 | .5898 | .6048 | .4915 | 1.704 | | 1.7604 |
| 7 | .7167 | .5898 | .7182 | .6226 | 1.6057 | 1.714 | 1.9113 |
| 8 | 2.652 | 2.7526 | 2.7558 | 2.6216 | .2294 | .567 | .5658 |
| 9 | 2.8673 | 2.6886 | 3.2117 | | .3799 | .3799 | .3605 |
| 10 | 3.2114 | 3.2263 | 3.1017 | | .3036 | .3395 | .2949 |
| 11 | 3.0803 | 3.0989 | 2.6825 | 2.2939 | .3416 | .2641 | .2949 |
| 12 | 2.6543 | 3.1397 | 2.4143 | 2.8182 | .3039 | .2641 | .2622 |
| 13 | 1.6385 | 2.6947 | 2.0454 | 2.7854 | .3416 | .3018 | .2622 |
| 14 | .2949 | .3795 | .3772 | 2.4905 | .3416 | .3018 | .2622 |
| 15 | .3605 | .4175 | .3395 | 2.2939 | .3416 | .3395 | .2949 |
| 16 | .3605 | .3799 | .3395 | .3277 | .3799 | | .2949 |
| 17 | .3605 | .3419 | | .6882 | .3799 | .4904 | .3277 |
| 18 | .426 | .3799 | | .3277 | .3799 | .3772 | .3605 |
| 19 | .3605 | .4179 | .679 | .3605 | .606 | .6036 | .3605 |
| 20 | 2.0645 | 2.275 | 2.1795 | 2.2939 | .7182 | .679 | .5243 |
| 21 | 1.7368 | 2.146 | 1.7436 | 1.6385 | .6804 | .679 | .5898 |
| 22 | .3605 | .7938 | .6036 | 1.6385 | 1.3596 | 1.9662 | .5243 |
| 23 | .3277 | .6439 | .3772 | 1.5729 | 1.7974 | 1.8023 | .4915 |
| 24 | .5093 | .2949 | .4934 | .4096 | 1.4746 | 1.6205 | 1.7204 |
| Max | 3.2114 | 3.2263 | 3.2117 | 2.8182 | 1.7974 | 1.9662 | 1.9113 |
| Min | .2949 | .2949 | .3395 | .3277 | .2294 | .2641 | .2622 |
| Avg | 1.1250 | 1.2119 | 1.2178 | 1.2905 | .8781 | .8852 | .7947 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 202 / 11 KV Tembhe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .2622 | .3039 | .2622 | .4915 | .5438 | .4359 |
| 2 | .2829 | .2622 | .3036 | .2622 | .4915 | .5438 | .4359 |
| 3 | .3395 | .2622 | .3419 | .3277 | .5571 | .5098 | .3688 |
| 4 | .3395 | .3605 | .3791 | .3932 | .5571 | .5438 | .4694 |
| 5 | .415 | .426 | .5292 | .426 | .5571 | .5778 | .5792 |
| 6 | .5281 | .5571 | .567 | .4915 | .5898 | .6104 | .7545 |
| 7 | .6036 | .5243 | .6237 | .5735 | .5243 | .6104 | .7712 |
| 8 | .415 | .3932 | .417 | .3277 | .4175 | .3416 | .3206 |
| 9 | .2458 | .3039 | .3609 | | .3039 | .3419 | .2622 |
| 10 | .1966 | .2469 | .2641 | | .2467 | .2452 | .2294 |
| 11 | .1966 | .2279 | .2075 | .2458 | .2089 | .1698 | .1638 |
| 12 | .3605 | .2279 | .1886 | .1966 | .171 | .1698 | .1311 |
| 13 | .1966 | .2279 | .2075 | .1966 | .1899 | .1886 | |
| 14 | 1.6385 | 1.3857 | 1.0059 | 1.2125 | .2279 | .1698 | .1311 |
| 15 | 1.6712 | 1.3842 | 1.073 | 1.278 | .2467 | .2075 | .1638 |
| 16 | 1.6712 | 1.2829 | 1.1736 | 1.2452 | .2659 | .2075 | .1802 |
| 17 | 1.3108 | 1.1478 | 1.0395 | 1.1469 | .2279 | .2075 | .2294 |
| 18 | 1.1797 | .6775 | 1.0059 | .9831 | .2659 | .3018 | .2622 |
| 19 | .852 | .8738 | .7545 | .7537 | .4166 | .5093 | .4915 |
| 20 | .6882 | .6752 | .6036 | .6554 | .4744 | .4715 | .426 |
| 21 | .5898 | .6217 | .57 | .5898 | .4554 | .4338 | .3932 |
| 22 | .3277 | .5292 | .3772 | .4915 | .3977 | .6249 | .3277 |
| 23 | .3277 | .4158 | .3395 | .4915 | .6145 | .5155 | .2949 |
| 24 | .3395 | .2949 | .3405 | .2622 | .4915 | .5438 | .4915 |
| Max | 1.6712 | 1.3857 | 1.1736 | 1.278 | .6145 | .6249 | .7712 |
| Min | .1966 | .2279 | .1886 | .1966 | .171 | .1698 | .1311 |
| Avg | .6250 | .5655 | .5407 | .5824 | .3913 | .3996 | .3615 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 203 / 11 KV GANGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5424 | 1.5089 | 1.5867 | 1.5927 | .4024 | .4166 | .415 |
| 2 | 1.4419 | 1.3413 | 1.3904 | 1.5089 | .3688 | .4166 | .3772 |
| 3 | 1.2574 | 1.2742 | 1.2576 | 1.4251 | .3688 | .4175 | .3772 |
| 4 | 1.3413 | 1.2742 | 1.3779 | 1.4754 | .503 | .5292 | .6036 |
| 5 | 1.4251 | 1.4419 | 1.5261 | 1.5927 | .7377 | .6687 | .7922 |
| 6 | 1.5249 | 1.7101 | 1.7295 | 1.7101 | .8718 | .9659 | .9431 |
| 7 | 1.6575 | 1.7772 | 1.8313 | 1.7604 | .8383 | | 1.0185 |
| 8 | .7042 | .8383 | .7802 | .6036 | .8048 | .8571 | .8299 |
| 9 | .5365 | .6831 | .6335 | | *** | 2.8166 | 2.2466 |
| 10 | .4694 | .6072 | .415 | | 2.643 | 2.6825 | 2.3472 |
| 11 | .4024 | .4179 | .3395 | .503 | 2.5839 | 2.3807 | 2.0119 |
| 12 | .3353 | .3229 | .3018 | .4024 | 2.2005 | 1.3413 | 1.9784 |
| 13 | .3277 | .3609 | .2641 | .2683 | 1.025 | 2.0553 | 1.6766 |
| 14 | .3353 | .3039 | .2641 | .3018 | 2.1438 | 1.9062 | 1.5089 |
| 15 | | .3609 | .3206 | .2683 | 2.1845 | 1.9006 | 1.5089 |
| 16 | .4694 | .3605 | .3395 | .2683 | 2.0393 | 1.704 | 1.5257 |
| 17 | .6706 | .3609 | .3018 | .3353 | .4744 | .3772 | .503 |
| 18 | .7377 | .4554 | .4527 | .503 | .6452 | .415 | .5365 |
| 19 | | .9081 | .8676 | .7712 | .743 | .9054 | .8048 |
| 20 | .7712 | .8198 | .9054 | .7712 | .8198 | .8299 | .6706 |
| 21 | .6371 | .756 | .7545 | .6371 | .7407 | .7167 | .6036 |
| 22 | 2.079 | 2.1077 | 2.0119 | .503 | .6348 | .6036 | 1.3413 |
| 23 | 1.6766 | 1.8778 | 1.8442 | .4359 | .526 | .4904 | 1.5089 |
| 24 | 1.6095 | 1.6095 | 1.7476 | 1.6766 | .4024 | .4914 | .4527 |
| Max | 2.079 | 2.1077 | 2.0119 | 1.7604 | 12.4695 | 2.8166 | 2.3472 |
| Min | .3277 | .3039 | .2641 | .2683 | .3688 | .3772 | .3772 |
| Avg | .9978 | .9783 | .9685 | .8779 | 1.5488 | 1.1256 | 1.1076 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 204 / 11 KV SHEWALI I/C - I

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | 3.6702 | 4.1495 | 3.8139 | 3.7037 | 3.155 | 1.0206 | 1.6124 |
| 16 | 2.6063 | 1.9434 | 1.7368 | 1.9204 | 1.9204 | 1.8842 | 2.0576 |
| 24 | 2.364 | 2.2634 | 2.4983 | 3.7037 | 2.4691 | 2.6171 | 2.6052 |
| Max | 3.6702 | 4.1495 | 3.8139 | 3.7037 | 3.155 | 2.6171 | 2.6052 |
| Min | 2.364 | 1.9434 | 1.7368 | 1.9204 | 1.9204 | 1.0206 | 1.6124 |
| Avg | 2.8802 | 2.7854 | 2.683 | 3.1093 | 2.5148 | 1.8406 | 2.0917 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 301 / 33 KV SHEWALI IC I

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | 2.8509 | 3.1335 | 3.1164 | 2.8588 | .4782 | .4668 | .5574 |
| 16 | 2.1276 | 1.4094 | 1.268 | 1.4447 | 2.4358 | 1.9287 | 1.638 |
| 24 | 1.9121 | 1.7346 | 2.329 | 1.9635 | 2.1568 | 2.2231 | 2.4577 |
| Max | 2.8509 | 3.1335 | 3.1164 | 2.8588 | 2.4358 | 2.2231 | 2.4577 |
| Min | 1.9121 | 1.4094 | 1.268 | 1.4447 | .4782 | .4668 | .5574 |
| Avg | 2.2969 | 2.0925 | 2.2378 | 2.089 | 1.6903 | 1.5395 | 1.5510 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 201 / 11 KV RAYKOT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1126 | .9602 | 1.2193 | 1.2498 | 1.1934 | 1.2431 | 1.3108 |
| 2 | 1.1126 | .9145 | 1.1736 | 1.2193 | 1.1934 | 1.2431 | 1.1126 |
| 9 | 2.2862 | | | | 2.1548 | 2.3777 | 2.0576 |
| 10 | 2.1186 | | | | 2.1548 | 2.3777 | 2.2862 |
| 11 | 1.9662 | | | | 1.9062 | 2.3167 | 2.1338 |
| 12 | 1.829 | | | | 1.8399 | 1.829 | 1.7985 |
| 13 | | 1.3413 | 2.0424 | 2.0424 | | | |
| 14 | 1.1126 | 1.5546 | 2.21 | 1.829 | | | |
| 15 | | 1.7528 | 1.9814 | 1.829 | | | |
| 16 | | 1.8747 | 1.8747 | 1.5699 | | | |
| 19 | | | 1.6766 | | | | |
| 20 | 1.6766 | 1.2498 | 1.6766 | 1.5242 | 2.0553 | 1.8595 | 1.5242 |
| 21 | 1.6461 | 1.3717 | 1.5242 | 1.5242 | 1.9913 | 1.7375 | 1.4937 |
| 22 | 1.5242 | 1.448 | 1.448 | 1.326 | 1.8233 | 1.6309 | 1.448 |
| 23 | 1.3717 | 1.4022 | 1.4937 | 1.326 | 1.5249 | 1.5242 | 1.3717 |
| 24 | 1.3413 | 1.0669 | 1.3717 | 1.3717 | 1.1934 | 1.2431 | 1.3717 |
| Max | 2.2862 | 1.8747 | 2.21 | 2.0424 | 2.1548 | 2.3777 | 2.2862 |
| Min | 1.1126 | .9145 | 1.1736 | 1.2193 | 1.1934 | 1.2431 | 1.1126 |
| Avg | 1.5915 | 1.3579 | 1.6410 | 1.5283 | 1.7301 | 1.7620 | 1.6281 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 202 / 11 KV DEOJIPADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2651 | 1.1431 | 1.3717 | 1.448 | 1.3923 | 1.326 | 1.4632 |
| 2 | 1.2651 | 1.1431 | 1.326 | 1.4022 | 1.3923 | 1.326 | 1.3413 |
| 9 | | 2.2862 | 2.2862 | 2.8178 | | | |
| 10 | | 2.332 | 2.271 | 2.7515 | | | |
| 11 | | 2.1643 | 2.0576 | 2.4863 | | | |
| 12 | | 2.0119 | 1.9662 | 2.1548 | | | |
| 13 | 2.5911 | | | | 2.2377 | 2.3167 | 2.5453 |
| 14 | 2.5911 | | | | 2.1548 | 2.21 | 2.3777 |
| 15 | 2.4387 | | | | 2.0719 | 1.9814 | 2.21 |
| 16 | 2.0119 | | | | 2.0222 | 2.0119 | 1.7375 |
| 20 | 1.7528 | 1.3717 | 1.9052 | 1.989 | 1.9559 | 1.7985 | 1.6766 |
| 21 | 1.6766 | 1.4784 | 1.829 | 1.8233 | 1.9062 | 1.6461 | 1.3717 |
| 22 | 1.5242 | 1.5546 | 1.7071 | 1.6575 | 1.6575 | 1.7071 | 1.4022 |
| 23 | 1.448 | 1.5242 | 1.6461 | 1.4918 | 1.5912 | 1.6461 | 1.3717 |
| 24 | 1.4632 | 1.2193 | 1.5242 | 1.5242 | 1.3923 | 1.326 | 1.5242 |
| Max | 2.5911 | 2.332 | 2.2862 | 2.8178 | 2.2377 | 2.3167 | 2.5453 |
| Min | 1.2651 | 1.1431 | 1.326 | 1.4022 | 1.3923 | 1.326 | 1.3413 |
| Avg | 1.8207 | 1.6572 | 1.8082 | 1.9588 | 1.7977 | 1.7542 | 1.7292 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 202 / 11 KV DATARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.9161 |
| Max | 1.9161 |
| Min | 1.9161 |
| Avg | 1.9161 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 203 / 11 KV BHAMER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.5261 |
| Max | 1.5261 |
| Min | 1.5261 |
| Avg | 1.5261 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 204 / 11 KV CHHADWEL-P

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.9522 |
| Max | 1.9522 |
| Min | 1.9522 |
| Avg | 1.9522 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 205 / 11 KV SAKRI GAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.1195 |
| Max | 2.1195 |
| Min | 2.1195 |
| Avg | 2.1195 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212] BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 401 / 33 KV NAVAPUR

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 13.023 |
| Max | 13.023 |
| Min | 13.023 |
| Avg | 13.023 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212] BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 408 / 33 KV CHAWADI

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 11.6941 |
| Max | 11.6941 |
| Min | 11.6941 |
| Avg | 11.6941 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 098013 / 220/33 SHIVAJINAGAR EHV

Feeder No / Name : 401 / 33 KV CHHADWEL

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 13.023 |
| Max | 13.023 |
| Min | 13.023 |
| Avg | 13.023 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 098013 / 220/33 SHIVAJINAGAR EHV

Feeder No / Name : 402 / 33 KV JAITANE

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 13.8203 |
| Max | 13.8203 |
| Min | 13.8203 |
| Avg | 13.8203 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212] BU 0523

Substation No/ Name :- 098013 / 220/33 SHIVAJINAGAR EHV

Feeder No / Name : 403 / 33 KV SUZLON WIND GEN TO
CHAD Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.5947 |
| Max | 1.5947 |
| Min | 1.5947 |
| Avg | 1.5947 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 201 / LAMKANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | 2.5434 | 2.7435 |
| 2 | | | | | 2.5434 | 2.5911 |
| 3 | | | | | 2.5434 | 3.0864 |
| 4 | | | | | 2.713 | 3.2579 |
| 5 | | | | | 3.0521 | 3.2388 |
| 6 | | | | | 3.3913 | 3.4294 |
| 7 | | | | | 3.476 | 3.4008 |
| 8 | | | | | 3.5608 | 3.5627 |
| 9 | | | | | 3.3913 | 3.4008 |
| 10 | 3.1722 | 2.572 | 3.0521 | 3.0178 | | |
| 11 | 3.4008 | 3.6008 | 3.3913 | 3.1131 | | |
| 12 | 3.6046 | 3.6456 | 3.5608 | 3.3198 | | |
| 13 | 3.6008 | 3.6456 | 3.5608 | 3.4818 | | |
| 14 | 3.5208 | 3.6456 | 3.6456 | 3.4408 | | |
| 15 | 3.5208 | 3.5608 | | 3.3608 | | |
| 16 | 3.4408 | 3.5608 | | 3.4408 | | |
| 17 | 3.4818 | 3.5608 | 3.3913 | 3.5608 | | |
| 24 | | | | | | 2.2043 |
| Max | 3.6046 | 3.6456 | 3.6456 | 3.5608 | 3.5608 | 3.5627 |
| Min | 3.1722 | 2.572 | 3.0521 | 3.0178 | 2.5434 | 2.2043 |
| Avg | 3.4678 | 3.474 | 3.4337 | 3.3420 | 3.0239 | 3.0916 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 202 / BEHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7468 | .5144 | 1.0174 | .7392 | | |
| 2 | .7468 | .6859 | 1.0174 | .7392 | | |
| 3 | .924 | .6859 | 1.0174 | .823 | | |
| 4 | 1.086 | .8573 | 1.1022 | .905 | | |
| 5 | 1.267 | .8573 | 1.1022 | .905 | | |
| 6 | 1.2536 | .8573 | 1.1869 | 1.0745 | | |
| 7 | 1.3432 | .8573 | 1.1869 | 1.1641 | | |
| 8 | 1.2536 | 1.2003 | 1.1869 | 1.1641 | | |
| 9 | 1.267 | 1.2003 | 1.1869 | 1.0745 | | |
| 10 | | | | | .9326 | .8097 |
| 11 | | | | | 1.4413 | .8097 |
| 12 | | | | | 1.3565 | .8097 |
| 13 | | | | | 1.2717 | .8097 |
| 14 | | | | | 1.2717 | 1.0526 |
| 15 | | | | | 1.3565 | 1.1336 |
| 16 | | | | | 1.2717 | 1.1336 |
| 17 | | | | | 1.1869 | 1.1336 |
| 24 | .5087 | .5601 | | .5087 | | |
| Max | 1.3432 | 1.2003 | 1.1869 | 1.1641 | 1.4413 | 1.1336 |
| Min | .5087 | .5144 | 1.0174 | .5087 | .9326 | .8097 |
| Avg | 1.0397 | .8276 | 1.1116 | .9097 | 1.2611 | .9615 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 203 / BURZAD Single phasing
Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.267 | | 1.3565 | 1.267 | .5087 | .4858 |
| 2 | 1.267 | | 1.3565 | 1.267 | .5087 | |
| 3 | 1.4327 | | 1.3565 | 1.267 | .5935 | .4858 |
| 4 | 1.7909 | | 1.5261 | 1.2536 | .6783 | .5668 |
| 5 | 1.7909 | | 1.5261 | 1.2536 | .9326 | .6478 |
| 6 | 1.7909 | | 1.6956 | 1.5223 | 1.0174 | .9717 |
| 7 | 1.7909 | | 1.6956 | 1.7147 | .8478 | .9717 |
| 8 | 1.7556 | | 1.8652 | 1.7147 | .763 | .7287 |
| 9 | 1.7556 | | 1.7804 | 1.6118 | .5935 | .5668 |
| 10 | .5601 | | .4239 | .5601 | 1.2717 | 1.1336 |
| 11 | .5601 | | .4239 | .5601 | 1.448 | 1.4575 |
| 12 | .4668 | | .4239 | .4668 | 1.6108 | 1.4575 |
| 13 | .4668 | | .5087 | .4668 | 1.5261 | 1.4575 |
| 14 | .5544 | | .5087 | .4668 | 1.6108 | |
| 15 | .5544 | | .5087 | .4668 | 1.6956 | |
| 16 | .5544 | | .4239 | | 1.6956 | |
| 17 | .5601 | | .4239 | .4668 | 1.5261 | |
| 18 | .7468 | | .5087 | .5544 | .5087 | |
| 19 | .924 | | .8478 | .6535 | .763 | |
| 20 | .724 | | .763 | .7392 | .6783 | |
| 21 | .5544 | | .5935 | | .5935 | |
| 22 | .5601 | | .5087 | | .5087 | |
| 23 | .5601 | | .5087 | | .5087 | 1.6194 |
| 24 | .9326 | .9955 | | .9326 | | .5087 |
| Max | 1.7909 | .9955 | 1.8652 | 1.7147 | 1.6956 | 1.6194 |
| Min | .4668 | .9955 | .4239 | .4668 | .5087 | .4858 |
| Avg | .9967 | .9955 | .9363 | .9603 | .9734 | .9328 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 204 / CHINCHWAR Single phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2801 | | .2543 | .2801 | 1.8652 | 1.6194 | |
| 2 | .2801 | | .2543 | .2801 | 1.8652 | 1.6194 | |
| 3 | .2801 | | .2543 | .2829 | 1.8652 | 1.7814 | |
| 4 | .2801 | | .2543 | .3734 | 2.0348 | 1.7814 | |
| 5 | .3734 | | .3391 | .4668 | 2.1195 | | |
| 6 | .6535 | | .5087 | .5544 | 2.3739 | .7287 | |
| 7 | .6468 | | .5087 | .5544 | 2.5434 | | |
| 8 | .5601 | | .4239 | .4668 | 2.4587 | .4049 | |
| 9 | .3734 | | .3391 | .3734 | 2.2043 | 1.9433 | |
| 10 | 1.8099 | | 1.6956 | 1.1088 | .3391 | .3239 | |
| 11 | 2.8045 | | 2.5434 | 1.9909 | .2543 | .2429 | |
| 12 | 2.915 | | 2.713 | 2.3282 | .2543 | .2429 | |
| 13 | 2.8826 | | 2.713 | 2.6863 | .2543 | .2429 | |
| 14 | 2.7978 | | 2.713 | 2.4539 | .2543 | .2429 | |
| 15 | 2.7664 | | 2.713 | 2.3034 | .2543 | .2429 | |
| 16 | 2.6825 | | | 2.2291 | .2543 | .2429 | |
| 17 | 2.6216 | | 2.5434 | 2.3282 | .2543 | .2429 | |
| 18 | .5544 | | .5087 | .2801 | .3391 | .3239 | |
| 19 | .7392 | | .5087 | .4668 | .5087 | .5668 | |
| 20 | .5601 | | .4239 | .4668 | .5087 | .5668 | |
| 21 | .5601 | | .3391 | | .4239 | .4858 | |
| 22 | .5601 | | .3391 | | | .4049 | |
| 23 | .5601 | | .3391 | | .3391 | .3239 | |
| 24 | .2543 | .3734 | | .2543 | | .9326 | 1.6194 |
| Max | 2.915 | .3734 | 2.713 | 2.6863 | 2.5434 | 1.9433 | 1.6194 |
| Min | .2543 | .3734 | .2543 | .2543 | .2543 | .2429 | 1.6194 |
| Avg | 1.1998 | .3734 | 1.0559 | 1.0728 | 1.0713 | .7049 | 1.6194 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 205 / BORIS SINGLE PHASING.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .6783 | | |
| 2 | | | | .6783 | .6478 | |
| 3 | | | | .6783 | .6478 | |
| 4 | | | | .763 | .6478 | |
| 5 | | | | .763 | .6478 | |
| 6 | | .3561 | | .8478 | .6478 | |
| 7 | | | | .8478 | | |
| 8 | | | | .8478 | .8097 | |
| 9 | | | | .763 | .8097 | |
| 10 | .5601 | .6783 | .5601 | | | |
| 11 | .7468 | .6783 | .8316 | | | |
| 12 | .7392 | .6783 | .924 | | | |
| 13 | .8316 | .763 | 1.0059 | | | |
| 14 | .823 | .763 | 1.0059 | | | |
| 15 | .823 | .763 | .905 | | | |
| 16 | .905 | .6783 | .8402 | | | |
| 17 | .905 | .6783 | .905 | | | |
| 24 | | | | | .5087 | .6478 |
| Max | .905 | .763 | 1.0059 | .8478 | .8097 | .6478 |
| Min | .5601 | .3561 | .5601 | .6783 | .5087 | .6478 |
| Avg | .7917 | .6707 | .8722 | .7630 | .6709 | .6478 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 206 / BEHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1867 | | .1696 | .1886 | .1696 | .1619 | |
| 2 | .1886 | | .1696 | .1886 | .1696 | .1619 | |
| 3 | .1886 | | .1696 | .1867 | .1696 | .1619 | |
| 4 | .2801 | | .1696 | .2801 | .2543 | .1619 | |
| 5 | .3734 | | .2543 | .3734 | .2543 | .2429 | |
| 6 | .4668 | | .3391 | .3696 | .3391 | .2429 | |
| 7 | .462 | | .3772 | .2801 | .3391 | .3239 | |
| 8 | .2801 | | .2543 | .2801 | .1696 | .2429 | |
| 9 | .1867 | | .2543 | .2801 | .1696 | .2429 | |
| 10 | .1867 | | .1696 | .1867 | .1696 | .1619 | |
| 11 | .1867 | | .1696 | | .1696 | .1619 | |
| 12 | .1867 | | .1696 | | .1696 | .1619 | |
| 13 | .1867 | | .1696 | .1867 | .1696 | .1619 | |
| 14 | .1867 | | .1696 | .1867 | .1696 | .1619 | |
| 15 | .1867 | | .1696 | .1867 | .1696 | .1619 | |
| 16 | .2801 | | .1696 | .1867 | .1696 | .1619 | |
| 17 | .2801 | | .1696 | .1867 | .1696 | .1619 | |
| 18 | .3696 | | .1696 | .2801 | .1696 | .1619 | |
| 19 | .3734 | | .1696 | .1867 | .2543 | .2429 | |
| 20 | .3734 | | .1696 | | .2543 | .2429 | |
| 21 | .3734 | | .1696 | | .1696 | .2429 | |
| 22 | .1886 | | .1696 | | .1696 | .1619 | |
| 23 | .1886 | | .1696 | | .1696 | .1619 | |
| 24 | .1696 | .1886 | | .1696 | | .1696 | .1619 |
| Max | .4668 | .1886 | .3772 | .3734 | .3391 | .3239 | .1619 |
| Min | .1696 | .1886 | .1696 | .1696 | .1696 | .1619 | .1619 |
| Avg | .2638 | .1886 | .1970 | .2324 | .1991 | .1926 | .1619 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 207 / Nakumbhe (Single Phasing) SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2536 | | 1.3565 | 1.2536 | .2543 | .2429 | |
| 2 | 1.267 | | 1.3565 | 1.4327 | .2543 | .2429 | |
| 3 | 1.448 | | 1.3565 | 1.4327 | .2543 | .2429 | |
| 4 | 1.6118 | | 1.5261 | 1.4899 | .3391 | .2429 | |
| 5 | 1.7909 | | 1.5261 | 1.5061 | .4239 | .3239 | |
| 6 | 1.7909 | | 1.6108 | 1.4575 | .4239 | .4049 | |
| 7 | 1.7718 | | 1.6956 | 1.6118 | .3391 | .3239 | |
| 8 | 1.7147 | | 1.8652 | 1.7147 | .3391 | .3239 | |
| 9 | 1.6118 | | 1.6956 | 1.7147 | .2543 | .2429 | |
| 10 | .2801 | | .1696 | .2801 | 1.1869 | 1.2146 | |
| 11 | .1867 | | .1696 | .2801 | 1.95 | 1.7004 | |
| 12 | .1867 | | .1696 | .1867 | 1.95 | 1.7004 | |
| 13 | .1886 | | .1696 | .1867 | 1.95 | 1.7004 | |
| 14 | .1886 | | .1696 | .1867 | 1.8652 | | |
| 15 | .1886 | | .1696 | .1867 | 1.7804 | 1.7004 | |
| 16 | .2801 | | .1696 | .1867 | 1.6956 | 1.7004 | |
| 17 | .2801 | | .1696 | .1867 | 1.6956 | 1.7004 | |
| 18 | .462 | | .2543 | | .3391 | | |
| 19 | .5544 | | .2543 | .3734 | .3391 | .3239 | |
| 20 | .3734 | | .3391 | | .3391 | .3239 | |
| 21 | .3734 | | .3391 | | .3391 | .3239 | |
| 22 | .3734 | | .3391 | | .2543 | .3239 | |
| 23 | .3734 | | .3391 | | .2543 | .3239 | |
| 24 | 1.0174 | .9955 | | | | .2543 | .2429 |
| Max | 1.7909 | .9955 | 1.8652 | 1.7147 | 1.95 | 1.7004 | .2429 |
| Min | .1867 | .9955 | .1696 | .1867 | .2543 | .2429 | .2429 |
| Avg | .8153 | .9955 | .7483 | .8704 | .8183 | .7219 | .2429 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 201 / 11 KV Billadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6279 | .6241 | .4012 | .4458 | | | |
| 2 | .6488 | .6241 | .4458 | .5201 | | | |
| 3 | .6379 | .6241 | .4755 | .5944 | | | |
| 4 | .6783 | .6836 | | .5944 | | | |
| 5 | .6783 | .7133 | .5201 | .6687 | | | |
| 6 | .7078 | .743 | .5944 | .6836 | | | |
| 7 | .7249 | .743 | .6687 | .7876 | | | |
| 8 | | | .5944 | .7135 | | | |
| 9 | | | .5498 | .6421 | | | |
| 10 | | | .5498 | | .3139 | .3333 | .2591 |
| 11 | | | | | .8898 | .8419 | .57 |
| 12 | | | | | .8578 | .8562 | .6478 |
| 13 | | | | | .5914 | .7922 | .7678 |
| 14 | | | | | .858 | .8152 | .6653 |
| 15 | | | | | .8152 | .742 | .667 |
| 16 | | | | | .8004 | .7856 | .667 |
| 17 | | | | | .7133 | .743 | .5944 |
| 22 | .535 | | | | | | |
| 23 | .535 | | | | | | |
| 24 | .6379 | .535 | | .2972 | | | |
| Max | .7249 | .743 | .6687 | .7876 | .8898 | .8562 | .7678 |
| Min | .535 | .535 | .4012 | .2972 | .3139 | .3333 | .2591 |
| Avg | .6412 | .6613 | .5333 | .5947 | .7300 | .7387 | .6048 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 202 / NYHALOD Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5698 | .5418 | .4064 | .4214 | | | |
| 2 | .5604 | .5418 | .4064 | .4515 | | | |
| 3 | .5604 | .5418 | .4214 | .4515 | | | |
| 4 | .5914 | .5719 | .4515 | .5117 | | | |
| 5 | .5929 | .5719 | .5117 | .5268 | | | |
| 6 | .6488 | .5117 | .5418 | .602 | | | |
| 7 | .6783 | .5117 | .6923 | .6321 | | | |
| 8 | | | .602 | .5977 | | | |
| 9 | | | .5418 | .6357 | | | |
| 10 | | | .602 | | .4284 | .4609 | .358 |
| 11 | | | | | .8567 | .749 | .6564 |
| 12 | | | | | .8272 | .7688 | .7161 |
| 13 | | | | .1139 | .8262 | .6783 | .7161 |
| 14 | | | | | .7 | .6801 | .5408 |
| 15 | | | | | .6505 | .6801 | .5618 |
| 16 | | | | | .7468 | .6505 | .6622 |
| 17 | | | | | .6321 | .6321 | .6321 |
| 22 | .4816 | | | | | | |
| 23 | .4816 | | | | | | |
| 24 | .5693 | .4515 | | .4214 | | | |
| Max | .6783 | .5719 | .6923 | .6357 | .8567 | .7688 | .7161 |
| Min | .4816 | .4515 | .4064 | .1139 | .4284 | .4609 | .358 |
| Avg | .5735 | .5305 | .5177 | .4878 | .7085 | .6625 | .6054 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 203 / KAPADANE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .1448 | .1774 | .1448 |
| 2 | | | | | .1738 | .2263 | .1593 |
| 3 | | | | | .1738 | .1774 | .1882 |
| 4 | | | | | .1882 | .1992 | .2027 |
| 5 | | | | | .2172 | .2277 | .2462 |
| 6 | | | | | .2172 | .2957 | .3041 |
| 7 | | | | | .2462 | .3261 | .333 |
| 8 | | | | | .3416 | .4571 | .362 |
| 9 | .406 | .4666 | | | .3844 | .4719 | |
| 10 | .4344 | .4633 | | .3244 | | | |
| 11 | .4344 | .4344 | .5068 | .5027 | | | |
| 12 | .4054 | .3765 | .5357 | .5027 | | | |
| 13 | .3765 | .4054 | .5213 | .4435 | | | |
| 14 | .3765 | .3909 | .4923 | .5121 | | | |
| 15 | .3844 | .362 | .4633 | .4435 | | | |
| 16 | .3992 | .3765 | .3909 | .3844 | | | |
| 17 | | | .4344 | .3765 | | | |
| 18 | | | | .3185 | | | |
| 22 | | | | | | | .1448 |
| 24 | | | | | .1448 | .1478 | .1593 |
| Max | .4344 | .4666 | .5357 | .5121 | .3844 | .4719 | .362 |
| Min | .3765 | .362 | .3909 | .3185 | .1448 | .1478 | .1448 |
| Avg | .4021 | .4095 | .4778 | .4231 | .2232 | .2707 | .2244 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 204 / Nyhalod Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4527 | .3658 | .3048 | .3506 | .3506 | .3506 | .5288 |
| 2 | .373 | .3353 | .3048 | .3353 | .3353 | .3658 | .5589 |
| 3 | .415 | .3353 | .3353 | .3658 | .3658 | .3506 | .588 |
| 4 | .4904 | .3963 | .3963 | .3963 | .4115 | .4572 | .1984 |
| 5 | .5281 | .4268 | .4344 | .4572 | .4572 | .4572 | .7232 |
| 6 | .7545 | .6097 | .5944 | .5639 | .5182 | .5182 | .9041 |
| 7 | .8299 | .4572 | .6097 | .6401 | .5487 | .5944 | .9649 |
| 8 | .679 | .4877 | .4572 | .5093 | .4748 | .4572 | .8126 |
| 9 | .6413 | .3963 | .3963 | .373 | .4338 | .4115 | .8295 |
| 10 | .3048 | .381 | .3048 | .3772 | .4527 | .4527 | .3772 |
| 11 | .3201 | .3353 | .2896 | .3391 | .3772 | .415 | .3395 |
| 12 | .2896 | .3506 | .2591 | .3391 | .3391 | .415 | .3395 |
| 13 | .2896 | .3048 | .2591 | .3353 | .3772 | .3395 | .2683 |
| 14 | .2896 | .2743 | .2896 | .4158 | .415 | .3395 | .3391 |
| 15 | .3048 | .3048 | .3048 | .415 | .373 | .3395 | .3391 |
| 16 | .415 | .3201 | .3048 | .3772 | .415 | .415 | .3772 |
| 17 | .4527 | .381 | .3048 | .3963 | .381 | .3658 | .3658 |
| 18 | .4527 | .4268 | .3353 | .4572 | .381 | .3963 | .381 |
| 19 | .4904 | .4572 | .3658 | .4877 | .442 | .4268 | .4572 |
| 20 | .5658 | .4877 | .3658 | .4572 | .4572 | .4572 | .4572 |
| 21 | .4572 | .4572 | .3658 | .442 | .4572 | .4572 | .442 |
| 22 | .4268 | .4268 | .3963 | .4115 | .3963 | .4268 | .4268 |
| 23 | .381 | .381 | .4115 | .3963 | .3658 | .4268 | .3963 |
| 24 | .4904 | .3658 | | .381 | .381 | .3506 | .5589 |
| Max | .8299 | .6097 | .6097 | .6401 | .5487 | .5944 | .9649 |
| Min | .2896 | .2743 | .2591 | .3353 | .3353 | .3395 | .1984 |
| Avg | .4623 | .3944 | .3648 | .4175 | .4128 | .4161 | .4989 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 205 / Kapadana Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0168 | .0173 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 2 | .0168 | .0175 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 3 | .0168 | .0175 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 4 | .017 | .0173 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 5 | .017 | .0173 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 6 | .017 | .0173 | .0175 | .0175 | .0175 | .0175 | .0175 |
| 7 | .0189 | .0173 | .0175 | .0168 | .0175 | .0175 | .0175 |
| 8 | .0189 | .0173 | .0175 | .0168 | .0175 | .0175 | .0175 |
| 9 | .0189 | .0173 | .0175 | .017 | .0175 | .0173 | .0175 |
| 10 | .0175 | .0173 | .0175 | .017 | .0168 | .0168 | .0189 |
| 11 | .0175 | .0173 | .0152 | .0168 | .017 | .0189 | .017 |
| 12 | .0175 | .0173 | .0175 | .0189 | .0189 | .017 | .0189 |
| 13 | .0175 | .0173 | .0175 | .0189 | .0168 | .017 | .0168 |
| 14 | .0175 | .0173 | .0175 | .017 | .017 | .0189 | .0189 |
| 15 | .0175 | .0173 | .0175 | .017 | .0189 | .0189 | .0189 |
| 16 | .0175 | .0173 | .0175 | .0189 | .0168 | .0168 | .017 |
| 17 | .0168 | .0173 | .0175 | .0175 | .0173 | .0173 | .0173 |
| 18 | .017 | .0173 | .0175 | .0175 | .0173 | .0173 | .0175 |
| 19 | .0189 | .0173 | .0175 | .0173 | .0173 | .0181 | .0181 |
| 20 | .0189 | .0173 | .0175 | .0173 | .0173 | .0181 | .0181 |
| 21 | .0173 | .0173 | .0175 | .0175 | .0173 | .0177 | .0181 |
| 22 | .0173 | | .0175 | .0175 | .0175 | .0175 | .0175 |
| 23 | .0173 | | .0175 | .0175 | .0175 | .0175 | .0175 |
| 24 | .017 | .0173 | | .0175 | .0175 | .0175 | .0175 |
| Max | .0189 | .0175 | .0175 | .0189 | .0189 | .0189 | .0189 |
| Min | .0168 | .0173 | .0152 | .0168 | .0168 | .0168 | .0168 |
| Avg | .0175 | .0173 | .0174 | .0175 | .0174 | .0176 | .0177 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 206 / NAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2035 | .2103 | .1214 | .1341 | .156 | .1578 | .1387 |
| 2 | .1696 | .1753 | .1214 | .1341 | .156 | .1578 | .1387 |
| 3 | .1696 | .1753 | .1387 | .1357 | .1734 | .1753 | .156 |
| 4 | .1696 | .1928 | .1387 | .1677 | .1734 | .1753 | .156 |
| 5 | .2641 | .2454 | .1734 | .2515 | .2254 | .2629 | .1907 |
| 6 | .2829 | .2629 | .2601 | .2829 | .2601 | .2804 | .2629 |
| 7 | .2829 | .2454 | .2774 | .2713 | .2947 | .3155 | .298 |
| 8 | .2829 | .2103 | .2427 | .2263 | .2601 | .2103 | .2454 |
| 9 | .1886 | .1753 | .208 | .1886 | .1753 | .1928 | .2075 |
| 10 | .156 | .1578 | .1734 | .1677 | .1865 | .1886 | .1677 |
| 11 | .1387 | .1402 | .1387 | .1677 | .2263 | .2263 | .1696 |
| 12 | .1214 | .1227 | .1214 | .1886 | .1696 | .1696 | .1696 |
| 13 | .1214 | .1227 | .1214 | .1886 | .1886 | .1509 | .1341 |
| 14 | .1387 | .1227 | .1387 | .1357 | .2035 | .1509 | .1886 |
| 15 | .1509 | .1402 | .1214 | .1696 | .2012 | .1509 | .1886 |
| 16 | .1509 | .1402 | .1387 | .1886 | .1677 | .1886 | .1696 |
| 17 | .1677 | .1402 | .1387 | .1734 | .1753 | .1753 | .1753 |
| 18 | .1696 | .1928 | .1387 | .1734 | .2103 | .1753 | .1753 |
| 19 | .1886 | .2454 | .208 | .208 | .2103 | .2103 | .1928 |
| 20 | .2263 | .2103 | .208 | .208 | .2103 | .2454 | .2103 |
| 21 | .1753 | | .1734 | .1734 | .1753 | .2103 | .1753 |
| 22 | .1753 | | .1734 | .1734 | .1734 | .1734 | .1734 |
| 23 | .1402 | | .1387 | .156 | .156 | .1734 | .1734 |
| 24 | .2012 | .1402 | | .1214 | .1387 | .156 | .1387 |
| Max | .2829 | .2629 | .2774 | .2829 | .2947 | .3155 | .298 |
| Min | .1214 | .1227 | .1214 | .1214 | .1387 | .1509 | .1341 |
| Avg | .1848 | .1794 | .1658 | .1827 | .1945 | .1947 | .1832 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 201 / MOHADI PD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7781 | .571 | | .7011 | .6401 | .5487 | .743 |
| 2 | .9018 | .5889 | .4725 | .6859 | .6706 | .5487 | .8002 |
| 3 | .5325 | .7233 | .4725 | .5487 | .6554 | .6344 | .7621 |
| 4 | .9195 | .7536 | .503 | .5487 | .6706 | .5639 | .8002 |
| 5 | 1.049 | .9298 | .6097 | .6249 | .7011 | .5792 | .8215 |
| 6 | .9122 | 1.142 | .7621 | .7468 | .7468 | .5944 | .9896 |
| 7 | 1.0099 | 1.1859 | .9297 | .7621 | .7621 | .7621 | 1.1458 |
| 8 | .3384 | 1.0634 | .5335 | .7773 | .8535 | .9297 | 1.1827 |
| 9 | .6186 | 1.1043 | .7773 | .7316 | .7316 | 1.1043 | 1.0974 |
| 10 | | .7926 | .6249 | .6249 | .5335 | .6994 | .5853 |
| 11 | | 1.0669 | .9602 | .8535 | .9297 | 1.1411 | .9145 |
| 12 | | 1.0822 | 1.0669 | .9297 | .9755 | .9899 | 1.0974 |
| 13 | | 1.0822 | .9297 | .9602 | 1.0212 | 1.1043 | 1.0974 |
| 14 | | .9907 | .8993 | .945 | .9755 | 1.0697 | 1.0974 |
| 15 | | .9145 | .884 | .9145 | .8993 | 1.0541 | 1.0608 |
| 16 | | .945 | .8993 | .884 | .9602 | 1.0541 | 1.0059 |
| 17 | | .9602 | .9145 | .8383 | .8383 | .9659 | .9694 |
| 24 | | .4887 | .4572 | .7316 | .5182 | .5487 | .381 |
| Max | 1.049 | 1.1859 | 1.0669 | .9602 | 1.0212 | 1.1411 | 1.1827 |
| Min | .3384 | .4887 | .4572 | .5487 | .5182 | .5487 | .381 |
| Avg | .7844 | .9103 | .7468 | .7672 | .7824 | .8274 | .9195 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 202 / SANJAY AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 9 | | 1.1294 |
| 10 | .9899 | |
| 11 | 1.1728 | |
| 12 | 1.206 | |
| 13 | 1.1891 | |
| 14 | 1.3251 | |
| 15 | 1.2883 | |
| 16 | .8628 | |
| 17 | 1.0099 | |
| 23 | | .3681 |
| Max | 1.3251 | 1.1294 |
| Min | .8628 | .3681 |
| Avg | 1.1305 | .7488 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 203 / MOHADI PD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3566 | .3807 | .3429 | .3601 | .3601 | .3429 | .3584 |
| 2 | .3258 | .3681 | .3429 | .3429 | .3429 | .3429 | .3584 |
| 3 | .3887 | .4049 | .3429 | .3429 | .3429 | .3429 | .3772 |
| 4 | .4072 | .5153 | .3601 | .3601 | .3772 | .3601 | .4527 |
| 5 | .3909 | .6023 | .4115 | .3944 | .4115 | .4115 | .5228 |
| 6 | .4235 | .5521 | .4801 | .4458 | .463 | .4801 | .5975 |
| 7 | .4398 | .5313 | .5316 | .4973 | .5316 | .5144 | .5544 |
| 8 | .3421 | .4329 | .3772 | .3772 | .3772 | .3086 | .4805 |
| 9 | .2769 | .2824 | .2229 | .2572 | .2572 | .2281 | .3142 |
| 10 | .2475 | .2572 | .2401 | .2572 | .1886 | .1882 | .2378 |
| 11 | .198 | .3086 | .2401 | .2572 | .2229 | .1877 | .2378 |
| 12 | .2393 | .2401 | .2058 | .2915 | .2229 | .1955 | .2378 |
| 13 | .2167 | .2743 | .2743 | .3258 | .2058 | .2118 | .2743 |
| 14 | .2673 | .2915 | .3772 | .2915 | .2401 | .2443 | .2743 |
| 15 | .2769 | .2572 | .3429 | .2401 | .2401 | .2443 | .2743 |
| 16 | .2932 | .3086 | .3601 | .2572 | .2915 | .2443 | .2743 |
| 17 | .3135 | .3086 | .3772 | .2743 | .2743 | .2926 | .2926 |
| 18 | .3681 | .2743 | .3944 | .3086 | .2743 | .3258 | .3841 |
| 19 | .3668 | .3772 | .3772 | .3601 | .4115 | .3584 | .4207 |
| 20 | .4233 | .3772 | .3944 | .3772 | .3944 | .3584 | .462 |
| 21 | .2745 | .3944 | .3772 | .3772 | .4115 | .3584 | .3696 |
| 22 | .3147 | .3772 | .3944 | .3601 | .3429 | .3421 | .3696 |
| 23 | .3258 | .3601 | .3601 | .3601 | .3429 | .3681 | .3395 |
| 24 | | .3681 | .3429 | .3429 | .3429 | .3429 | .3584 |
| Max | .4398 | .6023 | .5316 | .4973 | .5316 | .5144 | .5975 |
| Min | .198 | .2401 | .2058 | .2401 | .1886 | .1877 | .2378 |
| Avg | .3251 | .3685 | .3529 | .3358 | .3279 | .3164 | .3676 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 204 / Sanjay Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1731 | .2209 | .2743 | .1886 | .1715 | .1886 | .2378 |
| 2 | .1955 | .244 | .2743 | .1886 | .1886 | .1886 | .2378 |
| 3 | .2024 | .2649 | .2572 | .1715 | .1715 | .1886 | .2378 |
| 4 | .2547 | .3576 | .2743 | .2058 | .1886 | .2058 | .2743 |
| 5 | .3135 | .417 | .3086 | .2058 | .2229 | .2572 | .3475 |
| 6 | .3658 | .4141 | .3772 | .2401 | .3086 | .3429 | .4024 |
| 7 | .3642 | .3761 | .3601 | .2915 | .3429 | .3429 | .362 |
| 8 | .2206 | .2815 | .2572 | .2572 | .2229 | .2401 | .2896 |
| 9 | .1987 | .184 | .2229 | .2229 | .1886 | .181 | .2303 |
| 10 | .1792 | .1715 | .1715 | .2058 | .1543 | .1448 | .124 |
| 11 | .1667 | .2058 | .1543 | .1715 | .1543 | .1417 | .1417 |
| 12 | .1466 | .1886 | .12 | .1715 | .1715 | .1417 | .1772 |
| 13 | .1303 | .1886 | .1543 | .1543 | .1715 | .1772 | .1772 |
| 14 | .1472 | .1886 | .1715 | .1715 | .1543 | .1772 | .1772 |
| 15 | .137 | .1886 | .1886 | .1715 | .1715 | .1772 | .1772 |
| 16 | .1466 | .2058 | .1886 | .1886 | .1715 | .1772 | .1949 |
| 17 | .1466 | .2229 | .2058 | .1886 | .2229 | .2126 | .181 |
| 18 | | .2058 | .2058 | .2058 | .2401 | .2658 | .2534 |
| 19 | | .2915 | .2229 | .2229 | .2401 | .2658 | .2715 |
| 20 | | .2915 | .2401 | .2401 | .2058 | .2715 | .2896 |
| 21 | .2761 | .2915 | .2229 | .2058 | .2058 | .2715 | .2534 |
| 22 | .2393 | .2915 | .2229 | .1886 | .2058 | .2561 | .2172 |
| 23 | .2195 | .2743 | .2058 | .1715 | .1886 | .2378 | .1829 |
| 24 | | .2284 | .2743 | .1886 | .1886 | .1886 | .2378 |
| Max | .3658 | .417 | .3772 | .2915 | .3429 | .3429 | .4024 |
| Min | .1303 | .1715 | .12 | .1543 | .1543 | .1417 | .124 |
| Avg | .2112 | .2581 | .2315 | .2008 | .2022 | .2184 | .2365 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 205 / NAVRA-NAVRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .1372 | .1372 | .12 |
| 2 | | | | | .1372 | .1219 | .1372 |
| 3 | | | | | .1524 | .1219 | .1543 |
| 4 | | | | | .1677 | .1372 | .1543 |
| 5 | | | | | .1677 | .1372 | .1543 |
| 6 | | | | | .1981 | .1372 | .1781 |
| 7 | | | | | .2591 | .1829 | .2105 |
| 8 | | | | | .1981 | .1829 | .2429 |
| 9 | | | | | .1677 | .1943 | .2429 |
| 10 | .1332 | .2134 | .1981 | .1543 | | | |
| 11 | .2945 | .2591 | .2896 | .2286 | | | |
| 12 | .297 | .2439 | .2134 | .2134 | | | |
| 13 | .2138 | .2286 | .2286 | .2286 | | | |
| 14 | .2769 | .2134 | .2591 | .2286 | | | |
| 15 | .2443 | .1981 | .2286 | .2439 | | | |
| 16 | .2118 | .2286 | .2134 | .2286 | | | |
| 17 | .2257 | .1981 | .2286 | .2286 | | | |
| 24 | | | | | .1524 | .1219 | .12 |
| Max | .297 | .2591 | .2896 | .2439 | .2591 | .1943 | .2429 |
| Min | .1332 | .1981 | .1981 | .1543 | .1372 | .1219 | .12 |
| Avg | .2372 | .2229 | .2324 | .2193 | .1738 | .1475 | .1715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 201 / FAGANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .1715 | .1372 | .1372 | .1029 | .5144 | .3772 |
| 2 | .1372 | .1715 | .1372 | .1372 | .1029 | .5144 | .3772 |
| 3 | .1372 | .1715 | .1372 | .12 | .1029 | .5144 | .3772 |
| 4 | .1715 | .1715 | .1372 | .12 | .1029 | .6173 | .4801 |
| 5 | .1715 | .2058 | .1715 | .1029 | .1372 | .6859 | .583 |
| 6 | .1715 | .2058 | .1715 | .1029 | .1372 | .6859 | 1.0288 |
| 7 | .1715 | .2058 | .1372 | .1029 | .1372 | 1.3717 | 1.2346 |
| 8 | .1715 | .2058 | .12 | .1029 | .1372 | 1.5089 | 1.5089 |
| 9 | .1372 | .1715 | .1029 | .12 | .1029 | 1.5432 | 1.5775 |
| 10 | .1372 | .6859 | .8573 | 1.0631 | .1372 | .1372 | .0857 |
| 11 | 1.3717 | 1.0974 | 1.2003 | 1.166 | .1372 | .1029 | .0857 |
| 12 | 1.4403 | 1.2346 | 1.3717 | 1.2689 | .1372 | .1029 | .0857 |
| 13 | 1.5089 | 1.3032 | 1.3717 | 1.2346 | .1372 | .1372 | .0857 |
| 14 | 1.4575 | 1.3717 | 1.3717 | 1.2003 | .1372 | .1372 | .12 |
| 15 | 1.3717 | 1.3717 | 1.2003 | 1.2003 | .1372 | .12 | .12 |
| 16 | 1.2003 | 1.3717 | 1.0288 | 1.2003 | .1372 | .1372 | .12 |
| 17 | 1.1145 | 1.3717 | .9602 | 1.166 | .1372 | .1715 | .1372 |
| 18 | .1372 | .1372 | .1715 | .1372 | .1372 | .2058 | .1715 |
| 19 | .1715 | .1886 | .1715 | .1372 | .1372 | .2058 | .1715 |
| 20 | .2058 | .2058 | .1372 | .1372 | .1715 | .2058 | .1715 |
| 21 | .1715 | .2058 | .1372 | .1372 | .2058 | .1715 | .1715 |
| 22 | .1715 | .1715 | .12 | .1372 | .2058 | .1372 | .1715 |
| 23 | .1715 | .1715 | .1029 | .1372 | .1715 | .1372 | .1715 |
| 24 | .1372 | .1715 | .1715 | .0857 | .1372 | .3429 | .3429 |
| Max | 1.5089 | 1.3717 | 1.3717 | 1.2689 | .2058 | 1.5432 | 1.5775 |
| Min | .1372 | .1372 | .1029 | .0857 | .1029 | .1029 | .0857 |
| Avg | .5073 | .5309 | .4844 | .4773 | .1386 | .4337 | .4065 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 202 / VARKHEDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | .0514 | .0514 | .0343 | .0514 | .0343 | .0343 |
| 2 | .0857 | .0514 | .0514 | .0343 | .0514 | .0343 | .0343 |
| 3 | .0857 | .0514 | .0686 | .0514 | .0514 | .0343 | .0343 |
| 4 | .0857 | .0514 | .0686 | .0514 | .0514 | .0343 | .0343 |
| 5 | .1029 | .0686 | | .0686 | .0514 | .0343 | .0343 |
| 6 | .12 | .0857 | .0686 | .0686 | .0686 | .0343 | |
| 7 | .12 | .0857 | .0686 | .0686 | .0686 | .0514 | .0343 |
| 8 | .0343 | .0686 | .0686 | .0686 | .0686 | .0343 | .0343 |
| 9 | .0343 | .1029 | .0686 | .0686 | .0686 | .0343 | .0343 |
| 10 | .0343 | .0343 | .0343 | .0343 | .0857 | .0686 | .0857 |
| 11 | .0343 | .0343 | .0343 | .0343 | .0857 | .0686 | .0857 |
| 12 | .0343 | .0343 | .0343 | .0343 | .12 | .0686 | .0686 |
| 13 | .0343 | .0343 | .0343 | .0343 | .0857 | .1029 | .0686 |
| 14 | .0343 | | .0343 | .0343 | .0857 | .1029 | .0857 |
| 15 | .0343 | .0343 | .0343 | .0343 | .0857 | .0857 | .0857 |
| 16 | .0343 | .0343 | .0343 | .0343 | .0857 | .0857 | .0686 |
| 17 | .0343 | .0343 | .0343 | .0343 | .0857 | .1029 | .0686 |
| 18 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 19 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 20 | .0514 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 21 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 22 | .0343 | .0343 | .0343 | .0343 | .0343 | | .0343 |
| 23 | .0514 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 24 | .0857 | .0514 | .0514 | .0514 | .0514 | .0343 | .0343 |
| Max | .12 | .1029 | .0686 | .0686 | .12 | .1029 | .0857 |
| Min | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| Avg | .0564 | .0485 | .0455 | .0436 | .0629 | .0529 | .0492 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 203 / ARNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .0514 | .1029 | .0857 | .0686 | | |
| 2 | .1715 | .0514 | .1029 | .1029 | .0686 | | |
| 3 | | .0857 | .12 | .1029 | .0686 | | |
| 4 | .1715 | .0857 | .1715 | .12 | .0686 | | |
| 5 | .1715 | .12 | .2058 | .12 | .0857 | | |
| 6 | .1715 | .12 | .2058 | .1372 | .0857 | | |
| 7 | .1715 | .1715 | .2229 | .1372 | .1029 | | |
| 8 | | .1715 | .2058 | .1543 | .1029 | | |
| 9 | | .0686 | .1372 | .1372 | .1029 | | |
| 10 | | | | | .0857 | .1029 | .0686 |
| 11 | | | | | .1029 | .12 | .0857 |
| 12 | | | | | .1372 | .1372 | .1029 |
| 13 | | | | | .1372 | .12 | .1029 |
| 14 | | | | | .1372 | .1372 | .1029 |
| 15 | | | | | .1372 | .12 | .1029 |
| 16 | | | | | .0857 | .1372 | .1029 |
| 17 | | | | | .0857 | .1029 | .1029 |
| 23 | .0343 | | | .0686 | | | |
| 24 | .1372 | .0514 | .0514 | .0514 | .0686 | | |
| Max | .1715 | .1715 | .2229 | .1543 | .1372 | .1372 | .1029 |
| Min | .0343 | .0514 | .0514 | .0514 | .0686 | .1029 | .0686 |
| Avg | .1501 | .0977 | .1526 | .1107 | .0962 | .1222 | .0965 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 204 / VADJAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .5144 | .3429 |
| 2 | | | | | .5144 | .3429 |
| 3 | | | | | .5144 | .3429 |
| 4 | | | | | .6859 | .5144 |
| 5 | | | | | .8573 | .5144 |
| 6 | | | | | .8573 | .6859 |
| 7 | | | | | .8573 | 1.0288 |
| 8 | | | | | 1.2517 | 1.1317 |
| 9 | | | | | 1.286 | 1.2003 |
| 10 | .2572 | .8573 | .8573 | .9259 | | |
| 11 | .7716 | .8573 | 1.0288 | .9945 | | |
| 12 | 1.406 | .8916 | 1.286 | 1.2003 | | |
| 13 | 1.2003 | .9259 | 1.2003 | 1.166 | | |
| 14 | 1.166 | .9259 | 1.0288 | 1.1317 | | |
| 15 | .9945 | .9431 | .9431 | 1.0288 | | |
| 16 | .823 | .9431 | .8916 | .9602 | | |
| 17 | .7716 | .9259 | .7888 | .8573 | | |
| 24 | 1.6817 | | | | .3429 | .3429 |
| Max | 1.6817 | .9431 | 1.286 | 1.2003 | 1.286 | 1.2003 |
| Min | .2572 | .8573 | .7888 | .8573 | .3429 | .3429 |
| Avg | 1.0080 | .9088 | 1.0031 | 1.0331 | .7682 | .6447 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 205 / 11 KV OM SHANTI EXP.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .1715 | .0514 | .0686 | .1029 | .0857 | .0686 |
| 2 | .2572 | .1715 | .0514 | .0686 | .1029 | .0857 | .0686 |
| 3 | .2743 | .1715 | .0514 | .0686 | .1029 | .0857 | .0686 |
| 4 | .2743 | .2058 | .0514 | .0686 | .1029 | .0857 | .0686 |
| 5 | .3086 | .2229 | .0514 | .0686 | .1029 | .1372 | .0686 |
| 6 | .3086 | .2229 | .0514 | .0857 | .1029 | .1372 | .0686 |
| 7 | .2743 | .2229 | .0514 | .0857 | .1029 | .0857 | .0686 |
| 8 | .3086 | .0514 | .12 | .1029 | .1029 | .1372 | .1029 |
| 9 | .3086 | .0514 | .1715 | .12 | .1372 | .1372 | .1372 |
| 10 | .2743 | .0343 | .1715 | .12 | .2058 | .1543 | .2401 |
| 11 | .3772 | .0343 | .1715 | .12 | .2058 | .1715 | .3429 |
| 12 | .3772 | .0514 | .1715 | .1372 | .1715 | .2058 | .3429 |
| 13 | .3429 | .0514 | .1715 | .1372 | .1715 | .2058 | .4287 |
| 14 | .3429 | .0514 | .1715 | .1372 | .1715 | .2058 | .4287 |
| 15 | .3429 | .0514 | .1715 | .1372 | .1886 | .1715 | .4287 |
| 16 | .3429 | .0514 | .1715 | .12 | .1715 | .1715 | .4287 |
| 17 | .2743 | .0514 | .2058 | .1029 | .12 | .1715 | .4287 |
| 18 | .2401 | .0514 | .2058 | .12 | .0857 | .1372 | .3429 |
| 19 | .2401 | .0514 | .1715 | .1372 | .1029 | .1372 | .3429 |
| 20 | .2401 | .0514 | .1372 | .1029 | .1029 | .1029 | .2572 |
| 21 | | .0514 | .1372 | .1029 | .1029 | .1029 | .2572 |
| 22 | .2401 | .0514 | .1372 | .0686 | .1029 | .1029 | .2572 |
| 23 | .2058 | .0514 | .12 | .1029 | .1029 | .0857 | .2572 |
| 24 | 1.8849 | .2058 | .0514 | .1029 | .1029 | .0686 | .1372 |
| Max | 1.8849 | .2229 | .2058 | .1372 | .2058 | .2058 | .4287 |
| Min | .2058 | .0343 | .0514 | .0686 | .0857 | .0686 | .0686 |
| Avg | .3600 | .0993 | .1257 | .1036 | .1279 | .1322 | .2351 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 206 / FAGANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .4287 | .4287 | .4287 | .3429 | .4287 | .4115 |
| 2 | .3429 | .4287 | .4287 | .4287 | .3429 | .4287 | .4115 |
| 3 | .3429 | .4287 | .4287 | .5144 | .3429 | .4287 | .4115 |
| 4 | .4287 | .5144 | .5144 | .5144 | .4115 | .4801 | .4801 |
| 5 | .6001 | .6859 | .6001 | .5487 | .4801 | .6859 | .583 |
| 6 | .7716 | .6859 | .6859 | .6001 | .583 | .6859 | .6516 |
| 7 | .8573 | .6859 | .7716 | .6001 | .6859 | .7202 | .6859 |
| 8 | .6859 | .6001 | .5144 | .6859 | .5144 | .5144 | .6173 |
| 9 | .4287 | .5144 | .4287 | .6859 | .4115 | .6859 | .5144 |
| 10 | .4287 | .4458 | .5144 | .5144 | .3086 | .3429 | .3429 |
| 11 | .3429 | .4458 | .5144 | .3429 | .3086 | .2743 | .3429 |
| 12 | .3429 | .4287 | .6001 | .3086 | .3429 | .2401 | .3429 |
| 13 | .3429 | .4287 | .5144 | .3429 | .3429 | .2743 | .4287 |
| 14 | .3429 | .4115 | .5144 | .3429 | .3772 | .2743 | .4287 |
| 15 | .3429 | .4287 | .4287 | .3429 | .3772 | .2401 | .4287 |
| 16 | .4115 | .4287 | .4287 | .3772 | .4287 | .2401 | .4287 |
| 17 | .4287 | .5144 | .4458 | .4115 | .4287 | .3086 | .4287 |
| 18 | .4115 | .6001 | .4458 | .4801 | .463 | .3429 | .4287 |
| 19 | .4801 | .6001 | .5144 | .5487 | .4801 | .4115 | .5144 |
| 20 | .5144 | .6001 | .5487 | .5487 | .4801 | .4801 | .6001 |
| 21 | .5144 | .5144 | .6001 | .5487 | .5144 | .4801 | .5144 |
| 22 | .5144 | .5144 | .6001 | .5487 | .4801 | .4801 | .5144 |
| 23 | .4287 | .4287 | .5144 | .4115 | .4287 | .4458 | .4287 |
| 24 | .3429 | .4287 | .4287 | .5144 | .3429 | .4287 | .4115 |
| Max | .8573 | .6859 | .7716 | .6859 | .6859 | .7202 | .6859 |
| Min | .3429 | .4115 | .4287 | .3086 | .3086 | .2401 | .3429 |
| Avg | .4580 | .5080 | .5173 | .4830 | .4258 | .4301 | .4730 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 207 / VADAJAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .5487 | .4287 | .3086 | .3772 | .3944 | .3429 |
| 2 | .3429 | .5487 | .4287 | .3429 | .3772 | .3944 | .3429 |
| 3 | .3429 | .5487 | .4287 | .3429 | .3772 | .3944 | .3429 |
| 4 | .4287 | .6001 | .5144 | .4287 | .4115 | .4287 | .4115 |
| 5 | .5144 | .6001 | .6001 | .4287 | .4458 | .6173 | .4801 |
| 6 | .6001 | .6001 | .6859 | .5144 | .4801 | .6859 | .5487 |
| 7 | .6859 | .6001 | .6859 | .6001 | .5658 | .6173 | .6344 |
| 8 | .6001 | .6001 | .6001 | .6001 | .4801 | .5144 | .6001 |
| 9 | .4287 | .3944 | .463 | .5144 | .4115 | .5144 | .5658 |
| 10 | .3429 | .3944 | .4287 | .4973 | .3944 | .4458 | .4287 |
| 11 | .3086 | .3944 | .3429 | .4801 | .3429 | .4115 | .3944 |
| 12 | .3429 | .4115 | .3086 | .463 | .4115 | .3772 | .3429 |
| 13 | .2743 | .4115 | .3429 | .4801 | .4115 | .3086 | .4287 |
| 14 | .3429 | .4115 | .3429 | .4801 | | .3086 | .5144 |
| 15 | .3772 | .4287 | .3772 | .4801 | .4287 | .3429 | .6001 |
| 16 | .3944 | .5144 | .4115 | .463 | .5144 | .3086 | .6001 |
| 17 | .4287 | .5144 | .4115 | .4458 | .5144 | .3772 | .6001 |
| 18 | .4115 | .6001 | .4458 | .4801 | .4801 | .4458 | .4287 |
| 19 | .4115 | .6001 | .5144 | .5144 | .4458 | .4801 | .5144 |
| 20 | .5144 | .5144 | .5487 | .4801 | .4801 | .5658 | .6001 |
| 21 | .5144 | .5144 | .5487 | .4801 | .4801 | .5144 | .6001 |
| 22 | .5144 | .4287 | .5144 | .463 | .4287 | .4801 | .5144 |
| 23 | .5487 | .4287 | .4801 | .4458 | .4287 | .4458 | .4287 |
| 24 | .5487 | .5487 | .4287 | .4458 | .3944 | .3944 | .3772 |
| Max | .6859 | .6001 | .6859 | .6001 | .5658 | .6859 | .6344 |
| Min | .2743 | .3944 | .3086 | .3086 | .3429 | .3086 | .3429 |
| Avg | .4401 | .5065 | .4701 | .4658 | .4384 | .4487 | .4851 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 208 / Varkheda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 2 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 3 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 4 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 5 | .0686 | .0686 | .0686 | .0514 | .0514 | .0686 | .0514 |
| 6 | .0686 | .0686 | .0686 | .0686 | .0686 | .0686 | .0514 |
| 7 | .0686 | .0686 | .0686 | .0686 | .0686 | .0686 | .0514 |
| 8 | .0686 | .0686 | .0686 | .0686 | .0686 | .0857 | .0514 |
| 9 | .0686 | .0686 | .0514 | .0686 | .0686 | .0686 | .0514 |
| 10 | .0686 | .0514 | .0514 | .0686 | .0857 | .0686 | .0857 |
| 11 | .0514 | .0514 | .0686 | .0686 | .0514 | .0686 | .0857 |
| 12 | .0857 | .0514 | .0686 | .0686 | .0686 | .0686 | .0857 |
| 13 | .0514 | .0343 | .0686 | .0857 | .0514 | .0514 | .0857 |
| 14 | .0514 | .0514 | .0686 | .0686 | .0514 | .0514 | .1029 |
| 15 | .0686 | .0514 | .0857 | .0686 | .0857 | .0514 | .1029 |
| 16 | .0686 | .0514 | .0857 | .0686 | .0857 | .0514 | .1029 |
| 17 | .0514 | .0514 | .1029 | .0514 | .1029 | .0857 | .0857 |
| 18 | .0514 | .0514 | .1029 | .0686 | .0686 | .1029 | .1029 |
| 19 | .0514 | .0686 | .0857 | .0686 | .0514 | .0857 | .1029 |
| 20 | .0514 | .0514 | .0686 | .0514 | .0514 | .0686 | .0857 |
| 21 | .0686 | .0514 | .0686 | .0514 | .0686 | .0514 | .0857 |
| 22 | .0686 | .0514 | .0686 | .0514 | .0686 | .0514 | .0686 |
| 23 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 24 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| Max | .0857 | .0686 | .1029 | .0857 | .1029 | .1029 | .1029 |
| Min | .0514 | .0343 | .0514 | .0514 | .0514 | .0514 | .0514 |
| Avg | .0600 | .0550 | .0679 | .0614 | .0636 | .0636 | .0729 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 201 / 11 KV Nimdale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7316 | | | .3201 | .0805 | |
| 2 | .6401 | | | .3201 | .0805 | |
| 3 | .5601 | | | .3201 | .0805 | |
| 4 | .5601 | | | .4801 | .0805 | |
| 5 | .6401 | | | .4801 | .0805 | |
| 6 | .6401 | | .5601 | .6401 | .0805 | |
| 7 | .8002 | | | .7202 | .0805 | |
| 8 | .5601 | .6401 | .8002 | .6401 | .0805 | .8954 |
| 9 | .5487 | .7316 | | .5601 | .0914 | |
| 10 | .0914 | | | .032 | .0914 | |
| 11 | .1097 | .1097 | .128 | .08 | 1.0974 | 1.0974 |
| 12 | | .1463 | | .128 | 1.1888 | 1.1888 |
| 13 | .1646 | .1463 | | .096 | 1.2254 | 1.0974 |
| 14 | .1829 | .1463 | | .096 | 1.1888 | 1.0059 |
| 15 | .1829 | .1646 | | .096 | 1.0974 | 1.0059 |
| 16 | | .1463 | .128 | | 1.0059 | 1.0059 |
| 17 | | .128 | .1387 | | | .1097 |
| 18 | .096 | .128 | .0867 | | | |
| 19 | | .128 | .128 | | | .128 |
| 20 | | .128 | | .1235 | | .128 |
| 21 | | | | .1463 | | |
| 22 | .112 | .1463 | | .1463 | .1235 | |
| 23 | .2401 | .1463 | .2401 | .0926 | | |
| 24 | .823 | | .3201 | | | |
| Max | .823 | .7316 | .8002 | .7202 | 1.2254 | 1.1888 |
| Min | .0914 | .1097 | .0867 | .032 | .0805 | .1097 |
| Avg | .4269 | .2168 | .2811 | .2904 | .4561 | .7662 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 202 / 11 kv INDIRA GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.287 | | | .9002 | 1.1031 | | 1.0802 |
| 2 | 1.195 | | | .9002 | .9193 | | 1.0802 |
| 3 | 1.195 | | | .9002 | .9193 | | 1.0802 |
| 4 | 1.287 | | | 1.0802 | .9193 | | 1.0802 |
| 5 | 1.287 | | | 1.0802 | 1.1031 | | 1.2603 |
| 6 | 1.4708 | | 1.4118 | 1.2603 | 1.3789 | | 1.4403 |
| 7 | 1.7466 | | | 1.5546 | 1.4708 | | 1.6204 |
| 8 | 1.5627 | 1.386 | 1.5304 | 1.5304 | 1.5627 | | 1.5304 |
| 9 | 1.4632 | 1.3717 | | 1.2536 | 1.4632 | | 1.3503 |
| 10 | 3.1007 | 1.3717 | | 1.2603 | 1.1888 | | 1.2603 |
| 11 | 1.0974 | 1.2803 | 1.0745 | 1.0802 | 1.0974 | 1.1888 | 1.0802 |
| 12 | | 1.1888 | | 1.0262 | 1.0425 | 1.0974 | 1.0802 |
| 13 | 1.0425 | 1.1888 | | 1.0802 | 1.0059 | 1.0974 | 1.0802 |
| 14 | 1.0425 | 1.0974 | | 1.0802 | | 1.0425 | 1.0802 |
| 15 | 1.0242 | 1.0974 | | 1.0802 | 1.0974 | 1.0974 | 1.0802 |
| 16 | | | 1.0745 | | 1.0974 | 1.0974 | 1.0802 |
| 17 | | | 1.0917 | | | 1.0974 | 1.1703 |
| 18 | 1.1653 | | 1.1827 | | | 1.0974 | 1.1703 |
| 19 | | | 1.4784 | | | 1.5546 | 1.2603 |
| 20 | 1.379 | 1.448 | | 1.4661 | | 1.5546 | 1.2603 |
| 21 | | | | | | | 1.4403 |
| 22 | 1.3575 | | | | 1.3432 | | |
| 23 | 1.1765 | | 1.1752 | 1.1765 | | | |
| 24 | | | 1.1458 | | | | |
| Max | 3.1007 | 1.448 | 1.5304 | 1.5546 | 1.5627 | 1.5546 | 1.6204 |
| Min | 1.0242 | 1.0974 | 1.0745 | .9002 | .9193 | 1.0425 | 1.0802 |
| Avg | 1.3822 | 1.2700 | 1.2406 | 1.1594 | 1.1695 | 1.1925 | 1.2174 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 204 / GONDUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1848 | | | .181 | .1848 | | .2715 |
| 2 | .1848 | | | .181 | .1848 | | .2715 |
| 3 | .1848 | | | .181 | .1848 | | .2715 |
| 4 | .2772 | | | .2715 | .2772 | | .2715 |
| 5 | .3696 | | | .362 | .3696 | | .3601 |
| 6 | .462 | | .6036 | .4525 | .462 | | .4525 |
| 7 | .5544 | | | .5544 | .5544 | | .4525 |
| 8 | .462 | .3696 | .362 | .4525 | .462 | | .362 |
| 9 | .3658 | .3658 | | .2715 | .5487 | | .2715 |
| 10 | .2195 | .2743 | | .2715 | .4755 | .2561 | .2715 |
| 11 | | .2378 | .2218 | .0905 | .4572 | .2743 | .3582 |
| 12 | | .2743 | | .2172 | .4572 | .2743 | .0072 |
| 13 | .2378 | .2743 | | .181 | .4572 | .2743 | .2715 |
| 14 | .2378 | .2378 | | .181 | .4572 | .2743 | .2715 |
| 15 | .2378 | .2378 | | .2715 | .4572 | .2743 | |
| 16 | | | .1848 | | .4572 | .2743 | .2715 |
| 17 | | | | | | .2743 | .2801 |
| 18 | .3696 | | .1819 | | | .2743 | .2715 |
| 19 | | | .1829 | | | .4572 | .4525 |
| 20 | .4066 | .3696 | | .3696 | | .3658 | |
| 22 | .2772 | | | | .2772 | | |
| 23 | .2402 | | .2218 | .2402 | | | |
| 24 | | | .2402 | | | | |
| Max | .5544 | .3696 | .6036 | .5544 | .5544 | .4572 | .4525 |
| Min | .1848 | .2378 | .1819 | .0905 | .1848 | .2561 | .0072 |
| Avg | .3101 | .2935 | .2749 | .2782 | .3955 | .2976 | .3022 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 403 / 33KV Incommmer (Gondur) NON SHEDDABLE EXPRESS HV FEEDERS
 from 22 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 22 | 1.2936 | | | |
| 23 | | 1.2974 | | 1.1946 |
| 24 | | | 1.2974 | |
| Max | 1.2936 | 1.2974 | 1.2974 | 1.1946 |
| Min | 1.2936 | 1.2974 | 1.2974 | 1.1946 |
| Avg | 1.2936 | 1.2974 | 1.2974 | 1.1946 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 201 / 11 KV Navlane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1457 | .1475 | .1341 | .1029 | | | |
| 2 | .1619 | .1638 | .1341 | .1029 | | | |
| 3 | .1943 | .1989 | .1677 | .1715 | | | |
| 4 | .2267 | .218 | .1715 | .2058 | | | |
| 5 | .2515 | .2374 | .2058 | .2401 | | | |
| 6 | .3856 | .3856 | .2743 | .2835 | | | |
| 7 | .5721 | .5316 | .5144 | .4908 | | | |
| 8 | .5087 | .6706 | .57 | .5765 | | | |
| 9 | .426 | .3932 | .4641 | .5304 | | | |
| 10 | | | | | .192 | .1492 | .1581 |
| 11 | | | | | .3647 | .4915 | .4752 |
| 12 | | | | | .6962 | .5079 | .5735 |
| 13 | | | | | .6554 | .6062 | .5407 |
| 14 | | | | | .5735 | .5898 | .4372 |
| 15 | | | | | .4424 | .4915 | .4049 |
| 16 | | | | | .4752 | .4588 | .3041 |
| 17 | | | | | .3725 | .4001 | .25 |
| 24 | .0819 | .0829 | .1029 | .0983 | | | |
| Max | .5721 | .6706 | .57 | .5765 | .6962 | .6062 | .5735 |
| Min | .0819 | .0829 | .1029 | .0983 | .192 | .1492 | .1581 |
| Avg | .2954 | .3030 | .2739 | .2803 | .4715 | .4619 | .3930 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 202 / MEHERGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1296 | .1475 | .1341 | .1372 | .2195 | .1387 | .1341 |
| 2 | .1457 | .1638 | .1341 | .1715 | .2743 | .1578 | .1341 |
| 3 | .1943 | .1989 | .2012 | .2058 | .362 | .1543 | .1341 |
| 4 | .2429 | .2515 | .3429 | .2572 | .4525 | .1696 | .1715 |
| 5 | .3185 | .3052 | .4287 | .2915 | .5014 | .298 | .4287 |
| 6 | .5083 | .5959 | .5487 | .567 | .5552 | .5493 | .4801 |
| 7 | .6068 | .5658 | .5658 | .5083 | .567 | .6024 | .5658 |
| 8 | .4578 | .4024 | .3856 | .407 | .4115 | .3944 | .4458 |
| 9 | .2949 | .2785 | .2984 | .2652 | .2683 | .2321 | .3086 |
| 10 | .2155 | .218 | .1802 | .1677 | .208 | .1492 | .1739 |
| 11 | .1844 | .1526 | .1509 | .1865 | .116 | .1147 | .1147 |
| 12 | .1526 | .1357 | .1174 | .1357 | .0995 | .0983 | .1311 |
| 13 | .1174 | .1357 | .0995 | .1006 | .1147 | .0983 | .1147 |
| 14 | .1147 | .1341 | .0983 | .1006 | .1311 | .0983 | .1134 |
| 15 | .1174 | .1341 | .1326 | .116 | .1475 | .0983 | .0972 |
| 16 | .1341 | .1509 | .1326 | .1341 | .1475 | .1147 | .112 |
| 17 | .2347 | .1677 | .1475 | .1509 | .1943 | .128 | .1094 |
| 18 | .4108 | .2715 | .2801 | .2561 | .2561 | .2172 | .2715 |
| 19 | .4527 | .4668 | .4108 | .3921 | .4024 | .4481 | .4108 |
| 20 | .2801 | .3174 | .2801 | .2614 | .2772 | .3734 | .3018 |
| 21 | .2033 | .2054 | .1848 | .2033 | .2033 | .2241 | .1867 |
| 22 | .1867 | .168 | .1663 | .1848 | .1829 | .1867 | .1848 |
| 23 | .1663 | .1372 | .1478 | .1848 | .1646 | .1867 | .1478 |
| 24 | .1311 | .1326 | .1372 | .1311 | .1478 | | .1494 |
| Max | .6068 | .5959 | .5658 | .567 | .567 | .6024 | .5658 |
| Min | .1147 | .1326 | .0983 | .1006 | .0995 | .0983 | .0972 |
| Avg | .2500 | .2432 | .2377 | .2299 | .2669 | .2275 | .2259 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 203 / 11 KV Deshmukhwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4049 | .3277 | .1677 | .2058 | | | |
| 2 | .4534 | .3605 | .1677 | .2058 | | | |
| 3 | .4858 | .3812 | .1677 | .2572 | | | |
| 4 | .4858 | .4191 | .2572 | .2743 | | | |
| 5 | .5197 | .4578 | .3086 | .2915 | | | |
| 6 | .4557 | .5609 | .3429 | .3366 | | | |
| 7 | .7282 | .823 | .6859 | .6485 | | | |
| 8 | .6443 | .8048 | .8048 | .6783 | | | |
| 9 | .6062 | .5407 | .6962 | .5967 | | | |
| 10 | | | | | .2401 | .2486 | .3163 |
| 11 | | | | | .6299 | .6882 | .6718 |
| 12 | | | | | .8288 | .4915 | .8356 |
| 13 | | | | | .7701 | .852 | .7373 |
| 14 | | | | | .7537 | .7701 | .7125 |
| 15 | | | | | .7209 | .7537 | .6154 |
| 16 | | | | | .7373 | .6882 | .5441 |
| 17 | | | | | .6154 | .6401 | .4999 |
| 24 | .2785 | .2035 | .1715 | .1966 | | | |
| Max | .7282 | .823 | .8048 | .6783 | .8288 | .852 | .8356 |
| Min | .2785 | .2035 | .1677 | .1966 | .2401 | .2486 | .3163 |
| Avg | .5063 | .4879 | .3770 | .3691 | .6620 | .6416 | .6166 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 204 / 11 Kv Tilenagar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4858 | .4915 | .2012 | .5487 | 1.0059 | *** | .7545 |
| 2 | .5182 | .5243 | .2515 | .6001 | 1.0974 | 1.0867 | .8048 |
| 3 | .5668 | .5801 | .3018 | | 1.1765 | 1.0288 | .8383 |
| 4 | .6154 | .6539 | .3086 | .8402 | 1.267 | 1.1022 | 1.0288 |
| 5 | .8215 | .8478 | .3429 | .8745 | 1.2894 | 1.3146 | 1.3717 |
| 6 | | | | | 1.379 | 1.5769 | 1.7147 |
| 7 | | | | | 1.5415 | 1.8604 | 1.989 |
| 8 | .6274 | .6706 | .6036 | .5426 | 1.6461 | 2.1434 | 2.1776 |
| 9 | .6882 | .3932 | .6299 | .6133 | 1.5089 | 1.8399 | 2.1434 |
| 10 | 1.4752 | 1.1736 | .9831 | 1.291 | .3681 | .4475 | .4111 |
| 11 | 2.3304 | 2.2552 | 2.1795 | 2.0008 | .3647 | .3768 | .3605 |
| 12 | 2.3739 | 2.4417 | 2.3807 | 2.2382 | .3647 | .3441 | .4588 |
| 13 | 2.4478 | 2.1704 | 2.3205 | 2.1795 | .3605 | .3441 | .3441 |
| 14 | 1.3108 | 2.0454 | 1.9334 | 1.9281 | .4424 | .3768 | .4049 |
| 15 | 1.9951 | 2.0119 | 1.9559 | 1.8399 | .4424 | .4096 | .4049 |
| 16 | 1.8442 | 1.8275 | 1.8233 | 1.861 | .426 | .4096 | .4321 |
| 17 | 1.7772 | 1.576 | 1.5729 | 1.7101 | .4534 | .4001 | .4062 |
| 18 | .6535 | .543 | .5415 | .823 | .5487 | .5068 | .543 |
| 19 | .8676 | .8589 | .8029 | .7655 | .823 | .7842 | .8029 |
| 20 | .8402 | .8215 | .8775 | .7842 | .7762 | .8029 | .8488 |
| 21 | .7577 | .7842 | .7762 | .7577 | .7392 | .7655 | .7842 |
| 22 | .7095 | .7095 | .7207 | .6468 | .6401 | .7095 | .7023 |
| 23 | .6468 | .6001 | .6283 | .5544 | .5853 | .7468 | .5544 |
| 24 | 2.1385 | .547 | .5487 | .5243 | .5729 | .8488 | .8402 |
| Max | 2.4478 | 2.4417 | 2.3807 | 2.2382 | 1.6461 | 10.8358 | 2.1776 |
| Min | .4858 | .3932 | .2012 | .5243 | .3605 | .3441 | .3441 |
| Avg | 1.2042 | 1.1149 | 1.0311 | 1.1392 | .8258 | 1.2942 | .8801 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 201 / 11 KV Vadel AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8573 | .4877 | .4001 | .3734 | | | |
| 2 | .8916 | .4572 | .4001 | .3734 | | | |
| 3 | .9259 | .4877 | .4001 | .4268 | .0171 | | |
| 4 | .9945 | .5792 | .4534 | .4668 | | | |
| 5 | 1.0288 | .8535 | .5601 | .5601 | | | |
| 6 | 1.3546 | 1.0974 | .7735 | .6535 | | | |
| 7 | 1.5089 | 1.2955 | 1.0936 | .9602 | | | |
| 8 | 1.2174 | 1.2193 | 1.0936 | 1.0002 | | | |
| 9 | 1.1145 | 1.0364 | .9602 | .5735 | | | |
| 10 | | | | | .6859 | .5792 | .3201 |
| 11 | | | | | 1.406 | 1.2803 | 1.1203 |
| 12 | | | | | 1.3717 | 1.0974 | 1.2269 |
| 13 | | | | | 1.2689 | 1.0669 | 1.1203 |
| 14 | | | | | 1.1317 | 1.0364 | 1.0669 |
| 15 | | | | | 1.166 | 1.0364 | .9602 |
| 16 | | | | | 1.1317 | 1.0974 | .9202 |
| 17 | | | | | .9602 | 1.1584 | .8802 |
| 24 | .3467 | .4801 | .4268 | .3467 | | | |
| Max | 1.5089 | 1.2955 | 1.0936 | 1.0002 | 1.406 | 1.2803 | 1.2269 |
| Min | .3467 | .4572 | .4001 | .3467 | .0171 | .5792 | .3201 |
| Avg | 1.0240 | .7994 | .6562 | .5735 | 1.0155 | 1.0441 | .9519 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 202 / 11 KV Dhamane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4458 | .3658 | .3467 | .2934 | | | |
| 2 | .4973 | .3048 | .3467 | .4287 | | | |
| 3 | .4973 | .3353 | .3467 | .3601 | | | |
| 4 | .4973 | .3048 | .3467 | .3601 | | | |
| 5 | .4801 | .3353 | .3734 | .3734 | | | |
| 6 | .5144 | .4572 | .3734 | .3868 | | | |
| 7 | .6173 | .5487 | .4668 | .3868 | | | |
| 8 | .583 | .4877 | .4668 | .4134 | | | |
| 9 | .4458 | .4877 | .4534 | .4801 | | | |
| 10 | | | | | .4458 | .381 | .2667 |
| 11 | | | | | .6859 | .5487 | .4801 |
| 12 | | | | | .6859 | .5792 | .5335 |
| 13 | | | | | .6859 | .6097 | .5335 |
| 14 | | | | | .6859 | .6401 | .5335 |
| 15 | | | | | .6173 | .5792 | .5335 |
| 16 | | | | | .6516 | .5792 | .5068 |
| 17 | | | | | .583 | .6401 | .4934 |
| 24 | .3067 | .4115 | .3658 | .2801 | | | |
| Max | .6173 | .5487 | .4668 | .4801 | .6859 | .6401 | .5335 |
| Min | .3067 | .3048 | .3467 | .2801 | .4458 | .381 | .2667 |
| Avg | .4885 | .4039 | .3886 | .3763 | .6302 | .5697 | .4851 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 203 / Govinda Gas Ex. Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 2 | | .0171 | .0152 | .0171 | | .9088 | .0171 |
| 3 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 4 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 5 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 6 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 7 | | .0171 | .1067 | .0171 | .0171 | .0171 | .0171 |
| 8 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 9 | | .0171 | .0152 | .0171 | .0171 | .0152 | .0171 |
| 10 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 11 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 12 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 13 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 14 | .0171 | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 15 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 16 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 17 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 18 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 19 | | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 20 | .0171 | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 21 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 22 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 23 | .0171 | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 24 | .0152 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 |
| Max | .0171 | .0171 | .1067 | .0171 | .0171 | .9088 | .0171 |
| Min | .0152 | .0171 | .0133 | .0133 | .0171 | .0152 | .0171 |
| Avg | .0170 | .0171 | .0189 | .0169 | .0171 | .0542 | .0171 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 204 / Ex. Jay Laxmi Fiber Ltd.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 2 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 3 | | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 4 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 5 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 6 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 7 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 8 | .0171 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| 9 | | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 10 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 11 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 12 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 13 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 14 | .0171 | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 15 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 16 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 17 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 18 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 19 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 20 | .0171 | .0171 | .0152 | .0171 | | .0171 | .0171 |
| 21 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| 22 | | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 23 | .0171 | .0171 | .0152 | .0171 | .0171 | .0171 | .0171 |
| 24 | .0152 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| Max | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| Min | .0152 | .0171 | .0133 | .0171 | .0171 | .0171 | .0171 |
| Avg | .0170 | .0171 | .0150 | .0171 | .0171 | .0171 | .0171 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 205 / 11 KV Dhamane Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1029 | .1029 | .1067 | .1029 | .1029 | .12 | .12 |
| 2 | .1029 | .1029 | .1067 | .1029 | .1029 | .12 | .12 |
| 3 | .1029 | .12 | .1067 | .12 | .0171 | .12 | .12 |
| 4 | .12 | .12 | .1372 | .1372 | .0171 | .12 | .1372 |
| 5 | .1372 | .1715 | .1677 | .1372 | .1372 | .1543 | .1543 |
| 6 | | .2058 | .1829 | .1543 | .1715 | .1715 | .1715 |
| 7 | .1715 | .1715 | .1524 | .1715 | .1715 | .1715 | .1715 |
| 8 | .1372 | .1543 | .1334 | .1543 | .1543 | .1715 | .1543 |
| 9 | .1029 | .1372 | .1067 | .1372 | .1372 | .1372 | .1029 |
| 10 | | .12 | .1067 | .1029 | .12 | .12 | .1029 |
| 11 | .12 | .12 | .0914 | .1029 | .12 | .12 | .12 |
| 12 | .12 | .12 | .0914 | .0686 | .12 | .1029 | .12 |
| 13 | .1029 | .12 | .0914 | .0686 | .12 | .1029 | .12 |
| 14 | | .12 | .0914 | .1029 | .12 | .1029 | .12 |
| 15 | .12 | .12 | .0914 | .12 | .12 | .1029 | .12 |
| 16 | .12 | .12 | .1067 | .12 | .12 | .1029 | .1029 |
| 17 | | .12 | .1067 | .12 | .12 | .12 | .1029 |
| 18 | .1372 | .1372 | .0914 | .1372 | .12 | .1886 | .1029 |
| 19 | .1715 | .1715 | .1067 | .1543 | .1715 | .12 | .1029 |
| 20 | | .1543 | .1067 | .1715 | .1715 | .1543 | .1715 |
| 21 | .12 | .1372 | .0914 | .1543 | .1372 | .1543 | .1543 |
| 22 | .12 | .1372 | .0914 | .12 | .1372 | .1715 | .1372 |
| 23 | .12 | .1372 | .0914 | .12 | .12 | .1543 | .1372 |
| 24 | .1067 | .0171 | .1372 | .08 | .1029 | .12 | .1543 |
| Max | .1715 | .2058 | .1829 | .1715 | .1715 | .1886 | .1715 |
| Min | .1029 | .0171 | .0914 | .0686 | .0171 | .1029 | .1029 |
| Avg | .1229 | .1307 | .1122 | .1234 | .1222 | .1343 | .1300 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 206 / 11 Kv Gangamai Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .3086 | .2743 | .3086 | .3429 | .3086 | .3086 |
| 2 | .3086 | .3086 | .2743 | .3772 | .3429 | .3086 | .3086 |
| 3 | .3086 | .3086 | .2743 | .463 | .3429 | .3086 | .3086 |
| 4 | .3258 | .3429 | .2896 | .4973 | | .3429 | .3772 |
| 5 | .4115 | .4115 | .5182 | .6001 | .4801 | .3772 | .5487 |
| 6 | .5144 | .5487 | .6401 | .6859 | .7545 | .5487 | .6859 |
| 7 | .7716 | .6859 | .7011 | .7716 | .7716 | .6859 | .7888 |
| 8 | .583 | .5487 | .5487 | .6173 | .6173 | .6173 | .6173 |
| 9 | .4801 | .4801 | .4115 | .4801 | .4115 | .5144 | .463 |
| 10 | .4115 | .4458 | .3353 | .3429 | .4115 | .3601 | .4115 |
| 11 | .3429 | .4115 | .2743 | .3429 | .3429 | .3086 | .3086 |
| 12 | .2743 | .3772 | .2439 | .3086 | .3429 | .2743 | .3086 |
| 13 | .2743 | .3772 | .2286 | .2743 | .3429 | .2743 | .3086 |
| 14 | .2743 | .3429 | .2743 | .3086 | .3429 | .3086 | .3429 |
| 15 | .2743 | .3772 | .2743 | .3086 | .3429 | .3258 | .3772 |
| 16 | .2743 | .3429 | .2896 | .3429 | .3429 | .3429 | .3429 |
| 17 | .2743 | .3772 | .2896 | .3429 | .3429 | .3772 | .3772 |
| 18 | .3086 | .4115 | .3201 | .4115 | .4115 | .4115 | .3772 |
| 19 | .6173 | .5144 | .3658 | .4115 | .4801 | .4801 | .4801 |
| 20 | .5144 | .4801 | .3963 | .4458 | .4458 | .4973 | .4115 |
| 21 | | .3944 | .3353 | .3772 | .3772 | .4287 | .3772 |
| 22 | .4115 | .3601 | .2896 | .3429 | .3429 | .3601 | .3429 |
| 23 | .3429 | .3429 | .3086 | .3086 | .3429 | .3258 | .3429 |
| 24 | .2743 | .3429 | .3086 | .2743 | .3086 | .3086 | .3258 |
| Max | .7716 | .6859 | .7011 | .7716 | .7716 | .6859 | .7888 |
| Min | .2743 | .3086 | .2286 | .2743 | .3086 | .2743 | .3086 |
| Avg | .3861 | .4101 | .3528 | .4144 | .4167 | .3915 | .4101 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 201 / 11 KV saitale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.4434 | | | | 1.307 | 1.1145 | 1.086 |
| 2 | 2.4434 | | | | 1.587 | 1.2003 | 1.267 |
| 3 | 2.4434 | | | | 2.0538 | 1.286 | 1.3575 |
| 4 | 2.4434 | | | | 2.4272 | 1.4575 | 1.6118 |
| 5 | 2.4434 | | | | 2.5873 | 1.5432 | 1.7718 |
| 6 | 2.4434 | | | | 2.6797 | 1.7147 | 2.2786 |
| 7 | 2.4434 | | | | 2.4025 | 2.2291 | 2.3148 |
| 8 | 2.4434 | | | | 2.4691 | 2.2291 | 2.4006 |
| 9 | | | | 1.9004 | 2.2291 | | 2.4863 |
| 10 | 1.2003 | 1.4632 | 1.0974 | 1.6289 | | | |
| 11 | 2.572 | 2.1262 | 2.1491 | 2.5339 | | | |
| 12 | 2.8292 | 2.392 | 2.2148 | 2.9235 | | | |
| 13 | 2.8292 | 2.7149 | 2.2148 | 2.8006 | | | |
| 14 | 2.572 | 2.5968 | 2.191 | 2.7435 | | | |
| 15 | 2.6578 | 2.4177 | 1.97 | 2.6139 | | | |
| 16 | 2.7435 | 2.1719 | 1.9004 | 2.3577 | | | |
| 17 | 2.2291 | 2.0119 | 1.9204 | 2.2862 | | | |
| 18 | | | | 2.2862 | | | |
| 19 | | | | 2.2862 | | | |
| 20 | | | | 2.2862 | | | |
| 21 | | | | 2.2862 | | | |
| 22 | | | | 2.2862 | | | |
| 23 | | | | 2.2862 | | | |
| 24 | | | | | 1.2012 | 1.1145 | .924 |
| Max | 2.8292 | 2.7149 | 2.2148 | 2.9235 | 2.6797 | 2.2291 | 2.4863 |
| Min | 1.2003 | 1.4632 | 1.0974 | 1.6289 | 1.2012 | 1.1145 | .924 |
| Avg | 2.4488 | 2.2368 | 1.9572 | 2.3671 | 2.0944 | 1.5432 | 1.7498 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 202 / 11KV Rudane Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6032 | 1.3717 | 1.3717 | 1.4327 | 1.97 | |
| 2 | 1.8861 | 1.3717 | 1.4632 | 1.4022 | 1.97 | |
| 3 | 2.0748 | 1.4575 | 1.4175 | 1.5775 | 1.97 | |
| 4 | 2.2634 | 1.5432 | 1.5947 | 1.6651 | 1.97 | |
| 5 | 2.4272 | 1.6289 | 1.6651 | 1.7147 | 1.97 | |
| 6 | 2.5206 | 1.7147 | 1.7147 | 1.8004 | 1.97 | |
| 7 | 2.3577 | 1.8004 | 1.8861 | 2.0576 | 1.97 | |
| 8 | 2.0748 | 1.6289 | 2.0157 | 1.7528 | 1.97 | |
| 9 | 1.8861 | 1.267 | 2.0595 | 1.7013 | | |
| 10 | | | | 1.7013 | 1.6289 | 1.3717 |
| 11 | | | | 1.7013 | 2.2291 | 2.3777 |
| 12 | | | | 1.7013 | 2.3148 | 2.2291 |
| 13 | | | | 1.7013 | 2.1434 | 2.0576 |
| 14 | | | | 1.7013 | 1.9719 | 1.8204 |
| 15 | | | | 1.7013 | 2.2291 | 2.191 |
| 16 | | | | 1.7013 | | 1.4327 |
| 17 | | | | 1.7013 | 2.1434 | 1.6461 |
| 18 | | | | 1.7013 | 1.5432 | |
| 19 | | | | 1.7013 | | |
| 20 | | | | 1.7013 | | |
| 21 | | | | 1.7013 | | |
| 22 | | | | 1.7013 | | |
| 23 | | | | 1.7375 | | |
| 24 | 1.6032 | 1.0288 | 1.2012 | 1.2012 | 1.97 | |
| Max | 2.5206 | 1.8004 | 2.0595 | 2.0576 | 2.3148 | 2.3777 |
| Min | 1.6032 | 1.0288 | 1.2012 | 1.2012 | 1.5432 | 1.3717 |
| Avg | 2.0697 | 1.4813 | 1.6389 | 1.6733 | 1.9961 | 1.8908 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 203 / 11 kV Lamkani AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.3577 | 1.7147 | 1.6461 | 1.97 | |
| 2 | 2.452 | 1.7147 | 1.829 | 1.9281 | 2.6863 |
| 3 | 2.5463 | 2.0576 | 1.949 | 2.1033 | 2.6863 |
| 4 | 2.6406 | 2.2291 | 2.1262 | 2.1033 | 2.6863 |
| 5 | 2.8006 | 2.2291 | 2.3663 | 2.2291 | 2.6863 |
| 6 | 2.9874 | 2.4006 | 2.4006 | 2.3148 | 2.6863 |
| 7 | 2.9235 | 2.572 | 2.4863 | 2.7168 | 2.6863 |
| 8 | 2.6406 | 2.572 | 2.8045 | 2.7168 | 2.6863 |
| 9 | 2.572 | 2.6244 | 2.8654 | 2.6863 | |
| 10 | | | | 2.6863 | 2.0576 |
| 11 | | | | 2.6863 | 2.915 |
| 12 | | | | 2.6863 | 3.0007 |
| 13 | | | | 2.6863 | 2.8292 |
| 14 | | | | 2.6863 | 2.7435 |
| 15 | | | | 2.6863 | 2.6578 |
| 16 | | | | 2.6863 | |
| 17 | | | | 2.6863 | 2.8921 |
| 18 | | | | 2.6863 | |
| 19 | | | | 2.6863 | |
| 20 | | | | 2.6863 | |
| 21 | | | | 2.7435 | |
| 22 | | | | 2.7435 | |
| 23 | | | | 2.6863 | |
| 24 | 2.3577 | 1.6289 | 1.386 | 1.7556 | |
| Max | 2.9874 | 2.6244 | 2.8654 | 2.7435 | 3.0007 |
| Min | 2.3577 | 1.6289 | 1.386 | 1.7556 | 2.0576 |
| Avg | 2.6278 | 2.1743 | 2.1859 | 2.5103 | 2.7071 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 204 / 11 KV Lamkani Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4715 | .4287 | .4572 | .4477 | .3696 | .543 |
| 2 | .4715 | .4287 | .4207 | .4382 | .3734 | .543 |
| 3 | .4715 | .6001 | .5316 | .5258 | .5601 | .7164 |
| 4 | .6602 | .7716 | .6201 | .6135 | .6535 | .8059 |
| 5 | 1.0269 | .8573 | .7888 | .6859 | .924 | .9745 |
| 6 | 1.2136 | | .8573 | .8573 | 1.2012 | 1.0631 |
| 7 | .8488 | .9431 | 1.0288 | .8573 | 1.0164 | .8764 |
| 8 | .6602 | .6859 | .8764 | .8764 | .823 | .7011 |
| 9 | .6001 | .5487 | .8059 | .8059 | .6001 | |
| 10 | .6001 | .5487 | .7316 | .8145 | .5144 | |
| 11 | .5144 | .5316 | .5373 | .543 | .5144 | |
| 12 | .5144 | .5316 | .5316 | .5658 | .5144 | |
| 13 | .4287 | .5373 | .5316 | .5601 | .4287 | |
| 14 | .4287 | .4525 | .5258 | .5487 | .4287 | |
| 15 | .5144 | .5373 | .5373 | .5601 | .4287 | |
| 16 | .6001 | .543 | .6335 | .5658 | .4382 | |
| 17 | .7716 | .6401 | .6401 | .6401 | .6135 | |
| 18 | .7716 | .7316 | .7468 | .763 | .8145 | |
| 19 | .7716 | .9145 | .9335 | .7316 | .905 | |
| 20 | .6001 | .6468 | .7468 | .6401 | .6401 | |
| 21 | .5144 | .5544 | .6602 | .543 | .5544 | |
| 22 | .4287 | .4668 | .5658 | .4477 | .5487 | |
| 23 | .4287 | .4668 | .4668 | .462 | .4572 | |
| 24 | .3734 | .4287 | .462 | .462 | | .4572 |
| Max | 1.2136 | .9431 | 1.0288 | .8764 | 1.2012 | 1.0631 |
| Min | .3734 | .4287 | .4207 | .4382 | .3696 | .4572 |
| Avg | .6119 | .5998 | .6516 | .6231 | .6227 | .7423 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 201 / 11KV NEW KAPDANE GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .3948 | .4115 | .3582 | .3772 | .4115 |
| 2 | .3429 | .4307 | .4115 | .3582 | .3772 | .4115 |
| 3 | .3429 | .5167 | .4115 | .3582 | .4801 | .4115 |
| 4 | .4115 | .6545 | .4287 | .394 | .6516 | .4287 |
| 5 | .6173 | .7733 | .6001 | .4124 | .7716 | .6001 |
| 6 | .6859 | .7561 | .7373 | .5155 | .7545 | .7545 |
| 7 | .7202 | .7218 | .7716 | .6874 | .703 | .6859 |
| 8 | .5487 | .5339 | .4287 | .4812 | .6173 | .5658 |
| 9 | .5014 | .5144 | .4287 | .4298 | .4287 | .4287 |
| 10 | .4656 | .4287 | .4458 | .4298 | .4287 | .3772 |
| 11 | .4656 | .4287 | .3772 | .394 | .3772 | .3772 |
| 12 | .4298 | .4115 | .3429 | .3582 | .3944 | .3772 |
| 13 | .4298 | .4115 | .3772 | .3582 | .4115 | .3944 |
| 14 | .4656 | .4115 | .4115 | .394 | .4115 | .4287 |
| 15 | .5014 | .4115 | .3772 | .394 | .463 | .3944 |
| 16 | .5014 | .4115 | .3772 | .4298 | .4458 | .3944 |
| 17 | .4812 | .4287 | .3772 | | .4458 | .4458 |
| 18 | .5499 | .463 | .4458 | | | .463 |
| 19 | .653 | .6001 | .5144 | | | .5487 |
| 20 | .6874 | .6859 | .4801 | | | .4973 |
| 21 | .6187 | .6516 | .4458 | | | .4458 |
| 22 | .5167 | .5144 | .4115 | | | .4287 |
| 23 | .4822 | .4115 | .4115 | | | .4115 |
| 24 | .3429 | .4298 | .4115 | .4298 | .4115 | .3772 |
| Max | .7202 | .7733 | .7716 | .6874 | .7716 | .7545 |
| Min | .3429 | .3948 | .3429 | .3582 | .3772 | .3772 |
| Avg | .5044 | .5165 | .4515 | .4225 | .4973 | .4608 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 202 / 11KV NEW KAPDANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 1.1084 | .7133 | .743 |
| 2 | | | | 1.0749 | .9945 | .743 |
| 3 | | | | 1.0749 | .8916 | .743 |
| 4 | | | | 1.0749 | | .8173 |
| 5 | | | | .9726 | 1.0402 | .8916 |
| 6 | | | | 1.0223 | 1.1145 | .8916 |
| 7 | | | | 1.0761 | 1.1888 | .9659 |
| 8 | | | | 1.0492 | 1.2631 | .8916 |
| 9 | .878 | | | 1.0252 | 1.0402 | 1.1145 |
| 10 | 1.0117 | .9659 | 1.2003 | | | |
| 11 | 1.1465 | 1.0402 | 1.2346 | | | |
| 12 | 1.2106 | 1.0402 | | | | |
| 13 | 1.1433 | 1.1145 | | | | |
| 14 | 1.0761 | 1.0402 | | | | |
| 15 | 1.0477 | 1.0402 | | | | |
| 16 | 1.0031 | .8916 | | | | |
| 17 | | .743 | | | | |
| 24 | | | | 1.0791 | .5647 | .8173 |
| Max | 1.2106 | 1.1145 | 1.2346 | 1.1084 | 1.2631 | 1.1145 |
| Min | .878 | .743 | 1.2003 | .9726 | .5647 | .743 |
| Avg | 1.0646 | .9845 | 1.2175 | 1.0558 | .9790 | .8619 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 203 / 11KV DHANUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7833 | .9456 | 1.6347 | 1.5432 | | | |
| 2 | 1.7147 | 1.0521 | 1.6347 | 1.3375 | | | |
| 3 | 1.749 | 1.1465 | 1.7833 | 1.3375 | | | |
| 4 | 1.749 | 1.3182 | 1.7833 | 1.4861 | | | |
| 5 | 1.7147 | 1.4796 | 1.8576 | 1.4861 | | | |
| 6 | 1.8176 | 1.5468 | 1.9319 | 1.5604 | | | |
| 7 | 1.7833 | 1.5737 | 1.9319 | 1.709 | | | |
| 8 | | 1.4754 | 1.9319 | | | | |
| 9 | | | 1.6766 | | | | |
| 10 | | | | | 1.2157 | 1.6347 | .1412 |
| 11 | | | | | 1.4796 | 1.9319 | 1.6347 |
| 12 | | | | | 1.5468 | 1.7981 | 1.709 |
| 13 | | | | | 1.6049 | 1.9319 | 1.709 |
| 14 | | | | | 1.6049 | 1.709 | 1.709 |
| 15 | | | | | 1.6718 | 1.6347 | 1.5604 |
| 16 | | | | | 1.6049 | 1.7387 | 1.6347 |
| 17 | | | | | | 1.6049 | 1.6347 |
| 24 | 1.749 | 1.0006 | 1.4861 | 1.0402 | | | |
| Max | 1.8176 | 1.5737 | 1.9319 | 1.709 | 1.6718 | 1.9319 | 1.709 |
| Min | 1.7147 | .9456 | 1.4861 | 1.0402 | 1.2157 | 1.6049 | .1412 |
| Avg | 1.7576 | 1.2821 | 1.7652 | 1.4375 | 1.5327 | 1.7480 | 1.4666 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 201 / 11 KV Vadane Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .3772 | .373 | .3605 |
| 2 | | | | | .3772 | .4409 | .4588 |
| 3 | | | | | .4115 | .4409 | .4915 |
| 4 | | | | | .4801 | .4748 | .5079 |
| 5 | | | | | .5487 | .4917 | .5571 |
| 6 | | | | | .5487 | .5256 | .6226 |
| 7 | | | | | .6001 | .6104 | .639 |
| 8 | | | | | .6859 | .7461 | .6554 |
| 9 | | | | | .6859 | .3605 | .7202 |
| 10 | .4917 | .4752 | .5144 | | | | |
| 11 | .6443 | .7045 | .6173 | | | | |
| 12 | .78 | .7045 | .6173 | | | | |
| 13 | .763 | .7045 | .6001 | | | | |
| 14 | .7291 | .7373 | .7202 | | | | |
| 15 | .6952 | .7701 | .7545 | | 1.8313 | | |
| 16 | .6783 | .7537 | .7373 | | | | |
| 17 | .6613 | .6226 | .7716 | | | | |
| 23 | | | | .3258 | | | |
| 24 | | | | | .3429 | .3391 | .3277 |
| Max | .78 | .7701 | .7716 | .3258 | 1.8313 | .7461 | .7202 |
| Min | .4917 | .4752 | .5144 | .3258 | .3429 | .3391 | .3277 |
| Avg | .6804 | .6841 | .6666 | .3258 | .6263 | .4803 | .5341 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 202 / 11 KV Burzad Single

SINGLE PHASING

Phasing. Feeder KV- 11 /

OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.17 | 1.1191 | 1.1142 | 1.2174 | | | |
| 2 | 1.2378 | 1.3904 | 1.3763 | 1.2517 | | | |
| 3 | 1.3904 | 1.8143 | 1.6712 | 1.3717 | | | |
| 4 | 1.4922 | 1.95 | 1.7695 | 1.6804 | | | |
| 5 | 1.8652 | 2.0687 | 1.8351 | 1.7147 | | | |
| 6 | 1.95 | 2.0178 | 1.8679 | 1.749 | | | |
| 7 | 1.9161 | 1.8821 | 1.8679 | 1.7833 | | | |
| 8 | 1.6787 | 1.6956 | 1.8519 | 1.6975 | | | |
| 9 | 1.4752 | 1.8143 | 1.8004 | | | | |
| 10 | | | | | 1.0174 | 1.3108 | 1.1317 |
| 11 | | | | | 1.6617 | 1.8187 | 1.8519 |
| 12 | | | | | 1.8652 | 1.9006 | 1.9204 |
| 13 | | | | | 1.933 | 1.8023 | 1.989 |
| 14 | | | | | 1.8991 | 1.7695 | 1.9719 |
| 15 | | | | | 1.8313 | 1.7695 | 2.0062 |
| 16 | | | | | 1.6448 | 1.7695 | 1.7833 |
| 17 | | | | | 1.5939 | 1.7532 | 1.749 |
| 24 | 1.0682 | .8139 | .8029 | .8402 | | | |
| Max | 1.95 | 2.0687 | 1.8679 | 1.7833 | 1.933 | 1.9006 | 2.0062 |
| Min | 1.0682 | .8139 | .8029 | .8402 | 1.0174 | 1.3108 | 1.1317 |
| Avg | 1.5244 | 1.6566 | 1.5957 | 1.4784 | 1.6808 | 1.7368 | 1.8004 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 203 / 11 KV Burzad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3222 | | .1966 | .1715 | .1715 | .2035 | .1966 |
| 2 | .3391 | .2374 | .1966 | .1715 | .1715 | .2035 | .1966 |
| 3 | .3391 | .2374 | .1966 | .2058 | .2401 | | .1966 |
| 4 | .373 | .2713 | .2622 | .2572 | .3086 | .2374 | .2294 |
| 5 | .39 | .2883 | .2949 | .3258 | .3429 | .2713 | .2949 |
| 6 | .4409 | .3222 | .3605 | .3772 | .3258 | .3561 | .3441 |
| 7 | .4578 | .3391 | .3113 | .3429 | .2229 | .2949 | .3932 |
| 8 | .3391 | .2713 | .2915 | .2229 | .1372 | .2458 | .2785 |
| 9 | .3052 | .2622 | .2743 | | .12 | .1802 | .2058 |
| 10 | .1696 | .1802 | .1886 | | .1187 | .1638 | .1715 |
| 11 | .1526 | .1802 | .1715 | | .1187 | .1475 | .1886 |
| 12 | .1526 | .1638 | .0154 | | .1017 | .1475 | .1886 |
| 13 | .1696 | .1311 | .1543 | | .1187 | .1475 | .1715 |
| 14 | | .1311 | .1372 | | .1357 | .1311 | .1715 |
| 15 | .1526 | .1311 | .1372 | | .1696 | .1311 | .1886 |
| 16 | .1696 | .1802 | .1372 | | .1696 | .1475 | .1886 |
| 17 | .1865 | .1966 | .1372 | | .1696 | .1638 | .1543 |
| 18 | .2883 | .213 | .1715 | | .2035 | .1966 | .2229 |
| 19 | .2883 | .2622 | .2743 | | .1865 | .2622 | .2915 |
| 20 | .2543 | .2458 | .2572 | | .1865 | .2294 | .2572 |
| 21 | .2035 | .2267 | .2401 | | .2035 | .213 | .2401 |
| 22 | .1696 | .1966 | .2058 | .2058 | .2035 | .1966 | .2401 |
| 23 | .1696 | .1966 | .1715 | .1715 | .2374 | .1966 | .2058 |
| 24 | .2883 | .1696 | .1966 | .1715 | .1715 | .2035 | .1943 |
| Max | .4578 | .3391 | .3605 | .3772 | .3429 | .3561 | .3932 |
| Min | .1526 | .1311 | .0154 | .1715 | .1017 | .1311 | .1543 |
| Avg | .2661 | .2189 | .2075 | .2385 | .1890 | .2031 | .2255 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467] BU 0467

Substation No/ Name :- 094064 / 33/11 KV Burzad Stn

Feeder No / Name : 406 / 33KV Incommmer (Burzad)
from 22 Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 07-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .3441 |
| Max | .3441 |
| Min | .3441 |
| Avg | .3441 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 201 / VANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3567 | .3239 | .3241 | .3593 | | | |
| 2 | .3269 | .3887 | .3241 | .3637 | | | |
| 3 | .3269 | .4534 | .3281 | .3637 | | | |
| 4 | .3269 | .4696 | .3281 | .3637 | | | |
| 5 | .3567 | .4858 | .3841 | .3637 | | | |
| 6 | .3864 | .502 | .3841 | .3637 | | | |
| 7 | .503 | .4696 | .426 | .4534 | | | |
| 8 | | .4534 | .3005 | .4268 | | | |
| 9 | | | .427 | .4572 | | | |
| 10 | | | | | .3963 | .4024 | .3605 |
| 11 | | | | | .5792 | .5596 | .5243 |
| 12 | | | | | .5792 | .5533 | .5571 |
| 13 | | | | | .5487 | .4858 | .5243 |
| 14 | | | | | .4725 | .5087 | .5079 |
| 15 | | | | | .503 | .5087 | .5079 |
| 16 | | | | | .3506 | .5426 | .5079 |
| 17 | | | | | .4694 | .4409 | .5079 |
| 24 | 1.2226 | .3077 | .2743 | .2709 | | | |
| Max | 1.2226 | .502 | .427 | .4572 | .5792 | .5596 | .5571 |
| Min | .3269 | .3077 | .2743 | .2709 | .3506 | .4024 | .3605 |
| Avg | .4758 | .4282 | .3500 | .3786 | .4874 | .5003 | .4997 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 202 / Verkhedi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2035 | .2204 | .2378 | .2427 | .2204 | .1696 | .181 |
| 2 | .2035 | .2035 | .2378 | .2012 | .2204 | .1696 | .181 |
| 3 | .2204 | .2035 | .2378 | .2012 | .2204 | .1696 | .181 |
| 4 | .2035 | .2204 | .2987 | .2427 | .2204 | .2035 | .2172 |
| 5 | .3052 | .2713 | .3361 | .3361 | .3052 | .2543 | .2896 |
| 6 | .373 | .3391 | .3921 | .4108 | .3391 | .373 | .3982 |
| 7 | .4239 | .407 | .5415 | .5041 | .407 | .4239 | .4163 |
| 8 | .3391 | .3391 | .3561 | .3982 | .3391 | .39 | .3077 |
| 9 | .1865 | .2543 | .2543 | .2896 | .2534 | .2035 | .3258 |
| 10 | .1865 | .2374 | .2204 | .1448 | .181 | .2035 | .2294 |
| 11 | .1865 | .2561 | | .1448 | .181 | .1526 | .1296 |
| 12 | .1696 | .2561 | | .1448 | .2172 | .1526 | .1296 |
| 13 | .1696 | .2378 | .2204 | .1629 | .1991 | .1696 | .1715 |
| 14 | .1696 | .2378 | .2035 | .181 | .1991 | .1696 | .2172 |
| 15 | .1865 | .2561 | .2035 | .1991 | .181 | .1526 | .2353 |
| 16 | .1865 | .2378 | .2035 | .1865 | .181 | .1696 | .2534 |
| 17 | .2035 | .2378 | .2035 | .2204 | .2035 | | .2896 |
| 18 | .2374 | .2561 | .2035 | .2543 | .2035 | .2374 | .2353 |
| 19 | .3052 | .2987 | .2374 | .3052 | .2035 | .2543 | .2715 |
| 20 | .3391 | .2801 | .2801 | .3391 | .2713 | .2543 | .2896 |
| 21 | .3561 | .2801 | .3174 | .2713 | .3052 | .2715 | .3077 |
| 22 | .2035 | .2801 | .2801 | .2204 | .2374 | .2353 | .3077 |
| 23 | .2204 | .2801 | .2801 | .2204 | .2035 | .2172 | .2896 |
| 24 | .4477 | .2204 | .2614 | .2427 | .2204 | .1865 | .2715 |
| Max | .4477 | .407 | .5415 | .5041 | .407 | .4239 | .4163 |
| Min | .1696 | .2035 | .2035 | .1448 | .181 | .1526 | .1296 |
| Avg | .2511 | .2630 | .2730 | .2527 | .2380 | .2254 | .2553 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&M DHULE[467]

BU 0467

Substation No/ Name :- 094069 / 33/11 KV Varkhede

Feeder No / Name : 203 / 11 Varkheda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3688 | .3429 | .2932 | .2439 | | | |
| 2 | .3521 | .3772 | .2932 | .2469 | | | |
| 3 | .3521 | .3944 | .3163 | .2469 | | | |
| 4 | .3353 | .3944 | .3201 | .3125 | | | |
| 5 | .3521 | .3944 | .3163 | | | | |
| 6 | .3521 | .3944 | .3768 | .3321 | | | |
| 7 | .4578 | .3944 | .431 | .4534 | | | |
| 8 | | .3944 | .4372 | .4572 | | | |
| 9 | | .3772 | .1781 | .4115 | | | |
| 10 | | | | | .3963 | .4748 | .426 |
| 11 | | | | | .6097 | .6478 | .5735 |
| 12 | | | | | .6249 | | .6226 |
| 13 | | | | | .5792 | .6478 | .6062 |
| 14 | | | | | .5639 | .5668 | .5898 |
| 15 | | | | | .5792 | .5668 | .5898 |
| 16 | | | | | .381 | .5182 | .5735 |
| 17 | | | | | .5243 | .5506 | .5571 |
| 24 | 1.4737 | .3258 | .2591 | .1829 | | | |
| Max | 1.4737 | .3944 | .4372 | .4572 | .6249 | .6478 | .6226 |
| Min | .3353 | .3258 | .1781 | .1829 | .381 | .4748 | .426 |
| Avg | .5055 | .3790 | .3221 | .3208 | .5323 | .5675 | .5673 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 201 / 11KV DEOPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0288 | 1.1145 | 1.0288 | 1.0288 | 1.1145 | 1.1145 | 1.0288 |
| 2 | .9431 | 1.0288 | .9431 | .9431 | 1.0288 | 1.0288 | 1.0288 |
| 3 | .9431 | 1.0288 | .9431 | .9431 | 1.0288 | 1.0288 | 1.0288 |
| 4 | 1.0288 | 1.0288 | .9431 | .9431 | 1.0288 | 1.0288 | 1.0288 |
| 5 | 1.0288 | 1.0288 | .9431 | .9431 | 1.1145 | 1.0288 | 1.0288 |
| 6 | 1.166 | 1.0288 | 1.2003 | 1.0288 | 1.286 | 1.2003 | 1.3375 |
| 7 | 1.3717 | 1.2003 | 1.3717 | 1.2003 | 1.5432 | 1.4575 | 1.4575 |
| 8 | 1.3717 | 1.3375 | 1.0288 | 1.286 | 1.4575 | 1.4575 | 1.4575 |
| 9 | 1.286 | 1.2003 | 1.2003 | 1.286 | 1.3717 | 1.286 | 1.4232 |
| 10 | | 1.286 | 1.2003 | 1.286 | 1.2003 | 1.2003 | 1.0288 |
| 11 | 1.2003 | 1.286 | 1.1145 | 1.2003 | 1.1145 | 1.2003 | 1.2003 |
| 12 | 1.2003 | 1.2003 | 1.1145 | 1.1145 | 1.1145 | 1.2003 | 1.2003 |
| 13 | 1.0288 | 1.2003 | 1.2003 | 1.0288 | 1.1145 | 1.1145 | 1.2003 |
| 14 | 1.0288 | 1.1145 | 1.1145 | .9431 | 1.1145 | 1.1145 | 1.286 |
| 15 | 1.0288 | 1.0288 | 1.1145 | .9431 | 1.1145 | 1.1145 | 1.2003 |
| 16 | 1.0288 | 1.0288 | 1.0288 | .8573 | 1.1145 | 1.1145 | 1.2003 |
| 17 | | 1.0288 | 1.1145 | .9431 | 1.1145 | 1.1145 | 1.1145 |
| 18 | 1.1145 | 1.0288 | 1.2003 | 1.0288 | 1.1145 | 1.2003 | 1.286 |
| 19 | 1.286 | 1.3717 | 1.4575 | 1.286 | 1.3717 | 1.3717 | 1.4575 |
| 20 | 1.286 | 1.3717 | 1.4575 | 1.3717 | 1.4575 | 1.4575 | 1.286 |
| 21 | 1.3717 | 1.286 | 1.3717 | 1.3717 | 1.4575 | 1.3717 | 1.4575 |
| 22 | 1.286 | 1.286 | 1.286 | 1.286 | 1.3717 | 1.3717 | 1.4575 |
| 23 | 1.2003 | 1.1145 | 1.2003 | 1.286 | 1.286 | 1.286 | 1.3717 |
| 24 | 1.1145 | 1.2003 | 1.0288 | 1.1145 | 1.1145 | 1.1145 | 1.1145 |
| Max | 1.3717 | 1.3717 | 1.4575 | 1.3717 | 1.5432 | 1.4575 | 1.4575 |
| Min | .9431 | 1.0288 | .9431 | .8573 | 1.0288 | 1.0288 | 1.0288 |
| Avg | 1.1519 | 1.1595 | 1.1503 | 1.1110 | 1.2145 | 1.2074 | 1.2367 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 202 / 11KV PAROLA ROAD (OLD)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .0514 | .0514 | .0762 |
| 2 | | | | | .0514 | .0686 | .0914 |
| 3 | | | | | .0514 | .0686 | .0914 |
| 4 | | | | | .0514 | .1029 | .0914 |
| 5 | | | | | .0686 | .12 | .1067 |
| 6 | | | | | .1029 | .1372 | .1219 |
| 7 | | | | | .12 | .1543 | .1677 |
| 8 | | | | | .1543 | .1886 | .2134 |
| 9 | | | | | .1543 | .2229 | .2229 |
| 10 | .1524 | .12 | .2058 | .1372 | | | |
| 11 | .2915 | .2058 | .2743 | .3258 | | | |
| 12 | .3429 | .2401 | .3086 | .2915 | | | |
| 13 | .3086 | .2572 | .3086 | .3429 | | | |
| 14 | .3086 | .2572 | .2915 | .2915 | | | |
| 15 | .3086 | .2743 | .3086 | .3086 | | | |
| 16 | .3086 | .2743 | .3258 | .3086 | | | |
| 17 | .3086 | .2572 | .2743 | .3258 | | | |
| 24 | | | | | .0514 | .0514 | .0457 |
| Max | .3429 | .2743 | .3258 | .3429 | .1543 | .2229 | .2229 |
| Min | .1524 | .12 | .2058 | .1372 | .0514 | .0514 | .0457 |
| Avg | .2912 | .2358 | .2872 | .2915 | .0857 | .1166 | .1229 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 204 / 11 KV VIDYANAGARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | 1.2003 | 1.2003 | 1.1145 | 1.3717 | 1.286 | 1.2003 |
| 2 | 1.2003 | 1.2003 | 1.1145 | 1.1145 | 1.2003 | 1.2003 | 1.2003 |
| 3 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.2003 | 1.2003 | 1.2003 |
| 4 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.2003 | 1.2003 | 1.2003 |
| 5 | 1.1145 | 1.2003 | 1.2003 | 1.1145 | 1.2003 | 1.2003 | 1.286 |
| 6 | 1.2346 | 1.1145 | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.4918 |
| 7 | 1.3717 | 1.2003 | 1.5432 | 1.3717 | 1.4575 | 1.3717 | 1.6289 |
| 8 | 1.3717 | 1.2003 | 1.4575 | 1.3717 | 1.3717 | 1.3717 | 1.5432 |
| 9 | 1.2003 | 1.2003 | 1.286 | 1.286 | 1.2003 | 1.2003 | 1.3717 |
| 10 | 1.1145 | 1.1145 | 1.1145 | 1.2003 | 1.1145 | 1.0288 | 1.286 |
| 11 | 1.0288 | 1.1145 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.2003 |
| 12 | 1.1145 | 1.2003 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.1145 |
| 13 | 1.1145 | 1.1145 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.2003 |
| 14 | 1.1145 | 1.1145 | 1.1145 | 1.2003 | 1.1145 | 1.1145 | 1.1145 |
| 15 | 1.2003 | 1.1145 | 1.1145 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| 16 | 1.2003 | 1.1145 | 1.2003 | 1.2003 | 1.2003 | 1.1145 | 1.2003 |
| 17 | 1.2003 | 1.1145 | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| 18 | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.286 | 1.2003 |
| 19 | 1.4575 | 1.4575 | 1.6289 | 1.9719 | 1.5432 | 1.5432 | 1.6289 |
| 20 | 1.4575 | 1.5432 | 1.6289 | 1.7147 | 1.5432 | 1.5432 | 1.6289 |
| 21 | 1.5432 | 1.4575 | 1.5432 | 1.6289 | 1.5432 | 1.5432 | 1.6289 |
| 22 | 1.5432 | 1.4575 | 1.4575 | 1.6289 | 1.5432 | 1.5432 | 1.6289 |
| 23 | 1.3717 | 1.286 | 1.3717 | 1.4575 | 1.4575 | 1.4575 | 1.5432 |
| 24 | 1.2003 | 1.286 | 1.2003 | 1.286 | 1.3717 | 1.286 | 1.286 |
| Max | 1.5432 | 1.5432 | 1.6289 | 1.9719 | 1.5432 | 1.5432 | 1.6289 |
| Min | 1.0288 | 1.1145 | 1.1145 | 1.1145 | 1.1145 | 1.0288 | 1.1145 |
| Avg | 1.2410 | 1.2253 | 1.2717 | 1.3110 | 1.2896 | 1.2681 | 1.3410 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 206 / 11 KV EKVIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | | .6859 | .6859 | .6859 | .6859 | .6859 |
| 2 | .6859 | .6859 | .6001 | .6001 | .6859 | .6859 | .6859 |
| 3 | .6859 | .6859 | .6001 | .6001 | .6859 | .6859 | .6859 |
| 4 | .6859 | .6859 | .6001 | .6001 | .6859 | .6859 | .6859 |
| 5 | .7716 | .6859 | .6001 | .6001 | .7716 | .6859 | .6859 |
| 6 | .823 | .6859 | .7716 | .6859 | .8573 | .6859 | .7716 |
| 7 | .8916 | .8573 | .8573 | .7716 | .9431 | .9431 | .9431 |
| 8 | 1.0288 | .9431 | .8573 | .9431 | 1.0288 | 1.0288 | .9945 |
| 9 | 1.0288 | 1.0288 | .8573 | .9431 | 1.1145 | 1.0288 | 1.0288 |
| 10 | .9431 | 1.2003 | .8573 | .9431 | .9431 | 1.0288 | .9431 |
| 11 | .8573 | 1.286 | .7716 | 1.0288 | .8573 | .9431 | 1.0288 |
| 12 | .9431 | 1.286 | .7716 | 1.0288 | .9431 | .8573 | .8573 |
| 13 | .8573 | 1.2003 | .8573 | .9431 | .9431 | .8573 | .8573 |
| 14 | .8573 | .8573 | .6859 | .6859 | .8573 | .7716 | .7716 |
| 15 | .8573 | .6859 | .6859 | .6859 | .7716 | .7716 | .6859 |
| 16 | .8573 | .6859 | .6859 | .6859 | .7716 | .7716 | .7716 |
| 17 | .8573 | .6859 | .7716 | .6859 | .7716 | .7716 | .7716 |
| 18 | .8573 | | .7716 | .7716 | .9431 | .8573 | .7716 |
| 19 | 1.0288 | .8573 | .9431 | .9431 | 1.0288 | 1.0288 | |
| 20 | 1.1145 | .9431 | 1.0288 | .8573 | 1.0288 | 1.0288 | 1.0288 |
| 21 | .9431 | .8573 | .8573 | .9431 | .9431 | .9431 | .9431 |
| 22 | .8573 | .7716 | .8573 | .8573 | .8573 | .9431 | .8573 |
| 23 | .7716 | .6859 | .7716 | .7716 | .7716 | .7716 | .7716 |
| 24 | .6859 | .6859 | .6859 | .6859 | .6859 | .6859 | .6859 |
| Max | 1.1145 | 1.286 | 1.0288 | 1.0288 | 1.1145 | 1.0288 | 1.0288 |
| Min | .6859 | .6859 | .6001 | .6001 | .6859 | .6859 | .6859 |
| Avg | .8573 | .8612 | .7680 | .7895 | .8573 | .8395 | .8223 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 210 / 11 KV JAIHIND COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7716 | .7716 | .8573 | .8573 | .8573 | .8573 | .7716 |
| 2 | .7716 | .7716 | .7716 | .7716 | .7716 | .7716 | .7716 |
| 3 | .7716 | .7888 | .7716 | .7716 | .7716 | .7716 | .7716 |
| 4 | .7716 | .7716 | .7716 | .7716 | .8573 | .7716 | .7716 |
| 5 | .8573 | .7716 | .7716 | .7716 | .8573 | .8573 | .8573 |
| 6 | .9431 | .7716 | .8573 | .8573 | .9431 | .8573 | .8916 |
| 7 | .9431 | .8573 | .8573 | .8573 | 1.0288 | 1.0288 | .9945 |
| 8 | 1.0288 | .9431 | .9431 | .9431 | .8573 | 1.0288 | .8916 |
| 9 | .9088 | .9431 | .8573 | .8573 | .9431 | 1.0288 | .9088 |
| 10 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 |
| 11 | .8573 | .8573 | .8573 | .8573 | .7716 | .8573 | .8573 |
| 12 | .8573 | .8573 | .8573 | .8573 | .7716 | .9431 | .8573 |
| 13 | .7716 | .8573 | .7716 | .7716 | .7716 | .8573 | .8573 |
| 14 | .7716 | .7716 | .7716 | .6859 | .7716 | .823 | .7716 |
| 15 | .8573 | .7716 | .7716 | .6859 | .8573 | .8573 | .8573 |
| 16 | .8573 | .7716 | .7716 | .7716 | .8573 | .8573 | .8573 |
| 17 | .8573 | .6859 | .8573 | .7716 | .7716 | .8573 | .8573 |
| 18 | .9431 | .7716 | .8573 | .8573 | .9431 | .8573 | .9431 |
| 19 | 1.1145 | 1.0288 | 1.0288 | 1.0288 | 1.2003 | 1.1145 | 1.1145 |
| 20 | 1.0288 | 1.1145 | 1.2003 | 1.0288 | 1.2003 | 1.1145 | 1.0288 |
| 21 | 1.0288 | 1.0288 | 1.0288 | 1.0288 | 1.0288 | 1.1145 | 1.1145 |
| 22 | 1.0288 | .9431 | 1.0288 | .9431 | 1.0288 | 1.0288 | 1.0288 |
| 23 | .9431 | .8573 | .9431 | .9431 | .9431 | .9431 | .9431 |
| 24 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 |
| Max | 1.1145 | 1.1145 | 1.2003 | 1.0288 | 1.2003 | 1.1145 | 1.1145 |
| Min | .7716 | .6859 | .7716 | .6859 | .7716 | .7716 | .7716 |
| Avg | .8916 | .8509 | .8716 | .8502 | .8966 | .9130 | .8930 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 211 / ITI EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 2 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 3 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 4 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 5 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 6 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 7 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 8 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| 9 | .0305 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 10 | .0305 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 11 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 12 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 13 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 14 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 15 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 16 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 17 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 18 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 19 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 20 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 | .0343 |
| 21 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 22 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 23 | .0343 | .0343 | .0343 | .0343 | | .0343 | .0343 |
| 24 | .0305 | .0343 | .0343 | .0343 | .0343 | .0343 | .0305 |
| Max | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| Min | .0305 | .0343 | .0343 | .0343 | .0343 | .0305 | .0305 |
| Avg | .0329 | .0343 | .0343 | .0343 | .0343 | .0327 | .0330 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 242 / 11KV INCOMER II

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 7.9733 | 8.2305 | 8.2305 | 8.2305 | 9.6194 | 10.1338 | 9.465 |
| 2 | 7.7161 | 7.9733 | 7.4074 | 7.4074 | 9.105 | 9.4136 | 9.7737 |
| 3 | 7.7161 | 7.9733 | 7.4074 | 7.4589 | 9.3622 | 9.5165 | 9.7737 |
| 4 | 7.9733 | 7.9733 | 7.5103 | 7.5103 | 9.9794 | 9.8766 | 9.8251 |
| 5 | 8.642 | 8.0761 | 7.6132 | 7.6132 | 10.8539 | 9.9794 | 10.1852 |
| 6 | 9.6708 | 8.3848 | 9.3622 | 8.5391 | 12.3971 | 11.5226 | 12.1914 |
| 7 | 10.4424 | 9.6708 | 10.2366 | 9.4136 | 14.0947 | 14.1461 | 14.249 |
| 8 | 10.8539 | 10.1852 | 9.2593 | 10.2881 | 13.6831 | 14.8663 | 14.1461 |
| 9 | 10.2881 | 10.0823 | 9.2593 | 9.8766 | 14.0432 | 9.8766 | 13.8375 |
| 10 | 12.0371 | 12.6029 | 11.5226 | 11.6255 | 9.5165 | 9.7222 | 8.9506 |
| 11 | 13.1687 | 14.4548 | 12.0885 | 13.1687 | 8.6934 | 9.465 | 9.7737 |
| 12 | 13.786 | 14.249 | 12.7058 | 13.2716 | 8.8992 | 9.4136 | 9.2593 |
| 13 | 12.6543 | 13.9918 | 12.8601 | 12.7058 | 8.9506 | 8.8992 | 9.3622 |
| 14 | 12.6543 | 12.5 | 11.7799 | 11.2654 | 8.6934 | 8.642 | 8.9506 |
| 15 | 12.7058 | 11.7799 | 11.9342 | 11.2654 | 8.7449 | 8.7449 | 8.7449 |
| 16 | 12.6029 | 11.5226 | 11.8313 | 11.3169 | 8.8477 | 8.7963 | 9.0021 |
| 17 | 12.3457 | 11.3169 | | 11.4712 | 8.4877 | 8.7449 | 8.6934 |
| 18 | 9.465 | 8.2305 | 8.9506 | 8.5391 | 9.5165 | 9.2593 | 9.465 |
| 19 | 11.0082 | 10.4424 | 10.9568 | 10.4424 | 11.3683 | 11.1626 | 11.1626 |
| 20 | 10.9054 | 10.8539 | 11.677 | 10.391 | 11.4712 | 11.4198 | 10.6996 |
| 21 | 10.6482 | 10.0823 | 10.3395 | 10.6482 | 10.8539 | 10.9054 | 11.1111 |
| 22 | 10.0309 | 9.5679 | 10.0823 | 9.8251 | 10.3395 | 10.5967 | 10.5967 |
| 23 | 9.2593 | 8.4877 | 9.2593 | 9.5165 | 9.5165 | 9.6194 | 9.8251 |
| 24 | 8.4877 | 8.7449 | 8.2305 | 8.4877 | 9.6194 | 10.1338 | 9.8766 |
| Max | 13.786 | 14.4548 | 12.8601 | 13.2716 | 14.0947 | 14.8663 | 14.249 |
| Min | 7.7161 | 7.9733 | 7.4074 | 7.4074 | 8.4877 | 8.642 | 8.6934 |
| Avg | 10.5431 | 10.3074 | 10.0219 | 10.0116 | 10.2774 | 10.2024 | 10.3717 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 243 / 11 KV INCOMER III

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.0288 |
| Max | 1.0288 |
| Min | 1.0288 |
| Avg | 1.0288 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 421 / 33 KV DEOPUR (I/C)

Feeder KV- 33 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.5432 |
| Max | 1.5432 |
| Min | 1.5432 |
| Avg | 1.5432 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 424 / 33 KV UMRAONAGAR (O/G)
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2346 | 1.2346 | 1.286 | 1.286 | 1.286 | | 1.286 |
| 2 | 1.2346 | 1.1831 | 1.2346 | 1.2346 | 1.2346 | 1.2346 | 1.2346 |
| 3 | 1.1831 | 1.1831 | 1.1831 | 1.2346 | 1.1831 | 1.1831 | 1.2346 |
| 4 | 1.1831 | | 1.1831 | 1.286 | 1.2346 | 1.1831 | 1.1831 |
| 5 | 1.2346 | 1.1831 | 1.1831 | 1.3375 | 1.3375 | 1.1831 | 1.2346 |
| 6 | 1.286 | 1.1831 | 1.3889 | 1.4918 | 1.3889 | 1.286 | 1.4403 |
| 7 | 1.4918 | 1.286 | 1.5432 | 1.5947 | 1.4403 | 1.4918 | 1.5432 |
| 8 | 1.4918 | 1.3375 | 1.4403 | 1.4918 | 1.3889 | 1.3375 | 1.5432 |
| 9 | 1.286 | 1.3375 | 1.3375 | 1.4918 | 1.286 | 1.2346 | 1.4403 |
| 10 | 1.1831 | 1.2346 | 1.1831 | 1.286 | 1.1831 | 1.1831 | 1.286 |
| 11 | 1.1317 | 1.2346 | 1.1317 | 1.0802 | 1.0802 | 1.1317 | 1.1831 |
| 12 | 1.0802 | 1.1831 | 1.0802 | 1.1317 | .9774 | 1.0802 | 1.1317 |
| 13 | 1.0802 | 1.1831 | .9774 | 1.1317 | 1.0802 | 1.0802 | 1.1831 |
| 14 | 1.0288 | 1.1831 | 1.0802 | 1.1317 | 1.0288 | .6173 | 1.1831 |
| 15 | 1.1317 | 1.1831 | 1.1317 | 1.1317 | 1.0802 | 1.0802 | 1.2346 |
| 16 | 1.1317 | 1.1317 | 1.0802 | 1.1831 | 1.0802 | 1.0802 | 1.1317 |
| 17 | 1.1831 | 1.1317 | 1.0802 | 1.1831 | 1.1831 | 1.1831 | 1.1831 |
| 18 | 1.286 | 1.2346 | 1.1317 | 1.2346 | 1.2346 | 1.2346 | 1.2346 |
| 19 | 1.5432 | 1.4918 | 1.4918 | 1.3889 | 1.4403 | 1.4403 | 1.3889 |
| 20 | 1.5432 | 1.6461 | 1.5947 | 1.5947 | 1.5947 | 1.5947 | 1.5947 |
| 21 | 1.5947 | 1.5947 | 1.5947 | 1.5947 | 1.5947 | 1.5947 | 1.6461 |
| 22 | 1.5947 | 1.5947 | 1.5432 | 1.5947 | 1.5432 | 1.5947 | 1.6461 |
| 23 | 1.3889 | 1.4403 | 1.4403 | 1.4918 | 1.4918 | 1.4918 | 1.5432 |
| 24 | 1.286 | 1.286 | 1.286 | 1.286 | 1.286 | 1.286 | 1.3375 |
| Max | 1.5947 | 1.6461 | 1.5947 | 1.5947 | 1.5947 | 1.5947 | 1.6461 |
| Min | 1.0288 | 1.1317 | .9774 | 1.0802 | .9774 | .6173 | 1.1317 |
| Avg | 1.2839 | 1.2905 | 1.2753 | 1.3289 | 1.2774 | 1.2525 | 1.3353 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 201 / 11 KV PAROLA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .7621 | | .8764 | .8764 |
| 4 | | | .6478 | .8402 | .9145 | |
| 6 | | | .8002 | | .9145 | |
| 8 | | .823 | .8764 | .8916 | .9526 | 1.1431 |
| 10 | | | 1.0669 | | .9526 | |
| 12 | .1715 | | .9907 | .8745 | .8383 | .8383 |
| 13 | | | | .8745 | | |
| 14 | | | .8002 | | | |
| 16 | | .6859 | .9145 | .9259 | | 1.0288 |
| 18 | | | 1.1431 | | | |
| 20 | | | 1.105 | .9602 | .9945 | .9945 |
| 23 | | .7545 | .8764 | .8916 | | 1.2689 |
| 24 | .6859 | .7888 | .8383 | .7888 | .9526 | 1.105 |
| Max | .6859 | .823 | 1.1431 | .9602 | .9945 | 1.2689 |
| Min | .1715 | .6859 | .6478 | .7888 | .8383 | .8383 |
| Avg | .4287 | .7631 | .9018 | .8809 | .9245 | 1.0364 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 202 / 11 KV VADJAI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | 1.3336 | | 2.8959 | |
| 4 | | | 1.5242 | 2.3491 | 2.934 | 2.2862 |
| 6 | | | 1.8671 | | 3.0483 | |
| 8 | | 1.9204 | 1.9814 | 2.0919 | 3.2388 | 3.0483 |
| 10 | | | 4.0009 | | 4.3439 | |
| 12 | | | 3.6199 | 3.7551 | 4.382 | 4.1914 |
| 14 | | | 3.5056 | | | |
| 16 | | 2.0576 | 3.7723 | 3.4294 | | 3.5437 |
| 18 | | | 4.0009 | | | |
| 20 | | | 3.3913 | 3.5322 | 3.8066 | 3.8923 |
| 23 | | 1.3717 | | 2.6063 | | 2.6578 |
| 24 | 1.8861 | 2.4006 | 1.4861 | 2.6063 | 3.0102 | 2.8959 |
| Max | 1.8861 | 2.4006 | 4.0009 | 3.7551 | 4.382 | 4.1914 |
| Min | 1.8861 | 1.3717 | 1.3336 | 2.0919 | 2.8959 | 2.2862 |
| Avg | 1.8861 | 1.9376 | 2.7712 | 2.9100 | 3.4575 | 3.2165 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 204 / 11 KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------------|--------------|--------------|--------------|--------------|--------------|--------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | .0762 | |
| 4 | | | .0762 | .0686 | .0762 | .0762 |
| 6 | | | | | .0762 | |
| 8 | | .0343 | .0762 | .0686 | .0762 | .0762 |
| 10 | | | | | .0762 | |
| 12 | | | .0762 | .0686 | .0762 | .0762 |
| 16 | | .0343 | .0762 | .0686 | | .0762 |
| 20 | | | .0762 | .0686 | .1372 | .0686 |
| 23 | | .0343 | .0762 | .0686 | | .0686 |
| 24 | .0343 | | .0762 | .0514 | .0762 | .0762 |
| Max | .0343 | .0343 | .0762 | .0686 | .1372 | .0762 |
| Min | .0343 | .0343 | .0762 | .0514 | .0762 | .0686 |
| Avg | .0343 | .0343 | .0762 | .0661 | .0838 | .0740 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 205 / Microtower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------------|--------------|--------------|--------------|--------------|--------------|--------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | .0762 | |
| 4 | | | .0762 | .0686 | .0762 | .0762 |
| 6 | | | | | .0762 | |
| 8 | | .1372 | .1905 | .1372 | .1905 | .0762 |
| 10 | | | | | .1905 | |
| 12 | | | .2286 | .1886 | .1905 | .0762 |
| 16 | | .1029 | .2286 | .1715 | | .0762 |
| 20 | | | .2286 | .1372 | .1372 | .1372 |
| 23 | .0343 | .0686 | .0762 | .0686 | | .0686 |
| 24 | .0343 | .0343 | .0762 | .0514 | .0762 | .0762 |
| Max | .0343 | .1372 | .2286 | .1886 | .1905 | .1372 |
| Min | .0343 | .0343 | .0762 | .0514 | .0762 | .0686 |
| Avg | .0343 | .0858 | .1578 | .1176 | .1267 | .0838 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 206 / ABHAY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .9526 | | 2.1338 | |
| 4 | | | 1.2574 | 1.8519 | 2.0957 | 1.829 |
| 6 | | | 1.4861 | | 2.1719 | |
| 8 | | 1.6804 | 1.6766 | 1.6804 | 2.2862 | 2.0957 |
| 10 | | | 2.934 | | 2.5149 | |
| 12 | | | 2.934 | 2.692 | 2.934 | 3.0483 |
| 14 | | | 2.0957 | | | |
| 16 | | 1.2346 | 2.7435 | 2.4006 | | 3.0483 |
| 18 | | | 2.0957 | | | |
| 20 | | | 2.0195 | 2.692 | 2.8292 | 3.1893 |
| 23 | | 1.1317 | 1.9814 | 1.9719 | | 2.1434 |
| 24 | 1.5432 | 1.989 | 1.1431 | 1.9204 | 2.2862 | 2.2862 |
| Max | 1.5432 | 1.989 | 2.934 | 2.692 | 2.934 | 3.1893 |
| Min | 1.5432 | 1.1317 | .9526 | 1.6804 | 2.0957 | 1.829 |
| Avg | 1.5432 | 1.5089 | 1.9433 | 2.1727 | 2.4065 | 2.5200 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 207 / KABIRGANJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | .6478 | |
| 4 | | | .5716 | .6687 | .6859 | .7621 |
| 6 | | | | | .8383 | |
| 8 | | .7888 | .8002 | .7888 | .9526 | .9526 |
| 10 | | | .9907 | | 1.0288 | |
| 12 | | | .8764 | .8745 | .9907 | .9526 |
| 14 | | | .6859 | | | |
| 16 | | .6859 | .7621 | .7202 | | .9907 |
| 18 | | | .9145 | | | |
| 20 | | | .9526 | .9259 | .9259 | 1.0117 |
| 23 | | .6173 | .7621 | .7202 | | .6859 |
| 24 | .4801 | .6173 | .6287 | .6344 | .6859 | .8383 |
| Max | .4801 | .7888 | .9907 | .9259 | 1.0288 | 1.0117 |
| Min | .4801 | .6173 | .5716 | .6344 | .6478 | .6859 |
| Avg | .4801 | .6773 | .7945 | .7618 | .8445 | .8848 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 208 / 11KV OLD DHULE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------------|--------------|---------------|---------------|---------------|---------------|---------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | .8383 | |
| 4 | | | .7621 | .8916 | .8764 | 1.1431 |
| 6 | | | | | 1.105 | |
| 8 | | 1.1317 | 1.3336 | 1.3889 | 1.5242 | |
| 10 | | | 1.1431 | | 1.3336 | |
| 12 | | | .8764 | .8059 | .9526 | |
| 14 | | | .6859 | | | |
| 16 | | .7888 | .8002 | .7888 | | |
| 18 | | | 1.0288 | | | |
| 20 | | | 1.105 | 1.0288 | 1.0974 | 1.0802 |
| 23 | | .7888 | .9526 | .8916 | | .7888 |
| 24 | .6859 | .7202 | .8383 | .7545 | .8383 | .9907 |
| Max | .6859 | 1.1317 | 1.3336 | 1.3889 | 1.5242 | 1.1431 |
| Min | .6859 | .7202 | .6859 | .7545 | .8383 | .7888 |
| Avg | .6859 | .8574 | .9526 | .9357 | 1.0707 | 1.0007 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 209 / NATRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | .9526 | |
| 4 | | | .7621 | .8402 | 1.0288 | |
| 6 | | | | | 1.2193 | |
| 8 | | .7888 | 1.0669 | .8402 | 1.3336 | |
| 10 | | | 1.2574 | | 1.6766 | |
| 12 | | | 1.4861 | 1.3375 | 1.448 | 1.166 |
| 14 | | | 1.1812 | | | |
| 16 | | 1.0288 | 1.4098 | 1.2174 | | 1.2003 |
| 18 | | | 1.448 | | | |
| 20 | | | 1.2574 | 1.3032 | 1.3546 | 1.286 |
| 23 | | .7545 | 1.0288 | .9259 | | .9602 |
| 24 | .6859 | .8916 | .8383 | .8573 | 1.105 | |
| Max | .6859 | 1.0288 | 1.4861 | 1.3375 | 1.6766 | 1.286 |
| Min | .6859 | .7545 | .7621 | .8402 | .9526 | .9602 |
| Avg | .6859 | .8659 | 1.1736 | 1.0460 | 1.2648 | 1.1531 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 210 / 11 kv Sultaniya

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | | 1.6004 | |
| 4 | | | 1.1431 | 1.5089 | 1.7147 | |
| 6 | | | | | 1.8671 | |
| 8 | | 1.7147 | 1.7147 | 1.5261 | 1.9052 | |
| 10 | | | 2.0957 | | 2.0957 | |
| 12 | | | 1.8671 | 1.6118 | 1.9814 | 1.5775 |
| 14 | | | 1.6385 | | | |
| 16 | | 1.5432 | 1.8671 | 1.3203 | | 1.3717 |
| 18 | | | 2.0957 | | | |
| 20 | | | 1.9052 | 1.6118 | 1.8519 | 1.8004 |
| 23 | | 1.3717 | 1.6004 | 1.4918 | | |
| 24 | 1.0288 | 1.3032 | 1.4861 | 1.4403 | 1.7147 | |
| Max | 1.0288 | 1.7147 | 2.0957 | 1.6118 | 2.0957 | 1.8004 |
| Min | 1.0288 | 1.3032 | 1.1431 | 1.3203 | 1.6004 | 1.3717 |
| Avg | 1.0288 | 1.4832 | 1.7414 | 1.5016 | 1.8414 | 1.5832 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 211 / 11 KV RAMCHANDRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------------|--------------|--------------|--------------|--------------|--------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | | .3048 | |
| 4 | | .2286 | .3429 | .3429 | |
| 6 | | | | .3429 | |
| 8 | | .381 | .3772 | .4191 | |
| 10 | | .3429 | | .381 | |
| 12 | | .2667 | .2572 | .3429 | .2401 |
| 14 | | .2286 | | | |
| 16 | | .3048 | .2743 | | .2743 |
| 18 | | .381 | | | |
| 20 | | .4572 | .3429 | .3772 | .3772 |
| 23 | | .381 | .3601 | | .3429 |
| 24 | .2058 | .3429 | .3258 | .381 | |
| Max | .2058 | .4572 | .3772 | .4191 | .3772 |
| Min | .2058 | .2286 | .2572 | .3048 | .2401 |
| Avg | .2058 | .3315 | .3258 | .3615 | .3086 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 33 / INCOMING

| DATE | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4 | | 10.2881 | 11.1626 | 12.5743 |
| 8 | 12.6543 | 12.0028 | | 14.289 |
| 12 | | 16.0037 | | 16.0037 |
| 16 | 9.2593 | 14.289 | | |
| 20 | | 16.0037 | | |
| 23 | 8.3333 | 12.0028 | | |
| 24 | 13.1687 | 8.0018 | 10.6996 | 12.0028 |
| Max | 13.1687 | 16.0037 | 11.1626 | 16.0037 |
| Min | 8.3333 | 8.0018 | 10.6996 | 12.0028 |
| Avg | 10.8539 | 12.6560 | 10.9311 | 13.7175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 242 / 11KV INCOMER II

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------------|---------------|----------------|----------------|----------------|----------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4 | | | 10.2881 | 12.6543 | 16.0037 |
| 8 | | 12.6543 | 18.2899 | | 17.7184 |
| 12 | | | 20.0046 | | 21.1477 |
| 16 | | 10.8025 | 19.433 | | |
| 20 | | | 20.0046 | | |
| 23 | | 9.465 | 16.0037 | | |
| 24 | 9.9794 | 13.1687 | 9.145 | 13.3231 | 15.4321 |
| Max | 9.9794 | 13.1687 | 20.0046 | 13.3231 | 21.1477 |
| Min | 9.9794 | 9.465 | 9.145 | 12.6543 | 15.4321 |
| Avg | 9.9794 | 11.5226 | 16.1670 | 12.9887 | 17.5755 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 243 / 11 KV INCOMER III

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------------|---------------|---------------|---------------|---------------|---------------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4 | | | 4.0009 | 4.5268 | 5.144 |
| 8 | | 2.572 | 5.7156 | | 5.7156 |
| 12 | | | 5.6013 | | 6.2872 |
| 13 | | | | 4.321 | |
| 16 | | 4.1152 | 5.7156 | | |
| 20 | | | 6.2872 | | |
| 23 | | 4.1152 | 5.144 | | |
| 24 | 3.0864 | 3.9095 | 4.0009 | 4.321 | 5.144 |
| Max | 3.0864 | 4.1152 | 6.2872 | 4.5268 | 6.2872 |
| Min | 3.0864 | 2.572 | 4.0009 | 4.321 | 5.144 |
| Avg | 3.0864 | 3.6780 | 5.2094 | 4.3896 | 5.5727 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094040 / 33/11 KV UMRAONAGAR

Feeder No / Name : 202 / 11 KV AKASHWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.166 | 1.2346 | 1.2003 | 1.2346 | 1.2003 | .8002 |
| 2 | 1.0288 | 1.1317 | 1.1317 | 1.166 | 1.2003 | 1.2003 | 1.2003 |
| 3 | | 1.1317 | 1.166 | 1.1317 | 1.1831 | 1.1145 | 1.2003 |
| 4 | 1.0974 | 1.2003 | 1.1317 | 1.0802 | 1.2003 | 1.2003 | 1.2174 |
| 5 | | 1.2346 | 1.2346 | 1.2003 | 1.3032 | | 1.2346 |
| 6 | 1.2689 | 1.3032 | 1.406 | 1.3546 | 1.3546 | 1.3032 | 1.3717 |
| 7 | 1.3717 | 1.2689 | 1.5432 | 1.4403 | 1.4403 | 1.3717 | 1.4918 |
| 8 | | | 1.406 | 1.4575 | 1.3203 | 1.3032 | 1.4403 |
| 9 | 1.2689 | 1.2346 | 1.286 | 1.4403 | 1.2346 | 1.2003 | 1.3375 |
| 10 | 1.1145 | 1.1831 | 1.1831 | 1.2174 | | 1.1145 | 1.2174 |
| 11 | 1.0974 | 1.1317 | 1.0631 | 1.1317 | | 1.0974 | 1.1145 |
| 12 | 1.0288 | 1.1317 | 1.0117 | 1.0974 | | 1.0288 | 1.0974 |
| 13 | 1.1145 | 1.166 | .9602 | 1.0631 | | 1.0802 | 1.0631 |
| 14 | 1.0974 | 1.166 | 1.0288 | 1.0631 | | 1.0631 | 1.1145 |
| 15 | 1.166 | 1.1317 | 1.1145 | 1.1145 | | 1.046 | 1.1831 |
| 16 | 1.0974 | 1.0974 | 1.046 | 1.1145 | | .9945 | 1.1317 |
| 17 | 1.1317 | 1.1145 | 1.0974 | 1.1317 | | 1.0288 | 1.0974 |
| 18 | 1.2517 | 1.2689 | 1.4232 | 1.166 | | 1.1317 | 1.2346 |
| 19 | 1.5261 | 1.4918 | 1.4232 | 1.3717 | | 1.4232 | 1.4575 |
| 20 | 1.4746 | 1.5432 | 1.4746 | 1.5089 | | 1.4575 | 1.5432 |
| 21 | 1.5261 | 1.5432 | 1.4746 | 1.5089 | | 1.4746 | 1.5947 |
| 22 | 1.4575 | 1.5604 | 1.4746 | 1.5261 | | 1.5432 | 1.5947 |
| 23 | 1.4232 | 1.406 | 1.406 | 1.406 | 1.3717 | 1.4403 | 1.4746 |
| 24 | 1.3032 | 1.2689 | 1.2346 | 1.2517 | 1.3032 | 1.286 | 1.3717 |
| Max | 1.5261 | 1.5604 | 1.5432 | 1.5261 | 1.4403 | 1.5432 | 1.5947 |
| Min | 1.0288 | 1.0974 | .9602 | 1.0631 | 1.1831 | .9945 | .8002 |
| Avg | 1.2423 | 1.2555 | 1.2481 | 1.2560 | 1.2860 | 1.2219 | 1.2743 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 202 / 11 KV CIRCUIT HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1762 | .1829 | .0934 | .1772 | .2643 | .2801 | .2643 |
| 2 | .1762 | .1772 | .0934 | .1772 | .2643 | .2801 | .2643 |
| 3 | .1762 | .1772 | .0934 | .1829 | .1762 | .2801 | .2643 |
| 4 | .1762 | .1772 | .0934 | .1772 | .1762 | .2801 | |
| 5 | .1762 | .1772 | .1494 | .1772 | .2643 | .1867 | .1762 |
| 6 | .1762 | .1772 | .0934 | .1772 | .3525 | .1867 | .1762 |
| 7 | .1762 | .1772 | .0934 | .1772 | .2643 | .1867 | .1762 |
| 8 | .1762 | .1867 | .1787 | .1772 | .1762 | .1848 | .2643 |
| 9 | .1772 | .1867 | .1772 | .1762 | .4108 | .1762 | .3544 |
| 10 | .2658 | .2241 | .1772 | .1762 | .4108 | .2643 | .3544 |
| 11 | .2658 | .2241 | .2658 | .1762 | .4481 | .3525 | .3544 |
| 12 | .2658 | .2218 | .2658 | .3525 | .4481 | .4406 | .3544 |
| 13 | .2658 | .1867 | .1772 | .3525 | .4108 | .3525 | .3544 |
| 14 | .2658 | .1848 | .1772 | .2643 | .4108 | .3525 | .3544 |
| 15 | .1772 | .1867 | .1772 | .2643 | .3734 | .2643 | .3544 |
| 16 | .1772 | .1867 | .2658 | .2643 | .3734 | .2643 | .3544 |
| 17 | .1772 | .1867 | .1772 | .3525 | .3734 | .3525 | .3544 |
| 18 | .1772 | .1867 | .1772 | .3525 | .3734 | .3525 | .3544 |
| 19 | .1772 | .1867 | .1772 | .2643 | .2801 | .2643 | .3544 |
| 20 | .1772 | .1494 | .1772 | .2643 | .2801 | .2643 | .2658 |
| 21 | .1772 | .1494 | .1772 | .3525 | .2801 | .3525 | .2658 |
| 22 | .1772 | .1494 | .1772 | .3525 | .2801 | .2643 | .1829 |
| 23 | .1772 | .1494 | .1772 | .3525 | .2801 | .2643 | .1772 |
| 24 | .4811 | .1772 | .1494 | .1772 | .2643 | .2801 | .3525 |
| Max | .4811 | .2241 | .2658 | .3525 | .4481 | .4406 | .3544 |
| Min | .1762 | .1494 | .0934 | .1762 | .1762 | .1762 | .1762 |
| Avg | .2080 | .1821 | .1651 | .2466 | .3182 | .2803 | .2925 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 203 / 11 KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3525 | .2658 | .0934 | .0886 | .2643 | .0934 | .0881 |
| 2 | .3525 | .2658 | .0934 | .0886 | .2643 | .0924 | .0881 |
| 3 | .1762 | .2658 | .0934 | .2658 | .1762 | .2801 | .1762 |
| 4 | .1762 | .2658 | .0934 | .2681 | .1762 | .2801 | |
| 5 | .3525 | .3544 | .3734 | .3544 | .2643 | .2801 | .2643 |
| 6 | .4406 | .3544 | .3734 | .3544 | .3525 | .3734 | .3525 |
| 7 | .443 | .3544 | .3921 | .3544 | .3525 | .3921 | .2643 |
| 8 | .443 | .3734 | .3544 | .3544 | .4406 | .3734 | .3525 |
| 9 | .443 | .2772 | .3544 | .2658 | .4668 | .3525 | .3544 |
| 10 | .443 | .2772 | .3544 | .2658 | .4668 | .2643 | .3544 |
| 11 | .443 | .2801 | .0886 | .2643 | .4668 | .3525 | .3544 |
| 12 | .443 | .3361 | .0886 | .3525 | .4854 | .4406 | .3544 |
| 13 | .443 | .3361 | .3544 | .3544 | .4668 | .3525 | .3544 |
| 14 | .443 | .3361 | .3544 | .2658 | .4481 | .3525 | .3544 |
| 15 | .443 | .3361 | .3544 | .2643 | .4481 | .4406 | .3544 |
| 16 | .443 | .3734 | .3544 | .3525 | .4435 | .4406 | .3544 |
| 17 | .3544 | .3696 | .3544 | .3525 | .5228 | .4406 | .3544 |
| 18 | .3544 | .4668 | .3544 | .3525 | .4066 | .3525 | .3658 |
| 19 | .443 | .4294 | .3544 | .2643 | .4108 | .3525 | .3544 |
| 20 | .443 | .4481 | .3544 | .2643 | .4066 | .2643 | .3544 |
| 21 | .443 | .4066 | .3544 | .3525 | .4481 | .1762 | .3544 |
| 22 | .443 | .4066 | .3544 | .2643 | .2801 | .1762 | .3544 |
| 23 | .3544 | .2614 | .3544 | .2643 | .2801 | .1762 | .3544 |
| 24 | .4406 | .3544 | .2614 | .0886 | .3525 | .2801 | .1762 |
| Max | .443 | .4668 | .3921 | .3544 | .5228 | .4406 | .3658 |
| Min | .1762 | .2614 | .0886 | .0886 | .1762 | .0924 | .0881 |
| Avg | .3982 | .3415 | .2880 | .2799 | .3788 | .3075 | .3082 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 204 / AJINKYA TARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9002 | .8859 | .9335 | .8859 | .8954 | .8402 | .985 |
| 2 | .8954 | .8859 | .9335 | .9145 | .8016 | .8402 | .8954 |
| 3 | .8059 | .8859 | .9335 | .8859 | .8059 | .8402 | .8954 |
| 4 | .985 | .8859 | 1.0269 | .8859 | .985 | .9335 | |
| 5 | 1.0802 | 1.0631 | 1.0164 | .8859 | 1.1703 | 1.1203 | 1.0802 |
| 6 | 1.1703 | 1.0631 | 1.2136 | 1.0631 | 1.3503 | 1.307 | 1.3575 |
| 7 | 1.5384 | 1.2403 | 1.307 | 1.251 | 1.4556 | 1.307 | 1.448 |
| 8 | 1.5465 | 1.1203 | 1.2403 | 1.2403 | 1.5465 | 1.307 | 1.448 |
| 9 | 1.2403 | 1.1203 | 1.0631 | 1.1703 | 1.307 | 1.1703 | 1.0631 |
| 10 | 1.2403 | 1.1203 | 1.0631 | 1.0802 | 1.0269 | 1.086 | .8859 |
| 11 | 1.0631 | 1.0269 | .8859 | .9902 | .9335 | .9902 | .7087 |
| 12 | .8859 | 1.0269 | .7087 | .8954 | .9335 | .8059 | .7087 |
| 13 | .8859 | .7468 | .7087 | .8016 | .9335 | .7125 | .7087 |
| 14 | | .7468 | .7087 | .7125 | .9335 | .6201 | .7087 |
| 15 | .8859 | .7468 | .7973 | .7125 | .9335 | .5344 | .7087 |
| 16 | .8859 | .6535 | .7973 | .7125 | .9709 | .7087 | .7087 |
| 17 | .8859 | .8402 | .8859 | .8016 | 1.0269 | .8954 | .7087 |
| 18 | .8859 | 1.0269 | .8859 | .8954 | 1.2136 | .8059 | .8859 |
| 19 | 1.0631 | 1.2696 | 1.0631 | .9902 | 1.4003 | .985 | 1.0631 |
| 20 | 1.0631 | 1.2136 | 1.1517 | 1.0802 | 1.4003 | 1.1641 | 1.2403 |
| 21 | 1.2403 | 1.1576 | 1.0631 | 1.1703 | 1.2136 | 1.267 | 1.2403 |
| 22 | 1.0631 | 1.1203 | 1.0631 | 1.086 | 1.1203 | 1.1765 | 1.2403 |
| 23 | 1.0631 | 1.1203 | 1.0631 | .985 | 1.0269 | 1.086 | 1.0631 |
| 24 | .985 | .9745 | .9335 | .8859 | .985 | .9335 | 1.0802 |
| Max | 1.5465 | 1.2696 | 1.307 | 1.251 | 1.5465 | 1.307 | 1.448 |
| Min | .8059 | .6535 | .7087 | .7125 | .8016 | .5344 | .7087 |
| Avg | 1.0547 | .9976 | .9770 | .9576 | 1.0987 | .9765 | .9927 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 205 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3503 | 1.4175 | 1.307 | 1.4175 | 1.5465 | 1.4937 | 1.5465 |
| 2 | 1.2603 | 1.4175 | 1.307 | 1.4175 | 1.4556 | 1.4937 | 1.4556 |
| 3 | | 1.2403 | 1.307 | 1.4175 | 1.4556 | 1.4784 | 1.3575 |
| 4 | 1.267 | 1.2403 | 1.4003 | 1.4175 | 1.3575 | 1.587 | |
| 5 | 1.3575 | 1.2403 | 1.4563 | 1.4175 | 1.5465 | 1.587 | 1.5465 |
| 6 | 1.5465 | 1.4175 | 1.587 | 1.5061 | 1.7285 | 1.6804 | 1.6375 |
| 7 | 1.8195 | 1.5061 | 1.8484 | 1.7718 | 1.8195 | 1.8111 | 1.7285 |
| 8 | 1.8195 | 1.8671 | 1.8604 | 1.7718 | 1.9104 | 1.9605 | 2.0014 |
| 9 | 1.7718 | 1.8111 | 1.7718 | 1.7285 | 1.6804 | 1.8195 | 1.7718 |
| 10 | 1.7718 | 1.7737 | 1.6832 | 1.6375 | 1.7737 | 1.6289 | 1.6084 |
| 11 | 1.5947 | 1.6632 | 1.5947 | 1.6375 | 1.4937 | 1.4556 | 1.5061 |
| 12 | 1.5061 | 1.6632 | 1.5061 | 1.6375 | 1.4003 | 1.4556 | 1.5061 |
| 13 | 1.4175 | 1.6617 | 1.4175 | 1.5465 | 1.307 | 1.3503 | 1.4175 |
| 14 | 1.3289 | 1.587 | 1.4175 | 1.4556 | 1.307 | 1.2603 | 1.4175 |
| 15 | 1.2403 | 1.587 | 1.4175 | 1.4556 | 1.307 | 1.3503 | 1.5947 |
| 16 | 1.2403 | 1.6244 | 1.4175 | 1.4556 | 1.3443 | 1.448 | 1.5947 |
| 17 | 1.4175 | 1.6617 | 1.4175 | 1.5465 | 1.3817 | 1.4556 | 1.5947 |
| 18 | 1.7718 | 1.6804 | 1.4175 | 1.4556 | 1.587 | 1.6375 | 1.5947 |
| 19 | 1.8604 | 2.0538 | 1.5947 | 1.6375 | 1.8671 | 1.7285 | 1.7718 |
| 20 | 1.8604 | 2.0538 | 1.949 | 1.6375 | 1.9605 | 1.8195 | 1.8604 |
| 21 | | 1.9044 | 1.7718 | 1.8195 | 1.8671 | 1.9104 | 1.8604 |
| 22 | 1.7718 | 1.8671 | 1.6832 | 1.6375 | 1.6804 | 1.8195 | 1.7718 |
| 23 | 1.5947 | 1.6804 | 1.5947 | 1.5465 | 1.4937 | 1.7285 | 1.5947 |
| 24 | 1.4556 | 1.5061 | 1.531 | 1.5061 | 1.6375 | 1.4937 | 1.6375 |
| Max | 1.8604 | 2.0538 | 1.949 | 1.8195 | 1.9605 | 1.9605 | 2.0014 |
| Min | 1.2403 | 1.2403 | 1.307 | 1.4175 | 1.307 | 1.2603 | 1.3575 |
| Avg | 1.5466 | 1.6302 | 1.5524 | 1.5616 | 1.5795 | 1.6022 | 1.6251 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 206 / SRP Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1762 | .1772 | .1867 | .1772 | .2643 | .1848 | .1762 |
| 2 | .1762 | .1772 | .1848 | .1772 | .1762 | .1867 | .1762 |
| 3 | .1762 | .1772 | .1867 | .1772 | .1762 | .1848 | .1762 |
| 4 | .2643 | .1772 | .1867 | .1772 | .1762 | .2241 | |
| 5 | .2643 | .2658 | .2241 | .1772 | .2643 | .2801 | .1762 |
| 6 | .2643 | .2658 | .2801 | .2658 | .3525 | .3734 | .2643 |
| 7 | .3525 | .2658 | .3734 | .3544 | .2643 | .3734 | .2643 |
| 8 | .3525 | .2801 | .3544 | .3544 | .3525 | .3734 | .3525 |
| 9 | .1772 | .2614 | .2681 | .3525 | .2801 | .3525 | .2658 |
| 10 | .1772 | .2218 | .2658 | .2643 | .2241 | .2643 | .2658 |
| 11 | .1772 | .2218 | .1772 | .1762 | .2241 | .1762 | .1772 |
| 12 | .1772 | .2218 | .1772 | .1762 | .1867 | .1762 | .1772 |
| 13 | .1772 | .2241 | .1772 | .1762 | .1867 | .1762 | .1772 |
| 14 | .1772 | .1848 | .1772 | .2643 | .1867 | .2643 | .1772 |
| 15 | .1772 | .1848 | .1772 | .2643 | .1867 | .2643 | .1772 |
| 16 | .1772 | .1867 | .1772 | .2643 | .1867 | .1762 | .1772 |
| 17 | .1772 | .2241 | .1772 | .1753 | .2241 | .1762 | .1772 |
| 18 | .1772 | .2241 | .1772 | .1762 | .2801 | .1762 | .2658 |
| 19 | .2658 | .2772 | .1772 | .2643 | .3734 | .1762 | .2658 |
| 20 | .2658 | .2801 | .2658 | .2643 | .3734 | .2643 | .2658 |
| 21 | .2658 | .2801 | .2658 | .2643 | .2801 | .2643 | .2658 |
| 22 | .2658 | .2241 | .2658 | .1762 | .2241 | .1762 | .2658 |
| 23 | .1772 | .1867 | .2658 | .1762 | .1867 | .1762 | .2658 |
| 24 | .1762 | .1772 | .1867 | .2658 | .2643 | .1867 | .2643 |
| Max | .3525 | .2801 | .3734 | .3544 | .3734 | .3734 | .3525 |
| Min | .1762 | .1772 | .1772 | .1753 | .1762 | .1762 | .1762 |
| Avg | .2173 | .2236 | .2231 | .2317 | .2456 | .2345 | .2268 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV SUNAVKAR-OM SHREE
AGRO Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4861 | 1.1622 | .1715 | 1.2765 | .1715 | | 1.4861 |
| 2 | 1.467 | 1.1431 | .1715 | 1.3146 | .3429 | | 1.5242 |
| 3 | 1.448 | .9717 | .1524 | 1.2574 | .2096 | | 1.3717 |
| 4 | 1.4289 | .8192 | .1524 | 1.2574 | .1905 | | 1.5051 |
| 5 | 1.448 | .7621 | .1334 | 1.2193 | .1905 | | 1.5242 |
| 6 | 1.4098 | .3429 | .1334 | 1.1622 | .1905 | | |
| 7 | 1.3336 | .3239 | .1334 | 1.2574 | .2286 | | 1.5432 |
| 8 | 1.3146 | .3048 | .1334 | 1.2193 | .3048 | | 1.6385 |
| 9 | 1.3908 | .3048 | .3429 | 1.2955 | | 1.6766 | 1.1812 |
| 10 | 1.5432 | .3048 | .381 | 1.0098 | | 1.7528 | 1.4861 |
| 11 | 1.5242 | .2286 | .4191 | 1.7718 | | 1.8099 | 1.5623 |
| 12 | 1.5242 | .1524 | .381 | 1.7528 | | 1.8861 | 1.448 |
| 13 | 1.5242 | .1524 | .4382 | 1.5051 | | 1.829 | 1.448 |
| 14 | 1.467 | .1334 | .4191 | 1.5242 | | 1.7528 | 1.467 |
| 15 | 1.3717 | .1334 | .4001 | 1.7147 | | 1.7147 | 1.5432 |
| 16 | 1.4098 | .1334 | .4191 | 1.7337 | | 1.7147 | 1.5242 |
| 17 | 1.1431 | .1334 | .2858 | 1.6956 | 1.7528 | 1.6766 | 1.5242 |
| 18 | 1.2193 | .1334 | .5525 | 1.6004 | 1.6766 | 1.6766 | |
| 19 | 1.1812 | .1143 | .4763 | 1.4098 | 1.6194 | 1.5432 | 1.2384 |
| 20 | 1.1431 | .0762 | .4572 | 1.1812 | 1.3146 | 1.3717 | 1.2003 |
| 21 | 1.1431 | .0762 | .4954 | 1.1812 | 1.5051 | 1.4098 | 1.2193 |
| 22 | 1.105 | .1334 | .4763 | 1.2193 | 1.4289 | 1.5051 | 1.2193 |
| 23 | .9717 | .1715 | .4572 | 1.2955 | 1.5051 | 1.4289 | 1.3527 |
| 24 | 1.5051 | 1.1622 | .1715 | 1.2955 | .1715 | | 1.4861 |
| Max | 1.5432 | 1.1622 | .5525 | 1.7718 | 1.7528 | 1.8861 | 1.6385 |
| Min | .9717 | .0762 | .1334 | 1.0098 | .1715 | 1.3717 | 1.1812 |
| Avg | 1.3543 | .3906 | .3231 | 1.3813 | .8002 | 1.6499 | 1.4315 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV LAURAL-COLDSTORAGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1905 | .1905 | .1715 | .2096 | .2858 | | .2286 |
| 2 | .2096 | .1905 | .1715 | .2096 | .2667 | | .1905 |
| 3 | .2096 | .1905 | .1524 | .2096 | .2667 | | .2477 |
| 4 | .2096 | .1715 | .1524 | .1715 | .2667 | | .3048 |
| 5 | .2286 | .1715 | .1524 | .1905 | .2858 | | .1905 |
| 6 | .2096 | .1715 | .1715 | .1905 | .2477 | | .2096 |
| 7 | .1905 | .1715 | .1715 | .1715 | .2477 | | .2096 |
| 8 | .1334 | .1715 | .1715 | .1905 | .2286 | | .1905 |
| 9 | .381 | .1524 | .1905 | .3429 | .4191 | .4954 | .6287 |
| 10 | .4572 | .1334 | .1905 | .4191 | .6859 | .5906 | .6287 |
| 11 | .4954 | .1143 | .2096 | .6287 | .724 | .724 | .5906 |
| 12 | .5716 | .1143 | .2286 | .5144 | .724 | .7811 | .5906 |
| 13 | .4572 | .1143 | .2477 | .4572 | .6859 | .6859 | .4763 |
| 14 | .4001 | .1143 | .2667 | .4954 | .724 | .6859 | .4954 |
| 15 | .381 | .1143 | .2477 | .4954 | .7049 | .6668 | .5144 |
| 16 | .9145 | .0762 | .2858 | .4763 | .724 | .743 | .4763 |
| 17 | .381 | .1143 | .2858 | .4954 | .7049 | .6668 | .4763 |
| 18 | .1524 | .1334 | .1905 | .6097 | .6859 | .5716 | .4572 |
| 19 | .1524 | .1334 | .2286 | .381 | .6668 | .5335 | .4572 |
| 20 | .1715 | .1524 | .2477 | .3048 | .4191 | .362 | .362 |
| 21 | .1715 | .1715 | .1524 | .2858 | .2286 | .2858 | .2667 |
| 22 | .1715 | .1715 | .2286 | .2286 | .2667 | .1905 | .2477 |
| 23 | .1715 | .1715 | .1905 | .1715 | .3048 | .2286 | .2477 |
| 24 | .1905 | .1905 | .1715 | .2096 | .3239 | | .2096 |
| Max | .9145 | .1905 | .2858 | .6287 | .724 | .7811 | .6287 |
| Min | .1334 | .0762 | .1524 | .1715 | .2286 | .1905 | .1905 |
| Avg | .3001 | .1500 | .2032 | .3358 | .4620 | .5474 | .3707 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV Bhausaheb Hire
Express Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1143 | .1143 | .1143 | .1143 | .8764 | | .1524 |
| 2 | .1143 | .1143 | .1143 | .1143 | 1.0479 | | .1524 |
| 3 | .1143 | .1143 | .1334 | .1143 | .9526 | | .1334 |
| 4 | .1143 | .1143 | .1334 | .1143 | 1.2955 | | .1334 |
| 5 | .1143 | .1143 | .1143 | .1143 | 1.4098 | | .1524 |
| 6 | .1143 | .1143 | .1143 | .1334 | 1.4098 | | .1524 |
| 7 | .1524 | .1143 | .1334 | .1334 | 1.5432 | | .1334 |
| 8 | .1905 | .1143 | .1334 | .1143 | 1.3146 | | .2096 |
| 9 | .1905 | .0953 | .1524 | .1334 | .1715 | .1905 | .2477 |
| 10 | .1905 | .0762 | .1905 | .1334 | .2286 | .2286 | .2477 |
| 11 | .1905 | .1143 | .1715 | .1143 | .1715 | .2286 | .2477 |
| 12 | .1905 | .1143 | .1715 | .1143 | .1715 | .2477 | .1905 |
| 13 | .1715 | .1143 | .1715 | .0953 | .1524 | .2477 | .1715 |
| 14 | .1524 | .1143 | .1143 | .0953 | .1715 | .2096 | .1334 |
| 15 | .1524 | .1143 | .1334 | .0953 | .2096 | .2096 | .1334 |
| 16 | .1715 | .8002 | .1334 | .0953 | .1905 | .1905 | .1524 |
| 17 | .1715 | .1143 | .1334 | .0953 | .1524 | .1715 | .1524 |
| 18 | .1524 | .1143 | .1334 | .0953 | .1334 | .1334 | .1524 |
| 19 | .1524 | .1143 | .1143 | .1143 | .1524 | .1524 | .1715 |
| 20 | .1334 | .1334 | .1524 | .1143 | .1524 | .1524 | .1715 |
| 21 | .1334 | .1143 | .1334 | .1334 | .1715 | .1524 | .1715 |
| 22 | .1334 | .1143 | .1524 | .1143 | .1715 | .1524 | .1715 |
| 23 | .1334 | .1143 | .1143 | .1143 | .1334 | .1524 | .1334 |
| 24 | .1143 | .1143 | .1143 | .1143 | .8954 | | .1524 |
| Max | .1905 | .8002 | .1905 | .1334 | 1.5432 | .2477 | .2477 |
| Min | .1143 | .0762 | .1143 | .0953 | .1334 | .1334 | .1334 |
| Avg | .1484 | .1413 | .1366 | .1135 | .5533 | .1880 | .1675 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV NIRMAL-R K AGRO
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2858 | .4382 | | .1715 | .0953 | | .2667 |
| 2 | .2858 | .4191 | .1905 | .1524 | .0953 | | .2477 |
| 3 | .2667 | .4191 | .1524 | .1524 | .0953 | | .2286 |
| 4 | .2858 | .4001 | .1334 | .1524 | .0953 | | .1905 |
| 5 | .3048 | .4191 | .1334 | .1334 | .0953 | | .2858 |
| 6 | .3048 | .1715 | .1143 | .1334 | .1143 | | .2667 |
| 7 | .1905 | .1143 | .1143 | .1334 | .1143 | | .3048 |
| 8 | .1334 | .1143 | .1143 | .1334 | .0762 | | .2096 |
| 9 | .381 | .1334 | .1715 | .362 | .4572 | .5335 | .7049 |
| 10 | .4572 | .1334 | .2286 | .5335 | .6668 | .743 | .8764 |
| 11 | .4954 | .1524 | .2667 | .5525 | .6859 | .8383 | .9717 |
| 12 | .5716 | .1715 | .2667 | .4572 | .6668 | .9717 | .8383 |
| 13 | .4572 | .1715 | .2667 | .4763 | .6668 | .9145 | .8002 |
| 14 | .4001 | .1905 | .3429 | .5716 | .6859 | .8002 | .743 |
| 15 | .381 | .1905 | .2286 | .4001 | .724 | .724 | .6478 |
| 16 | .4763 | .2096 | .2477 | .4763 | .724 | .6097 | .6097 |
| 17 | .5716 | .1905 | .2096 | .4954 | .724 | .5716 | .6097 |
| 18 | .0762 | .1905 | .2096 | .5144 | .724 | .4763 | .5716 |
| 19 | .0762 | .1715 | .2286 | .381 | .6668 | | .4191 |
| 20 | .0762 | .1143 | .1524 | .2477 | .4191 | .3239 | .381 |
| 21 | .0953 | .1715 | .0953 | .2667 | .362 | .2477 | .3429 |
| 22 | .0953 | .1905 | .1524 | .3048 | .3429 | .3239 | .362 |
| 23 | .0953 | .1905 | .1715 | .2858 | .3429 | .2858 | .381 |
| 24 | .3048 | .4572 | .1905 | .1715 | .0953 | | .2667 |
| Max | .5716 | .4572 | .3429 | .5716 | .724 | .9717 | .9717 |
| Min | .0762 | .1143 | .0953 | .1334 | .0762 | .2477 | .1905 |
| Avg | .2945 | .2302 | .1905 | .3191 | .4057 | .5974 | .4803 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 208 / Dama water supply
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2667 | .6287 | .1334 | .5335 | .8764 | | .7811 |
| 2 | .2477 | .5716 | .1334 | .5144 | .8192 | | .8002 |
| 3 | .2096 | .5716 | .1143 | .5144 | .8192 | | .8383 |
| 4 | .1905 | .5716 | .1143 | .5525 | .9145 | | .743 |
| 5 | .2286 | .5906 | .1334 | .5716 | 1.2955 | | .7621 |
| 6 | .1715 | .5335 | .1334 | .5906 | 1.4098 | | .9145 |
| 7 | .1905 | .1334 | .1524 | .5716 | 1.5432 | | .6668 |
| 8 | .2096 | .1143 | .1715 | .5525 | 1.3146 | | .6478 |
| 9 | .5716 | .0953 | .1905 | .5906 | .6859 | .3048 | .743 |
| 10 | .7621 | .0953 | .4763 | .6668 | .724 | .8192 | .8573 |
| 11 | .7811 | .1143 | .6097 | .7811 | .7621 | .8383 | .8573 |
| 12 | .8002 | .1143 | .5716 | .7049 | .8002 | .7811 | .8383 |
| 13 | .724 | .1143 | .5144 | .5525 | .7811 | .8002 | .7811 |
| 14 | .6668 | .1334 | .4191 | .6478 | .6859 | .7811 | .8002 |
| 15 | .724 | .1334 | .5906 | .6478 | .5144 | .7621 | .7811 |
| 16 | .7621 | .1334 | .6097 | .6097 | .381 | .7049 | .8002 |
| 17 | .743 | .1143 | .6097 | .7049 | .3239 | .743 | .7621 |
| 18 | .6478 | .0953 | .5906 | .724 | .2858 | .7621 | .724 |
| 19 | .6097 | .0953 | .5716 | .6668 | .2858 | .724 | .6859 |
| 20 | .6859 | .1143 | .5716 | .6097 | .2667 | .743 | .5906 |
| 21 | .6668 | .1334 | .5525 | .5906 | .2096 | .6478 | .5335 |
| 22 | .6478 | .1334 | .5716 | .6287 | .2477 | .6859 | .5716 |
| 23 | | .1143 | .5906 | .6097 | .1905 | .6668 | .7049 |
| 24 | .2858 | .724 | .1143 | .5716 | .6478 | | .7621 |
| Max | .8002 | .724 | .6097 | .7811 | 1.5432 | .8383 | .9145 |
| Min | .1715 | .0953 | .1143 | .5144 | .1905 | .3048 | .5335 |
| Avg | .5128 | .2572 | .3850 | .6128 | .6994 | .7176 | .7478 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 210 / New Madhur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5813 | 1.2384 | .1524 | 1.3527 | 1.4289 | 1.5623 | 1.5623 |
| 2 | 1.5623 | 1.1622 | .1334 | 1.3717 | 1.4289 | 1.6575 | 1.6575 |
| 3 | 1.5242 | 1.2193 | .1143 | 1.4289 | 1.448 | 1.6194 | 1.6194 |
| 4 | 1.5432 | 1.7909 | .1524 | 1.3336 | 1.467 | | 1.5051 |
| 5 | 1.5623 | 1.0288 | .1334 | 1.3908 | .2858 | | 1.5242 |
| 6 | 1.5432 | .1715 | .0953 | 1.3527 | 1.4289 | | 1.5432 |
| 7 | 1.5623 | .1905 | .0953 | 1.3336 | 1.467 | | 1.4861 |
| 8 | 1.5432 | .1143 | .0762 | 1.3336 | 1.3336 | | 1.4289 |
| 9 | 1.6575 | .0953 | .6668 | 1.3717 | 1.4098 | 1.5623 | 1.4861 |
| 10 | 1.7528 | .0762 | .9145 | 1.3336 | 1.5051 | 1.5432 | 1.467 |
| 11 | 1.7147 | .0762 | 1.0288 | 1.6004 | 1.5432 | 1.6194 | 1.5432 |
| 12 | 1.6385 | .0762 | 1.105 | 1.5813 | 1.5242 | 1.6385 | 1.6194 |
| 13 | 1.086 | .0762 | 1.2003 | 1.5242 | 1.5242 | 1.5623 | 1.6194 |
| 14 | 1.6194 | .0762 | 1.2003 | 1.5242 | 1.5432 | 1.5051 | 1.6194 |
| 15 | 1.6575 | .0762 | 1.2574 | 1.6766 | 1.5623 | 1.5432 | 1.5432 |
| 16 | 1.6766 | .0762 | 1.3336 | 1.5242 | 1.5242 | 1.6194 | 1.3717 |
| 17 | 1.5242 | .0762 | 1.3527 | 1.4861 | 1.5813 | 1.5432 | 1.4098 |
| 18 | 1.5813 | .1143 | 1.2765 | 1.4098 | 1.5242 | 1.5242 | 1.2384 |
| 19 | | .1143 | 1.2955 | 1.4289 | 1.4861 | 1.4861 | 1.0479 |
| 20 | 1.4098 | .1143 | 1.2384 | 1.3717 | 1.467 | 1.4289 | 1.2003 |
| 21 | 1.4289 | .1334 | 1.3146 | 1.4098 | 1.467 | 1.6004 | 1.467 |
| 22 | 1.4861 | .1334 | | 1.4098 | 1.4861 | 1.5623 | 1.5051 |
| 23 | 1.4289 | .1524 | 1.3336 | 1.4098 | 1.3146 | 1.5242 | 1.6194 |
| 24 | 1.6004 | 1.3146 | .1524 | 1.3336 | 1.448 | 1.6194 | 1.6194 |
| Max | 1.7528 | 1.7909 | 1.3527 | 1.6766 | 1.5813 | 1.6575 | 1.6575 |
| Min | 1.086 | .0762 | .0762 | 1.3336 | .2858 | 1.4289 | 1.0479 |
| Avg | 1.5515 | .4041 | .7662 | 1.4289 | 1.4249 | 1.5643 | 1.4876 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 211 / New Deesan

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.5149 | 1.9052 | .8002 | 1.5051 | 2.2862 | | 2.0957 |
| 2 | 2.4768 | 1.8861 | .9526 | 1.5242 | 2.2672 | | 2.1719 |
| 3 | 2.4196 | 1.848 | .9717 | 1.6956 | 2.3624 | | 2.21 |
| 4 | 2.4577 | 1.7337 | .8192 | 1.5051 | 2.2481 | | 2.1529 |
| 5 | 2.4387 | 1.6194 | .8383 | 1.4861 | 2.2862 | | 1.9052 |
| 6 | 2.4006 | 1.5242 | .8002 | 1.9052 | 2.2862 | | 1.9243 |
| 7 | 2.4006 | .9526 | .8573 | 2.21 | 1.6956 | | 1.7528 |
| 8 | 2.3243 | .8383 | .9526 | 1.9814 | 2.0576 | | 1.448 |
| 9 | 2.3815 | .8383 | .9145 | 2.0957 | 2.3243 | 2.2862 | 1.6956 |
| 10 | 2.4577 | .8383 | .743 | 2.2291 | 2.7435 | 2.6292 | 2.0576 |
| 11 | 2.3624 | .8573 | .7621 | 2.3815 | 2.6863 | 2.6863 | 2.0005 |
| 12 | 2.2481 | .8764 | .8192 | 2.4006 | 2.572 | 2.7054 | 1.9052 |
| 13 | 2.3434 | .8573 | .8954 | 2.3815 | 2.4958 | 2.5149 | 1.8671 |
| 14 | 2.3243 | .8192 | 1.4098 | 2.2291 | 2.6673 | 2.5149 | 1.8099 |
| 15 | 2.4768 | .8573 | 1.4098 | 2.4768 | 2.8006 | 2.4768 | 2.0576 |
| 16 | 2.6863 | .8002 | 1.5432 | 2.7435 | 2.7625 | 2.8387 | 2.1529 |
| 17 | 2.3815 | .7811 | 1.6004 | .2858 | 2.7435 | 2.8769 | 2.0957 |
| 18 | 2.3053 | .7621 | 2.4006 | .3048 | 2.6863 | 2.8769 | 2.191 |
| 19 | 2.3624 | .7621 | 2.2481 | .2667 | | 2.7435 | 2.2291 |
| 20 | 2.3815 | .8002 | .7811 | 2.6673 | 2.6863 | 2.2862 | 1.9052 |
| 21 | 2.4006 | .8383 | 2.1148 | 2.0957 | 2.3815 | 2.0005 | 1.7147 |
| 22 | 2.3243 | .9145 | 2.3243 | 2.191 | 2.3815 | 2.1148 | 1.8671 |
| 23 | 2.191 | .9145 | 1.9052 | 2.2672 | 2.3815 | 2.0957 | 1.9243 |
| 24 | 2.5911 | 2.191 | .9145 | 1.4861 | 2.4768 | | 2.1338 |
| Max | 2.6863 | 2.191 | 2.4006 | 2.7435 | 2.8006 | 2.8769 | 2.2291 |
| Min | 2.191 | .7621 | .743 | .2667 | 1.6956 | 2.0005 | 1.448 |
| Avg | 2.4021 | 1.1257 | 1.2408 | 1.8465 | 2.4469 | 2.5098 | 1.9695 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 212 / New RMC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6482 | 1.3336 | .724 | 1.2193 | 1.5432 | | 1.4289 |
| 2 | 2.6863 | 1.2003 | .7621 | 1.2193 | 1.5432 | | 1.5242 |
| 3 | 2.6673 | 1.105 | .8002 | 1.2955 | 1.5242 | | 1.5051 |
| 4 | 2.7054 | .9717 | .7621 | 1.2003 | 1.448 | | 1.467 |
| 5 | 2.7054 | .7621 | .743 | 1.1622 | 1.4098 | | 1.4289 |
| 6 | 2.7244 | .724 | .7049 | 1.2384 | 1.1431 | | 1.4098 |
| 7 | 2.6101 | .6287 | .743 | 1.2384 | 1.1622 | | 1.3908 |
| 8 | 2.4196 | .6478 | .8383 | 1.2384 | 1.3717 | | 1.448 |
| 9 | 2.4768 | .6478 | 1.0098 | 1.4289 | 1.848 | 1.6766 | 1.7528 |
| 10 | 2.9531 | .6859 | 1.1812 | 1.7528 | 1.848 | 1.9624 | 1.9624 |
| 11 | 1.7147 | .6668 | 1.448 | 2.0576 | 1.829 | 2.1338 | 2.0957 |
| 12 | 1.6385 | .6668 | 1.448 | 2.1529 | 1.8671 | 2.2481 | 2.21 |
| 13 | 2.7625 | .6859 | 1.5051 | 2.0767 | 1.829 | 2.0957 | 2.0957 |
| 14 | 2.6673 | .6668 | 1.5623 | 1.8861 | 1.7909 | 1.9052 | 1.7528 |
| 15 | 1.6575 | .6478 | 1.6004 | 1.8099 | 1.7718 | 1.9433 | 1.8861 |
| 16 | 1.6766 | .6478 | 1.6194 | 1.7528 | 1.829 | 1.9433 | 1.9433 |
| 17 | 2.2862 | .6097 | 1.6194 | 1.4861 | 1.6766 | 1.9243 | 2.0195 |
| 18 | 2.0767 | .6287 | 1.7337 | 1.6766 | | 1.829 | 1.829 |
| 19 | 1.9052 | .6287 | 1.6194 | 1.6956 | 1.6004 | 1.7909 | 1.6956 |
| 20 | 1.3146 | .6668 | 1.7718 | 1.6956 | 1.4861 | 1.6004 | 1.6194 |
| 21 | 1.3146 | .6478 | 1.5051 | 1.7147 | 1.4861 | 1.448 | 1.6004 |
| 22 | 1.2574 | .6287 | 1.4289 | 1.6575 | 1.2765 | 1.5242 | 1.6004 |
| 23 | 1.2955 | .7049 | 1.3527 | 1.6194 | 1.3146 | 1.467 | 1.4098 |
| 24 | 2.6482 | 1.3336 | .7049 | 1.3146 | 1.5432 | | 1.5051 |
| Max | 2.9531 | 1.3336 | 1.7718 | 2.1529 | 1.8671 | 2.2481 | 2.21 |
| Min | 1.2574 | .6097 | .7049 | 1.1622 | 1.1431 | 1.448 | 1.3908 |
| Avg | 2.2005 | .7724 | 1.2162 | 1.5662 | 1.5714 | 1.8328 | 1.6909 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 201 / 11 KV RAJWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.286 | 1.6194 | 1.4289 | 1.5242 | 1.3336 | 1.3717 | 1.7147 |
| 2 | 1.1869 | 1.6194 | 1.3336 | 1.4289 | 1.2384 | 1.286 | 1.7147 |
| 3 | 1.1145 | 1.5242 | 1.3336 | 1.4289 | 1.2384 | 1.4289 | 1.6194 |
| 4 | 1.1145 | 1.5242 | 1.3336 | 1.4289 | 1.2384 | 1.2003 | 1.6194 |
| 5 | 1.1145 | 1.4289 | 1.3336 | 1.4289 | 1.4289 | 1.3717 | 1.6194 |
| 6 | 1.286 | 1.4289 | 1.5242 | 1.4289 | 1.5242 | 1.5432 | 1.6194 |
| 7 | 1.3717 | 1.5242 | 1.7147 | 1.5242 | 1.6194 | 1.7147 | 1.7147 |
| 8 | 1.7147 | 2.0005 | 1.8099 | 1.9052 | 1.9052 | 1.8004 | 2.191 |
| 9 | 2.0957 | 2.2862 | 1.7147 | 2.191 | 2.0957 | 1.8861 | 2.2862 |
| 10 | 2.0957 | 2.3815 | 1.8004 | 2.191 | 2.191 | 2.0576 | 2.2862 |
| 11 | 2.2862 | 2.3815 | 2.0576 | 2.2862 | 2.2862 | 2.0576 | 2.191 |
| 12 | 2.191 | 2.3815 | 1.8861 | 2.2862 | 2.2862 | 2.1434 | 2.572 |
| 13 | 2.191 | 2.2862 | 1.8861 | 2.0957 | 2.0957 | 2.1434 | 2.4768 |
| 14 | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.8099 | 1.8861 | 1.9052 |
| 15 | 1.8099 | 1.3336 | 1.7147 | 1.6194 | 1.9052 | 1.7147 | 1.9052 |
| 16 | 1.9052 | 1.4289 | 1.9052 | 1.8099 | 1.8004 | 2.0957 | 1.7147 |
| 17 | 2.0005 | 1.5242 | 2.191 | 1.8099 | 1.8861 | 2.2862 | 1.9719 |
| 18 | 2.191 | 1.6194 | 2.191 | 1.8099 | 2.0957 | 2.191 | 2.0576 |
| 19 | | 1.8099 | 2.2862 | 2.0957 | 2.0576 | 2.572 | 2.2291 |
| 20 | 2.2862 | 2.0957 | 2.2862 | 2.0005 | 2.2291 | 2.4768 | 2.3148 |
| 21 | 2.0005 | 2.0005 | 1.9052 | 2.0005 | 1.9719 | 2.191 | 1.8861 |
| 22 | 1.8099 | 1.8099 | 1.7147 | | 1.7147 | 2.0005 | 1.7147 |
| 23 | 1.7147 | 1.7147 | 1.6194 | 1.6194 | 1.7147 | 1.7147 | 1.5432 |
| 24 | 1.286 | 1.6194 | 1.5242 | 1.5242 | 1.4289 | 1.4575 | 1.7147 |
| Max | 2.2862 | 2.3815 | 2.2862 | 2.2862 | 2.2862 | 2.572 | 2.572 |
| Min | 1.1145 | 1.3336 | 1.3336 | 1.4289 | 1.2384 | 1.2003 | 1.5432 |
| Avg | 1.729 | 1.7941 | 1.7587 | 1.7892 | 1.7956 | 1.8580 | 1.9409 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 202 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .7621 | .5716 | .6668 | .5716 | .6001 | .7621 |
| 2 | .5144 | .7621 | .5716 | .6668 | .5716 | .5144 | .7621 |
| 3 | .5144 | .6668 | .5716 | .6668 | .5716 | .5144 | .6668 |
| 4 | .5144 | .6668 | .7621 | .6668 | .6668 | .5144 | .6668 |
| 5 | .6859 | .6668 | .8573 | .6668 | .8573 | .6859 | .6668 |
| 6 | .8573 | .7621 | .9526 | .8573 | .9526 | .6859 | .8573 |
| 7 | .9431 | .9526 | 1.0479 | .9526 | 1.1431 | .7716 | 1.1431 |
| 8 | .9431 | .9526 | 1.0479 | 1.2384 | 1.0479 | .8573 | 1.1431 |
| 9 | .9526 | .9526 | .8573 | 1.2384 | .9526 | .8573 | .9526 |
| 10 | .6668 | .9526 | .7716 | .9526 | .7621 | .7716 | .7621 |
| 11 | .6668 | .9526 | .7716 | .9526 | .6668 | .6001 | .7621 |
| 12 | .6668 | .9526 | .6001 | .9526 | .6668 | .6001 | .7621 |
| 13 | .7621 | .8573 | .6001 | .7621 | .6668 | .6668 | .6668 |
| 14 | .6668 | .7621 | .6668 | .5716 | .5716 | .6001 | .6668 |
| 15 | .5716 | .6668 | .6668 | .5716 | .5716 | .5144 | .6668 |
| 16 | .5716 | .6668 | .5716 | .5716 | .5144 | .6668 | .6001 |
| 17 | .5716 | .6668 | .6668 | .5716 | .6859 | .5716 | .6001 |
| 18 | .6668 | .6668 | .6668 | .6668 | .8573 | .6668 | .6859 |
| 19 | .8573 | .8573 | .8573 | .8573 | | .8573 | .6859 |
| 20 | .8573 | .8573 | .9526 | .7621 | .7716 | .8573 | .8573 |
| 21 | .8573 | .8573 | .8573 | .7621 | .7716 | .9526 | .7716 |
| 22 | .7621 | .7621 | .8573 | | .6859 | .8573 | .6859 |
| 23 | .7621 | .6668 | .7621 | .6668 | .7621 | .7621 | .6859 |
| 24 | .5144 | .7621 | .5716 | .7621 | .5716 | .6001 | .7621 |
| Max | .9526 | .9526 | 1.0479 | 1.2384 | 1.1431 | .9526 | 1.1431 |
| Min | .5144 | .6668 | .5716 | .5716 | .5144 | .5144 | .6001 |
| Avg | .7025 | .7938 | .7533 | .7828 | .7331 | .6894 | .7601 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 203 / 11 KV SHIVAJI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | 1.5242 | 1.3336 | 1.5242 | 1.2384 | 1.2003 | 1.7147 |
| 2 | 1.1145 | 1.5242 | 1.2384 | 1.5242 | 1.2384 | 1.2003 | 1.6194 |
| 3 | 1.2384 | 1.4289 | 1.2384 | 1.3336 | 1.2384 | 1.0288 | 1.5242 |
| 4 | 1.1145 | 1.4289 | 1.1431 | 1.3336 | 1.2384 | 1.0974 | 1.5242 |
| 5 | 1.1145 | 1.4289 | 1.1431 | 1.3336 | 1.3336 | 1.1431 | 1.5242 |
| 6 | 1.3336 | 1.3336 | 1.2384 | 1.2384 | 1.4289 | 1.1145 | 1.5242 |
| 7 | 1.286 | 1.2384 | 1.3336 | 1.3336 | 1.3336 | 1.2003 | 1.4289 |
| 8 | 1.4289 | 1.3336 | 1.4289 | 1.4289 | 1.3336 | 1.286 | 1.5242 |
| 9 | 1.5242 | 1.3336 | 1.5242 | 1.5242 | 1.5242 | 1.3717 | 1.5242 |
| 10 | 2.0005 | 1.2384 | 1.7147 | 1.6194 | 1.7147 | 1.5432 | 1.9052 |
| 11 | 2.191 | 1.3336 | 1.9052 | 1.9052 | 2.191 | 2.0576 | 2.2862 |
| 12 | 2.2862 | 1.2384 | 2.2862 | 1.9052 | 2.191 | 2.0576 | 2.3815 |
| 13 | 2.191 | 1.2384 | 2.2862 | 1.8099 | 1.9719 | 2.2862 | 2.191 |
| 14 | 2.0957 | 1.2384 | 2.191 | 1.7147 | 1.9719 | 2.4768 | 2.191 |
| 15 | 2.191 | 1.3336 | 2.191 | 1.6194 | 2.1434 | 2.0957 | 2.2862 |
| 16 | 2.0957 | 1.3336 | 2.191 | 1.5242 | 2.1434 | 2.0957 | 2.2862 |
| 17 | 1.9052 | 1.4289 | 2.191 | 1.5242 | 2.4006 | 2.2862 | 2.2862 |
| 18 | 2.0957 | 1.5242 | 2.3815 | 1.7147 | 2.4006 | 2.3815 | 2.572 |
| 19 | 2.0957 | 1.8099 | 2.7625 | 2.0957 | 2.572 | 2.8578 | 2.8578 |
| 20 | 1.9052 | 1.9052 | 2.7625 | 1.9052 | 2.4863 | 2.7625 | 2.6673 |
| 21 | 1.9052 | 1.6194 | 2.0957 | 1.8099 | 1.9719 | 2.191 | 1.9052 |
| 22 | 1.7147 | 1.6194 | 1.7147 | | 1.7147 | 1.8099 | 1.6194 |
| 23 | 1.5242 | 1.5242 | 1.5242 | 1.5242 | 1.4575 | 1.7147 | 1.6194 |
| 24 | 1.3336 | 1.5242 | 1.3336 | 1.5242 | 1.3336 | 1.286 | 1.7147 |
| Max | 2.2862 | 1.9052 | 2.7625 | 2.0957 | 2.572 | 2.8578 | 2.8578 |
| Min | 1.1145 | 1.2384 | 1.1431 | 1.2384 | 1.2384 | 1.0288 | 1.4289 |
| Avg | 1.7036 | 1.4368 | 1.7980 | 1.5987 | 1.7738 | 1.7727 | 1.9449 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 204 / 11 KV Civil Hospital

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .1905 | .2858 | .2858 | .2286 | .1715 | .1905 |
| 2 | .1715 | .1905 | .2858 | .2858 | .2286 | .1715 | .1905 |
| 3 | .1715 | .1905 | .2858 | .2858 | .2286 | .1905 | .1905 |
| 4 | .1715 | .1905 | .2858 | .2858 | .2286 | .1715 | .1905 |
| 5 | .1715 | .1905 | .2858 | .2858 | .2667 | .1715 | .1905 |
| 6 | .2572 | .1905 | .2858 | .2858 | .2858 | .2572 | .1905 |
| 7 | .2858 | .1905 | .2858 | .2858 | .2858 | .2572 | .2858 |
| 8 | .3429 | .1905 | .2858 | .2858 | .381 | .2572 | .381 |
| 9 | .381 | .1905 | .3429 | .2858 | .381 | .3429 | .381 |
| 10 | .4763 | .1905 | .4287 | .2858 | .4763 | .4287 | .5716 |
| 11 | .5716 | .1905 | .5144 | .2858 | .6668 | .5144 | .6668 |
| 12 | .6668 | .2858 | .5144 | .381 | .6668 | .6001 | .6668 |
| 13 | .6668 | .2858 | .5144 | .381 | .6668 | .6001 | .6668 |
| 14 | .5716 | .2858 | .5716 | .381 | .5716 | .6001 | .6668 |
| 15 | .5716 | .2858 | .5716 | .381 | .5716 | .1715 | .6668 |
| 16 | .5716 | .2858 | .6668 | .381 | .6001 | .6668 | .6001 |
| 17 | .5716 | .2858 | .5716 | .381 | .6001 | .6668 | .6001 |
| 18 | .2858 | .2858 | .5716 | .3239 | .5144 | .5716 | .5144 |
| 19 | .381 | .381 | .4763 | .381 | .5716 | .4763 | .5716 |
| 20 | .381 | .381 | .5716 | .381 | .4287 | .381 | .5144 |
| 21 | .381 | .381 | .381 | .2858 | .4763 | .4763 | .3429 |
| 22 | .2858 | .381 | .2858 | | .3429 | .1905 | .2572 |
| 23 | .1905 | .381 | .2858 | .2477 | .1715 | .1905 | .2572 |
| 24 | .1905 | .1905 | .2858 | .2858 | .2286 | .1715 | .1905 |
| Max | .6668 | .381 | .6668 | .381 | .6668 | .6668 | .6668 |
| Min | .1715 | .1905 | .2858 | .2477 | .1715 | .1715 | .1905 |
| Avg | .3703 | .2580 | .4100 | .3189 | .4195 | .3624 | .4144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 205 / 11 KV Datta Mandir

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 2 | .1715 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 3 | .1715 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 4 | .1715 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 5 | .1715 | .1905 | .1905 | .1905 | .2477 | .1905 | .1905 |
| 6 | .1715 | .1905 | .1905 | .1905 | .2667 | .1715 | .1905 |
| 7 | .1715 | .1524 | .1905 | .1905 | .2858 | .1715 | .1905 |
| 8 | .1715 | .1524 | .2858 | .1905 | .2858 | .1715 | .2858 |
| 9 | .1905 | .1905 | .1715 | .1905 | .2858 | .1715 | .1905 |
| 10 | .1905 | .1905 | .1715 | .2477 | .1905 | .1715 | .2286 |
| 11 | .1905 | .1905 | .1715 | .2477 | .1905 | .1715 | .2286 |
| 12 | .1905 | .1524 | .1715 | .1905 | .1905 | .1905 | .1905 |
| 13 | .1905 | .1905 | .1715 | .1905 | .1905 | .1715 | .1905 |
| 14 | .1905 | .1524 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 15 | .1905 | .1524 | .1905 | .1905 | .1905 | .1715 | .1905 |
| 16 | .1905 | .1524 | .1905 | .1905 | .1715 | .1905 | .1715 |
| 17 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 | .1715 |
| 18 | .1905 | .1905 | .2286 | .1905 | .1715 | .1905 | .1715 |
| 19 | .2858 | .1905 | .2858 | .1905 | .2572 | .2858 | .2572 |
| 20 | .2858 | .1905 | .2858 | .2477 | .2858 | .2858 | .2572 |
| 21 | .2858 | .1905 | .1905 | .2477 | .2572 | .2858 | .2572 |
| 22 | .1905 | .1905 | .1905 | | .1715 | .1905 | .2572 |
| 23 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 | .1715 |
| 24 | .1905 | .1905 | .1905 | .1905 | .1905 | .1715 | .1905 |
| Max | .2858 | .1905 | .2858 | .2477 | .2858 | .2858 | .2858 |
| Min | .1715 | .1524 | .1715 | .1905 | .1715 | .1715 | .1715 |
| Avg | .1961 | .1810 | .2000 | .2004 | .2135 | .1913 | .2056 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 201 / 11 KV MOHADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.572 |
| Max | 2.572 |
| Min | 2.572 |
| Avg | 2.572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 202 / 11 KV RAMWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 17 | .0857 |
| 24 | 3.9057 |
| Max | 3.9057 |
| Min | .0857 |
| Avg | 1.9957 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 203 / 11 KV MILK DAIRY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | 1.0479 |
| 24 | .6668 |
| Max | 1.0479 |
| Min | .6668 |
| Avg | .8574 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 204 / 11 KV ZANKAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .2096 |
| Max | .2096 |
| Min | .2096 |
| Avg | .2096 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 206 / 11 KV LALBAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.8578 |
| Max | 2.8578 |
| Min | 2.8578 |
| Avg | 2.8578 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 208 / 11 KV TEXTILE MILL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .4763 |
| Max | .4763 |
| Min | .4763 |
| Avg | .4763 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 402 / 33 KV Nakane

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 12.8601 |
| Max | 12.8601 |
| Min | 12.8601 |
| Avg | 12.8601 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 406 / 33 KV SOOTGIRNI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 14.289 |
| Max | 14.289 |
| Min | 14.289 |
| Avg | 14.289 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 408 / 33KV MAIN INCOMER AT MIDC

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 12.8601 |
| Max | 12.8601 |
| Min | 12.8601 |
| Avg | 12.8601 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214] BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 422 / 33 KV GONDUR (I/C)

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | | | | | 4.2867 | |
| 24 | 3.8295 | 4.2867 | 4.0009 | 4.0009 | 3.7151 | 4.2867 |
| Max | 3.8295 | 4.2867 | 4.0009 | 4.0009 | 4.2867 | 4.2867 |
| Min | 3.8295 | 4.2867 | 4.0009 | 4.0009 | 3.7151 | 4.2867 |
| Avg | 3.8295 | 4.2867 | 4.0009 | 4.0009 | 4.0009 | 4.2867 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 201 / 11 KV KALMADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .362 | .3395 | .3174 | .3258 | .3174 | .3475 | .3734 |
| 2 | .3258 | .3395 | .3361 | .3258 | .3361 | .362 | .3658 |
| 3 | .3258 | .3772 | .3292 | .3077 | .3395 | .362 | .3658 |
| 4 | .362 | .415 | .3292 | .3077 | .3734 | .362 | .3292 |
| 5 | .3982 | .4527 | .3292 | .362 | .4904 | .3982 | .4108 |
| 6 | .5249 | .4715 | .4024 | .4344 | .4904 | .4887 | .4481 |
| 7 | .5068 | .4481 | .4854 | .4938 | .4715 | .4706 | .4854 |
| 8 | .3801 | .3547 | .3189 | .362 | .3142 | .362 | .3292 |
| 9 | .3961 | .3547 | .2614 | .2715 | .3174 | .3258 | .2987 |
| 10 | .4481 | .2427 | .2614 | .4108 | .3258 | .3361 | .2801 |
| 11 | .3018 | .2241 | .2614 | .3206 | .3801 | .3734 | .2987 |
| 12 | .3772 | .2241 | .2743 | .3018 | .3077 | .3734 | .3206 |
| 13 | .3772 | .2241 | .2172 | .2614 | .2715 | .2561 | .2801 |
| 14 | .3547 | | .2172 | .2263 | .2328 | .2561 | .2452 |
| 15 | .3361 | .2241 | .2353 | .2452 | .362 | .2743 | |
| 16 | .3361 | .2195 | .2715 | .2263 | .3077 | .2926 | .3018 |
| 17 | .3584 | .2241 | .3045 | .2241 | .3801 | .2926 | .3018 |
| 18 | .3584 | .2614 | .3077 | .2195 | .4163 | .3734 | .2614 |
| 19 | .4338 | .3361 | .4938 | .3696 | .5068 | .4854 | .4904 |
| 20 | .3772 | .4481 | .4344 | .4294 | .4706 | .4854 | .4854 |
| 21 | .3772 | .4481 | .4163 | .415 | .4344 | .4854 | .4527 |
| 22 | .3584 | .3734 | .3982 | .415 | .4344 | .4207 | |
| 23 | .3395 | .3361 | .3801 | .3734 | .4024 | .439 | .3734 |
| 24 | .3801 | .3395 | .3109 | .3841 | .3395 | .362 | .4207 |
| Max | .5249 | .4715 | .4938 | .4938 | .5068 | .4887 | .4904 |
| Min | .3018 | .2195 | .2172 | .2195 | .2328 | .2561 | .2452 |
| Avg | .3790 | .3338 | .3289 | .3339 | .3759 | .3744 | .3599 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 202 / 11 KV WARUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8322 | .6497 | .5144 | .7282 | | | |
| 2 | .8215 | .6811 | .543 | .743 | | | |
| 3 | .8471 | .5906 | .543 | .7133 | | | |
| 4 | .8509 | .6584 | .543 | .6984 | | | |
| 5 | .8916 | .7148 | .743 | .6836 | | | |
| 6 | .9362 | .8916 | .8109 | .7335 | | | |
| 7 | 1.2631 | 1.0669 | .8322 | 1.1145 | | | |
| 8 | | .1943 | .7727 | 1.0402 | | | |
| 9 | .5639 | .2401 | .7716 | .8916 | | | |
| 10 | | | | | .639 | | .8901 |
| 11 | | | | | .4161 | .7133 | 1.0536 |
| 12 | | | | | .5201 | .743 | 1.2967 |
| 13 | | | | | .5944 | .9145 | 1.2342 |
| 14 | | | | | 1.0402 | .9846 | .2724 |
| 15 | | | | | 1.2334 | 1.07 | .7145 |
| 16 | | | | | 1.448 | 1.0997 | .7232 |
| 17 | | | | | 1.1591 | 1.4632 | .8505 |
| 24 | .7876 | .4001 | | .6984 | | | |
| Max | 1.2631 | 1.0669 | .8322 | 1.1145 | 1.448 | 1.4632 | 1.2967 |
| Min | .5639 | .1943 | .5144 | .6836 | .4161 | .7133 | .2724 |
| Avg | .8660 | .6088 | .6749 | .8045 | .8813 | .9983 | .8794 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 203 / 11 KV NARDANA TOWN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .362 | .3292 | .4024 | .4024 | .3582 | .3982 | .3734 |
| 2 | .362 | .3326 | .4024 | .362 | .3982 | .3982 | .3361 |
| 3 | .3258 | .3511 | .3658 | .3982 | .3982 | .3982 | .3292 |
| 4 | .362 | .3658 | .3658 | .3982 | .4298 | .4163 | .3292 |
| 5 | .362 | .3696 | .394 | .4207 | .4706 | .4163 | .3658 |
| 6 | .4163 | .4108 | .3269 | .4344 | .4706 | .4706 | .439 |
| 7 | .4706 | .5228 | .4755 | .5121 | .5228 | .5068 | .5121 |
| 8 | .4298 | .4557 | .4755 | .4887 | .439 | .4344 | .4481 |
| 9 | .3772 | .4207 | .439 | .4344 | .439 | .4163 | .4024 |
| 10 | .3506 | .3856 | .3506 | .4075 | .3982 | .3734 | .3856 |
| 11 | .4207 | .4207 | .3658 | .4252 | .362 | .3506 | .3544 |
| 12 | .3898 | .4481 | .4024 | .4252 | .3982 | .3658 | .3582 |
| 13 | .3582 | .439 | .3582 | .3898 | .3982 | .3258 | .3582 |
| 14 | .3582 | .439 | .3982 | .394 | .362 | .3292 | .3582 |
| 15 | .3544 | .439 | .362 | .4252 | .4344 | .3658 | .3544 |
| 16 | .3856 | .4755 | .4163 | .4252 | .4163 | .3658 | .394 |
| 17 | .3898 | .4755 | .4163 | .4207 | .3801 | .4024 | .3898 |
| 18 | .4298 | .4755 | .4344 | .4115 | .4163 | .439 | .3898 |
| 19 | .4961 | .5487 | .4887 | .4908 | .4706 | .5121 | .4908 |
| 20 | .5014 | .5601 | .5304 | .5014 | .4733 | .4755 | .5014 |
| 21 | .4706 | .5228 | .4706 | .4656 | .4525 | .4755 | .4706 |
| 22 | .439 | .4755 | .4525 | .4298 | .4344 | .439 | .4706 |
| 23 | .4024 | .4755 | .4572 | .4298 | .4344 | .439 | .4024 |
| 24 | .3982 | .362 | .4207 | .4163 | .394 | .4163 | .4024 |
| Max | .5014 | .5601 | .5304 | .5121 | .5228 | .5121 | .5121 |
| Min | .3258 | .3292 | .3269 | .362 | .3582 | .3258 | .3292 |
| Avg | .4005 | .4375 | .4155 | .4295 | .4230 | .4138 | .4007 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 204 / 11KV CHANDGAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .5201 | .7133 | .743 |
| 2 | | | | | .5361 | .6984 | .9511 |
| 3 | | | | | .5617 | .7133 | .9335 |
| 4 | | | | | .5617 | .7335 | 1.0608 |
| 5 | | | | | .583 | .7727 | .9214 |
| 6 | | | | | .5916 | .7876 | 1.3169 |
| 7 | | | | | .823 | .9659 | 1.3169 |
| 8 | | | | | .823 | .9957 | 1.07 |
| 9 | | | | | .8251 | 1.0536 | 1.0974 |
| 10 | 1.0669 | .8573 | .8859 | .8573 | | | |
| 11 | 1.3123 | 1.0288 | .9717 | 1.0848 | | | |
| 12 | 1.2193 | 1.39 | 1.07 | .9957 | | | |
| 13 | 1.1126 | 1.0402 | .9511 | .9267 | | | |
| 14 | .9095 | .9511 | .9214 | .8459 | | | |
| 15 | .8535 | .9808 | .8916 | .8859 | | | |
| 16 | .9191 | 1.2437 | 1.2127 | .9829 | | | |
| 17 | .8002 | 1.0402 | .9659 | .8859 | | | |
| 24 | | | | | .7526 | .743 | .8025 |
| Max | 1.3123 | 1.39 | 1.2127 | 1.0848 | .8251 | 1.0536 | 1.3169 |
| Min | .8002 | .8573 | .8859 | .8459 | .5201 | .6984 | .743 |
| Avg | 1.0242 | 1.0665 | .9838 | .9331 | .6578 | .8177 | 1.0214 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 205 / 11KV INDUSTRIAL NARDANA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7783 | .7762 | .8048 | .181 | .2774 | .8145 | .8215 |
| 2 | .8145 | .7842 | .8048 | .1829 | .2058 | .8048 | .7468 |
| 3 | .8326 | .7468 | .7316 | .181 | .208 | .8145 | .8215 |
| 4 | .8145 | .7842 | .8048 | .181 | .2401 | .8507 | .8048 |
| 5 | .905 | .8215 | .8048 | .1753 | .2427 | .9412 | .8779 |
| 6 | .9774 | .8215 | .8779 | .1772 | .2804 | .9231 | .8048 |
| 7 | .9412 | .8676 | .8048 | .1791 | .2103 | .724 | .8048 |
| 8 | .6335 | .7842 | .695 | .567 | .5373 | .8145 | .2614 |
| 9 | .7842 | .8962 | .8048 | .6335 | .9808 | .724 | .8962 |
| 10 | 1.0456 | .8215 | .7316 | .4525 | .9412 | .6733 | .8962 |
| 11 | 1.0456 | .7468 | .7316 | .5014 | .905 | .8962 | .8676 |
| 12 | .7922 | .8215 | .7316 | .5373 | .8688 | .9145 | .8589 |
| 13 | .9431 | .8962 | .7964 | .4961 | .905 | .8063 | .9709 |
| 14 | .9808 | .8215 | .7712 | .3086 | .7783 | .788 | 1.0456 |
| 15 | .9808 | .8215 | .724 | .3856 | .9412 | .8779 | .9808 |
| 16 | .8215 | .8048 | .4075 | .4161 | .8507 | .8048 | .7545 |
| 17 | .7545 | .8215 | .4252 | .394 | .8326 | .7316 | .8299 |
| 18 | .8962 | .6722 | .362 | .3258 | .724 | .8048 | .7842 |
| 19 | .9054 | .7316 | .3898 | .5068 | .8507 | .8962 | .9808 |
| 20 | .8962 | .8215 | .4031 | .4557 | .8145 | .8215 | .8215 |
| 21 | .8589 | .8779 | .3982 | .463 | .8145 | .8048 | .8299 |
| 22 | .8676 | .9511 | .362 | .4854 | .7316 | .8048 | .7842 |
| 23 | .8962 | .8779 | .4075 | .4557 | .6335 | .8962 | .8215 |
| 24 | .7602 | .8962 | .8779 | .1949 | .2401 | .7783 | .9511 |
| Max | 1.0456 | .9511 | .8779 | .6335 | .9808 | .9412 | 1.0456 |
| Min | .6335 | .6722 | .362 | .1753 | .2058 | .6733 | .2614 |
| Avg | .8719 | .8194 | .6522 | .3682 | .6256 | .8213 | .8341 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 206 / 11 KV WARUD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1267 | .1052 | .1463 | .1267 | .1254 | .1267 | .1227 |
| 2 | .1254 | .124 | .1227 | .1267 | .1254 | .1267 | .1307 |
| 3 | .124 | .1254 | .124 | .1267 | .1254 | .124 | .1097 |
| 4 | .1267 | .1254 | .1097 | .1267 | .1433 | .1433 | .1097 |
| 5 | .1448 | .1448 | .1097 | .124 | .1448 | | .1097 |
| 6 | .1433 | .1448 | .128 | .1448 | .1629 | .1448 | .1463 |
| 7 | .1433 | .1629 | .1715 | .1448 | .1463 | .1629 | .1463 |
| 8 | .1417 | .1402 | .1433 | .1448 | .1227 | .1267 | .1494 |
| 9 | .1372 | .12 | .128 | .1433 | .12 | .124 | .1463 |
| 10 | .1029 | .1029 | .128 | .1174 | .1086 | .1227 | .1227 |
| 11 | .0701 | .1029 | .128 | .1174 | .1086 | .1097 | .1214 |
| 12 | .104 | .1052 | .1227 | .1341 | .124 | .0701 | .12 |
| 13 | .104 | .1227 | .1267 | .1187 | .1433 | .1097 | .1341 |
| 14 | .1052 | .1463 | .1448 | .1341 | .1417 | .1097 | .1326 |
| 15 | .1174 | .1463 | .1448 | .1147 | .1448 | .1097 | .1134 |
| 16 | .1372 | .1402 | .1448 | .128 | .1448 | .128 | .1296 |
| 17 | .1543 | .1494 | .1448 | .1341 | .181 | .1463 | .1296 |
| 18 | .156 | .1402 | .1448 | .1311 | .181 | .1829 | .1311 |
| 19 | .1753 | .1753 | .181 | .1619 | .1791 | .2195 | .1715 |
| 20 | .1772 | .1829 | .1928 | .2058 | .181 | .1829 | .1791 |
| 21 | .1612 | .1753 | .1772 | .1772 | .1448 | .1867 | .1791 |
| 22 | .1433 | .1753 | .1402 | .1753 | .1433 | .1829 | .181 |
| 23 | .1448 | .1463 | .1417 | .1595 | .1448 | .1829 | .1448 |
| 24 | .1254 | .1254 | .128 | .1448 | .1448 | .1433 | .1463 |
| Max | .1772 | .1829 | .1928 | .2058 | .181 | .2195 | .181 |
| Min | .0701 | .1029 | .1097 | .1147 | .1086 | .0701 | .1097 |
| Avg | .1330 | .1387 | .1406 | .1401 | .1430 | .1420 | .1378 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 207 / 11 KV CHANDGAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4207 | .4755 | .439 | .4525 | .4481 | .4525 | .439 |
| 2 | .4163 | .4344 | .4024 | .4344 | .4854 | .4525 | .4024 |
| 3 | .4163 | .439 | .4024 | .4525 | .5228 | .4887 | .4024 |
| 4 | .4656 | .4755 | .439 | .4887 | .6413 | .5249 | .4024 |
| 5 | .5973 | .6283 | .4755 | .5792 | .8299 | .5973 | .695 |
| 6 | .8954 | .9335 | .8779 | .905 | .9808 | .9412 | .7796 |
| 7 | .9955 | .9335 | .9145 | 1.0498 | .9808 | .9955 | 1.0608 |
| 8 | .7783 | .6878 | .6348 | .724 | .6653 | .724 | .7316 |
| 9 | .6135 | .5068 | .6219 | .543 | .6154 | .7602 | .6584 |
| 10 | .5316 | .3982 | .5853 | .7011 | .724 | .7682 | .6447 |
| 11 | .5895 | .4706 | .6516 | .6935 | .6516 | .7011 | .8596 |
| 12 | .5609 | .4755 | .7011 | .6661 | .724 | .8779 | .8764 |
| 13 | .5068 | .5853 | .724 | .6733 | .7602 | .8048 | .823 |
| 14 | .439 | .6348 | .6154 | .7011 | .5973 | .7316 | .583 |
| 15 | .3856 | .6584 | .543 | .7362 | .8507 | .695 | .6226 |
| 16 | .3856 | .6219 | .5792 | .7712 | .8145 | .7316 | .6478 |
| 17 | .4706 | .6584 | .724 | .7537 | .8507 | .8048 | .7042 |
| 18 | .5853 | .6219 | .8507 | .7125 | .724 | .8048 | .6706 |
| 19 | .7316 | .6584 | .8059 | .6219 | .7783 | .7468 | .6733 |
| 20 | .6584 | .6219 | .6697 | .6653 | .6697 | .6584 | .6447 |
| 21 | .6219 | .6219 | .6335 | .6219 | .6154 | .695 | .6154 |
| 22 | .5853 | .5487 | .5973 | .5487 | .5973 | .5487 | .5853 |
| 23 | .5121 | .5121 | .5373 | .5121 | .543 | .5487 | .5853 |
| 24 | .4706 | .4755 | .4755 | .5068 | .4527 | .5121 | .4755 |
| Max | .9955 | .9335 | .9145 | 1.0498 | .9808 | .9955 | 1.0608 |
| Min | .3856 | .3982 | .4024 | .4344 | .4481 | .4525 | .4024 |
| Avg | .5681 | .5866 | .6209 | .6464 | .6885 | .6903 | .6493 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 6.7901 |
| Max | 6.7901 |
| Min | 6.7901 |
| Avg | 6.7901 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / 33/11 KV SUB NARDANA

Feeder No / Name : 242 / 11 KV INCOMER II

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .8029 |
| Max | .8029 |
| Min | .8029 |
| Avg | .8029 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 201 / 11 KV SAWALDE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | 1.1022 |
| 2 | 1.153 |
| 3 | 1.153 |
| 4 | 1.1869 |
| 5 | 1.1869 |
| 6 | 1.2039 |
| 7 | 1.2039 |
| 8 | 1.2209 |
| 9 | 1.2209 |
| 24 | 1.1022 |
| Max | 1.2209 |
| Min | 1.1022 |
| Avg | 1.1734 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 203 / 11 KV BALDE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 05-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0324 |
| Max | .0324 |
| Min | .0324 |
| Avg | .0324 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 204 / 11 KV DABHASHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | 1.4413 | 1.3226 | 1.1869 |
| 2 | | | | | 1.3735 | 1.3226 | 1.1869 |
| 3 | | | | | 1.3279 | 1.3565 | 1.2887 |
| 4 | | | | | 1.3717 | 1.3565 | 1.2548 |
| 5 | | | | | 1.3565 | 1.3565 | 1.2887 |
| 6 | | | | | 1.5261 | | 1.3565 |
| 7 | | | | | 1.5261 | 1.3735 | 1.4413 |
| 8 | | | | | 1.6108 | 1.4413 | 1.4922 |
| 9 | | | | | 1.4575 | 1.4922 | 1.56 |
| 10 | 1.6617 | 1.5261 | 1.5261 | 1.5432 | | | |
| 11 | 1.6787 | 1.9109 | 1.8991 | 1.4918 | | | |
| 12 | 1.9669 | 1.9433 | 1.9161 | 1.7147 | | | |
| 13 | 1.933 | 1.8623 | 1.8821 | 1.6575 | | | |
| 14 | 1.6448 | 1.7814 | 1.8991 | 1.6108 | | | |
| 15 | 1.8482 | 1.7004 | 1.95 | 1.5261 | | | |
| 16 | 1.8482 | 1.6194 | 1.7804 | 1.5261 | | | |
| 17 | 1.8482 | 1.6194 | 1.7635 | 1.5432 | | | |
| 18 | | 1.6194 | | | | | |
| 24 | | | | | 1.3565 | 1.2548 | |
| Max | 1.9669 | 1.9433 | 1.95 | 1.7147 | 1.6108 | 1.4922 | 1.56 |
| Min | 1.6448 | 1.5261 | 1.5261 | 1.4918 | 1.3279 | 1.2548 | 1.1869 |
| Avg | 1.8037 | 1.7314 | 1.8271 | 1.5767 | 1.4348 | 1.3641 | 1.3396 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 205 / 11KV EXPRESS MIDC WATER NON SHEDDABLE WATER SUPPLY AND
WORKS Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 2 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 3 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 4 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 5 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 6 | .0324 | .0324 | .0324 | .0324 | .0339 | .0339 | .0324 |
| 7 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 8 | .0324 | .0324 | .0324 | .0324 | .0324 | .0339 | .0324 |
| 9 | .081 | .0324 | .081 | .081 | .081 | .0339 | .0324 |
| 10 | .081 | .081 | .081 | .0829 | .081 | .0848 | .081 |
| 11 | .081 | .0876 | .081 | .081 | .0848 | .0876 | .081 |
| 12 | .081 | .0876 | .081 | .0829 | .0848 | .0876 | .081 |
| 13 | .081 | .0876 | .081 | .081 | .0848 | .0876 | .081 |
| 14 | .081 | .0876 | .081 | .081 | .0339 | .0876 | .081 |
| 15 | .081 | .0351 | .0324 | .0324 | .0339 | .0876 | .081 |
| 16 | .081 | .0351 | .0324 | .0324 | .0339 | .0351 | .081 |
| 17 | .0324 | .0351 | .0324 | .0324 | .0339 | .0351 | .0324 |
| 18 | .0324 | .0351 | .0324 | .0324 | .0339 | .0351 | .0324 |
| 19 | .0324 | .0351 | .0324 | .0324 | .0339 | .0351 | .0324 |
| 20 | .0324 | .0351 | .0324 | .0324 | .0339 | .0351 | .0324 |
| 21 | .0324 | .0351 | .0324 | .0324 | .0339 | .0351 | .0324 |
| 22 | .0324 | .0351 | .0324 | .0324 | .0343 | .0351 | .0324 |
| 23 | .0324 | .0351 | .0324 | .0324 | | .0351 | .0324 |
| 24 | .0324 | .0324 | | .0312 | .0324 | .0339 | |
| Max | .081 | .0876 | .081 | .0829 | .0848 | .0876 | .081 |
| Min | .0324 | .0324 | .0324 | .0312 | .0324 | .0339 | .0324 |
| Avg | .0486 | .0446 | .0451 | .0447 | .0441 | .0476 | .0472 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 206 / 11 KV DABHASHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1619 | .1619 | .1943 | .1943 | .2753 | .2883 | .2753 |
| 2 | .1619 | .1619 | .1943 | .1943 | .2591 | .2883 | .2753 |
| 3 | .1943 | .1943 | .2267 | .2267 | .2591 | .2883 | .2753 |
| 4 | .2429 | .2429 | .2915 | .2591 | .2591 | .3052 | .3077 |
| 5 | .2753 | .2915 | .3563 | .2915 | .2915 | .3561 | .3725 |
| 6 | .4534 | .4534 | .4534 | .4696 | .3239 | .4115 | .4534 |
| 7 | .4372 | .4696 | .4858 | .4372 | .4372 | .4578 | .4858 |
| 8 | .3077 | .3401 | .421 | .3563 | .3315 | .3391 | .3563 |
| 9 | .2753 | .2915 | .3077 | .2915 | .2984 | .2713 | .2753 |
| 10 | .2105 | .2591 | .2429 | .2753 | .2591 | .2543 | .2591 |
| 11 | .2105 | .2804 | .2429 | .2753 | .2374 | .2629 | .2429 |
| 12 | .1781 | .2629 | .2267 | .2591 | .2374 | .2629 | .2267 |
| 13 | .1943 | .2629 | .2429 | .2591 | .2204 | .2629 | .1943 |
| 14 | .2105 | .2804 | .2429 | .2591 | .2204 | .298 | .1943 |
| 15 | .2267 | .298 | .2267 | .2753 | .2204 | .298 | .1943 |
| 16 | .2267 | .298 | .2429 | .2591 | .2374 | .3155 | .2105 |
| 17 | .2753 | .298 | .2343 | .2591 | .2713 | .3155 | .2267 |
| 18 | .2915 | .333 | .2753 | .2591 | .3222 | .333 | .2429 |
| 19 | .2915 | .3856 | .3077 | .2591 | .3391 | .3506 | .2753 |
| 20 | .3077 | .4031 | .3563 | .3563 | .3601 | .3856 | .3239 |
| 21 | .3239 | .3681 | .3077 | .3561 | .373 | .3506 | .3239 |
| 22 | .2429 | .3155 | .2267 | .3239 | .3391 | .333 | .2429 |
| 23 | .1943 | .298 | .1943 | .3239 | .3052 | .3155 | .1943 |
| 24 | .1619 | .1619 | | .1943 | .3239 | .2883 | |
| Max | .4534 | .4696 | .4858 | .4696 | .4372 | .4578 | .4858 |
| Min | .1619 | .1619 | .1943 | .1943 | .2204 | .2543 | .1943 |
| Avg | .2523 | .2963 | .2827 | .2881 | .2917 | .3180 | .2795 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 KV SUB SUKWAD

Feeder No / Name : 207 / 11 KV TAWKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | .1296 |
| 2 | .1296 |
| 3 | .1619 |
| 4 | .1943 |
| 5 | .2429 |
| 6 | .4372 |
| 7 | .421 |
| 8 | .2753 |
| 9 | .2105 |
| 10 | .1943 |
| 11 | .1619 |
| 12 | .1619 |
| 13 | .2267 |
| 14 | .2429 |
| 15 | .2267 |
| 24 | .1296 |
| Max | .4372 |
| Min | .1296 |
| Avg | .2216 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 201 / 11KV INDUSTRIAL SONGIR
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2804 | .2534 | .2103 | .2103 | .2561 | .2629 | .2804 |
| 2 | .2804 | .2454 | .2103 | .1753 | .2279 | .2454 | .298 |
| 3 | .2454 | .2715 | .2103 | .1753 | .2172 | .2279 | .298 |
| 4 | .2454 | .2896 | .2103 | .2103 | .2149 | .2279 | .2804 |
| 5 | .2454 | .2534 | .2103 | .2103 | .2353 | .2454 | .2804 |
| 6 | .2454 | .2279 | .2103 | .2103 | .2172 | .2454 | .2804 |
| 7 | .2454 | .2172 | .2103 | .1753 | .1928 | .2279 | .2804 |
| 8 | .2454 | .1753 | .1928 | .1928 | .181 | .2103 | .2454 |
| 9 | .2804 | .4733 | .1928 | .2629 | .2534 | .2279 | .2804 |
| 10 | .3506 | .2286 | .2103 | .3856 | .2103 | .2454 | .2804 |
| 11 | .3506 | .2103 | .4908 | .4207 | .3856 | .4557 | .2454 |
| 12 | .3506 | .2103 | .6661 | .3121 | .4207 | .4557 | .2454 |
| 13 | .4207 | .2103 | .4908 | .3155 | .3155 | .2804 | .2454 |
| 14 | .2804 | .2103 | .4207 | .3982 | .4908 | .3155 | .2454 |
| 15 | .4207 | .1928 | .4908 | .4344 | .3155 | .3155 | .4908 |
| 16 | .4207 | .1928 | .4908 | .3988 | .3155 | | .4382 |
| 17 | .4207 | .1928 | | .3856 | .3856 | .2804 | .4382 |
| 18 | .3506 | .2103 | .4908 | .3506 | .4207 | .2804 | .4557 |
| 19 | .4207 | .1928 | .2804 | | .2804 | .3155 | .4344 |
| 20 | .4344 | .2454 | .2804 | .3801 | .3506 | .2804 | .4525 |
| 21 | .4525 | .2804 | .2629 | .3467 | .3856 | .2804 | .362 |
| 22 | .2896 | .2804 | .2454 | .2896 | .298 | .2804 | .3077 |
| 23 | .2896 | .0701 | .2103 | .2534 | .2804 | .3155 | .3109 |
| 24 | .3155 | .3077 | .2454 | .2454 | .2534 | .2629 | .2804 |
| Max | .4525 | .4733 | .6661 | .4344 | .4908 | .4557 | .4908 |
| Min | .2454 | .0701 | .1928 | .1753 | .181 | .2103 | .2454 |
| Avg | .3284 | .2351 | .3102 | .2930 | .2960 | .2820 | .3232 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 202 / 11KV NANDANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5074 | 1.3279 | 1.5074 | 1.4723 | .4191 | .3856 | .3856 |
| 2 | 1.5775 | 1.4217 | 1.5775 | 1.56 | .4001 | .3856 | .3856 |
| 3 | 1.8229 | 1.6604 | 1.5775 | 1.6126 | .4954 | .3856 | .4207 |
| 4 | 1.8755 | 1.7029 | 1.6651 | 1.6827 | .5525 | .5609 | .5609 |
| 5 | 1.9631 | 1.7497 | 1.8404 | 1.8755 | .6478 | .7011 | .7186 |
| 6 | 2.1735 | 1.9271 | 2.1209 | 1.9631 | .8764 | .7888 | .8413 |
| 7 | 2.2786 | 2.0081 | 2.0858 | 2.226 | .8954 | .8063 | |
| 8 | 1.8054 | 2.1209 | 1.9456 | 2.191 | .6478 | .5609 | .5959 |
| 9 | 1.6301 | 2.0508 | 1.7353 | 2.1209 | .4706 | .4382 | .3856 |
| 10 | .3155 | .4001 | .3856 | .4382 | 1.4373 | 1.7002 | |
| 11 | .298 | .2804 | .2804 | .2667 | 1.9105 | 2.0508 | |
| 12 | .2454 | .2629 | .2454 | .2477 | 1.9281 | 1.893 | |
| 13 | .2103 | .2629 | .2279 | | 1.9281 | 1.8054 | |
| 14 | .2279 | .2629 | .2629 | .2858 | 1.9105 | 1.858 | 1.5775 |
| 15 | .298 | .2804 | .298 | .2858 | 1.9281 | 1.858 | 1.8785 |
| 16 | .298 | .333 | .4908 | .3048 | 1.9631 | 1.9281 | 2.1384 |
| 17 | .298 | .333 | | .3239 | 1.7703 | 1.7703 | 1.893 |
| 18 | .7049 | .4207 | .3681 | .4001 | .3856 | .3856 | .5144 |
| 19 | .6859 | .7362 | .631 | | .5083 | .6661 | .7049 |
| 20 | .7049 | .6661 | .5784 | .7049 | .4908 | .5434 | .6859 |
| 21 | .5335 | .4557 | .5258 | .5335 | .4908 | .4908 | .5335 |
| 22 | .4382 | .4207 | .4557 | .4763 | .4733 | .4557 | .4954 |
| 23 | .4001 | .3856 | .4031 | .4191 | .3856 | .3856 | .4382 |
| 24 | 1.3672 | 1.3279 | 1.4723 | 1.4198 | .4572 | .3681 | .3856 |
| Max | 2.2786 | 2.1209 | 2.1209 | 2.226 | 1.9631 | 2.0508 | 2.1384 |
| Min | .2103 | .2629 | .2279 | .2477 | .3856 | .3681 | .3856 |
| Avg | .9858 | .9499 | .9861 | 1.0369 | .9739 | .9655 | .8179 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 203 / 11KV DEOBHANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8229 | 1.4089 | 1.7878 | 1.7002 | .4001 | .3856 | .3856 |
| 2 | 1.8404 | 1.4251 | 1.893 | 1.7878 | .4001 | .3506 | .3506 |
| 3 | 1.8404 | 1.4089 | 1.893 | 1.9105 | .4191 | .3506 | .4207 |
| 4 | 1.9631 | 1.4089 | 1.9806 | 1.9631 | .4191 | .4908 | .4908 |
| 5 | 2.0858 | 1.8461 | 2.0508 | 2.0332 | .5525 | .5609 | .5959 |
| 6 | 2.4188 | 2.0934 | 2.3137 | 2.0858 | .7811 | .7362 | .7888 |
| 7 | 2.6818 | 2.5263 | 2.5941 | 2.4188 | .724 | .6661 | .6836 |
| 8 | 2.1384 | 2.5065 | 2.0508 | 2.4539 | .5144 | .4382 | .4908 |
| 9 | 1.893 | 2.3487 | 2.0157 | 2.191 | .381 | .298 | .298 |
| 10 | .2103 | .3239 | .2279 | .362 | 1.4022 | 2.0157 | 1.8755 |
| 11 | .2804 | .298 | .2629 | .3048 | 2.4539 | 2.4714 | 2.4013 |
| 12 | .2804 | .3155 | .2804 | .3048 | 2.5591 | 2.4539 | 2.2786 |
| 13 | .2804 | .3155 | .2454 | .2667 | | 2.3312 | 2.3137 |
| 14 | .298 | .3155 | .2804 | .3048 | 2.3838 | 2.2436 | 2.3487 |
| 15 | .2804 | .3155 | .2804 | .3239 | 2.3487 | 2.2786 | 1.9997 |
| 16 | .298 | .3155 | .2804 | .3048 | 2.4188 | 2.2611 | 2.1735 |
| 17 | .3155 | .3155 | | .3239 | 2.191 | 2.1559 | 1.9105 |
| 18 | .3429 | .3506 | .333 | .3429 | .3155 | .298 | .3239 |
| 19 | .5525 | .5083 | .4908 | | .4908 | .5083 | .5144 |
| 20 | .6478 | .5258 | .5434 | .6478 | .5083 | .5609 | .6478 |
| 21 | .5906 | .5258 | .4908 | .5525 | .5083 | .5258 | .5716 |
| 22 | .4954 | .4733 | .4557 | .0381 | .4733 | .4733 | .4954 |
| 23 | .4191 | .4207 | .4207 | .4191 | .4207 | .4382 | .4763 |
| 24 | 1.6476 | 1.4089 | 1.5424 | 1.4373 | .4382 | .4031 | .4031 |
| Max | 2.6818 | 2.5263 | 2.5941 | 2.4539 | 2.5591 | 2.4714 | 2.4013 |
| Min | .2103 | .298 | .2279 | .0381 | .3155 | .298 | .298 |
| Avg | 1.0677 | .9875 | 1.0745 | 1.0642 | 1.0219 | 1.0707 | 1.0516 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 204 / 11KV WAGHADI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3155 | .381 | .333 | .3155 | .7611 | .9114 | .9465 |
| 2 | .3155 | .381 | .3155 | .3155 | .7655 | .8413 | .9816 |
| 3 | .3681 | .4001 | .3155 | .3155 | .8162 | .8413 | .9816 |
| 4 | .4908 | .4572 | .3856 | .3681 | .8745 | .8413 | 1.0166 |
| 5 | .5609 | .5906 | .5434 | | .8642 | .8589 | 1.0867 |
| 6 | .6485 | .7621 | .7011 | .6661 | .8796 | 1.0517 | 1.1919 |
| 7 | .6836 | .743 | .6661 | .6661 | .9877 | 1.2269 | 1.3321 |
| 8 | .4733 | .4908 | .4207 | .4382 | 1.0155 | 1.1919 | 1.2795 |
| 9 | .3155 | .3506 | .2804 | .1928 | .9555 | 1.1744 | 1.2269 |
| 10 | 1.0692 | 1.1812 | .8063 | .6718 | .2804 | .2629 | .3155 |
| 11 | 1.4373 | 1.4723 | 1.1744 | 1.1717 | .2279 | .2279 | .2103 |
| 12 | 1.4899 | 1.4548 | 1.1568 | 1.1174 | .2103 | .2279 | .2103 |
| 13 | 1.3672 | 1.3672 | 1.1218 | 1.1227 | .2279 | .2454 | .2454 |
| 14 | 1.2971 | 1.1568 | 1.1393 | 1.0753 | .2804 | .2629 | .2454 |
| 15 | 1.3847 | 1.1218 | 1.1218 | .9998 | .2804 | .2629 | .2858 |
| 16 | 1.262 | 1.1218 | 1.1568 | 1.0155 | .2804 | .2629 | .2629 |
| 17 | 1.267 | 1.0692 | | .9998 | .2804 | .2454 | .2804 |
| 18 | .4954 | .3681 | .2454 | .2858 | .2804 | .2804 | .2858 |
| 19 | .5716 | .5083 | .4908 | | .4207 | .5083 | .5716 |
| 20 | .381 | .4733 | .5083 | .5525 | .4207 | .4557 | .5906 |
| 21 | .4572 | .4382 | .4557 | .4954 | .4207 | .4382 | .4763 |
| 22 | .4382 | .3681 | .4031 | .4001 | .3856 | .4031 | .4572 |
| 23 | | .3506 | .3506 | .381 | .3506 | .3681 | .4001 |
| 24 | .3155 | .381 | .333 | .333 | .7611 | .8063 | .7888 |
| Max | 1.4899 | 1.4723 | 1.1744 | 1.1717 | 1.0155 | 1.2269 | 1.3321 |
| Min | .3155 | .3506 | .2454 | .1928 | .2103 | .2279 | .2103 |
| Avg | .7567 | .7245 | .6272 | .6318 | .5428 | .5916 | .6529 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 205 / 11KV SONGIR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5609 | .5959 | .6135 |
| 2 | | .5784 | .5959 | .5784 |
| 3 | | .5959 | .5959 | .5784 |
| 4 | | .6135 | .5959 | .5784 |
| 5 | | .6661 | .6485 | .6485 |
| 6 | | .6687 | .8764 | .6485 |
| 7 | | .8238 | .7888 | .7888 |
| 8 | | .7888 | .7537 | .7186 |
| 9 | | .7537 | .7186 | .7186 |
| 10 | | .631 | .631 | .6661 |
| 11 | | .6485 | .6135 | .7011 |
| 12 | | .5959 | .5959 | .631 |
| 13 | | .631 | .6485 | .7011 |
| 14 | | .631 | .5959 | .631 |
| 15 | | .6836 | .6135 | |
| 16 | | .6485 | | .7186 |
| 17 | | .7011 | | |
| 18 | | .7712 | .6135 | .724 |
| 19 | | .8764 | .5083 | .8413 |
| 20 | | .8764 | 1.0166 | .8507 |
| 21 | | .7888 | .8764 | .7712 |
| 22 | | .7537 | .8238 | .7362 |
| 23 | | .7186 | .7362 | .724 |
| 24 | .6485 | .6135 | .6485 | .6836 |
| Max | .6485 | .8764 | 1.0166 | .8507 |
| Min | .6485 | .5609 | .5083 | .5784 |
| Avg | .6485 | .6925 | .6860 | .6933 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 206 / 11 KV EXPRESS 765 KV BDTCL NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0526 | .0526 | .0526 | .0526 | .0543 | .0526 | .0526 |
| 2 | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 |
| 3 | .0526 | .0537 | .0526 | .0526 | .0526 | .0526 | .0526 |
| 4 | .0526 | .0526 | .0526 | .0526 | .0543 | .0526 | .0526 |
| 5 | .0526 | .052 | .0526 | .0543 | .0543 | .0526 | .0526 |
| 6 | .0526 | .0537 | .0526 | .0526 | .0526 | .0526 | .0526 |
| 7 | .0351 | .0362 | .0351 | .0351 | .0362 | .0351 | .0351 |
| 8 | .0351 | .0175 | .0175 | .0175 | .0175 | .0175 | .0351 |
| 9 | .0175 | .0175 | .0175 | .0526 | .0526 | .0175 | .0351 |
| 10 | .0175 | | .0175 | .0179 | .0175 | .0175 | .0175 |
| 11 | .0526 | .0175 | .0526 | .0175 | .0175 | .0175 | .0351 |
| 12 | .0351 | .0175 | .0526 | .0351 | .0351 | .0175 | .0351 |
| 13 | .0351 | .0175 | .0526 | .0351 | .0351 | .0175 | .0351 |
| 14 | .0526 | | .0526 | .0362 | .0526 | .0175 | .0351 |
| 15 | .0351 | .0175 | .0377 | .0351 | .0351 | .0175 | .0543 |
| 16 | .0351 | .0351 | .0526 | .0362 | .0526 | .3856 | .0351 |
| 17 | .0351 | .0351 | | .0526 | .0526 | .0175 | .0351 |
| 18 | .0351 | .0526 | .0526 | .0543 | .0526 | .0351 | .0351 |
| 19 | .0526 | .0526 | .0701 | | .0701 | .0351 | .0543 |
| 20 | .0724 | .0526 | .0701 | .0724 | .0701 | .0701 | .0526 |
| 21 | .0724 | .0701 | .0701 | .0701 | .0701 | .0701 | .0543 |
| 22 | .0724 | .0701 | .0701 | .0543 | .0701 | .0701 | .0526 |
| 23 | .0724 | .0701 | .0526 | .0526 | .0701 | .0526 | .0526 |
| 24 | .0701 | .0526 | .0701 | .0701 | .0543 | .0701 | .0701 |
| Max | .0724 | .0701 | .0701 | .0724 | .0701 | .3856 | .0701 |
| Min | .0175 | .0175 | .0175 | .0175 | .0175 | .0175 | .0175 |
| Avg | .0479 | .0432 | .0504 | .0462 | .0493 | .0540 | .0448 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 207 / 11 KV SAYANE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1928 | .2096 | .1753 | .1753 | .5668 | .6135 | .5434 |
| 2 | .1753 | .2286 | .1753 | .1753 | .6093 | .6485 | .6661 |
| 3 | .2103 | .2096 | .2103 | .2103 | .6562 | .6485 | .6661 |
| 4 | .2103 | .2477 | .2103 | .2103 | .6964 | .7011 | .7011 |
| 5 | .2629 | .362 | .2454 | .2629 | .7287 | .7362 | .8939 |
| 6 | .3506 | .4001 | .3155 | .333 | .7186 | .8939 | .8939 |
| 7 | .3681 | .4191 | .3681 | .3506 | .8179 | 1.1393 | 1.2094 |
| 8 | .2454 | .2804 | .2454 | .2454 | .8749 | 1.0517 | 1.1568 |
| 9 | .1402 | .1402 | .1402 | .1402 | .8642 | .964 | 1.1043 |
| 10 | .9114 | .9335 | .7362 | .5556 | 1.0517 | .1402 | .1227 |
| 11 | 1.1393 | 1.1218 | 1.1218 | .9842 | .1052 | .1227 | .1052 |
| 12 | 1.2094 | 1.1218 | 1.1218 | .9686 | .1052 | .1052 | .1052 |
| 13 | 1.1744 | 1.0867 | .964 | .9646 | .1052 | | .1227 |
| 14 | 1.1043 | 1.0517 | .8764 | .933 | .1052 | .1227 | .1052 |
| 15 | .9816 | .9816 | .9465 | .8749 | .1227 | .1227 | .1143 |
| 16 | .9816 | 1.0166 | 1.0166 | .8539 | .1402 | .1052 | .1227 |
| 17 | .9816 | .9991 | | .828 | .1052 | .1052 | .0526 |
| 18 | .1524 | .1402 | .1402 | .1334 | .1227 | .1052 | .1524 |
| 19 | .2286 | .2279 | .2454 | | .2279 | .2279 | .2477 |
| 20 | .2477 | .2279 | .2279 | .2667 | .2279 | .2279 | .2477 |
| 21 | .2667 | .2279 | .2103 | .2477 | .2103 | .2279 | .2477 |
| 22 | .2286 | .2103 | .2103 | .2477 | .1928 | .1928 | .2286 |
| 23 | .2096 | .1753 | .1753 | .1905 | .1928 | .1753 | .2096 |
| 24 | .1928 | .2096 | .1753 | .1753 | .5312 | .5784 | .5258 |
| Max | 1.2094 | 1.1218 | 1.1218 | .9842 | 1.0517 | 1.1393 | 1.2094 |
| Min | .1402 | .1402 | .1402 | .1334 | .1052 | .1052 | .0526 |
| Avg | .5069 | .5096 | .4458 | .4490 | .4200 | .4329 | .4394 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 208 / 11 KV SONDALE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0526 | .0572 | .0526 | .0526 | .3401 | .4908 | .6135 |
| 2 | .0526 | .0572 | .0526 | .0526 | .3749 | .5609 | .6661 |
| 3 | .0526 | .0572 | .0526 | .0526 | .4858 | .5609 | .6661 |
| 4 | .0526 | .0572 | .0526 | .0526 | .4843 | .6135 | .7362 |
| 5 | .0701 | .0572 | .0701 | .0701 | .6154 | .6135 | .7712 |
| 6 | .0876 | .1143 | .0876 | .0876 | .6316 | .7712 | .8413 |
| 7 | .0876 | .0953 | .0701 | .0701 | .7655 | 1.1393 | 1.1218 |
| 8 | .0526 | .0526 | .0526 | .0351 | .7968 | 1.1744 | .9465 |
| 9 | .0351 | .0351 | .0351 | .0351 | .7449 | .9991 | .9114 |
| 10 | .8238 | .7811 | .3856 | .3549 | .0351 | .0351 | .0351 |
| 11 | 1.0867 | 1.1043 | .8063 | .9374 | .0351 | .0526 | .0351 |
| 12 | 1.2269 | 1.1568 | 1.0867 | .8488 | .0351 | .0526 | .0351 |
| 13 | 1.2971 | 1.1218 | 1.1043 | .9105 | .0526 | .0351 | .0526 |
| 14 | 1.1919 | 1.0867 | .8764 | .8796 | .0526 | .0351 | .0351 |
| 15 | 1.1744 | 1.0341 | .9816 | .8356 | .0526 | .0351 | .0572 |
| 16 | 1.1218 | 1.0166 | .9816 | .9069 | .0526 | | .0526 |
| 17 | 1.0166 | .8939 | | .8697 | .0526 | .0351 | .0526 |
| 18 | .0381 | .0526 | .0351 | .0572 | .0526 | .0526 | .0572 |
| 19 | .0572 | .0701 | .0526 | | .0701 | .0701 | .0762 |
| 20 | .0762 | .0701 | .0526 | .0762 | .0701 | .0701 | .0762 |
| 21 | .0572 | .0701 | .0526 | .0572 | .0701 | .0701 | .0762 |
| 22 | .0572 | .0526 | .0526 | .0572 | .0526 | .0526 | .0572 |
| 23 | .0572 | .0526 | .0526 | .0572 | .0526 | .0526 | .0572 |
| 24 | .0526 | .0572 | .0526 | .0526 | .3281 | .4382 | .3681 |
| Max | 1.2971 | 1.1568 | 1.1043 | .9374 | .7968 | 1.1744 | 1.1218 |
| Min | .0351 | .0351 | .0351 | .0351 | .0351 | .0351 | .0351 |
| Avg | .4116 | .3835 | .3087 | .3221 | .2627 | .3483 | .3499 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 209 / 11 KV EXPRESS WW SONGIR
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | | .0543 | .0526 | .0526 | .0724 | .0701 | |
| 7 | .0526 | .0543 | .0701 | .0526 | .0526 | .0701 | .0701 |
| 8 | .0876 | .0876 | .0701 | .0526 | .0543 | .0701 | .0701 |
| 9 | .0701 | .0701 | .0701 | .0526 | .0543 | .0701 | .0701 |
| 10 | .0701 | .0572 | .0526 | .0543 | .0526 | .0526 | .0526 |
| 11 | .0526 | .0526 | | .0543 | .0526 | .0526 | .0526 |
| 12 | | .0526 | | .0526 | .0526 | .0526 | |
| 13 | | | .0526 | .0543 | | | |
| 15 | .0526 | | | | | | .0724 |
| 16 | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 |
| 17 | .0526 | .0701 | | | .0526 | | |
| 18 | .0543 | .0526 | | .0543 | | | |
| 19 | .0526 | | .0526 | | | .0526 | .0543 |
| 20 | .0526 | .0526 | | .0543 | .0526 | .0701 | .0543 |
| 21 | .0526 | .0526 | | | | .0526 | |
| Max | .0876 | .0876 | .0701 | .0543 | .0724 | .0701 | .0724 |
| Min | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 | .0526 |
| Avg | .0586 | .0591 | .0592 | .0534 | .0549 | .0606 | .0610 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.9945 |
| Max | 5.9945 |
| Min | 5.9945 |
| Avg | 5.9945 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 242 / 11 KV INCOMER II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 7.8349 |
| Max | 7.8349 |
| Min | 7.8349 |
| Avg | 7.8349 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 407 / 33 KV INCOMER SONGIR SS
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 4.3644 |
| Max | 4.3644 |
| Min | 4.3644 |
| Avg | 4.3644 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 421 / 33 KV INCOMER I

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.6827 |
| Max | 1.6827 |
| Min | 1.6827 |
| Avg | 1.6827 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / 33/11 KV SUB SONGIR

Feeder No / Name : 422 / 33 KV INCOMER II

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.3137 |
| Max | 2.3137 |
| Min | 2.3137 |
| Avg | 2.3137 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 KV SUB BABHALE

Feeder No / Name : 201 / 11 KV WALKHEDA SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | .5906 |
| 2 | .5716 |
| 3 | .5906 |
| 4 | .6478 |
| 5 | .743 |
| 6 | .8573 |
| 7 | .8383 |
| 8 | .7049 |
| 9 | .5525 |
| 10 | .9448 |
| 11 | 1.1904 |
| 12 | .9282 |
| 13 | .9614 |
| 24 | .5716 |
| Max | 1.1904 |
| Min | .5525 |
| Avg | .7638 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 KV SUB BABHALE

Feeder No / Name : 202 / 11 KV EXPRESS ABHAY COTEX NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7621 | .6478 | .6478 | .5716 | .5906 | .6478 | .6478 |
| 2 | .7621 | .6478 | .6478 | .5906 | .5716 | .6478 | .6478 |
| 3 | .724 | .6287 | .6668 | .5906 | .5906 | .6287 | .6668 |
| 4 | .6668 | .6478 | .6859 | .5906 | .5906 | .6287 | .6478 |
| 5 | .6478 | .6097 | .6859 | .6097 | .5716 | .6478 | .6478 |
| 6 | .5906 | .6097 | .7049 | .6097 | .5716 | .6287 | .6478 |
| 7 | .5906 | .6097 | .7049 | .6287 | .5335 | .5525 | .6097 |
| 8 | .5335 | .6859 | .7049 | .5906 | .6478 | .5144 | .7049 |
| 9 | .5525 | .724 | .7049 | .5144 | .6859 | .7621 | .6478 |
| 10 | .6859 | .724 | .724 | .6287 | .6859 | .5144 | .6478 |
| 11 | .8002 | .6097 | .5144 | .5716 | .5716 | .724 | .6478 |
| 12 | .8002 | .6859 | .5144 | .6287 | .5335 | .724 | .7049 |
| 13 | .724 | .6859 | .6478 | .5716 | .5525 | .743 | .6859 |
| 14 | | .6859 | .6859 | .6097 | .5906 | .7049 | .7049 |
| 15 | .8192 | .6668 | .6478 | .6287 | .5716 | .6859 | .6478 |
| 16 | .8002 | .724 | | .6287 | .6097 | .6668 | .5906 |
| 17 | .6478 | .724 | .5716 | .6287 | .6287 | .6668 | .6859 |
| 18 | .6287 | .724 | .5716 | .5716 | .6287 | .6668 | .724 |
| 19 | .7049 | .7621 | .6859 | .5906 | .6668 | .6859 | .5525 |
| 20 | .724 | .8002 | .724 | .5906 | .6668 | .6668 | .6287 |
| 21 | .6859 | .7811 | .724 | .6097 | .6097 | .6478 | .724 |
| 22 | .6478 | .6859 | .6287 | .5525 | .6097 | .6478 | .743 |
| 23 | .6478 | .7049 | .5906 | .5335 | .6478 | .6668 | .5906 |
| 24 | .743 | .6478 | .6859 | .5716 | .5716 | .6478 | .7049 |
| Max | .8192 | .8002 | .724 | .6287 | .6859 | .7621 | .743 |
| Min | .5335 | .6097 | .5144 | .5144 | .5335 | .5144 | .5525 |
| Avg | .6909 | .6843 | .6552 | .5922 | .6041 | .6549 | .6605 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 201 / 11 KV BETAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 10 | .9568 |
| 11 | 1.0155 |
| 12 | .9998 |
| 13 | 1.0648 |
| 14 | 1.0212 |
| 15 | .9907 |
| 16 | 1.0669 |
| 17 | .9145 |
| 19 | .9145 |
| Max | 1.0669 |
| Min | .9145 |
| Avg | .9939 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 202 / 11 KV BETAWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | .8596 |
| 2 | .8417 |
| 3 | .8417 |
| 4 | .9412 |
| 5 | 1.1888 |
| 6 | 1.4415 |
| 7 | 1.5524 |
| 8 | 1.1706 |
| 9 | .9694 |
| 10 | .9328 |
| 11 | .788 |
| 12 | .7701 |
| 13 | .7796 |
| 14 | .7628 |
| 15 | .7973 |
| 16 | .8413 |
| 17 | .8573 |
| 24 | .8688 |
| Max | 1.5524 |
| Min | .7628 |
| Avg | .9558 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 241 / 11 KV INCOMER I

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8596 | .7888 | .7373 | .7716 | 1.2967 | 1.5261 | 1.5775 |
| 2 | .8417 | .7888 | .6859 | .7373 | 1.3279 | 1.4575 | 1.5261 |
| 3 | .8417 | .7888 | .703 | .7373 | 1.3117 | 1.4575 | 1.5775 |
| 4 | .9412 | .823 | 1.0288 | .7716 | 1.4043 | 1.5089 | 1.6975 |
| 5 | 1.1888 | 1.0288 | 1.1831 | .9431 | 1.4937 | 1.6975 | 1.869 |
| 6 | 1.4415 | 1.2003 | 1.2517 | 1.1831 | 1.6792 | 1.989 | 1.9547 |
| 7 | 1.5524 | 1.166 | 1.0631 | 1.1488 | 1.7684 | 2.1091 | 2.0919 |
| 8 | 1.1706 | 1.046 | .9945 | .9431 | 1.4963 | 1.8519 | 1.869 |
| 9 | .9694 | .8745 | .8402 | .7888 | 1.423 | 1.7318 | 1.749 |
| 10 | 1.7438 | 1.9376 | 1.8176 | 1.6975 | .8059 | | .7716 |
| 11 | 1.869 | 2.0748 | 2.0062 | 1.6461 | .7888 | .7716 | .7373 |
| 12 | 1.8347 | 2.0062 | 1.9204 | 1.5394 | .7373 | .7888 | .7202 |
| 13 | 1.9376 | 1.8347 | 1.6461 | 1.4449 | .7202 | .7716 | .5144 |
| 14 | 1.9033 | 1.8004 | 1.7147 | 1.4266 | .7202 | .7202 | .5658 |
| 15 | 1.8861 | 1.8347 | 1.7147 | 1.4266 | .7888 | .7373 | .6173 |
| 16 | 2.0233 | 1.9033 | 1.6804 | 1.4523 | .7888 | .7716 | .6173 |
| 17 | 1.8861 | 1.8347 | 1.6975 | 1.3643 | .8059 | .7888 | .6173 |
| 18 | .9431 | .9431 | | .4908 | .8573 | .823 | .7202 |
| 19 | 1.1403 | 1.0288 | 1.0288 | .724 | .9945 | 1.0117 | 1.0288 |
| 20 | 1.0802 | 1.0631 | .9945 | .9955 | .9774 | 1.0802 | .9602 |
| 21 | .9431 | .8573 | .9431 | .9412 | .9259 | 1.1145 | .8402 |
| 22 | .9259 | .8059 | .8916 | .8596 | .8745 | .9088 | .8745 |
| 23 | .8745 | .7716 | .8059 | .8059 | .823 | .8573 | |
| 24 | .8688 | .823 | .7545 | .7888 | 1.2967 | 1.5775 | 1.5604 |
| Max | 2.0233 | 2.0748 | 2.0062 | 1.6975 | 1.7684 | 2.1091 | 2.0919 |
| Min | .8417 | .7716 | .6859 | .4908 | .7202 | .7202 | .5144 |
| Avg | 1.3194 | 1.2510 | 1.2219 | 1.0678 | 1.0878 | 1.2197 | 1.1764 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV SUB BETAWAD

Feeder No / Name : 421 / 33 KV INCOMER-1 BETAWAD SS NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9145 | .8573 | .8002 | .8573 | 1.6004 | 1.6575 | 1.7147 |
| 2 | .9145 | .8573 | .743 | .8002 | 1.6004 | 1.6004 | 1.6575 |
| 3 | .9145 | .8573 | .743 | .8002 | 1.6004 | 1.6004 | 1.7147 |
| 4 | .9717 | .9145 | 1.1431 | .8573 | 1.7147 | 1.6575 | 1.8861 |
| 5 | 1.2574 | 1.1431 | 1.3146 | 1.0288 | 1.8861 | 1.8861 | 2.0576 |
| 6 | 1.4861 | 1.3146 | 1.3717 | 1.3146 | 2.1719 | 2.1719 | 2.1719 |
| 7 | 1.6004 | 1.3146 | 1.1431 | 1.2574 | 2.2862 | 2.3434 | 2.2862 |
| 8 | 1.2003 | 1.1431 | 1.086 | 1.0288 | 1.9433 | 2.0576 | 2.0576 |
| 9 | 1.0288 | .9717 | .9145 | .8573 | 1.829 | 1.8861 | 1.9433 |
| 10 | 1.7593 | 2.1148 | 2.0005 | 1.8861 | .9145 | | .8573 |
| 11 | | 2.2862 | 2.2291 | 2.0576 | .8573 | .8573 | .8002 |
| 12 | 2.0005 | 2.2291 | 2.1148 | 1.9433 | .8002 | .8573 | .8002 |
| 13 | 2.1719 | 2.0005 | 1.829 | 1.829 | .8002 | .8573 | .5716 |
| 14 | 2.1148 | 2.0005 | 1.8861 | 1.829 | .8002 | .8002 | .6287 |
| 15 | 2.0576 | 2.0005 | 1.8861 | 1.829 | .8573 | .8002 | .6859 |
| 16 | 2.2291 | 2.1148 | 1.829 | 1.8861 | .8573 | .8573 | .6859 |
| 17 | 2.0576 | 2.0005 | 1.8861 | 1.7718 | .8573 | .8573 | .6859 |
| 18 | 1.0288 | 1.0288 | | .5144 | .9145 | .9145 | .8002 |
| 19 | 1.2003 | 1.1431 | 1.1431 | .743 | 1.086 | 1.086 | 1.1431 |
| 20 | 1.2003 | 1.1431 | 1.086 | 1.0288 | 1.086 | 1.2003 | 1.0288 |
| 21 | 1.0288 | .9145 | 1.0288 | .9717 | 1.0288 | 1.2003 | .9145 |
| 22 | 1.0288 | .8573 | .9717 | .9145 | .9717 | .9717 | .9717 |
| 23 | .9717 | .8573 | .8573 | .8573 | .9145 | .9145 | |
| 24 | .9145 | .9145 | .8002 | .8573 | 1.6004 | 1.7147 | 1.7147 |
| Max | 2.2291 | 2.2862 | 2.2291 | 2.0576 | 2.2862 | 2.3434 | 2.2862 |
| Min | .9145 | .8573 | .743 | .5144 | .8002 | .8002 | .5716 |
| Avg | 1.3936 | 1.3741 | 1.3394 | 1.2384 | 1.2908 | 1.3369 | 1.2947 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 097009 / 132 KV SUB NARDANA

Feeder No / Name : 401 / 33 KV SUKWAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 2 | | 3.0864 |
| 24 | 2.572 | |
| Max | 2.572 | 3.0864 |
| Min | 2.572 | 3.0864 |
| Avg | 2.572 | 3.0864 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216] BU 0566

Substation No/ Name :- 097009 / 132 KV SUB NARDANA

Feeder No / Name : 402 / 33 KV NARDANA

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 3.7551 |
| Max | 3.7551 |
| Min | 3.7551 |
| Avg | 3.7551 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 097009 / 132 KV SUB NARDANA

Feeder No / Name : 404 / 33 KV EXPRESS TAPI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.0288 |
| Max | 1.0288 |
| Min | 1.0288 |
| Avg | 1.0288 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 097009 / 132 KV SUB NARDANA

Feeder No / Name : 407 / 33 KV EXPRESS BABHALE
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | 5.144 |
| Max | 5.144 |
| Min | 5.144 |
| Avg | 5.144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 201 / BALSANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.5604 | 2.6063 | 2.5206 | 2.2977 | 2.4006 | 1.9376 | 2.0233 |
| 11 | 3.155 | 3.6694 | .3772 | 2.3663 | 2.915 | 3.035 | 3.0178 |
| 12 | 3.2579 | 3.6008 | | 3.3436 | 3.2065 | 3.1207 | 3.3436 |
| 13 | 3.3608 | 3.5322 | 3.0864 | 3.0007 | 3.0864 | 2.8292 | 3.2922 |
| 14 | 3.3608 | 3.4294 | 3.1893 | 2.7092 | 2.7435 | 2.7092 | 3.2579 |
| 15 | 3.035 | 3.0864 | 2.8292 | 2.7435 | 2.6578 | 2.2291 | 2.8121 |
| 16 | 2.915 | 3.1207 | 2.8635 | 2.7092 | 2.4006 | 1.869 | 2.6063 |
| 17 | 2.7949 | 3.2236 | 2.6578 | 2.2119 | 2.2977 | 2.2805 | 2.3834 |
| 24 | .6097 | | | | | | |
| Max | 3.3608 | 3.6694 | 3.1893 | 3.3436 | 3.2065 | 3.1207 | 3.3436 |
| Min | .6097 | 2.6063 | .3772 | 2.2119 | 2.2977 | 1.869 | 2.0233 |
| Avg | 2.6722 | 3.2836 | 2.5034 | 2.6728 | 2.7135 | 2.5013 | 2.8421 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 202 / HATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6173 | .8573 | .8573 | .8916 | .8573 | .8573 | .7888 |
| 2 | .6173 | .9259 | .8573 | .9259 | .8745 | .9259 | .823 |
| 3 | .6173 | .9602 | .8573 | .9431 | .8916 | .9259 | .8573 |
| 4 | .6859 | 1.0288 | .8573 | .9602 | .8745 | .9774 | .9259 |
| 5 | .8059 | 1.0117 | .9431 | .9602 | .8916 | .9602 | .9431 |
| 6 | .8916 | 1.1831 | 1.0288 | 1.286 | 1.0288 | 1.0631 | 1.166 |
| 7 | 1.4232 | 1.2346 | 1.4575 | 1.6461 | 1.3546 | 1.166 | 1.3546 |
| 8 | 1.3717 | 1.4403 | 1.5261 | 1.3032 | 1.4232 | 1.3032 | 1.3717 |
| 23 | .823 | .8573 | .8745 | .7202 | .703 | .7202 | .6859 |
| 24 | .6173 | .8573 | .8573 | .8916 | .8573 | .8573 | .7888 |
| Max | 1.4232 | 1.4403 | 1.5261 | 1.6461 | 1.4232 | 1.3032 | 1.3717 |
| Min | .6173 | .8573 | .8573 | .7202 | .703 | .7202 | .6859 |
| Avg | .8471 | 1.0357 | 1.0117 | 1.0528 | .9756 | .9757 | .9705 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 203 / HATTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .2572 | .2058 | .1543 | .2401 | .2915 | .2058 |
| 2 | .3086 | .3086 | .3772 | .2058 | .2915 | .2401 | .2401 |
| 3 | .4801 | .4973 | .5144 | .2572 | .463 | .463 | .3086 |
| 4 | .6173 | .6173 | .6859 | .3086 | .5144 | .5144 | .4973 |
| 5 | .8059 | .6859 | .7373 | .5487 | .5658 | .6516 | .6344 |
| 6 | | | .9602 | | | | |
| 9 | .7545 | .4801 | .6173 | .4115 | .4458 | .5658 | .4801 |
| 10 | .3601 | .3772 | .4458 | .3429 | .3086 | .3601 | .4115 |
| 11 | .2915 | .2743 | .3086 | .3086 | .2915 | .2229 | .2743 |
| 12 | .2572 | .2743 | .2915 | .2915 | .2229 | .2058 | .2401 |
| 13 | .2572 | .2229 | | .2915 | .2401 | .2229 | .2401 |
| 14 | .2401 | .2572 | .2401 | | .2229 | .2401 | |
| 15 | .2915 | .3086 | .3086 | .3258 | .1886 | .2743 | .3258 |
| 16 | .3429 | .3429 | .3429 | .3772 | .2572 | | .3772 |
| 17 | .463 | .3772 | .3429 | .3429 | .3086 | | .3772 |
| 19 | | | | | | .5316 | |
| 20 | .6859 | .823 | .6173 | .5316 | .583 | .583 | .823 |
| 21 | .5487 | .4973 | .3944 | .463 | .5144 | .5144 | .5658 |
| 22 | .463 | .3772 | .2572 | .2915 | .4287 | .4115 | .4973 |
| 23 | .2572 | .2572 | .1715 | .2401 | .3086 | .1886 | .3086 |
| 24 | .2229 | .2401 | .1715 | .1715 | .2401 | .3258 | .1886 |
| Max | .8059 | .823 | .9602 | .5487 | .583 | .6516 | .823 |
| Min | .2229 | .2229 | .1715 | .1543 | .1886 | .1886 | .1886 |
| Avg | .4151 | .3935 | .4205 | .3258 | .3493 | .3782 | .3887 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 204 / MALPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .463 | .463 | .5144 | .4287 | .4287 | .4115 | .4458 |
| 2 | .4801 | .4801 | .5658 | .5144 | .4287 | .4458 | .4801 |
| 3 | .4801 | .5144 | .6173 | .583 | .5487 | .5144 | .4973 |
| 4 | .5658 | .6687 | .7545 | .6516 | .6687 | .6173 | .6173 |
| 5 | .7545 | .7716 | .7716 | .7888 | .7716 | .7888 | .703 |
| 6 | 1.2003 | 1.0288 | .8402 | 1.1488 | 1.0974 | 1.1831 | 1.0288 |
| 7 | 1.3032 | 1.1831 | 1.046 | 1.2174 | 1.2003 | 1.0974 | 1.1145 |
| 8 | .9774 | 1.0117 | .8573 | .8573 | .9945 | .9259 | .9774 |
| 9 | .823 | .823 | .5658 | .8916 | .8059 | .823 | .9088 |
| 10 | .7373 | .7545 | .4973 | .6173 | .6687 | .6001 | .7373 |
| 11 | .5658 | .5658 | .463 | .463 | .4973 | | .5658 |
| 12 | .5144 | .4801 | .4115 | .4973 | .4801 | | .5144 |
| 13 | .4801 | .4287 | .3601 | .4801 | .4973 | .4115 | .4801 |
| 14 | .0343 | .3772 | .3944 | .4115 | .4973 | .4458 | .4458 |
| 15 | .4973 | .3944 | .3944 | .4115 | .4973 | .4115 | .3772 |
| 16 | .6173 | .4801 | .3944 | .463 | .4801 | .4287 | .4115 |
| 17 | .6687 | .4801 | .3258 | .463 | .4973 | .4458 | .4973 |
| 18 | .9088 | .6173 | .5487 | .5658 | .7373 | .6173 | .8916 |
| 19 | 1.046 | | .9259 | .9259 | .9088 | .9774 | 1.0117 |
| 20 | .823 | .823 | .8573 | .8059 | .7373 | .823 | .8402 |
| 21 | .6687 | .6859 | .6859 | .6859 | .6859 | .6687 | .703 |
| 22 | .5144 | .6001 | .5658 | .583 | .6344 | .6344 | .5658 |
| 23 | .4973 | .5658 | .4801 | .5487 | .4801 | .5316 | .5144 |
| 24 | .463 | .463 | .5316 | .4801 | .463 | .463 | .4801 |
| Max | 1.3032 | 1.1831 | 1.046 | 1.2174 | 1.2003 | 1.1831 | 1.1145 |
| Min | .0343 | .3772 | .3258 | .4115 | .4287 | .4115 | .3772 |
| Avg | .6702 | .6374 | .5987 | .6452 | .6544 | .6485 | .6587 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 205 / AICHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6516 | .8573 | .8573 | .8573 | .8573 | .8573 | .8059 |
| 2 | .6516 | .8916 | .8573 | .8573 | .8916 | .8573 | .823 |
| 3 | .6516 | .8573 | .8573 | .8573 | .8745 | .8745 | .8059 |
| 4 | .6516 | .8916 | .8573 | .8573 | .8573 | .8916 | .823 |
| 5 | .6516 | .8916 | .8573 | .8573 | .8745 | .8745 | .8059 |
| 6 | .6859 | 1.0288 | .9945 | 1.0631 | 1.0288 | 1.0288 | 1.0117 |
| 7 | .9945 | 1.3717 | 1.3203 | 1.3546 | 1.1145 | 1.1831 | 1.1831 |
| 8 | 1.1145 | 1.4403 | 1.3203 | 1.2517 | 1.166 | 1.1831 | 1.2517 |
| 23 | .7716 | .8573 | .8745 | .9088 | .8402 | .7888 | .823 |
| 24 | .6516 | .823 | .8573 | .8573 | .8573 | .8745 | .823 |
| Max | 1.1145 | 1.4403 | 1.3203 | 1.3546 | 1.166 | 1.1831 | 1.2517 |
| Min | .6516 | .823 | .8573 | .8573 | .8402 | .7888 | .8059 |
| Avg | .7476 | .9911 | .9653 | .9722 | .9362 | .9414 | .9156 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 206 / INDAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .9088 | .8916 | .823 | .6859 | .9088 | .9602 | .7373 |
| 11 | 1.2689 | 1.1831 | .9259 | .8573 | .9259 | | .9774 |
| 12 | 1.2689 | .9945 | .8916 | .823 | .9259 | 1.0288 | 1.4918 |
| 13 | 1.2003 | .9088 | .7202 | .8916 | .8573 | 1.0631 | .8916 |
| 14 | 1.2003 | .8745 | .6859 | .8573 | .8916 | .9945 | .8402 |
| 15 | 1.0974 | .8402 | .7202 | .9259 | .7716 | .9259 | .823 |
| 16 | .8916 | .8402 | .8573 | 1.0117 | .8059 | .8916 | .823 |
| 17 | .8059 | .8402 | .823 | .9945 | .8059 | | |
| 24 | .6097 | | | | | | |
| Max | 1.2689 | 1.1831 | .9259 | 1.0117 | .9259 | 1.0631 | 1.4918 |
| Min | .6097 | .8402 | .6859 | .6859 | .7716 | .8916 | .7373 |
| Avg | 1.0280 | .9216 | .8059 | .8809 | .8616 | .9774 | .9406 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 207 / BALSANE GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4801 | .463 | .4801 | .5144 | .3601 | .3601 | .4115 |
| 2 | .5144 | .3258 | .5144 | .5487 | .463 | .4115 | .4801 |
| 3 | .6173 | .6173 | .6173 | .6173 | .6173 | .5144 | .6687 |
| 4 | .823 | .8402 | .823 | .7202 | .7888 | .8402 | .7716 |
| 5 | 1.0288 | 1.0631 | 1.0288 | 1.0288 | .9431 | .9602 | .9259 |
| 6 | | | | .9945 | .9945 | 1.0288 | |
| 7 | | | | 1.0631 | 1.0288 | 1.0117 | |
| 8 | | | | .823 | .9088 | .9602 | 1.0974 |
| 9 | .9945 | .9774 | .823 | .6173 | .8745 | .8402 | .9602 |
| 10 | .703 | .7202 | .6859 | .5144 | .703 | .6687 | .7545 |
| 11 | .5316 | .6344 | .5487 | .5487 | .5487 | .5144 | .583 |
| 12 | .2229 | .5487 | | .4458 | .5144 | .5316 | .4801 |
| 13 | .2058 | .5316 | | .463 | .463 | .5144 | .4801 |
| 14 | .3258 | .4801 | | .4801 | .4801 | .5316 | |
| 15 | .5658 | .3772 | | .5144 | .4458 | .5316 | .5487 |
| 16 | .6859 | .3772 | | .5658 | .5487 | .5487 | .6173 |
| 17 | | | | .583 | .5144 | .5487 | .6173 |
| 18 | | .823 | .7545 | .7545 | .7202 | .6687 | .823 |
| 19 | | 1.0288 | 1.0974 | .9602 | .9259 | .9431 | .9259 |
| 20 | .8573 | .8745 | .7716 | .7202 | .7373 | .8916 | .8916 |
| 21 | .7202 | .6859 | .823 | .6859 | .6859 | .6173 | .703 |
| 22 | .5487 | .583 | .583 | .5144 | .5487 | .5144 | .5658 |
| 23 | .4458 | .5144 | .5144 | .4801 | .463 | .4458 | .5144 |
| 24 | .4801 | .463 | .4801 | .4801 | .3772 | .3772 | .4115 |
| Max | 1.0288 | 1.0631 | 1.0974 | 1.0631 | 1.0288 | 1.0288 | 1.0974 |
| Min | .2058 | .3258 | .4801 | .4458 | .3601 | .3601 | .4115 |
| Avg | .5973 | .6464 | .7030 | .6516 | .6523 | .6573 | .6777 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 208 / 11 KV BOKADBALLA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.1145 | .9945 | 1.0631 | 1.1317 | 1.0974 | 1.1317 | .8402 |
| 11 | 1.6632 | 1.6632 | 1.406 | 1.3203 | 1.2003 | 1.4403 | 1.2689 |
| 12 | 1.6461 | 1.5089 | 1.3203 | 1.5089 | .0343 | 1.5089 | 1.4918 |
| 13 | 1.5775 | 1.4575 | 1.406 | 1.3546 | 1.3717 | 1.3717 | 1.3717 |
| 14 | 1.3717 | 1.2346 | 1.2689 | 1.2346 | 1.3032 | 1.3032 | 1.3203 |
| 15 | 1.0802 | 1.1317 | 1.1831 | 1.1488 | 1.2689 | 1.2346 | 1.2003 |
| 16 | 1.5432 | 1.0974 | .8916 | .9602 | 1.0288 | 1.0288 | 1.0974 |
| 17 | 1.2346 | 1.0288 | 1.2003 | .8059 | 1.0631 | 1.046 | 1.046 |
| 20 | | | 1.3203 | | | | |
| Max | 1.6632 | 1.6632 | 1.406 | 1.5089 | 1.3717 | 1.5089 | 1.4918 |
| Min | 1.0802 | .9945 | .8916 | .8059 | .0343 | 1.0288 | .8402 |
| Avg | 1.4039 | 1.2646 | 1.2288 | 1.1831 | 1.0460 | 1.2582 | 1.2046 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 201 / DEVI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .5506 | .6478 | .7701 | .9393 | .9602 | .8322 | .8907 |
| 11 | .6401 | 1.0486 | 1.2334 | 1.2803 | 1.4419 | 1.278 | 1.2631 |
| 12 | .7373 | 1.1984 | 1.2003 | .9831 | 1.3283 | 1.2803 | 1.3599 |
| 13 | .8097 | 1.2483 | 1.1633 | .9922 | 1.2631 | 1.1336 | 1.2643 |
| 14 | 1.0279 | .8745 | 1.1797 | .9555 | 1.1498 | .9602 | 1.1203 |
| 15 | .9878 | 1.2955 | 1.1523 | .9831 | 1.0486 | 1.065 | 1.0322 |
| 16 | .8907 | 1.1203 | 1.2308 | 1.0279 | 1.0202 | .9602 | .9717 |
| 17 | .9012 | 1.0526 | 1.2631 | 1.1336 | 1.0364 | 1.0526 | .9012 |
| 24 | .6097 | | | | | | |
| Max | 1.0279 | 1.2955 | 1.2631 | 1.2803 | 1.4419 | 1.2803 | 1.3599 |
| Min | .5506 | .6478 | .7701 | .9393 | .9602 | .8322 | .8907 |
| Avg | .795 | 1.0608 | 1.1491 | 1.0369 | 1.1561 | 1.0703 | 1.1004 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 202 / Devi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .6097 |
| Max | .6097 |
| Min | .6097 |
| Avg | .6097 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 203 / Varzadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | .1296 | .3201 | .2294 |
| 2 | | | | | .144 | .426 | .2294 |
| 3 | | | | | .144 | .4961 | .2401 |
| 4 | | | | | .1619 | .5441 | .2753 |
| 5 | | | | | .1943 | .583 | .3125 |
| 6 | | | | | .4858 | .6081 | .5535 |
| 7 | | | | | .5668 | .6802 | .6478 |
| 8 | | | | | | .6964 | .6802 |
| 10 | .2267 | .3239 | .4049 | .3887 | | | |
| 11 | .5735 | .6401 | .6226 | .5601 | | | |
| 12 | .664 | .583 | .6401 | .3795 | | | |
| 13 | .6241 | .583 | .5506 | .3768 | | | |
| 14 | .5468 | .5761 | .421 | .3681 | | | |
| 15 | .6478 | .4001 | .3277 | .3563 | | | |
| 16 | .5601 | .4372 | .3563 | .3201 | | | |
| 17 | .5668 | .4321 | .3521 | .3479 | | | |
| 23 | | | | .5601 | .1781 | .2214 | .1619 |
| 24 | .6097 | | | | .1134 | .2267 | .2267 |
| Max | .664 | .6401 | .6401 | .5601 | .5668 | .6964 | .6802 |
| Min | .2267 | .3239 | .3277 | .3201 | .1134 | .2214 | .1619 |
| Avg | .5577 | .4969 | .4594 | .4064 | .2353 | .4802 | .3557 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 201 / NIMGUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2947 | | .3109 | | .2774 | .3109 |
| 2 | .3467 | | .3109 | | .2774 | .3109 |
| 3 | .3467 | | .3258 | | .3294 | .3292 |
| 4 | .3814 | | .3658 | | .3814 | .3292 |
| 5 | .4161 | | .4435 | | .4161 | .4207 |
| 6 | .5028 | | .543 | | .4508 | .5487 |
| 7 | .4681 | | .5304 | | .4681 | .4572 |
| 8 | .3467 | | .4344 | | .3467 | .3258 |
| 9 | | .298 | | .2601 | .3258 | .2012 |
| 10 | | .3366 | | .2427 | .2353 | |
| 11 | | .2715 | | .2601 | .3658 | |
| 12 | | .2507 | | .2601 | .2561 | |
| 13 | | .3045 | | .2774 | .2686 | |
| 14 | | .3045 | | .2427 | .2507 | |
| 15 | | .3258 | | .2427 | .2629 | |
| 16 | | .3439 | | .2601 | .298 | |
| 17 | | .3045 | | .3294 | .3403 | |
| 18 | | .362 | | .3467 | .3982 | |
| 19 | | .4435 | | .3641 | .4435 | |
| 20 | | .3982 | | .3988 | .4066 | |
| 21 | | .3841 | | .3467 | .3881 | |
| 22 | | .3658 | | .3294 | .3696 | |
| 23 | | .3292 | | .2947 | .3292 | |
| 24 | .1524 | | .3109 | | .2774 | .3109 |
| Max | .5028 | .4435 | .543 | .3988 | .4681 | .5487 |
| Min | .1524 | .2507 | .3109 | .2427 | .2353 | .2012 |
| Avg | .3617 | .3349 | .3973 | .2970 | .3401 | .3545 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 202 / Takerkheda Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .4854 | |
| 2 | .5201 | |
| 3 | .5201 | |
| 4 | .5028 | |
| 5 | .5375 | |
| 6 | .5201 | |
| 7 | .5028 | |
| 8 | .5375 | |
| 10 | | 2.3752 |
| 11 | | 2.4446 |
| 12 | | 2.4272 |
| 13 | | 2.4099 |
| 14 | | 2.4272 |
| 15 | | 2.2712 |
| 16 | | 2.0458 |
| 17 | | 2.0285 |
| 24 | .5616 | |
| Max | .5616 | 2.4446 |
| Min | .4854 | 2.0285 |
| Avg | .5209 | 2.3037 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 203 / Pathare Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------------|--------------|--------------|--------------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5028 | | .5201 |
| 2 | .5028 | | .4854 |
| 3 | .5375 | | .4854 |
| 4 | .5721 | | .5375 |
| 5 | .5721 | | .5201 |
| 6 | .6241 | | .5548 |
| 7 | .6068 | | .5721 |
| 8 | .5375 | | .5721 |
| 23 | | .5028 | |
| 24 | .5201 | | .5375 |
| Max | .6241 | .5028 | .5721 |
| Min | .5028 | .5028 | .4854 |
| Avg | .5529 | .5028 | .5317 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 204 / PANI-PURWATHA TAVKHEDA NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1734 | | .1867 | | .1734 | .2033 |
| 2 | .1734 | | .1867 | | .1734 | .2033 |
| 3 | .1734 | | .1867 | | .1734 | .1848 |
| 4 | .1734 | | .1848 | | .1734 | .2033 |
| 5 | .1734 | | .1848 | | .1734 | .2033 |
| 6 | .1734 | | .1867 | | .1734 | .2054 |
| 7 | .1734 | | .1848 | | .1907 | .2054 |
| 8 | .1734 | | .1848 | | .1734 | .1867 |
| 9 | | .2012 | | .1907 | .181 | .2614 |
| 10 | | .2012 | | .2774 | .2561 | |
| 11 | | .2743 | | .2774 | .2743 | |
| 12 | | .2772 | | .2601 | .2743 | |
| 13 | | .2033 | | .2427 | .2033 | |
| 14 | | .2743 | | .208 | .2587 | |
| 15 | | .2743 | | .208 | .2587 | |
| 16 | | .2587 | | .1907 | .2587 | |
| 17 | | .2561 | | .2427 | .2614 | |
| 18 | | .2012 | | .1734 | .2054 | |
| 19 | | .1829 | | .1734 | .2054 | |
| 20 | | .1848 | | .1734 | .1307 | |
| 21 | | .1848 | | .1734 | .1867 | |
| 22 | | .1848 | | .1734 | .2054 | |
| 23 | | .2054 | | .1734 | .2054 | |
| 24 | .0762 | | .1867 | | .1734 | .2054 |
| Max | .1734 | .2772 | .1867 | .2774 | .2743 | .2614 |
| Min | .0762 | .1829 | .1848 | .1734 | .1307 | .1848 |
| Avg | .1626 | .2243 | .1859 | .2092 | .2060 | .2062 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 205 / Daul Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4681 | | .4681 |
| 2 | .5375 | | .4508 |
| 3 | .6762 | | .5028 |
| 4 | .8149 | | .5895 |
| 5 | .8669 | | .6762 |
| 6 | .9362 | | .7975 |
| 7 | .9882 | | .9882 |
| 8 | .9189 | | .8669 |
| 9 | | .8322 | |
| 10 | | .5548 | |
| 11 | | .5201 | |
| 12 | | .4508 | |
| 13 | | .4161 | |
| 14 | | .3121 | |
| 15 | | .3814 | |
| 16 | | .4508 | |
| 17 | | .4508 | |
| 18 | | .6068 | |
| 19 | | .6588 | |
| 20 | | .6241 | |
| 21 | | .5895 | |
| 22 | | .5201 | |
| 23 | | .4854 | |
| 24 | .527 | | .4854 |
| Max | .9882 | .8322 | .9882 |
| Min | .4681 | .3121 | .4508 |
| Avg | .7482 | .5236 | .6473 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi

Sagar

Feeder No / Name : 201 / 11Kv Dondaicha (Tapi

SHEDDABLE URBAN

Sagar) Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4232 | 1.829 | 1.8861 | 1.8861 | 1.9547 | 1.7223 | 1.8004 |
| 2 | 1.3717 | 1.829 | 2.0576 | 1.8861 | 1.5432 | 1.6613 | 1.6461 |
| 3 | 1.3717 | 1.8595 | 2.0576 | 2.0576 | 1.5432 | 1.7375 | 1.6975 |
| 4 | 1.7833 | 1.8595 | 2.0919 | 2.1262 | 1.5947 | 1.829 | 1.869 |
| 5 | 2.1434 | 1.8747 | 2.2634 | 2.2291 | 1.8861 | 2.0729 | 2.1262 |
| 6 | 2.452 | 2.2862 | 2.572 | 2.572 | 2.7435 | 2.2253 | 2.7263 |
| 7 | 2.8978 | 2.4691 | 2.6406 | 2.8978 | 2.9492 | 2.4387 | 2.9664 |
| 8 | 2.332 | 2.6749 | 2.6749 | 2.6406 | 2.7092 | 2.21 | 2.5549 |
| 9 | 2.1338 | 2.4863 | 2.4348 | 2.4348 | 2.1186 | 2.2977 | 2.2977 |
| 10 | 2.0576 | 2.4006 | 2.4006 | 2.332 | 2.1033 | | 2.3148 |
| 11 | 2.1338 | 2.5377 | 2.1605 | 2.4691 | 2.0881 | 2.3663 | 2.3834 |
| 12 | 2.1491 | 2.4006 | 2.1262 | 2.332 | 2.1795 | 2.3834 | 2.3834 |
| 13 | 2.0729 | 2.1605 | 2.2291 | 2.2291 | 2.0729 | 2.2805 | 2.3491 |
| 14 | 1.9966 | 2.1262 | 2.2634 | 2.2291 | 2.1033 | 2.3148 | 2.332 |
| 15 | 1.9966 | 2.4006 | 2.332 | 2.1948 | 2.1643 | 2.3491 | 2.3663 |
| 16 | 2.1186 | 2.4691 | 2.3663 | 2.2119 | 2.0424 | 2.3148 | 2.3663 |
| 17 | 2.1338 | 2.4348 | 2.3148 | 2.1605 | 2.1338 | 2.2805 | 2.3663 |
| 18 | 2.1186 | 2.4348 | 2.4006 | 2.2977 | 2.0881 | 2.4177 | 2.5549 |
| 19 | 2.5301 | 3.0007 | 2.4691 | 2.7606 | 2.4996 | 3.0693 | 2.915 |
| 20 | 2.4844 | 2.7778 | 2.7949 | 2.7435 | 2.4387 | 2.8464 | 2.8121 |
| 21 | 2.4691 | 2.4691 | 2.572 | 2.5549 | 2.2558 | 2.572 | 2.6578 |
| 22 | 2.1795 | 2.2291 | 2.4691 | 2.4348 | 2.1338 | 2.5206 | 2.5034 |
| 23 | 1.9662 | 2.0576 | 2.2291 | 2.2291 | 1.9814 | 2.2291 | 2.3148 |
| 24 | 1.9719 | 1.8138 | 1.8861 | 2.0576 | 2.0748 | 1.829 | 2.0576 |
| Max | 2.8978 | 3.0007 | 2.7949 | 2.8978 | 2.9492 | 3.0693 | 2.9664 |
| Min | 1.3717 | 1.8138 | 1.8861 | 1.8861 | 1.5432 | 1.6613 | 1.6461 |
| Avg | 2.0953 | 2.2867 | 2.3205 | 2.3320 | 2.1418 | 2.2595 | 2.3484 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi
SagarFeeder No / Name : 202 / Universal Starch Allied NON SHEDDABLE EXPRESS HV FEEDERS
(USA) Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2743 | .3201 | .3429 | .6001 | .5487 | .5487 | .6516 |
| 2 | .2572 | .3353 | .3772 | .6001 | .5487 | .5487 | .6687 |
| 3 | .2572 | .3353 | .3772 | .5487 | .5487 | .5487 | .1715 |
| 4 | .2572 | .3048 | .5144 | .5487 | .5316 | .5792 | .1372 |
| 5 | .2572 | .3201 | .5144 | .5487 | .583 | .6097 | .1372 |
| 6 | .2743 | .3353 | .5487 | .583 | .5658 | .6401 | .7202 |
| 7 | .2572 | .5182 | .5487 | .6173 | .3258 | .5335 | .7716 |
| 8 | .2286 | .1715 | .5487 | .6173 | .2743 | .5182 | .6001 |
| 9 | .2286 | .2572 | .583 | .6173 | .1372 | .6344 | .6516 |
| 10 | .2439 | .3429 | .583 | .703 | .1372 | .6344 | .7202 |
| 11 | .2591 | .5487 | .5487 | .7202 | .6706 | .6687 | .4458 |
| 12 | .2591 | .5487 | .583 | .6516 | .6097 | .703 | .6516 |
| 13 | .2439 | .583 | .5487 | .6001 | .5487 | .7202 | .6173 |
| 14 | .2439 | .6173 | .583 | .6516 | .5487 | .703 | .6173 |
| 15 | .2591 | .6173 | .5487 | .6859 | .5792 | .703 | .6516 |
| 16 | .2743 | .6344 | .5487 | .583 | .5487 | .6687 | .6173 |
| 17 | .2896 | .6687 | .583 | .5316 | .5639 | .6344 | .7202 |
| 18 | .2591 | .4801 | .583 | .2915 | .5487 | .5658 | .583 |
| 19 | .3658 | .5487 | .583 | .5487 | .6097 | .5658 | .6344 |
| 20 | .4572 | .5144 | .583 | .6173 | .6249 | .6687 | .6516 |
| 21 | .6859 | .7202 | .6173 | .5316 | .503 | .6687 | .6344 |
| 22 | .2591 | .3086 | .6859 | .583 | .5335 | .6001 | .7202 |
| 23 | .1067 | .4458 | .6859 | .4115 | .5487 | .6001 | .6001 |
| 24 | .2743 | .3963 | .4458 | .583 | .583 | .5487 | .6173 |
| Max | .6859 | .7202 | .6859 | .7202 | .6706 | .7202 | .7716 |
| Min | .1067 | .1715 | .3429 | .2915 | .1372 | .5182 | .1372 |
| Avg | .2822 | .4530 | .5444 | .5823 | .5093 | .6173 | .583 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 201 / VIKHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5175 | .5175 | .6653 | .5544 | .5544 | .5175 | .7023 |
| 2 | .5544 | .5544 | .7392 | .5544 | .5914 | .5175 | .8316 |
| 3 | .8316 | .4934 | .8131 | .5914 | .6653 | .5544 | .9425 |
| 4 | .961 | .924 | .9055 | .8686 | .961 | .6838 | 1.0719 |
| 5 | 1.0719 | 1.0164 | .9795 | .9425 | 1.1088 | .8871 | 1.1827 |
| 6 | 1.1273 | 1.2752 | 1.0719 | 1.2012 | 1.1273 | .9425 | 1.3121 |
| 7 | 1.2752 | 1.1088 | | 1.2936 | 1.2382 | .9795 | 1.4415 |
| 8 | .961 | .9979 | 1.0164 | 1.0164 | .961 | 1.0349 | 1.1088 |
| 9 | .7577 | .8686 | .7577 | .7762 | .8131 | .7392 | .8501 |
| 10 | .6468 | .8131 | .5729 | .6099 | .6099 | .5914 | |
| 11 | .5544 | .7762 | .6283 | .5729 | .5544 | .5914 | |
| 12 | .5175 | .6468 | .5914 | .499 | .4805 | .5175 | |
| 13 | .499 | .5729 | .5729 | .5175 | .5729 | .4805 | |
| 14 | .462 | .5359 | .5544 | .4805 | .4805 | .4805 | |
| 15 | .5544 | .6283 | .5175 | .5729 | .499 | .5729 | |
| 16 | .5914 | .6468 | .499 | .5914 | .5175 | .6283 | |
| 17 | .7095 | .7207 | .4805 | .6099 | .5544 | .5914 | |
| 18 | .924 | .8871 | .7207 | .7023 | .8686 | .7762 | |
| 19 | 1.2382 | 1.1827 | 1.1088 | 1.1458 | 1.0719 | 1.1458 | |
| 20 | .8871 | .9425 | .9795 | .924 | .8871 | 1.0349 | |
| 21 | .8131 | .8131 | .7947 | .7762 | .7577 | .8131 | |
| 22 | .6653 | .7207 | .5914 | .6653 | .6653 | .7207 | |
| 23 | .6468 | .6468 | .5914 | .6099 | .5544 | .6283 | |
| 24 | .5175 | .6468 | .5914 | | .5544 | .5544 | .5914 |
| Max | 1.2752 | 1.2752 | 1.1088 | 1.2936 | 1.2382 | 1.1458 | 1.4415 |
| Min | .462 | .4934 | .4805 | .4805 | .4805 | .4805 | .5914 |
| Avg | .7619 | .7890 | .7280 | .7424 | .7354 | .7077 | 1.0035 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 202 / PEDKAI MATA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .423 | .4793 | .7049 | .5639 | .4934 | .5357 |
| 11 | .7331 | .6908 | .6908 | .6767 | .5639 | .6626 |
| 12 | .7049 | .7049 | .6626 | .5639 | .7577 | .578 |
| 13 | .6344 | .7049 | .6485 | .5639 | .5498 | .6062 |
| 14 | .6203 | .6485 | .5639 | .5075 | .6283 | .578 |
| 15 | .5639 | .5921 | .5921 | .4652 | .4512 | .5357 |
| 16 | .6626 | .6344 | .5075 | .5216 | .7023 | .6062 |
| 17 | | .6344 | .6062 | .5357 | .7207 | .6203 |
| Max | .7331 | .7049 | .7049 | .6767 | .7577 | .6626 |
| Min | .423 | .4793 | .5075 | .4652 | .4512 | .5357 |
| Avg | .6203 | .6362 | .6221 | .5498 | .6084 | .5903 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 203 / KHARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4115 | .5487 | .578 | .5921 | .4938 | .5213 | .6203 |
| 2 | .439 | .6173 | .6062 | .578 | .4938 | .4938 | .719 |
| 3 | .4664 | .6173 | .6203 | .5639 | .5487 | .439 | .8177 |
| 4 | .4938 | .5761 | .6485 | .5639 | .5761 | .5487 | .9164 |
| 5 | .5075 | .6173 | .6626 | .7754 | .6036 | .5898 | 1.0151 |
| 6 | .5075 | .6584 | .6908 | .9869 | .6584 | .6447 | 1.1138 |
| 7 | .7682 | .9465 | 1.0997 | 1.001 | 1.1111 | 1.0014 | 1.2125 |
| 8 | .9877 | 1.0288 | 1.1561 | 1.001 | 1.2071 | 1.0974 | 1.1138 |
| 9 | .9877 | 1.1797 | | | | | |
| 23 | | .4793 | .2538 | .4938 | .439 | .5075 | |
| 24 | .3841 | .4115 | .423 | .423 | .5487 | .4938 | .5357 |
| Max | .9877 | 1.1797 | 1.1561 | 1.001 | 1.2071 | 1.0974 | 1.2125 |
| Min | .3841 | .4115 | .2538 | .423 | .439 | .439 | .5357 |
| Avg | .5953 | .6983 | .6739 | .6979 | .6680 | .6337 | .8960 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 202 / S.MANDAL

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| | |
|------|-----------|
| DATE | 01-MAR-18 |
| HR | Load (MW) |
| 24 | .381 |
| Max | .381 |
| Min | .381 |
| Avg | .381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217] BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 203 / MALPUR

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .6097 |
| Max | .6097 |
| Min | .6097 |
| Avg | .6097 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 205 / 11kV SINDHI COLONY,
DONDAICHA Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .1524 |
| Max | .1524 |
| Min | .1524 |
| Avg | .1524 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217] BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 206 / NIMGUL

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .1524 |
| Max | .1524 |
| Min | .1524 |
| Avg | .1524 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 401 / 33KV VARUL

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.829 |
| Max | 1.829 |
| Min | 1.829 |
| Avg | 1.829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 402 / 33KV NIMGUL

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 5.487 |
| Max | 5.487 |
| Min | 5.487 |
| Avg | 5.487 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 404 / 33KV KUKAWAL

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.829 |
| Max | 1.829 |
| Min | 1.829 |
| Avg | 1.829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 405 / 33KV SHINDKHEDA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.829 |
| Max | 1.829 |
| Min | 1.829 |
| Avg | 1.829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097011 / 220/132/33KV DONDAICHA

SUBSTAT

Feeder No / Name : 403 / 33KV INDAVE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.829 |
| Max | 1.829 |
| Min | 1.829 |
| Avg | 1.829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097011 / 220/132/33KV DONDAICHA

SUBSTAT

Feeder No / Name : 404 / 33KV DEGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS) (NO

STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .9145 |
| Max | .9145 |
| Min | .9145 |
| Avg | .9145 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097011 / 220/132/33KV DONDAICHA

SUBSTAT

Feeder No / Name : 405 / 33KV CHIMTHANE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.829 |
| Max | 1.829 |
| Min | 1.829 |
| Avg | 1.829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097011 / 220/132/33KV DONDAICHA

SUBSTAT

Feeder No / Name : 406 / 33KV DONDAICHA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .9145 |
| Max | .9145 |
| Min | .9145 |
| Avg | .9145 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 201 / 11KV AKKADSE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5432 | 1.4575 | |
| 2 | 1.5432 | 1.4575 | |
| 3 | 1.5432 | 1.4575 | |
| 4 | 1.5432 | 1.4575 | |
| 5 | 1.7147 | 1.4575 | |
| 6 | 1.7147 | 1.8861 | |
| 7 | 1.7147 | 1.8861 | |
| 8 | 1.7147 | 1.8004 | |
| 10 | 1.2003 | | .3429 |
| 11 | 1.3717 | 1.3717 | .3429 |
| 12 | .9431 | 1.3717 | .3429 |
| 13 | .9431 | 1.3717 | .3429 |
| 14 | 1.0288 | 1.3717 | |
| 15 | 1.286 | 1.3717 | |
| 16 | 1.286 | 1.3717 | |
| 17 | 1.3717 | 1.3717 | |
| 23 | 1.5432 | 1.6289 | |
| 24 | 1.3717 | 1.4575 | |
| Max | 1.7147 | 1.8861 | .3429 |
| Min | .9431 | 1.3717 | .3429 |
| Avg | 1.4098 | 1.5028 | .3429 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 202 / 11KV VIRDEL AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3717 | 1.286 | 1.286 | | 1.3717 | 1.286 | 1.286 |
| 2 | 1.3717 | 1.286 | 1.286 | | 1.3717 | 1.286 | 1.286 |
| 3 | 1.3717 | 1.286 | 1.286 | | 1.3717 | 1.286 | 1.286 |
| 4 | 1.3717 | 1.286 | 1.286 | | 1.3717 | 1.286 | 1.3717 |
| 5 | 1.3717 | 1.286 | 1.286 | | 1.3717 | 1.3717 | 1.3717 |
| 6 | 1.3717 | 1.6289 | 1.286 | | 1.3717 | 1.4575 | 1.4575 |
| 7 | 1.3717 | 1.6289 | 1.4575 | | 1.3717 | 1.4575 | 1.4575 |
| 8 | 1.3717 | 1.4575 | 1.4575 | | 1.3717 | 1.5432 | 1.4575 |
| 10 | .7716 | .6001 | .6859 | .6001 | .5144 | .6859 | |
| 11 | .8573 | .6859 | .6859 | .8573 | .6859 | .7716 | .6859 |
| 12 | .8573 | .6859 | .6859 | .6859 | .6001 | .7716 | .6859 |
| 13 | .8573 | .6859 | .6859 | .6859 | .6001 | .7716 | .6859 |
| 14 | .8573 | .6859 | .6859 | .6859 | .5144 | .6859 | .6859 |
| 15 | .6859 | .6859 | .6859 | .6859 | .6001 | .6859 | .6001 |
| 16 | .6859 | .6859 | .6859 | .6859 | .6859 | .6859 | .6001 |
| 17 | .6859 | .6859 | .6859 | .6859 | .6859 | .6859 | .5144 |
| 21 | | | | 1.1145 | | | |
| 22 | | | | 1.2003 | | | |
| 23 | 1.286 | 1.3717 | .7716 | 1.3717 | 1.2003 | 1.0288 | 1.2003 |
| 24 | 1.2003 | 1.286 | 1.286 | | 1.3717 | 1.286 | 1.286 |
| Max | 1.3717 | 1.6289 | 1.4575 | 1.3717 | 1.3717 | 1.5432 | 1.4575 |
| Min | .6859 | .6001 | .6859 | .6001 | .5144 | .6859 | .5144 |
| Avg | 1.0955 | 1.0669 | 1.0098 | .8418 | 1.0240 | 1.0574 | 1.0540 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 203 / 11KV CHIMTHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.286 | 1.2003 | 1.286 | 1.2003 | 1.2003 | 1.286 | 1.2003 |
| 11 | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.286 | 1.3717 | 1.2003 |
| 12 | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.1145 | 1.0288 | 1.2003 |
| 13 | 1.1145 | 1.3717 | 1.2003 | 1.2003 | 1.286 | 1.1145 | 1.2003 |
| 14 | 1.1145 | 1.3717 | 1.1145 | 1.0288 | 1.1145 | 1.1145 | 1.1145 |
| 15 | 1.2003 | 1.3717 | 1.0288 | 1.0288 | 1.1145 | 1.1145 | 1.0288 |
| 16 | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.286 | 1.1145 | 1.2003 |
| 17 | 1.2003 | 1.286 | 1.1145 | 1.2003 | 1.286 | 1.2003 | 1.1145 |
| 22 | | | | | .6859 | | |
| 23 | | | | | .7716 | | |
| Max | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.286 | 1.3717 | 1.2003 |
| Min | 1.1145 | 1.2003 | 1.0288 | 1.0288 | .6859 | 1.0288 | 1.0288 |
| Avg | 1.2324 | 1.3181 | 1.2110 | 1.1574 | 1.1145 | 1.1681 | 1.1574 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 204 / 11KV SHINDKHEDA URBAN

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | 1.2003 | 1.0288 | 1.2003 | 1.2003 | 1.1145 | 1.2003 |
| 2 | 1.2003 | 1.2003 | 1.0288 | 1.2003 | 1.2003 | 1.1145 | 1.2003 |
| 3 | 1.2003 | 1.2003 | 1.0288 | 1.2003 | 1.2003 | 1.1145 | 1.2003 |
| 4 | 1.3717 | 1.2003 | 1.0288 | 1.3717 | 1.2003 | 1.1145 | 1.3717 |
| 5 | 1.2003 | 1.2003 | 1.0288 | 1.3717 | 1.3717 | 1.4575 | 1.3717 |
| 6 | 1.5432 | 1.3717 | 1.0288 | 1.5432 | 1.5432 | 1.5432 | 1.4575 |
| 7 | 1.5432 | 1.3717 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.4575 |
| 8 | 1.5432 | 1.3717 | 1.3717 | 1.5432 | 1.3717 | 1.3717 | 1.4575 |
| 9 | 1.2003 | 1.0288 | 1.1145 | 1.286 | 1.3717 | 1.286 | 1.3717 |
| 10 | 1.286 | 1.1145 | 1.2003 | 1.286 | 1.3717 | 1.2003 | 1.286 |
| 11 | 1.2003 | 1.2003 | 1.2003 | 1.286 | 1.2003 | 1.2003 | 1.2003 |
| 12 | 1.2003 | 1.2003 | 1.2003 | 1.1145 | 1.2003 | .9431 | 1.286 |
| 13 | 1.2003 | 1.2003 | 1.0288 | .5144 | 1.2003 | 1.0288 | 1.2003 |
| 14 | 1.2003 | 1.2003 | 1.286 | .5144 | 1.286 | 1.0288 | 1.2003 |
| 15 | 1.286 | 1.2003 | 1.2003 | 1.286 | | 1.2003 | 1.3717 |
| 16 | 1.286 | 1.0288 | 1.286 | 1.286 | 1.4575 | 1.1145 | 1.2003 |
| 17 | 1.286 | 1.0288 | 1.286 | 1.286 | 1.3717 | 1.2003 | 1.2003 |
| 18 | 1.2003 | 1.1145 | 1.286 | 1.3717 | 1.286 | 1.3717 | 1.3717 |
| 19 | 1.5432 | 1.3717 | 1.5432 | 1.5432 | 1.3717 | 1.5432 | 1.5432 |
| 20 | 1.5432 | 1.3717 | 1.4575 | 1.4575 | 1.4575 | 1.4575 | 1.5432 |
| 21 | 1.3717 | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.4575 | 1.3717 |
| 22 | 1.2003 | 1.3717 | 1.3717 | 1.3717 | 1.2003 | 1.3717 | 1.3717 |
| 23 | 1.2003 | 1.2003 | 1.3717 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| 24 | 1.2003 | 1.2003 | 1.0288 | 1.2003 | 1.2003 | 1.1145 | 1.2003 |
| Max | 1.5432 | 1.3717 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |
| Min | 1.2003 | 1.0288 | 1.0288 | .5144 | 1.2003 | .9431 | 1.2003 |
| Avg | 1.3003 | 1.2217 | 1.2217 | 1.2646 | 1.3046 | 1.2539 | 1.3182 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 206 / 11 KV TEMLAI + AKKADSE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .4287 | .3429 | .3429 | .3429 | .3429 | .3429 |
| 2 | .3429 | .4287 | .3429 | .3429 | .3429 | .3429 | .3429 |
| 3 | .3429 | .4287 | .3429 | .3429 | .3429 | .3429 | .3429 |
| 4 | .3429 | .4287 | .3429 | .5144 | .4287 | .3429 | .4287 |
| 5 | .4287 | .4287 | .3429 | .6859 | .5144 | .4287 | .5144 |
| 6 | .5144 | .6859 | .3429 | .5144 | .6001 | .6001 | .6859 |
| 7 | .5144 | .6859 | .6001 | .3429 | .5144 | .6001 | .6859 |
| 8 | .4287 | .5144 | .5144 | .4287 | .5144 | .5144 | .5144 |
| 9 | .3429 | .3429 | .3429 | .3429 | .4287 | .3429 | .4287 |
| 10 | .3429 | .3429 | .2572 | .3429 | .3429 | .2572 | .3429 |
| 11 | .2572 | .3429 | .2572 | .2572 | .2572 | .2572 | .2572 |
| 12 | .2572 | .3429 | .2572 | .3429 | .2572 | .2572 | .2572 |
| 13 | .2572 | .3429 | .2572 | .3429 | .2572 | .2572 | .2572 |
| 14 | .2572 | .3429 | .2572 | .3429 | .2572 | .2572 | |
| 15 | .3429 | .3429 | .2572 | .3429 | .2572 | .2572 | .2572 |
| 16 | .3429 | .3429 | .2572 | .3429 | .2572 | .2572 | .2572 |
| 17 | .4287 | .3429 | .4287 | .4287 | .2572 | .3429 | .3429 |
| 18 | .5144 | .4287 | .3429 | .4287 | .3429 | .4287 | .5144 |
| 19 | .5144 | .5144 | .5144 | .5144 | .4287 | .5144 | .5144 |
| 20 | .5144 | .5144 | .5144 | .4287 | .4287 | .4287 | .5144 |
| 21 | .5144 | .5144 | .4287 | .4287 | .4287 | .4287 | .4287 |
| 22 | .4287 | .5144 | .4287 | .4287 | .4287 | .4287 | .4287 |
| 23 | .3429 | .3429 | .3429 | .4287 | .4287 | .3429 | .3429 |
| 24 | .3429 | .4287 | .3429 | .3429 | .3429 | .3429 | .3429 |
| Max | .5144 | .6859 | .6001 | .6859 | .6001 | .6001 | .6859 |
| Min | .2572 | .3429 | .2572 | .2572 | .2572 | .2572 | .2572 |
| Avg | .3858 | .4322 | .3608 | .4001 | .3751 | .3715 | .4063 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 207 / 11KV CHIMTHANE+VIRDEL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .6097 | .6097 | .6859 | .5144 | .6859 | .6859 |
| 2 | .5144 | .6097 | .6097 | .6859 | .5144 | .6859 | .6859 |
| 3 | .6001 | .6097 | .6097 | .6859 | .6001 | .6859 | .6859 |
| 4 | .6859 | .6097 | .6097 | .8573 | .6001 | .6859 | .8573 |
| 5 | .8573 | .6097 | .6097 | .8573 | .6859 | .9431 | .8573 |
| 6 | 1.0288 | 1.286 | .6097 | .8573 | .8573 | 1.1145 | .8573 |
| 7 | 1.0288 | 1.286 | 1.2003 | .8573 | 1.0288 | 1.0288 | .8573 |
| 8 | .8573 | .8573 | 1.2003 | .6859 | .8573 | .7716 | .8573 |
| 9 | .6859 | .6859 | .6859 | .6001 | .7716 | .6859 | .7716 |
| 10 | .5144 | .6001 | .5144 | .6001 | .6859 | .5144 | .6859 |
| 11 | .5144 | .6001 | .5144 | .5144 | .5144 | .4287 | .6001 |
| 12 | .5144 | .6001 | .5144 | .5144 | .5144 | .4287 | .5144 |
| 13 | .5144 | .6001 | .5144 | .5144 | | .4287 | .5144 |
| 14 | .5144 | .6001 | .5144 | .5144 | .5144 | .5144 | .5144 |
| 15 | .6001 | .6001 | .5144 | .5144 | .5144 | .6001 | .5144 |
| 16 | .6001 | .6001 | .5144 | .5144 | .5144 | .6001 | .5144 |
| 17 | .6859 | .5144 | .5144 | .6001 | .6001 | .6001 | .6001 |
| 18 | .8573 | .7716 | .6001 | .8573 | .6859 | .6859 | .7716 |
| 19 | .6001 | 1.0288 | .9431 | 1.1145 | .8573 | .8573 | .9431 |
| 20 | .8573 | 1.0288 | .9431 | .8573 | .8573 | .7716 | 1.0288 |
| 21 | .8573 | 1.0288 | .8573 | .8573 | .7716 | .7716 | .8573 |
| 22 | .6859 | 1.0288 | .7716 | .6859 | .6859 | .7716 | .7716 |
| 23 | .6859 | .6859 | .6001 | .6001 | .6859 | .6859 | .6859 |
| 24 | .5144 | .6859 | | .6859 | .6001 | .6001 | .6859 |
| Max | 1.0288 | 1.286 | 1.2003 | 1.1145 | 1.0288 | 1.1145 | 1.0288 |
| Min | .5144 | .5144 | .5144 | .5144 | .5144 | .4287 | .5144 |
| Avg | .6787 | .7557 | .6772 | .6966 | .6710 | .6894 | .7216 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 208 / 11KV TEMLAY AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | 1.0288 | .9431 | 1.1145 | 1.2003 | .9431 | 1.0288 |
| 2 | 1.2003 | 1.0288 | .9431 | 1.1145 | 1.2003 | .9431 | 1.0288 |
| 3 | 1.2003 | 1.0288 | .9431 | 1.1145 | 1.2003 | .9431 | 1.0288 |
| 4 | 1.2003 | 1.0288 | .9431 | 1.2003 | 1.3717 | .9431 | 1.2003 |
| 5 | 1.2003 | 1.0288 | .9431 | 1.3717 | 1.3717 | 1.2003 | 1.3717 |
| 6 | 1.2003 | 1.3717 | .9431 | 1.3717 | 1.3717 | 1.286 | 1.3717 |
| 7 | 1.2003 | 1.3717 | 1.286 | 1.3717 | 1.3717 | 1.286 | 1.3717 |
| 8 | 1.3717 | 1.3717 | 1.2003 | 1.3717 | 1.3717 | 1.2003 | .8573 |
| 22 | | .8573 | | | | | |
| 23 | 1.0288 | .9431 | 1.0288 | 1.0288 | .8573 | 1.2003 | .9431 |
| 24 | .8573 | 1.0288 | .9431 | 1.1145 | 1.0288 | .9431 | 1.0288 |
| Max | 1.3717 | 1.3717 | 1.286 | 1.3717 | 1.3717 | 1.286 | 1.3717 |
| Min | .8573 | .8573 | .9431 | 1.0288 | .8573 | .9431 | .8573 |
| Avg | 1.1660 | 1.0989 | 1.0117 | 1.2174 | 1.2346 | 1.0888 | 1.1231 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 201 / 11KV AARAVE AG FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 02-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.1431 | | 1.2193 | 1.2651 | .6859 |
| 11 | 1.6766 | | 1.2955 | 1.4632 | .9145 |
| 12 | 1.829 | | 1.2498 | 1.3565 | 1.448 |
| 13 | 1.7223 | | 1.2955 | 1.3413 | 1.3717 |
| 14 | 1.6004 | | 1.2193 | 1.2651 | 1.448 |
| 15 | 1.6004 | | 1.2498 | 1.2955 | .8078 |
| 16 | 1.6309 | | 1.2193 | 1.326 | .7621 |
| 17 | 1.6309 | 1.6309 | 1.2346 | 1.326 | .6859 |
| Max | 1.829 | 1.6309 | 1.2955 | 1.4632 | 1.448 |
| Min | 1.1431 | 1.6309 | 1.2193 | 1.2651 | .6859 |
| Avg | 1.6042 | 1.6309 | 1.2479 | 1.3298 | 1.0155 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 202 / 11KV CHIMTHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .5335 | .7316 | .7316 | .6859 | .6706 | .6401 | .4572 |
| 11 | .8383 | .7621 | .8383 | .7621 | .7316 | .7621 | .6859 |
| 12 | .9145 | .7926 | .8078 | .7621 | .6859 | .7468 | .5639 |
| 13 | .7621 | .7621 | .6554 | .6097 | .6249 | .7621 | .5944 |
| 14 | .6859 | .7164 | .5792 | .5335 | .6097 | .5944 | .5335 |
| 15 | .6859 | .6859 | .6097 | .5335 | .5182 | .6097 | .5944 |
| 16 | .6859 | .7164 | .6249 | .5335 | .6097 | .6097 | .6097 |
| 17 | .7621 | .6706 | .7164 | .6859 | .6706 | .6401 | .6097 |
| Max | .9145 | .7926 | .8383 | .7621 | .7316 | .7621 | .6859 |
| Min | .5335 | .6706 | .5792 | .5335 | .5182 | .5944 | .4572 |
| Avg | .7335 | .7297 | .6954 | .6383 | .6402 | .6706 | .5811 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 203 / 11KV KHALANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5335 | .381 | .6859 | .6859 | .4572 | .5335 | .6401 |
| 2 | .4572 | .4572 | .7316 | .7621 | .4877 | .6097 | .7164 |
| 3 | .503 | .5335 | .7468 | .8688 | .5487 | .6097 | .7773 |
| 4 | | .6097 | .7926 | .9145 | .6097 | .6859 | .8078 |
| 5 | .5335 | .6554 | .8383 | .9907 | .6859 | .7621 | .8688 |
| 6 | .5335 | .6859 | 1.0669 | 1.0364 | .7621 | .8383 | .9297 |
| 7 | .7621 | .7621 | 1.1431 | 1.0669 | 1.0669 | .9145 | 1.0212 |
| 8 | .9145 | .9145 | 1.2955 | 1.2041 | 1.2193 | 1.1431 | 1.1431 |
| 9 | .9145 | | | | | | |
| 23 | .381 | .6097 | .4877 | .381 | .5335 | .5792 | .381 |
| 24 | .6859 | .4572 | .5792 | | .4572 | .5944 | |
| Max | .9145 | .9145 | 1.2955 | 1.2041 | 1.2193 | 1.1431 | 1.1431 |
| Min | .381 | .381 | .4877 | .381 | .4572 | .5335 | .381 |
| Avg | .6219 | .6066 | .8368 | .8789 | .6828 | .7270 | .8095 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 204 / 11KV SHEWALE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3048 | .3048 | .2743 | .2591 | .2286 | .2134 | .2286 |
| 2 | .2286 | .381 | .2286 | .2286 | .3048 | .1829 | .1524 |
| 3 | .2286 | .4572 | .2134 | .1524 | .381 | .2134 | .3048 |
| 4 | .3048 | .5335 | .1524 | .3048 | .4572 | .3048 | .381 |
| 5 | .4268 | 1.0669 | | .3506 | .5335 | .381 | .5335 |
| 6 | .503 | .6859 | .4268 | .381 | .6859 | .4572 | .5335 |
| 7 | .3048 | .7621 | .5487 | .381 | .6401 | .5335 | .503 |
| 8 | .381 | .3048 | .4572 | .381 | .4877 | .3658 | .381 |
| 9 | .3048 | .3048 | .4268 | .3048 | .4115 | .3048 | .3048 |
| 10 | .3048 | .2743 | .2286 | .4115 | .3658 | .2286 | .2591 |
| 11 | .2591 | .2896 | .2591 | .2286 | .3506 | .2134 | .2286 |
| 12 | .2286 | .2439 | .1829 | .1981 | .381 | .2439 | .1981 |
| 13 | .2896 | .2286 | .2439 | .2286 | .3353 | .2286 | .1677 |
| 14 | .2134 | .2134 | .2439 | .2591 | .2743 | .3048 | .1524 |
| 15 | .2743 | .2439 | .2743 | .2743 | .2134 | .2743 | .1219 |
| 16 | .3048 | .2896 | .1981 | .2439 | .2439 | .3048 | .1981 |
| 17 | .2896 | .3048 | .2896 | .2743 | .2896 | .3048 | .2743 |
| 18 | .2896 | .4268 | .3048 | .3048 | .3048 | .3048 | .3658 |
| 19 | .503 | .442 | .381 | .4268 | .4572 | .4572 | .5335 |
| 20 | .4572 | .5335 | .3048 | .503 | .5335 | .4572 | .4877 |
| 21 | .3658 | .4572 | .3353 | .4268 | .4268 | .381 | .4115 |
| 22 | .4115 | .381 | .3048 | .3353 | .3506 | .3506 | .3353 |
| 23 | .381 | .3353 | .3048 | .2591 | .3048 | .3048 | .2896 |
| 24 | | .3048 | .3048 | | .2286 | .3048 | |
| Max | .503 | 1.0669 | .5487 | .503 | .6859 | .5335 | .5335 |
| Min | .2134 | .2134 | .1524 | .1524 | .2134 | .1829 | .1219 |
| Avg | .3287 | .4071 | .2995 | .3095 | .3829 | .3175 | .3194 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 205 / 11KV CHIMTHANE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .381 | .3048 | .3048 | .3048 | .1829 | .3048 |
| 2 | .3048 | .4572 | .2286 | .3048 | .381 | .2134 | .1981 |
| 3 | .381 | .5335 | .1524 | .2286 | .4572 | .2743 | .3048 |
| 4 | .4572 | .6097 | .2743 | .381 | .5335 | .4572 | .4572 |
| 5 | .5792 | .6859 | .381 | .5335 | .6859 | .5335 | .6097 |
| 6 | .9602 | .7621 | .4572 | .7164 | .8383 | .6097 | .7468 |
| 7 | .8688 | .8383 | .5335 | .8383 | .8383 | .8688 | .8688 |
| 8 | .6859 | .381 | .5792 | .6859 | .5792 | .6097 | .6097 |
| 9 | .381 | .381 | .4877 | | .3658 | .381 | .5335 |
| 10 | .381 | .3658 | .381 | .4572 | .3658 | .3353 | .381 |
| 11 | .3353 | .381 | .3048 | .3048 | .3506 | .3048 | .3048 |
| 12 | .3048 | .3963 | .3353 | .3048 | .3048 | .3048 | .2286 |
| 13 | .3353 | .3658 | .3048 | .3048 | .2896 | .3048 | .1981 |
| 14 | .3048 | .3506 | .3353 | .3048 | .3048 | .3048 | .1981 |
| 15 | .3353 | .3048 | .3353 | .381 | .3201 | .3048 | .3048 |
| 16 | .3506 | .3658 | .381 | .3048 | .3048 | .3048 | .3048 |
| 17 | .3353 | .3353 | .3353 | .381 | .3506 | .3506 | .381 |
| 18 | .4572 | .4572 | .4572 | .381 | .381 | .4572 | .4572 |
| 19 | .6097 | .5639 | .6097 | .5335 | .4572 | .6097 | .6097 |
| 20 | .5335 | .5792 | .5335 | .6097 | .5335 | .5335 | .6097 |
| 21 | .4572 | .5335 | .5335 | .4572 | .4572 | .4877 | .5335 |
| 22 | .4572 | .4572 | .4572 | .381 | .4268 | .4572 | .4572 |
| 23 | .4572 | .381 | .4572 | .3048 | .381 | .4115 | .4572 |
| 24 | .381 | .4268 | .381 | | .2743 | .381 | |
| Max | .9602 | .8383 | .6097 | .8383 | .8383 | .8688 | .8688 |
| Min | .3048 | .3048 | .1524 | .2286 | .2743 | .1829 | .1981 |
| Avg | .4598 | .4706 | .3975 | .4274 | .4369 | .4160 | .4374 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 201 / MAHATMA FULE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 06-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | .8688 |
| 2 | .8688 |
| 24 | .8535 |
| Max | .8688 |
| Min | .8535 |
| Avg | .8637 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 201 / 11KV TAMTHARE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0974 | 1.0669 | 1.2803 | 1.2651 | 1.2955 | 1.0974 | 1.1584 |
| 2 | 1.1888 | 1.0974 | 1.3108 | 1.2803 | 1.3413 | 1.1431 | 1.1888 |
| 3 | 1.2193 | 1.1279 | 1.326 | 1.326 | 1.4022 | 1.2193 | 1.3413 |
| 4 | 1.2498 | 1.2041 | 1.4022 | 1.3565 | 1.448 | 1.2803 | 1.3413 |
| 5 | 1.2651 | 1.3717 | 1.4327 | 1.4784 | 1.4937 | 1.2955 | 1.4937 |
| 6 | 1.2651 | 1.4022 | 1.5089 | 1.6918 | 1.6461 | 1.326 | 1.5394 |
| 7 | 1.7071 | 1.6766 | 1.8138 | 1.7375 | 1.7223 | 1.3413 | 1.7833 |
| 8 | 1.768 | 1.5851 | 1.9204 | 1.6766 | 1.7375 | 1.5242 | 1.7528 |
| 9 | 1.7985 | | | | | | |
| 23 | 1.1126 | 1.1736 | 1.1736 | 1.1888 | 1.0974 | 1.1431 | 1.1431 |
| 24 | 1.1279 | 1.0974 | .5487 | 1.2498 | 1.2193 | 1.1279 | 1.1584 |
| Max | 1.7985 | 1.6766 | 1.9204 | 1.7375 | 1.7375 | 1.5242 | 1.7833 |
| Min | 1.0974 | 1.0669 | .5487 | 1.1888 | 1.0974 | 1.0974 | 1.1431 |
| Avg | 1.3454 | 1.2803 | 1.3717 | 1.4251 | 1.4403 | 1.2498 | 1.3901 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 202 / 11KV SAWAI MUKTI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | .442 | .4115 | .4572 |
| 2 | .4572 | .442 | .4877 |
| 3 | .4877 | .4725 | .5487 |
| 4 | .503 | .5335 | .5487 |
| 5 | .5182 | .5792 | .5792 |
| 6 | .503 | .6401 | .5792 |
| 7 | .5792 | .6859 | .8078 |
| 8 | .5944 | .7468 | .6249 |
| 9 | .7011 | | |
| 23 | | .4725 | .442 |
| 24 | .4115 | .381 | .4572 |
| Max | .7011 | .7468 | .8078 |
| Min | .4115 | .381 | .442 |
| Avg | .5197 | .5365 | .5533 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 203 / 11 KV SAWAI MUKTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0762 | .0762 | .1067 | .0762 | .0762 | .0762 | .0762 |
| 2 | .0914 | .0914 | .1067 | .0762 | .0762 | .0762 | .0914 |
| 3 | .1067 | .1219 | .0914 | .0914 | .0762 | .0914 | .1067 |
| 4 | .1372 | .1524 | .1067 | .0914 | .1067 | .1219 | .1372 |
| 5 | .1524 | .1829 | .1372 | .1372 | .1372 | .1372 | .1677 |
| 6 | .2286 | .2591 | .2439 | .1829 | .1829 | .1981 | .1981 |
| 7 | .2439 | .2439 | .1981 | .2286 | .2591 | .2286 | .2439 |
| 8 | .1829 | .1829 | .1524 | .1677 | .1677 | .1524 | .1372 |
| 9 | .1219 | .1372 | .1219 | .1067 | .0914 | .1219 | .1219 |
| 10 | .0914 | .0914 | .1067 | .0914 | .061 | .0762 | .0914 |
| 11 | .0762 | .0914 | .0914 | .0762 | .0762 | .061 | .0762 |
| 12 | .0762 | .0914 | .061 | .061 | .061 | .0762 | .0457 |
| 13 | .0762 | .0914 | .061 | .061 | .061 | .0762 | .0457 |
| 14 | .0762 | .0762 | .0762 | .061 | .0762 | .0762 | .0457 |
| 15 | .0762 | .061 | .0762 | .061 | .0762 | .0762 | .061 |
| 16 | .0762 | .061 | .0914 | .0457 | .0914 | .0762 | .061 |
| 17 | .0914 | .0914 | .0914 | .0457 | .1067 | .0762 | .0762 |
| 18 | .0762 | .0914 | .1067 | .0914 | .1067 | .1067 | .0762 |
| 19 | .1067 | .1981 | .1372 | .1219 | .1372 | | .1219 |
| 20 | .1677 | .1829 | .1524 | .1677 | .1677 | .1524 | .1524 |
| 21 | .1524 | .1524 | .1372 | .1372 | .1372 | .1219 | .1372 |
| 22 | .1067 | .1372 | .1219 | .1067 | .1067 | .1067 | .1067 |
| 23 | .1067 | .1219 | .0914 | .0914 | .0914 | .1067 | .0914 |
| 24 | .0914 | .0762 | .1067 | .0762 | .0762 | .0762 | .0914 |
| Max | .2439 | .2591 | .2439 | .2286 | .2591 | .2286 | .2439 |
| Min | .0762 | .061 | .061 | .0457 | .061 | .061 | .0457 |
| Avg | .1162 | .1276 | .1156 | .1022 | .1086 | .1073 | .1067 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 204 / 11KV ROHANE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .6249 | .6097 | .6706 | .5944 | | .6859 | .5944 |
| 11 | .7773 | .7468 | .8078 | .7621 | .7468 | .7316 | .6401 |
| 12 | .7773 | .7926 | .7773 | .6554 | .7468 | .7621 | .7468 |
| 13 | .7773 | .823 | .7926 | .7011 | .6554 | .6706 | .7011 |
| 14 | .823 | .7621 | .7164 | .6401 | .6859 | .6859 | .7011 |
| 15 | .8535 | .7926 | .7011 | .6706 | .7011 | .7011 | .6859 |
| 16 | .8535 | .8535 | .7316 | .6859 | .7164 | .7164 | .6859 |
| 17 | .8078 | .7773 | .7468 | .7011 | .7164 | .6859 | .7011 |
| Max | .8535 | .8535 | .8078 | .7621 | .7468 | .7621 | .7468 |
| Min | .6249 | .6097 | .6706 | .5944 | .6554 | .6706 | .5944 |
| Avg | .7868 | .7697 | .7430 | .6763 | .7098 | .7049 | .6821 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 205 / 11KV DANGURNE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.0364 | 1.2955 | 1.1279 | 1.2193 |
| 11 | 1.4784 | 1.4937 | 1.2041 | 1.3108 |
| 12 | 1.5089 | 1.4175 | 1.2498 | 1.2955 |
| 13 | 1.5546 | 1.3717 | 1.2041 | 1.3108 |
| 14 | 1.4327 | 1.3565 | 1.2193 | 1.2041 |
| 15 | | 1.3717 | 1.2346 | 1.1888 |
| 16 | | 1.3717 | 1.2498 | 1.1584 |
| 17 | | 1.3413 | 1.2041 | |
| Max | 1.5546 | 1.4937 | 1.2498 | 1.3108 |
| Min | 1.0364 | 1.2955 | 1.1279 | 1.1584 |
| Avg | 1.4022 | 1.3775 | 1.2117 | 1.2411 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 201 / 11KV KUMBHARE GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1267 | .1334 | .0914 | .0914 | .1267 | .1267 | .1267 |
| 2 | .1267 | .1334 | .0914 | .0914 | .1267 | .1267 | .1267 |
| 3 | .1629 | .1334 | .0914 | .0914 | .1267 | .1448 | .181 |
| 4 | .2172 | .1524 | .1524 | .1524 | .1629 | .181 | .2172 |
| 5 | .2534 | .2096 | .2286 | .1677 | | | .2715 |
| 6 | .362 | | .3048 | .3048 | .3439 | .3982 | .362 |
| 7 | .3258 | .4191 | .3048 | .3353 | .3982 | .3982 | .3982 |
| 8 | .2858 | .3429 | .2286 | .2591 | .2896 | .2715 | .2858 |
| 9 | .2858 | .2286 | .1981 | .2134 | .2172 | .2353 | .1981 |
| 10 | .2477 | .2134 | .1677 | .1981 | .181 | .2172 | .2286 |
| 11 | .2096 | .1829 | .1372 | .1829 | .181 | .181 | .1905 |
| 12 | .1905 | .1524 | .1372 | .1219 | .1448 | .181 | .1524 |
| 13 | .1715 | .1219 | .1372 | .1219 | .1448 | .1267 | .1524 |
| 14 | .1524 | .1219 | .1219 | .1219 | .1448 | .1448 | .1334 |
| 15 | .1524 | .1219 | .1372 | .1219 | .1448 | .1448 | .1334 |
| 16 | .1715 | .1677 | .1372 | .1372 | .1629 | .1448 | .1524 |
| 17 | .2096 | .1677 | .1524 | .1372 | | .1629 | .1905 |
| 18 | .3048 | .1981 | .1829 | .1829 | .2172 | .2172 | .3048 |
| 19 | .2477 | .1981 | .2134 | .2286 | .2534 | .2534 | .3048 |
| 20 | .1905 | .1372 | .1524 | .1524 | .181 | .181 | .2096 |
| 21 | .1524 | .1219 | .1219 | .1219 | .1629 | .181 | .1715 |
| 22 | .1524 | .1219 | .1067 | .1067 | .1448 | .1448 | .1524 |
| 23 | .1334 | .1067 | .1067 | .1067 | .1267 | .1267 | .1334 |
| 24 | .1267 | .1334 | .0914 | .0914 | | | .1267 |
| Max | .362 | .4191 | .3048 | .3353 | .3982 | .3982 | .3982 |
| Min | .1267 | .1067 | .0914 | .0914 | .1267 | .1267 | .1267 |
| Avg | .2066 | .1748 | .1581 | .1600 | .1896 | .1950 | .2043 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 202 / 11KV KALGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 2.6673 | 2.1643 | 2.3015 | 2.4234 | 2.1338 | 2.21 | 2.5339 |
| 11 | 2.8578 | 2.271 | 2.3777 | 2.5453 | | 2.2558 | 2.6673 |
| 12 | 2.8578 | 2.3015 | 2.3472 | 2.4691 | 2.1338 | 2.2862 | 2.7625 |
| 13 | 2.8769 | 2.271 | 2.3929 | 2.4539 | 2.21 | 2.21 | 2.7435 |
| 14 | 2.8578 | 2.332 | 2.3624 | 2.4082 | 2.21 | 2.1338 | 2.7625 |
| 15 | 2.7625 | 2.3624 | 2.3777 | 2.3624 | 2.1948 | 2.1338 | 2.8197 |
| 16 | 2.7816 | 2.3777 | 2.4082 | 2.3472 | 2.1643 | 2.1643 | 2.8578 |
| 17 | 2.8197 | 2.4082 | 2.3929 | 2.332 | | 2.1643 | 2.915 |
| Max | 2.8769 | 2.4082 | 2.4082 | 2.5453 | 2.21 | 2.2862 | 2.915 |
| Min | 2.6673 | 2.1643 | 2.3015 | 2.332 | 2.1338 | 2.1338 | 2.5339 |
| Avg | 2.8102 | 2.3110 | 2.3701 | 2.4177 | 2.1745 | 2.1948 | 2.7578 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094071 / 33/11KV LANGHANE SUB STATION

Feeder No / Name : 203 / 11KV VARNESHWAR AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2955 | 1.6194 | 1.326 | 1.326 | 1.2193 | 1.0669 | 1.0974 |
| 2 | 1.2955 | 1.6194 | 1.326 | 1.326 | 1.2193 | 1.0669 | 1.0974 |
| 3 | 1.2955 | 1.6385 | 1.326 | 1.326 | 1.2193 | 1.0669 | 1.0974 |
| 4 | 1.2955 | 1.6385 | 1.3108 | 1.326 | 1.2346 | 1.1431 | 1.1431 |
| 5 | 1.3413 | 1.6385 | 1.3565 | 1.3413 | 1.2346 | 1.1431 | 1.1888 |
| 6 | 1.3717 | 1.6766 | 1.387 | 1.3717 | 1.2346 | 1.2193 | 1.2193 |
| 7 | 1.3717 | 1.7337 | 1.4175 | 1.4327 | 1.2498 | 1.2193 | 1.5623 |
| 8 | 1.7528 | 1.7909 | 1.4632 | 1.4327 | 1.2803 | 1.2193 | 1.5623 |
| 23 | 1.5813 | 1.2803 | 1.2955 | | 1.0669 | 1.0974 | 1.3908 |
| 24 | 1.2955 | 1.6004 | 1.2955 | 1.3108 | | | 1.0974 |
| Max | 1.7528 | 1.7909 | 1.4632 | 1.4327 | 1.2803 | 1.2193 | 1.5623 |
| Min | 1.2955 | 1.2803 | 1.2955 | 1.3108 | 1.0669 | 1.0669 | 1.0974 |
| Avg | 1.3896 | 1.6236 | 1.3504 | 1.3548 | 1.2176 | 1.1380 | 1.2456 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 201 / 11 KV THALNER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.652 | 3.0178 | 2.7435 | 2.713 | 2.4996 | 2.8502 | 2.6216 |
| 2 | 2.652 | 3.0178 | 2.7435 | 2.7435 | 2.4996 | 2.8502 | 2.652 |
| 3 | 2.7846 | 3.0514 | 2.8045 | 2.8045 | 2.4996 | 2.8502 | 2.652 |
| 4 | 2.7854 | 3.0849 | 2.8654 | 2.8045 | 2.5606 | 2.8166 | 2.7349 |
| 5 | 2.7854 | 3.0849 | 2.9264 | 2.8349 | 2.5911 | 2.7496 | 2.7349 |
| 6 | 3.1131 | 3.0514 | 2.9569 | 2.8654 | 2.652 | 2.7161 | 2.7854 |
| 7 | | 3.1855 | 3.0483 | 2.8959 | 2.8349 | 3.0178 | 3.0476 |
| 8 | 2.8509 | 3.3196 | 3.0178 | 2.9569 | 2.8045 | 3.0849 | 3.0769 |
| 22 | | | | | 2.3807 | | |
| 23 | 2.2801 | 2.6216 | 2.4082 | 2.3167 | | 2.4863 | 1.6766 |
| 24 | 2.5857 | 2.6825 | 2.713 | 2.4387 | 2.4387 | 2.6825 | 2.6216 |
| Max | 3.1131 | 3.3196 | 3.0483 | 2.9569 | 2.8349 | 3.0849 | 3.0769 |
| Min | 2.2801 | 2.6216 | 2.4082 | 2.3167 | 2.3807 | 2.4863 | 1.6766 |
| Avg | 2.7210 | 3.0117 | 2.8228 | 2.7374 | 2.5761 | 2.8104 | 2.6604 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 202 / 11 KV HOLNANTHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 04-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | | 2.7435 | 2.6825 | 2.6216 |
| 11 | | 2.7435 | 2.7435 | 2.6216 |
| 12 | | 2.7435 | 2.7435 | 2.5606 |
| 13 | | 2.713 | 2.7435 | 2.5301 |
| 14 | | 2.7435 | 2.7435 | 2.5301 |
| 15 | | 2.9264 | 2.713 | 2.5606 |
| 16 | | 2.7435 | 2.6825 | 2.5911 |
| 17 | | 2.6825 | 2.5911 | 2.5301 |
| 23 | .9431 | | | |
| Max | .9431 | 2.9264 | 2.7435 | 2.6216 |
| Min | .9431 | 2.6825 | 2.5911 | 2.5301 |
| Avg | .9431 | 2.7549 | 2.7054 | 2.5682 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 203 / 11 KV BHORKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.9951 | 2.0957 | 1.7375 | 2.0119 | 2.146 | 2.2466 | 1.9052 |
| 11 | 2.146 | 2.1795 | 1.9509 | 2.0729 | 2.1293 | 2.2466 | 1.9204 |
| 12 | 2.1963 | 2.2131 | 2.0729 | 2.2634 | 2.2801 | 2.1628 | 1.9204 |
| 13 | 2.2298 | 2.2466 | 2.0576 | 1.9814 | 2.2634 | 2.1628 | 1.9509 |
| 14 | 2.2969 | 2.2298 | 1.9966 | 1.9814 | 2.2466 | 2.2211 | 1.9357 |
| 15 | 2.2131 | 2.2298 | 2.0271 | 1.9509 | 2.2131 | 2.146 | |
| 16 | 2.2131 | 2.2466 | 2.0729 | 1.9357 | 2.2466 | 2.0454 | 1.9509 |
| 17 | 2.2298 | 2.2298 | 2.0424 | 1.9509 | 2.2298 | 2.079 | 1.9204 |
| 18 | | | | | | | 1.9204 |
| 22 | | | | | | .5373 | |
| 23 | | | | | | .5373 | |
| 24 | | | | | | | .567 |
| Max | 2.2969 | 2.2466 | 2.0729 | 2.2634 | 2.2801 | 2.2466 | 1.9509 |
| Min | 1.9951 | 2.0957 | 1.7375 | 1.9357 | 2.1293 | .5373 | .567 |
| Avg | 2.1900 | 2.2089 | 1.9947 | 2.0186 | 2.2194 | 1.8385 | 1.7768 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 204 / 11 KV THALNER GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5316 | .4458 | .4287 | .4801 | .5144 | .5144 | .5316 |
| 2 | .567 | .4458 | .4287 | .4801 | .5144 | .5144 | .567 |
| 3 | .6024 | .4458 | .4801 | .5487 | .583 | .5144 | .567 |
| 4 | .6733 | .5144 | .5144 | .6516 | .6687 | .6001 | .6733 |
| 5 | .7973 | .8059 | .703 | .823 | .823 | .703 | .7888 |
| 6 | 1.0517 | 1.0117 | .9774 | .9945 | 1.0631 | .9088 | .8764 |
| 7 | .9465 | .9431 | .8916 | .9088 | .8745 | .9945 | 1.0517 |
| 8 | .7796 | .7545 | .703 | .7716 | .7202 | .7373 | |
| 9 | .5487 | .6001 | .5487 | .6001 | .5487 | .6024 | .5316 |
| 10 | .5144 | .5144 | .5144 | .583 | .4973 | .567 | .4801 |
| 11 | .5144 | .4801 | .4973 | .5144 | .4458 | .5138 | .4801 |
| 12 | .4458 | .463 | .4458 | .4801 | .4287 | .4656 | .4973 |
| 13 | .4287 | .463 | .4973 | .5144 | .4115 | .5194 | .5144 |
| 14 | .463 | .4973 | .5316 | .5487 | .4973 | .5316 | .4973 |
| 15 | .5487 | .5144 | .4973 | .5144 | .4973 | .5316 | .4801 |
| 16 | .583 | .6001 | .5144 | .463 | .5144 | .5552 | .5144 |
| 17 | .6173 | .6001 | .5316 | .5658 | .5487 | .6201 | .583 |
| 18 | .6859 | .6173 | .6516 | .6516 | .6344 | .7011 | .6344 |
| 19 | .8573 | .8573 | .7888 | .7202 | .8059 | .8413 | .8573 |
| 20 | .8573 | .8059 | .7545 | .7716 | .823 | .7362 | .7202 |
| 21 | .4344 | .6516 | .6859 | .6859 | .6687 | | .6516 |
| 22 | .6344 | .6516 | .6173 | .6173 | .5144 | .6805 | .6173 |
| 23 | .5144 | .583 | .5487 | .583 | .5144 | | .583 |
| 24 | .5373 | .4801 | .5316 | .5144 | .5316 | .4973 | |
| Max | 1.0517 | 1.0117 | .9774 | .9945 | 1.0631 | .9945 | 1.0517 |
| Min | .4287 | .4458 | .4287 | .463 | .4115 | .4656 | .4801 |
| Avg | .6306 | .6144 | .5952 | .6244 | .6101 | .6295 | .6226 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 205 / 11KV ASALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2172 | .2743 | .2058 | .2058 | .2401 | .3086 | .2195 |
| 2 | .2195 | .2743 | .2401 | .2401 | .2229 | .3086 | .2195 |
| 3 | .2534 | .2743 | .3086 | .2401 | .2229 | .3086 | .2195 |
| 4 | .2896 | .3086 | .3429 | .2743 | .2743 | .3429 | .2534 |
| 5 | .362 | .3429 | .3772 | .3429 | .3772 | .4115 | .3258 |
| 6 | .4706 | .4115 | .4287 | .4287 | .4458 | .4694 | .4656 |
| 7 | .5068 | .4801 | .4973 | .4801 | .4973 | .463 | .5014 |
| 8 | .3582 | .3944 | .3944 | .4115 | | .3856 | .4298 |
| 9 | .3086 | .3429 | .3086 | .3258 | .3429 | .2195 | .3258 |
| 10 | .2401 | .2572 | .2058 | .2915 | .2058 | .2534 | .2401 |
| 11 | .2401 | .2572 | .1715 | .2229 | .2229 | .2172 | .2058 |
| 12 | .2401 | .2401 | .2058 | .2401 | .2058 | .2534 | .2058 |
| 13 | .2401 | .2401 | .2572 | .2401 | .1886 | | .1886 |
| 14 | .2401 | .2229 | .2401 | .2401 | .2572 | .2715 | .2058 |
| 15 | .2572 | .2572 | .2401 | | .2572 | .2715 | .2401 |
| 16 | .2743 | .2572 | .2743 | .2401 | .2572 | .2896 | .2743 |
| 17 | .3086 | .3086 | .3086 | .2743 | .3086 | .2896 | .2743 |
| 18 | .3772 | .3429 | .3429 | .3772 | .3429 | .3258 | .3258 |
| 19 | .4115 | .3772 | .3944 | .3772 | .3944 | .3582 | |
| 20 | .3944 | .3772 | .3772 | .3601 | .3944 | .394 | |
| 21 | .3772 | .3429 | .3086 | .3429 | .3429 | | .3429 |
| 22 | .3086 | .3086 | .2743 | .3086 | .3086 | .3258 | |
| 23 | .3086 | .2743 | .2743 | .2743 | .3086 | .2561 | .2743 |
| 24 | .2534 | .2743 | .2401 | .2401 | | .3086 | .2195 |
| Max | .5068 | .4801 | .4973 | .4801 | .4973 | .4694 | .5014 |
| Min | .2172 | .2229 | .1715 | .2058 | .1886 | .2172 | .1886 |
| Avg | .3107 | .3101 | .3008 | .3034 | .3008 | .3197 | .2837 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 206 / 11 Kv JAITPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3565 | 1.4083 | 1.4632 | 1.5242 | 1.5242 | | 1.7101 |
| 2 | 1.4413 | 1.4251 | 1.5394 | 1.6156 | 1.5242 | | 1.7101 |
| 3 | 1.4413 | 1.4251 | 1.6461 | 1.6766 | 1.5242 | | 1.7604 |
| 4 | 1.5089 | 1.4251 | 1.7071 | 1.7375 | 1.5546 | | 1.7404 |
| 5 | 1.5927 | 1.5089 | 1.768 | 1.768 | 1.5546 | | 1.7404 |
| 6 | 1.6617 | 1.6598 | 1.9204 | 1.7985 | 1.6156 | | 1.8107 |
| 7 | 1.8275 | 1.7772 | 1.9662 | 1.829 | 1.8747 | | 1.9725 |
| 8 | 1.9448 | 2.0119 | 1.9966 | 1.9052 | 1.829 | | 1.989 |
| 9 | | | | | | 1.56 | |
| 19 | | | | | | 1.7368 | |
| 20 | | | | | | 1.8821 | |
| 21 | | | | | | 1.8143 | |
| 22 | | | | | | 1.7804 | |
| 23 | 1.3748 | 1.3565 | 1.4175 | 1.3108 | | 1.7635 | |
| 24 | 1.3565 | 1.4083 | 1.4022 | | 1.4937 | | 1.7126 |
| Max | 1.9448 | 2.0119 | 1.9966 | 1.9052 | 1.8747 | 1.8821 | 1.989 |
| Min | 1.3565 | 1.3565 | 1.4022 | 1.3108 | 1.4937 | 1.56 | 1.7101 |
| Avg | 1.5506 | 1.5406 | 1.6827 | 1.6850 | 1.6105 | 1.7562 | 1.7940 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 201 / 11 KV SANGVI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 14 | 3.4294 | 2.915 | 2.8959 | 2.8197 | | 2.4387 | 2.7282 |
| 15 | 3.6008 | 3.4294 | 3.2007 | 3.2769 | 3.4294 | 2.7435 | 3.0788 |
| 16 | 3.5151 | 3.6008 | 3.2007 | 3.2007 | 3.5151 | 2.9721 | 3.0483 |
| 17 | 3.4465 | 3.0864 | 3.2769 | 3.2007 | 3.6008 | 2.8959 | 2.9721 |
| 18 | 3.2579 | 3.2579 | 3.0483 | 2.9721 | 3.4294 | 2.7435 | 2.8959 |
| 19 | 3.1036 | 3.2579 | 2.8959 | 2.8197 | 3.0864 | 2.3624 | 2.774 |
| 20 | 2.915 | | 3.0007 | 2.5149 | 2.7435 | 2.3472 | 2.5758 |
| 21 | 2.4863 | 2.7435 | 2.6216 | 2.3624 | 2.7435 | 2.21 | 2.3929 |
| 22 | 2.2634 | 2.8292 | 2.4691 | 2.2862 | 2.572 | 1.9814 | 2.0576 |
| 23 | 2.1948 | 2.572 | 2.3472 | 2.21 | 2.4863 | 1.9509 | 1.8442 |
| 24 | 2.0576 | 2.4006 | 2.1338 | 2.1643 | 2.4006 | 2.1338 | 1.829 |
| Max | 3.6008 | 3.6008 | 3.2769 | 3.2769 | 3.6008 | 2.9721 | 3.0788 |
| Min | 2.0576 | 2.4006 | 2.1338 | 2.1643 | 2.4006 | 1.9509 | 1.829 |
| Avg | 2.9337 | 3.0093 | 2.8264 | 2.7116 | 3.0007 | 2.4345 | 2.5633 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 202 / 11 KV ROHINI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.0233 | 1.9814 | 1.6461 | 1.8861 | 1.5851 | 1.6461 |
| 2 | | 1.8861 | 2.0576 | 1.7528 | 1.9719 | 1.7528 | 1.6004 |
| 3 | | 1.9376 | 2.1338 | 1.9052 | 2.1434 | 1.829 | 1.6766 |
| 4 | | 2.0576 | 2.2862 | 2.2862 | 2.2291 | 2.0576 | 1.9052 |
| 5 | | 2.2462 | 2.3624 | 2.5149 | 2.4863 | 2.2862 | 2.0576 |
| 6 | | 2.4863 | 2.4387 | 2.5911 | 2.8292 | 2.4387 | 2.3624 |
| 7 | | 2.7606 | 2.6978 | 2.7587 | 2.9321 | 2.5758 | 2.6216 |
| 8 | | 2.915 | 2.8654 | 2.8349 | 1.989 | 2.7435 | 2.5758 |
| 9 | | | 1.7071 | 2.8654 | | 2.4082 | 2.4996 |
| 10 | | | 2.4082 | 2.1033 | | 2.2558 | |
| 20 | | 2.4177 | | | | | 1.448 |
| 21 | | 2.4863 | | | | 1.448 | 1.5242 |
| 22 | | 2.4006 | | 1.6004 | | 1.829 | 1.6309 |
| 23 | | 2.332 | | 1.6461 | | 1.829 | 1.6766 |
| 24 | .9431 | 2.2977 | 2.0424 | 1.4022 | 1.749 | 1.5546 | 1.6766 |
| Max | .9431 | 2.915 | 2.8654 | 2.8654 | 2.9321 | 2.7435 | 2.6216 |
| Min | .9431 | 1.8861 | 1.7071 | 1.4022 | 1.749 | 1.448 | 1.448 |
| Avg | .9431 | 2.3267 | 2.271 | 2.1467 | 2.2462 | 2.0424 | 1.9215 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 203 / 11 KV AMBE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8573 | .9945 | 1.0669 | .884 | .8745 | .7621 | .8383 |
| 2 | .8916 | .9431 | 1.1431 | .945 | 1.1145 | .7926 | .884 |
| 3 | 1.0288 | .8745 | 1.1431 | .9907 | 1.2003 | .9145 | .9755 |
| 4 | 1.0631 | .8573 | 1.2193 | 1.0974 | 1.286 | 1.0364 | 1.0974 |
| 5 | 1.166 | 1.0631 | 1.3717 | | 1.6289 | 1.1431 | 1.2955 |
| 6 | 1.2346 | 1.3546 | 1.6766 | 1.4937 | 1.8861 | 1.5242 | 1.6004 |
| 7 | 1.4746 | 1.8861 | 1.9357 | 2.0919 | 2.2291 | 1.9204 | 1.7223 |
| 8 | | 2.0748 | 1.9814 | 2.0119 | 1.4232 | 1.6613 | 1.7985 |
| 9 | | | 1.6766 | 1.7223 | 1.9376 | 1.6461 | 1.4632 |
| 10 | | | 1.5851 | 1.5699 | 1.4575 | 1.4632 | 1.2041 |
| 24 | 1.1317 | .9431 | .8383 | .6249 | .8059 | .7164 | .7621 |
| Max | 1.4746 | 2.0748 | 1.9814 | 2.0919 | 2.2291 | 1.9204 | 1.7985 |
| Min | .8573 | .8573 | .8383 | .6249 | .8059 | .7164 | .7621 |
| Avg | 1.1060 | 1.2212 | 1.4216 | 1.3432 | 1.4403 | 1.2346 | 1.2401 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 204 / 11 Kv Hadakhed Checkpost NON SHEDDABLE EXPRESS HV FEEDERS
 Expre Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .0686 | .061 | .0686 | .0514 | .0686 |
| 2 | .0686 | .0686 | .0514 | .0686 | .0514 | .0686 |
| 3 | .0686 | .0686 | .0514 | .0686 | .0514 | .0686 |
| 4 | .0686 | .0686 | .0457 | .0686 | .0343 | .0686 |
| 5 | .0686 | .0686 | .0514 | .0686 | .0343 | .0686 |
| 6 | .0514 | .0514 | .0514 | .0514 | .0343 | .0514 |
| 7 | .0514 | .0514 | .0514 | .0514 | .0343 | .0514 |
| 8 | .0514 | .0514 | .0686 | .0514 | .0343 | .0514 |
| 9 | .0514 | .0514 | .0686 | .0514 | .0514 | .0514 |
| 10 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 11 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 12 | .0514 | .0514 | .0514 | .0514 | .0514 | .0514 |
| 13 | .0229 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 14 | .0686 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 15 | .0686 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 16 | .0686 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 17 | .0514 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 18 | .0514 | .0686 | .0514 | .0514 | .0514 | .0514 |
| 19 | .0686 | .0686 | .0686 | .0686 | .0514 | .0686 |
| 20 | .0686 | .0686 | .0686 | .0686 | .0686 | .0686 |
| 21 | .0686 | .0686 | .0686 | .0686 | | .0686 |
| 22 | .0686 | .0686 | .0686 | .0686 | | .0686 |
| 23 | .0686 | .0686 | .0686 | .0686 | | .0686 |
| 24 | .5658 | .0686 | .0686 | .0686 | .0514 | .0686 |
| Max | .5658 | .0686 | .0686 | .0686 | .0686 | .0686 |
| Min | .0229 | .0514 | .0457 | .0514 | .0343 | .0514 |
| Avg | .0810 | .0636 | .0573 | .0593 | .0481 | .0593 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 201 / 11 KV AJANDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | | 1.1336 | 1.1336 |
| 2 | | | | | | 1.1336 | 1.2955 |
| 3 | | | | | | 1.1336 | 1.1336 |
| 4 | | | | | | 1.1336 | 1.1336 |
| 5 | | | | | | 1.2003 | 1.2003 |
| 6 | | | | | | 1.2003 | 1.2003 |
| 7 | | | | | | 1.2003 | 1.3336 |
| 8 | | | | | | 1.2003 | 1.3336 |
| 10 | 1.7337 | 1.7337 | 1.5337 | 1.3336 | 1.5337 | | |
| 11 | 1.7337 | 1.7337 | 1.6671 | 1.467 | 1.5337 | | |
| 12 | 1.7337 | 1.7337 | 1.6671 | 1.6004 | 1.6004 | | |
| 13 | 1.8004 | 1.7337 | 1.7337 | 1.5337 | 1.6004 | | |
| 14 | 1.9338 | 1.6671 | 1.7337 | 1.5337 | 1.6004 | | |
| 15 | 1.8671 | 1.6671 | 1.6004 | 1.5337 | 1.6004 | | |
| 16 | 1.8671 | 1.6671 | 1.6004 | 1.5337 | 1.5337 | | |
| 17 | 1.8671 | 1.6671 | 1.3336 | 1.467 | 1.4003 | | |
| 23 | | | | | 1.1336 | 1.1336 | 1.1336 |
| 24 | | | | | 1.1336 | | 1.1336 |
| Max | 1.9338 | 1.7337 | 1.7337 | 1.6004 | 1.6004 | 1.2003 | 1.3336 |
| Min | 1.7337 | 1.6671 | 1.3336 | 1.3336 | 1.1336 | 1.1336 | 1.1336 |
| Avg | 1.8171 | 1.7004 | 1.6087 | 1.5004 | 1.4670 | 1.1632 | 1.2031 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 202 / 11 KV GHODASGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6004 | 1.6004 | 1.6004 | 1.5337 | 1.467 | | |
| 2 | 1.6004 | 1.6004 | 1.6004 | 1.5337 | 1.467 | | |
| 3 | 1.6004 | 1.6004 | 1.6004 | 1.5337 | 1.467 | | |
| 4 | 1.6004 | 1.6004 | 1.6004 | 1.5337 | 1.6004 | | |
| 5 | 1.6004 | 1.6671 | 1.6004 | 1.6004 | 1.6004 | | |
| 6 | 1.6004 | 1.6671 | 1.7337 | 1.6004 | 1.6004 | | |
| 7 | 1.6004 | 1.6004 | 1.7337 | 1.6004 | 1.6004 | | |
| 8 | 1.6004 | 1.6004 | 1.7337 | 1.6004 | 1.467 | | |
| 10 | | | | | | 1.829 | 1.6004 |
| 11 | | | | | | 1.829 | 1.6004 |
| 12 | | | | | | 1.9814 | 1.7337 |
| 13 | | | | | | 1.7337 | 1.7337 |
| 14 | | | | | | 1.7337 | 1.8671 |
| 15 | | | | | | 1.7337 | 1.8671 |
| 16 | | | | | | 1.7337 | 1.8671 |
| 17 | | | | | | 1.7337 | 1.7337 |
| 23 | 1.6004 | 1.6004 | 1.467 | 1.467 | | | |
| 24 | | 1.6004 | | 1.467 | | | |
| Max | 1.6004 | 1.6671 | 1.7337 | 1.6004 | 1.6004 | 1.9814 | 1.8671 |
| Min | 1.6004 | 1.6004 | 1.467 | 1.467 | 1.467 | 1.7337 | 1.6004 |
| Avg | 1.6004 | 1.6137 | 1.6300 | 1.5470 | 1.5337 | 1.7885 | 1.7504 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 203 / 11 KV PILODA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .5658 |
| Max | .5658 |
| Min | .5658 |
| Avg | .5658 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 204 / 11 KV HOLNATHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3048 | .2 | .2286 | .3048 | .2286 | .3048 | .2667 |
| 2 | .3048 | .2 | .2286 | .3048 | .2286 | .3048 | .3048 |
| 3 | .3048 | .3048 | .2286 | .3048 | .2286 | .3048 | .3334 |
| 4 | .381 | .2667 | .2286 | .381 | .3048 | .381 | .3334 |
| 5 | .4572 | .4668 | .3048 | .4572 | .3048 | .4572 | .4001 |
| 6 | .5335 | .6097 | .381 | .5335 | .5335 | .5335 | .4668 |
| 7 | .6097 | .5335 | .6097 | .5335 | .6097 | .6097 | .4668 |
| 8 | .5335 | .4001 | .4572 | .5335 | .381 | .4572 | .5335 |
| 9 | .381 | .3048 | .381 | | .3048 | .4572 | .4572 |
| 10 | .3048 | .4001 | .381 | .3048 | .381 | .381 | .4572 |
| 11 | .3048 | .4001 | | .2286 | .3048 | .381 | .4572 |
| 12 | .3048 | .4572 | .3048 | .2286 | .3048 | .381 | .3048 |
| 13 | .3048 | .4572 | .3048 | .2286 | .3048 | .3334 | .3048 |
| 14 | .2286 | .381 | .3048 | .2286 | .3048 | .381 | .3048 |
| 15 | .3048 | .381 | .3048 | .3048 | .3048 | .381 | .3048 |
| 16 | .3048 | .3048 | .381 | .2667 | .381 | .381 | .381 |
| 17 | .3048 | .4572 | .381 | .3048 | .381 | .4572 | .381 |
| 18 | .381 | .4572 | .381 | .3334 | .4572 | .4001 | .4572 |
| 19 | .3048 | .5335 | .4572 | .4572 | .4572 | .4668 | .5335 |
| 20 | .3048 | .381 | .4572 | .3048 | .4572 | .3334 | .4572 |
| 21 | .3048 | .3048 | .4001 | | .381 | .3334 | .381 |
| 22 | .2286 | .3048 | .4572 | .3048 | .3048 | .3334 | .3048 |
| 23 | .2286 | .2286 | .381 | .2286 | .3048 | .2667 | .2286 |
| 24 | | .2286 | | .3048 | .3048 | | .2286 |
| Max | .6097 | .6097 | .6097 | .5335 | .6097 | .6097 | .5335 |
| Min | .2286 | .2 | .2286 | .2286 | .2286 | .2667 | .2286 |
| Avg | .3446 | .3735 | .3611 | .3356 | .3524 | .3922 | .3771 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 205 / 11 KV JAPORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8002 | 1.0669 | .9335 | 1.0669 | .8002 | | |
| 2 | .8002 | 1.0669 | .9335 | 1.0669 | .8002 | | |
| 3 | .8002 | 1.1431 | .9335 | 1.2193 | .8669 | | |
| 4 | .8002 | 1.0669 | .9335 | 1.0669 | .8669 | | |
| 5 | .8002 | .9335 | .9335 | 1.0669 | .9335 | | |
| 6 | .8002 | 1.0669 | .9335 | 1.0669 | .9335 | | |
| 7 | .8002 | .9335 | .9335 | 1.2193 | .9335 | | |
| 8 | .9335 | 1.0002 | .9335 | 1.0669 | .9335 | | |
| 10 | | | | | | 1.2193 | .9335 |
| 11 | | | | | | 1.2193 | 1.0669 |
| 12 | | | | | | 1.2193 | 1.0669 |
| 13 | | | | | | 1.0669 | 1.0669 |
| 14 | | | | | | 1.2193 | 1.0669 |
| 15 | | | | | | 1.0669 | 1.0669 |
| 16 | | | | | | 1.0669 | 1.0669 |
| 17 | | | | | | 1.0669 | .9335 |
| 23 | .9335 | .9335 | .9335 | .8002 | | | |
| 24 | | .9335 | | 1.0669 | | | |
| Max | .9335 | 1.1431 | .9335 | 1.2193 | .9335 | 1.2193 | 1.0669 |
| Min | .8002 | .9335 | .9335 | .8002 | .8002 | 1.0669 | .9335 |
| Avg | .8298 | 1.0145 | .9335 | 1.0707 | .8835 | 1.1431 | 1.0336 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 201 / 11 KV BAHTPURA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2591 | .1981 | .1981 | .2134 | .2439 | .2572 | .2591 |
| 2 | .2591 | .1829 | .2134 | .2134 | .2439 | .2572 | .2591 |
| 3 | .2591 | .2134 | .2439 | .2134 | .2439 | .2572 | .2743 |
| 4 | .2439 | .2134 | .2591 | .2439 | .2439 | .2743 | .2743 |
| 5 | .2286 | .2439 | .2591 | .2743 | .2439 | .2743 | .2896 |
| 6 | .2286 | .2439 | .2743 | .2743 | .2439 | .2743 | .3353 |
| 7 | .2896 | .2591 | .2743 | .2743 | .2743 | .2743 | .3048 |
| 8 | .3048 | .2743 | .2591 | .2591 | .2591 | .2915 | .2896 |
| 23 | .2134 | .2134 | .2134 | .2439 | .2743 | .2896 | .2286 |
| 24 | .2591 | .2134 | .1981 | .2134 | .2439 | .2572 | .2591 |
| Max | .3048 | .2743 | .2743 | .2743 | .2743 | .2915 | .3353 |
| Min | .2134 | .1829 | .1981 | .2134 | .2439 | .2572 | .2286 |
| Avg | .2545 | .2256 | .2393 | .2423 | .2515 | .2707 | .2774 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 202 / 11 KV BABHALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.5043 | 1.7394 | 1.692 | 1.4175 | 1.5261 | 1.6804 | 1.6446 |
| 11 | 1.8818 | 1.8343 | 1.8084 | 1.5091 | 1.6549 | 1.8884 | 1.7078 |
| 12 | 1.7869 | 1.8976 | 1.7284 | 1.56 | 1.7204 | 1.6004 | 1.6964 |
| 13 | 1.8404 | 1.866 | 1.6964 | 1.56 | 1.704 | 1.5684 | 1.5971 |
| 14 | 1.8185 | 1.8185 | 1.7078 | 1.387 | 1.7465 | 1.6004 | 1.5655 |
| 15 | 1.7711 | 1.7711 | 1.6446 | 1.543 | 1.7295 | 1.6804 | 1.6288 |
| 16 | 1.8564 | 1.7394 | 1.4232 | 1.5939 | 1.7804 | 1.6804 | 1.6762 |
| 17 | 1.7764 | 1.6604 | 1.4864 | 1.5769 | 1.6385 | 1.6004 | 1.5655 |
| Max | 1.8818 | 1.8976 | 1.8084 | 1.5939 | 1.7804 | 1.8884 | 1.7078 |
| Min | 1.5043 | 1.6604 | 1.4232 | 1.387 | 1.5261 | 1.5684 | 1.5655 |
| Avg | 1.7795 | 1.7908 | 1.6484 | 1.5184 | 1.6875 | 1.6624 | 1.6352 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 203 / 11KV BHATPURA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1448 | .1646 | .181 | .2012 | .1524 | .1715 | .181 |
| 2 | .1372 | .1663 | .2353 | .2195 | .2241 | .1886 | .181 |
| 3 | .1629 | .2012 | .2534 | .2218 | .2172 | .1886 | .2534 |
| 4 | .2172 | .2378 | .3077 | .2772 | .2534 | .2401 | .2896 |
| 5 | .2715 | .2587 | .3258 | .3142 | .2896 | .2743 | .3439 |
| 6 | .362 | .2743 | .362 | .3142 | .3982 | .3258 | .3982 |
| 7 | .2353 | .3109 | .3258 | .4024 | .3201 | .3601 | .4163 |
| 8 | .3048 | .3292 | .362 | .3841 | .362 | .3086 | .3258 |
| 9 | .3258 | .3109 | .1991 | .2743 | .362 | .2743 | |
| 10 | .2957 | .3077 | .3142 | .2172 | .2172 | .2715 | .2926 |
| 11 | .2561 | .2353 | .2926 | .3077 | .1966 | .2353 | .2587 |
| 12 | .2218 | .2353 | .2743 | .181 | .2035 | .2172 | .2378 |
| 13 | .2218 | .2353 | .3142 | .1991 | .2035 | .2172 | .2561 |
| 14 | .2033 | .2353 | .2561 | .2172 | .2012 | .2353 | .2561 |
| 15 | .2402 | .2534 | .2378 | .2353 | .1966 | .2534 | .2561 |
| 16 | .2587 | .2715 | .2402 | .3077 | .2515 | .2896 | .2772 |
| 17 | .3142 | .2896 | .2561 | .3258 | .2622 | .3258 | .2926 |
| 18 | .3142 | .362 | .3658 | .2715 | .3018 | .362 | .3142 |
| 19 | .2957 | .3982 | .4207 | .3439 | .3018 | .3801 | .3881 |
| 20 | .2378 | .3258 | .2926 | .3258 | .2915 | .3258 | .2957 |
| 21 | .2195 | .2715 | .2561 | .2534 | .2572 | .2896 | .2772 |
| 22 | .2012 | | .2195 | .2172 | .2058 | .2534 | .2033 |
| 23 | .2218 | .1991 | .2218 | .2353 | .1886 | .181 | .1294 |
| 24 | .1629 | .1663 | .181 | .2012 | .2172 | .1715 | .181 |
| Max | .362 | .3982 | .4207 | .4024 | .3982 | .3801 | .4163 |
| Min | .1372 | .1646 | .181 | .181 | .1524 | .1715 | .1294 |
| Avg | .2428 | .2626 | .2790 | .2687 | .2531 | .2642 | .2741 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 205 / 11 KV Ajnad Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.2405 | 2.21 | 1.9997 | 2.1338 | 2.1643 | 2.3663 | 2.1559 |
| 2 | 2.2558 | 2.271 | 2.0622 | 2.1186 | 2.1795 | 2.4348 | 2.1872 |
| 3 | 2.3015 | 2.271 | 2.1247 | 2.1795 | 2.2405 | 2.4863 | 2.2497 |
| 4 | 2.3015 | 2.3624 | 2.234 | 2.21 | 2.2405 | 2.4863 | 2.3122 |
| 5 | 2.332 | 2.3929 | 2.2653 | 2.4387 | 2.3015 | 2.5549 | 2.3746 |
| 6 | 2.6235 | 2.3929 | 2.2965 | 2.5149 | 2.3472 | 2.6406 | 2.4684 |
| 7 | 2.5911 | 2.6063 | 2.5621 | 2.6063 | 2.4996 | 2.7092 | 2.5934 |
| 8 | 2.5911 | 2.6673 | 2.6715 | 2.6978 | 2.5301 | 2.7263 | 2.7027 |
| 23 | 1.9814 | 1.9997 | 2.0119 | 2.0119 | 2.0405 | 2.0309 | 1.6613 |
| 24 | 2.0576 | 2.2405 | 1.9997 | 2.1033 | 2.1491 | 2.1605 | 2.0934 |
| Max | 2.6235 | 2.6673 | 2.6715 | 2.6978 | 2.5301 | 2.7263 | 2.7027 |
| Min | 1.9814 | 1.9997 | 1.9997 | 2.0119 | 2.0405 | 2.0309 | 1.6613 |
| Avg | 2.3276 | 2.3414 | 2.2228 | 2.3015 | 2.2693 | 2.4596 | 2.2799 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 206 / 11 KV NAGESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5944 | .6249 | .5182 | .5335 | .5487 | .5144 | .4877 |
| 2 | .6097 | .6401 | .5182 | .5639 | .5487 | .4973 | .5182 |
| 3 | .6859 | .6401 | .5182 | .5335 | .5487 | .5144 | .5182 |
| 4 | .6249 | .6554 | .5487 | .5487 | .5335 | .5144 | .5335 |
| 5 | .6401 | .6401 | .5487 | .5487 | .5335 | .5144 | .5487 |
| 6 | .6554 | .6401 | .5639 | .5639 | .5335 | .5144 | .5792 |
| 7 | .6859 | .6706 | .5792 | .6097 | .5792 | .5144 | .5487 |
| 8 | .7164 | .7316 | .6249 | .6249 | .6401 | .6859 | .6249 |
| 23 | .6097 | .5792 | .5792 | .5487 | .6173 | .5487 | .4967 |
| 24 | .5944 | .6401 | .5487 | .5944 | .5335 | | .4877 |
| Max | .7164 | .7316 | .6249 | .6249 | .6401 | .6859 | .6249 |
| Min | .5944 | .5792 | .5182 | .5335 | .5335 | .4973 | .4877 |
| Avg | .6417 | .6462 | .5548 | .5670 | .5617 | .5354 | .5344 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 207 / 11 KV TARADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .6554 | .8078 | .6859 | .6859 | .6401 | .6249 | .5792 |
| 11 | .7164 | .823 | .7316 | .7164 | .7291 | .6859 | .6554 |
| 12 | .7011 | .823 | .7316 | .7011 | .763 | .7011 | .6554 |
| 13 | .7164 | .9955 | .7316 | .7164 | .7373 | .7164 | .6706 |
| 14 | .7011 | .8383 | .7164 | .7468 | .763 | .7011 | .6554 |
| 15 | .7164 | .7773 | .6859 | .7621 | .7373 | .6859 | .6706 |
| 16 | .7468 | .7926 | .6859 | .7468 | .7537 | .6706 | .6401 |
| 17 | .7468 | .7621 | .7164 | .7316 | .6718 | .7011 | .6249 |
| Max | .7468 | .9955 | .7316 | .7621 | .763 | .7164 | .6706 |
| Min | .6554 | .7621 | .6859 | .6859 | .6401 | .6249 | .5792 |
| Avg | .7126 | .8275 | .7107 | .7259 | .7244 | .6859 | .6440 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 201 / 11 KV UNTAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.7625 | 2.4768 | 2.4768 | 2.6863 | 2.4958 | 2.3815 | 2.4768 |
| 2 | 2.7816 | | 2.4768 | 2.6863 | 2.4768 | 2.3815 | 2.4768 |
| 3 | 2.8197 | 2.6292 | 2.572 | 2.7625 | 2.4768 | 2.3434 | 2.572 |
| 4 | 2.9721 | 2.7625 | 2.7625 | 2.7816 | 2.5911 | 2.3815 | 2.572 |
| 5 | 2.9721 | 2.8197 | 2.8769 | 2.8197 | 3.0483 | 2.4006 | 2.6673 |
| 6 | | 2.915 | 2.934 | 2.915 | 3.0483 | 2.4006 | 2.7054 |
| 7 | 2.8197 | | | 2.6292 | 3.0483 | 2.8197 | 2.8959 |
| 8 | 2.7435 | 2.915 | 2.7054 | 2.9531 | 2.9912 | 3.0102 | 2.934 |
| 9 | | | 2.7054 | | | | |
| 16 | | | 2.4768 | | | | |
| 23 | 2.4196 | 2.3624 | 2.5911 | 2.5149 | 2.3815 | 2.3624 | 2.0957 |
| 24 | 2.8197 | 2.4768 | 2.3815 | 2.6482 | 2.5149 | 2.3815 | 2.3815 |
| Max | 2.9721 | 2.915 | 2.934 | 2.9531 | 3.0483 | 3.0102 | 2.934 |
| Min | 2.4196 | 2.3624 | 2.3815 | 2.5149 | 2.3815 | 2.3434 | 2.0957 |
| Avg | 2.7901 | 2.6697 | 2.6327 | 2.7397 | 2.7073 | 2.4863 | 2.5777 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 202 / 11 KV KHARDE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | | .3429 | .3429 | .381 | .381 | .381 |
| 2 | .381 | | .3429 | .3429 | .381 | .4191 | .4191 |
| 3 | .4191 | | .381 | .3429 | .4191 | .4001 | .4572 |
| 4 | .4572 | | .4191 | .381 | .0381 | .4572 | .4572 |
| 5 | .4572 | | .4954 | .4191 | .4572 | .5335 | .4763 |
| 6 | .5335 | | .5335 | .5335 | .4954 | .6097 | .5144 |
| 7 | .5335 | | .4763 | .5716 | .5335 | .5906 | .381 |
| 8 | .4954 | .6668 | .4763 | .4763 | .4572 | .5335 | .4954 |
| 9 | .4572 | .6097 | .4382 | .4382 | .4191 | .4382 | .4001 |
| 10 | .4191 | .4572 | .4001 | .4001 | .4191 | .4191 | .381 |
| 11 | .4572 | .4572 | .4001 | .4191 | .4191 | .381 | .4572 |
| 12 | .381 | .4191 | .381 | .4001 | .4191 | .381 | .4572 |
| 13 | .381 | .4191 | .381 | .381 | .4191 | .381 | .4191 |
| 14 | .381 | .4382 | .381 | .381 | .4001 | .381 | .4191 |
| 15 | .4191 | .4382 | .4001 | .381 | .4001 | .381 | .4382 |
| 16 | .4572 | .4382 | .4001 | .4191 | .4191 | | .4382 |
| 17 | .4572 | .4382 | .4001 | .4191 | .4382 | .4001 | .4382 |
| 18 | .4572 | .4191 | .4191 | .4191 | .4572 | .4191 | .4572 |
| 19 | .4572 | .4382 | .4191 | .4954 | .4763 | .4763 | .4572 |
| 20 | .4572 | .4191 | | .4572 | .5144 | | .5335 |
| 21 | .4572 | .4191 | .4382 | .4572 | .5144 | .4763 | .5716 |
| 22 | .4572 | .4191 | .4382 | .4572 | .4954 | .4191 | .5716 |
| 23 | .4572 | | .4191 | .4191 | .4572 | | .5335 |
| 24 | .381 | .4191 | .381 | .381 | .4191 | .4191 | .381 |
| Max | .5335 | .6668 | .5335 | .5716 | .5335 | .6097 | .5716 |
| Min | .381 | .4191 | .3429 | .3429 | .0381 | .381 | .381 |
| Avg | .4413 | .4572 | .4158 | .4223 | .4271 | .4427 | .4556 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 203 / 11KV BALDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4191 | | .381 | .381 | .4191 | .4382 | .4191 |
| 2 | .4191 | | .381 | .381 | .4191 | .4191 | .4572 |
| 3 | .4954 | | .4763 | .4572 | .4763 | .4572 | .4572 |
| 4 | .5335 | | .5716 | .5335 | .5144 | .5335 | .5335 |
| 5 | .5716 | | .6097 | .5906 | .5335 | .6668 | .6859 |
| 6 | | | .724 | .6668 | .5716 | .8002 | .8192 |
| 7 | .6859 | | .5716 | .7049 | .6859 | .724 | .5716 |
| 8 | .6859 | .6287 | .5335 | .5525 | .5906 | .5716 | |
| 9 | .5335 | .5716 | .5525 | .5144 | .5716 | .5335 | .4954 |
| 10 | .4954 | .4572 | .4954 | .4954 | .4572 | .4572 | .4572 |
| 11 | .4763 | .4954 | .4572 | .5144 | .4954 | .4954 | .4572 |
| 12 | .4954 | .4954 | .5335 | .4954 | .4763 | .5144 | .4572 |
| 13 | .4954 | .5335 | .5716 | .5335 | .4954 | .5144 | .4382 |
| 14 | .4954 | .5335 | .5716 | .4954 | .4572 | .4954 | .4382 |
| 15 | .5335 | .5716 | .5525 | .4572 | .5144 | .4763 | .4382 |
| 16 | .5335 | .5716 | .5525 | .4572 | .4572 | .4763 | .4572 |
| 17 | .5335 | .5716 | .5144 | 1.2384 | .4954 | .5144 | .4572 |
| 18 | .5335 | .6097 | .5716 | .5716 | .5716 | .5716 | .4572 |
| 19 | .5335 | .6859 | .6097 | .6859 | .6287 | .5716 | .4954 |
| 20 | .5525 | .6097 | .6097 | .6859 | .6097 | .6097 | .5335 |
| 21 | .5525 | .5906 | .6287 | .6097 | .6287 | .6287 | .5716 |
| 22 | .5716 | .5525 | .6097 | .5335 | .5525 | | .5716 |
| 23 | .5525 | .5525 | .5716 | .5335 | .4954 | | .5525 |
| 24 | .4572 | .4763 | .4954 | .4954 | .4954 | .4572 | .4572 |
| Max | .6859 | .6859 | .724 | 1.2384 | .6859 | .8002 | .8192 |
| Min | .4191 | .4572 | .381 | .381 | .4191 | .4191 | .4191 |
| Avg | .5285 | .5593 | .5478 | .5660 | .5255 | .5421 | .5078 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 205 / 11 KV SAKWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.3717 | 1.4098 | 1.2384 | 1.2955 | 1.2955 |
| 2 | 1.448 | | 1.3717 | 1.4098 | 1.3336 | 1.2955 | 1.2955 |
| 3 | 1.4861 | | 1.4289 | 1.4861 | 1.3908 | 1.2955 | 1.2955 |
| 4 | 1.5242 | | 1.4289 | 1.4861 | 1.3717 | 1.3146 | 1.3146 |
| 5 | 1.5242 | | 1.4861 | 1.5242 | 1.3717 | 1.2955 | 1.3146 |
| 6 | | | 1.5242 | 1.5432 | 1.3908 | 1.3146 | 1.3146 |
| 7 | 1.6194 | | 1.7147 | 1.5813 | 1.6575 | 1.5623 | 1.5432 |
| 8 | 1.6766 | 1.8671 | 1.7909 | 1.7147 | 1.7528 | 1.7147 | 1.6385 |
| 23 | 1.3717 | 1.3336 | 1.2955 | 1.3336 | 1.2765 | 1.2955 | .9145 |
| 24 | 1.4289 | 1.4289 | 1.3336 | 1.3336 | 1.3336 | 1.2955 | 1.2955 |
| Max | 1.6766 | 1.8671 | 1.7909 | 1.7147 | 1.7528 | 1.7147 | 1.6385 |
| Min | 1.3717 | 1.3336 | 1.2955 | 1.3336 | 1.2384 | 1.2955 | .9145 |
| Avg | 1.5099 | 1.5432 | 1.4746 | 1.4822 | 1.4117 | 1.3679 | 1.3222 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 201 / 11 KV PALASNER MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8596 | .9945 | .8596 | .7621 | .9259 | .9259 | .8954 |
| 2 | .8954 | | .815 | .8078 | .8745 | .9602 | .9214 |
| 3 | .9114 | .9259 | .7442 | .9145 | .8745 | .9945 | .9922 |
| 4 | .9922 | .9945 | .8764 | 1.0669 | 1.0288 | 1.0288 | 1.2178 |
| 5 | 1.6301 | 1.0631 | .9431 | 1.3108 | 1.1317 | 1.0974 | 1.5432 |
| 6 | 1.7147 | 1.0974 | 1.0631 | 1.4022 | 1.286 | 1.2346 | 1.6461 |
| 7 | 1.9204 | 1.6804 | 1.1869 | 1.6766 | 1.5432 | 1.6118 | 1.7147 |
| 8 | 1.8861 | 1.7661 | 1.5432 | 1.2498 | 1.4403 | 1.8861 | 1.749 |
| 9 | 1.6118 | 1.6991 | 1.5242 | | 1.6804 | 1.893 | |
| 10 | 1.5089 | 1.647 | 1.1279 | | 1.6118 | 1.6118 | |
| 19 | 1.0631 | | 1.4327 | | | | |
| 20 | 1.3375 | | 1.3717 | | | | |
| 21 | 1.286 | | 1.2955 | | | | |
| 22 | 1.0974 | | 1.2651 | | | | |
| 23 | 1.0631 | | 1.1736 | | | | |
| 24 | .9671 | 1.0288 | .8764 | 1.0517 | | .8573 | .9568 |
| Max | 1.9204 | 1.7661 | 1.5432 | 1.6766 | 1.6804 | 1.893 | 1.749 |
| Min | .8596 | .9259 | .7442 | .7621 | .8745 | .8573 | .8954 |
| Avg | 1.2966 | 1.2897 | 1.1312 | 1.1380 | 1.2397 | 1.2819 | 1.2930 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 202 / 11KV KHAIRKHUTI MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7888 | | | | | |
| 2 | | .7545 | | | | | |
| 3 | | .7202 | | | | | |
| 4 | | .7373 | | | | | |
| 5 | | .7545 | | | | | |
| 6 | | .7716 | | | | | |
| 14 | 1.0802 | 1.2269 | .945 | | 1.5432 | 1.2894 | |
| 15 | 1.286 | 1.4373 | 1.0669 | | 1.7833 | 1.5249 | |
| 16 | 1.406 | 1.3717 | 1.1431 | | 1.7318 | 1.5604 | |
| 17 | 1.3889 | 1.3717 | 1.1279 | | 1.6118 | 1.5249 | |
| 18 | 1.3717 | 1.4373 | 1.1126 | | 1.4746 | 1.4217 | |
| 19 | 1.3032 | 1.2795 | 1.1126 | | 1.2346 | 1.1919 | |
| 20 | 1.2346 | 1.0631 | 1.0059 | | 1.166 | 1.0692 | |
| 21 | .9088 | .9945 | .9145 | | .9259 | .9568 | |
| 22 | .8745 | .8764 | .8535 | | .8916 | .9114 | |
| 23 | .823 | .788 | .7621 | | .8573 | .8764 | |
| 24 | .7164 | .8059 | .7522 | .7011 | | .823 | .8505 |
| Max | 1.406 | 1.4373 | 1.1431 | .7011 | 1.7833 | 1.5604 | .8505 |
| Min | .7164 | .7202 | .7522 | .7011 | .8573 | .823 | .8505 |
| Avg | 1.1267 | 1.0105 | .9815 | .7011 | 1.3220 | 1.1955 | .8505 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 201 / 11 kv Aadhe Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | | .2572 | |
| 2 | | | | | | .2572 | |
| 3 | | | | | | .2572 | |
| 4 | | | | | | .2572 | |
| 5 | | | | | | .2743 | |
| 6 | | | | | | .4287 | |
| 7 | | | | | | .4458 | |
| 8 | | | | | | .3601 | |
| 9 | .3258 | .3429 | .3429 | .3086 | .3429 | .3258 | .3429 |
| 10 | .2915 | .3429 | .3086 | .3086 | .3429 | .3086 | .3086 |
| 11 | .3601 | .3429 | .3086 | .2743 | .3086 | .2915 | .2915 |
| 12 | .3258 | .3429 | .2915 | .2572 | .2915 | .2743 | .2401 |
| 13 | .3086 | .3086 | .2743 | .2401 | .2572 | .2401 | .2229 |
| 14 | .2743 | .2572 | .2401 | .2229 | .2229 | .2572 | .2229 |
| 15 | .2915 | .2743 | .2743 | .2229 | .2401 | .2915 | .2229 |
| 16 | .3258 | .3086 | .2915 | .2572 | .2743 | .2572 | .3086 |
| 17 | 1.3717 | .3258 | .3258 | .2915 | .2915 | | |
| 18 | .3601 | .3429 | .3429 | .3086 | .3429 | | |
| 19 | .4115 | .3772 | .4115 | .4458 | .4115 | | |
| 20 | .4287 | .4115 | .3772 | .3944 | .3429 | | |
| 21 | .3601 | .3429 | .3772 | .3601 | .3429 | | |
| 22 | .3429 | .2743 | .3086 | .3429 | .3258 | | |
| 23 | .2743 | .2401 | .2915 | .3086 | .2915 | | |
| 24 | .2401 | .2743 | | .2743 | .2743 | .2743 | |
| Max | 1.3717 | .4115 | .4115 | .4458 | .4115 | .4458 | .3429 |
| Min | .2401 | .2401 | .2401 | .2229 | .2229 | .2401 | .2229 |
| Avg | .3933 | .3193 | .3178 | .3011 | .3065 | .2975 | .2701 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 202 / 11 kv Tajpuri AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | | 1.4575 |
| 2 | | | | | | 1.4746 |
| 3 | | | | | | 1.4918 |
| 4 | | | | | | 1.4918 |
| 5 | | | | | | 1.4746 |
| 6 | | | | | | 1.5089 |
| 7 | | | | | | 1.6118 |
| 8 | | | | | | 1.6975 |
| 23 | .6954 | .8383 | .7145 | .7811 | .743 | |
| 24 | 1.0974 | .7145 | 1.3717 | .7621 | .7907 | .7907 |
| Max | 1.0974 | .8383 | 1.3717 | .7811 | .7907 | 1.6975 |
| Min | .6954 | .7145 | .7145 | .7621 | .743 | .7907 |
| Avg | .8964 | .7764 | 1.0431 | .7716 | .7669 | 1.4444 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 203 / 11 kv Aadhe AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.2517 | 1.286 | 1.5089 | 1.3717 | 1.3375 |
| 11 | 1.4232 | 1.5432 | 1.5775 | 1.4575 | 1.6632 |
| 12 | 1.5261 | 1.6289 | 1.5947 | 1.5432 | 1.6804 |
| 13 | 1.5432 | 1.6289 | 1.6632 | 1.5432 | 1.6975 |
| 14 | 1.5775 | 1.6289 | 1.6289 | 1.5604 | 1.6461 |
| 15 | 1.5775 | 1.6289 | 1.6461 | 1.5604 | 1.5947 |
| 16 | 1.5604 | 1.6289 | 1.6632 | 1.5432 | 1.6289 |
| 17 | .8669 | .8764 | .9145 | .8383 | .9145 |
| Max | 1.5775 | 1.6289 | 1.6632 | 1.5604 | 1.6975 |
| Min | .8669 | .8764 | .9145 | .8383 | .9145 |
| Avg | 1.4158 | 1.4813 | 1.5246 | 1.4272 | 1.5204 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 201 / 11 KV HINGONIPADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3292 | .3048 | .3048 | .3109 | .3292 | .3326 | .3429 |
| 2 | .3292 | .3048 | .3048 | .3109 | .3292 | .3326 | .3429 |
| 3 | .3292 | .3429 | .3429 | .3109 | .3292 | .3326 | .381 |
| 4 | .3841 | .362 | .362 | .4024 | .3841 | .3696 | .4763 |
| 5 | .4938 | .4763 | .4763 | .5121 | .5121 | .462 | .6287 |
| 6 | .6036 | .5525 | .6287 | .567 | .6036 | .6099 | .6287 |
| 7 | .6584 | .6287 | .6668 | .6036 | .6401 | .5729 | .6287 |
| 8 | .5487 | .5525 | .5487 | .5304 | .5121 | .499 | .5525 |
| 9 | .4763 | .4382 | .3801 | .4207 | .4024 | .4251 | .362 |
| 10 | .4001 | .3048 | .3292 | | .3658 | .3429 | .381 |
| 11 | .3475 | .362 | .2743 | | .3292 | .3429 | .3292 |
| 12 | .3475 | .3048 | .2561 | .3475 | .3109 | .3429 | .3292 |
| 13 | .3292 | .3048 | .2743 | .3475 | .2926 | .3429 | .3109 |
| 14 | .3429 | .3429 | .2926 | .2926 | .2743 | .3239 | .3109 |
| 15 | .362 | .3429 | .2926 | .2926 | .2926 | .3239 | .3292 |
| 16 | .362 | .3429 | .3109 | .3109 | .3475 | .3429 | .3292 |
| 17 | .4382 | .362 | .3292 | .3475 | .4024 | .4382 | .4024 |
| 18 | .4954 | .4572 | .3841 | .4938 | .4207 | .4954 | .4572 |
| 19 | .5906 | .5335 | .4755 | .5121 | .4207 | .5716 | .5121 |
| 20 | .5144 | .5335 | .4755 | .4755 | .4572 | .5335 | .4572 |
| 21 | .4382 | .4763 | .4938 | .3841 | .4207 | .4763 | .439 |
| 22 | .4001 | .4572 | .4024 | .3696 | .3841 | .4191 | .3658 |
| 23 | .3429 | .381 | .3658 | .3511 | .3658 | .381 | .3292 |
| 24 | .3475 | .3239 | .3429 | .3292 | .3292 | .3292 | .3429 |
| Max | .6584 | .6287 | .6668 | .6036 | .6401 | .6099 | .6287 |
| Min | .3292 | .3048 | .2561 | .2926 | .2743 | .3239 | .3109 |
| Avg | .4255 | .4080 | .3881 | .4010 | .3940 | .4143 | .4154 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 202 / 11 KV SHIRPUR BDK AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.5009 | 1.9052 | 1.7535 | 1.8278 | 1.6941 | 1.9433 | 1.9624 |
| 11 | 1.7684 | 2.0957 | 1.5455 | 1.8873 | 1.7238 | 2.1338 | 1.7535 |
| 12 | 1.7684 | 2.2481 | 1.6347 | 1.813 | 1.7387 | 2.1338 | 1.7387 |
| 13 | 1.8278 | 2.2481 | 1.6347 | 1.8724 | 1.7535 | 2.1529 | 1.709 |
| 14 | 2.3053 | 2.2481 | 1.7981 | 1.813 | 1.709 | 2.2291 | 1.7238 |
| 15 | 2.3243 | 2.2291 | 1.8278 | 1.8278 | 1.6347 | 2.2291 | 1.7535 |
| 16 | 2.3434 | 2.2291 | 1.8576 | 1.8278 | 1.709 | 2.3434 | 1.6941 |
| 17 | 2.3243 | 2.21 | 1.8724 | 1.6644 | 1.7238 | 2.2481 | 1.5752 |
| Max | 2.3434 | 2.2481 | 1.8724 | 1.8873 | 1.7535 | 2.3434 | 1.9624 |
| Min | 1.5009 | 1.9052 | 1.5455 | 1.6644 | 1.6347 | 1.9433 | 1.5752 |
| Avg | 2.0204 | 2.1767 | 1.7405 | 1.8167 | 1.7108 | 2.1767 | 1.7388 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094067 / 33/11 KV KARWAND

Feeder No / Name : 203 / 11 KV NATWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6773 | .8764 | .9526 | .7335 | .7188 | .7133 | .9145 |
| 2 | .7074 | .8954 | .9526 | .7335 | .9145 | .7133 | .9145 |
| 3 | .7225 | .8573 | .9526 | .7482 | .7628 | .6984 | .9145 |
| 4 | .7526 | .8764 | .9526 | .7482 | .7922 | .7133 | .9145 |
| 5 | .7977 | .8954 | .9526 | .7335 | .8215 | .7133 | 1.0288 |
| 6 | .8429 | .9145 | .9717 | .7482 | .8215 | .7133 | 1.105 |
| 7 | .873 | 1.1431 | 1.1431 | .8362 | .8802 | .8768 | 1.1431 |
| 8 | .9065 | 1.1812 | .9412 | .8802 | | .8916 | 1.1622 |
| 23 | .8002 | .8573 | .6516 | .6748 | .6455 | .8764 | .5647 |
| 24 | .6622 | .8383 | .9145 | .6805 | .7042 | .7042 | .8764 |
| Max | .9065 | 1.1812 | 1.1431 | .8802 | .9145 | .8916 | 1.1622 |
| Min | .6622 | .8383 | .6516 | .6748 | .6455 | .6984 | .5647 |
| Avg | .7742 | .9335 | .9385 | .7517 | .7846 | .7614 | .9538 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 201 / 11 Kv Nagalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.643 | 1.6478 | 1.6804 | 1.5592 | 1.3998 | 1.5424 | 1.5769 |
| 2 | 1.6617 | 1.6832 | 1.7737 | 1.5769 | 1.3998 | 1.56 | 1.5592 |
| 3 | 1.7177 | | 1.7924 | 1.5592 | 1.5061 | 1.5424 | 1.5769 |
| 4 | 1.7737 | 1.7896 | 1.8858 | 1.5769 | 1.5238 | 1.6301 | 1.6124 |
| 5 | 1.8111 | 1.9313 | 2.0376 | 1.5769 | 1.5947 | 1.6827 | 1.5947 |
| 6 | 1.8671 | 1.949 | 2.0199 | 1.5947 | 1.6832 | 1.7528 | 1.6124 |
| 7 | 2.1285 | 2.0199 | 1.8604 | 1.701 | 1.701 | 1.8404 | 1.7718 |
| 8 | 2.2405 | 2.2148 | 1.8656 | 1.9418 | 1.8427 | 1.858 | 1.9978 |
| 23 | 1.6804 | 1.5074 | 1.5415 | 1.4937 | 1.4529 | 1.4175 | 1.307 |
| 24 | 1.643 | | 1.5592 | 1.5415 | 1.4175 | 1.5424 | 1.5061 |
| Max | 2.2405 | 2.2148 | 2.0376 | 1.9418 | 1.8427 | 1.858 | 1.9978 |
| Min | 1.643 | 1.5074 | 1.5415 | 1.4937 | 1.3998 | 1.4175 | 1.307 |
| Avg | 1.8167 | 1.8429 | 1.8017 | 1.6122 | 1.5522 | 1.6369 | 1.6115 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 202 / 11 KV BHATPURA CHAUFULI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.475 | 1.4198 | 1.5415 | 1.5123 | 1.4723 | 1.4706 | 1.3443 |
| 11 | 1.6617 | 1.5249 | 1.5238 | 1.7177 | 1.5424 | 1.5238 | 1.4003 |
| 12 | 1.6804 | 1.4899 | 1.595 | 1.6991 | 1.5775 | 1.3643 | 1.4937 |
| 13 | 1.7551 | 1.5746 | 1.6478 | 1.6804 | 1.5769 | 1.4883 | 1.419 |
| 14 | 1.7177 | 1.5074 | 1.6478 | 1.6991 | 1.5249 | 1.4883 | 1.4563 |
| 15 | 1.7364 | 1.5424 | 1.6478 | 1.6617 | 1.5074 | 1.4706 | 1.4003 |
| 16 | 1.7551 | 1.4899 | 1.5769 | 1.643 | 1.3672 | 1.4706 | 1.4377 |
| 17 | 1.6991 | 1.4723 | 1.5592 | 1.6244 | 1.2445 | 1.1694 | 1.4937 |
| Max | 1.7551 | 1.5746 | 1.6478 | 1.7177 | 1.5775 | 1.5238 | 1.4937 |
| Min | 1.475 | 1.4198 | 1.5238 | 1.5123 | 1.2445 | 1.1694 | 1.3443 |
| Avg | 1.6851 | 1.5027 | 1.5925 | 1.6547 | 1.4766 | 1.4307 | 1.4307 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094068 / 33/11 KV BHATPURA

Feeder No / Name : 203 / 11 KV AJNAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2427 | .2054 | .2427 | .3174 | .2427 | .2614 | .2427 |
| 2 | .2427 | .2427 | .2614 | .3547 | .2427 | .2987 | .2427 |
| 3 | .3174 | .2427 | .2987 | .4108 | .2614 | .3174 | .3174 |
| 4 | .4108 | .2801 | .3361 | .4294 | .2801 | .2987 | .3361 |
| 5 | .4854 | .3361 | .3921 | .4668 | .3547 | .3361 | .4481 |
| 6 | .5415 | .3547 | .4481 | .5041 | .4668 | .3921 | .5415 |
| 7 | .5601 | .5041 | .5228 | .5601 | .4854 | .4854 | .5228 |
| 8 | .4108 | .3921 | .3734 | .4108 | .3547 | .3547 | .3921 |
| 9 | .3921 | .2987 | .3361 | | .2427 | .2987 | .3174 |
| 10 | .2801 | .2801 | .3174 | .2987 | .2054 | .2801 | .2614 |
| 11 | .2987 | .2241 | .2427 | .2614 | .2427 | .2427 | .2614 |
| 12 | .2614 | .2427 | .2801 | .2427 | .168 | .2229 | .2427 |
| 13 | .2801 | .2614 | .2614 | .2614 | .1867 | .2614 | .2241 |
| 14 | .2427 | .2614 | .2054 | .2427 | .2241 | .2614 | .2427 |
| 15 | .2801 | .2801 | .2614 | .2801 | .2801 | .2427 | .2801 |
| 16 | .2987 | .2801 | .3174 | .2987 | .2614 | .2614 | .2427 |
| 17 | .3174 | .3174 | .3361 | .3361 | .3174 | .2801 | .2987 |
| 18 | .3361 | .3921 | .3361 | .3734 | .3361 | .3361 | .3174 |
| 19 | .2801 | .3921 | .4108 | .4108 | .3921 | .4108 | .3734 |
| 20 | .2427 | .2987 | .3921 | .3361 | .3361 | .3734 | .3547 |
| 21 | .2801 | .2801 | .3174 | .3174 | .2987 | .3174 | .3361 |
| 22 | .2427 | .2427 | .3174 | .2987 | .2801 | .2987 | .3174 |
| 23 | .2427 | .2614 | .2987 | .2801 | .2801 | .2801 | .2801 |
| 24 | .2801 | .2614 | .2801 | .2801 | .2801 | .2427 | .2614 |
| Max | .5601 | .5041 | .5228 | .5601 | .4854 | .4854 | .5415 |
| Min | .2427 | .2054 | .2054 | .2427 | .168 | .2229 | .2241 |
| Avg | .3236 | .2972 | .3244 | .3466 | .2925 | .3065 | .3190 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 201 / 11 KV BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6513 | 1.2696 | 1.7924 | 1.488 | 1.6872 | 2.2405 |
| 2 | 2.8006 | 1.307 | 2.0538 | 1.6232 | 1.6804 | 2.2405 |
| 3 | 2.8006 | 1.4003 | 2.0911 | 1.8138 | | 2.4646 |
| 4 | 3.0807 | 1.643 | 2.2032 | 1.9471 | | 2.5206 |
| 5 | 3.0807 | 1.7924 | 2.3152 | 2.4905 | | 2.5206 |
| 6 | 3.1554 | 2.2405 | 2.4646 | 2.5396 | | 2.4646 |
| 7 | 3.1554 | 3.1367 | 2.6886 | 2.4806 | | 2.4646 |
| 8 | 2.5263 | 3.2301 | 3.0247 | 2.2531 | | 2.5393 |
| 19 | | | | | 2.4272 | |
| 20 | | | | | 2.5393 | |
| 21 | | | | | 2.6139 | |
| 22 | | | | | 2.6139 | |
| 23 | | 1.3443 | 1.0145 | 1.5676 | 2.4272 | 2.2032 |
| 24 | 2.4272 | .9522 | 1.4937 | 1.2631 | 1.5556 | 2.2405 |
| Max | 3.1554 | 3.2301 | 3.0247 | 2.5396 | 2.6139 | 2.5393 |
| Min | 2.4272 | .9522 | 1.0145 | 1.2631 | 1.5556 | 2.2032 |
| Avg | 2.8531 | 1.8316 | 2.1142 | 1.9467 | 2.1931 | 2.3899 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 202 / 11 KV WANAVAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.3672 | 2.2779 | 1.6097 | | 1.9791 |
| 11 | 1.813 | 2.4832 | 1.7433 | 2.0538 | 2.2032 |
| 12 | 1.7981 | 2.4459 | 1.8576 | 2.3339 | 2.3152 |
| 13 | 1.8595 | 2.5019 | 1.8576 | 2.4272 | 2.2032 |
| 14 | 1.6232 | 2.4832 | 1.5935 | 2.4272 | 2.1472 |
| 15 | 1.6598 | 2.4646 | 1.6038 | 2.4646 | 2.1845 |
| 16 | 1.7238 | 2.5019 | 1.5108 | 2.3339 | 2.1845 |
| 17 | 1.9216 | 2.4646 | 1.5962 | 2.1658 | 2.0538 |
| Max | 1.9216 | 2.5019 | 1.8576 | 2.4646 | 2.3152 |
| Min | 1.3672 | 2.2779 | 1.5108 | 2.0538 | 1.9791 |
| Avg | 1.7208 | 2.4529 | 1.6716 | 2.3152 | 2.1588 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094073 / 33/11 KV BALADE

Feeder No / Name : 203 / 11 KV GIDHADE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3734 | .2987 | .2987 | .2591 | .2321 | .3734 |
| 2 | .3734 | .2987 | .3174 | .2705 | .2321 | .3734 |
| 3 | .3734 | .3361 | .3547 | .3382 | .2557 | .3734 |
| 4 | .4854 | .4108 | .4108 | .3239 | .3096 | .5601 |
| 5 | .5975 | .4668 | .4481 | .4058 | .3963 | .7095 |
| 6 | .7468 | .5975 | .4578 | .514 | .514 | .7468 |
| 7 | .7468 | .7282 | .5087 | .5796 | .4801 | .7095 |
| 8 | .547 | .5601 | .5228 | .4572 | .6722 | .5228 |
| 9 | .3788 | .3921 | | .3788 | .5041 | .4108 |
| 10 | .3239 | .3921 | | .2801 | | .3734 |
| 11 | .3109 | .3734 | | .2721 | .5228 | .2987 |
| 12 | .2972 | .2713 | | .2641 | .5228 | .3734 |
| 13 | .3155 | .3547 | | .2591 | .5228 | .3174 |
| 14 | .3201 | .3361 | | .285 | .4854 | .3361 |
| 15 | .2561 | .3547 | | .2724 | .4694 | .3361 |
| 16 | .3201 | .4294 | | .2972 | .5041 | .3734 |
| 17 | .3887 | .4481 | | .322 | .4854 | .4108 |
| 18 | | .5041 | | .3096 | .5228 | .4854 |
| 19 | | .5601 | | .487 | .5601 | .5415 |
| 20 | | .4481 | | .3757 | .5788 | .4668 |
| 21 | | .4108 | | .3368 | .5601 | .4108 |
| 22 | | .3734 | | .2972 | .5601 | .3734 |
| 23 | | .3361 | | .2724 | .4108 | .3174 |
| 24 | .3734 | .3361 | .3174 | .2591 | .2347 | .3734 |
| Max | .7468 | .7282 | .5228 | .5796 | .6722 | .7468 |
| Min | .2561 | .2713 | .2987 | .2591 | .2321 | .2987 |
| Avg | .4182 | .4174 | .4040 | .3382 | .4581 | .4403 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 201 / 11 KV WAGHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.8004 | 1.8176 | 1.9204 | 1.7318 |
| 11 | 1.9204 | 1.9719 | 2.0233 | 1.869 |
| 12 | 1.9033 | 1.9547 | 2.0233 | .8916 |
| 13 | 1.9033 | 1.869 | 2.0062 | 1.2003 |
| 14 | 1.9204 | 1.8861 | 1.9719 | 1.6461 |
| 15 | 1.9033 | 1.9719 | 1.9376 | 1.6118 |
| 16 | 1.7661 | 1.9547 | 1.869 | 1.5947 |
| 17 | 1.8861 | 1.9719 | 1.9204 | 1.5947 |
| Max | 1.9204 | 1.9719 | 2.0233 | 1.869 |
| Min | 1.7661 | 1.8176 | 1.869 | .8916 |
| Avg | 1.8754 | 1.9247 | 1.9590 | 1.5175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 202 / 11 KV ASALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.5432 | 1.3717 | 1.3717 |
| 2 | | 1.3717 | 1.3717 | 1.3717 |
| 3 | | 1.3717 | 1.3717 | 1.3717 |
| 4 | | 1.3717 | 1.3717 | 1.4575 |
| 5 | | .9431 | 1.3717 | 1.3717 |
| 6 | | 1.3717 | 1.4575 | 1.3717 |
| 7 | | 1.3717 | 1.5432 | 1.5432 |
| 8 | | 1.5432 | 1.6289 | 1.5432 |
| 23 | | | 1.286 | |
| 24 | 1.5089 | 1.5432 | 1.3717 | 1.3717 |
| Max | 1.5089 | 1.5432 | 1.6289 | 1.5432 |
| Min | 1.5089 | .9431 | 1.286 | 1.3717 |
| Avg | 1.5089 | 1.3812 | 1.4146 | 1.4193 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 203 / 11 KV DAHIWAD AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 10 | 1.9719 | 1.9719 | 2.1434 |
| 11 | 2.4863 | 2.3148 | 2.4006 |
| 12 | 2.4863 | 2.4863 | 2.572 |
| 13 | 2.4863 | 2.4863 | 2.4863 |
| 14 | 2.4006 | 2.4006 | 2.4863 |
| 15 | 2.4006 | 2.4863 | 2.4006 |
| 16 | 2.4863 | 2.4006 | 2.3148 |
| 17 | 2.4006 | 2.3148 | 2.2291 |
| Max | 2.4863 | 2.4863 | 2.572 |
| Min | 1.9719 | 1.9719 | 2.1434 |
| Avg | 2.3899 | 2.3577 | 2.3791 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 204 / 11 KV RHT AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 1.1317 |
| Max | 1.1317 |
| Min | 1.1317 |
| Avg | 1.1317 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 205 / 11 KV PADMAVATI IND
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | .1715 | .1715 |
| 2 | .1715 | .1715 | .1715 |
| 3 | .1715 | .1715 | .1715 |
| 4 | .1715 | .1715 | .1715 |
| 5 | .1715 | .1715 | .1715 |
| 6 | .1715 | .1715 | .1715 |
| 7 | .1715 | .1715 | .1715 |
| 8 | .1715 | .1715 | .1715 |
| 9 | .1715 | .1715 | .1715 |
| 10 | .1715 | .1715 | .1715 |
| 11 | .1715 | .1715 | .1715 |
| 12 | .1715 | .1715 | .1715 |
| 13 | .1715 | .1715 | .1715 |
| 14 | .1715 | .1715 | .1715 |
| 15 | .1715 | .1715 | .1715 |
| 16 | .1715 | .1715 | .1715 |
| 17 | .1715 | .1715 | .1715 |
| 18 | .1715 | .1715 | .1715 |
| 19 | .1715 | .1715 | .1715 |
| 20 | .1715 | .1715 | .1715 |
| 21 | .1715 | .1715 | .1715 |
| 22 | .1715 | .1715 | .1715 |
| 23 | .1715 | .1715 | .1715 |
| 24 | .1715 | .1715 | .1715 |
| Max | .1715 | .1715 | .1715 |
| Min | .1715 | .1715 | .1715 |
| Avg | .1715 | .1715 | .1715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 206 / 11 KV Shirpur Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3772 | .3772 |
| 2 | | .3772 | .3772 |
| 3 | | .3772 | .3772 |
| 4 | | .3944 | .4458 |
| 5 | | .4287 | .5658 |
| 6 | | .6344 | .6344 |
| 7 | | .6344 | .6173 |
| 8 | | .6001 | .6173 |
| 9 | | .3944 | .4458 |
| 10 | | .3944 | .4458 |
| 11 | | .3944 | .3601 |
| 12 | | .3258 | .3601 |
| 13 | | .3601 | .3601 |
| 14 | | .3601 | .3601 |
| 15 | | .3086 | .3429 |
| 16 | | .3429 | .3772 |
| 17 | | .4115 | .4801 |
| 18 | | .6516 | .4973 |
| 19 | | .463 | .4801 |
| 20 | | .463 | .4287 |
| 21 | | .463 | .4458 |
| 22 | | .4287 | .4115 |
| 23 | | .3944 | .4458 |
| 24 | .5658 | .3601 | .3772 |
| Max | .5658 | .6516 | .6344 |
| Min | .5658 | .3086 | .3429 |
| Avg | .5658 | .4308 | .4430 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 207 / 11 KV Garg

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1715 | .1715 |
| 2 | | .1715 | .1715 |
| 3 | | .1715 | .1715 |
| 4 | | .1715 | .1715 |
| 5 | | .1715 | .1715 |
| 6 | | .1715 | .1715 |
| 7 | | .1715 | .1715 |
| 8 | | .1715 | .1715 |
| 9 | | .1715 | .1715 |
| 10 | | .1715 | .1715 |
| 11 | | .1715 | .1715 |
| 12 | | .1715 | .1715 |
| 13 | | .1715 | .1715 |
| 14 | | .1715 | .1715 |
| 15 | | .1715 | .1715 |
| 16 | | .1715 | .1715 |
| 17 | | .1715 | .1715 |
| 18 | | .1715 | .1715 |
| 19 | | .1715 | .1715 |
| 20 | | .1715 | .1715 |
| 21 | | .1715 | .1715 |
| 22 | | .1715 | .1715 |
| 23 | 1.1317 | .1715 | .1715 |
| 24 | .1715 | .1715 | .1715 |
| Max | 1.1317 | .1715 | .1715 |
| Min | .1715 | .1715 | .1715 |
| Avg | .6516 | .1715 | .1715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 208 / 11KV KARWAND/DAHIWAD

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2572 | .2572 |
| 2 | | .2572 | .2572 |
| 3 | | .2572 | .2572 |
| 4 | | .2572 | .7716 |
| 5 | | .2572 | .3429 |
| 6 | | .3429 | .4287 |
| 7 | | .3429 | .4287 |
| 8 | | .3429 | .3429 |
| 9 | | .2572 | .3429 |
| 10 | | .2572 | .2572 |
| 11 | | .2572 | .2572 |
| 12 | | .2572 | .2572 |
| 13 | | .2572 | .2572 |
| 14 | | .2572 | .2572 |
| 15 | | .2572 | .2572 |
| 16 | | .2572 | .2572 |
| 17 | | .2572 | .2572 |
| 18 | | .2572 | .2572 |
| 19 | | .3429 | .2572 |
| 20 | | .3429 | .3429 |
| 21 | | .3429 | .3429 |
| 22 | | .2572 | .3429 |
| 23 | | .2572 | .3429 |
| 24 | .3944 | .2572 | .2572 |
| Max | .3944 | .3429 | .7716 |
| Min | .3944 | .2572 | .2572 |
| Avg | .3944 | .2786 | .3179 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 210 / 33 KV KARWAND

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 1 | .7716 |
| 2 | .7716 |
| 3 | .7716 |
| 4 | .7716 |
| 5 | .7716 |
| 6 | .7716 |
| 8 | 1.286 |
| 9 | .7716 |
| 10 | .7716 |
| 11 | .7716 |
| 12 | .7716 |
| 13 | .7716 |
| 14 | .7716 |
| 15 | .7716 |
| 16 | .7716 |
| 17 | .7716 |
| 18 | .7716 |
| 19 | .7716 |
| 20 | .7716 |
| 21 | .7716 |
| 22 | .7716 |
| 23 | .7716 |
| 24 | .7716 |
| Max | 1.286 |
| Min | .7716 |
| Avg | .7940 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 402 / 33 KV SHIRPUR GOLD
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.286 | 1.1831 | 1.2346 | 1.2346 |
| 2 | 1.286 | 1.1831 | 1.2346 | 1.2346 |
| 3 | 1.286 | 1.1831 | 1.1831 | 1.2346 |
| 4 | 1.2346 | 1.1317 | 1.2346 | 1.0802 |
| 5 | 1.286 | 1.1831 | 1.2346 | 1.1831 |
| 6 | 1.2346 | 1.1831 | 1.2346 | 1.0802 |
| 7 | 1.1831 | 1.1317 | 1.1317 | 1.0802 |
| 8 | 1.286 | 1.1831 | 1.3375 | .9774 |
| 9 | 1.1317 | 1.1831 | 1.286 | .4115 |
| 10 | 1.3889 | 1.1831 | 1.286 | 1.1831 |
| 11 | 1.3375 | 1.2346 | | 1.286 |
| 12 | 1.286 | 1.2346 | 1.286 | 1.2346 |
| 13 | 1.286 | 1.1831 | 1.286 | 1.2346 |
| 14 | 1.3375 | .5658 | 1.286 | 1.286 |
| 15 | 1.286 | 1.1831 | 1.3375 | 1.3375 |
| 16 | 1.286 | 1.1831 | 1.286 | 1.3375 |
| 17 | 1.286 | 1.2346 | 1.286 | 1.286 |
| 18 | 1.2346 | 1.286 | 1.286 | 1.286 |
| 19 | 1.2346 | 1.286 | 1.286 | 1.286 |
| 20 | 1.286 | 1.286 | 1.3375 | 1.4403 |
| 21 | 1.286 | 1.286 | 1.3375 | 1.2346 |
| 22 | 1.286 | 1.3375 | 1.286 | 1.286 |
| 23 | 1.2346 | 1.286 | 1.286 | 1.3375 |
| 24 | 1.286 | 1.1831 | 1.2346 | 1.2346 |
| Max | 1.3889 | 1.3375 | 1.3375 | 1.4403 |
| Min | 1.1317 | .5658 | 1.1317 | .4115 |
| Avg | 1.2732 | 1.1874 | 1.2704 | 1.2003 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 405 / 33 KV HOLNANTHA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 10.2366 | 9.6708 | 7.6646 | 8.3848 |
| 2 | 10.2881 | 9.7737 | 7.9218 | 8.3333 |
| 3 | 10.4424 | 10.0823 | 8.0761 | 8.4362 |
| 4 | 11.3169 | 10.6482 | 8.7449 | 8.642 |
| 5 | 12.2943 | 11.677 | 9.7222 | 9.2078 |
| 6 | 10.751 | 13.786 | 10.4424 | 10.2881 |
| 7 | 12.7572 | 12.0371 | 10.0309 | 9.1564 |
| 8 | 4.2181 | 3.3951 | 4.1152 | 9.0535 |
| 9 | 7.6132 | 7.0473 | 8.4362 | 4.4239 |
| 10 | | 8.642 | 10.1852 | 10.2366 |
| 11 | 9.465 | 9.3107 | 10.1852 | |
| 12 | | 9.0535 | 10.1852 | 10.3395 |
| 13 | 9.465 | 9.1564 | | 10.1852 |
| 14 | 8.2819 | 9.0535 | 10.3395 | 10.2881 |
| 15 | 9.928 | 8.9506 | 10.4938 | 10.3395 |
| 16 | 10.2881 | 8.9506 | 14.5576 | 10.5453 |
| 17 | 4.8868 | 4.8354 | 4.4753 | 10.2881 |
| 18 | 4.9897 | 3.9609 | 4.9897 | 4.2696 |
| 19 | 2.2634 | 2.7263 | 2.8292 | 4.5782 |
| 20 | 2.4177 | 2.5206 | 2.4177 | 2.7778 |
| 21 | 2.0062 | 2.1091 | 2.2634 | 2.2119 |
| 22 | 8.642 | 8.6934 | 2.4691 | 1.9033 |
| 23 | 10.1852 | 10.2366 | 2.8292 | 6.1214 |
| 24 | 10.1852 | 9.7222 | 8.179 | 8.3848 |
| Max | 12.7572 | 13.786 | 14.5576 | 10.5453 |
| Min | 2.0062 | 2.1091 | 2.2634 | 1.9033 |
| Avg | 8.3146 | 8.1683 | 7.4588 | 7.7563 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 406 / 33 KV SOOTGIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 3.5494 | 5.2984 | 5.6584 |
| 2 | | 3.3951 | 5.2984 | 5.9156 |
| 3 | | 3.3951 | 5.144 | 5.7613 |
| 4 | | 3.7037 | 5.4012 | 5.5041 |
| 5 | | 3.9095 | 5.4012 | 5.8128 |
| 6 | | 3.7037 | 5.7099 | 5.5556 |
| 7 | | 3.8066 | 5.7613 | 5.607 |
| 8 | | 4.5268 | 5.6584 | 5.9156 |
| 9 | | 5.0412 | 5.2469 | 6.0185 |
| 10 | | | 5.9671 | 6.4301 |
| 11 | | 5.3498 | 5.7099 | 6.6358 |
| 12 | | 5.2984 | 5.8128 | 6.2243 |
| 13 | | 5.144 | 5.8642 | 6.2243 |
| 14 | | 5.2469 | 5.7099 | 6.2243 |
| 15 | | 5.2984 | 5.8642 | 6.4301 |
| 16 | | 5.1955 | 5.0926 | 6.9445 |
| 17 | | 4.9383 | 5.3498 | 5.607 |
| 18 | | 4.9383 | 5.5556 | 5.5556 |
| 19 | | 4.9897 | 5.4527 | 5.5041 |
| 20 | | 4.9897 | 5.4527 | 5.144 |
| 21 | | 4.5782 | 5.2984 | 5.2469 |
| 22 | | | 5.5556 | 5.3498 |
| 23 | | 4.6296 | 5.5556 | 5.1955 |
| 24 | 5.0926 | 3.3436 | 20.6276 | 5.607 |
| Max | 5.0926 | 5.3498 | 20.6276 | 6.9445 |
| Min | 5.0926 | 3.3436 | 5.0926 | 5.144 |
| Avg | 5.0926 | 4.4987 | 6.1579 | 5.8363 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 407 / 33 KV DYING & KNITTING

NON SHEDDABLE EXPRESS HV FEEDERS

EXPRESS Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 8.5391 | 6.7387 | 7.4589 | 7.356 |
| 2 | 8.7449 | | 7.6132 | |
| 3 | 8.5391 | 6.5844 | 7.5103 | 7.5103 |
| 4 | 8.4362 | 6.7901 | 7.4589 | 7.4589 |
| 5 | 8.3333 | 6.6873 | 7.5103 | 7.5617 |
| 6 | 8.4877 | 6.4815 | 7.7675 | 7.9218 |
| 7 | 8.2819 | 6.5844 | 8.179 | 7.9218 |
| 8 | 7.8704 | 7.6646 | 7.5103 | 8.0761 |
| 9 | 8.0761 | 8.2305 | 7.6646 | 7.8189 |
| 10 | 8.3333 | 8.8477 | 8.5905 | 9.0535 |
| 11 | 8.179 | 8.642 | 8.5905 | 9.0021 |
| 12 | 7.8704 | 8.7963 | 8.0247 | 8.8477 |
| 13 | 8.0247 | 8.5905 | 8.2305 | 8.642 |
| 14 | 8.0761 | 8.5391 | 8.7963 | 7.7161 |
| 15 | 8.4362 | 8.4362 | 8.3333 | 8.1276 |
| 16 | 7.1502 | 8.0247 | 7.5617 | 8.6934 |
| 17 | 7.2531 | 5.0412 | 7.7161 | 7.8189 |
| 18 | 7.1502 | 7.9218 | 7.8704 | 8.4877 |
| 19 | 6.8416 | 7.7675 | 7.356 | 8.179 |
| 20 | 6.8416 | 7.7675 | 7.4074 | 7.9218 |
| 21 | 7.0473 | 7.8704 | 7.5617 | 8.179 |
| 22 | 7.0988 | 8.4877 | 7.4589 | 7.9218 |
| 23 | 6.7387 | 8.2305 | 7.5617 | 7.356 |
| 24 | 8.642 | 6.5329 | 7.4589 | 7.4074 |
| Max | 8.7449 | 8.8477 | 8.7963 | 9.0535 |
| Min | 6.7387 | 5.0412 | 7.356 | 7.356 |
| Avg | 7.8747 | 7.6199 | 7.7997 | 8.0426 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 409 / 33 KV THALNER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINOUS PROCESS)(NO
STAGGERING)

| DATE | 01-MAR-18 | 03-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 8.8477 | | 6.4301 | 9.0535 |
| 2 | 8.8992 | 8.642 | 6.4301 | 9.1564 |
| 3 | 9.2078 | 8.8477 | 6.4301 | 9.1564 |
| 4 | 10.1852 | 9.6194 | 7.0473 | 9.3622 |
| 5 | 11.0597 | 10.4938 | 7.6646 | 9.9794 |
| 6 | 11.0082 | 10.9054 | 8.2305 | 10.6482 |
| 7 | 11.1111 | 10.9054 | 7.6646 | 10.4424 |
| 8 | 1.5947 | 1.5432 | 3.2407 | 10.2366 |
| 9 | 7.9218 | 8.8477 | 8.9506 | 1.749 |
| 10 | 8.7449 | 9.8251 | 9.3622 | 8.8477 |
| 11 | 8.9506 | 9.6708 | 9.0535 | 8.7963 |
| 12 | 8.9506 | 9.5165 | 9.1564 | 8.5905 |
| 13 | 7.5617 | 9.0535 | 9.1564 | 8.3333 |
| 14 | 8.8992 | 9.3622 | 9.0021 | 8.6934 |
| 15 | 9.105 | 9.7737 | 9.105 | 8.4362 |
| 16 | 9.5165 | 2.1091 | 8.5391 | 9.1564 |
| 17 | 1.749 | 7.1502 | 1.8004 | 8.4877 |
| 18 | 2.1091 | | 3.9095 | 1.4918 |
| 19 | 1.749 | .6687 | 4.0124 | 1.5947 |
| 20 | 1.6461 | 1.5947 | 3.6523 | 1.4918 |
| 21 | 1.5432 | 8.2305 | 3.8066 | 1.6461 |
| 22 | 8.8992 | 8.4877 | 8.9506 | 1.5432 |
| 23 | 7.7675 | 8.2305 | 3.858 | 4.5268 |
| 24 | 8.7963 | 8.6934 | 6.4301 | 9.0535 |
| Max | 11.1111 | 10.9054 | 9.3622 | 10.6482 |
| Min | 1.5432 | .6687 | 1.8004 | 1.4918 |
| Avg | 7.3260 | 7.8260 | 6.7451 | 7.1031 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 201 / 11 KV Main Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .9431 |
| 2 | | | .9259 |
| 3 | | | .8573 |
| 4 | | | .8573 |
| 5 | | | 1.1145 |
| 6 | | | 1.2003 |
| 7 | | | 1.2003 |
| 8 | | | 1.1145 |
| 9 | | 1.1145 | |
| 10 | | 1.1145 | |
| 11 | | 1.2003 | |
| 12 | | 1.2003 | |
| 13 | | 1.1145 | |
| 14 | | 1.1145 | |
| 15 | | 1.1145 | |
| 16 | | 1.2003 | |
| 17 | | 1.2003 | |
| 18 | | 1.2003 | |
| 19 | | 1.3717 | |
| 20 | | 1.3717 | |
| 21 | | 1.286 | |
| 22 | | 1.1145 | |
| 23 | | 1.0288 | |
| 24 | 1.6975 | | .9431 |
| Max | 1.6975 | 1.3717 | 1.2003 |
| Min | 1.6975 | 1.0288 | .8573 |
| Avg | 1.6975 | 1.1831 | 1.0174 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 202 / 11 kV Karwand naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .0857 | .1029 | .1029 | .1372 | .1029 | .1372 |
| 2 | .1029 | .0857 | .1029 | .1029 | .1372 | .1029 | .1372 |
| 3 | .1029 | .0857 | .1372 | .1029 | .1372 | .1372 | .1372 |
| 4 | .1372 | .1029 | .1372 | .1372 | .1029 | .1715 | .1372 |
| 5 | .1372 | .1029 | .1715 | .1372 | .1372 | .1715 | .1372 |
| 6 | .2229 | .1372 | .1715 | .1715 | .1715 | .2058 | .1372 |
| 7 | .3086 | .1715 | .2058 | .2058 | .2058 | .2058 | .2058 |
| 8 | .2058 | .1715 | .2058 | .2058 | .1715 | .2058 | .2058 |
| 9 | .1715 | .1715 | .2058 | .1715 | .2058 | .1715 | .1715 |
| 10 | .1715 | .1715 | .2058 | .1543 | .2058 | .1715 | .2058 |
| 11 | .1372 | .1715 | .1715 | .1372 | .2058 | .1372 | .2572 |
| 12 | .1372 | .1715 | .1715 | .1715 | .2058 | .1372 | .2915 |
| 13 | .0857 | .1715 | .1715 | .2058 | .2058 | .1372 | .2743 |
| 14 | .1715 | .1715 | .1715 | .1715 | .1715 | .1715 | .3086 |
| 15 | .1715 | .1715 | .1715 | .1543 | .1715 | .1715 | .2743 |
| 16 | .1715 | .1715 | .1715 | .1715 | .1715 | .1715 | .3086 |
| 17 | .1372 | .1715 | .1715 | .2058 | .2058 | .1372 | |
| 18 | .1372 | .1715 | .2058 | .2572 | .2058 | .1372 | .2401 |
| 19 | .1715 | .2058 | .2058 | .2401 | .2058 | .2058 | .3086 |
| 20 | .1372 | .2058 | .2058 | .1715 | .2058 | .2058 | .3086 |
| 21 | .1372 | .2058 | .2058 | .2058 | .2058 | .2401 | .2743 |
| 22 | .1029 | .2058 | .1715 | .1715 | .1715 | .2058 | .2058 |
| 23 | .1029 | .1715 | .1715 | .1715 | .1715 | .1715 | .2058 |
| 24 | .1372 | .0857 | .1372 | .1372 | .1372 | .1715 | .1372 |
| Max | .3086 | .2058 | .2058 | .2572 | .2058 | .2401 | .3086 |
| Min | .0857 | .0857 | .1029 | .1029 | .1029 | .1029 | .1372 |
| Avg | .1515 | .1558 | .1729 | .1694 | .1772 | .1686 | .2177 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 204 / CHANDPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6766 | 1.8861 | 1.8861 | 1.8861 | 1.89 | 1.7833 | 1.7204 |
| 2 | 1.829 | 1.8861 | 1.8861 | 1.9204 | 1.9509 | 1.8176 | 1.7204 |
| 3 | 1.829 | 1.8861 | 1.9547 | 2.0576 | 1.9509 | 1.8176 | 1.7204 |
| 4 | 1.8595 | 1.9719 | 2.0576 | 2.0919 | 1.9509 | 1.8519 | 1.8004 |
| 5 | 1.9509 | 2.0576 | 2.0919 | 2.1948 | 2.0119 | 1.8861 | 1.8023 |
| 6 | 2.0119 | 2.1434 | 2.2634 | 2.2634 | 2.1338 | 2.0233 | 1.9204 |
| 7 | 2.0729 | 2.4006 | 2.4006 | 2.4006 | 2.21 | 2.2634 | 2.0805 |
| 8 | 1.8595 | 2.4006 | 2.4348 | 2.4348 | 2.1948 | 2.2634 | 2.2672 |
| 9 | | | | 2.1338 | | | |
| 23 | 1.7147 | 1.8861 | 1.8861 | 1.6766 | 1.8861 | 1.5242 | 1.5699 |
| 24 | 2.4006 | 1.8861 | 1.8861 | 1.8861 | 1.7071 | 1.8861 | 1.6385 |
| Max | 2.4006 | 2.4006 | 2.4348 | 2.4348 | 2.21 | 2.2634 | 2.2672 |
| Min | 1.6766 | 1.8861 | 1.8861 | 1.6766 | 1.7071 | 1.5242 | 1.5699 |
| Avg | 1.9205 | 2.0405 | 2.0747 | 2.0860 | 1.9886 | 1.9117 | 1.8240 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 205 / TOWN COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0974 | 1.286 | 1.3717 | 1.3717 | 1.406 | 1.3717 | 1.4575 |
| 2 | 1.0631 | 1.2346 | 1.3375 | 1.3717 | 1.3375 | 1.3717 | 1.3889 |
| 3 | 1.0631 | 1.2346 | 1.3375 | 1.3717 | 1.3375 | 1.406 | 1.3375 |
| 4 | 1.2003 | 1.3375 | 1.4403 | 1.406 | 1.3717 | 1.4746 | 1.3375 |
| 5 | 1.3375 | 1.5089 | 1.5432 | 1.406 | 1.406 | 1.5775 | 1.4403 |
| 6 | 1.5775 | 1.6289 | 1.6461 | 1.5089 | 1.6804 | 1.7147 | 1.7147 |
| 7 | 1.7147 | 1.8004 | 1.6118 | 1.7147 | 1.7833 | 1.8861 | 1.869 |
| 8 | 1.749 | 1.8004 | 1.6804 | 1.5775 | 1.749 | 1.7833 | 1.7147 |
| 9 | 1.6289 | 1.6289 | 1.6118 | 1.5432 | 1.7147 | 1.5432 | 1.6289 |
| 10 | 1.5432 | 1.4746 | 1.5432 | 1.5089 | 1.4403 | 1.4746 | 1.5775 |
| 11 | 1.4575 | 1.4746 | 1.4746 | 1.5089 | 1.4403 | 1.4575 | 1.5432 |
| 12 | 1.4575 | 1.5089 | 1.4403 | 1.406 | 1.406 | 1.4403 | 1.4746 |
| 13 | 1.286 | 1.5089 | 1.406 | 1.4403 | 1.406 | 1.4575 | 1.5775 |
| 14 | 1.4575 | 1.406 | 1.4403 | 1.3375 | 1.5432 | 1.4918 | 1.5432 |
| 15 | 1.4575 | 1.3717 | 1.5089 | 1.3717 | 1.5432 | 1.4575 | 1.4746 |
| 16 | 1.4575 | 1.3375 | 1.5089 | 1.3717 | 1.406 | 1.4746 | 1.4403 |
| 17 | 1.4575 | 1.4746 | 1.4746 | 1.5089 | 1.4403 | 1.5261 | 1.5089 |
| 18 | 1.3717 | 1.3717 | 1.5432 | 1.406 | 1.5432 | 1.406 | 1.5775 |
| 19 | 1.6289 | 1.6804 | 1.6118 | 1.5432 | 1.6461 | 1.7147 | 1.7147 |
| 20 | 1.6289 | 1.6804 | 1.5432 | 1.5775 | 1.6804 | 1.6975 | 1.7833 |
| 21 | 1.6289 | 1.6461 | 1.4403 | 1.6804 | 1.6804 | 1.6804 | 1.749 |
| 22 | 1.6289 | 1.5775 | 1.4403 | 1.6118 | 1.6804 | 1.8004 | 1.6461 |
| 23 | 1.5432 | 1.5432 | 1.4403 | 1.5775 | 1.5775 | 1.6632 | 1.5775 |
| 24 | 1.406 | 1.406 | 1.4403 | 1.4403 | 1.5089 | 1.406 | 1.5604 |
| Max | 1.749 | 1.8004 | 1.6804 | 1.7147 | 1.7833 | 1.8861 | 1.869 |
| Min | 1.0631 | 1.2346 | 1.3375 | 1.3375 | 1.3375 | 1.3717 | 1.3375 |
| Avg | 1.4518 | 1.4968 | 1.4932 | 1.4818 | 1.5303 | 1.5532 | 1.5682 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 206 / 11 KV CHANDPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3086 | .2058 | .2401 | .2058 | .3086 | .2401 | .3086 |
| 2 | .3086 | .2058 | .2058 | .2058 | .2743 | .2401 | .3086 |
| 3 | .3086 | .2058 | .2058 | .2401 | .2743 | .3086 | .2915 |
| 4 | .3086 | .2058 | .3086 | .3086 | .3086 | .3772 | .3429 |
| 5 | .4115 | .2572 | .4115 | .4115 | .3772 | .4801 | .3772 |
| 6 | .5144 | .4287 | .5144 | .5487 | .4801 | .5487 | .5144 |
| 7 | .5487 | .4801 | .5487 | .5487 | .5144 | .5144 | .583 |
| 8 | .4801 | .4287 | .4115 | .4801 | .4801 | .4801 | .4287 |
| 9 | .4287 | .3429 | .4115 | .4115 | .4115 | .3429 | .3429 |
| 10 | .3429 | .2401 | .3429 | .3772 | .2743 | .3086 | .3772 |
| 11 | | .2401 | .3086 | .3429 | .2743 | .3429 | .3429 |
| 12 | | .2401 | .3086 | .3086 | .2743 | .2743 | .3429 |
| 13 | .3429 | .2401 | .2401 | .3086 | .2401 | .3086 | .3429 |
| 14 | .3429 | .2058 | .2401 | .3429 | .2743 | .3429 | .3086 |
| 15 | .3086 | .2058 | .2401 | .3429 | .2743 | .3086 | .3086 |
| 16 | .3086 | .2058 | .2401 | .3429 | .2743 | .3086 | .3086 |
| 17 | .3086 | .2401 | .2401 | .3429 | .2743 | .3086 | .3772 |
| 18 | .3772 | .2401 | .3429 | .4115 | .3429 | .3429 | .4115 |
| 19 | .3772 | | .3772 | .4458 | .3772 | .4115 | .4458 |
| 20 | .3429 | .3772 | .3429 | .4115 | .3772 | .3429 | .4458 |
| 21 | .3086 | .3429 | .3086 | .4115 | .3429 | .3772 | .3772 |
| 22 | .2572 | .3086 | .2401 | .3429 | .3086 | .3429 | .3772 |
| 23 | .2572 | .3086 | .2058 | .3429 | .2743 | .3429 | .3772 |
| 24 | .3086 | .2572 | .2401 | .2058 | .3429 | .2743 | .3429 |
| Max | .5487 | .4801 | .5487 | .5487 | .5144 | .5487 | .583 |
| Min | .2572 | .2058 | .2058 | .2058 | .2401 | .2401 | .2915 |
| Avg | .3546 | .2788 | .3115 | .3601 | .3315 | .3529 | .3743 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 207 / 11 KV Express Feeder PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 2 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 3 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 4 | .0857 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 5 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| 6 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 7 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 8 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 9 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 10 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 11 | .0343 | .0343 | .0171 | .0343 | .0343 | .0343 | .0343 |
| 12 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 13 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 14 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 15 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 16 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 17 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 18 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 19 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 20 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 21 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 22 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 | .0343 |
| 23 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| 24 | .9774 | .0343 | .0343 | .0343 | .0343 | .0343 | .0171 |
| Max | .9774 | .0343 | .0343 | .0343 | .0343 | .0343 | .0343 |
| Min | .0343 | .0343 | .0171 | .0343 | .0343 | .0171 | .0171 |
| Avg | .0757 | .0343 | .0336 | .0343 | .0343 | .0336 | .03 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 208 / 11 KV YOGESHWAR COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .1029 | .1029 | .0857 | .1372 | .1029 | .1372 |
| 2 | .1029 | .1029 | .1029 | .0857 | .1029 | .1029 | .12 |
| 3 | .1029 | .1029 | .1029 | .0857 | .1029 | .1372 | .12 |
| 4 | .1372 | .1372 | .1029 | .1029 | .1372 | .1372 | .1372 |
| 5 | .1715 | .2058 | .1372 | .1029 | .1715 | .1715 | .1372 |
| 6 | .2058 | .2572 | .1372 | .1372 | .2058 | .2058 | .1715 |
| 7 | .2401 | .2572 | .1715 | .2058 | .2572 | .2401 | .2915 |
| 8 | .2743 | .2743 | .2401 | .2058 | .2743 | .2401 | .2915 |
| 9 | .2743 | .2743 | .2401 | .2743 | .2743 | .2401 | .2915 |
| 10 | .2572 | .2743 | .2401 | .2743 | .2401 | .2401 | .2743 |
| 11 | .2572 | .2401 | .2058 | .2401 | .2058 | .2058 | .2401 |
| 12 | .2058 | .2401 | .2058 | .2058 | .1715 | .1715 | .2572 |
| 13 | .1372 | .2058 | .2058 | .2058 | .1372 | .1372 | .2058 |
| 14 | .1372 | .2058 | .2058 | .2058 | .1372 | .1372 | .2058 |
| 15 | .1372 | .1715 | .1715 | .2058 | .1372 | .1715 | .1715 |
| 16 | .1715 | .1715 | .1372 | .1715 | .1372 | .1715 | .1715 |
| 17 | .1715 | .2058 | .1372 | .2058 | .1372 | .1543 | .1715 |
| 18 | .2058 | .2058 | .1715 | .2058 | .1715 | .1886 | .2058 |
| 19 | .2572 | .2401 | .2058 | .2058 | .2401 | .2229 | .2401 |
| 20 | .1715 | .2401 | .2058 | .2401 | .2401 | .2229 | .2743 |
| 21 | .1715 | .2058 | .1715 | .2401 | .2058 | .1715 | .2401 |
| 22 | .1372 | .2058 | .1715 | .2058 | .1715 | .1543 | .2058 |
| 23 | .1372 | .2058 | .1715 | .1715 | .1372 | .1543 | .1715 |
| 24 | .1715 | .1029 | .1715 | .1372 | .1715 | .1029 | .1372 |
| Max | .2743 | .2743 | .2401 | .2743 | .2743 | .2401 | .2915 |
| Min | .1029 | .1029 | .1029 | .0857 | .1029 | .1029 | .12 |
| Avg | .1822 | .2015 | .1715 | .1836 | .1794 | .1743 | .2029 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 201 / VARUL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | 2.4006 |
| Max | 2.4006 |
| Min | 2.4006 |
| Avg | 2.4006 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 202 / JALOD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 11 | 2.3739 |
| 24 | 3.0864 |
| Max | 3.0864 |
| Min | 2.3739 |
| Avg | 2.7302 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 203 / TEKWADE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 | 05-MAR-18 | 06-MAR-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.6673 | 2.8578 |
| 2 | | 2.6673 | 2.8578 |
| 3 | | 2.6673 | 2.8578 |
| 4 | | 2.6673 | 2.8578 |
| 5 | | 2.6673 | 2.6673 |
| 6 | | 2.6673 | 2.6673 |
| 7 | | 2.572 | 2.6673 |
| 8 | | 2.4768 | 2.6673 |
| 24 | 2.0576 | 2.6673 | 2.6673 |
| Max | 2.0576 | 2.6673 | 2.8578 |
| Min | 2.0576 | 2.4768 | 2.6673 |
| Avg | 2.0576 | 2.6355 | 2.7520 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 204 / BHAMPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | 2.0576 |
| 24 | 2.0576 |
| Max | 2.0576 |
| Min | 2.0576 |
| Avg | 2.0576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 207 / 11 KV ABHANPURA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 11 | 3.0864 |
| Max | 3.0864 |
| Min | 3.0864 |
| Avg | 3.0864 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 201 / ARTHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.7532 | 1.869 | 1.174 | | 1.6804 |
| 2 | | 1.7695 | 1.8347 | 1.174 | | 1.6804 |
| 3 | | 1.749 | 1.8347 | 1.2492 | | 1.6975 |
| 4 | | 1.8023 | | 1.2793 | | 1.6289 |
| 5 | | 1.7394 | 1.8861 | 1.3094 | | 1.5947 |
| 6 | | 1.8138 | 1.8861 | 1.4449 | | 1.6289 |
| 7 | | 1.7924 | 1.9204 | 1.5804 | | 1.7147 |
| 8 | | 1.8679 | 1.9719 | 1.6707 | | 1.8004 |
| 23 | | 1.7318 | 1.5503 | | 1.5947 | 1.3998 |
| 24 | 2.0576 | 1.7328 | 1.7661 | 1.6255 | | 1.5947 |
| Max | 2.0576 | 1.8679 | 1.9719 | 1.6707 | 1.5947 | 1.8004 |
| Min | 2.0576 | 1.7318 | 1.5503 | 1.174 | 1.5947 | 1.3998 |
| Avg | 2.0576 | 1.7752 | 1.8355 | 1.3897 | 1.5947 | 1.6420 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 203 / VIKHRAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | .4902 | .583 | .4085 | .5735 | .5487 | .4085 |
| 11 | .5376 | .583 | .434 | .583 | .5658 | .434 |
| 12 | .5693 | .5658 | .4595 | .5921 | .5487 | .4595 |
| 13 | .5898 | .5487 | .4468 | .5898 | .5658 | .4723 |
| 14 | .5506 | .5487 | .4468 | .5571 | .5658 | .4595 |
| 15 | .5376 | .5144 | .434 | .5344 | .5658 | .434 |
| 16 | .5218 | .5658 | .4212 | .5182 | .5658 | .4085 |
| 17 | .5571 | .6001 | .4468 | .506 | .5658 | .3829 |
| Max | .5898 | .6001 | .4595 | .5921 | .5658 | .4723 |
| Min | .4902 | .5144 | .4085 | .506 | .5487 | .3829 |
| Avg | .5443 | .5637 | .4372 | .5568 | .5615 | .4324 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 204 / ARTHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .6859 |
| Max | .6859 |
| Min | .6859 |
| Avg | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 205 / BHARAWADE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .6859 |
| Max | .6859 |
| Min | .6859 |
| Avg | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 206 / 11 KV VIKHRAN GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 24 | .5144 |
| Max | .5144 |
| Min | .5144 |
| Avg | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 208 / ARTHE-WAGHADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-MAR-18 |
|------|-----------|
| HR | Load (MW) |
| 12 | 2.0576 |
| Max | 2.0576 |
| Min | 2.0576 |
| Avg | 2.0576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 201 / 11 KV Wadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2915 | .2915 | .3224 | .3086 | .3361 | .2865 | .2915 |
| 2 | .2915 | .2915 | .3224 | .3086 | .3142 | .2865 | .2915 |
| 3 | .3086 | .3086 | .3403 | .3086 | .3361 | .3045 | .3086 |
| 4 | .3429 | .3086 | .3801 | .3429 | .3734 | .3439 | .3429 |
| 5 | .4115 | .3772 | .4572 | .4458 | .4527 | .4435 | .4115 |
| 6 | .4458 | .5144 | .5601 | .5144 | .5281 | .5601 | .4801 |
| 7 | .4973 | .4801 | .5658 | .5316 | .5658 | .5658 | .4458 |
| 8 | .4115 | .4115 | .4755 | .4287 | .5415 | .4668 | .3772 |
| 9 | .3772 | .3601 | .4024 | .3772 | .4066 | .3292 | .3601 |
| 10 | .3086 | .3429 | .3429 | .3734 | .3734 | .3077 | .3086 |
| 11 | .2915 | .3582 | .2915 | .3174 | .3258 | .2743 | .2743 |
| 12 | .2915 | .3224 | .2915 | .2987 | .3045 | .2743 | .2915 |
| 13 | .2743 | .3224 | .3086 | | .3045 | .2743 | .2743 |
| 14 | .2743 | .3189 | .2915 | .2987 | .3012 | .2915 | |
| 15 | | .3403 | .3086 | .3142 | .3224 | .2915 | |
| 16 | .2743 | .362 | .3086 | .3292 | .3258 | .2743 | .3258 |
| 17 | .2915 | .362 | .3429 | .3326 | .362 | .2743 | .3429 |
| 18 | .3772 | .4207 | .3944 | .3841 | .4344 | .3258 | .4115 |
| 19 | .4801 | .5228 | .463 | .5359 | .5228 | .4458 | .463 |
| 20 | .4115 | .4854 | .4115 | .5041 | .4668 | .4801 | .4287 |
| 21 | .3772 | .4435 | .3772 | .4715 | .3841 | .3772 | .3772 |
| 22 | .3601 | .4024 | | .415 | .3658 | .3429 | .3601 |
| 23 | .3429 | .3801 | .3429 | .3734 | .3475 | .3258 | .3086 |
| 24 | .3086 | .3258 | .362 | .3258 | .3547 | .3077 | .2915 |
| Max | .4973 | .5228 | .5658 | .5359 | .5658 | .5658 | .4801 |
| Min | .2743 | .2915 | .2915 | .2987 | .3012 | .2743 | .2743 |
| Avg | .3496 | .3772 | .3767 | .3844 | .3896 | .3523 | .3531 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094056 / 33/11 KV FILTRATION PLANT

SHIR

Feeder No / Name : 203 / 11 KV K.G. ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.286 | | 1.2346 | 1.2003 | 1.286 | 1.3717 | |
| 2 | 1.286 | 1.0669 | 1.2689 | 1.2346 | 1.286 | 1.3375 | 1.2955 |
| 3 | 1.2689 | | 1.286 | 1.286 | 1.3032 | 1.3717 | |
| 4 | 1.3203 | 1.0669 | 1.3546 | 1.3203 | 1.3546 | 1.4232 | 1.3717 |
| 5 | 1.3375 | | 1.3717 | 1.3717 | 1.4232 | 1.5089 | |
| 6 | 1.5947 | 1.2193 | 1.4403 | 1.4575 | 1.5432 | 1.5432 | 1.3717 |
| 7 | 1.6118 | 1.3717 | 1.5775 | 1.5775 | 1.6632 | | 1.448 |
| 8 | 1.3717 | 1.5261 | 1.5261 | 1.5261 | 1.5432 | 1.3717 | 1.5432 |
| 9 | | 1.3546 | 1.4575 | 1.3889 | 1.4918 | | 1.4232 |
| 10 | 1.2955 | 1.286 | 1.3717 | 1.3717 | 1.3546 | 1.2955 | 1.5432 |
| 11 | | 1.3375 | .0857 | 1.3717 | 1.4232 | | 1.3717 |
| 12 | 1.3717 | 1.2346 | .1372 | 1.3375 | 1.406 | 1.2193 | 1.3375 |
| 13 | | 1.3032 | .0857 | 1.3375 | 1.3717 | | 1.3717 |
| 14 | 1.2955 | 1.3375 | 1.1831 | 1.3032 | 1.4575 | 1.2955 | 1.4575 |
| 15 | | 1.2346 | 1.286 | 1.3717 | 1.5432 | | 1.5089 |
| 16 | 1.2955 | 1.286 | 1.4575 | 1.4403 | 1.4918 | 1.3717 | 1.6118 |
| 17 | | 1.3375 | 1.6632 | 1.4918 | 1.4403 | | 1.5432 |
| 18 | 1.2193 | 1.3889 | 1.4575 | 1.5432 | 1.406 | 1.3717 | 1.5089 |
| 19 | | 1.5432 | 1.6289 | 1.5432 | 1.5432 | | 1.7147 |
| 20 | 1.3717 | 1.6975 | 1.8347 | 1.6975 | 1.6804 | 1.6766 | 1.8004 |
| 21 | | 1.7318 | 1.6975 | 1.6289 | 1.7147 | | 1.6975 |
| 22 | 1.3717 | 1.6118 | 1.6289 | 1.5432 | 1.6289 | 1.5242 | 1.6118 |
| 23 | | 1.4746 | 1.4575 | 1.4232 | 1.5432 | | 1.5089 |
| 24 | 1.3546 | 1.2193 | 1.2003 | 1.3717 | 1.3717 | 1.4575 | 1.3717 |
| Max | 1.6118 | 1.7318 | 1.8347 | 1.6975 | 1.7147 | 1.6766 | 1.8004 |
| Min | 1.2193 | 1.0669 | .0857 | 1.2003 | 1.286 | 1.2193 | 1.2955 |
| Avg | 1.3533 | 1.3633 | 1.2789 | 1.4225 | 1.4696 | 1.4093 | 1.4958 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094056 / 33/11 KV FILTRATION PLANT

SHIR

Feeder No / Name : 204 / 11 KV VIDYAVIHAR COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1715 | | .1372 | .1372 | .1372 | .1886 | |
| 2 | .1372 | .0914 | .1372 | .12 | .12 | .1543 | .1067 |
| 3 | .1372 | | .1372 | .12 | .12 | .1543 | |
| 4 | .1372 | .0914 | .1372 | .12 | .1372 | .1372 | .1219 |
| 5 | .1372 | | .1543 | .1372 | .1543 | .1372 | |
| 6 | .1715 | .1067 | .1715 | .1543 | .1886 | .1372 | .1524 |
| 7 | .1715 | .1219 | .1715 | .1715 | .2058 | .1715 | .1524 |
| 8 | .1524 | .1372 | .1372 | .1543 | .1715 | .1372 | .1543 |
| 9 | | .1372 | .12 | .1543 | .1372 | .1219 | .1372 |
| 10 | .1219 | .1029 | .1029 | .12 | .12 | .1219 | .12 |
| 11 | | .1029 | .1029 | .1372 | .0857 | | .1029 |
| 12 | .1067 | .12 | .1029 | .1372 | .1029 | .0914 | .1029 |
| 13 | | .1372 | .1029 | .12 | .1029 | | .1029 |
| 14 | .1219 | .1372 | .1029 | .1372 | .1029 | .0914 | .1029 |
| 15 | | .1029 | .1029 | .12 | .12 | | .1029 |
| 16 | .1067 | .1372 | .12 | .12 | .12 | .1067 | .1029 |
| 17 | | .1372 | .1029 | .1372 | .1029 | | .1029 |
| 18 | .0914 | .1372 | .12 | .1372 | .1372 | .1219 | .12 |
| 19 | | .1543 | .1543 | .1543 | .1543 | | .1715 |
| 20 | .1372 | .1715 | .1715 | .1715 | .1715 | .1524 | .1886 |
| 21 | | .1715 | .1715 | .1886 | .1715 | | .1886 |
| 22 | .1677 | .1886 | .1715 | .1886 | .1715 | .1829 | .2058 |
| 23 | | .1886 | .1886 | .1886 | .2058 | | .2058 |
| 24 | .1715 | .1524 | .1715 | .1715 | .1715 | .1886 | .1219 |
| Max | .1715 | .1886 | .1886 | .1886 | .2058 | .1886 | .2058 |
| Min | .0914 | .0914 | .1029 | .12 | .0857 | .0914 | .1029 |
| Avg | .1400 | .1346 | .1372 | .1457 | .1422 | .1410 | .1365 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 201 / 11 KV Vikharan-Mukhed

GAOTHAN FEEDER

Gavthan Feeder KV- 11 /

OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .2172 | .1886 | .1715 | .2172 | .1991 | .2172 |
| 2 | .1715 | .2534 | .1886 | .1886 | .2172 | .2172 | .2534 |
| 3 | .2058 | .2534 | .1886 | .2058 | .2353 | .2534 | .2534 |
| 4 | .2743 | .2896 | .2401 | .2058 | .2534 | .2534 | .3258 |
| 5 | .3086 | .3258 | .3258 | .3086 | .3439 | .362 | .362 |
| 6 | .3258 | | .3258 | .3086 | | | |
| 9 | .1715 | .2353 | .1715 | | .1629 | .2172 | .181 |
| 10 | .181 | .1715 | .1715 | .181 | .1448 | .1629 | .1629 |
| 11 | .181 | .1543 | .1715 | .181 | .1448 | .1448 | .1629 |
| 12 | .1991 | | .1715 | .181 | .1448 | .1629 | .1629 |
| 13 | .1991 | | .1715 | .181 | .1448 | .181 | .1629 |
| 14 | .1991 | .1715 | .1372 | .181 | .1448 | .181 | .1629 |
| 15 | .1991 | .1886 | .1715 | .181 | .1448 | .1991 | .1629 |
| 16 | .181 | .1886 | .1543 | .1629 | .1448 | .1991 | .1629 |
| 17 | .1991 | .1715 | .1715 | | .1448 | .1991 | .1448 |
| 18 | .181 | .1886 | .1715 | | .1448 | .2534 | .1991 |
| 19 | .1991 | .2572 | .2058 | .2896 | .181 | .2715 | .2715 |
| 20 | .2172 | .2572 | .2229 | .2715 | .1991 | .2896 | .2715 |
| 21 | .2172 | .2572 | .2401 | .2715 | .2353 | .2896 | .2715 |
| 22 | .2353 | .2058 | .2229 | .2172 | .2172 | .2172 | .2172 |
| 23 | .181 | .1886 | .2058 | .1991 | .2353 | .1991 | .1991 |
| 24 | .1715 | .1629 | .1543 | .1715 | .1991 | .1991 | .181 |
| Max | .3258 | .3258 | .3258 | .3086 | .3439 | .362 | .362 |
| Min | .1715 | .1543 | .1372 | .1629 | .1448 | .1448 | .1448 |
| Avg | .2085 | .2178 | .1988 | .2136 | .1905 | .2215 | .2138 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 202 / 11 KV Ukhalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | | 1.8623 | 1.917 | 1.8515 | 1.917 | 1.8515 |
| 11 | 1.9826 | 1.9271 | 1.8515 | 1.8842 | 1.9989 | 1.9006 |
| 12 | 1.9989 | 1.9433 | 1.9989 | 1.917 | 1.9826 | 1.9662 |
| 13 | 2.0481 | 1.9433 | 1.9989 | 1.9006 | 1.9498 | 1.9826 |
| 14 | 2.0153 | 1.9595 | 2.0153 | 1.917 | 1.9498 | 1.9334 |
| 15 | 1.9826 | 1.9757 | 1.9662 | 1.9334 | 1.8842 | 1.9334 |
| 16 | 2.0153 | 1.9757 | 1.9989 | 1.9334 | 1.9826 | 1.9498 |
| 17 | 2.0153 | 1.9595 | 1.9334 | 1.9006 | 1.9334 | 1.9334 |
| 18 | | 2.0243 | 1.9006 | | | |
| Max | 2.0481 | 2.0243 | 2.0153 | 1.9334 | 1.9989 | 1.9826 |
| Min | 1.9826 | 1.8623 | 1.8515 | 1.8515 | 1.8842 | 1.8515 |
| Avg | 2.0083 | 1.9523 | 1.9534 | 1.9047 | 1.9498 | 1.9314 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 203 / 11 KV Mukhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-MAR-18 | 02-MAR-18 | 03-MAR-18 | 04-MAR-18 | 05-MAR-18 | 06-MAR-18 | 07-MAR-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9433 | 1.8351 | 1.8138 | 1.749 | 1.8023 | 1.8023 | 1.8023 |
| 2 | 1.9433 | 1.8351 | 1.8299 | 1.7814 | 1.8679 | 1.8023 | 1.8187 |
| 3 | 2.0243 | 1.8515 | 1.8461 | 1.7976 | 1.8023 | 1.8515 | 1.8187 |
| 4 | 2.0243 | 1.9006 | 1.6518 | 1.7814 | 1.7859 | 1.8679 | 1.8351 |
| 5 | 2.1052 | 1.9006 | 1.7814 | 1.7814 | 1.7532 | 1.9006 | 1.8351 |
| 6 | 2.1376 | 1.8679 | 1.7814 | 1.7814 | 1.8023 | 1.917 | 1.9498 |
| 7 | 2.1052 | 1.9989 | 1.8623 | 1.9271 | 1.9498 | 1.917 | 1.9989 |
| 8 | 2.1052 | 1.8515 | 1.9433 | 1.9757 | 1.9989 | 1.917 | 1.9334 |
| 9 | 2.1862 | | 2.0243 | 2.0243 | | | |
| 23 | 1.8023 | 1.7814 | 1.7976 | 1.6549 | 1.6876 | 1.8187 | 1.6712 |
| 24 | 1.8623 | 1.8187 | 1.7814 | 1.7976 | 1.7368 | 1.8023 | 1.8187 |
| Max | 2.1862 | 1.9989 | 2.0243 | 2.0243 | 1.9989 | 1.917 | 1.9989 |
| Min | 1.8023 | 1.7814 | 1.6518 | 1.6549 | 1.6876 | 1.8023 | 1.6712 |
| Avg | 2.0217 | 1.8641 | 1.8285 | 1.8229 | 1.8187 | 1.8597 | 1.8482 |