

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 201 / Pawala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.0693	3.3573	2.1658	2.2405	2.1845	2.2405	2.0883
16		1.9022	3.2023	3.2156	3.0178	2.8147	2.9334
24	2.9334	2.9334	2.2779	2.3525	2.2779	2.3525	2.2405
Max	3.0693	3.3573	3.2023	3.2156	3.0178	2.8147	2.9334
Min	2.9334	1.9022	2.1658	2.2405	2.1845	2.2405	2.0883
Avg	3.0014	2.7310	2.5487	2.6029	2.4934	2.4692	2.4207

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 202 / Vyhur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.3137	2.3922					1.6991
16			2.1792	2.0165	2.2466	2.2801	2.0719
24	2.1548	1.989	1.6991	1.6991	1.6804	1.6991	1.6804
Max	2.3137	2.3922	2.1792	2.0165	2.2466	2.2801	2.0719
Min	2.1548	1.989	1.6991	1.6991	1.6804	1.6991	1.6804
Avg	2.2343	2.1906	1.9392	1.8578	1.9635	1.9896	1.8171

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334012 / KOTHALI

Feeder No / Name : 203 / Wadzakan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2125	1.1142	3.2047	3.3981	3.2579	3.1036	.9619
16	3.1893	1.7635	.9646	.9555	1.0688	.9442	1.0814
24	1.3599	1.291	2.4348	3.1901	3.0514	3.1554	3.034
Max	3.1893	1.7635	3.2047	3.3981	3.2579	3.1554	3.034
Min	1.2125	1.1142	.9646	.9555	1.0688	.9442	.9619
Avg	1.9206	1.3896	2.2014	2.5146	2.4594	2.4011	1.6924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 201 / THANEPADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.7128	2.0039	1.8669	1.5415
12	2.3122	2.2266				
16	2.1238	2.0896				
24				1.473	1.3702	1.3531
Max	2.3122	2.2266	1.7128	2.0039	1.8669	1.5415
Min	2.1238	2.0896	1.7128	1.473	1.3702	1.3531
Avg	2.218	2.1581	1.7128	1.7385	1.6186	1.4473

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 202 / Sutarpada AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1367	.8906	1.1647	1.0277	.9934
12	1.4387	1.336				
16	1.2846	1.1304				
24				.9249	.9078	.9934
Max	1.4387	1.336	.8906	1.1647	1.0277	.9934
Min	1.2846	.1367	.8906	.9249	.9078	.9934
Avg	1.3617	.8677	.8906	1.0448	.9678	.9934

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 203 / Nandarkheda AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			2.3636	2.1924	2.2095	2.3122
12	2.7062	2.1924				
16	2.5007	2.9117				
24				1.3702	1.4045	1.4216
Max	2.7062	2.9117	2.3636	2.1924	2.2095	2.3122
Min	2.5007	2.1924	2.3636	1.3702	1.4045	1.4216
Avg	2.6035	2.5521	2.3636	1.7813	1.807	1.8669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 204 / Ashta Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3658	.3109		.3841	.3658	.3841
12	.1097	.128	.0905	.128	.128	.1463	.128
16	.128	.128	.128	.1463	.128	.1463	
20	.2378	.2743		.2378	.2561	.2743	
24		.128	.128		.128	.1463	.1646
Max	.2378	.3658	.3109	.2378	.3841	.3658	.3841
Min	.1097	.128	.0905	.128	.128	.1463	.128
Avg	.1585	.2048	.1644	.1707	.2048	.2158	.2256

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 205 / Sutarpada Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2926		.2926	.3292	.2378
12	.2012	.1646	.1254	.1463	.128	.128	.1646
16	.2012	.2378	.1448	.1646	.128	.1097	
20	.3109	.2926		.2926	.3109	.3109	
24			.1463		.1646	.1829	.1646
Max	.3109	.2926	.2926	.2926	.3109	.3292	.2378
Min	.2012	.1646	.1254	.1463	.128	.1097	.1646
Avg	.2378	.2317	.1773	.2012	.2048	.2121	.189



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 206 / Shrirampur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.5304	.5121		.5487	.5121	.4938
12	.2561	.2378	.2172	.2743	.2743	.2926	.2743
16	.3658	.3475	.2835	.3475	.2743	.3292	
20	.567	.567		.5853	.6584	.6219	
24		.3292	.3292		.439	.4024	.4024
Max	.567	.567	.5121	.5853	.6584	.6219	.4938
Min	.2561	.2378	.2172	.2743	.2743	.2926	.2743
Avg	.3963	.4024	.3355	.4024	.4389	.4316	.3902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 207 / 11 KV Waghale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.2266					
12		2.8807	2.7404	2.8775	2.3979	2.4664
16		2.359	2.4321	2.5692	2.141	
20	.1367					
24	1.6443					
Max	2.2266	2.8807	2.7404	2.8775	2.3979	2.4664
Min	.1367	2.359	2.4321	2.5692	2.141	2.4664
Avg	1.3359	2.6199	2.5863	2.7234	2.2695	2.4664

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 208 / NDBR Muncipal Water supply

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0366	.0366		.0366	.0366	.0366
12	.0366	.0183		.0366	.0366	.0366	.0366
16	.0366	.0183	.0381	.0366	.0183	.0183	
20	.0549	.0549			.0549	.0549	
24		.0183	.0183		.0183	.0183	.0366
Max	.0549	.0549	.0381	.0366	.0549	.0549	.0366
Min	.0366	.0183	.0183	.0366	.0183	.0183	.0366
Avg	.0427	.0293	.031	.0366	.0329	.0329	.0366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334027 / ASHTE

Feeder No / Name : 209 / Bandharpada Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.3979					
12		2.8807	3.3399	2.9117	2.946	3.2373
16		2.7041	2.9117	2.809	2.8603	
24	1.2503					
Max	2.3979	2.8807	3.3399	2.9117	2.946	3.2373
Min	1.2503	2.7041	2.9117	2.809	2.8603	3.2373
Avg	1.8241	2.7924	3.1258	2.8604	2.9032	3.2373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 201 / Pachorabari Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6676	.9214	1.07	1.0669	.9214
2			.6676	.9214	1.07	1.0402	.8977
3			.6954	.9267	1.07	1.0235	.8688
4			.7093	.9145	1.1584	.9145	.7895
5			.7232	.9145	1.2193	.9145	.7895
6			.7895	1.0288		.9976	.9023
7			.8688	1.2483		1.1888	1.1431
8			.8688	1.1294	.9145	1.0562	1.086
9	1.0364	1.0837					
10	1.4373	1.2498					
11	1.3283	1.2346					
12	1.1873	1.2193					
13	1.0974	1.1888					
14	1.0837	1.1294					
15	1.0837	1.1888					
16	1.1294	1.2003					
23			.9511	1.0974	1.0364	.8916	
24			.612	.9511	1.0974	1.0974	.8916
Max	1.4373	1.2498	.9511	1.2483	1.2193	1.1888	1.1431
Min	1.0364	1.0837	.612	.9145	.9145	.8916	.7895
Avg	1.1729	1.1868	.7553	1.0054	1.0795	1.0191	.9211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 202 / Lonkheda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9457	1.086	1.1873	1.1888	1.278
2			.9457	1.086	1.1873	1.174	1.2631
3			.9736	1.1003	1.2498	1.2041	1.1873
4			1.001	1.1265	1.2654	1.2029	1.1873
5			1.0574	1.1523	1.3413	1.2763	1.1873
6			1.1728	1.3535	1.7177	1.5202	1.3432
7			1.3112	1.5901	1.5242	1.6556	1.4129
8			1.3466	1.5455	1.4327	1.4861	1.3032
9	1.643	1.382					
10	1.8576	1.8747					
11	1.7833	1.9134					
12	1.7869	1.8903					
13	1.6156	1.7535					
14	1.5851	1.5927					
15	1.6049	1.5718					
16	1.5649	1.5861					
23			1.1888	1.2346		1.2631	
24			.9318	1.1149	1.2193	1.3735	1.2929
Max	1.8576	1.9134	1.3466	1.5901	1.7177	1.6556	1.4129
Min	1.5649	1.382	.9318	1.086	1.1873	1.174	1.1873
Avg	1.6802	1.6956	1.0875	1.2390	1.3472	1.3345	1.2728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 203 / Jamboli single phase SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
20	1.1016
21	1.251
22	1.5655
23	1.5384
Max	1.5655
Min	1.1016
Avg	1.3641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 204 / Nalve Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.5041	.4251	.4435	.4854	.4805	.462
2	.4668	.5041	.4251	.4435	.5228	.5175	.5175
3	.5228	.5601	.5041	.5175	.5601	.5729	.5914
4	.6535	.6722	.5788	.5914	.6348	.6099	.6283
5	.8029	.8029	.7282	.6468	.7468	.7023	.7023
6	.9709	.9335	.8962	.7842	.8215	.8215	.7947
7	.9709	.9896	.8316	.6468	.8215	.8131	.6401
8	.6722	.7207	.567	.5121	.7316	.6468	.6584
9	.4024	.567	.5359	.5853	.5121	.5487	.5853
10	.2715	.4344	.462	.5359	.4481	.4435	
11	.3982	.3403	.4024	.4805	.439	.4435	.439
12	.394	.2865	.4572	.439	.4435	.4066	.439
13	.3224	.3761	.439	.4525	.4066	.4066	.4066
14	.3801	.3366	.4024	.439	.4066	.4024	.4066
15	.2715	.3721	.4207	.4024	.4435	.439	.4435
16	.3721	.443	.4656	.5249		.439	.4805
17	.5658	.5201	.6024	.5375	.5434	.583	.5959
18	.6135	.6201	.6201	.5731	.6733	.6836	.5959
19	.7023	.695	.695	.6584	.823	.724	.7133
20	.6653	.6584	.6584	.6653	.7023	.6584	.6767
21	.6283	.6468	.6401	.6283	.6653	.695	.6283
22	.5544	.6036	.5729	.5914	.5914	.6468	.5914
23	.5415	.439	.499	.5228	.4435	.4251	.5544
24	.499	.5041	.4435	.4435	.4854	.4435	.462
Max	.9709	.9896	.8962	.7842	.823	.8215	.7947
Min	.2715	.2865	.4024	.4024	.4066	.4024	.4066
Avg	.5460	.5638	.5530	.5444	.5805	.5647	.5658



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334034 / 33/11 KV KARANKHEDA Sub Stn

Feeder No / Name : 205 / Narayanpur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2987	.2987	.3361	.2614	.2801	.2801
2	.2614	.2801	.2987	.3174	.2614	.2614	.2614
3	.2801	.2987	.2987	.3174	.2801	.2801	.2801
4	.2987	.2987	.3174	.3361	.2987	.2987	.2987
5	.3174	.3174	.3174		.3361	.3361	.3361
6	.3361	.3361	.3547	.3547	.3734	.3696	.3734
7	.3734	.4066	.3841	.3881	.3734	.4066	.4024
8	.3511	.3511	.3109	.3511	.3361	.3292	.3439
9	.2587	.2587	.2587	.2926	.2378	.2561	.2743
10	.2218	.2218	.2218	.2402	.2427	.2402	
11	.2195	.2012	.2218	.2033		.2218	.2195
12	.2218	.2033	.2218	.2218		.2033	.2195
13	.2195	.197	.2195	.1867	.2427	.2033	.2218
14	.1829	.1991	.2195	.2241	.2402	.2033	.2033
15	.2172	.1646	.2195	.2195	.2195	.2195	.2587
16	.2328	.1791	.2328	.2507	.2218	.2378	.2772
17	.2743	.2713	.2713	.2713	.2743	.2572	.2804
18	.2743	.2658	.3086	.2804	.2774	.3258	.3121
19	.3292	.3439	.3077	.3582	.3292	.3439	.3439
20	.3326	.3475	.3658	.3696	.3696	.3696	.3547
21	.3696	.3511	.3696	.3511	.3511	.3696	.3734
22	.3696	.3547	.3547	.3511	.3547	.3547	.3361
23	.3142	.3174	.3174	.3174	.3361	.3361	.3361
24	.2987	.2987	.2987	.3361	.2987	.3174	.3174
Max	.3734	.4066	.3841	.3881	.3734	.4066	.4024
Min	.1829	.1646	.2195	.1867	.2195	.2033	.2033
Avg	.2840	.2818	.2912	.2989	.2962	.2926	.3002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 201 / Dhamdai Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.9522	1.0082	.9694	.9145	.8402	.8916	.9511
8	.8962	.7655	.6767	.7545	.8059	.8573	.8779
12	.6161	.6219	.567	.6001	.4973	.567	.5975
16	.6535	.695		.6516	.703	.7133	
19	.7682	.8962	.8413	.9431	.7716	.9145	
23	.5975	.6219	.5853		.5658	.695	
24	.5601	.5415	.5487	.5487	.5658	.5487	.6401
Max	.9522	1.0082	.9694	.9431	.8402	.9145	.9511
Min	.5601	.5415	.5487	.5487	.4973	.5487	.5975
Avg	.7205	.7357	.6981	.7354	.6785	.7411	.7667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 202 / Pathrai Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.0898	1.0227					
8	1.0227	1.0059					
9			.9242				
12			.7628	1.2517	.945	.9829	.9054
16			.5868	.7926	.4115	.7335	
23	.8383	.6455					
24	.7545	.8215	.6015				
Max	1.0898	1.0227	.9242	1.2517	.945	.9829	.9054
Min	.7545	.6455	.5868	.7926	.4115	.7335	.9054
Avg	.9263	.8739	.7188	1.0222	.6783	.8582	.9054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334035 / 33/11 KV Palashi Sub Stn

Feeder No / Name : 203 / Rajive Soot Girani SHEDDABLE FEEDER HAVING WEEKLY  
 Industrial Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)  
 OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.5041	.2054	.2452	.3292	.1543	.1543	.3395
8	.3174	.2427	.3395	.2229	.1715	.2229	.3206
12	.3361	.2829	.1448	.2743	.2401	.3018	.4668
16	.3696	.3018	.128	.3086	.3258	.3206	
19		.3018	.1595	.2401	.2743	.547	
20				.2058			
23	.2241	.2075	.2353		.1543	.2829	
24	.3326	.2033	.2075	.2378	.12	.12	.2263
Max	.5041	.3018	.3395	.3292	.3258	.547	.4668
Min	.2241	.2033	.128	.2058	.12	.12	.2263
Avg	.3473	.2493	.2085	.2598	.2058	.2785	.3383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 201 / BHONE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.7621	.7621	.7316	.6706
2				.8383	.7316	.7926	.6097
3				.9145	.8535	.8535	.6097
4				.945	.8688	.9297	.5487
5				.9755	.9145	.9755	.6706
6				.8535	.823	1.0669	.9145
7				.8535	.8078	1.1888	1.0974
8				.823	.8916	1.1279	.9602
9	.884	.6401					
10	.9145	1.1279					
11	.9755	1.0517					
12	.884	1.0364					
13	.7621	.9755					
14	.823	.945					
15	.7926	.8535					
16	.7621						
23		.3048	.6097	.6097	.6706		
24				.6859	.6401	.6859	.7316
Max	.9755	1.1279	.6097	.9755	.9145	1.1888	1.0974
Min	.7621	.3048	.3048	.6097	.6401	.6859	.5487
Avg	.8497	.8669	.4573	.8261	.7964	.9280	.757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 202 / WAVAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.1126					
2	1.2193	1.1584					
3	1.448	1.2193					
4	1.5394	1.2498					
5	1.5851	1.3108					
6	1.6156	1.3565					
7	1.6309	1.4022					
8	1.6156	1.2803					
9			1.4784	1.0974	1.1431	1.0669	1.0648
10			1.3717	1.3413	1.1888	1.2963	1.2037
11			1.4632	1.326	1.4175	1.2809	1.2654
12			1.4632	1.1888	1.2498	1.2037	1.2346
13			1.4632	1.1888	1.1279	1.142	1.1265
14			1.3108	1.1431	1.0059	.9877	1.0802
15			1.0822	1.1126	.945	1.0802	.9722
16			1.0822	1.0822	1.0212	1.142	
23	1.0212						
24	.9755	1.0364					
Max	1.6309	1.4022	1.4784	1.3413	1.4175	1.2963	1.2654
Min	.9755	1.0364	1.0822	1.0822	.945	.9877	.9722
Avg	1.3718	1.2363	1.3394	1.1850	1.1374	1.1500	1.1353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R1[219] BU 5517

Substation No/ Name :- 334047 / Chaupale s/s

Feeder No / Name : 203 / CHOUPALE GAVTHAN FEEDER

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.6001	.462	.4268	.4572	.5144	.5175
2	.4572	.6516		.4268	.4725	.5487	.4805
3	.4725	.6859		.4115	.5182	.583	.4805
4	.5182	.7545		.4572	.5487	.6001	.5544
5	.7316	.7888		.5487	.8688	.6516	.6283
6	.7926	.8402		.7926	.8078	.6859	.6653
7	.823	.9602		.823	.7926	.8573	.8871
8	.7621	.7888		.5792	.7621	.8059	.7392
9	.6097	.7202	.7621	.4877	.5792	.6859	.7207
10	.5487	.6838	.6401	.3048	.6173	.2218	.5914
11		.6283	.5792	.2896	.5144	.4251	.5544
12	.4287	.5914	.3658	.3963	.3772	.4066	.499
13	.4458	.5544	.3658	.3963	.3772	.4435	.3881
14		.4805	.3506	.381	.4115	.4066	.3696
15	.4458	.4435	.4268	.3963	.4801	.4251	.3696
16	.3772		.4268	.4115	.4458	.4251	
17	.583	.6468	.503		.4801	.5544	.6468
18	.6173	.7392	.7926		.5144	.7207	.7023
19	.6173	.961	.8078	.7011	.6173	.8871	.7762
20	.7202	.961	.8573	.7011	.7202	.7762	.924
21	.6173	.8131	.7621	.6097	.823	.6653	.7762
22	.583		.503	.5487	.6173	.6283	
23	.463	.5175	.4572	.4572	.5144		.462
24	.4572	.583		.4572	.4572	.5316	.4435
Max	.823	.961	.8573	.823	.8688	.8871	.924
Min	.3772	.4435	.3506	.2896	.3772	.2218	.3696
Avg	.5681	.6997	.5664	.5002	.5739	.5848	.5989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 201 / LIS - I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9595			1.9845	
2			1.9595	2.0622	2.2184		2.0119
3			1.9595			1.9204	
4				1.9989	2.1403		2.0454
5			1.9757		2.0153	1.9524	
6			1.9595	2.0809	1.9528	2.0325	2.0885
7			2.0243	2.2801	2.0153	2.1125	2.1464
8			2.0405	2.2298	2.0466	2.0399	2.1376
9	4.7203	2.1872					
10	2.7686	2.7206					
11	2.9797	2.7526					
12	2.8464	2.7044					
13	2.8622	2.6235					
14	2.7515	2.5749					
15	2.5772	2.5749					
16	2.5154	2.3644					
23		1.9685	2.1262	2.2184	2.1765	2.0972	
24			2.0325	2.1874	2.2184	2.0325	2.079
Max	4.7203	2.7526	2.1262	2.2801	2.2184	2.1125	2.1464
Min	2.5154	1.9685	1.9595	1.9989	1.9528	1.9204	2.0119
Avg	3.0027	2.4968	2.0041	2.1511	2.0980	2.0215	2.0848



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 202 / LIS - II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4251			1.4563	
2			1.4251	1.3717	1.3123		1.5775
3			1.4251			1.4563	
4				1.3375	1.3279		1.576
5			1.3441		1.2654	1.3763	
6			1.3603	1.3717	1.3435	1.4243	1.3546
7			1.5384	1.4746	1.4373	1.5203	1.4419
8			1.3927	1.4746	1.3904	1.4232	1.4232
9	3.0674	1.6716					
10	2.1925	2.1376					
11	2.332	2.1125					
12	2.2965	2.0891					
13	2.2184	2.0243					
14	2.2184	2.0729					
15	2.1296	2.0729					
16	2.0622	2.0405					
23		1.4563	.4435	1.4373	1.5043	1.5261	
24			1.4563	1.5432	1.5546	1.5043	1.543
Max	3.0674	2.1376	1.5384	1.5432	1.5546	1.5261	1.5775
Min	2.0622	1.4563	.4435	1.3375	1.2654	1.3763	1.3546
Avg	2.3146	1.9642	1.3123	1.4301	1.3920	1.4609	1.4860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 203 / KOPARLI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7449	.7449					
2	1.5512	.7362					
3	.7449	.7362					
4	1.7337	.7042					
5	.8745	.7042					
6	1.8338	.7274					
7	2.3339	1.0279					
8	1.5175	.9686					
9			.8642	.9231	.9962	.9014	1.1043
10			1.3245	1.1873	1.2163		1.4842
11				1.2967	1.2793	1.4746	
12			1.406	1.1873	1.085	1.286	1.3592
13				1.1248	1.1174		1.2654
14			1.1831	1.0936	1.0883		1.2654
15				1.0623		1.3889	1.2342
16			2.428	1.0936	1.0911	1.2548	1.2029
22							.6874
23	.7125						.7811
24	1.5162	.7449					
Max	2.3339	1.0279	2.428	1.2967	1.2793	1.4746	1.4842
Min	.7125	.7042	.8642	.9231	.9962	.9014	.6874
Avg	1.3563	.7883	1.4412	1.1211	1.1248	1.2611	1.1538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 204 / 11 KV BHAGSARI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-FEB-18
HR	Load (MW)
24	.9602
Max	.9602
Min	.9602
Avg	.9602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 205 / 11 Kv. Khondamali Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5853	.5853			.5853	
2	.5914	.5853	.5853	.5544	.5853		.5914
3		.5853	.5853			.6584	
4	.8131	.7392		.7392	.7392		.7392
5		.9709	.9709		.8871	.961	
6	1.2437	1.2696	1.2696	1.2437	1.1949	1.2696	1.2071
7	1.166	1.1949	1.1949	1.134	.8962	1.1203	1.1706
8	.9511	.8962	.8962	.8131	.7468	.8962	.8871
9	.8131	.7468	.6653	.7392	.7392	.7392	.7762
10	.7316	.6653	.6653	.6653	.6653		.7316
11	.5853	.5853		.5853	.5853	.5914	
12	.439	.5121	.5175	.5068	.5121	.5175	.6584
13	.3658	.4344		.5068	.5068		.5121
14	.439	.4344	.4805	.5068	.4344		.5121
15	.5121	.4344		.5068		.5175	.5121
16	.5731	.5068	.5175	.5068	.5068	.5914	.5853
17	.5792	.6089	.6099	.5792	.6379		.6584
18	.7468	.724		.6653	.724	.7762	.7468
19	.9709	1.0349	.9979	.9709	1.1088		1.0082
20	.8962	.924	.9425	.8962	.924	.9979	.8962
21	.8131	.8131			.8779	.8871	.8215
22	.6584	.7392	.7207		.7392	.7762	.6584
23	.5853	.6584	.5914	.5853	.5853	.6283	.5853
24	.5914	.5853	.5853	.5544	.5853	.5853	.5914
Max	1.2437	1.2696	1.2696	1.2437	1.1949	1.2696	1.2071
Min	.3658	.4344	.4805	.5068	.4344	.5175	.5121
Avg	.7174	.7181	.7434	.6979	.7229	.7705	.7425

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334004 / KHONDAMALI

Feeder No / Name : 206 / 11 Kv. Vikharan Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4706	.4755			.4755	
2	.4805	.4706	.4755	.4066	.439		.4805
3		.4706	.4755			.4755	
4	.7023	.7316		.6283	.5914		.6653
5		.9709	.9709		1.0082	.9709	
6	1.3535	1.3817	1.3443	1.2803	1.307	1.307	1.3169
7	1.2437	1.3443	1.1949	1.0608	1.307	1.307	1.2803
8	.9877	.9709	.9709	.8501	.9709	1.0082	.961
9	.8501	.7392	.6653	.5544	.7842	.7762	.7762
10	.6219	.6653	.7023	.5914	.7023		.6219
11	.5487	.5487		.5121	.5853	.6283	
12	.439	.439	.3696	.4706	.3658	.5544	.5487
13	.3658	.3982		.4344	.4344		.439
14	.4755	.3982	.4435	.362	.3982		.439
15	.4755	.3982		.5068		.5544	.5853
16	.4207	.4344		.4706	.4344	.6283	.6219
17	.543	.5014	.5544	.5853	.567		.695
18	.7468	.6878		.6653	.7602	.7762	.8215
19	1.0829	1.0349	.9425	1.0829	1.1088		1.1203
20	.8962	.8501	.7762	.9335	.924	.9425	.9335
21	.7468	.7392			.7682	.7762	.8215
22	.6219	.5914	.5544		.5914	.6653	.6283
23	.5121	.4755	.4435	.5121	.4755	.5175	.5121
24	.4805	.4805	.4755	.4435	.439	.4755	.4805
Max	1.3535	1.3817	1.3443	1.2803	1.307	1.307	1.3169
Min	.3658	.3982	.3696	.362	.3658	.4755	.439
Avg	.6950	.6747	.6962	.6501	.7125	.7552	.7374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 201 / SHANIMANDAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7922	.7545	.8299	.8488	.7842	.8402
2	.679	.7922	.7545	.8299	.8488	.7842	.7842
3	.679	.7922	.7545	.7922	.8488	.8215	.8215
4	.7545	.8488	.8676	.8676	.8865	.8589	.9335
5	.8299	.8865	.9431	.9619	1.0374	1.0456	1.1576
6	1.0185	1.094	1.1694	1.1317	1.226	1.1576	1.2136
7	1.1694	1.3203	1.2826	1.3203	1.358	1.307	1.251
8	1.226	1.1317	1.2449	1.3203	1.2826	1.3443	1.2136
9	1.1949	1.251	1.2136	1.307	1.4146	1.3443	1.3203
10	1.1949	1.2136	1.4003	1.3443	1.5089	1.3817	1.358
11	1.0829	1.2136	1.2323	.9602	1.3203	1.1576	1.2826
12	1.0642	1.1203	1.0829	.9709	1.1317	1.0642	1.1317
13	1.2883	1.0642	1.0456	.8962	1.1317	1.0082	.9997
14	.9149	1.0269	.9709	.8962	.9431	.8775	.9997
15	.8215	.9709	.9709	.9709	.7545	.9335	1.0562
16	1.0082	.9709	1.0829		.9808	1.0642	1.0562
17	1.1883	1.2826	1.1317	1.1883	1.1317	1.1576	1.0185
18	1.2826	1.3203	1.2071	1.3203	1.2449	1.2136	1.2826
19	1.1317	1.1694	1.1694	1.2071	1.1694	1.1203	1.1694
20	.9431	.9431	1.1317	1.1317	1.0374	1.0269	1.0562
21	.9431	.9431	1.0185	.9431	.9335	.9522	.9808
22	.9054	.8676	.9431	.9431	.9335	.8962	.9335
23	.8488	.8299	.8676	.9054	.7842	.8775	.8589
24	.679		.7545	.8299	.9054	.7095	.8589
Max	1.2883	1.3203	1.4003	1.3443	1.5089	1.3817	1.358
Min	.679	.7922	.7545	.7922	.7545	.7095	.7842
Avg	.9803	1.0368	1.0414	1.0378	1.0693	1.0370	1.0658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 202 / Akrale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5121					
2	.5487	.5121					
3	.5487	.5121					
4	.5487	.5121					
5	.5853	.5487					
6	.6584	.6401					
7	1.0059	1.0059					
8	.823	.7316					
9			.6161	.5601	.5658	.5601	.6401
10			.8029	.7095	.6602	.6908	.6767
11			.9149	.7655	.7545	.7282	.7682
12			.8962	.7842	.9431	.0747	.7865
13			.8775	.7468	.9431	.7655	.7499
14			.7842	.7095	.7545	.6908	.6584
15			.7842	.6908	.7545	.7468	.7133
16			.7842		.7545	.7842	.7316
23	.5853	.5121					
24	.5487	.5487	.4755				
Max	1.0059	1.0059	.9149	.7842	.9431	.7842	.7865
Min	.5487	.5121	.4755	.5601	.5658	.0747	.6401
Avg	.6401	.6036	.7706	.7095	.7663	.6301	.7156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 203 / 11 KV Akrale Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.8131	.7392	.7545	.8501	.8413	.8413
2	.7762	.8131	.7392	.7316	.8501	.8413	.8413
3	.7392	.8131	.7392	.7392	.8131	.8048	.8871
4	.9709	1.0082	1.0082	.9709	1.0456	.8501	1.0349
5	1.2696	1.3203	1.307	1.307	1.358	1.3306	1.3676
6	1.6975	1.5466	1.5844	1.6221	1.6975	1.643	1.6057
7	1.6221	1.773	1.6975	1.6975	1.6975	1.7924	1.6244
8	1.4335	1.5089	1.358	1.4712		1.3676	1.386
9	1.2197	1.2567	1.0608	1.2437	.9431	1.1458	1.1203
10	.9145	.961	.8413	1.0608	.5658	.961	1.0082
11	.8048	.8048	.8048	.9145	.7545	.7316	.7392
12	.5853	.6878	.7682	.724	.6602	.6908	.6653
13	.5792	.695	.5792	.695	.6602	.6219	.695
14		.695	.6401	.6878	.7545	.6219	.6584
15	.362	.695	.5487	.6697	.7545	.695	
16	.3258	.7316	.695	.695	.7922	.7865	.8131
17	.9054	.8299	.8676	.8676	.8299	.8413	.7762
18	1.094	1.0562	1.094	1.0562	1.1317	1.0349	1.1576
19	1.6221	1.6221	1.5844	1.6221	1.6032	1.587	1.6975
20	1.3203	1.226	1.226	1.226	1.4146	1.307	1.2449
21	1.2449	1.226	1.1694	1.1317	1.1827	1.2012	1.1317
22	1.0719	.9335	.9709	1.0456	1.0719	1.0534	.9979
23	.9335	.8131	.8501	.924	.8779	.8596	.8413
24	.7762	.8131	.7392	.7392	.8413	.8048	.823
Max	1.6975	1.773	1.6975	1.6975	1.6975	1.7924	1.6975
Min	.3258	.6878	.5487	.6697	.5658	.6219	.6584
Avg	1.0019	1.0268	.9839	1.0249	1.0065	1.0173	1.0416



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 204 / Nimbhel Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.282	.3384	.3102	.3475	.3475
2			.282	.3102	.3102	.3475	.3185
3			.282	.3102	.2961	.3475	.3185
4			.282	.3102	.3102	.3765	.3185
5			.3102	.3525	.4371	.4054	.4054
6			.3666	.4512	.4371	.4401	.4633
7			.5639	.6767	.7727	.5575	.6661
8			.4793	.5357	.6241	.5868	.4923
9	.3814	.3807					
10	.5721	.6081					
11	.5575	.6081					
12	.4841	.543					
13	.5281	.5502					
14	.4694	.5213					
15	.4401	.7529					
16	.5575	.5357					
23			.3666	.3666	.3765	.362	.2751
24				.3666	.3243	.3475	.3475
Max	.5721	.7529	.5639	.6767	.7727	.5868	.6661
Min	.3814	.3807	.282	.3102	.2961	.3475	.2751
Avg	.4988	.5625	.3572	.4018	.4199	.4118	.3953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 205 / Nimbhel Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.112	.112	.112	.112	.112	.112
2	.0934	.112	.112	.112	.112	.112	.112
3	.0934	.0934	.112	.0934	.112	.112	.112
4	.112	.1307	.1307	.1307	.1307	.1307	.1307
5	.2054	.2241	.2427	.2427	.2241	.2801	.2241
6	.3174	.2987	.3361	.3361	.2801	.3361	.2614
7	.3361	.3361	.3547	.3547	.2987	.3174	.3174
8	.2427	.2427	.2241	.2801	.2614	.2241	.2054
9	.168	.2054	.1494	.168	.1886	.1867	.1867
10	.1307	.1307	.1307	.1307	.1509	.1307	.1307
11	.112	.112	.112	.0934	.1132	.112	.0934
12	1.0642	.0747	.0857	.112	.0943	.0747	.0934
13	.056	.0747	.0747	.0934	.0943	.0747	.0747
14	.0747	.0747	.0747	.0747	.0754	.0747	.0934
15	.0747	.0686	.0747		.0754	.0747	.056
16	.0747	.0934	.0747	.0934	.0943	.0934	.0934
17	.0943	.1132	.1132	.132	.1132	.0934	.0934
18	.1509	.1509	.1698	.1698	.1698	.1307	.1494
19	.2452	.2641	.3206	.2641	.2829	.2427	.2801
20	.1886	.1886	.1886	.1886	.1886	.1867	.1867
21	.1509	.1509	.1509	.1509	.168	.1494	.1494
22	.1307	.1494	.1307	.1494	.1307	.1494	.1307
23	.112	.112	.112	.1307	.112	.112	.112
24	.0934	.112	.112	.112	.112	.112	.112
Max	1.0642	.3361	.3547	.3547	.2987	.3361	.3174
Min	.056	.0686	.0747	.0747	.0754	.0747	.056
Avg	.1840	.1510	.1541	.1619	.1539	.1509	.1463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334011 / 33/11 KV RANALA

Feeder No / Name : 206 / 11 KV INDUSTRIAL PARK

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18
HR	Load (MW)
11	.112
16	.0747
Max	.112
Min	.0747
Avg	.0934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 202 / Hatmohida Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
4	1.6095	1.587
5	1.5708	1.6194
6	1.6356	1.6356
7	1.6842	1.6518
8	1.7604	1.668
Max	1.7604	1.668
Min	1.5708	1.587
Avg	1.6521	1.6324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 203 / 11 Kv. Bahyane Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
4	.4287	.4115
5	.583	.6001
6	.7716	.7888
7	.823	.9431
8	.7373	.8745
Max	.823	.9431
Min	.4287	.4115
Avg	.6687	.7236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 204 / 11 Kv. Arale Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
4	.0686	.0857
5	.1886	.2058
6	.2058	.2572
7	.2229	.2229
8	.1715	.1543
Max	.2229	.2572
Min	.0686	.0857
Avg	.1715	.1852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334021 / KOPARLI

Feeder No / Name : 205 / New Arale Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-FEB-18
HR	Load (MW)
24	.8916
Max	.8916
Min	.8916
Avg	.8916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-R2[573] BU 5584

Substation No/ Name :- 334044 / 33/11 KV SHANIMANDAL

Feeder No / Name : 201 / 11 KV AKHATWADE MIX

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.9882	
5					1.262		
6	1.7718					1.4529	
7			1.7528				
8	2.0111	2.1672		2.0576		1.5769	
9					1.8399	1.8564	2.1534
10				1.7238			
11					1.6385		1.7166
12	1.5043	1.4737	1.4563	1.491	1.5546	1.5061	
14	1.3748				1.3441		1.531
16	1.2346	1.5043	1.6484	1.4403	1.5023	1.3757	
18				1.4251	1.4243		
19	1.4548				1.2887		
20	1.1831		1.2742	1.2071	1.0898	1.2887	1.3226
21				1.0978			
22	.9724						1.1603
24	.5801		.663	.8951	.8192	.8573	.8573
Max	2.0111	2.1672	1.7528	2.0576	1.8399	1.8564	2.1534
Min	.5801	1.4737	.663	.8951	.8192	.8573	.8573
Avg	1.343	1.7151	1.3589	1.4172	1.3763	1.3628	1.4569



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 202 / NANDURBAR SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					1.3253	1.3969	1.4327
6	1.448	1.5565	1.4327	1.5203			
7					1.5402	1.576	1.6118
9							1.4327
11			1.3969				
12		1.7193					1.7375
16		1.4685					
17	1.5927	1.4998	1.4175	1.4118			
18						1.7737	1.7918
19					2.0668		
20	1.848						
21		1.5565	1.5565	1.4842		1.7909	1.7741
24	1.1706	1.2071	1.2986	1.2986	1.2536	1.3969	
Max	1.848	1.7193	1.5565	1.5203	2.0668	1.7909	1.7918
Min	1.1706	1.2071	1.2986	1.2986	1.2536	1.3969	1.4327
Avg	1.5148	1.5013	1.4204	1.4287	1.5465	1.5869	1.6301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 203 / ZARALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.7164	.6447	1.0387
6	.8048	.7316	.8048	.7316			
7					1.0029	1.0387	1.0387
9							.8939
11			.8596				
12		.8059					.905
13			.8596				
16		.8596					
17	.905	.8507	1.086	.8238			
18						1.0242	.8596
19					1.0924		
20	.8859						
21		.9036	.9114	.985		.9877	1.0059
24	.7499	.695	.695	.7316	.7164	.6447	
Max	.905	.9036	1.086	.985	1.0924	1.0387	1.0387
Min	.7499	.695	.695	.7316	.7164	.6447	.8596
Avg	.8364	.8077	.8694	.818	.8820	.868	.9570

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 204 / B &amp; C FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.9313	1.2178	1.2536
6	.9877	1.0242	1.0608	.9877			
7					1.182	1.3969	1.379
9							1.0498
11			1.0387				
12		.9671					.9328
16		.5373					
17	.543	.5487	1.0059	.9709			
18						1.2071	1.0608
19					1.251		
20	1.1576						
21		1.2136	1.1222	1.1576		1.262	1.2803
24	.8779	.9328	.9694	1.0059	.9313	1.3969	
Max	1.1576	1.2136	1.1222	1.1576	1.251	1.3969	1.379
Min	.543	.5373	.9694	.9709	.9313	1.2071	.9328
Avg	.8916	.8706	1.0394	1.0305	1.0739	1.2961	1.1594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 205 / Panchayat Samiti

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.788	.7522	.8954
6	.9145	.9511	.9511	.9877			
7					.8954	.1515	.8954
9							.905
11			1.0387				
12		.8596					.9922
16		1.0387					
17	.9922	1.0745	.9991	1.0208			
18						1.0608	1.0608
19					1.267		
20	1.2308						
21		1.1523	1.0808	1.1283		1.1871	1.1888
24	.8779	.8779	.9328	.9877	.788	.7701	
Max	1.2308	1.1523	1.0808	1.1283	1.267	1.1871	1.1888
Min	.8779	.8596	.9328	.9877	.788	.1515	.8954
Avg	1.0039	.9924	1.0005	1.0311	.9346	.7843	.9896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 206 / Water Supply

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0913	.1397	.0036
6	.1648	.1754	.1223	.1134			
7					.1218		.0054
9							.1272
11			.163				
12		.1934					.1003
16		.1397					
17	.1289	.1343	.1254	.1157			
18						.1364	.1397
19					.0425		
20	.0754						
21		.111	.1248	.128		.1379	.1364
24	.0532	.1039	.1307	.111	.1343	.1755	
Max	.1648	.1934	.163	.128	.1343	.1755	.1397
Min	.0532	.1039	.1223	.111	.0425	.1364	.0036
Avg	.1056	.1430	.1332	.1170	.0975	.1474	.0854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 209 / 11 KV ITI Express Feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0036	.0036	
6	.0036	.0035	.0035	.0035			
7					.0054	.0054	.0054
9							.0047
11			.0072				
12		.0215					.0062
13			.0072				
16		.0072					
17	.0049	.0072	.0021	.0033			
18						.0107	.0107
19					.0025		
20	.005						
21		.0051	.005	.0035		.0054	.0053
24	.0053	.0036	.0054	.0035	.0036	.0036	
Max	.0053	.0215	.0072	.0035	.0054	.0107	.0107
Min	.0036	.0035	.0021	.0033	.0025	.0036	.0047
Avg	.0047	.0080	.0051	.0035	.0038	.0057	.0065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334001 / 33/11 KV NEHARU NAGAR SS

Feeder No / Name : 210 / 11 Kv Shirishkumar Mehta SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					1.6118	1.5043	1.6476
6	2.1719	1.9909	2.0774	1.9728			
7					1.97	2.0058	2.1491
9							1.9547
11			1.7551				
12		1.8267					1.6832
16		1.576					
17	1.5912	1.6644	1.5927	1.7193			
18							1.7737
19					2.0165		
20	1.829						
21		1.848	1.829	1.8111		1.97	1.9936
24	1.4998	1.5912	1.5524	1.6278	1.5043	1.576	
Max	2.1719	1.9909	2.0774	1.9728	2.0165	2.0058	2.1491
Min	1.4998	1.576	1.5524	1.6278	1.5043	1.5043	1.6476
Avg	1.7730	1.7495	1.7613	1.7828	1.7757	1.7640	1.8670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 201 / 11 KV Kanyadan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7316	.7164	.6447	.5853	.6584	.6584	.6516
16	.5068	.5068	.5731	.4961	.5014	.5609	.5014
24	.5121	.5014	.5014	.5792	.6653	.6584	.6268
Max	.7316	.7164	.6447	.5853	.6653	.6584	.6516
Min	.5068	.5014	.5014	.4961	.5014	.5609	.5014
Avg	.5835	.5749	.5731	.5535	.6084	.6259	.5933



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 202 / 11 KV Sindhi Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6722	.7468	.7468	.7682	.7164	.823	.8029
16	.591	.6379	.6697	.6805	.6908	.691	
24	.6348	.6348	.6535	.724	.7682	.8316	.8215
Max	.6722	.7468	.7468	.7682	.7682	.8316	.8215
Min	.591	.6348	.6535	.6805	.6908	.691	.8029
Avg	.6327	.6732	.69	.7242	.7251	.7819	.8122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NANDURBAR-U[220] BU 0591

Substation No/ Name :- 334036 / 33/11 KV EKTA NAGAR SS

Feeder No / Name : 203 / 11 KV Namskar Colony  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8029	.7468	.8402	.8316	.7783	.7865	.8413
16	.7087	.6447	.724	.6733	.7468	.7164	.5792
24	.5788	.6161	.5975	.6268	.6838	.6697	.7095
Max	.8029	.7468	.8402	.8316	.7783	.7865	.8413
Min	.5788	.6161	.5975	.6268	.6838	.6697	.5792
Avg	.6968	.6692	.7206	.7106	.7363	.7242	.71

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 202 / KADWAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				2.1052	1.9433	1.8623	1.8623
8			1.7814	2.2672	2.1052	2.1862	2.2996
12	2.4291	2.753					
16	2.3482	2.672					
24				1.3765	1.4575	1.2146	1.9433
Max	2.4291	2.753	1.7814	2.2672	2.1052	2.1862	2.2996
Min	2.3482	2.672	1.7814	1.3765	1.4575	1.2146	1.8623
Avg	2.3887	2.7125	1.7814	1.9163	1.8353	1.7544	2.0351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 204 / Chitvi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.5101	2.0729	1.7814				
8	2.1052	2.1862					
12			3.2388	3.5627	3.2388	3.6761	3.5789
16			2.5911	3.4008	2.672	3.3684	3.5465
24	1.7814	1.3765	1.6194				
Max	2.5101	2.1862	3.2388	3.5627	3.2388	3.6761	3.5789
Min	1.7814	1.3765	1.6194	3.4008	2.672	3.3684	3.5465
Avg	2.1322	1.8785	2.3077	3.4818	2.9554	3.5223	3.5627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 205 / VADKUT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				2.2672	3.2388	2.753	2.915
8			.4049	2.834	3.2388	1.2955	3.1579
12	3.5627	3.4818					
16	3.8056	.4858					
24				1.5384	2.4291	2.1862	2.5911
Max	3.8056	3.4818	.4049	2.834	3.2388	2.753	3.1579
Min	3.5627	.4858	.4049	1.5384	2.4291	1.2955	2.5911
Avg	3.6842	1.9838	.4049	2.2132	2.9689	2.0782	2.888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 206 / morkaranja gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4858	.4858	.4534	.4858	.4534	.5668	.4534
8	.5668	.4858	.4858	.4858	.5668	.4858	.4858
20	.5668	.5182	.5668	.6478	.5668	.5668	.5182
24	.4049	.4049	.4534	.4049	.4858	.4049	.4534
Max	.5668	.5182	.5668	.6478	.5668	.5668	.5182
Min	.4049	.4049	.4534	.4049	.4534	.4049	.4534
Avg	.5061	.4737	.4899	.5061	.5182	.5061	.4777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 207 / Visarwadi gavthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6478	.6478	.6154	.7287	.7287	.5668	.6802
12	.6478	.6478	.6478	.6802	.6802	.6802	.6478
16	.6478	.5668	.6154	.6478	.7287	.7287	.7287
20	.6154	.7287	.6478	.6154	.6478	.7287	.7773
24	.5668	.4858	.6478	.5668	.5668	.5668	.6478
Max	.6478	.7287	.6478	.7287	.7287	.7287	.7773
Min	.5668	.4858	.6154	.5668	.5668	.5668	.6478
Avg	.6251	.6154	.6348	.6478	.6704	.6542	.6964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 208 / chitvi gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7287	.6478	.5668	.7287	.5668	.7287	.7287
8	.6478	.7287	.6802	.7287	.7287	.7287	.7287
20	.5668	.7287	.7287	.6478	.7287	.7773	.8097
24	.6478	.4858	.6478	.5668	.5668	.5668	.6478
Max	.7287	.7287	.7287	.7287	.7287	.7773	.8097
Min	.5668	.4858	.5668	.5668	.5668	.5668	.6478
Avg	.6478	.6478	.6559	.668	.6478	.7004	.7287



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 209 / chinchpada gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6478	.7125	.6478	.6478	.6802	.6478	.6478
12	.6478	.6478	.6478	.6478	.6478	.6478	.6478
16	.5668	.5668	.6478	.5668	.7287	.7287	.6478
20	.7773	.7773	.6478	.6478	.6478	.7773	.7773
24	.6154	.5668	.6478	.5668	.5668	.6478	.6478
Max	.7773	.7773	.6478	.6478	.7287	.7773	.7773
Min	.5668	.5668	.6478	.5668	.5668	.6478	.6478
Avg	.6510	.6542	.6478	.6154	.6543	.6899	.6737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334003 / VISARWADI

Feeder No / Name : 210 / HALDANI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.5384	1.5384	1.4575				
8	1.8461	1.9433					
12			2.4291	2.1052	2.2672	2.3482	2.3158
16			1.9433	2.1052	1.8461	2.2996	2.1052
24	1.2308	1.0526	1.2955				
Max	1.8461	1.9433	2.4291	2.1052	2.2672	2.3482	2.3158
Min	1.2308	1.0526	1.2955	2.1052	1.8461	2.2996	2.1052
Avg	1.5384	1.5114	1.7814	2.1052	2.0567	2.3239	2.2105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 201 / NAVAPUR Light Bazar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.1517	1.1517	1.2403	1.4352	1.3169	1.3535	1.3535
8	1.949	2.0022	2.0022	1.8959	1.9387	1.829	1.829
12	1.701	1.8427			1.825	1.701	1.8781
16	1.5415		1.5061	2.0022	1.5592	1.7187	2.1971
19							2.0199
20	1.5947	1.6301	1.7364	1.6655	1.8427	1.7541	
24	1.1517	1.2403	1.2403	1.3643	1.3535	1.4632	1.4632
Max	1.949	2.0022	2.0022	2.0022	1.9387	1.829	2.1971
Min	1.1517	1.1517	1.2403	1.3643	1.3169	1.3535	1.3535
Avg	1.5149	1.5734	1.5451	1.6726	1.6393	1.6366	1.7901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 202 / KHEKDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.9052	1.8442					
8	2.2558	1.9814					
16			2.7949	3.0121	3.0476	3.1539	2.9664
24	1.7833	1.9204	1.5546				
Max	2.2558	1.9814	2.7949	3.0121	3.0476	3.1539	2.9664
Min	1.7833	1.8442	1.5546	3.0121	3.0476	3.1539	2.9664
Avg	1.9814	1.9153	2.1748	3.0121	3.0476	3.1539	2.9664

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 203 / NAVAGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			1.3108	1.7223	1.768	1.7375	1.89
8			1.89		2.0119	1.9814	2.1338
12	2.2119	2.7092					
16	2.1948	2.5892					
24				1.6156	1.768	1.6461	1.7375
Max	2.2119	2.7092	1.89	1.7223	2.0119	1.9814	2.1338
Min	2.1948	2.5892	1.3108	1.6156	1.768	1.6461	1.7375
Avg	2.2034	2.6492	1.6004	1.6690	1.8493	1.7883	1.9204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 204 / prabhakar colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5493	.5847	.5847	.567	.6379	.6379	.6733
8	.8859	1.0454	.9568	.9214	.8505	.8859	.9568
12	1.0099	1.0099	.9745	1.0277	1.0454	.9391	.9214
16	1.0631	.9568	.9391	1.0277	1.134	1.0808	1.1517
20	.7619	.7796	.7619	.7619	.8859	.8505	.8682
24	.567	.5847	.567	.5316	.6379	.4561	.6379
Max	1.0631	1.0454	.9745	1.0277	1.134	1.0808	1.1517
Min	.5493	.5847	.567	.5316	.6379	.4561	.6379
Avg	.8062	.8269	.7973	.8062	.8653	.8084	.8682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 205 / nawagoan gauthan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7282	.7628	.6415	.7282	.8413	.7442	.7796
12	.5316	.6201	.7087				
16	.6733	.6733	.6556	.7087	.7796	.7619	.8328
20	.9214	.8859	.9391	.9568	.9568	.9568	
24	.7108	.6415	.7108	.7455	.7796	.7442	.7796
Max	.9214	.8859	.9391	.9568	.9568	.9568	.8328
Min	.5316	.6201	.6415	.7087	.7796	.7442	.7796
Avg	.7131	.7167	.7311	.7848	.8393	.8018	.7973

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 206 / KHEKADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.7337	1.9071	2.0805	2.0805	.8859	2.3034	2.1262
12	2.4806	2.3034	2.392	2.3034	2.1262	2.3034	2.4806
20	2.8349	2.6578			1.5947	2.8349	
24	1.7337	2.2539	2.2539	2.4272	.8859	2.4806	2.4806
Max	2.8349	2.6578	2.392	2.4272	2.1262	2.8349	2.4806
Min	1.7337	1.9071	2.0805	2.0805	.8859	2.3034	2.1262
Avg	2.1957	2.2806	2.2421	2.2704	1.3732	2.4806	2.3625



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 207 / SAVARAT AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.829	1.829					
8	2.21	2.0424					
12			3.0521	3.2247	3.0121	2.9944	2.7949
16			2.7949	3.1716	2.8704	2.8349	2.8978
24	1.7985	1.6766	1.6004				
Max	2.21	2.0424	3.0521	3.2247	3.0121	2.9944	2.8978
Min	1.7985	1.6766	1.6004	3.1716	2.8704	2.8349	2.7949
Avg	1.9458	1.8493	2.4825	3.1982	2.9413	2.9147	2.8464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334006 / NAVAPUR

Feeder No / Name : 208 / 11 KV Kumbharwada U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8328	.815	.9568	.9391	.9877	.7316	.9145
8	1.3112	1.4529	1.4706	1.4175	1.5364	1.2803	1.3535
12	1.2403	1.2934	1.382	.2303	1.382	.9922	1.2226
16	1.3643	1.3643	1.3466		1.3466	1.0808	1.2757
20	1.134	1.0631	1.1163	1.5947	.9214	.7973	
24	.7796	.815	.8505	.8328	1.0242	.7316	.9511
Max	1.3643	1.4529	1.4706	1.5947	1.5364	1.2803	1.3535
Min	.7796	.815	.8505	.2303	.9214	.7316	.9145
Avg	1.1104	1.1340	1.1871	1.0029	1.1997	.9356	1.1435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 201 / 11 KV KHANDBARA MIX  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
15	3.2769	2.7435	2.4387
16	3.3532	1.829	
Max	3.3532	2.7435	2.4387
Min	3.2769	1.829	2.4387
Avg	3.3151	2.2863	2.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 202 / 11 KV MOGRANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	3.658		1.9814	
12	3.0483		2.0119	2.1033
13		3.0483		1.9814
14		2.8959		
Max	3.658	3.0483	2.0119	2.1033
Min	3.0483	2.8959	1.9814	1.9814
Avg	3.3532	2.9721	1.9967	2.0424

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 203 / 11 KV BARDIPADA MIX  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
15	2.713	2.4387	1.9814
16	2.652	2.2862	
Max	2.713	2.4387	1.9814
Min	2.652	2.2862	1.9814
Avg	2.6825	2.3625	1.9814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 204 / 11 KV MOGRANI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.4877	
12			.4572	.4572
13	.4572			
14	.4877	.4877		
15		.5182		
Max	.4877	.5182	.4877	.4572
Min	.4572	.4877	.4572	.4572
Avg	.4725	.5030	.4725	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 205 / 11 KV KHANDBARA GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		1.0669		
11		1.0669		
13	.9755		.9145	.9602
14	.9145		.9145	.9755
Max	.9755	1.0669	.9145	.9755
Min	.9145	1.0669	.9145	.9602
Avg	.945	1.0669	.9145	.9679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334019 / KHANDBARA

Feeder No / Name : 207 / 11 KV SHRAWANI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			.3048	.3048
13	.2743			
14	.2134	.3048		
15		.3048		
Max	.2743	.3048	.3048	.3048
Min	.2134	.3048	.3048	.3048
Avg	.2439	.3048	.3048	.3048



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 201 / NAVAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.5424						
8	2.2466	2.1963					
12			2.7664	2.6825	2.6825		2.9675
16			2.7161		2.9005	2.6063	2.7328
24		1.5927	1.5927				
Max	2.2466	2.1963	2.7664	2.6825	2.9005	2.6063	2.9675
Min	1.5424	1.5927	1.5927	2.6825	2.6825	2.6063	2.7328
Avg	1.8945	1.8945	2.3584	2.6825	2.7915	2.6063	2.8502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 202 / UKALPANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.0059						
8	1.4083	1.4754					
12			1.6766	1.6766	1.7101		1.7604
16			1.6095	1.5089	1.7101	1.6598	1.7436
24	.8718	.8383	.8551				
Max	1.4083	1.4754	1.6766	1.6766	1.7101	1.6598	1.7604
Min	.8718	.8383	.8551	1.5089	1.7101	1.6598	1.7436
Avg	1.0953	1.1569	1.3804	1.5928	1.7101	1.6598	1.752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 203 / CHAUKI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			1.1736		1.5927	1.8442	1.4922
8			1.861	1.9448	1.8442	1.9784	1.861
12	2.2466	2.3304					
16	2.1963	.9389					
24				1.4413	1.3413	1.5089	1.2574
Max	2.2466	2.3304	1.861	1.9448	1.8442	1.9784	1.861
Min	2.1963	.9389	1.1736	1.4413	1.3413	1.5089	1.2574
Avg	2.2215	1.6347	1.5173	1.6931	1.5927	1.7772	1.5369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 204 / NAVAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3155		.333		.3155	.3155	.3506
8		.3506	.333	.3506	.3856	.3506	.3681
12	.3506						
16	.2629	.2629	.2629		.2629	.333	.2629
20		.4382		.4207	.4382	.4382	
24	.3506	.3506	.333	.3856	.3155	.3506	.333
Max	.3506	.4382	.333	.4207	.4382	.4382	.3681
Min	.2629	.2629	.2629	.3506	.2629	.3155	.2629
Avg	.3199	.3506	.3155	.3856	.3435	.3576	.3287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 205 / UKALAPANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.298		.333		.298	.3155	.3506
8		.3506	.3155	.3506	.3506	.3506	.3506
12	.3506						
16	.2629	.2454	.2629		.2629	.333	.2629
20		.4207		.4031	.4382	.4382	
24	.3506	.3506	.333	.3856	.2629	.3506	.333
Max	.3506	.4207	.333	.4031	.4382	.4382	.3506
Min	.2629	.2454	.2629	.3506	.2629	.3155	.2629
Avg	.3155	.3418	.3111	.3798	.3225	.3576	.3243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334023 / RAIPUR

Feeder No / Name : 206 / MORTHUWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.8718		1.0059	1.0898	1.1065
8			1.1904	1.0059	1.0059	1.2071	1.1904
12	1.2574	1.5592					
16	1.5424	.7209					
24				.9326	.9054	.9724	1.0059
Max	1.5424	1.5592	1.1904	1.0059	1.0059	1.2071	1.1904
Min	1.2574	.7209	.8718	.9326	.9054	.9724	1.0059
Avg	1.3999	1.1401	1.0311	.9693	.9724	1.0898	1.1009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 201 / 11 KV BANDHARE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				1.5935	1.3279		
6			1.406			1.8122	1.7236
9	1.5497						
10		2.1338					
15	2.1338	2.0576					
24			1.2651	1.6129	1.3757	1.8027	1.4899
Max	2.1338	2.1338	1.406	1.6129	1.3757	1.8122	1.7236
Min	1.5497	2.0576	1.2651	1.5935	1.3279	1.8027	1.4899
Avg	1.8418	2.0957	1.3356	1.6032	1.3518	1.8075	1.6068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 202 / WASDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.2685	1.9052					
9			2.21				
10				2.8197	2.8959	2.6978	2.9784
15			2.9721				
16				2.8597	2.9721	2.8748	2.8197
24	2.1091	1.8747					
Max	2.2685	1.9052	2.9721	2.8597	2.9721	2.8748	2.9784
Min	2.1091	1.8747	2.21	2.8197	2.8959	2.6978	2.8197
Avg	2.1888	1.8900	2.5911	2.8397	2.934	2.7863	2.8991



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 204 / Kelpada Gaothan (old  
Wasada Ga Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.6468	.5914		
6	.6099	.5914	.6283			.6161	.6468
10				.695	.695		
12	.5121	.5853	.7316				
15							.6767
16				.6767	.5853	.6401	
18		.7207	.7392				
19	.7023			.7392	.7023	.7207	.6099
24	.5544	.5041	.5544	.5914	.5544	.5601	
Max	.7023	.7207	.7392	.7392	.7023	.7207	.6767
Min	.5121	.5041	.5544	.5914	.5544	.5601	.6099
Avg	.5947	.6004	.6634	.6698	.6257	.6343	.6445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 205 / 11KV KELPADA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.6872	1.7654					
9			1.8435				
10				2.6368	2.4528	2.7778	2.6825
15			1.9052				2.284
16				2.332	2.4234		
17						2.2253	
24	1.2651	1.5497					
Max	1.6872	1.7654	1.9052	2.6368	2.4528	2.7778	2.6825
Min	1.2651	1.5497	1.8435	2.332	2.4234	2.2253	2.284
Avg	1.4762	1.6576	1.8744	2.4844	2.4381	2.5016	2.4833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334029 / BILBARA

Feeder No / Name : 206 / 11 KV New Dokare AG Feeder FEEDER SEPERATION/PURE AG  
 Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				1.5935	1.6404		
6			1.531			2.0833	1.8747
9	1.406						
10		2.0833					
15	2.3624	2.2862					
24			1.3441	1.5813	1.6129	1.866	1.3603
Max	2.3624	2.2862	1.531	1.5935	1.6404	2.0833	1.8747
Min	1.406	2.0833	1.3441	1.5813	1.6129	1.866	1.3603
Avg	1.8842	2.1848	1.4376	1.5874	1.6267	1.9747	1.6175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 201 / 11 kv shaym sunder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.9204
5	1.9033		1.9033		1.4575	
8	2.3491		2.332		2.2291	1.8004
9			2.7435		2.6235	
10	2.7606	2.915				
12	2.3491		2.1262	1.3889	2.2634	
16	2.5034	2.5892		1.749	2.5377	
20		2.2977				1.4575
23		2.0233				
24	2.1605		2.0748		1.5089	
Max	2.7606	2.915	2.7435	1.749	2.6235	1.9204
Min	1.9033	2.0233	1.9033	1.3889	1.4575	1.4575
Avg	2.3377	2.4563	2.2360	1.5690	2.1034	1.7261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 202 / 11 kv kolda

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	2.0748				
8	2.572				
9			2.7949		3.0864
12			3.7723	3.738	4.0466
16				3.858	3.9095
23		1.5432			
24	1.9719		1.749		
Max	2.572	1.5432	3.7723	3.858	4.0466
Min	1.9719	1.5432	1.749	3.738	3.0864
Avg	2.2062	1.5432	2.7721	3.798	3.6808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 204 / RTO EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0514
5	.0514		.0514		.0514	
8	.0171		.0171		.0171	.0343
9			.0343		.0171	
10	.0171	.0343				
12	.0171		.0171	.0171	.0171	
16	.0171	.0343		.0171	.0171	
20		.0514				.0514
23		.0514				
24	.0514		.0514		.0514	
Max	.0514	.0514	.0514	.0171	.0514	.0514
Min	.0171	.0343	.0171	.0171	.0171	.0343
Avg	.0285	.0429	.0343	.0171	.0285	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 205 / Wadkut Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5144
5	.4801		.5144	.5144	
9				.4458	
10	.4287	.463			
12	.4115		.4287		
16	.4458	.4458		.3944	
20		.6173			
23		.5487			.6001
24	.4973		.5487	.5144	
Max	.4973	.6173	.5487	.5144	.6001
Min	.4115	.4458	.4287	.3944	.5144
Avg	.4527	.5187	.4973	.4673	.5573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 206 / AGRASEN IND Express

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2058
5	.1886		.1543		.1715	
8	.1886		.2229		.2229	.1886
9			.1886		.2401	
10	.2572	.2743				
12	.2229		.2229	.1372	.2058	
16	.2915	.2401		.2401	.2743	
20		.1715				.1029
23		.1372				
24	.2058		.1715		.2058	
Max	.2915	.2743	.2229	.2401	.2743	.2058
Min	.1886	.1372	.1543	.1372	.1715	.1029
Avg	.2258	.2058	.1920	.1887	.2201	.1658



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334043 / NAVAPUR MIDC 33/11 KV Sstn

Feeder No / Name : 207 / 11 Kv Chokhawala

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4115
5	.2915		.4287		.0686	
8	.2572		.2572		.1543	.2229
9			.4287		.2572	
10	.4287	.4973				
12	.2229		.2229	.1029	.2058	
16	.5144	.5316			.4458	
20		.3772				.3429
23		.4458				
24	.3601		.4287		.1029	
Max	.5144	.5316	.4287	.1029	.4458	.4115
Min	.2229	.3772	.2229	.1029	.0686	.2229
Avg	.3458	.4630	.3532	.1029	.2058	.3258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

NANDURBAR (O&amp;M) DIVISION[585]

NAVAPUR S/DN.[546] BU 0546

Substation No/ Name :- 334046 / 33 KV KHATGAON SUB STATION

Feeder No / Name : 202 / 11 KV KHADAKI MIX FEEDER SHEDDABLE RURAL  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3339	2.4025	2.2177	2.838			
6					2.7759	3.2579	2.4691
15	3.6591	3.091	3.6742	3.4751			
23					2.6242	2.2916	2.3152
Max	3.6591	3.091	3.6742	3.4751	2.7759	3.2579	2.4691
Min	2.3339	2.4025	2.2177	2.838	2.6242	2.2916	2.3152
Avg	2.9965	2.7468	2.9460	3.1566	2.7001	2.7748	2.3922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334008 / AKKALKUVA

Feeder No / Name : 201 / 11KV AKKALKUVA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8749			
2			.8592			
3			.9217			
4			.953			
5			.9686			
6		.9998	1.0155			
7			1.0623			
8				1.2029	1.2811	
9					1.3748	
10					1.3904	
11					1.3748	
12				1.406	1.3435	
13					1.3123	
14					1.2654	
15					1.3904	
24	.8592	.8592				1.4118
Max	.8592	.9998	1.0623	1.406	1.3904	1.4118
Min	.8592	.8592	.8592	1.2029	1.2654	1.4118
Avg	.8592	.9295	.9507	1.3045	1.3416	1.4118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334008 / AKKALKUVA

Feeder No / Name : 202 / 11KV AKKALKUVA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6975			1.7741	
2			1.6095			1.7375	
3			1.6278			1.6827	
4			1.6827			1.6461	
5			1.9204			1.7924	
6		2.268	2.2862		2.3777	2.2862	
7			2.5972			2.5606	
8			2.5789			2.5057	
9			2.3777			2.4691	
10			2.2314			2.396	
11			2.1399			2.2862	
12		2.7435			2.3594	2.3411	
13			2.0851			2.2314	
14			1.8656			1.9753	
15			1.8656			1.9753	
16			2.0485			2.2314	
17			2.0485			2.2314	
18		2.3411	2.2862		2.2862	2.4691	
19			2.5057			2.524	
20			2.396			2.5423	
21			2.1399			2.4691	
22			2.1399			2.2862	
23			1.9204			2.1948	
24	1.6461	1.7375		1.829	1.829		2.2405
Max	1.6461	2.7435	2.5972	1.829	2.3777	2.5606	2.2405
Min	1.6461	1.7375	1.6095	1.829	1.829	1.6461	2.2405
Avg	1.6461	2.2725	2.0932	1.829	2.2131	2.2003	2.2405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334008 / AKKALKUVA

Feeder No / Name : 203 / 11KV VANYAVIHIR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0364			1.4632	
2			1.0059			1.448	
3			1.0212			1.4327	
4			1.0669			1.4632	
5			1.1126			1.4937	
6		1.1279	1.1431		1.7528	1.5242	
7			1.1736			1.5089	
8			1.7833			1.3565	
9			2.1948			1.5699	
10			2.1795			1.6004	
11			2.1491			1.6309	
12		2.2862	2.1491		1.6004	1.5242	
13			2.1338			1.3565	
14			2.1338			1.2955	
15			2.1186			1.448	
22			1.1584			1.3413	
23			1.3413			1.5089	
24	1.0364	.9907		1.2803	1.5089		1.3998
Max	1.0364	2.2862	2.1948	1.2803	1.7528	1.6309	1.3998
Min	1.0364	.9907	1.0059	1.2803	1.5089	1.2955	1.3998
Avg	1.0364	1.4683	1.5824	1.2803	1.6207	1.4686	1.3998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334008 / AKKALKUVA

Feeder No / Name : 204 / 11KV VANYAVIHIR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2094			1.2094	
2			1.1744			1.1568	
3			1.1919			1.1218	
4			1.2269			1.0867	
5			1.2795			1.2094	
6		1.1218	1.4373		1.2971	1.3146	
7			1.595			1.56	
8			1.5775			1.4723	
9						1.4899	
10			1.4198			1.4548	
11			1.4022			1.3321	
12		1.1393	1.4266		1.3496	1.3847	
13			1.2795			1.3847	
14			1.2795			1.4022	
15			1.4198			1.2971	
16			1.4373			1.3672	
17			1.4548			1.4198	
18		1.3321	1.5249		1.5775	1.595	
19			1.4373			1.6651	
20			1.5775			1.6126	
21			1.5074			1.2094	
22			1.3496			1.4723	
23			1.2269			1.3146	
24	1.1568	1.2269		1.2094	1.1568		2.5076
Max	1.1568	1.3321	1.595	1.2094	1.5775	1.6651	2.5076
Min	1.1568	1.1218	1.1744	1.2094	1.1568	1.0867	2.5076
Avg	1.1568	1.2050	1.3834	1.2094	1.3453	1.3710	2.5076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334008 / AKKALKUVA

Feeder No / Name : 205 / KAKARPADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381			.381	
2			.381			.381	
3			.381			.381	
4			.381			.381	
5			.381			.381	
6		.5716	.381			.381	
7			.381			.381	
8			.381			.381	
9			.381			.381	
10			.381			.381	
11			.381			.381	
12		.381	.381		.381	.381	
13			.381			.381	
14			.381			.381	
15			.381			.381	
16			.381			.381	
17			.381			.381	
18		.381	.381		.5716	.381	
19			.381			.381	
20			.381			.381	
21			.381			.381	
22			.381			.5716	
23			.381			.381	
24	.5716	.381		.381	.381		.6001
Max	.5716	.5716	.381	.381	.5716	.5716	.6001
Min	.5716	.381	.381	.381	.381	.381	.6001
Avg	.5716	.4287	.381	.381	.4445	.3893	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334025 / MOLAGI

Feeder No / Name : 201 / 11KV MOLAGI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	.8192
Max	.8192
Min	.8192
Avg	.8192



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334025 / MOLAGI

Feeder No / Name : 202 / 11KV BHANGRAPANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	.9783
Max	.9783
Min	.9783
Avg	.9783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 201 / 11KV RAISINGPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4287	.6173				
8		.602	.6173				
12				.7716	.5944	.7811	.7287
16				.7716	.743	.7811	
24	.6173	.4515	.6944				.6773
Max	.6173	.602	.6944	.7716	.743	.7811	.7287
Min	.6173	.4287	.6173	.7716	.5944	.7811	.6773
Avg	.6173	.4941	.643	.7716	.6687	.7811	.703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 202 / 11KV NAVAPADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5401
2					.5401
3					.5401
4			.4687	.6249	.5401
5					.5401
6					.6173
7					1.0155
8			.743	.7526	1.0936
12	.9602	.9717			
16	.9374	.7202			
24			.4687	.6249	.6668
Max	.9602	.9717	.743	.7526	1.0936
Min	.9374	.7202	.4687	.6249	.5401
Avg	.9488	.8460	.5601	.6675	.6771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 203 / 11KV KHAPAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.8802	.9374				
8		1.1888	1.2498				
12				1.2498	1.1888	1.2498	1.7147
16				1.2498	1.3546	1.2498	
24	1.0936	1.0269	.9374				1.0288
Max	1.0936	1.1888	1.2498	1.2498	1.3546	1.2498	1.7147
Min	1.0936	.8802	.9374	1.2498	1.1888	1.2498	1.0288
Avg	1.0936	1.0320	1.0415	1.2498	1.2717	1.2498	1.3718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 204 / 11KV KHAPAR GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.9511
2							.9425
3							.8779
4	.7682	1.0456	1.0164		.9979	.8775	.8686
5							.9694
6							1.2197
7							1.2986
8	1.1888	1.2696	1.3121		1.2012	1.2696	1.2012
12		.9816	1.0136	.9991	.9709	.9145	.8869
16		.9694	.8954	.9114	.9896	.8962	
20		1.2254	1.2567	1.1043	1.3256	1.2254	
24	.8316	1.0456	.9694		.9896	1.0374	.7716
Max	1.1888	1.2696	1.3121	1.1043	1.3256	1.2696	1.2986
Min	.7682	.9694	.8954	.9114	.9709	.8775	.7716
Avg	.9295	1.0895	1.0773	1.0049	1.0791	1.0368	.9988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 205 / 11KV NAVAPADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6584
2							.6468
3							.6219
4		.5975	.6036		.6348	.5601	.5914
5							.6767
6							.6468
7							.7947
8		.7282	.6219		.6908	.6602	.7133
12		.5721	.2623	.3814	.3142	.4805	.5201
16		.5544	.2915	.6068	.6161	.5544	
20		.6838	.7888	.8149	.7468	.8686	
24	.695	.7207	.6653		.6468	.6602	.6001
Max	.695	.7282	.7888	.8149	.7468	.8686	.7947
Min	.695	.5544	.2623	.3814	.3142	.4805	.5201
Avg	.695	.6428	.5389	.6010	.6083	.6307	.6470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 206 / 11KV RAISINGPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.3239
2							.3048
3							.3239
4		.3239	.3429		.3429	.2858	.3429
5							.3048
6							.362
7							.4001
8		.4763	.4382		.381	.4191	.4001
12		.4001	.0343	.362	.2858	.3429	.0362
16		.381	.0362	.362	.3048	.3429	
20		.4382	.0476	.4191	.4763	.4191	
24	.4001	.4572	.381		.3239	.362	.4763
Max	.4001	.4763	.4382	.4191	.4763	.4191	.4763
Min	.4001	.3239	.0343	.362	.2858	.2858	.0362
Avg	.4001	.4128	.2134	.3810	.3525	.3620	.3275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 207 / 11KV PORAMBI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-FEB-18	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.463
2			.463
3			.463
4			.463
5			.463
6			.463
7			.7811
8			.7811
12	.8345	.7202	
16	.7811	.7202	
24			.4287
Max	.8345	.7202	.7811
Min	.7811	.7202	.4287
Avg	.8078	.7202	.5299



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334026 / KHAPAR

Feeder No / Name : 208 / 11KV MORMBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3858
2				.3858
3				.3858
4		.2372	.3163	.3858
5				.3858
6				.463
7				.5401
8		.4458	.4458	.463
12	.5411			
16	.463			
24		.16	.4001	.8002
Max	.5411	.4458	.4458	.8002
Min	.463	.16	.3163	.3858
Avg	.5021	.281	.3874	.4661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334030 / HORAFALI

Feeder No / Name : 201 / 11KV Valamba

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	.6687
Max	.6687
Min	.6687
Avg	.6687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334030 / HORAFALI

Feeder No / Name : 202 / 11KV HORAFALI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.8573	.8573	.8573	.8573	.8573	.8573	.8573
15	.8573	.8573	.8573	.8573	.8573	.8573	.8573
23		.8573					
24	.8573		.8573	.8573	.8573	.8573	.8573
Max	.8573	.8573	.8573	.8573	.8573	.8573	.8573
Min	.8573	.8573	.8573	.8573	.8573	.8573	.8573
Avg	.8573	.8573	.8573	.8573	.8573	.8573	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334033 / PIMPALKUNTHA

Feeder No / Name : 201 / 11KV BARDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334033 / PIMPALKUNTHA

Feeder No / Name : 202 / 11KV PIMPALKUNTHA  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	28-FEB-18
HR	Load (MW)
24	.1505
Max	.1505
Min	.1505
Avg	.1505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334041 / JAMANA

Feeder No / Name : 201 / 11KV ASLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
23	.3121
Max	.3121
Min	.3121
Avg	.3121

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334041 / JAMANA

Feeder No / Name : 202 / 11KV DAB

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	.2972
Max	.2972
Min	.2972
Avg	.2972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

AKKALKUWA S/DN.[837] BU 4837

Substation No/ Name :- 334041 / JAMANA

Feeder No / Name : 203 / 11KV JAMANA

Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	28-FEB-18
HR	Load (MW)
23	.3086
Max	.3086
Min	.3086
Avg	.3086



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 201 / 11KV Dhadgaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.101		.0934			
12	.0876			.0953			
16					.6401	.6859	.7011
18	.0857	.0762	.0876				
24	.0724	.0686	.0572	.0533	.6097	.6859	.6554
Max	.0876	.101	.0876	.0953	.6401	.6859	.7011
Min	.0724	.0686	.0572	.0533	.6097	.6859	.6554
Avg	.0819	.0819	.0724	.0807	.6249	.6859	.6783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 202 / 11KV Chulwad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0591		.1353			
12				.0476			
16					1.9204	1.89	1.7071
18	.1791	.2191					
24	.1029	.0419	.2267	.0914	1.4327	1.1126	1.2803
Max	.1791	.2191	.2267	.1353	1.9204	1.89	1.7071
Min	.1029	.0419	.2267	.0476	1.4327	1.1126	1.2803
Avg	.141	.1067	.2267	.0914	1.6766	1.5013	1.4937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 203 / 11 kv Surwani

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.04		.0305			
8					.7926	.6249	.8535
12	.0991						
16					.8383	.7621	
18		.1181					
24	.0229	.0476	.1353	.0229	.2134	.6249	.503
Max	.0991	.1181	.1353	.0305	.8383	.7621	.8535
Min	.0229	.04	.1353	.0229	.2134	.6249	.503
Avg	.061	.0686	.1353	.0267	.6148	.6706	.6783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 204 / 11KV Son feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0591		.0495			
8					.6706	.9297	
12	.101			.1334			
16					.9145	.8535	
18	.1124	.1257	.1429				.5639
24	.0343	.0362	.0381	.0495	.7773	.3353	
Max	.1124	.1257	.1429	.1334	.9145	.9297	.5639
Min	.0343	.0362	.0381	.0495	.6706	.3353	.5639
Avg	.0826	.0737	.0905	.0775	.7875	.7062	.5639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 205 / 11KV Rajbardi feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0762		.0457			
8					1.9509	1.7985	2.0881
12	.0876			.0495			
16					1.7375	1.9357	
18	.2743	.16	.2858				
24	.0324	.0457	.1257	.0572	.3658	.442	1.1279
Max	.2743	.16	.2858	.0572	1.9509	1.9357	2.0881
Min	.0324	.0457	.1257	.0457	.3658	.442	1.1279
Avg	.1314	.0940	.2058	.0508	1.3514	1.3921	1.608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334017 / 33/11KV Dhadgaon

Feeder No / Name : 207 / 11 KV UMRANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.1315		.0324			
8					.503	1.2346	1.3717
16					1.3717	1.0974	
18		.1715	.0381				
24	.0381	.1162	.0305	.0381	1.0822	1.0212	.823
Max	.0381	.1715	.0381	.0381	1.3717	1.2346	1.3717
Min	.0381	.1162	.0305	.0324	.503	1.0212	.823
Avg	.0381	.1397	.0343	.0353	.9856	1.1177	1.0974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334031 / 33/11KV Kakarda

Feeder No / Name : 201 / 11KV Kakarda feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.439	.4024	.4435	.4755	.543	.6154	
8	.5973	.5359	.543	.5914	.5914	.6584	.5544
12	.5792	.815	.691	.5316		.7522	.7133
16	.4298	.6762	.5493	.4961	.6447	.567	.6626
20	.7701	.964	.8954	.5281	.7095	.6805	.8145
24	.5068	.4435	.5121	.567	.5014	.6154	
Max	.7701	.964	.8954	.5914	.7095	.7522	.8145
Min	.4298	.4024	.4435	.4755	.5014	.567	.5544
Avg	.5537	.6395	.6057	.5316	.598	.6482	.6862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334031 / 33/11KV Kakarda

Feeder No / Name : 202 / 11KV Ghatali Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2241	.2402	.2054	.2587	.2829	.2534	.394
8	.3109	.2614	.2772	.3142	.2987	.2957	.4481
12	.3898	.4119	.3258	.362	.4252	.3681	.4755
16	.3506	.333	.2715	.3258	.2896	.3582	.4755
20	.3988	.4435	.4525	.3361	.2957	.499	.4755
24	.2561	.3361	.2241	.2957	.2641	.2957	.394
Max	.3988	.4435	.4525	.362	.4252	.499	.4755
Min	.2241	.2402	.2054	.2587	.2641	.2534	.394
Avg	.3217	.3377	.2928	.3154	.3094	.3450	.4438



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

DHADGAON S/DN.[838] BU 4838

Substation No/ Name :- 334031 / 33/11KV Kakarda

Feeder No / Name : 203 / 11 KV VALVAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.0373		.037
8	.0373				.0377		.0354
12	.0373	.0554	.0373	.0373	.0362	.0185	.0362
16	.0362	.037		.037		.0366	.0362
20	.0549	.0554	.0373	.0373	.0377	.0366	.0373
24	.0373				.0373		.0373
Max	.0549	.0554	.0373	.0373	.0377	.0366	.0373
Min	.0362	.037	.0373	.037	.0362	.0185	.0354
Avg	.0406	.0493	.0373	.0372	.0372	.0306	.0366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 201 / 11 KV JAVADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.5699	1.7071		
8			1.6918	1.9357
12			2.1491	1.9204
24	1.5394	1.7071		
Max	1.5699	1.7071	2.1491	1.9357
Min	1.5394	1.7071	1.6918	1.9204
Avg	1.5547	1.7071	1.9205	1.9281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 202 / 11KV MANDANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1715	.3772	.3772	.3429	.2743		.2743
12	.2058	.1715	.2058		.1372	.3086	.2743
16	.1886	.1715					
20	.3429	.2572	.3086		.3429	.2915	.3086
24	.1715	.1715	.1715	.1372	.1715	.1715	.1715
Max	.3429	.3772	.3772	.3429	.3429	.3086	.3086
Min	.1715	.1715	.1715	.1372	.1372	.1715	.1715
Avg	.2161	.2298	.2658	.2401	.2315	.2572	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 203 / 11KV BHONGRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3048	.3506	.3963	1.0974	1.5851		1.5851
8	1.7833	1.6766	1.5242	.442	.4115	.4115	.4572
12	1.9509	1.89	1.9052		.4877	.6401	.5792
24	.3048	.3658	.4268	1.2955	1.6766	1.6766	1.829
Max	1.9509	1.89	1.9052	1.2955	1.6766	1.6766	1.829
Min	.3048	.3506	.3963	.442	.4115	.4115	.4572
Avg	1.0860	1.0708	1.0631	.9450	1.0402	.9094	1.1126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 205 / 11KV DONGARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.7985	2.0119		1.9509
8	1.9966	2.1948	2.0881				
12	2.4387	2.6063	2.4234				
24				1.9509	1.89	1.9814	2.0576
Max	2.4387	2.6063	2.4234	1.9509	2.0119	1.9814	2.0576
Min	1.9966	2.1948	2.0881	1.7985	1.89	1.9814	1.9509
Avg	2.2177	2.4006	2.2558	1.8747	1.9510	1.9814	2.0043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 206 / 11 KV DONGARGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.583	.4287	.4115	.5487	.583		.4458
12	.5487	.4287	.4801	.5144	.583	.3944	
16	.3772	.3772		.3944		.4115	
20	.6859	.6173	.6173	.6859	.5487	.6859	.6173
24	.3601	.3086	.3258	.4115	.3429	.3086	.3429
Max	.6859	.6173	.6173	.6859	.583	.6859	.6173
Min	.3601	.3086	.3258	.3944	.3429	.3086	.3429
Avg	.5110	.4321	.4587	.5110	.5144	.4501	.4687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 207 / 11KV DAMALDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.9662	2.1643	1.7071				
8				2.1948	2.3472		2.3777
12				2.6216	2.4387	2.4539	2.6825
13					2.3472		
24	2.2558	2.1948	1.7375				
Max	2.2558	2.1948	1.7375	2.6216	2.4387	2.4539	2.6825
Min	1.9662	2.1643	1.7071	2.1948	2.3472	2.4539	2.3777
Avg	2.111	2.1796	1.7223	2.4082	2.3777	2.4539	2.5301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 208 / 11KV DAMALDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1715	.2058	.2058	.2058	.1715		.2058
12		.1715	.1372	.1886	.1543	.12	.1372
16	.1886	.1715		.1715		.1715	
20	.1715	.2743	.2229	.2229	.2058	.2572	.2229
24	.12	.12	.1886	.1372	.12	.1372	.1886
Max	.1886	.2743	.2229	.2229	.2058	.2572	.2229
Min	.12	.12	.1372	.1372	.12	.12	.1372
Avg	.1629	.1886	.1886	.1852	.1629	.1715	.1886



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 210 / 11 KV JAVADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.463	.4287	.4115	.4115	.4801
12	.5144	.4115		.5316	.4115
16	.5144			.4801	
20	.6859	.583	.5487	.6516	
24	.3258	.3086	.3086	.3944	.4115
Max	.6859	.583	.5487	.6516	.4801
Min	.3258	.3086	.3086	.3944	.4115
Avg	.5007	.4330	.4229	.4938	.4344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334005 / MANDANA

Feeder No / Name : 211 / 11KV SHAHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.6859	.8078		.8383
8	.8383	.9145	.9907				
12	1.1279	1.1279	1.0669				
24				.7316	.9145	.7621	.9755
Max	1.1279	1.1279	1.0669	.7316	.9145	.7621	.9755
Min	.8383	.9145	.9907	.6859	.8078	.7621	.8383
Avg	.9831	1.0212	1.0288	.7088	.8612	.7621	.9069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 201 / 11KV MHASAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.9052	2.4196	1.7071	1.7985
7				1.8595	2.0005	1.5699	1.8138
8	2.8387	1.3908	.381				
11		2.3472	2.4082				
15	2.3167	1.448	2.2405				
24				2.1338	2.5911	1.768	1.8442
Max	2.8387	2.3472	2.4082	2.1338	2.5911	1.768	1.8442
Min	2.3167	1.3908	.381	1.8595	2.0005	1.5699	1.7985
Avg	2.5777	1.7287	1.6766	1.9662	2.3371	1.6817	1.8188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 202 / 11KV SULWADE ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.1719	2.1719	1.6613				
7	2.191	2.3815	1.7223				
8				1.6918	2.3434	1.7528	1.7071
11				1.9509	2.0271	1.9966	2.0881
15				1.9052	1.89	1.7833	1.9814
24	2.1719	2.2481	1.6309				
Max	2.191	2.3815	1.7223	1.9509	2.3434	1.9966	2.0881
Min	2.1719	2.1719	1.6309	1.6918	1.89	1.7528	1.7071
Avg	2.1783	2.2672	1.6715	1.8493	2.0868	1.8442	1.9255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 203 / Amoda ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.7147	1.6766	1.2346				
7	1.6766	1.5813	1.326				
8				1.4022	2.21	1.7375	1.8138
11				1.9357	2.1186	2.0576	2.21
15				1.89	2.0271	2.1491	2.1491
24	1.7909	1.7909	1.2041				
Max	1.7909	1.7909	1.326	1.9357	2.21	2.1491	2.21
Min	1.6766	1.5813	1.2041	1.4022	2.0271	1.7375	1.8138
Avg	1.7274	1.6829	1.2549	1.7426	2.1186	1.9814	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 205 / 11KV NAVALPUR AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.829	2.2291	1.7375	1.2346
7				2.0576	2.3434	1.829	1.2803
8	2.8578	2.915	2.1948				
11	2.4234	2.332	2.2862				
15	2.2862	2.332	2.1948				
24				1.9662	2.2862	1.829	1.2346
Max	2.8578	2.915	2.2862	2.0576	2.3434	1.829	1.2803
Min	2.2862	2.332	2.1948	1.829	2.2291	1.7375	1.2346
Avg	2.5225	2.5263	2.2253	1.9509	2.2862	1.7985	1.2498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 207 / 11KV MHASAWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6859	.7621	.6249	.4877	.724	.6401	.6401
11	.4572	.4725	.4115	.503	.5335	.5182	.5639
15	.3048	.3506		.3506	.3506	.381	.3506
18	.6287	.5335	.5182	.7621	.4572	.4572	.5906
21	.6287	.5335	.5335	.6668	.503	.5182	.6668
24	.4191	.4382	.4268	.3963	.4572	.4572	.4268
Max	.6859	.7621	.6249	.7621	.724	.6401	.6668
Min	.3048	.3506	.4115	.3506	.3506	.381	.3506
Avg	.5207	.5151	.5030	.5278	.5043	.4953	.5398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 208 / 11KV DARA AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	3.1436	3.4294	2.2862				
7	3.1436	3.1436	2.332				
8				2.4234	3.658	2.9721	2.4691
11				3.3227	3.658	3.3532	3.2769
15				3.1703	3.4294	3.1245	2.9721
24	3.1436	3.5437	2.4691				
Max	3.1436	3.5437	2.4691	3.3227	3.658	3.3532	3.2769
Min	3.1436	3.1436	2.2862	2.4234	3.4294	2.9721	2.4691
Avg	3.1436	3.3722	2.3624	2.9721	3.5818	3.1499	2.9060



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334009 / MHASAWAD

Feeder No / Name : 209 / 11KV DARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4763	.4382	.381	.4115	.5144	.4268	
11	.4268	.503	.442	.503	.2134	.5182	.5182
15	.4115	.3506	.4268	.4115	.4877	.4572	
18	.6097	.5335	.503	.7049	.4572	.5487	.6859
21	.5335	.442	.442	.6097	.4725	.4877	.5716
24	.4763	.4572	.3963	.3963	.4763	.4268	.442
Max	.6097	.5335	.503	.7049	.5144	.5487	.6859
Min	.4115	.3506	.381	.3963	.2134	.4268	.442
Avg	.4890	.4541	.4319	.5062	.4369	.4776	.5544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334014 / 33/11KV Holmohida S/S

Feeder No / Name : 203 / 11KV BHAGAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.9357	2.0271	2.1643	2.1948
8		2.2862	2.4387				
12	2.915	2.8464	2.5301				
24				1.89	2.0119	2.1338	2.0119
Max	2.915	2.8464	2.5301	1.9357	2.0271	2.1643	2.1948
Min	2.915	2.2862	2.4387	1.89	2.0119	2.1338	2.0119
Avg	2.915	2.5663	2.4844	1.9129	2.0195	2.1491	2.1034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 201 / 11KV LACHORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.9145	.9602	.9755				
7	.8688	.9907	1.0059				
8				1.1126	1.387	1.3565	1.3413
12				1.4784	1.5242	1.4022	1.2955
15					1.4784	1.448	1.2651
24	.945	.9907	1.0059				
Max	.945	.9907	1.0059	1.4784	1.5242	1.448	1.3413
Min	.8688	.9602	.9755	1.1126	1.387	1.3565	1.2651
Avg	.9094	.9805	.9958	1.2955	1.4632	1.4022	1.3006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 202 / 11KV KUDAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.2346	1.2955	1.5089	1.2689
7				1.3717	1.2955	1.3565	1.286
8	1.5089	1.5851	1.2803				
12	1.6461	1.6613	1.7071				
15	1.6156	.7926	1.8519				
24				1.5089	1.4022	1.6004	1.0669
Max	1.6461	1.6613	1.8519	1.5089	1.4022	1.6004	1.286
Min	1.5089	.7926	1.2803	1.2346	1.2955	1.3565	1.0669
Avg	1.5902	1.3463	1.6131	1.3717	1.3311	1.4886	1.2073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 204 / 11KV KUDAWAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2229		.2572	.2572	.2229	.1715	.2229
9	.3086	.3258	.2572	.2915	.2229	.2572	.2743
12	.2229	.2229	.2058	.2058	.1886	.2058	.2058
15			.1715				
16	.2229	.2058			.2229	.1886	.2058
20	.3258	.2915	.3258	.2572	.2572	.2743	.2915
24	.1715	.1886	.2229	.2058	.1543	.1715	.1886
Max	.3258	.3258	.3258	.2915	.2572	.2743	.2915
Min	.1715	.1886	.1715	.2058	.1543	.1715	.1886
Avg	.2458	.2469	.2401	.2435	.2115	.2115	.2315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 205 / 11 KV PADALDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.3413	1.4937	1.448				
7	1.2955	1.448	1.4632				
8				1.4937	1.6918	1.6004	1.7375
12				1.7985	1.8442	1.9052	1.7833
15					1.7071	1.9204	1.768
24	1.4022	1.5394	1.4632				
Max	1.4022	1.5394	1.4632	1.7985	1.8442	1.9204	1.7833
Min	1.2955	1.448	1.448	1.4937	1.6918	1.6004	1.7375
Avg	1.3463	1.4937	1.4581	1.6461	1.7477	1.8087	1.7629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 206 / 11 KV BHUTE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.2498	2.6978		1.4022
7				1.4327	2.8959		1.5546
8	1.9052	1.8595	1.6156				
12	2.1491	2.271	1.7985				
15	1.9814	2.1338	1.6309				
24				1.2498	1.387	1.6156	1.5242
Max	2.1491	2.271	1.7985	1.4327	2.8959	1.6156	1.5546
Min	1.9052	1.8595	1.6156	1.2498	1.387	1.6156	1.4022
Avg	2.0119	2.0881	1.6817	1.3108	2.3269	1.6156	1.4937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334020 / KUDAWAD

Feeder No / Name : 208 / padalda gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4458	.4458	.463	.4458	.463	.4458	.4801
9	.5487	.5316	.5316	.5316	.5316	.583	.5316
12	.2915	.2743	.2915	.2572	.2915	.3086	.3086
16	.2743	.3258		.2743	.2572	.2743	.3258
20	.5144	.4973	.5144	.5144	.4801	.463	.4801
24	.3086	.2743	.2915	.3772	.2743	.3258	.2915
Max	.5487	.5316	.5316	.5316	.5316	.583	.5316
Min	.2743	.2743	.2915	.2572	.2572	.2743	.2915
Avg	.3972	.3915	.4184	.4001	.3830	.4001	.4030



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 201 / 11KV SULTANPUR AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
5	.0221		
10			.2496
11		.2705	
Max	.0221	.2705	.2496
Min	.0221	.2705	.2496
Avg	.0221	.2705	.2496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 202 / 11KV SULTANPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.061	.0457
5	.0069	.0762	.0819
9	.0069		
10			.0667
11		.0705	
13	.0044		
18	.0082	.0819	
Max	.0082	.0819	.0819
Min	.0044	.061	.0457
Avg	.0066	.0724	.0648

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 203 / 11KV RAIKHED AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.3163	.322
5		.3239	.3239
9	.0406		
13	.037		
Max	.0406	.3239	.3239
Min	.037	.3163	.322
Avg	.0388	.3201	.3230

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 204 / 11 KV RAIKHED GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0286	.0248
5	.004	.0476	.0419
9	.005		
10			.0533
11		.0381	
13	.003		
18	.0042	.0457	
Max	.005	.0476	.0533
Min	.003	.0286	.0248
Avg	.0041	.04	.04

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 205 / 11 KV KHARGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18
HR	Load (MW)
5	.0457
Max	.0457
Min	.0457
Avg	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334028 / 33/11 KV Sultanpur

Feeder No / Name : 206 / 11 KV BRAMHANPURI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0191	.04
5	.0036	.04	
9	.0034		
10			.0267
11		.0171	
13	.0015		
18	.0023	.0267	
Max	.0036	.04	.04
Min	.0015	.0171	.0267
Avg	.0027	.0257	.0334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334037 / SAVAKHEDA

Feeder No / Name : 201 / 11KV SAVAKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5316	.583	.5144	.463	.5144	.5144	.5144
12	.4115	.3601		.4115	.4115	.1715	.3772
16	.4115	.4287		.4115	.4287	.4287	.463
20	.5144	.4115	.463	.5144	.5144	.5144	.5658
23					.3258		
24	.2743	.3086	.2915	.3086	.2572	.3086	.3086
Max	.5316	.583	.5144	.5144	.5144	.5144	.5658
Min	.2743	.3086	.2915	.3086	.2572	.1715	.3086
Avg	.4287	.4184	.4230	.4218	.4087	.3875	.4458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334037 / SAVAKHEDA

Feeder No / Name : 204 / 11 KV LOHARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.332	2.2862		2.1338	2.1948	2.1643	2.1643
20	1.829	1.829	1.6004	1.6461	1.7375	1.829	1.768
Max	2.332	2.2862	1.6004	2.1338	2.1948	2.1643	2.1643
Min	1.829	1.829	1.6004	1.6461	1.7375	1.829	1.768
Avg	2.0805	2.0576	1.6004	1.8900	1.9662	1.9967	1.9662



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 201 / 11KV ISLAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8402	.7202	.7716	.7545	.6173	.8402	.6344
8		1.0288	.9259	1.0802	.9945	.8916	.7716
16	1.0631	.7716		.9259	.9431	.8059	
20	1.0288	1.046	1.0288	1.0802	.9945	.8916	.7888
24	.6516	.6516	.823	.6859	.6344	.6859	.6516
Max	1.0631	1.046	1.0288	1.0802	.9945	.8916	.7888
Min	.6516	.6516	.7716	.6859	.6173	.6859	.6344
Avg	.8959	.8436	.8873	.9053	.8368	.8230	.7116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 202 / 11KV ISLAMPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				2.4387		2.3929	2.2253
8	2.8197	2.6216	2.4387				
12	2.7435	2.8045	2.6825				
15			2.8045				
24				2.5149	2.5758	2.4691	2.3167
Max	2.8197	2.8045	2.8045	2.5149	2.5758	2.4691	2.3167
Min	2.7435	2.6216	2.4387	2.4387	2.5758	2.3929	2.2253
Avg	2.7816	2.7131	2.6419	2.4768	2.5758	2.431	2.271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 203 / 11KV AMBAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7621	.7316	.7926				
8				.7926	.884	.7468	.8535
12				1.0974	.8993	.9755	1.0669
24	.6097	.7011	.6706				
Max	.7621	.7316	.7926	1.0974	.8993	.9755	1.0669
Min	.6097	.7011	.6706	.7926	.884	.7468	.8535
Avg	.6859	.7164	.7316	.945	.8917	.8612	.9602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA - II S/DN[547] BU 0540

Substation No/ Name :- 334042 / ISLAMPUR

Feeder No / Name : 204 / 11KV RANIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.326	1.2955	1.326				
8				1.448	1.7223	1.5242	1.6309
12				1.7071	1.9204	1.9509	2.1186
24	1.1279	1.2193	1.1126				
Max	1.326	1.2955	1.326	1.7071	1.9204	1.9509	2.1186
Min	1.1279	1.2193	1.1126	1.448	1.7223	1.5242	1.6309
Avg	1.2270	1.2574	1.2193	1.5776	1.8214	1.7376	1.8748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 201 / 11KV PUSNAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8402	.6836	.8501	2.7496	2.4533	2.9447	2.4741
7							2.64
8	3.0994	2.9944					
12	2.9675	3.2773	2.2546		.57	.5731	.1638
16					.5121	.4755	.4572
20	.8848	1.0679	.57	.7682	.8642	.8131	.9339
24	.5415	.4161	.5228	2.6825	2.3331	2.7913	2.7343
Max	3.0994	3.2773	2.2546	2.7496	2.4533	2.9447	2.7343
Min	.5415	.4161	.5228	.7682	.5121	.4755	.1638
Avg	1.6667	1.6879	1.0494	2.0668	1.3465	1.5195	1.5672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 202 / 11KV KALAMBU

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.4842	1.7878	1.531	.2812	.2401	.333	.2656
7	1.825		1.7718				
8				1.4327	1.4998	1.8427	
12	.1802			1.4685	1.6766	2.0058	1.7071
16	.4961				1.6091		
20	.4915	.6219	.25	.4531	.5281	.6584	.5312
24	1.6404	1.6297	1.531	.2812	.2204	.208	
Max	1.825	1.7878	1.7718	1.4685	1.6766	2.0058	1.7071
Min	.1802	.6219	.25	.2812	.2204	.208	.2656
Avg	1.0196	1.3465	1.2710	.7833	.9624	1.0096	.8346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 203 / 11KV VARUL KANADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.9728	1.1744	.9755				
7	1.2715		1.2178				
8				1.0288	1.1797	1.4148	
12				1.0364	1.1145	1.3394	1.1288
24	.9869	1.1096	.9145				
Max	1.2715	1.1744	1.2178	1.0364	1.1797	1.4148	1.1288
Min	.9728	1.1096	.9145	1.0288	1.1145	1.3394	1.1288
Avg	1.0771	1.142	1.0359	1.0326	1.1471	1.3771	1.1288

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 204 / 11KV BILADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2195	.1753	.2218	.2058	.1943	.2103	.2534
8					.2155		
12	.1677	.1075	.1848	.2012	.1296	.1433	.1448
16	.1619	.1629		.1619	.1619	.1267	.1646
20	.2623	.3547	.2587	.2559	.25	.3326	.2195
24	.128	.104	.0914	.1494	.1006	.1214	.1143
Max	.2623	.3547	.2587	.2559	.25	.3326	.2534
Min	.128	.104	.0914	.1494	.1006	.1214	.1143
Avg	.1879	.1809	.1892	.1948	.1753	.1869	.1793



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 205 / 11KV KURHAWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				1.9052	1.6362	1.9806	1.5466
7							1.829
8		2.1491					
12	2.0934	2.3891	2.1033				
24				1.829	1.6707	1.9244	1.5653
Max	2.0934	2.3891	2.1033	1.9052	1.6707	1.9806	1.829
Min	2.0934	2.1491	2.1033	1.829	1.6362	1.9244	1.5466
Avg	2.0934	2.2691	2.1033	1.8671	1.6535	1.9525	1.6470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 206 / 11KV LIS-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0381	.0526	.0572	.0373	.0381	.0351	.0381
7	.1448		.1848				.0732
8	.0572	.0358		.2401	.0572	.0358	
12	.1715	.2534	.1494	.1494	.1905	.0366	.0762
16	.2328	.0914		.3856	.2896	.1294	.0953
20	.0953	.1307	.0373	.1524	.0953	.168	.0953
24	.0381	.052	.0381	.0373	.0572	.052	.0381
Max	.2328	.2534	.1848	.3856	.2896	.168	.0953
Min	.0381	.0358	.0373	.0373	.0381	.0351	.0381
Avg	.1111	.1027	.0934	.1670	.1213	.0762	.0694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 207 / 11KV SARANGKHEDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.9425	.7712	.8501	.8916	.6481	.8063	.8779
7	.2103		.0701				.208
8	.3174	.3189		.3086	1.0105	1.2536	
12	.8848	.985	.7842	.6964	.6706	.7577	.9259
16	.8322	.9774		.703	.9122		.4973
20	.8173	.9877	1.0082	.8431	.8768	1.0562	.9722
24	.6653	.5375	.5544	.5487	.5601		.5544
Max	.9425	.9877	1.0082	.8916	1.0105	1.2536	.9722
Min	.2103	.3189	.0701	.3086	.5601	.7577	.208
Avg	.6671	.7630	.6534	.6652	.7797	.9685	.6726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334010 / SARANGKHEDA

Feeder No / Name : 210 / SARANGKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.2291	2.5415	1.8061				
7	1.9938		2.0631				
8				2.0576	2.4387	3.7209	
12				2.0391	3.4294		3.1017
24	2.4768	2.5139	1.8534				
Max	2.4768	2.5415	2.0631	2.0576	3.4294	3.7209	3.1017
Min	1.9938	2.5139	1.8061	2.0391	2.4387	3.7209	3.1017
Avg	2.2332	2.5277	1.9075	2.0484	2.9341	3.7209	3.1017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334013 / 33 KV Kukawal

Feeder No / Name : 201 / 11KV JAINAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1905	.1509	2.7183	3.1493
8	2.6852	2.5987		.3353
12	3.408		3.514	.1276
16	.3071	3.0849	.2321	.2126
20	.3155	.3391	.381	.4085
Max	3.408	3.0849	3.514	3.1493
Min	.1905	.1509	.2321	.1276
Avg	1.3813	1.5434	1.7114	.8467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 202 / 11KV TARHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.2384	1.3336	1.1431	1.4289
9	2.0005	1.8099	1.6194				
15	1.9052	1.6194	1.6194				
24				1.3336	1.3336	1.2384	1.1431
Max	2.0005	1.8099	1.6194	1.3336	1.3336	1.2384	1.4289
Min	1.9052	1.6194	1.6194	1.2384	1.3336	1.1431	1.1431
Avg	1.9529	1.7147	1.6194	1.286	1.3336	1.1908	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 203 / 11KV PARIVARDHA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.9526	.9526	.9526	1.1431	1.0479	.9526	.9526
15	.4763	.381	.5716	.4763	.5716	.4763	.4763
17			.6668				
21	.7621	.8573	.6668	.9526	.8573	.8573	
24	.4763	.4763	.4763	.5716	.5716	.4763	.4763
Max	.9526	.9526	.9526	1.1431	1.0479	.9526	.9526
Min	.4763	.381	.4763	.4763	.5716	.4763	.4763
Avg	.6668	.6668	.6668	.7859	.7621	.6906	.6351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 204 / 11KV JAWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.4289	1.4289	1.5242			
9				1.7147	2.0957	2.2862
15				2.191	2.191	2.191
24	1.5242	1.5242	1.5242			
Max	1.5242	1.5242	1.5242	2.191	2.191	2.2862
Min	1.4289	1.4289	1.5242	1.7147	2.0957	2.191
Avg	1.4766	1.4766	1.5242	1.9529	2.1434	2.2386



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 205 / SONAWAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.9052	1.9052	2.0005				
9				2.2862	2.6673	.9526	2.6673
15				2.6673	2.6673	2.6673	2.4768
24	2.0957	1.9052	2.0957				
Max	2.0957	1.9052	2.0957	2.6673	2.6673	2.6673	2.6673
Min	1.9052	1.9052	2.0005	2.2862	2.6673	.9526	2.4768
Avg	2.0005	1.9052	2.0481	2.4768	2.6673	1.8100	2.5721

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334015 / PARIVARDHA

Feeder No / Name : 206 / VELHAWAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.1431	1.3336	1.6194	1.4289
9	1.7147	1.7147	1.7147				
15	1.7147	1.7147	1.6194				
24				1.3336	1.3336	1.7147	1.5242
Max	1.7147	1.7147	1.7147	1.3336	1.3336	1.7147	1.5242
Min	1.7147	1.7147	1.6194	1.1431	1.3336	1.6194	1.4289
Avg	1.7147	1.7147	1.6671	1.2384	1.3336	1.6671	1.4766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334018 / 33 kv Torkheda

Feeder No / Name : 201 / 11KV TORKHEDA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
1		2.6139
4	2.4272	2.5953
8		.8589
12	.3734	
18	2.6139	
24	2.6513	2.6513
Max	2.6513	2.6513
Min	.3734	.8589
Avg	2.0165	2.1799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334018 / 33 kv Torkheda

Feeder No / Name : 202 / 11KV KAKARDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
1	.2054	.1867
4	.1867	.1867
8	3.5101	3.2861
12	3.4355	
24	.2241	.2241
Max	3.5101	3.2861
Min	.1867	.1867
Avg	1.5124	.9709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 201 / 11KV Tarhawad Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.8595	1.9814	2.0119	
2				1.829	2.0424	2.0424	1.829
3				1.7985	2.4006	2.2291	
4				1.7985	2.3663	2.1605	1.7985
5				1.768	2.2805	1.829	
6				1.768	1.9814	1.8595	1.7528
7				1.768	2.0119	2.1605	1.7223
8	2.0729	2.0934	2.0778				
9	2.1186	2.1795	2.0424				
10	2.1491	2.1338	2.0424				
11	2.234	2.3472	2.3663				
12	2.2497	2.2862	2.2977				
13	2.3122		2.0729				
14	2.2809	2.2253					
15	2.1948	2.1795					
22			2.2405	2.2291		1.9814	
23			1.9357			1.9685	
24					1.9204	2.2634	1.906
Max	2.3122	2.3472	2.3663	2.2291	2.4006	2.2634	1.906
Min	2.0729	2.0934	1.9357	1.768	1.9204	1.829	1.7223
Avg	2.2015	2.2064	2.1345	1.8523	2.1231	2.0506	1.8017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 202 / 11KV Express prakasha  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.1543	.0914	.2058	.0305	
2		.1029		.0914	.2058	.0343	.1219
3	.1067	.12	.12	.0914	.2058	.0305	
4		.12	.1029		.1677	.0305	.0914
5	.1067	.1543	.1029	.0914	.1524	.0305	
6	.1067	.1372	.1029	.0914	.1524	.0914	.0457
7	.1067	.1543	.1029		.1524	.0914	
8	.0762	.12	.0857	.0762	.1029	.1029	.0457
9	.1029	.0914	.0914	.0857	.1372	.1067	.0457
10	.1372	.1372	.1372	.1715	.1372	.1219	.061
11		.1524	.1524	.1886	.12	.1219	.061
12	.1372	.0914		.1372	.1029	.1067	.0457
13	.12	.0914	.0914	.1543	.0914	.1219	.0305
14		.1067		.1029	.1067	.1524	.0457
15	.12	.1067		.1543	.1715	.1677	.0762
16		.1372		.1715	.0457	.1524	.0762
17	.1715		.1219	.1524	.0914	.12	.061
18	.1372	.0343	.1219	.1829	.1029	.1543	.061
19	.1372	.1715		.1829	.1372	.1372	.061
20	.12	.1543	.1677	.1524	.1219	.12	.061
21	.0857	.1372	.0762	.1715	.1372	.1029	.061
22	.1372	.1715	.0762	.0914		.1029	.0457
23	.1543	.1715				.1543	.0457
24	.1219	.0857	.1543		.1829	.0457	.1543
Max	.1715	.1715	.1677	.1886	.2058	.1677	.1543
Min	.0762	.0343	.0762	.0762	.0457	.0305	.0305
Avg	.1214	.1233	.1154	.1316	.1378	.1013	.0649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 203 / 11KV PRAKASHA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353			.3963	.3658	.3353	.3353
2	.3353	.3772	.4115	.3963	.5144	.3658	
3	.4268	.4115	.4458	.4268	.4877	.5144	.4572
4	.4877	.5487	.5487		.5487	.5487	
5	.5792	.6859	.6859	.381	.6859	.6097	.6097
9	.7545	.7316	.6344	.7888	.6097	.6706	.6097
10	.583	.5182	.4572	.5487		.5335	.4877
11		.4572	.3963	.4801		.4268	.4877
12	.4115	.3963	.3963	.4115	.3772	.3963	.4268
13	.4115	.3658	.4115	.3772			.4268
14		.3353		.3772	.3353	.3963	.3963
15	.4115	.3353		.4115		.3658	.3963
16		.3658		.3658	.4458	.3963	.4572
17	.4801		.5335	.3963	.3963	.4801	.4268
18	.5144	.4115	.4877	.3963	.4572	.4801	.4877
19	.6173	.583		.5487	.5182	.6173	.5792
20	.6173	.583	.5792	.6173	.5639	.6859	.6401
21	.6173	.583	.5487	.5792	.5792	.6173	.5792
22	.5487	.5144		.4877		.583	.5182
23	.4801	.4458	.4572			.5144	.4572
24	.3963	.4115	.4458		.4115	.3048	.4458
Max	.7545	.7316	.6859	.7888	.6859	.6859	.6401
Min	.3353	.3353	.3963	.3658	.3353	.3048	.3353
Avg	.5004	.4769	.4960	.4659	.4865	.4921	.4855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334022 / PRAKASHA

Feeder No / Name : 204 / 11 KV PRAKASHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7186					
2	.6706	.7186	.7499				
3	.6554	.7316					
4	.6401	.7499	.7811				
5	.6249	.7316	.7811				
6	.6554	.7343	.7811				
7	.6706	.7343	.7811				
8				.884	.9755	1.1488	1.0059
9				1.2186	1.2498	1.1431	1.2651
10				1.1873	1.2346	1.2346	1.3413
11				1.3717	1.2346	1.1888	1.3413
12				1.1888	1.406	1.1584	1.2955
13				1.1736	1.2193	1.1584	1.3565
14				1.1736	1.1584	1.1584	1.326
15				1.2193	1.1888	1.1431	1.326
22	.7655	.828					.9297
23	.7621	.823					.945
24	.7011	.7811	.7621				
Max	.7655	.828	.7811	1.3717	1.406	1.2346	1.3565
Min	.6249	.7186	.7499	.884	.9755	1.1431	.9297
Avg	.6832	.7551	.7727	1.1771	1.2084	1.1667	1.2132



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 201 / 11KV SHELTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		2.1142		2.1338	1.9913	1.7147	1.9509
17			2.0719				
24	1.7147	1.8861	1.5432	1.5146	1.6766	1.5003	1.5432
Max	1.7147	2.1142	2.0719	2.1338	1.9913	1.7147	1.9509
Min	1.7147	1.8861	1.5432	1.5146	1.6766	1.5003	1.5432
Avg	1.7147	2.0002	1.8076	1.8242	1.8340	1.6075	1.7471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 202 / 11KV TEMBHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6766	1.5242	1.6248	1.6792	1.8442	1.6644	1.3717
Max	1.6766	1.5242	1.6248	1.6792	1.8442	1.6644	1.3717
Min	1.6766	1.5242	1.6248	1.6792	1.8442	1.6644	1.3717
Avg	1.6766	1.5242	1.6248	1.6792	1.8442	1.6644	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 203 / 11KV VARUL KANADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.543	.6401	.6996	.7621
24	1.0669	1.0669	.543				
Max	1.0669	1.0669	.543	.543	.6401	.6996	.7621
Min	1.0669	1.0669	.543	.543	.6401	.6996	.7621
Avg	1.0669	1.0669	.543	.543	.6401	.6996	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 204 / BAMKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0669	1.0669	1.1431	.9602	1.0669	.9859	.9145
Max	1.0669	1.0669	1.1431	.9602	1.0669	.9859	.9145
Min	1.0669	1.0669	1.1431	.9602	1.0669	.9859	.9145
Avg	1.0669	1.0669	1.1431	.9602	1.0669	.9859	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334038 / SASDE

Feeder No / Name : 205 / 11 KV KANADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	1.7147	1.5306		1.5546	1.5455	1.5432	1.5546
17			1.5455				
24	1.7147	1.7147	1.2574	1.2483	1.3413	1.2574	1.5432
Max	1.7147	1.7147	1.5455	1.5546	1.5455	1.5432	1.5546
Min	1.7147	1.5306	1.2574	1.2483	1.3413	1.2574	1.5432
Avg	1.7147	1.6227	1.4015	1.4015	1.4434	1.4003	1.5489

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 201 / 11 KV OUTGOING VIKAS

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
6	2.6642	
10		3.0148
15		2.4714
18		2.5514
23		2.5065
24	2.0683	
Max	2.6642	3.0148
Min	2.0683	2.4714
Avg	2.3663	2.6360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 202 / 11 KV OUTGOING KUKDEL

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
6	1.4563	
10		1.5592
15		1.2715
18		1.3112
23		1.1999
24	.9816	
Max	1.4563	1.5592
Min	.9816	1.1999
Avg	1.2190	1.3355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 203 / 11 KV OUTGOING MALONI

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
10		2.0199
15		1.4563
18		1.595
23		1.5424
24	1.7703	
Max	1.7703	2.0199
Min	1.7703	1.4563
Avg	1.7703	1.6534



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN

SUBSTAT

Feeder No / Name : 401 / 33 KV RAPDRP SHAHADA

INCOMER-I Feeder KV- 33 /

INCOMING

DATE	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
6	4.0489	
15		3.6808
18		3.922
23		3.6808
24	3.1161	
Max	4.0489	3.922
Min	3.1161	3.6808
Avg	3.5825	3.7612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223] BU 5533

Substation No/ Name :- 334045 / 33/11 KV SHAHADA URBAN  
SUBSTATFeeder No / Name : 402 / 33 KV RAPDRP SHAHADA  
INCOMER-I Feeder KV- 33 /  
INCOMING

DATE	24-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
6	1.9433	
18		1.829
23		1.6575
24	1.3717	
Max	1.9433	1.829
Min	1.3717	1.6575
Avg	1.6575	1.7433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334048 / 33/11 Kv Tikhora subStation

Feeder No / Name : 201 / Tihora Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						1.2689	
6				1.0431	1.3546	1.2174	.8939
7				1.0014			
8		1.2483					
12	1.2334	1.2483	1.2483				
22				1.4232			
24				1.0709	1.3546	1.286	1.0288
Max	1.2334	1.2483	1.2483	1.4232	1.3546	1.286	1.0288
Min	1.2334	1.2483	1.2483	1.0014	1.3546	1.2174	.8939
Avg	1.2334	1.2483	1.2483	1.1347	1.3546	1.2574	.9614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

SHAHADA-I[223]

BU 5533

Substation No/ Name :- 334048 / 33/11 Kv Tikhora subStation

Feeder No / Name : 202 / Mohida Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					1.6461	1.5775	
6				1.2574	1.6461	1.5947	1.3611
7				1.3003			
8		1.6512					
12	1.5653	1.5752	1.5653				
22				1.7147			
24				1.3003	1.6804	1.6118	1.4118
Max	1.5653	1.6512	1.5653	1.7147	1.6804	1.6118	1.4118
Min	1.5653	1.5752	1.5653	1.2574	1.6461	1.5775	1.3611
Avg	1.5653	1.6132	1.5653	1.3932	1.6575	1.5947	1.3865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 201 / 11KV TALODA TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.267	1.448	1.6289	1.6289	1.6289	1.6289
2	1.448	1.267	1.448	1.6289			
3	1.448	1.267	1.448	1.6289			
4	1.8099	1.6289	1.8099	1.9909	2.1719	2.1719	2.1719
5	2.1719	2.1719	2.1719	2.3529			
6	2.8959	2.7149	2.8959	2.6244		2.8959	2.8959
7	3.0769	3.2579	3.4389	3.1674	3.0769	3.2579	3.2579
8	3.0769	2.7149	2.8959	3.0769	2.8959	2.8959	3.0769
9	2.5339	2.7149	2.7149	2.7149	2.5339	2.8959	2.7149
10	2.5339	2.1719	1.9909	2.3529	2.3529	2.3529	2.3529
11	1.9909	1.9909	1.8099	2.1719	2.1719	2.1719	2.3529
12	1.8099	1.6289	1.8099	1.8099		2.1719	1.9909
13	1.6289		1.8099	1.8099	1.8099	1.8099	1.8099
14	1.6289	1.448	.543	1.6289	1.6289		1.6289
15	1.6289	1.6289		1.6289	1.6289	1.6289	
16	1.6289	1.6289	1.086	1.6289	.905		
17	1.8099	1.448	.905	1.8099		1.9909	1.8099
18	2.1719	1.448	.9955	1.9909	2.1719	2.1719	2.1719
19	2.5339	1.9909	2.8959	2.3529	2.5339	2.7149	2.7149
20	2.3529		2.5339	2.3529	2.5339	2.5339	2.5339
21	2.1719		2.1719	2.1719	2.2624	2.3529	2.3529
22		2.3529	2.1719	1.9909	2.1719	2.1719	2.1719
23	1.8099	1.9909		1.8099	1.8099	1.9909	
24	1.448	1.448	1.6289	1.6289	1.6289	1.6289	1.6289
Max	3.0769	3.2579	3.4389	3.1674	3.0769	3.2579	3.2579
Min	1.448	1.267	.543	1.6289	.905	1.6289	1.6289
Avg	2.0460	1.9134	1.9375	2.0814	2.1065	2.2862	2.2926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 202 / 11KV TALAVA AG-I

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8383	.8097	.9717	.8097
2				.8383			
3				.8383			
4				.8383	.8097	.8097	.8097
5				.8383			
6				.8383		.8097	.8097
7				.8383	.8097	.8097	.9717
8	1.6194	1.2955	1.1336				
9	1.9433	1.2955	1.267				
10	1.9433	1.4575	1.448				
11	2.1719	1.6289	1.267				
12	2.1719	1.448	1.267				
13	1.9433	1.2955	1.267				
14		1.2955	1.267				
16	2.1719						
22			.8383	.8097	1.0059	.9717	
23				.8097	.9717	.8097	
24				.8383	.8097	.9717	.8097
Max	2.1719	1.6289	1.448	.8383	1.0059	.9717	.9717
Min	1.6194	1.2955	.8383	.8097	.8097	.8097	.8097
Avg	1.995	1.3881	1.2194	.8326	.8694	.8791	.8421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 203 / 11KV TALAVA AG-II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	1.9433	1.9433				
2	2.1052	1.9433	1.7814				
3	2.1052	1.9433	1.7814				
4	2.1052	1.9433	1.7814				
5	2.1052	1.9433	1.7814				
6	2.1052	1.9433	1.7814				
7	2.1052	1.9433	1.7814				
8				2.0119	2.5911	2.5911	2.2672
9				2.7149		2.8959	
10				2.7149		3.0769	
11				2.7149		3.0769	2.6825
12				2.7149			2.6825
13				2.4291		1.448	2.6825
14				2.4291			2.6825
15				2.4291		2.7149	
22		1.9433					2.2672
23	2.1052	1.9433					
24	2.2672	2.1052	1.9433				
Max	2.2672	2.1052	1.9433	2.7149	2.5911	3.0769	2.6825
Min	2.1052	1.9433	1.7814	2.0119	2.5911	1.448	2.2672
Avg	2.1412	1.9595	1.8219	2.5199	2.5911	2.6340	2.5441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 204 / 11KV CHINODA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.9433	2.1052				
2	1.9433	1.9433	2.1052				
3	1.9433	1.9433	2.1052				
4	1.9433	1.9433	2.1052				
5	1.9433	1.9433	2.1052				
6	1.9433	1.9433	2.1052				
7	1.9433	2.1052	2.1052				
8				2.5149	2.5911	2.5911	1.6194
9				3.2579	2.915	2.915	3.0178
10				3.0769	3.2579	.3258	3.0178
11				3.0769		3.0769	3.0178
12				3.0769	2.915	3.0769	3.0178
13				3.0769		3.2579	3.0178
14				2.753			2.8502
15						3.2579	
22		2.1052					2.4291
23	2.1052	2.1052					
24	1.9433	2.1052	2.1052				
Max	2.1052	2.1052	2.1052	3.2579	3.2579	3.2579	3.0178
Min	1.9433	1.9433	2.1052	2.5149	2.5911	.3258	1.6194
Avg	1.9613	2.0081	2.1052	2.9762	2.9198	2.6431	2.7485



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 206 / 11KV AMLAD AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	23-FEB-18	24-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
9	1.9433	2.1719	1.7814
10	1.9433	2.1719	1.9909
11	2.1719	2.1719	2.1719
12		2.1719	2.1719
13	1.9433	2.1719	1.9433
14		1.9433	
15	2.1719		2.1719
Max	2.1719	2.1719	2.1719
Min	1.9433	1.9433	1.7814
Avg	2.0347	2.1338	2.0386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334002 / TALODA

Feeder No / Name : 207 / 11KV AMLAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.362	.362	.362	.4525	.4525	.4525
2	.4525	.362	.362	.362			
3	.4525	.362	.362	.362			
4	.543	.543	.543	.543	.4525	.724	.543
5	.6335	.724	.724	.724			
6	.8145	.905	.905	.905			.8145
7	.9955	.905	.9955	.905	.9955	.905	.9955
8	.8145	.8145	.8145	.8145	.8145	.8145	.905
9	.6478	.724	.724	.6335	.724	.7287	.724
10	.6335	.543	.543	.543	.6335	.724	.6335
11	.4525	.543	.543	.543			
12	.4525	.543	.4858	.543	.4858		
13	.362	.543	.4858	.4525		.543	.543
14	.362	.543	.543	.543	.4525		.543
15	.362	.4858		.543		.543	
16	.362	.543	.543	.543			
17	.543	.724	.724	.6335			.724
18	.724	.8145	.724	.6335	.905		.8145
19	.8145	.905	.8145	.8145	.905	.905	.905
20	.724	.8145	.724	.8145	.905	.905	.8145
21	.724	.724	.724	.724	.6335	.724	.724
22		.543	.543	.543		.6335	.543
23	.543	.543		.543	.543	.543	
24	.4525	.4525	.4525	.4525		.4525	.4525
Max	.9955	.905	.9955	.905	.9955	.905	.9955
Min	.362	.362	.362	.362	.4525	.4525	.4525
Avg	.5790	.6236	.6201	.6033	.6848	.6856	.6957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 201 / 11KV KARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	2.3529	1.8861				
4			2.0576				
5		2.0576					
7	.724	2.0576	2.0576				
8				1.9719	3.0007	1.8861	.6859
11							3.0864
12				3.2579	3.2579	3.2579	
15				3.3436	3.0864	3.5294	
23	2.4434	1.8861					
Max	2.4434	2.3529	2.0576	3.3436	3.2579	3.5294	3.0864
Min	.724	1.8861	1.8861	1.9719	3.0007	1.8861	.6859
Avg	1.7988	2.0886	2.0004	2.8578	3.115	2.8911	1.8862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 202 / 11KV KADHEL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.8004	1.8861		1.8861
4				1.8004	1.7147		
5							1.8004
7		2.0576		1.8004	1.8861		1.8004
8	2.1434	2.0576	2.0576				
11	2.4863	2.4006					
12			2.2291				
15	2.2291	2.2291	2.0576				
22			1.8861				
23					1.8861	1.8861	
Max	2.4863	2.4006	2.2291	1.8004	1.8861	1.8861	1.8861
Min	2.1434	2.0576	1.8861	1.8004	1.7147	1.8861	1.8004
Avg	2.2863	2.1862	2.0576	1.8004	1.8433	1.8861	1.8290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 203 / 11KV MOD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.362	.362	.362	.543	.362
4						.543	
5		.6335	.724				.543
6				.724	.8145		
7	.724						
8						.724	
10		.362	.362			.543	
11		.362					.543
12	.543						
15		.362	.362	.4525	.362	.3429	
20	.8145	.724	.543	.724	.543	.724	
23	.4525	.362	.362	.362	.362	.362	
Max	.8145	.724	.724	.724	.8145	.724	.543
Min	.362	.362	.362	.362	.362	.3429	.362
Avg	.5792	.4525	.4525	.5249	.4887	.5403	.4827

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 204 / 11KV BORAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.543	.543	.543		.724
5	.905	.724	.905				
6				.905	.905		.905
8					.905		
10		.724	.724			.724	
11		.724					.724
12	.724			.724			
15		.543	.724		.724	.724	
20	1.086	.905	.905	1.086	.905	1.086	
23	.724	.724	.543		.724	.724	
Max	1.086	.905	.905	1.086	.905	1.086	.905
Min	.543	.543	.543	.543	.543	.724	.724
Avg	.7964	.6981	.724	.8145	.7843	.8145	.7843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 205 / 11KV MOHIDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2579			.7716	.7716	.9431	.8573
4					.8573	.9431	
7				1.0288	1.0288	.9431	.8573
8		1.0288	.9431				
11		1.1145					
12		1.1145	1.0288				
14	3.4294						
15		1.0288	1.0288				
23				.8573	.8573		.8573
Max	3.4294	1.1145	1.0288	1.0288	1.0288	.9431	.8573
Min	3.2579	1.0288	.9431	.7716	.7716	.9431	.8573
Avg	3.3437	1.0717	1.0002	.8859	.8788	.9431	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 206 / 11KV BORAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.7147	1.8861	2.0576	2.0576
4				1.7147	1.8004		1.8004
7				1.7147	1.9719	2.0576	2.0576
8	2.2291	2.2291	2.0576				
9		2.2291					
11		2.2291					
12	2.3148	2.0576	2.0576				
15	2.0576	2.0576	2.0576				
23					1.8861	2.0576	
Max	2.3148	2.2291	2.0576	1.7147	1.9719	2.0576	2.0576
Min	2.0576	2.0576	2.0576	1.7147	1.8004	2.0576	1.8004
Avg	2.2005	2.1605	2.0576	1.7147	1.8861	2.0576	1.9719



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334007 / BORAD

Feeder No / Name : 207 / 11KV MOD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.8861	1.8861				
4			1.8861				
5	1.7147						
7	1.6289	1.8861	1.8861				
8				1.8004	2.1434	2.2291	2.2291
11							2.572
12				2.0576	2.4006	2.4006	
15				2.0576	2.0576	2.4006	
23		2.0576					
Max	1.7147	2.0576	1.8861	2.0576	2.4006	2.4006	2.572
Min	1.6289	1.8861	1.8861	1.8004	2.0576	2.2291	2.2291
Avg	1.6861	1.9433	1.8861	1.9719	2.2005	2.3434	2.4006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 201 / 11KV AMONI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	2.2558				
8				2.8807	2.9569
10		3.4903	3.3532	3.6275	
11			3.3989	3.3532	
12		3.216	2.1643	2.21	
14			3.4751		
15				3.2312	
Max	2.2558	3.4903	3.4751	3.6275	2.9569
Min	2.2558	3.216	2.1643	2.21	2.9569
Avg	2.2558	3.3532	3.0979	3.0605	2.9569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 202 / 11KV BEDAPADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.5546	1.5242
8		1.9966		
12	2.3929			
15	2.1491			
Max	2.3929	1.9966	1.5546	1.5242
Min	2.1491	1.9966	1.5546	1.5242
Avg	2.271	1.9966	1.5546	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 203 / 11KV SHIRVE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	2.0729				
8				2.6978	2.8654
10		3.3532	3.3532	3.4598	
11			1.6766	3.0788	
12		3.2007	1.9052	3.0636	
13		1.5089			
15				2.652	
Max	2.0729	3.3532	3.3532	3.4598	2.8654
Min	2.0729	1.5089	1.6766	2.652	2.8654
Avg	2.0729	2.6876	2.3117	2.9904	2.8654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 204 / 11KV NARMADANAGAR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.4861			1.2955	1.4098
8			1.3336			1.2955	1.2384
10				.9907	.9526	1.0098	
11					.7811	.9145	
12		.8764		.9145	.8573	.8954	
14				.7621	.8764		
15		.9526				.724	
16	1.0479			1.1812			
18				1.2955			
19		1.4861					
20	1.2384	1.3336		1.2955	1.2955	1.2955	
21		1.2955			1.2955	1.3336	
22						1.2574	
23	1.2384						
Max	1.2384	1.4861	1.4861	1.2955	1.2955	1.3336	1.4098
Min	1.0479	.8764	1.3336	.7621	.7811	.724	1.2384
Avg	1.1749	1.1888	1.4099	1.0733	1.0097	1.1135	1.3241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 205 / 11KV NARMADANAGAR AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-FEB-18	24-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.5242	1.3717
8		1.3717		
15	1.6766			
Max	1.6766	1.3717	1.5242	1.3717
Min	1.6766	1.3717	1.5242	1.3717
Avg	1.6766	1.3717	1.5242	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334024 / SOMAVAL

Feeder No / Name : 206 / 11KV AMONI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.0669			1.0479	1.2955
8			.9907			.9526	1.2574
10				.6097	.9907	1.0479	
11					.9717	.9145	
12		.6097		.8764	.8383	.8764	
14				.6859	.9526		
15		.9145				.9907	
16	.9526	.9907		1.1431			
18		1.0479		1.2574			
19		1.0479					
20	1.1431	1.105		1.2193	1.2574	1.3717	
21		1.1431			1.2193	1.2955	
22						1.2765	
23	1.1431						
Max	1.1431	1.1431	1.0669	1.2574	1.2574	1.3717	1.2955
Min	.9526	.6097	.9907	.6097	.8383	.8764	1.2574
Avg	1.0796	.9798	1.0288	.9653	1.0383	1.0860	1.2765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 201 / 11KV PRATAPPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.9264		
2					2.6246	2.5777
3				2.8349		
4					2.6558	2.4996
5				2.7435		
6					2.7183	2.5777
7				2.8166		2.7801
8	3.9095	2.8121	2.8746			
9		3.437	3.914			
10	3.9095	3.7182	4.0604			
11		3.6557	3.9872			
12	3.7723	3.5307	4.1396			
13		3.4995	3.807			
14	3.8752	3.3745	3.8439			
15		3.2808	3.8043			
22			2.963		2.7496	
23			2.963			
24			2.9264		2.6871	
Max	3.9095	3.7182	4.1396	2.9264	2.7496	2.7801
Min	3.7723	2.8121	2.8746	2.7435	2.6246	2.4996
Avg	3.8666	3.4136	3.5712	2.8304	2.6871	2.6088



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 202 / 11KV PRATAPPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881		.3749			
2			.4218	.4251	.4374	.4062
3	.4805		.4687			
4			.4999	.4805	.4374	.4687
5	.5914		.5312			
6			.5624	.5914	.4999	.5312
7	.6653		.5937			
8	.6468		.6562	1.9959	.6249	.5624
9		.4531				
10		.4218	.5175	.5729	.5937	.499
11		.4218		.6099		
12	.5144	.3906	.4251		.4374	.3696
13		.3906				
14		.3125	.4435		.4062	.4066
15		.3749				
16		.4999	.5914		.5312	.5729
17		.5312				
18		.5624	.6283		.6249	.6838
20			.6283		.6874	.5914
22		.5312	.5175		.5937	.5914
23		.4999	.462			.462
24		.4687	.4066		.4062	.4066
Max	.6653	.5624	.6562	1.9959	.6874	.6838
Min	.3881	.3125	.3749	.4251	.4062	.3696
Avg	.5478	.4507	.5135	.7793	.5234	.5040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 203 / 11KV RANZANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
24	3.035
Max	3.035
Min	3.035
Avg	3.035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 204 / 11KV RANIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974		1.1561			
2			1.1561			
3	1.0608		1.2186			
4			1.2498			
5	1.0242		1.2498			
6			1.2498			
7	1.1458		1.2498			
8				1.39	1.531	1.4685
9				1.7558		2.0485
10				1.7002	1.6248	1.9022
11				1.885		2.0119
12					1.7497	1.9387
13						1.9753
14					1.7185	1.9022
15						1.829
22		1.2811				1.7002
23		1.2811				1.6095
24		1.2498				1.6263
Max	1.1458	1.2811	1.2498	1.885	1.7497	2.0485
Min	1.0242	1.2498	1.1561	1.39	1.531	1.4685
Avg	1.0821	1.2707	1.2186	1.6828	1.656	1.8193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 205 / 11 KV Ranzani Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435		.3125	.5175		
2			.3749		.3906	.3749
3	.5175		.4374	.5544		
4			.4374		.4687	.4374
5	.5914		.5312	.6653		
6			.5624		.5624	.4999
7	.6653		.5624	.7762		
8	.6283		.5937	.6653	.5937	.4687
9		.4999				
10		.4687	.4805	.5487	.3125	.5544
11		.4999		.5175		
12		.4062			.3125	.5175
13		.4062	.5175			
14		.3749	.5175		.4374	.4805
15		.4062				
16		.4687	.7023		.4687	.6653
17		.5937				
18		.5624			.5937	.7023
19			.8501			
20					.6249	.8501
21			.8131			
22		.5312			.5624	.7023
23		.4687	.5544			.5914
24		.4374	.5175		.4374	.5544
Max	.6653	.5937	.8501	.7762	.6249	.8501
Min	.4435	.3749	.3125	.5175	.3125	.3749
Avg	.5692	.4711	.5478	.6064	.4804	.5692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

JALGAON ZONE[058]

NANDURBAR CIRCLE[581]

SHAHADA DIVISION[584]

TALODA[224]

BU 5541

Substation No/ Name :- 334040 / Pratappur Substation

Feeder No / Name : 206 / 11 KV ROZWA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.1948		
2					2.0622	2.0309
3				2.0328		
4					2.0622	1.9997
5				2.1216		
6					2.0309	2.0934
7				2.4143		2.0119
8	2.7618	2.2028	2.1247			
9		2.7965	2.7435			
10		2.5934	2.963			
11		2.6402	2.8898			
12	2.9664	2.4684	2.8349			
13		2.5309	2.8166			
14		2.234	2.8898			
15		2.4528	2.809			
22			2.1807		2.0309	
23			2.2177			
24			2.3777		1.9997	
Max	2.9664	2.7965	2.963	2.4143	2.0622	2.0934
Min	2.7618	2.2028	2.1247	2.0328	1.9997	1.9997
Avg	2.8641	2.4899	2.6225	2.1909	2.0372	2.0340