

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 201 / 11 KV HOSPITAL FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715		.1715	.1715		.1543
2	.1715	.1715		.1715	.1715		.1543
3	.1715	.1886		.1715	.1715		.1543
4	.1715	.2058		.1715	.1886		.1715
5	.1715	.2229		.2058	.2229		.2058
6	.2743	.2743		.2915	.2915		.2401
7	.3944	.3772		.4115	.3772		.3429
8	.3944	.4287		.3429	.3944		
9	.4287	.4287	.4287		.4458		
10	.3944	.4115	.823	.3944	.3772	.3601	
11	.3086	.3258	.3258	.3601	.3086	.3086	
12	.2915	.2915	.2572	.3086	.2743	.2743	
13	.2572	.2743	.2401	.2401	.2401	.2743	
14	.2229		.2401	.2401	.2229	.2058	
15	.1886	.1886	.2229	.2229	.1886	.1715	
16	.1886	.1886	.2058	.2229	.1886	.1715	
17	.2229		.2229	.2229		.1886	.1886
18	.2743		.2572			.2058	.1886
19	.2572		.2743	.2743		.2572	.2743
20	.2572		.2915	.2572		.2572	.2401
21	.2572		.2572	.2572		.2229	.2572
22	.2401		.2401	.2058		.2058	.2229
23	.2058		.2229	.2058		.1886	.1886
24	.2058	.1886		.1886	.1886		.1715
Max	.4287	.4287	.823	.4115	.4458	.3601	.3429
Min	.1715	.1715	.2058	.1715	.1715	.1715	.1543
Avg	.2551	.2711	.3006	.2518	.2602	.2352	.2103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 202 / 11 KV YOGESHWARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429		.4115	.3429		.3429
2	.3429	.3429		.4115	.3429		.3048
3	.3429	.4115		.4115	.3429		.3429
4	.3429	.4801		.4115	.3429		.3429
5	.4115	.5487		.4801	.6173		.5487
6	.6859	.7545		.7545	.7545		.6859
7	1.0288	1.166		1.0288	1.0974		1.0288
8	1.166	1.166		1.0974	1.0974		
9	.9602	1.166	.8916		.8916		
10	.8916	.823	.823	.823	.823	.8916	
11	.6859	.7545	.7545	.7545	.6859	.823	
12	.6859	.6859	.6859	.6859	.6173	.7545	
13	.5487	.6173	.5487	.6173	.5487	.6859	
14	.4801		.5487	.5487	.4801	.5487	
15	.4801	.5487	.5487	.5487	.4801	.4801	
16	.5487	.5487	.6173	.5487	.5487	.5487	
17	.6173		.7545	.7545		.6173	
18	.823					.823	.6859
19	.8916		1.0288	.9602		.7545	.823
20	.823		.9602	.823		.7545	.823
21	.6859		.823	.6859		.7545	.7545
22	.5487		.6173	.5487		.6173	.6859
23	.4115		.4801	.4115		.4801	.5487
24	.3429	.3429		.4115	.3429		.3429
Max	1.166	1.166	1.0288	1.0974	1.0974	.8916	1.0288
Min	.3429	.3429	.4801	.4115	.3429	.4801	.3048
Avg	.6287	.6687	.7202	.6422	.6092	.6810	.5901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 204 / 11 KV LOKHANDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0364		1.2193	1.1584		1.1584
2	1.1431	1.0974		1.5242	1.2803		1.2193
3	1.2193	1.1584		1.5242	1.3413		1.2803
4	1.2193	1.2193		1.829	1.3413		1.3413
5	1.3413	1.2193		1.829	1.3413		1.4022
6	1.3413	1.2803		1.829	1.4022		1.5242
7	1.6766	1.7071		1.6766	1.5242		1.89
8	1.829	1.829		1.5242	1.768		
9	1.6461	1.6461	1.89		1.768		
10	1.5242	1.5851	1.5242	1.6461	1.5242	1.7071	
11	.061	.061					
12		.061		.061			
13	.061	.061					
14	.061						
16		.061					
17	.061						
18	.061		.061				.061
19	.061		.061	.1219			.0762
20	.061		.0762	.0914		.061	.061
21	.061		.0762	.0914		.061	.061
22	.061		.0762	.0914		.061	.061
23	.061		.0762	.061		.061	.061
24	.0762	.061		.061	.061		.061
Max	1.829	1.829	1.89	1.829	1.768	1.7071	1.89
Min	.061	.061	.061	.061	.061	.061	.061
Avg	.7033	.9389	.4801	.9488	1.3191	.3902	.7327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 205 / 11 KV MOREWADI-SAIGAON-
FEEDER Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6859		.6859	.6859		.6859
2	.7545	.6859		.6859	.6859		.6859
3	.7545	.6859		.7545	.823		.823
4	.7545	.823		.7545	.9602		1.0631
5	.8916	1.0288		.823	1.166		1.166
6	1.3717	1.3032		1.3717	1.4403		1.3032
7	1.7147	1.8519		1.8861	1.7833		1.7147
8	2.0233	1.989		2.0576	2.0576		
9	1.8519	1.8519	1.5775		1.9204		
10	1.5775	1.7147		1.6461	1.7147	1.4403	
11	1.4403	1.3032	1.3717	1.3717	1.3032	1.3032	
12	1.3032	1.2346	1.2346	1.3032	1.2346	1.166	
13	1.0974	1.0974	1.166	1.0974	1.2346	1.0974	
14	.9602		1.0288	1.0288	1.0288	.9602	
15	1.0288	1.0288	.9602	.9602	.8916	.9602	
16	1.166	1.0288	1.0974	1.0974	1.0974	.9602	
17	1.3032		1.3717	1.3032		1.166	1.166
18	1.5775		1.6461			1.4403	1.166
19	1.5775		1.6461	1.5775		1.4403	1.3717
20	1.4403		1.4403	1.4403		1.3717	1.166
21	1.2346		1.2346	1.2346		1.2346	1.0974
22	1.0288		1.0288	1.0974		1.0974	.9602
23	.8916		.823	.8916		.823	.7545
24	.7545	.6859		.7545	.6859		.6859
Max	2.0233	1.989	1.6461	2.0576	2.0576	1.4403	1.7147
Min	.7545	.6859	.823	.6859	.6859	.823	.6859
Avg	1.2189	1.1874	1.2591	1.1738	1.2184	1.1758	1.0540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 206 / 11 KV WAGHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.387	1.627	1.547		1.1736	1.0669	
12	1.2803	.2667	1.6004	.9602	1.547	1.4403	
13	1.768	1.4403	2.1948	1.0136	1.6537	1.4403	
14			1.7604	1.0136	1.547	.6935	
15	1.8671	.8535	1.7604	.9069	1.547	.5335	
16	1.9204	.9069	1.6004	1.6004	2.1262	1.6461	
17	1.8671		1.7337	1.4403		1.4403	1.9204
18	1.4937		1.4937			1.4403	1.7337
Max	1.9204	1.627	2.1948	1.6004	2.1262	1.6461	1.9204
Min	1.2803	.2667	1.4937	.9069	1.1736	.5335	1.7337
Avg	1.6548	1.0189	1.7114	1.1558	1.5991	1.2127	1.8271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 207 / 11 KV SHIVAJI CHOWK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2743		.3429	.3429		.3429
2	.3429	.2743		.3429	.3429		.3429
3	.3429	.2743		.3429	.3429		.2286
4	.3429	.4115		.3429	.4115		.4115
5	.3429	.4801		.4115	.4801		.4801
6	.6859	.6859		.6859	.6173		.6173
7	.9602	.8916		.8916	.823		.823
8	.9602	1.0288		.9602	.8916		
9	.9602	.9602	.9602		.8916		
10	.8916	.8916	.823	.8402	.823	.823	
11	.7545	.823	.7545	.7545	.7545	.823	
12	.6859	.6859	.6859	.6859	.6173	.6173	
13	.6173	.6173	.6173	.6173	.6173	.6173	
14	.5487		.5487	.6173	.6173	.5487	
15	.5487	.5487	.5487	.5487	.6173	.5487	
16	.5487	.5487	.5487	.5487	.5487	.5487	
17	.6859		.6173	.6173		.7545	.4115
18	.823		.8916			.9602	.6173
19	.9602		.9602	.9602		.9602	.7545
20	.823		.7545	.823		.823	.6859
21	.6173		.6173	.6859		.6173	.5487
22	.4801		.4801	.5487		.4801	.4801
23	.3429		.4115	.4115		.4115	.4115
24	.3429	.2743		.3429	.3429		.3429
Max	.9602	1.0288	.9602	.9602	.8916	.9602	.823
Min	.3429	.2743	.4115	.3429	.3429	.4115	.2286
Avg	.6230	.6044	.6813	.6056	.5931	.6810	.4999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 208 / 11 KV WATER WORKS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572			.0457	.0457		
2	.0572			.0457			
3	.0572			.0457			
4	.0572						
5	.0457						
6		.0457			.0457		
7	.0457	.0457		.0457	.0457		.0457
8	.0457	.0457		.0572	.0457		
9	.0457	.0457			.0457		
10						.0457	
11					.0457	.0457	
12					.0457	.0457	
13	.0457			.0457	.0457	.0457	
14	.0457		.0457		.0457	.0457	
15	.0457	.0572	.0457	.0457	.0457	.0457	
16		.0457	.0457	.0457	.0457	.0457	
17			.0457	.0457		.0457	.0457
18	.0457		.0457			.0457	.0457
19	.0457					.0457	
20	.0457					.0457	
21	.0457					.0457	
22	.0457		.0457	.0457			.0457
23	.0457		.0457	.0457		.0457	.0457
24	.0572			.0457	.0457		
Max	.0572	.0572	.0457	.0572	.0457	.0457	.0457
Min	.0457	.0457	.0457	.0457	.0457	.0457	.0457
Avg	.0489	.0476	.0457	.0467	.0457	.0457	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054007 / 33/11KV S/S AMBAJOGAI

Feeder No / Name : 209 / 11KV GFSS JOGAIWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762		.1143	.1143		.0762
2	.1524	.0762		.1143	.1143		.0762
3	.1524	.0762		.1143	.1143		.0762
4	.1334	.0762		.1334	.1143		.1143
5	.1334	.0762		.1334	.1143		.1524
6	.1143	.1524		.1143	.1143		.1524
7	.2096	.1905		.2286	.1905		.2286
8	.2096	.1524		.2286	.1905		
9	.1524	.1524	.1524		.1905		
10	.0953	.0953	.0762	.1524	.1143	.1905	
11	.0762	.1143	.1524	.1524	.1715	.1905	
12	.0762	.1524	.1524	.1524	.1524	.1524	
13	.1524		.2286	.2286	.1524	.1524	
14	.1524		.2286	.2286	.1524	.1524	
15	.1524	.1524	.1905	.2286	.1524	.1524	
16	.1524	.1524	.2286	.2286	.1524	.1905	
17	.1524		.2286			.1524	.1524
18	.1524		.2286			.0762	.1715
19	.1143		.1715	.1524		.1524	.1143
20	.0762		.2096	.1143		.1524	.0953
21	.0762		.1143	.2286		.1524	.1143
22	.1143		.1905	.1143		.1524	.1143
23	.1143		.1905	.1143		.1143	.1334
24	.1524	.1143		.1905	.1143		.1143
Max	.2096	.1905	.2286	.2286	.1905	.1905	.2286
Min	.0762	.0762	.0762	.1143	.1143	.0762	.0762
Avg	.1342	.1207	.1829	.1651	.1423	.1524	.1257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 201 / 11 KV MORWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.1334	.1024	.1131	.1454	.1163	.0958
2	.1865	.1334	.1043	.1509	.1474	.1166	.0923
3	.1888	.1331	.1128	.1512	.151	.1168	.0987
4	.1896	.152	.1509	.1478	.1524	.1332	.1238
5	.2286	.1903	.1941	.1523	.2286	.1677	.1749
6	.2286	.2286	.2385	.1524	.2286	.2044	.1795
7	.2667	.2477	.2478	.1524	.2662	.2414	.2231
8	.2849	.2472	.3033	.1524	.2662	.2282	.2662
9		.225	.2408		.1901	.2266	.2277
10	.1557	.2234	1.2209	.1894	.1859	.2215	.2218
11	.8268	1.4343	1.2209	1.2593	1.1424	.9976	1.0974
12	1.7092		1.3854	1.4408	1.4986	1.9888	.3429
13	1.8656	.6638	1.5236	1.6862	1.9625	1.9717	1.9143
14	2.0015		1.8122	1.9963	2.0613	2.0053	1.4736
15	1.8427	.0174	1.6758	2.0314	1.5435	1.978	1.5332
16	1.7558		1.6857	2.1849	1.6729	1.8564	1.868
17	1.797	1.0333	1.9074	1.5838	2.0015	1.6244	1.2846
18	1.4846	1.5845	1.3435		1.6511	1.2671	.4241
19	.2193	.2494	.1923	.2465	.243	.2419	.1646
20	.2215	.209	.2262	.2441	.2177	.239	.1896
21	.162	.2071	.2408	.2062	.1946	.1925	.1891
22	.1766	.1869	.1894	.1648		.157	.2035
23		.1317	.1708				
24	.1858	.1224	.0989	.1192	.1358	.1158	.1329
Max	2.0015	1.5845	1.9074	2.1849	2.0613	2.0053	1.9143
Min	.1557	.0174	.0989	.1131	.1358	.1158	.0923
Avg	.7348	.3692	.6912	.6917	.7403	.7134	.5444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 202 / 11 KV BARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2538	.1342	.2462	.2362	.1856	.1954	.249
2	.2404	.1371	.2854	.2248	.1811	.1945	.2736
3	.2401	.1382	.3521	.2172	.1799	.1933	.29
4	.2229	.1591	.318	.2272	.1771	.2167	.3128
5	.2477	.2226	.3647	.251	.2606	.2636	.325
6	.3086	.2984	.3621	.2923	.3172	.335	.3669
7	.4105	.3905	.4047	.4633	.4119	.4211	.3951
8	.4809	.4557	.4473	.4588	.5574	.4588	.4527
9		.4604	.5213	.4824	.5407	.4582	.4246
10	.4426	.4778	.4405	.3492	.4231	.4534	.4988
11	1.0303	.9348	.5921	.6127	1.1145	.3039	
12	1.267	1.3265	.4641	.8493	.3157	1.0429	1.5072
13	.8369	.8421	.3355	1.4132	.5024	1.0919	1.2293
14	1.0324		.4755	1.196	.6371	1.1251	1.2904
15	1.1987	1.3296		1.1413	1.3347	1.1728	1.5444
16	1.6347		1.2071	1.556	1.2878	.6001	1.1937
17	1.6498	1.0578	1.2193	1.2563	1.4754		1.5185
18	1.2955	1.4563	1.0489		1.2193	1.4608	.8326
19	.4513	.5665	.6783	.663	.5197	.5197	.4136
20	.4012	.4835	.6941	.465	.7035	.5024	.5843
21	.3245	.4274	.6394	.4418	.4502	.4612	.523
22	.2427	.3692	.6031	.3304		.3889	.502
23		.2833	.4813				
24	.2634	.1795	.2492	.373	.2092	.1963	.2586
Max	1.6498	1.4563	1.2193	1.556	1.4754	1.4608	1.5444
Min	.2229	.1342	.2462	.2172	.1771	.1933	.249
Avg	.6580	.5514	.5404	.6137	.5911	.548	.6812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054014 / 33 KV BARDAPUR

Feeder No / Name : 203 / 11 KV JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5985	.7554	.4949	1.0867	1.0144	.9752	.3006
2	.7221	1.008	.6481	1.2785	1.1971	1.0574	.4074
3	.8995	1.1871	.7926	1.3597	1.5684	1.1616	.56
4	1.2171	1.4989	1.1317	1.5307	1.8804	1.2563	.7164
5	1.4295	1.7128	1.2716	1.8484	2.0576	1.5304	.9397
6	1.6766	2.1338	1.7124	1.9814	2.2862	1.7569	1.5167
7	1.8671	2.3624	2.0974	2.4387	2.3405	2.0639	1.6966
8	2.1901	2.6593	2.3819	2.5149	2.5679	2.3589	1.8075
9		2.2436	2.5503	2.2481	2.3237	2.6549	2.0508
10	1.7476	2.0439	2.2222		2.0896	2.1389	.1371
11	.064	.0802	.1077	.117	.0834	.0992	.1513
12	.0729	.0726	.0766	.0672	.0814		.125
13	.0634	.0496	.0594	.0743	.0751		.108
14	.0503				.0682	.0756	.1147
15	.0572	.0649	.0747	.0808	.0599	.077	.1017
16	.0449		.0899	.0802	.0774	.0191	.0912
17	.0705	.0591	.2222	.059	.0727	.0668	.0859
18	.0887	.0724	.096		.084	.1137	.1046
19	.1143	.1381	.1811	.1113	.1317	.1335	.2472
20	.085	.1132	.193	.0964	.0751	.0831	.2451
21	.0674	.0802	.2427	.0843	.0792	.0703	.2469
22	.0617	.0701	.2789	.0832		.0462	.2177
23		.0672	.2035				
24	.08	.0617	.0591	.208	.0908	.0652	.0461
Max	2.1901	2.6593	2.5503	2.5149	2.5679	2.6549	2.0508
Min	.0449	.0496	.0591	.059	.0599	.0191	.0461
Avg	.6031	.8425	.7473	.8674	.9229	.8478	.5225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422] BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 201 / 11 KV RADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
4	1.4918	1.3916
5	1.8233	1.8564
6	1.989	2.13
7	2.4863	2.3975
8	2.8178	2.7328
9	2.8178	2.5484
10	2.4697	2.7831
11	1.9393	2.5434
Max	2.8178	2.7831
Min	1.4918	1.3916
Avg	2.2294	2.2979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 202 / 11 KV AKOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
1	.3429	.3239
2	.3429	.381
3	.381	.4572
12	2.0885	2.1879
13	1.9559	2.0885
14	2.0553	1.873
15	2.2377	1.917
16	2.1464	1.9334
17	2.1714	2.0885
18	2.0891	1.9662
19	1.8947	1.6644
20	.5906	
21	.5525	
22	.381	
23	.3429	
24	.3429	.2858
Max	2.2377	2.1879
Min	.3429	.2858
Avg	1.2447	1.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054031 / 33 KV DHANORA S/S

Feeder No / Name : 203 / 11 KV MAMDAPUR PATODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
1	.7545	.6224
2	.679	.5847
3	.679	.547
4	1.8233	1.4403
5	2.3205	1.9334
6	2.652	2.2466
7	2.6825	2.5034
8	2.7161	2.692
9	2.8502	2.7639
10	2.6155	
11	2.1879	2.9334
20	1.3443	
21	1.0456	
22	.8402	
23	.7468	
24	.7545	
Max	2.8502	2.9334
Min	.679	.547
Avg	1.6682	1.8267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 201 / 11 KV APEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	.0762	.9526	1.0479	1.6004	1.1431
2	1.3336	1.4289	1.3336	.9526	1.3336	1.6004	1.5242
3	1.3336	1.7147	1.3336	1.3336	1.3336	1.6004	1.5242
4	1.7147		1.7147	1.7147	1.6194	1.7147	1.8099
5	2.0957	1.9052	1.7147	2.0957	1.6194	1.7147	1.9052
6	2.2862	2.2862	1.9052		1.7147	1.9052	1.9052
7	2.6673	2.2862	2.6673		1.9052	1.9052	1.9052
8	2.6673	2.3815	3.0483	2.6673	1.9052	1.9052	2.0957
9	3.0483	2.4768	3.4294	3.0483	1.9052	1.9052	2.0957
10	3.2388	2.6673	3.4294	3.0483	1.9052	1.3336	1.8099
11	.0762	.0762	.0762	.0762	.0762	.0762	.0762
12	.0762	.0762	.0762		.0762	.0762	
13		.0762		.0762	.0762		
14	.0762	.0762	.0762		.0762		
15			.0762	.0762	.0762		.0762
16	.0762	.0762	.0762		.0762		.0762
17		.0762	.0762		.0762		.0762
18	.0762	.0762	.0762	.0762	.0762	.0762	.0762
19	.0762	.0762	.0762	.0762		.0762	.0762
20	.0762	.0762	.0762	.0762		.0762	.0762
21	.0762		.0762	.0762		.0762	.0762
22	.0762		.0762	.0762		.0762	.0762
23	.0762	.0762	.0762	.0762		.0762	.0762
24		.0762	.0762	.0762	.0762	.0762	.0762
Max	3.2388	2.6673	3.4294	3.0483	1.9052	1.9052	2.0957
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	1.1145	.9564	.941	.9208	.8934	.9406	.8836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 202 / 11 KV TATBORGAEON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	2.3285	1.9959	2.079	1.6632	1.4986	1.6632	1.6651
12	2.3285	2.2454	2.1622	2.3285	1.8317	1.6632	1.9982
13		2.3285	2.2454	2.6612	1.8317	1.8296	2.3312
14	2.3285		2.3285	2.6612	2.0814	1.8296	2.3312
15	2.3285		2.3285	2.6612	2.1647	1.9127	2.4977
16	2.3285	2.3285	2.3285	2.6612	2.3312	1.9959	2.4977
17	2.2953	2.3285	2.3285	1.6632	2.3312	1.9959	2.4977
18	2.2953	1.8296	1.6632	1.3306	2.4977	1.6632	2.3312
19		.0665					
Max	2.3285	2.3285	2.3285	2.6612	2.4977	1.9959	2.4977
Min	2.2953	.0665	1.6632	1.3306	1.4986	1.6632	1.6651
Avg	2.3190	1.8747	2.1830	2.2038	2.0710	1.8192	2.2688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054046 / 33 KV APEGAON

Feeder No / Name : 203 / 11KV GFSS APEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.127	.1589	.127	.1271	.1583	.127	.1583
2	.127	.1589	.127	.1271	.1583	.127	.1267
3	.127	.1589	.127	.1271	.1583	.127	.1267
4	.127		.127	.1271	.1583	.127	.1583
5	.127	.1589	.127	.1271	.19	.127	.19
6	.1587	.1907	.1587	.1589	.2217	.1904	.19
7	.2222	.2225	.2222	.2225	.2375	.2222	.19
8	.2222	.2225	.2222	.2225	.2375	.2222	.2217
9	.1904	.1907	.2222	.1907	.2217	.2222	.2217
10	.1587	.1589	.1587	.1589	.19	.1587	.19
11	.127		.1589	.127	.1583	.1583	.1583
12	.0794	.1271	.1271	.0794	.1267	.1267	.1267
13		.0794	.0794	.0832	.095	.095	.1267
14	.0794	.0794	.0794	.0832	.095	.0792	.1267
15			.0794	.0832	.095	.0792	.1267
16	.0794	.0794	.0794	.0832	.095	.0792	.1267
17	.0794	.1271	.1271	.0832	.1267	.1267	.1267
18	.127	.1589	.1589	.1331	.1583	.1583	.1583
19	.1589	.1589	.2225	.1589		.1583	.19
20	.1907	.2225	.2225	.1907		.19	.2217
21	.2225	.2225	.1907	.2225		.19	.19
22	.2225	.1907	.1589	.1907		.19	.1583
23	.1907	.1589	.1589	.1589		.2217	.1583
24	.1587	.1589	.1589	.1589	.1583	.1587	.19
Max	.2225	.2225	.2225	.2225	.2375	.2222	.2217
Min	.0794	.0794	.0794	.0794	.095	.0792	.1267
Avg	.1501	.1612	.1509	.1427	.1600	.1526	.1649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 201 / 11 KV SAIGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2561	.1829	.2534		.2172	.2195
2	.2561	.2561	.2056	.2534		.2534	.2195
3	.2926	.2561	.2401	.2896		.2896	.2378
12	.5636	.7802	.6154	.6796	.6802	.6796	.5801
13	.6796	.7202	.6154	.663	.6802	.663	
14	.663	.6468	.5506	.6962	.583	.5967	.663
15	.6036	.5868	.6478	.5304	.5182	.5636	.6299
16	.6706	.5636	.583	.5636		.5636	.431
17	.5801	.6859	.6478	.5967	.5182	.6299	.663
18	.6464	.5801		.5967	.583	.6796	.663
19	.4973	.5138	.583	.5636	.583	.6464	.6299
20	.4572	.4409	.4706	.4024	.4534	.4024	
21	.4024	.2591	.4344		.3887	.3292	.3658
22	.3292	.3005	.362			.2926	.2926
23	.2926	.2286	.2896			.2561	.2926
24	.2561	.2561	.1981	.2534		.2267	.2195
Max	.6796	.7802	.6478	.6962	.6802	.6796	.663
Min	.2561	.2286	.1829	.2534	.3887	.2172	.2195
Avg	.4654	.4582	.4418	.4878	.5542	.4556	.4362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 202 / 11 KV SUGAON FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.1132	.1086	.0943	.0905	.0943
2	.0943	.0943	.1143	.1086	.0754	.1086	.0943
3	.0943	.0943	.1132	.1267	.0754	.1448	.0943
4	.9145	.9145	.9145	.9717	.8535	.9717	.9145
5	.9907	1.1279	1.1111	1.166	.9145	1.1336	.9907
6	1.1888	1.2193	1.2967	1.2955	1.0059	1.2146	1.0669
7	1.2955	1.448	1.5565	1.5384	1.3413	1.4089	
8	1.5242	1.1736	1.7976	1.6194	1.4327	1.5384	1.4327
9	1.5089	1.2193	1.6804	1.6194	1.6194	1.6194	1.4937
10		1.6644	1.6194	1.2651	1.587	1.4327	1.4022
11	1.448	1.6004	1.6194	1.3108	1.3765	1.448	1.4784
20	.1886	.1715	.1629	.1886	.1619	.2075	
21	.1509	.1334	.1448	.1886	.1457	.1698	.1886
22	.132	.1143	.1267	.1132		.1509	.1509
23	.1132	.1143	.1267	.1132		.1132	.1509
24	.0754	.1132	.1143	.1086	.1132	.1086	.1132
Max	1.5242	1.6644	1.7976	1.6194	1.6194	1.6194	1.4937
Min	.0754	.0943	.1132	.1086	.0754	.0905	.0943
Avg	.6530	.7061	.7882	.7402	.7712	.7413	.6904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 203 / 11 KV POKHARI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.439	.5041	.543	.5487	.6878	.5487
2		.5487	.5041	.543	.6219	.6878	.5853
3		.6584	.6908	.6878	.695	.7602	.695
12	2.2138	2.2552	2.1376	2.1664	2.2024	2.0241	2.0873
13	2.1822	2.0348	2.0729	2.0399	2.2672	2.119	
14	2.0715	2.2466	2.0243	2.0399	2.2672	2.119	2.2929
15	2.2138	2.2969	2.0243	2.0873	2.1052	2.0715	1.7394
16	1.6604	2.2466	2.0891	1.8818		2.0557	1.5181
17	1.9766	2.1628	2.2348	1.4548	2.1376	2.1506	2.0241
18	1.9292	2.1125	2.1052	1.9292	2.2024	2.0241	1.8976
19	1.6446	1.9448	1.9433	1.8976	1.7814	1.7711	1.7394
20	.9877	1.0185	1.0136	.9877	.9069	.9877	
21	.8048	.8402	.9412	.7316	.8421	.9694	.8048
22	.6584	.6908	.8145	.6584		.823	.6584
23	.5853	.5914	.6516	.5853		.679	.5853
24		.4938	.4805	.5792	.5121	.724	.6413
Max	2.2138	2.2969	2.2348	2.1664	2.2672	2.1506	2.2929
Min	.5853	.439	.4805	.543	.5121	.679	.5487
Avg	1.5774	1.4113	1.3895	1.3008	1.4685	1.4159	1.2727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054064 / 33 KV SAIGAON

Feeder No / Name : 204 / Dudhdairy Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.168	.1867	.0648	.0362	.0972	.1629
2	.1448	.168	.1867	.0324	.0362	.0972	.1086
3	.1267	.168	.1867	.0324	.0543	.0972	.0543
4	.1267		.1478	.1134	.0543	.1134	.0543
5	.1267	.112	.0554	.1134	.0724	.0972	.0362
6	.1267	.1109	.037	.1134	.0724	.0972	.0543
7	.1086	.1109	.037	.1619	.0724	.0972	.0543
8	.0543	.1109	.037	.1619	.0724	.0972	.0543
9	.0362	.037	.037	.1619	.0324	.0324	.0362
10		.037	.0324	.0724	.1296	.0036	.037
11	.037	.0554	.0324	.0036	.0324	.0036	.0018
12	.0554	.037	.0324	.0036	.0324	.0543	.0019
13	.056	.037	.0324	.0036	.0324	.1086	
14	.037	.037	.0324	.0036	.0324	.1267	.0018
15	.0934	.037	.0324	.0036	.0324	.1629	.0019
16	.037	.037	.0324	.0036	.0324	.2353	.0018
17	.0554	.037	.0324	.0036	.0324	.1448	.0019
18	.0739	.037	.0324	.0018	.0324	.1448	.0018
19	.037	.037		.0018	.0324	.1629	.0018
20	.1294	.037	.0324	.0543	.1134	.2172	
21	.1109	.037	.1619	.0905	.0324	.2534	.1848
22	.1663	.2218	.1134	.0724		.2172	.2241
23	.168	.2218	.1134	.0362		.181	.168
24	.1448	.1867	.1663	.081	.0362	.0972	.1629
Max	.168	.2218	.1867	.1619	.1296	.2534	.2241
Min	.0362	.037	.0324	.0018	.0324	.0036	.0018
Avg	.0955	.0904	.0778	.0580	.0503	.1225	.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 201 / 11 KV NAGAZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3756	1.6221	1.4335	1.3169	1.2071	1.4335	1.2071
2	1.3756	1.4335	1.4335	1.3169	1.1706	1.3611	1.2071
3	1.2308	1.4335	1.4335	1.3169	1.1706	1.4335	1.2071
4	1.2308	1.5089	1.6221	1.3169	1.3169	1.4712	1.3306
5	1.3032	1.5844	1.773	1.2437	1.39	1.5089	1.5339
6	1.829	1.8107	1.9616	1.7924	1.885	1.5089	1.7372
7	2.3655	2.2634	2.2177	2.3655	2.5503	1.8107	2.3655
8	1.8107	1.9616	1.9418	2.0165	1.8858	1.829	2.0351
9	1.6975	1.7924	1.8298	1.7924	1.643	1.7924	1.8671
10	1.643	1.5524	1.6057	1.7002	1.4937	1.6263	
11	1.262	1.3169	1.423	1.39	1.4045	.679	1.6461
12	.5175	1.0974	1.1584	.9511	1.2567	.6722	1.6095
13	.9313	.4481	1.086	.9955	1.1088	.5914	1.4998
14	1.0745	1.0136	1.0029	.9492	1.1088	.4435	1.4299
15	1.5592	1.0745	.5014	1.0745	1.4784	.4435	1.6126
16	1.8229	1.4723	***	1.8031	1.4784	2.1262	1.858
17		1.7528	.6024	2.1498	2.0698	2.2436	2.0332
18	2.4539	2.1033	2.2207	2.3579	1.7002	2.3137	1.9136
19	2.3137	2.4188	2.0995		1.7002	2.2923	1.8099
20	1.9845	2.1033	1.7375		1.7002	2.0271	1.7375
21	1.8823	1.8625	1.5927		1.6632	1.7551	1.6095
22	1.7558	1.6289	1.5203			1.4327	.8962
23	1.6095	1.5154	1.4632				1.3443
24	1.448	1.39	1.4335	1.4632	1.2071	1.4045	1.2437
Max	2.4539	2.4188	10.5424	2.3655	2.5503	2.3137	2.3655
Min	.5175	.4481	.5014	.9492	1.1088	.4435	.8962
Avg	1.5859	1.5900	1.9015	1.5428	1.5268	1.4870	1.5972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 202 / 11 KV RAVIVAR PETH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.6036	.5658	.5792	.4961	.5281	.5068
2	.4344	.6036	.5658	.5068	.4706	.5281	.4755
3	.4344	.6036	.5658	.4344	.4706	.5281	.4755
4	.4344	.6036	.6036	.4344	.4755	.5281	.5175
5	.4344	.6413	.6413	.4298	.5121	.5658	.5914
6	.6722	.7545	.7733	.7095	.6908	.6036	.6535
7	.8962	.9054	.8589	.9054	.9054	.679	.9054
8	.9709	.9242	.9054	.9709	.9997	.9709	.9335
9	.8215	.8962	.8215	.7468	.9054	.8962	.9335
10	.7468	.6584	.7762	.6653	.7545	.7468	
11	.5121	.5914	.6219	.6036	.7468	.6584	.7762
12	.5068	.4835			.5601	.5853	.6468
13	.4298	.5121	.6024	.4298	.5975	.4344	.5487
14	1.0745	.394	.4607	.3898	.5601	.4435	.4706
15	.4119	.3898	.3856	.3898	.4481	.439	.4525
16	.4163	.4119	.4207	.3761	.4481	.439	.4525
17		.4656	.5373	.5014	.5975	.5068	.439
18	.6878	.7164	.7796	.7087	.7468	.7164	.5731
19	.7316	.788			.8215	.7796	.7712
20	.8131	.7164	.7628		.7468	.7087	.7796
21	.7762	.6878	.7011		.6722	.6415	.6859
22	.7392	.6516	.6447			.5658	.5426
23	.6653	.5792	.6447				.4908
24	.4344	.5914	.5601	.5792	.5201	.5228	.4961
Max	1.0745	.9242	.9054	.9709	.9997	.9709	.9335
Min	.4119	.3898	.3856	.3761	.4481	.4344	.439
Avg	.6295	.6322	.6454	.5756	.6430	.6094	.6138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 203 / 11 KV MUKUNDRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.679	.679	.6722	.5487	.6036	.5487
2	.5975	.679	.679	.5601	.5121	.6036	.5544
3	.5601	.679	.679	.5601	.4805	.6036	.5544
4	.5601	.7167	.7167	.5228	.4805	.6036	.5975
5	.5228	.7922	.7545	.4854	.5228	.6036	.6348
6	.7545	.8299	.8299	.7545	.7922	.6036	.7167
7	1.0562		.9808	.9808	1.0374	.7356	.9054
8	1.2071	1.1317	1.0562	1.2071	1.1694	1.0242	1.094
9	1.1317	1.0456	1.094	1.0562	1.0562	1.1317	1.1317
10	.9335	.961	.9709	.9709	1.0562	.9709	
11	1.3443		.8131	.7468	.9335	.8962	.9709
12	.7392	.7282	.7207	.6468	.9709	.7392	.9055
13	.6584	.4252		.6099	.7468	.7392	.8596
14	.6401	.6099	.6283	.5487	.7468	.6516	.8413
15	.5175	.6099	.5853	.5853	.5731	.6584	.7133
16	.6283	.5544	.567	.6099	.5373	.7316	.6653
17		.7392	.6584	.7316	.7164	.8131	.7316
18	.924	.961	1.0349	.9511	.8326	.961	.8322
19	1.1088	1.1088	1.1088		.9774	1.1088	.961
20	1.0456	1.0349	.8779		.8688	1.0349	1.0349
21	.9709	.9335	.8871		.8131	.8316	.8779
22	.9335	.8215	.8215			.6767	.5853
23	.7842	.7545	.8215				.5914
24	.5975	.6722	.679	.7468	.6219	.6653	.5853
Max	1.3443	1.1317	1.1088	1.2071	1.1694	1.1317	1.1317
Min	.5175	.4252	.567	.4854	.4805	.6036	.5487
Avg	.8180	.7940	.8106	.7341	.7725	.7822	.7780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 204 / 11KV KALWATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.6859	.6859	.6241	.5765	.6859	.6588
2	.4801	.6859	.6859	.6859	.6104	.6859	.7202
3	.4801	.6859	.6935	.7545	.6443	.6859	.7545
4	.4801	.7888	.7202	.7461	.6783	.6859	.823
5	.5426	.823	.7545	.7461	.6952	.6859	.8916
6	.6935	.8916	.8916	.8916	.823	.6859	.9774
7	.8413	.9259	1.0402	.9602	.9259	.8573	1.1616
8	.9114	.9259	1.0402	1.1096	1.0402		1.0682
9	.7628	.9015	1.1096	.9015	.9671	1.0402	1.0288
10	.6935	.7545	.8916	.8573	.7975	.8048	
11	.381	.1524	.1886	.1509	.2774	.2286	.2641
12	.1143	.1524	.168	.1524	.1524	.2286	.2641
13	.1143	.1524	.5544		.1524	.1886	.2452
14	.1143		.1509	.1524	.1524		.2452
15	.1143	.0762	.1509	.1143	.1524		.2096
16	.1254	.1524	.1524	.1524	.1524		.2286
17		.1905	.2263	.1715	.1524	.2286	.2286
18	.2641	.2286	.3018	.2263	.2286	.2263	.2286
19	.3048	.3048	.3018		.2667	.3048	.3048
20	.3395	.2743	.3048		.3048	.3048	.3048
21	.3048	.2667	.3048		.3048	.2641	.3048
22	.3048	.2286	.3048			.2263	.3048
23	.3048	.2286	.3048				.3048
24	.2263	.6859	.208	.3048	.2263	.6859	.2263
Max	.9114	.9259	1.1096	1.1096	1.0402	1.0402	1.1616
Min	.1143	.0762	.1509	.1143	.1524	.1886	.2096
Avg	.4077	.4853	.5056	.5390	.4673	.5108	.5108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 205 / 11 KV WATER SUPPLY EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648		.061			.061	
2	.0648		.061			.061	
3	.0648		.061				
4	.0648	.061	.061				
5	.064	.061	.061				
6	.0633	.061	.061	.064	.125		.0633
7	.0648	.061	.1296	.0655	.1296		.1296
8	.0648	.061	.1296	.0648	.0648	.061	.1296
9		.0648	.0633	.061	.0648	.1296	.1296
10			.0625	.061	.1219	.0633	
11				.0633	.1219	.064	.1296
12	.064		.0648	.0648	.1219	.0655	.1296
13	.064		.1905	.0633	.1341	.0648	.1296
14	.064	.0648		.064	.1219	.0633	.064
15		.0648	.064	.0633	.061	.064	.1296
16		.1311	.064	.0633	.061	.064	
17		.0633	.064	.064	.061	.1296	.128
18	.061	.0617		.0633	.061	.0617	.125
19	.061	.0617			.061	.1219	
20	.061	.061			.061	.1189	
21	.061	.0617	.0648		.061	.0587	
22	.061	.0617	.0648				.0587
23		.061	.0648				.061
24			.0617	.0648		.061	
Max	.0648	.1311	.1905	.0655	.1341	.1296	.1296
Min	.061	.061	.061	.061	.061	.0587	.0587
Avg	.0633	.0664	.0765	.0636	.0896	.0773	.1082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054067 / 33/11 KV PATHAN MANDVA

Feeder No / Name : 404 / 33 KV DAWAKHANA

Feeder KV- 33 / INCOMING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.6984	.8596	.6447	.6447	.6984	.6447
2	.7522	.6984	.6984	.6447	.6447	.6984	.6447
3	.7522	.7059	.6984	.6447	.6447	.6984	.6447
4	.8059	.6984	.6984	.6984	.6447	.6984	.7522
5	.8059	.8688	.8596	.6984	.7522	.8596	.8596
6	1.0745	.9671	1.0745	1.0208	1.1283	.8596	1.1283
7	1.4506	1.2894	1.3969	1.2357	1.5581	1.0317	1.5043
8	1.6118	1.3969	1.4506	1.3969	1.6118	1.5043	1.5581
9	1.3969	1.3969	1.3969	1.2894	1.4661	1.5043	1.6118
10	1.182	1.2357	1.182	1.1283	1.5043	1.3969	
11	1.9342	1.5581	1.6655	1.5043	2.2028	1.773	1.8804
12	1.6118	1.8267	1.6655	1.8804	2.0953	1.773	1.9879
13	1.9879	1.5581	1.8267	1.9342	1.9342	1.8267	1.9342
14	1.6655	1.6655	1.7193	1.8804	1.9879	1.9342	1.9342
15	1.5043	1.6118	.7522	1.8267	2.0953	1.9342	1.7193
16	1.7193	1.5581	.9134	1.9879	1.6655	1.8267	1.8267
17		1.6655	1.0208	1.9342	1.773	1.7193	1.6655
18	1.6632	1.6655	1.182	1.8804	1.8804	2.0953	1.773
19	1.6655	1.2357	1.2894		1.2894	1.2357	1.182
20	1.1283	.9671	1.2894		1.1283	1.1283	1.0208
21	1.0745	.8596	1.182		.9671	.9671	.9134
22	.9671	.7522	1.0745			.8596	.8596
23	.7682	.6984	.9671				.8059
24	.7522	.6984	.6984	.8596	.7522	.6984	.6447
Max	1.9879	1.8267	1.8267	1.9879	2.2028	2.0953	1.9879
Min	.7522	.6984	.6984	.6447	.6447	.6984	.6447
Avg	1.2620	1.1782	1.1484	1.3205	1.3805	1.2922	1.2824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 201 / 11 kv sonawala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6029	3.0178	2.1691	2.6406	1.5089	1.8861	2.6067
2	2.8292	3.2065	2.5538	2.8481	1.9805	2.2634	2.6482
3	2.7349	3.3951	2.7387	2.9235	2.0748	2.7349	2.9273
4	3.1876	3.4894	2.7425	2.9047	2.8292	2.8292	2.9801
5	3.1687	3.5837	2.9084	3.1687	3.2065	3.0178	3.0254
6	3.131	3.678	3.0933	3.4139	3.4894	3.3951	3.0593
7	3.3951	3.7346	3.1725	3.1687	3.6969	3.4705	3.0744
8	3.3951	3.2065	2.8707		3.7346	3.3008	3.6591
9		3.3008	3.2065	3.0178	3.5497	3.3196	3.678
10	2.8934	3.3196		3.0556	3.0556	3.0744	3.0178
11		1.7918	.9431	2.1502	2.1992	1.5089	2.2257
12		2.1125	2.2634	2.3011		1.905	2.452
13	2.403	2.2445	2.6217	2.3388	1.7579	2.2257	2.2822
14	2.3388	2.1502	2.3011	2.2634	1.7428	2.2822	2.452
15	2.2898	2.3011	2.1691	2.1879	1.8522	2.1691	2.2257
16	2.4143	2.2445	2.3011	2.3765	1.8824	2.4897	.0377
17	2.1691	2.0748	2.32	2.2634	2.0748	1.7956	.0717
18	1.6598	1.6523	2.1125	1.7918	1.3957	1.8258	
19	.0754	.1019	.0754	.1132	.0943	.0868	.132
20	.0754	.0981	.0754	.0754	.0754	.0981	.132
21	.0566	.0792	.0679	.0754	.0754	.0868	.132
22	.0566	.0566	.0679	.0566	.0754	.083	.132
23	.0377	.0604	.0566	.0566	.0754	.0792	
24	.0377	.0377	.0528	.0566	.0566	.0754	.0754
Max	3.3951	3.7346	3.2065	3.4139	3.7346	3.4705	3.678
Min	.0377	.0377	.0528	.0566	.0566	.0754	.0377
Avg	1.9501	2.1224	1.8645	1.9673	1.8471	1.9168	1.9558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054106 / DONGAR PIMPALA 33/11 KV

Feeder No / Name : 203 / 11 KV D.PIMPALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1715	.1652	.1372	.1715	.1886	.2327
2	.1698	.1829	.1744	.1629	.1829	.1867	.2515
3	.1848	.168	.2138	.1829	.2263	.1886	.284
4	.2263	.2033	.2534	.1886	.2957	.1886	.3224
5	.2587	.2801	.3363	.2263	.2987	.2641	.3695
6	.3584	.3395	.3848	.3206	.3772	.3584	.4742
7	.4715	.415	.415	.4715	.4338	.4715	.5017
8	.4904	.4108	.4715		.4338	.415	.5359
9		.3547	.4108	.4108	.2678	.3584	.4904
10	.249	.2926		.3696	.2651	.2829	.462
11		.1829	.2172		.2033	.1509	.439
12	.207	.2303	.2279	.1829		.1848	.4024
13	.1922	.1991	.2012	.197		.1478	.3258
14	.1663	.1991	.1829	.1433	.1843	.181	.3475
15	.1866	.1629	.1991	.1463	.257	.1772	.3077
16	.1863	.197	.2126	.1829	.1557	.2195	.2378
17	.2629	.2389	.2303	.2263	.2534	.3083	.2561
18	.3439	.2615	.2835	.2896	.2835	.3544	
19	.4191	.3532	.4252	.3721	.362	.5236	.2915
20	.3353	.3361	.3561	.3185	.2743	.4458	.2622
21	.2401	.2623	.2721	.2785	.2347	.332	.2591
22	.2105	.216	.2267	.1943	.192	.2851	.2401
23	.1389		.2035	.1619	.2012	.275	
24	.1509	.1543	.1696	.1475	.1509	.1658	.213
Max	.4904	.415	.4715	.4715	.4338	.5236	.5359
Min	.1389	.1543	.1652	.1372	.1509	.1478	.213
Avg	.2545	.2527	.2710	.2414	.2593	.2773	.3412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 201 / 11KV KRANTI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5148	.5212	.5212	.5212	.5516	.5212	.5228
2	.5148	.5212	.5212	.5212	.5516	.5212	.5228
3	.478	.5212	.5212	.5212	.5148	.5212	.5228
4	.5516	.5956	.5584	.5212	.5883	.5212	.5228
5	.7538	.7073	.6701	.7259	.7906	.7446	.5601
6	.9744	.9679	.8562	.9307	1.048	.9493	.7468
7	1.2134	1.2471	1.2657	1.1727	1.3053	1.2471	1.1389
8	1.3973	1.4333	1.4333	1.303	1.287	1.396	1.3443
9	1.3789	1.1913	1.3216	1.1399	1.1042	1.3443	1.363
10	1.0982	1.1168	1.0796	.9441	1.2657	1.1576	
11	.8376	.9307	.8935	.7354	1.1168	.9709	1.0424
12	.8004	.8376	.7632	.8641	.9493	.8215	.9493
13	.7818	.7446	.7073	.7538	.7818	.8029	.9121
14	.6701	.7073	.6515	.6619		.7282	.6701
15	.6329	.6701	.6329	.6251	.5584	.7282	.6329
16	.7073	.7446	.7073	.7538	.6887	.7655	.7044
17	.8562	.8562	.8376	.8273	.7632	.8962	.819
18	1.061	.9307	1.0796	.9928	.9865	1.0082	.9493
19	1.1354	1.167	1.2285	1.1399	1.1168	1.1576	1.0424
20	.9679	1.0051	1.0424	.9744	.9865	1.0082	.9149
21	.8376	.8376	.9121	.8825	.9307	.9335	.8376
22	.7073	.6887	.6515	.7354	.7259	.8402	.7446
23	.6329	.6515	.6515	.6619	.6515	.5601	.6143
24	.5148	.5584	.5956	.5584	.5883	.5584	.5228
Max	1.3973	1.4333	1.4333	1.303	1.3053	1.396	1.363
Min	.478	.5212	.5212	.5212	.5148	.5212	.5228
Avg	.8341	.8397	.8376	.8112	.8631	.8626	.8087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 202 / 11KV DAGADWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0494	.0556	.0554	.0926	.1318	.0556	.056
2	.0494	.0556	.0554	.0926	.0989	.0556	.056
3	.0494	.0556	.0373	.0926	.0989	.0556	.056
4	.0659	.0742	.0501	.1111	.1154	.0926	.056
5	.1154	.0927	.0554	.1296	.1318	.1481	.0934
6	.1648	.1112	.0924	.1667	.1483	.1852	.1494
7	.1978	.1112	.1663	.2407	.1648	.2222	.2987
8	.1978	.1112	.1478	.2778	.1978	.2593	.2801
9	.1978	.0742	.1109	.2142	.1978	.2241	.2614
10	.1112	.0927	.0921	.1978	.2037	.2801	
11	.2225	.0927	.1842	.1978	.2963	.2801	.2569
12	.2595	.0927	.2027	.0989	.3333	.2987	.2752
13	.2781	.0744	.2395	.2142	.3148	.2987	.2569
14	.2595	.0742	.2579	.2307	.0556	.2427	.2752
15	.2595	.0742	.0926	.3131	.1852	.1823	.2936
16	.241	.0927	.2222	.2142	.1111	.2427	.2936
17	.1854	.0927	.4259	.2472	.2222	.2054	.1468
18	.1298	.1298	.2037	.1154	.1852	.1494	.1468
19	.1483	.1112	.2407	.2142	.1667	.112	.1483
20	.2225	.1112	.2593	.1813	.0926	.112	.168
21	.2225	.0927	.2593	.1648	.0741	.112	.112
22	.2225	.0558	.1852	.1648	.0741	.0934	.1112
23	.2225	.0554	.1111	.1648	.0556	.0747	.0927
24	.0494	.2225	.056	.1111	.1318	.0556	.056
Max	.2781	.2225	.4259	.3131	.3333	.2987	.2987
Min	.0494	.0554	.0373	.0926	.0556	.0556	.056
Avg	.1717	.0919	.1585	.1770	.1578	.1683	.1713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054133 / 33/11KV DAWAKHANA S/S

Feeder No / Name : 203 / 11 KV KURUNWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1318		.1644	.0992	.1318	.1323	.1823
2	.1318	.2241	.1644	.0827	.1318	.1323	.1823
3	.1318	.1867	.1644	.0827	.1318	.1323	.1823
4	.1648	.2241	.1973	.0992	.1648	.1323	.1989
5	.1978	.2614	.2302	.1488	.2142	.1488	.2321
6	.2966	.3734	.3617	.215	.2966	.2646	.2652
7	.3955	.5415	.4933	.215	.3955	.3804	.4973
8	.3955	.4481	.411	.1984	.412	.3307	.4475
9	.2966	.3174	.3782		.3296	.2818	.4641
10	.2204	.2054	.2646		.1984	.2818	
11	2.0538	1.643	1.6868		1.4553	1.1603	1.3443
12	2.0911	1.7924	1.7364		1.7364	1.5746	1.9044
13	2.0911	1.8858	1.9183		2.1168	1.7901	2.0911
14	2.0351	1.9418	2.0175		1.6537	1.8233	2.0538
15	1.9978	1.8671	.2481		1.7364	1.8896	2.0538
16	1.9605	1.8111	.1654		1.8356	2.0222	1.9791
17	1.8671	1.7177	.2977		1.7695	1.6078	1.9231
18	1.4563	1.587	.2977		1.6041	1.4918	1.7177
19	.2427	.2801	.1158		.2315	.2155	.2241
20	.2614	.2302	.0992		.1984	.2486	.2427
21	.2427	.1809	.0992	.2307	.1984	.2818	.2241
22	.2427	.1973	.0992	.1813	.1488	.2652	.2054
23	.2427	.1973	.0992	.1318	.1323	.2321	.1867
24	.1318	.2241	.1809	.0992	.1318	.1323	.1823
Max	2.0911	1.9418	2.0175	.2307	2.1168	2.0222	2.0911
Min	.1318	.1809	.0992	.0827	.1318	.1323	.1823
Avg	.8033	.7973	.4955	.1487	.7231	.7064	.8254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 201 / MURTI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0876	.0701		.2454	.2629	.2454
2		.0876	.0701		.3155	.3506	.4207
3		.1227	.0876		.3506	.3856	.4382
4		.1402	.1052		.3856	.4207	.6135
5		.1578	.1402		.3856	.4908	.6661
6		.2103	.1753		.4908	.5609	.6661
7		.2629	.2103		.5434	.6661	.631
8	.2454	.2804			.6661	.7011	.7011
9		.2454		.6661	.6661	.7011	.631
10	.2103	.2103		.5258	.631	.5258	.4908
11	.5609	.5258		.1402	.1052	.1753	.2103
12	.1402	.5609	.5609	.0876	.0876	.1052	.1753
13	.631			.0701		.0876	.1227
14	.631	.5959		.0526		.0701	.1052
15	.5959		.4557	.0526	.0351	.0701	.1052
16	.5609	.5609		.0351	.0351	.0701	.1052
17	.5258	.5258		.0701	.0701	.1052	.0876
18	.4908	.4557		.1052	.1402	.1402	.1402
19	.2103			.1753	.1753	.1753	.2103
20	.1753			.2103	.2103	.2103	.1753
21	.1227			.1402		.1753	.1227
22	.1052			.0876		.1052	.1052
23	.0876			.0701		.0876	.0876
24	.0701	.0876	.0701	.0701	.0701	.0876	.0701
Max	.631	.5959	.5609	.6661	.6661	.7011	.7011
Min	.0701	.0876	.0701	.0351	.0351	.0701	.0701
Avg	.3352	.3010	.1946	.1599	.2952	.2804	.3053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 202 / PATTIWADGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012	.218		.3353	.3521	.3688
2		.2683	.285		.4359	.4527	.4527
3		.3353	.3353		.503	.503	.5197
4		.4359	.3856		.5365	.57	.5868
5		.503	.4191		.5868	.6371	.6371
6		.57	.4527		.7377	.7042	.7209
7		.6371	.503		.8718	.8383	.8048
8	.57	.5868			.8383	.9054	.8383
9		.503		.8383	.8048	.7545	.7712
10	.4024	.4191		.6371	.7712	.7042	.6706
11	.7042	.6539		.3353	.3521	.2515	.3018
12	.2347	.8048	.6874	.3018	.1341	.1677	.2347
13	.7377			.2683		.1509	.1677
14	.8048	.6539		.2347		.1677	.1677
15	.8383		.7042	.2347	.1174	.1844	.1677
16	.8048	.9389		.2515	.1341	.1509	.1677
17		.9054		.2683	.1509	.2012	.1844
18	.6706	.7712		.3353	.2515	.2347	.2347
19	.4694			.4694	.4694	.4694	.4527
20	.503			.4024	.4191	.4359	.4024
21	.3353			.3521		.3688	.3185
22	.2515			.2347		.285	.2515
23	.218			.2012		.218	.2012
24	.1677	.2012	.2012	.2012	.2012	.2012	.2012
Max	.8383	.9389	.7042	.8383	.8718	.9054	.8383
Min	.1677	.2012	.2012	.2012	.1174	.1509	.1677
Avg	.5142	.5523	.4192	.3479	.4553	.4129	.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

AMBEJOGAI[422]

BU 2569

Substation No/ Name :- 054141 / PATTIWADGAON SUBSTATION

Feeder No / Name : 203 / BHABALGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.788	.7042		.1677	.1844	.1844
2		1.0395	.8048		.218	.218	.2347
3		1.1736	1.0562		.2515	.2683	.2683
4		1.2407	1.2407		.3353	.3353	.3353
5		1.4419	1.4419		.3688	.5197	.4694
6		1.5424	1.4922		.5365	.5868	.5868
7		1.6766	1.5424		.8215	.6706	.6706
8	1.5424	1.5592			.7712	.7712	
9		1.4586		.6706	.6706	.7209	.788
10	1.291	1.4251		.5365	.57	.6371	.7042
11	.3521	.3856		1.1065	.9389	1.0059	1.2574
12	.0838		.2012	1.5089	1.291	1.0395	1.291
13	.2012			1.4251	1.2574	1.073	1.291
14	.2012	.2347		1.3916	1.3413	1.0562	1.3077
15	.1844	.1844	.1509		1.291	1.0898	1.3245
16	.1844	.1509		1.3748	1.3077	1.3413	1.3245
17	.1844	.2012		1.4419	1.358	1.2574	1.3077
18	.3353	.3521		1.2407	1.2071	1.1904	1.2239
19	.6371			.5365	.5197	.4527	.5365
20	.503			.4527	.4527	.4527	.4527
21	.3856			.3521		.3688	.3856
22	.285			.2515		.3018	.285
23	.218			.218		.2347	.2347
24	.1844	.1677	.1509	.1677	.1677	.1677	.1844
Max	1.5424	1.6766	1.5424	1.5089	1.358	1.3413	1.3245
Min	.0838	.1509	.1509	.1677	.1677	.1677	.1844
Avg	.4233	.8837	.8785	.8450	.7545	.6643	.7238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 201 / 11 KV DHARUR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-JAN-18
HR	Load (MW)
13	.2134
Max	.2134
Min	.2134
Avg	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 204 / EXPRESS JINING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0286					
2		.0343					
3		.0286					
4		.04					
5		.0286					
6		.0171					
7	.1307	.0114	.1097		.0362		.0732
9			.0191	.0286	.0229	.0343	.1494
10			.0114	.0343	.0114	.0343	.1494
11	.0747		.0286	.0457		.0457	.1307
12			.04	.061		.0114	.112
13				.0533	.0076		
14				.0286	.0114		
15		.112	.061	.0533	.0114		.112
16	.1494						
17	.04	.1646	.1307			.1463	
18	.04		.112	.1463			
19	.0286						
20	.0533						
21	.0343						
22	.0343						
23							.112
24	.0934	.0343					
Max	.1494	.1646	.1307	.1463	.0362	.1463	.1494
Min	.0286	.0114	.0114	.0286	.0076	.0114	.0732
Avg	.0679	.0500	.0641	.0564	.0168	.0544	.1198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 205 / GFSS Avargaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677					
2		.2191					
4		.3315					
5		.3887					
6		.5335					
7	.9896	.6001	.8859		.9313		.8596
9			.6135	.5468	.4687	.6401	.7164
10			.3429	.2096	.4344	.423	.6089
11	.4024		.3201	.181	.3429	.3544	.5731
12	.4024	.2987	.2286	.1905	.3086	.2286	.5194
13				.1296	.181		
14				.1067	.1219		
15			.1524		.1619		.2865
16	.3475						
17	.1905		.4207		.3801	.4656	
18	.3544		.4938	.439			
19	.5335						
20	.5601						
21	.5335						
22	.3544						
23							.4108
24	.4108	.2743					
Max	.9896	.6001	.8859	.5468	.9313	.6401	.8596
Min	.1905	.1677	.1524	.1067	.1219	.2286	.2865
Avg	.4617	.3517	.4322	.2576	.3701	.4223	.5678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054005 / 33/11 KV DHARUR

Feeder No / Name : 206 / GFSS Aranwadi
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0114					
2		.0114					
3		.0229					
4		.0114					
5		.04					
6		.0953					
7	.2241	.1334	.2561		.2378		.2353
9			.04	.04	.0191	.0572	.1791
10			.0191	.0286		.04	.1254
11	.0549		.0114	.0286	.0114	.0152	.1075
12	.0366	.0373	.0114	.0229	.0076	.0171	.1075
13				.0114	.0076		
14				.0114	.0076		
15		.0373	.0114	.0008	.0076		.0358
16	.0183						
17	.0114	.0532	.0732			.0709	
18	.04			.1063			
19	.0457						
20	.061						
21	.0457						
22	.0229						
23							.0373
24	.0373	.0114					
Max	.2241	.1334	.2561	.1063	.2378	.0709	.2353
Min	.0114	.0114	.0114	.0008	.0076	.0152	.0358
Avg	.0544	.0423	.0604	.0313	.0427	.0401	.1183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 201 / 11 KV. ADAS FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5261	1.0174	1.0174	1.0174	1.3565	1.5261	1.3565
2	1.5261	1.5261	1.3565	1.3565	1.5261	1.5261	1.3565
3	1.5261	1.6956	1.3565	1.3565	1.5261	1.5261	1.3565
4	1.6956	1.6956	1.3565	1.3565	1.8652	1.6956	1.6956
5	1.6956	1.8652	1.5261	1.5261	1.6956	1.6956	2.0348
6	2.0348	1.8652	1.6956	1.6956	2.0348	1.8652	2.2043
7	2.0348	1.8652	2.0348	2.0348	2.0348	2.2043	2.2043
8	2.0348	1.8652	2.0348	2.0348	1.8652	2.0348	2.1195
9	2.2043	2.0348	1.8652	2.0348	1.6956	2.0348	2.0348
10	1.8652	1.6956	1.6956	2.0348	1.6956	2.0348	2.0348
11	.5087	.5087	.5087	.5087	.5087	.5087	.5087
12		.5087	.5087	.6783	.5087		.5087
13	.5087	.5087		.6783	.5087	.5087	.5087
14	.5087	.5087		.6783	.5087	.5087	.5087
15		.5087	.5087	.6783	.5087	.5087	.5087
16	.5087	.5087	.5087	.5087	.5087	.5087	.5087
17		.5087	.5087	.8478	.5087	.6783	.5087
18	.5087	.8478	.8478	1.0174	.5087	.8478	.5087
19	1.0174	1.0174	1.0174	1.0174	1.0174	1.0174	.8478
20		1.0174	1.0174	1.0174	1.0174	1.0174	1.0174
21		1.0174	1.0174	1.0174	1.0174	.6783	.8478
22		.8478	.8478	1.0174	.8478	.5087	.6783
23		.5087	.5087	.8478	.6783	.5087	.6783
24	.5087	.5087	.5087	.5087	.5087	.5087	.5087
Max	2.2043	2.0348	2.0348	2.0348	2.0348	2.2043	2.2043
Min	.5087	.5087	.5087	.5087	.5087	.5087	.5087
Avg	1.3066	1.1022	1.1022	1.1446	1.1022	1.1501	1.1269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 202 / 11 KV. KHODAS FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3791	.5115	.3791	.3791	.1896	.3791	.3791
2	.3791	.341	.3791	.3791	.3791	.3791	.3791
3	.3791	.341	.3791	.3791	.3791	.3791	.3791
4	.3791	.341	.3791	.3791	.3791	.3791	.3791
5	.3791	.5115	.3791	.4739	.5687	.3791	.4739
6	.5687	.5115	.4739	.5687	.5687	.5687	.5687
7	.5687	.5115	.5687	.5687	.5687	.5687	.7583
8	.5687	1.8652	.5687	.5687	.5687	.5687	.7583
9	.3791	.5687	.4739	.4739	.5687	.3791	.5687
10	.3791	.3791	.3791	.3791	.5687	.3791	.3791
11	3.3174	1.7061	1.8957	2.0852	1.8957	2.0852	2.0894
12	3.3174	1.8957	2.0852	2.4644	2.2748	2.2748	2.4693
13	3.3174	2.0852		2.2748	2.4644	2.2748	2.6593
14	3.3174	1.8957		2.2748	2.4644	2.0852	2.4693
15	3.3174	1.8957	2.0852	2.0852	2.4644	2.0852	2.4693
16	2.2748	1.8957	2.2748	1.9905	2.2748	1.8957	2.4693
17	2.2748	1.8957	2.2748	1.8957	2.0852	2.0852	2.4693
18		1.7061	2.2748	1.8957	1.8957	2.0852	1.8995
19	.5687	.5687	.5687	.3791	.5687	.5687	.3799
20	.5687	.5687	.5687	.5687	.5687	.5687	.5698
21	.5687	.5687	.5687	.5687	.5687	.5687	.3799
22	.5687	.3791	.5687	.5687	.5687	.3791	.3799
23		.3791	.3791	.3791	.3791	.3791	.3799
24	.3791	.5115	.3791	.3791	.1896	.3791	.3791
Max	3.3174	2.0852	2.2748	2.4644	2.4644	2.2748	2.6593
Min	.3791	.341	.3791	.3791	.1896	.3791	.3791
Avg	1.2796	.9931	.9220	1.0150	1.0584	1.0031	1.1036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054017 / 33 KV. ADAS S/S

Feeder No / Name : 203 / 11 KV ASARDON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7583		.5687	.5687	.9478	.7583	.7583
2	.9478	.9478	.7583	.7583	.9478	.9478	.7583
3	.9478	1.1374	.9478	.7583	1.1374	.9478	.7583
4	.9478	1.1374	.9478	.9478	1.5165	1.1374	.9478
5	1.1374	1.1374	.9478	.9478	1.5165	1.1374	1.1374
6	1.1374	1.327	1.2322	1.1374	1.327	1.327	1.327
7	1.1374	1.327	1.4218	1.2322	1.5165	1.327	1.327
8	1.1374	1.1374	1.4218	1.2322	1.5165	1.327	1.327
9	1.327	1.1374	1.327	1.1374	1.327	1.1374	1.1374
10	1.1374	.9478	1.327	1.1374	1.1374	1.1374	1.1374
11	.3791	.3791	.1896	.1896	.1896	.1896	.1896
12	.3791	.1896	.1896	.3791	.1896	.1896	.1896
13	.1896	.1896		.3791	.1896	.1896	.1896
14	.1896	.1896		.3791	.1896	.1896	
15	.1896	.1896	.1896	.1896	.1896	.1896	
16	.1896	.1896	.1896	.1896	.1896	.1896	.1896
17	.1896	.1896	.1896	.3791	.1896	.1896	.1896
18	.1896	.3791	.3791	.3791	.1896	.3791	.1896
19	.3791		.5687		.3791	.5687	.3791
20	.3791		.5687	.5687	.5687	.5687	.5687
21	.3791		.5687	.5687	.5687	.4739	.3791
22			.4739	.3791	.3791	.1896	.3791
23		.1896	.1896	.3791	.1896	.1896	.1896
24	.3791	.3791	.1896	.1896	.1896	.1896	.1896
Max	1.327	1.327	1.4218	1.2322	1.5165	1.327	1.327
Min	.1896	.1896	.1896	.1896	.1896	.1896	.1896
Avg	.6376	.6685	.6721	.6264	.6951	.6280	.6290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 201 / HOAL

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	09-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	2.915	2.7435	2.7435
2	3.0864	2.7435	
3	3.4294	2.915	2.915
4			3.0864
5	3.6008	3.0864	3.4294
6	3.7723	3.4294	
7			3.6008
8	3.4294	3.7723	3.7723
9			3.858
10	3.0864		
11	2.915		2.7435
12	3.4294		3.2579
13	3.4294		
14	3.2579		
15	3.0864		2.915
16			3.0864
18			3.0007
19			1.2003
24	.5144	.5144	.5144
Max	3.7723	3.7723	3.858
Min	.5144	.5144	.5144
Avg	3.0732	2.7435	2.8660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 202 / LADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.1715
2	.1715	.2058	
3			.1715
4		.3429	
5	.2572	.4287	.2572
6	.3429		
9			.2572
11	2.7435		
12			3.1722
13	3.4294		
14	3.4294		3.6008
15	3.0864		3.5151
16			3.1722
17			2.915
18			2.6578
24	.1715	.2058	.2058
Max	3.4294	.4287	3.6008
Min	.1715	.2058	.1715
Avg	1.7040	.2958	1.8269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 203 / BHATUMBA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	09-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2058		.2058
2		.2572	.1715
3	.1715		
4			.1715
5	.3086	.3429	
6	.3429		.3429
9	.3429		
10			.2058
24	.2058	.2572	.2058
Max	.3429	.3429	.3429
Min	.1715	.2572	.1715
Avg	.2629	.2858	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054063 / 33/11 KV HOAL S/S

Feeder No / Name : 204 / CHANDANSAVARGAON
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	09-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	2.572		2.572
2	3.0864	2.572	
3			2.915
4	3.7723	2.915	
5	3.7723		3.0864
6	3.6008	3.0864	3.4294
8		3.6008	
9			3.7723
10			2.0576
12	.2058		.2572
14	.1715		
15	.1372		.2058
17			.2572
18			.3429
24	.2572	.2058	.3086
Max	3.7723	3.6008	3.7723
Min	.1372	.2058	.2058
Avg	1.9528	2.476	1.7459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 201 / GAVANDHARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-JAN-18
HR	Load (MW)
14	.2503
Max	.2503
Min	.2503
Avg	.2503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054072 / 33/11 KV AMBEWADGAON S/S

Feeder No / Name : 202 / AMBEWAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2756				1.6206	
2	1.2756				1.6041	
3	1.3077				1.5857	
4	1.3245				1.5692	
5					1.6518	
6	.503				.4955	
7	.6036				.6277	
8	.5533				.6607	
9	.47	.6161			.5781	.6435
10	.3357	.3663				.561
11	.2518	.2165				.5115
12						.462
13						.363
14			.2503			.2475
15						.2147
16		.2997	.2503		.1652	
17				.2815		
18				.3973		
19				.5138		
20				.3481		
21				.2818		
22				1.6244		
23				1.6391		
24	1.3458				1.6206	
Max	1.3458	.6161	.2503	1.6391	1.6518	.6435
Min	.2518	.2165	.2503	.2815	.1652	.2147
Avg	.8406	.3747	.2503	.7266	1.1072	.4290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 201 / Morphali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3201	.5182	.5335	.5792	.4877	.5487
2	.5944	.3963	.5792	.5792	.5792	.4877	.5944
3	.6097	.4725	.6097	.6097	.6097	.5792	.6554
4	.6249	.503	.6249	.6249	.7011	.6706	.6859
5	.6554	.5487	.6859	.6706	.7468	.7011	.7011
6	.6554	.6249	.6859	.6859	.823	.7621	.7468
7	.6706	.6706	.7011	.7316	.9145	.8535	.7926
8	.7164	.7164	.7621	.7164	1.0059	.7316	.9907
9	.7164	.8078	.7316	.7926	.945	.8535	.9602
10	.6859	.5944	.6706	.7164	.9145	.6249	.8993
11	.0572	.0762	.0572	.0572	.0572	.0381	.0762
12	.0381	.0572	.0572	.0572	.0572	.0381	.0762
13	.0381	.0381		.0381	.0381	.0381	.0572
14	.0381	.0381			.0381	.0381	.0572
15	.0381	.0381	.0381	.0381	.0381	.0381	.0572
16	.0381	.0381	.0381	.0572	.0381	.0381	.0572
17	.0572	.0381	.0572	.0762	.0381	.0572	.0572
18	.0762	.0762	.0762	.0762	.0381	.0762	.0572
19	.0953	.1143	.1334	.1143	.0762	.1143	.1143
20	.0953	.1143	.0953	.1143	.1143	.0953	.1143
21	.0762	.0762	.0953	.0953	.1143	.0953	.0953
22	.0762	.0572	.0762	.0762	.0762	.0762	.0762
23	.0572	.0572	.0572	.0572	.0381	.0762	.0762
24	.0572	.0572	.0572	.0572	.0381		.0572
Max	.7164	.8078	.7621	.7926	1.0059	.8535	.9907
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0572
Avg	.3048	.2721	.3367	.3294	.3591	.3292	.3585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 202 / Asardoha SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1905	.1715	.1905	.1524	.2477
2	.1905	.2096	.2096	.1905	.1905	.1524	.2667
3	.2286	.2286	.2286	.1905	.2096	.1524	.2858
4	.3048	.2286	.2667	.2667	.2477	.1905	.2858
5	.381	.2858	.3239	.3239	.3048	.2667	.3048
6	.4191	.362	.4001	.381	.381	.3429	.362
7	.4572	.4382	.4763	.4191	.4191	.381	.4191
8	.4382	.4001	.4382	.4191	.381	.0343	.4191
9	.381	.362	.4001	.362	.3429	.3048	.381
10	.3048	.3239	.2667	.3048	.2667	.3429	.381
11	1.1888	1.0974	1.0974	1.1279	1.3108	1.2803	1.2041
12	1.326	1.3108	1.326	1.4632	1.4022	1.4327	1.2955
13	1.387	1.4327		1.448		1.4937	1.4632
14	1.4327	1.448		1.4175	1.4022	1.4175	1.5394
15	1.5394	1.448	1.4327	1.1431	1.4327	1.5394	1.4327
16	1.5089	1.3717	1.4022	1.4327	1.4632	1.5089	
17	1.4784	1.3108	1.3565	1.5089	1.4632	1.4784	
18	1.2803	1.1736	1.0822	1.3565	1.4327	1.0669	.6401
19	.4001	.4382	.4191	.362	.381	.4191	.2858
20	.3239	.362	.3429	.3048	.381	.3239	.2667
21	.2858	.3048	.2667	.2286		.2858	.2477
22	.2477	.2096	.1905	.2286	.2667	.2286	.2096
23	.2096	.1905	.1905	.2096	.2286	.2286	.2096
24	.1715	.1905	.1905	.1715	.1905		.2096
Max	1.5394	1.448	1.4327	1.5089	1.4632	1.5394	1.5394
Min	.1715	.1905	.1905	.1715	.1905	.0343	.2096
Avg	.6690	.6382	.5681	.643	.6495	.6532	.5617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

DHARUR SUB-DN.[744] BU 4744

Substation No/ Name :- 054113 / 33KV ASARDOH S/stn

Feeder No / Name : 203 / Rui dharur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.4268	.4572	.6401	.5487	.5182	.5792
2	.9907	.5487	.7164	.7316	.6554	.6401	.6249
3	1.0212	.6554	.7926	.823	.6859	.6401	.7316
4	1.1279	1.0364	.9145	.9602	.7621	.7316	.945
5	1.1584	1.1279	1.1888	1.1736	.7926	.7621	1.0517
6	1.2651	1.326	1.2193	1.2955	1.2651	1.1888	1.2193
7	1.3565	1.387	1.3565	1.4327	1.387	1.3717	1.4022
8	1.4022	1.3108	1.4022	1.3717	1.4784	1.3108	1.387
9	1.2193	1.2651	1.387	1.2193	1.4327	1.3413	1.3413
10	1.1584	1.0364	1.0059	1.0822	1.326	.9297	1.1431
11	.1715	.1524	.1715	.1715	.1905	.2096	.2477
12	.1143	.1334	.1143	.1905	.1905	.1524	.2096
13	.0953	.1143		.1524	.1524	.1143	.1715
14	.0953	.1143		.0953	.1524	.0953	.1524
15	.1143	.1524	.0953	.1143	.1143	.1143	.1524
16	.1143	.1334	.1334	.1524	.1143	.1143	.1524
17	.1905	.2286	.1905	.1905	.1524	.1905	.1143
18	.3429	.2858	.3048	.2096	.1905	.2667	.2286
19	.4191	.4191	.4763	.4954	.4572	.381	.3429
20	.362	.362	.362	.4001	.4191	.3239	.3048
21	.3048	.2858	.2858	.2858	.3429	.2858	.2667
22	.2858	.2096	.1905	.2286	.2667	.2477	.2096
23	.2477	.2096	.1715	.1905	.2286	.1905	.1905
24	.1715	.1905	.1524	.1715	.1905		.1715
Max	1.4022	1.387	1.4022	1.4327	1.4784	1.3717	1.4022
Min	.0953	.1143	.0953	.0953	.1143	.0953	.1143
Avg	.6089	.5463	.5949	.5741	.5623	.5270	.5558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 201 / Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.5729						
8					2.0302		
12			1.2178	1.3717	.8848		1.5023
14	1.1041						
16				1.1157			
18			1.5995		1.4177		1.3213
19		1.4529					
24	.6401	.6335		.6899	.6461	.6725	
Max	1.5729	1.4529	1.5995	1.3717	2.0302	.6725	1.5023
Min	.6401	.6335	1.2178	.6899	.6461	.6725	1.3213
Avg	1.1057	1.0432	1.4087	1.0591	1.2447	.6725	1.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 202 / Tambva

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.6452	2.713	3.0521	3.3779
14	2.9835				
16			3.2579		
18		2.9675		2.4143	2.8675
Max	2.9835	2.9675	3.2579	3.0521	3.3779
Min	2.9835	2.6452	2.713	2.4143	2.8675
Avg	2.9835	2.8064	2.9855	2.7332	3.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 204 / Massajog Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	2.2377						
8					3.0498		
10				2.652			
12			.0826	.0995	.0992		.1147
14	.0995						
16				.0829			
18			.0992		.0992		.0983
24	.0995	.0829		.1158	.0995	.0827	
Max	2.2377	.0829	.0992	2.652	3.0498	.0827	.1147
Min	.0995	.0829	.0826	.0829	.0992	.0827	.0983
Avg	.8122	.0829	.0909	.7376	.8369	.0827	.1065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 205 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	2.2068						
8					2.2822		
10				2.2068			
12			1.3852	2.0182	1.9735		2.2634
14	1.6221						
16				1.6975			
18			2.0494		1.9166		1.7353
19		1.6124					
24	.8676	.811		1.0057	.9054	1.0057	
Max	2.2068	1.6124	2.0494	2.2068	2.2822	1.0057	2.2634
Min	.8676	.811	1.3852	1.0057	.9054	1.0057	1.7353
Avg	1.5655	1.2117	1.7173	1.7321	1.7694	1.0057	1.9994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 206 / Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3395						
8					.1097		
10				.3395			
12			.415	.3206	.3239		.132
14	.3961						
16				.3772			
18			.3772		.1417		.1307
24	.3584	.0848		.5281	.4715	.4805	
Max	.3961	.0848	.415	.5281	.4715	.4805	.132
Min	.3395	.0848	.3772	.3206	.1097	.4805	.1307
Avg	.3647	.0848	.3961	.3914	.2617	.4805	.1314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 207 / GFS sonijawalla

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3921						
8					.3658		
10				.3292			
12			.2247	.3658	.3654		.3403
14	.2629						
16				.3292			
18			.3189		.3765		.2321
24	.2195	.2629		.2195	.2195	.2355	
Max	.3921	.2629	.3189	.3658	.3765	.2355	.3403
Min	.2195	.2629	.2247	.2195	.2195	.2355	.2321
Avg	.2915	.2629	.2718	.3109	.3318	.2355	.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054002 / 33KV KAIJ

Feeder No / Name : 208 / GFS Tambva

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.5487						
8					.4024		
10				.3841			
12			.2402	.1463	.1846		.4207
14	.1478						
16				.1463			
18			.2957		.2769		.2012
24	.128	.1294		.1292	.1463	.1477	
Max	.5487	.1294	.2957	.3841	.4024	.1477	.4207
Min	.128	.1294	.2402	.1292	.1463	.1477	.2012
Avg	.2748	.1294	.2680	.2015	.2526	.1477	.3110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 201 / Bansarola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							1.2936
8	1.2012	1.1706			1.1827	1.1827	
13				.9175			
18				.8223			.7682
24	.4755	.4656	.5121	.4755	.4656	.5014	.5121
Max	1.2012	1.1706	.5121	.9175	1.1827	1.1827	1.2936
Min	.4755	.4656	.5121	.4755	.4656	.5014	.5121
Avg	.8384	.8181	.5121	.7384	.8242	.8421	.8580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 202 / Isthal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.9602
8	2.0481	1.9662			1.3443	1.4403	
18				.2774			.1949
24	.1254	.2172	.197	.1433	.1509	.1612	.1433
Max	2.0481	1.9662	.197	.2774	1.3443	1.4403	.9602
Min	.1254	.2172	.197	.1433	.1509	.1612	.1433
Avg	1.0868	1.0917	.197	.2104	.7476	.8008	.4328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 203 / Kaudgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.7049
8		.5335			.6097	.5335	
18				1.3889			1.6049
24	.1715	.2614	.2477	.1905	.1848	.2054	.2286
Max	.1715	.5335	.2477	1.3889	.6097	.5335	1.6049
Min	.1715	.2614	.2477	.1905	.1848	.2054	.2286
Avg	.1715	.3975	.2477	.7897	.3973	.3695	.8461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 204 / Jawallban SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.2452
8	.2096	.2241			.2286	.1698	
18				1.4403			1.4746
24	.0572	1.2803	1.0822	1.07	.9755	1.0608	1.0031
Max	.2096	1.2803	1.0822	1.4403	.9755	1.0608	1.4746
Min	.0572	.2241	1.0822	1.07	.2286	.1698	.2452
Avg	.1334	.7522	1.0822	1.2552	.6021	.6153	.9076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 205 / Awasgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							.7922
8	.7545	.6859			.7356	.743	
18				.3326			.3048
24	.2477	.2477	.2477	.2286	.2263	.2452	.2667
Max	.7545	.6859	.2477	.3326	.7356	.743	.7922
Min	.2477	.2477	.2477	.2286	.2263	.2452	.2667
Avg	.5011	.4668	.2477	.2806	.4810	.4941	.4546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054015 / 33KV BANSAROLA

Feeder No / Name : 206 / Borisavargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							2.6825
8	2.0454	2.332			2.6825	2.6216	
18				.3018			.3239
24	1.9109	.3048	.2858	.2667	.3048	.3018	.2858
Max	2.0454	2.332	.2858	.3018	2.6825	2.6216	2.6825
Min	1.9109	.3048	.2858	.2667	.3048	.3018	.2858
Avg	1.9782	1.3184	.2858	.2843	1.4937	1.4617	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 201 / Yusufwadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7183			.7468	
2	.7868			.8002	
3	.8768			.8288	
4	.9374			1.0117	
5	1.0059			1.1317	
6	1.1317		1.2087		1.046
7	1.3717				1.3714
8	1.4175				
10				1.2117	
11				.2469	
12				.1524	
16		.1437		.1799	
24	.1052	.0983		.1097	.1097
Max	1.4175	.1437	1.2087	1.2117	1.3714
Min	.1052	.0983	1.2087	.1097	.1097
Avg	.9279	.121	1.2087	.6420	.8424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054040 / YUSUFWADGAON

Feeder No / Name : 202 / Sadola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001			.4496	
2	.4572			.5845	
3	.5525			.5733	
4	.5525			.607	
5	.5857			.607	
6	.6188		.5304		.6299
7	.7183				.7183
8	.7514				
10				.6299	
11				.0613	
12				.0396	
16		.0211		.0291	
24		.02		.0122	.02
Max	.7514	.0211	.5304	.6299	.7183
Min	.4001	.02	.5304	.0122	.02
Avg	.5796	.0206	.5304	.3594	.4561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 204 / GFSS H.pimpri
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5144	.4382	.3582	.5544
Max	.5144	.4382	.3582	.5544
Min	.5144	.4382	.3582	.5544
Avg	.5144	.4382	.3582	.5544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054043 / 33/11 KV H.PIMPRI SS

Feeder No / Name : 205 / 11 KV Borgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.3658	.2743	.181	.2743
Max	.3658	.2743	.181	.2743
Min	.3658	.2743	.181	.2743
Avg	.3658	.2743	.181	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 204 / GFSS Dhanegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3696
2	.362					.3582
3						.3582
4	.362					.4477
5						.4477
6	.5373					.5258
7			.3239			.5373
8	.5258					
9			.4801		.6401	.6268
10				.3429	.5373	
11					.3582	
12					.1791	
13					.1791	
14					.1753	
15					.1791	
16				.1715	.1791	
17					.3506	
18					.3582	
19					.4477	
20					.4477	
21		.4001			.4477	
22					.4477	
23					.3582	
24	.3506		.3163		.3201	.3582
Max	.5373	.4001	.4801	.3429	.6401	.6268
Min	.3506	.4001	.3163	.1715	.1753	.3582
Avg	.4275	.4001	.3734	.2572	.3503	.4477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054077 / DHANEGAON

Feeder No / Name : 205 / GFSS Pathra

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5373				
4	.5373				
6	.7164				
7			.4915		
8	.8764				
9			.8288		.6554
10				.6001	
14					.5258
15					.5258
16				.3429	.3582
17					.5373
18					.5373
19					.7164
20					.7164
21		.3277			
24	.5373		.4801		.4915
Max	.8764	.3277	.8288	.6001	.7164
Min	.5373	.3277	.4801	.3429	.3582
Avg	.6409	.3277	.6001	.4715	.5627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 201 / Massajog

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-JAN-18
HR	Load (MW)
21	.6783
Max	.6783
Min	.6783
Avg	.6783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 202 / Sangvi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-JAN-18
HR	Load (MW)
21	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054079 / MASSAJOG

Feeder No / Name : 203 / SHINDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-JAN-18
HR	Load (MW)
21	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 202 / Janegaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	10-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.0914		
9		2.4006	
11			2.2558
Max	.0914	2.4006	2.2558
Min	.0914	2.4006	2.2558
Avg	.0914	2.4006	2.2558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 203 / Kumbephal
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	10-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	2.3167		
9		.0857	
11			.061
Max	2.3167	.0857	.061
Min	2.3167	.0857	.061
Avg	2.3167	.0857	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054080 / KUMBEPHAL

Feeder No / Name : 205 / Kumbhefal Gfss
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-18	10-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.5792		
9		.5487	
11			.2286
Max	.5792	.5487	.2286
Min	.5792	.5487	.2286
Avg	.5792	.5487	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 201 / Devgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0395		1.073	.9389		.2622	.2949
2	1.1736		1.2742	1.3413		.2622	.2949
3	1.3077		1.3748	1.5424		.2949	
4	1.5089		1.6095	1.7101		.2622	
5	2.0119			2.3137			
6	2.2131			2.3807			
7	2.2634			2.3472			
8	2.6825			2.4478			
9	2.5819			2.4143			
10	2.2131						
11					2.1628	1.9334	2.2801
12					2.4577	2.5888	2.4143
13					2.7199	2.4577	2.3472
14					2.6189	2.4905	2.3137
15					2.4249	2.0317	2.2131
16					2.4577	2.0972	1.9448
17			.2683		2.5232	2.2939	2.4143
18		.4359	.4359		2.4249	2.2283	1.9448
19			.6371		.5898	.5243	.57
20		.503	.4359		.6554	.5898	.4359
21			.4024		.5243	.4588	.4024
22		.4359	.2347		.426	.426	.3353
23			.2012		.3277	.3605	.3353
24			.2012			.2622	.3018
Max	2.6825	.503	1.6095	2.4478	2.7199	2.5888	2.4143
Min	1.0395	.4359	.2012	.9389	.3277	.2622	.2949
Avg	1.8996	.4583	.6790	1.9374	1.7164	1.2125	1.3027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 202 / Limbachiwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064		.032			.8192	.8192
2	.064		.032	.064		.8848	.8848
3	.096		.032	.064		.8848	
4	.096			.096		.9503	
5						.9831	.9831
6						1.0159	1.0814
7						.9175	1.2125
8						1.0486	1.2308
9						1.1797	1.0814
10					1.1012	1.2452	1.1469
12		1.4723					
13			1.2803				
14		1.4403	1.3123				
15			1.3763				
16		1.1523	1.2803				.064
17			1.3123		.0324		.096
18		1.1203	1.1203		.0324	.0655	.096
19			.16		.1296	.0983	.096
20			.128		.1296	.0983	.096
21			.096		.0972	.0655	.064
22			.064		.0648	.0648	.064
23		.064	.064		.0328	.0324	.064
24			.064			.0324	.064
Max	.096	1.4723	1.3763	.096	1.1012	1.2452	1.2308
Min	.064	.064	.032	.064	.0324	.0324	.064
Avg	.08	1.0498	.5569	.0747	.2025	.6110	.5379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 203 / Dahiphal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096		.0972	.0648		.7956	.8619
2	.096		.096	.0972		.8288	.8951
3	.128		.096	.1296		.8288	
4	.128		.128	.1619		.8951	
5						.9282	.9503
6						.9945	.9945
7						.8951	1.1603
8						1.0608	1.2266
9						1.1603	.9945
10					.9069	.9945	.9282
12		1.0688					
13			1.0688				
14		1.2308	1.0688				
15			1.004				
16		1.166	1.0688				
17			1.004		.0663	.0663	
18		.9717	.7773		.1326	.0995	.1296
19			.1943		.1989	.1658	.1619
20			.2105		.1989	.1658	.1619
21			.1943		.1638	.1658	.1296
22			.0972		.1658	.1658	.0972
23		.1296	.0972		.1326	.1326	.0972
24			.0972			.1326	.0972
Max	.128	1.2308	1.0688	.1619	.9069	1.1603	1.2266
Min	.096	.1296	.096	.0648	.0663	.0663	.0972
Avg	.112	.9134	.4562	.1134	.2457	.5820	.5924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054132 / 33KV Devgoan

Feeder No / Name : 204 / Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179		.0177	.0179		.0179	.0179
2	.0179		.0179	.0179		.0179	.0179
3	.0179		.0179	.0179		.0179	
4	.0179		.0179	.0179		.0179	
5	.0179			.0179		.0179	.0179
6	.0179			.0179		.0179	.0179
7	.0179			.0179		.0179	.0179
8	.0179			.0179		.0179	.0179
9	.0179			.0179		.0179	.0179
10				.0179		.0179	.0179
11					.0168	.0179	.0179
12		.1417			.0168	.0179	.0179
13			.0179		.0168	.0179	.0179
14		.1417	.0179		.0179	.0179	.0179
15			.0179		.0168	.0179	.0179
16		.1417	.0179		.0168	.0179	.0179
17			.0179			.0179	.0179
18		.0177	.0179		.0179	.0179	.0179
19			.0179		.0179	.0179	.0179
20			.0179		.0179	.0179	.0179
21			.0179		.0179	.0179	.0179
22			.0179		.0179	.0179	.0179
23		.0177	.0179		.0179	.0179	.0179
24			.0179			.0179	.0179
Max	.0179	.1417	.0179	.0179	.0179	.0179	.0179
Min	.0179	.0177	.0177	.0179	.0168	.0179	.0179
Avg	.0179	.0921	.0179	.0179	.0174	.0179	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425]

BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 201 / Narewadi

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	09-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
1	.9145	.9955
2	.9774	
3	.985	1.0808
4	1.0517	1.1517
5	1.166	1.2269
6	1.291	1.286
7	1.3717	1.3735
8		1.4255
9	1.4746	1.5074
10	1.3847	1.2489
Max	1.4746	1.5074
Min	.9145	.9955
Avg	1.1796	1.2551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 202 / Bandewadi

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-JAN-18	09-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
11	1.5775	1.2308	1.4022
12	1.6289		1.491
13	1.6651		1.3717
14	***		1.4083
15	1.5424		1.3441
16	1.5565		***
17			1.3889
18			1.2809
Max	48.4226	1.2308	43.3014
Min	1.5424	1.2308	1.2809
Avg	9.3988	1.2308	6.6236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

KAIJ (R) S/DN[425] BU 2577

Substation No/ Name :- 054136 / 33 KV Waghebabulgaon

Feeder No / Name : 203 / Waghebabulgaon
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)
16	2.1376	2.1674
17		1.9616
18		1.761
19	1.9281	1.7553
20	1.9033	1.6716
21	1.387	1.6604
22	1.4746	1.5623
23	1.4899	1.7177
Max	2.1376	2.1674
Min	1.387	1.5623
Avg	1.7201	1.7822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 201 / MANJRATH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048						
2	.3048						
3	.3048						
4	.3048						
5	.3048						
6	.3048						
7	.3048						
8	.3048						
9	.3048						
10	.3506						
11		.5487	.4607	.4877		.431	.4572
12		.5792	.5201	.5182	.4561	.5201	.4572
13		.6097	.535	.4877	.4772	.4904	.4572
14		.5792	.5201	.4572	.4713	.5053	.4572
15		.5487	.4755	.4877	.4725	.4607	.4572
16		.6097	.5201	.4572	.4584	.4904	.5335
17		.6401	.4904	.4268	.4992	.4904	.5335
18		.6401	.431	.4877	.4254	.3864	.4268
Max	.3506	.6401	.535	.5182	.4992	.5201	.5335
Min	.3048	.5487	.431	.4268	.4254	.3864	.4268
Avg	.3094	.5944	.4941	.4763	.4657	.4718	.4725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054134 / 33 KV MANUR DEVI S/stn

Feeder No / Name : 202 / NAGADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.6401	.5535	.4877	.6097	.3479
2		.6401	.6706	.6325	.5182	.6249	.4744
3		.6249	.6706	.7116	.5487	.6097	.5376
4		.6859	.7011	.7432	.6097	.6097	.6009
5		.7011	.884	.7748	.7316	.6249	.6325
6		.6859	.884	.8065	.8535	.6595	.6642
7		.8535	.945	.8381	.884	.7621	.7116
8		.884	.9145	.9646	.823	.8688	.7926
9		.9145	.9962	.9962	.884	.9145	.8383
10		.884	.8993	.823	.8802	.8223	.7621
11	1.0625						
12	1.1736						
13	1.0822						
14	1.2403						
15	1.2389						
16	1.2734						
17	1.1905						
18	.9745						
Max	1.2734	.9145	.9962	.9962	.884	.9145	.8383
Min	.9745	.6097	.6401	.5535	.4877	.6097	.3479
Avg	1.1545	.7484	.8205	.7844	.7221	.7106	.6362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

MAJALGAON S/DN.[423] BU 2593

Substation No/ Name :- 054135 / 33KV GANGAMASLA S/stn

Feeder No / Name : 203 / GANGAMASLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5979	.6704	.7255	.6167	.6348	.6001	.9078
2	.7247	.7247	.8525	.7255	.6711	.6173	.9986
3	.7247	.761	.925	.7981	.7436	.6859	1.0894
4	.8153	.8516	1.0338	.8706	.8162	.823	1.507
5	.9059	1.0328	1.0883	.9069	.9613	.9602	1.4525
6	1.0146	1.3045	1.1789	.9976	1.2334	1.2689	1.7249
7	1.3951	1.4495	1.3059	1.3966	1.3966	1.4918	1.7975
8	1.4857	1.4147	1.3966	1.4329	1.451	1.5089	1.7975
9		1.324	1.3603		1.2174	.9259	1.6522
10	1.0146	.9794	1.1064	1.0883	.9088	.8573	1.6886
11	.7791	.8162	.8525	.8706	.7888	1.0168	1.324
12	.7791	.7799	.7799		.583	.9986	1.3785
13	.8334	.8162	.7799	.9976	.5487	.926	1.2696
14	.761	.8343		.9432	.7716	.9441	1.1971
15	.7972	.8162	.7255	.9976	.8573	.9078	1.0883
16	.8516	.8706	.8706	1.1064	.9431	1.0168	1.0701
17	.9059	.9432	.9613	1.1427	1.0288	1.0894	1.0338
18	1.1777	1.1064	1.0701	1.1971		1.3073	1.052
19	1.1958	.9432	.9976	1.2334	1.166	1.0894	1.1064
20	.9603	.9976	.9069	.9976	1.1317	1.1802	1.052
21	.8697	.8525	.8343	.9432	.8916	.9986	.9432
22	.7429	.7436	.7618	.8525	.8059	.9441	.9069
23	.6885	.7255	.6711	.7436	.7202	.8715	.8887
24	.616	.6341	.6892	.6348	.7255	.5144	.8534
Max	1.4857	1.4495	1.3966	1.4329	1.451	1.5089	1.7975
Min	.5979	.6341	.6711	.6167	.5487	.5144	.8534
Avg	.8972	.9330	.9510	.9770	.9129	.9810	1.2408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 201 / 11kv CHANDAPUR AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.123			.1389	
8			.1494		.1405	
10		.4656		.4904		
12				.9645		
14					1.0498	
16				1.004		1.1576
18	.1016			.1191		
20	.1216			.1405		
22			.1254	.1248		
24		.1059			.107	
Max	.1216	.4656	.1494	1.004	1.0498	1.1576
Min	.1016	.1059	.1254	.1191	.107	1.1576
Avg	.1116	.2315	.1374	.4739	.3591	1.1576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 202 / 11 KV GANESHPAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.7778			1.8107
8					2.5553
10		2.0995		2.7721	
12				2.3557	
14					1.5565
16				1.6974	
18	2.2916			2.3777	
20	2.0698			2.1393	
22			1.3756	1.5676	
24		1.0512			1.1827
Max	2.2916	2.0995	1.3756	2.7721	2.5553
Min	2.0698	1.0512	1.3756	1.5676	1.1827
Avg	2.1807	1.6428	1.3756	2.1516	1.7763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 204 / 11 KV GFSS CHANDAPUR
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0892			.1717	
8			.2054		.3513	
10		.1433		.214		
12				.3251		
14					.3224	
16				.1757		.2801
18	.2286			.214		
20	.1427			.216		
22			.1629	.1757		
24		.123			.1945	
Max	.2286	.1433	.2054	.3251	.3513	.2801
Min	.1427	.0892	.1629	.1757	.1717	.2801
Avg	.1857	.1185	.1842	.2201	.2600	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054042 / 33/11 KV OPH PARLI S/S

Feeder No / Name : 205 / 11 KV Kalratri Devi Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		1.5508			1.3929	
8			2.2779		2.0807	
10		1.7375		1.918		
12				1.5492		
14					.905	
16				1.0917		1.307
18	1.586			1.4601		
20	1.4016			1.3676		
22			.9412	.9491		
24		.6803			.6639	
Max	1.586	1.7375	2.2779	1.918	2.0807	1.307
Min	1.4016	.6803	.9412	.9491	.6639	1.307
Avg	1.4938	1.3229	1.6096	1.3893	1.2606	1.307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 201 / 11 KV PANGRI FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0291	.029	.029			.033	.029
2	.0291		.029			.033	.029
3	.0291		.029			.033	.029
4		.029	.029	.0145	.029	.033	.029
5	.0291			.029		.033	
10	1.4914						
11	1.8679	1.6217	1.6651	1.2308	1.4866	1.5493	1.5012
12	1.9403	1.8389	1.8823	1.8823	1.7198	1.8823	1.6761
13	1.9403	2.0271	2.0271	1.9113	1.851	1.8679	2.0113
14	1.9837	2.0271	2.0271	1.8534	1.8364	1.9113	1.9822
15	2.0271	1.9547	1.9692	1.8389	1.8073	1.8534	1.9676
16	1.7955	1.9113	1.8823	1.7375	1.7635		1.8656
17	1.7231	1.8389	1.7086	1.6651	1.5887		1.6615
18	1.4914	1.5927	1.448	1.3611	1.4866		1.4866
19	.029	.029		.029	.0291	.029	.0291
20		.029	.029	.029	.0291	.029	.0291
21		.029	.029			.029	
22	.029	.029		.029	.0291	.029	
23		.029	.029			.029	.0291
24	.0291		.029	.029	.029	.0291	.0328
Max	2.0271	2.0271	2.0271	1.9113	1.851	1.9113	2.0113
Min	.029	.029	.029	.0145	.029	.029	.029
Avg	1.0290	1.0010	.9276	.9743	1.0527	.5877	.8993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 202 / 11 KV NATHRA FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.038	.0414	.0559			.0507	.0414
2	.038		.0553	.0414	.0414	.0507	.0414
3	.038	.0414	.0691		.0414	.0507	.0414
4	.038	.0414	.0832	.0553	.0553	.0507	.0691
5	.0507	.0553		.0553		.0507	
9							.0414
10	.7044						
11	.7044	.8658	.6906	.6354	.7095	.7873	.6715
12	.8426	.8978	.9945	.8978	.7728	.8288	.7222
13	.884	.9116	.9393	.9393	.8489	1.0221	.7982
14	.7873	.9531	.9393	.9393	.8235	.9709	.7348
15	.8149	.8599	.9116	.8564	.8109	.884	.7095
16	.8288	.8564	.9393	.8426	.7855	.8564	.6842
17	.7597	.8564	.884	.8288	.6588	.7459	.6715
18		.7767	.7183	.6768	.6081	.6492	.5321
19	.0553	.0691	.0553	.0691	.0507	.0691	.0507
20	.0553	.0693	.0553	.0553	.0633	.0691	.0633
21	.0553	.0691	.0414	.0553	.0633	.0553	.0507
22		.0553	.0414	.0414	.0507	.0414	.0507
23	.0414	.0553	.0414		.0507	.0414	.0507
24	.038	.0414	.0553	.0414	.0414	.0507	
Max	.884	.9531	.9945	.9393	.8489	1.0221	.7982
Min	.038	.0414	.0414	.0414	.0414	.0414	.0414
Avg	.3763	.4176	.4206	.4394	.3810	.3855	.3347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 203 / 11 KV GFSS Nathra Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1481	.1483	.1483	.1668	.1665	.1481	.1483
2	.1481	.1483	.1483	.1668	.1665	.1329	.1483
3	.2593	.2225	.1668	.1854	.185	.1852	.1483
4	.5185	.482	.4078	.3337	.333	.3333	.3522
5	.7593	.7044	.7415	.7044	.7215	.7778	.7044
10	.6488	.6117	.6488	.6105	.6481	.7415	.7593
11	.4078	.2781	.4078	.3885	.4259	.5191	.6667
12	.2781	.2225	.2595	.259	.323	.3337	.6296
13	.2039	.1854	.1854	.222	.1852	.241	.5741
14	.1483	.1668	.1854	.148	.1481	.2225	.2593
15	.1854	.1854	.1854	.2035	.1481	.2225	.2407
16	.2225	.2225	.2225	.2405	.2222	.241	.2593
17	.3151	.3151	.241	.3145	.3704	.3522	.2778
18	.5191	.5376	.4449	.5365	.5	.3893	.2778
19	.6674	.5191	.6674	.6475	.5185	.4078	.4074
20	.4634	.3337	.5561	.518	.537	.3522	.3704
21	.3708	.2781	.2781	.37	.4815	.2781	.3333
22	.3337	.2225	.1854	.2405	.3704	.2225	.2778
23	.2966	.1854	.1668	.185	.2778	.1854	.2222
24	.1481	.1483	.1483	.1668	.1665	.1481	.1483
Max	.7593	.7044	.7415	.7044	.7215	.7778	.7593
Min	.1481	.1483	.1483	.148	.1481	.1329	.1483
Avg	.3521	.3059	.3198	.3304	.3448	.3217	.3603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 204 / 11 KV Pangri GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3788	.3692	.3692	.3323	.2954	.3219	.3508
2	.3788	.3692	.3692	.3323	.2954	.3219	.3323
3	.4734	.4431	.3692	.3323	.2954	.3788	.3508
4	.7764	.7385	.8123	.6461		.5681	.6461
5	1.1173	1.0338	1.1815	1.0338	1.0338	1.0416	1.0338
10	.96	.96	1.0708	.96	1.0226	1.1077	1.1741
11	.7385	.8123	.8677	.8492	.5538		1.0037
12	.5169	.5354	.6646	.5169	.5681		1.0037
13	.4431	.5169	.5169	.4431	.4924	.6461	.9848
14	.4431		.5169	.4431	.4166	.5354	.6439
15	.4431	.5169	.5169	.4431	.4166	.5354	.606
16	.5908	.5169	.5908	.48	.4545		.4166
17		.6646	.6831	.5169	.4372	.695	.4924
18	.8123	.96	.8861	.7385		.8492	.5681
19	.96		1.0338	1.1446		.8123	.7575
20	.7385		.7754	.5908	.7954	.72	.6439
21	.7015	.7015	.5908	.5169	.6818	.5908	.5303
22		.5538	.5538	.4431	.4166	.4431	.4545
23	.48	.4062	.3323	.3692	.3788	.4062	.3788
24	.3788	.3692	.3692	.3323	.2954	.3219	.3508
Max	1.1173	1.0338	1.1815	1.1446	1.0338	1.1077	1.1741
Min	.3788	.3692	.3323	.3323	.2954	.3219	.3323
Avg	.6295	.6157	.6535	.5732	.5206	.6056	.6361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 206 / Pimpalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0741	.0616	.0914	.031		.1111	.1463
2	.0741	.0616	.0927	.031		.1038	.1463
3	.1852	.1534	.1097	.05		.2076	.1646
4	.3114	.2771	.3109	.1818		.3287	.2743
5	.519	.4618	.5487	.3201			.5853
10	.3387	.4062	.4755	.3695	.3806	.4755	.4325
11	.2309	.2954	.1829	.2155	.2076	.3658	.4498
12	.1693	.1846	.0686	.2155	.1557	.2769	.3979
13	.1385	.1463	.0541	.1227	.1384	.1829	.346
14	.1078	.1097	.0372		.1038	.1646	.173
15	.1232	.1097		.0924	.1038	.2012	.173
16	.0924	.1463	.0433	.1232	.1384	.1646	.173
17	.1539	.1829	.0681	.1539	.173	.1829	.173
18	.2463	.2926	.0929	.2463	.2422	.2378	.2249
19	.3695	.2926	.161	.3387	.3287	.2743	.2595
20	.2771	.3109	.1362	.3079	.3806	.2561	.2076
21	.2463	.2743	.1072	.2155	.3114	.2195	.173
22	.1847	.1829	.0793	.1539		.1646	.1384
23	.1232	.1463	.07	.077	.173	.1646	.1384
24	.0692	.0616	.0914	.031		.1038	.1463
Max	.519	.4618	.5487	.3695	.3806	.4755	.5853
Min	.0692	.0616	.0372	.031	.1038	.1038	.1384
Avg	.2017	.2079	.1485	.1725	.2182	.2203	.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054048 / 33/11 KV NATHRA S/S

Feeder No / Name : 207 / Pimpalgaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9064	.8431	.9728	1.1349	1.216	1.0202	1.1109
2	1.0218	.9728	1.0052	1.2971	1.3781	1.0785	1.1744
3	1.1042	1.0539	1.0539	1.2971	1.3781	1.1368	1.1744
4	1.1701	1.1349	1.1389	1.2971	1.3781	1.2097	1.1744
5	1.4832	1.4268	1.443	1.2971	1.3943	1.2826	1.4442
6	1.615	1.5565	1.6375	1.5565	1.5565	1.4575	1.6505
7	1.7634	1.488	1.9942	1.9456	1.7313	1.749	2.1108
8		.1297	2.2699	2.0753	2.0753	1.8947	2.1425
9		1.7672		1.9618	2.1401	1.8947	2.1108
10	1.7997		1.978		1.4866		1.8218
18	.2432	.1621	.1621	.1621	.1457	.0973	.1312
19		.7134	.2756		.1749	.2539	.1749
20		.1946	.1946	.1946	.1895	.1428	.204
21	.1621	.1621	.1621		.1749	.127	.204
22		.1297	.1297		.1457	.127	.1749
23	.1297	.0973	.1297	.1297	.1166	.1111	.1457
24	.102		.0973	.0973	.0616	.0874	.0952
Max	1.7997	1.7672	2.2699	2.0753	2.1401	1.8947	2.1425
Min	.102	.0973	.0973	.0973	.0616	.0874	.0952
Avg	.9584	.7888	.9153	1.1112	.9849	.8544	1.0026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 203 / 11 KV Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.0856	1.07
2		1.1591	1.1294
3			1.1888
4		1.1591	1.2041
5		1.2041	1.2793
6		1.2803	1.4352
7		1.5497	1.7394
8	1.4419	1.9292	1.9292
Max	1.4419	1.9292	1.9292
Min	.9831	1.0856	1.07
Avg	1.2125	1.3382	1.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054065 / 33/11 KV DAUTPUR S/S

Feeder No / Name : 205 / 11 kv GFSS Wadgaon
 Dadahari Feeder KV- 11 /
 OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509		.1698	.1698
2			.1698	.1698
3			.2263	.2452
4			.3206	.3395
5			.5281	.5281
6			.6602	
17		.3395	.4715	
18		.4527	.5093	
19		.5658	.5658	
20		.4715		
21		.3584	.3961	
22		.2452	.2452	
23		.2075	.2075	
24	.1698		.1886	.1886
Max	.1698	.5658	.6602	.5281
Min	.1509	.2075	.1698	.1698
Avg	.1604	.3772	.3584	.2735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 201 / 11 KV KANYA SHALA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6337	.6379	.6619	.6878	.6776	.7278	.757
2	.6324	.6379	.664	.653	.679	.6928	.7602
3	.6447	.7171	.6899		.6763	.695	.7807
4	.7682	.9145	.7346	.727	.8299	.7324	.7856
5	1.1225	1.3016	1.5576	1.4608	1.2198	1.0456	1.5828
6	1.9239	1.8823	1.8296	1.9219	1.9636	1.8671	1.8296
7	2.6999	2.6972	2.6783	2.5198	2.6406	2.6996	2.6648
8	2.6756	2.8292	2.9176	2.9117	2.9047	2.5198	2.8959
9	2.5035	2.4495	2.4446	2.5976	2.8959	2.2212	2.7642
10	2.1559		2.0393	2.2451	2.7718	2.1703	2.4696
11	1.8709	1.6414	1.5926	1.7399	2.2542	1.7399	2.0601
12	1.5764	1.3016	1.4548	1.4937	2.0601	1.6414	1.8728
13	1.4161	1.396	1.1552	1.2298	1.609	1.2683	1.6838
14	1.1458	1.1564	1.0577	1.1458	1.1145	1.1366	1.4032
15	1.1065	1.0851	.9669	.9521	1.0185	1.0903	1.2273
16	1.1065	1.1571	1.0091	1.1088	1.2318	1.0632	1.1815
17	1.4922	1.5108	1.5524	1.4347	1.4201		1.4845
18	1.9378	1.9504	1.8333	1.6735	1.8614	1.8409	1.8652
19	1.739		1.8037	2	2.0041	2.0619	1.6757
20	1.5708	1.6045	1.653	1.6246	1.506	1.4969	1.4723
21	1.3549	1.3352	1.3832	1.3717	1.3605	1.3407	1.2476
22	1.0608	1.0284	1.0894	1.0917	1.0157	1.0746	.9126
23	.8145	.9613	.7905	.9164	.8743	.9299	.9069
24	.669	.6747	.6577	.7209	.7552	.7634	.7562
Max	2.6999	2.8292	2.9176	2.9117	2.9047	2.6996	2.8959
Min	.6324	.6379	.6577	.653	.6763	.6928	.7562
Avg	1.4426	1.4032	1.4257	1.4882	1.5560	1.4269	1.5433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054137 / 33/11 KV KALRATRI PARLI S/S

Feeder No / Name : 202 / 11 KV KASARWADI FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	.0881	.1089	.1093	.1097	.1118	.0722
2	.192	.0886	.1092	.1107	.1097	.1117	.0724
3	.1934	.1097	.1097	.1113	.1102	.1117	.0733
4	.1943	.1107	.1491	.1304	.1488	.1302	.0742
5	.203	.1488	.1501	.15	.1501	.1498	.0938
6	.2481	.1509	.1504	.1888	.1886	.1879	.1128
7	.2902	.1892	.2266	.2263	.1896	.2075	.2177
8	.2703	.1894	.2266	.1884	.1896	.2261	.3234
9	.2507	.1892	.1886	.1884	.1894	.1886	.3258
10	.2279	.1134	.1882	.1859	.1133		.1888
11		2.0719	2.1265	2.1172	1.9649	2.005	2.1125
12	1.8607	2.3921	2.2821	2.2698	2.1879	2.2466	2.3032
13	1.8317	2.3699	2.3232	2.2698	2.1498	2.2222	2.2211
14	2.0553	2.3445	2.2874	2.202		2.2428	2.1449
15	2.2428		2.216	2.2568	.0937	2.2979	2.2604
16	2.2812		2.2309	2.1523	1.9067	1.538	2.2439
17	2.262	2.1172	2.1728	2.1622		1.8522	2.13
18	2.0529	1.9966	2.0059	2.1573	2.0152	1.7939	
19	.1869	.1495	.1875	.2254	.1882	.1118	.2972
20	.1674	.1108	.1497	.1494	.1879	.1486	.1829
21	.1453	.1474	.1504	.1475	.1481	.0722	.1091
22	.1084	.1094	.1283	.1474	.148	.1093	.1097
23	.0886	.1089	.1065	.1102	.1302	.1088	.1097
24	.1898	.0881	.1088	.1079	.11	.112	.0721
Max	2.2812	2.3921	2.3232	2.2698	2.1879	2.2979	2.3032
Min	.0886	.0881	.1065	.1079	.0937	.0722	.0721
Avg	.7711	.6993	.8368	.8360	.5786	.7951	.7761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 201 / 11KV Someshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6001			.7716
2	.0549	.5144			.8573
3	.0549	.5144			1.0288
4	.0514	.5144			1.286
10				1.6289	
11	2.572		.2418	1.7147	
12	2.572			2.3148	
13	2.572			2.3148	
14	2.572			2.2291	
15	2.4863			2.2291	
16	2.1434		2.1091	2.2291	
17			2.0576		
18			1.6804		
19			1.3889		
20			1.1145		
21			1.0288		
22			1.046		
23			.9945		
24	.0754	.6859		.9431	.7373
Max	2.572	.6859	2.1091	2.3148	1.286
Min	.0514	.5144	.2418	.9431	.7373
Avg	1.5154	.5658	1.2957	1.9505	.9362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 202 / 11KV Ratneshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1115	1.2003				.6859
2	.1337	1.3717				.6859
3	.168	1.5432				
4	.1715	1.7147				
5	.1972	2.0576				
6	.204	2.0576				1.4232
7	.2058	2.0576				2.1948
8	2.2977	2.2291			1.5775	2.1948
9	1.6289			.2126	1.749	
10	1.6289			.1903	1.286	
14					.6859	
15	.7716				.6859	
16	.7716		.0754	.9259	.6859	
17			.0943	1.0288		
18			.1029	1.4403		
19			.1389	1.3889		
20			.0977	1.286		
21			.0857	1.046		
22			.0772	.9431		
23			.0686	.9088		
24	.06	.4287			.8573	.6687
Max	2.2977	2.2291	.1389	1.4403	1.749	2.1948
Min	.06	.4287	.0686	.1903	.6859	.6687
Avg	.6423	1.6289	.0926	.9371	1.0754	1.3089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

PARALI (R) S-DN[424] BU 2585

Substation No/ Name :- 054161 / 33/11 KV SANGAM(INDAPWADI)

Feeder No / Name : 203 / 11KV Kapileshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412	.8573			.6859
2	.0514	1.0288			.6859
3	.0772	1.0288			.6859
4	.0823	1.0288			.6001
5	.0857	1.2003			.6001
6	.0995	1.2003			.823
7	.1097	1.2346			1.1145
8	1.3203	1.286		1.2174	1.3375
9	1.2174		.1217	1.2174	
10	1.2003		.0977	.9431	
14	.3429			.4287	
15	.3429			.4287	
16	.4287		.4115	.4287	
17			.4801		
18			.703		
19			.8916		
20			.6001		
21			.5144		
22			.3772		
23			.3772		
24	.0206	.5144		.3429	.2572
Max	1.3203	1.286	.8916	1.2174	1.3375
Min	.0206	.5144	.0977	.3429	.2572
Avg	.3872	1.0421	.4575	.7153	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054039 / 33 KV S/S LONGAON

Feeder No / Name : 201 / 11 Kv Belura

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-JAN-18
HR	Load (MW)
24	.2389
Max	.2389
Min	.2389
Avg	.2389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 201 / 11 kv Dewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
2	.463	.3772
4	.6068	
6	.9536	.7716
7		.8916
8	.7282	.7716
9		.4334
10	.4681	
11	1.5261	
13	2.2298	
14	2.0119	
15	1.9281	
16	1.8442	
17	1.8564	
18	1.7814	
19	.9088	
20	.7202	
21	.6935	
23	.463	
24	.4801	.4287
Max	2.2298	.8916
Min	.463	.3772
Avg	1.1567	.6124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054049 / 33 KV S/S DEWADI

Feeder No / Name : 203 / 11 Kv Khalwat Limbgaon
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
1	1.1509	1.2331
2	1.2003	1.4798
3	1.2825	1.4798
4	1.4633	1.4798
5	1.562	1.562
6	1.6277	1.7264
7	1.9401	1.825
8	1.6113	1.973
9		1.8908
10	1.5455	
11	.2466	
13	.1973	
14	.1644	
15	.1644	
16	.1644	
18	.3288	
19	.4933	
20	.4604	
21	.4439	
23	.3946	
24	.2795	.3288
Max	1.9401	1.973
Min	.1644	.3288
Avg	.8361	1.4979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054052 / 33 KV S/S WADWANI

Feeder No / Name : 203 / 11 Kv Pusara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-JAN-18
HR	Load (MW)
21	.442
Max	.442
Min	.442
Avg	.442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 201 / 11 Kv Laul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3334	.4534	.2332	.2469	.2286	
2	.2881	.3292	.4428	.2761	.2652	.2195	
3	.4054	.3338	.4268	.3429	.3475	.2353	
4	.4687	.421	.4428	.3715	.4218	.2721	
5	.4902	.4641	.4481	.4167	.4696	.3658	
9	.5138	.583	.5376		.5636	.5144	
10	.4134	.4999	.4934	.535	.503		
11	.3467	.4902		.4843	.4475		.4807
15	.4268	.3763		.4108	.4877		.3506
16	.4572	.4725		.4816	.4744		.4321
17	.4134			.5093	.4531		.5155
18	.3963	.4725		.4755	.4428		.4666
19	.3628			.4268			.3772
20	.2724			.3887	.3041		.4666
21	.3715			.3231	.2804		.2818
22	.4001			.3231	.3029		.2928
23	.3734			.2667	.2675		.2721
24	.3269	.3467	.4268	.2401	.2328	.2389	
Max	.5138	.583	.5376	.535	.5636	.5144	.5155
Min	.2724	.3292	.4268	.2332	.2328	.2195	.2721
Avg	.3909	.4269	.4590	.3827	.3830	.2964	.3936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 202 / 11 Kv Pathrud

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2187	.2058	.1947	.25	.1753	
2	.1966	.1715	.2229	.2401	.1829	
3	.2035	.1715	.2343	.2454	.1629	
4	.2507	.3239	.2683	.2561	.2561	
5	.3018	.3772	.3224	.3018	.3109	
6	.5281	.3772	.4527	.4527	.4108	
7	.6036	.3048	.5335	.5335	.4854	
8	.5093	.6097	.4715	.5281	.3734	
9	.3772		.4382	.3772	.3361	
10	.2641		.3361	.2439		
11	1.406		1.3889	1.439		.3018
12	1.6194			1.5402		.2987
13	1.6129			1.5729		.2427
14	1.6049					.2241
15	1.6204		1.5432	1.5051		
16	1.5851		1.7497	1.4327		
17	1.6385		1.6248	1.448		.1875
18	1.1736		1.5009	1.4327		.2561
19			.4435			.3506
20	.2984		.2881	.3086		.2881
21	.2429		.2572	.3429		.3077
22	.2103		.2675	.25		.3041
23	.2401		.2675	.2134		.2915
24	.2164	.2229	.1972	.2317	.2058	
Max	1.6385	.6097	1.7497	1.5729	.4854	.3506
Min	.1966	.1715	.1947	.2134	.1629	.1875
Avg	.7358	.3072	.6192	.6885	.2900	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054090 / 33 KV S/S LAUL

Feeder No / Name : 203 / 11 Kv Pardi Mategaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6737	.7468	.4416	.4496	.3048	
2	.5906	.7735	.4001	.4489	.3515	
3	.5716	.6935	.3757	.4146	.5601	
4	.5487	.6668	.3978	.4016	.381	
5	.567	.6935	.4018	.3822	.3807	
6	.6127	.7145	.4001	.378	.3628	
7	.583	.695	.4085	.3887	.4068	
8	.6607	.7232	.4405	.4464	.4934	
9	.6676	.6287	.4733	.4995	.5213	
10	.6316		.4843	.4733		
11						.6539
12						.7819
13						.9214
14						.9122
15						.9362
17						.9511
18						.7819
Max	.6737	.7735	.4843	.4995	.5601	.9511
Min	.5487	.6287	.3757	.378	.3048	.6539
Avg	.6107	.7039	.4224	.4283	.4180	.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 201 / 11kv kuppa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.3795	.362	.2469	.3353	.4111	.3982
2	.8192	.4428	.362	.2469	.3353	.4744	.3982
3	.9831	.506	.362	.2778	.4191	.5693	.4344
4	.9831	.5693	.3982	.4321	.503	.6325	.4706
5	1.0814	.6325	.5068	.6173	.6554	.6642	.543
6	1.1469		.724			.7274	.724
7	1.3108		1.0498				1.0136
8	1.3435						
9	1.4091						
10		1.1984	1.0494	1.1469	1.1702	1.004	1.0494
11		1.3765	1.2654	1.3927	1.186	2.2672	1.1111
12		1.3765	1.2346	1.3927	1.2018		1.142
13		1.3765		1.3927	1.1702	2.2672	1.142
14		1.3765		1.3763	1.1385	2.2672	1.1111
15		1.2955	1.358	1.3108	1.1069	2.2996	1.0802
16		1.1336	1.3272	1.3108	1.1227	2.2024	1.0494
17		1.2308	1.2037	1.1736	1.1385	1.2631	.9877
18	.7907	.6154	.5556	.5868	.6009	.6516	.3395
19	.759	.8326	.6481	.8383	.5851	.7602	.4938
20	.6958	.724	.5247	.5868	.5693	.6154	.463
21	.506	.543	.463	.503	.506	.543	.4321
22	.4744	.4344	.4012	.4359	.4428	.3982	.4012
23	.4111	.362	.3395	.3353	.3479	.3982	.3395
24	.3353	.3163	.362	.2778	.3353	.3163	.3982
Max	1.4091	1.3765	1.358	1.3927	1.2018	2.2996	1.142
Min	.3353	.3163	.3395	.2469	.3353	.3163	.3395
Avg	.8627	.8361	.7249	.7941	.7435	1.0366	.7056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 202 / 11KV UPALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	1.6712	2.1052	2.3045	2.332	.2294	2.1862
2	.1341	1.8679	2.2024	2.3685	2.4291	.2949	2.2672
3	.1341	1.9662	2.2024	2.4006	2.4577	.3277	2.4291
4	.2012	2.2283	2.2672	2.4326	2.5911	.3605	2.4291
5	.2683	2.4905	2.2672	2.4966	2.332	.3768	2.4291
6		2.8018	2.4291	2.5926	2.5911	.3932	2.5911
7		2.9492	2.672	2.7366	2.8664	.426	2.7206
8		2.7526	2.7692	2.8807	2.672	.4424	3.0445
9		2.556		2.7846	2.7206	.4588	2.915
10	2.9492	.1448	.192	.1341	.1966		.192
11	3.3425	.0724		.1341	.1311	.0724	.192
12	3.6046	.0724	.064	.0671	.0655		.192
13	3.6046	.0724		.0671	.0655	.0724	.128
14	3.5719	.0724		.0671	.0655	.0724	
15	3.6046	.0724	.064	.0671	.0655	.0724	
16	3.5719	.0724	.064	.0671	.0655	.0724	.064
17	3.5391	.1448	.128	.0671	.0655	.0724	.128
18	.1966	.2896	.192	.2012	.1311	.2172	.128
19	.1966	.2896	.2561	.2683	.1638	.2896	.192
20	.1966	.2172	.192	.2683	.1966	.2172	.192
21	.1966	.181	.192	.2012		.1448	.16
22	.1638	.1448	.064	.1341		.1086	.064
23	.1311	.1448	.064	.1219	.0655	.0724	.064
24	.1341	.0655	.1448	.064	.1341	.0655	.0724
Max	3.6046	2.9492	2.7692	2.8807	2.8664	.4588	3.0445
Min	.1311	.0655	.064	.064	.0655	.0655	.064
Avg	1.4938	.9725	1.0266	1.0386	1.1093	.2209	1.1264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

AMBEJOGAI DIVISION[681]

TALEGAON S/DN[563] BU 5631

Substation No/ Name :- 054130 / 33 KV Kuppa Sub-station

Feeder No / Name : 203 / 11KV RAJEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.6036	.543	.5636	.503	.6371	.5792
2	1.3108	.6706	.543	.5636	.503	.7377	.5792
3	1.4746	.7377	.543	.5967	.6706	.8718	.6516
4	1.6385	.8048	.5792	.7625	.8383	.9724	.724
5	1.6194	.8718	.6878	.9945	.9831	1.0395	1.0498
6	1.6194		.8688			1.1065	1.1222
7	2.1862		1.267				1.3032
8	2.1862						
9	2.2672						
10		1.5546	1.757	1.6385	1.8778	1.8138	1.8233
11		2.1862		2.1862	2.079		2.1548
12		2.5263		2.2672	2.2801		2.1548
13		2.5263		2.1862	2.3472		2.2542
14		2.5587		2.1052	2.4478		2.0885
15		2.5263		1.9662	2.5484		2.3537
16		2.5911	2.2211	1.6385	2.0287		2.42
17		2.4291	2.1879		1.8442	2.2024	2.2874
18	.9892	.9412	.8288	.6706	.8383	.8688	.5304
19	.8551	1.1946	.9945	1.1142	.8551	1.086	.6962
20	.7545	.8326	.8288	.8192	.8718	.8688	.6962
21	.6706	.724	.7625	.5365	.8215	.7964	.6299
22	.6371	.5792	.663	.5365	.7377	.6516	.5967
23	.57	.543	.5967	.503	.6371	.5792	.5636
24	.6706	.5365	.543	.5636	.503	.5365	.5792
Max	2.2672	2.5911	2.2211	2.2672	2.5484	2.2024	2.42
Min	.57	.5365	.543	.503	.503	.5365	.5304
Avg	1.2770	1.3969	.9656	1.1691	1.3108	.9846	1.2654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054120 / Ashti

Feeder No / Name : 201 / Ashti Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.724	.7621	.743	.8002	.7049	.8002
2	.724	.7621	.8002	.743	.7811	.6859	.8383
3	.7621	.8192	.9145	.7811	.7621	.743	.8573
4	.8573	.9526	1.0479	.9145	1.0098	.9526	1.0288
5	1.1241	1.105	1.3146	1.0669	1.1622	1.1241	1.2384
6	1.448	1.467	1.6575	1.5623	1.5813	1.5432	1.5432
7	2.0576	1.9814	2.1338	2.2291	2.1529	1.9624	1.9624
8	2.21	2.4196	2.2862	2.4958	2.4006	1.848	2.2862
9	1.9052	2.0386	2.0195	2.3243	2.2672	1.7909	2.0957
10	1.6385	1.848	1.8671	1.9243	2.0005	1.8861	2.1148
11	1.7718	1.5813	1.7718	.6097	1.848	1.7147	2.0957
12	1.8099	1.6575	1.6766		1.7718	1.5051	1.7909
13	1.5432	1.5623	1.4861			1.448	1.6575
14	1.2384	1.3527	1.2955	1.5051		1.3336	1.5242
15	1.2384	1.4098	1.3717	1.5813		1.2955	
16	1.2955	1.4289	1.4289	1.6194	1.5813	1.0098	1.2003
17	1.5432	1.6004	1.4861	1.6194	1.7147		1.3336
18	1.7528	1.7528	1.6766	1.7528	1.9624	1.4289	1.5813
19	1.8099	1.829	1.7909	1.8099	2.0576		
20	1.6575	1.5623	1.5242	1.5623		1.5813	1.4861
21	1.2765	1.3146	1.2384	1.448	1.467	1.3527	1.3146
22	1.0479		1.1241		1.2003	1.1241	1.086
23	.8573	.8573	.9145	.9717		.8954	.9526
24	.7621	.743	.7811	.7811	.8573		.8573
Max	2.21	2.4196	2.2862	2.4958	2.4006	1.9624	2.2862
Min	.724	.724	.7621	.6097	.7621	.6859	.8002
Avg	1.3781	1.4248	1.4321	1.4307	1.5462	1.3300	1.4384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 201 / 11 TAKALI AMIYA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4239	.407	.4287	.4748	.4287	.4191
2	.4359	.4239	.39	.4287	.431	.4287	
3	.503	.4239	.4409	.3429	.431	.3429	.4191
4	.6371	.5087	.78	.3429	.663	.5087	.4191
5	.8383	.6783	.9496	.5087	.8288	.6783	.503
6	.9221	.8478		.8478	.9614	.8478	.7545
9	.9892	1.0174	.5765	.5087	.6443		
10	.7712		.6952	.6274	.6539		.9221
11	1.9281	1.7436	2.1795	2.0719	2.1795	2.0119	2.4143
12	2.2634	2.079	2.652	2.649	2.8178		2.649
13	2.5149	2.3061	2.7846	.5636	2.7854		2.536
14	2.8166	2.4086	2.7035	2.1051	2.9492	2.1795	2.4863
15	2.8502	2.6658	2.6216	2.4863			2.5194
16	2.7664	2.6791	2.5888	.7127	2.7035	2.5149	2.5857
17	2.6825	2.4926	2.6216	2.1714	2.8673	2.8502	2.4863
18	2.5149	2.0687	2.4863			2.6825	2.1216
19	1.0059	.763	.7545	1.0608	.8383	1.0059	.7459
20	1.1736	.9496	1.0059	.9221	1.0174	1.0059	.6706
21	.9326	.8817	.9221	.7545	.9326	1.0898	.6783
22	.8478	.7209	.7545	.6706	.763	.7545	.6443
23	.6783	.5426	.6783	.503	.6783	.6706	.5087
24	.3688	.5087	.5596	.5087	.4917	.5087	.503
Max	2.8502	2.6791	2.7846	2.649	2.9492	2.8502	2.649
Min	.3353	.4239	.39	.3429	.431	.3429	.4191
Avg	1.3989	1.2921	1.4072	1.0103	1.3056	1.2064	1.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054124 / TAKALI AMIYA

Feeder No / Name : 202 / 11 KV CHOBHA NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1191	.5935	1.153	.503	1.0395	1.0059	1.0059
2	1.1869	.6783	1.2209	.503	1.1736	1.1736	1.1736
3	1.2742	.6783	1.3565	.503	1.3077	1.3413	1.2431
4	1.4419	.763		.503	1.4419	1.4251	1.326
5	1.6766	.8478	1.56	.6706	1.6766	1.6766	1.5089
6	1.9281	.9326	1.7465	.7545	1.7101	2.0119	1.8442
7	1.989	1.0059	2.2131	.8383	2.0287	2.3205	1.989
8	1.989	.6706	2.3807	1.6766	2.364	2.5888	2.4577
9	1.7772	1.0059	2.3304	2.4034	1.8442	2.5194	
10	1.7604	1.3748	2.1125	2.5987	2.1628	2.5194	2.146
11	.218	.2204	.2713	.373	.3391	.2486	.503
12	.2012	.1696	.2204	.2713	.2543		.4694
13	.2012	.1357	.1696	.2486	.2204		.4527
14	.1341	.1526	.1696	.1989			.4024
15	.1341	.1357	.1696	.1658			.3353
16			.2035	.1326	.2374	.285	.2347
17		.2204	.2035	.1492	.2035		.2683
18		.407	.3391				.3856
19		.407	.5087	.4973	.4239		.4862
20	.5087	.5087	.6783	.57	.5935	.6371	.5087
21	.5087	.4917	.5935	.5426	.5087	.5868	.5087
22	.4239	.4917	.5087	.5087	.5087	.503	.4748
23	.3391	.4748	.5087	.4748	.4239	.5868	.4409
24	.3561		.407	.4239	.3856	.3391	.4191
Max	1.989	1.3748	2.3807	2.5987	2.364	2.5888	2.4577
Min	.1341	.1357	.1696	.1326	.2035	.2486	.2347
Avg	.9584	.5621	.9141	.6744	.9928	1.2805	.8950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 201 / 11 KV SALEWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18
HR	Load (MW)
24	.426
Max	.426
Min	.426
Avg	.426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 202 / 11 KV DAULAWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18
HR	Load (MW)
24	.3887
Max	.3887
Min	.3887
Avg	.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

ASHTI (R) S/DN[415] BU 2551

Substation No/ Name :- 054127 / 33/11 KV DAULAWADGAON SUB

STAT

Feeder No / Name : 203 / 11 KV PIMPALGAON GHAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18
HR	Load (MW)
24	1.1603
Max	1.1603
Min	1.1603
Avg	1.1603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 201 / 11 KV. TILAK ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.7164	.7602	.724	.7964	.7802	.724
2	.6805	.6805	.7316	.724	.788		.724
3	.6089	.6878	.724	.724	.7602	.7602	.7522
4	.5731	.724	.7602	.7442	.7964	.8048	.788
5	.6805	.8413	.8779	.9145	.8688	.9145	.8688
6	.8954	.9671	1.0242	.9774	1.0498	1.1222	1.0136
7	1.4632		1.5203	1.448	1.4685	1.448	1.2803
8	1.576		1.7375	1.6827	1.7013	1.6476	1.6827
9	1.5746	1.6832	1.848	1.7194	1.7918	1.6289	1.7013
10	1.6651	1.5927		1.5927	1.7375	1.5927	1.6289
11	1.5203	1.5203	1.6817	1.4842	1.6651	1.6108	1.6289
12	1.3756	1.3394	1.46		1.4661	1.448	1.5043
13	1.267	1.267	1.3491	1.267	1.3969	1.3032	1.379
14	1.1946	1.1403	1.2567		1.3253	1.2127	1.267
15	1.1765	1.1946			1.2894	1.2127	1.1403
17	1.4045		1.3611	2.0774		1.379	1.2382
18	1.7556		1.8446	2.2028	1.6289	1.6834	1.5154
19	2.0144		1.8804	2.0058		1.97	1.7741
20			1.8099	1.9342	1.8461	1.7551	
21			1.4148	1.4327		1.4864	1.4415
22						1.2696	
23							1.0029
24	.7522	.788	.7602	.7964	.8326	.788	.7602
Max	2.0144	1.6832	1.8804	2.2028	1.8461	1.97	1.7741
Min	.5731	.6805	.724	.724	.7602	.7602	.724
Avg	1.2031	1.0816	1.3054	1.3584	1.2894	1.3247	1.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 202 / 11 KV. JALNA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224		.3582	.362	.3224	.3582	.362
2	.2865	.3258	.3258	.362	.2865	.3658	.3258
3	.2926		.3258	.3258	.2865	.3224	.3292
4	.3326	.3658	.362	.3658	.3258	.3258	.3658
5	.3696	.3982	.4344	.4656	.3982	.439	.3982
6	.4656	.5068	.5487	.5792	.5487	.5121	.439
7		.6878	.695	.7316	.724	.6516	.5792
8		.7164	.7316	.7682	.7602	.7682	.7602
9	.7602	.7682	.8145	.7682	.7164	.7602	.7602
10	.724	.6805		.724	.6805	.724	.6805
11	.6697	.6447	.7343	.6805	.6089	.6626	.6805
12	.5014	.5316	.6089		.5731	.5258	.5609
13	.4656	.4961		.4961	.5014	.4458	.4973
14	.5373	.4607		.4607	.4656	.4458	.4024
15	.5014	.4607		.4961	.5014	.4801	.4115
17	.5373		.7802	.5373		.5138	.3898
18	.6733		.8413	.7164	.5014	.6201	.5138
19	.7973		.7186	.7265		.6733	.6201
20			.7011	.6767	.6516	.6379	
21			.631	.6447		.567	.5138
22			.5201			.5316	
23							.4252
24	.394	.362	.3982	.394	.3582	.3982	.362
Max	.7973	.7682	.8413	.7682	.7602	.7682	.7602
Min	.2865	.3258	.3258	.3258	.2865	.3224	.3258
Avg	.5077	.5290	.5850	.5641	.5117	.5332	.4942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 203 / 11 KV MONDHA ROAD FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5792	.5792	.5792	.5792	.543	.5853
2	.5121	.543	.5792	.543	.5487	.5731	.5487
3	.4755	.543	.5487	.5487	.5487	.5792	.5853
4	.4755	.5068	.5853	.5853	.5853	.6219	.6219
5	.7023	.6154	.6154	.6335	.7316	.7316	.695
6	.8596	.905	.9877	.9511	1.086	1.0608	1.0136
7	1.4998	1.5565	1.6289	1.6651	1.5927	1.5364	1.3756
8	1.6787	1.6651	1.6651	1.6651	1.829	1.7924	1.5729
9	1.5546	1.6095	1.7164	1.7741	1.9022	1.5912	1.7924
10	1.3535	1.3394		1.5364	1.7013	1.3032	1.4998
11	1.1765	1.2489	1.1763	1.1946	1.4118	1.2489	1.4118
12	1.0679	1.0059	.9896		1.2851	1.0974	1.1584
13	.8688	.8688		.8688	1.1222	.9313	1.086
14	.7964	.7783		.8048	.8326	.8596	.8688
15	.6697	.7421		.9412		.7783	.7783
16						.8589	
17	.924			1.0719		.9979	.8686
18	1.2567		1.9753	1.4003	1.2071	1.2197	1.2071
19	1.3717		1.7375	1.4045		1.3676	1.1888
20			1.3169	1.2752	1.2071	1.307	
21			1.1389	1.0974		1.1458	.9955
22			.9335			.924	
23							.7762
24	.5914	.6154	.6154	.6089	.6154	.6381	.6154
Max	1.6787	1.6651	1.9753	1.7741	1.9022	1.7924	1.7924
Min	.4755	.5068	.5487	.543	.5487	.543	.5487
Avg	.9681	.9451	1.1053	1.0575	1.1051	1.0308	1.0117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054050 / 33/11 KV. MALIVES S/S, BEED

Feeder No / Name : 205 / 11 KV Jillha Parishad

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.362	.3982	.3982	.394	.362	.362
2	.2926	.3258	.3658	.3658	.3582	.3582	.3292
3	.2561	.2865	.4024	.362	.362	.3292	.362
4	.2561	.3258	.4024	.4024	.394	.362	.3982
5	.3292	.4344	.4344	.4572	.4207	.4344	.439
6	.5121	.5068	.5487	.5853	.695	.6154	.6516
7	.9511	1.0498	1.0608	1.0136	.9511	.9412	.8779
8	.9877	1.0136	1.0608	1.0387	1.086	1.1584	1.086
9	.9145	.9412	1.0349	.905	.905	.9412	.9774
10	.724	.7964		.7602	.7522	.724	.8688
11	.6516	.6516	.6653	.6878	.6805	.6697	.6154
12	.5792	.5792			.394	.6154	.6154
13	.543	.543		.4887	.5014	.5068	.5792
14	.4706	.4706		.4344	.394	.4706	.5258
15	.4706	.4706		.4706	.4298	.394	.5068
17	.5175			.5487		.5853	.4805
18	.7392		1.2071	.7682	.724	.6584	.6283
19	.7762		1.134	.8048		.8048	.7392
20			.8048	.7682	.8048	.7682	
21			.8413	.6584		.6219	.6653
22			.6584			.6219	
23							.5121
24	.3841	.3982	.4298	.3982	.394	.3982	.3982
Max	.9877	1.0498	1.2071	1.0387	1.086	1.1584	1.086
Min	.2561	.2865	.3658	.362	.3582	.3292	.3292
Avg	.5623	.5722	.7156	.6158	.5912	.6064	.6009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 201 / 11 KV. GORE FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.3429	.3429	.3086	.3086	
2		.3772	.2058			.3086	
3		.4287	.2743	.3086		.3086	
4		.4287	.3086	.2401	.2915	.3429	
5		.4287	.3944	.2229	.2743	.3429	.3944
6		.4287		.2915	.3086	.3944	.4115
7		.4973	.4115	.4458	.3429	.4801	.4801
8		.4973		.4458	.4115	.5487	.5144
9	.5487	.6516		.4973	.583		.4973
10	.6859	.7716		.8402	.7545		.6516
11	.8059	.7716		.5944	.7716		.6344
12	.7545	.7373		.8402	.7716		.6859
13	.7373			.7716			.6687
14	.7202	.6859		.7545			.6859
15	.8402	.6173		.703			.6859
16	.7545	.6687					
17		.6859	.2401	.6859	.7545	.6516	
18	.7716	.7202	.2743	.7716	.6859	.7373	
19	.823	.6687	.3258	.7888	.7888	.7202	
20	.6859		.2401	.5487	.5316	.6687	
21	.5487	.5316	.3258	.4458	.463	.5487	
22	.5658	.4287	.3086	.3601	.4801	.4458	
23	.5144	.4287			.4287		
24		.4382	.3856	.2401	.3086	.3601	.4287
Max	.8402	.7716	.4115	.8402	.7888	.7373	.6859
Min	.5144	.3772	.2058	.2229	.2743	.3086	.3944
Avg	.6969	.5577	.3106	.5305	.5144	.4778	.5616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 202 / 11 KV. N.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772		.3963	.6401	.5144	
2		.3506	.5144			.5144	
3		.3429	.4973	.3658		.5487	
4		.3772	.463	.3048	.6401	.583	
5		.3944	.4458	.3048	.5487	.6001	.5487
6		.4287	.4287	.5487	.5792	.6173	.5182
7		.5658	.583	.6097	.7011	.6859	.5792
8		.6516		.7011	.6706	.823	.5639
9	.8402	.7316		.9259	.7926		.7316
10	1.0288	.7316		1.046	.8535		.823
11	1.0974	.8535		.9945	.8535		.823
12	1.0974	.945			.823		.8535
13	1.0288			.9259			.6401
14	1.0288	.7926		.9431			.6401
15	1.0974	.7926		.9602			.6706
16	1.0974	.6706					
17		.823	.2439		.6859	.7926	
18	1.0288	.8916	.1829	.9755	.8916	.8383	
19	.8916	.823	.2439	.7621	.8916	.7621	
20	.703	.6516	.3048	.945	.5487	.6249	
21	.6687	.583	.3658	.6706	.5487	.6401	
22	.5658	.6344	.4877	.7316	.5487	.5792	
23	.5144	.6173			.5487		
24		.2858		.4268	.6706	.5487	.5487
Max	1.0974	.945	.583	1.046	.8916	.8383	.8535
Min	.5144	.2858	.1829	.3048	.5487	.5144	.5182
Avg	.9063	.6224	.3968	.7125	.6909	.6448	.6617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 203 / 11KV POLYTECHNIC COLLEGE FEEDER SEPERATION/PURE AG
feede Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.1029	.1543	.12	.1543	
2		.0857	.1029			.1543	
3		.12	.1029	.1372		.1715	
4		.1715		.1715	.1543	.1886	
5		.2058	.1543	.2058	.1715	.2058	.1715
6		.2401		.3086	.2743	.2743	
7		.3258	.3258	.4115	.3772	.3258	.3772
8		.3429	.2743	.4287		.4115	.463
9		.3429		.4458	.463		.4458
10	.3601	.2915		.4115	.3429		.463
11	.3429	.2572		.3944	.3601		.4115
12	.3086	.2401		.4115	.3601		.3429
13	.3086			.3601			.3258
14	.3086	.2058		.3429			.2572
15	.2743	.2058		.3601			.2572
16	.2743	.2229					
17	.2743	.2401	.2229	.3429	.3258	.3086	
18	.2915	.2572	.3086	.2915	.3685	.3258	
19	.3086	.2743	.4287	.3429	.3258	.3086	
20	.1543	.2058	.3086	.2743	.3086	.2572	
21	.1715	.1543	.2572	.2229	.2572	.1886	
22	.1715	.12		.1886	.2058	.1715	
23	.12	.1029			.1715		
24		.0857	.1029	.1715	.1543	.1543	.1543
Max	.3601	.3429	.4287	.4458	.463	.4115	.463
Min	.12	.0857	.1029	.1372	.12	.1543	.1543
Avg	.2621	.208	.2243	.3037	.2789	.2400	.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 204 / 11 KV BAHIRWADI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3772	.3658	.3658	.3429	
2		.3772	.3772			.3429	
3		.3772	.4115	.3963		.3772	
4		.463	.4973	.4877	.6097	.4115	
5		.6859	.583	.5487	.7011	.5144	.5487
6		.9602	.9602	.8535	.9755	.823	.8535
7		1.3717	1.3375	.9755	1.1279	1.1145	1.1126
8		1.4575		1.2803	1.2193	1.286	1.326
9	1.286	1.1888		1.2346	.9755		1.2498
10	1.0288	.945		1.0631	.9755		1.2193
11	.8916	.7621		.8573	.7316		.9907
12	.6859	.6706		.4344	.5487		.7926
13	.6001			.4458			.7011
14	.4973	.4877		.4801			.4268
15	.4801	.4877		.4973			.4268
16	.4973	.3658					
17	.6173	.6001	.4877	.6706	.6001	.6097	
18	.8573	.823	.6706	.7926	.7545	.7316	
19	.9602	.9774	.8535	.8535	.9259	.7926	
20		.8916	.6706		.823	.7316	
21		.7545	.5487	.5487	.6859	.6401	
22	.5487	.6516	.4877		.5487		
23	.5144	.4801			.463		
24		.3944		.3048	.3353	.3772	.3353
Max	1.286	1.4575	1.3375	1.2803	1.2193	1.286	1.326
Min	.4801	.3429	.3772	.3048	.3353	.3429	.3353
Avg	.7281	.7181	.6356	.6890	.7426	.6497	.8319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054082 / 33/11 KV. MIDC S/S, BEED

Feeder No / Name : 205 / 11 KV MAULI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.4973	.4115	.5144	.4406	
2		.4973	.463			.4287	
3		.463	.4458	.4458		.4287	
4		.463	.4287	.463	.4801	.5487	
5		.5144	.4973	.4801	.5144	.5487	.4801
6		.6001	.4973	.5316	.6344	.5658	.5658
7		.7202	.6001	.6516	.7716	.6173	.6687
8		.823		.6859	.7468	.6687	.7716
9	.7373	.8573		.7373	.7545		.6516
10	.6859	.7716		.823	.8059		.5316
11	.6344	.7716		.703	.703		.5316
12	.6001	.703		.6687	.703		.5316
13	.5316			.6001			.4973
14	.0514	.6344		.5658			.4287
15	.5487	.6173		.5658			.4287
16	.583	.7202					
17		.7202	.3944		.6687	.6001	
18	.6001	.7545	.3086	.6173	.703	.583	
19	.6173	.823	.3772	.583	.7202	.6516	
20	.6687	.6687	.5144	.6516	.4572	.583	
21	.5316	.5316	.5144	.6173	.6001	.4801	
22	.5658	.583	.463	.583		.503	
23	.5487	.5487			.4973		
24		.5144	.5144	.4287	.5487	.463	.4115
Max	.7373	.8573	.6001	.823	.8059	.6687	.7716
Min	.0514	.463	.3086	.4115	.4572	.4287	.4115
Avg	.5646	.6441	.4654	.5907	.6367	.5407	.5416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054116 / 33/11 KV BARSHI ROAD S/ST

Feeder No / Name : 201 / 11 KV DOODH DAIRY FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)
8	.6401	.7133
9		.6584
Max	.6401	.7133
Min	.6401	.6584
Avg	.6401	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 201 / 11 KV WASANWADI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0709	.0709	.0709	.0709		
2	.0686	.0709	.0709	.0709	.0709		
3	.0686	.0709	.0709	.0709	.0709		
4	.0686	.0886	.0709	.0886	.0709		
5	.0857	.1063	.1063	.1063	.0886		
6	.1543	.1772	.1949	.1772	.1772		
7	.2401	.2303	.2481	.2303	.2835	.2507	.2865
8		.2303	.2481	.1949	.3189	.2534	.362
9				.2172	.2896	.2534	.3982
10				.2172	.2896	.2172	.3982
11		.197		.2172	.2896	.2172	.3982
12					.2715	.2172	.362
13				.181	.2896	.181	.3258
14				.181	.2896	.1448	.2896
15	.2328			.181	.2896		.2534
16	.2353	.2353		.181			.2534
17	.2172	.2172		.2401	.2572	.2743	.2229
18	.2172	.2172		.2572	.2743	.2743	.1886
19		.2172		.2229	.2229	.2229	.1372
20	.1463	.181		.1715	.1715	.1886	.12
21	.128	.1448		.1543	.1372	.1543	.1029
22		.0886		.124			
23		.0709		.1063			
24	.0857	.0709	.0709	.0709	.0886		
Max	.2401	.2353	.2481	.2572	.3189	.2743	.3982
Min	.0686	.0709	.0709	.0709	.0709	.1448	.1029
Avg	.1441	.1492	.1280	.1623	.2054	.2192	.2733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 202 / 11 KV SHANTAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2658	.2658	.2481	.2835		
2	.2561	.2481	.2481	.2481	.2658		
3	.2378	.2481	.2481	.2481	.2658		
4	.2378	.2481	.2658	.2658	.2835		
5	.2561	.2481	.2835	.2835	.3544		
6	.5304	.443	.567	.5138	.3544		
7	.6219	.6556	.7087	.691	.6379	.6268	.5552
8		.7442	.7265	.7265	.7087	.6219	.5853
9				.7316	.7087	.5853	.5853
10				.6584	.7316	.5853	.5487
11		.5194		.5853	.6584	.5487	.5487
12				.6219	.5853	.5121	.5121
13				.5121	.5487	.4755	.4755
14				.439	.5121	.4755	.439
15	.4656			.439	.4755	.4755	.4024
16	.4572	.4755		.439			.4024
17	.5487	.5121		.4755	.4938	.4938	.3841
18	.5853	.5487		.567	.5853	.5487	.4207
19	.5853	.5853		.6767	.6401	.567	.5304
20	.5487	.5487		.6401	.5487	.5487	.4938
21	.4755	.4755		.5487	.4755	.4572	.4207
22	.4075	.3898	.4784	.4607			
23	.3366	.3189	.3544	.3898			
24	.2743	.2835	.2658	.2658	.3012		
Max	.6219	.7442	.7265	.7316	.7316	.6268	.5853
Min	.2378	.2481	.2481	.2481	.2658	.4572	.3841
Avg	.4266	.4310	.4011	.4865	.4961	.5373	.4870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 203 / 11KV Ambika Nagar feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.7087	.7442	.7087	.815		
2	.5155	.7087	.7087	.6733	.7973		
3	.7316	.7087	.7087	.6733	.7973		
4	.7499	.6733	.7087	.7087	.8328		
5	.8048	.6379	.815	.7442	.8682		
6	1.2986	1.0277	1.382	1.3466	1.3466		
7	1.6278	1.5238	1.6655	1.6124	1.6655	1.6655	1.4327
8		1.6655	1.7364	1.7541	1.7896	1.6461	1.39
9				1.6461	1.7558	1.5729	1.3169
10					1.4632	1.4998	1.2437
11		1.0924		1.7924	1.3535	1.39	1.2071
12				1.5729	1.1706	1.0974	1.0242
13				1.134	1.0974	.9511	.8779
14				.9877	.9511	.9877	.8413
15				.9511	.8779	1.0242	.8048
16	.8413	.9511		.9877			.8413
17	1.0974	1.0974		1.0974	.9694	1.1157	.9145
18	1.2437	1.3535		1.3717	1.2437	1.262	1.1523
19	1.39	1.4632		1.5729	1.4815	1.5181	1.4266
20	1.3169	1.39		1.4449	1.4266	1.39	1.262
21	1.0974	1.2437		1.2254	1.2254	1.134	1.0974
22	.9214	.9214		.9568			
23	.8505	.8505		.9214			
24	.7316	.7442	.7796	.7442	.8505		
Max	1.6278	1.6655	1.7364	1.7924	1.7896	1.6655	1.4327
Min	.5155	.6379	.7087	.6733	.7973	.9511	.8048
Avg	.9957	1.0423	1.0276	1.1577	1.1799	1.3039	1.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 204 / 11 KV Vitthal Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724		.0886	.0886	.0886		
2	.0724		.0886	.0886	.0886		
3	.0905		.0886	.0886	.0886		
4	.0905		.0886	.0886	.0886		
5	.1086		.0886	.1063	.0886		
6	.181		.1595	.1949	.2303		
7	.2715		.1772	.2658	.3012	.2865	.2507
8			.3189	.3189	.3366	.2957	.2587
9				.2957	.2957	.2957	.2402
10				.2772	.2561	.2772	.2218
11		.1791		.2587	.2195	.2743	.2218
12				.2402	.2012		.1848
13				.1663	.1848	.2195	.1478
14				.1478	.1478	.2012	.1478
15	.1254			.1294	.1294	.1463	.1294
16	.1307	.1867		.1294			.1294
17	.1867	.1867		.1448	.1448	.1448	.1448
18	.2241	.2054		.2534	.2172	.2353	.181
19	.2427	.2054		.2715	.2715	.2534	.2353
20	.2427	.2054		.2715	.2534	.2353	.2172
21	.1867	.2054		.2353	.1991	.1991	.181
22				.1949			
23				.1595			
24	.0905		.0886	.1063	.1063		
Max	.2715	.2054	.3189	.3189	.3366	.2957	.2587
Min	.0724	.1791	.0886	.0886	.0886	.1448	.1294
Avg	.1544	.1963	.1319	.1884	.1875	.2357	.1928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054125 / 33/11 KV JALANA ROAD S/STN

Feeder No / Name : 205 / 11 kv Jain Patra Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.0886	.0886	.0886		
2	.0905		.0886	.0886	.0886		
3	.0905		.0886	.0886	.0886		
4	.0905		.0886	.0886	.0886		
5	.0905		.0886	.0886	.0886		
6	.1448		.1772	.124	.1772		
7	.181		.2658	.1595	.2303	.2149	.2328
8			.2658	.2658	.2835	.2172	.2715
9				.2534	.2896	.2353	.2896
10				.2353		.2353	.2896
11		.197		.2534	.2534	.2353	.2896
12				.2534	.2534	.2172	.2772
13				.2172	.2534	.2172	.2534
14				.1991	.2896	.2353	.2353
15	.2149			.1991	.2896	.2534	.2353
16	.181	.2534		.1991			.2353
17	.181	.2896		.2172	.2896	.2896	.2172
18	.1991	.2896		.2534	.2534	.3077	.1991
19	.181	.2172		.1734	.2353	.2896	.181
20	.1448	.181		.2353	.1991	.2534	.1629
21	.1267	.1629		.1991	.1448	.181	.1448
22				.124			
23				.1063			
24	.0905		.0886	.0886	.1063		
Max	.2149	.2896	.2658	.2658	.2896	.3077	.2896
Min	.0905	.1629	.0886	.0886	.0886	.181	.1448
Avg	.1398	.2272	.1378	.1750	.1996	.2416	.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054151 / 33/11 KV KHAPAR-PANGARI

S/Stn

Feeder No / Name : 201 / 11 KV Gawli Baba Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.1296			
6	.1619		.1989			
7	.1781	.2105	.2267			
8	.2267	.1781	.2429			
9	.2105	.1296			.2622	
10	.2105	.1781			.2267	.3149
11	.2105	.1966	.1006	.2591	.213	
12		.1966			.1966	
13		.2105			.2294	
14	.2429	.2294	.1492		.2267	
15		.2294		.2591	.2652	
16	.2591	.2753		.2591		
17						.1475
18		.2267	.1619			.1311
Max	.2591	.2753	.2429	.2591	.2652	.3149
Min	.1619	.1296	.1006	.2591	.1966	.1311
Avg	.2125	.2055	.1728	.2591	.2314	.1978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED (U) S/DN[412] BU 2518

Substation No/ Name :- 054151 / 33/11 KV KHAPAR-PANGARI

S/Stn

Feeder No / Name : 202 / 11 KV Shivneri Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.0995			
6	.2155		.1989			
7	.3315	.2984	.3315			
8	.3315	.3149	.3481			
9	.2486	.2486			.2915	
10	.1989	.2321			.2785	.3812
11	.1989	.1943	.1844	.1658	.1989	
12		.1638			.1823	
13		.1311			.1658	
14	.0995	.1475	.116		.1658	
15		.1311		.1326	.1457	
16		.116		.1326		
17			.1823			.1311
18		.1658	.1989			.1326
Max	.3315	.3149	.3481	.1658	.2915	.3812
Min	.0995	.116	.0995	.1326	.1457	.1311
Avg	.2321	.1949	.2075	.1437	.2041	.2150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 201 / 11 KV. CHOUSALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9717	.8859	.9288	1.267	.8669	.8368	
7			.8669				
8							.7802
9						2.0309	.8779
11		.9869		.8421	1.0364		
12		.9869		.9587	1.0802	.9907	
13				.9957	1.004		
14		.9164		.9202			
15				.9736			
16	1.0364	.9869	.8535	.8551	.9602		
17	.9002	1.0288		.9869			.4954
18		1.0717		.8935	.8269		
19		.8669	.9717	.8802			.6811
20		.743					
22		.5573		.4954		.5573	.5573
24	.3887		.4954	.5182	.3715		
Max	1.0364	1.0717	.9717	1.267	1.0802	2.0309	.8779
Min	.3887	.5573	.4954	.4954	.3715	.5573	.4954
Avg	.8243	.9031	.8233	.8822	.8780	1.1039	.6784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 202 / 11 KV. SULTANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.8138	1.9814	2.6863	1.5546	2.6292	1.9052	
7					2.955		
8					3.2579		
9		2.7035	3.1341				
11							2.8654
12							3.0445
14							3.2579
16							3.2579
17							3.3484
19	.8535	1.166	.9717	.7545		.6335	.7659
20	.6973	1.085					
21	.6602						
22		.6382		.5744		.6382	.5744
24	.6478		1.7147	.6478	1.7147		
Max	1.8138	2.7035	3.1341	1.5546	3.2579	1.9052	3.3484
Min	.6478	.6382	.9717	.5744	1.7147	.6335	.5744
Avg	.9345	1.5148	2.1267	.8828	2.6392	1.0590	2.4449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 203 / 11 KV. S. BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-JAN-18
HR	Load (MW)
12	3.3608
Max	3.3608
Min	3.3608
Avg	3.3608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 204 / 11 KV. HINGNI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0364	.8402	1.2689	.8545	1.2346	.8535	.2477
7		.9145			1.3213		
8					1.6918		
9		1.2803	1.6918		1.6432	1.4022	
13							1.8099
15							1.7147
16							1.7861
17		.1463		.2366			1.7147
18		.3467		.298	.2953		
19	.4649		.8145	.4633		.724	.3467
20	.4068	.4087					
21	.3429						
22		.2724		.2804		.2724	.2724
24	.6478		.6001	.6478	.5916		
Max	1.0364	1.2803	1.6918	.8545	1.6918	1.4022	1.8099
Min	.3429	.1463	.6001	.2366	.2953	.2724	.2477
Avg	.5798	.6013	1.0938	.4634	1.1296	.8130	1.1275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 205 / 11 KV ANJANWATI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5182	.4489		.724	.4468	.4134	
7			.5106				
8							2.734
11		2.8045		2.0538	1.0802		
12		2.8654		2.0328		2.9874	
13		2.955		2.2405			
14		3.0445		2.2405			
15		3.2007		2.4272			
16		3.2922	1.5242		1.1584		
17		3.1674		2.8006			.2515
18		2.7149		2.6406	.9755		
19	.4252	.4468	.3887	.2515			.4401
20	.4134	.5182					
21	.3487						
22		.3772		.3772		.3829	.3772
24	.2591		.3191	.2715	.3144		
Max	.5182	3.2922	1.5242	2.8006	1.1584	2.9874	2.734
Min	.2591	.3772	.3191	.2515	.3144	.3829	.2515
Avg	.3929	2.1530	.6857	1.6418	.7951	1.2612	.9507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054003 / 33/11 KV. CHOUSALA

Feeder No / Name : 206 / 11 KV Palsingan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6573		
2				.823		
3				.904		
4				.9164		
5				.9869		
6		.7335		.9869		.6811
7				1.1431		
8				1.4289		
9	1.1984	1.0288		1.4289		
12						1.3394
13						1.286
14						1.2689
15						1.1431
16						1.2146
17	.2229		.3547			1.286
18	.3344		.4715			
19	.4582		1.0164		.8145	.3715
20	.3963					
21	.2477					
22	.1829		.2724		.3096	.2229
24		.5258		.4601		
Max	1.1984	1.0288	1.0164	1.4289	.8145	1.3394
Min	.1829	.5258	.2724	.4601	.3096	.2229
Avg	.4344	.7627	.5288	.9736	.5621	.9793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 202 / 11 KV. KALEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.1121	2.6543	2.7664	2.8645	
16	.1478	.1494			
17				.1663	
19			.2829		
24	.7459	.743	.9709	.8478	.112
Max	3.1121	2.6543	2.7664	2.8645	.112
Min	.1478	.1494	.2829	.1663	.112
Avg	1.3353	1.1822	1.3401	1.2929	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 203 / 11 KV. BORKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.4413	1.2651
2						1.6549	1.4563
3						1.8138	1.6324
4						1.9919	1.8138
5						2.2186	2.1862
6						2.6023	2.6543
7						3.2653	3.315
8	.5788	.5281	.6274	.5601	1.8671		3.3648
9						2.5857	3.2693
10						.4715	
11					.3658	.3174	
12					.2241	.3734	
13					.3018	.3142	
14					.2241	.3142	
15						.2743	.2829
16	3.2322	3.0514		3.0178	.2641	.3142	.2829
17					.3361	.3326	.415
18					.4338	.5228	.3772
19			1.989		.7842	.7392	.5601
20					.5788	.5544	.5228
21					.499	.5228	.5281
22					.4854	.4435	.4715
23					.4668	.4066	.4294
24	.3688	.3734	.3391	.381	1.0898	1.1591	.9031
Max	3.2322	3.0514	1.989	3.0178	1.8671	3.2653	3.3648
Min	.3688	.3734	.3391	.381	.2241	.2743	.2829
Avg	1.3933	1.3176	.9852	1.3196	.5658	1.0710	1.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054032 / 33/11 KV. S.S LIMBAGANESH

Feeder No / Name : 204 / 11 KV LIMBAGANESH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.112	.1063
2						.1307	.1063
3						.168	.1254
4						.1848	.1629
5						.2033	.2534
6						.3547	.3658
7						.4481	.439
8	.4024	.4668	.462	.5041	.5041	.5729	.3841
9						.462	.4435
10						.3547	.3921
11					.2774	.2715	.4207
12					.2835	.1294	.4119
13					.2713	.1448	.3475
14					.2103	.2481	.2534
15					.2641	.2481	.2126
16	.2103	.1509		.2054	.2481	.2865	.2126
17					.2401	.2686	.0235
18			.2829		.2896	.3439	.2353
19					.3326	.362	.2172
20					.2561	.2743	.2614
21					.1772	.1829	.1663
22					.1433	.1463	.1109
23					.1254	.1097	.1109
24	.1017	.0934	.1132	.132		.1478	.1063
Max	.4024	.4668	.462	.5041	.5041	.5729	.4435
Min	.1017	.0934	.1132	.132	.1254	.1097	.0235
Avg	.2381	.2370	.2860	.2805	.2588	.2565	.2446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 201 / 11 KV. SIDDOD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7613			.824	
5				.8993		.7011
7		1.1561				
8				1.8138		
17						1.4861
19	.6062		.6859			
20	.6485					
22				.2965		
23			.3048			
24		.4934		.6249	.5393	
Max	.6485	1.1561	.6859	1.8138	.824	1.4861
Min	.6062	.4934	.3048	.2965	.5393	.7011
Avg	.6274	.8036	.4954	.9086	.6817	1.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 204 / 11 KV. MIDC PENDGAON
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7142			.8321	
5				.7621		
7		.6168				
8				.9145		
9						.8078
10			1.0669			
11		.4545	1.2955			
12				.7142		
13			1.0822		.9755	
15		.3285	1.2193			
16	.7142		1.2346	.8354		
17			1.0364			
18		.5372		.7995		.9861
19	.48		1.0364			
20	.8765					
22				1.2337		
23			.9145			
24		.8116		.9145	.788	
Max	.8765	.8116	1.2955	1.2337	.9755	.9861
Min	.48	.3285	.9145	.7142	.788	.8078
Avg	.6902	.5771	1.1107	.8820	.8652	.8970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 205 / 11 KV KUMSHI NEW FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2597			.2579	
9						1.1431
11		.9739	.823			
12				1.2012		
13			1.1126		1.1888	
15		1.1012	1.1431			
16	1.1907			1.0023		
18		.5535		.8596		
19	.3725					
20	.2524					
22				.2389		
24		.1454			.1578	
Max	1.1907	1.1012	1.1431	1.2012	1.1888	1.1431
Min	.2524	.1454	.823	.2389	.1578	1.1431
Avg	.6052	.6067	1.0262	.8255	.5348	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054034 / 33/11 KV. S/S PENDGAON

Feeder No / Name : 206 / 11 KV KUKKADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2016		.1948	
9					.6706
11		.3106			
12			.6193		
13				.6859	
15		.4938			
16	.5162		.6818		
18		.5389	.52		
19	.2617				
20	.2149				
22			.1377		
24		.1018		.1142	
Max	.5162	.5389	.6818	.6859	.6706
Min	.2149	.1018	.1377	.1142	.6706
Avg	.3309	.3293	.4897	.3316	.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 202 / 11 KV. GHATSAWALI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764		.5868	.6516		.7888
2		1.1919		.8718	.6516		.8764
3		1.2971		.9221	.7202		.9465
4		1.286		1.0898	1.1317		1.0517
5		1.3203		1.4251	1.5775		1.3717
6		1.3717		1.5927	1.749		1.5432
7		1.5432		1.7939	2.0233		1.8004
8	1.9719	1.9719	2.0576	2.1293	2.1605	2.1262	2.1605
9	2.0233	2.1262	1.8442	2.1795	2.1605	2.2634	2.4863
10	.4668	.462		.4801	.3086	.5316	.6335
11	.2241		.2715	.2572	.2058		.5068
12	.1867		.2172	.1715		.2614	.4344
13			.1267	.1543		.2241	.3258
14	.168		.1267	.1372		.2241	.2172
15			.1448	.12	.1372	.1867	.1448
16		.1341		.1372		.1867	.1629
17	.3361		.2353	.3258		.2801	.181
18	.4108		.4887	.4287		.462	.362
19	.6908		.5068			.7023	.5068
20	.5914		.5611			.5975	.3801
21	.4854		.3258			.4706	.3258
22	.3361		.2353			.3734	.2534
23	.2241		.2241			.2801	.2172
24	.6859	.8764	.5935	.503	.583	.5487	.7011
Max	2.0233	2.1262	2.0576	2.1795	2.1605	2.2634	2.4863
Min	.168	.1341	.1267	.12	.1372	.1867	.1448
Avg	.6287	1.2048	.5306	.8056	1.0816	.6074	.7658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054036 / 33/11 KV. PIMPALNER S/S

Feeder No / Name : 203 / 11KV GUNDHA NEW FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481		.3681	.3772		.4298
2		.4115		.4382			.5014
3		.5144		.5258			.5373
4		.5487		.5868	.4801	.5487	.5609
5		.6516		.7545	.5144		.631
6		.6859		.8048			.6859
7		.7545		.8551			.7545
8	.8573	1.0288	1.0288	1.0395		1.0288	.9945
9	.8573	1.0631	1.0059	1.0059	1.0288	1.0288	1.0288
10	.1867	.168		.2058		.2058	.1867
11	.1494		.0934	.12		.1307	.2241
12	.112	.0838	.0934	.12			.2054
13	.0934		.0747	.0686		.112	.1307
14	.0934		.0747	.0514		.0934	.0747
15	.0934		.0747	.0514		.0934	.0747
16	.0934			.0686		.0747	.056
17	.1307		.0934	.1372		.112	.0934
18	.2614	.2035	.2054	.2401		.1867	.1867
19	.3734		.3361			.3696	.2241
20	.2987		.4108			.2801	.2614
21	.1867		.4668			.1867	.1307
22	.1307		.2801			.1494	.0934
23	.0934		.1867			.1307	.0934
24	.2572	.3429	.2543	.2629	.6344	.3429	.3582
Max	.8573	1.0631	1.0288	1.0395	1.0288	1.0288	1.0288
Min	.0934	.0838	.0747	.0514	.3772	.0747	.056
Avg	.2511	.5311	.3119	.4055	.6070	.2985	.3549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 201 / 11 kv Shivni feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1696
2							.2442
3							.3307
4							.423
5							.4396
6							.4966
7							.6013
8							.6376
9							.5372
11	.5021	.4959	.447	.4426	.4408	.5149	
12	.5857	.5533	.4659	.4426	.5234	.4945	
13	.5857	.5234	.4353	.4426	.4959	.5252	
14	.5923	.4973	.453	.4546	.4683	.5959	
15	.5873	.4703	.4619	.4683	.4683	.5495	
16	.603	.4564	.463	.4703	.4683	.5372	
17		.4408	.467	.415	.427	.5536	
18		.427	.513	.415	.4132	.522	
24							.1776
Max	.603	.5533	.513	.4703	.5234	.5959	.6376
Min	.5021	.427	.4353	.415	.4132	.4945	.1696
Avg	.5760	.4831	.4633	.4439	.4632	.5366	.4057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 202 / 11 MOCHI PIMPALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5432	.4614	.5516	.677	.5401	.5093	.745
2	.5602	.4614	.5828	.674	.5883	.5262	.8944
3	.5772	.4285	.7354	.7095	.6238	.5432	1.0296
4	.6451	.4944	.8642	.8232	.8396	.662	1.5077
5	.7639	.5933	1.0168	.8349	.956		1.7046
6	.8997	.6592	1.1293	.8869	1.0894	.9167	1.8092
7	.7809	.791	.9193	.9223	.8825	.8148	2.0065
8	.679	.8278	.8378	.8869	.9107	.696	2.3616
9	.4923	.6972	.6451	.7272	.6557	.679	2.3086
10	.3955	.5148	.4583	.51	.4414	.6208	.5941
11	1.7798	1.9489	1.5786	2.165	2.2238	1.9177	.4753
12	2.505	2.439	2.2881	2.6536	2.3086	2.2704	.5602
13	2.5709	2.8621	2.4478	2.7321	2.037	2.5185	.5093
14	2.505	2.9142	2.4123	2.4105	.9506		.4244
15	2.5115	2.8497	2.3794	2.3086	2.4444	2.5747	
16	2.5709	2.5809	2.3413	2.6603	2.3596	2.4504	.3225
17		2.3851	2.4149	2.0224	1.7824	2.3059	.4753
18		1.8753		2.0902		2.113	.4753
19		.7706	.8168	.6972	.7639		.679
20	.6592	.6921	.7813	.6986	.6451	.6747	.6451
21	.5933	.6557	.6747	.6481	.6451	.674	.6111
22	.5603	.6557	.6385	.5883	.6111	.6385	.5602
23	.5274	.5871	.674	.5504	.5262		.7339
24		.5219	.5464	.6031	.5504	.5093	.674
Max	2.5709	2.9142	2.4478	2.7321	2.4444	2.5747	2.3616
Min	.3955	.4285	.4583	.51	.4414	.5093	.3225
Avg	1.1560	1.2361	1.2059	1.2700	1.1033	1.2308	.9612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 203 / 11 KV Indestrial feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0734	.0735	.1091	.0709	.0911	.055	.0532
2		.0735	.0735	.0709	.09	.055	.0533
3	.0732	.0911	.0734	.0709	.0917	.0367	.0533
4	.055	.0911	.0735	.0888	.0907	.0367	.0355
5	.0734	.1093	.0552	.0888	.0919	.055	.0355
6	.0734	.1093	.055	.0894	.0908	.055	.0355
7	.0917	.0911	.0183	.0887	.1275	.055	.0355
8	.055	.0729	.0182	.071	.108	.055	.094
9	.0917	.144	.0183	.071	.1275	.1835	.1101
10	.1094	.1634	.0367	.1101	.1468	.1419	.0917
11	.1094	.1636	.0355	.1089	.1651	.1064	.0734
12	.0911	.1651	.071	.1089	.1835	.1598	.0734
13	.0912	.1468	.0532	.0734	.1835	.1283	.0734
14	.0729	.1089	.0533	.1284	.1284	.1064	.0734
15	.0919	.1091	.0533	.1651	.1468	.1596	
16	.0919	.1101	.0533	.216	.0734	.1774	.0734
17		.1103	.0733	.1471	.1468	.1953	.0734
18		.1101	.0533	.1101	.1284	.1598	.0734
19		.1101	.0533	.1081	.1101	.1065	.0917
20	.0368	.0919	.0533	.0919	.055	.1065	.0734
21	.0729	.0908	.0709	.0726	.055	.071	.055
22	.0729	.0919	.0709	.0919	.055	.0709	.055
23	.0729	.0917	.0709	.09	.055	.1064	.0734
24	.0734	.0546	.1093	.0709	.0908	.055	.0533
Max	.1094	.1651	.1093	.216	.1835	.1953	.1101
Min	.0368	.0546	.0182	.0709	.055	.0367	.0355
Avg	.0787	.1073	.0586	.1002	.1097	.1016	.0658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054053 / 33/11 KV. S/S SHIVNI

Feeder No / Name : 204 / 11 kv Borfadi feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7642	.7929	.9107	1.1009	1.0564	.7642	.6393
2	.8733	.9229	1.0296	1.4205	1.1703	.8733	.6392
3	.9643	.9934	1.2334	1.7046	1.321	1.1463	.7103
4	1.1281	1.3875	1.345	2.0398	1.4708	1.5465	.8523
5	1.3646	1.5876	1.5778	2.2704	1.6145	1.7285	.9233
6	1.5465	1.9845	1.7303	2.5569	1.7485	1.8377	.9954
7	2.1106	2.2134	2.3585	2.5569	2.6053	2.7474	1.0476
8	2.62	2.8146	2.9167	2.8055	3.0456	3.275	1.0831
9	2.3107	3.0053	2.9657	3.0808	.4501	2.8748	
10	.3304	.4681		.3853	.4731	.4982	.564
11	.2649	.3302	.2841	.2569	.3821	.4262	2.5291
12	.2152	.2574	.2661	.2341	.3093	.2838	.6004
13	.2152	.2186	.2433	.2385	.2365	.3196	.5458
14	.2152	.2018	.2483	.2183	.2547	.2841	.4549
15	.1987	.2004	.2308	.2001	.2183	.2663	
16	.1978	.2004	.2445	.2368	.2365	.3196	2.893
17		.2902	.2486	.4403	.4549	.3666	2.62
18		.4036	.5682	.6907	.4549	.5682	2.3653
19		.6972	.7813	.7634	.8006		.6732
20	.4139	.5883	.7458	.5883	.655	.7095	.4913
21	.3296	.478	.6747	.4412	.4367	.6392	.4185
22	.3138	.3635	.5676	.3643	.4185	.6037	.4003
23	.2973	.3309	.4972	.3125	.3395	.3116	.3457
24	.7096	.7616	.8256	.9026	.8457	.6914	.3145
Max	2.62	3.0053	2.9657	3.0808	3.0456	3.275	2.893
Min	.1978	.2004	.2308	.2001	.2183	.2663	.3145
Avg	.8278	.8955	.9780	1.0754	.8750	1.0036	1.0048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 201 / 11 KV. MHALASJAWALA SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0583	.068	.0667	.0854	.0572	.8149
2	.0747	.0707	.068	.0667	.0854	.0572	.823
3	.0854	.072	.0693	.068	.096	.0572	.8718
4	.096	.0838	.0693	.0777	.1162	.0583	.9175
5	.096	.1086	.0892	.101	.1162	.0583	1.1012
6	.1132	.1067	.1048	.1749	.1216	.0892	1.1069
7	.1387	.1303	.128	.1646	.1216	.0991	1.1717
8	.1494	.1572	.1658	.1257	.128	.128	1.4373
9	.1414	.1372	.1278	.1162	.0909	.1536	1.6872
10	.0543	.1219		.0914	.0977	.0869	.0505
11	.6478	1.4685		1.3603	1.3889	1.5089	.0505
12		1.6872	1.5242	1.4661	1.6204	1.6787	.0404
13		1.6204	1.5851	1.4842	1.5586	1.5546	.0396
14	.8383	1.4815	1.5655	1.3889	1.448	1.5546	
15	1.6956	1.406	1.5623	1.4575	1.3889	1.6598	.0396
16	1.6766	1.4506	.9722	1.406	1.3717	1.4548	.0404
17	1.7284	1.4373	1.4403	1.5623	1.4373	1.4685	.0495
18	1.5746	1.4403	1.186	1.5546	1.5023	1.3108	.072
19	.1326	.1048	.1257	.1303	.1189	.1326	.096
20	.1236	.1212	.128	.1303	.1153	.1153	.1105
21	.1105	.0892	.1174	.1326	.1153	.1174	.0854
22	.0838	.0793	.1086	.1162	.068	.1086	.072
23	.0707	.0762	.0995	.084	.068	.0977	.0693
24	.0747	.0594	.0667	.0777	.084	.0572	.7802
Max	1.7284	1.6872	1.5851	1.5623	1.6204	1.6787	1.6872
Min	.0543	.0583	.0667	.0667	.068	.0572	.0396
Avg	.4446	.5654	.5169	.5585	.5560	.5694	.5012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 202 / 11 KV. KALEGAON FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3226	.9717	1.012	1.1104	1.0229	.8779	
2	1.4074	1.065	1.1336	1.1789	1.1317	.9145	
3	1.543	1.1934	1.4251	1.2346	1.2003	.9955	
4	1.5939	1.3077	2.0119	1.286	1.3546	1.4022	
5	1.7126	1.5261	2.0008	2.0957	1.6787	1.8861	
6	1.8482	1.8442	2.0348	2.0957	1.9113	2.0348	
7	2.1026	2.0119	2.1704	2.2377	2.3304	2.0957	
8	2.2382	2.2377	2.1795	2.4034	2.42	2.1548	
9	2.2043	2.2377	2.1382	2.3472	2.0957	2.2045	.0328
10	.0753	.0505		.0305	.0381	.0404	.0335
11	.0667	.0328	.0633	.0305	.0328	.0404	1.6004
12	.0541	.0312	.032	.0312	.0328	.0404	2.1862
13	.0541	.029	.032	.032	.0328	.0404	2.3758
14	.0533	.0297	.032	.0305	.029	.0389	2.3758
15	.0526	.0297	.032	.0267	.029	.0389	2.4863
16	.0518	.0305	.06	.0351			2.5194
17	.032	.0312	.0312	.0343	.0305		2.4646
18	.0362	.032	.0419	.041	.0396		2.4247
19	.0381	.0335	.0476	.0457	.0572		.0358
20	.0429	.0419	.0457	.0457	.0766		.0358
21	.0457	.0438	.0438	.0448	.0638		.0358
22	.0373	.032	.0448		.0419		.0448
23	.0366	.032	.0448	.0467	.0335		.0448
24	.9667	.8097	.9374	1.0242	.8322	.8316	
Max	2.2382	2.2377	2.1795	2.4034	2.42	2.2045	2.5194
Min	.032	.029	.0312	.0267	.029	.0389	.0328
Avg	.7340	.6535	.7650	.7604	.7181	.9773	1.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 203 / 11KV MHALASJAWALA -G- GAOTHAN FEEDER
 FEEDER Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.096	.1562	.104	.108	.1134	.1067
2	.0995	.0983	.1543	.1014	.1372	.1134	.0914
3	.096	.0972	.1543	.1	.1372	.1134	.104
4	.0937	.128	.1829		.1932	.1619	.1014
5	.1635	.2267	.2258	.1758	.2115	.1829	.1715
6	.2397	.4228	.2858	.184	.2534	.2743	.3201
7	.2606	.4365	.3018		.2721	.3109	.3319
8	.3467	.3319	.3018	.2601	.2766	.3319	.3064
9	.3517	.2934	.3111	.2606	.2858	.2808	.3517
10	.2469	.2439		.2429	.2721	.3418	.3041
11	.1758	.2056	.1656	.2031	.2056	.286	.3048
12	.1947	.176	.192	.1943	.208	.2559	.2286
13	.1646	.1619	.1898	.1943	.1943	.2315	.2343
14	.1758	.1619	.1865	.1802	.1739	.1981	.2343
15	.16	.1739	.1823	.1619	.1739	.2591	.2187
16		.1966	.1492	.208	.216	.2785	.1718
17	.2105	.2267	.1781	.2429	.2347	.2753	.2201
18	.2881	.2134	.2623	.2932	.2187	.2812	.2107
19	.2332	.1981	.2408	.2623	.2031	.2343	.2214
20	.1783	.1829	.2134	.1718	.2056	.2031	.208
21	.132	.1656	.1718		.1739	.1581	.176
22	.1067	.1486	.1406	.1562	.16	.1219	.1423
23	.0926	.1505	.125	.108	.1296	.1054	.1265
24	.1187	.0914	.1524	.108	.108	.1107	.108
Max	.3517	.4365	.3111	.2932	.2858	.3418	.3517
Min	.0926	.0914	.125	.1	.108	.1054	.0914
Avg	.1839	.2012	.2010	.1863	.1980	.2177	.2081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054059 / 33/11 KV. S/S/ MHALASJAWALA

Feeder No / Name : 204 / 11KV KALEGAON -G- FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1052	.1372	.12	.1509	.1029	.1254
2	.1886	.1174	.1372	.1174	.1698	.1029	.1086
3	.2263	.1134	.0903	.1134	.1698	.0972	.1075
4	.2641	.1204	.1486	.1265	.2012	.0937	.104
5	.2591	.1783	.1783	.1677	.2427	.1286	.1174
6	.2538	.2401	.1734	.1635	.2753	.1867	.217
7	.152	.2298	.1858	.1867	.257	.1943	.2389
8	.2534	.2534	.2073	.1981	.2629	.2105	.2332
9	.2534	.1894	.1951	.1814	.1219	.1943	.217
10	.1315	.1739		.1715	.1543	.1981	.2622
11	.1166	.1143	.1406		.1094	.1581	.1898
12	.1067	.104	.125	.1423	.1067	.1526	.1562
13	.0974	.1067	.125	.1134	.1054	.0926	.1543
14	.1183	.108	.1067	.0995	.1094	.0995	.1389
15	.1082	.1389	.128	.1296	.1067	.125	.1219
16	.1143	.1423	.116	.1134	.1189	.1423	.1067
17	.1389	.1635	.1296	.1505	.1406	.1174	.1027
18	.1543	.176	.1698	.2	.1475	.1614	.1265
19	.1844	.1614	.1875	.2187	.1715	.2012	.156
20	.1578	.1448	.1791	.1753	.1772	.1886	.1772
21	.1463	.1303	.1646	.1646	.1848	.1791	.1629
22	.1307	.1457	.1494	.1509	.1663	.1646	.1463
23	.1132	.1457	.1478	.1509	.1294	.1402	.1294
24	.1509	.112	.1492	.1214	.1509	.1109	.1417
Max	.2641	.2534	.2073	.2187	.2753	.2105	.2622
Min	.0974	.104	.0903	.0995	.1054	.0926	.1027
Avg	.1663	.1506	.1509	.1512	.1638	.1476	.1559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054081 / 33/11 KV. RAJURI (N) S/S

Feeder No / Name : 204 / 11KV Rajuri-Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-JAN-18	10-JAN-18
HR	Load (MW)	Load (MW)
2		.2258
4		.3572
6		.5801
7		.2378
14		.2705
16	.2972	.3018
18	.3715	
20	.4287	
22	.2972	
24		.1486
Max	.4287	.5801
Min	.2972	.1486
Avg	.3487	.3031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-STATION

Feeder No / Name : 201 / 11 KV Nalwandi (New) SINGLE PHASING

Feeder Feeder KV- 11 /
OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3978	.3353	.3277	.3315	.3932	.3978
2	.3932	.3315	.3932	.426	.5304	.3932	.3978
3	.3932	.3978	.4024	.426	.5967	.4915	.4641
4	.5571	.3978	.4588	.5571	.663	.5243	.5365
5	.7209	.4641	.7209	.7773	.7377	.5571	
6	.7865	.5304	.9831	1.004	.7956	.5898	
7		.5967	1.1401	1.004	.8619		
8	.9503	.663	1.073	1.0242	.9282	.7865	
9	1.5912	.9282	.9945	.8745	.7956	.9503	
10	.7293	.8215	.5967	.6554	.8951		.5898
11	1.5912	1.4784	1.5181	1.9662	1.6385	1.7436	1.6842
12	2.1879	1.5813	1.9433	2.0809	2.0317	2.2131	2.1765
13	2.1216	.3795	2.0081	1.9662	1.1142	2.2131	2.4615
14	1.989	2.2672	1.9433	2.2939	2.0972	1.3413	2.3685
15	2.1216	2.2138	1.0364	2.3266	2.13	2.146	2.2405
16	2.3205	2.2138	2.0485	2.2283	2.2939	2.2131	2.1125
17		2.3594	1.9845	1.5912	2.0317	2.2131	1.9845
18		1.8351	1.9204	1.8778	1.8351	1.9227	
19		.7865	.8421	.8718	.7209	.7377	.7125
20		.6554	.7449	.7956	.7209	.7377	.6154
21	.4641	.5967	.6154	.663	.4588	.6036	.5506
22	.5304	.4588	.4534	.5304	.4588	.5365	.4915
23	.4641	.439	.3887	.3978	.3932	.4024	.4588
24		.3978	.3658	.3605	.3978	.3932	
Max	2.3205	2.3594	2.0485	2.3266	2.2939	2.2131	2.4615
Min	.3932	.3315	.3353	.3277	.3315	.3932	.3978
Avg	1.1281	.9663	1.0380	1.1261	1.0608	1.0956	1.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054103 / 33/11 KV NALWANDI SUB-STATION

Feeder No / Name : 202 / 11 KV Jarud SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-JAN-18	11-JAN-18
HR	Load (MW)	Load (MW)
1		.8131
2		1.1706
3		1.4998
4		1.9753
5		2.0271
6		2.1357
7		2.1357
8		2.1719
9		2.1719
11	.2987	
12	.2614	
13	.2987	
14	.2614	
15	.2614	
16	.2987	
17	.4435	
18	.7023	
19	.961	
20	.8131	
21	.5914	
22	.4805	
23	.4066	
24		.7392
Max	.961	2.1719
Min	.2614	.7392
Avg	.4676	1.6840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054112 / 33/11 KV GHATSAVLI SS

Feeder No / Name : 201 / 11 KV GHATSAVLI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1789	.6371	.8488	1.1191	.5243	.7716
2	1.3003	1.0898	1.0494	1.5927	.6226	.9568
3	1.5604	1.4922	1.1574	1.7604	.7865	1.0494
4	1.7337	1.8107	1.3889	2.3472	.8192	1.1111
5	2.0576	2.0957	1.7747	2.3472	.9995	1.1574
6	2.3472	2.1795	1.929	2.6993	1.6385	1.2346
7	2.5194	2.4813	1.0494	2.8837	2.4577	1.3117
8	2.5692	2.8166	.9259	3.0178	2.9329	1.6204
9	2.3472	2.5149	.6327	2.431	1.5123	1.3735
10		.5365		.4725	.571	.571
11		1.2037	1.21		1.142	2.0119
12		1.4352	1.3108		1.358	2.5987
13		1.4352	1.2289		1.4661	
14		1.4352	1.2289		1.4352	
15			1.1469		1.4661	
16		1.4969	1.1142		1.5432	
17		1.4043	.8192		1.5432	
18		1.3735	1.1469		1.3117	
19		.7716	.823		.8025	.571
20		.6327	.8573		.6481	
21		.4784	.5487		.4321	
22		.3704	.463		.4475	
23		.3241	.3772	1.0526	.3395	
24	1.0402	.4191	.7407	1.0526	.3277	.7253
Max	2.5692	2.8166	1.929	3.0178	2.9329	2.5987
Min	1.0402	.3241	.3772	.4725	.3277	.571
Avg	1.8654	1.3232	1.0336	1.8980	1.1303	1.2189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 201 / 11 KV DOKEWADA TALAV SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.12	.1357	.1357	.1372	.1543	.1696
2	.1187	.12	.1357	.1357	.1372	.1372	.1696
3	.1187	.12	.1187	.1357	.1372	.1372	.1696
4	.1357	.12	.1357	.1677	.1543	.1372	.1696
5	.1357	.1372	.1526	.1844	.1715	.1543	.1865
6	.1677		.1677	.1677	.1886	.1543	.1865
7	.2012	.1715	.1677	.218	.1715	.1715	.1865
8	.1509	.1715		.1865	.1886	.1715	.2515
9	.1526	.1029		.1526	.1543	.1543	.1696
10	.1357	.12		.1696		.1543	.1526
11	2.9508	2.672		2.4006	2.7046	2.4352	2.7831
12	3.0849			2.364	2.878	2.6368	2.9675
13	3.2442	3.0087		3.1824	2.9412	2.6368	2.8502
14	3.2606	2.7206	2.3863	3.1493	3.0636	2.8086	3.2985
15	2.6852	3.1398	2.7578	3.0333	3.0933	2.7511	2.9835
16	2.6155		2.8435	3.0498	2.8938	2.6673	2.9675
17	3.0346	2.8464	2.6292	2.9172	2.6566		3.0514
18	2.8502	2.8166	2.472	2.7999	2.7044	2.6673	2.9508
19	.1886	.1886	.1865	.1844	.2058	.1844	.2058
20	.1715	.1715	.1696	.1886	.1715	.2012	.1886
21	.1543	.1715	.1696	.1715	.1886	.2012	.1715
22	.1372	.1543	.1357	.1543	.2058	.2012	.1715
23	.1372	.1372	.1357	.1543	.2229	.2012	.1715
24	.1187	.12	.1357	.1357	.1372	.1715	.1696
Max	3.2606	3.1398	2.8435	3.1824	3.0933	2.8086	3.2985
Min	.1187	.1029	.1187	.1357	.1372	.1372	.1526
Avg	1.0862	.9205	.8353	1.0641	1.1090	.9256	1.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 202 / 11 KV BHALWANI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.5775	1.4403	1.4403	1.4243	1.326	1.3916
2	1.7814	1.56	1.6362	1.5813	1.4582	1.4754	1.4842
3	1.7814	1.5424	1.8099	1.5813	1.56	1.6712	1.5546
4	1.8623	1.6933	1.9004	1.6129	1.7436	1.8947	1.6004
5	1.8623	1.9784	2.0719	1.6129	1.7939	2.0005	1.829
6	1.8564	2.4034	2.1434	1.9766	2.4478	2.1445	1.8873
7	1.8884	2.8012	1.1279	2.2929	2.5316	2.372	2.348
8	2.2085	2.967		2.5459	2.7328	2.6871	2.5412
9	2.3045	2.9504		2.5459	2.6322	2.5587	2.4234
10		.2743		.3018	.3258	.3429	.4096
11	.1715	.2229		.2204	.2229	.2229	.2572
12	.1543	.1715		.1715	.1543	.2012	.2229
13	.1372	.1372		.12	.1372	.1696	.1715
14	.1372	.1372	.1526	.12	.12	.1696	.1715
15	.12	.1372	.1341	.1029	.12	.1696	.1372
16	.12	.1372	.1357	.1029	.12	.1357	.1372
17	.12	.2058	.1357	.1372	.1372	.1357	
18	.3086	.2058	.2012		.1886	.1865	.1543
19	.3429	.3429	.3185	.2743	.3429	.285	.2915
20	.3429	.3086	.3185	.2743	.3258	.3185	.2743
21	.3086	.2572	.285	.2572	.2743	.2012	.2572
22	.2743	.2543	.2543	.2572	.2572	.2012	.2572
23	.2572	.2543	.2543	.2572	.2229	.2012	.2229
24	1.6194	1.4575	1.3123	.1376	1.286	1.2407	1.2967
Max	2.3045	2.967	2.1434	2.5459	2.7328	2.6871	2.5412
Min	.12	.1372	.1341	.1029	.12	.1357	.1372
Avg	.9382	.9991	.8685	.8663	.9400	.9297	.9270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054123 / 33/11KV PIMPALWADI S/Sn

Feeder No / Name : 203 / 11 KV PIMPALWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0181	.0181	.0181	.0177	.0175	.0362
2	.0362	.0181	.0181	.0181	.0177	.0175	.0362
3	.0362	.0181	.0362	.0181	.0179	.0351	.0362
4	.0362	.0358	.0362	.0362	.0354	.0526	.0514
5	.0543	.0532	.0686	.0514	.1052	.0857	.0857
6	.0857	.1052	.1029	.1029	.1387	.12	.1029
7	.1029	.1372	.12	.1526	.1543	.1029	.1526
8	.1029	.1214		1.5091	.1715	.12	.1526
9	.1187	.1214		.1187	.1214	.0857	.1187
10	.0857	.0857		.0857	.0857	.1029	.0857
11	.0701	.0526		.0514	.0686	.0701	.104
12	.0351	.0351		.0532	.0526	.0514	.0526
13	.0354	.0351		.0354	.0351	.0362	.0351
14	.0177	.0351	.0362	.0354	.0351	.0362	.0177
15	.0177	.0351	.0514	.0177	.0876	.0362	.0177
16	.0351	.0351	.0362	.0177	.0351		.0177
17	.0354	.0526	.0362	.0532	.0351	.0362	.0354
18	.0526	.0701	.0686	.1227	.0514	.0514	.0354
19	.124	.12	.1357	.1052	.1029	.1029	.1052
20	.0886	.0857	.0686	.0701	.0701	.0857	.0876
21	.0709	.0686	.0514	.0532	.0701	.0857	.0709
22	.0537	.0362	.0362	.0354	.0526	.0362	.0532
23	.0358	.0362	.0362	.0354	.0351	.0362	.0354
24	.0362	.0354	.0362	.0181	.0354	.0351	.0362
Max	.124	.1372	.1357	1.5091	.1715	.12	.1526
Min	.0177	.0181	.0181	.0177	.0177	.0175	.0177
Avg	.0585	.0603	.0552	.1173	.0680	.0626	.0651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 201 / 11 kv Kukkadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.1638	.1638	.112	.144	.1638	.4915
2	.2561	.1638	.1475	.112	.144	.1966	.5243
3	.2721	.1966	.1311	.112	.16	.1966	
4	.3041	.1966	.1311	.128	.144	.2294	.6882
5	.3201	.2294	.1966	.16	.16	.2294	.6554
6	.3681	.2622	.213	.192	.2401	.2458	.7373
7	.4321	.3113	.1638	.2561	.2881	.2622	.6554
8	.2241	.2622	.1311	.2561	.2561	.213	.7373
9	.192	.1802	.1147	.176	.192	.1966	.5407
10	.16	.2458		.16	.2561	.1475	
11	.852	.7373	.7202	.6401	.7537	.5243	
12	.9995	.852	.8802	.6562	.9667	.5898	.3041
13		.9831	.9282	.9282	.9175	.6882	.2721
14	.9503	.9175	.9122	.9282	.8848	.852	.2561
15	.9175	.8192	.8962	.8482	.852	.852	.2401
16	.852	.852	.8962	.8162	.9012	.7373	.2241
17	.9175	.8192	.9122	.8642	.8684	.7701	.2401
18	.9503	.9175	.7522	.9122	.852	.7865	.2401
19	.3605	.2458	.176	.208	.2949	.2949	.2721
20	.2294	.2949	.144	.176	.2949	.2949	.2721
21	.1475	.2949	.128	.192	.2294	.2949	.2241
22	.1638	.2785	.128	.144	.2294	.2949	.192
23	.1638	.2622	.128	.16	.1966	.2785	.192
24		.1638	.1638	.144		.1638	.4096
Max	.9995	.9831	.9282	.9282	.9667	.852	.7373
Min	.1475	.1638	.1147	.112	.144	.1475	.192
Avg	.4677	.4437	.3982	.3867	.4446	.3960	.3985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 202 / 11 kv Wadgaon Gunda SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2881	.4096	.2401	.2915	.2881	.1802
2	.3401	.3521	.5407	.2401	.3077	.3201	.1966
3	.3563	.3521	.5243	.2401	.3401	.3201	.213
4	.3563	.3841	.5735	.2881	.3239	.3841	.1966
5	.3725	.4481	.5898	.3361	.3563	.4481	.2294
6	.4049	.4694	.639	.4001	.4049	.5121	.213
7	.5668	.4961	.6882	.5921	.4534	.5761	.2458
8	.6478	.6562	.6554	.6401	.583	.6081	.2622
9	.502	.6882	.6718	.5921	.5992	.6081	.213
10	.1457	.192		.2267	.1619	.2561	.1966
11	.112	.1147	.176	.1781	.16	.213	.4321
12	.096		.128	.1619	.16	.1638	.5121
13		.1147	.096	.1457	.128	.1638	.5121
14	.128	.1147	.096	.1619	.096	.1311	.4481
15	.096	.0983	.112	.1457	.08	.0983	.4641
16	.096	.1147	.08	.1457	.096	.1311	.4481
17	.128	.1147	.128	.1619	.128	.1638	.3841
18	.176	.1475	.2401	.0648	.176	.1966	.4161
19	.208	.2785	.2561	.1134	.192	.1638	.208
20	.208	.2785	.144	.2267	.192	.213	.2241
21	.2401	.2294	.2241	.1943	.208	.213	.208
22	.2241	.2458	.208	.1457	.2241	.1966	.208
23	.192	.2458	.208	.1781	.192	.1966	.208
24		.2881	.2458	.2753		.2881	.1638
Max	.6478	.6882	.6882	.6401	.5992	.6081	.5121
Min	.096	.0983	.08	.0648	.08	.0983	.1638
Avg	.2676	.2918	.3319	.2540	.2545	.2856	.2910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054145 / 33/11 KV KUKKADGAON S/Stn

Feeder No / Name : 203 / 11 KV Rakshasbhuwan feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4359	.6882	.3315	.503	.4694	.5079
2	.5868	.4359	.7373	.3315	.5868	.5365	.5243
3	.7042	.4694	.7209	.3315	.6706	.5365	.5407
4	.7209	.4694	.8192	.3647	.6874	.6036	.5735
5	.7377	.5365	.852	.4144	.7209	.6036	.5898
6	.7712	.6036	.9175	.663	.8215	.6371	.6554
7	1.0059	.7545	.8848	.663	1.073	.6874	.6882
8	1.2239	1.0059	.852	.8619	1.0898	.9892	.7373
9	1.2742	.9892	.8192	.9116	.9724	.8551	.7373
10	.4694	.4862		.4862	.4024	.5365	.5735
11		.3277	.3149	.3018	.3018	.3277	.8288
12		.213	.2818	.3185	.1006	.2458	.9448
13		.2458	.2321	.285	.1341	.1638	.9945
14	.3018	.2949	.2155	.2515	.2347	.2458	.8619
15	.285	.1966	.2984	.285	.3353	.2949	.8288
16	.3353	.213	.2818	.2683	.3856	.2785	.779
17	.4359	.1966	.3647	.3185	.4694	.3605	.6962
18	.5533	.2785	.5967	.57	.5365	.5407	.5967
19	.503	.3605	.5967	.5365	.503	.5735	.4641
20	.4694	.5571	.5138	.4359	.503	.5407	.4475
21	.4359	.4915	.4973	.4191	.4694	.5243	.4475
22	.4024	.5079	.3978	.4024	.4527	.4915	.3978
23	.3688	.4588	.3978	.3856	.4359	.4096	.3978
24		.4359	.4588	.4191		.4694	
Max	1.2742	1.0059	.9175	.9116	1.0898	.9892	.9945
Min	.285	.1966	.2155	.2515	.1006	.1638	.3978
Avg	.5985	.4568	.5539	.4399	.5387	.4967	.6441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 201 / 11 Kv Dagdi Shahajanpur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.2629	.2652	.2683	.3772	.3277	.2683
2	.3521	.2972	.3018	.2984	.3944	.4049	.2915
3	.3521	.3681		.3353	.463	.4858	.4024
4	.3353	.3887	.3647	.4024	.5144	.5182	.4066
5	.4359	.3963	.4694	.4641	.6516	.5668	.4908
6	.463	.421	.5304	.5365	.823	.5992	.5935
7	.4801	.421	.5868	.8478	.9619	.6401	.8139
8	.6859	.4534		1.1022	1.0751	.9488	.9496
9	.5521	.5201		.9892	.8381	.9393	1.0004
10	.2601	.2073			.1075		
11	.1814	.1337		.08	.2172		
12	.1296	.08		.1067	.2561		
13	.1238	.1189		.1334	.2561	.2218	.1036
14	.1296	.1067	.1886	.1067	.1629	.1829	.1166
15	.1315	.1067	.2263	.1341	.2012	.2195	.1315
16	.1446	.12	.2075	.1174	.1829	.2427	.1486
17	.2103		.3174	.1677	.2561	.1848	
18	.3628	.3734	.5228	.1829	.3292	.4572	
19	.3898	.4001	.6099	.218	.6036	.5175	.3155
20	.3368	.4001	.6036	.218	.499	.4024	.3628
21	.2629	.3467	.3696	.2012	.3658	.2743	.2892
22	.2366	.2	.2926	.1677	.3109	.3174	.2477
23	.2229	.1734	.2561	.1677	.2743	.2772	.2229
24	.3688	.2366	.2713	.2652	.2347	.2984	.2486
Max	.6859	.5201	.6099	1.1022	1.0751	.9488	1.0004
Min	.1238	.08	.1886	.08	.1075	.1829	.1036
Avg	.3125	.2840	.3755	.3266	.4315	.4299	.3897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 202 / 11 Kv Pargaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.2103	.1734		.2012	.2486	.2429	.2458
12	.2229	.285		.3018	.2652	.2458	.2105
13	.2477	.3353		.3018	.2753	.1943	.1555
14	.285	.3521	.2267	.3018	.3292	.3441	.1814
15	.2724	.3688	.3401	.2915	.2753	.3277	.2073
16	.2721	.3856	.3605	.3086	.2753	.3605	.2263
17	.2629		.2915	.2743	.2591	.3113	.2073
18	.2761	.3353	.2267	.2572	.2267	.2267	.2073
Max	.285	.3856	.3605	.3086	.3292	.3605	.2458
Min	.2103	.1734	.2267	.2012	.2267	.1943	.1555
Avg	.2562	.3194	.2891	.2798	.2693	.2817	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

BEED RURAL S/DN[413] BU 2542

Substation No/ Name :- 054164 / 33/11 KV SHIRAS PARGAON

Feeder No / Name : 203 / 11 kv Pargaon G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.2629	.2641	.2012	.3018	.2984	.1989
2	.3018	.285	.2614	.2012	.3688	.3315	.2561
3	.3018	.2477	.3772	.2035	.4694	.3277	.2743
4	.3353	.3109	.3772	.2155	.503	.4096	.2715
5	.3856	.3887	.4527	.2347	.57	.4858	.2896
6	.3856	.4664	.4481	.2652	.6516	.5668	.2896
7	.4024	.4582	.5601	.431	.6859	.6316	.407
8	.503	.4954		.5636	.8402	.7125	.5596
9	.3963	.5441		.57	.7449	.7449	.6104
10	.2012	.2591			.1646		.1886
11	.1578	.1867		.1334	.1991	.1886	.1886
12	.1296	.16		.2134	.3258	.132	.0907
13	.1315	.2		.2401	.3142	.1267	.1315
14	.1315	.1734	.1463	.2401	.2987	.1254	.1509
15	.1425	.1867	.1448	.2561	.2743	.1307	.1684
16	.1734	.1867	.128	.16	.3801	.1463	.1734
17	.184		.181	.1734	.3658	.1463	.1943
18	.2103	.2134	.2172	.2	.2126	.1629	.16
19	.1981	.2675	.2534	.2683	.2561	.2743	.1578
20	.2073	.2134	.2534	.1932	.2402	.2172	.1814
21	.184	.1867	.1867	.1783	.2195	.1848	.1814
22	.1578	.16	.1867	.1783	.2033	.1867	.1555
23	.184	.16	.1698	.1486	.1829	.1867	.1555
24		.1814	.2374	.1989	.2012	.2321	.1989
Max	.503	.5441	.5601	.57	.8402	.7449	.6104
Min	.1296	.16	.128	.1334	.1646	.1254	.0907
Avg	.2467	.2693	.2692	.2464	.3739	.3022	.2347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 201 / 11 KV. CHAVANWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						1.643
10				1.8473		2.0144
11				1.7558		2.0328
12	1.5524			1.8665		1.8858
13	1.5339			1.8656		1.7002
14	1.5154			1.8839		
15				1.8111		1.848
16	1.5339	.1905		1.5154		1.8671
17	.1715	.2477		.1524		
18	.2858			.2667		
19	.3239	.381		.3429		
20	.3239	.3429		.3239		
21	.3048	.3048		.2858		
22	.2667	.2477		.2477		
23	.2096	.2096		.2286		
24		.2096	.1905		.2286	
Max	1.5524	.381	.1905	1.8839	.2286	2.0328
Min	.1715	.1905	.1905	.1524	.2286	1.643
Avg	.7293	.2667	.1905	1.0281	.2286	1.8559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054021 / 33/11 KV. TALWADA S/S

Feeder No / Name : 205 / 11 KV DEVI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9						.6097
10						.5525
11	.362					.4382
12	.3239					.4382
13	.381					.4382
14	.4191					.4572
16	.4382	.4572				.4572
17	.5335	.4572		.4382		
18	.6478	.4954		.5144		
19	.7621			.811		
20	.8002	.7811		.7733		
21	.8002	.724		.743		
22	.7811	.6859		.6859		
23	.6859	.6668		.6478		
24		.4763	.6287		.6287	
Max	.8002	.7811	.6287	.811	.6287	.6097
Min	.3239	.4572	.6287	.4382	.6287	.4382
Avg	.5779	.5930	.6287	.6591	.6287	.4845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 201 / 11 KV. SIRASMARG FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1132	.0914	.0972	.1132	.1132	.0914	.0972
4	.1132	.0914	.0937	.1494	.1132		.0972
6	.2241	.1219	.2267	.2218	.2263	.1829	.1619
8	.1867	.1524	.2267	.2926	.2241	.1981	.2267
9	.1372	.0914	.2561		.1524	.1829	
10	.1219	.1562	.1829	.2241	.1524	.1524	.3206
11	.1219		.1478		.1219		
12	.1067	.0972	.1494	.132	.1067		.1886
13	.1067		.1494		.1067	.0972	
14	.1067	.0972	.1494	.1132	.0914	.0937	.1509
15	.1067		.1132		.0914		
16	.0914	.081	.1132	.1132	.1067	.0972	.1132
17	.1067		.1494		.1372		
18	.1372	.2267	.1848	.132	.1524	.1562	.1509
19	.1829		.2561		.1829		
20	.1524	.1943	.2218	.1509	.1524		.1886
21	.1372		.1848		.1372	.1715	
22	.1219	.1494	.1478	.132	.1219		.132
23	.1067		.1478				
24	.1132	.0914	.0972	.1132	.132	.0914	.0972
Max	.2241	.2267	.2561	.2926	.2263	.1981	.3206
Min	.0914	.081	.0937	.1132	.0914	.0914	.0972
Avg	.1297	.1263	.1648	.1573	.1380	.1377	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 202 / 11 KV. UKHADPIMPRI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6773	.4858	.3239	.3064	.5268	.381	.3239
4	.6773	.4858	.4049	.4268	.6923	.4572	.4858
6	.7526	.8097	.6478	.6097	1.0385	.9145	.9717
8	.8429	.9717	1.0688	.9031	1.1288	1.1279	1.3927
9	.945		1.0526		.9755	1.0669	
10	.4268	.502	.4374	.3953	.2591	.2591	.6443
11	.3048		.2031		.1829		
12	.2439	.1296	.128	.0983	.1524		.4917
13			.128		.0914	.1718	
14	.1829	.0972	.1341	.1147	.0914	.1781	.2401
15	.1524		.1311		.0914		
16	.1372	.0972	.1311	.116	.0914	.1943	.208
17	.1219		.2267		.3048		
18	.381	.3239	.463	.3041	.3658	.3048	.2778
19	.4877		.5155		.4572		
20	.4572	.3887	.4374	.3658	.4877		.2968
21	.381		.25		.381	.362	
22	.3048	.2683	.2267	.2622	.3048		.25
23	.2743		.1943		.3048		
24	.3957	.4858	.3239	.3064	.2553	.3048	.3239
Max	.945	.9717	1.0688	.9031	1.1288	1.1279	1.3927
Min	.1219	.0972	.128	.0983	.0914	.1718	.208
Avg	.4288	.4205	.3714	.3507	.4092	.4769	.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 203 / 11 KV. SHAJANPIMPRI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2503	.1943	.1943	.2155	.5535	.3963	.2591
4	.2812	.2429	.2591	.2949	.6706	.4572	.3239
6	.4096	.6249	.421	.3521	.788	.6401	.6478
8	.4424	.7449	.7545	.8259	.788	.6249	.6802
9	.4115		.9995		.8688		
10	.1067	.0648	.2054	.1063	.1524		.0754
11	.0914		.1132		.1067		
12	.0762	.0648	.0943	.0943	.1067		.2075
13	.0762		.0943			.0648	
14	.061	.0648	.0754	.0943		.0648	.1867
15	.061		.0754				
16	.1219	.0972	.0943	.1132		.0648	.1524
17	.1372		.1132		.1524		
18	.1677	.0972	.2263	.2075	.1829	.0937	.2452
19	.2134		.2641		.1981		
20	.1981	.2753	.3018	.2241	.1981		.2987
21	.1829		.3018		.1829	.2715	
22	.1677	.2534	.2241	.2452	.1524		.2452
23	.1524		.2054		.2286		
24	.1391	.1943	.1943	.2155	.1898	.2286	.2591
Max	.4424	.7449	.9995	.8259	.8688	.6401	.6802
Min	.061	.0648	.0754	.0943	.1067	.0648	.0754
Avg	.1874	.2432	.2606	.2491	.3450	.2907	.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 204 / 11 KV. TAKALGAVAN FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1886	.1619	.1619	.1848		.1524	.1619
4	.1886	.1619	.2267	.2561		.1829	.2267
6	.3734	.3239	.3239	.3982		.3353	.3353
8	.499	.4858	.4049	.3658		.3963	.3887
9	.3963		.4207				
10	.3506	.3239	.362	.2378			.4344
11	.6401		.4755		.4877		
12	.6401	.7935	.6287	.643	.6097		.751
13	.9145		.695		.6401	.8124	
14	.945	.8421	.7628	.643	.5792	.8421	.9023
15	.945		.7282		.5792		
16	.884	.7773	.7133	.6308	.6401	.9231	.8109
17	.8383		.5944		.6097		
18	.7011	.6478	.4877	.5721	.6097	.7164	.5792
19	.3048		.3658		.2743		
20		.2896	.3361	.3761	.2134		.2658
21	.2743		.2829		.1829	.2896	
22	.2439	.2534	.2149	.2353	.1524		.2126
23	.2134		.1949		.1524		
24	.1886	.1619	.1619	.1848		.1524	.1562
Max	.945	.8421	.7628	.643	.6401	.9231	.9023
Min	.1886	.1619	.1619	.1848	.1524	.1524	.1562
Avg	.5121	.4353	.4271	.3940	.4408	.4803	.4354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 205 / 11 KV TARTEWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0754	.081	.0972	.0934	.061	.061	.0972
4	.0754	.081	.0972	.0934	.061	.061	.0972
6	.0953	.1296	.1296	.1132	.1219	.0914	.1296
8	.0953	.1619	.1296	.1132	.2439	.0914	.1296
9	.061		.112				
10	.061	.1781	.1132	.1132	.1219		.2031
11	.381		.4321		.381		
12	.2896		.6133	.5898	.4572		.5636
13	.1524		.7459		.442	.8907	
14	.1829	.6802	.7127	.6796	.4268	.8421	.7127
15	.1524		.7209		.381		
16	.5487	.664	.7373	.779	.4268	.6478	.7127
17	.5487		.6796		.5487		
18	.4725	.5668	.4534	.6133	.5487	.6802	.5668
19	.1219		.1848		.1677		
20	.1067	.168	.1629	.1494	.1677		.1132
21	.0914		.112		.1524	.1372	
22	.0762	.112	.0943		.1219		.0953
23	.0762		.0943		.0914		
24	.0943	.081	.0972	.0934	.197	.061	.0972
Max	.5487	.6802	.7459	.779	.5487	.8907	.7127
Min	.061	.081	.0943	.0934	.061	.061	.0953
Avg	.1879	.2640	.3260	.3119	.2695	.3564	.2932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054035 / 33/11 KV. SIRASMARG S/S

Feeder No / Name : 206 / 11 KV. TANDALWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0514	.0486	.0678	.0754	.0457	.0457	.0648
4	.0514	.0486	.0686	.0701	.0457	.0457	.0625
6	.0686	.0625	.1029	.0895	.0762	.061	.0972
8	.0983	.0972	.104	.0724	.0762	.0914	.0972
9	.061		.0701				
10	.061	.0972	.0701	.0663	.0914		.064
11	.4572		.0995		.4725		
12	.4572	.6316	.6241	.6241	.4572		.5201
13	.4877		.8149		.6401	.664	
14	.4877	.6964	.7108	.7202	.6401	.664	.6935
15	.4877		.7202		.6401		
16	.5944	.6964	.7373	.703	.6401	.6316	.6068
17	.5792		.6762		.4725		
18	.3048	.583	.5426	.5316	.4572	.4534	.4862
19	.0914		.0734		.0914		
20	.0762	.112	.0724	.0705	.0914		.0972
21	.061		.0518		.0762	.112	
22	.0457	.0747	.0663	.0594	.0762		.0492
23	.0457		.0663		.0457		
24	.0686	.0486	.0678	.0754	.0457	.0457	.0648
Max	.5944	.6964	.8149	.7202	.6401	.664	.6935
Min	.0457	.0486	.0518	.0594	.0457	.0457	.0492
Avg	.2318	.2664	.2904	.2632	.2727	.2815	.2420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 201 / 11KV RAJPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2926	.2683	.1372	.3086	.2347	.2374
2	.3086	.2804	.2347	.1402	.2683	.2374	.2321
3	.3155	.2804	.2321	.1387	.2622	.2652	.2683
4	.4252	.2896	.373	.1387	.2881	.2652	.3018
5	.5144	.2926	.2374	.1372	.3429	.3018	.3391
6	.5609	.439	.2683	.2103	.3506	.3353	.3391
7	.5487	.4801	.2652	.2743	.4115	.373	.3391
8	.5365	.4801	.2374	.2103	.3856	.3052	.2984
9	.4801	.3467	.2035	.2804	.4161	.2294	.3361
10	.3506	.2401	.1734	.1387	.2804	.2035	.2614
16	.2103		.1372				
17	.6859	.9671	.7545	1.0288	.7522	.7522	.884
18	.7545	.9602	.7011	.9114	.6516	.823	.8855
19	.6173	.9015	.4115	.7712	.6241	.8478	
20	.4908	.823	.4207	.5144	.57	.7377	
21	.4161	.7377	.4801	.4801	.5426	.6962	
22	.4207	.7377	.4207	.4748	.503	.663	
23		.7122	.3429	.4161	.5087	.57	
24		.2896	.6783	.1372	.3506	.4694	.5765
Max	.7545	.9671	.7545	1.0288	.7522	.8478	.8855
Min	.2103	.2401	.1372	.1372	.2622	.2035	.2321
Avg	.4669	.5306	.3600	.3633	.4343	.4617	.4076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 202 / 11KV DHONDRAI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.439	.57	.2743	.5487	.8048	.5426
2	.4458	.4207	.6371	.2804	.5365	.8478	.5967
3	.5258	.4207	.663	.4161	.4915	.8619	.7042
4	.5316	.4344	.7461	.4854	.5121	.8951	.8048
5	.5487	.5853	.8139	.823	.6516	.9054	.9156
6	.5609	.6173	.8718	1.0517	1.0517	1.0059	.9835
7	.6173	.823	.8951	1.0974	1.2346	1.153	
8	.6706	.8916	.9496	1.1919	.9465	1.0852	1.0608
10			.7461				
14	.3429		.4161				
15	.3429	.2865	.4207	.4748	.2743	.2743	
16	.4207	.2835	.4115	.5365	.3155	.3155	
17	.5487	.3224	.5487	.5487	.3582	.4298	.724
18	.6859	.3772	.7011		.4801	.5487	.7842
19	.8916	.5895	.8916	.8718	.5548	.5765	
20	.7712	.583	.8413	.823	.57	.6036	
21	.6935	.6036	.6859	.6859	.5765	.5304	
22	.631	.5365	.7011	.5765	.5365	.4973	
23	.4207	.5087	.4801	.5548	.5087	.4694	
24	.4207	.4344	.4748	.2743	.5258	.503	.4748
Max	.8916	.8916	.9496	1.1919	1.2346	1.153	1.0608
Min	.3429	.2835	.4115	.2743	.2743	.2743	.4748
Avg	.5512	.5087	.6733	.6451	.5930	.6838	.7591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 203 / 11KV GANGAWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0732	.0671	.0686	.0343	.1006	.1017
2	.0514	.0701	.0671	.0701	.0335	.0995	.0995
3	.0701	.0701	.0663	.0693	.0328	.0995	.1006
4	.0709	.0724	.1017		.048	.1341	.1341
8	.2012	.2058	.1357	.1402			
9	.6859	.7628	.4748	.7011	.8322	.7865	.6958
10	.7712	.8413	.5548	.8322		.9156	.8124
11	.7628	.8916	.823	.8764	.9313		
12	.8413	.8413		1.0288	.9568	.9816	.8749
13	.9602		.8916	.9015	.5014	1.0745	.8749
14	.8916	.9568	.9362	.9602	.9709		.8436
15	.9602	.9313	.567	.9496	.9259		.9061
16	.9816	.9568	.7545	.8718	.9114		.9172
18	.0686		.0701				
19	.0686	.1734	.0686	.0335	.1387	.1696	
20	.0701	.1372	.0701	.0343	.1341	.1677	
21	.0693	.1006	.0686	.0514	.1357	.1326	
22	.0701	.1006	.0701	.0509	.1017	.0995	
23	.0701	.0678	.0686	.0351	.1017	.1006	
24	.0351	.0724	.0678	.0686	.0351	.1006	.1017
Max	.9816	.9568	.9362	1.0288	.9709	1.0745	.9172
Min	.0335	.0678	.0663	.0335	.0328	.0995	.0995
Avg	.3867	.4070	.3118	.4302	.4015	.3545	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

GEORAI (R) S/DN[414] BU 2534

Substation No/ Name :- 054085 / 33/11KV DHONDRAI S/S

Feeder No / Name : 204 / 11 KV MAHALAXMI INDESTRIAL SHEDDABLE FEEDER HAVING WEEKLY
 FEE Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.5853		.3429	.4115	.7042	.7461
2	.5144	.5609	.6036	.3856	.4191		.7293
3	.5258	.5258	.5304	.3814	.3932	.6299	.7042
4	.567	.543	.5426	.3814	.4161	.5636	.6706
5	.5487	.5487	.5087	.3772	.4115	.57	.5765
6	.631	.6584	.57	.3856	.4557	.3688	.5765
7	.6516	.6173	.5967	.3772	.4458	.373	.5426
8	.6706	.7545	.6443	.5609	.6661	.6104	.4973
9	.5144	.8322	.2713	.5959	.3467	.7209	.4801
10	.5258	.8063	.2774	.3814	.4207	.407	.5792
11	.4854	.7545	.3429	.4557	.3224		.1063
12	.4207	.631		.6173	.3544	.631	.1417
13	.4458	.6089	.4115	.5548	.3582	.788	.1791
14	.4115	.7442	.3467	.6173	.3814	.7282	.2865
15	.5487	.7087	.3506	.7122	.4458	.7545	.3086
16	.7011	.7442	.3258	.5365	.5258	.7362	.3814
17	.6859	.788	.2401	.7545	.7522	.8596	.5068
18	.6859	.7888	.2454	.7712	.7545	.7888	
19	.7202	.7975	.2058	.57	.7975	.7461	
20	.5258	.7545	.1753	.4801	.8048	.7377	
21	.6241	.7377	.3772	.4801	.8139	.663	
22	.631	.7042	.3856	.4409	.8048	.663	
23	.631	.6783	.3772	.4161	.78	.7377	
24	.4908	.5792	.6783	.3429	.4207	.7712	.78
Max	.7202	.8322	.6783	.7712	.8139	.8596	.78
Min	.4115	.5258	.1753	.3429	.3224	.3688	.1063
Avg	.5678	.6855	.4094	.4966	.5293	.6615	.4885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 201 / 11 KV. PATODA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.7716		.7716			.7888
4		.8745					.8745
6		1.543		1.5775			1.4232
7	1.9281		1.8945	1.8652	2.0454	1.8778	
8	2.2874	2.0729	2.3205	2.1262	2.2708	2.2211	
9	2.0454	2.0222	2.0622	1.8023	1.9784	2.0119	1.8679
10		1.8399		1.9281		1.873	1.8652
11	1.5089	1.6956	1.6289	1.6956		1.5604	2.0668
12	1.4232		1.4746	1.491		1.406	1.9753
13	1.3717	1.4217	1.4232		1.4737	1.3375	1.7737
14	1.2174	1.335	1.2517	1.335	1.2795	1.2803	
15	1.0974	1.1919	1.286	1.2269		1.3169	1.3535
16	1.2346	1.2269	1.3375	1.2269	1.2971	1.4266	1.2803
17	1.3889		1.3375	1.3146		1.6095	1.3717
18	1.4074	1.5089	1.4575	1.4737	1.4563	1.406	
19	1.5592	1.5947			1.6804	1.7147	1.3889
20		1.5083		1.5947	1.4737	1.3375	1.2517
21	1.2346	1.3146	1.2003	1.2269	1.2971	1.166	1.0974
24		.6859		.703	.7442	.7087	.7373
Max	2.2874	2.0729	2.3205	2.1262	2.2708	2.2211	2.0668
Min	1.0974	.6859	1.2003	.703	.7442	.7087	.7373
Avg	1.5157	1.4130	1.5562	1.4600	1.5451	1.5159	1.4077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 203 / 11 KV. MAJARSUMBHA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.0288		1.0802			1.2003
4		1.286		1.3375			1.6356
5		1.4575		1.6632			
18	1.7814	2.2708	2.0405	1.6956	2.4366	2.0567	
19	1.668	1.8652			1.8347	1.7465	1.3546
20		1.543		1.6118	1.5604	1.3546	1.286
21	1.406	1.5089	1.3546	1.491	1.3523	1.4746	1.3032
24		.9602		.9774	.9745	.9745	1.1145
Max	1.7814	2.2708	2.0405	1.6956	2.4366	2.0567	1.6356
Min	1.406	.9602	1.3546	.9774	.9745	.9745	1.1145
Avg	1.6185	1.4901	1.6976	1.4081	1.6317	1.5214	1.3157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 204 / 11 KV. TALE PIMPALGAON SINGLE PHASING
FEEDER Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.5775		1.4575			1.5089
4		1.6804		1.6289			1.6461
6		1.8399		1.7072			1.9719
7	2.2211		2.0957	2.0081	2.1714	2.0622	
8	2.4034	2.4249	2.2542	2.1559	2.42	2.2542	
9	2.4697	2.304	2.2542	2.3703	2.3537	2.3205	2.34
10		.2915		.443		.4115	.4973
11	.2743	.2328	.2743		.2507	.3258	.407
12	.1543		.1715	.1448		.2229	.4372
13	.1543	.1097	.1715		.197	.1715	.3795
14	.1543	.056	.1543	.1463	.1463		.2656
15	.1543	.1448	.1543				.1423
16	.1543	.1097	.1543	.1463	.1463	.1646	.1581
17	.2058		.1715	.1463		.2543	.2374
18	.3429	.4252	.3601	.3544	.2328	.3944	
19	.4287	.4252			.443	.4458	.2743
20		.2507		.3544	.3544	.2743	.2572
21	.2915	.197	.2915	.2865	.3224	.2743	.2743
24		1.4918		1.3546	1.3523	1.2971	1.4232
Max	2.4697	2.4249	2.2542	2.3703	2.42	2.3205	2.34
Min	.1543	.056	.1543	.1448	.1463	.1646	.1423
Avg	.7238	.8476	.7090	.9803	.8659	.7767	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 206 / MAHASANGVI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2229		.3086			.2915
4		.4115		.4458			.4115
5				.5487			.6687
6		.583					
11	1.9498	1.8482	2.0729	2.2377	2.0287	2.2186	1.491
12	2.1214		2.2939	2.0454		2.2874	2.2939
13	2.3102	1.6956	2.2283		2.5232	2.3967	2.4417
14	2.17	1.5775		2.2708	2.4697	2.3348	
15	2.2024	1.6461	2.2348	2.2542		2.4247	2.1963
16	2.1538	1.6461	2.0081	2.1125	2.4034	2.4253	2.2891
17	2.1956		2.0165	2.1795		2.4874	2.2213
18	2.1445	1.6632	1.9989	1.9616	2.3537	2.0972	
19	.4801	.5316			.5138	.5316	.3258
20		.443		.4607	.443	.4115	.3086
21	.4115	.3544	.3429	.3898	.4607	.3772	.2915
24		.2058		.2229	.2149	.2149	.2229
Max	2.3102	1.8482	2.2939	2.2708	2.5232	2.4874	2.4417
Min	.4115	.2058	.3429	.2229	.2149	.2149	.2229
Avg	1.8139	.9868	1.8995	1.3414	1.4901	1.6839	1.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054008 / 33/11 KV. PATODA S/S

Feeder No / Name : 207 / 11 KV HT Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0171		.0171			.0171
4		.0171		.0343			.0343
6		.0171		.0343			.0343
7	.0373		.0373	.0343	.0373	.0373	
8	.0732	.0686	.0373	.0686	.0373	.0373	
9	.1463	.12	.056	.0171	.056	.056	.0514
10		.1372		.0739		.0686	.1543
11	.0514	.197		.0373	.056	.0514	.0526
12	.0343			.0373		.0514	.0526
13	.0857	.128			.056	.0343	.0709
14	.0171	.0732		.0189	.0373	.0343	
15	.0514	.1267		.0189		.0526	.0358
16	.2229	.128		.0189	.0373	.1402	.1734
17	.3258		.0343	.0373		.0175	.1578
18	.0343	.0373	.0343	.0187	.0373	.0343	
19	.0343	.0373			.0373		.0171
20		.0373		.0373	.0373	.0171	.0171
21	.0171	.0373	.0171	.0373	.0373	.0343	.0343
24		.0171		.0343	.0373	.0373	.0343
Max	.3258	.197	.056	.0739	.056	.1402	.1734
Min	.0171	.0171	.0171	.0171	.0373	.0171	.0171
Avg	.0870	.0748	.0361	.0339	.0420	.0469	.0625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 201 / 11 KV NAIGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2134	.2134	.1829	.2401	.2743	.2134
2	.3048	.2591	.3086	.2134	.2743	.2896	.2439
3	.3353	.3048	.3429	.2439	.2743	.3353	.3048
4	.381	.3658	.3944	.2743	.3048	.3963	.4268
5	.4572	.4572	.4572	.3048	.3658	.4572	.5487
6	.5487	.6859	.7316	.3658	.4268	.5944	.6097
7	.6097	.7926	.823	.4268	.6706	.8535	.884
8	.9145	1.0669	.9907	.5182	1.0669	1.1126	1.2193
9	1.0669	.9755	1.0974	.5792	1.0059	1.2651	1.2955
16	.3772	.4115	.2743	.4458	.4458	.3086	.4458
17	.5144	.5144	.4458	.4115	.6173	.3772	.5144
18	.6249	.7545	.6859	.6173	.823		.6001
19	.8383	.8573	.7716	.8573	.8916	.9602	.6859
20	.5792	.6516	.5487	.583		.6173	.4801
21	.4572	.4458	.4458	.4287	.4801	.4801	.463
22	.3048	.3429	.2058	.3772	.3772	.3429	.4287
23	.2915	.3086	.1715	.3429	.3086	.3086	.3944
24	.1829		.1829	.1524	.2439		.1829
Max	1.0669	1.0669	1.0974	.8573	1.0669	1.2651	1.2955
Min	.1829	.2134	.1715	.1524	.2401	.2743	.1829
Avg	.5035	.5534	.5051	.4070	.5186	.5608	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 202 / 11 KV ROHATWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4458	.463	.4801	.5144	.4801	.5487
2	.583	.4458	.4572	.5487	.5144	.5144	.6173
3	.6859	.5487	.5487	.823	.6859	.6516	.7202
4	1.0288	.9945	.8916	.9602	.9945	.9431	.9259
11	1.829	1.6461	1.768	1.7071	1.6766		1.9509
12	2.0576	1.9509	1.89	1.829	1.9814	1.9052	2.3167
13	2.0119	2.0729	2.1948	1.829	1.9814	2.0119	2.2558
14	1.829	2.0576	2.2862	1.829	1.9509	2.0729	2.1948
15	1.9662	2.1033	2.1338	1.829	1.9357	2.1338	2.0729
16	1.9662	2.0729	2.1338	1.829	2.0119	2.0729	1.9509
17	1.9509	2.0119	2.0119	1.9052	1.9814	2.0119	2.0424
18	1.89	1.9509	1.89	1.829	1.9662	1.8595	1.829
19	.9907	.9602	1.166	1.2346	1.2517	1.2346	.8573
20	.945	.9945	1.0974	1.0974	1.0631	1.0288	.8573
21	.7468	.9431	.9602	.9259	.9259	.9259	.7716
22	.6097	.6859	.7202	.7545	.7373	.823	.6859
23	.583	.5487	.583	.6859	.5316	.6173	.5144
24	.4268		.4801	.5144	.4801		.5487
Max	2.0576	2.1033	2.2862	1.9052	2.0119	2.1338	2.3167
Min	.4268	.4458	.4572	.4801	.4801	.4801	.5144
Avg	1.2583	1.3196	1.3153	1.2562	1.2880	1.3304	1.3145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054057 / 33/11 KV ROHATWADI

Feeder No / Name : 203 / 11 KV DOMRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3658	.381	.3963	.3048	.4268	.4877
2	.3353	.381	.4268	.4572	.4572	.4725	.5792
3	.4115	.4115	.4877	.5487	.4877	.5487	.6401
4	.3963	.5182	.5335	.6401	.5792	.6401	.7621
5	.4877	.6097	.6401	.823	.6097	.7621	.9145
6	.884	.7926	.8535	1.0059	.6706	.884	.945
7		1.0669	1.0669	1.0974	.945	1.1888	1.1888
8	1.0059	1.2651	1.1888	1.2955	1.2803	1.4937	1.4327
9	1.0059	1.2803	1.2955		1.2498	1.4175	1.2955
16	.2058	.1715	.1372	.1372	.1715	.1715	.1715
17	.2058	.2058	.1715		.2229	.2229	.2401
18	.3201	.3772	.3429	.2743	.3086	.3601	.2572
19	.5487	.6173	.5658	.6173	.5316	.6173	.3601
20	.3963	.4287	.4115	.4458		.4458	.2572
21	.2439	.2915	.2572	.3086	.3086	.3429	.2229
22	.1829	.2572	.2058	.2743	.2058	.2058	.2058
23	.1372	.1715	.2058	.2743	.1543	.1715	.1715
24	.3353		.3658	.381	.3201		.4268
Max	1.0059	1.2803	1.2955	1.2955	1.2803	1.4937	1.4327
Min	.1372	.1715	.1372	.1372	.1543	.1715	.1715
Avg	.4375	.5419	.5299	.5611	.5181	.6101	.5866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 201 / 11 KV. NALWANDI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.2743		
6	1.3717		1.1831	1.7147	1.0974	1.829	1.0631
8							1.8004
9		1.6194		1.9719			
20			.3921				
22		.1715					
24	.7716		.7545	.6001		1.1431	.6859
Max	1.3717	1.6194	1.1831	1.9719	1.0974	1.829	1.8004
Min	.7716	.1715	.3921	.6001	.2743	1.1431	.6859
Avg	1.0717	.8955	.7766	1.4289	.6859	1.4861	1.1831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 202 / 11 KV. DONGARKINHI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.6516		
6	.8573		.8402	.8916	.6859	.9145	.7545
8							.9602
9		1.0479		1.0631			
20			.112				
22		.1372					
24	.4801		.7545	.3429		.724	.5144
Max	.8573	1.0479	.8402	1.0631	.6859	.9145	.9602
Min	.4801	.1372	.112	.3429	.6516	.724	.5144
Avg	.6687	.5926	.5689	.7659	.6688	.8193	.7430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 203 / 11 KV. JATNANDUR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.2743		
15		2.0576				
16	2.5377					
18	2.2291	2.4006	2.4006		2.7092	2.7435
24			.4108		1.1812	.5228
Max	2.5377	2.4006	2.4006	.2743	2.7092	2.7435
Min	2.2291	2.0576	.4108	.2743	1.1812	.5228
Avg	2.3834	2.2291	1.4057	.2743	1.9452	1.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 204 / NALWANDI GAOTHAN (P)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.4801		
6			.5144	.3086	.4801	.6097	.4287
10			.5144			.5144	
14						.2743	
15			.3429				
16		.3944					
18			.4801	.2572		.3086	.3601
20			.4287				
21						.2058	
22		.3944					
24	.1372		.3772	.2058		.362	.1715
Max	.1372	.3944	.5144	.3086	.4801	.6097	.4287
Min	.1372	.3944	.3429	.2058	.4801	.2058	.1715
Avg	.1372	.3944	.4430	.2572	.4801	.3791	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054069 / 33/11 KV. DONGARKINNI S/S

Feeder No / Name : 205 / 11 kv Dongarkini

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.3086		
6			.3258	.3086	.3086	.2286	.3429
8							.4115
10			.4115			.3429	
14						.1886	
16		.3086					
18			.3086	.2058		.2058	.2743
20			.3086				
21						.1715	
22		.2743					
24	.1029		.2401	.1372		.2286	.1402
Max	.1029	.3086	.4115	.3086	.3086	.3429	.4115
Min	.1029	.2743	.2401	.1372	.3086	.1715	.1402
Avg	.1029	.2915	.3189	.2172	.3086	.2277	.2922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 201 / 11 KV. DASKHED FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187		.0187	.0187	.0187
2	.0187	.0187	.0187		.0187	.0187	.0187
3	.0187	.0187	.0187		.0187	.0187	.0187
4	.0187	.0187	.0187		.0187	.0187	.0187
5	.0187	.0187	.0187		.0187	.0187	.0747
6	.0187	.0187			.0187	.0187	.0187
7	.0187	.0187	.0187	.0187	.0187	.0187	.0187
8	.0187	.0187	.0187	.0187	.0187	.0187	.0187
9	.0187		.0187	.0187	.0187	.0187	.0187
10	.0187		.0187	.0187	.0187	.0187	.0187
11	.3906		.4062	.3161	.3734		.4054
12	.4999	.5121	.5312	.4321	.4481	.4115	.5155
13	.506	.5281		.3681	.4801	.4268	.5182
14	.5121	.5281	.503	.4321	.5121	.4725	.5668
15	.5344	.5601	.381	.4372	.5121	.442	.5344
16	.5506	.5441	.5851	.421	.4481		
17	.5182	.5441	.4725	.4049		.4268	.4696
18	.4641	.4641	.3048	.4372	.3841	.3963	.3887
19	.0187	.0187	.0187	.0187		.0179	.0187
20	.0187	.0187	.0187	.0187	.0187		.0187
21	.0187	.0187	.0187	.0187	.0187		.0187
22	.0187	.0187	.0187	.0187	.0187		.0187
23	.0187	.0187	.0187	.0187	.0187		.0187
24		.0187	.0187		.0187	.0187	
Max	.5506	.5601	.5851	.4372	.5121	.4725	.5668
Min	.0187	.0187	.0187	.0187	.0187	.0179	.0187
Avg	.1851	.1877	.1575	.201	.1563	.1555	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 203 / Pachangri Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4531	.5624	.6401		.703	.7611	.6874
2	.7116	.703	.7202		.7499	.8162	.7499
3	.8539	.8124	.8002		.7811	.8802	.7811
4	1.0279	.9061	.9602		.8436	.9602	.8436
5	1.1248	.9842	1.1363		.8749	.9602	.9217
6	1.2186	1.2342	1.2803		1.1873	1.0402	1.0155
7	1.3123	1.4842	1.3603	1.5546	1.4373	1.3279	1.2029
8	1.531	1.6716	1.8747	1.5752	1.6404	1.4842	1.531
9	1.7497	1.9044	1.8595	1.5546	1.7604	1.6004	1.5466
10	1.5779	1.6804	1.5242	1.5089	1.7124	1.6804	1.2186
Max	1.7497	1.9044	1.8747	1.5752	1.7604	1.6804	1.5466
Min	.4531	.5624	.6401	1.5089	.703	.7611	.6874
Avg	1.1561	1.1943	1.2156	1.5483	1.1690	1.1511	1.0498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 204 / Pachangri Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0953	.0934		.0762	.112	.0953
2	.0762	.0953	.0934		.0953	.112	.0381
3	.0762	.1143	.0934		.1143	.112	.1334
4	.0953	.1524	.0934		.1524	.1307	.2286
5	.2286	.2286	.1307		.2286	.1494	.3429
6	.3429	.3429	.1494		.3239	.2801	.4191
7	.4382	.4572	.3734		.4572	.4108	.5335
8	.4954	.4382	.4108	.4572	.4191	.4668	.4954
9	.2667	.3361	.4763	.362	.3734	.4108	.381
10	.2286	.2427	.2286	.3048	.2614	.3361	.2667
11	.1524	.1494	.1905	.1715	.1867	.2241	.3239
12	.1143		.1524	.1143	.1494	.1867	.362
13	.0953	.1267		.0953	.1307	.1867	.3048
14	.0953	.1307	.0953	.0953	.1307	.1494	.2667
15	.0953	.1307		.0953	.1307	.1494	.2096
16		.1494		.0953	.1307	.168	.1905
17	.1143	.1494		.1143		.1307	.2286
18	.1715	.2801	.2858	.1905	.2801	.2241	.2286
19	.2667	.3734	.4382	.3429	.2614	.3734	.3048
20	.3048	.2801	.3048	.2667	.2241		.2667
21	.2096	.168	.1524	.1334	.1867		.1715
22	.1524	.1307		.0953	.1307		.1334
23	.1143	.1307	.1143	.0953	.112		.1143
24		.0953	.112		.0762	.112	
Max	.4954	.4572	.4763	.4572	.4572	.4668	.5335
Min	.0572	.0953	.0934	.0953	.0762	.112	.0381
Avg	.1905	.2086	.2099	.1893	.2014	.2213	.2626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 205 / Vaidyakini Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.7654	1.6766	1.9204	1.749	1.5242		2.0081
12	2.7808		.7926	3.0121	1.9814	2.4082	2.8502
13	3.1903	2.6673		2.915	2.7206		3.0121
14	2.8826	2.713		2.672	2.8902	2.5301	3.1539
15	2.915	2.7435	1.9662	2.5911	2.8121	2.4691	2.7206
16	2.9312	2.713	2.7282	2.4615	2.4996	2.3777	2.5587
17	2.753	2.6673	2.7892	2.5263		2.3777	2.4615
18	2.4777	2.1338	2.0881	2.1862	2.1338	2.0729	2.0729
Max	3.1903	2.7435	2.7892	3.0121	2.8902	2.5301	3.1539
Min	1.7654	1.6766	.7926	1.749	1.5242	2.0729	2.0081
Avg	2.712	2.4735	2.0475	2.5142	2.3660	2.3726	2.6048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054096 / 33/11 KV. DASKHED S/S

Feeder No / Name : 206 / Vaidyakini Gav

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0354	.0457		.0532	.0543	.0532
2	.0532	.0532	.0457		.0532	.0543	.0532
3	.0532	.0709	.0457		.0709	.0543	.0709
4	.0709	.0709	.0457		.0709	.0724	.0709
5	.0886	.0709	.061		.0886	.0724	.1063
6	.124	.1063	.0762		.1063	.0905	.124
7	.1417	.124	.0914		.124	.1267	.1595
8	.1417	.1417	.061	.0543	.124	.1086	.124
9	.0886	.1086	.1086	.0724	.1086	.0543	.124
10	.0886	.1086	.1086	.0181	.1629	.0724	.1417
11	.0709	.0905	.1086	.0886	.1267	.0532	.1463
12	.0886	.0905	.0905	.0886	.0876	.0532	.1063
13	.1063	.0905	.0724	.0532	.0724	.0709	.0886
14	.1063	.0905	.0543	.0709	.0724	.1063	.0886
15	.1063	.0886	.0905	.0532	.0724	.0709	.0886
16	.0354	.0709	.0724	.0532	.0724	.0886	.0886
17	.0354	.0709	.0724	.0709		.0886	.0886
18	.0354	.0709	.112	.0886	.1086	.1063	.1063
19	.0709	.0905	.1448	.1063	.1086	.0886	.124
20	.0886	.1086	.1086	.1063	.0905		.1063
21	.0886	.0905	.0905	.0886	.0724		.0709
22	.0709	.0724		.0886	.0724		.0709
23	.0532	.0724	.0543	.0709	.0724		.0532
24		.0354	.0457		.0532	.0724	
Max	.1417	.1417	.1448	.1063	.1629	.1267	.1595
Min	.0354	.0354	.0457	.0181	.0532	.0532	.0532
Avg	.0809	.0843	.0785	.0733	.0889	.0780	.0980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 201 / Lambarwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.9665	
2		1.0174	
3		1.1022	
4		1.2209	
5		1.2717	
6		1.3056	
7	.2427	1.4074	
8		1.4074	1.543
9	.7108		
18	.181		
19	.2715		
20	.2353		
21	.1629		
22	.12		
23	.12		
24		.9431	
Max	.7108	1.4074	1.543
Min	.12	.9431	1.543
Avg	.2555	1.1825	1.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 202 / Chincholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	12-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.415	
2			.4527	
3			.5847	
4			.8573	
5			1.2003	
7		.8745		
9		.7108		
10		.5487		
11		.39		
12		.2947		
13		.2515		
14		.2601		1.7661
15	.6241	.3077		
16		.4382		
17		.4382		
18		.6268		
19		.7164		
20		.6415		
21		.4424		
22		.4287		
23		.3944		
24			.415	
Max	.6241	.8745	1.2003	1.7661
Min	.6241	.2515	.415	1.7661
Avg	.6241	.4853	.6542	1.7661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054114 / 33/11Kv Lambarwadi S/s

Feeder No / Name : 203 / Muggoan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	10-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.763	
2		.8478	
3		.8478	
4		.8987	
5		.9665	
6		1.0174	
7	.3988	1.0513	
8		1.0513	1.1022
18	.4525		
19	.543		
20	.543		
21	.3772		
22	.3429		
24		.7716	
Max	.543	1.0513	1.1022
Min	.3429	.763	1.1022
Avg	.4429	.9128	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054159 / 33/11 KV PIMPALWANDI

Feeder No / Name : 201 / PIMPALWANDI GAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3814	.407		
4		.5087			
5			.5243		
6		.9389			
7			.9389		
8		1.4582	1.153		
9					1.2289
10	1.0631	1.1869	.9503	1.1822	
12		.8139			
15	.9835	.8817			
18	1.3226	1.153			
19				1.1174	
21		.7122			
22	.6226				
23		.4409			
24		.4588			
Max	1.3226	1.4582	1.153	1.1822	1.2289
Min	.6226	.3814	.407	1.1174	1.2289
Avg	.9980	.8122	.7947	1.1498	1.2289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054159 / 33/11 KV PIMPALWANDI

Feeder No / Name : 202 / Jarewadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.2346	1.1561		
4		1.3435			
5			1.3123		
6		1.6248			
7			1.3435		
8		1.6057	1.5181		1.4251
9		1.3927			
10	1.3123			1.065	
15		1.2346			
24		.9374	1.0936		
Max	1.3123	1.6248	1.5181	1.065	1.4251
Min	1.3123	.9374	1.0936	1.065	1.4251
Avg	1.3123	1.3390	1.2847	1.065	1.4251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 201 / 11KV TAGARA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543					
5	.1886					
7					.3772	
8	.3086		.3772		.4239	
9	.2401			.3429	.407	
13		1.2346				
18		.1715		.2572		
19		.2401		.2915		
20		.2058				
21		.1886	.1886	.1715		.12
24	.12				.1174	
Max	.3086	1.2346	.3772	.3429	.4239	.12
Min	.12	.1715	.1886	.1715	.1174	.12
Avg	.2023	.4081	.2829	.2658	.3314	.12

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 202 / GARMATHA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831			
5	1.406			
7				1.9033
8	1.8861	2.2291		2.0348
9	1.7833		1.4918	1.8821
24	1.1145			.9556
Max	1.8861	2.2291	1.4918	2.0348
Min	1.1145	2.2291	1.4918	.9556
Avg	1.4746	2.2291	1.4918	1.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

PATODA (R) S/DN[416] BU 2526

Substation No/ Name :- 054163 / 33/11 KV JAWALAGIRI

Feeder No / Name : 203 / NIRGUDI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429				
5	.8573				
11	1.2003		.9431		.8916
12	1.3375		1.0974	1.1145	1.2003
13	1.406		1.1145		1.2346
14				1.1317	1.2003
15		1.3546	1.0631		1.1488
16		1.3203	1.0631	1.166	1.0802
17		1.2689		1.0974	1.2346
18		1.2174		1.0288	
19		.7202		.9088	
20		.6687			
21		.6173	.6516	.583	.5144
23				.285	
24	.3086				
Max	1.406	1.3546	1.1145	1.166	1.2346
Min	.3086	.6173	.6516	.285	.5144
Avg	.9088	1.0239	.9888	.9144	1.0631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 201 / PIMPALNER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4487		.3772	1.0071	.3715		1.2336
2	.6385			1.0803	.4268	.6078	1.3027
3	.7026		.669	1.1869	.4999		1.4053
4	.802			1.2901	.644	1.0005	1.5041
5	.9127		.8221	1.3626	.7956		1.6056
6	.9934			1.3982	.919	1.4035	1.6297
7	1.1608		1.1336	1.4526	1.451		1.5656
8	1.1971		1.5909	1.473	1.6692	1.6181	1.7052
9	1.329		1.4186	1.065		1.6692	1.7198
10	.4422			.5249	.5618	.4845	
11			.3039	.3405	.3219	.3405	
12	.2846	.3226	.2662		.1886	.2657	.5313
13	.2277	.2464	.1901	.1327	.1513	.2454	.4929
14	.1901		.171	.2062		.1899	.3416
15	.1703	.1518	.151	.2247		.1898	.3033
16	.171	.2077		.2077	.1327	.2089	.2662
17	.1898	.2275	.2273	.2574	.2089	.1884	.2852
18	.2846	.3576	.415	.3969	.2467	.4154	.455
19	.114	.8925	.8436	.7095		.8069	.6722
20	.3772	.7538	.6866	.5841	.7059	.668	.5004
21	.2627	.5453	.5057	.4434	.4923	.5132	.422
22	.1483	.3776	.4134	.3877	.3673	.4439	.373
23		.3323	.3357	.2942	.3316	.3345	.3368
24	.3705		.2985	.8748	.2668	.3935	1.0938
Max	1.329	.8925	1.5909	1.473	1.6692	1.6692	1.7198
Min	.114	.1518	.151	.1327	.1327	.1884	.2662
Avg	.5190	.4014	.5694	.7348	.5376	.5994	.8975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054051 / 33 KV PIMPLNER

Feeder No / Name : 202 / 11 KV GOMALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4732		.423	.5752	.4399		.6091
2	.507			.5752	.5075	.5414	.6429
3	.7098		.5414	.6091	.5752		1.0997
4	.7444			.7106	.7106	.6429	1.1843
5	.8797		.7106	.8121	1.0151		1.2858
6	1.0151			.8797	1.2181	.6936	1.3873
7	.9474		.9813	1.0658	.9136		1.4888
8	.8628		.9982	.9474	.6767	.7613	.9474
9	.7106		.6091	.6429		.6767	.7444
10						.5075	.7106
11	2.1655		2.1655	2.3685	2.6392	2.6223	2.71
12		2.1655	2.8761	2.8423	2.7238	3.316	
13	2.7069	2.4024	3.1468	2.9776	3.1637	3.2145	3.5568
14	2.7915	2.7577	2.7238	2.7069	2.9268	3.2483	3.1164
15	3.0114	2.7407	2.9099	2.1655	3.2483	2.893	3.0487
16	2.9776	2.5687	2.7069	2.5716	2.8592	3.1129	2.9776
17		2.6701	2.4701	1.3535		2.5208	2.1655
18	1.8948	2.518	2.267	2.3009	2.6223	2.4531	
19	1.0828	1.1153	1.0997	1.0151		1.1166	.8797
20	1.0828	.9136	.829	.8121	.8967	.9136	.7114
21	.7106	.6767	.6767	.7106	.6767	.7782	.6775
22	.5414	.5583	.6091	.5752	.4906	.5414	.5414
23		.4906	.5414	.4737	.4737	.4568	.4399
24	.4394		.406	.5583	.406	.3722	.5245
Max	3.0114	2.7577	3.1468	2.9776	3.2483	3.316	3.5568
Min	.4394	.4906	.406	.4737	.406	.3722	.4399
Avg	1.3127	1.7981	1.4846	1.3152	1.4592	1.5692	1.4295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054054 / 33 KV KHALAPURI

Feeder No / Name : 201 / Khalapuri Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	09-JAN-18	10-JAN-18	11-JAN-18	12-JAN-18	13-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6516	.9907	1.1145	1.1218	1.046	
2	.9431	.7202	1.0364	1.0669	1.2269	1.1488	
3	1.1145	.9431	1.2346	1.286	1.2971	1.286	
4	1.286	1.0974	1.3717	1.3717	1.4022	1.3717	
5	1.6461	1.3032	1.5089	1.3413	1.5424	1.2955	1.9719
6	1.8519	1.3717	1.8176	1.8861	1.6827	1.448	2.1434
7	1.989	2.0576		2.2634	2.0683	2.2436	2.3491
8	2.1948	2.0919		2.5606	2.4364	2.7168	2.6749
9	2.332	2.1948		2.6116	2.4348	2.7168	2.4863
10	.5144	.4801		.4382	.463	.5258	.5182
11	.2401	.2401		.298	.3086	.333	.3772
12		.1715		.2629	.2229	.2454	.3429
13	.1715	.1372		.1753	.1715	.2103	.3086
14	.1715	.1543	.2134	.1928	.1715	.2279	.2401
15	.1372	.1715	.2134	.1753	.1715	.2279	.2058
16	.1715	.1372	.2286	.1402	.2229	.1715	
17	.2743	.1981	.2439	.2279	.2572		.1981
18	.5144	.3963	.3506	.4557	.3353		.2401
19	.4801	.5487	.5182	.5434	.4725		.4287
20	.4458	.381	.442	.4557	.4115		.3601
21	.3429	.2439	.2743	.3856	.3772		.3086
22	.3086	.2286	.2439	.3155	.2743		.2572
23	.2743	.2134	.2591	.2629	.2401		.2401
24	.4115	.3772	.9297	1.0288	1.0867	.8535	
Max	2.332	2.1948	1.8176	2.6116	2.4364	2.7168	2.6749
Min	.1372	.1372	.2134	.1402	.1715	.1715	.1981
Avg	.8044	.6879	.6986	.8692	.8500	1.0629	.8695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054054 / 33 KV KHALAPURI

Feeder No / Name : 202 / 11 KV KHALAPUR(GAO)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-JAN-18	11-JAN-18
HR	Load (MW)	Load (MW)
8	.3429	
10		.2229
11		.1543
13		.1543
14		.0857
15		.0857
16		.0857
Max	.3429	.2229
Min	.3429	.0857
Avg	.3429	.1314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 201 / 11 KV TINTARWANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	11-JAN-18	12-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			1.1181	
10	1.0296	.891	1.0657	.8037
11	.9075			.8735
12	.733	.5241		.9609
13	.8726	.8561		1.0319
14	.9075	.9434		1.1193
15	.9424	.8561		1.0319
16	.89			.9969
17	.9947			1.1368
18	1.1344	.9434		1.1019
19		1.0657		.7521
20		.8561		.5947
21		.6639		
22		.5416		
Max	1.1344	1.0657	1.1181	1.1368
Min	.733	.5241	1.0657	.5947
Avg	.9346	.8141	1.0919	.9458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 202 / Anandwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	11-JAN-18	12-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			2.364	
10	.3537	.3697	.3856	.3342
11	.2526			.4344
12	.1516	.1344		.3509
13	.1853	.1682		.3175
14	.2189	.1851		.2673
15		.1682		.2676
16	.1853			.2676
17	.4547			.2342
18	.2526	.2692		.2509
19		.4206		.3178
20		.1514		.2676
21		.1514		
22		.2523		
Max	.4547	.4206	2.364	.4344
Min	.1516	.1344	.3856	.2342
Avg	.2568	.2271	1.3748	.3009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-18 and 14-JAN-18

LATUR ZONE, LATUR[068]

BEED CIRCLE[617]

BEED DIVSION[251]

SHIRUR(KASAR) S/DN.[802] BU 4802

Substation No/ Name :- 054128 / 33 KV TINTARWANI

Feeder No / Name : 203 / Matori Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-18	11-JAN-18	12-JAN-18	14-JAN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.2873	
10	.2189	.3207	.2197	.2028
11	.9421			.8281
12	1.2785	.9284		1.3688
13	1.6991	1.4854		1.4702
14	1.6318	1.3335		1.5209
15	1.5814	1.1478		1.4348
16	1.5645			1.2322
17	1.3627			1.2322
18	1.1944	1.0297		.979
19		.1519		.1688
20		.1519		.1688
21		.1519		
22		.1182		
Max	1.6991	1.4854	.2873	1.5209
Min	.2189	.1182	.2197	.1688
Avg	1.2748	.6819	.2535	.9642