

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 201 / 11 KV LOHARISAWANGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.1147	.1147	.081	.1147	.1134	.0972
2	.0972	.1147	.1147	.081	.1147	.1134	.0972
3	.0972	.1147	.1147	.081	.1147	.1134	.0972
4	.0972	.1147	.0655	.081	.1147	.1134	.0972
5	.0972	.1147	.1147	.081	.1147	.1134	.0972
6	.0972	.1147	.1147	.081	.1311	.1134	.0972
7	.0972	.1311	.1311	.1134	.1311	.1296	.0972
8	.1134	.1311	.1311	.1134	.1311	.1457	.1134
9	.2915	.2949	.3277	.2591	.2949	.2949	.2429
10	.3563	.3605	.3605	.2915	.3277	.3441	.2591
11	.3932	.3605	.3563	.3277	.3277	.2915	.3277
12	.3932	.4588	.3563	.3605	.3277	.3239	.2949
13	.3605	.3605	.3239	.3277	.2949	.3239	.2949
14	.3277	.3441	.3887	.2949	.2949	.3239	.3277
15	.3605	.2949	.3887	.2949	.2949	.2915	.3605
16	.3605	.3605	.3239	.3277	.2949	.2915	.3605
17	.1966	.1147	.0648	.0983	.1147	.081	.0983
18	.2294	.1475	.1134	.1638	.1296	.1943	.1966
19	.2458	.2294	.1943	.2294	.2267	.2105	.2458
20	.2458	.2294	.2105	.2294	.2267	.2105	.2458
21	.213	.2294	.2105	.1966	.1943	.1943	.2294
22	.1638	.1638	.1619	.1638	.1619	.1781	.1638
23	.1311	.1147	.0972	.1311	.1296	.1134	.1147
24	.1147		.1147	.1147		.1134	.0972
Max	.3932	.4588	.3887	.3605	.3277	.3441	.3605
Min	.0972	.1147	.0648	.081	.1147	.081	.0972
Avg	.2157	.218	.2039	.1885	.2003	.1974	.1939

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 202 / 11 KV LOHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0655	.0655	.081	.0655	.0648	.081
2	.0648	.0655	.0655	.081	.0655	.0648	.081
3	.0648	.0655	.0655	.081	.0655	.0648	.081
4	.0648	.0655	.0655	.081	.0655	.0648	.081
5	.0648	.0655	.0655	.081	.0655	.0648	.081
6	.0648	.0819	.0819	.081	.0819	.0648	.081
7	.081	.0819	.0819	.0972	.0819	.081	.081
8	.0972	.0983	.0819	.0648	.0983	.081	.0972
9	.5344	.5243	.5898	.5344	.5735	.5735	.5668
10	.583	.5735	.6718	.5344	.4915	.6062	.502
11	.5898	.5898	.6316	.6226	.6226	.5992	.5243
12	.5898	.6226	.583	.5571	.639	.5992	.4915
13	.6062	.6226	.6316	.6062	.5898	.5668	.4096
14	.5571	.5571	.6478	.5571	.5898	.583	.426
15	.5898	.6062	.664	.5079	.5571	.6154	.3768
16	.6554	.5898	.5992	.5243	.5898	.664	.426
17	.0328	.0492	.0324	.0328	.0324	.0486	.0328
18	.0492	.0655	.081	.0655	.0648	.0972	.1147
19	.1638	.1638	.1781	.1475	.1619	.1457	.1802
20	.1638	.1638	.1457	.1638	.1619	.1457	.1802
21		.1311	.1457	.1475	.1296	.1457	.1475
22	.1311	.1147	.1134	.1147	.1134	.1134	.1147
23	.0983	.0983	.0972	.0819	.0972	.081	.0983
24	.0819		.0655	.0819	.0819	.081	.081
Max	.6554	.6226	.6718	.6226	.639	.664	.5668
Min	.0328	.0492	.0324	.0328	.0324	.0486	.0328
Avg	.2606	.2636	.2688	.2470	.2536	.2590	.2224

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 203 / 11 KV KHARALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0819	.0819	.081	.0819	.081	.081
2	.081	.0819	.0819	.081	.0819	.081	.081
3	.081	.0819	.0819	.081	.0819	.081	.081
4	.081	.0819	.0819	.081	.0819	.081	.081
5	.081	.0819	.0819	.081	.0819	.081	.081
6	.081	.0819	.0983	.081	.0983	.081	.081
7	.0972	.0983	.0983	.1134	.0983	.0972	.0972
8	.0972	.0983	.1147	.0972	.1147	.0972	.081
9	.2915	.3277	.3932	.3887	.3277	.3605	.2591
10	.3239	.3932	.3605	.5182	.426	.4588	.3887
11	.3605	.4588	.4858	.4588	.4424	.3887	.4096
12	.426	.426	.6478	.4588	.4588	.3239	.4588
13	.4588	.4915	.3563	.426	.4588	.3887	.4096
14	.4588	.4588	.3563	.3932	.4588	.3563	.4588
15	.4588	.4588	.3563	.426	.4588	.2915	.4588
16	.426	.4588	.421	.426	.4096	.2915	.426
17	.0655	.0655	.0486	.0655	.081	.0486	.0492
18	.1311	.0983	.0648	.0655	.0972	.1619	.1311
19	.1638	.1638	.1943	.1638	.1619	.1781	.1802
20	.1638	.1638	.1943	.1638	.1943	.1781	.1475
21	.1638	.1638	.1781	.1475	.1619	.1781	.1311
22	.1311	.1147	.1457	.1147	.1296	.1619	.1147
23	.1147	.0819	.081	.0819	.0972	.0972	.0983
24	.0819		.0819	.0819		.0972	.0972
Max	.4588	.4915	.6478	.5182	.4588	.4588	.4588
Min	.0655	.0655	.0486	.0655	.081	.0486	.0492
Avg	.2042	.2180	.2119	.2115	.2211	.1934	.2035

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 204 / 11 KV KHARASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0328	.0328	.0324	.0328	.0324	.0324
2	.0324	.0328	.0328	.0324	.0328	.0324	.0324
3	.0324	.0328	.0328	.0324	.0328	.0324	.0324
4	.0324	.0328	.0328	.0324	.0328	.0324	.0324
5	.0324	.0328	.0328	.0324	.0328	.0324	.0324
6	.0324	.0328	.0328	.0324	.0328	.0324	.0324
7	.0324	.0328	.0328	.0324	.0328	.0324	.0324
8	.0324	.0328	.0328	.0324	.0328	.0324	.0324
9	.2591	.2294	.2949	.2915	.2622	.3277	.2915
10	.2915	.2622	.3605	.3239	.2949	.3277	.2915
11	.2949	.2949	.3239	.2949	.3277	.2591	.2949
12	.2622	.2949	.3563	.3277	.3277	.2753	.2949
13	.2622	.2949	.3887	.3277	.3277	.3239	.2949
14	.2949	.3277	.3887	.2949	.3441	.3239	.2949
15	.2622	.3605	.3887	.2949	.3277	.2915	.3277
16	.2622	.3277	.3239	.2949	.3277	.2915	.3605
17	.0328	.0328	.0162	.0328	.0324	.0162	.0328
18	.0328	.0328	.0324	.0328	.0324	.0486	.0328
19	.0492	.0655	.0486	.0492	.0486	.0648	.0655
20	.0492	.0655	.0648	.0655	.0648	.0648	.0655
21	.0492	.0655	.0486	.0655	.0486	.0486	.0655
22	.0492	.0492	.0324	.0492	.0486	.0324	.0492
23	.0328	.0492	.0324	.0492	.0324	.0324	.0328
24	.0328		.0328	.0328	.0328	.0324	.0324
Max	.2949	.3605	.3887	.3277	.3441	.3277	.3605
Min	.0324	.0328	.0162	.0324	.0324	.0162	.0324
Avg	.1157	.1311	.1415	.1286	.1309	.1258	.1286



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 205 / 11 KV Jatlapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.213	.213	.0486	.0492	.0324	.0486
2	.0324	.1966	.213	.0486	.0492	.0324	.0486
3	.0324	.1638	.1966	.0486	.0492	.0324	.0486
4	.0324	.1311	.1966	.0486	.0492	.0324	.0486
5	.0324	.0492	.1638	.0486	.0492	.0324	.0486
6	.0324	.0492	.1966	.0486	.0492	.0324	.0486
7	.0324	.0492	.0492	.0486	.0492	.081	.0486
8	.0324	.0492	.0492	.0486	.0492	.0324	.0486
9	.2915	.3768	.3277	.3725	.3441	.6062	.5668
10	.3077	.3932	.3605	.3725	.3768	.639	.583
11	.3441	.6062	.3887	.4096	.6062	.6154	.6226
12	.3932	.6226	.4372	.3932	.6226	.2915	.6226
13	.4424	.6226	.4372	.4096	.5735	.0648	.6554
14	.4096	.3441	.4372	.5898	.6226	.2915	.5898
15	.4096	.5571	.4049	.6062	.5407	.3239	.5735
16	.3768	.5571	.4424	.6062	.5571	.2915	.6062
17	.213	.213	.0486	.213	.2105	.2267	.213
18	.2294	.0983	.0486	.2294	.1943	.0972	.2294
19	.213	.0492	.0486	.2458	.2267	.0972	.2294
20	.2458	.0492	.0486	.2458	.2429	.0486	.2294
21	.2458	.0655	.0486	.2458	.2267	.0486	.2294
22	.2294	.0655	.0486	.2294	.0486	.0486	.2294
23	.213	.213	.0486	.213	.0324	.0486	.2294
24	.2294		.213	.0492		.0324	.0486
Max	.4424	.6226	.4424	.6062	.6226	.639	.6554
Min	.0324	.0492	.0486	.0486	.0324	.0324	.0486
Avg	.2105	.2493	.2111	.2425	.2530	.1700	.2853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 201 / 11KV CHANDANIBURDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1715	.1696	.1423	.16	.192	.1696
2	.16	.1715	.1696	.1423	.16	.16	.1696
3	.16	.1715	.1696	.1423	.16	.16	.1696
4	.16	.1715	.1696	.1423	.16	.16	.1696
5	.16	.1715	.1696	.1423	.16	.16	.1696
6	.16	.1886	.1696	.1898	.176	.16	.1696
7	.192	.1886	.1696	.2056	.16	.192	.1696
8	.16	.1543	.1357	.1581	.16	.16	.2035
9	.6401	.583	.6783	.8065	.8002	.7362	.7122
10	.7682	.7202	.9156	1.0562	.8322	.8642	.8478
11	.8322	.8139	.8223	1.0202	.8962		.78
12	.9259	.9496	.9646	1.0242	.8962	.7122	.8478
13	.9088	.8817	.9646	1.0242	.8962	.1696	.8478
14	.9259	.9156	.9488	.8642	.8642	.1526	.4748
15	.9602	.9156	.8539	.8962	.8642	.9835	.7461
16	.9602	.9156	.9172	.9282	.8962	1.0174	.78
17	.1029	.1357	.1423	.1423	.16	.78	.1357
18	.12	.2035		.192	.2241		.2374
19	.3772	.373	.3795	.3521	.3521	.373	.373
20	.3944	.373	.3795	.3521	.3841	.373	.373
21	.3429	.3391	.3479	.3201	.3521	.3391	.373
22	.2743	.2374	.2372	.2372	.2561	.2713	.2713
23	.2058	.2035	.1739	.1898	.192	.2374	.2374
24	.16	.1715	.1696	.1581	.16	.192	.1696
Max	.9602	.9496	.9646	1.0562	.8962	1.0174	.8478
Min	.1029	.1357	.1357	.1423	.16	.1526	.1357
Avg	.4255	.4217	.4443	.4512	.4301	.3884	.3999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 202 / 11 KV AMBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0926	.1029	.1017	.0972	.081	.1067	.1017
2	.0926	.1029	.1017	.0972	.081	.1067	.1017
3	.0926	.1029	.1017	.0972	.081	.1067	.1017
4	.0926	.1029	.1017	.0972	.081	.1067	.1017
5	.0926	.1029	.1017	.0972	.081	.0914	.1017
6	.0926	.1029	.1017	.0972	.0972		.1017
7	.0926	.1029	.1017	.081	.0972	.0914	.1017
8	.0772	.1029	.0678	.081	.0972	.0762	.1017
9	.1698	.2058	.2035	.1457	.1943	.1829	.1696
10	.2006	.2572	.2713	.2105	.208	.2134	.2035
11	.2006	.2883	.2267	.2429	.1781	.2713	.2204
12	.2743	.3052	.2429	.2753	.2134	.1696	.407
13	.2915	.3561	.2429	.3077	.2439	.0678	.3052
14	.2743	.2713	.1943	.3239	.2896	.0678	.2713
15	.2743	.2374	.2267	.3077	.2896	.2713	.2204
16	.2572	.2713	.2267	.2753	.2743	.2543	.1696
17	.0857	.0678	.0648	.0648	.064	.1865	.0678
18	.1029	.1357		.0972	.0914		.1357
19	.2401	.2374	.2105	.2267	.1981	.2374	.2374
20	.2401	.2374	.2267	.2105	.2134	.2374	.2374
21	.2229	.2035	.1943	.2105	.1981	.2035	.2374
22	.1715	.1526	.1457	.1619	.1524	.1865	.1696
23	.12	.1357	.1134	.1134	.1219	.1696	.1696
24	.0926	.1029	.1017	.1134	.1134	.1067	.1187
Max	.2915	.3561	.2713	.3239	.2896	.2713	.407
Min	.0772	.0678	.0648	.0648	.064	.0678	.0678
Avg	.1643	.1787	.1596	.1680	.1559	.1596	.1731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 203 / Rampuri Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0343	.0339	.0312	.0312	.064	.0339
2	.0316	.0343	.0339	.0324	.0312	.032	.0339
3	.0316	.0343	.0339	.0312	.0312	.032	.0339
4	.0316	.0343	.0339	.0312	.0312	.032	.0339
5	.0316	.0343	.0339	.0312	.0312	.032	.0339
6	.0316	.0343	.0339	.0312	.0312	.032	.0339
7	.0316	.0514	.0339	.0469	.0312	.032	
8	.0316	.0343	.0339	.0312	.0312	.032	.0339
9	.4428	.4458	.407	.3593	.3437	.4161	.4409
10	.506	.4801	.4748	.4428	.4999	.5121	.4409
11	.506	.407	.4687	.4374	.5155	.5765	.4748
12	.5658	.5087	.5312	.4843	.6081	.407	.407
13	.4801	.5765	.5312	.5155	.6401	.0339	.4748
14	.5144	.5765	.4687	.5312	.6081	.0339	.4748
15	.5316	.5765	.4843	.5624	.5441	.6104	.5426
16	.4801	.5765	.5312	.5468	.5761	.6443	.4409
17	.0343	.0339	.0312	.0312	.032	.5426	.0339
18	.0686	.0509		.0312	.032		.0509
19	.1029	.0848	.0937	.0781	.096	.0678	.0848
20	.1029	.0848	.0937	.0781	.096	.0848	.0848
21	.0857	.0848	.0781	.0781	.096	.0678	.0848
22	.0686	.0678	.0625	.0625	.064	.0678	.0678
23	.0514	.0509	.0469	.0469	.064	.0678	.0678
24	.0316	.0343	.0339	.0312	.0312	.064	.0509
Max	.5658	.5765	.5312	.5624	.6401	.6443	.5426
Min	.0316	.0339	.0312	.0312	.0312	.032	.0339
Avg	.2011	.2055	.2004	.1910	.2124	.1950	.1939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 201 / 11KV Thadipawani

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	06-FEB-18
HR	Load (MW)
17	.3688
18	.4024
19	.4359
Max	.4359
Min	.3688
Avg	.4024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 202 / 11 KV WADHONA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.1463	.2743	.2713	.2561	.2401	.2683
2	.2374	.1463	.2743	.2713	.2561	.2401	.2683
3	.2035	.1463	.2743	.2401	.2561	.2401	.2683
4		.1463	.2743	.2401	.2561	.2401	.2683
5		.1463	.2743	.2401	.2561	.2572	.2683
6		.1463	.2743	.2401	.2481	.2743	.3018
7		.2481	.3258	.2713	.3429	.3429	.3353
8		.2835	.3429	.3052	.3856	.3772	.3688
9		.5487	1.0974	.9282	.9389	1.166	1.1736
10	.4359	.6859	1.2071	1.1401	1.1498	1.1336	1.2071
11	.7042	.7202	1.2266	1.278	1.2308	1.166	1.2407
12	.7377	.7202	1.2955	1.3413	1.2631	1.2631	1.1934
13	.7377	.7545	1.2929	1.2407	1.2955	1.3279	1.1736
14	.7042	.6859	1.2407	1.2071	1.1498	1.2955	1.1401
15	.6443	.6516	1.1934	1.2071	1.2308	1.1984	1.073
16	.6104	.6173	1.1603	1.2071	1.2631	1.1336	1.0395
17	.1097	.1715	.1696	.2481	.1943	.3688	.2374
18	.1417	.2743	.1696	.2926	.3086	.4024	.2713
19	.1463		.3391	.2835	.3429	.4359	.3391
20	.1463		.407	.3086	.4115	.4024	.373
21	.1463	.3429	.4024	.3292	.3429	.3688	.373
22	.1463	.2572	.2713	.3292	.2743	.3018	.3052
23		.2743	.2713	.2926	.2743	.9054	.2713
24	.2374	.1463	.2743	.2713	.2926	.2743	.2683
Max	.7377	.7545	1.2955	1.3413	1.2955	1.3279	1.2407
Min	.1097	.1463	.1696	.2401	.1943	.2401	.2374
Avg	.3722	.3755	.5972	.5827	.5925	.6398	.5845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 203 / 11KV Lohari-Sawanga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.2561	.2058	.2713	.2926	.2058	.2683
2	.2713	.2195	.2058	.2713	.2926	.2058	.2683
3	.2374	.2195	.2058	.2401	.2835	.2058	.2683
4	.2374	.2126	.2058	.2401	.2835	.2058	.2683
5	.2374	.1829	.2058	.2401	.2835	.2058	.2683
6	.2035	.1463	.1886	.2103	.2561	.2058	.8718
7	.9054	.6783	.823	.6706	.763	.823	
8	.9389	.823	1.0631	.9282	1.0059	1.0974	1.073
9	.9724	1.073	1.1317	1.094	1.2071	1.4403	1.3077
10	1.073	1.0562	1.073	1.1065	1.166	1.3279	1.2597
11	1.0395	1.0562	1.0608	1.0059	1.166	1.3279	1.2407
12	1.0395	.9945	1.0631	.9724	1.2955	1.2955	1.1934
13	1.0059	.8916	1.0277	.9724	1.3441	1.2955	1.1401
14	.9724	.8916	1.0059	.9389	1.1984	1.2631	1.073
15	1.0059	1.166	1.5912	1.5089	1.1336	1.2308	1.1065
16	1.643	1.3927	1.7368	1.6095	1.1012	1.166	1.1401
17	1.3413	1.2955	1.6244	1.3413	1.0688	1.1736	1.0395
18	1.3077	1.2003	1.4419	1.2071	1.0364	1.0059	.9054
19	1.1736	.3601	1.1401	1.073	1.1145	1.073	.6706
20	1.1401	.4115	1.073	1.0059	1.1317	1.0395	.6371
21	1.073	1.0288	.9724	.9835	1.0288	1.0059	.7377
22	1.0059	1.0288	.9389	.9259	.9945	.9724	.8048
23	.3292	.2572	.2713	.2835	.2401	.9054	.3052
24	.2713	.2835	.2229	.2713	.2926	.2229	.8718
Max	1.643	1.3927	1.7368	1.6095	1.3441	1.4403	1.3077
Min	.2035	.1463	.1886	.2103	.2401	.2058	.2683
Avg	.8207	.7136	.8533	.8072	.8325	.8709	.8139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 204 / 11KV Jalalkheda-R

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1097	.1029	.1357	.1097	.1029	.1341
2	.1357	.1097	.1029	.1029	.1097	.1029	.1341
3	.1017	.1097	.1029	.1029	.1097	.1029	.1341
4	.1017	.1097	.1029	.1029	.1097	.1029	.1341
5	.1357	.1097	.1029	.1029	.1097	.1029	.1341
6	.1017	.0732	.1029		.1097	.1029	.1174
7	.1017	.1097	.1029	.1029	.1463	.1029	.1006
8	.1017	.1097	.1029	.1029	.1417	.1029	.1006
9	.8048	1.1736	.7888	.7377	.8817	.7202	.7377
10	1.2742	1.166	.8048	.8139	.8745	.823	.7377
11	1.3748	1.2146	.8383	.8383	.8745	.8573	.7712
12	1.4582	1.2631	.9945	.8718	.8421	.9259	.7712
13	1.5424	1.3603	.9282	.9054	.8097	.9259	.8048
14	1.643	1.5364	.8383	.9602	.7773	.9259	.8048
15	1.576	1.4899	.9389	.9724	.8097	.9259	.8048
16	1.4746	1.4251	.9614	.9835	.8097		.7712
17		.0686	.1017	.1097	.0686	.1677	.1017
18		.1029	.1017	.1463	.1372	.2012	.1357
19	.1097	.2058	.1696	.1772	.2058	.2347	.1696
20	.1463	.2401	.2374	.1829	.2401	.2347	.2035
21	.1463	.2058	.2374	.1829	.2058	.1677	.2035
22	.1463	.1372	.1696	.1772	.1543	.1341	.1696
23	.1463	.1372	.1696	.1463	.1372	.1341	.1357
24	.1357	.1463	.1029	.1357	.1097	.1372	.1341
Max	1.643	1.5364	.9945	.9835	.8817	.9259	.8048
Min	.1017	.0686	.1017	.1029	.0686	.1029	.1006
Avg	.5861	.5298	.3836	.3954	.3702	.3626	.3519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 205 / 11 KV PARADSINGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
1	.2012
Max	.2012
Min	.2012
Avg	.2012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 206 / 11KV Jalalkheda-U-APDRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6371	.6516		.6443	.6443	.6516	.6706
2	.6371	.6516	.583	.6443	.6516	.6173	.6706
3	.6036	.6516	.583	.6173	.6516	.6173	.6706
4	.6104	.6516	.583	.6173	.6516	.6173	.6706
5	.5765	.6516	.583	.6173	.7202	.6173	.6706
6	.6104	.6859	.583	.6516	.7377	.6344	.6706
7	.6706	.9835	.7888	.6706	.9835	.7716	
8	.8048	1.1065	.9945	.9945	1.1065	.9945	1.1065
9	1.073	1.1401	1.3032	1.3077	1.2742	1.2003	1.1736
10	1.2742	2.332	1.3748	1.3413	1.2631	1.2308	1.2071
11	1.5089	1.2631	1.4255	1.3413	1.2955	1.2955	1.2071
12	1.576	1.2631	1.5364	1.3413	1.3927	1.3603	1.2597
13	1.576	1.2955	1.5729	1.4083	1.4413	1.4403	1.2266
14	1.576	1.2955	1.5581	1.4419	1.4251	1.4403	1.2071
15	1.576	1.2308	1.4918	1.4754	1.4575	1.4251	1.2266
16	1.576	1.166	1.4754	1.4754	1.4899	1.3927	1.2071
17	1.3413	1.0288	1.3748	1.2407	1.3375		1.1401
18	1.3077	.8573	1.3077	1.1401	1.1317	1.0059	.9389
19	1.0059	.8573	1.073	1.0059	1.0974	1.073	.9054
20	.9724	.8573	1.0059	.9724	1.0631	.9724	.8718
21	.8383	.7545	.7712	.8478	.9431	.8383	.8048
22	.8048	.6516	.7377	.78	.7545	.7042	.7377
23	.7122	.6173	.6706	.6859	.7202	.6706	.6706
24	.6371	.6516	.583	.6443	.6516	.6859	.6706
Max	1.576	2.332	1.5729	1.4754	1.4899	1.4403	1.2597
Min	.5765	.6173	.583	.6173	.6443	.6173	.6706
Avg	1.0211	.9707	1.0418	.9961	1.0369	.9677	.9385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 201 / 11 KV Datewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1852		.1524		.1524	.1677	.1372
2	.1852		.1524		.1389	.1677	.1219
3	.1852		.1372		.1355	.1677	.1219
4	.1852		.1372		.1355	.1677	.1219
5	.1852		.1524		.1355	.1677	.1219
6	.1852		.1372		.1505	.1677	.1219
7	.216		.1372		.1806	.1829	.1219
8	.2623		.1829		.2107	.2286	.1677
9	.4475				.2709	.3353	.2286
10	.4784				.4475	.3963	.3201
11	.6019			.602	.5944	.3963	.4877
12	.6481			.6321	.5944	.4115	
13	.6944			.6173	.4572	.381	.4268
14	.6327			.6249	.5335	.3658	.6249
15	.5864			.5796	.4877	.3963	.6249
16	.5556			.6171	.4877	.3963	.6249
17	.5247	.4115		.4938	.4572	.3963	.5335
18	.3241	.3353			.2591	.3353	.2134
19	.216	.2286		.2107	.1981	.1981	.1372
20	.216	.2134		.1698	.2134	.1981	.1524
21	.2006	.1829		.1505	.1981	.1677	.1524
22	.1852	.1677		.1524	.1981	.1524	.1372
23	.1852	.1524		.1355	.1981	.1524	.1219
24	.1852	.1852	.1524		.1505	.1829	.1372
Max	.6944	.4115	.1829	.6321	.5944	.4115	.6249
Min	.1852	.1524	.1372	.1355	.1355	.1524	.1219
Avg	.3446	.2346	.1490	.4155	.2911	.2617	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 203 / 11 KV Wadhona Rural

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.061		.0743	.0762	.061
2	.061	.061	.061		.0602	.0762	.061
3	.061	.061	.061		.0602	.0762	.061
4	.061	.061	.061		.061	.0762	.061
5	.061	.061	.061		.0602	.0762	.061
6	.061	.061	.061		.0617	.0762	.0762
7	.061	.061	.061		.0753	.1067	.0762
8	.1219	.0914	.1067		.1355	.1372	.1372
9	.2743	.2743	.2743		.2134	.3048	.1829
10	.3506	.3506	.3201		.3161	.3506	.2591
11	.4115	.4115	.4572	.4064	.3963	.4115	.3048
12	.4877	.442	.503	.4784	.4115	.4877	.3353
13	.5182	.4268	.503	.442	.4572	.4572	.3201
14	.5487	.4268	.5182	.4167	.4725	.4115	.3201
15	.4877	.442	.4877	.3658	.4725	.3353	.3658
16	.442	.4572	.4877	.3506	.4572	.3048	.3201
17	.4115	.3963	.3506	.3161	.3353	.2591	.2439
18	.1372	.2134	.1677		.1524	.1524	.1219
19	.0914	.1219	.1067	.1389	.1067	.1067	.0914
20	.0914	.1067	.1067	.108	.0914	.1219	.0914
21	.0914	.0762	.0914	.0914	.1067	.0914	.0914
22	.0762	.0762	.0914	.0903	.0914	.0914	.0762
23	.061	.061	***	.0762	.0762	.0762	.061
24	.0762	.061	.061	.0762	.0753	.0762	.061
Max	.5487	.4572	11.0806	.4784	.4725	.4877	.3658
Min	.061	.061	.061	.0762	.0602	.0762	.061
Avg	.2127	.2026	.6725	.2582	.2009	.1975	.1600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 401 / 33 KV Loharisawanga

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
8	.1086	.1109
16	1.9685	1.9919
24	.1132	.1132
Max	1.9685	1.9919
Min	.1086	.1109
Avg	.7301	.7387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 402 / 33 KV Bharsingi

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5947	1.8724	1.933	1.9839	2.3926	4.561	2.4177
16	5.2332	2.4966	5.3292	4.9451	3.7003	2.3405	3.7963
24	.7522	.8871	.1412	.8316	.9425	.9425	.9328
Max	5.2332	2.4966	5.3292	4.9451	3.7003	4.561	3.7963
Min	.7522	.8871	.1412	.8316	.9425	.9425	.9328
Avg	2.5267	1.7520	2.4678	2.5869	2.3451	2.6147	2.3823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 403 / 33 KV Paradsinga

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
8	.2829	.2263
16	4.1667	4.1667
24	.2829	.2829
Max	4.1667	4.1667
Min	.2829	.2263
Avg	1.5775	1.5586

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 404 / 33 KV Mowad

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	6.8501	7.9698	7.5377	5.671	6.1671	5.7813	5.5053
16	6.3375	6.5775	6.2414	6.7696	7.1056	7.0096	6.7021
24	3.3608	4.0329	3.8409	2.9287	2.4486	2.9412	3.3036
Max	6.8501	7.9698	7.5377	6.7696	7.1056	7.0096	6.7021
Min	3.3608	4.0329	3.8409	2.9287	2.4486	2.9412	3.3036
Avg	5.5161	6.1934	5.8733	5.1231	5.2404	5.2440	5.1703



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 201 / 11 KV HATLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1715	.1715	.1772	.1595	.1949	.1905
2	.1595	.1715	.1715	.1595	.1595	.1949	.1905
3	.1595	.1715	.1524	.1595	.1595	.1949	.1524
4	.1595	.1524	.1524	.1595	.1595	.1949	.1905
5	.1595	.1524	.1524	.1595	.1595	.1772	.1715
6	.1595	.1524	.1524	.1595	.1595	.1772	.1905
7	.1772	.1715	.1595	.1595	.1595	.1417	.1715
8	.1595	.1715	.1595	.1772	.1595	.1772	.1715
9	.1595	.1715	.1595	.1772	.124	.1772	.1715
10	.7973	.4763	.7796	.8328	.8505	.7973	.6478
11	.9593	.9335	.9036	.9391	.8682	.8954	.7265
12	1.1041	1.0479	1.0099	.9745	.9568	.9145	.8682
13		1.086	.9922	.9745	.9745	.9526	.8859
14		.9745	.9745	.9568	.9922	.9526	.9214
15	1.0317	.8682	.9745	.9745	.8859	.9335	
16		.9391	.9568	.9214	.8859	.9145	
17		.9036	.9214	.7619	.7796	.8383	
18		.1949	.2303	.2303	.1772	.2096	.2481
19	.3658	.3366	.3012	.3189	.3366	.3239	.2835
20	.3475	.3366	.3366	.3189	.3366	.362	.3189
21	.3109	.2858	.3012	.3189	.2658	.2858	.3189
22	.2715	.2096	.2126	.2481	.2126	.2667	.2658
23	.181	.1595	.1772	.2303	.1949	.2286	.1949
24	.1949	.1715	.1715	.1772	.1595	.1949	.1905
Max	1.1041	1.086	1.0099	.9745	.9922	.9526	.9214
Min	.1595	.1524	.1524	.1595	.124	.1417	.1524
Avg	.3693	.4337	.4448	.4444	.4282	.4458	.3558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 202 / 11 KV Chargaon (old Dorli) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	.1267	.0953	.0867	.0867	.0867	.0953
2	.0693	.1086	.0953	.0867	.0867	.0867	.0953
3	.0693	.1086	.0953	.0867	.0867	.0867	.0953
4	.0693	.1097	.0953	.0867	.0867	.0867	.0953
5	.0693	.1097	.0953	.0867	.0867	.0867	.0953
6	.0693	.0914	.0953	.0867	.0867	.0867	.0953
7	.0867	.1086	.104	.0867	.0867	.0693	.0953
8	.0693	.0905	.0693	.0867	.0693	.0693	.0953
9	.0693	.1086	.0693	.0867	.0693	.0693	.0762
10	.3121	.3258	.4161	.4334	.3814	.4508	.381
11	.4298	.4161	.5375	.5201	.5028	.5335	.3467
12	.543	.4508	.5721	.5548	.5895	.6668	.5375
13	.5611	.5028	.5721	.5548	.5895	.5716	.5721
14	.6516	.5028	.5548	.5548	.5375	.5144	.5721
15	.5973	.4681	.5201	.5201	.5375	.5335	.5375
16		.5028	.5028	.5201	.5721	.5335	.5201
17		.6068	.4681	.5375	.4681	.5525	.4681
18		.0693	.104	.0693	.104	.1143	.0867
19	.1448	.1214	.1387	.104	.1387	.1334	.104
20	.1629	.1214	.1387	.1214	.1387	.1524	.1214
21	.1267	.1143	.1214	.1214	.1214	.1334	.1214
22		.1143	.104	.104	.104	.1143	.104
23		.104	.104	.104	.104	.1143	.0867
24	.0867	.0924	.0953	.0867	.0867	.0867	.0953
Max	.6516	.6068	.5721	.5548	.5895	.6668	.5721
Min	.0693	.0693	.0693	.0693	.0693	.0693	.0762
Avg	.2241	.2281	.2402	.2369	.2384	.2472	.2289

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 204 / 11 KV Kotwalbardi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.5249	.5335	.4191	.4694	.503	.5335
2	.4694	.5249	.5335	.4191	.4694	.503	.5335
3	.4694	.5068	.5335	.4359	.4694	.503	.5335
4	.4694	.5121	.5335	.4359	.4694	.503	.5335
5	.503	.5121	.5335	.4359	.4694	.503	.5335
6	.503	.5121	.5335	.4359	.503	.503	.5335
7	.5197	.4938	.503	.4527	.503	.4862	.4954
8	.4527	.4755	.4694	.4527	.4694	.4359	.4954
9	.4527	.5359	.4694	.4694	.4191	.4527	.4954
10	.8718	.9412	.9389	.9556	1.0395	1.0898	1.0669
11	1.2308	1.1401	.9892	1.2239	1.2407	1.5242	1.1736
12	1.2894	1.2742	1.0059	1.3413	1.4251	1.6004	1.291
13	1.4784	1.4419	1.3077	1.3413	1.5089	1.5623	1.2574
14	1.4661	1.4251	1.3748	1.3413	1.3077	1.5242	1.2574
15	1.4842	1.3413	1.4083	1.3413		1.6004	1.291
16		1.4251	1.3916	1.3413	1.5257	1.6004	1.2574
17		1.1401	1.3748	1.2574	1.3748	1.5242	1.2239
18		.4694	.5365	.4694	.4359	.5144	.4862
19	.7545	.6706	.6371	.6706	.6371	.6097	.57
20	.7545	.6706	.6706	.6539	.6706	.724	.6371
21	.7545	.6097	.6036	.6203	.6036	.6859	.6371
22	.5914	.503	.4694	.5197	.5533	.6478	.5533
23	.5249	.4694	.4527	.4862	.5197	.6097	.4694
24	1.1981	.5304	.5335	.4191	.4694	.503	.5716
Max	1.4842	1.4419	1.4083	1.3413	1.5257	1.6004	1.291
Min	.4527	.4694	.4527	.4191	.4191	.4359	.4694
Avg	.7956	.7771	.7641	.7475	.7632	.8631	.7679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 402 / 33 KV Metpanjara

Outgoing(koh Feeder KV- 33 /  
INCOMING

DATE	06-FEB-18
HR	Load (MW)
22	.4001
Max	.4001
Min	.4001
Avg	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 404 / 33 KV T/F Incomer No.II

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3801	.3601	.3086	.3086	.3601	
2	.3086	.3801	.3601	.3086	.3086	.3601	
3	.3086	.3258	.3601	.3086	.3086	.3601	
4	.3086	.3258	.3086	.3086	.3086	.3601	
5	.3086	.3258	.3086	.3086	.3086	.3601	
6	.3086	.3258	.3086	.3086	.3086	.3601	
7	.3601	.3258	.3601	.3086	.3086	.3086	
8	.3086	.3292	.3086	.3086	.3086	.3086	
9	.3086		.3086	.3086	.2572	.3086	
10	1.9547	.4344	1.9547	2.0576	2.1091	2.0062	
11	2.4177	2.2119	2.5206	2.2634	2.2634		2.0062
12	2.7149	2.3663	2.7263	2.4691	2.5206		2.2634
13	2.7401	2.5206	2.6749	2.4691	2.572		2.2634
14	2.8778	2.5206	2.6235	2.4691	2.572		2.3148
15	2.9384	2.4691	2.5206	2.4177	2.572		1.3375
16		2.5206	2.4177	2.3663	2.4691		1.4403
17		2.4691	2.2634	2.2119	2.3148		1.4403
18		.3086	.4115	.3601	.3601		.3601
19	.5144	.5144	.5144	.5144	.5658		.463
20	.5144	.5144	.5658	.5144	.5658		.5144
21	.5144	.463	.463	.5144	.463		.5144
22		.4115	.3601	.4115	.4115		.4115
23	.3881	.3601	.3601	.3601	.4115		.3601
24	.3601	.3801	.3601	.3601	.3086	.3601	
Max	2.9384	2.5206	2.7263	2.4691	2.572	2.0062	2.3148
Min	.3086	.3086	.3086	.3086	.2572	.3086	.3601
Avg	1.0382	1.0080	1.0717	1.0224	1.0502	.4957	1.2069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 202 / 11 Kv MASLI (OLD FEEDER SEPERATION/PURE AG  
 BHISHNOOR) Feeder KV- 11 /  
 OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.116	.1433	.1492	.1326	.1433	.1326	.1326
2	.116	.1267	.1492	.1326	.1417	.116	.116
3	.0995	.1254	.1326	.1326	.124	.116	.116
4	.0995	.1267	.1326	.116	.1254	.0995	.116
5	.0995	.1433	.116	.116	.1254	.0995	.116
6	.116	.1417	.0995	.1326	.1254	.0995	.116
7	.1326	.1448	.116	.1326	.124	.1326	.1326
8	.1326	.124	.116	.1326	.1254	.1326	.1492
9	.116	.1254	.1326	.1326	.1267	.0995	.116
10	2.1879	2.3739	2.6023	2.1714	2.1879	.4475	2.1879
11	2.8433	2.5526	2.8012	2.3703	2.6023		2.4034
12	2.8656	2.5194	2.8675	2.431	2.3205	2.3537	2.4531
13	2.7664	2.6023	2.6852	2.4413	2.6189	2.3703	2.3537
14	2.713	2.6189	2.4531	2.3537	2.6023	2.5692	2.2874
15	2.5987	2.6189	2.6852	2.2708	2.5857	2.7183	2.2542
16	2.4034	2.6852	2.7018	2.2634	2.6686	2.6355	2.1879
17	2.3148	2.4531	2.4863	2.2382	2.4531	2.1879	2.0719
18	.1629	.116	.116	.1433	.1326	.116	.1823
19	.3045	.1492	.2984	.2481	.1658	.2818	.2984
20	.3155	.1823	.2818	.2865	.1989	.2818	.2984
21	.2686	.2155	.2652	.2686	.2321	.2652	.2652
22	.2328	.1658	.1989	.2126	.1823	.1989	.1989
23	.1612	.1658	.1326	.1433	.1326	.1989	.1492
24	.1326	.1433	.1658	.1326	.1433	.1326	.1658
Max	2.8656	2.6852	2.8675	2.4413	2.6686	2.7183	2.4531
Min	.0995	.116	.0995	.116	.124	.0995	.116
Avg	.9708	.9485	.9952	.8806	.9328	.7733	.8695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 203 / 11 Kv Khangao SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
2	.2321
23	.2321
Max	.2321
Min	.2321
Avg	.2321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 204 / 11 KV KHAPRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0362	.0332	.0332	.0362	.0332	.0332
2	.0332	.0351	.0332	.0332	.0362	.0332	.0332
3	.0166	.0358	.0166	.0332	.0354	.0166	.0332
4	.0166	.0179	.0166	.0332	.0179	.0166	.0332
5	.0166	.0183	.0166	.0332	.0183	.0166	.0332
6	.0166	.0366	.0166	.0332	.0366	.0166	.0332
7	.0332	.037	.0332	.0332	.0358	.0332	.0166
8	.0166	.0358	.0166	.0332	.0362	.0332	.0166
9	.0332	.0362	.0166	.0332	.0362	.0166	.0332
10	.2818	.2658	.2652	.2652	.2743	.2321	.2321
11	.3772	.3315	.3647	.3467	.2915	.2984	.2984
12	.4115	.3812	.3481	.373	.3812	.3315	.3315
13	.4207	.3978	.3812	.4115	.3978	.3481	.3647
14	.4334	.3647	.3978	.407	.3812	.3647	.3481
15	.4287	.3647	.4144	.4115	.3647	.3647	.3149
16	.431	.3978	.3812	.3772	.3647	.3812	.2818
17	.4115	.3481	.3647		.2984	.3647	.2486
18	.0358	.0332	.0497	.0366	.0332	.0332	.0332
19	.0886	.0663	.0829	.0905	.0663	.0663	.0829
20	.0716	.0829	.0829	.0886	.0663	.0663	.0829
21	.0543	.0663	.0829	.0709	.0829	.0663	.0829
22	.0537	.0497	.0663	.0543	.0497	.0497	.0663
23	.0366	.0332	.0332	.0366	.0332	.0332	.0497
24	.0332	.0362	.0332	.0332	.0366	.0332	.0332
Max	.4334	.3978	.4144	.4115	.3978	.3812	.3647
Min	.0166	.0179	.0166	.0332	.0179	.0166	.0166
Avg	.1577	.1462	.1478	.1435	.1421	.1354	.1299



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 205 / 11 KV NEW BHISHNOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2818	.3045	.3481	.2818	.3155	.3481	.3647
2	.2652	.3077	.3149	.2818	.3224	.2984	.3481
3	.2321	.3045	.2984	.2652	.3045	.2984	.3149
4	.2321	.2865	.2818	.2652	.3077	.2652	.3149
5	.2486	.3403	.2652	.2818	.3012	.2652	.3149
6	.2652	.3045	.2818	.2652	.3224	.2818	.2818
7	.3149	.3403	.3149	.2652	.3189	.3315	.3149
8	.3647	.3898	.3647	.2984	.3506	.3315	.3315
9	.3812	.3856	.3647	.3647	.4031	.3978	.3481
10	1.0442	1.1488	1.1768	1.0774	1.0898	.9945	1.0277
11	1.2071	1.1768	1.2266	1.1361	1.1043	.3149	1.1603
12	1.3696	1.2929	1.2597	1.0898	1.21	1.326	1.21
13	1.2929	1.2266	1.2597	1.1065	1.1934	1.1934	1.1437
14	1.2742	1.2431	1.1934	1.1401	1.1768	1.2597	1.1271
15	1.2717	1.21	1.1768	1.1831	1.1768	1.21	1.0277
16	1.2929	1.2431	1.2597	1.153	1.1768	1.326	.9488
17		1.2431	1.1271	1.1269	1.0608	1.0277	.9614
18	.3898	.3481	.4144	.3721	.3978	.3647	.4144
19	.6687	.4144	.6962	.6859	.547	.663	.6796
20	.6068	.5801	.6962	.6935	.5304	.663	.6962
21	.5609	.5138	.663	.6588	.4973	.663	.663
22	.5258	.4475	.5138	.5316	.4475	.5304	.547
23	.3898	.4144	.3315	.4252	.3812	.431	.3978
24	.2984		.3647	.2984	.3189	.3481	.4144
Max	1.3696	1.2929	1.2597	1.1831	1.21	1.326	1.21
Min	.2321	.2865	.2652	.2652	.3012	.2652	.2818
Avg	.6425	.6725	.6748	.6353	.6356	.6306	.6397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 403 / 33 KV Paradsinga Incomer

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1097	.1595	.1423	.1629	.1578	.1612
2	.1578	.1075	.1595	.1423	.1612	.1017	.1612
3	.1086	.1063	.1526	.1423	.1595	.1017	.1075
4	.1017	.1097	.1063	.1423	.1086	.1052	.1063
5	.1052	.1075	.1063	.1423	.1097	.1052	.1063
6	.1017	.1086	.1052	.1423	.1097	.1017	.1063
7	.1578	.1097	.1578	.1423	.1629	.1526	.1063
8	.1595	.1629	.1052	.1423	.1612	.1526	.1595
9	.1578	.1595	.1578	.1423	.1595	.1052	.1595
10	3.155	2.4177	3.6677	2.8938	2.4691	.8648	3.083
11	3.0864	3.6145	3.6528	2.8807	2.9321	.0474	3.0361
12	3.2076	3.774	3.7477	3.0521	3.5082	2.9412	3.2259
13	2.8995	3.8272	3.558	2.9835	3.8272	3.6145	3.131
14	3.1927	3.8272	3.2733	2.7664	3.774	3.7209	3.0836
15	2.7664	3.774	3.4631	2.7263	3.7209	3.8803	3.0836
16	3.8255	3.8803	3.558	2.9835	3.9866	3.8803	2.9412
17	2.7161	3.5614	3.2733	2.6155	3.5082	3.2425	2.7515
18	.1612	.1063	.1423	.1629	.1578	.1629	.1898
19	.3189	.1595	.1423	.3155	.2126	.3721	.3321
20	.3258	.2126	.3321	.3155	.2126	.3761	.3321
21	.2686	.2658	.2846	.2686	.2658	.3224	.3321
22	.2172	.2126	.2372	.2149	.2126	.2686	.2372
23	.1595	.2126	.1898	.1612	.2035	.2658	.1898
24	.1595	.1612	.1595	.1423	.1612	.1578	.2149
Max	3.8255	3.8803	3.7477	3.0521	3.9866	3.8803	3.2259
Min	.1017	.1063	.1052	.1423	.1086	.0474	.1063
Avg	1.1529	1.2953	1.2872	1.0735	1.2687	1.0501	1.1391

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 404 / 33 kv T/F NO.II P'SINGA

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1097	.1052	.0949	.1086	.1017	.1063
2	.1017	.1075	.1052	.0949	.1097	.1052	.1063
3	.0526	.1086	.1017	.0949	.1086	.1017	.1063
4	.0514	.1075	.1017	.0949		.0526	.1063
5	.0509	.1086	.0509	.0949		.0509	.1063
6	.0532	.1075	.1063	.0949	.1097	.1017	.1063
7	.1063	.1097	.1052	.0949	.1086	.1017	.1063
8	.1017	.1075	.1063	.0949	.1075	.1017	.1063
9	.1063	.1063	.1052	.1423	.1063	.1017	.1063
10	1.3672	1.4043	1.5415	1.2809	1.4043	1.262	1.0631
11	1.5947	1.5947	1.5912	1.5083	1.4752		1.3757
12	1.7684	1.7541	1.5181	1.4752	1.701	1.5655	1.4706
13	1.749	1.701	1.5655	1.5261	1.701	1.6478	1.4232
14	1.749	1.701	1.5181	1.5769	1.6478	1.701	1.4232
15	1.7164	1.6478	1.5181	1.5947	1.6301	1.6478	1.2809
16	1.7684	1.7541	1.5655	1.5775	1.6478	1.8073	1.2334
17	1.5947	1.701	1.4232	1.3375	1.4352	1.4883	1.1385
18	.1097	.1052	.1423	.1086	.1063	.1063	.1423
19	.2181	.1595	.2372	.2149	.2103	.2126	.2372
20	.2172	.2126	.2372	.2149	.2103	.2126	.2372
21	.1629	.1595	.2372	.1629	.1526	.2126	.2372
22	.1086	.1595	.1898	.1629	.1526	.2126	.1898
23	.1075	.1595	.0949	.1097	.1052	.1595	.1423
24	.1063	.1086	.1063	.0949	.1086	.1017	.1595
Max	1.7684	1.7541	1.5912	1.5947	1.701	1.8073	1.4706
Min	.0509	.1052	.0509	.0949	.1052	.0509	.1063
Avg	.6278	.6373	.5989	.5770	.6567	.5720	.5296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 201 / 11 KV LAXMINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0914	.0914	.128	.1097	.12	.128
2	.1097	.0914	.0914	.128	.1097	.12	.128
3	.0924	.0914	.0914	.128	.1097	.12	.128
4	.0914	.0914	.0914	.128	.1097	.12	.128
5	.0914		.0914	.1097	.1097	.12	.1097
6	.1097	.128	.128	.0914	.128	.12	.128
7	.1463	.1463	.128	.128	.1646	.1543	.128
8	.1646	.1463	.1463	.1646	.1463	.1646	.128
9	.1646	.1848	.1829	.1715	.2195	.2012	.1646
10	.2012	.1663	.1646	.1715	.1829	.1791	.1829
11	.2012	.1829	.1829	.1829	.1829	.2012	.1646
12	.1829	.2012	.2012	.1829	.1829	.181	.1646
13	.1463	.2195	.2012	.1646	.1829	.2195	.1646
14	.1646	.1646	.1646	.1646	.1463	.2012	.1463
15	.1646		.1646	.1646	.1646	.1829	.128
16	.1646	.1463	.1646	.1646	.1463	.1463	.128
17	.1463	.1463	.1646	.1646	.12	.1463	.128
18	.2012	.1829	.1646	.1646	.1543	.181	.1463
19	.2195	.2195	.2378	.2012	.2195	.2378	.1629
20	.2012	.2195	.2195	.2195	.2402	.2195	.1715
21	.1829	.1646	.2195	.2012	.2012	.2012	.181
22	.1463	.1646	.1646	.1646	.1662	.1463	.1629
23	.128	.128	.1463	.1463	.1463	.1463	.12
24	.1097	.0914	.0914	.128	.1097	.128	.128
Max	.2195	.2195	.2378	.2195	.2402	.2378	.1829
Min	.0914	.0914	.0914	.0914	.1097	.12	.1097
Avg	.1517	.1531	.1539	.1568	.1564	.1649	.1437

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 202 / 11 KV BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.3366	.3189	.3544	.3366	.3429	.3898
2	.3189	.3366	.3189	.3544	.3366	.3429	.3898
3	.3012	.3366	.3189	.3544	.3189	.3429	.3898
4	.2835	.3366	.3366	.3544	.3189	.3429	.3898
5	.2835	.4075	.3366	.3544	.3189	.3601	.443
6	.3544	.4607	.3721	.3721	.3721	.3601	.443
7	.567	.567	.4607	.5138	.567	.5316	.567
8	.5847	.6024	.5493	.5138	.5493	.567	.567
9	.5493	.6268	.5316	.5316	.6024	.6024	.567
10	.6024	.6626	.5493	.463	.6379	.6024	.6024
11	.5847	.6379	.6201	.5847	.5493	.7087	.6201
12	.6379	.6379	.6201	.5847	.6024	.6379	.6556
13	.6556	.5847	.6201	.5493	.6024	.6379	.567
14	.5493	.567	.5316	.5493	.5316	.6024	.567
15	.567		.4607	.5493	.567	.567	.5847
16	.5493	.567	.4252	.5138	.5847	.5847	.5316
17	.5493	.567	.5194	.5138	.583	.5847	.567
18	.6556	.7087	.5847	.6024	.6516	.6733	.691
19	.7973	.7973	.7265	.7265	.7796	.815	.7087
20	.7265	.7087	.6379	.7087	.7796	.815	.6687
21	.567	.5847	.5493	.567	.2286	.6379	.567
22	.4961	.5316	.4784	.4784	.4784	.6379	.5316
23	.3721	.4252	.4075	.3898	.4252	.443	.4287
24	.3189	.3366	.3189	.3544	.3366	.3544	.3898
Max	.7973	.7973	.7265	.7265	.7796	.815	.7087
Min	.2835	.3366	.3189	.3544	.2286	.3429	.3898
Avg	.5079	.5360	.4831	.4933	.5024	.5456	.5345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 203 / 11 kV IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2149	.2149	.2149	.2149	.2229	.2507
2	.2126	.2149	.2149	.2149	.2149	.2229	.2507
3	.2303	.2149	.2149	.2149	.2507	.2229	.2507
4	.2658	.2149	.2149	.2328	.2865	.2229	.2507
5	.3045	.2865	.2686	.2686	.3403	.3086	.3045
6	.3582	.3582	.3582	.3403	.394	.3601	.4656
7	.4298	.4477	.4477	.4298	.4477	.4287	.5014
8	.4298	.4656	.4298	.4298	.4477	.4119	.5194
9	.4656	.4656	.5014	.4458	.4477	.4784	.4477
10	.4835	.5373	.5014	.463	.4656	.443	.4835
11	.4835	.4835	.5014	.4835	.5194	.4656	.4835
12	.4298	.4298	.4656	.4119	.4477	.4298	.4656
13	.394	.4298	.4477	.4835	.4119	.4119	.3761
14	.3045	.2865	.3403	.4835	.3582	.3761	.3189
15	.3761		.3045	.4298	.394	.3224	.2865
16	.4477	.3761	.394	.394	.4119	.4298	.3582
17	.4477	.4119	.394	.4477	.4115	.394	.3544
18	.4656	.5194	.4656	.4298	.4287	.4656	.4607
19	.5014	.5373	.5373	.5373	.5552	.591	.5373
20	.5373	.5373	.5014	.5014	.6984	.5373	.3944
21	.394	.4835	.3761	.3761	.4298	.4119	.394
22	.3224	.3582	.3045	.3224	.3366	.3224	.3403
23	.2507	.2865	.2686	.2507	.2835	.2865	.2743
24	.2149	.2149	.2149	.2149	.2149	.2303	.2507
Max	.5373	.5373	.5373	.5373	.6984	.591	.5373
Min	.2126	.2149	.2149	.2149	.2149	.2229	.2507
Avg	.3735	.3815	.3701	.3759	.3922	.3749	.3758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 204 / 11 KV PANCHWATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2481	.2303	.2303	.2686	.2572	.3189
2	.2507	.2481	.2303	.2303	.2534	.2572	.3189
3	.2507	.2481	.2303	.2303	.2534	.2572	.3189
4	.2534	.2481	.2303	.2303	.2353	.2572	.3189
5	.2534	.2835	.2303	.2303	.2353		.3189
6	.2353	.3189	.2835	.2303	.2896	.2743	.4252
7	.3582	.3366	.2835	.3189	.3403	.3086	.4075
8	.3898	.3544	.3544	.3721	.3544	.3898	.4075
9	.3544	.3582	.3544	.3944	.3544	.3898	.3721
10	.3721	.394	.3898	.3772	.3761	.3189	.3898
11	.2835	.3544	.3012	.3898	.3012	.362	.3898
12	.3012	.3012	.3544	.3898	.3189	.2896	.3012
13	.2835	.2658	.3544	.4075	.3012	.2481	.3012
14	.2303	.2353	.2835	.4075	.2835	.2328	.3012
15	.2303		.2658	.4075	.2835	.2658	.3012
16	.2835	.2303	.2835	.2658	.2835	.2835	.2835
17	.3012	.3224	.3224	.2835		.3366	.3012
18	.3366	.362	.4119	.4075	.3601	.4344	.3898
19	.5316	.4961	.5493	.4961	.5194	.5316	.4706
20	.443	.4961	.5138	.5068	.5194	.5316	.463
21	.4075	.443	.4075	.4252	.4835	.4784	.4477
22	.3544	.3898	.3898	.3801	.3898	.443	.4163
23	.2835	.2835	.3012	.2835	.3189	.3544	.3429
24	.2534	.2481		.2303	.2715	.2658	.3189
Max	.5316	.4961	.5493	.5068	.5194	.5316	.4706
Min	.2303	.2303	.2303	.2303	.2353	.2328	.2835
Avg	.3123	.3246	.3285	.3386	.3302	.3377	.3594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 205 / 11 KV PETHBUDHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.1214	.1387	.1907	.1612	.1372	.156
2	.1267	.1214	.1387	.1734	.1612	.1372	.156
3	.1254	.1214	.1387	.1734	.1433	.1372	.156
4	.1086	.104	.1387	.1734	.1448	.1372	.156
5	.1075	.1214	.1214	.156	.1448	.1372	.156
6	.1612	.156	.1387	.1387	.1791	.1543	.1387
7	.181	.1734	.1387	.1387	.1791	.1715	.208
8	.1734	.1907	.1907	.208	.1949	.1949	.1907
9	.1907	.2328	.1907	.2401	.2254	.2126	.208
10	.1907	.2507	.208	.2401	.1991	.2126	.1907
11	.1907	.2254	.208	.208	.2427	.2149	.1907
12	.208	.2254	.208	.2601	.2601	.2328	.1907
13	.1387	.2774	.208	.1907	.2774	.2126	.1734
14	.1734	.181	.1734	.1907	.1907	.1991	.1907
15	.1387		.208	.1907	.2427	.1753	.208
16	.156	.1907	.208	.1214	.2427	.1753	.208
17	.1734	.1991	.2534	.2427		.208	.1949
18	.1907	.2534	.2328	.208	.2743	.2507	.2328
19	.2601	.2947	.3294	.3012	.2865	.3121	.2534
20	.2601	.2947	.3121	.3045	.2686	.3121	.2401
21	.2254	.2427	.3467	.2658	.2328	.2947	.2534
22	.1907	.2254	.2254	.2328	.2149	.2427	.2353
23	.1387	.1387	.1907	.1949	.1772	.2254	.1886
24	.1267	.1214	.1387	.1907	.1629	.1417	.156
Max	.2601	.2947	.3467	.3045	.2865	.3121	.2534
Min	.1075	.104	.1214	.1214	.1433	.1372	.1387
Avg	.1692	.1941	.1994	.2056	.2090	.2012	.1930



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 401 / 33 KV T/F Incomer No.I NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.631	.631	.6836	.6836	.6687	.7362
2	.631	.631	.631	.6836	.6836	.6687	.7362
3	.631	.631	.631	.6836	.6836	.6687	.7362
4	.631	.631	.631	.6836	.6836	.6687	.7362
5	.6836	.7888	.7362	.7362	.7362	.7716	.8939
6	.8413	.9465	.8939	.7888	.8939	.823	1.0517
7	1.1043	1.1568	.9991	1.0517	1.1043	1.1317	1.2094
8	1.1568	1.2094	1.1043	1.1043	1.1283	1.1163	1.1568
9	1.1568	1.2894	1.262	1.1317	1.1568	1.2757	1.1568
10	1.262	1.3432	1.1568	1.1831	1.3146	1.2226	1.2094
11	1.2094	1.262	1.262	1.2094	1.2094	1.262	1.2094
12	1.2094	1.262	1.262	1.3146	1.2094	1.3146	1.262
13	1.1568	1.2094	1.262	1.1568	1.1568	1.2226	1.1043
14	.9991	1.1043	.9991	1.1568	.9991	1.1043	.9991
15	1.1043		.8413	1.1568	1.1043	1.1283	.9991
16	1.1568	1.0517	.9991	1.1043	1.1043	1.1694	1.0517
17	1.1043	1.2094	1.0745	1.0517	1.0802	1.1043	1.0631
18	1.262	1.3146	1.2357	1.2094	1.2346	1.3146	1.2757
19	1.5249	1.5249	1.4723	1.5415	1.5581	1.6301	1.4198
20	1.4198	1.4198	1.3146	1.4198	1.5581	1.5249	1.286
21	1.1043	1.2094	1.1043	1.3032	1.3289	1.2094	1.1568
22	.9465	.9991	.9465	.9991	.9568	1.0517	1.0517
23	.7362	.7362	.7888	.8505	.8505	.8413	.8745
24	.631	.631	.631	.6836	.6836	.691	.7362
Max	1.5249	1.5249	1.4723	1.5415	1.5581	1.6301	1.4198
Min	.631	.631	.631	.6836	.6836	.6687	.7362
Avg	1.0122	1.0518	.9946	1.0370	1.0459	1.0660	1.0463

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 402 / 33 KV T/F Incomer No.II NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.3681	.3681	.4207	.4207	.4115	.4733
2	.3681	.3681	.3681	.4207	.4207	.4115	.4733
3	.3681	.3681	.3681	.2629	.3681	.4115	.4733
4	.3155	.3681	.3681	.4207	.3681	.4115	.4733
5	.3155	.4207	.3681	.3681	.3681	.4115	
6	.4207	.4733	.4733	.3681	.4733	.4115	.5258
7	.5258	.5258	.4733	.4207	.5258	.463	.5784
8	.5784	.5258	.5784	.5784	.5847	.5847	.5784
9	.4733	.4298	.5258	.5658	.5784	.5847	.631
10	.5784	.6447	.5784	.6173	.5784	.5316	.5784
11	.4733	.5784	.4733	.5784	.5258	.5784	.5784
12	.4733	.5258	.5258	.5784	.5784	.5258	.4733
13	.4207	.5258	.5784	.5784	.5784	.4784	.4207
14	.3681	.4207	.4207	.5784	.4733	.4207	.4733
15	.3681		.4207	.5784	.5258	.4784	.5258
16	.4207	.4207	.4733	.5258	.5258	.4784	.4733
17	.4733	.4207	.591	.5258	.5144	.5258	.4784
18	.5258	.5784	.6447	.5784	.6173	.631	.6379
19	.7888	.7888	.8939	.7973	.8059	.8413	.7888
20	.6836	.7888	.8413	.7888	.8059	.8413	.7716
21	.631	.6836	.7362	.7442	.6984	.7888	.6836
22	.5258	.631	.631	.631	.5847	.6836	.631
23	.4207	.4207	.4733	.5316	.4784	.5784	.5658
24	.3681	.3681	.3681	.4207	.4207	.4252	.4733
Max	.7888	.7888	.8939	.7973	.8059	.8413	.7888
Min	.3155	.3681	.3681	.2629	.3681	.4115	.4207
Avg	.4689	.5063	.5226	.5366	.5341	.5379	.5548

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 404 / 33 KV RAPDRP Incomer NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9991		.9882	1.1043	1.1043	1.0802	1.1963
2	.9991	.9882	.9882	1.1043	1.1043	1.0802	1.1963
3	.9991	.9882	.9882	1.1043	1.0517	1.0802	1.1963
4	.9568	.9882	.9882	1.1043	1.0517	1.0802	1.1963
5	.9991	1.1963	1.0923	1.1043	1.1163	1.1831	1.3523
6	1.262	1.4043	1.3523	1.1568	1.3672	1.2346	1.5604
7	1.5775	1.6644	1.4563	1.4723	1.6301	1.5947	1.7684
8	1.7353	1.7164	1.7164	1.6827	1.6832	1.701	1.7164
9	1.6124	1.7193	1.7684	1.6975	1.7353	1.8604	1.7684
10	1.8204	1.9879	1.7164	1.8004	1.8404	1.7541	1.7684
11	1.6644	1.8404	1.7164	1.7684	1.7353	1.8404	1.8204
12	1.6644	1.7878	1.7684	1.8724	1.7878	1.8404	1.7164
13	1.5604	1.7353	1.8204	1.7164	1.7353	1.7918	1.5083
14	1.3523	1.5249	1.4043	1.7164	1.4563	1.5249	1.4563
15	1.4563		1.2483	1.7164	1.6301	1.5203	1.5083
16	1.5604	1.4723	1.4043	1.6124	1.6301	1.6289	1.5083
17	1.5604	1.7353	1.6655	1.5604	1.5947	1.6301	1.5415
18	1.7684	1.893	1.8804	1.7684	1.8519	1.9456	1.9136
19	2.2885	2.2885	2.3663	2.3348	2.364	2.4714	2.1794
20	2.0805	2.1845	2.1559	2.2085	2.364	2.3405	1.9547
21	1.7164	1.8724	1.8404	1.9547	2.0199	1.9982	1.8404
22		1.6124	1.5775	1.6301	1.5415	1.7164	1.6827
23	1.1443	1.1443	1.262	1.3575	1.3289	1.4198	1.3375
24	.9991	.9882	.9882	1.1043	1.1043	1.1163	1.2094
Max	2.2885	2.2885	2.3663	2.3348	2.364	2.4714	2.1794
Min	.9568	.9882	.9882	1.1043	1.0517	1.0802	1.1963
Avg	1.4685	1.5788	1.5064	1.5688	1.5762	1.6014	1.5790

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 201 / 11kv Ladgaon Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0876	.1075	.1017	.104	.1052	.1214
2	.0838	.0876	.1075	.0838	.104	.1052	.104
3	.0838	.0867	.1063	.0838	.104	.0867	.104
4	.0829	.0867	.1063	.0838	.1029	.0867	.1029
5	.0829	.0857	.1052	.0983	.1029	.0848	.1006
6	.0995	.081	.104	.0972	.1029	.0838	.1174
7	.0819	.0762	.1029	.1006	.0857	.0829	.1029
8	.0829	.0819	.0772	.1063	.0838	.0848	.0848
9	.1017	.0819	.0541	.1063	.1052	.1063	.104
10	.4374	.4218	.3479	.4218	.4111	.3953	.3906
11	.5218	.4744	.3953	.427	.427	.4586	.4012
12	.4999	.4744	.4481	.4321	.4428	.4111	.4167
13	.5312	.4902	.4481	.4321	.4586	.4062	.4115
14	.4531	.4428	.4531	.4428	.4428	.3437	.4064
15	.4218	.427	.4999	.3795	.4062	.3521	.3858
16	.4374	.4218	.506	.427	.3906	.3361	.3612
17	.4374	.3858	.4115	.3749	.3963	.2932	.3506
18	.1267	.1109	.104	.1029	.124	.1254	.128
19	.2218	.2033	.2033	.2012	.2033	.2033	.2033
20	.2218	.2033	.2241	.2195	.2218	.2241	.2054
21	.2033	.2033	.2033	.181	.2033	.2054	.2263
22	.1629	.1663	.1646	.1448	.1646	.1848	.1848
23	.1227	.128	.1214	.1254	.1254	.1433	.1463
24	.1006	.1052	.1086	.1017	.104	.1052	.1227
Max	.5312	.4902	.506	.4428	.4586	.4586	.4167
Min	.0819	.0762	.0541	.0838	.0838	.0829	.0848
Avg	.2368	.2256	.2296	.2198	.2257	.2089	.2201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 202 / 11kv Murti Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1132	.112	.112	.112	.112	.1132
2	.1109	.1132	.112	.112	.112	.112	.1132
3	.1109	.112	.112	.112	.112	.112	.1132
4	.1109	.112	.112	.112	.112	.112	.1132
5	.1109	.112	.112	.1109	.112	.112	.1132
6	.1109	.112	.112	.1097	.112	.112	.1307
7	.1109	.112	.112	.1109	.112	.112	.1294
8	.132	.132	.132	.132	.0934	.132	.1334
9	.1334	.1334	.1334	.1509	.132	.1132	.1334
10	.7968	.8065	.787	.6687	.7253	.7968	.6859
11	.8436	.828	.7562	.7773	.8025	.6944	.6554
12	.8179	.8025	.8642	.8025	.8078	.6859	.8025
13	.8905	.8333	.8688	.8436	.7621	.7316	.8078
14	.8333	.8025	.8383	.7562	.7253	.6859	.7977
15	.8488	.7468	.8488	.7407	.7253	.7011	.6602
16	.8383	.7716	.8333	.787	.823	.6859	.5868
17	.7316	.6836	.7225	.6923	.7827	.5868	.5639
18	.1509	.1509	.1698	.132	.1886	.2075	.2054
19	.3018	.3206	.3018	.3018	.3018	.3018	.3048
20		.3048	.3048	.3018	.3048	.3048	.2858
21	.2263	.2667	.2858	.2641	.2667	.2858	.2667
22	.1886	.1886	.1886	.1867	.1886	.2096	.2096
23	.132	.1509	.1307	.1307	.1494	.1905	.132
24	.1109	.1132	.1307	.112	.112	.1307	.132
Max	.8905	.8333	.8688	.8436	.823	.7968	.8078
Min	.1109	.112	.112	.1097	.0934	.112	.1132
Avg	.3806	.3676	.3784	.3567	.3615	.3428	.3412

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 203 / 11kV Ambada Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0705	.0714	.0781	.0753	.0972	.0829	.096
2	.0705	.0714	.0743	.0743	.0972	.0819	.081
3	.0695	.0705	.0724	.0743	.096	.081	.0781
4	.0695	.0705	.0714	.0724	.08	.0791	.0781
5	.0686	.0705	.0705	.0734	.08	.0772	.0762
6	.0686	.0686	.0549	.0705	.0791	.0762	.0753
7	.0724	.0549	.0541	.0724	.0781	.0762	.0762
8	.0533	.0724	.0714		.0743	.0772	.0734
9	.0772	.0556	.0549		.0625	.0781	.0564
10	1.0402	.9717	.9602		1.0883	1.1305	.8697
11	1.2308	1.0364	1.247	.3953	1.2308	1.166	.9488
12	1.2793	1.0562	1.2308	1.0814	1.2631	1.1822	1.0722
13	1.2631	1.1203	1.2146	1.2616	1.2492	1.1203	1.0562
14	1.247	1.2163	1.0883	.9442	1.2176	1.1498	.9804
15	1.1363	1.1683	1.3279	1.4413	1.2003	1.1043	.9646
16	1.2483	1.1702	1.3765	1.2643	1.1683	.6882	.9962
17	1.2163	1.1405	1.1683	1.1843	1.0753	.8065	.8796
18	.1187	.061	.08	.0791	.0829	.0819	.0848
19	.1629	.1448	.1448	.1629	.1629	.1448	.1463
20	.1629	.1595	.1629	.1629	.1629	.1629	.1646
21	.1433	.1417	.1433	.1433	.1448	.1629	.1463
22	.1433	.1214	.124	.1387	.124	.1433	.124
23	.112	.1029	.0972	.0995	.104	.1187	.1017
24	.0714	.08	.0838	.0753	.096	.0838	.0972
Max	1.2793	1.2163	1.3765	1.4413	1.2631	1.1822	1.0722
Min	.0533	.0549	.0541	.0705	.0625	.0762	.0564
Avg	.4665	.4290	.4605	.4260	.4631	.4148	.3885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 405 / 33 KV Murti Incomer  
Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1109	.1086	.1097	.112	.1086	.1109
2	.1097	.1109	.1086	.1097	.112	.1086	.1109
3	.1086	.1086	.1086	.1086	.112	.1086	.1109
4	.1086	.1086	.1097	.1086	.112	.1086	.1097
5	.1075	.1086	.1097	.1086	.1109	.1075	.1097
6	.1075	.1086	.1097	.1075	.1109	.1075	.1086
7	.1063	.1075	.1097	.1075	.1097	.1075	.1109
8	.1075	.112	.1075	.1132	.1063	.1086	.1086
9	.1109	.1097	.1063	.1698	.1132	.1109	.1109
10	2.3148	2.1559	2.1296	1.0837	2.1759	2.2497	1.9204
11	2.6246	2.2965	2.3434	1.6004	2.4371	2.2497	1.9907
12	2.5463	2.2685	2.484	2.2965	2.484	2.2497	2.2685
13	2.6389	2.4074	2.484	2.5617	2.4537	2.2222	2.2405
14	2.5	2.4074	2.3611	2.0833	2.3611	2.1296	2.1948
15	2.3611	2.2862	2.5926	2.5	2.2685	2.1033	1.9867
16	2.4691	2.2862	2.6389	2.4074	2.3611	1.6667	1.8964
17	2.332	2.1948	2.2405	2.2405	2.2125	1.6918	1.7604
18	.1698	.168	.168	.112	.1698	.2263	.2263
19	.2829	.3395	.2829	.2829	.2829	.2829	.2829
20	.2263	.2829	.2829	.2829	.2829	.2829	.2829
21	.2263	.2829	.2829	.2829	.2829	.2829	.2829
22	.1698	.168	.168	.1698	.1698	.2263	.2263
23	.112	.1663	.1097	.112	.1663	.168	.112
24	.1097	.112	.1086	.1097	.112	.1097	.1109
Max	2.6389	2.4074	2.6389	2.5617	2.484	2.2497	2.2685
Min	.1063	.1075	.1063	.1075	.1063	.1075	.1086
Avg	.9192	.8670	.9023	.7987	.8841	.7966	.7822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 167013 / 132 KV KATOL

Feeder No / Name : 204 / 11 KV PATHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
23	.5144
24	.2241
Max	.5144
Min	.2241
Avg	.3693



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 201 / 11 KV MOHPA RURAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.1494	.7095	.1423	.2658	.1543	.4908
2	.4458	.1494	.5228	.1423	.2658	.1543	.4557
3	.4287	.1494	.4481	.1423	.2658	.1543	.4557
4	.4458	.2658	.4458	.1423	.2658	.1715	.4557
5		.3544	.4458	.1581	.2126	.1886	.5258
6	.4801	.5316	.6173	.1739	.1949	.1886	.5609
7	.7202	.691	.7716	.197	.1772	.2058	.7537
8	1.166	1.0802	1.094	.2056	.1772	.2058	1.1488
9	1.3032	1.2346	1.2452	.2214	.2126	.1886	1.286
10	1.046	.7202	.7377	.2303	.2058	.1612	
11	.168	.1715	.1739	1.3375	1.286	1.2431	.1715
12	.1867	.1715	.1581	1.5604	1.4575	1.442	.12
13	.1867	.1715	.1595	1.5261	1.5432	1.3426	.1029
14	.1949	.1715	.1433	1.4575	1.5261		.1029
15	.1949	.1372	.1433	1.4232	1.3717	1.153	.1715
16	.2126	.1372	.1417	1.3717	1.3375	1.2742	.1715
17	.2126	.1372	.1265	1.3546	1.3717	1.2239	.1715
18	.2126	.1715	.1898	1.046	.703	.8139	.2572
19	.2658	.3772	.4075	.3544	.3429	.3721	.3601
20	.3721	.3772	.3721	.4075	.3601	.3772	.3944
21	.3366	.3429	.3544	.3721	.3601	.3544	.3772
22	.2303	.2401	.2865	.2835	.2572	.2572	.2743
23	.1867	.1715	.1898	.2835	.2058	.2058	.2229
24	.1543	.1494	.1543	.1581	.2835	.1543	.1715
Max	1.3032	1.2346	1.2452	1.5604	1.5432	1.442	1.286
Min	.1543	.1372	.1265	.1423	.1772	.1543	.1029
Avg	.4172	.3439	.4183	.6122	.6104	.5212	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 202 / 11 KV LINGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3012	.2743	.6802	.5316	.7716	.3544
2	.2743	.3012	.2743	.6802	.5316	.8059	.3189
3	.2572	.3012	.2743	.6802	.5316	.7716	.3189
4	.2915	.3012	.2743	.664	.7087	.8059	.3189
5	.2915	.3012	.2743	.7125	.7973	.8573	.3189
6	.3086	.3189	.3258	.8421	.9391	.9088	.4075
7	.3601	.3366	.3601	1.1603	1.3717	1.2174	.4252
8	.3429	.3189	.3544	1.6356	1.749	1.8004	.3429
9	.3429	.3366	.3544	1.9044	2.1026	1.9376	.3601
10	.3366	.3086	.3544	1.8482	1.7833	1.6244	.3601
11	1.5604	1.869	1.7444	.3721	.2743	.3366	1.6289
12	2.0178	2.1605	1.8027	.3721	.2915	.3189	
13	2.0348	2.1434	2.0809	.3544	.2743	.2835	
14	2.0008	2.1262	2.0729	.3366	.2743		1.9719
15	1.9839	1.5432	2.0645	.3366	.2743	.3012	1.869
16	1.95	2.0405	1.6078	.3189	.2915	.2303	1.8347
17	1.6956	2.0576	1.7711	.3189	.2915	.2126	1.8176
18	1.6289	1.5775	1.3916	.3898	.4287	.4733	1.406
19	.6201	.6001	.6661	.6201	.6173	.7011	.6859
20	.6556	.6001	.6485	.6733	.6859	.6859	.6516
21	.6024	.6001	.6135	.6379	.6516	.6836	.6344
22	.4607	.463	.4961	.5316	.5144	.5316	.5658
23	.3544	.3772	.3605	.5316	.4287	.4801	.4287
24	.2743	.3012	.2915	.2785	.5316	.3772	.3601
Max	2.0348	2.1605	2.0809	1.9044	2.1026	1.9376	1.9719
Min	.2572	.3012	.2743	.2785	.2743	.2126	.3189
Avg	.8717	.8994	.8639	.7033	.7032	.7442	.7900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 203 / 11 KV METPANJRA

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1			.0747
2			.0747
3			.0747
4			.0747
5			.0747
6			.0747
7			.0747
8			.0747
9			.0747
10	.0747	.0747	
11	.0747	.0747	
12	.0747	.0747	
13	.0747	.0747	
14	.0747	.0747	
15	.0747	.0747	
16	.0747	.0747	
17	.0747	.0747	
18	.0747	.0747	
19	.0747	.0747	
20	.0747	.0747	
21	.0747	.0747	
22	.0747	.0747	
23	.0747	.0747	
24			.0747
Max	.0747	.0747	.0747
Min	.0747	.0747	.0747
Avg	.0747	.0747	.0747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 204 / 11KV BUDHLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.168	.4458	.7842	.3366	.7202	.4252
2	.3601	.168	.0448	.7842	.3366	.7202	.3898
3	.3429	.168	.4481	.7682	.3366	.7373	.3898
4	.3429	.1867	.4481	.7682	.5316	.7545	.3856
5	.463	.443	.5601	.7682	.7265	.7888	.4557
6	.4801	.5316	.6722	.8642	.9036	.8916	.4207
7	.583	.6379	.7282	1.1768	1.286	1.2174	.5609
8	1.1145	1.0117	.9995	1.6004	1.6461	1.749	.9088
9	1.2003	1.2003	1.2616	1.7284	1.6118	1.8519	1.0802
10	.5316	.9945	1.0277	1.1145	1.4403	1.6741	.8745
11	1.0288	1.8519	1.6288	1.0974	1.3375	1.0059	1.5604
12	1.95	1.3203	1.8884	1.2689	1.4746	1.2574	1.6289
13	1.8652	1.8176	2.0645	1.2689	1.3717	1.2742	1.4918
14	1.5432	2.0233	1.9662	1.2689	1.3375		1.5775
15	1.4575	1.989	1.9559	1.286	1.3032	1.21	1.5261
16	1.3717	1.9033	1.9227	1.3032	1.2689	1.1736	1.3546
17	1.286	1.8861	1.8724	1.3546	1.1145	1.1568	1.406
18	1.2346	1.4918	1.3443	.9602	.7545	.7545	1.0974
19	.443	.3258	.3189	.3189	.3086	.3366	.3258
20	.3366	.3429	.3224	.3189	.3601	.3086	.3429
21	.3012	.3258	.3224	.3012	.3429	.3012	.3086
22	.2303	.2401	.2507	.2801	.2572	.2401	.2915
23	.1949	.1715	.1781	.2658	.2058	.2058	.2572
24	.1543	.168	.1715	.1619	.2481	.1886	.1715
Max	1.95	2.0233	2.0645	1.7284	1.6461	1.8519	1.6289
Min	.1543	.168	.0448	.1619	.2058	.1886	.1715
Avg	.7990	.8903	.9518	.9088	.8684	.8921	.8013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 205 / 11 KV GINNI AGRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3898	.0754	.2743	.0934	.132	.1334
2	.3772	.3544	.0754	.3018	.0934	.132	.1143
3	.3772	.3189	.0754	.2829	.0934	.1132	.1143
4	.3584	.2835	.0754	.2829	.0934	.1132	.1334
5	.3395	.2658	.0754	.2829	.0934	.1132	.1334
6	.3395	.2658	.0754	.3018	.0934	.1132	.1334
7	.1509	.2835	.0754	.3048	.0934	.1132	.0953
8	.132	.1307	.0762	.0943	.0934	.0943	.1334
9	.112	.1494	.1143	.132	.0934	.1132	.1143
10	.1307	.1524	.1524	.168	.132	.1143	.0566
11	.168	.1905	.1698	.2126	.132	.1334	
12	.168	.1524	.1509	.2303	.2075	.1143	.0566
13	.168	.1143	.1334	.2303	.2452		.0754
14	.168	.0953	.1524	.2126	.132		.0566
15	.168		.0762	.0747	.0754	.0762	.1132
16	.168	.1905	.0953		.0754	.1143	.0566
17	.1867	.2667	.0754	.0747	.1132		.0943
18	.1867	.2286	.0754	.0934	.1132	.1715	.1886
19	.168	.1509	.1143	.0934	.132	.1715	.1509
20	.1307	.1132	.0953	.0934	.0943	.0953	.0857
21	.1307	.0943	.0953	.0934	.0943	.0953	.0943
22	.168	.0943	.0953	.0934	.0943	.1143	.132
23	.3544	.0943	.2829	.0934	.1132	.1334	.132
24	.3772	.3544	.0953	.1132	.0934	.132	.1334
Max	.3961	.3898	.2829	.3048	.2452	.1715	.1886
Min	.112	.0943	.0754	.0747	.0754	.0762	.0566
Avg	.2260	.2058	.1074	.1798	.112	.1192	.1101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 206 / Mohapa Urban Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0187	.0171	.0189	.0187	.0187
2	.0187	.0189	.0187	.0171	.0189	.0187	.0187
3	.0187	.0189	.0171	.0171	.0189	.0187	.0187
4	.0187	.0189	.0187	.0171	.0189	.0187	.0187
5	.0187	.0189	.0187	.0171	.0189	.0187	.0187
6	.0187	.0189	.0187	.0171	.0189	.0187	.0187
7	.0187	.0189	.0187	.0187	.0189	.0187	.0187
8	.0187	.0189	.0187	.0171	.0189	.0187	.0187
9	.0189	.0189	.0187	.0171	.0189	.0187	.0187
10	.0189	.0187	.0187	.0189	.0171	.0187	.0187
11	.0189	.0187	.0171	.0189	.0187	.0187	.0187
12	.0189	.0187	.0171	.0189	.0187	.0187	.0187
13	.0189	.0187	.0187	.0189	.0187	.0187	.0187
14	.0189	.0187	.0187	.0373	.0187		.0187
15	.0189	.0187	.0187	.0373	.0187	.0187	.0171
16	.0189	.0187	.0187	.0373	.0187	.0187	.0187
17	.0189	.0187	.0171	.0373	.0187	.0187	.0187
18	.0373	.0187	.0171	.0189	.0187	.0187	.0171
19	.0373	.0187	.0187	.0189	.0187	.0187	.0187
20	.0373	.0187	.0187	.0189	.0187	.0187	.0187
21	.0189	.0187	.0187	.0373	.0187	.0181	.0187
22	.0189	.0187	.0187	.0189	.0187	.0187	.0187
23	.0189	.0187	.0171	.0189	.0187	.0187	.0187
24	.0187	.0189	.0187	.0171	.0189	.0187	.0187
Max	.0373	.0189	.0187	.0373	.0189	.0187	.0187
Min	.0187	.0187	.0171	.0171	.0171	.0181	.0171
Avg	.0211	.0188	.0183	.0221	.0187	.0187	.0186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 201 / 11 KV Kumari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2658	.2658	.2713	.0474	.0532	.0566
2		.2543	.2481	.2713	.0474	.0532	.0566
3		.7291	.2481	.2713	.0469	.0532	.056
4		.2883	.2481	.2713	.0463	.0532	.0566
5		.3052	.2804	.2883	.0463	.0532	.0566
6		.3391	.3155	.2883	.0474	.0532	.0566
7		.3561	.3856	.4578	.0474	.0532	.0566
8		.5935	.631	.6104	.0474	.0532	.0566
9		.691	.7362	.6952	.0474	.0532	.0566
10		.5935	.6485	.5765	.0309	.0354	.0566
11	.5087	.0377	.0354	.0316	.6135	.6135	.5218
12	.6783	.0189	.0177	.0158	.7973	.7888	.5693
13	.6783	.0189	.0177	.0158	.815	.8238	.5761
14	.763	.0189	.0177	.0158	.7545	.8589	.5735
15	.7969	.0189	.0177	.0309	.7545	.815	.5801
16	.6274	.0189	.0175	.0316	.7969	.7888	.3077
17	.5256	.0189	.0177	.0154	.763	.7362	.4111
18	.5316	.0377	.0354	.0316	.5596	.3721	.3681
19	.0876	.112	.1063	.0781	.0886	.112	.0819
20	.1063	.112	.0886	.0791	.0876	.112	.0983
21	.1063	.0934	.0886	.064	.0876	.0934	.0983
22	.0709	.0747	.0532	.048	.0709	.0747	.0655
23	.0526	.0566	.0532	.0474	.0532	.0566	.0492
24	.0463	.0532	.0566	.0526	.0474	.0526	.056
Max	.7969	.7291	.7362	.6952	.815	.8589	.5801
Min	.0463	.0189	.0175	.0154	.0309	.0354	.0492
Avg	.3986	.2128	.1929	.1900	.2810	.2839	.2051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 202 / nandikheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4784	.5487	.5967	.583	.1265	.1543	.1526
2	.5218	.583	.547	.6173	.1265	.1543	.1526
3		.6173	.547	.6344	.1235	.1543	.1543
4		.6516	.5304	.6344	.1423	.1543	.1372
5		.6859	.547	.6613	.1423	.1543	.1372
6		.7202	.5636	.6859	.1389	.1543	.1526
7		.7888	.7956	.8916	.1423	.1543	.1696
8		1.1317	1.2763	1.2003	.1265	.1372	.1526
9		1.1317	1.4586	1.3375	.1581	.1543	.1526
10		.9945	1.1437	.9602	.1423	.1543	.1543
11	.1372	.1029	.12	.1265	1.046	1.0277	.9488
12	.1029	.1029	.12	.1094	1.4403	1.2763	1.1561
13	.1029	.1187	.12	.1265	1.4232	1.3592	1.2431
14	.12	.1029	.0514	.108	1.5089	1.3763	1.1142
15	.12	.0686	.12	.1107	1.4232	1.3272	1.1227
16	.1029	.0686	.12	.108	1.3717	1.2597	1.0437
17	.12	.0857	.12	.1094	1.4232	1.21	1.0242
18	.1372	.1357	.1715	.1698	1.1831	.9448	.8065
19	.2572	.2543	.2743	.2372	.2572	.2713	.2652
20	.2743	.2713	.2915	.2315	.2743	.2713	.2458
21	.2401	.2374	.2572	.216	.2401	.2543	.2214
22	.1886	.2035	.2058	.1718	.1886	.2035	.1638
23	.1543	.1526	.1715	.1581	.1715	.1696	.1475
24	.1265	.125	.1372	.1543	.1423	.1543	.1526
Max	.5218	1.1317	1.4586	1.3375	1.5089	1.3763	1.2431
Min	.1029	.0686	.0514	.108	.1235	.1372	.1372
Avg	.1990	.4118	.4286	.4310	.5610	.5263	.4655



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 203 / Mohapa Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1638	.1423	.1423	.1638	.1638	.1423
2	.1543	.1638	.1475	.1581	.1475	.1581	.1475
3	.1543	.1638	.1475	.1638	.1475	.1638	.1475
4	.1543	.1581	.1475	.1638	.1638	.1638	.1475
5	.1715	.1638	.1475	.1638	.1638	.1638	.1638
6	.1715	.1581	.1638	.1677	.1638	.1581	.1581
7	.1715	.1802	.1638	.1638	.1802	.1802	.1638
8	.1715	.1739	.1802	.1802	.1802	.1802	.1638
9	.2058	.1638	.1638	.1966	.1638	.1638	.1638
10	.1886	.1581	.1638	.1802	.1638	.1638	.1638
11	.1886	.1638	.1638	.1802	.1802	.1638	.1638
12	.1886	.1802	.1802	.1638	.1638	.1581	.1581
13	.1886	.1638	.1802	.1638	.1638	.1581	.1475
14	.1886	.1638	.1802	.1638	.1638	.1423	.1581
15	.1886	.1638	.1739	.1638	.1475	.1581	.1677
16	.2058	.1739	.1802	.1581	.1475	.1739	.1475
17	.1886	.1638	.1638	.1638	.1475	.1802	.1475
18	.1886	.1739	.1802	.1966	.1802	.1966	.1802
19	.2058	.1966	.1966	.1966	.1966	.1966	.1966
20	.2058	.1966	.1802	.2515	.1966	.2012	.1966
21	.1715	.1739	.1802	.1802	.1966	.1802	.1802
22	.1715	.1581	.1638	.1638	.1638	.1802	.1638
23	.1543	.1581	.1475	.1677	.1638	.1677	.1638
24	.1715	.1715	.1475	.1638	.1638	.1638	.1475
Max	.2058	.1966	.1966	.2515	.1966	.2012	.1966
Min	.1543	.1581	.1423	.1423	.1475	.1423	.1423
Avg	.1793	.1687	.1661	.1732	.1672	.1700	.1617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 204 / TELKAMTHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0469	.0514	.0469	.0633	.1718	.116
2		.0469	.0514	.0469	.0791	.1718	.116
3		.0469	.052	.0312	.0791	.1718	.116
4		.0469	.052	.0312	.0772	.1875	.116
5		.0469	.0514	.0312	.0949	.1875	.1326
6		.0469	.0514	.0312	.1107	.1875	.1326
7		.0469	.0343	.0469	.1739	.2187	.1989
8		.0469	.0343	.0312	.2315	.2968	.2486
9		.0312	.0343	.0312	.3163	.3125	.2984
10		.0316	.0343	.0312	.253	.2812	.2984
11	.2968	.2818	.2031	.2372	.0312	.0343	.0309
12	.3437	.3315	.2812	.2469		.0514	.0316
13	.2812	.3315	.3125	.3163	.0156	.0343	.0497
14	.2656	.3481	.3125	.3086	.0312	.0343	.0316
15	.2812	.2984	.3125	.2688	.0312	.0343	.0655
16	.2656	.2984	.2656	.253	.0312	.0343	.0328
17	.2812	.3149	.25	.2469	.0312	.0343	.0328
18	.2031	.2486	.1875	.2056	.0469	.0514	.0655
19	.0937	.0848	.0781	.0791	.0781	.1017	.0983
20	.0937	.1017	.0937	.0791	.0937	.1017	.0983
21	.0781	.0848	.0781	.0791	.0937	.1017	.0983
22	.0625	.0686	.0625	.0617	.0781	.0848	.081
23	.0469	.0514	.0469	.0463	.0625	.0678	.0663
24		.0469	.0514	.0469	.0474	.0469	.0514
Max	.3437	.3481	.3125	.3163	.3163	.3125	.2984
Min	.0469	.0312	.0343	.0312	.0156	.0343	.0309
Avg	.1995	.1387	.1243	.1181	.0935	.1250	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 205 / KANIYADOL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0848	.0848	.0848	.1581	.2374	.2321
2		.0848	.0857	.0848	.1698	.2543	.2321
3		.0848	.0857	.0848	.1739	.2543	.2321
4		.0848	.0857	.0848	.1898	.2713	.2321
5		.0848	.0857	.0848	.1898	.2713	.2321
6		.0848	.1017	.1017	.1898	.3052	.2321
7		.1017	.1017	.1017	.253	.407	.3315
8		.1017	.1187	.0848	.3479	.4917	.4475
9		.1017	.1029	.1017	.4111	.6104	.5801
10		.1017	.1029	.1017	.3637	.5596	.4973
11	.5087	.547	.4239	.4012	.0848	.0686	.0633
12	.5596	.7127	.5935	.4428	.0678	.0857	.0633
13	.6274		.6104	.506	.0848	.0857	.0633
14	.5935		.5426	.5218	.0848	.0857	.0655
15	.6274	.547	.5087	.506	.0848	.0686	.0633
16	.5426	.6464	.4917	.4744	.0339	.0686	.0655
17	.5765	.6133	.5426	.4428	.0339	.0857	.0791
18	.5087	.4807	.4409	.3479	.1187	.12	.1311
19	.1696	.1696	.1696	.1562	.1696	.1865	.1802
20	.1865	.1865	.1865	.1562	.1696	.1696	.1802
21	.1696	.1696	.1696	.1423	.1696	.1696	.1638
22	.1187	.1357	.1357	.1107	.1187	.1357	.1311
23	.1017	.1017	.1187	.0949	.1017	.1187	.1147
24		.0848	.0848	.1017	.0791	.0848	.1017
Max	.6274	.7127	.6104	.5218	.4111	.6104	.5801
Min	.1017	.0848	.0848	.0848	.0339	.0686	.0633
Avg	.4070	.2414	.2489	.2217	.1604	.2165	.1965

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 201 / 11 KV BELONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.4954	.2667	.2254	.1905	.1905	.3294
2	.2427	.5335	.2858	.2427	.1715	.1715	.3294
3	.2774	.5716	.3048	.2774	.1524	.1524	.3294
4	.3121	.5335	.3429	.2947	.1524	.1715	.3294
5	.3467	.5716	.381	.3121	.1905	.1905	.3294
6	.3641	.5906	.4763	.3294	.3239	.3239	.3294
7	.3988	.6097	.5716	.3467	.4763	.4191	.3294
8	.5375	.9335	.8383	.4161	.4382	.4572	.3988
9	.6762	.8764	.8192	.4334	.4572	.4763	.4681
10	.3988	.4382	.4001	.6415	.6097	.724	.5721
11	.381	.3239	.2858	.8192	.5906	.6762	.8002
12	.2286	.2477	.2254		.7049	.7455	.8192
13	.1715	.2286			.6859	.7108	.4763
14	.1524	.2096	.2254		.7049	.6935	.4382
15	.1524	.1905	.156	.7049	.743	.6415	.4763
16	.1524	.2096	.156	.8192	.6668	.6068	.6097
17	.2477	.2286	.2254	.7811	.8002	.5548	.5716
18	.3239	.362	.3121	.362	.362	.2601	.362
19	.5335	.5144	.4854	.5525	.5144	.3641	.4954
20	.5144	.5335	.4681	.5144	.5335	.4681	.4954
21	.4954	.4763	.4334	.4572	.4954	.3988	.4763
22	.381	.3239	.3467	.362	.381	.3294	.4001
23	.2477	.2858	.2427	.2477	.2667	.3294	.2858
24	.1907	.4763	.2477	.1907	.2096	.2096	.3294
Max	.6762	.9335	.8383	.8192	.8002	.7455	.8192
Min	.1524	.1905	.156	.1907	.1524	.1524	.2858
Avg	.3306	.4485	.3694	.4443	.4509	.4277	.4492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 203 / 11 KV MOWAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1143	.1143	.1307	.1143	.1334	.2241
2	.1494	.0953	.0953	.1307	.1143	.1143	.2241
3	.1494	.0953	.0953	.1494	.1334	.1143	.2241
4	.168	.1143	.1143	.1494	.1334	.1334	.2241
5	.168	.1334	.1334	.1494	.1524	.1334	.208
6	.1867	.1524	.1905	.1494	.1905	.1524	.2241
7	.2054	.1715	.2096	.1494	.2286	.1524	.2241
8	.2241	.2286	.2477	.1867	.2286	.2096	.2054
9	.2614	.2477	.2286	.2427	.2667	.1905	.2054
10	.2614	.2667	.2477	.2054	.3239	.2286	.2054
11	.2286	.2096	.2477	.2096	.3048	.2241	.2286
12	.2096	.2096			.2286	.1867	.2286
13	.1905	.1905	.2427	.2286	.2286	.1867	.2096
14	.2096	.1715	.2241		.2096	.1867	.1715
15	.2096	.1905	.2241	.2096	.2096	.2054	.1905
16	.2096	.2096	.2054	.2096	.2096	.2054	.1905
17	.2286	.1905	.2054	.2096	.2477	.2241	.1715
18	.2477	.1905	.2241	.2286	.2667	.2427	.2286
19	.4001	.2286	.3547	.3048	.3239	.2427	.3429
20	.3048	.2667	.2987	.2477	.3048	.2614	.3048
21	.2667	.2286	.2614	.2096	.2477	.2427	.2667
22	.2286	.1905	.2241	.1905	.2096	.2241	.2286
23	.1524	.1334	.1494	.1524	.1715	.2241	.2096
24	.1307	.1334	.1143	.1307	.1334	.1524	.0373
Max	.4001	.2667	.3547	.3048	.3239	.2614	.3429
Min	.1307	.0953	.0953	.1307	.1143	.1143	.0373
Avg	.2134	.1818	.2023	.1898	.2159	.1905	.2158

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 204 / 11 KV MANIKWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1823	.5335	.5144	.1658	.1715	.1524	.2321
2	.2155	.5716	.5525	.1658	.1524	.1334	.2321
3	.2486	.6097	.5906	.1658	.1524	.1334	.2155
4	.2984	.6478	.6287	.1823	.1715	.1524	.2155
5	.3481	.6859	.6668	.1823	.1715	.1905	.2155
6	.3978	.724	.6859	.1823	.1905	.2096	.2155
7	.431	.7621	.7049	.1823	.1905	.2286	.2155
8	.5636	1.1622	1.0479	.1989	.2096	.2096	.1715
9	.7127	1.2193	1.2574	.1823	.2096	.2096	.1823
10	.1823	.2096	.2286	.6962	.8764	.8764	.7127
11	.2096	.1715	.2286	1.0288	1.105	.9779	1.1241
12	.1905	.1334	.1658		1.086	.9779	1.1241
13	.1334	.1524		1.1431	1.1622	.9448	1.0479
14	.1715	.1334	.1311	1.086	1.1622	.9116	.9335
15	.1524	.1334	.1326	1.0098	1.1622	.9448	.9526
16		.1524	.1475	.9907	1.0669	.9614	.9717
17	.1334	.1524	.1492	.9526	1.086	.8951	.8573
18	.2096	.2286	.1658	.2286	.1715	.1429	.2096
19	.362	.3429	.2984	.3429	.3429	.2321	.362
20	.3429	.362	.2984	.3429	.3429	.2984	.3429
21	.3048	.3429	.2984	.3239	.3429	.2652	.3239
22	.2477	.2477	.2321	.2858	.2858	.2321	.2667
23	.2096	.2096	.1989	.2096	.2286	.2321	.1905
24	.1492	.4763	.4572	.1658	.1905	.1715	.2321
Max	.7127	1.2193	1.2574	1.1431	1.1622	.9779	1.1241
Min	.1334	.1334	.1311	.1658	.1524	.1334	.1715
Avg	.2781	.4319	.4253	.4528	.5096	.4452	.4811

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 205 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0191	.0572	.0446	.0381	.0381	.0297
2	.0149	.0191	.0381	.0446	.0191	.0381	.0297
3	.0149	.0191	.0191	.0446	.0191	.0191	.0446
4	.0297	.0381	.0191	.0446	.0191	.0191	.0446
5	.0446	.0572	.0381	.0446	.0191	.0191	.0446
6	.0446	.0572	.0381	.0446	.0381	.0381	.0446
7	.0446	.0762	.0572	.0446	.0572	.0381	.0446
8	.0446	.0572	.0572	.0446	.0381	.0572	.0446
9	.0446	.0572	.0572	.0446	.0572	.0572	.0446
10	.0446	.0572	.0572	.0446	.0572	.0572	.0446
11	.0762	.0572	.0572	.0572	.0572	.0446	.0572
12	.0762	.0572	.0446	.0572	.0762	.0446	.0572
13	.0381	.0572	.0446	.0381	.0572	.0446	.0572
14	.0381	.0572	.0446	.0381	.0572	.0446	.0572
15	.0762	.0381	.0446	.0572	.0572	.0297	.0572
16	.0572	.0572	.0446	.0572	.0572	.0297	.0572
17	.0572	.0572	.0446	.0572	.0572	.0297	.0572
18	.0572	.0381	.0297	.0191	.0572	.0297	.0572
19	.0572	.0381	.0446	.0381	.0572	.0297	.0762
20	.0572	.0381	.0594	.0191	.0572	.0297	.0762
21	.0762	.0381	.0446	.0381	.0572	.0297	.0572
22	.0572	.0381	.0446	.0572	.0762	.0297	.0762
23	.0381	.0381	.0446	.0381	.0762	.0297	.0572
24	.0147	.0381	.0572	.0446	.0381	.0572	.0297
Max	.0762	.0762	.0594	.0572	.0762	.0572	.0762
Min	.0147	.0191	.0191	.0191	.0191	.0191	.0297
Avg	.0466	.0461	.0453	.0443	.0500	.0368	.0519

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 206 / 11 KV BORKHEDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.0191	.0191	.1429	.2096	.2667	.0143
2	.0143	.0191	.0191	.1572	.2477	.2858	.0143
3	.0143	.0191		.1715	.2858	.3048	.0143
4	.0143	.0191	.0191	.1858	.3239	.3239	.0143
5	.0143	.0191	.0191	.2	.3429	.3429	.0143
6	.0143	.0191	.0191	.2143	.381	.3429	.0143
7	.0143	.0191	.0191	.2286	.4001	.362	.0143
8	.0143	.0191	.0191	.4001	.5335	.4954	.0143
9	.0143	.0191	.0381	.443	.5906	.5525	.0143
10	.2572	.4763	.4191	.0141	.0191	.0191	.2715
11	.5716	.7049	.6097		.0191	.0143	.5335
12	.6668	.8002			.0191	.0143	.5525
13	.743	.7621	.4715	.0191	.0191	.0147	.5335
14	.724	.7621	.4858	.0191	.0191	.0143	.4763
15	.7621	.7049	.4793	.0191	.0191	.0143	.4572
16	.8002	.6668	.4858	.0191	.0191	.0143	.4191
17	.5144	.6097	.4715	.0191	.0191	.0143	.362
18	.0191	.0191	.0143	.0191	.0191	.0143	.0191
19	.0381	.0191	.0282	.0381	.0381	.0143	.0191
20	.0381	.0381	.0282	.0191	.0191	.0143	.0191
21	.0191	.0381	.0286	.0191	.0381	.0143	.0191
22	.0191	.0191	.0286	.0191	.0191	.0143	.0191
23	.0191	.0191	.0143	.0191	.0191	.0143	.0191
24	.6001	.0191	.0191	.1286	.1715	.1524	.0143
Max	.8002	.8002	.6097	.443	.5906	.5525	.5525
Min	.0143	.0191	.0143	.0141	.0191	.0143	.0143
Avg	.2467	.2429	.1707	.1143	.158	.1514	.1610



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV NARKHED URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6668	.6268	.7164	.4763	.7164	.7164
2	.7621	.6668	.6268	.7164	.4763	.7164	.6268
3	.7621	.6668	.5373	.7164	.4763	.7164	.6268
4	.7621	.6668	.5373	.7164	.4763	.7164	.5373
5	.7621	.6668	.6268	.7164	.4763	.7164	.5373
6	.7621	.7621	.7164	.8059	.4763	.7164	.7164
7	.9526	.7621	.8954	.8954	.7621	.8954	.8954
8	1.1431	1.1431	.8954	1.0745	.9526	1.2536	.8954
9	1.1431	1.0479	1.2536	1.0745	.9526	1.1641	1.0745
10	1.2384	1.1431	1.0745	.8954	.9526	1.0745	.4477
11	.8059	1.1431	1.3336	.8059	.8059	1.0479	.2686
12	.8954	1.1431	1.1431	.8059	.8954	.9526	
13	.8059	.9526	.9526	.7164	.7164	1.105	
14	.7164	.8573	.7621	.7164	.5373	.9526	.8954
15	.7164	.7621	.7621	.6268	.6268	.8573	.8059
16	.6268	.9526	.9526	.6268	.7164	.7621	.7164
17	.9526	.8954	.8954	.5716	.6268	.7164	.8059
18	.9526	1.0745	.8059	.6668	.8059	1.0745	.9526
19	.9526	1.2536	1.0745	.7621	1.0745	1.0745	.9526
20	1.0479	1.1641	1.0745	.8573	1.0745	1.0745	.9526
21	1.0479	1.0745	.985	.8573	.985	.985	.9526
22	.7621	.985	.8954	.6668	.8954	.8954	.8573
23	.6668	.7164	.8059	.5716	.8059	.8059	.7621
24	.7621	.6668	.6268	.7164	.5716	.7164	.7164
Max	1.2384	1.2536	1.3336	1.0745	1.0745	1.2536	1.0745
Min	.6268	.6668	.5373	.5716	.4763	.7164	.2686
Avg	.8651	.9097	.8692	.7623	.7340	.9044	.7597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV YENIKONI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8573	.6081	.0154	.0191	.016	.6401
2	.8383	.8573	.6081	.0154	.0191	.016	.6401
3	.8383	.8573	.5921	.0154	.0191	.016	.6722
4	.8573	.8573	.5921	.0154	.0191	.016	.6562
5	.8573	.8573	.6241	.0154	.0191	.016	.6401
6	.8764	.8573	.7042	.0154	.0191	.016	.7362
7	1.3336	1.105	.8802	.0154	.0191	.016	.9122
8	1.467	1.6004	1.2003	.0154	.0191	.016	1.0883
9	1.3908	1.6194	1.2163	.0154	.0191	.016	1.0883
10	.0191	.0191	.016	.679	1.0288	.8802	.016
11	.0154	.0191	.0191	1.2483	1.0648	1.0669	.0154
12	.0154	.0191	.0191	1.2003	1.2191	1.086	.0154
13	.0154	.0191	.0191	1.1523	1.0802	1.1431	.0154
14	.0154	.0191	.0191	1.1523	1.1111	1.2003	.0154
15	.0154	.0191	.0191	1.1363	1.0957	1.2384	.0154
16	.0154	.0191	.0191	1.1203	1.0648	1.2003	.0154
17	.0191	.016	.0154	1.3336	1.1683	1.0082	.0154
18	.0191	.016	.0154	.0191	.016	.016	.0191
19	.0191	.016	.0154	.0191	.016	.016	.0191
20	.0191	.016	.0154	.0191	.016	.016	.0191
21	.0191	.016	.0154	.0191	.016	.016	.0191
22	.0191	.016	.0154		.016	.016	.0191
23	.0191	.016	.0154		.016	.016	.0191
24	.8192	.8573	.5601	.0154	.0191	.016	.5761
Max	1.467	1.6194	1.2163	1.3336	1.2191	1.2384	1.0883
Min	.0154	.016	.0154	.0154	.016	.016	.0154
Avg	.4317	.4405	.326	.4206	.3800	.3783	.3287

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV NARKHED RURAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8573	.7956	.0166	.0191		.8288
2	.9335	.8573	.7956	.0166	.0191	.0166	.8453
3	.9335	.8573	.7625	.0166	.0191	.0166	.8453
4	.9145	.8573	.779	.0166	.0191	.0166	.8288
5	.9145	.8573	.8122	.0166	.0191	.0166	.7956
6	.8954	.9145	.8453	.0166	.0191	.0166	.8288
7	1.1241	1.105	.9116	.0166	.0191	.0166	.9779
8	1.3146	1.448	1.326	.0166	.0191	.0166	1.3094
9	1.5623	1.2384	1.4255	.0166	.0191	.0166	1.3757
10	.0191	.0191	.0166	1.0277	1.1431	1.094	.0166
11	.0166	.0191	.0191	1.6078	1.2266	1.448	.0166
12	.0166	.0191	.0191	1.5746	1.2929	1.5623	
13	.0166	.0191	.0191	1.5415	1.2266	1.5242	
14	.0166	.0191	.0191	1.4918	1.3094	1.5051	.0166
15	.0166	.0191	.0191	1.3757	1.3592	1.467	.0166
16	.0166	.0191	.0191	1.2763	1.326	1.467	.0166
17	.0191	.0166	.0166	1.467	1.2763	1.2929	.0166
18	.0191	.0166	.0166	.0191	.0166	.0166	.0191
19	.0191	.0166	.0166	.0191	.0166	.0166	.0191
20	.0191	.0166	.0166	.0191	.0166	.0166	.0191
21	.0191	.0166	.0166	.0191	.0166	.0166	.0191
22	.0191	.0166	.0166		.0166	.0166	.0191
23	.0191	.0166	.0166	.0191	.0166	.0166	.0191
24	.9335	.8573	.7459	.0166	.0191	.0166	.7956
Max	1.5623	1.448	1.4255	1.6078	1.3592	1.5623	1.3757
Min	.0166	.0166	.0166	.0166	.0166	.0166	.0166
Avg	.4463	.4208	.3936	.5054	.4354	.5048	.4384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV SARDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8383	.7625	.0158	.0191	.0166	.7625
2	.9526	.8383	.7625	.0158	.0191	.0166	.7625
3	.9526	.8383	.779	.0158	.0191	.0166	.7459
4	.9526	.8383	.7625	.0158	.0191	.0166	.7459
5	.9145	.8764	.7459	.0158	.0191	.0166	.7625
6	.8954	.9145	.7625	.0158	.0191	.0166	.8619
7	1.4861	1.8099	.9614	.0158	.0191	.0166	1.0111
8	1.6004	1.8099	1.4089	.0158	.0191	.0166	1.0608
9	1.7337	1.6385	1.4586	.0158	.0191	.0166	1.0608
10	.0191	.0191	.0166	.8223	1.2384	.7956	.0166
11	.0158	.0191	.0191	1.4918	1.1227	1.4289	.0158
12	.0158	.0191	.0191	1.4586	1.2651	1.5813	.0158
13	.0158	.0191	.0191	1.4255	1.3599	1.5242	.0158
14	.0158	.0191	.0191	1.3923	1.2967	1.4289	.0158
15	.0158	.0191	.0191	1.326	1.2334	1.3908	.0158
16	.0158	.0191	.0191	1.2929	1.2018	1.4861	.0158
17	.0191	.0166	.0158	1.4098	1.3426	1.2929	.0158
18	.0191	.0166	.0158	.0191	.0166	.0166	.0191
19	.0191	.0166	.0158	.0191	.0166	.0166	.0191
20	.0191	.0166	.0158	.0191	.0166	.0166	.0191
21	.0191	.0166	.0158	.0191	.0166	.0166	.0191
22	.0191	.0166	.0158		.0166	.0166	.0191
23	.0191	.0166	.0158		.0166	.0166	.0191
24	.9526	.8383	.7459	.0158	.0191	.0166	.7127
Max	1.7337	1.8099	1.4586	1.4918	1.3599	1.5813	1.0608
Min	.0158	.0166	.0158	.0158	.0166	.0166	.0158
Avg	.4850	.4788	.3913	.4933	.4313	.4664	.3637

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV KHARSOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.056	.7865	.9717	.9335	.056
2	.0381	.0572	.056	.7701	.9717	.9335	.056
3	.0381	.0572	.056	.7701	.9717	.9522	.056
4	.0381	.0572	.056	.7537	.9717	.9522	.056
5	.0572	.0572	.056		.9717	.9709	.056
6	.0572	.0572	.056		.9717	.9709	.056
7	.0572	.0572	.056	.9667	1.5623	1.1949	.0747
8	.0572	.0572	.056	1.3927	1.7718	1.6804	.056
9	.0762	.0762	.056	1.5238	1.829	1.8484	.056
10	1.3717	1.3336	1.4003	.0762	.0572	.056	1.1949
11	1.6221	1.6194	1.8099	.056	.0572	.0381	1.3927
12	1.704	1.848	1.6194	.0373	.0191	.0191	1.4091
13	1.6057	1.6575	1.6194	.0187	.0572	.0191	1.4582
14	1.491	1.5623	1.6194	.0187	.0191	.0191	1.2452
15	1.4746	1.467	1.6194	.056	.0191	.0191	1.278
16	1.4746	1.5432	1.6575	.056	.0191	.0191	1.3272
17	1.6194	1.587	1.5893	.0572	.0187	.0187	1.4091
18	.0572	.0747	.0762	.0572	.056	.0747	.0762
19	.0953	.1494	.1334	.0953	.1307	.112	.0953
20	.1143	.1307	.1334	.1143	.1307	.1307	.1143
21	.1143	.112	.1143	.1143	.112	.112	.1143
22	.1143	.0934	.0953		.0934	.0747	.0953
23	.0762	.0747	.0762		.056	.056	.0762
24	.0191	.0572	.056	.7865	.9717	.9149	.056
Max	1.704	1.848	1.8099	1.5238	1.829	1.8484	1.4582
Min	.0191	.0572	.056	.0187	.0187	.0187	.056
Avg	.5588	.5994	.5885	.4254	.5338	.5050	.4944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV PARSODI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.017	.3795	.4763	.4024	.0168
2	.0381	.0381	.0168	.3795	.4763	.4024	.0168
3	.0381	.0381	.0168	.3795	.4763	.4191	.0168
4	.0381	.0381	.0168	.3795	.4763	.4359	.0168
5	.0381	.0381	.0168	.3795	.4954	.4191	.0168
6	.0381	.0381	.0168	.3795	.5144	.4527	.0168
7	.0381	.0191	.0168	.5535	.9907	.7042	.0168
8	.0381	.0191	.0168	.9488	1.1431	1.1065	.0168
9	.0191	.0191	.0335	1.0437	1.1812	1.0898	.0168
10	.8954	.724	.6874	.0158	.0381	.0168	.5868
11	.9804	1.2955	1.1431	.0168	.0158	.0191	.8697
12	.9488	1.467	1.4289	.0168	.0158	.0191	1.0279
13	1.0753	1.3527	1.3717	.0168	.0158	.0381	1.0911
14	1.1385	1.3908	1.3336	.0168	.0158	.0381	1.0595
15	1.1069	1.3336	1.3336	.0168	.0158	.0381	1.0595
16	1.0595	1.3908	1.3336	.0168		.0191	1.0437
17	1.3908	1.2239	1.1069	.0381	.0168	.0168	.9804
18	.0191	.0168	.0158	.0381	.0335	.0168	.0381
19	.0381	.0335	.0316	.0381	.0335	.0335	.0381
20	.0381	.0335	.0316	.0381	.0335	.0335	.0381
21	.0381	.0335	.0316	.0381	.0335	.0335	.0381
22	.0381	.0335	.0316	.0381	.0168	.0335	.0381
23	.0381	.0168	.0316	.0191	.0168	.0168	.0381
24	.0191	.0381	.0168	.3795	.4572	.3856	.0168
Max	1.3908	1.467	1.4289	1.0437	1.1812	1.1065	1.0911
Min	.0191	.0168	.0158	.0158	.0158	.0168	.0168
Avg	.3804	.4446	.4207	.2320	.3039	.2579	.3381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 207 / 11 kv Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5716	.6783	.5487	.4191	.9496	.8817
2	.3429	.5716	.6783	.5144	.4191	.9835	.8478
3	.3429	.5716	.6952	.5144	.4191	.9835	.8478
4	.3429	.5716	.6783	.4801	.4001	.017	.8139
5	.362	.5716	.6443	.4801	.4001	.1187	.8139
6	.381	.6097	.5935	.463	.4001	.1357	.78
7	.7621	.8383	.5935	.5144	.7621	.1357	.763
8	.8954	1.0669	1.1022	.9431	.8573	.8309	.6613
9	.9145	.4191	.9326	.9088	1.1812	.8987	.5256
10	.8954	.7049	1.0004	1.0288	1.1431	.9326	.7461
11	.6687	.7621	1.0479	1.0174	1.0288	1.086	.8745
12	.7202	.8192	.9526	1.0174	.9945	1.1241	
13	.7373	.8573	.9526	1.0174	.8916	1.1431	
14	.7545	.9526	.9526	.8478	.6687	1.2003	.6173
15	.7716	1.0098	1.0288	.5426	.7202	1.2574	.7716
16	.7716	1.0669	1.0479	.4239	1.046	1.2193	.8573
17	.9526	1.0343	.9431	.2858	1.153	1.17	.8573
18	1.0288	1.0682	1.046	.3048	.7291	.9156	1.086
19	.8573	.5596	.9602	.2477	.5596	.9156	1.0288
20	.8383	.5765	.8573	.1905	.6783	.8987	.9907
21	.8573	.5935	.7888	.1715	.8478	.8478	.9526
22	.6859	.5935	.6173	.2286	.9156	.8139	.9526
23	.5716	.6783	.6173	.3048	.9496	.8478	.9526
24	.3239	.5525	.6952	.6173	.4191	.9835	.8987
Max	1.0288	1.0682	1.1022	1.0288	1.1812	1.2574	1.086
Min	.3239	.4191	.5935	.1715	.4001	.017	.5256
Avg	.6717	.7342	.8377	.5672	.7501	.8504	.8419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 208 / 11 KV YENIKONI II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.7718	1.5432	.0328	.0381	.0343	1.5432
2	1.6385	1.7718	1.5432	.0328	.0381	.0343	1.5432
3	1.6385	1.7718	1.5089	.0328	.0381	.0343	1.5089
4	1.6575	1.7718	1.5261	.0328	.0381	.0343	1.4918
5	1.6956	1.7909	1.5775	.0328	.0381	.0343	1.5261
6	1.7147	1.829	1.6632	.0328	.0381	.0343	1.7147
7	2.6292	2.3053	2.2462	.0492	.0572	.0686	2.0576
8	2.7244	2.6673	2.915	.0492	.0572	.0514	2.4691
9	2.9721	3.0102	2.9835	.0492	.0572	.0514	2.3148
10	.0381	.0381	.0343	1.9662	2.2672	2.0405	.0343
11	.0328	.0191	.0381	2.8121	2.343	2.6673	.0328
12	.0328	.0191	.0381	2.7435	2.4086	2.915	.0328
13	.0328	.0191	.0381	2.572	2.4577	2.8959	.0328
14	.0328	.0191	.0572	2.4691	2.3102	2.915	.0328
15	.0328	.0381	.0381	2.3663	2.1956	2.8959	.0328
16	.0164	.0381	.0381	2.2291	2.3102	2.8578	.0328
17	.0191	.0343	.0164	2.6673	2.3148	2.1605	.0328
18	.0381	.0686	.0328	.0572	.0514	.0514	.0572
19	.0572	.0857	.0983	.0953	.1029	.0857	.0762
20	.0953	.0857	.0983	.1143	.1029	.1029	.0953
21	.0953	.0686	.0819	.1143	.0857	.0857	.0953
22	.0953	.0686	.0655	.0762	.0686	.0686	.0762
23	.0572	.0514	.0492	.0572	.0514	.0514	.0572
24	1.6194	1.7718	1.5089	.0328	.0381	.0343	1.5089
Max	2.9721	3.0102	2.9835	2.8121	2.4577	2.915	2.4691
Min	.0164	.0191	.0164	.0328	.0381	.0343	.0328
Avg	.8585	.8798	.8225	.8632	.8129	.9252	.7667



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 209 / 11 KV Tinkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0324	.6009	.6859	.6154	.0324
2	.0381	.0381	.0324	.6009	.7049	.6154	.0324
3	.0381	.0381	.0324	.6009	.7049	.5992	.0324
4	.0381	.0381	.0324	.6009	.7049	.583	.0324
5	.0572	.0381	.0324	.6009	.724	.5992	.0324
6	.0572	.0572	.0324	.6009	.7811	.6316	.0324
7	.0572	.0572	.0486	.7274	1.1431	.7935	.0648
8	.0762	.0762	.0648	.8855	1.2574	.9069	.0648
9	.0762	.0572	.0486	.9804	1.2384	.9717	.0486
10	.9907	.9907	.8907	.0474	.0381	.0486	.6802
11	1.0279	1.1812	1.2384	.0486	.0316	.0381	.8539
12	1.0437	1.3146	1.2193	.0324	.0158	.0381	.9172
13	1.0437	1.2765	1.1812	.0324	.0316	.0381	.9646
14	1.0279	1.1812	1.0669	.0162	.0158	.0381	.9172
15	.9488	1.1241	1.0479	.0162	.0158	.0381	.9014
16	.8539	1.1431	1.105	.0324	.0158	.0381	.8855
17	1.1812	1.0364	.933	.0381	.0162	.0324	.8697
18	.0381	.0486	.0316	.0381	.0324	.0486	.0572
19	.0572	.081	.0791	.0572	.081	.0648	.0572
20	.0762	.081	.0791	.0762	.081	.0648	.0762
21	.0762	.0648	.0633	.0762	.0648	.0648	.0762
22	.0762	.0486	.0474	.0572	.0486	.0486	.0572
23	.0381	.0324	.0474	.0381	.0324	.0324	.0381
24	.0381	.0381	.0324	.6009	.6859	.583	.0324
Max	1.1812	1.3146	1.2384	.9804	1.2574	.9717	.9646
Min	.0381	.0324	.0316	.0162	.0158	.0324	.0324
Avg	.3748	.4200	.3925	.3086	.3813	.3139	.3232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 201 / 11 KV SONOLI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0848	.0905	.0905	.0905	.0905	.0905
2	.0905	.0848	.0905	.0905	.0905	.0905	.0905
3	.0905	.0848	.0905	.0905	.0905	.0905	.0905
4	.9503	.9448	.9717	.0905	.0905	.0905	.0905
5	.9831	.9116	1.004	.0905	.0905	.0905	.0905
6	1.0159	.9945	1.0364	.0905	.0905	.0905	.0905
7	1.065	1.2929	1.2146	.0905	.0905	.0905	.0905
8	1.4746	1.442	1.4899	.0905	.0905	.0905	.0905
9	1.7695	1.6244	1.5729	.0905	.0905	.0905	.0905
10	1.7204	1.9559	1.8351	.0905	.0905	.0905	.0905
11	1.6575	1.9757	1.7695	.0905	.0905	.0905	.0905
12	.0995	.0905	.1086	1.3927	1.2631	1.2631	1.3279
13	.1187	.0905	.1086	2.0481	1.2955	1.2955	1.3765
14	.1017	.0905	.1086	1.9662	1.3765	1.3765	1.4089
15	.1017	.0905	.1086	1.9334	1.4089	1.4575	1.4575
16	.1017	.0905	.0905	1.8023	1.4575	1.7004	1.4899
17	.1017	.0905	.0905	1.8023	1.4251	1.587	1.2955
18	.1017	.0905	.0905	1.5565	1.2146	1.3117	1.2308
19	.1357	.0905	.1086	1.2289	1.1012	1.166	1.1012
20	.1357	.1086	.1448	.1448	.1448	.1448	.1448
21	.1187	.1086	.1448	.1448	.1448	.1086	.1448
22	.1017	.0905	.0905	.0905	.0905	.0905	.0905
23	.1017	.0905	.0905	.0905	.0905	.0905	.0905
24	.0905	.0848	.0905	.0905	.0905	.0905	.0905
Max	1.7695	1.9757	1.8351	2.0481	1.4575	1.7004	1.4899
Min	.0905	.0848	.0905	.0905	.0905	.0905	.0905
Avg	.5133	.5251	.5226	.6370	.5041	.5283	.5102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 202 / 11 KV NANDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0867	.0914	.1097	.1097	.1097	.1097
2	.1086	.0867	.0914	.1086	.1097	.0914	.0914
3	.0905	.0693	.0732	.0914	.0914	.0914	.0914
4	.852	.9835	.9012	.0732	.0905	.0914	.0914
5	.9012	1.0343	.9175	.0914	.1097	.0914	.0914
6	.9831	1.1869	.9831	.1097	.128	.1097	.1097
7	1.0159	1.2717	1.0486	.1086	.1267	.1097	.1097
8	1.3435	1.3056	1.4419	.128	.1086	.128	.128
9	1.6057	1.2717	1.6712	.1267	.1448	.1097	.1097
10	1.5893	1.7295	1.8023	.1448	.128	.1097	.1097
11	1.5091	1.7368	1.704	.1267	.128	.1097	.0914
12	.104	.0914	.0905	1.2289	1.4582	1.1633	1.4091
13	.0693	.0914	.0905	1.917	1.5074	1.2289	1.4746
14	.0693	.0732	.0905	1.8187	1.5565	1.3435	1.5074
15	.0867	.0732	.0905	1.7532	1.5893	1.4255	1.5565
16	.0867	.0732	.1086	1.7532	1.6876	1.5402	1.5565
17	.0867	.0732	.0905	1.6221	1.5238	1.5729	1.3108
18	.1214	.0914	.1448	1.4419	1.3272	1.3435	1.1469
19	.208	.2195	.2353	1.3927	1.1961	1.1797	1.0322
20	.2254	.2195	.2378	.2353	.2378	.2378	.2378
21	.208	.2012	.2172	.2012	.2012	.1463	.2195
22	.156	.1463	.1448	.1646	.1646	.1646	.1829
23	.104	.1097	.1097	.1267	.1463	.128	.1463
24	.1086	.0867	.0914	.1097	.1097	.1097	.1097
Max	1.6057	1.7368	1.8023	1.917	1.6876	1.5729	1.5565
Min	.0693	.0693	.0732	.0732	.0905	.0914	.0914
Avg	.4892	.5130	.5195	.6243	.5825	.5307	.5427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 203 / 11 KV MALAPUR SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0514	.056	.0543	.0543	.056	.056
2	.0543	.0514	.056	.0543	.0543	.056	.056
3	.0543	.0514	.056	.0543	.0543	.056	.056
4	.0543	.0514	.056	.0838	.0838	.081	.0819
5	.0543	.0514	.056	.0838	.0838	.081	.0819
6	.0543	.0514	.056	.0838	.0838	.081	.0819
7	.0543	.0514	.056	.0503	.1006	.2591	.0819
8	.0543	.0514	.056	.2949	.2458	.4858	.2949
9	.0543	.0514	.0543	.6226	.6226	.5735	.5668
10	.0543	.0514	.0543	.6882	.6554	.7209	.6554
11	.0514	.0549	.0543	.6554	.6718	.6554	.7125
12	.218	.5735	.3277	.0543	.0549	.0549	.0549
13	.8718	.6554	.7373	.0543	.0549	.0543	.0549
14	.8718	.6882	.852	.0543	.0549	.0549	.0549
15	.8718	.7045	.8029	.0543	.0549	.0549	.0549
16	.8383	.7209	.6554	.0543	.0549	.0549	.0549
17	.8048	.7537	.6554	.0543	.0549	.056	.0549
18	.6371	.7045	.4096	.0543	.0549	.056	.0549
19	.3353	.3277	.3277	.0905	.0549	.056	.0549
20	.0514	.056	.0905	.0905	.0549	.056	.0549
21	.0514	.056	.0905	.0905	.0549	.056	.0549
22	.0514	.056	.0905	.0905	.0549	.056	.056
23	.0514	.056	.0905	.0905	.0549	.056	.056
24	.0543	.0514	.056	.0543	.0543	.056	.056
Max	.8718	.7537	.852	.6882	.6718	.7209	.7125
Min	.0514	.0514	.0543	.0503	.0543	.0543	.0549
Avg	.2626	.2489	.2415	.1505	.1427	.1595	.1434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 204 / 11KV MANNATH AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1254	.1478	.128	.1463	.1663	.1478
2	.1267	.1254	.1294	.128	.1463	.1478	.1478
3	.1267	.1075	.1294	.128	.1463	.1478	.1294
4	.1267	.1254	.1294	1.2289	1.2452	1.2929	1.1768
5	.1267	.1254	.1294	1.278	1.278	1.3094	1.1934
6	.1448	.1433	.1478	1.3108	1.3435	1.4255	1.2597
7	.1646	.1433	.1663	1.3927	1.4255	1.5581	1.3923
8	.1463	.1433	.1294	1.9826	1.9498	2.0885	1.9062
9	.1448	.1791	.1267	2.2119	2.3102	1.989	2.5194
10	.1463	.1433	.1267	2.1628	2.2874	1.9393	2.2045
11	.1433	.1294	.1448	2.0645	2.2377	1.9725	2.0891
12	1.6617	1.6409	1.4746	.1086	.0995	.0924	.1109
13	2.3569	1.7404	2.0317	.1448	.1109	.0924	.1109
14	2.3739	1.9559	2.3102	.1267	.1109	.0924	.1109
15	2.3908	1.989	2.1792	.128	.1294	.0739	.1109
16	2.323	2.0222	2.0972	.1267	.1294	.0739	.1294
17	2.2043	2.0056	2.2119	.1097	.1109	.1109	.1478
18	1.9669	1.7901	1.6385	.2172	.1663	.2033	.1478
19	1.6956	1.4586	1.5565	.3077	.3326	.2957	.3511
20	.3045	.3326	.3077	.3292	.3326	.2772	.3326
21	.2686	.2957	.2715	.2743	.2772	.2587	.3142
22	.2328	.2033	.2195	.2378	.2218	.2218	.2772
23	.1612	.1663	.1463	.181	.1848	.1848	.1848
24	.1463	.1433	.1478	.128	.1646	.1663	.1663
Max	2.3908	2.0222	2.3102	2.2119	2.3102	2.0885	2.5194
Min	.1267	.1075	.1267	.1086	.0995	.0739	.1109
Avg	.8171	.7181	.7542	.6848	.7036	.6742	.6942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 205 / SAWARGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0876	.0914	.1086	.1086	.1097	.0905
2	.0905	.0876	.0914	.1075	.0886	.0914	.0905
3	.0905	.0876	.0914	.0895	.0886	.0914	.0905
4	.0724	.0876	.0914	.0895	.0886	.0914	.0905
5	.0905	.0876	.0914	.1075	.124	.1097	.0905
6	.1267	.1052	.1097	.1433	.1433	.1463	.1086
7	.1448	.1578	.1829	.1267	.1612	.1463	.1629
8	.181	.2103	.1949	.1612	.1949	.1829	.181
9	.2353	.2103	.1772	.2126	.2126	.181	.2353
10	.2172	.2103	.2172	.2303	.1991	.2172	.2353
11	.1753	.181	.1991	.2126	.181	.1448	.2172
12	.1578	.181	.1991	.1772	.1629	.1448	.1448
13	.1578	.1629	.1448	.1772	.1448	.1267	.1448
14	.1753	.1448	.181	.1629	.1267	.1267	.1267
15	.1928	.1448	.1448	.1629	.1267	.1086	.1629
16	.1753	.1629	.1629	.1629	.1991	.1629	.181
17	.1928	.2534	.1629	.1629	.1629	.181	.1991
18	.1928	.1991	.2172	.2303	.181	.2172	.1991
19	.2454	.2534	.2896	.2658	.2172	.2534	.2715
20	.2454	.2353	.2507	.2481	.2534	.2534	.2534
21	.2103	.2353	.2172	.2126	.2172	.2172	.2353
22	.1753	.1448	.181	.1949	.181	.181	.2172
23	.1227	.1267	.1267	.1448	.1629	.181	.181
24	.1086	.1052	.1097	.1075	.1267	.1463	.1267
Max	.2454	.2534	.2896	.2658	.2534	.2534	.2715
Min	.0724	.0876	.0914	.0895	.0886	.0914	.0905
Avg	.1611	.1609	.1636	.1666	.1605	.1588	.1682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 201 / 11 KV MOHGAON-JATAMZARI-  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.0772	.0772	1.0185	1.0279	1.012	.0625
2	.0617	.0772	.0772	1.034	1.0279	1.0437	.0625
3	.0617	.0772	.0772	1.034	1.0437	1.0753	.0625
4	.0617	.0772	.0772	1.0494	1.0595	1.1385	.0625
5	.0617	.0772	.0772	1.0494	1.0753	1.1702	.0625
6	.0772	.0772	.0772	1.0648	1.1069	1.2651	.0781
7	.0772	.0772	.0772	1.2654	1.2492	1.3283	.0781
8	.0617	.0617	.0463	1.6049	1.7553	1.6604	.0625
9	.0463	.0617	.0617	1.929	1.9608	1.5971	.0625
10	1.6204	1.4661	1.25	.0617	.0633	.0633	1.1873
11	2.0216	1.7438	1.8056	.0791	.0474	.0474	1.4232
12	2.0525	2.0062	1.8673	.0791	.0474	.0469	1.6129
13	2.0679	1.9599	2.0216	.0633	.0474	.0469	1.8343
14	2.0525	1.8982	1.9907	.0474	.0474	.0469	1.7553
15	1.9907	1.8364	1.929	.0474	.0474	.0469	1.8027
16	1.9599	1.9444	1.7747	.0633	.0633	.0469	1.4074
17	1.9753	1.8827	1.7747	.0633	.0474	.0469	1.4074
18	.0617	.0617	.0617	.0791	.0633	.0937	.0949
19	.1543	.1698	.1543	.1739	.1581	.1562	.1739
20	.1698	.1698	.1543	.1739	.1581	.1718	.1739
21	.1698	.1698	.1389	.1739	.1898	.1718	.1739
22	.1235	.1235	.0926	.1265	.1265	.125	.1265
23	.0772	.0926	.0772	.1265	.0791	.0937	.0949
24	.0772	.0772	.0772	1.0185	1.012	.9804	.0625
Max	2.0679	2.0062	2.0216	1.929	1.9608	1.6604	1.8343
Min	.0463	.0617	.0463	.0474	.0474	.0469	.0625
Avg	.7144	.6777	.6591	.5594	.5627	.5615	.5802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 202 / 11 KV AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1574	1.1574	1.142	.0457	.0463	.0463	1.1111
2	1.1574	1.1883	1.1728	.0457	.0463	.0463	1.1111
3	1.1574	1.1883	1.1728	.0457	.0463	.0463	1.1111
4	1.1574	1.2346	1.1728	.0457	.0463	.0463	1.1111
5	1.1728	1.2963	1.2037	.0457	.0463	.0463	1.1574
6	1.2037	1.2963	1.2037	.0457	.0463	.0463	.0031
7	1.3889	1.5123	1.4661	.0457	.0463	.0463	1.3426
8	1.7438	1.9136	1.8519	.0305	.0463	.0463	1.2191
9	2.0525	2.2685	2.0679	.0305	.0309	.0463	1.5741
10	.0309	.0463	.0309	1.2498	1.5741	1.3272	.0309
11	.0309	.0309	.0305	1.9444	1.929	1.9907	.0312
12	.0309	.0309	.0305	2.3148	1.9907	2.1759	.0312
13	.0309	.0305	.0305	2.284	2.1605	2.2068	.0312
14	.0309	.0305	.0305	2.2685	2.0062	2.1296	.0312
15	.0309	.0305	.0305	2.2377	1.8673	1.9444	.0312
16	.0309	.0305	.0305	2.0833	1.8827	1.8827	.0312
17	.0309	.0305	.0305	1.8982	1.8827	1.821	.0312
18	.0309	.0463	.0457	.0463	.0463	.0463	
19	.0926	.0926	.0762	.0772	.0772	.0926	.0937
20	.0926	.0926	.0914	.0926	.0617	.0926	.0937
21	.0926	.0926	.0762	.0926	.0772	.0926	.0937
22	.0772	.0617	.061	.0772	.0617	.0772	.0781
23	.0617	.0463	.0457	.0463	.0617	.0463	.0469
24	1.142	1.1265	1.1111	.0457	.0463	.0463	1.0648
Max	2.0525	2.2685	2.0679	2.3148	2.1605	2.2068	1.5741
Min	.0309	.0305	.0305	.0305	.0309	.0463	.0031
Avg	.5845	.6198	.5919	.7141	.6719	.6829	.4983



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 203 / 11 kv pipla feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0282	.0429	.0286	.141	.1027	.1174	.0293
2	.0282	.0286	.0286	.141	.1027	.1174	.0293
3	.0282	.0286	.0286	.141	.1027	.1174	.0293
4	.0282	.0286	.0286	.141	.1027	.1174	.0293
5	.0282	.0286	.0286	.141	.1174	.1467	.0293
6	.0282	.0286	.0286	.1269	.1174	.176	.0029
7	.0282	.0286	.0286	.1692	.1174	.1907	.0293
8	.0282	.0286	.0286	.2115	.2347	.1907	.0293
9	.0282	.0286	.0286	.282	.2641	.2347	.0293
10	.1974	.2286	.2715	.0423	.0293	.044	.2347
11	.2858	.3395	.3102	.044	.0293	.044	.2526
12	.3429	.3286	.282	.044	.0293	.0293	.2526
13	.3429	.3384	.2397	.0293	.0293	.0293	
14	.2858	.3666	.2256	.0293	.0293	.0293	.2526
15	.3001	.2679	.2679	.0293	.0293	.0293	.2824
16	.3001	.2397	.2961	.0293	.0293	.0293	.2824
17	.2858	.2538	.1974	.0293	.0293	.0293	.2675
18	.0286	.0286	.0423	.044	.044	.044	.0446
19	.0714	.0714	.0564	.0587	.0587	.0587	.0743
20	.0714	.0714	.0564	.0734	.0587	.0734	.0743
21	.0714	.0714	.0423	.0734	.044	.0734	.0743
22	.0572	.0429	.0564	.0587	.0587	.0587	.0594
23	.0429	.0286	.0564	.044	.0587	.044	.0446
24	.0282	.0429	.0286	.1551	.1027	.1174	.0293
Max	.3429	.3666	.3102	.282	.2641	.2347	.2824
Min	.0282	.0286	.0286	.0293	.0293	.0293	.0029
Avg	.1236	.1247	.1119	.0949	.0801	.0892	.1071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 201 / 11 KV KALMBHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0739	.0905	.0739	.0739	.0724	.0716
2	.0739	.0739	.0905	.0739	.0739	.0724	.0724
3	.0739	.056	.0905	.0739	.0747	.0724	.0724
4	.0739	.056	.0905	.0739	.1294	.0724	.0716
5	.0739	.0747	.0905	.2058	.2321	.1187	.0709
6	.0739	.0924	.0905	.2058	.2486	.1526	.0716
7	.0924	.1109	.1267	.2058	.2818	.1526	.0905
8	.1294	.0924	.1086	.2572	.3481	.2204	.0819
9	.0924	.0924	.1086	.4096	.5243	.3222	.0983
10	.1086		.1086	.5087	.4752	.5426	.0819
11	.0905	.0739	.1109	.5256	.4843	.5144	.0747
12	.0905	.0924	.0924	.5087	.4218	.4115	.056
13	.6443	.6173	.5898	.0724	.0492	.0554	.4359
14	.6274	.6859	.4915	.0724	.0492	.0554	.4694
15	.6443	.6173	.5079	.0905		.0532	.4359
16	.6104	.583	.4424	.0905		.0554	.4359
17	.5935	.6173	.426	.0924		.0554	.4527
18	.4752	.4409	.3772	.1097	.0543	.0655	.0343
19	.4424	.373	.3258	.1829	.1448	.1311	.3258
20	.4096	.39	.3258	.1829	.1448	.1448	.3086
21	.1294	.1448	.1294	.1402	.1267	.1267	.1294
22	.1109	.1267	.1109	.104	.1086	.1086	.1109
23	.0747	.1086	.0895	.0924	.0905	.0905	.0739
24	.0739	.0747	.0905	.0739	.0739	.0724	.0716
Max	.6443	.6859	.5898	.5256	.5243	.5426	.4694
Min	.0739	.056	.0895	.0724	.0492	.0532	.0343
Avg	.2451	.2465	.2127	.1845	.2005	.1558	.1749

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 202 / 11 KV ISAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.128	.1629	.1663	.1463	.2172	.1949
2	.1478	.1294	.1629	.1663	.1463	.2172	.197
3	.1478	.1109	.1448	.1663	.1294	.1991	.1991
4	.1294	.1109	.1448	.1663	.1294	.181	.1772
5	.6516	.6464	.5765	.1848	.1646	.1991	.5079
6	.7207	.6062	.6613	.2033	.1646	.2353	.5898
7	.6859	.7045	.7291	.2218	.1478	.1991	.7127
8	.9945	.9995	1.0852	.2218	.1463	.2172	.7968
9	1.2174	.6882	1.5091	.1949	.1478	.1991	1.1717
10	1.3395		1.4413	.2172	.1294	.2172	1.1873
11	1.2887	.1183	1.3108	.1629	.1311	.1663	1.1736
12	1.0513	1.1145	1.1797	.1448	.1311	.1663	1.0395
13	.1629	.1478	.1294	1.4922	1.2654	1.4746	.1307
14	.1267	.1478	.1294	1.543	1.3748	1.5604	.112
15	.1267	.1478	.1478	1.5091		1.4419	.112
16	.1267	.1294	.1294	1.4074		1.4575	.112
17	.1267	.1294	.1294	1.3108		1.3032	.112
18	.1294	.1991	.2218	1.0978	1.0852	1.0311	.2587
19	.2195	.3439	.3326	.8684	1.1191	.8749	.3696
20	.2378	.362	.3511	.8356	1.0343	.8356	.3258
21	.2378	.3439	.3511	.2279	.362	.2303	.3142
22	.2012	.2715	.2772	.1753	.3077	.3045	.2957
23	.1494	.1991	.2103	.1478	.2353	.2686	.1663
24	.1478	.112	.181	.1663	.1478	.2353	.2303
Max	1.3395	1.1145	1.5091	1.543	1.3748	1.5604	1.1873
Min	.1267	.1109	.1294	.1448	.1294	.1663	.112
Avg	.4381	.3431	.4875	.5416	.4117	.5597	.4370

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 203 / 11 KV YENWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.128	.1267	.1478	.1463	.1629	.1433
2	.1294	.1294	.1086	.1294	.1463	.1448	.1267
3	.1294	.1109	.1086	.1294	.128	.1448	.1463
4	.1109	.1109		.1109	.1294	.1448	.1267
5	.1294	.1109	.1086	1.0117	.9614	.8478	.1267
6	.1294	.1109	.1267	1.0631	.8288	.9326	.1267
7	.1478	.1646	.1629	1.1488	1.1305	1.1191	.1463
8	.1294	.1478	.1448	1.2689	1.4746	1.4243	.1475
9	.1478	.1663	.1448	1.8945	1.9433	1.7295	.1311
10	.1448		.1448	1.9161	1.8785	1.8991	.1311
11	.1267	.1294	.1109	1.7295	1.7029	1.6118	.112
12	.1086	.1109	.0924	1.5261	1.4529	1.3546	.0934
13	2.0517	1.9204	2.1376	.1267	.0983	.1109	1.5424
14	2.1534	2.0576	2.1538	.0905	.0983	.1109	1.643
15	2.0348	2.0698	1.8623	.1267		.0895	1.7101
16	1.9839	2.0062	1.7859	.1086		.1109	1.7604
17	1.8991	1.9033	1.7532	.1097		.0924	1.5592
18	1.6549	1.6448	1.5604	.1463	.2172	.1475	1.406
19	1.2944	1.3226	1.286	.2561	.2896	.2458	1.3546
20	1.2452	1.2887	1.1831	.2743	.2896	.2507	1.1831
21	.2561	.2534	.2587	.2279	.2715	.2534	.2587
22	.2012	.2172	.2218	.1753	.2172	.1991	.2033
23	.1494	.1448	.1448	.1478	.3258	.1612	.1478
24	.1478	.1307	.1267	.1478	.1478	.1629	.1448
Max	2.1534	2.0698	2.1538	1.9161	1.9433	1.8991	1.7604
Min	.1086	.1109	.0924	.0905	.0983	.0895	.0934
Avg	.6931	.7122	.6893	.5839	.6609	.5605	.6030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 204 / 11 KV GONHI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.0739	.0543	.0739	.0747	.0543	.0709
2	.0554	.0747	.0543	.0739	.0747	.0543	.0709
3	.0554	.056	.0543	.0554	.0747	.0543	.0709
4	.0554	.0747	.0543	.0554	.0747	.0543	.0709
5	.0739	.0747	.0543	.0857	.0838	.0678	.0701
6	.0739	.1109	.0905	.1029	.1006	.0848	.0867
7	.1109	.112	.1086	.1372	.1326	.1865	.1052
8	.1109	.0934	.0724	.2058	.1989	.2204	.0655
9	.0924	.0934	.0724	.3222	.2984	.2543	.0983
10	.0724		.0905	.3052	.2984	.3052	.0819
11	.0543	.037	.056	.2883	.1875	.2572	.056
12	.0543	.037	.0554	.2374	.1875	.2058	.056
13	.0543	.3258	.3315	.0724	.0492	.0554	.285
14	.2543	.3258	.3481	.0543	.0328	.037	.3018
15	.2713	.3086		.0362		.0526	.285
16	.3391	.2915		.0362		.052	.285
17	.2883	.2572	.2486	.037	.0543	.037	.2515
18	.2321	.2204	.2915	.0924	.0724	.0492	.2058
19	.1658	.2035	.2058	.1109	.1086	.0983	.1715
20	.1341	.2035	.2058	.1294	.1086	.1214	.1663
21	.1109	.1086	.0924	.1052	.0905	.104	.0924
22	.0924	.0905	.0924	.0876	.0905	.0876	.0739
23	.0747	.0724	.0701	.0747	.0724	.0701	.0739
24	.0554	.056	.0543	.0739	.0747	.0724	.0701
Max	.3391	.3258	.3481	.3222	.2984	.3052	.3018
Min	.0543	.037	.0543	.0362	.0328	.037	.056
Avg	.1224	.1435	.1254	.1189	.1155	.1098	.1319

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 205 / 11 KV KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.056	.0724	.0739	.0739	.0724	.0724
2	.0739	.056	.0543	.0739	.0747	.0724	.0724
3	.0554	.056	.0543	.0739	.0747	.0724	.0732
4	.0554	.056	.0543	.0739	.0747	.0724	.0724
5	.7207	.6299	.5596	.0554	.0739	.0724	.6706
6	.6516	.6796	.6613	.0739	.0747	.0724	.6882
7	.6859	.779	.763	.0739	.0739	.0724	.7712
8	.9945	.852	1.0004	.0739	.056	.0724	.8436
9	1.3032	.9339	1.3565	.0724	.0747	.0724	.953
10	1.3226		1.2039	.0724	.0934	.0724	.9686
11	1.1022	1.046	1.0322	.0724	.0492	.0739	.9892
12	.9955	.8573	.8356	.0543	.0492	.0554	.8886
13		.0343	.0739	1.3056	1.1405	1.2517	.056
14	.0543	.0554	.0554	1.1361	1.1873	1.2517	.056
15	.0543	.0554		1.1271		1.2239	.056
16	.0543	.0554		1.0852		1.0974	.056
17	.0543	.037	.0739	1.0608	1.1869	1.0117	.056
18	.0747	.0543	.0924	.852	1.153	.7655	.0924
19	.1663	.1629	.1663	.779	.9496	.7373	.1663
20	.1646	.1629	.1663	.7459	.8987	.6802	.1478
21	.1478	.1448	.1478	.1402	.1448	.1448	.1478
22	.1109	.1086	.1109	.0876	.1086	.128	.1109
23	.0747	.0724	.0905	.0934	.0724	.0905	.0924
24	.0739	.056	.0724	.0739	.0747	.0724	.0716
Max	1.3226	1.046	1.3565	1.3056	1.1873	1.2517	.9892
Min	.0543	.0343	.0543	.0543	.0492	.0554	.056
Avg	.3941	.3044	.3953	.3888	.3527	.3879	.3405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 201 / 11 KV KACHARISAWANGA  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0732	.0486	.0648	.0648	.0486	.0648
2	.0648	.0648	.0486		.0648	.0486	.0648
3	.0648	.0648	.0486	.0648	.0648	.0486	.0648
4	.0648	.0648	.0486	.0648	.0648	.0486	.0648
5	.2267	.2591	.1943	.0648	.0648	.0486	.1619
6	.2267	.2591	.2591	.0648	.0648	.0648	.1943
7	.3563	.3887	.3563	.0648	.0648	.0648	.3563
8	.5506	.421	.4858	.0625	.0648	.0648	.5506
9	.6154	.5506	.6478	.0648	.0648	.0648	.6478
10	.7125	.6802	.6802	.0648	.0648	.0648	.6802
11	.5992	.6478	.6802	.0648	.0648	.0648	.6478
12	.6154	.5992	.6478	.0648	.0648	.0648	.5506
13	.081	.0648	.0648	.6478	.6478	.7449	.0486
14	.081	.0648	.0648	.7773	.6802	.7449	.0486
15	.0648	.0648	.0648	.7449	.7449	.7449	.0486
16	.0486	.0648	.0648	.6478	.7125	.7449	.0486
17	.0486	.0648	.0972	.7125	.7449	.6478	.0486
18	.0648	.0648	.0648	.5506	.583	.4534	.0648
19	.081	.0648	.0972	.4534	.3887	.3887	.0648
20	.081	.1052	.0972	.421	.3887	.3563	.0648
21	.0648	.081	.081	.0972	.0972	.0648	.0648
22	.0648	.0648	.0648	.0648	.0648	.0648	.0648
23	.0648	.0648	.0648	.0648	.0648	.0648	.0648
24	.0648	.0648	.0648	.0648	.0648	.0648	.0648
Max	.7125	.6802	.6802	.7773	.7449	.7449	.6802
Min	.0486	.0648	.0486	.0625	.0648	.0486	.0486
Avg	.2072	.2045	.2099	.2590	.2483	.2409	.1977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 202 / 11 KV KHURSAPAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.1989	.1989	.2486	.2321	.1989	.2321
2	.2321	.1989	.1989	.2321	.2321	.1989	.2321
3	.2321	.1989	.1989	.2321	.2321	.1989	.2321
4	.2321	.1989	.1989	.2321	.2321	.1989	.2321
5	.5636	.7293	.6299	.208	.1989	.1989	.5068
6	.663	.7293	.6962	.2321	.2321	.1989	.5636
7	.8619	.8288	.9945	.1989	.1989	.1989	.9614
8	1.3592	1.0277	1.326	.2155	.1989	.1658	1.326
9	1.9227	1.989	1.8564	.2155	.1989	.1989	1.757
10	2.1548	2.0222	1.3923	.1989	.1989	.1989	1.8564
11	1.873	1.7404	1.8564	.1989	.1658	.1658	1.4918
12	1.5746	1.4255	1.5249	.1658	.1989	.1326	1.2266
13	.1989	.1823	.1658	1.9227	1.8564	1.9559	.1823
14	.1989	.1658	.1658	2.0222	1.8564	1.989	.1823
15	.1823	.1989	.1989	2.0222	1.7901	2.1548	.1823
16	.1989	.2321	.1658	2.0222	1.989	1.8896	.1823
17		.1658	.1658	1.8564	1.8564	1.7238	.1658
18		.2321	.2401	1.4586	1.5249	1.326	.1989
19	.3315	.431	.4807	1.2597	1.2763	1.1934	.2984
20	.3315	.4641	.4641	1.2266	1.2266	1.094	.2984
21	.3315	.431	.4475	.431	.431	.4641	.2984
22	.2652	.3315	.3812	.3315	.3315	.2652	.2984
23	.2652	.2321	.2818	.2652	.2652	.2652	.2652
24	.2321	.1989	.1989	.2486	.2321	.2321	.2321
Max	2.1548	2.0222	1.8564	2.0222	1.989	2.1548	1.8564
Min	.1823	.1658	.1658	.1658	.1658	.1326	.1658
Avg	.6562	.6064	.6012	.7352	.7148	.7003	.5585



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 204 / 11 KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2896	.2534	.3258	.3258	.2896	.3258
2	.2534	.2896	.2534	.3077	.2896	.2896	.2896
3	.2534	.2896	.2534	.3077	.2896	.2896	.2896
4	.2534	.2896	.2534	.2896	.2896	.2896	.2896
5	.3258	.5068	.4706	.2896	.2896	.2896	.4344
6	.3258	.5068	.543	.3258	.3258	.2896	.4706
7	.4706	.724	.5792	.3077	.2896	.3258	.5068
8	.7964	1.0136	.8326	.2896	.2534	.2534	
9	1.3756	1.3756	1.448	.2715	.2534	.2896	.2534
10	1.3756	1.3032	1.5927	.2896	.2172	.2534	.3258
11		1.1403	1.3756	.2715	.2172	.2172	.2172
12	.9412	1.086	.9412	.2715	.2172	.2534	.181
13	.2172	.2172	.181	1.4118	1.3394	1.4842	.2172
14	.1991	.2172	.181	1.448	1.3756	1.4842	.2172
15	.1991	.2172	.181	1.267	1.1584	1.448	.2172
16	.1991	.2172	.181	1.3756	1.3756	1.3032	.2172
17	.2172	.2172	.2172	1.3394	1.267	1.1584	.2172
18	.2896	.2534	.3077	.9774	1.0136	.905	.3258
19	.543	.5068	.5609	.905	.8507	.7602	.362
20	.543	.5068	.543	.7602	.724	.7602	.362
21	.543	.4887	.4706	.5068	.5068	.5068	.362
22	.4344	.3982	.4344	.4344	.4344	.3258	.362
23	.362	.3258	.3801	.362	.362	.362	.362
24	.3258	.2896	.2896	.3258	.3258	.3258	.3258
Max	1.3756	1.3756	1.5927	1.448	1.3756	1.4842	.5068
Min	.1991	.2172	.181	.2715	.2172	.2172	.181
Avg	.4682	.5279	.5302	.6109	.5830	.5898	.3101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 205 / 11 KV KONDHALI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2629	.2454	.3366	.3155	.3155	.3856
2	.2103	.2629	.2454	.3189	.2804	.3155	.3506
3	.2103	.2629	.2454	.3189	.2804	.3155	.3506
4	.2103	.2629	.2454	.3012	.2804	.3155	.3506
5	.2103	.2629	.2629	.2835	.3155	.3155	.3155
6	.3155	.2629	.2804	.2835	.3155	.3155	.3155
7	.3856	.3506	.4207	.3898	.3856	.3856	.3856
8	.4557	.4557	.3856	.4961	.4908	.5258	.4557
9	.631	.5258	.631	.6024	.5609	.4908	.4557
10	.5258	.5609	.5609	.567	.5959	.5609	.4557
11	.5138	.5847	.5258	.5609	.4908	.4908	.4557
12	.443	.4607	.3856	.4908	.3856	.4908	.4557
13	.4252	.443	.4207	.5258	.4557	.4207	.3856
14	.4252	.4252	.3856	.4557	.4207	.4557	.3856
15	.4075	.3898	.3856	.4207	.4557	.4557	.3856
16	.4252	.4252	.3856	.3856	.4908	.4557	.4207
17	.4252	.4252	.4908	.4557	.4557	.5258	.4207
18	.4908	.4706	.5316	.5609	.5258	.5609	.4908
19	.5609	.5959	.7087	.631	.631	.7011	.5609
20	.5609	.631	6.0065	.5959	.5609	.631	.5609
21	.5258	.5258	.5138	.5258	.5258	.5609	.5609
22	.4207	.4207	.443	.4908	.4207	.5258	.5609
23	.3506	.3506	.3721	.3506	.3506	.3856	.4207
24	.2926	.2629	.298	.3544	.3155	.3155	.3856
Max	.631	.631	6.0065	.631	.631	.7011	.5609
Min	.2103	.2629	.2454	.2835	.2804	.3155	.3155
Avg	.4043	.4117	.6407	.4459	.4294	.4513	.4280

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 206 / 11KV MASOD NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0328	.0328	.0328	.0328	.0328	.0328
2	.0328	.0328	.0328	.0328	.0328	.0328	.0328
3	.0328	.0328	.0328	.0328	.0328	.0328	
4	.0328	.0328	.0328	.0328	.0328	.0328	.0328
5	.0655	.0819	.0983	.0328	.0328	.0328	.0655
6	.0819	.0819	.1311	.0328	.0328	.0328	.0819
7	.0983	.1638	.1475	.0328	.0328	.0328	.0819
8	.1638	.1638	.1638	.0328	.0328	.0328	.0983
9	.1802	.1638	.213	.0328	.0328	.0328	.1147
10	.1802	.1802	.2294	.0328	.0328	.0328	.0983
11	.1475	.1966	.1802	.0328	.0328	.0328	.0819
12	.1475	.1802	.1802	.0328	.0328	.0328	.0819
13	.0328	.0328	.0328	.213	.1966	.1311	.0328
14	.0328	.0328	.0328	.213	.2294	.1311	.0328
15	.0328	.0328	.0328	.1966	.2458	.1147	.0328
16	.0328	.0328	.0328	.1638	.1475	.1147	.0328
17	.0328	.0328	.0328	.1638	.1311	.1147	.0328
18	.0328	.0328	.0328	.1311	.0983	.0983	.0328
19	.0328	.0328	.0328	.1311	.0819	.0983	.0328
20	.0328	.0328	.0328	.1311	.0819	.0983	.0328
21	.0328	.0328	.0328	.0328	.0328	.0328	.0328
22	.0328	.0328	.0328	.0328	.0328	.0328	.0328
23	.0328	.0328	.0328	.0328	.0328	.0328	.0328
24	.0328	.0328	.0328	.0328	.0328	.0328	.0328
Max	.1802	.1966	.2294	.213	.2458	.1311	.1147
Min	.0328	.0328	.0328	.0328	.0328	.0328	.0328
Avg	.0662	.0724	.0778	.0778	.0724	.0594	.0520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 207 / 11 KV WW

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2103	.1753	.1753	.1753	.1402	.1402
2	.2454	.2103	.1753	.1753	.2103	.1402	.1753
3	.2454	.2103	.1753	.2103	.2103	.1402	.1753
4	.2804	.2629	.1753	.2454	.2454	.1402	.2103
5	.2454	.2804	.1753	.2629	.2454	.1753	.2103
6	.2454	.2804	.2454	.2454	.2103	.2103	.2454
7	.2454	.2804	.2454	.2629	.2454	.2103	.2103
8	.2103	.2804	.2454	.2454	.2454	.2454	.2454
9	.3506	.2804	.3506	.2629	.3856	.2804	.2804
10	.3155	.2454	.2804	.3506	.3856	.2103	.2804
11	.298	.2804	.3506	.3856	.3856	.2103	.2804
12	.3506	.3155	.3856	.4207	.3856	.2454	.3155
13	.3856	.298	.3856	.4557	.3506	.2454	.2804
14	.3681	.2454	.3155	.3506	.1402	.3155	.2454
15	.3856	.3155	.3856	.3506	.3506	.3155	.2454
16	.4557	.3155	.439	.3506	.3155	.3155	.3155
17	.4031	.1753	.4557	.3506	.2103	.3155	.3155
18	.2454	.2804	.3681	.2103	.2103	.2454	.2454
19	.2454	.2103	.2279	.1753	.1578	.2454	
20	.2103	.2454	.2279	.1402	.1402	.1402	.2454
21	.1928	.1753	.2103	.1753	.1402	.1753	.1753
22	.1928	.1753	.1928	.1753	.1402	.1753	.1753
23	.2103	.1753	.1928	.1753	.1402	.1753	.1753
24	.2103	.2103	.1753	.1753	.1753	.1402	.1402
Max	.4557	.3155	.4557	.4557	.3856	.3155	.3155
Min	.1928	.1753	.1753	.1402	.1402	.1402	.1402
Avg	.2812	.2483	.2732	.2637	.2417	.2147	.2317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 402 / 33 KV Katol Kondhali

Incomer Feeder KV- 33 /  
INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6763	2.7435	3.4568	3.5997	3.4019	3.7311	3.5665
2	3.5665	2.7435	3.4568	3.4385	3.4019	3.7311	3.6214
3	3.5665	2.7435	3.4568	3.4922	3.5117	3.7311	3.6214
4	3.6763	2.7984	3.4568	3.6923	3.6214	3.7311	3.6214
5	4.225	3.9506	4.4445	4.3439	3.9506	3.7311	4.7737
6	4.6091	3.9506	4.7737	4.4056	4.2798	3.786	5.3224
7	5.1029	5.1029	5.5418	4.137	4.225	3.9506	6.31
8	6.4198	6.6392	6.3649	5.3727	4.4993	6.2552	7.7915
9	8.0659	8.2305	8.2853	6.4472	7.1331	6.9685	9.2181
10	8.7792	8.1756	7.4623	6.4198	6.9136	7.4074	9.273
11	7.6292	7.1456	7.7366	6.3649	6.6941	6.8039	8.3951
12	6.877	6.9307	7.0233	5.487	5.6516	5.8711	5.487
13	6.5547	5.695	4.5542	7.9561	7.8464	8.3951	3.6214
14	6.3397	6.3935	6.8587	7.6269	7.7915	8.5597	3.5665
15	3.6534	5.4801	6.749	7.2977	7.8464	8.5597	3.786
16	5.0503	6.286	6.9685	7.7366	8.1207	8.2305	3.786
17	6.4472	6.3935	7.3525	7.572	6.6392	7.8464	3.8958
18	6.5844	6.5844	6.0174	6.6941	4.8834	6.9685	3.786
19	5.9808	6.1454	5.8774	6.1454	5.3772	6.3649	4.1152
20	5.1029		6.0711	5.9259	6.4198	6.2552	4.1152
21	3.4019	4.5542	4.3519	4.225	4.8285	4.8285	4.0055
22	3.1276	4.0604	4.1907	3.786	4.2798	4.225	3.9506
23	3.0178	3.5117	***	3.2922	3.4019	3.7311	3.7311
24	3.6763	2.7435	3.5665	3.6534	3.4019	3.8409	3.7311
Max	8.7792	8.2305	34.1701	7.9561	8.1207	8.5597	9.273
Min	3.0178	2.7435	3.4568	3.2922	3.4019	3.7311	3.5665
Avg	5.2138	5.1740	6.7578	5.3797	5.3384	5.7293	4.8788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 403 / 33 KV Kondhali B'gaon  
outgoing Feeder KV- 33 /  
INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4691	1.6461	2.4691	2.3891	2.1948	2.6337	2.3594
2	2.4691	1.6461	2.4691	2.2805	2.1948	2.6337	2.4143
3	2.4691	1.6461	2.4691	2.3348	2.3045	2.6337	2.4143
4	2.524	1.6461	2.4691	2.4434	2.4143	2.6337	2.3594
5	2.524	1.6461	2.4691	3.1493	2.7435	2.6337	3.0178
6	2.6337	1.6461	2.4691	3.2579	3.0727	2.6337	3.2922
7	2.524	2.1948	2.5789	2.8778	2.963	2.6337	3.6214
8	2.6337	3.0178	2.6337	4.0724	3.1824	5.048	4.8285
9	2.6337	2.963	2.7435	4.9954	5.5967	5.7613	5.4321
10	3.1276	2.8532	2.4143	4.7782	5.3224	6.1454	5.2675
11	2.9864	2.3348	2.4143	4.7188	5.2675	5.5418	4.9383
12	2.6063	2.7149	2.6337	4.0055	4.2798	4.6091	2.4143
13	5.2126	4.5068	3.2373	2.4143	2.6337	3.0727	2.4143
14	5.0497	5.2669	5.6516	1.9753	2.7435	3.0727	2.4143
15	2.3891	4.2353	5.4321	1.9204	2.7435	2.963	2.3388
16	3.6923	5.0497	5.6516	2.3594	2.7435	3.0727	2.524
17	5.3212	5.2126	5.8162	2.4143		3.0727	2.6337
18	5.2126	5.2126	4.5068	2.524	.6036	3.1276	2.3594
19	4.1152	4.1701	3.9095	2.3045	1.701	2.7435	2.4691
20	3.2922		4.1267	2.4143		2.963	2.4691
21	1.6461	2.7435	2.6063	2.3594		2.963	2.4691
22	1.6461	2.5789	2.6606	2.1948		2.7435	2.4143
23	1.6461	2.2497	2.0633	1.9753	2.1948	2.3594	2.3045
24	2.4691	1.6461	2.4691	2.4434	2.1948	2.6337	2.524
Max	5.3212	5.2669	5.8162	4.9954	5.5967	6.1454	5.4321
Min	1.6461	1.6461	2.0633	1.9204	.6036	2.3594	2.3045
Avg	3.0539	2.9925	3.2652	2.8584	2.9547	3.3470	2.9873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 201 / 11 KV MASOD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0899	.0457	.0549	.064	.061	.061
2	.0914	.0838	.0457	.0518	.0594	.061	.061
3	.0914	.0808	.0457	.0503	.0503	.0457	.061
4	.0914	.0777	.061	.0457	.0472	.0457	.0457
5	.0914	.0762	.061	.1402	.1616	.1219	.1524
6	.0914	.0732	.061	.1616	.16	.1219	.1829
7	.0914	.0808	.0457	.2469	.221	.1829	.2286
8	.1067	.0854	.061	.3307	.3216	.2743	.3353
9	.1128	.0914	.0488	.3231	.3658	.381	.381
10	.1006	.1067	.0564	.192	.3963	.3506	.3506
11	.0823	.061	.0442	.349	.2743	.945	.0152
12	.0777	.0457	.3277	.3003	.2286	.2591	.2743
13		.381	.2774	.0427	.1067	.0457	.0457
14	.4207	.5182	.4313	.0396	.0457	.0457	.0457
15		.4725	.4603	.0396	.0457	.0457	.0457
16	.4085	.2439	.4557	.0396	.0305	.0457	.0457
17	.5228	.2743	.4039	.0472	.0457	.0457	.0457
18	.3612	.381	.3033	.0579	.061	.061	.061
19	.2759	.2896	.2637	.1128	.0914	.1067	.1067
20	.2774	.2591	.2454	.1021	.1067	.1219	.1067
21	.1631	.1067	.1052	.1036	.1067	.1067	.1067
22	.1204	.0762	.0854	.0914	.0762	.0914	.0914
23	.1082	.061	.0625	.0777	.0762	.061	.061
24	.0914	.0945	.0457	.0594	.0671	.061	.061
Max	.5228	.5182	.4603	.349	.3963	.945	.381
Min	.0777	.0457	.0442	.0396	.0305	.0457	.0152
Avg	.1759	.1713	.1685	.1275	.1337	.1537	.1238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 202 / 11 KV DHURKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0793	.061	.0625	.0594	.0762	.0762
2	.061	.0777	.061	.0594	.0594	.0762	.061
3	.061	.0762	.061	.0579	.0579	.061	.061
4	.061	.0732	.061	.0564	.0579	.061	.061
5	.061	.0686	.0762	.3521	.3902	.3353	.3963
6	.061	.0671	.0762	.407	.3749	.3963	.4572
7	.061	.064	.061	.5548	.5472	.4725	.503
8	.061	.0701	.061	.7514	.7407	.8535	.7621
9	.0716	.061	.0747	1.07	1.0364	.945	.8993
10	.0549	.061	.0732	.9922	.8993	1.0517	.9145
11	.0518	.061	.0533	.7804	.8688	.8688	.7926
12	.0594	.061	.0503	.6828	.6859	.7316	.7011
13	1.0319	.9755	1.0334	.0671	.0457	.0457	.061
14	1.0837	1.0517	1.1065	.0655	.0457	.0457	.0457
15		1.0364	.977	.0518	.0457	.0457	.0457
16	.724	.945	.977	.0503	.0457	.061	.0457
17	1.1065	.8993	.9069	.0472	.0457	.0457	.0457
18	.8596	.7011		.0686	.0457	.0762	.061
19	.6295	.5792	.5822	.1311	.1219	.1524	.1372
20	.5822	.5182	.5563	.1357	.1372	.1372	.1372
21	.1341	.1219	.1265	.1326	.1372	.1372	.1372
22	.0975	.0914	.096	.0945	.0914	.1067	.1067
23	.093	.0762	.0716	.0838	.0914	.0762	.0762
24	.061	.0808	.061	.0686	.0686	.0914	.0762
Max	1.1065	1.0517	1.1065	1.07	1.0364	1.0517	.9145
Min	.0518	.061	.0503	.0472	.0457	.0457	.0457
Avg	.3099	.3290	.3158	.2843	.2792	.2896	.2775



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 203 / 11 KV DHOTIWADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1875	.1829	.1829	.2103	.2134	.2134
2	.1524	.1859	.1981	.1814	.2058	.2134	.2134
3	.1524	.1844	.2134	.1799	.2012	.1981	.1981
4	.1677	.1829	.2134	.1829	.1981	.1829	.1981
5	.1677	.1783	.2134	.3673	.4009	.3506	.381
6	.1829	.1753	.2134	.3948	.3567	.3658	.4268
7	.1677	.16	.1829	.5959	.5685	.5182	.4877
8	.1677	.1494	.1829	.82	.82	.945	.7773
9	.16	.3048	.1722	1.0395	1.0669	1.1584	1.768
10	.1494	.2744	.1936	1.0486	1.0364	1.1126	1.6156
11	.1265	.2438	.1402	.8962	.9755	.884	
12	.1189	.1219	.1357	.7331	.8535	1.6613	
13	.692	.6554	.8429	.1524	.1219	.1372	.1524
14	.7758	.6859	1.0943	.1341	.1372	.1372	.1524
15	.6051	.6706	1.1767	.128	.1067	.1372	.1524
16	.6843	1.0669	1.1858	.1311	.1372	.1372	.1067
17	.6691	1.0669	1.0593	.1722	.1524	.1524	.1677
18	.5822	.7773	.8063	.221	.2134	.2591	.2439
19	.4466	.6249	.7072	.3582	.3963	.381	.3658
20	.4085	.5792	.5898	.3597	.381	.381	.3658
21	.2683	.3353	.3399	.3414	.3506	.3658	.381
22	.2195	.2591	.2713	.2896	.2743	.2896	.3048
23	.2012	.1981	.2164	.218	.2286	.2286	.2439
24	.1524	.189	.1829	.1844	.2119	.2286	.2134
Max	.7758	1.0669	1.1858	1.0486	1.0669	1.6613	1.768
Min	.1189	.1219	.1357	.128	.1067	.1372	.1067
Avg	.3154	.3941	.4465	.3880	.4002	.4433	.4150

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 401 / 33 KV Masod B'gaon feeder

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.1509	.1372	.1372	.1509	.1555	.16
2	.1326	.1463	.1372	.1326	.1463	.1417	.1555
3	.128	.1463	.1372	.1326	.1509	.1417	.1463
4	.128	.1417	.1372	.1372	.1417	.1372	.1372
5	.1372	.1326	.1829	.9556	.9374	.8688	.9465
6	.1417	.1372	.1829	1.0425	.9145	.9191	1.2254
7	.1417	.1326	.1372	1.6507	1.4266	1.2529	1.4038
8	.1463	.1235		2.2222	2.1856	2.3594	2.2405
9	.1555	.1372	.1235	2.6566	2.7938	2.7984	2.5149
10	.1372	.1372	.1372	2.7526	2.6429	2.931	2.4691
11	.1143	.1372	.1189	2.3091	2.4051	2.4326	1.2803
12	.1143	.1143	.1052	2.0302	2.0302	2.0119	1.1888
13	1.8336	2.332	2.3777	.1143	.1052	.0914	.0914
14	2.588	2.5149	2.9127	.1189	.1143	.1143	.1372
15	.6584	2.0576	2.9447	.0914	.0914	.1189	.1372
16	2.1719	2.4691	2.9264	.096	.1143	.1143	.0914
17	2.5469	2.4691	2.7023	.1372	.1235	.1143	.1543
18	1.9845	2.1491	2.0576	.16	.1646	.2103	.2058
19	1.4678	1.6918	1.5684	.2743	.2789	.2789	.2743
20	1.3717	1.5546	1.4449	.2743	.2789	.2835	.3086
21	.2378	.2286	.2378	.2469	.2515	.2652	.2743
22	.1829	.2058	.1966	.2103	.1966	.2058	.2286
23	.1738	.1372	.1646	.1646	.1875	.1738	.2058
24	.1372	.16	.1372	.1417	.16	.1738	.1646
Max	2.588	2.5149	2.9447	2.7526	2.7938	2.931	2.5149
Min	.1143	.1143	.1052	.0914	.0914	.0914	.0914
Avg	.7068	.8170	.9221	.7579	.7497	.7623	.6726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACE

Feeder No / Name : 201 / 11 KV Yerkheda 1

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.5265	.6017	.5788	.5641	.6205	.6348
2	.8029	.4889	.6017	.5601	.5641	.6205	.6348
3	.8029	.4889	.6017	.5601	.5641	.6205	.6348
4	.8029	.4889	.6393	.5601	.5641	.6205	.6348
5	.8029	.5077	.6393	.5601	.6017	.6582	.6348
6	.8029	.6393	.677	.7095	.6958	.7334	.7842
7	1.3443	.7898	.771	.7095	.8086	.865	.8029
8	1.3817	.7898	.8462	.7842	.8086	.8274	.8029
9	1.4003	.9402	.8838	.8775	.8838	.8838	.8215
10	1.3727	.959	.9214	.9231	.9214	.9214	.8589
11	1.3163	.9966	.8274	.9778	.959	.8962	.865
12	1.2035	.9214	.724	.9778	.8274	.8215	.7146
13	1.0907	.7334	.7095	.865	.771	.6535	1.2411
14	.9026	.8462	.5601	.7522	.6017	.6535	.9778
15	.9026	.7898	.5601	.677	.6393	.6535	.9214
16	.9026	.5265	.5601	.6393	.6017		.8274
17	.9402	.6017	.6348	.6393	.6205	.6161	.9026
18	1.1471	.677	.6348	.6958	.7334	.7842	1.1283
19	.9026	.8838	.9522	.9402	.9778	.9522	1.3915
20	.865	.865	.8962	.9402	.9402	.9522	1.4103
21	.8274	.8274	.8402	.8462	.8838	.9149	1.2787
22	.7522	.7898	.7655	.7898	.8462	.8402	1.2411
23	.6582	.7146	.7095	.6958	.7522	.7468	1.1471
24	.8589	.5641	.6205	.6908	.6017	.6958	.6908
Max	1.4003	.9966	.9522	.9778	.9778	.9522	1.4103
Min	.6582	.4889	.5601	.5601	.5641	.6161	.6348
Avg	.9851	.7232	.7158	.7479	.7388	.7631	.9159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTTEE(DRAGON  
PALACE

Feeder No / Name : 202 / 11 KV NERI 1 Fdr

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.3282	.3282	.3439	.3464	.3282	.3077
2	.3258	.31	.3282	.3258	.3464	.3282	.3077
3	.3258	.31	.31	.3258	.3464	.3282	.3077
4	.3258	.31	.31	.3258	.3464	.3464	.3077
5	.3258	.3282	.3464	.3258	.3647	.3464	.3077
6	.4706	.3829	.3829	.3801	.4194	.3647	.362
7	.4344	.4376	.4376	.3801	.4376	.4194	.362
8	.4344	.4558	.4558	.4344	.4376	.4376	.362
9	.4706	.5288	.4923	.4525	.4741	.4741	.5068
10	.6928	.5834	.6199	.724	.4923	.7658	.5792
11	.7293	.5105	.4741	.7658	.6199	.7602	.6199
12	.7658	.5834	.543	.7475	.6564	.7059	.5834
13	.6564	.4741	.5973	.6564	.6746	.5788	.4923
14	.3829	.4558	.4163	.6381	.3647	.5611	.4376
15	.5834	.4558	.4163	.6199	.3464	.5611	.3647
16	.6928	.4376	.4344	.7293	.547	.724	.4923
17	.7293	.4741	.5249	.7658	.7475	.724	.547
18	.7293	.5105	.5249	.7658	.7293	.8507	.5105
19	.784	.6199	.7602	.6928	.8752	.8507	.6564
20	.547	.5834	.5611	.7111	.6564	.7964	.6564
21	.5105	.5105	.5068	.5105	.4558	.6878	.4741
22	.4376	.4558	.4344	.4558	.4194	.8145	.4376
23	.3647	.3829	.4344	.4011	.3647	.362	.3647
24	.624	.3282	.3464	.4163	.3647	.3282	.3258
Max	.784	.6199	.7602	.7658	.8752	.8507	.6564
Min	.3258	.31	.31	.3258	.3464	.3282	.3077
Avg	.5286	.4482	.4577	.5373	.4931	.5602	.4447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACEFeeder No / Name : 205 / 11 KV YERKHEDA 2 FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0434	.0626	.0577	.1158	.0626	.0433	.0434
2	.0434	.0626	.0577	.1158	.1448	.1442	.1448
3	.0434	.0626	.0577	.1158	.1448	.1442	.1448
4	.0434	.0626	.0577	.1158	.1448	.1731	.1448
5	.0434	.0626	.0577	.1593	.1448	.1731	.1882
6	.0434	.0626	.0577	.3185	.1738	.2019	.2172
7	.0434	.0626	.0433	.3475	.1882	.2308	.2462
8	.0579	.0626	.0433	.1882	.2172	.2452	.2027
9	.0434	.047	.0433	.2172	.2317	.2884	.2751
10	.2606	.3185	.2596	.2462	.2308	.3461	.2462
11	.3041	.3606	.2884	.3185	.2452	.2462	.2462
12	.3909		.3185	.333	.0433	.0434	.047
13	.4054	.4327	.3475	.333	.0577	.0579	.0626
14	.3909	.4182	.3185	.3185	.0577	.0579	.0626
15	.4199	.4038	.3185	.3185	.0577	.0434	.047
16	.4054	.3894	.3475	.3041	.0433	.0434	.0626
17	.3909	.3606	.3475	.2896	.0433	.0434	.047
18	.3765	.3173	.3185	.2606	.0433	.0434	.0626
19	.2896	.2884	.2462	.2027	.0433	.0434	.047
20	.047	.0433	.0434	.0434	.0433	.0434	.047
21	.0626	.0433	.0434	.0626	.0433	.0434	.047
22	.0626	.0433	.0434	.0626	.0433	.0434	.047
23	.0626	.0577	.0434	.0626	.0433	.0434	.047
24	.0579	.0626	.0577	.0434	.0626	.0433	.0434
Max	.4199	.4327	.3475	.3475	.2452	.3461	.2751
Min	.0434	.0433	.0433	.0434	.0433	.0433	.0434
Avg	.1805	.1777	.1591	.2039	.1064	.1179	.1154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACE

Feeder No / Name : 207 / 11 KV MODI 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	.4887	.543	.4887	.543	.543	.5792
2	.5068	.4706	.6878	.4706	.5068	.543	.5792
3	.5068	.4525	.543	.4706	.5068	.5792	.5792
4	.5068	.4525	.5249	.4706	.5068	.5792	.5792
5	.5068	.4706	.5249	.4706	.543	.5792	.5792
6	.724	.543	.5249	.5973	.5973	.5973	.6154
7	.7059	.724	.7421	.5973	.6878	.724	.7421
8	.724	.7783	1.086	1.0498	.6154	.7059	.6878
9	.7964	.724	.7059	.7783	1.086	.905	.7421
10	.7602	.724	.6154	.7783		.7602	.9593
11	.724	.7421	.724	.7421	.724	.7421	.724
12	.724	.7475	.6878	.724	.6697	.7059	.6878
13	.6154	.6878	.6697	.6697	.6335	.5973	.6154
14	.5792	.6335	.5611	.6154	.6335	.5973	
15	.543	.5792	.5611	.5792	.5611	.5973	.5973
16	.543	.543	.5792	.5249	.543	.5792	.5611
17	.543	.6335	.6154	.543	.5792	.5792	.5792
18	.7602	.6878	.6154	.724	.724	.8145	.724
19	.8688	.8145	.8507	.905	.8326	.8688	.8145
20	.8507	.7964	.8326	.8326	.8145	.8688	.7964
21	.7964	.7602	.7602	.7783	.7783	.7964	.7964
22	.724	.6878	.6878	.724	.724	.7602	.6878
23	.6154	.3077	.6516	.6335	.6516	.6516	.6516
24	.5249	.543	.5611	.6516	.5792	.5792	.5792
Max	.8688	.8145	1.086	1.0498	1.086	.905	.9593
Min	.5068	.3077	.5249	.4706	.5068	.543	.5611
Avg	.6531	.6247	.6607	.6591	.6540	.6772	.6721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACEFeeder No / Name : 209 / 11 KV YASHODHARA NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2775	.2821	.2957	.259	.3385	.3326
2	.2587	.259	.2821	.2772	.2405	.3385	.3326
3	.2587	.2405	.2633	.2772	.2405	.3385	.3326
4	.2587	.2405	.2633	.2772	.2405	.3385	.3326
5	.2587	.2405	.2821	.2772	.2405	.3385	.3326
6	.3142	.2775	.3009	.3326	.259	.3385	.3142
7	.2957	.296	.3573	.3326	.296	.3385	.3511
8	.3881	.333	.3761	.3511	.333	.3573	.3696
9	.3696	.3515	.4137	.3696	.37	.3573	.3696
10	.333	.37	.3761	.3326	.3761	.3949	.4066
11	.333	.4325	.3949	.37	.4513	.3696	.37
12	.3515	.3197	.3881	.407	.4325	.3511	.3145
13	.333	.3009	.3881	.3515	.4325	.3142	.2775
14	.3515	.2821	.3326	.2775	.6582	.3142	.259
15	.3515	.2633	.3326	.2405	.5265	.3142	.259
16	.2775	.2445	.3326	.333	.4701	.3142	.2405
17	.3145	.2633	.3511	.37	.3901	.3142	.2775
18	.296	.2633	.3511	.3885	.3715	.3696	.2775
19	.37	.3761	.4066	.3885	.4325	.4066	.3515
20	.333	.3761	.3511	.3515	.4137	.4066	.37
21	.296	.3385	.3326	.333	.3761	.3696	.3145
22	.3145	.3009	.3142	.296	.3761	.3696	.296
23	.296		.3142	.296	.3761	.3696	.3145
24		.2775	.2821	.3142	.2775	.3385	.3326
Max	.3881	.4325	.4137	.407	.6582	.4066	.4066
Min	.2587	.2405	.2633	.2405	.2405	.3142	.2405
Avg	.3144	.3011	.3362	.3267	.3683	.3500	.3220

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACE

Feeder No / Name : 210 / 11 kv Ramanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2172	.2746	.2012	.2353	.2563	.3045
2	.2149	.1991	.2746	.1829	.2172	.2563	.3045
3	.2149	.1991	.2746	.1829	.1991	.2563	.3045
4	.2149	.1991	.2746	.1829	.1991	.2746	.3045
5	.2149	.1991	.2746	.1791	.1991	.2746	.3045
6	.2686	.2353	.2929	.3045	.2534	.3113	.3224
7	.2328	.4163	.3662	.3045	.3077	.3479	.394
8	.4835	.3439	.3662	.3761	.3077	.3296	.3224
9	.3045	.362	.4028	.2865	.3439	.3296	.3045
10	.3077	.3439	.3296	.4119	.3113	.2746	.3582
11	.2715	.3296	.3113	.362	.3296	.2507	.2896
12	.2896	.4211	.2865	.3258	.2929	.2328	.2715
13	.2715	.3662	.2686	.3258	.2746	.2328	.2715
14	.2172	.3296	.2328	.2715	.2563	.2328	.2534
15	.1991	.2929	.2328	.2534	.238	.2328	.1991
16	.2353	.2197	.2507	.2172	.2563	.2507	.1991
17	.2715	.2746	.2865	.2353	.2746	.2507	.2353
18	.3077	.3113	.2865	.2896	.3296	.2686	.2896
19	.362	.3845	.3761	.3439	.4394	.4119	.3258
20	.362		.3761	.3439	.4211	.4119	.3258
21	.3258	.3845	.3761	.2715	.3845	.3582	.3258
22	.2896	.3479	.3403	.2896	.3662	.2686	.2896
23	.2715	.3296	.3224	.2715	.3296	.3045	.2896
24	.2686	.2353	.2746	.3045	.2534	.2929	.2686
Max	.4835	.4211	.4028	.4119	.4394	.4119	.394
Min	.1991	.1991	.2328	.1791	.1991	.2328	.1991
Avg	.2764	.3018	.3063	.2799	.2925	.2880	.2941



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACE

Feeder No / Name : 211 / 11 kv J P NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4558	.567	.5121	.5105	.5487	.567
2	.4755	.4376	.567	.4938	.4923	.5487	.567
3	.4755	.4376	.567	.4938	.4923	.5487	.567
4	.4755	.4376	.5853	.4938	.4923	.6401	.567
5	.4755	.4741	.5853	.4938	.5288	.6401	.567
6	.823	.6017	.5853	.6584	.6381	.7133	.7133
7	.7865	.6928	.7865	.6584	.6928	.8413	.823
8	.7316	.8205	1.0974	1.1523	.6928	.6767	.7316
9	.9145	.7293	.8048	.823	1.1304	1.0059	.7499
10	.7293	.8022	.7682	.8048	1.0059	.7865	1.0242
11	.6928	.8048	.714	.7658	.7316	.7682	.6928
12	.6928	.8048	.695	.7293	.6584	.6401	.6564
13	.6381	.7133	.695	.6746	.6767	.5487	.6381
14	.5834	.567	.5853	.5834	.6225	.5487	.5652
15	.5288	.5121	.567	.5105	.5853	.5487	.5105
16	.5105	.4755	.5853	.5105	.5487	.5304	.5105
17	.6199	.6219	.6036	.5834	.5853	.5194	.547
18	.6746	.6767	.6036	.6564	.7316	.7682	.6746
19	.8752	.8596	.8779	.784	.8962		.8752
20	.784	.8413	.8413	.7658	.8962	.8779	.8752
21	.7475	.7865	.8048	.6928	.8048	.7682	.7293
22	.7293	.7316	.7499	.6746	.7316	.7499	.7475
23	.5834	.6584	.695	.6381	.6767	.6767	.6381
24	.4938	.4923	.5853	.6767	.547	.6036	
Max	.9145	.8596	1.0974	1.1523	1.1304	1.0059	1.0242
Min	.4755	.4376	.567	.4938	.4923	.5194	.5105
Avg	.6473	.6431	.6882	.6596	.6820	.6739	.6755

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON  
PALACEFeeder No / Name : 401 / 33 KV DRAGON PALACE  
INCOMMER Feeder KV- 33 /  
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7166	2.2848	2.6192	2.6057	2.5634	2.6802	2.7166
2	2.5503	2.2848	2.6192	2.4394	2.5634	2.8421	2.7166
3	2.5503	2.2291	2.6192	2.4394	2.5634	2.8421	2.7166
4	2.5503	2.2291	2.6749	2.4394	2.5634	3.0093	2.7166
5	2.5503	2.2848	2.7306	2.4394	2.7306	3.0093	2.7166
6	2.5503	2.7864	2.8421	3.1047	3.1207	3.1764	3.1047
7	3.6591	3.5108	3.4551	3.1047	3.5108	3.6223	3.6591
8	3.9918	3.6223	4.0681	4.1581	3.446	3.678	3.5482
9	4.2135	3.7337	3.7894	3.8255	4.6253	4.3467	3.8809
10	4.4582	4.2353	3.1764	4.1581	4.291	4.1795	4.5462
11	4.5139	4.3467	3.7894	4.4582	4.0124	4.1027	3.9566
12	4.5696	4.291	3.77	4.4024	3.5665	3.5482	3.3436
13	4.1238	3.7337	3.4928	4.0124	3.7337	3.0493	3.6223
14	3.5665		3.0493	3.5665	3.6223	3.0493	3.1764
15	3.678		3.0493	3.2879	2.2932		2.9535
16	3.7337		3.1047	3.3436	3.0093	3.0493	2.8978
17	3.9566	3.2879	3.4374	3.5665	3.1764	3.1047	3.1764
18	4.4582	3.4551	3.4374	3.9009	2.8556	3.7146	3.7337
19	4.5696	4.1795	4.3244	4.3467	4.2353	4.3799	4.5139
20	3.8452	3.9566	3.77	4.0124	4.2353	4.1581	4.5139
21	3.5665	3.678	3.6037	3.5665	3.7337	3.9363	4.0124
22	3.3436	3.3436	3.2156	3.3436	.1641	3.4928	3.7894
23	2.8978	3.065	3.0493	3.065	3.1178	1.2752	3.5108
24	2.6612	2.5634	2.7306	2.7166	2.7306	2.8443	2.8829
Max	4.5696	4.3467	4.3244	4.4582	4.6253	4.3799	4.5462
Min	2.5503	2.2291	2.6192	2.4394	.1641	1.2752	2.7166
Avg	3.5531	3.2906	3.2674	3.4293	3.1860	3.3518	3.4336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 201 / 11 KV Bhilgaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.6036	.6036	.5658	.6602	.6413	.6602
2	.4572	.6036	.6413	.5658	.6413	.6036	.6602
3	.4382	.5847	.6413	.547	.6224	.5847	.6602
4	.4382	.6036	.6602	.547	.6224	.6224	.6413
5	.5658	.5847	.6602	.5658	.6413	.6036	.6413
6	.5847	.6224	.6979	.6036	.679	.6413	.6722
7	.6036	.7922	.7922	.679	.7356	.8299	.7655
8	.7356	.7922	.8029	.7922	.7655	.8029	.8589
9	.8299	.9896	1.1203	.7842	.9149	.8402	.679
10	.7545	.8029	1.1016	.9896	.8962	1.0642	.6036
11	.7545	.8962	.9335	1.1949	1.1763	.9896	.6036
12	.6602	.7356	.9149	.9335	1.0082	.8775	.4904
13	.6224	.7468	.679	1.0269	.6602	.6224	.4338
14	.6036	.8029	.6036	.5847	.8402	.8215	.4191
15	.6602	.7095	.7545	.8676	.7282	.7167	.4572
16	.5658	.6979	.6224	.5847	.8589	.9709	.4001
17	.8962	.6602	.8589	.6224	.8029	.6602	.4001
18	.8962	.8488	.8589	1.0269	.8962	.9709	.547
19	.9522	.8775	1.1016	1.2323	1.2136	.9149	.6979
20	.8029	.8029	.8029	.9522	.8589	.8402	.7167
21	.7468	.7655	.7655	.8402	.7468	.7655	.6602
22	.6722	.7095	.7468	.7655	.7655	.7167	.6224
23	.6224	.6602	.6602	.7468	.6908	.6979	.5847
24	.3361	.6036	.5847	.6413	.6602	.6413	.6413
Max	.9522	.9896	1.1203	1.2323	1.2136	1.0642	.8589
Min	.3361	.5847	.5847	.547	.6224	.5847	.4001
Avg	.6524	.7290	.7754	.7775	.7952	.7683	.6049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 202 / 11 KV Ranala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.3547	.381	.3772	.3734	.3696	.4527
2	.0377	.3511	.362	.3772	.3734	.3658	.4338
3	.0373	.3696	.362	.3772	.3547	.3475	.4527
4	.0377	.3801	.381	.3584	.3547	.4251	.415
5	.0566	.4024	.4191	.3961	.3361	.439	.4715
6	.056	.439	.4338	.415	.3921	.462	.5281
7		.4805	.5281	.4527	.5228	.5487	.5658
8	.0377	.5415	.6535	.5658	.6161	.5175	.679
9	.0377	.5544	.547	.6036	.5415	.5914	.5847
10	.056	.5359	.5093	.5487	.4715	.5228	.4805
11	.0381	.4481	.4668	.5359	.4904	.5041	.4805
12	.0381	.4668	.4338	.4805	.4527	.5041	
13	.0381	.4108	.4108	.4435	.415		
14	.0572	.3734	.3921	.4294	.3772	.3921	
15	.0381	.3361	.3734	.3881	.3048	.3921	
16	.0381	.3361	.3547	.3734	.381	.3734	
17	.037	.4527	.3921	.3772	.3326	.4108	
18	.0366	.4527	.4481	.4527	.5175	.4715	
19	.5914	.547	1.1016	.5975	.6099	.6348	.056
20	.5415	.5658	.5228	.5601	.5601	.6036	.0377
21	.5121	.5281	.5415	.5041	.4805	.5281	.0377
22	.4572	.4715	.4854	.4668	.462	.5144	.0377
23	.4066	.415	.4294	.4294	.4066	.4763	.0377
24	.0377	.3511	.3772	.3734	.3772	.3511	.4191
Max	.5914	.5658	1.1016	.6036	.6161	.6348	.679
Min	.0366	.3361	.3547	.3584	.3048	.3475	.0377
Avg	.1418	.4402	.4711	.4535	.4377	.4672	.3630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 203 / 11 KV Ankit Industrial  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7282	.6478	.7167	.8589	.961	.9054
2	.6413	.7095	.6287	.6602	.8402	.961	.8676
3	.6602	.7468	.6097	.6602	.8402	.9335	.8676
4	.6036	.7655	.6097	.6979	.8215	.9522	.8488
5	.6224	.7842	.6097	.7356	.8402	.9149	.8865
6	.5658	.7842	.5847	.7922	.8589	.8962	.9896
7	.5093	1.1088	.5335	.7733	.8775	.8775	.9522
8	.6413	1.5339	.6478	1.3203	.9149	1.251	.8962
9	.7167	1.1203	.6224	.9997	1.0269	1.9959	.8402
10	.8402	.9425	.6287	1.6278	1.1694	1.251	.8501
11	1.1203	1.0829	.6348	1.9589	1.2696	1.2136	.8871
12	1.2696	.9335	.6161	1.0974	1.3676	1.251	.6722
13	1.0829	1.1203	.6535	1.6095	2.3655	1.2136	.7392
14	1.6078	1.6991	.5228	.9877	1.1389	1.3817	.7865
15	1.7926	1.1949	.6908	.8316	1.2567		.5544
16	1.6263	1.251	.6535	2.0119	1.5708	1.8298	.6036
17	1.0164	1.6817	.6348	.9997	1.5524	1.7187	.6878
18	.9795	1.6817	.8029	1.0751	1.251	1.7187	.7282
19	1.0719	1.0642	.7468	2.1285	.924	.8299	.5975
20	.7392	.6979	.6161	.7468	.8402	.9522	.4715
21	.7392	.6036	.7095	.8215	.7577	.8775	.679
22	.8131	.6413	.7095	.8775	.8316	.8775	.6413
23	.7762	.6413	.7468	.8402	.8962	.9335	.6413
24	.6413	.7282	.6413	.6908	.8865	.9979	.8402
Max	1.7926	1.6991	.8029	2.1285	2.3655	1.9959	.9896
Min	.5093	.6036	.5228	.6602	.7577	.8299	.4715
Avg	.9041	1.0102	.6459	1.0692	1.0816	1.1648	.7681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 204 / 11 KV Suman Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.168	.1715	.1698	.1886	.1867	.1905
2	.1698	.1867	.1905	.1698	.1867	.1867	.1905
3	.1509	.2054	.1715	.1886	.168	.1867	.1905
4	.1509	.1867	.1905	.1886	.2241	.1867	.1905
5	.2075	.2054	.1905	.2075	.2427	.1867	.1905
6	.2263	.2218	.1905	.2075	.2054	.1829	.1905
7	.2452	.2353		.2075	.2614	.2614	.2477
8	.2452	.2743	.2667	.2263	.2614	.2218	.2667
9	.3206	.2587	.2858	.2829	.2987	.2987	.2667
10	.3547	.2743	.3429	.2987	.3206	.3361	.3142
11	.3239	.2801	.4108	.2957	.3772	.3174	.2614
12	.381	.3361	.3772	.4163	.3772	.3921	.2587
13	.3048	.2801	.3174	.3292	.3048	.2801	.2033
14	.362	.2241	.3174	.3109	.3429	.3174	.2195
15	.3961	.3174	.3547	.2987	.3048	.2614	.2218
16	.381	.3547	.3547	.3511	.415	.2801	.2218
17	.3696	.3048	.3361	.3018	.3142	.2829	.2218
18	.3696	.3772	.3734	.3547	.3511	.362	.2427
19	.2801	.3239	.2801	.2614	.2957	.3048	.2241
20	.2587	.2667	.2801	.2641	.2743	.3048	.132
21	.2378	.2667	.2614	.2427	.2561	.2477	.112
22	.2195	.2096	.2241	.2241	.2218	.2286	.1132
23	.5394	.1905	.1867	.1867	.1848	.2096	.0943
24	.3361	.168	.1715	.168	.168	.1829	.1905
Max	.5394	.3772	.4108	.4163	.415	.3921	.3142
Min	.1509	.168	.1715	.168	.168	.1829	.0943
Avg	.2917	.2549	.2716	.2564	.2727	.2586	.2065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 205 / 11 KV Khasala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	1.0136	1.1203	.9431	1.1016	1.0974	1.0829
2	.9054	1.0082	1.1576	.9242	1.0456	1.1273	1.1016
3	.8676	1.0082	1.1389	.9242	1.0456	1.1203	1.1016
4	.8676	.9896	1.1016	.9808	1.0269	1.1389	1.0829
5	.8865	.9896	.9335	1.1317	1.0082	1.086	1.0642
6	.9808	.9709	1.0642	1.1506	1.2696	1.1222	1.1016
7	1.094	1.251	1.1389	1.2637	1.4003	1.4377	1.2567
8	1.1883	1.2567	1.2883	1.3203	1.419	1.419	1.3306
9	1.2449	1.251	1.4415	1.5278	1.4937	1.531	1.3121
10		1.5893	1.8111	1.7372	1.7164	1.2254	1.46
11	1.5708	1.643	2.0165	1.4969	1.8665	1.7364	1.3491
12	1.4415	1.5497	2.037	1.885	1.6448	1.6991	.8316
13	1.386	1.4937	1.7737	1.7741	1.8296	1.6057	1.0791
14	1.3306	1.363	1.4937	1.7737	1.5154	1.419	1.0269
15	1.423	1.4937	1.6991	1.5912	1.7372	1.6244	1.2752
16	1.5708	1.5497	1.6244	1.5524	1.848	1.8111	.1848
17	1.4563	1.4969	1.7551	1.8296	2.0165	1.7737	.1991
18	1.5893	1.7187		1.773	1.9035	1.848	.2614
19	1.7926	1.9035	1.9418	1.6244	1.423	1.848	1.587
20	1.4045	1.7741	1.6057	1.5684	1.6057	1.7556	1.1883
21	1.2197	1.3491	1.4937	1.307	1.4784	1.3491	1.2826
22	1.2752	1.3121	1.475	1.4563	1.262	1.2936	1.0562
23	1.2696	1.1016	1.1763	1.1576	1.3392	1.1949	1.1883
24	.8865	1.0534	1.1763	.9522	1.1128	1.0974	1.1203
Max	1.7926	1.9035	2.037	1.885	2.0165	1.848	1.587
Min	.8676	.9709	.9335	.9242	1.0082	1.086	.1848
Avg	1.2408	1.3388	1.4550	1.4019	1.4629	1.4317	1.0635

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 201 / 11 KV MES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4668	.543	.5487	.7545	.3734	.5601
2	.3734	.4715	.4525	.5601	.7545	.2801	.5601
3	.2801	.5504	.5487	.5601	.7545	.2801	.5601
4	.7468	.5658	.7316	.5601	.8488	.6535	.6468
5	.9335	.823	.905	.6535		.9335	.7468
6	1.1203	1.2803	1.086		1.1317	.9335	1.2936
7	1.1203	1.3203	1.086	.9431	1.1317	.9335	1.1317
8		1.1203	1.0974	.9145	.9431	.9335	.8488
9	.9335	.9335	.9335	.9431	.9431	.9335	.9431
10	.9335	.9335	.9145	.9431	1.226	.9335	.8488
11	.9431	.7468	.9145	.8488	.9145	.9431	.9145
12	.9431	.905	.7545	.8488	.9145	.9431	.7316
13	.9145	.5487	.7545	.7545	.7316	.8488	.2829
14	.4572	.5487	.7545	.7545	.7316	.8488	.2829
15	.4572	.5601	.7545	.7545	.5487	.8488	.3772
16	.6602	.7468	.5601	.7545	.3696	.8488	.5487
17	.7545	.7316	.7468	.8488	.3658	.9431	.5658
18	.7468	.9145	.9431	.7545		.9431	.9335
19	.7468	.9335	.9431	.9431	.905	1.1317	1.1317
20	1.0269	.9335	.9431	.9431	.905	.9431	.7545
21	.8488	.9335	.9431	.8488	.9335	.9431	.9145
22	.6602	.9145	.7545	.8488	.7468	.8402	.7545
23	.5601	.5487	.5658	.7545	.6535	.7545	.7545
24	.5601	.5601	.5487	.5658	.7545	.4668	.5658
Max	1.1203	1.3203	1.0974	.9431	1.226	1.1317	1.2936
Min	.2801	.4668	.4525	.5487	.3658	.2801	.2829
Avg	.7432	.7913	.7991	.7761	.8165	.8098	.7355



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 205 / 11 KV AIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.181	.2743	.3658	.1848	.1848
2	.1848	.1829	.181	.1848	.2743	.1848	.1848
3	.1848	.2743	.181	.1848	.2743	.1848	.1848
4	.1848	.2743	.181	.1848	.2743	.1848	.1848
5	.1848	.2743	.2743	.1848	.2743	.1848	.1848
6	.1848	.2743	.181		.2743	.1848	.1848
7	.1848	.2743	.181	.2743	.2743	.1848	.1829
8	.1867	.2772	.1829	.1829	.2743	.1848	.1829
9	.1848	.2772	.1848	.2743	.2743	.1848	.1829
10	.1848	.2772	.2715	.2743	.3658	.1848	.1829
11	.2743	.1848	.2715	.3658	.362	.1829	.2715
12	.2743	.181	.2715	.3658	.3658	.2743	.2715
13	.2743	.1829	.2715	.3658	.362	.2743	.2743
14	.2195	.1829	.2743	.3658	.181	.1829	.2743
15	.2743	.1848	.2715	.3658	.181	.1829	.2743
16	.2743	.1848	.2715	.3658	.1791	.1829	.2743
17	.2743	.2715	.1848	.3658	.1791	.1829	.2743
18	.1848	.362	.2743	.2743	.2715		.2743
19	.1848	.2772	.2743	.2743	.2715	.3658	.3658
20	.3696	.2772	.2715	.2743	.2715	.2743	.3658
21	.4572	.2772	.2715	.3658	.1848	.2743	.2743
22	.3658	.181	.2715	.3658	.1848	.2772	.2743
23	.2772	.1829	.2715	.3658	.1848	.2743	.2743
24	.1848	.2772	.181	.2743	.3658	.1848	.1829
Max	.4572	.362	.2743	.3658	.3658	.3658	.3658
Min	.1848	.181	.181	.1829	.1791	.1829	.1829
Avg	.2391	.2408	.2347	.2945	.2696	.2157	.2403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 206 / 11 KV NCDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3658	.5487	.2743	.2743	.3772	.3696
2	.3772	.2743	.5487	.2743	.2743	.2829	.2772
3	.2829	.2743	.3658	.2743	.2743	.2829	.2743
4	.3772	.2195	.5487	.2743	.2743	.4715	.2743
5	.3772	.2195	.5487	.3658	.2743	.4715	.2686
6	.3772	.2195	.7316		.2743	.3772	.2715
7	.3772	.3658	.5487	.3658	.1829	.1886	.1829
8	.3658	.3658	.4525	.3658	.2743	.1886	.1829
9	.3658	.5487	.5658	.3658	.2743	.3772	.1829
10	.4572	.5487	.5487	.3658	.2195	.1886	.1829
11	.1829	.5487	.4572	.4572	.2715	.1829	.2743
12	.1829	.362	.4572	.3658	.2715	.362	.2743
13	.3658	.543	.4572	.3658	.362	.3658	.1829
14	.3658	.543	.5487	.3658	.362	.3658	.2743
15	.4572	.5658	.5487	.3658	.181	.3658	.2743
16	.4572	.5658	.5487	.3658	.1848	.3658	.1829
17	.3658	.724	.4572	.3658	.181	.3658	.2743
18	.4572	.724	.2743	.4582	.362	.3658	.3658
19	.5487	.7545	.4572	.4572	.5373	.7316	.4572
20	.4572	.5658	.7316	.3658	.362	.3658	.3658
21	.4572	.4715	.3658	.3658	.3772	.3658	.3658
22	.4572	.543	.3658	.3658	.3772	.362	.3658
23	.3658	.4572	.3658	.3658	.2829	.3658	.2743
24	.4715	.3658	.7316	.2743	.3658		.3658
Max	.5487	.7545	.7316	.4582	.5373	.7316	.4572
Min	.1829	.2195	.2743	.2743	.181	.1829	.1829
Avg	.3958	.464	.5073	.3579	.2948	.3538	.2819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 208 / 11 KV KAMPTEE I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	1.0974	1.0974	1.0974	1.2536	1.448
2	.8954	1.0974	1.0974	1.086	1.0974	1.0745	1.4327
3	.7164	1.0059	.9145	1.086	.9145	1.0745	1.2536
4	1.2536	1.0374	1.2803	1.086	.9145	1.2536	1.267
5	1.4327	1.0059	1.267	1.267	.9145	1.4327	1.448
6	1.4327	1.0059	1.448		1.4632	1.2536	1.4327
7	1.4327	2.0119	1.6461	1.4632	1.6289	1.0745	
8	1.9909		1.829	2.0119	1.4632	1.97	.905
9	1.6289	1.8099	1.4327	1.6461	1.8099	1.6975	2.1719
10	1.448	1.8099	1.448	1.829	1.3575	1.6118	1.9909
11	1.448	1.9909	1.2803	1.4632	1.6289	1.6289	1.829
12	1.6289	2.0119	1.448	1.8099		1.6289	1.6461
13	1.4632	2.0119	1.4632	1.6289	1.2803	1.448	1.2803
14	1.1888	1.4632	1.4632	1.6289	1.267	1.6289	1.2803
15	1.0059	1.4632	1.267	1.448	1.0974	1.448	1.1888
16	1.1888	1.2803	1.2803	1.448	1.086	1.448	1.0974
17	1.4632	1.2803	1.2536	1.448	1.267	1.448	1.4632
18	.724	1.4632	1.829	1.3717	1.267	1.8099	1.829
19	1.9909	1.97	1.829	1.8099	1.9909	1.9909	1.7375
20	1.8099	1.97	1.829	1.829	1.9909	1.8099	1.829
21	1.829	1.7909	1.6461	1.4632	1.7909	1.8099	1.829
22	1.2803	1.4632	1.6461	1.6289	1.6118	1.6118	1.4632
23	1.086	1.2803	1.2803	1.448	1.4327	1.448	1.4632
24	1.0745	1.086	1.2803	1.2803	1.448	1.2536	1.448
Max	1.9909	2.0119	1.829	2.0119	1.9909	1.9909	2.1719
Min	.7164	1.0059	.9145	1.086	.9145	1.0745	.905
Avg	1.3541	1.4955	1.4273	1.4904	1.3835	1.5045	1.5102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 210 / 11 KV KAMPTEE II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7316	.543	.9145	.7316	.7392	.8954
2	.5544	.7316	.724	.8954	.7316	.5544	.905
3	.5544	.7316	.5487	.7164	.6401	.5544	.8954
4	.7392	.7316	.724	.7164	.6401	.924	.8954
5	.924	.7316	.724	.7164	.6401	1.1088	.9145
6	.924	.823	.905		.9145	.924	.8954
7	.924	1.2803	.9145	.9145	1.086	.924	1.267
8		1.6289	1.4632	1.2803	1.0974	1.1088	1.267
9	1.267	1.267	1.2936	1.0974	1.448	1.3203	1.267
10	1.086	1.448	1.086	1.2803	1.1765	1.2936	1.448
11	1.086	1.6289	.905	1.2803	1.086	1.086	1.0974
12	1.086	1.4632	1.086	1.267		1.086	1.0974
13	1.0974	1.4632	1.086	1.086	.905	1.086	.9145
14	.7316	1.086	.9145	1.086	.9145	1.086	.9145
15	.7316	.9145	.9145	.905	.724	.905	.7316
16	.9145	.905	.9145	.9145	.724	.905	.7316
17	.9145	.905	.905	.905	.724	.905	.7316
18	.905	.905	.9145	.9145	1.086	1.086	.9145
19	1.086	1.1088	1.0974	1.086	1.086	1.086	1.0974
20	1.267	1.1088	1.0974	1.0974	1.086	1.086	.9145
21	1.0974	1.1088	.9145	.9145	1.1088	1.086	.9145
22	1.0059	.9145	.9145	1.086	.924	1.086	.9145
23	.905	.9145	1.0974	.905	.924	.905	.9145
24	.7392	.724	.7316	.9145	.905	.924	.905
Max	1.267	1.6289	1.4632	1.2803	1.448	1.3203	1.448
Min	.5544	.724	.543	.7164	.6401	.5544	.7316
Avg	.9245	1.0523	.9341	.9954	.9262	.9904	.9768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 402 / 33 KV Khaperkheda 2  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6461	1.9204	1.9805	1.6975	2.009	2.1948
2		1.6975	1.6461	1.9204	1.7558	1.7375	2.009
3		1.8107	1.9204	1.8107	1.8107	1.6289	2.0513
4	2.1176	1.8107	1.9204	1.8107	1.8107	2.1176	2.0513
5	2.6063	1.8107	2.4691	1.8107	2.0936	2.1176	2.2177
6	2.552	2.1	2.4691		2.2634	2.1719	2.3285
7	2.552	2.5789	2.4691	2.5463	2.3045	2.4434	2.4691
8	2.7149	2.7435	2.7435	2.8292	2.3765	2.4434	2.4691
9	2.7435	2.7435	2.552	2.8292	2.5789	2.552	2.5789
10	2.5789	2.5789	2.7149	2.7435	2.4691	2.9864	2.4691
11	2.4691	1.9204	2.5789	2.6337		2.4691	2.3765
12	2.1948	2.5789	2.4691	2.4691	2.1948	2.4691	1.9805
13	2.2634	2.4691	2.6595	2.1948	2.4691	2.4691	1.8107
14	1.8107	1.9404	2.3765	1.9204	2.1948	2.1948	1.4146
15	2.0936	1.9204	2.2634	2.1948	2.1719	2.4691	1.6461
16	2.1502	1.9204	2.5463	2.1948	2.1719	2.4691	2.3045
17	2.2634	2.1948	2.4691	2.4691	2.1948	2.3045	2.2634
18	2.4691	3.0178	3.1121	2.2634	2.4434	2.7149	3.1121
19	2.8532	2.9864	2.9424	2.5789	3.2922	3.2922	3.1121
20	2.9081	2.9864	2.8292	2.5463	3.0178	3.0178	2.8292
21	2.7435	2.9864	2.8292	2.524	2.8235	2.7435	2.6595
22	2.1948	2.1948	2.037	2.3045	2.4434	2.4691	2.5463
23	2.1948	2.1948	2.2634	1.9204	1.9547	2.1948	
24	1.9004	1.9204	1.9204	2.0936	1.6461	2.009	2.1948
Max	2.9081	3.0178	3.1121	2.8292	3.2922	3.2922	3.1121
Min	1.6461	1.6461	1.6461	1.8107	1.6461	1.6289	1.4146
Avg	2.3646	2.2813	2.4217	2.2865	2.2687	2.3956	2.3082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 404 / 33 KV SAGGU CASTING

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.8477	4.9794	4.1872	4.4582	4.6399	4.7611	4.2438
16	5.7693	5.2669	4.201	5.4332	7.4497		2.4949
24	8.0093	6.2809	5.9414	6.394	6.2809	5.8848	6.5638
Max	8.0093	6.2809	5.9414	6.394	7.4497	5.8848	6.5638
Min	3.8477	4.9794	4.1872	4.4582	4.6399	4.7611	2.4949
Avg	5.8754	5.5091	4.7765	5.4285	6.1235	5.3230	4.4342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 408 / 33 KV MAHADULA I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0751	1.0185	.9619	.9717	.9619	1.0185	1.0185
Max	1.0751	1.0185	.9619	.9717	.9619	1.0185	1.0185
Min	1.0751	1.0185	.9619	.9717	.9619	1.0185	1.0185
Avg	1.0751	1.0185	.9619	.9717	.9619	1.0185	1.0185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 409 / 33 KV MAHADULA II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	4.4136	3.7346	4.0741	3.6008	4.4702	4.5268	3.7912
Max	4.4136	3.7346	4.0741	3.6008	4.4702	4.5268	3.7912
Min	4.4136	3.7346	4.0741	3.6008	4.4702	4.5268	3.7912
Avg	4.4136	3.7346	4.0741	3.6008	4.4702	4.5268	3.7912



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 201 / 11KV VASAHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.056	.0565	.056	.056	.0373	.0373
2	.0373	.056	.0565	.056	.0373	.0373	.0373
3	.0373	.056	.0565	.056	.0373	.0373	.0373
4	.0373	.056	.0565	.056	.0373	.0373	.056
5	.056	.056	.0565	.056	.0373	.0373	.056
6	.056	.056	.0565	.056	.056	.056	.0373
7	.056	.056	.0565	.056	.056	.0565	.0373
8	.056	.0373	.0376	.0373	.056	.0187	.0187
9	.0373	.0187	.0376	.0187	.0187	.0565	.0373
10	.0373	.056	.0376	.056	.056	.0565	.0373
11	.0373	.0376	.0188	.0189	.0565	.056	.0373
12	.0373	.0376	.0376	.056	.0188	.056	.0377
13	.056	.0376	.056	.056	.0565	.0373	.056
14	.056	.0376	.056	.056	.0565	.0373	.056
15	.056	.0565	.056	.056	.0565	.0373	.056
16	.056	.0188	.056	.056	.0565	.056	.056
17	.056	.0188	.056	.056	.0376	.0373	.056
18	.056	.0188	.056	.056	.0376	.0373	.056
19	.056	.0376		.056	.0376	.056	.0373
20	.056	.0565	.056	.056	.0376	.0373	.0187
21	.0373	.0376	.0514	.0187	.0188	.056	.0189
22	.056	.0376	.0373	.0189	.0188	.0373	.0187
23	.056	.0376	.0373	.0377	.0373	.0373	.0189
24	.056		.0565	.056	.056	.0376	.0373
Max	.056	.0565	.0565	.056	.0565	.0565	.056
Min	.0373	.0187	.0188	.0187	.0187	.0187	.0187
Avg	.0490	.0424	.0495	.0483	.0429	.0436	.0397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 202 / 11kv BORDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2241	.2071	.2614	.3174	.2987	.1867
2	.168	.2241	.2259	.2614	.2987	.2987	.1867
3	.168	.2241	.2259	.2614	.2987	.2987	.1867
4	.168	.2241	.2259	.2614	.2987	.2987	.1867
5	.1867	.2614	.2824	.2987	.3361	.3361	.2241
6	.2241	.2987	.32	.3734	.4854	.3361	.2614
7	.2801	.3361	.3388	.3921	.4668	.3547	.2614
8	.3361	.3547	.4141	.4294	.4481	.2987	.2801
9	.2801	.2801	.4141	.3361	.3361	.2614	.2801
10	.3547	.2987	.3953	.2987	.3361	.2614	.2427
11	.2801	.3012	.3576	.4481	.3012	.2614	.2801
12	.2801	.32	.3576	.3547	.2635	.2801	.2614
13	.2614	.2824	.2241	.3174	.2824	.2614	.2427
14	.3174	.2635	.0934	.3361	.3388	.1867	.2054
15	.3174	.2635	.2241	.2987	.3388	.1867	.1867
16	.3174	.2447	.3174	.3547	.2259	.2054	.2241
17	.2987	.2824	.2987	.3174	.2824	.2427	.1867
18	.3361	.3576	.3547	.3734	.32	.2801	.2801
19	.2987	.3576		.3547	.3012	.2987	.2801
20	.2987	.32	.3174	.3361	.2824	.2801	.2801
21	.2614	.2824	.2801	.2987	.2824	.2427	.2614
22	.2241	.2447	.2427	.2614	.2259	.2241	.2241
23	.1867	.2071	.2614	.2427	.2427	.2241	.2054
24	.1867	.2241	.2071	.2614	.2987	.2427	.2054
Max	.3547	.3576	.4141	.4481	.4854	.3547	.2801
Min	.168	.2071	.0934	.2427	.2259	.1867	.1867
Avg	.2591	.2782	.2863	.3221	.3170	.2692	.2342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 203 / 11 KV TEKADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6535	.6776	.7842	.8029	.8402	.9709
2	.7095	.6535	.6588	.7842	.7655	.8029	.9335
3	.7095	.6535	.6588	.7842	.7842	.8029	.9335
4	.6722		.7153	.7842	.7842	.7655	.9709
5	.7095		.7906		.8589	.8402	1.0082
6	.8962	.9149	.9035	.8402	.9149	.8589	1.0829
7	1.1203		.96	.8962	1.0269	1.0269	1.1763
8	1.0829	1.0269	1.0165	.8962	1.0642	1.0729	1.1763
9	1.1576	1.0456	1.0165	1.0082	1.1016	1.1203	1.251
10	1.0269	.9709	.9788	.9335	1.2136	1.1203	.9522
11	.9149	.9035	.9035	.9149	1.167	1.0456	1.0456
12	.9335	.7153	.8094	.8775	.8094	.9335	.7842
13	1.0082		.8402	.8029	.8471	.9709	.8962
14	.7202		.8215	.7655	.8471	.9896	.8589
15	.8215	.7153	.7095	.6535	.9035	.9896	.8029
16		.7529	.7655	.6722	.9412	.9896	.9896
17		.9035	.8029	.7282	1.167	.9522	.9522
18	.8402	.9976	.9522	.9896	1.2423	1.1203	1.1203
19	1.3443	1.1482		1.0456	1.2235	1.4003	1.1949
20	1.2696	.96	1.251	.9709	1.2235	1.307	1.1389
21	1.1203	.9035	.9709	.8589	.9788	1.1949	1.2323
22	.8029	.8471	.8029	.8029	.9223	1.1203	.9522
23	.8215	.8282	.6535	.6908	.8659	1.0829	1.0269
24	.7846	.6535	.7906	.8215	.6908	.8471	1.0082
Max	1.3443	1.1482	1.251	1.0456	1.2423	1.4003	1.251
Min	.6722	.6535	.6535	.6535	.6908	.7655	.7842
Avg	.9188	.8551	.8457	.8394	.9644	1.0081	1.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 201 / 11 KV VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
15	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 203 / 11 KV KANHAN U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381					
13		.0191	.0191		.0191	
14				.0191		.0191
15	.0191					
24	.0191					
Max	.0381	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0254	.0191	.0191	.0191	.0191	.0191

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 205 / 11 KV KANHAN R

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191						
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
16	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 206 / 11 KV KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
16	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 207 / 11 KV WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191						
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
15	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 209 / 11KV KFA II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
15	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 210 / 11 KV STATION T/F  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191						
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
15	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 211 / 11 KV REHAB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0191	.0191		.0191	.0191	
14				.0191			.0191
16	.0191						
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 400 / 33KV Mansar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0572	.0572		.0572	.0572	
14				.0572			.0572
15	.0572						
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 401 / 33 KV KANHAN W/W  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0572	.0572		.0572	.0572	
14				.0572			.0572
15	.0572						
24	.0572						
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 402 / 33KV GONDEGAON  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572						
13		.0572	.0572		.0572	.0572	
14				.0572			.0572
15	.0572						
24	.0572						
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 403 / 33kv Dragon Palace fdr  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0572	.0572		.0572	.0572	
14				.0572			.0572
15	.0572						
24	.0572						
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 201 / 11 KV GUMTHALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4338	.4382	.415	.3772	.3429	.381
2	.3772	.4338	.4001	.4191	.4115	.3601	.381
3	.3772	.3772	.4001	.4001	.4287	.3944	.362
4	.4115	.3772	.362	.4001	.4287	.4115	.362
5	.4115	.3772	.362	.381	.3944	.3944	.4382
6	.3944	.3961	.3239	.4001	.3944	.4287	.4763
7	.4287	.4904	.3239	.4191	.4115	.4115	.5144
8	.3772	.4715	.3429	.4763	.3429	.4287	.4763
9	.4115	.6413	.4954	.5716	.3944	.4115	.4763
10	.4715	.6097	.4854	.463	.4973	.4954	.4715
11	.4904	.5906	.4668	.4801	.5658	.5144	.4954
12	.3961	.5716	.5041	.5487	.5144	.5335	.4763
13	.5093	.5906	.5601	.5144	.5658	.5716	.4763
14	.4904	.5716	.5415	.4801	.5316	.5525	
15	.4715	.5525	.5041	.4973	.5144	.5335	
16	.5658	.5716	.5415	.5144	.5144	.5906	
17	.5847	.5716	.5601	.4801	.463	.5716	.2075
18	.6036	.5906	.5975	.463	.4801	.6097	.4527
19	.6224	.5335	.6348	.463	.4973	.5716	.4715
20	.5658	.5716	.6097	.4801	.4801	.5525	.4382
21	.5093	.5144	.5525	.4115	.463	.5144	.4001
22	.4715	.4763	.4763	.4115	.3944	.4763	.381
23	.4338	.4382	.4382	.3601	.3601	.4382	.3584
24	.3429	.4338	.4382	.4338	.3772	.3601	.381
Max	.6224	.6413	.6348	.5716	.5658	.6097	.5144
Min	.3429	.3772	.3239	.3601	.3429	.3429	.2075
Avg	.4616	.5078	.4733	.4535	.4501	.4779	.4227



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 202 / 11 KV PALSAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.1886	.2614	.2829	.5144	.2572	.4108
2	.3429	.1886	.2614	.2829	.6001	.2572	.4108
3	.3429	.1886	.2427	.2829	.6859	.3429	.4294
4	.2572	.1886	.2427	.1886	.6859	.3429	.4294
5	.1715	.1886	.2801	.1886	.6001	.2572	.4668
6	.1715	.2075	.2801	.1886	.6001	.2572	.4668
7	.2572	.2263	.3174	.2829	.6859	.3429	.5041
8	.3429	.2452	.3361	.2829	.3429	.3429	.5228
9	.4287	.6036	.4108	.3772	.6001	.4287	.5601
10	.7922	.6722	.4715	.6001	.5144	.6908	.5658
11	1.0562	.7468	.9431	.6859	.8573	.8962	.5658
12	.9619	.8029	.7468	.7716	.7716	.9335	
13	.9619	.9149	.5658	.7716	1.0288	.9709	
14	.9431	.8589	.5601	.7716	.9431	.9335	
15	.9054	.8029	.9335	.8573	.8573	.8962	
16	.9431	.7655	.7468	.7716	.8573	.9149	
17	.9054	.7095	.7468	.4801	.7716	.8962	.5658
18	.8488	.7468	.6535	.8573	.6859	.9335	.6602
19	.7545	.6161	.5601	.6859	.6859	.9896	.7545
20	.6036	.5415	.4668	.6859	.3429	1.0269	.4715
21	.5281	.4108	.4715	.6001	.3429	.5975	.4715
22	.4715	.3361	.3772	.5144	.4287	.4854	.4715
23	.2829	.2987	.3772	.3601	.2572	.4481	.415
24	.2572	.2829	.2614	.3772	.4287	.2572	.415
Max	1.0562	.9149	.9431	.8573	1.0288	1.0269	.7545
Min	.1715	.1886	.2427	.1886	.2572	.2572	.4108
Avg	.5745	.4888	.4798	.5062	.6287	.6125	.5030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 203 / 11 KV BHUGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6154	.6722	.5975	.583	.6001	.6722
2	.5144	.6154	.6348	.6036	.5487	.6001	.6348
3	.5487	.5973	.6348	.5658	.5487	.6173	.6348
4	.5487	.5973	.7095	.5281	.583	.6516	.6722
5	.583	.5973	.7842	.5281	.583	.6516	.7095
6	.5658	.6516	.8962	.6036	.5658	.6173	.7468
7	.6344	.724	.8962	.6602	.6173	.6687	.7842
8	.8573	1.0317	.9896	.9431	.6859	.9259	.8402
9	.8916	1.1584	1.0082	1.0562	.823	.9431	.8962
10	1.0498	1.251	1.0751	1.1145	1.1145	1.0456	.9808
11	1.1222	1.307	1.1317	1.1488	1.0974	1.0829	1.0456
12	1.3394	1.363	1.226	.6859	1.2003	1.1763	1.0374
13	1.4842	1.4003	1.3392	1.0288	1.286	1.4003	1.0185
14	1.4842	1.363	1.251	1.1831	1.2346	1.3443	.9808
15	1.4842	1.4003	1.1576	1.2346	1.2517	1.307	
16	1.4842	1.419	1.1576	1.2174	1.3032	1.3443	
17	1.3032	1.3443	1.1576	1.2689	1.2517	1.1576	
18	1.086	1.2696	.9709	.8745	1.0288	1.0642	
19	.9412	1.1016	.9054	.8573	.9088	.9522	.7655
20	.8326	.9522	.7922	.8059	.823	.9149	.6979
21	.7421	.8029	.7356	.7373	.7716	.8402	.6602
22	.6697	.7468	.6602	.6859	.703	.7468	.6036
23	.6154	.7095	.6224	.6173	.6516	.7095	.5847
24	.5487	.6154	.6722	.5975	.5658	.6344	.6722
Max	1.4842	1.419	1.3392	1.2689	1.3032	1.4003	1.0456
Min	.5144	.5973	.6224	.5281	.5487	.6001	.5847
Avg	.9102	.9848	.9200	.8393	.8638	.9165	.7819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 204 / 11 KV BHOWARI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.1867	.1132	.1886	.0171	.1715	.1132
2	.0171	.0747	.0566	.1886	.0171	.0171	.0754
3	.0171	.056	.0566	.1698	.0171	.0171	.0566
4	.0171	.056	.0377	.1698	.0171	.0171	.0943
5	.0171	.0373	.0377	.0566	.0171	.0171	.0377
6	.0171	.1494	.0566	.0566	.0171	.0171	.0377
7	.1029	.1494	.0943	.132	.1372	.1372	.1132
8	.2229	.2241	.1509	.1886	.1543	.1543	.1509
9	.1886	.1867	.1886	.1886	.2427	.1372	.1886
10	.2241	.2075	.2263	.2229	.2229	.2075	.2263
11	.2427	.2452	.2641	.1886	.2743	.2452	.3018
12	.2075	.2263	.1886	.1715	.2572	.2263	.2263
13	.168	.1886	.1509	.1886	.2229	.1886	.2075
14	.1886	.2263	.2263	.2743	.1886	.2263	.2075
15	.2263	.2263	.2452	.2572	.2401	.2452	.2263
16	.2427	.2452	.2829	.1886	.2572	.2829	.2263
17	.2054	.2263	.3018	.2229	.2229	.1886	.2263
18	.2241	.2452	.2263	.0171	.1886	.2263	.1886
19	.1867	.1886	.1509	.0171	.1715	.1886	.1698
20	.168	.1886	.1698	.0171	.0171	.1509	.1698
21	.1494	.1886	.2263	.1029	.1372	.1509	.1698
22		.2075	.2075	.2229	.1886	.1509	.1886
23	.2054	.1698	.2829	.1886	.2743	.1509	.1886
24	.1372	.2054	.1509	.1867	.2743	.2572	.1509
Max	.2427	.2452	.3018	.2743	.2743	.2829	.3018
Min	.0171	.0373	.0377	.0171	.0171	.0171	.0377
Avg	.1475	.1794	.1705	.1586	.1573	.1572	.1643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 205 / 11 KV SAWALI GARLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.181	.3395	.4338	.3429	.2572	.3395
2	.1715	.181	.415	.4338	.3429	.3429	.3018
3	.2572	.181	.4715	.415	.4287	.3429	.3018
4	.2572	.1629	.5847	.415	.4287	.3429	.3395
5	.3429	.1629	.6224	.3772	.3429	.4287	.3395
6	.2572	.1991	.5658	.3772	.3429	.3429	.3772
7	.2572	.3982	.6224	.4715	.3772	.3429	.3772
8	.4287	.543	.6979	.5658	.3429	.4801	.4715
9	.4287	.5973	.7356	.6602	.4287	.4287	.5093
10	.543	.679	.7095	.6001	.6001	.6036	.5093
11	.6722	.7167	.7167	.6859	.7716	.7167	.5093
12	.724	.7733	.7095	.5144	.5144	.811	
13	.9955	.9054	.7167	.5144	.6001	.9054	
14	.9774	.8676	.7167	.6001	.5144	.8676	
15	.6335	.8676	.7095	.6859	.583	.8488	
16	.6516	.9054	.6535	.6001	.6859	.9054	
17	.6154	.811	.5975	.6001	.6001	.7356	.4904
18	.5611	.7545	.5601	.5144	.6859	.6979	.4715
19	.543	.6036	.5601	.5144	.6859	.5847	.4715
20	.5068	.5281	.5281	.5144	.5144	.5281	.3772
21	.4525	.4715	.5093	.4287	.4287	.4904	.3395
22	.362	.4338	.4715	.4287	.5144	.4527	.3584
23	.3077	.3961	.415	.3429	.3429	.415	.3018
24	.2572	.3077	.3395	.415	.3429	.2572	.3395
Max	.9955	.9054	.7356	.6859	.7716	.9054	.5093
Min	.1715	.1629	.3395	.3429	.3429	.2572	.3018
Avg	.4740	.5262	.582	.5045	.4901	.5471	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 206 / 11 KV VAISHNAVI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0566	.0566	.0566	.0514	.0514	.0566
2	.0514	.0566	.0566	.0566	.0514	.0514	.0566
3	.0514	.0566	.0566	.0566	.0514	.0514	.0566
4	.0514	.0566	.0566	.0566	.0514	.0514	.0566
5	.0514	.0566	.0566	.0566	.0514	.0514	.0566
6	.0514	.0566	.0566	.0566	.0514	.0514	.0566
7	.0514	.0566	.0566	.0566	.0514	.0514	.0566
8	.0514	.0566	.0566	.0566	.0514	.1372	.0754
9	.0514	.0566	.0754	.0566	.0514	.0514	.0754
10	.0566	.1698	.0943	.0514	.1372	.2075	.0566
11	.0566	.2263	.1307	.1372	.2572	.2829	.0566
12	.0566	.2075	.132	.6859	.3429	.3018	.0566
13	.0566	.2452	.112	.6859	.5144	.3395	.0566
14	.0566	.3206	.1698	.6001	.3429	.415	.0566
15	.0566	.3018	.1886	.5144	.4287	.4338	.0566
16	.0566	.3584	.2075	.4287	.4287	.4715	.0566
17	.0566	.2452	.2263	.6859	.3429	.3206	.0566
18	.0566	.1886	.1886	.0514	.0686	.1886	.0566
19	.0566	.1132	.1886		.0514	.1132	.0566
20	.0566	.0754	.0566	.0514	.0514	.0943	.0566
21	.0566	.0754	.0566	.0514	.0514	.0943	.0566
22	.0566	.0754	.0566	.0514	.0514	.0754	.0566
23	.0566	.0754	.0566	.0514	.0514	.0754	.0566
24	.0514	.0566	.0754	.0566	.0514	.0514	.0566
Max	.0566	.3584	.2263	.6859	.5144	.4715	.0754
Min	.0514	.0566	.0566	.0514	.0514	.0514	.0566
Avg	.0544	.1352	.1029	.2005	.1514	.1672	.0582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 207 / 11KV WADODA INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.4481	.3395	.4115	.3601	.4854
2	.3772	.3772	.4481	.3395	.4287	.3601	.4854
3	.4115	.3772	.4294	.3206	.4287	.4115	.4668
4	.4115	.3772	.4668	.297	.3772	.4287	.4668
5	.3258	.3772	.5415	.3584	.3772	.4287	.4294
6	.3258	.415	.6348	.3961	.3944	.4115	.3921
7	.4115	.5093	.6348	.4715	.4801	.4801	.3547
8	.583	.6602	.6722	.5658	.5144	.6344	.4294
9	.6344	.7733	.8962	1.4523	.6859	.6859	.4854
10	1.2826	.9709	1.1694	1.286	.8916	.8029	.4527
11	1.9993	1.0642	1.2637	1.3717	1.1145		.415
12	1.3014	.9522	1.226	1.4575	.8573		.3961
13	.5658	.8589	.4904	1.286	.703		.3961
14	.9808	1.0456	.9808	.8573	.7545	.9709	.3206
15	2.037	1.1763	1.0562	.823	.7545	1.1016	.2452
16	1.094	1.2696	1.1694	.7545	.6001	1.2136	.2829
17	.9808	1.1763	1.2517	.823	.7545	1.1576	.3018
18	.8865	1.2136	1.1317	1.0802	.8573	1.1203	.3395
19	.7733	.9149	.9997	1.0288	.8745	.9896	.415
20	.679	.6535	.7167	.703	.7373	.7842	.4527
21	.5093	.5788	.4338	.6687	.6859	.7282	.4715
22	.415	.5228	.415	.4458	.5487	.6722	.415
23	.3584	.4854	.3772	.4115	.5144	.5601	.3772
24	.3944	.3584	.4481	.3772	.3772	.4115	.5228
Max	2.037	1.2696	1.2637	1.4575	1.1145	1.2136	.5228
Min	.3258	.3584	.3772	.297	.3772	.3601	.2452
Avg	.7534	.7286	.7626	.7465	.6301	.7007	.4083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 208 / 11 KV CHIKHALI NIMBHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1629	.1509	.1509	.1372	.1372	.1886
2	.1372	.1629	.1509	.1509	.1372	.1886	.1886
3	.1543	.1448	.132	.132	.12	.1886	.168
4	.1715	.1448	.132	.132	.1543	.1372	.1698
5	.1715	.1448	.1698	.132	.1543	.1372	.1886
6	.1372	.1448	.2263	.1509	.1543	.1715	.2263
7	.1715	.181	.2263	.1886	.1886	.1886	.2641
8	.2229	.2172	.2641	.2829	.2229	.2572	.2452
9	.2534	.3258	.3584	.3206	.2572	.2743	.2829
10	.362	.3772	.362	.3601	.3258	.3395	.3206
11	.3982	.3961	.3801	.3086	.3772	.3584	.3584
12	.4344	.4338	.4163	.4115	.3601	.4338	.3961
13	.4887	.4527	.4344	.3944	.3772	.4715	.4338
14	.4706	.4338	.4163	.3772	.3601	.4338	.4338
15	.2829	.415	.3982	.3944	.3772	.4715	.4527
16	.415	.415	.3982	.3601	.3944	.4527	.4527
17	.362	.4338	.4163	.3944	.3772	.3584	.0377
18	.2896	.3206	.3077	.2058	.2572	.3206	.3206
19	.2353	.2641	.2534	.1886	.2401	.2829	.2641
20	.2172	.2075	.2263	.1715	.2058	.2641	.2452
21	.1991	.1886	.2263	.1543	.1715	.2452	.2075
22	.181	.1698	.1886	.1372	.1715	.2263	.1886
23	.1629	.1698	.1509	.12	.1543	.2263	.1886
24	.1372	.1629	.1509	.1494	.12	.1543	.1886
Max	.4887	.4527	.4344	.4115	.3944	.4715	.4527
Min	.12	.1448	.132	.12	.12	.1372	.0377
Avg	.2573	.2696	.2724	.2403	.2415	.2800	.2671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 209 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0343	.0377	.0377	.0377	.0343	.0343	.0377
16		.0377	.0377			.0377	.0377
24	.0754	.0754	.0566	.1132			.0566
Max	.0754	.0754	.0566	.1132	.0343	.0377	.0566
Min	.0343	.0377	.0377	.0377	.0343	.0343	.0377
Avg	.0549	.0503	.044	.0755	.0343	.036	.044



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 201 / 11 KV INDUSTRIAL I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.8962	1.0829	.9709	1.0082	.9335	1.1763
2	.7095	.8589	1.0829	.9335	.9709	.9335	1.1203
3	.6908	.7842	1.0456	.9335	.9335	.8962	1.0456
4	.6908	.7468	1.0456	.8962	.9335	.8962	.9896
5	.6908	.8029	1.0082	.8589	.8962	.9335	.9335
6	.6722	.8962	.8775	.8215	.8962	.9335	.8402
7	.6722	1.0829	1.0456	.8589		.8962	.7842
8	.7468	1.0642	1.1576	1.2323	1.0082	.9709	.8029
9	.8402	1.2696	1.307	1.419	1.1203	1.0456	.8215
10	1.0829	1.475	1.8298	2.2032	1.251	1.8298	.7842
11	1.4003	2.4086		2.5206	2.2779	2.2218	.7842
12	2.1658	2.0911	2.3525	2.3525	2.2218	1.9978	
13	2.2032	2.0351	1.8484	2.2032	1.7364	1.9231	
14	2.2779	2.5019	1.9231	2.3339	3.0994	2.0538	
15	2.3152	2.5019	2.1098	2.4272	2.1658	2.2965	
16	2.2405	2.4459	2.3152	2.3899	2.0538	2.2965	
17	2.1845	2.1285	2.2405	2.2965	2.0165	2.1845	.6535
18	1.9791	2.0538		1.9044	1.7364	2.0538	.8962
19	1.1203	1.9044	1.531	1.4937	1.4563	2.0165	
20	1.0269	1.5684	1.419	1.2696	1.3443	1.4563	.7282
21	.9149	1.2136	1.2696	1.1763	.9896	1.1203	.6722
22	.9335	1.0829	1.0456	1.1203	.9896	1.0456	.7095
23	.8775	1.1203	.9709	1.0082	.9709	.9149	.6722
24	.7095	.9335	1.0829	.9709	.9709	.9335	1.2136
Max	2.3152	2.5019	2.3525	2.5206	3.0994	2.2965	1.2136
Min	.6722	.7468	.8775	.8215	.8962	.8962	.6535
Avg	1.2440	1.4945	1.4360	1.5248	1.4369	1.4493	.8682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 202 / 11 KV INDUSTRIAL II  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.6535	.6348	.9335	.5975	.7842	.8962
2	.2801	.6161	.5975	.8962	.6348	.7842	.8589
3	.2801	.5975	.5601	.8589	.6722	.8215	.8215
4	.2801	.5601	.5228	.8215	.7095	.7842	.8215
5	.2987	.5415	.4668	.7468	.7468	.7842	.7842
6	.2987	.4854	.7655	.6722	.7468	.7468	.7842
7	.2987	.5601	.5975	.6348	.7842	.7655	.7468
8	.4108	.6908	.8402	.8962	.9335	1.0269	.7095
9	.5228	.7842	1.0829	.9335	1.1203	1.2883	.6722
10	.6908	.9709	.9149	1.2136	1.251	1.3817	.5975
11	.8589	1.0642	1.0082	1.3443	1.3817	1.5497	.5415
12	.9335	.9335	1.4377	1.307	1.363	1.3443	.6722
13	.9709	.9522	1.3443	1.2323	1.4003	1.3817	.6535
14		.9335	1.3256	1.2696	1.4563	1.4937	.6348
15	1.0829	1.2696	1.3817	1.307	1.363	1.363	.7468
16	1.0269	1.3443	1.419	1.419	1.3817	1.5497	.6908
17	.9896	1.3443	1.307	1.3817	1.3443	1.2883	.7655
18	.9335	1.307	1.2136	1.1763	1.3256	1.363	.6348
19	.8402	1.1949	1.0829	.9709	1.2323	1.307	
20	.7468	.8962	.9335	.8402	1.1763	1.0456	.5975
21	.6535	.7095	.8589	.7468	.9709	.8962	.4481
22	.6348	.7468	.5975	.6535	.8402	.9335	.4481
23	.7095	.7095	1.0829	.5792	.8215	.9149	.4481
24	.2614	.6722	.6722	1.0456	.5601	.7842	.9335
Max	1.0829	1.3443	1.4377	1.419	1.4563	1.5497	.9335
Min	.2614	.4854	.4668	.5792	.5601	.7468	.4481
Avg	.6202	.8557	.9437	.9950	1.0339	1.0993	.6916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 203 / 11 KV INDUSTRIAL III  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.4937	1.531	1.7551	1.4563	1.307	1.6057
2	1.2323	1.419	1.531	1.7177	1.4937	1.307	1.6244
3		1.3817	1.4937	1.6804	1.531	1.307	1.6057
4	1.307	1.307	1.4937	1.643	1.4937	1.2696	1.6057
5	1.2696	1.2696	1.3817	1.6057	1.4563	1.2696	1.5684
6	1.2696	1.3443	1.4563	1.5684	1.4003	1.307	1.5684
7	1.307	1.4563	1.4937	1.531	1.3443	1.307	1.531
8	1.1203	1.5497	1.6057	1.8671	1.4937	1.307	1.4003
9	1.0456	1.7177	1.6991	1.9791	1.6804	1.6804	1.2696
10	1.2136	2.0165	2.0351	2.1472	2.0538	1.9231	1.2323
11	1.4003	2.5953	2.3152	2.3525	2.3712	2.2405	
12	1.6991	2.5393	2.3899	2.2405	2.5019	2.4086	
13	1.8298	2.3712	2.2965	2.1658	2.0911	2.1845	
14	2.2779	2.4646	2.2592	2.2405	2.3712	2.6139	
15	2.4272	2.6513	2.4086	2.4272	2.3712	2.4272	.6908
16	2.3339	2.6513	2.5579	2.2965	2.4272	2.5019	.5975
17	2.3525	2.4086	2.5206	2.1658	2.5393	2.4459	.6908
18	2.3899	2.6139	2.5206	2.0538	2.5953	2.4272	.9149
19	2.2405	2.6513	2.5019	1.9791	2.3899	2.3525	.9896
20	2.0538	2.1285	2.0538	1.9044		2.2405	.9709
21	1.7177	1.8858	1.8298	1.7364	.5228	1.9044	1.1016
22	1.6057	1.6244	1.7551	1.6057	1.3443	1.7924	1.1203
23	1.587	1.6057	1.6804	1.4563	1.3817	1.6804	1.1576
24	1.1203	1.531	1.5684	1.7177	1.4003	1.307	1.5684
Max	2.4272	2.6513	2.5579	2.4272	2.5953	2.6139	1.6244
Min	1.0456	1.2696	1.3817	1.4563	.5228	1.2696	.5975
Avg	1.6520	1.9449	1.9325	1.9099	1.8135	1.8547	1.2407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 204 / 11 KV INDUSTRIAL IV  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.7177	1.587	1.419	1.4937	1.587	1.4563
2	1.1949	1.6804	1.4937	1.3817	1.531	1.4937	1.4937
3	1.1763	1.6057	1.4563	1.3443	1.6057	1.4003	1.531
4	1.1763	1.4937	1.4563	1.307	1.6057	1.307	1.531
5	1.1576	1.4563	1.4377	1.2696	1.643	1.2696	1.5684
6	1.1576	1.5684	1.4937	1.2323	1.643	1.251	1.5684
7	1.1203	1.7177	1.5497	1.2323	1.6804	1.251	1.587
8	1.4563	1.7924	1.8111	1.4937	1.7924	1.4003	1.6244
9	1.587	1.7737	2.1285	1.587	1.9044	1.531	1.587
10	1.7364	2.0538	2.2218	1.8298	2.0351	2.2592	1.4003
11	2.0911	2.894	2.3712	2.2405	2.2218	2.782	1.2696
12		2.5393	2.3152	2.5206	2.3339	2.9127	1.2883
13	2.5766	2.3339	2.2405	2.6513	1.9978	2.4272	1.0829
14	2.6139	2.0911	2.2592	2.3339	1.587	1.8858	.9896
15	2.6513	2.5206	2.4646	2.2405	2.0911	2.2032	1.1763
16	2.6139	2.5393	2.8006	2.3339	2.1285	2.2218	1.1949
17	2.5766	2.2779	2.6139	2.2965	2.1472	2.2965	1.0082
18	2.5206	2.2405	2.4272	2.2405	2.1658	2.1658	1.0829
19	2.2405	2.1658	2.2405	2.1472	2.1285	2.0538	1.1763
20	1.8671	1.5123	2.2032	2.0911	2.1658	1.8298	1.1763
21	1.7177	1.531	2.1472	1.9044	1.7177	1.5684	1.1576
22	1.8298	1.8671	1.7924	1.6804	1.9978	1.4937	1.1576
23	1.9231	1.7737	1.4937	1.531	1.7737	1.419	1.1203
24	1.1576	1.7924	1.6804	1.419	1.4563	1.7551	1.4003
Max	2.6513	2.894	2.8006	2.6513	2.3339	2.9127	1.6244
Min	1.1203	1.4563	1.4377	1.2323	1.4563	1.251	.9896
Avg	1.7973	1.9558	1.9869	1.8220	1.8686	1.8235	1.3179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 205 / 11 kv kapsi pawangaon  
dhargaon Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7095	.6722	.6348	.7468	.6908	.8402
2	.6722	.6535	.6722	.6535	.7468	.6908	.8962
3	.6722	.7282	.6348	.6722	.7282	.6908	.9335
4	.6348	.7842	.6722	.6348	.7095	.6722	.9709
5	.6348	.7468	.6535	.6535	.6908	.6722	.9896
6	.5975	.7095	.7655	.6722	.6908	.6535	.9896
7	.5975	.7282	.5975	.6722	.6535	.6722	1.0269
8	.6535	.7842	.7095	.8215	.7468	.6722	1.0269
9	.7468	.8215	.7468	.8589	.8402	.7282	.9896
10	.8589	1.307	.9896	1.1763	1.1389	1.1576	.9335
11	1.1016	1.4937	1.1949	1.4003	1.4003	1.4003	.6161
12	1.4377	1.5123	1.3443	1.1203	1.0829	1.4937	.6908
13	1.475	1.3256	1.3256	.8962	.9896	1.0829	.6908
14	1.531	1.0269	1.307	.9709	.9149	1.0269	.6908
15	1.419	.8589	1.3443	.9335	.9335	1.0082	
16	1.4563	.9896	1.3443	1.0082	.9335	1.3256	
17	1.3256	1.5123	1.307	.9709	.9709	1.4003	.5601
18	1.3443	1.9605	1.1203	.9335	.9709	1.307	.5975
19	1.1203	2.0725	.8215	.8962	.8589	1.2136	.6161
20	1.1203	.6908	.8215	.8402	.7468	.9335	.5975
21	.6908	.6722	.8029	.8215	.6908	.7842	.6161
22	.7095	.6908	.7842	.7842	.6908	.7842	.6348
23	.6535	.6908	.6161	.7468	.7095	.7468	.6535
24	.7468	.6722	.6722	.6348	.7842	.6908	.7842
Max	1.531	2.0725	1.3443	1.4003	1.4003	1.4937	1.0269
Min	.5975	.6535	.5975	.6348	.6535	.6535	.5601
Avg	.9546	1.0059	.9133	.8503	.8487	.9374	.7884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 206 / 11 KV ADKA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5975	.5601	.5975	.5228	.5601	.5228
2	.4668	.6535	.5601	.5975	.5601	.5601	.5041
3	.4668	.6348	.5601	.5601	.5601	.5601	.5228
4	.4668	.6161	.5601	.5975	.5975	.5788	.5228
5	.4481	.5601	.5415	.6161	.5975	.5601	.5415
6	.4481	.5415	.5601	.6348	.6535	.5788	.5415
7	.4481	.5975	.5601	.6535	.6535	.5788	.5601
8	.7842	.7468	.6722	.7842	.7468	.7842	.6535
9	.8402	.8775	.8962		.8402	.8589	.7468
10	.8962	.9709	.9335	.9709	.8215	.9149	.7468
11	.9335	1.1203	.9709	1.0269	.8402	.9709	.7842
12	1.0082	1.0082	.9896	1.0269	.8402	1.1389	.8589
13	1.0456	1.0269	.9522	1.0082	.6535	1.0456	.8589
14	.9709	.8029	1.0269	.9709	.9522	1.4003	1.1203
15	.9896	.9522	1.0269	.9149	.9149	1.2323	.8775
16	.9335	.9896	1.0829	.9149	.8962	1.1203	.8589
17	.8589	1.0456	.9335	.9335	.9522	.2241	1.0269
18	.8962	.9335	.8402	.7468	.8402	.7468	.8962
19	.8589	.8029	.8029	.6722	.7282	.8029	.6722
20	.7468	.6535	.7468	.6161	.6535	.6722	.6161
21	.6348	.6348	.6722	.5975	.5975	.5975	.5975
22	.6161	.5788	.5975	.5601	.5601	.5601	.5975
23	.6535	.5601	.5228	.5415	.5975	.5041	.5601
24	.4854	.5975	.5601	.5601	.5041	.5975	.4854
Max	1.0456	1.1203	1.0829	1.0269	.9522	1.4003	1.1203
Min	.4481	.5415	.5228	.5415	.5041	.2241	.4854
Avg	.7243	.7710	.7554	.7436	.7118	.7562	.6947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359] BU 0359

Substation No/ Name :- 164031 / 33 KV MAA UMIYA

Feeder No / Name : 207 / 11 KV STATION XMER  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
17		.0373	
19			.0373
24	.0373		
Max	.0373	.0373	.0373
Min	.0373	.0373	.0373
Avg	.0373	.0373	.0373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 201 / 11 KV BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.4999	.5716	.5716	.5906	.506	.5906
2	.6287	.4999	.5716	.5716	.5906	.506	.5906
3	.6097	.4999	.5716	.5716	.5906	.506	.5906
4	.6097	.5218	.6097	.5716	.5906	.5218	.5716
5	.6478	.5668	.6668	.5716	.5906	.5535	.6097
6	.724	.6133	.7049	.6287	.6478	.6062	.6668
7	.743	.6706	.7621	.724	.724	.6962	.724
8	.8192	.6962	.7811	.8002	.7811	.7293	.724
9	.7811	.7293	.7811	.7811	.8573	.7293	.7049
10	.743	.663	.743	.743	.6325	.6554	.6097
11	.6401	.7621	.7811	.743	.5693	.7621	.5525
12	.7042	.7811	.8002	.7049	.6642	.7621	.5716
13	.7362	.724	.8192	.6859	.6874	.8002	.5906
14	.5921	.724	.8192	.7621	.6562	.8002	.5144
15	.6481	.8192	.8192	.8002	.6882	.7049	.5716
16	.6481	.8002	.8002	.7621	.7682	.6859	.5906
17	.6173	.8383	.7621	.7811	.7202	.7811	.5906
18	.7202	.7621	.724	.743	.7274	.743	.6668
19	.763	.8383	.8002	.7811	.788	.8192	.6478
20	.6952	.8383	.743	.7811	.6706	.743	.6097
21	.6613	.724	.7049	.7049	.6401	.7049	.5525
22	.5441	.6478	.6287	.6478	.5921	.6097	.5335
23	.5121	.5906	.5716	.6097	.5441	.5716	.5335
24	.6287	.4999	.5906	.5716	.5906	.5218	.5716
Max	.8192	.8383	.8192	.8002	.8573	.8192	.724
Min	.5121	.4999	.5716	.5716	.5441	.506	.5144
Avg	.6686	.6796	.7137	.6922	.6626	.6675	.6033



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 202 / NEW DHANLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8589	.9526	.9335	.9145	.8328	.9145
2	.9145	.8413	.9526	.9335	.9145	.8328	.8954
3	.9145	.8413	.9717	.9335	.9145	.8328	.8954
4	.9907	.8764	1.0479	.9335	.9145	.8505	.8954
5	1.1812	.9745	1.1431	.9335	.9145	.9313	1.0479
6	1.3336	1.0924	1.2765	1.086	1.2193	1.1041	1.2955
7	1.4289	1.3032	1.5242	1.2955	1.4861	1.4083	1.467
8	1.3908	1.267	1.3717	1.4098	1.4289	1.3969	1.5432
9	1.2003	1.2536	1.3717	1.3717	1.2193	1.3253	1.5432
10	1.1812	1.0208	1.3717	1.4289	.9922	1.2048	1.3336
11	.9465	1.0098	1.2384	1.2193	.9568	1.2574	1.0479
12	1.0341	1.0288	1.2384	1.3908	.9036	1.1812	.9526
13	1.0341	1.1241	1.3336	1.2193	.9568	1.2765	.9907
14	.964	1.0288	1.3336	1.2574	1.0454	1.2193	1.0669
15	.8718	1.0288	1.1812	1.1241	1.0117	1.2003	.9907
16	.8215	.8954	1.1241	1.0479	1.0288	1.0288	.9335
17	.8048	1.086	1.1622	1.2384	.9602	1.1241	1.0479
18	1.0631	1.2955	1.1241	1.2574	1.1919	1.3717	1.2193
19	1.3717	1.5813	1.4098	1.467	1.4299	1.3336	1.3908
20	1.2986	1.467	1.3527	1.3146	1.2489	1.3146	1.2955
21	1.2071	1.2765	1.2765	1.2193	1.134	1.2193	1.1431
22	.9922	1.105	1.1241	1.0669	.9745	1.0479	1.0288
23	.9036	.9907	.9717	.9526	.8859	.9526	.9145
24	.9335	.8589	.9526	.9526	.9335	.8505	.9526
Max	1.4289	1.5813	1.5242	1.467	1.4861	1.4083	1.5432
Min	.8048	.8413	.9526	.9335	.8859	.8328	.8954
Avg	1.0715	1.0878	1.2003	1.1661	1.0658	1.1291	1.1169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 204 / 11 kv Pawaddona

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0903	.1143	.1715	.1905	.0926	.1334
2	.1334	.0903	.1143	.1715	.1905	.0926	.1334
3	.1334	.0903	.1143	.1715	.1905	.0926	.1334
4	.1334	.0903	.1143	.1715	.1905	.0926	.1334
5	.1334	.0903	.1143	.1715	.1905	.0926	.1334
6	.1334	.108	.1143	.1905	.1905	.0949	.1524
7	.1524	.1094	.1334	.1905	.1905	.112	.1524
8	.1715	.125	.1524	.2286	.2096	.1372	.1905
9	.1905	.1677	.2096	.2477	.2477	.1677	.1715
10	.2096	.1829	.2096	.2477	.1932	.1806	.1905
11	.1524	.2286	.2286	.2858	.1932	.2477	.2286
12	.2315	.2286	.2858	.2858	.1957	.2667	.2096
13	.216	.2286	.2667	.2858	.2286	.3048	.2286
14	.2315	.2477	.2858	.2858	.2286	.3239	.2477
15	.2172	.2477	.2667	.2667	.208	.2858	.2477
16	.2027	.2477	.2477	.3048	.1783	.3048	.2286
17	.1882	.2477	.2667	.3048	.1783	.3048	.1715
18	.1486	.2096	.2477	.2667	.1806	.2286	.1715
19	.128	.1715	.2096	.2286	.144	.1715	.1524
20	.128	.1524	.2096	.2286	.16	.1715	.1334
21	.128	.1524	.2096	.2096	.128	.1715	.1334
22	.108	.1334	.1905	.1905	.112	.1715	.1334
23	.108	.1334	.1715	.1905	.096	.1524	.1143
24	.1334	.0903	.1334	.1715	.1905	.0926	.1524
Max	.2315	.2477	.2858	.3048	.2477	.3239	.2477
Min	.108	.0903	.1143	.1715	.096	.0926	.1143
Avg	.1602	.1610	.1921	.2278	.1836	.1814	.1699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 205 / 11 KV NEHARVANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.6718	.8002	.8383	.8573	.6958	.8192
2	.8002	.6562	.8002	.8192	.8573	.6958	.8192
3	.8002	.6562	.8192	.8192	.8573	.6958	.8383
4	.8002	.6718	.8383	.8002	.8573	.6958	.8573
5	.8383	.7362	.8573	.8002	.8573	.7116	.8954
6	.8764	.8192	.9526	.8954	.9335	.8029	.9526
7	.9717	.8785	1.0288	.9907	1.0288	.9448	1.0098
8	1.0479	.8421	1.0669	1.086	1.0479	.9503	.9335
9	.9717	.9231	1.0669	1.0479	1.0098	.9667	.8764
10	.9717	.8745	1.0479	.9526	.8333	.8745	.8192
11	.8697	.9717	1.0288	1.0479	.8025	.9335	.6668
12	.953	.9907	1.105	1.086	.8436	.9335	.6478
13	.9842	1.1431	1.0669	1.1431	.8951	1.0098	.724
14	.9374	1.1431	1.0288	1.1622	.8488	.8764	.7811
15	.9755	1.105	1.1622	.9145	.8535	1.0098	.724
16	.9907	.9907	1.1431	.8764	.7773	.9717	.743
17	.9755	1.2003	1.1431	.8383	.9755	.9717	.743
18	.9172	1.1622	1.086	1.0288	.9442	1.0669	.8002
19	1.0059	1.105	1.1241	1.105	1.0059	1.105	.9145
20	.9389	1.0288	1.0288	1.086	.9724	1.0288	.8954
21	.9054	.9717	1.0288	.9907	.8583	.9717	.8383
22	.759	.8954	.9145	.9145	.7935	.8764	.7621
23	.7116	.8192	.8764	.8764	.7611	.8383	.724
24	.8002	.6718	.8002	.8383	.8573	.7116	.8002
Max	1.0479	1.2003	1.1622	1.1622	1.0479	1.105	1.0098
Min	.7116	.6562	.8002	.8002	.7611	.6958	.6478
Avg	.9001	.9137	.9923	.9566	.8887	.8891	.8161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 206 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1524
2	.1524	.1524	.1524	.1524	.1524	.1524	.1524
3	.1524	.1524	.1524	.1524	.1524	.1524	.1524
4	.1524	.1524	.1524	.1524	.1524	.1524	.1524
5	.1524	.1524	.1524	.1524	.1524	.1524	.1524
6	.1524	.1524	.1334	.1524	.1524	.1524	.1524
7	.0381	.1524	.0381	.0381	.0381	.1524	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.1524	.0381	.1524	.1524	.1524	.1524	.1524
20	.1715	.1524	.1524	.1524	.1524	.1524	.1524
21	.1524	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Max	.1715	.1524	.1524	.1524	.1524	.1524	.1524
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0960	.0953	.0945	.0953	.0953	.1000	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 201 / 11 KV MOUDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5415	.543	.5658	.5601	.6348	.6535
2	.547	.5415	.5249	.5658	.5658	.6535	.6535
3	.5228	.5415	.5068	.6036	.5415	.6535	.6535
4	.5359	.5415	.5487	.6036	.5847	.6535	.6722
5	.5975	.5975	.5792	.6602	.6099	.7095	.7468
6	.8299	.8029	.7522	.7356	.9149	.8402	.8589
7	1.0829	1.1016	1.0498	.8676	1.0829	1.1203	.9709
8	1.0082	1.0562	.9593	.9431	1.0269	.8775	.9997
9	.8488	.9242	.905	.9054	.9335	.8775	.8775
10	.7842	.9335	.905	.9242	.9054	.9522	.8589
11	.8488	.905	.8865	.9335	.8215	1.0082	.8402
12	.7922	.7522	.811	.9335	.7468	.8402	.724
13	.811	.724	.7733	.7762	.6447	.8215	.7468
14	.7922	.6878	.7733	.7468	.7468	.7655	.7282
15	.7733	.6697	.7356	.7468	.7095	.8029	.6908
16	.811	.7682	.6413	.6979	.6722	.8029	.7468
17	.7922	.724	.6979	.9709	.7545	.7842	.7282
18	.9242	.8326	.9242	.8962	.9709	.7842	.8316
19	1.1506	.9955	1.1128	1.0269	1.0456	.7842	1.0669
20	1.0456	.9593	1.0562	1.0082	1.0082	.6348	1.0082
21	.9808	.9145	.9054	.8962	.9335	.9522	.823
22	.7733	.7602	.7545	.7842	.8402	.7842	.8402
23	.6413	.6584	.6036	.6535	.6908	.7282	.6697
24	.5601	.5601	.567	.5658	.6161	.6348	.6722
Max	1.1506	1.1016	1.1128	1.0269	1.0829	1.1203	1.0669
Min	.5228	.5415	.5068	.5658	.5415	.6348	.6535
Avg	.7917	.7706	.7715	.7921	.7886	.7959	.7943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 202 / 11 KV WADODA IND  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.743	.8131	.6478	.8865	.8488	.5658
2	.4954	.724	.7865	.6478	.8764	.8488	.5658
3	.5093	.724	.7602	.6859	.8775	.8299	.679
4	.5228	.724	.823	.6859	.8589	.8299	.7545
5	.5601	.743	.8688	.7049	.8962	.8299	.7545
6	.6287	.7922	.905	.7811	.9242	.811	.8299
7	.6979	.7167	.8145	.8192	.9145	.7733	.7545
8	.6161	.7922	.8779	.8002	.8488	.8488	.5847
9	.8383	1.1506	.9145	1.0374	1.0751	1.2071	.547
10	.9896	1.4712	1.0679	1.1128	.9907	1.4712	.547
11	1.0562	1.3169	.9619	1.1576	.8865	1.4335	.5093
12	.0377	1.3394	.9619	1.1622	.8865	1.1694	.6908
13	.547	1.2715	.9242	1.0082	1.1694	1.226	.6535
14	.9242	1.0566	.9997	1.1317	1.1317	1.358	.6722
15	1.0562	1.1523	1.094	1.0456	.9997	1.4146	.6478
16	.9242	1.0425	1.0185	1.0374	.9997	1.363	.4527
17	1.0562	1.134	1.0374	.9709	1.0374	1.3392	.4715
18	.9808	1.1999	1.0751	.9896	1.0185	1.2826	.5415
19	1.094	1.2715	1.1128	1.1576	.8962	1.1389	.6348
20	.9619	.9328	.8865	.9997	.9242	1.094	.5788
21	.8488	1.0136	.9054	.8676	.8865	1.094	.5975
22	.8865	.9694	.8299	.7922	.8402	.9619	.5788
23	.7167	.8145	.8488	.9149	.7545	.8488	.6036
24	.5281	.7545	.823	.7733	.8299	.8522	.8299
Max	1.094	1.4712	1.1128	1.1622	1.1694	1.4712	.8299
Min	.0377	.7167	.7602	.6478	.7545	.7733	.4527
Avg	.7494	.9938	.9213	.9138	.9337	1.0781	.6269

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 203 / 11 KV WADODA R

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-FEB-18	03-FEB-18
HR	Load (MW)	Load (MW)
1		.5533
2		.5365
3		.5197
4		.4973
5		.5138
6		.547
7		.6036
8		.7042
9		.7127
10		.7209
11	.3315	
12	.5533	
13	.57	
14	.6962	
15	.8215	
16	.8122	
17	.8383	
18	.7127	
19	.7545	
20	.7293	
21	.6952	
22	.6203	
23	.5868	
24		.5765
Max	.8383	.7209
Min	.3315	.4973
Avg	.6709	.5896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 204 / 11 KV TARSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.4298	.1829	.1595	.1433	.1791	.1254
2	.1646	.4656	.1629	.1595	.1254	.1791	.1254
3	.1448	.4656	.1463	.1595	.1448	.1791	.1254
4	.1448	.5014	.1326	.1595	.1433	.1791	.1254
5	.1478	.5373	.1509	.1772	.1629	.1791	.1433
6	.1267	.6805	.1823	.1772	.1629	.1791	.1612
7	.1791	.7619	.2353	.1949	.1829	.197	.1791
8	.2033	.8238	.2172	.1949	.2172	.197	.1254
9	.1629	.2126	.1991	.1402	.1629	.1612	.1254
10	.1848	.2126	.1791	.0886	.1448	.1791	.1433
11	.1595	.1991	.1063	.2149	.1433	.197	.1267
12	.1595	.1829	.1595	.181	.1254	.197	.1267
13	.1772	.1629	.1578	.1612	.1254	.1791	.1267
14	.1595	.1086	.1595	.1612	.1433	.1612	.1086
15	.1772	.1629	.1417	.1629	.1075	.1612	.1448
16	.1949	.1829	.1595	.2534	.1791	.1612	.1463
17	.2126	.1791	.1595	.1629	.1612	.1433	.1629
18	.2303	.2328	.2126	.1991	.2507	.1433	.1629
19	.2835	.2743	.2303	.2353	.2328	.1433	.1791
20	.2658	.2896	.2279	.2353	.2328	.1612	.181
21	.2481	.2534	.2126	.2033	.197	.1612	.181
22	.2126	.2328	.1772	.181	.1612	.1433	.1612
23	.1949	.1829	.1595	.1646	.1612	.1433	.1448
24	.1509	.4607	.181	.1595	.1612	.1612	.0895
Max	.2835	.8238	.2353	.2534	.2507	.197	.181
Min	.1267	.1086	.1063	.0886	.1075	.1433	.0895
Avg	.1847	.3415	.1764	.1786	.1655	.1694	.1426



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 205 / 11 KV NIMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-FEB-18	03-FEB-18
HR	Load (MW)	Load (MW)
1		.0181
2		.0183
3		.0181
4		.0181
5		.0183
6		.0181
7		.0183
8		.0183
9		.0183
10		.0183
11	.0181	
12	.0183	
13	.0181	
14	.0183	
15	.0181	
16	.0183	
17	.0181	
18	.0181	
19	.0183	
20	.0181	
21	.0183	
22	.0181	
23	.0183	
24		.0183
Max	.0183	.0183
Min	.0181	.0181
Avg	.0182	.0182

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 206 / 11 KV BAPDEO SUGAR FACTORY NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0362	.128	.1267	.1227	.1402	.1612
2	.128	.0362	.1267	.1267	.1052	.1433	.1612
3	.1254	.0362	.1097	.1267	.1086	.1612	.1612
4	.1254	.0905	.1086	.1448	.0867	.1791	.1612
5	.1267	.1267	.1463	.1448	.0867	.1791	.1612
6	.1254	.1448		.1448	.1052	.2328	.1612
7	.1448	.1448	.2353	.1433	.1402	.0179	.1612
8	.1402	.1254	.0543	.0716	.1227	.0179	.1612
9	.1448	.1433	.0543	.2303	.156	.0179	.1075
10	.0537	.1254	.0543	.1753	.1052	.0179	.1791
11	.2149	.1267	.0177	.156	.0358	.0179	.1734
12	.2149	.128	.0175	.1402	.1075	.0179	.1734
13	.197	.1086	.0177	.1387	.0179	.0179	.181
14	.1254	.2926	.0175	.1629	.0179	.0179	.1578
15	.1254	.1991	.0175	.1227	.2507	.0179	.2507
16	.1791	.181	.1063	.1052	.2149	.0358	.0175
17	.1791	.1448	.1402	.156	.1791	.0179	.0173
18	.2149	.1629	.1433	.1402	.1612	.0179	.0526
19	.2328	.2012	.1612	.1753	.2149	.0179	.1448
20	.2328	.181	.1417	.1629	.1791	.2328	.12
21	.2126	.181	.1417	.1753	.1791	.0179	.1227
22	.2835	.1646	.124	.3109	.1075	.1791	.1052
23	.0532	.1646	.1227	.052	.0895	.1612	.1267
24	.1307	.0543	.1448	.1254	.0526	.1433	.1433
Max	.2835	.2926	.2353	.3109	.2507	.2328	.2507
Min	.0532	.0362	.0175	.052	.0179	.0179	.0173
Avg	.1596	.1375	.1014	.1483	.1228	.0842	.1401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 207 / 11 KV BORGAO (33 KV DCL  
STN) Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3292	.3353	.3361	.3077	.3258	.3258
2	.2715	.3326	.3185	.3361	.2865		.3224
3	.2896	.3511	.3315	.3361	.3077		.3224
4	.2865	.3475	.3149	.3361	.3224		.3224
5	.3077	.3658	.3315	.3696	.3403		.3224
6	.3258	.4024	.3688	.3881	.3475		.3582
7	.362	.4119	.3812	.4207	.3801		.4119
8	.4344	.4298	.3647	.4572	.4572	.4163	.4163
9	.4656	.4477	.3812	.5121	.4706	.4119	.4656
10	.4344	.4656	.4475	.567	.4887	.0895	.4656
11	.4572	.3812	.4755	.543	.4382	.4656	.3077
12	.4755	.4024	.4572	.5611	.4557	.1433	.362
13	.4572	.3978	.4572	.5914	.5552	.4298	.3258
14	.3475	.3978	.439	.543	.5373	.4119	.3658
15	.4024	.3812	.4572	.5552	.5258	.4656	.3439
16	.4572	.407	.4435	.5028	.5552	.5014	.3582
17	.462	.4024	.4805	.5544	.5434	.4908	.3292
18	.4251	.3856	.499	.4887	.5434	.5083	.3801
19	.4251	.3978	.499	.5359	.5959	.5258	.4163
20	.4251	.3812	.4854	.5729	.5258	.5373	.4344
21	.4251	.3647	.4294	.5304	.4031	.5014	.4024
22	.3734	.4024	.3734	.4525	.3761	.3582	.362
23	.3547	.3647	.3734	.3582	.3761	.3224	.3258
24	.3109	.3361	.3481	.3547	.3475		.3224
Max	.4755	.4656	.499	.5914	.5959	.5373	.4656
Min	.2715	.3292	.3149	.3361	.2865	.0895	.3077
Avg	.3862	.3869	.4080	.4668	.4370	.4062	.3654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 201 / 11 KV TARSA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501		.8962	1.0719	.9979	1.1888	.8413
2	.8131		.8501	1.0719	.9979	1.1706	.8413
3	.8131		.8413	1.0719	.9979	1.1888	.8596
4	.8131		.8413	1.0719	.9979	1.134	.8596
5	.8686		.8596	1.0719	.9795	1.0242	.9145
6	.8871		.9694	1.0903	.9795	1.0974	1.0059
7	1.1088		.823	1.1088	.9795	.9328	1.0059
8	1.1088	.695	1.0974	1.1273	1.0719	1.3535	.8779
9	1.4415	1.1523	.9511	1.0534	1.0164	1.1706	.567
10	1.1157	1.5546	1.2986	1.6263	1.6448	1.2803	.5544
11	1.4449	1.1523	1.386	.2033	1.5912	1.4083	.4481
12	1.4266	1.3169	1.3491	1.1273	1.4632	.8413	.5041
13	1.3535		1.0903	1.1458	.9511	1.0242	.8871
14	1.134	.9328	1.2197	1.1643	.8962	.9328	.9522
15	1.5729	1.0608	1.1273	1.1273	1.2803	.9694	.9149
16	1.4815	1.1706	.9425	1.0719	1.1523	.7682	.8962
17	1.8656	1.4998	1.3306	1.1088	1.2437	1.0974	.8029
18	1.4632	1.5729	.9055	1.0534	1.262	1.1706	.8131
19	1.6461	1.7558	.9795	1.1458	1.3352	1.0242	.9425
20	1.4998	1.2803	.9979	1.0903	1.3169	1.0425	.8775
21	1.39	1.3169	.9425	.961	1.0425	1.0608	1.1643
22	.9328	1.1157	.7947	.924	1.1523	.9328	1.0164
23	.4938	.9877	.9425	1.0719	1.0974	.9145	.9149
24	.8501		.9694	1.0534	.9979	1.2254	.8596
Max	1.8656	1.7558	1.386	1.6263	1.6448	1.4083	1.1643
Min	.4938	.695	.7947	.2033	.8962	.7682	.4481
Avg	1.1823	1.2376	1.0169	1.0673	1.1436	1.0814	.8467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 202 / 11 KV NIMKHEDA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.3734	.4066	.462	.462	.5228	.4854
2	.3696	.3734	.3696	.462	.462	.5228	.4854
3	.3696	.3547	.3696	.462	.462	.5041	.5041
4	.3696	.3734	.3696	.462	.462	.5601	.5228
5	.4251	.3921	.4251	.5175	.462	.5788	.5228
6	.5175	.5228	.6099	.5914	.6283	.7282	.6535
7	.7392	.6908	.7023	.7762	.7392	.7842	.7655
8	.7023	.6908	.7023	.8131	.6468	.7842	.7282
9	.9055	.7842	.7023	.8871	.6653	.8029	.4024
10	.9335	.7947	.8316	.9425	.7207	.8215	.3841
11	.8775	.961	.9795	.8871	.7282	1.0456	.2241
12	.7468	1.1458	1.0164	.8501	.7468	1.0456	.4481
13	.7282		.8871	.7207	.7095	.9335	.6348
14	.7282	.9425	.9425	.6099	.8029	.9149	.7655
15	.7655	1.1088	.7762	.7207	.7655	1.0082	.8215
16	.7095	1.1088	.8131	.6838	.6908	.7842	.7762
17	.7842	1.0534	.8131	.5175	.6722	.9149	.7468
18	.5788	1.1088	.8871	.5914	.7468	1.0269	.8501
19	.7468	1.0719	.9425	.6468	.7655	.9335	.8131
20	.6535	.8871	.7207	.6653	.7282	.8215	.7468
21	.5975	.6283	.5914	.5914	.6908	.6722	.6468
22	.4481	.5359	.5175	.5175	.5975	.5788	.5914
23	.4108	.462	.4805	.462	.5415	.5415	.5228
24	.3881	.3734	.462	.4251	.4251	.5041	.5041
Max	.9335	1.1458	1.0164	.9425	.8029	1.0456	.8501
Min	.3696	.3547	.3696	.4251	.4251	.5041	.2241
Avg	.6201	.7277	.6799	.6360	.6384	.7640	.6061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 204 / 11 KV STN XMER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0366	.0343	.0343	.0377	.0377
2	.0377	.0377	.0366	.0343	.0343	.0377	.0377
3	.0377	.0377	.0366	.0343	.0343	.0377	.0377
4	.0377	.0377	.0366	.0343	.0343	.0377	.0377
5	.0377	.0377	.0366	.0343	.0343	.0377	.0377
6	.0377	.0377	.0366	.0343	.0343	.0377	.0377
7	.0377	.0377	.0183	.0343	.0171	.0377	.0377
8	.0377	.0377	.0366	.0343	.0171	.0377	.0377
9	.0377	.0377	.0183	.0171	.0171	.0377	.0373
10	.0189	.0189	.0183	.0171	.0171	.0189	.0373
11	.0189	.0183	.0171	.0171	.0189	.0189	.0373
12	.0189	.0183	.0171	.0171	.0189	.0189	.0187
13	.0189		.0171	.0171	.0189	.0189	.0187
14	.0189	.0183	.0171	.0171	.0189	.0189	.0187
15	.0189	.0183	.0171	.0171	.0189	.0189	.0189
16	.0189	.0183	.0171	.0171	.0189	.0189	.0189
17	.0189	.0183	.0171	.0171	.0189	.0189	.0185
18	.0189	.0183	.0171	.0343	.0189	.0377	.037
19	.0377	.0366	.0343	.0343	.0377	.0377	.0754
20	.0377	.0366	.0343	.0343	.0377	.0377	.0377
21	.0377	.0366	.0343	.0343	.0377	.0377	.0377
22	.0377	.0366	.0343	.0343	.0377	.0377	.037
23	.0377	.0366	.0343	.0343	.0377	.0377	.0377
24	.0377	.0377	.0366	.0343	.0343	.0377	.0377
Max	.0377	.0377	.0366	.0343	.0377	.0377	.0754
Min	.0189	.0183	.0171	.0171	.0171	.0189	.0185
Avg	.0307	.0307	.0273	.0279	.0270	.0314	.0344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 401 / 33 KV GUMTHALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		5.6573		4.9931		5.7133	5.5453
10							5.5453
16	4.425		6.0585		10.8053	6.6655	5.3189
24	4.2798	4.6696		5.0452	7.6589	4.8325	5.487
Max	4.425	5.6573	6.0585	5.0452	10.8053	6.6655	5.5453
Min	4.2798	4.6696	6.0585	4.9931	7.6589	4.8325	5.3189
Avg	4.3524	5.1635	6.0585	5.0192	9.2321	5.7371	5.4741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 402 / 33 KV DPL

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		6.7335		9.3364		1.4146	1.8107
10							1.8107
16	6.3443		6.6301		3.8255	3.3385	1.6409
22						3.3385	
24	5.7716	6.1111		5.7693	1.17	1.2449	1.4563
Max	6.3443	6.7335	6.6301	9.3364	3.8255	3.3385	1.8107
Min	5.7716	6.1111	6.6301	5.7693	1.17	1.2449	1.4563
Avg	6.0580	6.4223	6.6301	7.5529	2.4978	2.3341	1.6797



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 403 / 33 KV VISAKHA

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		9.3696		10.3675		10.4784	
10							9.8457
16	10.0412		10.2606		10.2058	9.5782	8.7243
24	8.85	7.9538		8.5934	8.7043	9.0741	8.9621
Max	10.0412	9.3696	10.2606	10.3675	10.2058	10.4784	9.8457
Min	8.85	7.9538	10.2606	8.5934	8.7043	9.0741	8.7243
Avg	9.4456	8.6617	10.2606	9.4805	9.4551	9.7102	9.1774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 405 / 33 KV MURLI AGRO  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		3.4751		3.4751	3.4385	
10						3.1824
16	4.7331		4.9429		5.0972	.9522
24	2.073	2.3891		2.2262	2.3348	3.2922
Max	4.7331	3.4751	4.9429	3.4751	5.0972	3.2922
Min	2.073	2.3891	4.9429	2.2262	2.3348	.9522
Avg	3.4031	2.9321	4.9429	2.8507	3.6235	2.4756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 408 / 33 KV XMER NO1 (MOUDA)  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.8107		1.829		1.8673	1.6409
16	1.7741		1.6244		1.7364	1.8484	1.1883
24	1.1317	1.358		1.4146	1.4712	1.4146	1.5278
Max	1.7741	1.8107	1.6244	1.829	1.7364	1.8673	1.6409
Min	1.1317	1.358	1.6244	1.4146	1.4712	1.4146	1.1883
Avg	1.4529	1.5844	1.6244	1.6218	1.6038	1.7101	1.4523

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 409 / 33 KV XMER NO. 2 (MOUDA)

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.9879		1.4043		1.262	1.4352
16	1.1963		1.5912		1.8484	1.358	.763
24	1.0923	1.3432		1.1831	1.1443	1.2094	1.1568
Max	1.1963	1.9879	1.5912	1.4043	1.8484	1.358	1.4352
Min	1.0923	1.3432	1.5912	1.1831	1.1443	1.2094	.763
Avg	1.1443	1.6656	1.5912	1.2937	1.4964	1.2765	1.1183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 703 / 132 KV PENNAR

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		2.6337		2.8235		2.1491	3.5757
16	2.8532		18.7243		2.9424	3.155	3.1687
22						3.155	
24	3.7311	2.4897		1.893	1.749	4.8903	3.2579
Max	3.7311	2.6337	18.7243	2.8235	2.9424	4.8903	3.5757
Min	2.8532	2.4897	18.7243	1.893	1.749	2.1491	3.1687
Avg	3.2922	2.5617	18.7243	2.3583	2.3457	3.3374	3.3341

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 704 / 132 KV DCL

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		2.6886		2.6886		2.6886	2.7161
16	2.7161		2.7161		2.9424	2.7161	2.7161
24	2.4646	2.4646		2.4897	2.6886	2.6886	2.7161
Max	2.7161	2.6886	2.7161	2.6886	2.9424	2.7161	2.7161
Min	2.4646	2.4646	2.7161	2.4897	2.6886	2.6886	2.7161
Avg	2.5904	2.5766	2.7161	2.5892	2.8155	2.6978	2.7161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 201 / 11 kV Chacher

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6602	.5895	.6413
2					.679	.5784	.5658
3					.7167	.5548	.5847
4					.6979	.5895	.6602
5					.7356	.6556	.679
6					.7545	.7362	.6413
7					.7922		
8	.7468	.6836	.9054	.7628	.7167		
9	.7468	.8682	.8676	.9015	.6036		
10	.7842	.8869	.7922	.7712	.5658		
11	.7545	.9431	.7712	.7922	.4115		
12	.7108	.8676	.7011	.7922	.4115		
13	.6935	.7468	.8328	.7545			
14	.6516	.7095	.6661	.7545			
15	.6661	.7468	.6661	.6036			
16		.7095	.6661				
17			.5959				
19				.5658			
20				.5658			
21				.5281	.5609	.5658	.4904
22				.5658	.6241	.7167	.4527
23				.6602	.6415	.679	.415
24	.4108				.679	.5959	.6413
Max	.7842	.9431	.9054	.9015	.7922	.7362	.679
Min	.4108	.6836	.5959	.5281	.4115	.5548	.415
Avg	.6850	.7958	.7465	.6937	.6407	.6261	.5772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 202 / 11 KV NAGARDHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7682	.6224	.8131	.5093	.6099	.6413
2	.6722	.7577	.6224	.7762	.547	.5914	.6036
3	.7095	.7316	.5658	.7577	.6602	.5975	.547
4	.7468	.7964	.7356	.8048	.7545	.6401	.5093
5	.8029	.9877	.9619	.9055	.7545	.6722	.6036
6	.9149	1.1523	1.0751	.9709	.7922	.7577	.6602
7	1.0269	1.2127	1.1128	1.1041	.9242	1.4003	.679
8		.7421	.8299	.703	.8299	1.1763	1.1128
9	1.1016	.8962	.9242	.8871	.8676	1.1389	1.0185
10	.9709		.9054	1.0136	.6602	.9522	.7545
11	.8402	.8299	.8215	.8676	1.1279	.7545	.6602
12	.8048	.7545	.7282	.7922	1.0277	.6413	.6036
13	.6401	.5601	.7095	.9054		.5847	.5093
14	.6626	.6722	.695	.7545		.5658	.547
15	.5973	.6348	.6653	.6413		.6413	.5658
16	.7316	.6161	1.4563	.8299		.6413	.6036
17	.6401	.6036	.5228	.9242	1.0136	.9242	.6224
18	.8413	.7733	.7655	.8676	1.0829	1.3392	.8865
19	1.262	.5281	1.2696	.9054	1.3443	1.7541	1.226
20	1.2696	1.0562	1.1576	.8865	1.3256	1.6975	1.1506
21	1.1203	.9619	1.1765	.7356	.7783	.811	.7922
22	.9328	.7922	1.0059	.7167	.7842	.811	.811
23	1.6906		.8413	.7356	.6348	.6979	.7167
24	1.0242	.7842	.6413	.8215	.7356	.6219	.679
Max	1.6906	1.2127	1.4563	1.1041	1.3443	1.7541	1.226
Min	.5973	.5281	.5228	.6413	.5093	.5658	.5093
Avg	.8981	.8005	.8672	.8383	.8577	.8759	.7293



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 203 / 11 KV BELDONGRI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.5655	1.5089	1.1389	1.0374	1.1317	1.4146
2	1.0974	1.5655	1.4712	1.0642	1.094	1.094	
3	1.1888	1.5844	1.3392	1.0269	1.1317	1.0751	1.3203
4	1.2803	1.5089	1.3014	.9896	1.1694	1.0185	1.3203
5	1.3535	1.4712	1.358	.9431	1.1694	1.0751	1.3392
6	1.4815	1.4523	1.4523	1.1694	1.2071	1.0456	1.5089
7	1.4998	1.4712	1.4712	1.0185	1.1317	1.2637	1.5089
8	1.3352	1.3014	1.4335	1.1506	1.1317	.9709	1.358
9	1.2437	1.5466	1.1883	.8962	.8299	.8029	1.358
10	1.2803	1.5655	1.358	1.094	.9242	1.2449	1.3957
11	1.4335	1.8484	1.4523	1.1694	.9602	1.5089	1.6975
12	1.6032	1.5089	1.5844	1.4335	1.0802	1.5655	1.6975
13	1.4335	1.5466	1.358	1.2449	1.3375	1.5844	1.5844
14	.2439	1.5466	1.5278	1.3014	1.286	1.5089	1.6221
15	1.4146	1.5089	1.4901	.4527	1.166	1.3014	1.6598
16	1.4712	1.3957	1.4335	.9619	.9774	1.226	1.6598
17	1.2826	1.5089	1.6787	1.1883	1.1203	1.3769	1.358
18	1.5844	1.4335	1.2826	1.1883	1.0829	1.3014	1.5844
19	1.8107	1.358	1.4901	1.1883	1.0082	1.4901	1.4146
20	1.5655	1.358	1.1576	1.2449	.8299	1.4335	1.1317
21	1.4335	1.5089	1.094	1.3392	1.0751	1.358	1.1317
22	1.5278	1.5278	.7922	1.2071	1.3203	1.226	1.2449
23	1.5466	1.5844	.9054		1.3014	1.3203	1.3203
24	1.134	1.5278	1.5655	1.2012	1.358	1.1317	1.5089
Max	1.8107	1.8484	1.6787	1.4335	1.358	1.5844	1.6975
Min	.2439	1.3014	.7922	.4527	.8299	.8029	1.1317
Avg	1.3461	1.5081	1.3623	1.1136	1.1137	1.2523	1.4408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 204 / 11 KV W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.017		.0152		.0171	
2		.0171		.0152		.0173	
3		.0177		.0162		.017	
4		.0175		.0152		.0171	
5		.0171		.0166		.0166	
6		.0171		.0166		.017	
7		.0173		.017		.017	
8		.0181	.0189			.0177	
9		.0179	.0189	.0171			
10		.0181	.0189				
11	.0166	.0189	.0166				.0189
12	.0162	.0189	.0171				.0189
13	.0171	.0183	.0171				.0189
14	.0162		.0171				
15	.0171	.0183	.0171		.0171		.0189
16	.0171	.0183	.017		.0171	.0189	
17	.0171	.0189	.017		.0171	.0189	.0189
18	.0166	.0189	.0171		.0166	.0189	.0189
19		.0189	.0187		.0181	.0189	.0189
20	.0181	.0189	.0185		.0181	.0189	.0189
21	.0171	.0189	.0181		.0171	.0189	.0189
22	.0171	.0189	.0171		.0181	.0189	.0189
23	.0171	.0189	.0181		.0175	.0189	.0189
24	.0183	.0171		.0154		.017	.0189
Max	.0183	.0189	.0189	.0171	.0181	.0189	.0189
Min	.0162	.017	.0166	.0152	.0166	.0166	.0189
Avg	.0171	.0181	.0177	.0161	.0174	.0179	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 205 / 11 KV Incomer I Nagardhan

Feeder KV- 11 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7682	.6224	.8131	1.1694	1.2254	1.2826
2	.6722	.7655	.6224	.7682	1.226	1.1888	1.1694
3	.7095	.7316	.5658	.7499	1.3769	1.1765	1.1317
4	.7468	.7964	.7356	.7964	1.4523	1.2489	1.1694
5	.8029	.9877	.9619	.8962	1.4901	1.3352	1.2826
6	.9149	1.1643	1.0751	.9709	1.5466	1.5181	.679
7	1.0269	1.2382	1.1128	1.1157	1.7164	1.4003	.679
8	.7468	1.4632	1.7353	1.3565	1.5466	1.2323	1.1128
9	1.8484	1.7737	1.7918	1.7909	1.4712	1.1389	1.0185
10	1.7551	1.701	1.6975	1.7718	1.226	.9522	.7545
11	1.6108	1.773	1.6095	1.6032	.9602	.7545	.6602
12	1.5546	1.6221	1.4299	1.5844	.9088	.6413	.6036
13	1.3575	1.307	1.5384	1.5089		.5847	.5093
14	1.3575	1.3817	1.3756	1.5089		.5658	.547
15	1.2445	1.3817	1.3352	1.2449		.6413	.5658
16	.7316	1.3256	1.0059	.8299		.6413	.6036
17	.6401	.6036	1.134	.9242	1.0136	.9242	.6224
18	.8413	.7733	.7655		1.0829	1.3392	.8865
19	1.262	.5281	1.2696	1.4712	1.3443	1.7541	1.226
20	1.2696	1.0562	1.2323	1.4523	1.3256	1.6975	1.1506
21	1.1203	.9619	1.1765	1.2637	1.3575	1.3769	1.2826
22	.9328	.7922	1.0059	1.2826	1.4118	1.5278	1.2637
23	.823	.6979	.8413	1.3957	1.3213	1.3957	1.1317
24	1.0242	.7842	.6413	.8215	1.3957	1.2437	1.3203
Max	1.8484	1.7737	1.7918	1.7909	1.7164	1.7541	1.3203
Min	.6401	.5281	.5658	.7499	.9088	.5658	.5093
Avg	1.0686	1.0991	1.1367	1.2140	1.3172	1.1460	.9439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 206 / 11kv Incomer II Nagardhan

S/s Feeder KV- 11 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608				1.0374		1.4712
2	1.0974				1.094		1.4146
3	1.1888				1.1317		1.3203
4	1.2803				1.1694		1.3203
5	1.3535				1.1694		1.3392
6	1.4815				1.2071		1.4146
7	1.4998				1.1317		1.5089
8	1.3352				1.1317		1.358
9	1.2437				1.5089		1.358
10	1.2803				.9242		1.3957
11		1.8484		1.1694	.9602	1.5089	1.7164
12		1.5089		1.4335	1.0802	1.5655	1.7164
13		1.5466		1.2449	1.3375	1.5844	1.6032
14		1.5466		1.3014	1.286	1.5089	1.6221
15		1.5278		.4715	1.1831	1.3014	1.6787
16				.9619	.9945	1.2449	1.6598
17				1.1883		1.3957	1.3769
18				1.1883		1.3203	1.6032
19				1.1883		1.5089	1.4335
20				1.2449		1.4712	1.1506
21				1.3392		1.3769	1.1506
22				1.2071		1.2449	1.2637
23				1.2637		1.3392	1.3392
24	1.1403		1.5655		1.358		1.5278
Max	1.4998	1.8484	1.5655	1.4335	1.5089	1.5844	1.7164
Min	1.0608	1.5089	1.5655	.4715	.9242	1.2449	1.1506
Avg	1.2692	1.5957	1.5655	1.1694	1.1591	1.4132	1.4476

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 202 / 11 KV Deolapar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.924	.924	.8002	.6468	.6859	.6859
2	.7621	.924	.924	.7621	.6468	.6859	.6859
3	.7621	.924	.924	.7621	.6468	.6859	.6859
4	.7621	.924	.924	.8002	.6468	.7716	.6859
5	.7621	.924	.8316	.7621	.6468	.7716	.7202
6	.7621	.924	.8316	.8573	.6468	.7716	.7716
7	.7621	.924	.8316		.6468	.6859	.7716
8	.8573	.924	.924	.8573	.7392	.8573	.7716
9	.9526	1.0164	.9526	.9526		.7716	.7716
10	.924	.9526	.9526	.924	.6859	.7716	.7716
11	.924	.8573	.9526	.924	.6859	.6859	.6859
12	.924	.8131	.8764	.7392	.6859	.6859	.6097
13	.924	.8316	.9145	.7392	.6859	.6001	.5335
14	.924	.7947	.9526	.7392	.6859	.8573	.5792
15	.9526	.7947	.7621	.7392	.7888	.6001	.5639
16	.7621	.7392	.7621	.7392	.6859	.6859	.5792
17	.7621	.7392	.8002	.7392	.6859	.6859	.5792
18	.8316	.924	.8573	.924	.7468	.8573	.9145
19	1.2012	1.1088	1.2384	1.2012	1.2003	1.3717	1.0364
20	1.1088	1.1088	1.2384	1.2936	1.1145	1.286	1.0669
21	1.0164	.924	1.0479	1.0164	.9431	.8573	.9907
22	1.0164	.924	.7621	1.0164	.9526	.7716	.7621
23	.924	.924	.7621		.6859	.6001	.8535
24	.7621	.924	.924	.7621	.6468	.6516	.6859
Max	1.2012	1.1088	1.2384	1.2936	1.2003	1.3717	1.0669
Min	.7621	.7392	.7621	.7392	.6468	.6001	.5335
Avg	.8792	.9070	.9113	.8659	.7455	.7773	.7401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 203 / 11 KV TOTALADOH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1294	.1109	.0762	.1109	.1029	.1029
2	.1143	.1294	.1109	.0762	.1109	.0857	.1029
3	.1143	.1294	.1109	.0953	.1109	.0857	.1029
4	.1143	.1294	.1109	.0953	.1109	.1029	.1029
5	.1143	.1478	.1109	.0953	.1109	.1029	.1029
6	.1143	.1478	.1109	.0953	.1109	.1372	.1029
7	.1524	.1478	.1109	.1524	.1109	.1029	.1372
8	.1524	.1848	.1294	.1524	.1478	.1524	.1372
9	.1905	.1848	.1524	.1524		.1372	.1372
10	.1848	.1905	.1524	.1109	.285	.1372	.1372
11	.1848	.1905	.1905	.1848	.1372	.1372	.1029
12	.1848	.1848	.1905	.2218	.1372	.1372	.1219
13	.1848	.1478	.1905	.2218	.1372	.1372	.1219
14	.1848	.1109	.1905	.1478	.1372	.1372	.1219
15	.1905	.1294	.1524	.1478	.1372	.1372	.1219
16	.1905	.1109	.1524	.1848	.1372	.1372	.0914
17	.1524	.1109	.1524	.1109	.12	.1372	.1067
18	.1848	.1478	.1524	.1478	.1143	.1715	.1524
19	.1848	.1848	.1524	.2218	.1715	.1715	.1524
20	.1848	.1848	.1524	.1478	.1715	.1715	.1524
21	.1848	.1478	.1524	.1848	.1372	.1543	.1829
22	.1848	.1109	.0953	.1478	.1524	.1372	.1829
23	.1478	.1109	.0953		.1029	.1029	.1524
24	.1143	.1478	.1109	.0953	.1478	.1029	.1029
Max	.1905	.1905	.1905	.2218	.285	.1715	.1829
Min	.1143	.1109	.0953	.0762	.1029	.0857	.0914
Avg	.1594	.1475	.1392	.1420	.1370	.1300	.1264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 204 / 11 KV Ambazari AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.037	.0185	.0191	.037	.0514	.0514
2	.0381	.037	.0185	.0191	.0554	.0514	.0514
3	.0381	.037	.0185	.0191	.0554	.0514	.0514
4	.0381	.037	.0185	.0191	.0554	.0514	.0514
5	.0381	.037	.0185	.0191	.0554	.0686	.0686
6	.0381	.037	.0185	.0191	.0554	.0514	.0686
7	.0381	.037	.0185	.0191	.0185	.0171	.0171
8	.0572	.0739	.0554	.0572	.0185	.0381	.0171
9	.0953	.0739	.0572	.0572		.0171	.0171
10	.0739	.0762	.0762	.0554	.0185	.0171	.0171
11	.0739	.0953	.0762	.0739	.0171	.0171	.0343
12	.0739	.0739	.0762	.0739	.1372	.0171	.0305
13	.0739	.0739	.0762	.0924	.0171	.0171	.0305
14	.0739	.0739	.0762	.0924		.0171	.0305
15	.0381	.0739	.0762	.0924	.0171	.0171	.0305
16	.0381	.0185	.0191	.0185	.0171	.0171	.0305
17	.0381	.0185	.0191	.0185	.0171	.0171	.0152
18	.037	.0185	.0191	.0185	.0191	.0343	.0305
19	.037	.0185	.0191	.0185	.0343	.0171	.0762
20	.037	.0185	.0191	.0185	.0171	.0171	.061
21	.037	.0185	.0191	.0185	.0514	.0686	.061
22	.037	.0185	.0191	.0185	.0381	.0514	
23	.037	.0185	.0191		.0514	.0514	.0305
24	.0381	.037	.0185	.0191	.0554	.0514	.0514
Max	.0953	.0953	.0762	.0924	.1372	.0686	.0762
Min	.037	.0185	.0185	.0185	.0171	.0171	.0152
Avg	.0485	.0441	.0363	.0381	.0390	.0344	.0402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 205 / 11 KV Incomer I Pauni

S/Stn Feeder KV- 11 /

INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.2012	1.1088	.9145	.8131	.8573	.7716
2	.9145	1.2012	1.1088	.9335	.8131	.8745	.7716
3	.9145	1.2012	1.1088	.9335	.8131	.8573	.7716
4	.9145	1.2012	1.1088	.9526	.8131	.8916	.8573
5	.9145	1.2012	1.1088	.9526	.8131	.9259	.8916
6	.9145	1.2382	1.0719	.9526	.8131	.9602	.9088
7	.9907	1.2382	1.0534	1.0288	.7762	.8573	1.0631
8	1.0288	1.0719	1.2012	1.0669	.9055	1.0479	1.166
9	1.2574	1.2012	1.2574	1.1622		.9259	1.1488
10	1.2382	1.2574	1.2384	1.1458	.9055	1.1831	1.1488
11	1.2197	1.1431	1.2384	1.1827	.9259	.9774	.9088
12	1.1827	1.1273	1.1431	1.0349	1.0117	.9602	.7621
13	1.2197	1.0719	1.1431	1.0534	.9774	.9259	.6859
14	1.2012	.9979	1.1622	.9795	.8745	.8916	.6859
15	1.2384	1.0164	1.1812	.9795	.9088	.823	.7164
16	1.1431	.9979	1.0288	.9425	.9259	.8916	.7011
17	1.0288	.9979	1.0288	.8686	.9774	.9088	.7011
18	1.2936	1.2936	1.0288	1.0903	.8775	1.2174	1.0974
19	1.7741	1.4784	1.4098	1.4415	1.4403	1.5775	1.2955
20	1.7187	1.4415	1.3908	1.46	1.3032	1.5604	1.3717
21	1.5708	1.386	1.2384	1.2197	1.1317	1.0802	1.2498
22	1.2567	1.3491	1.086	1.1827	1.1431	.9259	1.0517
23	1.2012	1.2936	.9526		.8573	.7888	1.2193
24	.9145	1.2012	1.1088	.7621	.7762	.823	.7716
Max	1.7741	1.4784	1.4098	1.46	1.4403	1.5775	1.3717
Min	.9145	.9979	.9526	.7621	.7762	.7888	.6859
Avg	1.1652	1.2004	1.1461	1.0539	.9390	.9889	.9466



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 206 / 11 KV Standby Feeder Pauni SINGLE PHASING

I Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.7556	1.848	1.6194	.7716	1.0288	.9259
2	1.5623	1.7556	1.7556	1.6194	.7716	.9945	.9259
3	1.6194	1.7556	1.7556	1.7147	.7716	.9945	.9259
4	1.6766	1.7556	1.7556	1.7147	.8573	1.0288	.9431
5	1.7147	1.7556	1.8111	1.7147	.8573	1.046	.9602
6	1.7528	1.7556	1.885	1.7718	.8573	1.046	.9945
7	1.8099	1.8111	1.922	1.8861	1.5432	1.7147	1.6632
8	1.1431	1.1643	1.1643	1.1622			1.5604
9	1.3336	1.1827	1.3146	1.3527	1.6289	1.4403	1.5089
10	1.2936	1.3908	1.2955	.1372	1.5947	1.5775	1.3375
11	1.2382	1.2574	1.105	1.3889	1.286	1.2689	1.1831
12	1.1273	1.2567	1.2193	1.3375	1.3032	1.2346	.9755
13	1.1088	1.1643	1.2193	1.0802	1.1488		.9602
14	1.0349	1.0349	1.1812	1.0631	1.1145	1.0631	.8078
15	1.0288	1.0719	1.1431	.9088	1.2003	1.0117	.8535
16	1.2384	1.3121	1.2765	1.046	1.2003	.9774	.823
17	1.4289	1.3121	1.467	1.0802	1.2689	1.0974	.9145
18		1.8111	1.8099	1.6632	1.8099	1.6975	1.6766
19	2.4209	2.4025	2.553	2.2291	2.2462	2.2462	1.9966
20	2.4025	2.4025	2.4768	2.1262	2.2805	2.2805	2.0119
21	2.0328	2.1807	2.2862	1.9719	1.2003	1.1317	1.829
22	1.9035	1.9404	1.7147	1.7661	1.2955	1.0802	1.5851
23	1.6632	1.885	1.7147	.8573	1.0631	.9259	1.6004
24	1.6194	1.6632	1.848	1.7147	.7888	1.0288	.9259
Max	2.4209	2.4025	2.553	2.2291	2.2805	2.2805	2.0119
Min	1.0288	1.0349	1.105	.1372	.7716	.9259	.8078
Avg	1.5512	1.6157	1.6468	1.4553	1.2548	1.2689	1.2454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 201 / 11 KV AROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8328	.8328	1.0631	.9922	1.2757	1.0454	1.3289
2	.8328	.815	1.0631	.9922	1.2757	1.0985	1.3289
3	.8328	.815	1.0454	.9922	1.2403	1.0985	1.3289
4	.8328	.8328	1.0454	.9391	1.2496	1.0277	1.3289
5	.8859	.9922	1.1517	1.0631	1.3112	1.0808	1.3289
6	1.1163	1.2757	1.2403	1.2403	1.4175	1.3466	1.5592
7	1.5769	1.5769	1.3112	1.5061	.8682	1.5061	1.4175
8	1.6832	1.6301	1.5947	1.5061	.6733	1.3466	1.4175
9	1.7896	1.7364	1.6301		1.4175	1.3466	1.4175
10	1.7896	1.7187	1.382	1.6832	1.134	1.1163	1.2403
11	1.4529	1.5947	1.3289	1.6655	.9214	.9391	.8859
12	1.4529	1.5238	1.3112	1.6655	.8505	.8505	.7619
13	1.3643	1.5061	1.2934	1.6478	.7796	.8505	.7087
14	1.2403	1.4706	1.4842	1.5769	.7442	.7973	.7087
15		1.4883	1.1871	1.2934	.7442	.7619	.7265
16	.7265	.7796	.7973	.7796	.7796	.7619	.7442
17	1.134		.815	.8505	.7796	.7973	.7442
18	1.5415	1.0631	.9922	1.2226	.9745	1.0985	.8328
19	1.4175		1.1694	1.4833	1.3998	1.3289	1.4352
20	1.0454	1.1694	1.2403	1.3112	1.3643	1.382	1.3289
21			1.2757	1.0985	1.0099	1.4175	1.258
22	.9036	1.134	1.0631		1.0454	1.382	1.0631
23	.8682		.9922	1.3289		1.382	.9568
24	.8328		1.0974	.9922	1.2934	1.0808	1.382
Max	1.7896	1.7364	1.6301	1.6832	1.4175	1.5061	1.5592
Min	.7265	.7796	.7973	.7796	.6733	.7619	.7087
Avg	1.1888	1.2608	1.1906	1.2650	1.0674	1.1185	1.1347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 202 / 11 KV GHOTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.6908	.7095	.6584	.5847	.6154	.6516
2	.5601	.6908	.7095	.6653	.591	.6154	.6516
3	.5601	.6722	.6767	.6653	.5731	.5611	.6516
4	.5601	.6722	.6767	.6161	.5792	.5611	.6516
5	.5601	.7282	.7655	.6584	.6335	.5611	.6516
6	.6535	.7842	.8316	.724	.6697	.6335	.6516
7	.7655	.8326	.8775	.7602	.7356	.6535	.724
8	.8145	.6878	.8779	.7602	.695	.5228	.724
9	.8145	.724	.8869	.905	.811	.6344	.7421
10	.8145	.7537	.7164	.9145	.7842	.6722	.6401
11	.6335	.7888	.5792	.8779	.7282	.6535	.6401
12	.7421	.8059	.7164	.8596	.6348	.5788	.5487
13	.6878	.788	.8059	.7796	.6161	.5788	.5487
14	.7602	.7701	.788	.7522	.6161	.5611	.5487
15	.724	.7164	.788	.6984	.6348		.567
16	.4668	.5975	.7682		.6535	.543	.5487
17	.5975		.7316	.4938	.6348	.543	.5121
18	.8215	.7282	.6089	.8215	.7468	.181	.6099
19	1.0642		.7087	.9619	1.0269	.9593	.8775
20	1.0269	1.0082	.815	.9145	1.0269	.8145	.8488
21	.8215		.8328	.7499	.7059	.6335	.8488
22	.7059	.7468	.7392		.6697	.7059	.7545
23	.6878		.6722	.6536	.6878	1.3575	.6535
24	.5975		.7095	.6516	.6401	.6516	.7059
Max	1.0642	1.0082	.8869	.9619	1.0269	1.3575	.8775
Min	.4668	.5975	.5792	.4938	.5731	.181	.5121
Avg	.7083	.7467	.7497	.7519	.6950	.6431	.6647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 203 / 11 KV KODAMENDHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1886	.2774	.2715	.4161	.373	.4287
2	.2401	.1886	.2774	.2715	.4161	.39	.4287
3	.2401	.1886	.2601	.2715	.3988	.39	.4287
4	.2401	.1886	.2601	.2715	.3988	.373	.4287
5	.2401	.1886	.3294	.3224	.4249	.39	.4287
6	.3429	.2401	.3814	.3761	.4409	.4239	.5068
7	.4801	.4917	.4334	.443	.5426	.4801	.5144
8	.6344	.3222	.6173	.5493	.5144	.5658	.5316
9	.6344	.7461	.6104	.6516	.503	.5316	.5316
10	.6274	.6001	.6001	.6516	.4807	.4801	.5201
11	.5765	.5959	.6001	.6344		.3429	.3467
12	.4748	.5784	.583	.6001		.2572	.3121
13	.4917	.5609	.583	.5548		.2915	.2947
14	.5426	.5304	.583	.4973		.2915	
15	.5256	.5258	.5658	.4933		.2915	
16	.2058	.2454	.2658	.2601		.2915	
17	.2058		.2743	.2572		.2915	
18	.2572	.3721	.3429	.3467		.3429	
19	.3258		.3544	.4207		.3944	
20	.3429	.4251	.3721	.2947		.3944	
21	.2572		.3721	.4508		.4287	
22	.2035	.3258	.3258			.4287	
23	.1865		.2715	.4144		.4287	
24	.2229		.2774	.2715	.4115	.39	.4287
Max	.6344	.7461	.6173	.6516	.5426	.5658	.5316
Min	.1865	.1886	.2601	.2572	.3988	.2572	.2947
Avg	.3641	.3949	.4091	.4163	.4498	.3860	.4379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 204 / 11 KV KHAT

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.1886	.3772	.443	.7202	.7373	.8573
2	.4115	.3601	.3772	.443	.7282	.7373	.8573
3	.4115	.3601	.3601	.443	.7108	.7202	.8573
4	.4481	.3601	.3772	.443	.6935	.7202	.8573
5	.4115	.3772	.4115	.5258	.7802	.7545	.8573
6	.5144	.3772	.4801	.5493	.8573	.823	.8916
7	.583	.4458	.5028	.5959	.6173	.823	.5144
8	1.0288	1.0288	1.0402	.9536	.5144	.583	.5144
9	1.046	1.0974	1.0749	1.0056	.5144	.5658	.5144
10	1.046	1.2003	1.046		.4973	.463	
11	1.166	1.153	1.0631	.9882		.463	.4287
12	1.0288	1.1145	1.0802	.9882		.4458	.3601
13	1.0117	1.1145	1.1145	.9709		.4458	.3258
14	1.046	1.1145	1.046	.9602		.4458	.3258
15	1.1145	1.0288	.9991	.9602		.4287	.3086
16	.3601	.4287	.4287	.4508		.4287	.3258
17	.4287		.4287	.463		.3772	.3258
18	.4458	.5375	.4801	.6068		.5144	.4458
19			.5144	.6859		.6001	.583
20	.5316	.5144	.5658	.6415		.6001	
21	.3944		.5658	.7291		.8573	
22	.3601		.4973			.9088	
23	.3601		.4287	.7373		.9088	
24	.407		.3772	.443	.7282	.7716	.9088
Max	1.166	1.2003	1.1145	1.0056	.8573	.9088	.9088
Min	.3601	.1886	.3601	.443	.4973	.3772	.3086
Avg	.6507	.7112	.6515	.6831	.6693	.6301	.5821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 205 / 11KV Hatwar

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187			.0048	.016	.0099
2		.0187			.0071	.016	
3		.0187			.0048	.016	
4		.0187			.0048	.016	
5		.0187			.0071	.016	
6		.0187			.0074	.016	
7		.008			.0114	.0373	
8		.008			.0095	.0373	
9		.008	.0032	.0187	.0179	.0373	.0171
10	.008			.0248	.0537	.0198	
11	.016	.112	.1456	.0943		.1307	.1226
12	.016	.132	.1475	.1132		.1307	.1245
13	.016	.132	.1335	.132		.1307	.1176
14	.008	.132	.1317	.132		.1307	.1207
15	.008	.1307	.1244	.024		.1307	.1283
16	.0187	.132	.1214	.0543		.1307	.1207
17	.0187		.1158	.0316		.0505	.1151
18	.0187	.0135	.0924	.0095		.0099	
19	.0187			.0129			
20	.0187			.0095			
21	.0187		.0189	.0095			
23				.0124			
24					.0095	.016	
Max	.0187	.132	.1475	.132	.0537	.1307	.1283
Min	.008	.008	.0032	.0095	.0048	.0099	.0099
Avg	.0154	.0575	.1034	.0485	.0125	.0573	.0974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 206 / 11 KV YAWALKAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.008	.008				.0099	
2		.008				.0099	
3		.008				.0099	
4		.008				.0099	
5		.008				.0099	
6		.008				.0099	
7		.0099			.0183	.0093	
8		.008				.0093	.008
9						.028	.0701
10	.0099			.0048		.0591	
11	.0099		.0747	.0133		.0236	.0747
12	.0099		.0702	.02		.0236	.0896
13	.0099		.0672	.02		.0236	.0579
14	.0099		.0635	.0625		.0236	.0672
15	.0099		.1027			.0236	.0728
16	.0189		.099	.0943		.0236	.0672
17	.0187		.0467	.1003		.0236	.0105
18	.0187		.0189	.02		.0099	
19	.0187			.0672			
20	.008			.0206			
21	.0187			.0143			
22	.008						
24						.0099	
Max	.0189	.0099	.1027	.1003	.0183	.0591	.0896
Min	.008	.008	.0189	.0048	.0183	.0093	.008
Avg	.0127	.0082	.0679	.0398	.0183	.0184	.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 207 / 11 KV DURGA RICE MILL NON SHEDDABLE EXPRESS HV FEEDERS  
 EXPRESS Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171					.0171
2		.0171					
3						.0171	
4						.0171	
5						.0171	
6							.0171
7						.0171	.0171
8						.0171	.0171
9	.0343		.0124			.0343	.0171
10	.0343	.0248	.0579	.0048	.0937	.0514	
11	.0514	.0246		.031		.0514	
12	.12	.0124		.056		.0343	
13	.1029	.0509	.1326	.0566		.0343	
14	.12	.0596	.1288	.0606		.0343	
15	.1029	.0532	.1283	.0878		.0343	
16	.12	.0577	.1232	.0747		.0343	
17	.12		.1139	.1259		.0343	
18	.1029	.1267	.0895	.0747		.0171	
19	.1029		.0868	.112			
20	.0857	.1307	.0803	.112			
21	.0857		.0691				
22			.0191				
Max	.12	.1307	.1326	.1259	.0937	.0514	.0171
Min	.0343	.0124	.0124	.0048	.0937	.0171	.0171
Avg	.091	.0523	.0868	.0724	.0937	.0297	.0171



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 208 / 11 KV ADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1829	.1755	.1578	.3277	.3005	.3277
2	.1578	.1829	.1578	.1578	.3113	.3005	.3277
3	.1578	.1829	.1578	.156	.3113	.3005	.3277
4	.1578	.1829	.1578	.1402	.2953	.3005	.3277
5	.1578	.1829	.1753	.1715	.3391	.3005	.3605
6	.1715	.1829	.1907	.1715	.3361	.3658	.3768
7	.213	.1898	.208	.1844	.2303	.3658	.2035
8	.4096	.4111	.3814	.2915	.1928	.2012	.2543
9	.4096	.4111	.3605	.3563	.1886	.2012	.2543
10	.3953	.4218	.3353	.3479	.2321	.16	.2343
11	.4111	.427	.3353	.3321		.16	.1875
12	.4111	.4481	.3688	.3321		.1638	.1562
13	.4428	.4428	.3978	.3163		.1638	.1562
14	.427	.4321	.3978	.3201		.1311	.1406
15	.3953	.4321		.3163		.1311	.1562
16	.1829	.1389	.12	.1734		.1311	.144
17	.1829			.1823		.1638	.144
18	.2012	.1677	.1543	.2353		.2622	.2058
19	.2743		.1677	.2534		.2785	.3045
20	.2561	.2507	.2012			.2949	.2865
21	.2012		.2012	.407		.3277	.2658
22	.1581	.208	.1677			.3605	.2347
23	.1581		.1677	.3321		.3605	.218
24	.1753		.1734	.1578	.3201	.3005	.3605
Max	.4428	.4481	.3978	.407	.3391	.3658	.3768
Min	.1578	.1389	.12	.1402	.1886	.1311	.1406
Avg	.2611	.2883	.2342	.2497	.2804	.2511	.2481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 209 / 11 KV NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3403	.4163	.4656	.4687	.4586	.6104
2	.3506	.3403	.4207	.4607	.4915	.4586	.6104
3	.3506	.3045	.4163	.4607	.4915	.4586	.6104
4	.3506	.3403	.3982	.4344	.4752	.4744	.6104
5	.3506	.3761	.4525	.5316	.5658	.4744	.6104
6	.5258	.4656	.5611	.5487	.6062	.5693	.6952
7	.5218	.5218	.6584	.6344	.5914	.6805	.5087
8	.6226	.6642	.6722	.7291	.5792	.6268	.5087
9	.6882	.7116	.7291	.7969	.5731	.6089	.5935
10	.6642	.7459	.7682	.7373	.4607	.4641	
11	.6483	.6962	.7682	.7373		.4144	.4287
12	.6483	.663	.7682	.7209		.3481	.3429
13	.4428	.6133	.7316	.6882		.3481	.3086
14	.5376	.5735	.695	.639		.3481	.3077
15		.5868	.6447	.664		.3481	.3077
16	.5373	.3605	.3658	.3544		.3315	.3185
17	.5731		.3841	.3521		.3315	.3185
18	.4477	.4508	.4572	.5121		.4144	.4252
19	.5373		.4656	.5973		.4973	.5121
20	.5373	.543	.4784	.5068		.4973	.4755
21	.4119		.4784	.5087		.5967	.4656
22	.3163	.4382	.4755			.6173	.394
23			.4755	.4999		.5967	.3772
24	.333		.4344		.5079	.4744	.6104
Max	.6882	.7459	.7682	.7969	.6062	.6805	.6952
Min	.3163	.3045	.3658	.3521	.4607	.3315	.3077
Avg	.4885	.5124	.5465	.5718	.5283	.4766	.4761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 401 / 33 KV Aroli Incomer No I

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4118	1.5203	1.7918	1.5746	1.9004	1.7375	2.1176
2	1.4118	1.5203	1.7918	1.5746	1.8461	1.7918	2.1176
3	1.4118	1.5203	1.7375	1.5746	1.8461	1.7375	2.1176
4	1.4118	1.7375	1.7375	1.5746	1.8461	1.6832	2.1176
5	1.4661		1.9004	1.7918	2.009	1.7375	2.1176
6	1.7918	2.1176	2.0633	2.009	2.1176	2.0633	2.2805
7	2.3348	2.4977	2.1719	2.3348	1.4661	2.2262	2.1719
8	2.552	2.3891	2.4977	2.3348	1.5203	1.9547	2.1719
9	2.6606	2.4977	2.552	2.6606	1.5236	2.1176	2.2805
10	2.6606	2.552	2.2805	2.6606	2.0633	1.9004	2.009
11	2.1719	2.552	2.1176	2.7149	1.7918	1.7375	1.7193
12	2.2805	2.4977	2.2805	2.7149	1.6289	1.5746	1.5203
13	2.1176	2.4434	2.3348	2.6606	1.5203	1.5746	1.4661
14	2.1719	2.3891	2.4434	2.552	1.4118	.9774	1.4661
15	2.009	2.3891	2.1719	2.2262	1.4661	.9774	1.5203
16	12.9773	1.5203	1.7918	1.4118	.1086	1.5203	1.4661
17	1.4661		1.7375	1.5203	1.5746	1.5203	1.4118
18	2.009	1.7918	1.7375	2.1176	1.7918	1.3032	1.5203
19	2.6606		1.9547	2.4977	2.552	2.3348	2.2805
20	2.4977		2.1176		2.4977	2.3348	2.2262
21	1.9004		2.1491		1.7918	2.0633	2.0633
22	1.7918	1.9004	1.7918		1.8461	2.1176	1.7918
23	1.5746	1.7918	1.6289	2.009	1.7375	2.1176	1.6289
24	1.4661	1.5746			2.009	1.7918	2.1176
Max	12.9773	2.552	2.552	2.7149	2.552	2.3348	2.2805
Min	1.4118	1.5203	1.6289	1.4118	.1086	.9774	1.4118
Avg	2.4253	2.0633	2.0340	2.1258	1.7444	1.7873	1.9042

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 402 / 33 KV Aroli Incomer No II

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.5258	.6984	.6687	1.0814	1.0688	1.2003
2	.7059	.5784	.6762	.6687	1.0814	1.0688	1.2003
3	.7059	.5784	.6241	.6687	1.0322	1.0688	1.2003
4	.7059	.5784	.6241	.6687	1.0322	1.0202	1.2003
5	.7059	.5784	.7282	.823	1.1305	1.0688	1.2003
6	.9231	.631	.8842	.9156	1.2431	1.166	1.2483
7	1.0802	.8745	.9362	1.0288	1.0174	1.3146	.9945
8	1.5844	1.2631	1.6644	1.4083	1.086	1.1568	1.0082
9	1.5844	1.7078	1.7164	1.6095	1.086	1.1043	1.0082
10	1.6032	1.7004	1.6221		1.0517	.8259	1.0288
11	1.6518	1.6712	1.6221	1.5238	1.0517	.7773	.763
12	1.4089	1.6221	1.6221	1.5238	.7888	.6962	.7122
13	1.4089	1.6221	1.6221	1.4255	.6836	.6802	.6104
14	1.0688	1.5729	1.5729	1.3923	.6836	.6962	.5967
15	1.5546	1.4746	1.5089	1.3603	.7888	.6962	.547
16		.6613	.6539	.7122	.7362	.7122	.4973
17	.5784		.7042	.7122	.7362	.6613	.5967
18	.7362	.9231	.8048	.9156	.8939	.8648	.7373
19	.8939		.8551	1.0682	1.1043	.9448	.9774
20	.6836		.9054		1.0517	.9448	.8551
21	.6836		.9054		1.262	1.2431	.8745
22		.7602	.6539	1.5729	1.2094	1.2929	.7202
23	.5784		.6539	1.1174	1.2094	1.2929	.6687
24	.631		.639		1.0688	1.1174	1.2483
Max	1.6518	1.7078	1.7164	1.6095	1.262	1.3146	1.2483
Min	.5784	.5258	.6241	.6687	.6836	.6613	.4973
Avg	1.0083	1.0735	1.0374	1.0892	1.0046	.9785	.9039

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 403 / 33 KV Aroli Incomer No III

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.543	.6836	.691	1.0814	.7682	.9448
2	.543	.543	.5784	.6316	.7865	.7682	.9448
3	.5601	.4887	.5847	.6316	.7865	.7682	.9448
4	.5601	.543	.5258	.583	.7865	.8162	.9448
5	.543	.543	.6516	.6316	.9665	.8162	.9448
6	.7602	.6516	.7602	.6802	.9665	.9122	1.094
7	.823	.7202	.7865	.8048	.7888	1.086	.6882
8	1.0082	1.1043	1.0322	1.0059	.8145	.8688	.7373
9	1.1043	1.1523	1.0814	1.17	.7602	.8688	.8356
10	1.1043	1.1934	1.0202	1.1305	.8145	.7122	
11	1.1043	1.1305	1.0688	1.1305	.7059	.6613	.6687
12	1.1523	1.1305	1.0688	1.1305	.6516	.5596	.5144
13	1.0082	1.1191	1.078	1.0814	.543	.5596	.5144
14	1.4883	1.0442	1.1174	1.0059	.543	.5596	.5144
15	1.0562	1.0814	1.1174	1.0814	.6516	.5596	.5144
16	.8688	.5596	.5344	.5596	.6516	.5087	.503
17	.8688		.6036	.6241	.6516	.5596	.503
18	.7602	.7282	.6539	.9465	.6516	.7122	.6173
19	.9231		.6802	.9465	.8145	.7956	.7545
20	.9231		.6802		.9231	.7956	
21	.7059		.6802		.8688	.9448	
22	.543	.6379	.6316		1.086	.9448	
23	.543		.6316	.8356	1.086	.9448	.6104
24	.5658		.5596	.6316	.8356	.7682	.547
Max	1.4883	1.1934	1.1174	1.17	1.086	1.086	1.094
Min	.543	.4887	.5258	.5596	.543	.5087	.503
Avg	.8366	.8286	.7838	.8540	.8007	.7608	.7170

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 201 / Ramtek I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3429	.3239	.381	.381	.381
2	.362	.381	.3429	.3239	.381	.381	.381
3	.3239	.381	.3048	.2858	.4191	.3429	.3429
4	.3239	.3429	.3048	.381	.4191	.3429	.3429
5	.381	.4191	.4954	.4382	.4572	.4191	.4191
6	.4763	.4763	.5716	.5335	.4572	.4763	.4572
7	.6478	.6287	.6287	.5716	.6478	.6287	.6478
8	.6859	.724	.6287	.5716	.724	.6859	.724
9	.6478	.6287	.5906	.6097	.6287	.5906	.5716
10	.5335	.5716	.5716	.6478	.5906	.5716	.5716
11	.5144	.5525	.5716	.6478	.5716	.5716	.5335
12	.4763	.381	.5335	.5525	.5716	.4954	.4763
13	.4382	.4954	.4954	.4572	.4954	.4763	.4572
14	.4001	.4382	.4191	.4191	.4572	.4763	.4191
15	.4191	.4191	.4763	.4001	.4191	.4954	.4001
16	.4763	.4001	.4001	.4382	.4382	.4763	.4001
17	.4954	.4763	.5335	.4572	.4954	.4572	.4382
18	.6097	.6859	.743	.5716	.6097	.6668	.5906
19	.6668	.743	.6097	.7049	.743	.724	.6859
20	.6668	.6478		.6478	.6287	.7049	.6287
21	.6097	.5716		.6097	.5906	.6287	.5525
22	.4763	.4954	.4954	.5144	.5335	.5525	.5144
23	.4001	.4382	.4001	.4382	.4763	.4191	.4572
24	.362	.362	.381	.3429	.381	.381	.4001
Max	.6859	.743	.743	.7049	.743	.724	.724
Min	.3239	.3429	.3048	.2858	.381	.3429	.3429
Avg	.4898	.5009	.4928	.4954	.5215	.5144	.4914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 202 / Ramtek II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1905	.1524	.1524	.1524	.1524
2	.1524	.1334	.1905	.1524	.1524	.1524	.1524
3	.1334	.1143	.1524	.1334	.1524	.1524	.1334
4	.1334	.1143	.1524	.1334	.1334	.1334	.1334
5	.0953	.0953	.1334	.1905	.1334	.1334	.0953
6	.0953	.0953	.1715	.1905	.1334	.1334	.0953
7	.0953	.0572	.1143	.1715	.0762	.1334	.2286
8	.0953	.1524	.1334	.1524	.3048	.1905	.2096
9	.1524	.1524	.1715	.1905	.2858	.1905	.1715
10	.3239	.2667	.3429	.4001	.4191	.4191	.362
11	.3048	.2858	.362	.4001	.4572	.4001	.3239
12	.3239	.2858	.3429	.4191	.3429	.4572	.381
13	.3239	.3429	.362	.4001	.4763	.381	.4191
14	.3239	.3429	.3239	.362	.4191	.3048	.3239
15	.2858	.3429	.362	.3239	.381	.3429	.2858
16	.2667	.3048	.3048	.2858	.381	.2858	.2858
17	.1334	.2096	.2477	.1334	.1905	.1715	.2858
18	.1334	.1524	.1334	.1905	.2096	.1334	.2286
19	.1334	.1524	.1524	.1905	.2096	.1334	.1334
20	.1334	.1334		.1905	.2096	.1334	.1334
21	.1334	.1905		.1715	.1524	.1334	.1334
22	.1334	.1905	.1715	.1715	.1715	.1715	.1715
23	.1524	.1715	.1715	.1715	.1715	.1524	.1715
24	.1715	.1524	.1905	.1715	.1715	.1524	.1524
Max	.3239	.3429	.362	.4191	.4763	.4572	.4191
Min	.0953	.0572	.1143	.1334	.0762	.1334	.0953
Avg	.1826	.1905	.2217	.2270	.2453	.2143	.2151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 204 / BORI SINGLE PHASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8002	.8002	.8002	.6859	.6097	.6287
2	.7621	.8383	.7621	.7621	.724	.6097	.6287
3	.724	.8383	.724	.7621	.724	.5716	.5716
4	.724	.8764	.7621	.8192	.7621	.5716	.5716
5	.8002	.8764	.8192	.8764	.8002	.6287	.6668
6	.9335	.9145	.9145	.9145	.8383	.8002	.7621
7	.9717	.9907	1.0288	.9335	.9145	.8954	.8954
8	.8002	.8573	.9145	.8192	1.0098	1.0098	.9907
9	.8573	.9526	.9526	.8002	1.0669	1.0479	.9717
10	.9526	.8764	.8573	.8764	.9717	.9907	.8954
11	.8002	.743	.7811	.8192	.8954	.8764	.8192
12	.7811	.7811	.8192	.7811	.7811	.8192	.6859
13	.7621	.9335	.8002	.8192	.724	.8002	.743
14	.7811	.9335	.724	.8192	.7621	.724	.6478
15	.7049	.8002	.743	.7621	.7811	.724	.6478
16	.7049	.743	.5716	.724	.8383	.724	.6478
17	.743	.8002	.7811	.8002	.8383	.7621	.6859
18	.743		.9145	.9717	.9335	.9335	.8764
19	1.3146	1.2384	1.2384	1.2003	1.2574	1.0479	1.2003
20	1.2955	1.2574	1.2765	1.2003	1.2574	1.1431	.8954
21	1.1622	1.105		.8954	.7621	.8573	1.0479
22	.9907	.9526	1.0098	.7811	.6668	.7621	.8954
23	.8383	.8383	.8573	.724	.6668	.7049	.7811
24	.8002	.8002	.8192	.8192	.6859	.6478	.6859
Max	1.3146	1.2574	1.2765	1.2003	1.2574	1.1431	1.2003
Min	.7049	.743	.5716	.724	.6668	.5716	.5716
Avg	.8629	.9021	.8640	.8534	.8478	.8026	.7851



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 205 / 11 KV RAMTALAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6478	.5335	.5716	.6287	.5716	.6478
2	.5716	.6478	.5335	.5335	.6478	.5716	.6478
3	.5335	.724	.4954	.5144	.6478	.5335	.6097
4	.5335	.724	.5716	.5716	.6859	.5335	.6097
5	.6097	.7621	.6859	.6859	.6859	.6668	.6859
6	.724	.8002	.8764	.7621	.743	.7811	.7811
7	.8954	.8954	1.0098	.8764	.9717	.8954	.8764
8	.9526	.9717	.9526	.9526	1.0098	1.0098	1.0098
9	.9335	.9145	.8764	.9335	.8573	.8954	.9335
10	.8002	.8383	.8573	.9145	.8002	.8383	.743
11	.7621	.7621	.8002	.8192	.724	.7621	.724
12	.6668	.7621	.7811	.724	.743	.6859	.6859
13	.6478	.6668	.6287	.743	.6668	.6478	.6097
14	.6097	.6097	.5906	.6287	.6287	.6097	.5335
15	.6287	.6097	.5716	.5906	.6097	.6097	.5525
16	.6478	.6478	.6097	.6287	.6668	.6668	.5906
17	.743	.6859	.6478	.6668	.724	.743	.6478
18	.8954		.8192	.8383	.8573	.8954	.8764
19	.9907	.9526	1.0669	.9335	.9717	1.0479	.9526
20	.9335	.9145	.9717	.9335	.8954	.9526	.8954
21	.8764	.8192		.8954	.8383	.8764	.8383
22	.7811	.724	.8002	.8192	.8002	.8192	.7811
23	.6478	.6097	.6668	.7049	.724	.724	.6859
24	.5716	.5716	.5716	.6097	.6287	.6097	.6668
Max	.9907	.9717	1.0669	.9526	1.0098	1.0479	1.0098
Min	.5335	.5716	.4954	.5144	.6097	.5335	.5335
Avg	.7303	.7505	.7356	.7438	.7565	.7478	.7327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 206 / 11 KV Musewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-FEB-18
HR	Load (MW)
13	.724
Max	.724
Min	.724
Avg	.724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 400 / 33 KV Ramtek Transformer I

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.1431	1.086	1.0288	1.1431	1.086	1.2003
2	1.086	1.1431	1.086	1.0288	1.2003	1.086	1.2003
3		1.2003	.9717	.9145	1.2003	1.0288	1.086
4	.9717	1.2003	1.086	1.086	1.2574	1.0288	1.086
5	1.086	1.2574	1.3146	1.3146	1.2574	1.2003	1.2003
6	1.3146	1.3717	1.6004	1.4861	1.3146	1.3717	1.3146
7	1.6575	1.5432	1.7718	1.6004	1.7147	1.6575	1.7718
8	1.7147	1.829	1.7147	1.6575	2.0576	1.8861	1.9433
9	1.7147	1.7147	1.6575	1.7147	1.7718	1.6575	1.6575
10	1.6575	1.6575	1.7718	1.9433	1.829	1.829	1.6575
11	1.6004	1.6004	1.7147	1.8861	1.7718	1.7147	1.6004
12	1.4861	1.4289	1.6575	1.7147	1.6575	1.6575	1.5432
13	1.4289	1.4861	1.4861	1.6004	1.6575	1.4861	1.4861
14	1.3146	1.3717	1.3146	1.4289	1.4861	1.3717	1.2574
15	1.3146	1.3717		1.3146	1.4289	1.4289	
16	1.3717	1.3717	1.3146	1.3717	1.4861		
17	1.3717	1.3717	1.4289	1.2574	1.4289	1.4861	
18	1.6575	1.6575	1.6004	1.6004	1.6575	1.6575	
19	1.7718	1.829	1.9433	1.829	1.9433	1.8861	
20	1.7147	1.7147	1.7147	1.7718	1.7147	1.7718	
21	1.6004	1.6004		1.6575	1.6004	1.6575	
22	1.3717	1.4289	1.4861	1.4861	1.4861	1.5432	
23	1.2003	1.2003	1.2574	1.3146	1.3717	1.3146	
24	1.086	1.086	1.1431	1.1431	1.2003	1.1431	1.2003
Max	1.7718	1.829	1.9433	1.9433	2.0576	1.8861	1.9433
Min	.9717	1.086	.9717	.9145	1.1431	1.0288	1.086
Avg	1.4165	1.4408	1.4601	1.4646	1.5265	1.4761	1.4137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 401 / 33 KV Ramtek Transformer

II Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.8002	.8002	.8002	.6859	.6287	.6287
2	.743	.8573	.743	.743	.743	.6287	.6287
3	.743	.8573	.743	.743	.743	.5716	.5716
4	.743	.8573	.743	.8002	.743	.5716	.5716
5	.8002	.8573	1.2003	.8573	.8002	.6287	.6859
6	.9145	.9145	.9145	.9145	.8573	.8002	.743
7	.9717	.9717	1.0288	.9145	.9145	.9145	.9145
8	.8002	.8573	.9145	.8002	1.0288	1.0288	.9717
9	.8573	.9717	.9717	.8002	1.086	1.0288	.9717
10	.9717	.8573	.8573	.8573	.9717	.9717	.9145
11	.8002	.743	.8002	.8002	.9145	.8573	.8002
12	.8002	.8002	.8002	.8002	.8002	.8002	.6859
13	.743	2.5149	.8002	.8002	.743	.8002	.743
14	.8002	.8002	.743	.8002	.743	.743	.6287
15	.6859	.8002	.743	.743	.8002	.743	
16	.6859	.743	.743	.743	.8573		
17	.743	.8002	.8002	.8002	.8573		
18	.743	1.0288	.9145	.9717	.9145	.9145	
19	1.3146	1.2574	1.2574	1.2003	1.2574	1.1431	
20		1.2574	1.2574	1.2003	1.2574	1.1431	
21	1.1431	1.086		.9145	.743	.8573	
22	.9717	.9717	1.0288	.8002	.6859	.743	
23	.8573	.8573	.8573	.743	.6859	.6859	
24	.8002	.8002	.8002	.8002	.6859	.6287	.6859
Max	1.3146	2.5149	1.2574	1.2003	1.2574	1.1431	.9717
Min	.6859	.743	.743	.743	.6859	.5716	.5716
Avg	.8424	.9693	.8896	.8478	.8550	.8106	.7430

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 201 / 11 KV Aroli Khindasi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.6556	.691	1.4352
Max	.6556	.691	1.4352
Min	.6556	.691	1.4352
Avg	.6556	.691	1.4352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 202 / 11 KV Moil

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18
HR	Load (MW)
18	.0191
Max	.0191
Min	.0191
Avg	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 207 / Mansar 11 KV Incomer I  
Feeder KV- 11 / INCOMING

DATE	01-FEB-18	02-FEB-18	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6485	.6836	.6836	2.0858
Max	.6485	.6836	.6836	2.0858
Min	.6485	.6836	.6836	2.0858
Avg	.6485	.6836	.6836	2.0858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 208 / Mansar 11 KV Incomer II

Feeder KV- 11 / INCOMING

DATE	01-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6908	.9335	.9896	1.1016
Max	.6908	.9335	.9896	1.1016
Min	.6908	.9335	.9896	1.1016
Avg	.6908	.9335	.9896	1.1016



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164071 / 33 KV Khat S/Stn

Feeder No / Name : 201 / 11 KV KHAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.6859	.6859	.7282	.7628	.7545	.7545
2	.6485	.6516	.6859	.7282	.7282	.7373	.3772
3	.631	.6173	.6516	.6935	.7282	.7373	.3772
4	.6661	.703	.6859	.6935	.6935	.7545	.4115
5	.7186	.823	.7202	.7628	.8322	.8059	.4287
6	.8063	.8916	.8059	.8322	.8669	.8402	.4801
7	1.0166	.9602	.9945	1.0229	.9709	1.046	.5658
8	.9465	.9816	.9088	.9709	1.0056	.9945	.583
9	1.1393	1.0631	1.0288	1.1616	1.0056	1.0117	.6344
10	.9602	.9602	.9774	1.1616	.9709	.9774	.7975
11	1.046	.9602	1.0229	1.1096	.9709	.9259	.7455
12	.9945	.9088	.8842	1.0923	.9431	.9431	.7455
13	.9602	.9088	.9189	1.0402	.9945	.9259	.7455
14	.9945	.9259	.8495	1.1096	.9602	.9602	.6935
15	.9088	.8573	.8495	1.0056	.9431	.8059	.7282
16	.6173	.9259	.9362	1.0229	.9774	.9259	.7802
17	1.0631	.8745	.8842	.9362	1.0288	.8402	.7545
18	1.0802	.9602	.9709	.9362	1.0117	.8402	.8059
19	.9602	1.0117	1.0576	.9882	1.0288	.9602	.9088
20	.9259	.9602	.9882	.9362	1.0117	.9088	.8745
21	.8916	.8745	.8669	.8669	.9088	.8573	.7545
22	.823	.7888	.8322	.8322	.823	.7545	.6859
23	.7716	.7202	.7975	.7975	.7716	.703	.6859
24	.6836	.7202	.703	.7628	.7628	.7716	.6859
Max	1.1393	1.0631	1.0576	1.1616	1.0288	1.046	.9088
Min	.6173	.6173	.6516	.6935	.6935	.703	.3772
Avg	.8717	.8639	.8628	.9247	.9042	.8659	.6668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / INCOMING

DATE	07-FEB-18
HR	Load (MW)
24	1.8399
Max	1.8399
Min	1.8399
Avg	1.8399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 402 / 33 KV SURYALAXMI

Feeder KV- 33 / INCOMING

DATE	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)
24	2.0005	2.5463
Max	2.0005	2.5463
Min	2.0005	2.5463
Avg	2.0005	2.5463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 403 / 33 KV WCL GONDEGAON  
Feeder KV- 33 / INCOMING

DATE	04-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)
24	5.2624	5.4887
Max	5.2624	5.4887
Min	5.2624	5.4887
Avg	5.2624	5.4887

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 404 / 33 kV Aroli  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
8			5.5447
24	3.095	5.2904	
Max	3.095	5.2904	5.5447
Min	3.095	5.2904	5.5447
Avg	3.095	5.2904	5.5447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 167004 / 132 KV MANSAR

Feeder No / Name : 407 / Station T/F II

Feeder KV- 33 / INCOMING

DATE	07-FEB-18
HR	Load (MW)
24	1.0751
Max	1.0751
Min	1.0751
Avg	1.0751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 202 / 11 KV NAXI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1393	1.0517	1.2269	1.2269	1.2269	1.2269	1.166
9	1.3146	1.2269	1.3146	1.4022	1.4022	1.4022	1.2003
10	1.3717	1.2003	1.3375	1.3717	1.5775	1.3717	1.2003
11	1.3717	1.2003	1.3717	1.3717	1.4899	1.3717	1.166
12	1.3717	1.3717		1.406	1.4899	1.3889	1.1145
13	1.3717	1.3717		1.4575	1.4575	1.3889	1.2003
14	1.3717	1.3717		1.3717	1.3717	1.3889	1.2003
15	1.286	1.3717		1.3717	1.3717	1.3717	1.166
Max	1.3717	1.3717	1.3717	1.4575	1.5775	1.4022	1.2003
Min	1.1393	1.0517	1.2269	1.2269	1.2269	1.2269	1.1145
Avg	1.3248	1.2708	1.3127	1.3724	1.4234	1.3639	1.1767

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 203 / 11 KV PULLAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.4746	1.3927	1.4582	1.4746	1.4255	1.4419	1.3279
9	1.6518	1.5223	1.5546	1.7004	1.6518	1.5546	1.4529
10	1.7328	1.6518	1.668	1.7004	1.6194	1.5546	1.5061
11	1.7444	1.5384	1.6518	1.7328	1.6356	1.5708	1.4089
12	1.7764	1.6032	1.7328	1.7652	1.6194	1.4413	1.4413
13	1.7604	1.6842	1.749	1.7328	1.6004	1.587	1.4413
14	1.749	1.6842	1.7814	1.749	1.7004	1.6518	1.4413
15	1.7166	1.6194	1.7166	1.7328	1.7166	1.6518	1.4089
16			1.668				
17			1.5813				
Max	1.7764	1.6842	1.7814	1.7652	1.7166	1.6518	1.5061
Min	1.4746	1.3927	1.4582	1.4746	1.4255	1.4413	1.3279
Avg	1.7008	1.5870	1.6562	1.6985	1.6211	1.5567	1.4286



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 204 / 11 KV KARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.3429	.381	.381	.362	.381
2	.3048	.3048	.3239	.3429	.381	.362	.381
3	.3048	.3048	.3239	.3429	.362	.3429	.4191
4	.3048	.2858	.3239	.3429	.362	.3429	.4191
5	.3429	.2858	.3429	.3429	.381	.381	.4191
6	.381	.3429	.381	.381	.4572	.4191	.4572
7	.381	.3429	.4382	.4382	.4191	.4191	.4572
8	1.4737	1.4548	1.4737	1.5604	1.5775	1.5604	1.3969
9	1.6289	1.5775	1.6289	1.6289	1.7147	1.7147	1.4232
10	1.7147	1.5729	1.6221	1.5893	1.6289	1.5729	1.3763
11	1.6461	1.6549	1.704	1.6221	1.5432	1.6057	1.3435
12	1.7833	1.8351	1.704	1.6385	1.7147	1.6876	1.3435
13	1.869	1.6057	1.6712	1.6712	1.8861	1.6385	1.3108
14	1.8347	1.6385	1.6221	1.5893	1.7147	1.6057	1.2289
15	1.6975	1.6876	1.6712	1.6385	1.6194	1.5402	1.2289
16	.2515	.2515	1.6712	.2515	.2772	.2683	.2515
17	.2683	.2858	1.8099	.2858	.2858	.2286	.2858
18	.3688	.381	.4763	.381	.381	.4763	.381
19	.6203	.6668	.6668	.6668	.6668	.7621	.6668
20	.6203	.6668	.6668	.6668	.6668	.6668	.6668
21	.5365	.5716	.5716	.5716	.5716	.5716	.5716
22	.4572	.4572	.4763	.4572	.4572	.4572	.4763
23	.3429	.381	.4382	.4191	.381	.3429	.3429
24	.3429	.3429	.3429	.381	.381	.381	.3429
Max	1.869	1.8351	1.8099	1.6712	1.8861	1.7147	1.4232
Min	.2515	.2515	.3239	.2515	.2772	.2286	.2515
Avg	.8258	.8009	.9456	.8163	.8421	.8212	.7321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 205 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0381
2	.0191	.0191	.0191	.0191	.0191	.0191	.0381
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.1928	.1267	.1448	.1753	.1928	.2126	.2195
9	.2572	.1753	.2279	.2254	.2303	.2279	.2353
10	.3077	.2572	.2401	.2743	1.6651	.2572	.2058
11	.3258	.2743	.2743	.2572	.2774	.2572	.2229
12	.3439	.1886	.3258	.2401	.3086	.2915	.2401
13	.362	.3258	.3086	.3086	.3439	.3429	
14	.3982	.3429	.3086	.3429	.3258	.3772	
15	.3801	.3429	.3086	.3429	.3258	.3429	
16	.3772	.3086	.3601	.3429		.3944	.2058
17	.3772	.2715	.2896	.3439	.362	.3801	.2172
18	.2572	.2715	.2353	.2896	.3258	.3258	.181
19	.2401	.2172	.2353	.2715	.2715	.2715	.1448
20	.0171	.0191	.0191	.0191	.0191	.0191	.0191
21	.0171	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0381	.0191
23	.0191	.0191	.0191	.0191	.0191	.0381	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0381
Max	.3982	.3429	.3601	.3439	1.6651	.3944	.2401
Min	.0171	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1685	.1388	.1453	.1518	.2112	.1645	.1028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 206 / 11 KV BHIWAPUR BUS STAND

SHEDDABLE URBAN

FEEDE Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2054	.1867	.2054	.2241	.2241	.2667
2	.1848	.1867	.1867	.2054	.2054	.2241	.2667
3	.1867	.1867	.1867	.1867	.2054	.2054	.2477
4	.1867	.1867	.1867	.1867	.2054	.2054	.2858
5	.2033	.2054	.2054	.2054	.2054	.2054	.2667
6	.2218	.2427	.2054	.2241	.2241	.2402	.2858
7	.2587	.2772	.2241	.2402	.2587	.2402	.2858
8	.2218	.2427	.2587	.2957	.2587	.2772	.2987
9	.2561	.2957	.2587	.2614	.3142	.2772	.2772
10	.3109	.2587	.2957	.3142	.2957	.2772	.2587
11	.3326	.3326	.2772	.3326	.2957	.3142	.2033
12	.2987	.2772	.2587	.3142	.2587	.2957	.2033
13	.2218	.2957	.2587	.2957	.2801	.2957	.1848
14	.1848	.2218	.2772	.2218	.2587	.2957	.1848
15	.2427	.2033	.2218	.2402	.2801	.2957	.1848
16	.2402	.2587	.2033	.2587	.2772	.2218	.1848
17	.2957	.2614	.2427	.2427	.2427	.2241	.2054
18	.3142	.2987	.2801	.2987	.3174	.3734	.2614
19	.4251	.3734	.4108	.3547	.4108	.4108	.3547
20	.3696	.3734	.3734	.3547	.4294	.3921	.3734
21	.3326	.3361	.3361	.3361	.3361	.3734	.3361
22	.2587	.2772	.2957	.2957	.2957	.3239	.3048
23	.2033	.2054	.2241	.2402	.2427	.2667	.2667
24	.181	.2033	.2054	.2054	.2241	.2427	.2477
Max	.4251	.3734	.4108	.3547	.4294	.4108	.3734
Min	.181	.1867	.1867	.1867	.2054	.2054	.1848
Avg	.2549	.2586	.2525	.2632	.2728	.2793	.2598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 207 / 11 KV BHIMADEVI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1307	.1307	.1307	.1307	.1307	.1715
2	.0934	.1307	.112	.1307	.1307	.1307	.1715
3	.0934	.112	.112	.112	.1307	.1307	.1715
4	.0934	.112	.112	.112	.1307	.1307	.1905
5	.112	.112	.112	.1307	.1307	.1307	.1905
6	.1494	.1307	.1307	.1494	.1494	.1478	.1905
7	.1307	.168	.1494	.168	.1848	.1646	.1905
8	.1494	.1867	.1848	.1663	.1829	.1829	.2033
9	.168	.1848	.1663	.2012	.1646	.2012	.2218
10	.1867	.2241	.168	.2241	.2012	.2427	.1867
11	.2054	.1867	.2241	.2427	.2195	.168	.1494
12	.2587	.1867	.2241	.2054	.1829	.2054	.112
13	.1663	.168	.2054	.2054	.1848	.2054	.1307
14	.1646	.168	.2054	.1494	.1867	.1307	.1307
15	.1663	.1867	.1307	.2054	.1494	.1307	.112
16	.2241	.1307	.1307	.2054	.1867	.1867	.1307
17	.1494	.1494	.1494	.168	.2054	.168	.1307
18	.2241	.1494	.1494	.1867	.1867	.2054	.1867
19	.2987	.2054	.2614	.2241	.2427	.2427	.1867
20	.2054	.2054	.2614	.1867	.2241	.2241	.1867
21	.2054	.2054	.1867	.1867	.2054	.2054	.1867
22	.168	.1848	.168	.1867	.1848	.1905	.1524
23	.1307	.1307	.1494	.1494	.1494	.1715	.1334
24	.0934	.1307	.1307	.1494	.1307	.1478	.1524
Max	.2987	.2241	.2614	.2427	.2427	.2427	.2218
Min	.0934	.112	.112	.112	.1307	.1307	.112
Avg	.1638	.1617	.1648	.1740	.1740	.1740	.1654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 201 / JAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-FEB-18
HR	Load (MW)
8	.5609
Max	.5609
Min	.5609
Avg	.5609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 202 / TATOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9907	.9614	.9012	.9536		.9134	.6135
9		.9945	.9503		1.0166	1.0341	
10		.9995	.9831		1.0029	1.0517	
11		1.0159	.9503		.8916	1.0867	
12		1.0978			1.0517	1.1218	
13		1.1305			1.0749	1.1145	
14		1.065			1.0745	1.1145	
15		1.0322			1.1043	1.1317	
Max	.9907	1.1305	.9831	.9536	1.1043	1.1317	.6135
Min	.9907	.9614	.9012	.9536	.8916	.9134	.6135
Avg	.9907	1.0371	.9462	.9536	1.0309	1.0711	.6135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 205 / 11 KV Pandharwani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6668	.5895	.5243	.5937	.5609	.631	.5407
9	.6588	.5801	.639	.7362	.6836	.6718	.6068
10	.6762	.5801	.6226	.6661	.7202	.6882	.5548
11	.6762	.5898	.639	.7186	.7011	.6554	.5959
12	.6935	.6226		.7362	.7202	.7209	.5784
13	.7108	.639		.7362		.7209	.5375
14	.6935	.639		.8383	.7522	.7045	.5375
15	.7108	.639		.7712	.7537	.7045	.4733
Max	.7108	.639	.639	.8383	.7537	.7209	.6068
Min	.6588	.5801	.5243	.5937	.5609	.631	.4733
Avg	.6858	.6099	.6062	.7246	.6988	.6872	.5531

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 401 / 33 KV INCOMER NO I JAWALI SINGLE PHASING

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9717	1.0425	.9877	.9671	1.0425
9	1.1523	1.0974	1.0425	1.0425	1.0425
10	1.0974	1.0974	1.0974	1.0974	1.0208
11	1.0974	1.1523	1.0425	1.0974	.8939
12	1.262	1.2071	1.0425	1.1523	1.0288
13	1.262	1.262		1.2003	1.1043
14	1.3169	1.2071		1.1523	1.0745
15	1.262	1.1523		1.2574	1.1043
22			.4572		
Max	1.3169	1.262	1.0974	1.2574	1.1043
Min	.9717	1.0425	.4572	.9671	.8939
Avg	1.1777	1.1523	.9450	1.1208	1.0390



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 402 / 33 KV INCOMER NO 2 JAWALI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.3429	.2858	.2858	.2858
2	.2858	.2286	.2858	.2858	.2858	.2858	.2858
3	.2858	.2286	.2858	.2858	.2286	.2858	.2858
4	.2858	.2286	.2858	.2858	.2286	.2858	.2858
5	.2858	.2286	.2858	.2858	.2858	.2858	.2858
6	.2858	.2858	.2858	.2858	.2858	.2858	.2858
7	.2858	.2286	.2858	.2858	.2858	.3429	.2858
8	2.4006	2.2862	2.0851	2.2565	1.8107	2.1491	2.0513
9	2.4143	2.3045	2.4143	2.524	2.4691	2.364	2.3594
10	2.3045	2.3045	2.2497	2.3045	2.4714	2.3102	2.0302
11	2.2497	2.4143	2.3594	2.3045	2.3137	2.364	2.0851
12	2.3594	2.3594		2.3594	2.4177	2.4714	1.262
13	2.5789	2.524		2.524	1.6301	2.4977	1.9204
14	2.4691	2.5789		2.4143	2.3388	2.552	2.0851
15	2.524	2.6337		2.3594	1.8804	2.552	1.9204
16	.1715	.1715		.1715	.1715	.1715	.1715
17	.2286	.1715		.1715	.2286	.1715	.2195
18	.3429	.3429		.2286	.2858	.2858	.2858
19	.5144	.5144	.5716	.5716	.4001	.5144	.5144
20	.5144	.5144	.5144	.5144	.5144	.5144	.5144
21	.4572	.4572	.4572	.4001	.4572	.5144	.5144
22	.4001	.3429	.4001	.3429		.4001	.4001
23	.3429	.2858	.3429	.3429	.3429	.3429	.3841
24		.2858	.2858	.3429	.2858	.2858	.2858
Max	2.5789	2.6337	2.4143	2.524	2.4714	2.552	2.3594
Min	.1715	.1715	.2858	.1715	.1715	.1715	.1715
Avg	1.0554	1.0086	.8048	1.0079	.9524	1.0216	.8752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 406 / 33 KV Gokul WCL Express NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.3429	.4572	.3429	.4572
2	.4572	.4572	.4572	.3429	.4572	.3429	.4572
3	.4572	.4572	.4572	.3429	.4572	.3429	.4572
4	.4572	.4572	.4572	.3429	.4572	.3429	.4572
5	.4572	.4572	.4572	.3429	.3429	.3429	.4572
6	.4572	.4572	.4572	.4572	.3429	.3429	.4572
7	.4572	.3429	.3429	.4572	.3429	.3429	.3429
8	.3429	.3429	.3429	.4572	.3429	.3429	.3429
9	.4572	.3429	.3429	.3429	.3429	.3429	.3429
10	.3429	.3429	.3429	.3429	.3429	.3429	.3429
11	.3429	.3429	.3429	.3429	.3429	.3429	.3429
12	.3429	.3429		.3429	.3429	.3429	.3429
13	.3429	.3429		.3429	.3429	.3429	.3429
14	.3429	.3429		.3429	.3429	.3429	.3429
15	.3429	.3429		.3429	.3429	.3429	.3429
16	.3429	.3429		.3429	.3429	.3429	.3429
17	.3429	.3429		.3429	.3429	.3429	.3429
18	.3429	.3429		.3429	.3429	.3429	.3429
19	.3429	.3429	.3429	.4572	.3429	.3429	.3429
20	.4572	.3429	.3429	.4572	.3429	.4572	.4572
21	.4572	.3429	.3429	.4572	.3429	.4572	.4572
22	.4572	.3429	.3429	.4572	.3429	.3429	.4572
23	.4572	.3429	.3429	.4572	.3429	.4572	.4572
24	.4572	.4572	.4572	.3429	.4572	.3429	.4572
Max	.4572	.4572	.4572	.4572	.4572	.4572	.4572
Min	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.4048	.3762	.3900	.381	.3667	.3572	.3953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 168021 / 220 KV UMRED

Feeder No / Name : 401 / 33 KV BHIWAPUR  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.8453	3.6574	.8951	.9339	1.0059	.6464
Max	.8453	3.6574	.8951	.9339	1.0059	.6464
Min	.8453	3.6574	.8951	.9339	1.0059	.6464
Avg	.8453	3.6574	.8951	.9339	1.0059	.6464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 168021 / 220 KV UMRED

Feeder No / Name : 404 / 33 KV JAWALI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.1903	.1943	.1955	.2103	.2109
Max	.1903	.1943	.1955	.2103	.2109
Min	.1903	.1943	.1955	.2103	.2109
Avg	.1903	.1943	.1955	.2103	.2109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 168021 / 220 KV UMRED

Feeder No / Name : 405 / 33KV MOHPA ROAD

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.9081	2.5766	2.9127	2.8292	2.9938	2.8292
Max	2.9081	2.5766	2.9127	2.8292	2.9938	2.8292
Min	2.9081	2.5766	2.9127	2.8292	2.9938	2.8292
Avg	2.9081	2.5766	2.9127	2.8292	2.9938	2.8292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 201 / 11 KV KUHI U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.2096	.2286	.381	.3048	.3429
2	.2477	.2667	.2096	.2286	.381	.3048	.3429
3	.2667	.2667	.2286	.2477	.362	.3048	.3429
4	.2667	.2667	.2286	.2477	.362	.3048	.3239
5	.3239	.2667	.2477	.2858	.362	.3239	.3239
6	.3239	.3048	.3048	.362	.362	.4191	.381
7	.381	.4191	.362	.4001	.4191	.4763	.4191
8	.4191	.4382	.4382	.4001	.4572	.4382	.4382
9	.4382	.4191	.5716	.4001	.5716	.4191	.4001
10	.5335	.381	.5335	.381	.4763	.381	.3048
11	.5906	.3239	.4954	.381	.4763	.381	.2477
12	.4191	.3048		.3429	.4572	.3429	.2858
13	.4191	.3048	.4191	.3429	.4572	.3429	.3048
14	.381	.2858	.2477	.3429	.4572	.3429	.3048
15	.3048	.2667	.2667	.3048	.4191	.3429	.3239
16	.3048	.2667	.2667	.2667	.381	.3429	.3429
17	.2858	.2286	.2858	.381	.3239	.3429	.3429
18	.4191	.3429	.3429	.4954	.381	.381	.362
19	.5525	.4572	.5144	.5716	.4191	.4572	.4001
20	.4954	.4191	.4954	.5335	.4763	.5144	.4191
21	.4572	.3429	.4382	.4954	.4572	.4572	.4191
22	.3429	.2667	.362	.4572	.3429	.381	.362
23	.3048	.2477	.2858	.4191	.3429	.362	.2858
24	.2477	.2858	.2286	.2477	.381	.3048	.362
Max	.5906	.4572	.5716	.5716	.5716	.5144	.4382
Min	.2477	.2286	.2096	.2286	.3239	.3048	.2477
Avg	.3739	.3191	.3471	.3652	.4128	.3739	.3493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 202 / 11 KV CHAFEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4191	.4572	.4954	.4763	
2	.381	.4572	.4191	.4572	.4954	.4763	.4572
3	.4572	.4572	.4191	.4763	.4572	.4572	.4572
4	.4572	.4382	.4382	.4763	.4572	.4382	.4763
5	.4954	.4382	.4572	.4954	.4191	.4382	.4763
6	.5144	1.1431	1.2003	1.2003	.4191	.5716	.5144
7	.4954	1.3527	1.467	1.3336	.5525	.6097	.5716
8	.4954	1.3146	1.5432	1.5051	.4954	.5525	.6097
9	.4954	1.5242	1.6385	1.6766	.5144	.4954	.5716
10	.381	1.4098	1.6004	1.6004	.381	.381	.381
11	.3048	1.3336	1.5623	1.6004	.3429	.3048	.2858
12	.2286	1.4098	1.6575	1.6004	.2858	.2477	.2667
13	.2286	1.4861	1.6766	1.6004	.2858	.2477	.2667
14	1.7528	.3048	.2667	.2667	1.848	1.829	1.1812
15	1.7718	.3048	.2667	.2667	1.8099	1.829	1.2955
16	1.7909	.2858	.2667	.2667	1.7528	1.7909	1.3717
17	1.8099	.2667	.2667	.4954	1.6956	1.7909	1.4289
18	1.7528	.362	.5335	.5716	1.5623	1.7528	1.4289
19	1.6956	.724	.8192	.8954	1.5242	1.7337	1.4098
20	1.6385	.9335	.9145	.8383	1.5242	1.7337	1.448
21	1.6004	.7811	.8573	.7621	1.5051	1.7147	1.448
22	.6097	.5525	.6478	.6859	.5906	.4572	.5335
23	.5716	.4763	.5144	.6478	.5716	.4763	.4954
24	.381	.5335	.4572	.4763	.5716	.5335	.4763
Max	1.8099	1.5242	1.6766	1.6766	1.848	1.829	1.448
Min	.2286	.2667	.2667	.2667	.2858	.2477	.2667
Avg	.8621	.7819	.8462	.8605	.8565	.8891	.7762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 203 / 11 KV DONGARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1334	.1143
2	.1143	.1143		.1143	.1143	.1334	.1143
3	.1143	.1143	.1143	.1143	.1143	.1334	.1143
4	.1143	.1143	.1143	.1143	.1143	.1334	.1334
5	.1143	.1143	.1143	.1143	.1143	.1334	.1334
6	.1143	.4191	.3429	.4763	.1143	.1334	.1143
7	.1143	.4572	.4954	.5144	.1524	.1524	.1905
8	.1143	.5335	.5716	.6478	.1143	.1334	.1143
9	.1143	.6097	.6668	.724	.1143	.1334	.1143
10	.0953	.6097	.6859	.6859	.1143	.0762	.0953
11	.0762	.6097	.7049	.6859	.0762	.0381	
12	.0953	.6668	.7049	.6478	.0762	.0381	.0762
13	.0953	.7049	.6859	.6478	.0762	.0381	.0762
14	.381	.1334	.0572	.0381	.6859	.7621	.4954
15	.381	.1143	.0572	.0762	.724	.7621	.5525
16	.6668		.0762	.0762	.7621	.7621	.6097
17	.724		.0762	.1143	.7621	.7621	.6287
18	.6668	.1524	.0953	.1524	.6478	.724	.6097
19	.5906	.1905	.2286	.2286	.6287	.6859	.5906
20	.5716	.2477	.2096	.1905	.6097	.6097	.5525
21	.5716	.1905	.1905	.4001	.6097	.5716	.5335
22	.1524	.1524	.1334	.1524	.1524	.1524	.1905
23	.1334	.1334	.1143	.1524	.1524	.1524	.1524
24	.1143	.1143	.1143	.1143	.1143	.1334	.1143
Max	.724	.7049	.7049	.724	.7621	.7621	.6287
Min	.0762	.1143	.0572	.0381	.0762	.0381	.0762
Avg	.2643	.3005	.2899	.3040	.3025	.3120	.2792



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 204 / 11 KV SATARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.3048	.3048	.4572	.4191	.3429
2	.2667	.3239	.3048	.3048	.4572	.4191	.3429
3	.2667	.3239	.2858	.3048	.4191	.4001	.3429
4	.2667	.3239	.3048	.3239	.381	.4001	.381
5	.3048	.3048	.3239	.3429	.3048	.381	.381
6	1.6194	.381	.4191	.4763	1.6004	1.5242	.8383
7	1.7147	.5144	.4954	.5144	1.6766	1.6575	1.448
8	1.829	.4572	.4001	.4763	1.7147	1.6766	1.6766
9	1.9052	.3239	.362	.381	1.7909	1.6956	1.6004
10	1.9052	.2667	.3239	.3048	1.7337	1.6385	1.5813
11	1.8861	.1905	.2096	.2667	1.7337	1.6004	1.6004
12	1.8861	.1715	.2096	.2096	1.7337	1.5242	1.5813
13	1.8861	.1334	.1905	.1905	1.7147	1.5242	1.5623
14	.1524	1.5051	2.0195	2.0195	.1715	.1905	.1715
15	.1524	1.6575	2.0386	2.0195	.1715	.1905	.2096
16	.1715	1.8861	2.0386	2.0195	.1905	.1905	.1905
17	.1905	2.0005	2.0386	1.9814	.1905	.1905	.2096
18	.4763	1.9624	1.8861	1.9052	.4191	.2667	.362
19	.6478	1.9052	1.848	1.448	.5335	.3048	.4572
20	.6097	1.9243	1.848	1.4098	.5716	.3429	.4954
21	.5716	1.8671	1.829	1.3336	.5906	.381	.5525
22	.4191	.381	.4572	.3048	.4572	.381	.4382
23	.381	.3429	.3239	.4572	.4572	.381	.362
24	.3048	.3429	.3239	.3048	.4954	.4382	.3429
Max	1.9052	2.0005	2.0386	2.0195	1.7909	1.6956	1.6766
Min	.1524	.1334	.1905	.1905	.1715	.1905	.1715
Avg	.8383	.8264	.8661	.8168	.8319	.7549	.7279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 205 / 11 KV BHOJAPUR GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524	.1334	.1715	.1905	.1905	.1905
2	.1143	.1524	.1334	.1715	.1905	.1905	.1905
3	.1524	.1715	.1524	.1715	.1905	.2096	.2096
4	.1524	.1905	.1524	.1715	.1905	.2096	.2096
5	.1905	.2096	.1524	.1905	.1905	.2096	.2096
6	.1905	.2286	.2667	.2096	.1905	.2286	.2096
7	.2096	.2286	.3429	.2286	.2096	.2286	.2096
8	.2286	.2667	.2667	.2096	.2286	.2477	.2096
9	.2667	.1715	.1905	.2096	.2667	.2858	.2667
10	.2477	.2096	.2286	.1905	.2667	.2667	.2667
11	.2286	.2667	.2286	.1905	.2286	.2477	.2667
12	.2096	.2667	.2667	.1905	.1905	.2096	.2477
13	.2096	.2858	.1905	.1905	.1905	.2096	.2477
14	.2096	.2858	.0762	.1905	.1905	.2096	.2286
15	.1905	.2667	.0762	.1715	.1905	.2096	.2096
16	.1905	.2477	.1143	.1524	.1905	.2096	.1905
17	.2096	.2667	.1334	.1905	.1715	.2286	.1715
18	.2096	.2667	.2286	.2286	.1715	.2286	.1905
19	.2286	.2477	.2667	.2667	.2096	.2477	.2096
20	.2286	.2477	.2667	.2667	.2286	.2477	.2477
21	.2286	.1905	.2286	.2286	.2286	.2286	.2477
22	.1905	.1524	.2096	.2286	.2096	.2286	.2286
23	.1715	.1334	.1905	.2286	.1905	.1905	.1905
24	.1143	.1524	.1334	.1715	.1905	.1905	.1905
Max	.2667	.2858	.3429	.2667	.2667	.2858	.2667
Min	.1143	.1334	.0762	.1524	.1715	.1905	.1715
Avg	.1953	.2191	.1929	.2008	.2040	.2231	.2183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 206 / 11 KV TITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1715	.1905	.2286	.2096	.1905
2	.1715	.1905	.1715	.1905	.2286	.1905	.1905
3	.1905	.1905	.1715	.1905	.2286	.1905	.1905
4	.1905	.1905	.1715	.1905	.2096	.2096	.1905
5	.2096	.1905	.1905	.2096	.2096	.2096	.2096
6	.2096	.5716	.5335	.4763	.2096	.2286	.2286
7	.2096	.6097	.6478	.6287	.2096	.2667	.2286
8	.1905		.6668	.7621	.2286	.2477	.2477
9	.1905	.8192	.6668	.7811	.2286	.2286	.2096
10	.1524	.7621	.7621	.7811	.1715	.1905	.1715
11	.1143	.743	.8192	.7811	.1715	.1524	.1334
12	.0953	.7811	.8383	.7811	.0381	.0953	.1334
13	.0953	.743	.8383	.7621	.0381	.0953	.1334
14	.8573	.1524	.0953	.1524	.9335	1.0288	.6097
15	.8954	.1334	.0953	.1143	.9335	1.0669	.6097
16	.8573	.1334	.1143	.1143	.9145	1.0288	.724
17	.724	.1143	.1143	.1905	.8954	.9145	.7811
18	.6859	.2667	.1905	.2667	.7811	.8383	.8002
19		.3239	.362	.3239	.7621	.8002	.724
20	.6478	.362	.362	.3239	.6859	.6859	.6859
21	.6097	.2667	.3239	.3048	.6478	.5716	.6478
22	.2286	.2096	.2667	.3048	.2477	.1905	.2667
23	.2096	.1905	.1905	.2667	.2286	.2096	.2286
24	.1715	.1905	.1905	.1905	.2667	.2096	.1905
Max	.8954	.8192	.8383	.7811	.9335	1.0669	.8002
Min	.0953	.1143	.0953	.1143	.0381	.0953	.1334
Avg	.3512	.3620	.3731	.3866	.4041	.4192	.3636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 207 / 11KV MIDC KUHI FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT  
HAVING WEEKLY STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858	.1905	.381	.3048	.2858	.381
2	.381	.1905	.2096	.381		.2858	.3429
3	.381	.1905	.2667	.4001	.2667	.3048	.3429
4	.3429	.1715	.3048	.4001	.2667	.3429	.381
5	.3429	.1524	.3429	.4001	.2286	.381	.4001
6	.3429	.381	.381	.381	.2286	.381	.4001
7	.362	.4191	.4191	.381	.381	.381	.4191
8	.362	.4191	.4191	.381	.4954	.3429	.4191
9	.362	.4191	.4382	.4191	.5335	.2667	.4382
10	.4763	.3429	.5525	.4191	.5144	.381	.4382
11	.5906	.2667	.6668	.4191	.6097	.4954	.4572
12	.6859	.5716	.7049	.4191	.6668	.5716	.4572
13	.6668	.5525	.7049	.381	.6478	.4954	.4763
14	.6097	.5716	.7811	.2477	.5716	.4191	.4382
15	.5525	.5716	.6668	.2667	.5335	.4954	.3429
16	.5525	.5906	.5716	.2667	.4954	.5716	.3239
17	.5335	.5906	.5525	.381	.381	.5906	.2858
18	.4954	.5335	.5525	.4191	.5906	.5716	.2286
19	.4763	.4954	.4763	.4954	.5716	.4954	.2096
20	.4763	.4572	.4382	.381	.5335	.4001	.1715
21	.4954	.4191	.4001	.381	.4191	.4001	.0572
22	.4382	.381	.381	.3429	.2858	.381	.2667
23	.4191	.3048	.362	.3429	.2858	.381	.1715
24	.4382	.381	.2667	.381	.3429	.2667	.381
Max	.6859	.5906	.7811	.4954	.6668	.5906	.4763
Min	.3429	.1524	.1905	.2477	.2286	.2667	.0572
Avg	.4652	.4025	.4604	.3778	.4415	.4120	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 208 / 11 KV BHOJAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1715	1.0288	1.086	.8573	.1524	.1143
2	.1334	.1715	.1143	.0953	.1715	.1524	.1143
3	.1334	.1715	.1143	.0953	.1715	.1334	.1143
4	.1524	.1715	.1143	.0953	.1715	.1334	.1143
5	.1524	.1905	.0953	.0953	.1715	.1334	.1143
6	.7049	.1905	.0953	.1143	.0762	.8573	.6859
7	.7621	.1905	.1143	.1143	.0953	.9526	.7621
8	.8764	.2096	.1334	.1334	.0953	.9907	1.0479
9	.9907	.2286	.1524	.1334	.9145	1.0288	1.0479
10	1.0288	.2286	.1715	.1524	.9717	1.0669	
11	1.0669	.2286	.1715	.1524	1.105	1.0669	.5144
12	1.086	.2286	.1905	.1524	1.1812	1.105	.5335
13	1.105	.2286	.2096	.1715	1.1431	1.1431	.5716
14	1.1812	.9145	1.3336	1.448	1.2955	1.1812	.5525
15	1.2193	1.1241	1.3717	1.4861	1.2955	1.1812	.5525
16	1.2193	1.2193	1.3908	1.5242	1.2955	1.2003	.5716
17	1.2003	1.3527	1.3908	1.448	1.2765	1.2003	.5144
18	.1905	1.2955	1.2955	1.3717	.1715	.1143	.1524
19	.2096	1.2193	1.2384	1.2384	.1715	.1143	.1715
20	.2096	1.1812	1.2003	1.1431	.1524	.1143	.2286
21	.1905	1.1431	1.1241	1.0669	.1524	.0953	.1905
22	.1905	1.0479	1.105	1.0669	.1524	.0953	.1905
23	.1715	1.0479	1.105	.9526	.1524	.0953	.2096
24	.9145	.1524	1.0288	1.086	.9526	.1524	.1143
Max	1.2193	1.3527	1.3908	1.5242	1.2955	1.2003	1.0479
Min	.1334	.1524	.0953	.0953	.0762	.0953	.1143
Avg	.6343	.5962	.6787	.6843	.5914	.6025	.3993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 201 / 11 KV MANDHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5525	.4572	.5335	.6287	.5716	.6097
2	.4954	.5525	.4572	.5335	.6287	.5716	.6097
3	.4954	.5525	.4572	.5335	.6287	.5716	.6097
4	.5716	.5716	.4382	.5716	.6287	.5906	.6478
5	.6478	.6097	.5716	.6097	.6668	.6859	.6859
6	.6859	.7049	.6097	.6478	.7049	.7621	.724
7	.8383	.8764	.5906	.743	.7621	.8192	.8764
8	1.2765	1.2955	1.3527	1.3527	1.2193	1.2193	1.3146
9	1.448	1.2574	1.5051	1.448	1.1241	1.2955	1.3527
10	1.2384	1.2384	1.3527	1.3908	1.3146	1.3336	1.2003
11	1.2765	1.3717	1.4098	1.3717	1.2574	1.2955	1.1622
12	1.2955	1.2193	1.3336	1.4289	1.105	1.3146	1.2384
13	1.4289	1.2193	1.3146	1.3908	1.3908	1.2574	1.105
14	1.4861	1.2384	1.2765	1.4098	1.4098	1.2193	1.105
15	1.3717	1.3146	1.3146	1.2765	1.2955	1.2574	1.086
16	.5335	.4382	.4954	.4191	.5525	.6097	
17	.6478	.4382	.5144	.5906	.6097	.6097	
18	.724	.5906	.7621	.9335	.5906	.7621	.8764
19	.9717	.6668	.9145	.9717	.9335	1.0098	.8954
20	.9526	.6478	.8954	.9335	.8954	1.0288	.8573
21	.8573	.5906	.8002	.8573	.8383	.9145	.8192
22	.7049	.5144	.6668	.7621	.724	.8002	.7621
23	.6287	.4763	.5716	.6668	.6097	.724	.743
24	.5144	.5525	.4572	.5335	.6287	.5716	.6668
Max	1.4861	1.3717	1.5051	1.448	1.4098	1.3336	1.3527
Min	.4954	.4382	.4382	.4191	.5525	.5716	.6097
Avg	.8994	.8121	.8550	.9129	.8811	.9082	.9067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 202 / 11 KV CHICHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.1143	.1143	.1524	.1334	.1524
2	.0953	.1334	.1143	.1143	.1524	.1334	.1524
3	.0953	.1334	.1143	.1143	.1524	.1334	.1334
4	.1143	.1524	.1143	.1334	.1715	.1334	.1334
5	.1143	.1524	.1524	.1524	.1715	.1524	.1715
6	.1334	.1905	.1715	.1524	.1715	.1905	.1905
7	.1715	.1905	.1715	.1524	.1905	.1905	.2096
8	.362	.4001	.3239	.3239	.4001	.3239	.3239
9	.4191	.4382	.4001	.4382	.3429	.362	.3239
10	.4191	.4191	.4191	.4382	.4191	.362	.3239
11	.4572	.381	.4001	.4382	.4191	.362	.3048
12	.4382	.4001	.4191	.4572	.4382	.3429	.2667
13	.4572	.4001	.4382	.4191	.4382	.4001	.2667
14	.4763	.4382	.4382	.4763	.4191	.381	.2667
15	.4572	.4382	.4382	.4572	.4001	.381	.2477
16	.1143	.1143		.1334	.1334	.1143	.1143
17	.1143	.1143	.0953	.1334	.1143	.1334	.1143
18	.1524	.1524	.1524	.2286	.1905	.1905	.1905
19	.2477	.2286	.2286	.2477	.2667	.2477	.2286
20	.2667	.2286	.2286	.2477	.2667	.2667	.2096
21	.2286	.2096	.2096	.2096	.2286	.2667	.2096
22	.1715	.1715	.1524	.1715	.1905	.2096	.1715
23	.1334	.1334	.1524	.1715	.1524	.1905	.1524
24	.1143	.1334	.1143	.1334	.1524	.1524	.1715
Max	.4763	.4382	.4382	.4763	.4382	.4001	.3239
Min	.0953	.1143	.0953	.1143	.1143	.1143	.1143
Avg	.2437	.2453	.2419	.2524	.2556	.2397	.2096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 203 / 11 KV DONGARMOUDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6004	1.6004	1.4861	1.2574	1.2193	1.2003
2	1.6194	1.6004	1.5623	1.448	1.2574	1.1812	1.2003
3	1.6194	1.6004	1.5623	1.448	1.2574	1.1812	1.2003
4	1.6575	1.6004	1.5813	1.4861	1.2765	1.2193	1.2384
5	1.6956	1.5242	1.6385	1.5242	1.2765	1.2955	1.2955
6	1.7147	1.5623	1.6766	1.4861	1.3146	1.3717	1.2765
7	1.7909	1.6575	1.6766	1.5813	1.3527	1.3527	1.3717
8	2.191	2.0386	1.9624	1.848	1.6004	1.5813	1.5051
9	2.572	2.3815	2.0195	1.9624	1.9052	1.7718	1.5623
10	2.4768	2.21	2.0767	2.0195	1.7909	1.7528	1.3908
11	2.572	2.3053	2.21	2.0195	1.7337	1.7337	1.3336
12	2.572	2.5339	2.3434	2.1148	1.9433	1.7909	.8573
13	2.5339	2.5149	2.4196	2.0957	1.9243	1.9052	1.2003
14	2.4387	2.4006	2.4577	2.2672	1.9814	1.8671	1.2384
15	1.0479	2.3815	2.1148	2.0005	2.0195	1.848	1.2574
16	1.6385	2.21	2.1338	1.8861	1.9243	1.8099	
17	1.7337	2.1719	2.0576	1.8671	1.8671	1.7147	
18	1.8671	1.8671	1.7909	1.8099	1.4098	1.6194	1.1431
19	1.9052	1.8861	1.7909	1.6194	1.4861	1.5242	1.2384
20	1.8861	1.8671	1.829	1.5813	1.5242	1.5432	1.2193
21	1.6956	1.829	1.7337	1.5242	1.4861	1.4861	1.1622
22	1.6194	1.7528	1.6766	1.3527	1.3908	1.3336	1.105
23	1.6194	1.6385	1.6004	1.3146	1.2574	1.2955	.9907
24	1.6575	1.6004	1.6004	1.5242	1.2574	1.2193	1.2384
Max	2.572	2.5339	2.4577	2.2672	2.0195	1.9052	1.5623
Min	1.0479	1.5242	1.5623	1.3146	1.2574	1.1812	.8573
Avg	1.9060	1.9473	1.8798	1.7195	1.5623	1.5257	1.2375



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 204 / Mandhal II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1905	.2286	.2286	.1905	.2286
2	.1905	.2096	.1905	.1905	.2286	.1905	.2286
3	.1905	.2096	.1905	.1905	.2286	.1905	.2286
4	.2286	.2096	.1905	.2286	.2286	.2096	.2667
5	.2667	.2096	.2286	.2286	.2477	.2477	.2858
6	.3048	.2477	.2667	.2477	.2477	.2858	.3048
7	.3239	.3048	.2858	.2858	.2858	.2667	.3048
8	.9335	.9335	.9717	.9907	.8383	1.0479	.9335
9	1.0669	.9717	1.0288	.8764	.9335	1.0288	.9717
10	1.0669	.8954	.9335	.8764	.9526	1.0288	.8764
11		.9526	.9526	.9335	.9526	1.0098	.9335
12	1.0669	.9907	.8954	.9526	1.0288	1.0669	.2667
13	1.0098	1.0098	.9717	.9335	1.1241	1.0098	.2096
14	1.0288	.9907	.9145	.9717	1.1431	.9907	.2477
15	1.0098	1.0098	.9526	.9526	1.105	1.0288	.2477
16	.2096	.2477	.2858	.2477	.2858	.3048	.1905
17	.2096	.2096	.2667	.2477	.2858	.3239	.2286
18	.2286	.2667	.2667	.3048	.1905	.3239	.2286
19	.2858	.3239	.2858	.3048	.2477	.3239	.2286
20	.2667	.3239	.2667	.2858	.2477	.3048	.2286
21	.2667	.2858	.2667	.2858	.2286	.3239	.1905
22	.2286	.2477	.2477	.2477	.2286	.2667	.1905
23	.2286	.2096	.2477	.2477	.1905	.2667	.1905
24	.2286	.2096	.1905	.2286	.2286	.1905	.2477
Max	1.0669	1.0098	1.0288	.9907	1.1431	1.0669	.9717
Min	.1905	.2096	.1905	.1905	.1905	.1905	.1905
Avg	.4796	.4866	.4787	.4787	.4961	.5176	.3525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 205 / 11 KV WAG FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.4191
Max	.4191
Min	.4191
Avg	.4191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 206 / 11 KV PUNARVASAN FFEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1715	.1905	.1905	.1715	.1905
2	.1524	.1524	.1715	.1715	.1905	.1715	.1905
3	.1524	.1524	.1715	.1715	.1905	.1715	.1905
4	.1905	.1524	.1905	.2096	.1905	.1715	.2286
5	.2667	.1715	.1905	.2477	.2286	.2286	.2667
6	.3048	.2096	.1905	.2667	.2858	.3048	.2667
7	.3429	.2286	.1905	.3429	.381	.3239	.3429
8	.4191	.3429	.4191	.381	.4001	.3239	.4191
9	.4382	.3429	.4191	.4191	.3048	.3239	.4001
10	.3048	.4382	.4001	.4191	.381	.4382	.362
11	.4191	.381	.4382	.4763	.381	.2858	.3429
12	.3429	.381	.4382	.4191	.381	.3239	.4001
13	.3239	.4191	.4001	.4001	.381	.381	.381
14	.4001	.4001	.381	.4382	.3429	.3429	.362
15	.3429	.381	.362	.3429	.3239	.3429	.3239
16	.1334	.1143	.1143	.0953	.1334	.1143	.1143
17	.1524	.1334	.1334	.1334	.1334	.1143	.1143
18	.1715	.1905	.2286	.3429	.1715	.1524	.2286
19	.2667	.362	.3429	.3429	.3429	.3239	.3048
20	.2477	.3429	.3048	.3048	.3239	.3048	.3048
21	.2096	.3048	.2858	.2667	.2858	.2667	.2667
22	.1715	.2667	.2286	.2286	.2477	.2286	.2096
23	.1715	.1905	.2096	.2096	.2096	.2096	.1905
24	.1715	.1524	.1905	.1905	.1905	.1905	.1905
Max	.4382	.4382	.4382	.4763	.4001	.4382	.4191
Min	.1334	.1143	.1143	.0953	.1334	.1143	.1143
Avg	.2604	.2651	.2739	.2921	.2747	.2588	.2747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 201 / 11 KV VELTUR SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7265	.591	.7762	.823	.7964	.815	.8871
2	.7265	.5973	.7762	.823	.8145	.815	.8871
3	.7164	.5792	.7865	.823	.8507	.815	.8871
4	.7087	.543	.7865	.8686	.905	.815	.9055
5	.7888	.6556	.8962	.9335	.5554	.9922	1.0059
6	.9088	.7265	.9145	1.0534	1.0317	.9922	1.0679
7	1.0117	.8859	1.1041	1.1643	1.1222	1.1163	1.1706
8	1.0227	1.1065	1.0343	1.1022	1.0395	1.1065	1.0288
9	1.0277	1.1568	1.0395	1.166	1.073	1.073	1.0004
10	1.0277	1.0898	1.0442	1.0059	.8383	1.0111	.8718
11	.9945	1.0682	1.0395	.9556	1.0277	1.0059	.8383
12	.9779	1.0343	.9945	.9221	.9448	.9116	.8383
13	.9945	1.0343	1.0774	.9389	.8619	.8951	.8383
14	1.0277	1.0343	1.1105	.9665	.9614	.9779	.8383
15	1.0442	1.0174	1.1233	.9602	.8619	.9945	.8048
16	.6443	.7343	.8962	.8328	.7442	.7842	.5138
17	.7969	.8316	.9511	.8859	.8505	.8316	.591
18	.8238	.8962	1.0136	.9671	.9568	1.1888	.6984
19	.929	1.2851	1.2567	1.1283	1.2757	1.3535	.7522
20	.8859	1.2308	1.2936	1.2357	1.2226	1.2986	.8869
21	.7973	1.1088	1.2752	1.0029	1.1517	1.1273	.8145
22	.7164	.9231	1.2012	.9492	.9391	1.0349	.6878
23	.6805	.7964	.9425	.8775	.8505	.9425	.6516
24	.7343	.6089	.7762	.8501	.8326	.815	.8962
Max	1.0442	1.2851	1.2936	1.2357	1.2757	1.3535	1.1706
Min	.6443	.543	.7762	.823	.5554	.7842	.5138
Avg	.8630	.8973	1.0046	.9682	.9378	.9880	.8484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 202 / 11 KV BHIWKUND

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4887	.4435	.4854	.2715	.5014	.4938
2	.4706	.4887	.4668	.4805	.3077	.5194	.499
3	.4656	.4525	.462	.499	.3077	.5194	.4938
4	.4656	.4344	.462	.499	.3258	.5194	.499
5	.4835	.4656	.462	.499	.362	.5194	.5304
6	.5138	.4961	.4805	.567	.3982	.394	.5304
7	.5258	.5493	.499	.6099	.3982	.4656	.5611
8	.6104	.6613	.6443	.6783	.6036	.6133	.5935
9	.7209	.7377	.7042	.7122	.6539	.7127	.5765
10	.7545	.7377	.7209	.7461	.6706	.6882	.5935
11	.7127	.7969	.7293	.7209	.6554		.6036
12	.4763	.7712	.7293	.7042	.6882		.6036
13	.7293	.8309	.8048	.7209	.7537	.6796	.6203
14	.779	.8478	.8215	.7545	.7537	.6962	.6539
15	.8288	.8478	.8648	.703	.7701	.7122	.6036
16	.6344	.6584	.7316	.4557	.7522	.6219	.4075
17	.6415	.7207	.7207	.4607	.6089	.6335	.4477
18	.6415	.7095	.6838	.4656	.6268	.6584	.4835
19	.6588	.6722	.6838	.5373	.7343	.7133	.5194
20	.6485	.6468	.7023	.5973	.7343	.6878	.5611
21	.5784	.5359	.5544	.543	.6447	.5853	.4887
22	.5316	.4805	.5415	.4887	.5731	.5544	.4344
23	.5194	.4572	.5041	.362	.5373	.5041	.4163
24	.4706	.4835	.4435	.4938	.3258	.5373	.499
Max	.8288	.8478	.8648	.7545	.7701	.7133	.6539
Min	.4656	.4344	.4435	.362	.2715	.394	.4075
Avg	.5972	.6238	.6192	.5743	.5607	.5926	.5297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 203 / 11 KV CHIKHALI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2149	.2402	.2587	.1991	.2378	.2743
2	.2507	.197	.2378	.2587	.1991	.2378	.2743
3	.2481	.1991	.2587	.2587	.2172	.2378	.2743
4	.2715	.181	.2614	.3109	.2353	.2378	.2957
5	.3045	.2126	.2801	.3511	.2353	.2378	.3326
6	.333	.2303	.2987	.3696	.2534	.2926	.3511
7	.3294	.2481	.3326	.3511	.2896	.3475	.3696
8	.3086	.3222	.3429	.3429	.3018	.3052	.3294
9	.3353	.3353	.373	.4115	.3185	.3391	.3052
10	.3561	.1677	.3521	.373	.3185	.3052	.3052
11	.3647	.3391	.407	.3521	.3353	.3258	.3018
12	.3647	.373	.4191	.3521	.3185		.3185
13	.3812	.3561	.4239	.3688	.3521	.3561	.3185
14	.3812	.373	.407	.3647	.3185	.3561	.3185
15	.3647	.3688	.407	.3429	.3018	.3561	.3018
16	.2401	.3109	.3696	.2658	.2743	.2743	.1949
17	.2774	.2865	.3511	.2658	.2743	.2926	.2149
18	.2774	.362	.362	.2686	.3292	.3582	.2328
19	.3121	.4252	.4435	.2686	.4024	.4344	.2534
20	.298	.4119	.462	.3045	.4024	.439	.2896
21	.2629	.362	.3696	.2715	.3658	.3475	.2534
22	.2481	.3142	.3475	.2534	.2829	.3292	.2534
23	.2149	.2957	.2957	.2353	.2561	.2926	.2172
24	.2507	.2149	.2561	.2772	.2353	.2378	.2926
Max	.3812	.4252	.462	.4115	.4024	.439	.3696
Min	.2149	.1677	.2378	.2353	.1991	.2378	.1949
Avg	.3011	.2959	.3458	.3116	.2924	.3121	.2864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 201 / 11KV LANJALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.09	.0572	.0715	.0762	.0762
2	.0762	.0572	.09	.0572	.0715	.0762	.0762
3	.0762	.0572	.09	.0572	.0715	.0762	.0762
4	.0762	.0572	.072	.0572	.0536	.0762	.0762
5	.0762	.0572	.072	.0572	.0536	.0762	.0762
6	.0762	.0572	.09	.0572	.0715	.0762	.0762
7	.0762	.0572	.09	.0572	.0715	.0762	.0762
8	.0953	.1524	.126	.0953	.1251	.1524	.1905
9	.1143	.1524	.126	.0953	.143	.1524	.1905
10	.1143	.1905	.162	.1143	.1787	.1715	.1905
11	.1143	.126	.1524	.1072	.0953	.1524	.143
12	.0953	.108	.1334	.1251		.1334	.0894
13	.0953	.108	.1524		.1524	.1715	.0894
14	.0953	.144	.1524	.1251	.1143	.1715	.0894
15	.0762	.144	.1524	.143	.1143	.1524	.0894
16	.0762		.0572	.0536	.0953	.0572	.0715
17	.0381	.072	.0762	.0536	.0572	.0762	.0715
18	.0572	.072	.0953	.0894	.0762	.0953	.0894
19	.0762	.126	.1524	.1251	.0953	.1524	.0894
20	.0762	.126	.1524	.1251	.0572	.1524	.1251
21	.0953	.108	.1334	.1251	.0762	.1143	.143
22	.0953	.09	.0572	.1072	.1143	.0953	.1072
23	.0572	.09	.0762	.0894	.0953	.0953	.0894
24	.0762	.0572	.09	.0762	.0715	.0953	.0762
Max	.1143	.1905	.162	.143	.1787	.1715	.1905
Min	.0381	.0572	.0572	.0536	.0536	.0572	.0715
Avg	.0826	.0986	.1101	.0891	.0924	.1135	.1028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 202 / 11 KV SASEGAON SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2858	.2683	.2858	.284	.2858	.3429
2	.3239	.2858	.2683	.2858	.284	.2858	.3048
3	.3239	.2858	.2683	.3048	.2682	.2858	.3048
4	.3429	.2858	.2515	.3048	.2682	.2858	.3239
5	.3429	.2858	.2515	.3048	.2524	.3429	.3239
6	.3429	.2858	.285	.2858	.2524	.3429	.3048
7	.3429	.2858	.285	.2667	.2524	.2858	.3048
8	.7621	.9526	.8197	1.105	.8676	1.0288	.9145
9	1.0479	.9526	.6691	1.1812	.8992	1.0479	.9526
10	1.2384	.9145	.9389	1.1812	.9307	.9526	1.0479
11	1.2384	.8886	1.1431	1.0096	1.2193	1.0479	.9307
12	1.2384	.9221	1.2003	.9781		1.1431	.9465
13	1.1431	.9724	1.1812		1.3336	1.1622	.8203
14	1.0479	1.0227	1.2193	1.0096		1.2384	.8045
15	.9526	1.0059	1.105	.9465		1.1431	.631
16	.9526		.1524	.1735	1.1431	.1715	.1578
17	.2286	.1677	.1715	.1578	.9526	.1905	.1578
18	.2858	.285	.2286	.2997	.0762	.2667	.2682
19	.381	.4862	.4572	.4102	.381	.4763	.3628
20	.4954	.4694	.4382	.4259	.4763	.4763	.3786
21	.4191	.3688	.381	.4102	.4191	.4191	.3786
22	.3429	.3353	.362	.3313	.381	.381	.2997
23	.0953	.3018	.3429	.2997	.2858	.3429	.284
24	.3429	.2858	.285	.3048		.2858	.3429
Max	1.2384	1.0227	1.2193	1.1812	1.3336	1.2384	1.0479
Min	.0953	.1677	.1524	.1578	.0762	.1715	.1578
Avg	.6073	.5362	.5406	.5332	.5614	.5787	.4953



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 203 / 11 KV KHAPRI-MANGLI SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0505	.0572	.0506	.0572	.0572
2	.0572	.0381	.0336	.0572	.0506	.0381	.0572
3	.0572	.0381	.0336	.0381	.0506	.0381	.0572
4	.0572	.0381	.0336	.0381	.0506	.0381	.0572
5	.0572	.0381	.0336	.0381	.0506	.0572	.0572
6	.0572	.0572	.0336	.0381	.0506	.0572	.0572
7	.0572	.0572	.0336	.0381	.0506	.0381	.0572
8	.0953	.0953	.1009	.0381	.0506	.0953	.1143
9	.1524	.1143	.1009	.0953	.0506	.1334	.1143
10	.1524	.1143	.0841	.0953	.0337	.1143	.1143
11	.1334	.1178	.0953	.0843	.0381	.1143	.0843
12	.0953	.1009	.0953	.1012		.1143	.0843
13	.1143	.1009	.0953		.0572	.1334	.0843
14	.1143	.1009	.0762	.0843	.0762	.1143	.1012
15	.0762	.1178	.0953	.0843	.0953	.1143	.0506
16	.0762	.0336	.0572	.0506	.0953	.0572	.0337
17	.0381	.0336	.0572	.0506	.0953	.0572	.0337
18	.0572	.0505	.0572	.0506	.0953	.0572	.0506
19	.0572	.0841	.0572	.0843	.0762	.0762	.0674
20	.0572	.0673	.0572	.0843	.0572	.0762	.0674
21	.0762	.0505	.0572	.0506	.0572	.0572	.0674
22	.0572	.0505	.0572	.0506	.0572	.0572	.0506
23	.0381	.0505	.0572	.0506	.0572	.0572	.0506
24	.0572	.0572	.0505	.0572	.0506	.0572	.0572
Max	.1524	.1178	.1009	.1012	.0953	.1334	.1143
Min	.0381	.0336	.0336	.0381	.0337	.0381	.0337
Avg	.0770	.0693	.0626	.0616	.0608	.0754	.0678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 201 / 11 kV ADAM FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.2667
2		.1715	.1715	.2667
3		.1715	.1715	.2477
4		.1715	.1715	.2477
5		.1715	.1715	.2477
6		.2058	.1715	.2477
7		.2058	.2058	.2286
8		.1715	.5658	.6859
9		.1715	.724	.724
10		.4801	.7621	.8002
11		.6173	.7811	.7811
12		.7202	.8002	.7621
13		.7202	.8383	.8383
14		.7202	.8573	.8383
15		.6859	.7811	.8383
16		.1372	.1715	.1524
17		.1886	.1905	.1715
18		.2058	.2096	.1905
19		.2743	.3048	.1905
20		.2572	.2858	.1905
21		.2572	.2858	.1905
22		.2229	.2667	.1905
23		.2058	.2667	.1715
24	.4763	.1715	.2058	.2667
Max	.4763	.7202	.8573	.8383
Min	.4763	.1372	.1715	.1524
Avg	.4763	.3115	.3972	.4057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 202 / 11 kV MAJARI FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.4287	.4572
2		.3429	.4287	.4572
3		.3429	.3944	.4572
4		.3429	.3944	.4382
5		.3429	.3944	.4382
6		.3086	.3944	.4191
7		.3086	.3944	.4382
8		.6859	.8745	.724
9		.7716	1.0288	.8954
10		.8573	.8954	.9145
11		.823	.9526	.9526
12		.8745	1.0098	.8192
13		.8916	1.0098	.8192
14		.9088	.9907	.8383
15		.9431	1.0098	.8002
16		.2572	.3239	.1905
17		.3772	.362	.4001
18		.4458	.4382	.4191
19		.5316	.5525	.4763
20		.5144	.4954	.4763
21		.4973	.4954	.4954
22		.463	.4763	.4191
23		.4458	.4763	.4001
24	.4382	.3772	.4458	.4763
Max	.4382	.9431	1.0288	.9526
Min	.4382	.2572	.3239	.1905
Avg	.4382	.5415	.6111	.5676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 167016 / 132 KV AMBHORA

Feeder No / Name : 401 / 33 KV PACHKHEDI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.2808	2.0062	1.8204	1.7541
Max	3.2808	2.0062	1.8204	1.7541
Min	3.2808	2.0062	1.8204	1.7541
Avg	3.2808	2.0062	1.8204	1.7541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 167016 / 132 KV AMBHORA

Feeder No / Name : 402 / 33 KV LIS

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
24	.7956	2.6452	2.5652
Max	.7956	2.6452	2.5652
Min	.7956	2.6452	2.5652
Avg	.7956	2.6452	2.5652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 167016 / 132 KV AMBHORA

Feeder No / Name : 403 / 33KV LIS-II

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)
24	.4973	.0045
Max	.4973	.0045
Min	.4973	.0045
Avg	.4973	.0045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 167016 / 132 KV AMBHORA

Feeder No / Name : 404 / 33KV Kuhi feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1443	1.2894	2.1125	2.0622	2.2565	1.3969	1.4918
Max	1.1443	1.2894	2.1125	2.0622	2.2565	1.3969	1.4918
Min	1.1443	1.2894	2.1125	2.0622	2.2565	1.3969	1.4918
Avg	1.1443	1.2894	2.1125	2.0622	2.2565	1.3969	1.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 167016 / 132 KV AMBHORA

Feeder No / Name : 406 / 33 KV AMBHORA(XMER 4)  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.8871				
24	.8779	.9134	.8871	.9979	.7842	1.0082	.9134
Max	.8779	.9134	.8871	.9979	.7842	1.0082	.9134
Min	.8779	.9134	.8871	.9979	.7842	1.0082	.9134
Avg	.8779	.9134	.8871	.9979	.7842	1.0082	.9134



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 201 / 11 KV SIRSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2589		.2521	.2864	.2761	.2881	.3001
2	.2418		.2452	.2743	.2658	.2675	.2984
3	.2263		.2383	.2641	.2538	.2555	.2984
4	.3824	.487	.5281	.6327	.2092	.2195	.4081
5	.4132	.5127	.5676	.7253	.2143	.2418	.3789
6	.4904	.6087	.5984	.8779	.2349	.2966	.3481
7	.5624	.7047	.7322	1.0065	.2452	.3395	.3447
8	.6722	.9362	.9928	1.0288	.2915	.3669	.3584
9	.8522	1.1403	1.13	1.1334	.3155	.3138	.3309
10	.6464	.8505	1.106	1.0854	.3241	.2864	.2949
11	.7236	.8882	.9585	1.0014	.2486	.2383	.2675
12	.2349	.2366	.2898	.2898	.7785	.9071	.7699
13	.2435	.2538	.2469	.1286	1.2363	1.1471	.9722
14	.2332	.2692	.2435	.2383	1.3032	1.1471	1.0168
15	.2315	.156	.2418	.2212	1.2534	1.0477	.8402
16	.1852	.1612	.2521	.2315	1.1814	.9774	.8591
17	.2383	.1389	.2503	.2401	1.1145	1.0185	.787
18	.3429	.3155	.2915	.2761	.9328	.8402	.679
19	.5264	.5384	.5093	.4887	.8865	.8093	.6962
20	.583	.5676	.571	.5881	.5796	.5898	.631
21	.499	.5281	.5178	.5195	.5093	.5075	.583
22	.3704	.3738	.4012	.3841	.3961	.4235	.4492
23	.2778	.2846	.3086	.3206	.3344	.3224	.3687
24	.2743	.2606	.2761	.2966	.3001	.2898	.3018
Max	.8522	1.1403	1.13	1.1334	1.3032	1.1471	1.0168
Min	.1852	.1389	.2383	.1286	.2092	.2195	.2675
Avg	.4046	.4863	.4895	.5225	.5702	.5476	.5243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 202 / 11 kV Mahalgao

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1835	.18	.1783	.1903	.2126	.204	.204
2	.1749	.1766	.1749	.1852	.2023	.1938	.2006
3	.168	.1715	.1732	.1835	.1938	.1835	.1972
4	.132	.1372	.1286	.1303	.4715	.4938	.3738
5	.1389	.156	.1303	.1389	.5144	.559	.4715
6	.1698	.1818	.2006	.1835	.595	.6842	.5607
7	.1903	.2092	.2023	.2075	.6602	.7836	.6224
8	.2143	.8556	.2435	.2263	.7082	.8762	.8196
9	.2281	.2486	.1989	.216	.9139	1.0597	.9654
10	.1852	.2023	.2126	.1938	.9928	.9448	.8265
11	.1903	.1646	.1783	.2246	.8025	.8968	.7287
12	.8848	.8248	.7905	.8299	.0857	.168	.156
13	1.0202	1.1025	1.0665	1.1814	.1286	.1115	.1749
14	1.0099	1.0014	1.0374	1.1025	.1526	.1595	.132
15	.9774	1.0237	.9911	.9842	.156	.1886	.1492
16	.9431	.9722	.9054	.9482	.1972	.1595	.1475
17	.9139	.9379	.9019	.9534	.156	.1475	.1663
18	.7888	.775	.8076	.799	.2178	.2486	.2349
19	.7956	.775	.7922	.8042	.4612	.475	.4561
20	.4647	.4698	.4561	.4664	.4767	.475	.4733
21	.3824	.4235	.4098	.3978	.4098	.4047	.4252
22	.2761	.2846	.2829	.2984	.3086	.3069	.2949
23	.2006	.2126	.2143	.2332	.2726	.2366	.2349
24	.192	.1835	.2006	.1989	.2195	.2092	.2109
Max	1.0202	1.1025	1.0665	1.1814	.9928	1.0597	.9654
Min	.132	.1372	.1286	.1303	.0857	.1115	.132
Avg	.4510	.4862	.4532	.4699	.3962	.4238	.3844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 402 / 33KV INCOMER(sirsi Stn)

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.5144	.5144	.5298	.5658	.5658
2	.4733	.499	.499	.5144	.535	.5298
3	.4527	.4887	.4835	.499	.5041	.463
4	.7202	.8179	.8333	.499	.6584	.7922
5	.7819	.8488	.8951	.6379	.8179	.8693
6	.8951	.9465	.9979	1.07	.8848	.9671
7	.9774	1.0494	1.1111	1.3323	.9568	1.0905
8	1.0648	1.3323	1.4043	1.3992	1.0237	1.214
9	1.2551	1.4506	1.5226	1.5226	1.2088	1.3529
10	1.0905	1.2397	1.4815	1.4249	1.3014	1.2551
11	1.0288	1.1934	1.2757	1.358	1.0185	1.1574
12	1.07	.9928	.9774	1.034	.9568	1.1368
13	1.1523	1.3529	1.322	1.4352	1.5123	1.394
14	1.2551	1.2551	1.322	1.394	1.6101	1.4403
15	1.2243	1.2397	1.2654	1.2191	1.5895	1.394
16	1.214	1.1831	1.1626	1.1368	1.5072	1.2963
17	1.3992	1.1111	1.1934	1.1986	1.3992	1.3272
18	1.1163	1.0597	1.142	1.1677	1.3014	1.2551
19	1.3426	1.322	1.3169	1.3529	1.5278	
20	1.0545	1.0648	1.0237	1.034	1.0288	
21	.8642	.9619	.9259	.9362	.8951	
22	.6893	.6893	.715	.7407	.7253	
23	.5401	.571	.5658	.6533	.6636	
24	.5247	.5247	.5247	.5504	.5864	.5658
Max	1.3992	1.4506	1.5226	1.5226	1.6101	1.4403
Min	.4527	.4887	.4835	.499	.5041	.463
Avg	.9452	.9879	1.0198	1.0267	1.0324	1.0561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 201 / 11 kV Pachgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.3258	.3439	.362	.362	.3439	.1991
2	.2715	.3258	.3258	.3439	.3721	.3439	.1991
3	.2715	.3258	.3258	.3439	.362	.3439	.181
4	.2896	.3258	.3077	.2172	.2896	.3544	.181
5	.3258	.3258	.3258	.2172	.2715		.181
6	.362	.3982	.3801	.2353	.3258	.2658	.1991
7	.3801	.3982	.4163	.3439	.3982	.362	.2172
8	.3982	.4887	.4887	.4525	.4887	.5249	.2172
9	.4525	.4344	.4706	.543	.4887		.2353
10	.4344	.3982	.4163	.4887	.5792	.4525	.2172
11	.2896	.2896	.362	.4706	.5249	.3982	.2172
12	.2534	.362	.362	.2896	.2534	.1991	
13	.5792	.543	.5249		.3258	.181	
14	.6516	.5249	.4706	.3258	.2896		
15	.5792	.4706	.4887	.2715	.3077	.181	.4706
16	.5611	.5068	.4706	.2715	.2715	.1629	.5611
17	.543	.4706	.2715	.3077	.3077	.1629	.5068
18	.4344	.4163	.3982	.3982	.3801	.2172	.4706
19	.4344	.4525	.4163	.5611	.5249	.2715	.4163
20	.5068	.5249	.5068	.5611	.5249	.2896	.3982
21	.5068	.5068	.5068	.543	.5068	.2896	.3801
22	.4163	.4163	.4525	.4887	.4163	.2353	.362
23	.362	.362	.3801	.4163	.3801	.2172	.3439
24	.9907	.362	.3439	.362	.3801	.362	.1991
Max	.9907	.543	.5249	.5611	.5792	.5249	.5611
Min	.2534	.2896	.2715	.2172	.2534	.1629	.181
Avg	.4410	.4148	.4065	.3832	.3888	.2933	.3025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 202 / 11 kV Surgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.3395	.3395	.3584	.3721	.3961	.3772
2	.3189	.3395	.3395	.3395	.362	.3772	.3772
3	.3258	.3395	.3206	.3584	.3772	.3772	.3584
4	.6602	.6036	.4527	.3584	.3961	.3772	.3772
5	.6602	.6413	.5847	.3772		.3772	.3772
6	.679	.679	.7167	.3772		.415	.3772
7	.8299	.811	.8488	.3584	.3772	.3395	.3772
8	1.1694	1.3957	1.226	.3584	.3206	.3206	.3584
9	1.3575	1.3203	1.3957	.3395	.3258		.3584
10	1.3575	1.3769	1.4901	.3206	.6036	.3206	.3206
11	1.2449	1.2826	1.2826	.2658	.2829	.3018	.2829
12	.2829	.2452	.2641	.9619	.8865	.9054	.8676
13	.2829	.2452	.2829		.9808	1.2637	1.094
14	.2829	.2641	.2641	1.1403		1.3014	1.0562
15	.2641	.2263	.2641	1.1946	1.3014	1.2826	.9619
16	.3018	.2452	.2641	1.3394	1.1883	1.2449	.9054
17	.2829	.2452	.3206	1.1694	1.1506	1.1317	.9619
18	.4338	.415	.3584	.9568	1.0374	.9997	.8676
19	.5658	.5658	.5281	1.0185	.8299	.9088	.7922
20	.547	.547	.5281	.5847	.5281	.547	.547
21	.5281	.5281	.5281	.5249	.5281	.547	.5281
22	.415	.3961	.4527	.4904	.4338	.4527	.4527
23	.3772	.3584	.3772	.4527	.3961	.3961	.415
24	.3584	.3584	.3395	.3772	.3961	.3772	.3584
Max	1.3575	1.3957	1.4901	1.3394	1.3014	1.3014	1.094
Min	.2641	.2263	.2641	.2658	.2829	.3018	.2829
Avg	.5776	.5737	.5737	.6097	.6226	.6505	.5729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 203 / 11 KV Jassal Industrial      NON SHEDDABLE EXPRESS HV FEEDERS  
 champa Feeder KV- 11 / OUTGOING      (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0187	.0189	.0072	.0122	.0143	.0175
2	.0191	.0183	.0183	.013	.0061	.0143	.0173
3	.0105	.0187	.0191	.013	.0059	.0147	.0177
4	.0189	.0181	.0191	.0074	.0057	.0135	.0179
5	.0173	.0181	.0189	.0057	.0065	.0177	.0181
6	.0185	.0179	.0173	.0057	.0046	.0177	.0181
7	.0185	.0181	.0166	.0059	.0084	.0179	.0185
8	.0187	.0183	.0183	.0053	.0069	.0175	.0177
9	.0191	.0189	.0185	.0259	.0183	.0189	.0173
10	.0124	.0179	.0278	.0141	.0248	.0141	.0179
11	.0185	.021	.0164	.0105	.0118	.0109	.0183
12	.0181	.0332	.0236	.0244	.0168	.0293	.0187
13	.0126	.0088	.0244		.021	.0316	.0183
14	.0111	.0236	.0351	.0164	.0065	.0263	.0173
15	.0168	.0229	.016	.0305	.0168	.0175	.0183
16	.0206	.0183	.0198	.021	.0187	.0305	.0181
17	.0206	.0351	.0244	.021	.0232	.0156	.0183
18	.0191	.0187	.0225	.0156	.0171	.0377	.0185
19	.0187	.0373	.0171		.0179	.0189	.0189
20	.0187	.0187	.013	.0168	.0181	.0181	.0185
21	.0187	.0316	.0084	.0381	.0175	.0189	.0187
22	.0185	.0377	.0137	.0097	.0185	.0189	.0187
23	.0187	.0183	.016	.0095	.0181	.0189	.0185
24	.0191	.0187	.0189	.0091	.009	.0149	.0177
Max	.0206	.0377	.0351	.0381	.0248	.0377	.0189
Min	.0019	.0088	.0084	.0053	.0046	.0109	.0173
Avg	.0169	.0220	.0193	.0148	.0138	.0195	.0181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 204 / 11 KV CHAMPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1949	.2126	.2126	.2534	.2303	.2481
2	.2126	.1949	.2126	.2126	.2353	.2303	.2481
3	.2126	.1949	.2126	.1949	.2353	.2303	.2303
4	.2126	.2126	.2126	.1772	.5316	.3544	.2303
5	.2303	.2126	.2126	.1772	.5316	.4252	.2481
6	.2658	.2126	.1772	.2126	.5493	.6024	.2658
7	.2835	.2126	.1949	.2126	.6201	.6733	.2481
8	.2481	.1595	.2303	.815	.8328	.9036	.2303
9	.2835	.2263	.1949	1.0277	.9745		.2658
10	.2126	.2126	.2481	1.0808	.9745	.8859	.2303
11	.2303	.2263	.2481	.8505	.9568	.8328	.1949
12	.6201	.7796	.8328	.8859	.2126	.7265	
13		1.1883	.691		.2452	.7087	
14		1.0751	1.1163	.6733	.2641	.2481	
15	1.258	1.226	1.0808	.724	.2829	.2303	.8328
16	.8859	1.1163	1.0985	.2353	.2641	.2658	.9922
17	1.2403	1.1517	1.0985	.2103	.2481	.2658	1.0099
18	1.0808	1.0751	.8859	.2896	.3721	.3189	.9036
19	.9036	1.0374	.8682	.3898	.3721	.4075	.9054
20	.7087	.3772	.3366	.4075	.3898	.3721	.815
21	.7619	.3206	.3012	.3721	.3366	.2643	.7442
22	.2303	.2641	.2658	.3189	.2658	.2835	.691
23	.2126	.2303	.2303	.2835	.2481	.2481	.6556
24	.362	.1949	.2126	.2126	.2481	.2303	.2481
Max	1.258	1.226	1.1163	1.0808	.9745	.9036	1.0099
Min	.2126	.1595	.1772	.1772	.2126	.2303	.1949
Avg	.4942	.5124	.4740	.4425	.4352	.4321	.4970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 205 / 11 KV PACHGAON II  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.0669	1.1694	1.1812	1.0185	1.2193	1.2449
2	1.1694	1.0669	1.2637	1.2574	.9619	1.2193	1.226
3	1.094	1.0288	1.2637	1.1431	1.1506	1.1812	1.2071
4	1.094	.9997	1.2449	1.3717	1.1317	1.2449	1.226
5	1.1317	.9997	1.226	1.3336	1.3203	1.3203	1.2071
6	1.1694	1.094	1.226	1.3717	1.4146	1.5466	1.3014
7	1.4146	1.2449	1.0562	1.2955	1.773	1.2449	1.4523
8	1.7918	1.848	2.1125	1.9624	1.9805	1.6409	1.3014
9	2.1691	2.3577	2.7349	2.0195	2.452	1.9616	1.2826
10	2.3577	2.915	2.3577	2.7054	2.1691	2.8578	1.4523
11	2.5274	3.1121	3.0178	2.6972	2.7726	2.8104	1.358
12	2.7161	3.0178	2.5274	2.0005	2.5274	2.8292	1.5623
13	2.3765	2.7538	2.7054		2.3954	2.6783	1.7353
14	2.4768	1.7556	2.4577	2.2068		1.9239	1.3908
15	2.3577	2.3285	2.934	2.6406	2.1502	2.3011	1.2193
16	2.452	2.3765	3.2388	2.452	2.5274	2.8669	1.3336
17	2.3765	2.7349	2.2481	2.452	2.7726	2.9047	1.3146
18	1.2574	2.0144	2.8959	1.9805	2.452	2.8292	1.2574
19	1.3203	1.4712	1.2193	1.2193	1.1883	1.2449	1.3336
20	1.2637	1.2449	1.2955	1.2574	1.1317	1.3203	1.3527
21	1.3203	1.2826	1.3146	1.2637	1.3203	1.3203	1.3146
22	1.1317	1.2449	1.3908	1.2574	1.1694	1.2449	1.2765
23	1.1128	1.1883	1.3336	1.2384	1.1317	1.2826	1.2765
24	1.1883	1.1241	1.1506	1.3336	1.1694	1.3336	1.2449
Max	2.7161	3.1121	3.2388	2.7054	2.7726	2.9047	1.7353
Min	1.0185	.9997	1.0562	1.1431	.9619	1.1812	1.2071
Avg	1.6787	1.7613	1.8910	1.7235	1.7426	1.8470	1.3280



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 206 / 11 KV CHAMPA II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	1.2071	1.094	.9431	1.3392	1.4523	1.2637
2	.8676	1.2071	1.0562	1.0185	1.3014	1.358	1.2826
3	.8299	1.1694	1.2826	.9808	1.226	1.358	1.2826
4	.9431	1.226	1.2449	1.0562	1.2826	1.5089	1.2637
5	.9054	1.1883	1.2071	.9619	1.2826	1.5089	1.226
6	1.094	1.1506	1.1506	1.3203	1.4712	1.6598	1.2449
7	1.2071	1.1883	.9431	1.0751	1.3014	1.3392	1.2449
8	1.4523	1.2449	1.1317	1.2449	1.3769	1.6975	1.0185
9	1.2826	1.9616	1.9427	1.9427	1.7353	2.2257	1.358
10	1.9805	2.6406	1.9616	2.1879	1.8296	2.8104	1.4712
11	2.0559	2.9424	1.9993	2.6595	1.7164	2.9047	1.3203
12	2.452	2.1338	2.584	2.6029	2.7726	3.7912	1.4523
13	1.5089	2.3011	2.7915		2.32	2.5274	1.2449
14		2.3388	1.3957	2.1125		2.1502	1.2449
15	2.6972	2.5274	2.2068	2.452	3.0367	3.263	1.1694
16	2.9424	1.5089	3.0933	2.8292	2.8858	3.7157	1.1128
17	1.3203	2.6406	1.5844	2.6029	2.5086	3.131	1.0751
18	2.0936	2.0748	2.2822	2.0748	2.6972	2.9235	1.1317
19	1.1317	1.4146	1.6598	1.8296	1.5844	1.4523	1.1506
20	1.226	1.2449	.9997	1.2826	1.4146	1.094	1.1128
21	1.2449	1.1694	1.1883	1.3957	1.358	1.3203	1.1317
22	1.2071	1.0751	1.1883	1.226	1.358	1.358	1.1506
23	1.2071	1.2637	1.0751	1.3769	1.4335	1.4712	1.1883
24	.9054	1.1317	1.358	1.0374	1.1694	1.3957	1.3203
Max	2.9424	2.9424	3.0933	2.8292	3.0367	3.7912	1.4712
Min	.8299	1.0751	.9431	.9431	1.1694	1.094	1.0185
Avg	1.4532	1.6646	1.6009	1.6615	1.7566	2.0590	1.2276

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 207 / 11KV Anand Mohta

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0953	.1715	.2858	.2477	.2477	.1715
2	.0381	.0953	.1715	.2286	.2667	.2477	.1715
3	.0381	.0953	.1715	.1905	.2477	.2667	.1905
4	.0381	.0762	.1905	.2286	.2829	.2477	.1905
5	.0381	.0953	.2286	.2096	.2667	.2667	.1905
6	.0381	.0953	.2286	.2477	.2641	.2667	.1905
7	.0381	.1143	.2477	.2477	.2286	.1905	.1905
8	.0381	.1715	.2286	.1715	.2477	.2286	.1715
9	.0762	.1715	.2286	.2667	.2286	.3048	.1715
10	.0762	.1334	.2286	.1905	.2286	.2477	.1334
11	.0572	.1524	.2286	.2096	.2096	.2667	.1524
12	.0572	.2096	.2477	.2477	.2477	.2858	.1524
13	.0572	.2096	.2286		.2286	.2667	.1524
14	.0572	.2286	.2096	.2667		.2477	.1524
15	.0572	.2096	.2286		.2667	.2477	.1524
16	.0572	.2477	.2096	.3048	.2477	.2858	.1715
17	.0381	.2477	.2477	.2477	.2858	.2477	.1715
18	.0191	.2096	.2667	.2667	.2858	.2096	.1715
19	.1143	.2096	.2477	.2858	.2286	.1905	.1715
20	.1143	.2096	.2477	.2667	.2286	.1905	.1715
21	.1143	.2286	.2477	.2667	.2286	.1715	.1715
22	.1143	.2286	.2477	.2477	.2286	.1715	.1524
23	.0953	.2286	.2667	.2858	.2477	.1905	.1715
24	.0381	.0953	.1715	.2667	.2858	.2858	.1524
Max	.1143	.2477	.2667	.3048	.2858	.3048	.1905
Min	.0191	.0762	.1715	.1715	.2096	.1715	.1334
Avg	.0603	.1691	.2247	.2468	.2491	.2405	.1683

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 403 / 33KV DONGARGAO(KUHI SDN)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.3086		
8	1.0802	1.0442	1.0059		.9774	.9602	1.0751
9	1.2717	1.17	1.0751	1.1305	1.0802	1.2574	1.0202
10	1.386	1.0174	1.0802	1.094	1.1831	1.0059	1.0202
11	1.1568	1.1191	1.1065	1.2071	1.1831	1.1191	.9717
12	1.1568	1.0562	1.1934		.9774	1.17	1.1065
13	1.1065	1.0814	1.2146		1.4918	1.2431	.9231
14	1.0322	1.17	1.2146	1.1831		1.2431	.8745
15	1.0682	1.0562	1.1934	1.3032		1.0174	.6642
18				.4115			
19	.4527	.5093	.5093	.4784	.4527	.4527	.4527
20	.4527	.5093	.4527	.4938	.5658	.5093	.4527
21	.3961	.3761	.4527	.4435	.4527	.3961	.3961
22		.3395	.3395	.3641	.3395	.3395	.3395
24	.6859						
Max	1.386	1.17	1.2146	1.3032	1.4918	1.2574	1.1065
Min	.3961	.3395	.3395	.3641	.3086	.3395	.3395
Avg	.9372	.8707	.9032	.8109	.8193	.8928	.7747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 405 / 33 kv Vidhi alloy pvt ltd. NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	1.6975	1.5844	1.6409		1.8107	1.8673
2	1.1317	1.6975	1.6409	1.7541		1.8107	1.8673
3	1.2449	1.7541	1.5844	1.6975		1.7541	1.7541
4	1.5844	1.8107	1.6409	1.7541		1.6975	1.8107
5	1.4712	1.6975	1.6975	1.6975		1.8107	1.7541
6	1.5844	1.6975	1.7541	1.8673		1.6975	1.6975
7	1.8107	1.5844	1.7541	1.8107		1.5278	1.6975
8	2.037	1.9239	1.0751	1.6975		1.5844	1.6975
9	1.6975	1.9239	1.7541	1.7541		1.5844	1.0185
10	1.6975	2.037	1.9239	1.7541		1.6409	1.8107
11	1.8107	2.037	1.9239	1.7541		1.8673	1.8673
12	1.6409	1.5089	1.8673	1.5844		1.8673	1.7541
13	1.8107	1.7541	1.8673			1.9239	1.8673
14	1.6975	2.037	1.9805			1.6975	1.6975
15	1.7541	1.7541	1.9805			1.4712	1.8673
16	1.9239	1.8673	1.9805			1.6975	1.6409
17	1.8107	1.4712	2.037			2.037	1.8107
18	1.8107	2.037	1.9239			1.6975	1.7541
19	1.8107	1.6975	1.9805	1.5844	.8488	1.5844	1.6975
20	1.9239	1.5844	1.8107		1.1317	1.1317	1.6409
21	1.6975	1.5844	1.6975		1.6975	1.6975	1.5844
22	1.8673	1.6409	1.8673		1.8107	1.5844	1.8107
23	1.7541	1.7541	1.7541		1.6975	1.9239	1.6975
24	.6859	1.6975	1.5844	1.6975		1.4712	1.8107
Max	2.037	2.037	2.037	1.8673	1.8107	2.037	1.8673
Min	.6859	1.4712	1.0751	1.5844	.8488	1.1317	1.0185
Avg	1.6294	1.7604	1.7777	1.7177	1.4372	1.6905	1.7282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 201 / 11 KV BELA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3814	.4525	.4706	.4656	.4334	.4656	.5973
2	.3641	.4344	.4525	.4477	.4334	.4835	.5068
3	.3467	.4344	.4525	.5014	.4334	.4656	.4706
4	.3294	.4163	.4344	.6268			
5	.3641	.4163	.4525	.5014			
6	.4161	.5068	.5792	.4835			
7	.5201	.5973	.6335	.591			
8	.6068	.6154	.5973	.591			
9	.6588	.6154	.543	.6268			
10	.5375	.6335	.5373	.6626			
11	.5068	.543	.5373	.6588			
12					.5014	.5068	.3988
13					.4477	.4525	.3641
14					.4298	.5068	
15					.4119	.5249	
16					.4119	.4344	
17					.4477	.5068	
18					.6626	.6697	.6068
19					.8954	.9412	.7802
20		.8326	.8596	.8149	.8954	.9774	.8495
21		.7682	.788	.7108	.788	.7602	.7975
22		.5792	.6447	.5895		.7059	.6415
23	.5068	.4887	.4835	.5028	.5373	.6516	.5375
24	.3988	.4525	.4706		.4334	.5014	.6154
Max	.6588	.8326	.8596	.8149	.8954	.9774	.8495
Min	.3294	.4163	.4344	.4477	.4119	.4344	.3641
Avg	.4567	.5492	.5585	.5850	.5442	.5971	.5972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 202 / 11 KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.362	.362	.3224	.3222	.3582	.4163
2	.2883	.3258	.3439	.3224	.3222	.3582	.3982
3	.2713	.3077	.3439	.3403	.3222	.3403	.362
4	.2543	.3077	.3439	.4119	.7461	.8238	.8326
5	.3052	.3439	.362	.3761	.78	.8954	.9412
6	.3391	.3801	.4163	.394	.8648	.9313	1.0136
7	.4239	.4207	.4525	.4119	1.0852	1.182	1.2127
8	.407	.4344	.3801	.4477	1.2209	1.4864	1.3394
9	.3561	.4163	.3801	.394		1.6476	1.6651
10	.3222	.362	.3224	.2507		1.5402	1.448
11	.2534	.181	.2865	.2204	1.3969	1.1946	1.2548
12	1.2308	1.267	1.1999	1.0682	.2149	.1991	.1865
13	1.6289	1.8656	1.6476	1.56	.2149	.181	.2035
14	1.5927	1.7918	1.6834	1.3904	.197	.5068	
15	.2896	1.5384	1.3611	1.3565	.2328	.1991	
16	.2896	1.6289	1.6834	1.4074	.2328	.2353	
17	.2896	1.5565	1.5927	1.3565	.2507	.2353	
18	1.4842	1.3756	1.3611	1.2378	.4119	.4525	.39
19	1.4842	1.4118	1.3969	1.1869	.788	.7602	.7461
20	1.3756	.7421	.7343	.6952	.788	.7783	.7291
21	1.2127	.6878	.6268	.6274	.6805	.6516	.6613
22	1.0498	.4525	.5014	.4748		.543	.5256
23	.3801	.3801	.3582	.373	.4119	.4887	.407
24	.3222	.362	.362		.3391	.3761	.4525
Max	1.6289	1.8656	1.6834	1.56	1.3969	1.6476	1.6651
Min	.2534	.181	.2865	.2204	.197	.181	.1865
Avg	.6732	.7876	.7709	.7229	.563	.6819	.7593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 203 / 11 KV Daheli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2896	.3258	.2686	.3048	.2507	.3077
2	.2667	.2715	.3258	.2686	.2858	.2507	.2896
3	.2667	.2715	.3077	.2865	.2858	.2686	.2715
4	.2477	.2534	.3077	.3582	.2286	.2328	.1448
5	.2858	.2534	.3258	.3224	.2667	.2865	.1612
6	.2858	.2743	.3439	.3045	.362	.3224	.2328
7	.2858	.2896	.3077	.3045	.5335	.3582	.3224
8	.2667	.2896	.2896	.3045	.5716	.394	.4298
9	.2477	.2715	.2353	.2865		.5552	.4706
10	.2477	.2534	.2149	.2507		.6268	.4835
11	.1991	.1629	.2328	.2286	.591	.5194	.5335
12	.2865	.4706	.4119	.4954	.1791	.181	.1334
13	.591	.6036	.6447	.724	.1791	.181	.1334
14	.8059	.6335	.591	.6287	.1791	.2172	
15	.4344	.6516	.6268	.6478	.197	.2172	
16	.394	.5973	.3582	.7049	.1791	.1991	
17	.7343	.362	.4835	.6478	.1791	.181	
18	.5552	.4706	.4298	.5335	.2865	.3077	.2858
19	.4656	.4163	.394	.4954	.5304	.5068	.5716
20	.4656	.5304	.5373	.5335	.5194	.5249	.5716
21	1.6834	.4887	.4835	.4954	.4835	.4525	.4954
22	.3224	.3801	.3761	.4001		.3801	.381
23	.3077	.3258	.2865	.3239	.3045	.362	.3429
24	.2286	.2896	.3258		.3048	.2865	.3258
Max	1.6834	.6516	.6447	.724	.591	.6268	.5716
Min	.1991	.1629	.2149	.2286	.1791	.181	.1334
Avg	.4233	.3792	.3819	.4267	.3310	.3359	.3444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 401 / 33 KV PURTI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0549	.0549	.0549	.0566	.0549	.0549
2	.0566	.0549	.0549	.0549	.0566	.0549	.0549
3	.0566	.0549	.0549	.0549	.0566	.0549	.0549
4	.0566	.0549	.0549	.0549	.0566	.0549	.0549
5	.0566	.0549	.0549	.0549	.0566	.0549	.0549
6	.0566	.0549	.0549	.0549	.0566	.0549	.0549
7	.0566	.0549	.0549	.0549	.0566	.0549	.0549
8	.0566	.0549	.0549	.0549	.0566	.0549	.0549
9	.0566	.0549	.0549	.0549		.0549	.0549
10	.0566	.0549	.0549	.0549		.0549	.0549
11		.0549	.0549	.0566	.0549	.0549	.0566
12	.0549	.0549	.0549	.0566	.0549	.0549	.0566
13	.0549	.0549	.0549	.0566	.0549	.0549	.0566
14	.0549	.0549	.0549	.0566	.0549	.0549	.0566
15	.0549	.0549	.0549	.0566	.0549	.0549	.0566
16	.0549	.0549	.0549	.0566	.0549	.0549	.0566
17	.0549	.0549	.0549	.0566	.0549	.0549	.0566
18	.0549	.0549	.0549	.0566	.0549	.0549	.0566
19	.0549	.0543	.0549	.0566	.0549	.0549	.0566
20	.0549	.0549	.0549	.0566	.0549	.0549	.0566
21	.0549	.0549	.0549	.0566	.0549	.0549	.0566
22	.0549	.0549	.0549	.0566		.0549	.0566
23	.0549	.0549	.0549	.0566	.0549		.0566
24	.0566	.0549	.0549		.0566	.0549	.0549
Max	.0566	.0549	.0549	.0566	.0566	.0549	.0566
Min	.0549	.0543	.0549	.0549	.0549	.0549	.0549
Avg	.0557	.0549	.0549	.0559	.0556	.0549	.0558



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 402 / 33KV INCOMER(Bela)

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4938	.4938	.4938	.5041		.5487
2	.5041	.4938	.4938	.4938	.5041		.5487
3	.5041	.4938	.4938	.4938	.5041		.4938
4	1.1203	.8779	1.2071		1.2883	.9877	.9877
5	1.2323	1.1523	1.262		1.4563	1.0974	1.5364
6	1.2323	1.4815	1.3717		1.7924	1.4266	1.7558
7	1.2883	1.4815	1.3717		2.2405	1.6461	2.0302
8	1.4563	1.5912	1.5364		2.4646	1.9204	2.3594
9	1.6244	1.5912	1.5912			3.0178	2.963
10	1.4003	1.4266	1.4815			3.0178	2.4143
11	1.262	1.3717	1.4266		2.6886	2.4143	2.1948
12	2.3594	2.8532	2.1399		.823	1.3717	.4938
13	2.963	3.4568	3.0727		1.6461	1.5364	.5487
14	3.1824	3.4019	3.1824	2.1845	1.6461	1.6461	
15	1.5364	3.0178	2.9081	2.1845	1.5364	1.5364	
16	1.7558	3.0727	3.0178	2.2405	1.5912	1.5912	
17	1.7558	2.7435	2.963	2.1285	1.4815	1.5912	
18	2.8532	2.6337	2.5789	2.4086	1.5364	1.5912	.9328
19	2.8532	2.6886	2.6886	2.4086	1.8107	1.6461	.8779
20	2.0302	.823	.8779	.8402	.823	1.7558	.9328
21	1.7558	.7682	.823	.7842		1.701	.823
22	1.4815	.6584	.7133	.6722		.7133	.7133
23	.5487	.5487	.5487	.5601		.6516	.6584
24	.5601	.5487	.5487		.5601		.6036
Max	3.1824	3.4568	3.1824	2.4086	2.6886	3.0178	2.963
Min	.5041	.4938	.4938	.4938	.5041	.6516	.4938
Avg	1.5758	1.6529	1.6164	1.3764	1.4157	1.6430	1.2209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 801 / 400KV Ideal Power Bela  
Feeder KV- 400 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18
HR	Load (MW)
24	1.3856
Max	1.3856
Min	1.3856
Avg	1.3856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 201 / 11 KV SIRPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844	.1638	.1543	.1844	.176	.1715	.1844
2	.1844	.1638	.1543	.1844	.176	.1715	.1844
3	.1677	.1638	.1543	.1677	.176	.1715	.1844
4	.1677	.1475	.1543	.1677	.16	.1715	.1677
5	.1677	.1475	.1543	.1677	.16	.1715	.1677
6	.1677	.1638	.1715	.1677	.176	.1715	.1677
7	.1844	.1638	.1715	.1844	.144	.1886	.1677
8	.1677	.1638	.1715	.1509	.16	.1715	.1677
9	.1509	.1475	.1677	.1174	.144	.1677	.1677
10	.1475	.1543	.1943	.3201	.3944	.3725	.3163
11	.1311	.1543	.2881	.3681	.463	.421	.2688
12	.4096	.1715	.096	.4641	.4458	.4372	.3005
13	.4588	.4801	.4641	.4801	.4115	.4049	.1898
14	.5079	.4287	.4696	.4481	.3429	.3563	.2846
15	.4915	.3258	.4481	.4321	.3086	.3563	.2846
16	.4915	.3772	.4001	.4161	.3258	.3239	.2688
17	.4752	.4115	.4641	.3841	.3429	.3401	.253
18	.426	.3772	.1677	.176	.1886	.1341	.1739
19	.3441	.3772	.3018	.3041	.2743	.3185	.3163
20	.3113	.3258	.3353	.2881	.3429	.3185	.3005
21	.2622	.2915	.3018	.2721	.3086	.3185	.2846
22	.2294	.2572	.2515	.2241	.2572	.2515	.2214
23	.1966	.1715	.1844	.176	.2058	.2012	.1898
24	.1844	.1638	.1715	.1844	.176	.1886	.1844
Max	.5079	.4801	.4696	.4801	.463	.4372	.3163
Min	.1311	.1475	.096	.1174	.144	.1341	.1677
Avg	.2754	.2455	.2497	.2679	.2608	.2625	.2249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 202 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0351	.0358	.0514	.0347	.0358	.0343
2	.0514	.0347	.0358	.0514	.0347	.0358	.0343
3	.0503	.0347	.0358	.0514	.0347	.0358	.0343
4	.0514	.0347	.0358	.0343	.0347	.0358	.0343
5	.0514	.0347	.0358	.0343	.0347	.0358	.0343
6	.0514	.0347	.0358	.0343	.0347	.0358	.0343
7	.0514	.0351	.0358	.0343	.0347	.0358	.0343
8	.0514	.0351	.0358	.0343	.0347	.0358	.0343
9	.0514	.0351	.0343	.0343	.0347	.0343	.0694
10	.0377	.0358	.1715	.156	.1612	.1543	.312
11	.0377	.0358	.1907	.1387	.2149	.1715	.3468
12	.0754	.1433	.2254	.1753	.197	.2058	.3814
13	.0754	.2686	.2572	.2454	.1791	.1907	.3814
14	.0943	.2686	.2572	.2279	.197	.208	.3814
15	.3018	.2507	.2572	.2279	.2149	.2427	.3814
16	.3018	.2686	.2401	.2279	.2149	.2254	.3814
17	.2829	.2865	.2572	.1928	.2149	.208	.3468
18	.2641	.2865	.0514	.0351	.0358	.052	.0694
19	.2452	.2686	.0857	.0351	.0358	.0867	.0347
20	.0377	.0358	.0857	.0351	.0358	.0857	.0347
21	.0566	.0358	.0686	.0351	.0358	.0686	.0347
22	.0377	.0358	.0686	.0347	.0358	.0686	.0347
23	.0377	.0358	.0514	.0347	.0358	.0686	.0347
24	.0514	.0351	.0358	.0514	.0351	.0358	.0514
Max	.3018	.2865	.2572	.2454	.2149	.2427	.3814
Min	.0377	.0347	.0343	.0343	.0347	.0343	.0343
Avg	.1	.1086	.1094	.0922	.0898	.0997	.1479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 203 / 11 KV DAWWA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1372	.1543	.1696	.1715	.1715	.1526
2	.1696	.1372	.1543	.1526	.1715	.1715	.1526
3	.1696	.1372	.1543	.1526	.1715	.1715	.1526
4	.1526	.1372	.1543	.1357	.1543	.1715	.1526
5	.1526	.1372	.1543	.1357	.1543	.1372	.1357
6	.1696	.1543	.1715	.1526	.1886	.1715	.1357
7	.1696	.1372	.1715		.1372	.1715	.1357
8	.1187	.12	.1715	.1187	.12	.1543	.1357
9	.1187	.0857	.1696	.0848	.12	.1696	.1357
10	.1029	.1029	.2683	.3258	.3944	.4239	.3772
11	.1029	.1029	.3222	.3429	.4458	.407	.1886
12	.3429	.2743	.3561	.4287	.4287	.373	.3258
13	.4115	.5316	.2035	.4801	.3944	.373	.3086
14	.5144	.5144	.4748	.3944	.3429	.3391	.3258
15	.463	.3601	.39	.4115	.3258	.3561	.3429
16	.463	.4287	.39	.463	.3601	.3561	.3429
17	.463	.4458	.3391	.4115	.3772	.3561	.2743
18	.4115	.3944	.1017	.1372	.12	.1017	.1543
19	.3772	.3429	.2713	.2743	.2572	.2543	.2743
20	.2743	.2572	.2713	.2743	.2865	.2543	.2572
21	.2401	.2572	.2374	.2572	.2507	.2543	.2401
22	.1886	.2229	.2035	.2058	.2058	.2035	.2058
23	.1715	.1715	.1696		.1715	.1526	.1715
24	.1696	.1372	.1543	.1696	.1715	.1715	.1526
Max	.5144	.5316	.4748	.4801	.4458	.4239	.3772
Min	.1029	.0857	.1017	.0848	.12	.1017	.1357
Avg	.2536	.2386	.2337	.2581	.2467	.2444	.2180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 204 / 11KV MIDC Water Works  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.029	.029	.0269	.029	.029	.0287	.009
2	.029	.029	.0269	.029	.029	.0287	.009
3	.029	.029	.009	.029	.029	.0287	.009
4	.029	.029	.0082	.029	.029	.0287	.029
5	.029	.029	.0161	.029	.029	.0287	.0299
6	.029	.029	.0269	.029	.029	.0287	.029
7	.029	.0308	.0287	.029	.0308	.0304	.029
8	.029	.0308	.0304	.0308	.0308	.0287	.0308
9	.029	.0308	.0308	.029	.0308	.0308	.009
10	.0308	.0287	.0308	.0308	.0304	.0308	.0308
11	.0308	.0304	.0308	.0308	.009	.0308	.0308
12	.0308	.0304	.0308	.0326	.0304	.0308	.0308
13	.0308	.0304	.0308	.0326	.0304	.0308	.0308
14	.0308	.0304	.0308	.0326	.0304	.0308	.0308
15	.0308	.0304	.0308	.0308	.0304	.0308	.0308
16	.0308	.0304	.0308	.0308	.0304	.0308	.0308
17	.0308	.0304	.0308	.0308	.0304	.0308	.0308
18	.0308	.0322	.029	.0308	.0287	.0308	.0308
19	.0308	.0291	.029	.0308	.0287	.029	.0308
20	.029	.0287	.029	.029	.0287	.029	.029
21	.0308	.0287	.029	.029	.0287	.029	.029
22	.029	.0287	.029	.029	.0287	.029	.029
23	.029	.0287	.029	.029	.0287	.029	.009
24	.009	.009	.0287	.029	.029	.0287	.0299
Max	.0308	.0322	.0308	.0326	.0308	.0308	.0308
Min	.009	.009	.0082	.029	.009	.0287	.009
Avg	.0290	.0289	.0272	.0301	.0287	.0297	.0257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 205 / MIDC OLD WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0088	.007	.0082	.009	.0073	.0082	.009
2	.007	.007		.0072	.0073	.0082	.0072
3	.007	.007	.0082	.0072	.0073	.0082	.0072
4	.007	.007	.0082	.0072	.0073	.0082	.0072
5	.0088	.007	.0082	.009	.0073	.0082	.0072
6	.009	.007	.0082	.009	.0073	.0082	.009
7	.0088	.007	.0082	.009	.0073	.0082	.009
8	.0088	.007	.0082	.009	.0073	.0819	.009
9	.0088	.007	.0088	.009	.0073	.009	.009
10	.007	.0082	.0088	.0073	.0082	.009	.0072
11	.007	.0082	.0088	.0073	.0082	.009	.0072
12	.007	.0082	.0088	.0073	.0082	.009	.0072
13	.007		.0088	.0073	.0082	.009	.0072
14	.007	.3932	.0088	.0073	.2949	.009	.0072
15	.007	.3605	.0088	.0073	.0082	.009	.0072
16	.007	.0082	.0088	.0073	.0082	.009	.0072
17	.007	.0082	.009	.007	.0082	.009	.0072
18	.007	.0082	.009	.0073	.0082	.009	.0072
19	.007	.0082	.009	.0073	.0082	.009	.0072
20	.007	.0082	.009	.007	.0082	.009	.0072
21	.007	.0082	.009	.0073	.0082	.009	.0072
22	.007	.0082	.009	.0073	.0082	.009	.0072
23	.007	.0082	.009	.0073	.0082	.009	.0072
24	.009	.007	.0082	.009	.0073	.0082	.009
Max	.009	.3932	.009	.009	.2949	.0819	.009
Min	.007	.007	.0082	.007	.0073	.0082	.0072
Avg	.0075	.0397	.0087	.0078	.0198	.0118	.0077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 206 / 11KV GAOTHAN MAKARDHOKDA

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.072	.072	.0652	.0706	.076	.0772	.0933
2	.0686	.072	.0652	.0706	.0724	.0772	.0914
3	.0703	.0703	.0652	.0688	.0706	.0772	.0924
4	.0857	.0686	.0623	.0724	.0706	.0772	.0887
5	.0892	.0703	.0617	.076	.0742	.0737	.0869
6	.0926	.0806	.0857	.0833	.1104	.0943	.0924
7	.0995	.0909	.108	.1086	.1032	.1063	.1158
8	.1115	.1046	.0977	.1158	.0977	.108	.1122
9	.0892	.084	.0977	.1158	.0977	.0814	.1032
10	.0703	.1252	.1132	.1158	.0999	.1014	.0778
11	.0703	.12	.0923	.0959	.1046	.1231	.076
12	.0806	.0943	.0905	.1068	.1029	.105	.0833
13		.1115	.0869	.0923	.0977	.1003	.0796
14		.1029	.0977	.0995	.0857		.0814
15	.0995	.0806	.0851	.0941	.0652	.0894	.0941
16	.096	.0772	.105	.0905	.0772	.128	.1104
17	.0977	.0703	.105	.0814	.0806	.1021	.0959
18	.1097	.1046	.0778	.0923	.12	.1092	.105
19	.156	.1217	.1347	.1376	.1286	.1522	.1629
20	.1389	.1406	.1385	.1303	.1286	.1466	.152
21	.1269	.12	.1297	.1158	.1217	.1357	.143
22	.0977	.0943	.1104	.0941	.0977	.1158	.1303
23	.0874	***	.0778	.0814	.0789	.0887	.0995
24	.0686	.0737	.0686	.0688	.0778	.0823	.0923
Max	.156	36.0769	.1385	.1376	.1286	.1522	.1629
Min	.0686	.0686	.0617	.0688	.0652	.0737	.076
Avg	.0945	1.5928	.0926	.0949	.0933	.1023	.1025



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 401 / 33KV INCOMER(makardhokda) NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 33 / INCOMING UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.168	.1423	.1543	.168	.1423	.1543
2	.1543	.168	.1423	.1543	.168	.1423	.1543
3	.1543	.168	.0949	.1543	.168	.1423	.1543
4	.1543	.112	.0949	.1543	.168	.1423	.1543
5	.1543	.112	.1423	.1543	.168	.1423	.1543
6	.1543	.168	.1423	.1543	.168	.1423	.1543
7	.1543	.168	.1423	.1543	.112	.1423	.1543
8	.1543	.112	.0949	.1543	.112	.1423	.1543
9	.1543	.112	.1526	.1029	.112	.1543	.1543
10	.112	.1423	.7042	.8962	.9014	.9945	.9522
11	.112	.1423	.8453	.9522	1.0437	1.0442	.7282
12	.9522	.5693	.7042	1.2323	.9962	1.0442	.9522
13	1.0642	1.186	1.0059	1.3443	.9145	.9945	.7842
14	1.2323	1.1385	1.2574	1.2323	.8539	1.086	.8962
15	1.4003	1.0437	1.1568	1.2323	.8065	1.0059	.9522
16	1.4003	.9962	1.0562	1.2323	.8539	.9054	.8962
17	1.3443	1.0437	1.1065	1.1203	.8539	.9054	
18	1.2323	.9962	.1526	.168	.1423	.1526	
19	1.0642	.9014	.2572	.2241	.2372	.2572	
20	.2801	.2372	.2543	.2241	.2372	.2572	
21	.2241	.2372	.2572	.2241	.2372	.2572	
22	.168	.1898	.2058	.168	.1898	.2058	
23	.168	.1423	.1543	.168	.1898	.1543	
24	.1543	.168	.1423	.1543	.168	.1423	.1543
Max	1.4003	1.186	1.2574	1.3443	1.0437	1.086	.9522
Min	.112	.112	.0949	.1029	.112	.1423	.1543
Avg	.5124	.4343	.4337	.4963	.4154	.4458	.4532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 201 / 11KV GANGAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5533	.5973	.6401	.6455	.6836	.724
2	.5853	.5533	.5792	.6036	.627	.6661	.7059
3	.567	.5902	.5973	.6584	.627	.6733	.6878
4	.5487	.6086	.6154	.6767	.6455	.7087	.6878
5	.5853	.6086	.6219	.6401	.6455	.7164	.7133
6	.6036	.627	.6401	.6401	.6639	.6805	.7133
7	.6401	.627	.6584	.6219	.7008	.7059	.7316
8	.695	.7008	.6767	.695	.7193		.7682
9	.6379	.6733	.6379	.7087	.6661	.6767	.7377
10	.6201	.7087	.6024	.691	.6556	.695	.7193
11	.6661	.5784	.631	.6984	.6201	.6767	.6086
12	.5721	.5959	.6661	.631	.5959	.695	.5902
13	.5201	.6241	.5959	.5895	.5721	.631	.6086
14	.5487	.6068	.6068	.6068	.5721	.5959	.5164
15	.5426	.5375	.5375	.5895	.5487	.5959	.5164
16	.583	.5548	.5487	.5548	.6001	.5959	.5348
17	.6639	.6984	.6257	.6824	.7468	.724	.5533
18	.8483	.7964	.9511	.8483	.8215	.8779	.793
19	1.0328	.9145	1.0974	1.0697	.924	.9979	1.0143
20	.9959	.9795	1.0242	1.0328	.9979	1.0534	1.0512
21	.959	.9145	.9145	.959	.9979	1.0164	.9959
22	.793	.823	.7865	.8483	.8871	.9145	.8852
23	.6639	.6516	.6584	.7377	.7682	.8048	.793
24	.644	.5902	.5973	.6401	.6639	.7059	.7316
Max	1.0328	.9795	1.0974	1.0697	.9979	1.0534	1.0512
Min	.5201	.5375	.5375	.5548	.5487	.5959	.5164
Avg	.6694	.6715	.6862	.7110	.7047	.7431	.7242

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 202 / 11KV SONEZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.5332	.543	.6767	.6619	.631	.6697
2	.5853	.5332	.5611	.6767	.6803	.5959	.6516
3	.695	.5699	.5792	.6584	.6803	.6024	.6878
4	.6401	.6067	.6154	.695	.6986	.567	.724
5	.7133	.6435	.6584	.695	.717	.6447	.7682
6	.7682	.6986	.695	.7316	.6986	.7164	.8048
7	.823	.7354	.7316	.7499	.7354	.7964	.8413
8	.823	.6986	.7682	.7316	.7906	.8326	.823
9	.7796	.7362	.7442		.7442	.8596	.7722
10	.7888	.7796	.7442	.815	.7619	.7682	.7354
11	.7975	.8238	.8238	.788	.815	.8048	.8273
12	.6935	.7888	.8063	.7537	.7888	.8048	.7538
13	.6588	.7282	.7011		.7455	.7362	.7354
14	.5935	.6935	.6935	.6935	.6935	.7011	
15	.6104	.6762	.6762	.6415	.6859	.703	
16	.6859	.7802	.6173	.6415	.703	.7282	1.0296
17	.6986	.7343	.695	.7538	.7468	.7602	.8825
18	.8825	.8869	1.0242	.9376	.9522	1.0059	.956
19	1.0663	.9511	1.0974	1.0663	.9979	1.0719	1.1031
20	.9928	1.0164	1.0608	1.0112	1.0349	1.1088	.9928
21	.9193	.9145	.8779	1.0112	.961	.924	.9009
22	.7906	.8048	.7682	.8457	.8871	.823	.8273
23	.6435	.5973	.6584	.717	.7023	.7499	.7354
24	.5487	.5516	.5611	.6584	.6619	.6516	.695
Max	1.0663	1.0164	1.0974	1.0663	1.0349	1.1088	1.1031
Min	.5487	.5332	.543	.6415	.6619	.567	.6516
Avg	.7433	.7284	.7376	.7704	.7727	.7745	.8144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357] BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 203 / 11KV KAWARAPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	06-FEB-18
HR	Load (MW)
12	.695
16	.5895
Max	.695
Min	.5895
Avg	.6423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 204 / 11KV DREAM CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.3635	.362	.4024	.3999	.4031	.4525
2	.4755	.3635	.362	.4572	.3999	.3856	.4525
3	.3658	.3999	.3801	.439	.418	.3898	.4706
4	.4938	.4362	.3982	.4572	.4544	.4252	.5068
5	.5121	.4907	.4207	.5121	.4544	.4656	.5487
6	.5487	.5271	.4572	.5121	.4362	.5014	.5853
7	.5853	.5816	.5121	.5487	.4907	.543	.6584
8	.5853	.5816	.567	.5487	.5453	.543	.5853
9	.5316	.5316	.5316	.5138	.5316	.567	.5998
10	.5083	.4961	.4961	.5138	.5316	.5853	.618
11	.4681	.4733	.0351	.5014	.4784	.5487	.5271
12	.4681	.4557	.4382	.4908	.4733	.4755	.4726
13	.3641	.3814	.4207	.4382	.4334	.423	.4726
14	.373	.3814	.4161	.4334	.4508	.3856	.3999
15	.39	.3641	.3988	.3988	.4458	.4031	.3999
16	.3772	.4334	.3772	.4161	.4287	.4207	.418
17	.3999	.4119	.439	.4362	.5601	.4706	.3999
18	.4726	.543	.6219	.5453	.5788	.5121	.5089
19	.5816	.567	.695	.6543	.6099	.5914	.5998
20	.5816	.5544	.6219	.618	.6283	.6283	.6361
21	.5453	.5121	.5487	.5816	.5914	.5914	.5816
22	.4726	.4755	.4572	.5271	.5914	.5487	.5271
23	.3999	.3801	.4024	.4544	.4435	.5121	.4726
24	.3658	.3635	.3801	.3898	.418	.4163	.4755
Max	.5853	.5816	.695	.6543	.6283	.6283	.6584
Min	.3641	.3635	.0351	.3898	.3999	.3856	.3999
Avg	.4726	.4612	.4475	.4913	.4914	.4890	.5154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 205 / 11KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.6381	.543	.439	.4504	.4207	.4525
2	.5487	.5818	.5068	.4024	.4129	.3856	.4525
3	.5853	.5442	.5068	.439	.4316	.3721	.4344
4	.5487	.5067	.4706	.4207	.4692	.3544	.4344
5	.5121	.4692	.4572	.439	.4129	.3224	.4207
6	.5304	.5067	.4755	.439	.4316	.3224	.4207
7	.4938	.4129	.5121	.4572	.4879	.3077	.439
8	.7499	.563	.5304	.5487	.5442		.4024
9	.7442	.7087	1.227	.5847	.567	.8596	.563
10	.7362	.7265	1.9631	.6733	.6201	.7316	.7131
11	1.0923	1.1218	1.9176	1.0566	.691	.9145	1.0884
12	.8669	.9114	.8573	1.0166	.6836	.9877	1.201
13	.5375	.8669	.631	.7011	.6241	.8939	1.126
14	.8139	1.0056	.6241	.6935	.6588	.8063	.8445
15	.8139	.6935	.5201	.7628	.7202	.6661	.7131
16	.8402	1.0749	1.1317	1.7684	.823	.5895	.9758
17	.9008	.9134	1.0242	1.1072	.7842	.8326	.9383
18	.4504	.7783	.6401	1.0509	.5228	.7499	.8257
19	.3378	.695	.3841	.4504	.4435	.7023	.4129
20	.3378	.5544	.4572	.4504	.4066	.5175	.5442
21	.4504	.5121	.4755	.4879	.5175	.4805	.6193
22	.4879	.4755	.4572	.5067	.4805	.4572	.5818
23	.4504	.3982	.4755	.5442	.4066	.439	.6193
24	.833	.6005	.5611	.439	.4316	.4344	.951
Max	1.0923	1.1218	1.9631	1.7684	.823	.9877	1.201
Min	.3378	.3982	.3841	.4024	.4066	.3077	.4024
Avg	.6346	.6775	.7229	.6616	.5426	.5890	.6739

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 401 / 33KV TATA EXP FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2414	.2384	.2172	.2305	.212	.2156	.2281
2	.2305	.2269	.2063	.2305	.2387	.2366	.2172
3	.214	.2154	.1955	.2414	.2215	.202	.2063
4	.203	.2089	.1846	.2469	.2323	.186	.1955
5	.214	.187	.1756	.2305	.2154	.1934	.214
6	.1975	.2024	.1701	.2305	.2026	.2042	.2085
7	.1866	.1988	.1756	.225	.2254	.19	.203
8	.1756	.1896	.1866	.214	.2098	.2063	.2689
9	.2126	.2286	.2209	.2286	.2179	.2195	.2477
10	.2209	.2524	.2392	.186	.2286	2.4143	.2374
11	.1872	.2209	.1893	.1451	.1648	.2305	.205
12	.1872	.2209	.1893	.184	.2051	.214	.2582
13	.1976	.2237	.1946	.1998	.2185	.2209	.2788
14	.2086	.2341	.208	.182	.2341	.1998	.1709
15	.2187	.2497	.2289	.1716	.2445	.216	.2256
16	.2315	.2601	.2778	.182	.2623	.1955	.2411
17	.2506	.2149	.2634	.2889	.2521	.2226	.2573
18	.219	.1466	.2524	.1525	.1904	.1756	.2209
19	.2653	.2853	.2634	.2185	.2661	.2938	.2874
20	.2513	.2717	.2689	.2348	.2938	.2273	.2689
21	.2505	.2634	.2743	.2336	.2661	.2661	.2845
22	.1922	.203	.2634	.1593	.2329	.2469	.25
23	.2015	.2335	.2359	.1807	.2051	.225	.2199
24	.6859	.2165	.2226	.2195	.2011	.2172	.2524
Max	.6859	.2853	.2778	.2889	.2938	2.4143	.2874
Min	.1756	.1466	.1701	.1451	.1648	.1756	.1709
Avg	.2351	.2247	.2210	.2090	.2267	.3091	.2353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 201 / 11 kV Umrer U I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0183	.0187	.0183	.0189	.0187
2		.0183	.0183	.0187	.0185	.0189	.0187
3	.0189	.0183	.0183	.0187	.0183	.0189	.0187
4	.0189	.0183	.0183	.0187	.0185	.0189	.0187
5	.0189	.0183	.0183	.0187	.0179	.0189	.0187
6	.0189	.0183	.0183	.0187	.0181	.0189	.0187
7	.0189	.0183	.0183	.0187	.0185	.0189	.0187
8	.0189	.0183	.0183	.0187	.0183	.0189	.0187
9	.0189	.0183	.0185	.0187	.0183	.0189	.0183
10	.0183	.0183	.0183	.0187	.0183	.0189	.0183
11	.0183	.0183	.0187	.0183	.0189	.0187	.0183
12	.0183	.0185	.0187	.0179	.0189	.0187	.0183
13	.0183	.0183		.0183	.0189	.0187	.0183
14	.0183	.0183	.0187	.0183	.0189	.0187	.0183
15	.0183	.0183	.0187	.0179	.0189	.0187	.0183
16	.0183	.0183	.0187	.0183	.0189	.0187	.0183
17	.0183	.0183	.0187	.0183	.0189	.0187	.0183
18	.0183	.0183	.0187	.0183	.0189	.0187	.0183
19	.0183	.0183	.0187	.0185	.0189	.0187	.0183
20	.0183	.0183	.0187	.0183	.0189	.0187	.0183
21	.0183	.0185	.0187	.0183	.0189	.0187	.0183
22	.0183	.0183	.0187	.0183	.0189	.0187	.0183
23	.0183	.0183	.0187	.0183	.0189	.0187	
24	.0189	.0183		.0187	.0185	.0189	.0187
Max	.0189	.0185	.0187	.0187	.0189	.0189	.0187
Min	.0183	.0183	.0183	.0179	.0179	.0187	.0183
Avg	.0185	.0183	.0185	.0185	.0186	.0188	.0185



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 202 / 11 KV UMRER U II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0549	.0549	.0366	.0732	.0566	.056
2	.0566	.0549	.0549	.0366	.0732	.0566	.056
3	.0566	.0549	.0732	.0366	.0724	.0566	.056
4	.0566	.0732	.0732	.0549	.0732	.0566	.0549
5	.0754	.0732	.0732	.0549	.0732	.0566	.0549
6	.0754	.0732	.0732	.0549	.0732	.0754	.0732
7	.0754	.0732	.0732	.056	.0732	.0754	.0732
8	.0943	.0914	.0732	.0732	.0914	.0754	.0914
9	.0943	.128	.0716	.0732	.0914	.0754	.0732
10	.0732	.0914	.0732	.1097	.0724	.0754	.0914
11	.1097	.1097	.0732	.0732	.0943	.0914	.0914
12	.0732	.0732	.0732	.0732	.0754	.0732	.0732
13	.0732	.0732	.0549	.0549	.0754	.0549	.0732
14	.1097	.0732	.0747	.0724	.0754	.0549	.0549
15	.1097	.0732	.0732	.0914	.0566	.0732	.0732
16	.0732	.0732	.0914	.0716	.0566	.0914	.0732
17	.0732	.1097	.0732	.0732	.0566	.0747	.0732
18	.0732	.0732	.0549	.0732	.0754	.0732	.0732
19	.0732	.0914	.0732	.0732	.0754	.0934	.0732
20	.0914	.0905	.0732	.0732	.0754	.0732	.0914
21	.0914	.0895	.0732	.0914	.0754	.0732	.0914
22	.0914	.0914	.0732	.0732	.0754	.0747	.0549
23	.0732	.0537	.056	.0549	.0566	.056	.0549
24	.0566	.0366	.0732	.056	.0716	.0566	.0549
Max	.1097	.128	.0914	.1097	.0943	.0934	.0914
Min	.0566	.0366	.0549	.0366	.0566	.0549	.0549
Avg	.0786	.0783	.0702	.0663	.0734	.0698	.0703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 203 / 11 KV HEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987			.3109		.3734	.4024
2	.2801			.3109		.3361	.3841
3	.2801			.3292		.2987	.3475
4	.3174			.3292	.5853	.5544	.567
5	.3547			.3475	.6401	.6767	.5853
6	.4108			.3658	.6805	.8145	.6219
7	.4108			.4572	.7682	.9412	.6584
8	.3734			.2743	.9145	1.0498	.8779
9	.3547			.4938	.9877	1.0498	.9145
10				.3292	1.0608	.9774	.7316
11			.2195		.8688	.9145	.724
12	.7682	.9145	.8048	.9511	.2241	.2195	
13	.9774	1.2071	1.1706	1.1706	.2241	.2195	
14	1.1584	1.2803	.8596	1.1283	.2241	.1829	
15	1.2071	1.2331	1.134	1.1462	.2241	.2195	
16	1.2437	1.1462	1.1523	1.0745		.2195	
17	1.1222	1.134	1.1523	1.134	.2427	.2743	
18	1.0498	.9877	1.0242	.9922	.4108	.4572	
19	.9511	1.134	1.0608	1.0242	.695	.695	
20			.6767		.695	.695	
21			.567		.6401	.6584	
22			.4572		.4805	.567	
23			.3475		.4108	.4024	
24	.3174			.3361		.4108	.4024
Max	1.2437	1.2803	1.1706	1.1706	1.0608	1.0498	.9145
Min	.2801	.9145	.2195	.2743	.2241	.1829	.3475
Avg	.6598	1.1296	.8174	.6582	.5777	.5503	.6014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 205 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361			.3658		.4108	.4024
2	.2987			.3658		.3734	.4024
3	.2801			.3475		.3734	.4024
4	.2801			.3475	.3658	.4108	
5	.3174			.3658	.394	.462	.4755
6	.3547			.3841	.394	.5359	.4755
7	.3734			.4024	.439	.5544	.4938
8	.3361			.3734	.4887	.5914	.5853
9	.2987			.3658	.567	.6584	.5853
10				.3109	.5121	.6401	.5121
11			.2561		.5359	.5853	.4572
12	.4024	.4755	.4207	.4344	.2987	.2926	
13	.5068	.5853	.4207	.5853	.2801	.2561	
14	.5611	.5973	.4572	.5853	.2614	.2926	
15	.5487	.543	.3144	.5853	.2614	.2926	
16	.5487	.5853	.4755	.5853	.2427	.3109	
17	.543	.5853	.5304	.5304	.2801	.3109	
18	.543	.5121	.4938	.6089	.3734	.4024	
19	.5853	.6219	.5853	.695	.6584	.6584	
20			.6584		.695	.695	
21			.5853		.6099	.6584	
22			.5121		.5175	.5487	
23			.439		.4435	.4207	
24	.3048			.4108		.4108	.4024
Max	.5853	.6219	.6584	.695	.695	.695	.5853
Min	.2801	.4755	.2561	.3109	.2427	.2561	.4024
Avg	.4122	.5632	.4730	.4552	.4309	.4644	.4722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 207 / 11KV Express Water work  
feeder Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.0549	.128	.1097	.1829	.0943	.128
2	.1698	.0549	.1097	.128	.1646	.132	.0732
3	.1698	.0732	.1097	.1097	.1463	.1509	.0549
4	.1698	.0732	.128	.1463	.0716	.1509	.0549
5	.1867	.1097	.128	.1463	.1097	.1698	.0549
6	.1867	.1097	.1463	.128	.1463	.1867	.1097
7	.1867	.1097	.1829	.1463	.1646	.2054	.128
8	.1698	.1097	.2012	.2012	.1829	.2054	.1829
9	.132	.128	.1463	.128	.128	.0943	.128
10	.128	.1463	.1829	.1097	.1463	.132	.128
11	.128	.1829	.1829	.1646	.1698	.1829	.1829
12	.1097	.1829	.1829	.1791	.1698	.1829	.1829
13	.1097	.1829	.1463	.1097	.1509	.1829	.1829
14	.128	.1463	.1097	.1646	.1132	.1829	.1097
15	.128	.181	.0914	.1646	.1509	.1829	.1097
16	.1097	.1829	.1646	.1829	.1698	.1646	.1463
17	.1097	.1829	.1646	.1463	.132	.1646	.1463
18	.128	.128	.1646	.128	.1132	.1646	.128
19	.128	.0914	.128	.0732	.0754	.0732	.128
20	.1097	.1097	.0732			.0914	.128
21	.1097	.1791	.1829	.1646	.1698	.0732	.128
22	.1097	.1829	.1829	.1646	.1132	.1097	.0914
23	.0732	.181	.0554	.0543	.0943	.1463	.0914
24	.0943	.0366	.1829	.0732	.1097		.1463
Max	.1867	.1829	.2012	.2012	.1829	.2054	.1829
Min	.0732	.0366	.0554	.0543	.0716	.0732	.0549
Avg	.1344	.1300	.1448	.1358	.1381	.1489	.1227

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 208 / 11KV UMRED AG SEPERATED

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.0914	.0943	.0934
5					.1075	.0943	.0914
6					.0914	.0943	.1097
7					.0914	.0943	.1097
8					.0914	.0943	.1097
9					.0914	.1132	.1097
10					.0914	.1132	.1097
11					.1509	.1097	.0914
12	.1829	.1463	.1097	.128			
13	.2195	.1829	.1463	.1463			
14	.2378	.2012	.1463	.1629			
15	.2195	.2012	.1646	.1463			
16	.1829	.2012	.1463	.1646			
17	.1829	.181	.128	.1646			
18	.1463	.2012	.1463	.1463			
19	.1097	.1463	.0914	.124			
Max	.2378	.2012	.1646	.1646	.1509	.1132	.1097
Min	.1097	.1463	.0914	.124	.0914	.0943	.0914
Avg	.1852	.1827	.1349	.1479	.1009	.1010	.1031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 401 / 33KV INCOMER(Waigao)  
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4143	2.1719	2.5789	2.6886	2.6886	3.2579	2.524
2	2.2497	2.1719	2.3891	2.6886	2.6337	3.2579	2.524
3	2.3045	2.009	2.4143	2.7435	2.5789	3.095	2.4691
4	2.552	2.0633	2.7692	4.3896	4.0724	4.5182	4.2798
5	2.7149	2.4434	2.7435	4.2798	4.3439	5.0497	4.3347
6	3.0407	2.7692	2.9864	4.4445	4.7817	5.9534	4.7188
7	3.2036	2.9321	3.4208	5.487	5.3772	6.5204	4.9931
8		3.1493	2.5789	5.2126	5.9099	6.9936	6.1454
9	3.3665	3.6923	3.5665	5.3772	6.5844	6.9936	6.5295
10	2.9321	3.2036	3.6214	5.9808	6.857	6.5729	6.3649
11	3.0407	3.4019	3.9506	5.2652	6.31	6.9136	6.5158
12	6.0905	6.5547	6.0357	8.4162	4.137	4.0055	4.6153
13	6.2986	6.2003	6.8587	10.1509	4.0832	4.2798	4.6696
14	6.8959	6.749	6.3649	9.9314	3.9758	3.9506	4.4525
15	6.9502	7.1879	6.9685	7.8464	4.0832	4.2798	4.3439
16	7.4932	7.0382	7.0782	8.0053	4.0295	4.3347	4.2896
17	7.1674	7.0045	7.2977	6.8039	3.9758	3.4568	4.1267
18	6.8416	6.8959	5.6516	5.8471	3.5837	3.3819	4.3439
19	6.2986	7.4623	6.749	6.7696	4.0832	4.4445	4.0181
20	3.8009	3.2922	4.1152	4.0055	3.6534	4.1152	4.0181
21	3.0087	3.4019	3.6214	3.3665	3.3665	3.4019	3.6923
22	2.6063	3.2236	2.7984	2.9232	2.9321	3.2373	3.6923
23	2.552	2.6235	3.0178	2.5789	3.4751	2.9081	3.2579
24	2.3594	2.2805	2.6886	2.7984	2.6337	3.2036	2.6886
Max	7.4932	7.4623	7.2977	10.1509	6.857	6.9936	6.5295
Min	2.2497	2.009	2.3891	2.5789	2.5789	2.9081	2.4691
Avg	4.1818	4.1634	4.2611	5.3334	4.1729	4.5052	4.3170

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 402 / 33 KV PACHGAON -VIRANGANA- NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.2195	.3841	.3841	.3052	.3961	.3841
2	.3395	.2195	.3292	.3361	.3052	.3961	.3841
3	.3395	.2195	.3292	.3292	.3601	.3961	.3841
4	.3395	.2195	.3841	.3292	.3761	.3961	.3841
5	.3395	.2195	.3841	.3292	.3761	.3961	.2641
6	.3961	.2195	.3841	.3841	.3761	.3961	.3841
7	.3961	.2195	.3841	.3841	.3721	.3961	.3841
8	.3961	.2195	.3841	.3841	.3921	.3961	.2195
9	.3961	.3841	.3761	.4938	.8059	1.0082	.7682
10	.3841	.3841	.3841	1.0425	1.3432	1.386	.9328
11	.3841	.3561	1.0425	1.1523	1.386	1.3717	.7133
12	1.0425	1.1523	.9328	1.3432	1.2323	1.3169	
13	1.086	1.3432	1.262	1.3432	1.2323	1.3169	.9328
14	1.2489	1.4815	1.4815	1.3575	1.1203	1.1523	.9231
15	1.3032	1.3717	1.4266	1.3032	1.1203	1.3169	.8779
16	1.5746	1.3717	1.3717	1.3032	1.0642	1.3169	.8779
17	1.5203	1.3717	1.3717	.3258	.9522	.2743	.543
18	1.4118	1.2071	.3292	.3086	.4527	.3292	.3841
19	1.086	1.1523	.5487	.5144	.5601	.6099	.3841
20	.543	.3841	.5487	.6036	.5601	.5487	.543
21	.4344	.4578	.4938	.5087	.5093	.5487	.4344
22	.3801	.439	.3841	.3841	.3961	.4938	.3258
23	.3801	.4578	.3326	.3292	.3961	.3841	.3258
24	.3961	.1097	.3561	.3292	.3601	.3961	.3841
Max	1.5746	1.4815	1.4815	1.3575	1.386	1.386	.9328
Min	.3395	.1097	.3292	.3086	.3052	.2743	.2195
Avg	.6881	.6325	.6502	.6459	.6814	.7058	.5278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 404 / 33 KV NCDC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.086	1.2071	1.3169	1.2071	1.386	.9877
2	1.0642	1.086	1.1523	1.4266	1.2071		1.0974
3	1.1203	1.086	1.0974	1.4815	1.1523	1.1203	1.1523
4	1.1203	1.086	1.2096	1.3717	.9877	1.0082	1.0425
5	1.1763	1.1946	1.0974	1.1523	.9877	1.1203	.9877
6	1.2883	1.1946	1.1523	1.2071	1.3169	1.2883	1.0974
7	1.386	1.3032	1.3717	1.8107	1.4506	1.386	1.1523
8	1.386	1.3032	1.3717	1.3717	1.4661	1.4415	1.5364
9	1.386	1.3575	1.2357	1.262	1.262	1.3306	1.2071
10	1.1946	1.3032	1.262	1.5364	1.4352	1.3306	1.4815
11	1.3575	1.3717	1.262	.9887	1.2883	.9877	1.6289
12	1.4661	1.5043	1.3169	.9328	1.4415	1.1523	1.3032
13	1.1403	1.3717	1.0534	1.262	1.1763	1.2071	1.1946
14	.9231	1.0974	.9877	1.2071	1.0082	1.0425	.9231
15	1.086	1.0974	1.262	1.0425	1.1203	1.2071	.9231
16	1.4118	1.2071	1.0974	1.3603	1.2323	1.3717	.9231
17	1.3032	1.0974	1.0425	1.0974	1.2323	1.3717	1.086
18	1.2489	1.6461	1.0974	1.0974	1.3306	1.2071	1.2489
19	1.3032	1.5912	1.6461	1.5415	1.3306	1.6461	1.3032
20	1.4118	1.4266	1.701		1.2323	1.6461	1.6832
21	1.086	1.1283	1.4266	1.0745	1.1763	1.0974	1.6832
22	.9774	1.262	.9877	1.086	1.1203	1.2071	1.7918
23	1.086	1.2383	1.5364	1.2071	1.4969	1.262	1.7918
24	1.2323	.9774	1.1694	1.4266	1.1283	1.1763	1.2071
Max	1.4661	1.6461	1.701	1.8107	1.4969	1.6461	1.7918
Min	.9231	.9774	.9877	.9328	.9877	.9877	.9231
Avg	1.2175	1.2507	1.2393	1.2722	1.2411	1.2606	1.2681



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 405 / 33 KV SIRSI

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527		.4435		.4938	1.0082
2	.3961		.439		.4938	1.1203
3	.3961		.3841		.4938	1.1203
4	.6722		.6099		.823	1.2323
5	.6722		.6447		.8688	1.386
6	.7842		.823		.8779	1.6632
7	.8402		.9877		1.0208	1.9404
8	1.0082		1.3169		1.2071	2.1399
9	1.1203		1.3746		1.2757	1.5524
10			1.3717		1.1283	1.2883
11		1.0436		2.6886	1.0642	
12		1.0631		3.0624	1.0642	
13		1.2071		4.3439	1.3306	
14		1.3169		3.8409	1.4969	
15		1.3032		1.9204	1.4969	
16		1.1946		1.8656	1.4415	
17		1.262		1.9204	1.3443	
18		1.0974		1.2226	1.2323	
19		1.5364		1.4352	1.4415	
20		.7133		.9877	1.0082	
21		.8871		.8779	.8402	
22		.7682		.6447	.7282	
23		.4938		.5487	1.0642	
24	.5093		.4938		.4938	1.0082
Max	1.1203	1.5364	1.3746	4.3439	1.4969	2.1399
Min	.3961	.4938	.3841	.5487	.4938	1.0082
Avg	.6852	1.0682	.8081	1.9507	1.0304	1.4054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 201 / 11 KV TOWN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.724	.8573	.6668	.8002	.7621	.5716
2	.5716	.6859	.8573	.6668	.8002	.7621	.5716
3	.5716	.6859	.8002	.6668	.7621	.7811	.5716
4	.5716	.724	.7621	.6668	.7621	.6859	.5716
5	.5716	.7621	.7621	.6668	.8002	.6668	.5716
6	.5716	.724	.724	.6668	.8002	.724	.5716
7	.5716	.6859	.7621	.6668	.7621	.6668	.6668
8	.5716	.724	.7621	.6668	.8764	.9526	.6097
9	.9526	1.5051	.9526	.7621	.9907	.9526	.6668
10	1.1431	1.105	.9526	.9145	1.0669	1.1431	.7621
11	1.3717	1.5051	1.1431	1.105	1.3336	1.2955	.9526
12	1.105	1.6766	1.2574	1.0669	1.3336	1.2193	.8764
13	1.2955	1.5242	1.1431	.9145	1.2955	1.2193	.9145
14	1.0288	1.5242	.9907	.8764	1.1431	1.0669	.9526
15	1.1431	1.3336	1.1431	.9145	1.1431	1.1431	.8764
16	1.105	1.1431	1.2193	.9145	1.1431	1.0669	.9145
17	1.105	.9526	1.1431	1.0288	1.1431	1.1431	.9907
18	1.1431	.9526	1.1431	.9907	1.1431	1.1431	.9907
19	1.105	.9526	1.1431	.9526	1.1431	1.0479	1.0288
20	.9526	1.1431	1.0669	.9145	.9526	.9907	.9526
21	.9145	1.0479	1.0288	.9526	.9526	.8573	.8764
22	.8383	.9526	.9526	.8764	.9526	.8383	.8764
23	.8002	.9526	.7621	.8764	.7621	.7621	.8383
24	1.0288	.724	.9526	.6668	.8383	.8573	.5716
Max	1.3717	1.6766	1.2574	1.105	1.3336	1.2955	1.0288
Min	.5716	.6859	.724	.6668	.7621	.6668	.5716
Avg	.9002	1.0296	.9701	.8359	.9875	.9478	.7811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 202 / 11 KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	2.0195	1.7528	1.829	1.9433	1.829	1.9052
2	.9526	1.9433	2.0195	1.7147	1.829	1.9814	1.5242
3	.9145	1.8671	1.9814	1.6385	1.9814	1.829	1.448
4	9.2402	1.6766	1.9052	1.5623	1.8671	1.7528	1.3717
5	.9145	1.6004	1.829	1.6004	1.829	1.6004	1.1431
6	.9145	1.3717	1.6004	1.5242	1.8099	1.6194	.9907
7	.9526	1.5242	1.4098	1.0669	1.6004	1.3527	.9145
8	1.0669	1.5242	.8573	1.2955	1.5242	1.5242	.9145
9	1.2193	1.5623	1.6004	1.3717	1.6766	1.6004	.9907
10	1.5242	1.6004	1.7528	1.5242	1.829	1.829	.9907
11	1.7909	1.9052	1.6766	1.7718	1.8671	1.9052	1.086
12	1.9052	2.3815	1.829	1.9052	1.8861	1.829	.9145
13	1.5432	2.2672	1.3717	1.7147	2.0767	1.9052	.9145
14	2.2291	2.2481	1.448	1.5242	2.1338	1.5242	.9526
15	2.0576	2.4768	1.4098	2.0386	2.3624	1.7528	1.086
16	2.1719	1.9243	1.448	1.5242	2.2862	1.9052	1.0669
17	1.829	1.7528	1.9052	1.6385	2.572	1.6004	1.105
18	1.4861	1.6385	1.6766	1.2955	1.8861	1.9052	.9907
19	1.5623	1.6004	1.9052	1.3336	1.6385	1.9814	1.086
20	1.5242	1.5432	1.5242	1.1431	1.8671	1.448	.9526
21	1.2955	1.9052	1.6385	1.6004	2.0195	1.5242	1.086
22	.9145	1.9624	1.7147	1.7718	2.2291	2.1338	1.0479
23	1.2003	1.9052	1.7528	2.0957	2.0005	2.0195	1.0288
24	.9526	1.9052	2.0195	1.9052	1.9052	1.7528	2.21
Max	9.2402	2.4768	2.0195	2.0957	2.572	2.1338	2.21
Min	.9145	1.3717	.8573	1.0669	1.5242	1.3527	.9145
Avg	1.7131	1.8377	1.6679	1.5996	1.9425	1.7544	1.1550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 203 / 11 KV WENA FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1715
2	.1905	.1905	.381	.1905	.1905	.1905	.1905
3	.362	.381	.381	.362	.381	.3429	.362
4	.362	.362	.1905	.362	.381	.3429	.362
5	.362	.362	.1905	.362	.362	.362	.362
6	.362	.362	.381	.362	.362	.362	.362
7	.362	.362	.362	.362	.362	.362	.362
8	.381	.362	.381	.381	.362	.362	.362
9	.362	.362	.381	.362	.362	.381	.362
10	.362	.362	.381	.381	.362	.362	.362
11	.362	.362	.362	.381	.381	.362	.362
12	.362	.1905	.1905	.381	.1905	.381	.381
13	.1905	.1905	.1905	.1905	.362	.1905	.0762
14	.362	.381	.1905	.362	.381	.1905	.0762
15	.362	.381	.362	.362	.381	.381	.0762
16	.362	.381	.362	.362	.362	.381	.1524
17	.362	.381	.362	.362	.362	.381	.3429
18	.362	.381	.362	.362	.381	.362	.362
19	.362	.381	.362	.362	.381	.362	.3429
20	.362	.3429	.362	.362	.362	.362	.362
21	.362	.3429	.362	.362	.362	.362	.362
22	.1905	.1905	.1905	.1905	.1905	.362	.362
23	.1905	.1905	.1905	.1905	.1905	.1715	.362
24	.1905	.1905	.1905	.1905	.1905	1.4861	.1715
Max	.381	.381	.381	.381	.381	1.4861	.381
Min	.1905	.1905	.1905	.1905	.1905	.1715	.0762
Avg	.3199	.3159	.3024	.3223	.3247	.3747	.2937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 204 / CHANVIM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 206 / 11KV GONDKHAIRY AG SEP SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0572	.0572	.0381	.0191	.0191
2	.0572	.0572	.0572	.0572	.0572	.0191	.0191
3	.0381	.0572	.0762	.0572	.0572	.0191	.0191
4	.0572	.0572	.0762	.0572	.0572	.0191	.0191
5	.0572	.0572	.0762	.0572	.0572	.0191	.0191
6	.0762	.0762	.0572	.0762	.0381	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0762	.0762	.0762
9	.0191	.0191	.0191	.0191	.0953	.1143	.1524
10	.0191	.0191	.0191	.0191	.1143	.1143	.1715
11	.0191	.0191	.0191	.0191	.2286	.1715	.2477
12	.0191	.0381	.0191	.0191	.3048	.1905	.2667
13	.0191	.0191	.0191	.0191	.1905	.1524	.2477
14	.0191	.0191	.0191	.0191	.1143	.1715	.2286
15	.0191	.0191	.0191	.0191	.0762	.1143	.2096
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0381	.0191	.0191
20	.0191	.0191	.0191	.0191	.0381	.0191	.0191
21	.0572	.0762	.0572	.0381	.0191	.0191	.0191
22	.0572	.0572	.0762	.0572	.0191	.0191	.0191
23	.0572	.0572	.0762	.0381	.0191	.0191	.0191
24	.0381	.0381	.0572	.0572	.0572	.0191	.0191
Max	.0762	.0762	.0762	.0762	.3048	.1905	.2667
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0334	.0366	.0389	.0342	.0738	.0588	.0794

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 401 / 33 KV NISHANT TUBE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.2026	10.7453	12.2314	10.2881	11.7741	11.3169	9.5451
2	10.2881	11.5455	11.8313	9.888	10.8596	11.374	10.5739
3	9.7165	11.374	11.8313	9.7165	10.4024	11.6027	12.0028
4	10.0023	11.6598	11.4312	10.0023	10.7453	11.8884	10.0023
5	10.1738	10.2881	9.4879	10.5739	10.974	11.4312	9.7165
6	9.4307	10.5167	10.1166	10.2309	9.7737	10.974	10.1738
7	8.7449	8.1162	9.3736	7.8875	10.1166	10.6882	9.4307
8	6.5158	8.802	11.0311	10.2309	10.631	10.3452	8.059
9	10.0595	9.4879	8.6306	10.1166	11.374	10.3452	10.9168
10	10.1166	9.7165	8.802	9.5451	10.2881	9.2593	11.4884
11	9.145	10.0023	9.4879	10.1738	9.4879	7.6017	6.6873
12	6.2872	9.7737	9.7737	11.6598	8.9735	8.3448	9.4879
13	4.4582	10.974	9.4307	8.0018	10.1166	10.4595	
14	7.8875	11.0883	8.1162	10.6882	10.4595	9.3736	
15	10.1738	9.4879	8.6306	10.1166	10.0595	9.2593	
16	9.145	8.6877	8.1162	8.802	10.2881	11.1454	
17	10.2881	8.9163	6.0585	9.9451	10.5739	9.3736	
18	9.0878	8.802	7.6589	9.7165	9.6022	10.5739	8.5162
19	8.9163	8.6877	7.9447	10.6882	10.4024	11.717	11.6598
20	9.4307	9.2593	7.6017	8.7449	4.8011	10.4024	7.8304
21	10.2881	8.9163	8.6877	10.1166	10.8596	9.2021	3.658
22	10.4595	7.7732	8.4591	8.1733	11.2026	10.2309	3.2579
23	9.4879	10.1738	9.145	9.7737	11.6598	9.6022	10.1738
24	8.3448	9.6022	11.7741	11.717	9.145	12.2314	9.7737
Max	11.2026	11.6598	12.2314	11.717	11.7741	12.2314	12.0028
Min	4.4582	7.7732	6.0585	7.8875	4.8011	7.6017	3.2579
Avg	9.1521	9.7665	9.4022	9.8666	10.1904	10.3643	9.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 201 / 11 KV MIDC -I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	1.4335	1.2765	1.358	1.6975	1.4712	1.7337
2	.4904	1.4335	1.2574	1.3014	1.6221	1.358	1.6385
3	.5281	1.3957	1.2384	1.3014	1.5466	1.358	1.6004
4	.5281	1.3957	1.2384	1.3203	1.4712	1.4146	1.5432
5	.547	1.3957	1.2193	1.3392	1.3957	1.4335	1.5051
6	.6036	1.4335	1.2193	1.3769	1.3203	1.5278	1.3336
7	.6602	1.4335	1.2003	1.2174	1.2637	1.6221	1.0479
8	1.1506	1.7353	1.6194	1.4523	1.6409	1.7353	1.105
9	1.448	1.9427	1.905	1.5432	1.9239	1.8671	1.1431
10	1.7528	2.4143	2.1691	2.2672	2.3388	2.4196	1.0288
11	2.1529	2.2634	1.9616	2.4196	2.3954	2.4577	.9717
12	2.0195	2.1125	1.9239	2.191	2.3954	2.1719	
13	1.9814	2.1502	1.9993	1.9814	2.2257	1.9624	
14	2.0005	2.5652	2.0748	2.3243	2.3954	1.8099	
15	1.9243	2.6406	1.9993	1.7718	2.1502	2.0195	
16	1.7147	1.9033	1.9616	1.9616	1.9805	2.0005	.8192
17	1.905	1.9433	1.9805	1.8296	1.8484	2.0195	.6602
18	1.6032	1.6766	1.7164	1.7353	1.905	1.7147	.6036
19	1.5089	1.4098	1.6221	1.3203	1.9993	1.448	.6224
20	1.226	1.2765	1.3203	1.6221	1.8107	1.7337	.4527
21	1.8484	1.7909	1.7541	1.6598	1.9993	1.6385	.4715
22	1.358	1.3527	1.4937	1.4712	1.7918	1.6766	.4715
23	1.3392	1.3146	1.3769	1.7164	1.773	1.448	.4527
24	.4715	1.4712	1.2765	1.4534	1.773	1.8107	1.8861
Max	2.1529	2.6406	2.1691	2.4196	2.3954	2.4577	1.8861
Min	.4527	1.2765	1.2003	1.2174	1.2637	1.358	.4527
Avg	1.3006	1.7452	1.6168	1.6640	1.8610	1.7550	1.0545



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 202 / 11 KV MIDC-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.679	.6668	.4568	.3772	.3584	.4572
2	.679	.6979	.6859	.4527	.3584	.3395	.4572
3	.679	.7167	.7049	.4715	.3584	.3395	.4191
4	.6979	.7167	.7621	.4904	.3772	.3395	.4001
5	.7545	.7356	.7811	.5093	.415	.3584	.3429
6	.7373	.7545	.8002	.4338	.4904	.3506	.3239
7	.6979	.7922	.8002	.4527	.6413	.3018	.2858
8	.811	.7545	.724	.4527	.3395	.2829	.3239
9	.6859	.811	.7545	.362	.4338	.5847	.2858
10	.8764	1.1694	1.0185	.743	.5658	.7167	.2858
11	1.1812	1.2449	1.2637	.724	.6224	1.1694	.3048
12	1.2193	1.0374	1.1694	.8002	.8676	.8865	.2858
13	1.2193	.8488	1.1128	.724	1.3203	.4715	.2667
14	1.1241	1.1317	.6602	.8002	.5093	.8676	.3048
15	1.2193	1.1506	.9054	.9907	.6036	.9431	.2667
16	1.1431	1.3392	.7545	.7733	.5847	.7356	.2667
17	.8488	1.1622	.6687	.6036	.9808	.8002	.3018
18	.7922	.8383	.7545	.6036	.3206	.5525	.2829
19	.5281	.381	.7545	.7167	.679	.7049	.2829
20	.7356	.9335	.6413	.6224	.3206	.4382	.3018
21	.6602	.4572	.547	.3772	.5093	.3048	.2829
22	.5281	.7049	.6036	.4527	.4904	.4763	.2829
23	.5093	.6859	.5093	.415	.4715	.2477	.2641
24	.679	.679	.6668	.4973	.3772	.3772	.4954
Max	1.2193	1.3392	1.2637	.9907	1.3203	1.1694	.4954
Min	.5093	.381	.5093	.362	.3206	.2477	.2641
Avg	.8194	.8509	.7796	.5802	.5423	.5395	.3238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 203 / 11 KV GONDKHAIRY

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 204 / 11 kv Mohapa

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0191	.0172	.0189	.0189	.0191
2	.0189	.0189	.0191	.0189	.0189	.0189	.0191
3	.0189	.0189	.0191	.0189	.0189	.0189	.0191
4	.0189	.0189	.0191	.0189	.0189	.0189	.0191
5	.0189	.0189	.0191	.0189	.0189	.0189	.0191
6	.0189	.0189	.0191	.019	.0189	.0189	.0381
7	.0189	.0189	.0381	.019	.0189	.0189	.0381
8	.0189	.0189	.0381	.0189	.0189	.0189	.0381
9	.0381	.0189	.0377	.0381	.0189	.0189	.0191
10	.0191	.0377	.0189	.0381	.0377	.0189	.0191
11	.0381	.0377	.0189	.0381	.0377	.0189	.0191
12	.0381	.0377	.0189	.0381	.0377	.0189	.0381
13	.0191	.0189	.0189	.0191	.0189	.0189	.0191
14	.0191	.0189	.0189	.0191	.0377	.0377	.0381
15	.0191	.0189	.0189	.0381	.0189	.0377	
16	.0191	.0171	.0189	.0377	.0189	.0377	.0381
17	.0377	.0191	.0377	.0189	.0377	.0381	.0189
18	.0377	.0191	.0377	.0189	.0343	.0381	.0171
19	.0377	.0191	.0377	.0189	.0377	.0381	.0377
20	.0377	.0381	.0189	.0377	.0189	.0381	.0189
21	.0377	.0191	.0377	.0189	.0189	.0381	.0189
22	.0189	.0381	.0189	.0189	.0189	.0191	.0189
23	.0189	.0191	.0172	.0189	.0189	.0191	.0189
24	.0189	.0189	.0191	.0189	.0189	.0171	.0191
Max	.0381	.0381	.0381	.0381	.0377	.0381	.0381
Min	.0189	.0171	.0172	.0172	.0189	.0171	.0171
Avg	.0253	.0228	.0244	.0244	.0242	.0252	.0247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 206 / 11 KV STEEL ASSOCIATE  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.362	.3018	.3772	.2829	.3239
2	.3395	.3395	.3429	.3206	.3584	.2829	.3239
3	.3018	.3395	.3429	.3206	.3584	.2615	.3429
4	.3206	.3395	.3429	.3395	.3584	.2829	.3429
5	.3395	.3395	.3239	.3206	.3584	.3018	.3429
6	.3206	.3395	.3239	.3206	.3772	.3018	.362
7	.3018	.3584	.3239	.3018	.3772	.3018	.362
8	.3206	.3584	.3239	.3018	.3584	.3018	.3429
9	.2858	.3616	.3206	.3239	.3772	.2829	.3429
10	.4191	1.094	.415	1.0098	.6979	.3584	.3429
11	.4382	.679	.547	.8192	.8865	.3772	.3239
12	1.5813	1.5466	.4527	.8954	1.1128	.3772	.3239
13	.9526	.6413	.4338	.7811	.7733	.3395	.3429
14	.8002	1.6409	.4338	.4954	.7545	.6036	.3239
15	.6668	1.2637	.6413	.4382	1.1694	.3395	.362
16	.8002	.6413	.7167	.4715	.5093	.3206	.3239
17	.9808	.6478	.415	.6224	.6413	.3048	.3395
18	.3395	.4763	.3772	.3584	.4904	.3048	.3395
19	.3395	.3429	.2829	.3584	.3206	.3048	.3395
20	.3395	.381	.3395	.3584	.3584	.3239	.3206
21	.3395	.362	.3018	.3584	.3018	.3239	.3395
22	.3395	.362	.3206	.3584	.2615	.3239	.3395
23	.3395	.362	.3236	.3772	.2829	.3429	.3206
24	.3206	.3395	.362	.321	.3772	.3206	.3239
Max	1.5813	1.6409	.7167	1.0098	1.1694	.6036	.362
Min	.2858	.3395	.2829	.3018	.2615	.2615	.3206
Avg	.4929	.5790	.3904	.4531	.5099	.3277	.3372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 207 / 11 KV DHAPEWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)
1		.0189
2		.0189
3		.0189
4		.0189
5		.0189
6		.0189
7		.0189
8		.0189
21	.3018	
Max	.3018	.0189
Min	.3018	.0189
Avg	.3018	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 208 / 11 KV KALMESHWAR U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.9431	.9335	.9431	.9431	1.1168	1.1241
2	.8488	.9054	.9526	.9054	.9808	1.1317	1.1241
3	1.0374	.9054	.9526	.8865	1.0185	1.0374	1.1431
4	.9242	.9054	.9907	.9054	1.0562	1.094	1.1431
5	.9997	.9808	1.0288	.9242	1.094	1.1128	1.2003
6	1.0751	1.0751	1.1241	1.0374	1.1694	1.1317	1.2574
7	1.1694	1.1694	1.2003	1.1694	1.2637	1.1506	1.3336
8	1.3392	1.4335	1.3717	1.3014	1.3203	1.2826	1.5051
9	1.4861	1.4712	1.4712	1.467	1.5089	1.2826	1.448
10	1.4289	1.4523	1.4712	1.448	1.5844	1.4146	1.448
11	1.5432	1.4901	1.4712	1.5623	1.6032	1.5089	1.3717
12	1.467	1.5655	1.5089	1.3527	1.4901	1.4146	1.3146
13	1.3336	1.4523	1.3957	1.3908	1.3957	1.3203	1.2574
14	1.3146	1.4712	1.3203	1.4098	1.3014	1.3203	1.1241
15	1.3527	1.1317	1.2826	1.3336	1.358	1.2826	1.2193
16	1.2955	1.3392	1.3957	1.3957	1.3392	1.3203	1.105
17	1.3769	1.3527	1.3392	1.3203	1.358	1.448	1.2071
18	1.5655	1.5623	1.4246	1.4712	1.5089	1.6194	1.3769
19	1.9616	1.829	1.7353	1.7353	1.7918	1.9433	1.5261
20	1.7918	1.7909	1.6598	1.6032	1.7164	1.829	1.6598
21	1.5844	1.5051	1.5278	1.5089	1.4712	1.5432	1.5089
22	1.3203	1.2955	1.3392	1.3203	1.358	1.4289	1.4523
23	1.094	1.1431	1.1128	1.1317	1.3203	1.2384	1.3203
24	.9242	.9431	.9335	.9997	.9431	1.2826	1.086
Max	1.9616	1.829	1.7353	1.7353	1.7918	1.9433	1.6598
Min	.8488	.9054	.9335	.8865	.9431	1.0374	1.086
Avg	1.2967	1.2964	1.2893	1.2718	1.3289	1.3439	1.3023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 210 / 11 KV AGSEPARATED GHOGLI  
FEEDE Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0189	.0377	.0191
2					.0189	.0343	.0191
3					.0189	.0381	.0191
4					.0189	.0377	.0191
5					.0189	.0377	.0191
6					.0189	.0377	.0191
7					.0189	.0566	.0381
8					.0943	.0943	.1143
9					.1132	.1509	.1143
10	.0191	.0566	.0566	.0381			
11	.0762	.1132	.1132	.1143			
12	.1715	.1142	.132	.1905			
13	.1334	.0943	.1886	.1334			
14	.1334	.0943	.1886	.1143			
15	.1334	.0754	.132	.0762			
16	.1524	.0754	.1132	.1132			
17	.132	.1143	.1132	.0943			
24					.0189	.0377	.0191
Max	.1715	.1143	.1886	.1905	.1132	.1509	.1143
Min	.0191	.0566	.0566	.0381	.0189	.0343	.0191
Avg	.1189	.0922	.1297	.1093	.0359	.0563	.0400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 211 / 11 kv NEW DHAPEWADA SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189					.0189	
2	.0189					.0189	
3	.0189					.0189	
4	.0189					.0189	
5	.0189					.0189	
6	.0189					.0171	
7	.0189			.0189		.0189	
8	.0189			.0171		.0171	
9		.0171			.0189		
10		.0189			.0189		
11		.0189			.0189		
12		.0189			.0189		
13		.0189			.0189		
14		.0189			.019		
15		.0189			.0189		
16		.0189			.019		
17			.019		.0171		.0189
18			.0189		.019		.0189
19			.0189		.019		.0189
20			.0189		.019		.0189
21			.0189		.0189		.0189
22					.0189		.0189
23			.0189		.0189		.0189
24	.0189					.0189	
Max	.0189	.0189	.019	.0189	.019	.0189	.0189
Min	.0189	.0171	.0189	.0171	.0171	.0171	.0189
Avg	.0189	.0187	.0189	.018	.0188	.0185	.0189



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 212 / 11 KV GURUNANAK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.7167	.7049	.4904	.3018	.7545	.2667
2	.2829	.6979	.7049	.4527	.3018	.7167	.2667
3	.2641	.6979	.6859	.4715	.2829	.6036	.2667
4	.2641	.679	.6859	.4715	.2829	.5093	.2858
5	.2829	.679	.6668	.5281	.2829	.4406	.2858
6	.3018	.6979	.6668	.547	.2829	.4527	.2667
7	.3395	.7167	.6668	.5847	.2829	.4527	.2858
8	.3206	.7545	.743	.6413	.2829	.3018	.3048
9	.2667	.7545	.7545	.4191	.2263	.2858	.2667
10	.1905	.9431	.8676	.5335	.2452	.3429	.3239
11	.2858	.8676	.9431	.2286	.2452	.362	.3239
12	.2667	.9431	.9054	.2477	.2263	.3239	.3429
13	.362	.2829	.3018	.1905	.2452	.2667	.3048
14	.2667	.2829	.2641	.1905	.2829	.2858	.3048
15	.2858	.2452	.2829	.2286	1.0562	.3048	.3239
16	.2667	.3206	.2829	.1509		.3048	.3048
17	.2641	.3048	.3206	.2075	.9619	.3048	.2915
18	.3395	.362	.3961	.2829	.9431	.362	.3018
19	.3395	.362	.415	.2829	.3772	.3429	
20	.415	.362	.3772	.3395	.3206	.3239	
21	.7356	.8383	.5847	.2829	.2829	.2858	
22	.811	.743	.5281	.2829	.7922	.2858	
23	.7356	.724	.5658	.3018	.7922	.2667	
24	.759	.7167	.7049	.5093	.3018	.7733	.2667
Max	.811	.9431	.9431	.6413	1.0562	.7733	.3429
Min	.1905	.2452	.2641	.1509	.2263	.2667	.2667
Avg	.3720	.6122	.5842	.3694	.4174	.4022	.2939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 201 / 11 KV Dhapewada town  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3239	.3429	.2241	.3239	.1524	.3361
2	.3174	.3429	.3429	.168	.3429	.1334	.3361
3	.3174	.3429	.3429	.112	.3429	.1334	.3174
4	.3361	.3239	.3429	.1307	.3429	.1334	.3361
5	.3174	.3429	.3429	.1494	.3239	.1334	.2614
6	.3547	.381	.381	.1494	.1905	.1905	.2054
7	.4108	.381	.4001	.2054	.3429	.2096	.2241
8	.3734	.2096		.2054	.4191	.2096	.2241
9	.168	.2096	.1905	.2054	.4001	.1905	.2241
10	.4108	.4191	.2096	.2427	.4001	.4001	.2614
11	.362	.4191	.1867	.381	.362	.4294	.381
12	.362	.1524	.3547	.3429	.362	.4108	.381
13	.1715	.4001	.1494	.3429	.362	.3921	.3048
14	.3429	.381		.381	.362	.3921	.381
15	.3429	.3429	.3547	.362	.362	.3547	.1524
16	.362	.381	.3547	.362	.3429	.4294	.1715
17	.4191	.381	.4108	.4001	.362	.4108	.1905
18	.2286	.2286	.4668	.4001	.2286	.3361	.2477
19	.2858	.3048	.4854	.2858	.3239	.2801	.2858
20	.2477	.2667	.4481	.2667	.2667	.2801	.2477
21	.4382	.2286	.4108	.2286	.2477	.4294	.2286
22	.1715	.2096	.3734	.381	.1715	.3921	.2096
23	.1524	.362	.3361	.362	.1524	.3547	.1715
24	.2987	.3239	.3429	.2801	.3239	.1143	.3174
Max	.4382	.4191	.4854	.4001	.4191	.4294	.381
Min	.1524	.1524	.1494	.112	.1524	.1143	.1524
Avg	.3129	.3191	.3441	.2737	.3191	.2872	.2665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 202 / 11 KV Dhapewada Ag  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2286	.2286	.2054	.2096	.2286	.2427
2	.2054	.2477	.2286	.2241	.2096	.1905	.2427
3	.2054	.2477	.2096	.2054	.2096	.1905	.2614
4	.2241	.2286	.2096	.1867	.2096	.1905	.2427
5	.2054	.2286	.2286	.2054	.2286	.1905	.2801
6	.2427	.2667	.2667	.2054	.2286	.2477	.2987
7	.3174	.3429	.3048	.2801	.2858	.2286	.3361
8	.3921	.4191	.381	.3547	.4191	.362	.4294
9	.5041	.5144	.4763	.4108	.5335	.4763	.5041
10	.5228	.5525	.5716	.4481	.4763	.5335	.5601
11	.6097	.6478	.5788	.6097	.5335	.5415	.5335
12	.6478	.7621	.6348		.6478	.6535	.5144
13	.6478	.8192	.7095	.724	.7049	.6348	.5906
14	.724	.724	.7468	.7811	.6859	.6348	.5906
15	.743	.743	.7468	.7049	.724	.6908	.6097
16	.3429	.743	.7842	.7811	.743	.5975	.5716
17	.743	.7811	.7468	.743	.6859	.5415	.5335
18	.5144	.4191	.3734	.4001	.4001	.4294	.381
19	.4572	.4001	.3547	.381	.3429	.3921	.362
20	.381	.4001	.3174	.3429	.3429	.3734	.3429
21	.3429	.3048	.3174	.3048	.3239	.3174	.3048
22	.2858	.2858	.2614	.2667	.2667	.2987	.2667
23	.2477	.2667	.2241	.2286	.2477	.2614	.2477
24	.2241	.2477	.2286	.2054	.2286	.2477	.2614
Max	.743	.8192	.7842	.7811	.743	.6908	.6097
Min	.2054	.2286	.2096	.1867	.2096	.1905	.2427
Avg	.4148	.4509	.4221	.4000	.4120	.3939	.3962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 203 / 11 KV Purti feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.0191				
11	.1334		.112	.0191	.1307	.0762
12	.1143	.0953	.112		.112	.0762
14	.1143	.0953	.112		.0934	
15	.0953		.112	.0381	.0934	
16	.1334	.1143		.1143	.112	.0953
17	.1143	.1143	.112	.1143	.0934	.1143
Max	.1334	.1143	.112	.1143	.1307	.1143
Min	.0953	.0191	.112	.0191	.0934	.0762
Avg	.1175	.0877	.112	.0715	.1058	.0905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 201 / 11 KV KALMESHWAR NEW URBAN SHEDDABLE URBAN  
FEE Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1524	.1143	.1143	.1143	.1143	.1143
2	.0762	.1143	.0953	.1143	.0953	.1143	.1143
3	.0762	.1143	.0953	.1143	.0953	.0762	.0953
4	.0762	.1143	.1143	.0953	.0953	.0762	.0953
5	.0953	.1524	.1143	.1143	.1143	.0953	.0953
6	.1143	.1905	.1143	.1143	.1143	.1334	
7	.1715	.1905	.1524	.1334	.1524	.2286	.1524
8	.1905	.2286	.1715	.1334	.2096	.2286	.1905
9	.2096	.3429	.2096	.1715	.2096	.2286	.2477
10	.362	.4191	.381	.3429	.4382	.3048	.3048
11	.381	.2286	.3429	.3239	.4954	.3239	.3048
12	.381	.2286	.3429	.381	.4572	.3429	.3048
13	.2096	.1334	.1715	.1524	.2286	.3239	.0953
14	.3239	.1524	.1715	.1334	.4191	.2096	.1905
15	.3429	.3429	.4001	.381	.381	.3429	.2667
16	.381	.2286	.2286	.2096	.362	.362	.3048
17	.2858	.2286	.3429	.3429	.3429	.3429	.2667
18	.3048	.1524	.1715	.1715	.3048	.1905	.1715
19	.2286	.2667	.2096	.2096	.2096	.3048	.2286
20	.2286	.2667	.1905	.2096	.1905	.2858	.1905
21	.2286	.1715	.1905	.1524	.1905	.1905	.1905
22	.1905	.3429	.1715	.1715	.1334	.1905	.1715
23	.1524	.1143	.1334	.1143	.1524	.1334	.1334
24	.0953	.1524	.1143	.1143	.1143	.1143	.1143
Max	.381	.4191	.4001	.381	.4954	.362	.3048
Min	.0762	.1143	.0953	.0953	.0953	.0762	.0953
Avg	.2167	.2096	.1977	.1881	.2342	.2191	.1889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 203 / 11 KV KALMESHWAR AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0381	.0572	.0381	.0572	.0381
2	.0381	.0381	.0381	.0572	.0381	.0572	.0572
3	.0381	.0381		.0381	.0381	.0762	.0381
4	.0381	.0191	.0381	.0381	.0381	.0762	.0381
5	.0381	.0191	.0381	.0381	.0381	.0762	.0572
6	.0572	.0381		.0572	.0572	.1143	.0572
7	.0572	.0572		.0572	.0762	.1143	.0762
8	.0762	.0762	.0572	.1524	.0762	.1143	.0762
9	.0953	.0762	.0381	.0572	.0953	.2286	.0762
10	.0953	.0381	.0381	.0572	.1143	.1905	.0381
11	.1524	.0572	.1334	.0572	.1334	.1715	.0381
12	.1524	.0381	.1143	.0762	.1524	.1715	.0381
13	.1715	.0381	.1143	.0953	.1524	.1905	.1715
14	.1524	.0381	.1334	.1334	.1143	.1334	.0572
15	.1905	.0381	.1524	.1524	.1715	.1334	.0572
16	.1334	.1334	.1524	.1715	.1143	.1143	.0572
17	.0953	.1143	.1524	.1715	.1143	.1524	.0953
18	.0953	.0953	.1143	.0762	.1143	.1143	.0572
19	.0762	.0762	.1143	.0572	.0953	.1143	.0381
20	.0762	.0572	.0953	.0572	.0953	.0762	
21	.0572	.0381	.0762	.0572	.0762	.0572	
22	.0572	.1334	.0572	.0572	.0572	.0572	
23	.0572	.0381	.0572	.0572	.0762	.0572	
24	.0572	.0572	.0381	.0572	.0572	.0572	.0572
Max	.1905	.1334	.1524	.1715	.1715	.2286	.1715
Min	.0381	.0191	.0381	.0381	.0381	.0572	.0381
Avg	.0881	.0588	.0853	.0786	.0889	.1127	.0610

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 204 / 11 KV DAHEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1524	.1524	.1905
2	.1334	.1143	.1143	.1524	.1334	.1334	.1524
3	.1143	.1143	.0953	.1334	.1334	.1143	.1334
4	.1143	.1334	.1334	.1334	.1143	.1715	.1334
5	.1524	.1905	.1334	.1524	.1334	.1905	.1715
6	.1715	.2286	.1524	.1524	.1334	.2286	.1905
7	.2286	.3048	.2096	.1715	.1524	.3239	.2286
8	.4001	.4191	.362	.2667	.3048	.4572	.3048
9	.5716	.5144	.4763	.4572	.4191	.5716	.362
10	.5144	.4572	.5335	.4954	.4763	.5716	.4001
11	.724	.4001	.4954	.4763	.4954	.5335	.2858
12	.4382	.381	.4001	.381	.381	.6097	.1905
13	.5144	.4191	.4191	.4191	.4572	.4954	.3429
14	.4954	.4763	.4572	.381	.4954	.381	.4001
15	.4954	.4954	.4572	.4382	.5335	.4954	.4382
16	.5525	.4954	.5144	.4572	.5335	.4954	.4382
17	.5716	.4954	.4572	.4191	.4572	.4572	.3429
18	.4954	.362	.3048	.362	.4191	.3048	.2286
19	.4191	.2477	.2096	.2286	.3048	.3048	.1905
20	.2096	.2286	.2286	.2096	.2667	.2667	.1905
21	.2096	.1905	.2096	.2286	.2477	.2286	.1715
22	.1905	.1905	.1905	.1905	.2286	.2286	.1524
23	.1905	.1905	.1715	.1715	.1715	.1905	.1334
24	.1715	.1715	.1715	.1715	.1524	.1715	.1905
Max	.724	.5144	.5335	.4954	.5335	.6097	.4382
Min	.1143	.1143	.0953	.1334	.1143	.1143	.1334
Avg	.3429	.3072	.2937	.2834	.3040	.3366	.2485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 205 / 11 KV GHORAD FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4763	.4763	.5525	.4382	.4954	.4572
2	.4763	.4191	.4382	.5525	.4191	.4954	.4191
3	.4572	.4191	.4191	.5335	.4191	.4191	.381
4	.4382	.381	.4572	.5525	.4001	.4191	.381
5	.4763	.381	.5144	.5716	.4191	.4954	.4572
6	.5144	.4191	.5525	.5906	.4572	.6097	.5716
7	.6478	.5144	.724	.6859	.5335	.8383	.6859
8	.9335	.9907	1.1431	.9526	.9145	1.0669	.9145
9	1.3146	1.4861	1.467	1.2765	1.2765	1.4861	1.1431
10	1.3527	1.448	1.5813	1.6194	1.3717	1.5242	
11	1.5432	1.5432	1.5813	1.5051	1.448	1.4861	
12	1.7909	1.6194	1.7147	1.6575	1.6766	1.4861	
13	1.8671	1.8671	1.8099	1.7528	1.6766	1.448	
14	1.8099	1.9052	1.7718	1.7718	1.6575	1.4098	
15	1.7718	1.848	1.6385	1.7718	1.6766	1.3336	
16	1.9052	1.8671	1.9052	1.6575	1.7337	1.7528	
17	1.9052	1.8671	1.8099	1.3146	1.5623	1.6194	
18	1.6004	1.2955	1.1812	1.0669	1.2193	1.1431	
19	.7621	.8002	.8002	.7621	.8383	1.105	
20	.724	.724	.7621	.7049	.7621	.6478	
21	.6478	.6859	.7049	.6478	.743	.6097	
22	.6097	.6287	.6478	.6097	.6478	.5716	
23	.5144	.5525	.5906	.4001	.5716	.5144	
24	.4954	.5144	.5144	.5716	.4382	.5335	.4572
Max	1.9052	1.9052	1.9052	1.7718	1.7337	1.7528	1.1431
Min	.4382	.381	.4191	.4001	.4001	.4191	.381
Avg	1.0439	1.0272	1.0502	1.0034	.9709	.9796	.5868



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 401 / 33 kv INDUSTRIAL  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2829	2.612	2.572	.9054	2.6978	2.6595	2.572
Max	.2829	2.612	2.572	.9054	2.6978	2.6595	2.572
Min	.2829	2.612	2.572	.9054	2.6978	2.6595	2.572
Avg	.2829	2.612	2.572	.9054	2.6978	2.6595	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 402 / 33 KV Kohali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.5432	6.0928	5.7156	5.715	5.6927	5.6584	5.6584
Max	1.5432	6.0928	5.7156	5.715	5.6927	5.6584	5.6584
Min	1.5432	6.0928	5.7156	5.715	5.6927	5.6584	5.6584
Avg	1.5432	6.0928	5.7156	5.715	5.6927	5.6584	5.6584

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 405 / 33KV OMCO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0288	1.1031	1.6575	2.0936	1.6004	2.037	1.6004
Max	1.0288	1.1031	1.6575	2.0936	1.6004	2.037	1.6004
Min	1.0288	1.1031	1.6575	2.0936	1.6004	2.037	1.6004
Avg	1.0288	1.1031	1.6575	2.0936	1.6004	2.037	1.6004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 406 / 33 kv Tirth alloy  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 407 / 33 kv PUROHIT

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 408 / 33 kV KSL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.7922	1.0288	1.0288	.7356	1.0288	.7356	.6859
Max	.7922	1.0288	1.0288	.7356	1.0288	.7356	.6859
Min	.7922	1.0288	1.0288	.7356	1.0288	.7356	.6859
Avg	.7922	1.0288	1.0288	.7356	1.0288	.7356	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 409 / 33 kv Bazargaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	8.6877	5.5156	5.487	4.6965	5.2012
Max	8.6877	5.5156	5.487	4.6965	5.2012
Min	8.6877	5.5156	5.487	4.6965	5.2012
Avg	8.6877	5.5156	5.487	4.6965	5.2012



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 410 / 33 KV DHAPEWADA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.5093	.5487	.5144	.5093	.503	.3961	.5144
Max	.5093	.5487	.5144	.5093	.503	.3961	.5144
Min	.5093	.5487	.5144	.5093	.503	.3961	.5144
Avg	.5093	.5487	.5144	.5093	.503	.3961	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 411 / 33 KV KALMESHWAR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 412 / 33 KV FETRI

Feeder KV- 33 / INCOMING

DATE	01-FEB-18
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 806 / 220 kV Ispat

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	20.5762	14.7081	12.1933	13.203	17.947	16.2209	12.5743
Max	20.5762	14.7081	12.1933	13.203	17.947	16.2209	12.5743
Min	20.5762	14.7081	12.1933	13.203	17.947	16.2209	12.5743
Avg	20.5762	14.7081	12.1933	13.203	17.947	16.2209	12.5743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 201 / 11kV Khapa-U-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.4715	.6602	.5281	.5658		.4715
2	.547	.4715	.5847	.5281	.5658		.4904
3	.547	.4338	.5281	.5281	.5658		.5093
4	.4904	.4338	.4715	.4904	.5281		.5281
5	.4904	.4338	.4338	.4904	.5281		.547
6	.415	.4338	.3961	.4904	.4527		.5658
7	.3772	.4715	.3772	.4904	.415		.5658
8	.415	.5658	.415	.415	.415		.5658
9	.415	.415	.4904		.415	.4904	.6036
10	.4715	.415	.5281		.415	.5093	.6036
11	.4715	.415	.5658		.415	.5093	.6413
12	.4715	.3772	.6036		.415	.5093	.6413
13	.5281	.3772	.6036		.415	.5093	.6413
14	.5658	.3772	.6413		.415	.5281	.6602
15	.6602	.3772	.6413		.415	.5281	.6602
16	.6602	.3772	.6036		.4527	.5281	.6602
17	.6602	.3772	.6036	.5658		.547	.6224
18	.679	.3772	.6224	.5847		.5658	.6224
19	.679	.3772	.6413	.5847		.5658	.6036
20	.5658	.415	.6413	.6224		.547	.6036
21	.5658	.4715	.6036	.6224		.5281	.6036
22	.4715	.5093	.6036	.5658		.4904	.6036
23	.4715	.5658	.5658	.5281		.4715	.5658
24	.547	.4715	.6036	.6224	.5281		.4527
Max	.679	.5658	.6602	.6224	.5658	.5658	.6602
Min	.3772	.3772	.3772	.415	.415	.4715	.4527
Avg	.5297	.4338	.5596	.5411	.4660	.5218	.5847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 204 / 11kV MOIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.415	.4715	.2641	.3395		.3395
2	.3018	.415	.4527	.2641	.3395		.3206
3	.3018	.415	.3772	.2641	.3206		.3206
4	.3018	.415	.2641	.2829	.3206		.3206
5	.3018	.415	.2641	.2829	.3206		.3206
6	.3018	.415	.2641	.2829	.3018		.3018
7	.3018	.4338	.2641	.2829	.2829		.3018
8	.415	.4338	.5281	.2641	.415		.3018
9	.5658	.547	.5658		.5281	.5658	.3772
10	.6602	.5847	.5658		.5281	.6602	.4527
11	.6602	.5847	.6036		.6036	.7356	.5281
12	.8676	.6413	.6413		.6036	.7356	
13	.8676	.6036	.6413		.6413	.6602	.6413
14	.8488	.6036	.3772		.6036	.5281	.5281
15	.8488	.3206	.2829		.415	.3584	.3206
16	.8488	.4527	.3772		.4715	.2641	.3584
17	.8488	.5847	.4904	.3772		.5281	.3772
18	.6979	.7167	.5281	.3772		.6224	.3772
19	.6979	.8299	.4527	.3772		.6036	.3584
20	.6602	.7922	.4527	.3772		.5658	.3395
21	.6602	.7545	.415	.3395		.4527	.3395
22	.5658	.6602	.4338	.3395		.3772	.3395
23	.4715	.6036	.4338	.3395		.3395	.3395
24	.415	.415	.5658	.4338	.3395		.3395
Max	.8676	.8299	.6413	.4338	.6413	.7356	.6413
Min	.3018	.3206	.2641	.2641	.2829	.2641	.3018
Avg	.5714	.5439	.4464	.3218	.4338	.5332	.3715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 205 / 11kV Water Works New

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1886	.0943	.1886		.1886
2	.1509	.1509	.1698	.0943	.1886		.1698
3	.1509	.1509	.1698	.0943	.1886		.1698
4	.1509	.1509	.1509	.0943	.2075		.1509
5	.1509	.1886	.1509	.1509	.2075		.1509
6	.1886	.2452	.2263	.1886	.2075		.2075
7	.1886	.2452	.2452	.2641	.2452		.2452
8	.2263	.2641		.2263	.1698		.2641
9	.2263		.2452		.2263	.2263	.2641
10	.2263		.2641		.2263	.2263	.2452
11	.2263		.2641		.2452	.2263	.2452
12	.2452		.2641		.2452	.2452	.2263
13	.2452		.2641		.2452	.2452	.2452
14	.2452		.2263		.2263	.2452	.2452
15	.2452		.1886		.2263	.2641	.2263
16	.2452		.1886		.2263	.2641	.2263
17	.2452	.2452	.1886	.1886		.2641	.2075
18	.2263	.2452	.1509	.1886		.1132	.2075
19	.2263	.2452	.1509	.2075		.1132	.1886
20	.1886	.2263	.0943	.2075		.2075	.1886
21	.1886	.2263	.0943	.2075		.2075	.1886
22	.1886	.2075	.0943	.2075		.2075	.1509
23	.1509	.2075	.0943	.2263		.2075	.1509
24	.1132	.1509	.1886	.0943	.2263		.1886
Max	.2452	.2641	.2641	.2641	.2452	.2641	.2641
Min	.1132	.1509	.0943	.0943	.1698	.1132	.1509
Avg	.1996	.2063	.1853	.1709	.2175	.2175	.2059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 207 / 11 KV RAMDONGRI

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572			.4715		
2	.4904			.4715		
3	.4904			.4715		
4	.4904			.4715		
5	.4904			.4715		
6	.4904			.4715		
7	.4904			.4715		
8	.4904			.4527		
9		.4715			.3395	
10		.4715			.3395	
11		.4715			.3395	
12		.3772			.3395	
13		.3772			.3584	
14		.3772			.3772	
15		.4715			.3772	
16		.415			.3772	
17			.4527			.4904
18			.4527			.3018
19			.4715			.3018
20			.4527			.3018
21			.4715			.3018
22			.4715			.3395
23			.4715			.3395
24				.4715		
Max	.4904	.4715	.4715	.4715	.3772	.4904
Min	.2572	.3772	.4527	.4527	.3395	.3018
Avg	.4613	.4291	.4634	.4694	.356	.3395



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 208 / 11 KV Kothulna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.3772	.4527	.4527	.5093		.3395
2	.4904	.3772	.415	.415	.5093		.3395
3	.4904	.3772	.3961	.415	.5093		.3395
4	.4527	.3772	.3395	.3961	.5281		.3206
5	.4527	.3772	.2829		.5281		.3206
6		.3772	.2452	.3772	.5281		.3206
7	.415	.4338	.2263	.3584	.5658		.3018
8	.3395	.4715	.3395		.5658		.3018
9	.3395	.4715	.3772		.5281	.3961	.3772
10	.3395	.4715			.4904	.4715	.3772
11	.3395	.4715	.415		.5847	.3961	.415
12	.3395	.4338	.4338		.415	.3961	.4338
13	.3018	.4527	.4338		.415	.415	.4527
14	.3018	.4527	.4338		.415	.415	.415
15	.3018	.6036	.4338		.2641	.1698	.3395
16		.6036	.415		.2829	.1509	.3772
17		.5847	.415	.3584		.2829	.415
18		.2829	.4527	.3772		.3395	.5281
19		.2263	.4904	.3772		.3395	.4715
20	.6036	.3206	.4904	.415		.3395	.5658
21	.6036	.3961	.4904	.415		.3584	.5658
22	.6036	.415	.4904	.4338		.3584	.5658
23	.5658	.4338	.5658	.4338		.3584	.7167
24	.4904	.5093	.4527	.4527	.415		.3584
Max	.6036	.6036	.5658	.4527	.5847	.4715	.7167
Min	.3018	.2263	.2263	.3584	.2641	.1509	.3018
Avg	.4348	.4291	.4125	.4055	.4738	.3458	.4149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 209 / 11 KV Waki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.3772	.5093	.5281	.3961		.4338
2		.3772	.4715	.4904	.3961		.4207
3		.3772	.4527	.4904	.415		.4338
4		.3772	.4338	.4904	.415		.415
5		.3772	.415	.4527	.4338		
6		.3772	.3961	.4527	.4338		.415
7	.4904	.3772	.3772	.415	.4527		.415
8	.3772	.4715	.4527	.3584	.4338		.415
9		.4527	.5281		.5281	.415	.4527
10	.415	.4527	.5658		.547	.4338	.4527
11	.415	.4527	.6413		.6224	.4338	.4904
12	.415	.5281	.6413		.6036	.4338	.4904
13	.415	.5281	.679		.6036	.4527	.5093
14	.4527	.4527	.6413		.5281	.4527	.4527
15	.4527	.4527	.6224		.2641	.3395	.3584
16	.4527	.7733	.4904		.2641	.3206	.415
17	.4527	.7545		.3772		.3961	1.2072
18	.4527	.4527	.4904	.3772		.3961	
19	.4527	.3772	.5281	.4527		.4338	
20	.5658	.415	.5658	.4527		.4338	
21	.5658	.4527	.6224	.4904		.4338	
22	.5658	.4904	.6224	.4904		.4338	
23	.5658	.5281	.547	.4715		.4338	.8676
24	.4904	.4338	.5658	.5658	.4715		.4338
Max	.5658	.7733	.679	.5658	.6224	.4527	1.2072
Min	.3772	.3772	.3772	.3584	.2641	.3206	.3584
Avg	.4715	.4629	.5330	.4598	.4593	.4162	.5044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 401 / 33kv I/C Khapa- Parshioni

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.9602	1.0517	.9602	.8642		.8688
2	.7773	.9602	1.0059	.9602	.7682		.8688
3	.7773	.9602	1.0059	.9602	.7682		.8688
4	.7773	.9602	1.0059	.9602	.8642		.8688
5	.7773	.9602	.9602	.9602	.8642		.8688
6	.7773	.9602	.9602	1.1883	.8642		.823
7	.5487	.9602	.9602	.9602	.9602		.823
8	.5487	.9602	.9145	.9602	.9602		.823
9	.5487	1.1317	.9602		.9145	1.1883	.8642
10	.7316	1.1317	1.0082		.9145	.9602	.8642
11	.7316	.9619	1.0082		.9145	.9602	2.4006
12	.7316	1.0185	1.0082		.9145	.9602	2.4006
13	.7316	1.0185	1.0082		.9145	.9602	2.4966
14	.823	1.0185	1.0082		.9145	1.2346	2.4006
15	.823	1.3014	1.0082		.9145	1.2346	2.4006
16	.9145	.9145	.8642		.9145	.7773	.7202
17	.9602	.9602		.8642		.8688	.8642
18	1.1043	.9602	.8688	.8642		1.0059	
19	1.1043	1.0059	.8688	.9602		1.0059	
20	1.1043	1.0059	.8688	.9602		1.0059	
21	1.3014	1.0059	.8688	1.0082		.9145	
22	1.1043	1.0059	.8688	1.0082		.9145	
23	.9602	1.0517	.9145	1.0082		.9145	
24	.0514	.9602	1.0517	.9145	.8642		.9145
Max	1.3014	1.3014	1.0517	1.1883	.9602	1.2346	2.4966
Min	.0514	.9145	.8642	.8642	.7682	.7773	.7202
Avg	.8120	1.0056	.9586	.9686	.8879	.9937	1.2855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 201 / 11 kv Kochhi Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4481	.4656	.4338	.4207	.4527	.4854
2	.4207	.4294	.4163	.4527	.4108	.4294	.4481
3	.4108	.4294	.3921	.4338	.3921	.4294	.4294
4	.3921	.4108	.3761	.4338	.4108	.4294	.4668
5	.4294	.4108	.3761	.4294	.4481	.4294	.4854
6	.462	.4715	.3801	.4572	.4706	.4668	.5228
7	.4706	.5415	.394	.4938	.3841	.5041	.5228
8		.4656	.4477	.4344	.4344	.4435	.3801
9	.543	.5316	.5194	.4578	.5249	.567	.4887
10	.5973	.5914	.5552		.5533		.5304
11	.543	.591	.5014	.5249	.4835	.5201	.394
12	.5792	.5194	.4917	.543	.5087	.5144	.3761
13	.5792	.543	.4973	.5792	.5138	.5144	.394
14	.5731	.5552	.4973	.5792	.5304	.5487	.394
15	.5611	.4656	.4973	.3982	.547	.5895	.2534
16	.2241	.3224	.2883	.3142	.2713	.2987	.2481
17	.2012	.3582	.3224	.3258	.3052	.3734	.2507
18	.5601	.4706	.499	.5249	.4801	.5228	.5731
19	.8962	.8238	.8962	.8326	.8417	.8962	.8954
20	.8589	.8954	.9242	.7733	.8962	.8962	.8775
21	.8488	.8417	.8299	.8215	.811	.8402	.8589
22	.6908	.724	.6413	.6602	.6036	.679	.5552
23	.5041	.6268	.5658	.679	.5658	.5041	.5552
24	.4527	.4668	.5373	.4338	.4338	.4527	.4904
Max	.8962	.8954	.9242	.8326	.8962	.8962	.8954
Min	.2012	.3224	.2883	.3142	.2713	.2987	.2481
Avg	.5321	.5389	.513	.5225	.5101	.5349	.4948

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 202 / 11 kv Sironji

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4119		.4607	.4527	.4298	.4527	
2	.394		.3898	.4527	.4119	.4481	
3	.394		.3224	.4527	.394	.4481	
4	.3761		.3189	.4527	.4119	.4481	
5	.4119		.3366	.4481	.4477	.4481	
6	.4477		.3582	.439	.4835	.5228	
7	.4656		.3582	.439	.4835	.5228	
8		.4572	.4075	.2896	.4119	.2957	
9	.5552	.5973	.5138	.407	.5373	.2926	.4572
10	.4784	.5138	.3898		.4835		.4207
11	.3544	.394	.2149	.4835	.2713	.2715	.5138
12	.3544	.3898	.2035	.5014	.2652	.3439	.5493
13	.3721	.4252	.2652	.5014	.1989	.3439	.4961
14	.394	.4477	.2652	.4119	.1989	.3258	.4784
15	.4298	.3544	.1989	.4835	.1989	.3258	.2328
16		.2865	.2035	.3658	.1989		.2481
17		.3224	.2149	.3045	.2035		.2658
18		.394	.4435	.4656	.4115		.4607
19		.788	.7468	.8059	.788		.8059
20		.7973	.7545	.8596	.8215		.7796
21		.7619	.7545	.7522	.8299		.7522
22		.6379	.6036	.591	.6036		.4835
23		.5373	.5281	.4835	.5281		.4835
24	.394		.4784	.4527	.4298	.4527	
Max	.5552	.7973	.7545	.8596	.8299	.5228	.8059
Min	.3544	.2865	.1989	.2896	.1989	.2715	.2328
Avg	.4156	.5065	.4055	.4911	.4351	.3962	.4952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 402 / 33kV Chargaon I/C from  
Khapa Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5041	.4835	.4527	.5093	.4527	.5144
2	.4481	.5041	.4298	.4527	.4527	.4481	.4481
3	.3921	.5041	.4298	.4527	.3921	.4481	.4481
4	.3921	.5041	.4298	.4527	.3921	.4481	.4481
5	.4481	.5041	.4344	.4481	.4527	.4481	.5041
6	.5041	.5041	.4344	.4938	.5041	.5041	.5041
7	.5041	.5601	.4835	.4938	.5658	.5041	.5041
8		.823	.6984	.7059	.7282	.7207	.7842
9	.9774	.9877	.8596	.9156	.9328	1.0974	.9328
10	.9877	.9671	.8688		.9774		.9425
11		.9134	.7522	.9231	.7956	.8145	.9134
12	.9328	.8688	.763	.9231	.7459	.8688	.8596
13	.9328	.8596	.7459	.9774	.6962	.8779	.8688
14	.9328	.8596	.7459	.9774	.7459	.823	.8596
15	.8779	2.4977	.7956	.8145	.7956	.8962	.2686
16	.2829	.1612	.3052	.3361	.1989	.2801	.2686
17	.3361	.2715	.3224	.3841	.3052	.2829	.3224
18	.5093	.4298	.499	.5041	.463	.5041	.4887
19	.8962	.8688	.8402	.8962	.8596	.8962	.8596
20	.9054	.9134	.9054	.8962	.8962	.9522	.8596
21	.8488	.8688	.8488	.8402	.8488	.8402	
22	.6722	.6984	.679	.6722	.6224	.6722	.591
23	.5601	.4887	.5658	.5093	.5093	.5601	.5973
24	.5041	.5601	.4887	.4527	.5041	.4527	.5093
Max	.9877	2.4977	.9054	.9774	.9774	1.0974	.9425
Min	.2829	.1612	.3052	.3361	.1989	.2801	.2686
Avg	.6522	.7343	.6170	.6511	.6206	.6432	.6216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 201 / SBM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0343	.0286	.0343	.0343	.0305	.0343
2	.0305	.0343	.0286		.0343	.0305	.0343
3	.0305	.0343	.0286	.0351	.0343	.0305	.0343
4	.0305	.0343	.0286		.0343	.0305	.0362
5	.0305	.0343	.0286		.0343	.0335	.0343
6	.0305	.0343	.0286	.0351	.0343	.0305	.0343
7	.0305	.0343	.0286		.0343	.0305	.0343
8	.0305	.0343	.0286	.0362	.0343	.0305	.0343
9	.0305	.0343	.0286	.0343	.0343	.0305	.0343
10	.0343	.0286		.0343	.0305	.0362	
11	.0343	.0286	.0343	.0362	.0305	.0362	.0343
12	.0686	.0286		.0343	.0305	.0343	
13	.0343	.0286	.0343	.0343	.0305	.0343	.0343
14	.0343	.0286		.0343	.0305	.0343	
15	.0343	.0286	.0343	.0362	.0305	.0343	.0343
16	.0343	.0286		.0362	.0305	.0343	
17	.0343	.0286	.0343	.0362	.0305	.0343	.0343
18	.0343	.0286		.0343	.0305	.0343	
19	.0343	.0286	.0343	.0343	.0305	.0343	.0343
20		.0286		.0362	.0305	.0343	
21	.0343	.0286	.0343	.0343	.0857	.0343	.0343
22	.0362	.0286		.0343	.0857	.0362	
23	1.267	.0286	.0343	.0343	.0305	.0343	.0351
24	.0305	.0343	.0286	.0343		.0305	.0343
Max	1.267	.0343	.0343	.0362	.0857	.0362	.0362
Min	.0305	.0286	.0286	.0343	.0305	.0305	.0343
Avg	.0878	.0310	.0309	.0350	.0368	.0331	.0345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 202 / 11 kV Patansawangi R  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.2715	.2134	.2572	.1715	.1696	.2572
2	.1658	.181	.2134	.2572	.1715	.1696	.2572
3	.1658	.181	.1981	.2572	.1715	.1696	.1715
4	.1658	.181	.1981	.2572	.1715	.2543	.1715
5	.1658	.2715	.2286	.2572	.2572	.2543	.2572
6	.2486	.2715	.2591	.2572	.2715	.2543	.2572
7	.2486	.2572	.2591	.3429	.3429	.3391	.3429
8	.3391	.362	.3353	.3429	.4287	.4239	.3429
9	.4239	.4287	.381	.4287	.4287	.4239	.4287
10	.4287	.4572	.4287	.5144	.4239	.4525	.4287
11	.4287	.4268	.4287	.5144	.4239	.4525	.4287
12	.4287	.381	.5144	.5144	.4239	.4287	.4287
13	.4525	.381	.5144	.543	.4239	.4287	.4287
14	.4287	.3048	.4287	.4287	.4239	.4287	.3429
15	.3429	.381	.4287	.4287	.4239	.4287	.3429
16	.3429	.381	.4287	.4287	.4239	.4287	.4287
17	.4287	.381	.4287	.4287	.5087	.4287	.4287
18	.4287	.3048	.4287	.4287	.4239	.3429	.905
19	.4525	.4268	.4287	.5144	.5087	.4287	.4287
20	.4287	.381	.4287	.4287	.5087	.4287	.4287
21	.4525	.3048	.4287	.3429	.4239	.4287	.3429
22	.3429	.3048	.3429	.362	.3391	.2572	.3429
23	.2572	.2134	.2572	.2572	.2543	.2572	.3429
24	.5916	.2715	.1981	.2572	.2715	.2543	.2715
Max	.5916	.4572	.5144	.543	.5087	.4525	.905
Min	.1658	.181	.1981	.2572	.1715	.1696	.1715
Avg	.3469	.3211	.3500	.3771	.3592	.3472	.3670



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 203 / WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.9955	.9145	.9955	.9955	.924	.8573
2	.7392	.9955	1.1706	1.086	.9955	1.1088	.8573
3	.8316	.9955	1.3717		.905	1.2012	.9431
4	.8316	3.3122	1.4083	1.1641	.9955	1.386	1.0288
5	.924	1.086	1.3169	1.1765	1.0288	1.386	1.086
6	.924	.905	1.1888	1.1641	1.086	1.4784	1.2003
7	.924	.8145	1.0974	.905	1.1765	1.386	1.267
8	.8316	.905	.362	.543	.2715	.7392	.2715
9	.8316	.8145	.6401	.6859	.6001	.7392	.7716
10	1.1765	1.0059	.9955	.8573	.924	.9955	.9955
11	1.448	1.3717	1.5384	1.286	1.2012	1.1765	
12	1.448	1.2803	1.5223	1.5384	1.2936	1.1765	1.267
13	1.448	1.6095	1.5384	1.3717	1.386	1.1765	1.3575
14	1.448	1.5546	1.5384	1.3575	1.386	1.267	
15	1.448	1.3717	1.5384	.905	1.2936	1.2003	.7164
16	1.267	1.0059	1.3575	.2715	.7392	.6335	.6335
17	1.1765	1.0974	1.1765	1.0288	.8316	1.2003	.6335
18	1.3575	1.3717	1.1765	1.267	.924	1.1145	.905
19	1.5384	1.3717	1.1765	1.4937	1.386	1.448	1.448
20	1.286	1.4632	1.1765	1.448	1.4784	1.448	1.3432
21	.4525	1.5912	1.1765	1.2003	1.386	1.3717	1.1641
22	1.3575	1.4266	.905	.9955	1.2936	1.1145	.905
23	1.2003	1.4632	.724	.8145	1.0164	1.0288	.6335
24	.5544	1.1765	1.0425	.985	1.1765	.7392	.9955
Max	1.5384	3.3122	1.5384	1.5384	1.4784	1.4784	1.448
Min	.4525	.8145	.362	.2715	.2715	.6335	.2715
Avg	1.0833	1.2910	1.1689	1.0670	1.0738	1.1433	.9673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 204 / Town APDRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.4525	.4031	.5373	.4525	.4382	.4287
2	.3506	.4525	.3856	.5373	.4525	.4382	.4287
3	.3506	.4525	.3856	.5373	.4525	.4382	.4287
4	.3506	.4525	.4031	.5373	.4525	.4382	***
5	.4382	.4525	.4733	.5373	.4525	.5258	.4525
6	.5258	.543	.5609	.5373	.543	.5258	.543
7	.6135	.6335	.6135	.6268	.6335	.6135	.6335
8	.6135	.6335	.6485	.7164	.724	.6135	.724
9	.7011	.6335	.7011	.6859	.6859	.7011	.6859
10	.724	.6935	.8059	.6335	.6935	.724	.7164
11	.6335	.7011	.8059	.724	.6935	.724	.6268
12	.6335	.7011	.7011	.724	.6935	.6001	.6268
13	.6335	.6135	.6135	.724	.6935	.5144	.6268
14	.6335	.5258	.6268		.6935	.543	.6268
15	.543	.5258	.6268	.543	.6135	.4287	.6268
16	.6335	.5258	.6268	.6335	.6068	.6335	.6268
17	.6335	.6135	.6268	.6335	.6068	.6335	.5373
18	.6335	.5258	.7011	.6335	.6135	.6859	.6268
19	.905	.7888	.7888	.8145	.7011	.8145	.7164
20	.8145	.7888	.8596	.8402	.7888	.8145	.7164
21	.6859	.7011	.7164	.724	.7011	.724	.7011
22	.543	.5258	.6268	.543	.6135	.724	.6135
23	.4525	.4382	.5373	.4525	.5258	.543	.5373
24	.3506	.4525	.4031	.5373	.4525	.4382	.543
Max	.905	.7888	.8596	.8402	.7888	.8145	15.656
Min	.3467	.4382	.3856	.4525	.4525	.4287	.4287
Avg	.5727	.5761	.6101	.6267	.6058	.5949	1.2271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 205 / 11 KV Itangoti water supply Feeder KV- 11 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848		.0895		.0857	
2	.0848		.0895		.0848	
3	.0848		.0895		.0857	
4	.0848		.0895		.0857	
5	.0848		.0895		.0857	
6	.0848		.0895		.0857	
7	.0848		.0895		.0857	
8	.0848		.0895		.0857	
9	.0857				.0857	
10		.0895		.0857		.0895
11		.0895		.0857		.0895
12		.0895		.0857		.0895
13		.0895		.0857		.0895
14		.0895		.0857		.0857
15		.0895		.0857		.0857
16		.0895		.0857		.0895
17		.0895		.0857		.0895
18		.0895		.0857		.0895
19		.0905		.0857		.0895
20		.0895		.0857		.0905
21		.0895		.0857		.0905
22		.0895		.0857		.0895
23		.0895		.0857		.0895
24	.3429		.0895		.0857	
Max	.3429	.0905	.0895	.0857	.0857	.0905
Min	.0848	.0895	.0895	.0857	.0848	.0857
Avg	.1107	.0896	.0895	.0857	.0856	.0891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 207 / 11 KV PATANSAWANGI GAOTHAN  
Feeder KV- 11 / OUTGOING

DATE	01-FEB-18
HR	Load (MW)
2	.1524
Max	.1524
Min	.1524
Avg	.1524

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 401 / 33 KV SOOTGIRNI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3306		1.0751	.9054
2			1.3306		1.1317	1.0185
3			1.3306		1.1317	1.1317
4			1.3306		1.1883	1.0185
5			1.3306		1.1883	1.1883
6			1.3306		1.2449	1.0185
7			1.2197		1.1883	1.1317
8			1.2197		1.1883	1.4146
9					1.2449	1.3014
10		1.1088		1.1883	1.358	1.3306
11		1.1088		1.4146	1.358	1.3306
12		1.1088		1.1883	1.4146	1.3306
13		1.1088		1.3014	1.4146	1.3306
14		1.1088		1.358	1.2449	1.3306
15		1.0974		1.4712	1.1883	1.3306
16		1.1088		1.1317	.9054	1.3306
17		1.1088		1.1883	1.1317	1.3306
18		1.1088		1.3014	1.3014	
19				1.2449	1.3014	1.3306
20		1.3169		1.3014	1.2449	1.3306
21		1.3306		1.358	1.358	1.3306
22		1.3306		1.358	1.0185	1.3306
23		1.3306		1.1317	1.0974	1.3169
24	1.0185		1.3306		1.0751	1.0751
Max	1.0185	1.3306	1.3306	1.4712	1.4146	1.4146
Min	1.0185	1.0974	1.2197	1.1317	.9054	.9054
Avg	1.0185	1.1751	1.3060	1.2812	1.2081	1.2386

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 402 / 33 KV Incomer I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	2.3891	1.8107	2.0302	2.6606	2.0508	2.9127
2	1.4043	2.2805	2.0302	2.1399	2.552	2.2611	2.8235
3	1.5083	2.2805	2.2497	2.1399	2.552	2.2085	2.8567
4	1.5083	2.3348	2.2497	2.2497	2.7692	2.4714	2.7692
5	1.6644	2.009	2.3045	2.2497	2.9864	2.3663	22.3709
6	1.8724	1.9547	2.3045	2.2497	3.095	2.4188	3.0407
7	1.9244	1.9004	2.2497	2.0851	3.4208	2.4714	2.4434
8	1.9244	2.1176	1.6461	1.8656	1.6832	1.9456	1.5746
9	2.1325	2.1176	2.0302	2.1176	2.009	2.0508	2.2262
10	2.552	2.4977	2.524	2.2805	2.1845	2.3891	2.4143
11	2.7149	2.8235	3.0727	2.8235	2.4446	2.552	2.3594
12	2.7149	2.6886	3.0178	2.9864	2.5486	2.4434	2.5789
13	2.7149	2.9081	2.9081	2.7778	2.6526	2.3891	2.7166
14	2.7149	2.6886	2.8532	2.4177	2.6526	2.4977	2.4691
15	2.552	2.6337	2.8532	2.1176	2.4446	2.3891	1.9204
16	2.4434	2.2497	2.6337	1.5203	1.9244	1.8461	1.9204
17	2.4434	2.4143	2.4691	2.3891	2.0805	2.552	1.8656
18	2.6063	2.524	2.5789	7.0045	2.1033	2.4977	2.2177
19	1.4661	2.9081	2.6886	3.0407	2.7343	2.9321	2.8829
20	2.8235	2.963	2.6886	2.9321	2.9447	2.9321	2.7435
21	2.7149	2.9081	2.5789	2.552	2.6818	2.8235	2.4691
22	2.4977	2.5789	2.0851	2.1176	2.3663	2.3663	2.0851
23	2.1719	2.4143	1.9753	1.7375	2.2611	2.1176	1.7558
24	1.3003	2.4977	1.9204	2.0302	3.0407	1.9982	3.0247
Max	2.8235	2.963	3.0727	7.0045	3.4208	2.9321	22.3709
Min	1.2483	1.9004	1.6461	1.5203	1.6832	1.8461	1.5746
Avg	2.1508	2.4618	2.4051	2.4940	2.5330	2.3738	3.2684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 403 / 33 KV Incomer II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.156	6.6787	5.4332	5.655	5.2669	5.156	4.9411
2	5.5996	6.8416	5.8253	6.0985	6.6244	5.655	5.104
3	5.9877	6.6787	6.7776	6.653	6.6244	6.4312	4.8325
4	6.0985	6.5158	6.7215	6.9302	6.6787	6.7084	6.4072
5	6.3758	6.5158	7.6738	7.0965	6.5158	7.0965	7.0045
6	6.7084	6.8416	7.5057	7.2074	6.9502	7.54	6.733
7	6.2094	6.9502	6.5535	6.2094	7.276	6.5975	6.5158
8	5.9322	6.9502	5.0412	5.7659	6.19	5.3778	5.7013
9	5.4887	5.647	5.2652	6.5158	5.9728	5.5441	6.0185
10	6.2443	7.2977	6.0985	7.3303	6.3758	5.9728	6.8193
11	7.0588	7.5172	6.653	7.4932	7.3737	6.5158	7.0965
12	6.19	7.6178	6.653	7.6017	6.7084	7.9538	6.9302
13	6.2443	7.8978	6.653	6.5329	6.9302	7.2217	
14	6.8959	6.8896	6.653	6.5158	6.9302	6.8416	5.5441
15	6.2986	6.3855	6.7638	6.07	7.2074	6.5701	4.4353
16	4.0724	5.1532	4.9897	5.4298	4.8788	4.8868	4.4993
17	4.3439	4.9851	4.8788	6.5158	4.8234	4.3439	4.5462
18	7.8732	7.0576	6.0985	7.0588	7.041	6.6787	
19	8.1219	8.1219	7.4846	8.1219	8.2053	7.8732	7.1519
20	7.2531	7.8418	7.54	7.8978	8.1499	7.2017	7.3183
21	6.8416	7.5617	7.2074	7.2817	8.0944	7.276	7.3183
22	7.5474	7.5617	6.9302	6.6244	7.9836	7.0588	6.0985
23	5.9728	5.9934	6.3758	5.4298	5.9877	5.647	5.5441
24	4.4353	6.2986	4.9291	4.9897	5.4841	4.9343	5.2126
Max	8.1219	8.1219	7.6738	8.1219	8.2053	7.9538	7.3183
Min	4.0724	4.9851	4.8788	4.9897	4.8234	4.3439	4.4353
Avg	6.2062	6.8250	6.3627	6.6261	6.6780	6.3784	5.9897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 201 / 11 kV Lonara w/w  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953		.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953	.0953	.0953
9	.0953	.0953	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.0953	.0953
13	.0953	.0953	.0953	.0953	.0953	.0953	.0953
14	.0953	.0953	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0381
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0381
Avg	.0953	.0953	.0953	.0953	.0953	.0953	.0929



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 203 / 11 kV Colony

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	07-FEB-18
HR	Load (MW)
21	.0953
Max	.0953
Min	.0953
Avg	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 204 / 11 kV Polefactory

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.381		.2858	.2858	.381
2	.2858	.2858	.2858	.2858	.2858	.2858	.381
3	.2858	.2858	.2858	.2858	.2858	.2858	.381
4	.2858	.2858	.2858	.2858	.2858	.2858	.381
5	.2858	.2858	.2858	.2858	.2858	.2858	.381
6	.2858	.2858	.381	.2858	.381	.381	.381
7	.381	.2858	.381	.2858	.381	.381	.381
8	.381	.381	.381	.381	.381	.4763	.381
9	.381	.381	.381	.381	.381	.2858	.4763
10	.381	.381	.381	.381	.381	.2858	.381
11	.2858	.2858	.2858	.381	.2858	.2858	.381
12	.2858	.2858	.2858	.4763	.381	.2858	.381
13	.2858	.2858	.2858	.381	.2858	.2858	.381
14	.2858	.2858	.2858	.381	.2858	.2858	.2858
15	.2858	.2858	.2858	.2858	.2858	.2858	.2858
16	.2858	.2858	.2858	.381	.2858	.2858	.2858
17	.2858	.2858	.2858	.381	.2858	.2858	.2858
18	.381	.381	.381	.381	.381	.381	.381
19	.5716	.5716	.5716	.4763	.5716	.5716	.5716
20	.5716	.5716	.5716	.4763	.5716	.5716	.5716
21	.4763	.5716	.4763	.4763	.4763	.5716	.4763
22	.4763	.381	.4763	.381	.4763	.4763	.4763
23	.381	.381	.381	.381	.381	.381	.381
24	.2858	.2858	.381	.2858	.2858	.2858	.381
Max	.5716	.5716	.5716	.4763	.5716	.5716	.5716
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.3493	.3453	.3612	.3645	.3572	.3533	.3929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 207 / 11 kV Mahadula

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905	.1905		.1905
3	.1905	.1905	.1905	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.2858	.2858	.1905	.2858	.1905	.1905
8	.2858	.2858	.2858	.1905	.2858	.2858	.2858
9	.1905	.2858	.2858	.2858	.2858	.2858	.2858
10	.1905	.2858	.1905	.2858	.2858	.1905	.1905
11		.2286	.1905	.2858	.1905	.1905	.1905
12		.1905	.1905	.2858	.1905	.1905	.1905
13		.1905	.1905	.2858	.1905	.1905	.1905
14		.1905	.1905	.1905	.1905	.1905	.1905
15		.1905		.1905	.1905	.1905	.1905
16		.1905		.1905	.1905	.1905	.1905
17		.1905	.1905	.1905	.1905	.1905	.1905
18	.2858	.2858	.1905	.1905	.381	.2858	.1905
19	.2858	.381	.2858	.2858	.381	.381	.2858
20	.2858	.381	.2858	.2858	.2858	.381	.2858
21	.2858	.2858	.2858	.2858	.2858	.2858	.2858
22	.2858	.2858	.2858	.2858	.2858	.2858	.2858
23	.1905	.1905	.1905	.1905	.2858	.2858	.2858
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.2858	.381	.2858	.2858	.381	.381	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2241	.2358	.2208	.2262	.2381	.2319	.2183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 208 / 11 KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.2858	.381	.381	.381	.381	.381	.381
3	.2858	.381	.381	.381	.381	.381	.381
4	.2858	.381	.381	.381	.381	.381	.381
5	.2858	.381	.381	.381	.381	.4763	.381
6	.381	.381	.4763	.381	.381		.4763
7	.4763	.4763	.5716	.4763	.4763	.5716	.5716
8	.4763	.5716	.5716	.5716	.5716	.5716	.5716
9	.5716	.5716	.5716	.5716	.5716	.5716	.5716
10	.5716	.6668	.5716	.6668	.5716	.5716	.6668
11	.5716	.5716	.5716	.5716	.4763	.5716	.5716
12	.5716	.5716	.5716	.5716	.4763	.5716	.4763
13	.5716	.5716	.4763	.4763	.4763	.5716	.4763
14	.4763	.4763	.4763	.4763	.4763	.5716	.381
15	.4763	.4763	.4763	.4763	.4763	.4763	.381
16	.4763	.4763	.4763	.4763	.4763	.4763	.4763
17	.5716	.4763	.4763	.4763	.4763	.5716	
18	.6668	.6668	.6668	.5716	.5716	.5716	
19	.8573	.8573	.7621	.7621	.7621	.7621	
20	.7621	.7621	.7621	.7621	.7621	.7621	
21	.6668	.6668	.5716	.6668	.5716	.6668	
22	.5716	.5716	.4763	.5716	.5716	.5716	
23	.4763	.4763	.4763	.4763	.4763	.4763	
24	.381	.381		.381	.381	.381	.381
Max	.8573	.8573	.7621	.7621	.7621	.7621	.6668
Min	.2858	.381	.381	.381	.381	.381	.381
Avg	.5041	.5239	.5177	.5120	.4961	.5343	.4651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 209 / 11 kV Koradi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1905	.1905	.2858	.2858
2		.1905	.1905	.1905	.1905	.2858	.2858
3		.1905	.1905	.1905	.1905	.2858	.2858
4		.1905	.1905	.1905	.1905	.2858	.2858
5		.2858	.1905	.1905	.1905	.2858	.2858
6		.2858	.2858	.1905	.2858	.2858	.2858
7		.2858	.2858	.2858	.2858	.2858	.2858
8		.2858	.381	.2858	.2858	.2858	.2858
9		.2858	.2858	.381	.2858	.2858	.2858
10		.2858	.2858	.2858	.2858	.2858	.2858
11		.2858	.2858	.2858	.2858	.2858	.2858
12		.1905	.2858	.2858	.1905	.1905	.2858
13		.1905	.1905	.2858	.1905	.1905	.1905
14		.1905	.1905	.1905		.1905	.1905
15		.1905		.1905	.1905	.1905	.1905
16		.1905		.1905	.1905	.1905	.1905
17		.1905	.1905	.2858	.1905	.1905	.1905
18	.381	.2858	.2858	.2858	.2858	.2858	.2858
19	.381	.381	.381	.381	.381	.381	.381
20	.381	.381	.381	.381	.381	.381	.381
21	.2858	.2858	.381	.381	.2858	.381	.381
22	.2858	.2858	.381	.2858	.2858	.381	.2858
23	.2858	.2858	.2858	.2858	.2858	.2858	.2858
24	.1905	.1905	.1905	.1905	.1905	.2858	.2858
Max	.381	.381	.381	.381	.381	.381	.381
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.3130	.2501	.2685	.2620	.2485	.2778	.2778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 210 / 11 kV Lonkhairy

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1905	.1905	.1905	.1905
2		.1905	.1905	.1905	.1905	.1905	.1905
3		.1905	.1905	.1905	.1905	.1905	.1905
4		.1905	.1905	.1905	.1905	.1905	.1905
5		.1905	.1905	.1905	.1905	.1905	.1905
6		.1905	.1905	.1905	.1905	.1905	.1905
7		.1905	.1905	.1905	.1905	.2858	.1905
8		.2858	.2858	.1905	.1905	.2858	.2858
9		.381	.381	.2858	.2858	.381	.2858
10		.381	.381	.4763	.381	.381	.2858
11			.2858	.5716	.4763	.381	.2858
12			.2858	.4763	.381	.2858	.2858
13		.381	.2858	.381	.381	.2858	.2858
14		.381	.2858	.381	.381	.2858	.2858
15		.381	.2858	.381	.381	.2858	.2858
16		.381	.381	.381	.2858	.2858	.2858
17		.381	.381	.381	.1905	.2858	.2858
18	.1905	.381	.2858	.2858	.1905	.2858	.2858
19	.1905	.381	.1905	.1905	.1905	.2858	.1905
20	.1905	.381	.2858	.1905	.1905	.2858	.1905
21	.1905	.2858	.1905	.1905	.1905	.1905	.1905
22	.1905	.2858	.1905	.1905	.1905	.1905	.1905
23	.1905	.1905	.1905	.1905	.1905	.1905	.1905
24	.5334	.1905	.1905	.1905	.1905	.1905	.1905
Max	.5334	.381	.381	.5716	.4763	.381	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2395	.2901	.2540	.2778	.2500	.2580	.2342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 211 / 11 kV Gayatri Bricks  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0191	.0953	.0191	.0191	.0762	.0572
2	.0572	.0191	.0953	.0191	.0191	.0762	.0572
3	.0381	.0191	.0953	.0191	.0191	.0762	.0953
4	.0381	.0191	.0953	.0191	.0191	.0762	.0953
5	.0381	.0191	.0953	.0191	.0191	.0762	.0953
6	.0381	.0191	.0953	.0191	.0191	.0762	.0953
7	.0381	.0191	.0953	.0381	.0191	.0191	.0953
8	.0191	.0191	.0953	.0381	.0191	.0191	.0953
9		.0953	.0191	.0381	.0191	.0191	.0953
10	.0191	.0953	.0953	.0191	.0191	.0191	.0381
11	.0381	.0953	.0953	.0191	.0381	.0191	.0381
12	.0381	.0953	.0953	.0191	.0381	.0191	.0381
13	.0572	.0953	.0953	.0191	.0572	.0191	.0381
14	.0572	.0953	.0953	.0191	.0191	.0191	.0381
15	.0381	.0953		.0191	.0191	.0191	.0381
16	.0381	.0953		.0191	.0191	.0191	.0381
17	.0381	.0572	.0572	.0191	.0191	.0191	.0191
18	.0381	.0381	.0953	.0191	.0381	.0191	.0191
19	.0381	.0953	.0953	.0191	.0381	.0191	.0381
20	.0381	.0953	.0953	.0191		.0191	.0953
21	.0381	.0381	.0953	.0191	.0381	.0191	.0953
22	.0191	.0381	.0953	.0191	.0381	.0572	.0191
23	.0191	.0953	.0953	.0191	.0381	.0572	.0381
24	.0381	.0191	.0953	.0953	.0191	.0762	.0572
Max	.0572	.0953	.0953	.0953	.0572	.0762	.0953
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0381	.0580	.0901	.0247	.0265	.0389	.0596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 213 / 11 KV Panjara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905		.1905	.1905
3	.1905	.1905	.1905	.1905		.1905	.1905
4	.1905	.1905	.1905	.1905		.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.2858	.1905	.1905	.1905	.1905
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.2858	.1905	.1905	.1905	.1905	.1905	.1905
12	.2858	.1905	.1905	.1905	.1905	.1905	.1905
13	.2858	.1905	.1905	.1905	.1905	.1905	.1905
14	.1905	.1905	.1905	.1905		.1905	.1905
15	.1905	.1905	.1905	.1905	.1905	.1905	.1905
16	.1905	.1905	.1905	.1905	.1905	.1905	.1905
17	.1905	.1905	.1905	.1905	.1905	.1905	.1905
18	.1905	.1905	.1905	.1905	.2858	.1905	.1905
19	.2858	.2858	.2858	.2858	.2858	.2858	.2858
20	.2858	.2858	.2858	.2858		.2858	.2858
21	.2858	.2858	.1905	.2858	.2858	.2858	.2858
22	.1905	.1905	.1905	.1905	.2858	.1905	.1905
23	.1905	.1905	.1905	.1905	.1905	.1905	.1905
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2143	.2024	.2024	.2024	.2106	.2024	.2024



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 214 / NANDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2858	.1905	.1905	.1905	.1905	.1905
2	.1905	.1905	.1905	.1905	.1905	.1905	.1905
3	.1905	.1905	.1905	.1905	.1905	.1905	.1905
4	.1905	.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	.1905
8	.2858	.1905	.2858	.1905	.1905	.2858	.1905
9	.2858	.2858	.381	.2858	.2858	.4763	.1905
10	.381	.381	.381	.381	.381	.4763	.2858
11	.381	.381	.2858	.381	.381	.4763	.1905
12	.381	.381	.2858	.381	.381	.4763	.1905
13	.2858	.381	.381	.381	.2858	.4763	.1905
14	.2858	.381	.381	.381	.2858	.4763	.1905
15	.2858	.381	.381	.381	.2858	.381	.1905
16	.381	.381	.381	.381	.2858	.381	.1905
17	.2858	.2858	.381	.381	.381	.381	.1905
18	.381	.381	.381	.381	.381	.4763	.2858
19	.381	.381	.381	.381	.381	.4763	.2858
20	.381	.4763	.381	.381	.381	.4763	.2858
21	.2858	.381	.2858	.381	.2858	.381	.2858
22	.1905	.2858	.2858	.2858	.2858	.2858	.2858
23	.1905	.2858	.1905	.2858	.1905	.1905	.2858
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.381	.4763	.381	.381	.381	.4763	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2739	.3016	.2897	.2977	.2739	.3374	.2183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 216 / MODERN SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.2858	.2858	.2858	.381
2	.2858	.2858	.2858	.2858	.2858	.2858	.381
3	.2858	.2858	.2858	.2858	.2858	.2858	.381
4	.2858	.2858	.2858	.2858	.2858	.2858	.381
5	.2858	.2858	.2858	.2858	.2858	.2858	.381
6	.2858	.2858	.381	.2858	.2858	.2858	.381
7	.381	.381	.381	.2858	.381	.381	.4763
8	.4763	.4763	.4763	.381	.4763	.4763	.4763
9	.6668	.5716	.5716	.4763	.5716	.6668	.5716
10	.7621	.6668	.7621	.6668	.6668	.6668	.4763
11	.7621	.6668	.7621	.6668	.6668	.6668	.4763
12	.6668	.6668	.5716	.6668	.6668	.6668	.381
13	.5716	.5716	.5716	.6668	.6668	.6668	.381
14	.4763	.5716	.5716	.5716	.5716	.6668	.381
15	.4763	.4763	.5716	.5716	.5716	.4763	.2858
16	.4763	.4763	.5716	.4763	.4763	.4763	.2858
17	.4763	.4763	.381	.4763	.4763	.4763	.2858
18	.4763	.4763	.5716	.4763	.4763	.5716	.381
19	.5716	.5716	.5716	.5716	.4763	.5716	.4763
20	.5716	.5716	.5716	.5716	.4763	.5716	.4763
21	.4763	.4763	.4763	.4763	.4763	.4763	.4763
22	.4763	.4763	.4763	.4763	.4763	.4763	.4763
23	.381	.381	.381	.381	.381	.381	.4763
24	.6287	.2858	.2858	.2858	.2858	.2858	.381
Max	.7621	.6668	.7621	.6668	.6668	.6668	.5716
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.4787	.4565	.4723	.4525	.4565	.4723	.4128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 401 / 33 KV Incomer I(Uppalwadi NON SHEDDABLE EXPRESS HV FEEDERS  
 I) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.5716	.5716	.6859	.5716
2	.5716	.5716	.5716	.5716	.5716	.6859	.5716
3	.5716	.5716	.5716	.5716	.5716	.6859	.8573
4	.5716	.5716	.5716	.5716	.5716	.6859	.8573
5	.5716	.5716	.5716	.5716	.5716	.6859	.8573
6	.5716	.5716	.8573	.5716	.5716	.6859	.8573
7	.8573	.8573	.8573	.5716	.8573	.743	.8573
8	1.1431	.8573	1.1431	.5716	.8573	.8573	.8573
9	.5716	1.1431	.8573	.8573	.8573	.9717	.8573
10	1.1431	1.1431	.8573	.8573	.8573	.8573	.8573
11	.9145	.5716	.8573	1.1431	.8573	.8573	.8573
12	.6859	.5716	.8573	1.1431	.8573	.5716	.8573
13	.743	.8573	.743	.8573	.8573	.5716	.5716
14	.743	.8573	.743	.8573	.8573	.5716	.5716
15	.5716	.8573		.8573		.5716	.5716
16	.8002	.8573		.8573	.5716	.5716	
17	.8002	.5716	.8002	.8573	.5716	.5716	
18	.8573	.8573	.8573	.8573		.8573	
19	.8573	1.1431	1.1431	.8573	.9717	1.1431	
20	.8573	1.1431	1.1431	.8573	.8573	1.1431	
21	.8573	.8573	.8573	.8573	.8002	.8573	
22	.8573	.8573	.8573	.8573	.8002	.8573	
23	.5716	.8573	.8573	.5716	.8002	.5716	
24	.5716	.5716	.5716	.5716	.5716		.5716
Max	1.1431	1.1431	1.1431	1.1431	.9717	1.1431	.8573
Min	.5716	.5716	.5716	.5716	.5716	.5716	.5716
Avg	.7430	.7859	.8054	.7621	.7378	.7505	.7502

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 402 / 33 KV INCOMER II(UPPALWADI NON SHEDDABLE EXPRESS HV FEEDERS  
 II) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.572	2.8578	2.572	2.8578	2.8578	2.8578
2	2.572	2.572	2.572	2.572	2.8578	2.8578	2.8578
3	2.572	2.572	2.572	2.572	2.8578	2.8578	2.8578
4	2.572	2.572	2.572	2.572	2.8578	2.8578	2.8578
5	2.572	2.572	2.572	2.572	2.8578	2.8578	2.8578
6	2.8578	2.8578	2.572	2.8578	3.1436	3.1436	3.1436
7	3.1436	3.1436	3.4294	3.1436	3.4294	3.4294	3.4294
8	4.0009	3.4294	3.7151	3.4294	3.7151	3.8866	3.4294
9	4.0009	4.0009	3.7151	4.0009	4.0009	4.7439	4.0009
10	4.2867	4.2867	4.2867	4.2867	4.2867	4.7439	4.0009
11	4.2295	3.8295	3.8866	4.2867	4.0009	4.0009	3.4294
12	3.9438	3.7151	3.7151	4.2867	4.0009	4.0009	3.1436
13	3.6008	3.4294	2.572	4.0009	3.4294	4.0009	3.1436
14	3.2579	3.4294	2.572	3.4294		4.0009	2.8578
15	3.1436	3.315	3.315	3.4294	3.1436	3.1436	2.8578
16	3.2579	3.2579	3.0864	3.4294	3.1436	3.1436	2.8578
17	3.315	3.1436	3.2007	3.4294	3.4294	3.7151	2.8578
18	3.7151	3.7151	4.0009	3.7151		4.0009	3.4294
19	4.5725	4.5725	4.2867	4.2867		4.5725	4.2867
20	4.2867	4.8583	4.5725	4.2867	4.401	4.8583	4.2867
21	4.0009	4.2867	4.0009	4.0009	3.7723	4.2867	4.2867
22	3.4294	3.7151	3.7151	3.7151	3.7723	4.0009	4.0009
23	3.1436	3.1436	3.1436	3.1436	3.2007	3.1436	3.4294
24	2.572	2.572	2.8578	2.8578	2.8578	2.8578	2.8578
Max	4.5725	4.8583	4.5725	4.2867	4.401	4.8583	4.2867
Min	2.572	2.572	2.572	2.572	2.8578	2.8578	2.8578
Avg	3.4008	3.3984	3.3246	3.4532	3.4294	3.6651	3.3341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 201 / 11 KV Rohana Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.1753	.1753	.1753	.1753	.1753
2	.1753	.1753	.1753	.1753	.1753	.1753	.1753
3	.1753	.1753	.1753	.1753		.1753	.1753
4	.1753	.1753	.1753	.1753	.1753	.1753	.1753
5	.1753	.1753	.1753	.1753	.1753	.1753	.1753
6	.1753	.1753	.1753	.1753	.2629	.1753	.1753
7	.1753	.1753	.2629	.1753	.1753	.2629	.1753
8	.2629	.2629	.2629	.2629	.1753	.2629	.1867
9	.2629	.2629	.3506	.2629	.1753	.2629	.1753
10	.3544	.2629	.4382	.2629	.2629	.2629	.4382
11	.1772	.4382	.4382	.3506	.2629	.3506	.3506
12	.2658	.4382	.4382	.3506	.2629	.3506	.3506
13	.3544	.4382	.4382	.4382	.3506	.3506	.4382
14	.443	.4382	.4382	.4382	.1753	.4382	.3506
15	.4382	.4382	.4382	.4382	.4382	.4382	.4382
16	.4334	.4382	.3506	.3506	.4382	.4382	.4382
17	.4334	.4382	.4382	.3506	.4382	.3506	.4382
18	.4334	.3506	.3506	.3506	.4382	.3506	.4382
19	.4668	.3506	.3506	.3506	.4382	.3506	.3506
20	.4668	.3506	.3506	.3506	.4382	.3506	.3506
21	.3734	.3506	.2629	.2629	.3506	.3506	.2629
22	.3734	.2629	.2629	.2629	.2629	.2629	.2629
23	.3734	.2629	.1753		.2629	.2629	.2629
24	.3429	.2801	.1753	.1753	.1753	.1753	.1753
Max	.4668	.4382	.4382	.4382	.4382	.4382	.4382
Min	.1753	.1753	.1753	.1753	.1753	.1753	.1753
Avg	.3118	.3038	.3031	.2820	.2820	.2885	.2890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 203 / Silewara

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	1.1203	1.2536	1.307	.7468	1.2536	1.307
2	1.3432	1.4003	1.4327	1.307	1.4937	1.4327	1.587
3	1.4327	1.4937	1.6118	1.4003		1.6118	1.6804
4	1.5223	1.587	1.7909	1.587	1.4937	1.7909	1.6804
5	1.6118	1.6804	1.7909	1.4937	1.4937	1.6118	1.1203
6	1.4327	1.2136	1.6118	1.307	1.6804	1.2536	1.307
7	1.1641	1.0269	.8954	.9335	1.1203	.5373	.7468
8	.8059	.6535	.8954	.8402	.9335	.4477	.7468
9	1.0745	.7468	1.1641	.8402	.9335	.7164	1.4937
10	1.2012	1.4003	1.4937	1.307	1.2136	1.6804	1.6804
11	1.386	1.2136	1.2136	1.2136	1.1203	1.4003	1.4003
12	1.0164	2.0538	1.4937	1.307	.9335	1.6804	1.2136
13	1.4784	1.6804	1.307	1.4937	1.307	1.4937	1.587
14	1.386	1.7194	1.4937	1.4937	1.8671	1.307	
15	1.1088	1.267	1.307	1.1203	1.7737	1.4937	
16	.9335	1.2136	.9335	.9335	.9335	.9335	1.0269
17	1.0269	1.6804	.9335	.9335	.9335	.9335	1.0269
18	1.1088	1.2536	1.1203	1.307	1.5223	1.1203	1.6804
19	1.4937	1.4327	1.4937	1.587	1.4327	1.1203	1.6804
20	1.8671	1.7909	1.307	1.4937	1.7909	1.1203	1.4937
21	1.8671	1.7909	1.6804	1.4937	1.1641	1.307	1.307
22	1.6804	1.7909	1.6804	1.6804	1.5223	1.4937	1.1203
23	.7468	1.2536	1.1203	1.1203	.8954	1.4937	1.1203
24	.3429	1.1203	1.0745	.9335	.5601	.8954	1.4937
Max	1.8671	2.0538	1.7909	1.6804	1.8671	1.7909	1.6804
Min	.3429	.6535	.8954	.8402	.5601	.4477	.7468
Avg	1.2544	1.3993	1.3375	1.2681	1.2550	1.2554	1.3409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 204 / Walni II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.0517	1.0402	.8954	.8859	1.0402	1.1517
2	1.1269	1.1393	1.2136	.985	.8859	1.1269	1.1517
3	1.1269	1.2269	1.2136			1.2136	1.2403
4	1.2136	1.2269	1.387		.8859	1.387	1.4175
5	1.387	1.1393	1.387	1.0631	1.0631	1.4737	1.5061
6	1.5604	1.0517	1.3003	1.4175	.9431	1.387	1.1517
7	1.3003	.964	1.1269	1.0631	1.0631	1.0402	.8859
8	1.9071	1.8671	1.1269	1.6832	1.7718	1.7337	2.0538
9	1.7337	1.7528	1.1269	1.6832	1.7718	1.5604	1.7718
10	1.5061	1.6804	1.2536	1.6118	1.4327	1.4175	1.6832
11	1.3289	1.4899	.985	1.4327	1.2536	.9745	1.3289
12	.8859	1.3146	1.3432	1.3432	1.2403	1.1517	1.2403
13	.8859	1.2269	1.2536	1.2536	1.0631	1.0631	1.1517
14	1.1517	1.2403	1.0745	1.1641	.9745	.9745	1.0631
15	1.1517	1.2403	1.0745	1.0745	1.0631	.9745	1.0631
16		.8954	1.0745	1.0745	.8859	1.0631	1.2403
17		1.0745	.5373	.8859	.5316	.8859	1.1517
18	1.3146	1.1269	.8954	1.1517	1.1269	1.2403	1.2403
19	1.4937	1.4737	1.6118	1.4175	1.4737	1.5947	1.4175
20	1.307	1.5604	1.4327	1.2403	1.387	1.5947	1.4175
21	1.307	1.3003	1.4327	1.2403	1.2136	1.5947	1.2403
22	1.1203	1.2136	1.1641	1.1517	1.1269	1.2403	1.2403
23	.9335	1.1269	1.0745	1.0631	1.0402	1.2403	1.2403
24	1.0402	1.1203	1.0402	.985	.9745	1.0402	1.2403
Max	1.9071	1.8671	1.6118	1.6832	1.7718	1.7337	2.0538
Min	.8859	.8954	.5373	.8859	.5316	.8859	.8859
Avg	1.2647	1.2710	1.1738	1.2218	1.1330	1.2505	1.3037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 206 / 11 KV D point Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934	.0934	.0934	.0934	.0934
2	.0934	.0934	.0934	.0934	.0934	.0934	.0934
3	.0934	.0934	.0934	.0934	.0934	.0934	.0934
4	.0934	.0934	.0934	.0934	.0934	.0934	.0934
5	.0934	.0934	.0934	.0934	.0934	.0934	.0934
6	.0934	.0934	.0934	.0934	.0934	.0934	.0934
7	.0934	.0934	.0934	.0934	.0934	.0934	.0934
8	.0934	.0934	.0934	.0934	.0934	.0934	.0934
9	.0934	.0934	.0934	.0934	.0934	.0934	.0934
10	.0934	.0934	.0934	.0934	.0934	.0934	.0934
11	.0934	.0934	.0934	.0934	.0934	.0934	.0934
12	.0934	.0934	.0934	.0934	.0934	.0934	.0934
13	.0934	.0934	.0934	.0934	.0934	.0934	.0934
14	.0934	.0934	.0934	.0934	.0934	.0934	.0934
15	.0934	.0934	.0934	.0934	.0934	.0934	.0934
16	.0934	.0934	.0934	.0934	.0934	.0934	.0934
17	.0934	.0934	.0934	.0934	.0934	.0943	.0934
18	.0934	.0934	.0934	.0934	.0934	.0934	.0934
19	.0934	.0934	.0934	.0934	.0934	.0934	.0934
20	.0934	.0934	.0934	.0934	.0934	.0934	.0934
21	.0934	.0934	.0934	.0934	.0934	.0934	.0934
22	.0934	.0934	.0934	.0934	.0934	.0934	.0934
23	.0934	.0934	.0934	.0934	.0934	.0934	.0934
24	.0934	.0934	.0934	.0934	.0934	.0934	.0934
Max	.0934	.0934	.0934	.0934	.0934	.0943	.0934
Min	.0934	.0934	.0934	.0934	.0934	.0934	.0934
Avg	.0934	.0934	.0934	.0934	.0934	.0934	.0934



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 207 / Walni I

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	2.0748	1.6975	1.1317	1.5089	1.6975	1.8861
2	2.0748	2.2634	1.8861	1.4146	2.2634	1.8861	2.0748
3	2.2634	2.3577	2.0748	1.6975		2.0748	2.452
4	2.2634	2.4272	2.452	2.0748	2.0748	2.452	2.452
5	2.452	.0943	2.6406	1.8861	2.0748	2.6406	2.6406
6	2.452	2.6139	2.452	2.2634	2.8006	2.8292	2.8292
7	2.2634	2.6406	2.2634	2.2634	2.8292	2.452	2.452
8	.8488	.9431	.8488	.9431	1.3203	.9431	.7545
9	1.3203	.9431	1.3203	1.1317	1.3203	1.1317	1.4146
10	2.8292	2.6406	2.8292	2.7349	1.6032	1.8861	1.8861
11	2.8292	2.8292	2.6406	3.0178	2.6406	2.2634	2.2634
12	2.8292	2.8292	2.7349	2.8292	.9431	3.0178	2.0748
13	2.8292	2.6406	2.452	2.6406	2.2634	2.7349	2.0748
14	2.452	2.2634	2.5463	2.3577	2.0748	2.452	1.8861
15	2.2405	1.8861	1.9805	2.0748	2.0748	2.3577	1.6975
16	1.1203	1.307	1.4146	1.6975	1.3203	1.3203	1.226
17	1.8861	1.6975	1.8861	2.2634	2.0748	1.3203	1.6975
18	2.8006	2.452	2.1691	2.452	2.5463	2.2634	2.0748
19	2.5206	2.452	2.452	2.6406	2.8292	2.6406	2.2634
20	2.5206	2.6406	2.2634	2.6406	2.6406	2.6406	2.2634
21	2.8006	2.452	2.3577	2.3577	2.6406	2.6406	2.2634
22	2.5206	2.452	2.3577	2.2634	2.6406	2.452	2.0748
23	1.4937	1.8861	1.8861	1.5089	1.8861	2.452	1.7918
24	1.226	.9335	1.1317	.7545	1.5089	1.226	1.8861
Max	2.8292	2.8292	2.8292	3.0178	2.8292	3.0178	2.8292
Min	.8488	.0943	.8488	.7545	.9431	.9431	.7545
Avg	2.1889	2.0717	2.1141	2.0433	2.0817	2.1573	2.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 402 / 33 KV Incomer NON SHEDDABLE EXPRESS HV FEEDERS  
 II(Bhagimari) Feeder KV- 33 / (NON-CONTINUOUS PROCESS)(NO  
 INCOMING STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4353	4.7611	4.4353	3.9209	3.6408	4.4353	4.7611
2	4.9383	5.3212	4.9383	4.201	5.0412	4.6639	5.3212
3	5.487	5.6013	5.2126	4.7611		5.2126	5.6013
4	5.487	5.6013	6.0357	5.0412	4.7611	6.0357	5.8814
5	5.7613	5.8814	6.31	4.7611	5.3212	6.31	5.6013
6	5.7613	5.8814	5.7613	5.6013	6.1614	6.0357	5.8814
7	5.2126	5.0412	4.9383	4.7611	5.6013	4.4353	4.481
8	3.8809	3.9209	3.3265	3.9209	4.481	3.6037	4.201
9	4.6639	3.9209	4.1581	4.201	4.481	4.1581	5.3212
10	6.1614	6.1614	6.4415	6.1614	4.7611	5.3212	5.8814
11	6.1614	6.4415	5.6013	6.1614	5.6013	5.3212	5.6013
12	5.3212	7.0016	6.1614	5.8814	3.6408	6.4415	5.0412
13	5.8814	6.1614	5.6013	6.1614	5.3212	5.8814	5.6013
14	5.6013	6.1614	5.8814	5.6013	5.3212	5.3212	3.3608
15	5.3212	5.0412	4.7611	5.0412	5.6013	5.6013	3.6408
16	2.8006	3.9209	4.201	4.201	3.6408	3.9209	
17	3.3608	4.7611	3.9209	4.481	4.201	3.6408	4.7611
18	6.1614	5.2126	4.7611	5.3212	5.7613	5.3212	5.6013
19	6.1614	6.0357	6.1614	6.1614	6.8587	6.1614	6.1614
20	6.4415	6.5844	5.6013	5.8814	6.31	6.1614	5.8814
21	6.4415	6.0357	5.8814	5.6013	5.487	6.1614	5.3212
22	5.6013	6.0357	5.6013	5.6013	5.7613	5.6013	5.0412
23	5.0412	4.7611	4.481	4.201	4.4353	5.6013	4.7611
24	3.6037	4.481	3.6037		3.3608	3.6037	5.3212
Max	6.4415	7.0016	6.4415	6.1614	6.8587	6.4415	6.1614
Min	2.8006	3.9209	3.3265	3.9209	3.3608	3.6037	3.3608
Avg	5.2370	5.4470	5.1574	5.1142	5.0240	5.2063	5.1751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 201 / 11 kV Khaperkheda  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.5658	.5914	.679	.6653	.6722	.6722
2	.6478	.547	.5601	.6602	.6348	.6348	.6413
3	.6668	.5658	.5228	.6413	.6036	.6535	.6161
4	.6668	.6413	.6099	.6602	.6838	.7545	.6535
5	.7621	.7545	.6838	.679	.7842	.8676	.7922
6	.8002	.8775	.8029		.9149	1.0562	.9431
7	1.2003	1.1389	1.1203		1.1458	1.1576	1.2136
8	1.105	1.1203	1.1643	1.0751	1.1458	1.1576	1.1317
9	1.1431	1.1458	1.1458	1.2449	1.1016	1.1088	1.1694
10	1.1317	1.1458	1.1827	1.1763	1.0903	1.1888	1.0829
11	.9877	.9877	1.1203	1.1273	.961	1.1203	1.0059
12	.7421	.8413	.9335	1.0719	.8962	.9335	.8507
13	.7421	.8326	.8962		.8962		.8326
14	.7522	.788	.8589		.823		.7164
15	.7701	.7682	.8215		.724		.724
16	.7796	.6984	.7842		.7343	.7655	.6697
17	.8413	.8686	.8402		.8779	.9335	.7421
18	1.0924	1.0498	1.0456	.9709	1.1041	1.2696	1.1088
19	1.3676	1.386	1.363	1.2382	1.3676	1.46	1.307
20	1.2883	1.2936	1.2323	1.2323	1.2696	1.3443	1.1088
21	1.1016	1.0903	1.1203	1.1827	1.1576	1.1694	1.1389
22	.8676	.9055	.9431	1.0164	.9522	.9808	.9896
23	.6535	.7095	.7356	.7947	.7577	.7167	.8589
24	.6097	.6036	.5914	.679	.6838	.7167	.7095
Max	1.3676	1.386	1.363	1.2449	1.3676	1.46	1.307
Min	.6097	.547	.5228	.6413	.6036	.6348	.6161
Avg	.8903	.8886	.9029	.9488	.9156	.9839	.9033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 202 / 11 kV Bhanegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3018	.3206	.2987	.3395	.3361
2			.2801	.3018	.2801	.3206	.3174
3			.2829	.3018	.2829	.3018	.2987
4			.3206	.3206	.3018	.3206	.3174
5			.3547	.3395	.3174	.3395	.3395
6			.3921	.3772	.3395	.3772	.4108
7			.4108	.415	.415	.3961	.4338
8			.4904	.415	.4294	.4715	.4481
9			.679	.4904	.5658	.547	.4527
10			.6036	.4481	.5658	.6099	.4294
11		.439	.5601	.4527		.5601	.5975
12		.3881	.5228	.3772		.4715	
13		.3658	.4854	.3206		.4108	
14		.3511	.4481	.3772		.4294	
15		.3696	.4294	.3584		.415	.4163
16		.439	.4481	.3772			.5601
17		.4435	.4527	.3772			.6283
18		.5415	.4854	.3584	.415	.5601	.5601
19		.6908	.6602	.5093	.6224	.6653	.5975
20		.5415	.5975	.4904	.5041	.5658	.547
21		.5228	.4904	.4715	.4904	.4481	.547
22		.4481	.4527	.3921	.4904	.415	.4527
23		.3395	.3772	.3174	.3961	.3961	.4338
24	.2801		.3018	.3395	.2987	.3772	.3772
Max	.2801	.6908	.679	.5093	.6224	.6653	.6283
Min	.2801	.3395	.2801	.3018	.2801	.3018	.2987
Avg	.2801	.4523	.4512	.3854	.4126	.4426	.4524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 203 / 11 KV WCL BHANEGAON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2071	1.1883	.7468	.7922	.811
2			1.1203	1.1317	.6908	.811	.8676
3			1.0374	1.0562	.6413	.8299	.9242
4			1.1128	1.094	.7356	.811	.9149
5			1.1883	1.0374	.8488	.9054	.9522
6			1.2696	.9997	.9808	.8676	.9997
7			1.0082	1.1694	.7922	.9054	.9522
8			1.3014	1.1694	.7922	.9054	1.1317
9			1.2696	1.1317	1.0269	.8686	1.1389
10			1.1317	1.1203	.9709	1.2136	1.094
11		.679	1.0829	1.1949	1.2826	1.1203	.811
12		1.3306	1.0456	1.0562		1.0082	.9619
13		1.2567	1.1203	1.0185		1.0456	
14		.8962	1.1576	.8215		1.1694	
15		.6348	1.1203	1.0562		1.2136	.4294
16		1.0903	1.1389	1.0562			1.1317
17		1.0456	1.1763	1.2136			.8299
18		1.358	1.2136	1.2071	1.1317	1.1576	1.0562
19		1.1458	1.094	.9709	1.358	1.251	3.2253
20		1.3443	1.2323	.9997	1.307	1.2449	.9997
21		1.3306	1.2826	1.0185	1.2883	1.094	.9896
22		1.1088	1.1317	1.0185	1.0374	1.1317	1.0456
23		1.1317	1.1506	.811	.8488	.8488	.9149
24	1.1088		1.2826	1.2071	.811	.7922	.7842
Max	1.1088	1.358	1.3014	1.2136	1.358	1.251	3.2253
Min	1.1088	.6348	1.0082	.811	.6413	.7922	.4294
Avg	1.1088	1.1040	1.1615	1.0728	.9606	.9994	1.0439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 401 / 33 KV GCR1

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.0008	.1008	.0008	.1029	.1019
2	.1143		.0008	.1064	.0007	.1029	.1075
3	.1143	.1029	.0007	.1008	.0008	.1029	.1019
4	.1143	.1029	.0008	.1019	.0008	.1029	.1008
5	.1143	.1029	.0007	.1019	.0007	.1029	.1064
6	.1143	.1029	.0006	.1019	.0006	.1029	.1019
7	.1143	.1029	.0007	.1019	.0007	.1029	.1075
8	.1143	.1029	.0008	.1132	.0008	.1029	.1019
9	.1143	.1029	.0008	.1132	.0008	.1029	.1075
10	.1029	.1029	.0008	.1075	.0008	.1029	.1132
11	.1029	.0009	.1019	.0008	.1029	.112	.1029
12	.1029	.0008	.1008	.0008	.1029	.1075	.1029
13	.1029	.0008	.1008	.0008	.1029	.1075	.1029
14	.1029	.0007	.1019	.0008	.1029	.1064	.1029
15	.1029	.0008	.1019	.0008	.1029	.1064	.1029
16	.1029	.0007	.1075	.0006	.1029	.1064	.1029
17	.1029	.0008	.1064	.0008	.1029	.1064	.1029
18	.1029	.0008	.112	.0007	.1029	.112	.1029
19	.1029	.0008	.1019	.0008	.1029	.1109	.1029
20	.1029	.0009	.1019	.0008	.1029	.1075	.1029
21	.1029	.0008	.1019	.0009	.1029	.1075	.1029
22	.1029	.0008	.1019	.0008		.1019	.1029
23	.2743	.0008	.1008	.0008	.1029	.1019	.1029
24	.1143	.1029	.0008	.1008	.0009	.1029	.1075
Max	.2743	.1029	.112	.1132	.1029	.112	.1132
Min	.1029	.0007	.0006	.0006	.0006	.1019	.1008
Avg	.1148	.0426	.0562	.0484	.0541	.1053	.1040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 402 / 33 KV GCR2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1029	.0008	.1008	.0008	.1029	.1019
2	.1143	.1029	.0008	.1075	.0007	.1029	.1008
3	.1143	.1029	.0007	.1019	.0008	.1029	.1008
4	.1143	.1029	.0008	.1075	.0008	.1029	.1019
5	.1143	.1029	.0006	.1019	.0007	.1029	.1008
6	.1143	.1029	.0006	.1019	.0006	.1029	.1075
7		.1029	.0007	.1075	.0007	.1029	.1008
8	.1143	.1029	.0008	.1019	.0008	.1029	.1064
9	.1143	.1029	.0008	.1019	.0008	.1029	.1064
10	.1029	.1029	.0008	.1132	.0008	.1029	.1008
11	.1029	.0009	.1008	.0008	.1029	.1064	.1029
12	.1029	.0008	.1008	.0008	.1029	.1019	.1029
13	.1029	.0008	.1019	.0008	.1029	.1064	.1029
14	.1029	.0007	.1019	.0008	.1029	.1008	.1029
15	.1029	.0008	.1008	.0008	.1029	.1064	.1029
16	.1029	.0007	.1064	.0006	.1029	.1019	.1029
17	.1029	.0008	.1064	.0008	.1029	.1064	.1029
18	.1029	.0008	.1064	.0007	.1029	.112	.1029
19	.1029	.0008	.1019	.0008	.1029	.1109	.1029
20	.1029	.0009	.1019	.0008	.1029	.1075	.1029
21	.1029	.0008	.1019	.0009	.1029	.1019	.1029
22	.1029	.0008	.1019	.0008	.1029	.1019	.1029
23	.1029	.0008	.1075	.0008	.1029	.1019	.1029
24	.2743	.1029	.0008	.1019	.0009	.1029	.1075
Max	.2743	.1029	.1075	.1132	.1029	.112	.1075
Min	.1029	.0007	.0006	.0006	.0006	.1008	.1008
Avg	.1143	.0476	.0562	.0483	.0561	.1041	.1031

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 403 / 33 KV Incomer I(KANHAN) NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0936	2.0513	2.0936	1.6804	1.8673	1.8673
2	2.0576	2.0936	1.9605	1.9805	1.5684	1.8107	1.8107
3	2.0576	2.0513	1.8107	1.8107	1.5278	1.8107	1.8107
4	2.0576	2.1502	1.9753	1.9805	1.6804	1.9239	1.9239
5	1.1431	2.1502	2.1845	2.037	1.9239	2.1502	2.1502
6	1.1431	2.1502	2.4331	2.037	2.1502	2.3765	2.2634
7	2.6863	2.7161	2.5463	2.4646	2.32	2.4897	2.5463
8	2.7435	2.7726	2.9687	2.7161	2.3765	2.4897	2.5206
9	2.6863	2.8292	3.0247	2.7161	2.6326	2.6029	2.6029
10	2.6595	2.6595	2.8567	2.7726	2.6326	2.9127	2.4646
11	2.4331	2.1285	2.999	2.8567	2.6886	2.7161	2.3765
12	2.2634	2.6886	2.8006	2.6029	2.2068	2.4646	1.8107
13	2.1845	2.5206	2.6886	2.2965	2.5206	2.4086	1.8673
14	2.2634	2.1845	2.6886	2.037	2.4086	2.4086	1.5278
15	2.1845	1.7541	2.6326	2.2068	2.2965	2.4086	1.4003
16	2.1845	2.2497	2.5206	2.2634	2.384	2.3525	2.2731
17	2.3285	2.3285	2.7161	2.4086	2.1502	2.3525	2.1285
18	2.8275	2.8829	2.8858	2.4086	2.4897	3.0247	2.6326
19	2.9424	3.1927	3.0247	2.7161	3.3608	3.271	3.2253
20	2.9424	3.1367	2.8292	2.7161	3.0556	3.1121	2.6595
21	2.7161	2.9687	2.8006	2.6595	2.8858	2.6326	2.6595
22	2.1502	2.4897	2.1502	2.4331	2.3765	2.4331	2.5463
23	2.1502	2.1502	2.1502	1.9239	1.9239	1.9805	2.2634
24	1.829	2.1502	2.1845	2.2068	1.7718	1.9239	1.9239
Max	2.9424	3.1927	3.0247	2.8567	3.3608	3.271	3.2253
Min	1.1431	1.7541	1.8107	1.8107	1.5278	1.8107	1.4003
Avg	2.2788	2.4372	2.5368	2.3477	2.2922	2.4135	2.2190



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 201 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0554	.0554	.0739	.0739	.0549	.0549
2	.0532	.037	.0554	.0739	.0554	.0549	.0549
3	.0532	.037	.0554	.0739	.0554	.0549	.0549
4	.0532	.037	.0554	.0739	.0554	.0549	.0549
5	.0532	.0554	.0554	.0739	.0554	.0732	.0549
6	.0709	.0554	.0554	.0739	.0554	.0732	.0732
7	.0709	.0739	.0554	.0739	.0554	.0732	.0732
8	.0709	.0554	.0554	.0739	.0554	.0732	.0732
9	.0532	.0554	.0739	.0739	.0739	.2012	.0366
10	.0709	.0554	.0924	.0739	.0924	.1829	.0549
11	.0709	.0739	.0739	.0739	.0924	.1829	.0549
12	.0709	.0739	.0924	.0554	.0924	.2012	.0732
13	.0532	.0739	.0924	.0739	.2033	.2012	.0549
14	.0532	.0739	.0739	.0554	.2033		
15	.0914	.0739	.0924	.0739	.2033	.0732	
16	.0739	.0924	.0924	.0924	.2033	.0554	
17	.0739	.0924	.0924	.0739	.2033	.0732	.0732
18	.0739	.0739	.0739	.0554	.1848	.0549	.0732
19	.0549	.0739	.0924	.0739	.1848	.0732	.0549
20	.0554	.0739	.0924	.0739	.2012	.0732	.0549
21	.0554	.0739	.0924	.0554	.0914	.0549	.0549
22	.0554	.0739	.0924	.0739	.0732	.0549	.0549
23	.037	.0554	.0739	.0739	.0732	.0549	.0549
24	.0532	.0554	.0554	.0739	.0739	.0549	.0549
Max	.0914	.0924	.0924	.0924	.2033	.2012	.0732
Min	.037	.037	.0554	.0554	.0554	.0549	.0366
Avg	.0615	.0647	.0747	.0716	.1130	.0915	.0593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 202 / 11 KV Jagdamba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0191	.0381	.0381	.0381	.0381	.0191
4	.0381	.0191	.0381	.0381	.0381	.0191	.0191
5	.0381	.0191	.0381	.0381	.0381	.0191	.0191
6	.0381	.0191	.0381	.0381	.0381	.0191	.0191
7	.0381	.0191	.0381	.0381	.0381	.0191	.0191
8	.0381	.0191	.0381	.0381	.0381	.0381	.0191
9	.0381	.0191	.0381	.0381	.0381	.0191	.0191
10	.0381	.0191	.0381	.0381	.0381	.0191	.0191
11	.0191	.0191	.0191	.0191	.0381	.0191	.0191
12	.0191	.0191	.0191	.0191	.0381	.0381	.0191
13	.0191	.0191	.0191	.0191	.0381	.0381	.0191
14	.0191	.0191	.0191	.0191	.0381	.0381	
15	.0191	.0191	.0191	.0191	.0381	.0191	
16	.0191	.0191	.0191	.0191	.0381	.0191	
17	.0191	.0191	.0191	.0191	.0381	.0191	.0191
18	.0381	.0191	.0191	.0191	.0381	.0381	.0381
19	.0381	.0381	.0572	.0381	.0381	.0572	.0381
20	.0381	.0381	.0381	.0381	.0572	.0572	.0572
21	.0381	.0381	.0381	.0381	.0381	.0572	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.1829	.0381	.0381	.0381	.0381	.0381	.0381
Max	.1829	.0381	.0572	.0381	.0572	.0572	.0572
Min	.0191	.0191	.0191	.0191	.0381	.0191	.0191
Avg	.0386	.0254	.0326	.0318	.0389	.0326	.0282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 201 / 11KV PARSEONI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058		.3086	.2229	.2572	.2915
2	.2229	.2058		.3086	.2229	.2572	.2743
3	.2229	.2058	.2572	.2915	.2229	.2572	.2743
4	.2401	.2058	.2572	.2915	.2229	.2572	.2915
5	.2401	.2401	.2401	.2743	.2229	.2572	.2743
6	.2572	.2743	.3086	.2915	.2915	.3086	.3258
7	.2915	.3086	.3429	.2915	.3258	.3601	.3772
8		.3601	.3772	.3601	.3944	.3601	.4115
9	.3086	.3429	.3772	.4115	.3944	.3772	.3772
10	.3258	.3086		.4115	.3772	.3086	.3429
11	.3258	.3258		.3258	.3601	.3429	.3086
12	.2915	.3429		.3258	.3429	.3086	.3429
13		.3429		.3086	.3086	.3429	.3086
14	.3258			.2915	.2743	.3772	.3772
15	.2915	.2743		.3258	.3772	.3772	.3429
16	.3086	.2743		.4115	.3772	.3772	.3601
17	.3258	.2743		.4115	.2572	.3429	.3601
18	.3601	.3772	.0343	.3601	.3601	.3772	.463
19	.4287	.463	.12	.4458	.4287	.4458	.4115
20	.3601	.4115	.3601	.3944	.4115	.4287	.3772
21	.3258	.3772	.4458	.3601	.3944	.3601	.3601
22	.2915	.3258	.3601	.3429	.3772	.3258	.3429
23	.2229	.2743	.2915	.2915	.2915	.2915	.2743
24	.2058	.2058	.2572	.2915	.2572	.2572	.2915
Max	.4287	.463	.4458	.4458	.4287	.4458	.463
Min	.2058	.2058	.0343	.2743	.2229	.2572	.2743
Avg	.2907	.3012	.2878	.3386	.3215	.3315	.3401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 202 / 11 KV PARASEONI RURAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4287	.5316	.4973			
2	.4973	.4287	.5316	.4973			
3	.4973	.4287	.5316	.5144			
4	.5144	.4287	.5487	.5316			
5	.5316	.4801	.6344	.5316			
6	.5658	.5487	.6516	.583			
7	.6001	.6173	.6859	.6516			
8	.6687	.5658	.7373	.823			
9	.7545	.7202	.7202	.823			
10	.6859	.6687					
11	.6687	.5658					
12	.463	.6173					
13	.6516	.4287	.2229				
14	.4458	.6001	.823				
15	.583	.703	.7716				
16	.7202	.7202					
17	.7545	.7545					
18	.7202	.7202	.7202				
19	.8745	.8402	1.0288				
20	.7716	.8402					
21	.703	.6516	.583				
22		.6344	.5487				
23	.463	.5316	.5144				
24	.4801	.4287	.5316	.4973	.4801	.5316	.5316
Max	.8745	.8402	1.0288	.823	.4801	.5316	.5316
Min	.4458	.4287	.2229	.4973	.4801	.5316	.5316
Avg	.6136	.5980	.6287	.5950	.4801	.5316	.5316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 203 / 11 KV SURYLATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1372	.1543	.1543	.1372	.1543
2	.1543	.1372	.1372	.1543	.1543	.1372	.1372
3	.1372	.1372	.1372	.1543	.1543	.1372	.1372
4	.1372	.1372	.1372	.1372	.1372	.1372	.1372
5	.1543	.1372	.1372	.1372	.1372	.1372	.1372
6	.1715	.1715		.1543	.1715	.1543	.1715
7	.1886	.2058	.2058	.2058	.2058	.2058	.1886
8	.1886	.1715	.1886	.2058	.1715	.1886	.1715
9	.1886	.1715	.1886	.2229	.1886	.1886	.1886
10	.1543	.1715	.1543	.2229	.1543	.1543	.1715
11	.1372	.12	.1372		.1543	.1372	.1372
12	.12	.12	.1372	.1372	.12	.1372	.12
13	.12	.12	.1372	.1372	.1372	.1372	.12
14	.1029	.12	.1372	.1543	.1543	.1372	.12
15	.12	.12	.1372	.1372	.1372	.12	.12
16	.12	.1372	.12	.1372	.1372	.0857	.12
17	.1372	.12	.1543	.1372	.1372	.1372	.12
18	.1715	.1543	.1715	.1715	.1372	.1543	.1715
19	.2743	.2743	.2229	.2401	.2572	.2401	.2229
20	.2401	.2401	.2229	.2401	.2401	.2229	.2229
21	.1886	.2229	.2058	.2229	.2058	.2058	
22	.1543	.1715	.1886	.1886	.1715	.1715	.1715
23	.1372	.1543	.1543	.1543	.1543	.1543	.1543
24	.1543	.1372	.1372	.1372	.1543	.1372	.1543
Max	.2743	.2743	.2229	.2401	.2572	.2401	.2229
Min	.1029	.12	.12	.1372	.12	.0857	.12
Avg	.1586	.1579	.1603	.1715	.1636	.1565	.1543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 204 / 11KV TAMSWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3944	.2743	.3601			
2	.463	.3944	.3086	.3944			
3	.463	.3944	.3086	.3944			
4	.463	.3944	.3429	.4287			
5	.4973	.4458	.3944	.4287			
6	.5487	.5144	.4801	.4973			
7	.583	.583	.5487	.6173			
8	.6344	.703	.6001	.5658			
9	.7202	.6859	.6344	.4801			
10	.6173	.5316					
11	.6173	.6001					
12	.6173	.6001					
13		.6173					
14	.7373	.6001					
15	.583	.4115					
16	.6344	.6173					
17	.703	.4458					
18	.6516	.6687	.7545				
19	.823	.6344	1.0974				
20	.7888	.4973	.9945				
21	.7545	.6859	.8916				
22	.4287	.5658	.703				
23	.3601	.4973	.5487				
24	.4458	.3944	.2743	.3429	.3258	.463	.4973
Max	.823	.703	1.0974	.6173	.3258	.463	.4973
Min	.3601	.3944	.2743	.3429	.3258	.463	.4973
Avg	.5905	.5366	.5723	.4510	.3258	.463	.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSHIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 205 / 11 kV MIDC Industrial  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4908	.373	.3641	.3294	.3294	.3052	.3561
Max	.4908	.373	.3641	.3294	.3294	.3052	.3561
Min	.4908	.373	.3641	.3294	.3294	.3052	.3561
Avg	.4908	.373	.3641	.3294	.3294	.3052	.3561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 207 / AG SEPERATION FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0171
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0171	.0171	.0171	.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171	.0171	.0171
16	.0171	.0171	.0171	.0171	.0171	.0171	.0171
17	.0171	.0171	.0171	.0171	.0171	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0171	.0171



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 201 / Bitoli AG Separated

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1265	.1311		.0983	.0983	.0791	.0949
2	.1265	.1311		.0983	.0983	.0791	.0949
3	.1265	.1311		.0983	.0983	.0791	.0949
4	.1265	.1311		.0983	.0983	.0791	.0949
5	.1265	.1311		.0983	.0983	.0791	.0949
6	.1265	.1475		.0983	.0983	.0791	.0949
7	.1265	.0983		.0905	.0983	.0633	.0949
8	.0949	.0983		.0983	.1311	.1107	.0949
9	.0983		.1311	.1147	.1581	.1265	.0995
10	.1311		.1311	.116	.2056	.1265	.1326
11	.1802		.1638	.1966	.2056	.1898	.1326
12	.1966		.1966	.213	.2214	.1898	.116
13	.2294		.213		.2372	.2056	.1658
14	.2534		.2622		.253	.2372	
15	.213		.2622		.2056	.253	.116
16	.2294		.2622		.1898	.2372	.1823
17	.2294		.1966		.1898	.2214	.1823
18	.1475		.0983	.1326	.0949	.1107	.0663
19	.1311		.1147	.1311	.0791	.0949	.0995
20	.1475		.0983	.1311	.0791	.0949	.0995
21	.1311		.0983	.1326	.0791	.0949	.0995
22	.1311		.0983	.116	.0791	.0949	.0995
23	.1311		.0983	.116	.0791	.0949	.0995
24	.1265	.1311		.0983	.0995	.0791	.0949
Max	.2534	.1475	.2622	.213	.253	.253	.1823
Min	.0949	.0983	.0983	.0905	.0791	.0633	.0663
Avg	.1536	.1256	.1617	.1198	.1365	.1292	.1107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 202 / INDUSTRIAL -H.T.-FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543		.0543	.0724	.0724	.0724
2		.0543		.0724	.0543	.0724	.0724
3		.0543		.0724	.0543	.0724	.0724
4		.0362		.0724	.0543	.0724	.0724
5		.0543		.0724	.0724	.0724	.0724
6		.0724		.0724	.0724	.0724	.0724
7		.0724		.0724	.0724	.0724	.0724
8		.0724		.0724	.0724	.0724	.0724
9			.0543	.0724	.0724	.0543	.0543
10			.0362	.0543	.0543	.0543	.0181
11			.0724	.0724	.0543	.0543	.0181
12			.0543	.0543	.0543	.0543	.0724
13			.0362		.0362	.0362	.0543
14			.0362		.0181	.0181	.0543
15			.0362		.0181	.0181	.0543
16			.0362		.0181	.0362	.0543
17			.0724		.0543	.0543	.0724
18			.0724	.0724	.0724	.0724	.0724
19			.0362	.0543	.0543	.0543	.0362
20			.0362	.0362	.0362	.0543	.0362
21			.0543	.0543	.0362	.0362	.0362
22			.0724	.0724	.0543	.0362	.0362
23			.0543	.0724	.0724	.0543	.0362
24	.2103	.0724		.0543	.0724	.0724	.0724
Max	.2103	.0724	.0724	.0724	.0724	.0724	.0724
Min	.2103	.0362	.0362	.0362	.0181	.0181	.0181
Avg	.2103	.0603	.0507	.0648	.0543	.0558	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 203 / 11KV CHARGAON FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566		.0566	.0377	.0566	.0377
2	.0377	.0566		.0566	.0566	.0566	.0377
3	.0377	.0566		.0754	.0377	.0566	.0377
4	.0189	.0566		.0754	.0377	.0566	.0377
5	.0754	.0566		.0754	.0566	.0566	.0566
6		.0754		.0754	.0754	.0566	.0566
7	.0754	.0943		.0754	.0943	.1132	.1132
8	.0754	.0943		.0943	.0754	.1132	.0754
9	.0754		.0566	.1132	.0943	.0543	.0759
10	.0754		.0754	.0758	.0943	.0754	.0569
11	.0566		.0566	.0754	.0754	.0377	.057
12	.0189		.0189	.0377	.0377	.0189	.038
13	.0377		.0377		.0377	.0377	.019
14	.0377		.0754		.0754	.0566	.019
15	.0566		.0566		.0566	.0377	.019
16	.0377		.0754		.0566	.0566	.038
17	.0189		.0566		.0158	.0377	.038
18	.0754		.0943	.0759	.0754	.0943	.0761
19	.1132		.1509	.0754	.0943	.1132	.1141
20	.0943		.132	.1132	.1132	.1132	.1141
21	.0943		.132	.1137	.0943	.1132	.0951
22	.0943		.0943	.0948	.0754	.0754	.0761
23	.0566		.0754	.0569	.0566	.0566	.057
24	.0377	.0566		.0566	.0379	.0566	.038
Max	.1132	.0943	.1509	.1137	.1132	.1132	.1141
Min	.0189	.0566	.0189	.0377	.0158	.0189	.019
Avg	.0582	.0671	.0792	.0775	.0651	.0667	.0577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 204 / Bitoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1097		.128	.1097	.1494	.1294
2	.1132	.1097		.1097	.1097	.1494	.132
3	.1132	.1097		.1097	.1097	.1509	.1307
4	.1132	.1097		.1097	.1097	.1478	.1307
5	.1132	.128		.1097	.1097	.1478	.1494
6	.1509	.1463		.1463	.1463	.1663	.1494
7	.1867	.1829		.1829	.2012	.2218	.168
8	.2054	.2195		.2012	.2195	.2353	.2075
9	.1829		.2012	.2012		.1991	.1848
10	.1646		.1829	.1663	.1829	.2012	.1478
11	.132		.1646	.1463	.1646	.1433	.1478
12	.128		.1463	.128	.128	.1254	.1294
13	.0183		.128		.128	.1254	.1109
14	.1097		.128		.1433	.1267	.0924
15	.0914		.1097		.1075	.132	.0739
16	.0914		.128		.1267	.1109	.0924
17	.0914		.1463		.1132	.132	.0924
18	.1646		.1646	.2402	.2033	.2263	.2033
19	.3292		.2926	.3109	.3361	.3395	.3326
20	.3109		.2561	.2926	.2801	.3174	.2772
21	.2378		.2378	.2402	.2641	.2829	.2402
22	.1829		.1886	.1663	.1867	.2263	.2033
23	.1463		.1463	.1294	.1509	.1509	.1478
24	.1132	.128		.128	.1109	.1509	.1294
Max	.3292	.2195	.2926	.3109	.3361	.3395	.3326
Min	.0183	.1097	.1097	.1097	.1075	.1109	.0739
Avg	.1502	.1382	.1747	.1709	.1627	.1816	.1584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 205 / 11 KV SATRAPUR Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	03-FEB-18	04-FEB-18
HR	Load (MW)	Load (MW)
8		.0191
17	.0191	
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 401 / 33 KV SMS RBC Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0572		.0572	.0572	.0572	.0572
2	.0486	.0572		.0572	.0572	.0572	.0572
3	.0486	.0572		.0572	.0572	.0572	.0572
4	.0486	.0572		.0572	.0572	.0572	.0572
5	.0486	.0572		.0572	.0572	.0572	.0572
6	.0486	.0572		.0572	.0572	.0572	.0572
7	.0486	.0572		.0572	.0572	.0572	.0572
8	.0486	.0572		.0572	.0572	.0572	.0572
9	.0572		.0572	.0572	.0572	.0572	.0572
10	.0572		.0572		.0572	.0572	.0572
11	.0572		.0572	.0572	.0572	.0572	.0572
12	.0572		.0572	.0572	.0572	.0572	.0572
13	.0572		.0572		.0572	.0572	.0572
14	.0572		.0572		.0572	.0572	.0572
15	.0572		.0572		.0572	.0572	.0572
16	.0572		.0572		.0572	.0572	.0572
17	.0572		.0572		.0572	.0572	.0572
18	.0572		.0572	.0572	.0572	.0572	.0572
19	.0572		.0572	.0572	.0572	.0572	.0572
20	.0572		.0572	.0572	.0572	.0572	.0572
21	.0572		.0572	.0572	.0572	.0572	.0572
22	.0572		.0572	.0572	.0572	.0572	.0572
23	.0572		.0572	.0572	.0572	.0572	.0572
24	.0486	.0572		.0572	.0572	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0486	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0540	.0572	.0572	.0572	.0572	.0572	.0572

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 402 / 33 KV SMS LBC FEEDER NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572			.0572	.0572
2	.0572			.0572	.0572
3	.0572				.0572
4	.0572				.0572
5	.0572				.0572
6	.0572				.0572
7	.0572			.0572	
8	.0572			.0572	.0572
9			.0572	.0572	.0572
10			.0572	.0572	.0572
11			.0572	.0572	.0572
12			.0572	.0572	.0572
13			.0572	.0572	.0572
14			.0572	.0572	.0572
15			.0572	.0572	.0572
16			.0572	.0572	.0572
17			.0572	.0572	.0572
18			.0572	.0572	.0572
19		.0572		.0572	.0572
20		.0572	.0572	.0572	.0572
21		.0572	.0572	.0572	.0572
22		.0572	.0572	.0572	.0572
23		.0572	.0572	.0572	.0572
24	.0572		.0572	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 201 / nanda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6878	.6859	.6478	1.3717	1.3717	1.9052
2	.5335	.6516	.6859	.6287	1.3717	1.4098	1.9814
3	.4954	.6516	.6859	.5525	1.3717	1.448	2.0576
4	.4954	.6154	.6097	.5335	1.3908	1.4861	2.0195
5	.4572	.6154	.6097	.5335	1.4289	1.5432	2.0576
6	.4191	.5792	.5716	.4954	1.5051	1.5242	2.1338
7	.4191	.543	.5716	.4382	.5715	.4572	.5335
8	2.0957	2.1719	2.2862	1.7909	.5144	.4572	.5716
9	2.0957	2.4434	2.2862	2.3243	.4191	.4191	.4954
10	2.2862	2.8054	2.4768	2.4006	.4191	.381	.4572
11	2.2081	2.8578	2.4387	2.3243	.4191	.4191	.4572
12	2.2624	2.6673	2.4387	2.2862	.381	.4382	.4191
13	2.1719	2.6292	2.3624	2.2862	.4001	.4382	.4191
14	2.0814	2.553	2.3624	2.0957	.4191	.4191	.4001
15	1.9909	2.4768	2.3243	2.0957	.4382	.4191	.381
16	.543	.6478	.4954	.4191	.4382	.4382	.4572
17	.543	.6097	.5335	.4191	.4572	.4954	.5716
18	.5792	.5144	.6097	.7621	.4954	.6097	.6668
19	.6516	.5335	.743	.9526	.6097	.7049	.6478
20	.6878	.6097	.7621	.9526	.6478	.8002	.6478
21	.724	.6478	.8002	1.1431	1.2955	.9907	.6097
22	.724	.6859	.7811	1.2193	1.3146	1.3336	.5716
23	.7421	.7049	.724	1.2574	1.3336	1.3717	.5335
24	.6478	.724	.7049	.6668	1.2193	1.3336	1.6766
Max	2.2862	2.8578	2.4768	2.4006	1.5051	1.5432	2.1338
Min	.4191	.5144	.4954	.4191	.381	.381	.381
Avg	1.0995	1.2761	1.2312	1.2177	.8430	.8629	.9447



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 202 / KHAPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8326	.724	.7811	.2667	.2286	.1905
2	.9907	.905	.724	.8192	.2667	.2286	.1905
3	1.0288	.905	.724	.8764	.2667	.2286	.1905
4	1.1431	.905	.743	.9526	.2667	.2096	.1905
5	1.2955	.9412	.8002	.9526	.2667	.2096	.1905
6	1.3336	.9774	.8573	.9526	.2286	.1905	.2096
7	.2286	.1991	.2286	.1905	.1905	.1905	.2096
8	.1524	.1448	.1905	.1715	1.7147	1.5242	1.2384
9	.1524	.1448	.1905	.1905	1.7147	1.7147	1.4861
10	.1715	.1448	.1524	.1905	1.8671	1.7718	1.5813
11	.1629	.1524	.1524	.1905	1.829	1.7147	1.5813
12	.1448	.1524	.1524	.1524	1.7909	1.7147	1.5051
13	.1086	.1524	.1524	.1524	1.7528	1.6956	1.4289
14	.1086	.1524	.1334	.1524	1.7147	1.6956	1.3146
15	.1086	.1524	.1334	.1524	1.6766	1.6956	1.2574
16	.1086	.1524	.1524	.1905	.1524	.1905	.1905
17	.1086	.1334	.1715	.2286	.1524	.1905	.1905
18	.1448	.1524	.3048	.3048	.1524	.3048	.2096
19	.1448	.1905	.362	.381	.1905	.3429	.2286
20	.1629	.2667	.362	.381	.2667	.362	.2667
21	.5973	.5716	.5525	.3429	.3048	.3429	.4954
22	.6516	.724	.724	.2667	.2667	.3048	.5335
23	.6878	.724	.7621	.2667	.2286	.2286	.5906
24	.7621	.7602	.743	.8002	.2667	.2286	.2096
Max	1.3336	.9774	.8573	.9526	1.8671	1.7718	1.5813
Min	.1086	.1334	.1334	.1524	.1524	.1905	.1905
Avg	.4771	.4390	.4247	.4183	.7414	.7295	.6533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 203 / 11 kV Budhala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2534	.2096	.2096	.2286	.1715
2	.2667	.2534	.2096	.2286	.2286	.1715
3	.3429	.2534	.2096	.2286	.2286	.1524
4	.3429	.2534	.2286	.2477	.2286	.1524
5	.3429	.2172	.2286	.2667	.2286	.1715
6	.3048	.181	.2286	.2667	.2286	.1715
7	.3048	.1629	.1905	.1905	.1905	.1715
8	.1494	.1629	.1905	.1715	.3429	.362
9	.1448	.1448	.1524	.1715	.381	.3429
10	.1448	.1448	.1524	.1715	.4191	.3429
11	.1448	.1524	.1524	.1715	.4001	.362
12	.1448	.1334	.1524	.1715	.3239	.362
13	.1448	.1334	.1524	.1524	.3429	.362
14	.1629	.1334	.1524	.1524	.3048	.362
15	.1629	.1334	.1524	.1524	.2667	
16	.1629	.1143	.1524	.1524		
17	.1629	.1143	.1524	.1524		
18	.1629	.1334	.1524	.1524	.1524	
19	.1629	.1524	.1524	.1905	.1715	
20	.1629	.1715	.1524	.1905	.1905	
21	.1629	.1905	.1524	.1905	.2096	
22	.1629	.1905	.1715	.1905	.1905	
23	.181	.1905	.1905	.1905	.1715	
24	.7049	.2172	.2096	.1905	.2286	.1715
Max	.7049	.2534	.2286	.2667	.4191	.362
Min	.1448	.1143	.1524	.1524	.1524	.1524
Avg	.2265	.1745	.1770	.1897	.2572	.2553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 204 / 11 kV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.7602	1.0669	1.3336	1.0288	1.1622	1.467
2	1.0288	.7602	1.0669	1.3146	1.0288	1.1431	1.4289
3	1.0288	.7602	1.086	1.2765	1.105	1.1431	1.4289
4	1.105	.7602	1.105	1.2574	1.105	1.105	1.2384
5	1.1431	.7602	1.1241	1.1622	1.1431	1.1241	1.0479
6	.5144	.8326	1.1622	1.1431	1.1812	1.086	.8573
7	1.2193	1.0317	1.1431	1.1241	1.2574	1.0288	.7811
8	1.3756	1.2308	1.2193	1.3146	1.2955	1.0669	1.2574
9	1.448	1.4118	1.4098	1.4861	1.3717	1.1241	1.2003
10	1.5023	1.5927	1.4861	1.5432	1.4289	1.3717	1.0479
11	1.6289	1.7909	1.7147	1.5242	1.5242	1.5623	.9335
12	1.7918	1.9052	1.829	1.4861	1.8099	1.7528	
13	1.7375	1.8671	1.9243		1.7909	1.829	
14	1.6651	1.7147	1.8099	1.5623	1.7528	1.6575	
15	1.6289	1.4098	1.6766	1.5623	1.7147	1.2765	.7621
16	1.5927	1.3336	1.6385	1.448	1.6004	1.3717	.8002
17	1.5565	1.2955	1.5051	1.4098	1.5242	1.3336	.8383
18	1.3032	1.2193	1.2765	1.2574	1.3336	1.4098	.8764
19	1.1222	1.1431	1.105	1.1431	1.2955	1.3336	.8002
20	1.0498	1.0288	1.467	1.0098	1.2955	1.2955	.6668
21	.9774	1.0669	1.3717	1.1431	1.1812	1.3717	.5525
22	.8326	1.0288	1.3908	1.1812	1.1431	1.4098	.5716
23	.7421	1.0288	1.2955	1.1812	1.1812	1.4098	.5716
24	1.0288	.7602	1.0479	1.2955	1.1431	1.1622	1.467
Max	1.7918	1.9052	1.9243	1.5623	1.8099	1.829	1.467
Min	.5144	.7602	1.0479	1.0098	1.0288	1.0288	.5525
Avg	1.2506	1.1872	1.3717	1.3113	1.3432	1.3138	.9807

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 401 / 33 KV Incomer Umari SStn

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.8778	3.4865	2.6863	3.7151	3.7723	3.8295
2	2.8578	3.1436	3.4865	2.7435	3.7723	3.7723	3.8866
3	2.9721	3.1436	3.658	2.915	3.7723	3.8866	4.0581
4	3.0864	3.1436	3.7723	2.915	3.9438	3.9438	4.0009
5	3.2007	3.1436	3.9438	3.0864	3.9438	4.0009	4.1724
6	3.4294	3.2007	3.8866	3.1436	4.1152	4.1724	4.2867
7	3.7151	2.8578	3.8866	2.5149	4.1152	3.8866	1.1431
8	4.8868	4.7439	4.6868	4.7439	4.4582	4.0581	4.401
9	5.2126	5.5441	4.9726	4.6296	4.9154	4.9154	4.6296
10	5.3755	5.5441	5.144	4.5725	5.144	4.7439	4.7439
11	5.5384	5.8871	6.1728	4.6868	5.3727	5.8299	4.7439
12	6.0814	6.2872	6.1728	5.487	5.5441	6.0014	4.0009
13	5.9728	6.1728	6.23	5.7156	5.487	6.0585	4.0581
14	5.8099	6.23	6.1728	5.7156	5.3727	5.6013	4.1724
15	5.647	5.7156	6.0014	5.8871	5.2584	5.3727	4.6868
16	3.6923	3.658	3.7723	1.2574	3.2007	3.315	2.6292
17	3.8009	3.6008	3.9438	1.2574	3.2579	3.2579	1.829
18	1.3032	1.2003	1.6004	1.4861	1.3717	1.4289	1.4289
19	1.4118	1.2574	1.6575	1.6575	1.4861	1.6004	1.4861
20	1.6289	1.4289	1.7147	1.6575	2.2862	2.4577	1.5432
21	1.8461	1.9433	2.0576	2.1719	2.2862	2.2291	1.6575
22	1.9004	1.9433	2.2291	2.4006	2.3434	2.3434	1.6575
23	1.6832	2.0005	2.0576	2.4006	2.2291	2.3434	1.6004
24	2.5149	2.7149	3.4865	2.7435	2.915	3.658	3.7723
Max	6.0814	6.2872	6.23	5.8871	5.5441	6.0585	4.7439
Min	1.3032	1.2003	1.6004	1.2574	1.3717	1.4289	1.1431
Avg	3.5963	3.6410	3.9247	3.2698	3.7628	3.8604	3.2674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 402 / 63 Mah. Border check post NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0543	.0572		.0572	.0572	
2	.0572	.0543	.0572		.0572	.0572	
3	.0572	.0543	.0572		.0572	.0572	
4	.0572	.0543	.0572		.0572	.0572	
5	.0572	.0543	.0572		.0572	.0572	
6	.0572	.0543	.0572		.0572	.0572	
7	.0572	.0572	.0572		.0572	.0572	
8	.0572	.0572	.0572		.0572	.0572	
9	.0572	.0572	.0572		.0572	.0572	
10	.0572	.0572	.0572		.0572	.0572	
11	.0543	.0572		.0572	.0572		
12	.0543	.0572		.0572	.0572		.0572
13	.0543	.0572		.0572	.0572		.0572
14	.0543	.0572		.0572	.0572		.0572
15	.0543	.0572		.0572	.0572		.0572
16	.0543	.0572		.0572	.0572		.0572
17	.0543	.0572		.0572	.0572		.0572
18	.0543	.0572		.0572	.0572		.0572
19	.0543	.0572		.0572	.0572		.0572
20	.0543	.0572		.0572	.0572		.0572
21	.0543	.0572		.0572	.0572		.0572
22	.0543	.0572		.0572	.0572		.0572
23	.0543	.0572		.0572	.0572		.0572
24	.0572	.0543	.0572		.0572	.0572	
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0543	.0543	.0572	.0572	.0572	.0572	.0572
Avg	.0556	.0564	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 403 / 33 KV Sawargaon out  
going(umri Feeder KV- 33 /  
INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.6244	1.7147	1.2574	1.7147	1.829
2	1.3717	1.6832	1.7147	1.2574	1.7147	1.829
3		1.5746	1.829	1.3717	1.7147	1.8861
4	1.4861	1.5746	1.9433	1.3717	1.829	1.9433
5	1.6004	1.4661	2.1719	1.4861	1.829	2.0576
6	1.7147	1.4118	2.1148	1.4861	1.9433	2.1148
7	1.9433	1.7375	2.0576	1.6575	1.9433	2.1719
8	2.1719	2.3348	1.9433	2.4006	2.0576	2.2291
9	1.7375	2.552	2.0005	1.8861	2.0576	2.1719
10	2.3348	2.1176	2.0005	1.829	2.1719	1.9433
11	2.7149	2.572	3.0293	1.9433	2.3434	2.8006
12	3.0407	2.9721	3.0864	2.7435	2.572	2.915
13	2.9321	2.915	3.0864	2.8578	2.5149	2.915
14	2.8778	2.9721	3.0864	2.8578	2.4577	2.8578
15	2.8235	2.8578	2.9721	3.0293	2.4006	2.6863
16	2.7692	2.8578	2.6863	.3429	2.2862	
17	2.7692	2.8006	2.6292	.3429	2.2862	
18	.2715	.3429	.3429	.5716	.3429	
19	.3258	.3429	.4001	.6287	.4001	
20	.4344	.4001	.3429	.4572	.4572	
21	.3801	.3429	.3429	.4572	.5716	
22	.543	.2858	.4001	.4572	.4572	
23	.2715	.2858	.2858	.4572	.3429	
24	1.1431	1.5203	1.7147	.9145	.9145	1.7147
Max	3.0407	2.9721	3.0864	3.0293	2.572	2.915
Min	.2715	.2858	.2858	.3429	.3429	1.7147
Avg	1.6969	1.7310	1.8290	1.4194	1.6385	2.2541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 200 / 11 KV STATION TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0191	.0191	.0381	.0191	.0191	.0248	.0191
Max	.0191	.0191	.0381	.0191	.0191	.0248	.0191
Min	.0191	.0191	.0381	.0191	.0191	.0248	.0191
Avg	.0191	.0191	.0381	.0191	.0191	.0248	.0191

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 201 / Kelod Town

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)
1		.1334
2		.1334
3		.1143
4		.1143
5		.1524
6		.1905
7		.1524
8		.1524
9		.1524
10		.1524
11		.1334
12		.1143
13		.0953
14		.0953
15		.0762
16		.0953
17	.1334	.1143
18	.1524	.1715
19	.2286	.2096
20	.2286	.2096
21	.2477	.1905
22	.2477	.1715
23	.1715	.1524
24		.1334
Max	.2477	.2096
Min	.1334	.0762
Avg	.2014	.1421



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 202 / Jatamkhora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0572	.0572	.1905	.2486	.3429
2	.0381	.0572	.0572	.0572	.1905	.2458	.3239
3	.0381	.0572	.0572	.0572	.2096	.2652	.3239
4	.0381	.0572	.0572	.0572	.2096	.2622	.3239
5	.0381	.0572	.0572	.0572	.2286	.2785	.362
6	.0381	.0572	.0572	.0572	.3239	.2785	.4001
7	.0381	.0572	.0572	.0572	.0572	.0381	.0572
8		.4191	.3239	.4382	.0572	.0572	.0572
9	.2477	.4359	.5525	.6478	.0572	.0572	.0572
10	.5525	.4641	.5716	.6097	.0572	.0572	.0381
11	.6859	.5138	.6478	.5335	.0572	.0572	.0381
12	.6859	.4973	.6478	.6478	.0191	.0381	.0381
13	.6859	.5138	.6287	.6859	.0191	.0381	.0381
14	.6287	.5138	.6097	.5716	.0191	.0381	.0381
15	.5906	.4973	.6097	.5335	.0381	.0381	.0381
16	.0381	.0381	.0381	.0381		.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0572	.0572
18	.0572	.0572	.0572	.0572	.0572	.0762	.0762
19	.0953	.0953	.0953	.0953	.0953	.1143	.1143
20	.0953	.0953	.0953	.0762	.0953	.1143	.1143
21	.0762	.0953	.0953	.1905	.2926	.381	.0953
22	.0762	.0762	.0762	.2096	.2561	.3429	.0953
23	.0572	.0762	.0572	.1905	.2172	.4001	.0762
24	.0381	.0572	.0572	.0572	.1715	.2715	.3429
Max	.6859	.5138	.6478	.6859	.3239	.4001	.4001
Min	.0381	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.2137	.2035	.2334	.2509	.1286	.1581	.1453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 203 / 11 KV Parsodi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.2667	.4031	.4191
2	.0762	.0762	.0762	.0762	.2667	.3944	.4191
3	.0762	.0762	.0762	.0762	.2667	.4161	.381
4	.0572	.0953	.0953	.0762	.2858	.4557	.381
5	.0572	.0953	.0953	.0762	.3048	.4801	.3429
6	.0762	.0953	.0953	.0953	.3048	.5144	.2858
7	.0953	.0953	.0762	.0762	.0953	.0953	.0953
8	.4572	.5716	.4191	.4954	.0762	.0953	.0953
9	.6097	.5895	.6668	.6097	.0953	.0953	.0953
10	.6097	.583	.724	.6859	.0953	.0762	.0953
11	.6287	.6516	.7621	.7621	.0953	.0762	.0953
12	.6097	.7888	.7621	.724	.0762	.0762	.0953
13	.6097	.7716	.6859	.724	.0762	.0762	.0762
14	.5716	.6783	.6668	.6478	.0762	.0762	.0762
15	.5335	.6001	.6287	.5716	.0762	.0762	.0762
16	.0762	.0754	.0953	.1143	.0762	.0762	.0762
17	.0572	.0762	.0572	.0953	.0762	.0762	.0762
18		.0762	.0953	.1143	.1143	.0953	.1143
19	.0953	.1334	.1524	.1334	.1524	.1715	.1334
20	.1143	.1524	.1524	.1334	.1524	.1524	.1334
21	.1334	.1334	.1334	.3048	.5304	.381	.1334
22	.1143	.0953	.0953	.3429	.5249	.4382	.1143
23	.0953	.0953	.0762	.2667	.4572	.4572	.0953
24	.0762	.0762	.0762	.0762	.2667	.4207	.4572
Max	.6287	.7888	.7621	.7621	.5304	.5144	.4572
Min	.0572	.0754	.0572	.0762	.0762	.0762	.0762
Avg	.2568	.2816	.2850	.3064	.2004	.2365	.1818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 401 / 33 KV Incomer Kelwad SStn

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2286	.2858	.6859	.8573	.9145
2	.2286	.2286	.2286	.2286	.6859	.8573	.8573
3	.1715	.2286	.2286	.2286	.6859	.9145	.8002
4	.1715	.2858	.2858	.2286	.743	1.0288	.8002
5	.1715	.2858	.2858	.2286	.743	1.086	.8573
6	.2286	.2858	.2858	.2858	.8573	1.1431	.8573
7	.2286	.2858	.2858	.2858	.3429	.2858	.2858
8	.6859	1.2003	1.2003	1.2003	.2858	.2858	.2858
9	1.1431	1.4289	1.4861	1.5432	.2858	.2858	.2858
10	1.3146	1.4289	1.5432	1.6004	.2858	.2858	.2858
11	1.4861	1.6575	1.6575	1.6004	.2858	.2858	.2858
12	1.5432	1.6575	1.6575	1.6575	.2286	.2286	.2286
13	1.5432	1.6575	1.5432	1.7147	.2286	.2286	.2286
14	1.4861	1.5432	1.4861	1.4289		.2286	.2286
15	1.3717	1.4289	1.4289	1.3146	.2286	.2286	.1715
16	.2286	.2286	.2286	.2858	.2286	.2286	.2286
17	.2286	.2286	.2286	.2286	.2286	.2858	.2286
18	.2858	.2858	.2858	.4001	.3429	.3429	.3429
19	.3429	.4001	.4572	.4572	.4572	.5144	.4572
20	.4001	.4572	.4572	.4001	.4572	.5144	.4572
21	.4572	.4001	.4572	.6859	1.1431	1.0288	.4001
22	.3429	.3429	.3429	.8002	1.086	1.0288	.4001
23	.2858	.2858	.2858	.6859	.9145	1.0288	.3429
24	.2286	.2286	.2286	.2858	.6287	.8573	.9145
Max	1.5432	1.6575	1.6575	1.7147	1.1431	1.1431	.9145
Min	.1715	.2286	.2286	.2286	.2286	.2286	.1715
Avg	.6168	.6954	.7002	.7526	.5243	.5858	.4644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 201 / SAONER URBAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7621	.6668	.9526		.9907	1.0288
2	.7621	.724	.6287	.9335		.9526	.9907
3	.7621	.724	.6097	.8954		.8954	.9526
4	.8192	.6859	.5906	.8002		.9145	.9145
5	.8764	.7049	.6097	.7621		.9335	.9145
6	1.0098	.7621	.6668	.7049		.9907	.9717
7	1.1241	.9335	.8002	1.0479		1.105	1.0098
8	1.2955	1.0098	.8192	1.1812		1.2193	1.0669
9	1.3146	1.0479	.9145	1.2955	1.3717	1.2955	
10	1.3336	.9907	.8764		1.2574	1.3336	
11	1.0669	.9717	.8383		.9335	1.2193	
12	1.0098	1.0098	.8192		.8192	1.1241	
13	.9717	.8383	.7811		.7621	1.0288	
14	.9526	1.6766	.743		.743	.8764	
15	.8954	.6859	.7811		.7049	.7049	
16	.8573	.7049	.7621		.743	.8002	
17	.9526	.743	.8192		.7811	.8954	
18	1.1431	.8192	.8002		.9335	.9526	
19	1.2384	1.0288	1.0288		1.2765	1.105	
20	1.3336	1.0669	1.0479		1.3336	1.1431	
21	1.2193	.9526	1.0288		1.3527	1.1812	
22	1.2193	.8954	1.0669		1.2384	1.2384	
23		.743	1.086		1.1431	1.1622	
24	.7621	.7621	.6859	1.0098		1.0288	1.086
Max	1.3336	1.6766	1.086	1.2955	1.3717	1.3336	1.086
Min	.724	.6859	.5906	.7049	.7049	.7049	.9145
Avg	1.0280	.8851	.8113	.9583	1.0262	1.0455	.9928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 202 / SAONER URBAN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.5716	.4954	.6668	.6097	.6097
2	.5335	.4382	.5335	.5335	.6668	.5716	.5716
3	.5906	.4382	.5335	.5335	.6668	.5525	.5335
4	.6478	.4191	.5525	.5716	.6668	.5716	.5716
5	.724	.4382	.5716	.6097	.6668	.6097	.6478
6	.7621	.5716	.6287	.6478	.6668	.6859	.8002
7	.8002	.7621	.8192	.6478	.8573	.8002	.9526
8	.8764	.9335	.8954	.7621	.9526	.9335	1.0098
9	.8954	1.0479	.9145	.8192	.9526	.9335	
10	.9145	.9907	.8764	.8573	.9145	.9145	
11	.7621	.9717	.8573	.8764	.8573	.8573	
12	.7621	.8764	.8192	.8573	.8002	.8002	
13	.724	.724	.8383	.8192	.7621	.7621	
14	.6859	.6478	.8002	.7621	.724	.724	
15	.6668	.6668	.8383	.7621	.6859	.6859	
16	.6287	.7049	.8002	.7621	.743	.8192	
17	.7049	.7811	.8573	.7621	.8954	.9145	
18	.9526	.8573	.8764	1.0479	1.0098	1.0669	
19	1.2384	1.105	1.1431	1.1431	1.0479	1.2193	
20	1.105	1.0288	1.0479	1.0669	1.0669	1.105	
21	.9907	.9145	.9526	.9526	.9335	.9717	
22	.7621	.8192	.8002	.7621	.724	.8764	
23	.5716	.6287	.6478	.6668	.6478	.7049	
24	.5335	.4763	.5906	.5335	.6668	.6097	.6859
Max	1.2384	1.105	1.1431	1.1431	1.0669	1.2193	1.0098
Min	.4954	.4191	.5335	.4954	.6478	.5525	.5335
Avg	.7637	.7375	.7819	.7605	.8018	.8042	.7092

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 203 / patsaongi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2667	.2477	.2858	.2667	.2667
2	.2096	.2477	.2477	.2286	.2858	.2477	.2667
3	.1905	.2477	.2667	.1905	.2858	.2286	.2286
4	.2286	.2286	.2477	.2286	.2858	.2286	.1905
5	.2667	.2477	.2667	.2667	.2667	.2477	.2477
6	.3048	.3048	.3239	.3048	.2858	.2858	.3239
7	.3429	.3429	.362	.3429	.3429	.381	.381
8	.4382	.4191	.4191	.4001	.4191	.4763	.4572
9	.4572	.4382	.4191	.4382	.4572	.4954	
10	.4763	.4001	.4572	.4572	.4763	.5144	
11	.4954	.4572	.4954	.4763	.4763	.4763	
12	.4763	.4763	.4382	.4954	.4954	.4572	
13	.4572	.4572	.4763	.4572	.4763	.4954	
14	.4382	.4382	.4382	.4382	.4572	.4572	
15	.4001	.4382	.4572	.4001	.4572	.4191	
16	.4001	.4191	.4763	.4001	.4572	.381	
17	.4191	.4191	.4763	.4001	.4382	.4001	
18	.4954	.4191	.4382	.4191	.4572	.4382	
19	.5144	.4572	.4954	.4572	.4954	.5144	
20	.5144	.4382	.4191	.4191	.4763	.4191	
21	.381	.381	.3429	.3429	.4382	.381	
22	.3429	.362	.3048	.3429	.381	.362	
23	.2667	.3048	.2858	.2858	.3239	.3048	
24	.2477	.2477	.2667	.2858	.2858	.2858	.2667
Max	.5144	.4763	.4954	.4954	.4954	.5144	.4572
Min	.1905	.2286	.2477	.1905	.2667	.2286	.1905
Avg	.3747	.3683	.3787	.3636	.3961	.3818	.2921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 204 / telkamthi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2286	.2286	.5144	.5144	.4572
2	.1715	.2286	.2286	.2096	.5144	.4954	.4191
3	.1524	.2286	.2096	.1715	.4763	.4763	.381
4	.1905	.2286	.2096	.1905	.4763	.4954	.4191
5	.2286	.2477	.2286	.2477	.4763	.5335	.4382
6	.2477	.2667	.2667	.2667	.5716	.5906	.4763
7	.2667	.3048	.3048	.2858	.3429	.2858	.3048
8	.724	.8764	.8383	.8383	.2858	.3048	.3239
9	.8764	1.0669	1.105	.8764	.2858	.3048	.2858
10	1.0288	.8954	1.086	.9717	.2858	.2858	.2286
11	1.105	.8573	1.1241	.9907	.2286	.2477	.2286
12	1.1431	.7621	1.105	1.0669	.1905	.1715	.1905
13	1.1431	.6478	1.1622	1.0288	.1715	.1905	.1905
14	1.105	1.2193	1.1431	.9717	.1524	.2096	.1905
15	1.1431	1.1431	1.0288	.9526	.1524	.2286	.1905
16	.2096	.2096	.2667	.2286	.1715	.2667	.2096
17	.2096	.2286	.2858	.2477	.1905	.3239	.2477
18	.362	.3429	.3239	.3239	.3239	.362	.3239
19	.6097	.4954	.4954	.4954	.4954	.5144	.5144
20	.5716	.4763	.4191	.5144	.5525	.4572	.4954
21	.4572	.4191	.3429	.5525	.6287	.5144	.4572
22	.3239	.362	.2858	.5525	.5906	.6097	.381
23	.2477	.2667	.2667		.5525	.5335	.3429
24	.7049	.2286	.2286	.2477	.5335	.5144	.4763
Max	1.1431	1.2193	1.1622	1.0669	.6287	.6097	.5144
Min	.1524	.2096	.2096	.1715	.1524	.1715	.1905
Avg	.5589	.5096	.5493	.5417	.3818	.3930	.3405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 205 / nanda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2477	.2477	.2096	.4191	.4191	.362
2	.1905	.2477	.2477	.1715	.4191	.381	.3429
3	.1715	.2286	.2286	.1334	.4191	.4001	.3429
4	.1334	.2286	.2286	.1524	.4001	.4001	.381
5	.1905	.2286	.2858	.2667	.4191	.4191	.4001
6	.2477	.3048		.2858	.4954	.4572	.4191
7	.3048	.2667	.3048	.6287	.3048	.3048	.362
8	.4572	.5716	.4954		.3239	.3048	.381
9	.5906	.724	.6097	.6668	.2858	.2858	.381
10	.6859	.7049	.6478	.7049	.2858	.2667	.3048
11	.7811	.724	.7049	.743	.2477	.2286	.2286
12	.7621	.7811	.6859	.7621	.2286	.1905	.362
13	.7621	.8002	.724	.8002	.2286	.1715	.1905
14	.724	.8002	.7621	.7811	.1905	.1524	.1905
15	.7049	.724	.7811	.724	.1715	.1524	.1905
16	.1905	.1905	.2858		.1905	.1905	.2286
17	.2096	.1715	.2667	.2096	.2477	.3048	.2477
18	.3048	.362	.2858	.2858	.3429	.4191	.381
19	.4954	.6097	.5906	.5906	.6097	.5906	.5716
20	.5716	.5906	.5525	.5144	.5525	.4001	.5906
21	.4954	.4763	.4572	.4572	.4382	.4382	.5335
22	.362	.4191		.4572	.4382	.4572	.4382
23	.2667	.2858	.2858	.4191	.4382	.4191	.381
24	.2477	.2477	.2477	.2477	.4191	.4191	.381
Max	.7811	.8002	.7811	.8002	.6097	.5906	.5906
Min	.1334	.1715	.2286	.1334	.1715	.1524	.1905
Avg	.4192	.4557	.4512	.4642	.3548	.3405	.3580



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 206 / kelod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.1143	.1334	.4763	.4382	.362
2	.1143	.1334	.1143	.1143	.4763	.4191	.381
3	.0953	.1334	.0953	.1334	.4763	.4191	.362
4	.0762	.1334	.1143	.0953	.4572	.4382	.4001
5	.0953	.1334	.0953	.1334	.4572	.4382	.4572
6	.1334	.1334	.1143	.1143	.4954	.4763	.4572
7	.1715	.1334	.1715	.1524	.5716	.1334	.2096
8	.6287	.8383	.724	.724	.0381	.1905	.1905
9	.724	1.2574	.7621	.7621	.2096	.1905	
10		.8383	.8383	.8002	.1715	.1715	
11	.8002	.7811	.8192	.8383	.1715	.1524	
12	.8192	.724	.8002	.8573	.1524	.1524	
13	.8573	.743	.7621	.8002	.1524	.1334	
14	.8192	.7621	.743	.724	.1524	.1334	
15	.8573	.724	.7621	.6668	.1524	.1334	
16	.1334	.1143	.1143	.1143	.1524	.1524	
17	.1334	.0953	.1334	.1143	.1524	.1715	
18	.1524	.1524	.1524	.1715	.1524	.1905	
19	.2286	.2858	.3239	.3048	.3239	.3239	
20	.2858	.2858	.2858	.2858	.3048	.2858	
21	.2477	.2477	.2286	.8573	.4382	.362	
22	.2096	.2477	.1905	.4954	.4572	.4382	
23	.1524	.1524	.1715	.4954	.4763	.4001	
24	.1524	.1524	.1334	.1524	.4763	.4382	.381
Max	.8573	1.2574	.8383	.8573	.5716	.4763	.4572
Min	.0762	.0953	.0953	.0953	.0381	.1334	.1905
Avg	.3487	.3898	.3652	.4184	.3144	.2826	.3556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 401 / 33 KV Khapa outgoing

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6292		2.6863	3.0293	2.6863	2.6863	3.0293
2	2.5149		2.572	2.915	2.6863	2.572	2.7435
3	2.4006		2.6292	2.7435	2.6292	2.4577	2.6292
4	2.2862		2.572	2.6292	2.572	2.5149	2.572
5	2.4006		2.572	2.6863	2.6292	2.5149	2.6863
6	2.6292		2.6863	2.8006	2.8006	2.572	2.7435
7	2.7435		3.0293	2.915	3.1436	3.2579	2.8006
8	3.7723	3.6008	3.7723	2.8578	3.4865	3.7723	3.658
9		4.4582	4.5153	4.1724	9.145	3.8295	
10		4.2295	4.8011	4.1152	4.6868	3.7723	
11		3.8866	5.0297	4.0009	4.8011	3.8866	
12		3.8866	4.9726	4.0009	4.7439	4.1724	
13		4.2867	4.8011	3.7151	4.1152	3.8866	
14		4.2295	4.1724	3.4294	3.8295	3.315	
15			3.8866	2.915	3.2579	2.2862	
16		2.9721	2.7435	2.0005	3.2007	2.5149	
17		2.7435	3.0864	2.1148	3.1436	3.0864	
18		3.4294	3.4294	2.6863	3.0864	3.7723	
19		4.401	4.401	3.315	4.2295	4.2867	
20		4.2867	3.9438	3.4294	3.9438	4.0581	
21		3.8866	3.658	3.1436	3.7723	3.7151	
22		3.3722	3.1436	3.1436	3.315	3.0864	
23		3.0293	2.6292	2.8006	2.9721	2.9721	
24	2.7435		2.8006	3.0293	2.6863	2.8578	2.915
Max	3.7723	4.4582	5.0297	4.1724	9.145	4.2867	3.658
Min	2.2862	2.7435	2.572	2.0005	2.572	2.2862	2.572
Avg	2.68	3.7799	3.5222	3.1079	3.6485	3.2436	2.8642

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 401 / 33 kv Umri

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.2007	3.1436	3.1436	3.1436	3.2007	3.4294	3.1436
Max	3.2007	3.1436	3.1436	3.1436	3.2007	3.4294	3.1436
Min	3.2007	3.1436	3.1436	3.1436	3.2007	3.4294	3.1436
Avg	3.2007	3.1436	3.1436	3.1436	3.2007	3.4294	3.1436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 402 / Saoner.1

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.7151	3.1436	6.2872	3.315	3.1436	3.3722	3.3722
Max	3.7151	3.1436	6.2872	3.315	3.1436	3.3722	3.3722
Min	3.7151	3.1436	6.2872	3.315	3.1436	3.3722	3.3722
Avg	3.7151	3.1436	6.2872	3.315	3.1436	3.3722	3.3722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 403 / MIDC

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	01-FEB-18	02-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4289	1.4289	1.6575	1.4861	2.0005	1.4861
Max	1.4289	1.4289	1.6575	1.4861	2.0005	1.4861
Min	1.4289	1.4289	1.6575	1.4861	2.0005	1.4861
Avg	1.4289	1.4289	1.6575	1.4861	2.0005	1.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 404 / Saoner 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.572	3.1436	3.1436	3.2007	3.0864	3.2007	3.2007
Max	2.572	3.1436	3.1436	3.2007	3.0864	3.2007	3.2007
Min	2.572	3.1436	3.1436	3.2007	3.0864	3.2007	3.2007
Avg	2.572	3.1436	3.1436	3.2007	3.0864	3.2007	3.2007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 405 / Khapa

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	6.5729	8.5734	8.9163	8.802	8.2876	8.2876	8.0018
Max	6.5729	8.5734	8.9163	8.802	8.2876	8.2876	8.0018
Min	6.5729	8.5734	8.9163	8.802	8.2876	8.2876	8.0018
Avg	6.5729	8.5734	8.9163	8.802	8.2876	8.2876	8.0018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 406 / 33 KV PATANSAWANGI

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	10.2881	10.2881	10.5739	11.1454	11.1454	10.5739	10.5739
Max	10.2881	10.2881	10.5739	11.1454	11.1454	10.5739	10.5739
Min	10.2881	10.2881	10.5739	11.1454	11.1454	10.5739	10.5739
Avg	10.2881	10.2881	10.5739	11.1454	11.1454	10.5739	10.5739



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 407 / 33 KV Kelwad

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4289	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Max	1.4289	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Min	1.4289	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Avg	1.4289	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 408 / Saoner 3

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0572						
24	.1143	.1143	.0572	.0572	.0572	.0572	.0572
Max	.1143	.1143	.0572	.0572	.0572	.0572	.0572
Min	.0572	.1143	.0572	.0572	.0572	.0572	.0572
Avg	.0858	.1143	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 409 / 33 KV Mohapa

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23	1.4289						
24	2.0005	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Max	2.0005	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Min	1.4289	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861
Avg	1.7147	1.4289	1.4861	1.5432	1.4289	1.4861	1.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-18 and 07-FEB-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 410 / 33 kv stn t/f

Feeder KV- 33 / OUTGOING

DATE	01-FEB-18	02-FEB-18	03-FEB-18	04-FEB-18	05-FEB-18	06-FEB-18	07-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0572	.1143	.1143	.1143	.1143	.1715	.1715
Max	.0572	.1143	.1143	.1143	.1143	.1715	.1715
Min	.0572	.1143	.1143	.1143	.1143	.1715	.1715
Avg	.0572	.1143	.1143	.1143	.1143	.1715	.1715