

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 201 / 11 KV LOHARISAWANGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.426	.4096	.4024	.4096	.4191	.4049	.4096
2	.4096	.3932	.4024	.3932	.3856	.4049	.4096
3	.4096	.3932	.3688	.3932	.3856	.3887	.3932
4	.3932	.3605	.3688	.3605	.3521	.3605	.3932
5	.3605	.3605	.3688	.3605	.3353	.3563	.3605
6	.2949	.2949	.3018	.2949	.285	.2915	.3113
7	.1966	.213	.218	.213	.2105	.2267	.1966
8	.1638	.1966	.1802	.1802	.1781	.1781	.1802
9	.1802	.1638	.2012	.1966	.1781	.2105	.1966
10	.1966	.2294	.2915	.2622	.2683	.1638	.1966
11	.2294	.2267	.2949	.2591	.2294	.1638	.1619
12	.2294	.2267	.2622	.2294	.2294	.1638	.1619
13	.2294	.2347	.2294	.1943	.2294	.1311	.1619
14	.2294	.2267	.1966	.1619	.2294	.1638	.1296
15	.2458	.2591	.2294	.1943	.1966	.1638	.1296
16	.2294	.2267	.2294	.2267	.1638	.1638	.1619
17	.2294	.1943	.2622	.1943	.1638	.1311	.1296
18	.2294	.2105	.2294	.2105	.1943	.1966	.2267
19	.2458	.2753	.2949	.2347	.2753	.2622	.2753
20	.3605	.4024	.3768	.3353	.3401	.3605	.3725
21	.4096	.4191	.3932	.3725	.4049	.4424	.4049
22	.426	.4534	.4424	.421	.4372	.4424	.421
23	.426	.4527	.426	.421	.421	.4424	
24	.426	.4096	.4359	.4096	.4191	.421	.426
Max	.426	.4534	.4424	.421	.4372	.4424	.426
Min	.1638	.1638	.1802	.1619	.1638	.1311	.1296
Avg	.2990	.3014	.3086	.2887	.2888	.2764	.2700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 202 / 11 KV LOHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.213	.1802	.218	.213	.218	.1943	.1966
2	.1966	.1802	.218	.1966	.1943	.1943	.1966
3	.1966	.1802	.1844	.1966	.1943	.1943	.1966
4	.1802	.1638	.1844	.1802	.1619	.1943	.1638
5	.1638	.1311	.1844	.1802	.1619	.1781	.1638
6	.1311	.1147	.1174	.1147	.0838	.1296	.1311
7	.0819	.0819	.1006	.0983	.0648	.081	.0819
8	.0819	.0492	.1006	.0819	.0648	.0648	.0819
9	.0819	.0328	.1006	.0655	.0671	.0324	.0655
10	.2458	.2458	.2591	.2622	.1943	.0819	.1638
11	.2294	.2347	.2458	.2267	.1638	.0983	.1943
12	.1966	.1943	.1966	.1943	.213	.0983	.1619
13	.2458	.1619	.1802	.1781	.213	.1147	.1457
14	.2458	.1619	.1638	.1844	.1966	.0983	.1134
15	.1966	.1457	.1802	.1619	.1966	.1147	.1134
16	.1966	.1457	.1966	.1781	.0655	.0819	.0648
17	.1966	.1509	.1966	.1619	.0655	.0819	.0486
18	.0328	.0324	.1475	.0648	.0324	.0655	.0648
19	.0983	.1134	.1147	.1006	.1296	.1147	.1296
20	.1638	.218	.1966	.1844	.1781	.213	.1781
21	.1966	.218	.213	.2105	.2105	.2294	.1943
22	.213	.2347	.2294	.2105	.2105	.2294	.2105
23	.1966	.218	.213	.2105	.1943	.213	
24	.213	.1966	.218	.213	.218	.1943	.213
Max	.2458	.2458	.2591	.2622	.218	.2294	.213
Min	.0328	.0324	.1006	.0648	.0324	.0324	.0486
Avg	.1748	.1578	.1816	.1695	.1539	.1372	.1423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 203 / 11 KV KHARALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.1966	.3353	.3277	.3401	.3239	.3277
2	.2949	.1966	.3353	.3277	.3239	.3239	.3277
3	.2949	.1966	.2915	.2949	.3239	.3239	.3277
4	.2622	.1966	.3018	.2949	.2915	.3239	.2949
5	.2622	.1966	.3018	.2622	.3018	.2915	.2622
6	.1966	.1966	.2267	.1966	.218	.2591	.2294
7	.1311	.1475	.1372	.1311	.1457	.1619	.1311
8	.1147	.1147	.0838	.1147	.1296	.1457	.1311
9	.1147	.0819	.1341	.1311	.1296	.1457	.1638
10	.1966	.2949	.2915	.2949	.2591	.1638	.2294
11	.2458	.2683	.2949	.2915	.2294	.2294	.1943
12	.2622	.2591	.2622	.2915	.2294	.1966	.1943
13	.2622	.2915	.2949	.2591	.2294	.1966	.1677
14	.2458	.2915	.2949	.2267	.2294	.1638	.1619
15	.2458	.2915	.2949	.2591		.1638	.1619
16	.2458		.2949	.2591		.1638	.0972
17	.2622	.2915	.2949	.2267	.0983	.1311	.0972
18	.1475	.1509	.1638	.1341	.1619	.1311	.1844
19	.1802	.218	.2294	.1677	.2591	.1638	.2347
20	.2622	.3688	.3277	.3018	.3239	.3605	.285
21	.3768	.3688	.3605	.3521	.3725	.3605	.3563
22	.3932	.3856	.3768	.3856	.3725	.3605	.3563
23	.3605	.3521	.3441	.3401	.3401	.3605	
24	.3277	.3441	.3353	.3277	.3521	.3239	.3441
Max	.3932	.3856	.3768	.3856	.3725	.3605	.3563
Min	.1147	.0819	.0838	.1147	.0983	.1311	.0972
Avg	.2506	.2478	.2753	.2583	.2573	.2404	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 204 / 11 KV KHARASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0655	.0648	.0655	.0671	.0648	.0655
2	.0655	.0655	.0671	.0655	.0671	.0648	.0655
3	.0655	.0492	.0503	.0492	.0671	.0648	.0492
4	.0655	.0492	.0503	.0492	.0671	.0648	.0492
5	.0492	.0492	.0503	.0492	.0671	.0648	.0492
6	.0492	.0492	.0503	.0492	.0503	.0486	.0328
7	.0492	.0492	.0335	.0328	.0324	.0486	.0328
8	.0492	.0492	.0335	.0328	.0324	.0324	.0492
9	.0492	.0328	.0335	.0328	.0324	.0324	.0328
10	.1311	.1638	.2267	.2294	.2267	.0819	.0819
11	.1475	.2347	.2294	.2267	.2294	.0819	
12	.1311	.2267	.2458	.2267	.1966	.0819	.0648
13	.1311	.2267	.2294	.1943	.1638	.0655	.0648
14	.1638	.2267	.2294	.2267	.1475	.0492	.1006
15	.1311	.2267	.2294	.1943	.1147	.0819	.0972
16	.1147	.2267	.2294	.2267	.0492	.0819	.0648
17	.1147	.2591	.2294	.1943	.0655	.0819	.0648
18	.0328	.0335	.0328	.0486	.0324	.0328	.0486
19	.0328	.0503	.0492	.0503	.0486	.0492	.0486
20	.0655	.0838	.0819	.0503	.0648	.0655	.0648
21	.0819	.0838	.0819	.0648	.0648	.0655	.0648
22	.0819	.0838	.0819	.0838	.0648	.0655	.0648
23	.0655	.0838	.0655	.0648	.0648	.0655	
24	.0655	.0655	.0671	.0655	.0648	.0648	.0655
Max	.1638	.2591	.2458	.2294	.2294	.0819	.1006
Min	.0328	.0328	.0328	.0328	.0324	.0324	.0328
Avg	.0833	.1139	.1143	.1072	.0867	.0625	.0601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164026 / 33/11KV LOHARISAWANGA

Feeder No / Name : 205 / 11 KV Jatlapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0492	.0503	.0492	.0503	.0324	.0328
2	.0492	.0492	.0335	.0328	.0503	.0324	.0328
3	.0328	.0328	.0335	.0328	.0503	.0324	.0328
4	.0328	.0328	.0335	.0328	.0503	.0324	.0328
5	.0328	.0328	.0335	.0328	.0514	.0324	.0328
6	.0328	.0328	.0335	.0328	.0343	.0162	.0328
7	.0164	.0164	.0168	.0164	.0162	.0162	.0164
8	.0164	.0164	.0171	.0164	.0162	.0162	.0164
9	.0164	.0164	.0162	.0164	.0162	.0162	.0164
10	.1638	.1311	.1943	.2458	.2105	.0492	.1147
11	.1311	.1781	.1966	.1943	.213	.0655	.0972
12	.1475	.1781	.1802	.1943	.1638	.0492	
13	.1475	.1943	.1802	.1619	.1311	.0492	
14	.1638	.1619	.1638	.1781	.1147	.0328	.1457
15	.1966	.1943	.1802	.1457	.1311	.0655	.1457
16	.1966	.1781	.1966	.1619		.0655	.081
17	.213		.1802	.1296	.0819	.0655	.0972
18	.0164	.0168	.0164	.0168	.0162	.0164	.0162
19	.0164	.0168	.0164	.0168	.0162	.0164	.0162
20	.0328	.0335	.0328	.0335	.0324	.0164	.0162
21	.0492	.0335	.0492	.0335	.0324	.0328	.0324
22	.0492	.0503	.0492	.0486	.0486	.0492	.0324
23	.0492	.0503	.0492	.0514	.0486	.0492	
24	.0492	.0492	.0503	.0492	.0503	.0324	.0492
Max	.213	.1943	.1966	.2458	.213	.0655	.1457
Min	.0164	.0164	.0162	.0164	.0162	.0162	.0162
Avg	.0792	.0759	.0835	.0802	.0707	.0368	.0519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 201 / 11KV CHANDANIBURDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7377	.6401	.7042	.7122	.6706	.6802
2	.7545	.7042	.6401	.6874	.7122	.6706	.6802
3	.7202	.7042	.5121	.6874	.7122	.6036	.6802
4	.7202	.7042	.5121	.6706	.7122	.6036	.6154
5	.6687	.6706	.5121	.6371	.6104	.6036	.6154
6	.463	.4359	.4161	.4359	.407	.4359	.421
7	.2229	.2012	.4161	.1677	.2374	.285	.2267
8	.2401	.285	.2881	.2683	.1526	.0671	
9	.2743	.2683	.2881	.2683	.2374	.2012	
10	.4801	.4694	.4161	.4694	.407	.1677	
11	.4694		.4694	.407	.373	.1341	.0648
12	.4191	.4481	.4359	.373	.3521	.1006	.0678
13	.4024	.4161	.4024	.2713	.3521	.1174	.4748
14	.4359	.4161	.4191	.2543	.3521	.2915	.5087
15	.4024	.4161	.4024	.3391	.3353	.2915	.4748
16	.4191	.4161	.3688	.3052		.3239	.373
17	.3856	.3521	.3688	.2713	.2347	.2267	.2713
18	.3018	.2241	.3018	.2713	.2683	.2915	.3052
19	.3688	.3201	.3353	.373	.4024	.421	.373
20	.6036	.5761	.5365	.5765	.6036	.6154	.6104
21	.7042	.7042	.6036	.6443	.6706	.6802	.6783
22	.788	.7042	.7545	.7461	.7377	.6802	.763
23	.7545	.7042	.7377	.7291	.7042	.7125	.6783
24	.7716	.7377	.7042	.7209	.7122	.7042	.6802
Max	.788	.7377	.7545	.7461	.7377	.7125	.763
Min	.2229	.2012	.2881	.1677	.1526	.0671	.0648
Avg	.5226	.5050	.4784	.4699	.4782	.4125	.4877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 202 / 11 KV AMBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3932	.4001	.3932	.373	.3605	.39
2	.4115	.3768	.4001	.3605	.373	.3605	.39
3	.4115	.3768	.3361	.3605	.373	.3441	.39
4	.4115	.3768	.3361	.3605	.373	.3441	.3052
5	.3772	.3605	.3041	.3441	.3052	.3441	.3052
6	.2572	.2294	.2401	.213	.2374	.2294	.2374
7	.1715	.1638	.176	.1475	.1696	.1638	.1696
8	.1543	.0819	.176	.1311	.1017	.0819	.1865
9	.1543	.0983	.128	.1475	.1187	.0983	.1865
10	.1715	.1966	.2241	.1802	.1696	.0819	.1696
11	.1966	.1966	.213	.1696	.1865	.0819	.1696
12	.213	.208	.213	.1865	.176	.1311	.2035
13	.213	.2241	.2294	.2035	.208	.1311	.2035
14	.2294	.2241	.2622	.1865	.208	.1696	.2204
15	.2294	.2241	.2294	.1696	.213	.1696	.1865
16	.2294	.2241	.2294	.1865		.1696	.1696
17	.1966	.176	.1802	.1696	.0819	.1526	.1187
18	.1311	.112	.1802	.1526	.1475	.1696	.1696
19	.1966	.192	.1475	.2035	.213	.2374	.2204
20	.3277	.2721	.2949	.3222	.3277	.3561	.3391
21	.3932	.3681	.3441	.3391	.3113	.4239	.39
22	.426	.3681	.3932	.4239	.4096	.4239	.4239
23	.426	.4001	.3932	.7291	.3441	.4239	.39
24	.4458	.4096	.4001	.3932	.407	.3932	.4239
Max	.4458	.4096	.4001	.7291	.4096	.4239	.4239
Min	.1311	.0819	.128	.1311	.0819	.0819	.1187
Avg	.2842	.2605	.2679	.2697	.2534	.2434	.2649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164027 / 33/11KV THADIPAWNI

Feeder No / Name : 203 / Rampuri Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1457	.1524	.1457	.1357	.1619	.1204
2	.1543	.1296	.1524	.1457	.1357	.1296	.1204
3	.1372	.1296	.1524	.1296	.1357	.1296	.1204
4	.1372	.1296	.1219	.1296	.1357	.1296	.1204
5	.1372	.1296	.1219	.1296	.1017	.0972	.0903
6	.0857	.081	.061	.081	.0678	.0972	.1017
7	.0514	.0648	.061	.0324	.0509	.0324	.0602
8	.0514	.0324	.061	.0324	.0339	.0486	.0602
9	.0514	.0486	.061	.0486	.0339	.0324	.0602
10	.2401	.2591	.2439	.2591	.2374	.1619	.2107
11	.2591	.2429	.2429	.2713	.2374	.1943	.2107
12	.2591	.2439	.2267	.2204	.2134	.1943	.2374
13	.2591	.2743	.2429	.2035	.2439	.1943	.2374
14	.2753	.2743	.2591	.2204	.2439	.1806	.2374
15	.2591	.2743	.2429	.2035	.2591	.1806	.1187
16	.2429	.2439	.2429	.2035		.1806	.1696
17	.1943	.2743	.2267	.2035	.1943	.1806	.1696
18	.0486	.0305	.0486	.0509	.0486	.0301	.0678
19	.0648	.061	.0648	.0678	.081	.0903	.0848
20	.1296	.1219	.0972	.1017	.1296	.1204	.1357
21	.1457	.1524	.1296	.1187	.1619	.1505	.1526
22	.1619	.1524	.1619	.1357	.1619	.1505	.1526
23	.1619	.1524	.1457	.1357	.1619	.1204	.1357
24	.1543	.1619	.1524	.1457	.1357	.1619	.1204
Max	.2753	.2743	.2591	.2713	.2591	.1943	.2374
Min	.0486	.0305	.0486	.0324	.0339	.0301	.0602
Avg	.1590	.1588	.1531	.1423	.1453	.1312	.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 202 / 11 KV WADHONA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.3018	.3086	.3688	.3239	.3688	.3086
2	.2743	.2683	.3086	.3688	.3239	.3688	.3086
3	.2743	.2683	.2743		.2915	.3688	.2743
4	.2743	.2683	.2743	.3688	.2915	.3353	.2743
5	.2743	.2347	.2401	.3688	.2915	.3353	.2401
6	.2427	.2347	.2401	.3353	.2915	.3018	.2401
7	.2058	.2012	.2401	.3086	.1943	.2347	.2401
8	.1753	.1357	.2401	.2743	.1943	.2374	.2401
9	.1772	.1357	.2401	.2058	.1943	.2035	.2401
10	.1357	.1372	.3018	.2343	.2347	.1715	.1052
11	.1357	.1372	.3353	.3077	.2683	.1029	.1052
12	.1357	.2401	.3688	.3239	.2347	.1029	.1052
13	.1357	.3086	.3688	.3401	.2012	.0686	.1097
14	.1696	.3429	.3353	.3563	.2012		.1402
15		.3429	.3353	.2267	.1677		.1463
16		.3086	.3018	.2267		.0686	.1417
17		.3086	.2347	.2429		.0686	.1463
18		.2743	.2454	.2591	.0678	.2058	.2481
19		.2743	.2401	.2591	.1357	.3086	.2774
20	.3052	.3429	.3052	.2753	.1696	.3772	.3391
21	.3052	.3772	.373	.2915	.373	.3772	.3772
22	.3052	.3772	.4359	.3239	.407	.3429	.407
23	.3052	.3772	.4359	.3563	.407	.3429	
24	.2926	.3018	.3429	.3688	.3563	.4024	.3086
Max	.3052	.3772	.4359	.3688	.407	.4024	.407
Min	.1357	.1357	.2347	.2058	.0678	.0686	.1052
Avg	.2313	.2708	.3053	.3040	.2555	.2588	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 203 / 11KV Lohari-Sawanga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4694	.3086	.3018	.3239	.3688	.2743
2	.3052	.4694	.3086	.3018	.3239	.3688	.2743
3	.3086	.4359	.2743	.3052	.2915	.3353	.2401
4	.3086	.4359	.2401	.3052	.2915	.3353	.2058
5	.2401	.4024	.2401	.2804	.2915	.3018	.2058
6	.2058	.3353	.2058	.2401	.2915	.2683	.1715
7	.2058	.2347	.2058	.2374	.1619	.2012	.1715
8	.1753	.1696	.1715	.2126	.1619	.1696	.1715
9	.1097	.2035	.1715	.1753	.1619	.1696	.1715
10	.503	.5144	.4694	.2429	.503	.1715	.1402
11	.57	.6859	.5967	.3077	.5365	.1715	.1402
12	.503	.4115	.6299	.4858	.4694	.1372	.1402
13	.503	.3772	.431	.4049	.4024	.1029	.1753
14	.4694	.3772	.3353	.421	.3688		.2103
15	.503	.3772	.3688	.3563	.3353		.2103
16	.57	.3772	.4024	.3401		.1029	.2103
17	.5365	.3772	.4359	.3725		.1029	.2103
18		.1715	.1772	.2591	.2012	.1715	.1753
19	.2374	.2058	.2103	.2267	.2012	.2743	.2804
20	.4409	.3086	.3155	.2591	.2012	.3772	.3052
21	.4748	.3772	.3353	.2915	.373	.3429	.3391
22	.5087	.3772	.3688	.3239	.407	.3086	.3688
23	.5087	.3772	.3688	.3563	.407	.3086	
24	.3086	.4694	.3429	.3052	.3725	.3688	.2743
Max	.57	.6859	.6299	.4858	.5365	.3772	.3688
Min	.1097	.1696	.1715	.1753	.1619	.1029	.1402
Avg	.3828	.3725	.3298	.3047	.3217	.2482	.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 204 / 11KV Jalalkheda-R

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3688	.2743	.3353	.1619	.3688	
2	.3353	.3688	.2401	.3353	.1619	.3688	
3	.3353	.3688	.2058	.3353		.3688	
4	.3353	.3353	.1715	.3353	.1943	.3353	
5	.3052	.3353	.1372	.3052	.2105	.2683	
6	.2103	.2683	.1372	.2774	.2591	.2347	
7	.1829	.1677	.1372	.2401	.2591		
8	.0732		.1372	.1772	.2753	.1696	
9	.0732	.1017	.1372	.1463	.2753	.2035	
10	.2683	.2401	.4359	.1943		.2401	
11	.3018	.3429	.4694	.2915		.2401	
12	.2683	.4115	.5304	.4858	.3353	.2401	.2347
13	.2012	.4458	.5304	.502	.4024	.2058	.3086
14	.2347	.4801	.5636		.4024		.3391
15	.2683	.4458	.4973		.4359		.3429
16	.0678	.4115	.4641			.2743	.3353
17	.3688	.4115	.431			.2743	.2743
18		.1715	.1097			.1372	.1772
19	.2035	.1715	.1463	.2267	.1677	.2401	.2401
20	.373	.3086	.2926	.3239	.2012	.3429	.3429
21	.373	.3772	.3688	.3401	.3391	.3429	.3772
22	.407	.3772	.4359	.3563	.407	.3429	.4024
23	.407	.4115	.3688	.3725	.407	.3086	
24	.3353	.4024	.3429	.3688	.1619	.3688	
Max	.407	.4801	.5636	.502	.4359	.3688	.4024
Min	.0678	.1017	.1097	.1463	.1619	.1372	.1772
Avg	.2723	.3358	.3152	.3131	.2810	.2798	.3068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 205 / 11 KV PARADSINGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3353	.2743	.2683		.6706	.2743
2	.2743	.3018	.2401	.2683		.6706	.2743
3	.2743	.3018	.2058	.2713		.6371	.2743
4	.2743	.3018	.1715	.2743		.6371	.2743
5	.2454	.3018	.1372	.2454		.503	.3086
6	.1753	.2347	.1372	.2103		.4359	.3086
7	.1463	.1341	.1029	.1753		.3353	.3086
8	.0732	.1029	.1029	.1772		.2713	.3086
9	.0732	.1017	.1029	.1448		.2374	.3086
10	.2683	.2743	.3018		.2012	.2401	.1097
11	.3018	.4458	.3353		.2347	.2058	.1097
12	.2683	.4115	.3688		.2683	.1029	.1097
13	.2347	.3429	.3688		.3018	.0686	.3429
14	.2683	.3086	.4024		.2683		.4024
15	.2683	.3429	.3688		.2683		.4287
16	.3018	.3772	.3353			.0686	.3353
17	.3018	.4115	.3353			.0686	.2835
18		.1372	.1097		.1677	.1372	.1417
19	.1357	.1372	.1463		.2012	.1715	.3353
20	.2713		.2103		.2347	.2743	.4024
21	.3052	.2743	.2481		.6706	.2743	.3353
22	.3391	.3086	.2835		.7042	.3086	.3429
23	.3391	.3429	.2804		.7042	.2743	
24	.2743	.3353	.3086	.2774		.6706	.2401
Max	.3391	.4458	.4024	.2774	.7042	.6706	.4287
Min	.0732	.1017	.1029	.1448	.1677	.0686	.1097
Avg	.2473	.2855	.2449	.2313	.3521	.3302	.2852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 206 / 11KV Jalalkheda-U-APDRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061	.9054	1.0608	.9686	.7287	.9724	1.0174
2	.9172	.9389	1.0608	.9686	.7287	.9724	.9945
3	.9172	.9389	1.0608	.9686	.7287	.9724	.9945
4	.9061	.9054	1.0395	.9686	.7287	.9389	.9945
5	.8749	.8718	1.0395	.9374	.7287	.823	.9945
6	.8592	.8383	1.0395	.9217	.7287	.8886	.9602
7	.7811	.9054	1.0288	.9217	.7449	.8718	.9259
8	.7287	.9724	.9945	.9217	.8097	.8383	1.0174
9	.9717	1.0774	.9602	.9217	.8745	.8551	1.0277
10	1.0277	1.166	.8749	1.004	.9282	.9259	.9374
11	1.0608	1.166	.9061	1.0526	.9614	1.0004	.9061
12	1.0277	1.1317	.9061	1.1174	1.0277	1.0004	.8749
13	.9945	1.094	.9374	.8097	1.094	1.0004	.9374
14	.9614	1.0608	1.078	.8421	1.0608		1.0467
15	.9945	1.1142	1.078	.8745	1.0277		1.0467
16	1.0608	1.166	1.0623	.8907		.9945	.9374
17	1.094	1.166	1.0623	.9069		.9088	.7811
18	1.0608	1.1984	1.0311	.8907	.8951	.823	.7186
19	1.0395	1.2146	1.0311	.8907	.9724	.9259	.7655
20	.9892	1.2146	1.0311	.9069	.9945	1.0486	.9061
21	.9724	1.1336	1.0311	.8745	1.0059	1.0608	.9374
22	.9724	1.1271	1.0155	.8421	1.0059	1.0395	1.2811
23	.9389	1.094	.9686	.8583	1.0059	1.0059	
24	.9061	.9389	1.0608	.9686	.8745	.9724	1.0174
Max	1.094	1.2146	1.078	1.1174	1.094	1.0608	1.2811
Min	.7287	.8383	.8749	.8097	.7287	.823	.7186
Avg	.9568	1.0558	1.0150	.9262	.8934	.9472	.9574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 201 / 11 KV Datewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3481	.3647	.3149	.3315	.3041	.3361	.3315
2	.3481	.3481	.3149	.3315	.3041	.3361	.3315
3	.3481	.3481	.3149	.3315	.3041	.3361	.3315
4	.3315	.3481	.3149	.3315	.3041	.3361	.2818
5	.3149	.2486	.2984	.2984	.2561	.3361	.2486
6	.1989	.1989	.1989	.1989	.192	.192	.2155
7	.116	.1326	.116	.0995	.096	.096	.1326
8	.0829	.0829	.0829	.0829	.096	.096	.116
9	.0995	.0663	.0829	.0995	.064	.096	.1326
10		.3647	.4144	.4144	.3041	.2241	.2591
11		.4144	.3978	.3361	.2881	.2267	.3239
12		.3812	.3647	.3201	.2881	.0324	.2105
13		.431	.3481	.208	.2401	.2267	.1943
14	.431	.3812	.2984	.2561	.2401	.1943	.2155
15	.3812	.3812	.3149	.2401	.2401	.1781	.2155
16	.3812	.3315	.3149	.144		.1943	.1658
17	.3481	.3149	.2818	.2241	.144	.1457	.0829
18	.1492	.116	.0829	.112	.112	.1326	.1492
19	.1989	.1658	.1823	.144	.192	.1326	.1658
20	.2818	.2818	.2155	.208	.2561	.2818	.2652
21	.3315	.3149	.3149	.3041	.3041	.3315	.3149
22	.3647	.3647	.3481	.3201	.3361	.3647	.3481
23	.3481	.3481	.3481	.3201	.3361	.3647	
24	.3481	.3481	.3315	.3315	.3041	.3361	.3315
Max	.431	.431	.4144	.4144	.3361	.3647	.3481
Min	.0829	.0663	.0829	.0829	.064	.0324	.0829
Avg	.2876	.2949	.2749	.2495	.2394	.2303	.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164076 / 33/11 KV Wadvihira (Umata)

S/S

Feeder No / Name : 203 / 11 KV Wadhona Rural

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.463	.4458	.4458	.4001	.4167	.4458
2	.4801	.463	.4458	.4287	.4001	.4321	.4458
3	.4801	.4458	.4458	.4287	.4001	.4321	.4458
4	.4801	.4458	.4458	.4287	.4001	.4321	.4115
5	.463	.3601	.4115	.3772	.3361	.3521	.3601
6	.3086	.2743	.2572	.2572	.2561	.2561	.3086
7	.1886	.2058	.1543	.1372	.16	.16	.1715
8	.1886	.1372	.1372	.1543	.112	.16	.1543
9	.1715	.1372	.1372	.1372	.128	.16	.12
10	.2401	.2915	.2915	.2058	.176	.096	.0995
11	.2229	.3121	.2743	.208	.208	.1017	.1311
12	.1886	.208	.2743	.208	.192	.1017	.1147
13	.2058	.1886	.1886	.208	.176	.1017	.1311
14		.2058	.1715	.16	.16	.1017	.1372
15	.2572	.2229	.1886	.16	.16	.1017	.12
16	.2572	.2058	.2743	.176		.1187	.1029
17	.2572	.2058	.2229	.208	.064	.0829	.0686
18	.2058	.1886	.1715	.144	.16	.1372	.2229
19	.2572	.2572	.2572	.192	.2721	.2229	.2401
20	.4115	.4287	.3429	.2721	.3521	.3429	.3772
21	.4458	.463	.4287	.3841	.4001	.4287	.4287
22	.4801	.4973	.4458	.4161	.4321	.463	.4801
23	.463	.4973	.4458	.4161	.4321	.463	
24	.4801	.4458	.4801	.4287	.4001	.3841	.4458
Max	.4801	.4973	.4801	.4458	.4321	.463	.4801
Min	.1715	.1372	.1372	.1372	.064	.0829	.0686
Avg	.3310	.3146	.3058	.2742	.2686	.2520	.2593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 401 / 33 KV Loharisawanga

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1595	.1595	.1698	.1646
16	1.1088	.6722	.9231	.5407
24	.4435	.4481	.499	.4435
Max	1.1088	.6722	.9231	.5407
Min	.1595	.1595	.1698	.1646
Avg	.5706	.4266	.5306	.3829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 402 / 33 KV Bharsingi

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2357	1.2894	1.3146	1.1694
16	2.2405	3.2693	2.6155	1.9033
24	1.8296	1.7187	1.885	1.9605
Max	2.2405	3.2693	2.6155	1.9605
Min	1.2357	1.2894	1.3146	1.1694
Avg	1.7686	2.0925	1.9384	1.6777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 403 / 33 KV Paradsinga

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3395	.3395	.2829	.2263
16	1.7341	2.2771	.1698	1.166
24	.7842	.9054	.9522	.6224
Max	1.7341	2.2771	.9522	1.166
Min	.3395	.3395	.1698	.2263
Avg	.9526	1.174	.4683	.6716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 404 / 33 KV Mowad

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1934	1.1317	2.6566	.6167
16	.7522	1.2757	3.8832	1.0402
24	1.4969	1.4266	1.4815	3.8009
Max	1.4969	1.4266	3.8832	3.8009
Min	.7522	1.1317	1.4815	.6167
Avg	1.1475	1.278	2.6738	1.8193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560] BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 405 / 33 KV T.Pawani Feeder
(Wadvih Feeder KV- 33 / OUTGOING)

DATE	15-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.0972	.096	.096
16	.5624	.3321	
24	.2629	.2658	.2658
Max	.5624	.3321	.2658
Min	.0972	.096	.096
Avg	.3075	.2313	.1809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 167026 / 132 KV Bharsingi S/S

Feeder No / Name : 408 / 33 KV WATHODA FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.6241	1.142	.7225
16	1.0174	1.2431	.5533
24	1.186	1.3923	1.0923
Max	1.186	1.3923	1.0923
Min	.6241	1.142	.5533
Avg	.9425	1.2591	.7894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 201 / 11 KV HATLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7621	.7087	.7087	.7011	.6478	.6733
2	.7059	.6668	.6733	.691	.6836	.6097	.6379
3	.6516	.6097	.6379	.6556	.6485	.5716	.6379
4	.543	.5716	.6024	.6201	.6135	.5335	.6024
5		.5716	.5316	.5493	.5434	.4954	.5316
6	.2715	.4763	.443	.4252	.4382	.4954	.4607
7	.2715	.381	.3012	.3544	.3506	.381	.3012
8	.2534	.3048	.2835	.3189	.2629	.3239	.2835
9	.2328	.2477	.2481	.2658	.2629	.3721	.2835
10	.4763	.6097	.5847	.5493	.6836	.5335	.443
11	.5716	.5316	.567	.5609	.6859	.443	.443
12	.4954	.5316	.5493	.5434	.6859	.443	.443
13	.4607	.5316	.5493	.5959	.6097	.4252	.4784
14	.5335	.5138	.5316	.5609	.6097	.4784	.443
15	.5335	.567	.4961	.6661	.6097	.443	.443
16	.5716	.6556	.4961	.7186	.5335	.5316	.443
17	.5906	.6024	.5493	.5609	.1905	.443	.4252
18	.3429	.3012	.2835	.2804	.2858	.3544	
19	.4572	.5316	.443	.333	.4607	.4075	
20	.5906	.5847	.5316	.4557	.567		
21	.7621	.7087	.6379	.631	.6379	.691	
22	.8002	.7619	.7087	.7186	.691	.7087	
23	.8002	.7265	.7619	.7537	.743	.691	
24	.7421	.7621	.7087	.7265	.7186	.6859	.6733
Max	.8002	.7621	.7619	.7537	.743	.7087	.6733
Min	.2328	.2477	.2481	.2658	.1905	.3239	.2835
Avg	.5384	.5630	.5345	.5518	.5507	.5091	.4804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 202 / 11 KV Chargaon (old Dorli) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2286	.2254	.2254	.2279	.2096	.208
2		.2286	.208	.208	.2103	.1905	.208
3	.1991	.1905	.208	.208	.2103	.1905	.1734
4	.181	.1905	.1907	.1907	.1928	.1905	.156
5	.1629	.1715	.156	.1734	.1753	.1905	.1387
6	.1629	.1524	.1214	.1387	.1402	.1715	.1214
7	.1448	.1334	.104	.104	.1052	.1334	.104
8	.1086	.1143	.104	.104	.1052	.1143	.104
9	.0905	.1143	.104	.104	.1052	.104	.104
10	.2286	.4001	.3294	.3467	.3506	.2858	.2774
11	.2667	.3467	.3294	.333	.4191	.2774	.3121
12	.3048	.2774	.3641	.3681	.381	.2947	.3121
13	.2774	.2947	.3641	.4031	.4763	.2774	.3467
14	.4191	.2947	.3467	.3856	.381	.2947	.3121
15	.381	.3121	.3121	.3155	.381	.2601	.2774
16	.3429	.3467	.2774	.2804	.2858	.2601	.2774
17	.3239	.3467	.3121	.3155	.2286	.2601	.2601
18	.1715	.104	.104	.1052	.1143	.104	
19	.1905	.1387	.1387	.1402	.1387	.1387	
20	.2096	.1734	.1734	.1753	.156		
21	.2286	.2254	.208	.2103	.1907	.208	
22	.2477	.2427	.2427	.2454	.2254	.2427	
23	.2477	.2427	.2427	.2454	.2477	.2427	
24	.2353	.2286	.2254	.2254	.2279	.2286	.2254
Max	.4191	.4001	.3641	.4031	.4763	.2947	.3467
Min	.0905	.104	.104	.104	.1052	.104	.104
Avg	.2323	.2291	.2247	.2313	.2365	.2117	.2177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 204 / 11 KV Kotwalbardi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	.9907	.9054	.8383	.8764	.6859	.8383
2	.905	.9526	.8718	.8383	.8764	.6859	.8048
3	.8688	.8764	.8383	.8048	.8413	.6668	.7712
4	.724	.7621	.8048	.788	.8238	.6668	.7377
5	.6516	.7621	.7545	.7545	.7888	.6097	.6706
6	.5731	.5335	.6706	.6539	.6836	.6097	.5868
7	.5014	.4954	.4862	.5197	.5434		.503
8	.4706	.4191	.4694	.4359	.4557	.4954	.4694
9	.3982	.4191	.4694	.4024	.4207	.4694	.4527
10		.9526	.9389	.9221	.964	.9526	.8551
11	.6859	.8551	1.0227	1.0867	1.1431	.8886	.8718
12	.9526	.9724	1.0395	1.1043	1.1431	.9054	.9054
13	.8383	.9054	1.0395	1.1393	.9526	.9054	.9724
14	.8764	.8886	1.0059	1.1568	.8573	.7377	.8383
15	.8764	.9389	.9724	1.0166	.8573	.7712	.8383
16		1.0227	.9389	.9465	.7621	.8215	.8383
17	.8764	1.0227	.9054	.9465		.7377	.7545
18	.5335	.5365	.4694	.4908	.4191	.4862	
19	.7621	.7377	.57	.5959	.6036	.57	
20	.8383	.8048	.7042	.7362	.8383		
21	.9526	.9221	.7377	.7712	.8886	.7545	
22	1.0479	.9556	.8383	.8764	.9221	.8718	
23	1.0479	.9221	.9054	.9465	.6859	.8718	
24	.9412	1.0098	.9054	.8718	.9114	.6859	.8383
Max	1.0479	1.0227	1.0395	1.1568	1.1431	.9526	.9724
Min	.3982	.4191	.4694	.4024	.4191	.4694	.4527
Avg	.7847	.8191	.8027	.8185	.7939	.7205	.7526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164021 / 33/11 KV METPANJRA

Feeder No / Name : 404 / 33 KV T/F Incomer No.II

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9231	.8573	.823	.8745	.8939	.5144	.8745
2	.9231	.8002	.7716	.823	.8413	.5144	.823
3	.8688	.743	.7202	.7716	.7888	.4572	.823
4	.7602	.6859	.6687	.7716	.7888	.4572	.7716
5	.5973	.6287	.6173	.6687	.6836	.4572	.6687
6	.4887	.5144	.5144	.5658	.5784	.4572	.5658
7	.4298	1.4861	.4115	.463	.4733	.5716	.4115
8	.3801	1.2574	.3601	.3601	.4207	.5144	.4115
9	.3258	.3429	.3601	.3601	.3681	.463	.4115
10		1.4289	1.3889	.8745		1.3146	1.0802
11	.9717	1.1831	1.3375	1.3672	1.7147	1.0288	1.1317
12	1.2574	1.286	1.2346	1.4198	1.7147	1.1317	1.1317
13	1.1317	1.2346	1.2346	1.4198	1.6575	1.1317	1.1831
14	1.2003	1.2346	1.1831	1.262	1.5432	1.0802	1.1317
15	.8573	1.286	1.0802	1.3146	1.5432	1.1317	1.0802
16		1.4918	1.0802	1.4198	1.3717	1.1831	1.0802
17	1.086	1.286	1.2346	1.262		1.0288	.9259
18	.4572	.4115	.4115	.4207			
19	.6287	.6173	.4115	.4733			
20	.743	.6613	.5144	.5784			
21	.8002	.823	.7202	.6836		.8745	
22	.9145	.823	.8745	.7888		.9259	
23	.8573	.823	.9259	.8939	.6287	.9259	
24	.9774	.8573	.823	.8745	.8939	.5716	.8745
Max	1.2574	1.4918	1.3889	1.4198	1.7147	1.3146	1.1831
Min	.3258	.3429	.3601	.3601	.3681	.4572	.4115
Avg	.7991	.9485	.8209	.8630	.9944	.7969	.8545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 201 / 11 Kv Paradsinga
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.779	.8238	.8505	.7459	.6802	.823
2	.7287	.779	.8149	.8505	.7293	.6478	.815
3	.6882	.7459	.7716	.815	.7293	.6226	.7087
4	.6226	.6796	.7087	.6733	.6796	.5898	.7087
5	.5304	.6464	.6733	.6379	.6464	.547	.6135
6	.4527	.547	.5316	.567	.5138	.5138	.5258
7	.3944	.4144	.443	.443	.3978	.4031	.4075
8	.3681	.3315	.3856	.4075	.3812	.3366	.3856
9	.3521	.2818	.3721	.4075	.3647	.3721	.3189
10	.2035	.2486	.2804	.2658	.2321	.1174	.1595
11	.1753	.3012	.3012	.2486	.2486	.1595	.1753
12	.2126	.3189	.298	.2818	.2454	.1753	.1578
13	.2321	.3155	.3012	.2321	.2481	.1417	.1417
14	.2321	.298	.298	.2155	.298	.1772	.1844
15	.2321	.298	.298	.2321	.2658	.1772	.1844
16	.2321	.2835	.3155	.3149	.1928	.197	
17	.2486	.2572	.3012	.2155	.1612	.2303	
18	.3481	.3506	.3189	.3812	.3681	.3681	.4207
19	.431	.4075	.4607	.4807	.5487	.5375	.5609
20	.6464	.6613		.6133	.6588	.7282	.6001
21	.7625	.7291	.7796	.7293	.6554	.8149	.6226
22	.7956	.8048	.8505	.0829	.6964	.8573	.6478
23	.8453	.8478	.8288	.8288	.7449	.8817	
24	.8192	.8122	.8413	.8505	.7956	.7125	.8573
Max	.8453	.8478	.8505	.8505	.7956	.8817	.8573
Min	.1753	.2486	.2804	.0829	.1612	.1174	.1417
Avg	.4721	.5058	.5216	.4844	.4812	.4579	.4771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 202 / 11 Kv MASLI (OLD FEEDER SEPERATION/PURE AG
 BHISHNOOR) Feeder KV- 11 /
 OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5407	.5801	.6379	.57	.547	.5735	.6201
2	.4915	.547	.5895	.5765	.5138	.5407	.5847
3	.4641	.547	.5959	.5426	.4807	.5197	.5316
4	.407	.5138	.567	.5087	.4475	.503	.5316
5	.3506	.4807	.539	.4527	.3978	.503	.5014
6	.2715	.3647	.3898	.3521	.3481	.4973	.4382
7	.2452	.2155	.2303	.2486	.2486	.2658	.2303
8	.1991	.1823	.1949	.2347	.1989	.2328	.2481
9	.2241	.1989	.2126	.1844		.2658	.2149
10	1.004	1.2929	1.3599	1.326		.5079	.6733
11	.9717	1.291	1.2763	1.326	1.3757	.4961	.5407
12	.8192	1.3226	1.0774		1.5384	.4382	.6316
13	.8951	1.2003	.9614		1.2289	.3761	.7045
14	.8951	1.073	.9614				.6882
15	.9614	1.0774	.8951				.6882
16	.9614	1.1568	.8288			.5658	
17	.9614	1.0774	.9448		.6687	.5028	
18	.1823	.2328	.1658	1.094	.5434	.2303	.2629
19	.2321	.2835	.2486	.8619	.4207	.3012	.2629
20	.4973	.5144		.8288	.5959	.5258	.2947
21	.5636	.5765	.4973	.7956	.6379	.5959	.3294
22	.6299	.6687	.5636	.5801	.6516	.6687	.3429
23	.6299	.6687	.5636	.6299	.6859	.6661	
24	.6584	.6133	.6516	.57	.5636	.6661	.631
Max	1.004	1.3226	1.3599	1.326	1.5384	.6687	.7045
Min	.1823	.1823	.1658	.1844	.1989	.2303	.2149
Avg	.5857	.6950	.6501	.6490	.6365	.4747	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 203 / 11 Kv Khangao SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.5138	.567	.5533	.4807	.4801	
2	.3155	.4807	.5316	.5533	.4475	.4458	.5316
3	.2835	.4807	.5258	.5365	.4475	.4557	.4961
4	.2835	.4475	.4908	.4694	.431	.4252	.4557
5	.2534	.4475	.4961	.3978	.3647	.394	.394
6	.2534	.3481	.3582	.3315	.3315	.394	.3544
7	.2686	.2486	.2658	.3315	.2321	.2715	.2454
8	.2481	.2155	.2149	.3315	.2155	.2353	.2149
9	.2427	.2155	.2279	.3149	.2155	.2241	.2279
10	.5868	.7459	.8478	.7127	.6962	.2515	.2303
11	.7045	.7712	.8288	.6962	.7459	.2835	.3222
12	.6687	.7373	.8288	.6464	.6661	.3012	.3353
13	.5801	.7122	.6962	.5967	.5596	.2149	.285
14	.6464	.7087	.663	.5138	.4973	.2126	.2713
15	.5967	.7291	.663	.6299		.2454	.2515
16	.6962	.7888	.6133	.4641	.2481	.1907	
17	.6133	.7461	.8453	.6299	.2481	.2454	
18	.2486	.2454	.1989	.2155	.2629	.2481	
19	.2984	.3045	.2818	.3149	.3681	.3366	.3506
20	.4973	.4854		.4144	.4607	.4973	.3772
21	.547	.5434	.4807	.5138	.4961	.5609	.3898
22	.5636	.5895	.5304	.5636	.5258	.6201	.4031
23	.5636	.5895	.5304	.547	.5375	.6135	
24	.3658	.547	.5596	.5365	.5138	.5258	.5784
Max	.7045	.7888	.8478	.7127	.7459	.6201	.5784
Min	.2427	.2155	.1989	.2155	.2155	.1907	.2149
Avg	.4448	.5267	.5324	.4923	.4344	.3614	.3534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 204 / 11 KV KHAPRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1326	.1417	.1326	.116	.1134	.1595
2	.112	.1326	.1402	.1326	.116	.1134	.1417
3	.1134	.116	.1267	.1341	.116	.0983	.1417
4	.0972	.116	.124	.1174	.116	.0983	.1267
5	.0983	.116	.1267	.116	.0995	.0983	.1075
6	.0819	.0829	.0905	.0995	.0829	.0819	.0886
7	.0492	.0497	.0549	.0829	.0497	.0497	.0543
8	.0332	.0497	.0362	.0829	.0497	.0332	.0362
9	.0492	.0497	.0549	.0829	.0497	.0492	.0537
10	.0972	.1492	.1772	.1823	.1823	.0166	.0183
11	.144	.1753	.2155	.1989	.2155	.0362	.0164
12	.144	.1772	.2321	.2155	.2267	.0366	.0164
13	.1658	.1595	.2321	.2155	.1966	.1267	.144
14	.1658	.1417	.2294	.1823	.1802	.0895	.1457
15	.1326	.1772	.1966	.1823	.1638	.1254	.1311
16	.1492	.208	.1638	.1823		.124	
17	.1492	.1772	.1492	.1658	.0166	.1612	
18	.0497	.0724	.0497	.0497	.0332	.0537	
19	.0663	.0709	.0663	.0663	.0819	.0895	.0655
20	.116	.124		.0995	.0983	.1417	.0655
21	.1492	.1578	.1326	.1326	.1134	.1433	.0972
22	.1658	.1772	.1492	.1492	.1134	.1578	.0972
23	.1492	.1772	.1492	.1492	.128	.1753	
24	.128	.1326	.1612	.1326	.1326	.128	.1595
Max	.1658	.208	.2321	.2155	.2267	.1753	.1595
Min	.0332	.0497	.0362	.0497	.0166	.0166	.0164
Avg	.1139	.1301	.1391	.1369	.1164	.0976	.0933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 205 / 11 KV NEW BHISHNOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4973	.5493	.547	.4807		.0362
2	.4359	.4807	.5138	.503	.4475		.0709
3	.407	.4807	.5138	.4641	.4475		.0709
4	.3856	.4475	.4733	.431	.431		.0724
5	.3155	.3978	.4252	.3978	.3978		.0716
6	.2658	.2984	.3189	.3315	.2984		.0543
7	.2328	.2321	.2328	.2486	.1823		.0366
8	.1949	.2155	.2149	.1989	.1823		.0362
9	.2126	.2155	.2126	.1989	.1989		.0358
10	.4862	.6133	.5658	.547	.5636		.0537
11	.4854	.6241	.4475	.5967	.5304		.0526
12	.4607	.5935	.4641		.4801		.0526
13	.4144	.6201	.4973		.4458	.2835	.0497
14		.6001	.4915		.4458	.2835	.0526
15		.5609	.4973		.4207	.298	.0503
16	.0663	.5144	.4915			.3189	
17	.5636	.5144	.4641			.1772	
18	.2652	.2303	.1658			.2481	
19	.2818	.2835	.2652	.2155		.3366	
20	.4475	.3856		.2486		.5258	.0526
21	.5304	.5028	.4973	.2652		.5548	.4862
22	.5801	.5609	.547	.5138		.5784	.4694
23	.547	.5784	.547	.5304		.5658	
24	.5197	.5138	.5609	.547	.4973		
Max	.5801	.6241	.5658	.5967	.5636	.5784	.4862
Min	.0663	.2155	.1658	.1989	.1823	.1772	.0358
Avg	.3894	.4567	.4329	.3991	.4031	.3791	.1003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 403 / 33 KV Paradsinga Incomer

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	.5218	.5316	.5973	.4744	.5784	.5316
2	.4207	.4744	.5373	.5973	.4744	.5258	.5373
3	.3721	.4744	.5316	.5973	.427	.5258	.4784
4	.3721	.4744	.5144	.4887	.427	.4784	.4835
5	.3224	.427	.4784	.4344	.3795	.4784	.3761
6	.2686	.3321	.3761	.3801	.3321	.4784	.2686
7	.2686	.2372	.2181	.2686	.2372	.2686	.1629
8	.2172	.1898	.1646	.2715	.1898	.2149	.1086
9	.2126	.1898	.1097	.2715	.0474	.2658	.1086
10	1.6461	1.945	2.2382	2.2028	.6642	.7888	.9134
11	1.7684	2.1262	2.2565	1.945	2.0399	.7442	.9036
12	1.5775	2.0576	2.0416	.6167	2.2382	.7602	1.0517
13	1.4232	1.7878	1.773	.5693	1.8519	.7522	1.0517
14	1.4706	1.749	1.7193	.4744	.5316	.2195	.9991
15	1.4706	1.8724	1.6655	.6167	.0537	.2715	.9991
16	1.5655	1.9547	1.5581	.427	.2686	.6241	.0532
17	1.5181	1.893	1.9342	.6167	.9465	.5784	.0532
18	.1898	.2149	.1629	1.0911	.6379	.2172	.1063
19	.2372	.2149	.2715	.9014	.5316	.2686	.3155
20	.4744	.3761		.9014	.5316	.4298	.3681
21	.5218	.4784	.543	.9014	.5847	.4835	.3681
22	.5693	.5316	.5973	.5218	.5847	.5316	.3641
23	.5693	.5373	.5973	.5693	.631	.5373	
24	.4784	.5693	.9568	.5973	.5218	.5784	.5373
Max	1.7684	2.1262	2.2565	2.2028	2.2382	.7888	1.0517
Min	.1898	.1898	.1097	.2686	.0474	.2149	.0532
Avg	.7670	.9012	.9468	.7025	.6503	.4833	.4843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164051 / 33/11 kV Paradsinga S/S

Feeder No / Name : 404 / 33 kv T/F NO.II P'SINGA

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	.427	.5316	.4835	.427	.2686	.5847
2	.4733	.427	.5316	.4835	.427	.2686	.543
3	.4252	.427	.4784	.4784	.427	.2658	.5316
4	.3721	.3795	.4887	.4298	.3795	.2658	.4784
5	.3224	.3795	.4252	.3761	.3795	.2172	.4252
6	.2686	.2846	.3761	.3224	.2846	.2149	.3721
7	.2172	.2372	.2715	.2486	.1898	.1629	.2686
8	.2172	.1898	.2715	.1989	.1898	.1086	.2686
9	.2126	.1898	.2715	.2126	.1898	.1629	.2686
10	.8322	.9488	1.1163	1.0099	.9945	.1612	.2715
11	.8413	1.1163	1.0099	.9962	.9488	.2172	.2715
12	.8505	1.1694	1.0099	.4744	.9774	.2715	.2172
13	.759	1.1568	1.0631	.427			.3681
14	.3795	1.2252	1.0631	.3795	.9465	.591	.3641
15	.3321	1.1568	1.0099	.3795	.8413	.6379	.3641
16	.427	1.1568	1.0099	.4744	.2149	.691	.0532
17	.9014	1.1163	.9568	.3795	.1612	.4298	.0532
18	.1898		.1595	.1423	.1612	.2686	.1595
19	.2372	.2715	.2686	.4744	.2126	.2658	.2126
20	.3795	.4252		.5693	.2658	.4784	.2629
21	.4744	.4733	.4835	.6642	.2658	.5316	.4115
22	.4744	.5847	.5373	.2372	.3155	.631	.4115
23	.4744	.5847	.591	.4744	.3155	.6379	
24	.5258	.4744	.5847	.4835	.4973	.3189	.5847
Max	.9014	1.2252	1.1163	1.0099	.9945	.691	.5847
Min	.1898	.1898	.1595	.1423	.1612	.1086	.0532
Avg	.4609	.6435	.6309	.4500	.4353	.3507	.3368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 201 / 11 KV LAXMINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4024	.439	.4207	.3601	.4207	.4119
2	.4024	.3658	.4207	.4207	.3429	.3658	.394
3	.3658	.3658	.4024	.4207	.3258	.3292	.3982
4	.3475	.3292	.3841	.4024	.3086	.2926	.3761
5	.3292	.2926	.3475	.3439	.2915	.2743	.362
6	.2743	.2561	.2743	.2926	.2401	.2561	.3292
7	.2561	.2561	.2378	.2561	.2058	.2378	.2328
8	.2195	.2561	.2195	.2378	.2058	.2195	.2229
9	.2149	.2561	.2229	.2378	.2401	.2012	.2378
10	.2328	.2378	.2534	.2561	.2572	.2012	.2561
11	.2686	.2572	.2743	.2743	.2743	.2561	.2561
12	.2561	.2743	.2743	.2926	.3292	.2378	.2743
13	.2743	.3086	.2926	.3292	.3475	.2561	.3292
14	.3224		.2561		.4024	.2743	.3475
15	.3224	.3258	.3658	.3475	.2378	.2743	.3292
16	.3224	.2915	.3658	.3109	.2195	.2926	.2012
17	.3224	.2915		.2401	.2195	.2328	
18	.3045	.2401	.2743	.2401	.2195	.2149	.0549
19	.3292	.3077	.2743	.2743	.2561	.2058	.0732
20	.3292	.3582	.3658	.3258	.3109	.3086	.3292
21	.3292	.3801	.3841	.3429	.3475	.3582	.4024
22	.3658	.3761	.4024	.3772	.4024	.4298	.4252
23	.3841	.4755	.439	.3944	.4024	.4477	.4024
24	.439	.4207	.4572	.439	.3944	.4207	.4119
Max	.439	.4755	.4572	.439	.4024	.4477	.4252
Min	.2149	.2378	.2195	.2378	.2058	.2012	.0549
Avg	.3180	.3185	.3316	.3251	.2976	.2920	.3069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 202 / 11 KV BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.258	1.2403	1.3289	1.258	1.2517	1.1871	1.2934
2	1.2226	1.2226	1.2757	1.258	1.2174	1.1163	1.2757
3	1.1871	1.2226	1.2403	1.258	1.166	1.0277	1.258
4	1.0985	1.0985	1.134	1.2048	1.0974	.9745	1.2048
5	1.0277	1.0099	1.0631	1.0631	1.0117	.9214	1.0808
6	.9036	.8859	.9745	.9568	.8745	.8682	.9391
7	.8505	.8682	.8859	.8682	.8745	.8682	.8859
8	.7973	.8859	.7796	.7442	.8573	.7796	.7373
9	.8328	.8505	.7716	.7796	.8745	.7973	.7973
10	.9313	.7619	.815	.9391	.8916	.8859	.9568
11	1.0631	.9259	.9745	1.1517	1.1871	1.0631	1.134
12	1.1871	.9088	1.0454	1.2226	1.258	1.134	1.2226
13	1.2403	1.046	1.1517	1.2934	1.2757		1.1871
14	1.3289		1.1517	1.3466	1.3643	1.2226	1.3998
15	1.3466	1.1488	1.2048	1.4352	1.2934	1.3112	1.3998
16	1.3643	1.1145	1.2048	1.3112	1.1163	1.3253	1.1163
17	1.2934	1.0631	1.1517	.9945	1.0985	1.2226	1.0808
18	1.1694	.9602	1.0454	.823	1.0808	1.0454	1.0808
19	1.258	1.0631	1.0985	1.2003	1.0808	1.0974	1.0631
20	1.3289	1.0985	1.2226	1.2517	1.1163	1.2346	1.134
21	1.2403	1.0985	1.2226	1.1488	1.1871	1.2403	1.1517
22	1.2403	1.1163	1.1694	1.2934	1.1694	1.258	1.1694
23	1.2757	1.3289	1.2934	1.3375	1.2048	1.3466	1.134
24	1.3112	1.3112	1.3289	1.2757	1.286	1.2048	1.3289
Max	1.3643	1.3289	1.3289	1.4352	1.3643	1.3466	1.3998
Min	.7973	.7619	.7716	.7442	.8573	.7796	.7373
Avg	1.1565	1.0535	1.1056	1.1423	1.1181	1.0927	1.1263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 203 / 11 kV IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.8238			.8059	.8059	.8238
2	.8238	.815	.788	.7973	.8059	.8059	.8238
3	.788	.7701	.7522	.7973	.8059	.788	.8059
4	.7522	.7701	.7164	.7796	.7888	.7796	.788
5	.7164	.7522	.7164	.7619	.7716	.7701	.7522
6	.7164	.7164	.6984	.691	.7888	.7522	.7343
7	.6447	.6805	.7164	.6201	.6516	.6805	.6626
8	.6626	.6805	.6805	.6268	.6516	.6447	.6687
9	.6984	.6626	.6516	.6268	.6516	.6089	.6805
10	.7164	.6805	.6984	.6984	.6516	.6984	.7164
11	.7522	.703	.6984	.7522	.7343	.5731	.7522
12	.7343	.6687	.7164	.7701	.7522	.591	.7701
13	.788	.6173	.7164	.8238	.8059	.6447	.8238
14	.8775		.6984	.7343	.8954	.6447	.7522
15	.8596	.6859	.7701	.8417	.6984	.6805	.7343
16	.8238	.703	.8059	.8059	.6984	.7701	.6089
17	.7522	.6687	.7701	.7373	.6984	.8059	.6268
18	.7164	.703	.7164	.6687	.7343	.7343	.6626
19	.8059	.7522	.7701	.6859	.7522	.703	.7343
20	.8954	.8775	.8596	.7202	.7522	.823	.8059
21	.8596	.9134	.8238	.703	.7164	.8238	.8238
22	.8059	.9313	.8059	.7545	.8417	.8954	.7343
23	.8238	.8596	.8238	.8059	.788	.9134	.6626
24	.8596	.8417	.8417	.8238	.8059	.8059	.8417
Max	.8954	.9313	.8596	.8417	.8954	.9134	.8417
Min	.6447	.6173	.6516	.6201	.6516	.5731	.6089
Avg	.7805	.7512	.7494	.7403	.7520	.7393	.7412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 204 / 11 KV PANCHWATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.1163	1.0985	1.1163	1.0802	1.0631	1.1222
2	1.0985	1.0808	1.0631	1.1163	1.046	1.0099	1.0924
3	1.0631	1.0277	1.0277	1.1163	.9945	.9568	1.086
4	.9922	1.0277	.9922	1.0631	.9431	.8859	1.0498
5	.8859	.8859	.9214	.9391	.8573	.815	.8954
6	.7619		.7265	.7796	.703	.7442	.7602
7	.6556	.6556	.6201	.6379	.6344	.6556	.6878
8	.6024	.5847	.5493	.567	.583	.5493	.5658
9	.6024	.6024	.4801	.4961	.5487	.4961	.567
10	.6024	.5847	.543	.5316	.5144	.567	.567
11	.5847	.6001	.567	.567	.567	.6024	
12	.5847		.6556	.6024	.6733	.567	.6201
13	.7265	.7202	.7087	.7442	.7442	.6024	.691
14	.8596		.7619	.7796	.8859	.6733	.8328
15	.8775	.8916	.8682	.8328	.7265	.7973	.8505
16	.8596	.8573	.8505	.815	.6201	.7964	.5493
17	.724	.823	.7619	.3944	.5847	.724	.567
18	.6805	.6859	.7796	.583	.5493	.6335	.5316
19	.7796	.6984	.6733	.6687	.6201	.6344	.6201
20	.9036	.9134	.8505	.8059	.815	.8059	.7796
21	.9391	.9492	.9214	.9259	.8859	.9231	.8859
22	1.0454	1.086	1.0631	1.134	.9568	1.1041	.9991
23	1.0808	1.134	1.134	1.1488	1.0099	1.2127	.8859
24	1.1517	1.1163	1.1163	1.134	1.1145	1.0631	1.1584
Max	1.1517	1.134	1.134	1.1488	1.1145	1.2127	1.1584
Min	.5847	.5847	.4801	.3944	.5144	.4961	.5316
Avg	.8415	.8591	.8222	.8125	.7774	.7868	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 205 / 11 KV PETHBUDHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6241	.6068	.6241	.6379	.6173	.5548	.6335
2	.6068	.5721	.5895	.6379	.6001	.5201	.6268
3	.5895	.5721	.5721	.6379	.583	.4854	.6154
4	.5721	.5548	.5548	.6201	.5487	.4681	.5973
5	.5375	.4681	.5375	.567	.5316	.4508	.5853
6	.4508	.4334	.4681	.4607	.4458	.4161	.4887
7	.3988	.3814	.3814	.3898	.3772	.3641	.4024
8	.3641	.3814	.3467	.3814	.3429	.3121	.3429
9	.3467	.3641	.3429	.3294	.3544	.3121	.3467
10	.3294	.3294	.3761	.3467	.3429	.3121	.3467
11	.3467	.3944	.3641	.3814	.3814	.3294	.3814
12	.3641		.4508	.3988	.3814	.3814	.4161
13	.4334	.6859	.4334	.4508	.4508	.2947	.4854
14	.5121		.4508	.4681	.4854	.3988	.4854
15	.5121	.5316	.4508	.4854	.3988	.4334	.5028
16	.5068	.4801	.4508	.4334	.2601	.4477	.3467
17	.4572	.4801	.4161	.6516	.2947	.394	
18	.3982	.4115	.3988	.3258	.3641	.3045	.3294
19	.4681	.4298	.4075	.3772	.3814	.3429	.3988
20	.5375	.5552	.4961	.4458	.4161	.4458	.4508
21	.5375	.5552	.5316	.5144	.4508	.5487	.5028
22	.5721	.5973	.5847	.6001	.5721	.6154	.7537
23	.6068	.6588	.6733	.6379	.5548	.6516	.5201
24	.6241	.6415	.6415	.6556	.6344	.5548	.6516
Max	.6241	.6859	.6733	.6556	.6344	.6516	.7537
Min	.3294	.3294	.3429	.3258	.2601	.2947	.3294
Avg	.4874	.5039	.4810	.4931	.4488	.4308	.4874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 401 / 33 KV T/F Incomer No.I NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4714	2.4714	2.524	2.4451	2.4177	2.3663	2.4714
2	2.4188	2.3663	2.4188	2.4451	2.3663	2.2085	2.4714
3	2.3137	2.3663	2.3663	2.4451	2.3148	2.1033	2.4188
4	2.1559	2.1559	2.2085	2.3388	2.2119	1.9982	2.3137
5	2.0508	1.9982	2.1033	2.1262	2.0576	1.893	2.1559
6	1.8404	1.9456	1.893	1.9136	1.8004	1.893	1.9456
7	1.7353	1.7878	1.7878	1.701	1.6461	1.7353	1.7353
8	1.6301	1.7878	1.6301	1.5947	1.6975	1.6827	1.5947
9	1.7353	1.6827	1.5947	1.6827	1.749	1.5775	1.6827
10	1.8404	1.6827	1.7353	1.8404	2.0576	1.7353	1.893
11	2.0508	1.8519	1.9456	2.1559	2.2085	1.8404	2.1033
12	2.1559	1.9033	1.9982	2.2611	2.3137	1.9456	2.2611
13	2.2611	2.0576	2.1559	2.4188	2.524	2.0508	2.3137
14	2.4714		2.0508	2.3663	2.6818	2.1033	2.4188
15	2.4714	2.1605	2.3663	2.5766	2.2611	2.2085	2.4188
16	2.4714	2.1091	2.4188	2.3663	1.9982	2.3137	1.893
17	2.3388	2.0062	2.2085	2.1091	1.9982	2.2085	1.6827
18	2.1559	1.9033	2.0508	2.0576	1.9982	1.9456	1.7878
19	2.3137	2.0508	2.1262	2.2634	2.0508	2.0062	1.8404
20	2.4714	2.3137	2.4177	2.4177	2.1033	2.3663	2.2085
21	2.3663	2.3663	2.392	2.2857	2.3137	2.3663	2.2611
22	2.4188	2.3663	2.3388	2.4451	2.3663	2.524	2.2611
23	2.4188	2.5766	2.4983	2.5206	2.3137	2.6818	2.1559
24	2.5766	2.524	2.5766	2.4983	2.4177	2.3663	2.5766
Max	2.5766	2.5766	2.5766	2.5766	2.6818	2.6818	2.5766
Min	1.6301	1.6827	1.5947	1.5947	1.6461	1.5775	1.5947
Avg	2.2139	2.1058	2.1586	2.2198	2.1612	2.0884	2.1194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 402 / 33 KV T/F Incomer No.II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	1.7353	1.7353	1.7353	1.6975	1.5775	1.6827
2	1.6827	1.6827	1.6301	1.7353	1.6461	1.5249	1.6827
3	1.6301	1.5775	1.5775	1.7353	1.5947	1.4198	1.6301
4	1.5775	1.5775	1.5249		1.4918	1.3146	1.5775
5	1.4198	1.3146	1.4723	1.4723	1.3889	1.262	1.4198
6	1.2094	1.3146	1.2094	1.4723	1.1317	1.1568	1.2094
7	1.0517	1.0517	.9991	1.0099	1.0288	.9991	1.0517
8	.9465	.9465	.8939	.9568	.9259	.8939	.8745
9	.9465	.9465	.8745	.8413	.8745	.7888	.8939
10	.9465	.8939	.8939	.8939	.8745	.7888	.8939
11	.9465	.9774	.9991	.9465	.9465	.8413	.9991
12	.8939		1.1043	.9991	1.0517	.9465	.9991
13	1.1568	1.1831	1.1568	1.1043	1.2094	.9991	1.1568
14	1.3146		1.2094	1.2094	1.3672	.9991	1.3146
15	1.3672	.9774	1.3146	1.3146	1.1043	1.1568	1.3146
16	1.3146	1.3375	1.3146	1.262	.8413	1.1568	.8939
17	1.1568	1.286	1.1568	1.0802	.8939	1.0517	.5258
18	1.0517	1.0802	1.2094	.9774	.8939	.8939	.8413
19	1.262	1.1043	1.0631	1.0802	.9991	.9774	.9991
20	1.4198	1.4198	1.3289	1.286	1.262	1.2346	1.2094
21	1.4723	1.4723		1.4403	1.3672	1.4198	1.3146
22	1.6301	1.6301	1.6478	1.6975	1.5249	1.6827	1.5775
23	1.6827	1.7878	1.8073	1.749	1.5249	1.7878	1.4198
24	1.7353	1.7353	1.7353	1.7541	1.6461	1.5775	1.7353
Max	1.7353	1.7878	1.8073	1.7541	1.6975	1.7878	1.7353
Min	.8939	.8939	.8745	.8413	.8413	.7888	.5258
Avg	1.3146	1.3196	1.2982	1.2936	1.2203	1.1855	1.2174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 404 / 33 KV RAPDRP Incomer NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2067	4.161	4.2593	4.2896	4.1152	3.9009	4.1541
2	4.1015	4.0049	4.0489	4.2896	4.0124	3.6928	4.1541
3	3.9438	3.9009	3.9438	4.2896	3.9095	3.4848	4.0489
4	3.7334	3.6928	3.7334	4.0724	3.7037	3.2768	3.8912
5	3.4705	3.2768	3.5757	3.6923	3.4465	3.1207	3.5757
6	3.0498	3.1207	3.1024	3.2036	2.9321	3.0167	3.155
7	2.7869	2.8086	2.7869	2.7984	2.7778	2.7046	2.7869
8	2.5766	2.7046	2.524	2.6063	2.6235	2.5486	2.6235
9	2.6818	2.6006	2.5206	2.524	2.6235	2.3663	2.5766
10	2.7869	2.5486	2.6292	2.7343	2.9321	2.524	2.7869
11	2.9973	2.8292	2.9127	3.0687	3.1207	2.6818	3.0687
12	3.0498	2.8292	3.0687	3.2602	3.3288	2.8921	3.2247
13	3.4179	3.1379	3.2768	3.5231	3.6928	3.0498	3.4328
14	3.786		3.2247	3.5757	4.0049	3.1024	3.7334
15	3.8386	3.6008	3.5888	3.8912	3.3288	3.3653	3.7334
16	3.786	3.4465	3.6928	3.6283	2.8086	3.4705	2.7869
17	3.4705	3.3653	3.4328	2.6749	2.8607	3.2602	2.2085
18	3.2076	3.0498	3.2247	2.9321	2.8607	2.8395	2.6292
19	3.5368	3.155	3.2579	3.2407	3.0167	2.9835	2.8395
20	3.8489	3.7334	3.8009	3.5494	3.3288	3.6008	3.4179
21	3.7969	3.8386	3.9506	3.774	3.6408	3.786	3.5757
22	4.0049		4.0724	4.0638	3.8489	4.2067	3.8386
23	4.2067	4.3644	4.3982	4.2181	3.8386	4.4696	3.5368
24	4.3118	4.2593	4.3118	4.3896	4.1152	3.9438	4.3118
Max	4.3118	4.3644	4.3982	4.3896	4.1152	4.4696	4.3118
Min	2.5766	2.5486	2.5206	2.524	2.6235	2.3663	2.2085
Avg	3.5249	3.3831	3.4724	3.5121	3.3696	3.2620	3.3371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 201 / 11kV Ladgaon Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.3395	.3206	.3395	.3206	.3395
2	.3206	.3395	.3206	.3206	.3395	.3018	.3206
3	.3206	.3395	.3206	.3206	.3395	.3018	.3206
4	.3018	.3206	.3018	.3018	.3206	.2829	.2829
5	.2641	.2614	.2452	.2641	.2829	.2452	.2263
6	.1867	.2452	.1886	.1886	.1886	.2075	.1698
7	.1109	.1307	.1294	.1307	.1307	.1307	.1509
8	.1097	.1307	.1109	.1109	.112	.112	.1132
9	.1097	.1307	.1307	.0895	.1307	.112	.132
10		.2881	.3479	.2372	.2214	.1475	.1524
11		.2915	.2915	.2056	.2846	.1423	.1638
12		.2915	.2785	.1677	.2591	.125	.1389
13		.2753	.2294	.1326	.2486	.125	.1219
14		.2591	.2155	.1509	.2294	.1235	.1526
15		.2591	.2486	.0995	.1619	.1389	.1475
16	.2721	.2622	.2561		.1134	.1406	.116
17	.2753	.2429	.2458	.16	.081	.116	.0972
18	.2688	.132	.168	.132	.128	.132	.132
19	.253	.1886	.1886	.1886	.1698	.1886	.1698
20	.2829	.2641	.2829	.2641	.2641	.2829	.1698
21	.3206	.3206	.3395	.3206	.3018	.3395	.2452
22	.3584	.3584	.3395	.3395	.3395	.3584	.2402
23	.3395	.3395	.3395	.3584	.3395	.3772	.2402
24	.3206	.3395	.3395	.3206	.3395	.3206	.3395
Max	.3584	.3584	.3479	.3584	.3395	.3772	.3395
Min	.1097	.1307	.1109	.0895	.081	.112	.0972
Avg	.2631	.2646	.2583	.2228	.2361	.2114	.1951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 202 / 11kv Murti Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4481	.4715	.4527	.4527	.4481	.4481
2	.4668	.4481	.4715	.4527	.4527	.4481	.4481
3	.4668	.4481	.4527	.4338	.4338	.4527	.4481
4	.4294	.4294	.415	.415	.415	.3734	.3921
5	.3734	.3921	.3395	.3395	.3361	.2987	.3361
6	.2641	.3206	.2452	.2075	.2829	.2452	.2427
7	.1698	.1698	.1698	.1698	.1509	.1886	.1867
8	.1663	.1698	.1867	.1886	.1698	.1463	.1848
9	.1848	.1867	.1698	.1698	.1307	.1132	.1867
10		.2778	.4254	.381	.3269	.1781	.1783
11		.2968	.2896	.3506	.2675	.1783	
12		.3041	.2932	.3201	.2643	.208	.2027
13		.2881	.2932	.2824	.3081	.1957	.1932
14		.2881	.2968	.286	.2743	.1806	.216
15		.2688	.2846	.2743	.2027	.1656	.2054
16	.2515	.2846	.3161	.2824	.1488	.1524	
17	.2187	.2778	.2641	.3241	.1252	.1391	.1389
18	.208	.1867	.168	.1494	.2054	.181	.2075
19	.1981	.2427	.2263	.2641	.3395	.2987	.3206
20	.4715	.4527	.415	.415	.4527	.4668	.4527
21	.5281	.5281	.5093	.4715	.4904	.5041	.4527
22	.4668	.5415	.5093	.4904	.4854	.5228	.4338
23	.5041	.5041	.4715	.4668	.4668	.5041	
24	.4668	.4481	.4715	.4481	.4481	.4481	.4668
Max	.5281	.5415	.5093	.4904	.4904	.5228	.4668
Min	.1663	.1698	.168	.1494	.1252	.1132	.1389
Avg	.3501	.3418	.3398	.3348	.3179	.2932	.302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 203 / 11kV Ambada Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2263	.2263	.2263	.2263	.2241	.2035
2	.2452	.2263	.2263	.2263	.2263	.2241	.2035
3	.2452	.2263	.2263	.2263	.2263	.2054	.1989
4	.2263	.2075	.2075	.2075	.2075	.2033	.1781
5	.2075	.1867	.2075	.1886	.1494	.2033	.1524
6	.168	.1494	.1698	.168	.1307	.1829	.1429
7	.1294	.1109	.1294	.1267	.1109	.1417	.1036
8	.1086	.1109	.1086	.1086	.1086	.1372	.0991
9	.1075	.112	.1109	.1075	.1109	.1372	.1006
10		.6167	.6562	.5864	.6401	.2559	.3612
11		.5601	.6722	.68	.6009	.2201	.3715
12		.7202	.6325	.6958	.5624	.1486	.3963
13		.6401	.5851	.5761	.5506	.2229	.4321
14		.6081	.6009	.5921	.5281	.2408	.4111
15		.2561	.6562	.6316	.3437	.2408	.3658
16	.7202	.6958	.7202	.6483	.3125	.2439	
17	.6882	.7202	.6093	.5121	.2641	.2115	
18	.6249	.1294	.1294	.1109	.1254	.1036	
19	.5182	.1478	.1478	.1494	.1663	.1389	
20	.1886	.2075	.1886	.1886	.1867	.2012	.2075
21	.2263	.2263	.2452	.2263	.2218	.2204	.1886
22	.2452	.2172	.2452	.2263	.2427	.2427	.1886
23	.2263	.2263	.2263	.2263	.2427	.2229	
24	.2452	.2263	.2263	.2263	.2263	.2427	.2204
Max	.7202	.7202	.7202	.6958	.6401	.2559	.4321
Min	.1075	.1109	.1086	.1075	.1086	.1036	.0991
Avg	.2981	.3231	.3398	.3276	.2796	.2007	.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164057 / 33/11 Kv MURTI SUBSTATION

Feeder No / Name : 405 / 33 KV Murti Incomer
Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	.4481	.4481	.4527	.4481	.4435	.4481
2	.4481	.4481	.4481	.4527	.4481	.4435	.4481
3	.4481	.4481	.4481	.4527	.4481	.4435	.4481
4	.4481	.4481	.3921	.3961	.3921	.3881	.3881
5	.3921	.3921	.3361	.3395	.3361	.2772	.3326
6	.2801	.3361	.2241	.2263	.2801	.2195	.2195
7	.1663	.1663	.168	.2801	.168	.1595	.1595
8	.1646	.1646	.1646	.168	.1612	.1543	.1578
9	.1578	.1646	.1646	.168	.1086	.1543	.1595
10		1.2186	1.2809	1.2186	1.186	.535	.6773
11		1.1385	1.3283	1.2186	1.1574	.6241	.5418
12		1.2963	1.2483	1.1717	1.1111	.4967	.7316
13		1.2003	1.1523	.9842	1.0517	.5487	.7968
14		1.1523	1.2003	1.0437	1.0437	.5487	.759
15		.7773	1.2483	.9962	.6859	.5556	.7499
16	1.2334	1.2631	1.2963	.9259	.5944	.5418	.0869
17	1.1717	1.2334	1.1248	.9602	.4904	.4904	
18	1.0974	.1663	.1646	.1663	.2126	.156	.2829
19	.9722	.2218	.2218	.2801	.3292	.2743	.3395
20	.4481	.4481	.3961	.3961	.4481	.4435	.4527
21	.5041	.5041	.5093	.4481	.5041	.499	.4527
22	.4481	.5601	.5093	.5041	.499	.499	.4527
23	.5041	.5041	.4527	.4481	.4435	.499	.4481
24	.4481	.4481	.4481	.4527	.4481	.4435	.4481
Max	1.4003	1.2963	1.3283	1.2186	1.186	.6241	.7968
Min	.1578	.1646	.1646	.1663	.1086	.1543	.0869
Avg	.5963	.6312	.6406	.5896	.5415	.4099	.4340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 201 / 11 KV MOHPA RURAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.6001	.8215		.7619	.7316	.6201
2	.5624	.6001	.8215	.7362	.7619	.724	.6201
3	.5624	.583	.8029	.7362	.7619	.6584	.6201
4	.5624	.583	.7842	.7011	.7619	.6219	.6201
5	.5312	.6001	.7842	.631	.7619	.4755	.6201
6	.5312	.6173	.5788	.4908	.5138	.4572	.4961
7	.4111	.6516	.4108	.3258	.3361	.5144	.4607
8	.6483	.6687	.2987	.3086	.3361	.583	.6733
9	.6167	.6859	.3547	.333	.3174	.5658	.6661
10	.5658	.6009	.3681	.3547	.3326	.443	.4973
11	.4108	.4481	.8916	.8682	.567	.2987	.4031
12	.4854	.4805	.8573	.8328	.567	.443	.5258
13	.5975	.6348	.8413	.7619	.6036	.443	.583
14	.6348	.7095	.7888	.7087	.5853	.443	.6001
15	.6535	.6722	.7888	.6733	.567	.3898	.5144
16	.6535	.5601	.7716		.4572	.3544	.4801
17	.5601	.4481	.7362	.4252	.3658	.443	.3856
18	.3734	.3547	.7011	.3898	.4755	.2801	.2804
19	.5228	.3921	.4557	.3721	.5601	.443	.3681
20	.7095	.5601	.6135	.5847	.6535	.6556	.5609
21	.7282	.8402	.7712	.6379	.7133	.7442	.6836
22	.8589	.8775	.7888	.7619	.7468	.8328	
23	.8589	.8589	.8063	.7796	.7682	.815	
24	.8402	.8402	.8402	.7712	.7619	.8048	.7973
Max	.8589	.8775	.8916	.8682	.7682	.8328	.7973
Min	.3734	.3547	.2987	.3086	.3174	.2801	.2804
Avg	.6017	.6195	.6949	.5993	.5849	.5486	.5489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 202 / 11 KV LINGA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	15-JUN-18	16-JUN-18	17-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.0082	.9922
2	1.0185	1.0082	.9804
3	1.0185	.9709	.9922
4	.9431	.9335	.9602
5	.8962	.7202	.9962
6	.6535	.6348	1.0722
7	.4854	.5975	1.2483
8	.5658	.5601	1.4243
9	.547	.5788	1.5364
10	.6161	.6413	1.4022
11	1.3889	1.3927	
12	1.406	1.5384	
13	1.4918	1.3765	
14	1.4918	1.3279	
15	1.4746	1.3765	
16	1.4918	1.5708	
17	1.4918	1.6194	
18	1.3032	1.4575	
19	1.0082	.5658	
20	1.0829	.8865	
21	1.1203	1.094	
22	1.0456	1.1317	
23	1.0456	1.094	
24	1.0374	1.0456	1.0562
Max	1.4918	1.6194	1.5364
Min	.4854	.5601	.9602
Avg	1.0684	1.0471	1.1510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 203 / 11 KV METPANJRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4374	.4801	.4854	.4115	.443	.439	.4607
2	.4687	.4801	.4854	.4115	.443	.439	.4607
3	.4687	.463	.4481	.3772	.443	.4207	.4607
4	.4374	.463	.4481	.3856	.443	.3658	.4607
5	.4062	.5144	.4108	.3506	.443	.4207	.4607
6	.427	.5144	.3361	.2804	.3361	.3658	.443
7	.5376	.6687	.2054	.2103	.1867	.4973	.4784
8	.5693	.6859	.1307	.1753	.1698	.5144	.6201
9	.5693	.7545	.1494	.1227	.1509	.5144	.6661
10	.5658	.6009	.1543	.1867	.1478	.5316	.5316
11	.2241	.1867	.7888	.8682	.6219	.1867	.1928
12	.2427	.1294	.8063	.7796	.6036	.2614	.2401
13	.2801	.1494	.7712	.6733	.6036	.2614	.2401
14	.2987	.1494	.7202	.6201	.567	.2801	.3086
15	.2987	.1494	.7011	.567	.5304	.2801	.2804
16	.2987	.2054	.6135		.4755	.1867	.2804
17	.1867	.2614	.583	.4252	.4938	.1509	.2454
18	.1494	.1867	.6173	.2987	.4755	.1132	.1402
19	.2614	.2054	.1753	.2054	.2614	.2241	.2103
20	.3361	.3734	.3155	.2987	.2987	.3361	.3155
21	.3361	.4668	.3856	.3547	.3511	.3898	.3506
22	.4854		.3944	.3898	.3734	.4252	
23	.4854	.4854	.4557	.4607	.462	.443	
24	.4854	.4854	.4854	.4557	.443	.4805	.4607
Max	.5693	.7545	.8063	.8682	.6219	.5316	.6661
Min	.1494	.1294	.1307	.1227	.1478	.1132	.1402
Avg	.3857	.3939	.4611	.4047	.4070	.3553	.3776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 204 / 11KV BUDHLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2241	.6718	.5609		.2402	.2427
2	.2054	.2241	.6718	.5609		.1848	.2427
3	.2054	.2054	.6562	.5258		.1848	.2427
4	.2054	.2054	.6562	.5258		.1848	.2427
5	.1867	.1867	.703	.583		.1478	.2054
6	.1494	.168	.7343	.8413		.1478	.1698
7	.112	.1494	.9646	1.046		.112	.132
8	.0934	.1494	.933	1.1568		.1307	.1132
9	.0747	.112	.9804	1.2003	1.1145	.1307	.1227
10	.1307	.1494	1.0692		1.1765	.1867	.1753
11	.9431	.8745	.1227		.2587	1.0974	1.0517
12	.9259	1.086	.1753		.2587	1.166	1.0166
13	.823	.8745	.1753		.2587	1.166	.9259
14	.823	.9069	.1578		.2195	1.1488	.9088
15	.7373	.9878	.1402		.1848	1.1317	.9465
16	.7888	1.0526	.1402		.1294	1.0631	.9088
17	.8059	1.1012	.1372		.1294	.8916	.9114
18	.7373	1.0364	.1029		.1294	1.1317	.8764
19	.1867	.168	.1052		.168	.2054	.12
20	.2054	.2054	.1928		.2427	.2427	.2401
21	.2241	.2614	.2454		.1294	.2614	.2629
22	.2614	.2614	.2454	.2614	.2801	.3174	
23	.2614	.2427	.2103		.2587	.2801	
24	.2241	.2427	.2241	.2103		.2033	.2427
Max	.9431	1.1012	1.0692	1.2003	1.1765	1.166	1.0517
Min	.0747	.112	.1029	.2103	.1294	.112	.1132
Avg	.3965	.4615	.4340	.6793	.3292	.4982	.4682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 205 / 11 KV GINNI AGRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.2829	.1132		.1143	.132
2	.3018	.2427	.3018	.0943		.1143	.132
3	.3018	.2829	.2829	.0943		.0953	.132
4	.3018	.2829	.2829	.0943		.0953	.132
5	.3018	.2641	.2829	.1132		.1143	.132
6	.0943	.1132	.1132	.1132		.0953	.1132
7	.1132	.112	.1132	.0943		.1029	.1132
8	.0943	.0943	.1132	.1132		.0566	.1132
9	.0943	.1132	.0754		.0943	.0754	.0754
10	.1132	.132	.132				.1132
11	.1132	.132			.0762	.0566	.1698
12	.1132	.1334			.0762		.132
13	.132	.1509	.2263		.0953	.2241	.1509
14	.0943	.1698	.2075		.1143	.2241	.1132
15	.0943	.132	.0754		.1143	.2614	
16	.0943	.132	.1132		.1143	.2614	.1509
17	.1132		.1132		.0762	.2987	.1886
18	.1132	.1132	.1509		.1905	.2801	.2452
19	.1698	.132	.1132		.0754	.2801	.1886
20	.0943	.132	.0943		.0754	.0943	.1132
21	.0943	.0943	.1132		.1143	.0943	.1509
22	.1132	.1132	.1132	.0943	.1132	.1132	
23	.3018	.3206	.1132		.1143	.1132	
24	.3018	.3018	.2829	.1132		.1143	.132
Max	.3018	.3206	.3018	.1132	.1905	.2987	.2452
Min	.0943	.0943	.0754	.0943	.0754	.0566	.0754
Avg	.1651	.1738	.1680	.1038	.1032	.1491	.1392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164025 / 33/11 KV KOHLI

Feeder No / Name : 206 / Mohapa Urban Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.0187		.0187	.0189
2		.0187		.0187		.0187	.0189
3		.0187		.0187		.0187	.0189
4		.0187		.0187		.0187	.0189
5		.0187		.0187		.0187	.0189
6		.0187		.0187		.0187	.0189
7		.0187		.0187		.0187	.0189
8		.0187		.0187		.0187	.0189
9		.0187		.0187	.0189	.0189	.0187
10	.0187		.0187	.0189	.0187	.0189	.0187
11	.0187		.0187	.0189	.0187	.0189	.0187
12	.0187	.0187	.0187	.0189	.0187	.0189	
13	.0187		.0187	.0189	.0187	.0189	.0187
14	.0187		.0187	.0189	.0187	.0189	.0187
15	.0187		.0187	.0189	.0187	.0189	.0187
16	.0187		.0187	.0189	.0187	.0189	.0187
17	.0187		.0187	.0189	.0187	.0189	.0187
18	.0187		.0187	.0189	.0187	.0189	.0187
19	.0187		.0187	.0189	.0187	.0189	.0175
20	.0187		.0187	.0189	.0187	.0189	.0175
21	.0187		.0187	.0189	.0187	.0189	.0187
22			.0187	.0189	.0187	.0189	
23	.0187		.0187	.0189	.0187	.0189	
24		.0187		.0187		.0187	.0189
Max	.0187	.0187	.0187	.0189	.0189	.0189	.0189
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0175
Avg	.0187	.0187	.0187	.0188	.0187	.0188	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 201 / 11 KV Kumari

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6516	.631	.6556	.5194	.6516	.4477
2	.6219	.6516	.631	.6379	.5014	.6154	.443
3	.567	.6516	.6485	.6024	.5014	.5792	.4075
4	.5792	.6344	.6485	.567	.4656	.543	.3721
5	.5847	.6173	.6859	.5138	.4344	.5249	.3366
6	.5571	.6344	.7545	.4252	.3475	.5068	.2835
7	.7602	.7716	.8718	.3544	.3326	.3258	.2658
8	.8859	.8745	1.1401	.2126	.2772	.2715	.1949
9	.7796	.8916	.9389	.1612	.2957	.2534	.2303
10	.7442	.7545	.9389	.2481	.2957	.1417	.2303
11	.2534			1.1233	1.0288	.8309	.9412
12	.3439			.9835	1.0631	.9724	.9922
13	.4525			1.0227	1.0288	.8718	1.0498
14	.5249		.4784	1.1065	1.046	.9326	1.086
15	.543	.5487	.4961	1.073	.8916	.8648	1.086
16	.4344	.4938	.4961	.9724		.8648	1.0679
17	.3258	.3511	.3189	1.0227	.7545	.5596	.9774
18	.2534	.2772	.2303	.9496	.6516	.5197	.9774
19	.2534	.2957	.2835	.3734	.3258	.3582	.362
20	.4706	.4938	.443	.5175	.4887	.5552	.5121
21	.5611	.567	.5138	.6283	.5611	.6268	.6036
22	.6516	.6767	.6556	.7133	.6878	.5144	
23	.6878	.6767	.6733	.5487	.7059	.3582	
24	.6733	.6697	.6767	.6626	.5194	.7059	.4656
Max	.8859	.8916	1.1401	1.1233	1.0631	.9724	1.086
Min	.2534	.2772	.2303	.1612	.2772	.1417	.1949
Avg	.5486	.6092	.6264	.6698	.5967	.5812	.6060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 202 / nandikheda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5493	.4973	.5316	.4784	.4805	.4706	.373
2	.6219	.5144	.5316	.4607	.462	.4344	.3688
3	.6219	.5144	.5144	.443	.462	.3982	.373
4	.5847	.5144	.5144	.3898	.4435	.362	.3688
5	.6201	.5144	.4973	.3544	.4066	.3258	.3688
6	.6335	.4973	.5487	.2835	.2987	.2896	.3688
7	.695	.5487	.6173	.2126	.2054	.2353	.407
8	.695	.703	.6952	.1595	.168	.1991	.5138
9	.7265	.6859	.6874	.2303	.1494	.0724	.5365
10	.6401	.6173	.6443	.2303	.2054	.2328	.5197
11	.2172	.1867	.2481	.6706	.6001	.503	.2481
12	.2896	.3326	.2835	.7209	.6344	.5087	.3292
13	.362	.3881	.3544	.6874	.6687	.4917	.362
14	.3801	.3696	.3544	.6539	.6859	.5197	.3441
15	.3982	.4066	.3721	.6539		.5426	.3258
16	.3077	.2772	.3189	.6036	.4115	.4917	.2896
17	.2534	.2801	.2658	.5765	.4458	.5087	.1629
18	.181	.2241	.2126	.5087	.3772	.4024	.181
19	.2172	.2614	.2507	.2614	.1991	.2534	
20	.4344	.4435	.4075	.3511	.4163	.4298	.4024
21	.4887	.499	.4961	.4435	.4887	.4835	.4525
22	.543	.5729	.5194	.4805	.5068	.5373	
23	.5249	.5544	.5138	.499	.5068	.5014	
24	.4961	.5068	.5359	.5014	.4805	.4887	.4835
Max	.7265	.703	.6952	.7209	.6859	.5426	.5365
Min	.181	.1867	.2126	.1595	.1494	.0724	.1629
Avg	.4784	.4546	.4548	.4523	.4219	.4035	.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 203 / Mohapa Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.543	.5609	.5487	.5434	.543	.6001
2	.4607	.5068	.5609	.5487	.5434	.5068	.6001
3	.3801	.5068	.5258	.5316	.5258	.5068	.583
4	.3841	.4706	.5258	.5144	.5083	.4706	.5487
5	.4024	.4525	.5083	.4801	.4908	.4525	.5316
6	.4075	.4344	.4784	.4458	.4252	.4344	.4801
7	.439	.3982	.4075	.4115	.3366	.3982	.4458
8	.362	.3439	.3544	.3772	.3366	.362	.4458
9	.3841	.3982	.3544	.3772	.3189	.3801	.4287
10	.4075	.3982	.3898	.3601	.3012	.3429	.4115
11	.4163	.4075	.3772	.4075	.3801	.3772	.4887
12	.3982	.4607	.3944	.443	.4163	.4287	.5068
13	.3982	.4075	.4287	.443	.4525	.5144	.5249
14	.4525	.4557	.4458	.5258	.5249	.4973	.5611
15	.5068	.5258	.4801	.5258	.5068	.5144	.5611
16	.5068	.5083	.4801	.4252	.4163	.5144	.5611
17	.4706	.4908	.4458	.3721	.3801	.3772	.5068
18	.3801	.4382	.4115	.3898	.3439	.3772	.5068
19	.4344	.4557	.463	.4607	.4344	.4801	.543
20	.543	.5258	.5144	.4733	.5068	.5144	.5853
21	.5611	.5434	.4801	.5083	.5249	.5144	.5853
22	.5611	.5258	.5316	.5434	.543	.5658	
23	.6154	.5609	.5658	.5784	.5973	.6516	
24	.5853	.5792	.5609	.591	.5434	.5792	.6001
Max	.6154	.5792	.5658	.591	.5973	.6516	.6001
Min	.362	.3439	.3544	.3601	.3012	.3429	.4115
Avg	.4578	.4724	.4686	.4701	.4542	.4710	.5276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 204 / TELKAMTHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1949	.2353	.2587	.2204	.1227	.1402	.2328
2	.1595	.2172	.2587	.2035	.1227	.1227	.2328
3	.1402	.1991	.2402	.2012	.1052	.1227	.2328
4	.1448	.181	.2241	.2012	.1052	.1227	.2149
5	.128	.1629	.2241	.1696	.1063	.1052	.197
6	.1402	.1448	.168	.1187	.124	.1052	.1433
7	.1086	.1086	.0934	.1509	.1052	.1753	.1075
8	.0732	.0905	.0934	.1865	.1715	.1928	.0895
9	.0732	.0724	.0934	.1526	.1715	.1753	.0709
10	.0709	.0905	.0934	.1357	.1372	.1433	.0709
11	.1052	.2058	.1696	.0934	.1086	.1075	.181
12	.1052	.2229	.1865	.112	.1086	.1075	.181
13	.1052	.1886	.1696	.1494	.1267	.1433	.181
14	.1402	.2058	.1526	.168	.181	.1612	.181
15	.1227	.2229	.1526	.112	.181	.1433	.181
16	.1227	.1734	.1696	.0747	.0905	.1075	.1629
17	.1402	.1734	.1696	.0747	.0905	.0895	.1448
18	.1402	.1227	.1526	.0747	.0905	.0716	.1448
19	.1052	.0934	.0886	.112	.1086	.0895	.1063
20	.1629	.168	.1595	.1494	.181	.1791	.1646
21	.2172	.2054	.1949	.168	.1991	.1791	.1829
22	.2353	.2218	.2507	.2033	.2172	.2328	
23	.2534	.2402	.2481	.2402	.2172	.2328	
24	.2303	.2534	.2587	.2328	.2402	.2353	.2149
Max	.2534	.2534	.2587	.2402	.2402	.2353	.2328
Min	.0709	.0724	.0886	.0747	.0905	.0716	.0709
Avg	.1425	.175	.1779	.1544	.1422	.1452	.1645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 205 / KANIYADOL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.3982	.4435	.3688	.3155	.3155	.4119
2	.3292	.3801	.4435	.3688	.3086	.3155	.394
3	.3012	.362	.4066	.3688	.2915	.3155	.3544
4	.2926	.3258	.4066	.3521	.2915	.298	.3403
5	.2835	.3077	.3696	.3521	.2774	.298	.3224
6	.2835	.2896	.2801	.3391	.2915	.298	.2865
7	.2012	.181	.1867	.3856	.2601	.3681	.1791
8	.1463	.1629	.168	.4409	.3086	.3856	.1417
9	.1595	.1448	.168	.4578	.3429	.3681	.1063
10	.1595	.1629	.168	.407	.3429	.3582	.1772
11	.3856	.3944	.3963	.1867	.181	.1791	.3258
12		.463	.4748		.2172	.2149	.3982
13		.463			.2896	.1075	.3982
14		.4287			.3077	.1075	.3801
15		.4115	.0848		.1267	.1075	.3361
16		.4458	.0678	.168	.0543	.0895	.2715
17	.4557	.4801	.1696	.1494	.1448	.0537	.3801
18	.4031	.3772		.168	.1448	.1254	.3658
19	.4031	.1867	.1772	.2241	.1991	.197	.1949
20	.3681	.3881	.3224	.2957	.3077	.3224	.3258
21	.3856	.3881	.3898	.3696	.362	.3761	.3681
22	.3856	.4435	.4119	.4066	.4163	.4298	
23	.3856	.4435	.4119	.4251	.4344	.4477	
24	.4252	.4163	.4435	.4119	.4066	.4344	.4298
Max	.4557	.4801	.4748	.4578	.4344	.4477	.4298
Min	.1463	.1448	.0678	.1494	.0543	.0537	.1063
Avg	.3224	.3519	.3043	.3323	.2759	.2714	.3131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 201 / 11 KV BELONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.8764	.8764	.8573	.8002	.724
2	.8383	.8383	.8383	.8573	.8383		.6859
3	.8383	.7811	.8002	.8383	.8192	.7811	.6478
4	.8383	.8192	.7621	.8383	.8002	.7811	.8002
5	.7621	.6668	.6478	.724	.5716	.7621	.6097
6	.5335	.4572	.5716	.5716	.4763	.6097	.5716
7	.3239	.3429	.4191	.4572	.4572	.4763	.5716
8	.362	.2858	.4001	.4572	.4382		.5716
9	.3239	.2096	.381	.3239	.4191		.724
10	.3048	.3239	.3429	.3239	.4382		
11	.3048	.3429	.362	.3429	.4572	.4572	.5335
12	.3239	.4763	.4001	.381	.5144	.4954	.4382
13	.4954	.6478	.6097	.4572	.4382	.5335	.9145
14	.6668	.6859	.6478	.381	.4572	.5335	.9526
15	.6287	.6478	.6859	.381		.6478	.8954
16	.5906	.5906	.4954	.381	.1905	.6668	.8192
17	.4954	.381	.4382	.381	.1715	.5906	.4572
18	.4001	.4191	.4001	.381	.1715	.5716	.4954
19		.6478	.5144	.381	.2096	.5335	.8002
20	.7811	.7049	.7049	.362	.2667	.6097	1.086
21	.8573	.8002	.7621	.5716	.7811	.6097	1.1431
22	.9145	.9145	.8764	.8002	.8573	.8764	1.1812
23	.8573	.8954	.9145	.8573	.8192	.8573	.9526
24	.8573	.8573	.8764	.8954	.8573	.8002	.7621
Max	.9145	.9145	.9145	.8954	.8573	.8764	1.1812
Min	.3048	.2096	.3429	.3239	.1715	.4572	.4382
Avg	.6155	.6081	.6136	.5509	.5351	.6497	.7538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 203 / 11 KV MOWAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6097	.6668	.6478	.6478	.5525	.4954
2	.6478	.5716	.6478	.6478	.6287	.5525	.4572
3	.6478	.5335	.5716	.6287	.6097	.5335	.381
4	.6287	.4954	.5335	.6287	.5906	.5525	.3429
5	.5335	.4572	.4954	.5335	.4763	.4763	.3429
6	.4572	.4191	.381	.4191	.381	.4001	.3048
7	.381	.381	.3429	.381	.362	.362	.3048
8	.3239	.3048	.3048	.2858	.2858	.2858	.3048
9	.2858	.2667	.2286	.2667	.2667	.2858	.3048
10	.3048	.3048	.362	.362	.3429	.3429	.3429
11	.3429	.3429	.381	.381	.362	.381	.4001
12	.381	.4572	.4191	.4382	.362	.4191	
13	.4191	.4954	.5144	.362	.4001	.4763	.4763
14	.4572	.5144	.4954	.362	.4763	.4954	.4954
15	.4001	.5144	.4954	.381		.5335	.4763
16		.5335	.4572	.4191	.3429	.4954	.4572
17	.4001	.4191	.4191	.381	.3239	.3429	.4191
18	.4001	.381	.362	.3048	.3048	.3048	.362
19	.4763	.4572	.4572	.362	.381	.3429	.4763
20	.5335	.5335	.5335	.4954	.4954	.5525	.5906
21	.5906	.6097	.5525	.5716	.5144	.6097	.6097
22	.6478	.6859	.6287	.5906	.5716		.6478
23	.6478	.6668	.6859	.6287	.6097		.6859
24	.6668	.6478	.6668	.6668	.6478	.5716	.5335
Max	.6668	.6859	.6859	.6668	.6478	.6097	.6859
Min	.2858	.2667	.2286	.2667	.2667	.2858	.3048
Avg	.4887	.4834	.4834	.4644	.4515	.4486	.4440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 204 / 11 KV MANIKWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.381	.4001	.381	.4001	.362
2	.362		.4001	.381	.381	.3429
3	.362	.362	.4191	.381	.381	.3239
4	.381	.362	.4191	.381	.381	.3239
5	.381	.3429	.4572	.3429	.2858	.2858
6	.4001	.3048	.4382	.2667	.2667	.2286
7	.4001	.2858	.4001	.2286	.2286	.1905
8	.4572	.2096	.381	.2096	.2286	.1905
9	.4382	.1524	.381	.2286	.2096	.2286
10	.4001	.4001	.4191	.2096	.2286	.2096
11	.4001	.381	.4001	.2286	.2286	.2096
12	.4001	.2858	.381	.2286	.2477	.1905
13	.362	.2667	.2667	.4001	.4001	
14	.3048	.3048	.2667	.3239	.4382	
15	.2858	.2667	.2858	.381		
16	.2667	.2858	.2477	.4572	.2286	
17	.2477	.2667	.2286	.4191	.1715	
18	.2096	.2477	.2286	.381	.1715	
19		.3048	.2286	.362	.1905	
20	.2286		.362	.381	.2096	
21	.3048	.381	.362	.3429	.3239	
22	.4001	.4191	.4001	.4001	.362	
23	.381	.4001	.4001	.4001	.381	
24	.381	.381	.4001	.4001	.4001	.381
Max	.4572	.4191	.4572	.4572	.4382	.381
Min	.2096	.1524	.2286	.2096	.1715	.1905
Avg	.3529	.3178	.3572	.3382	.2932	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 205 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0572	.0572	.0572
2	.0381	.0381	.0381	.0381	.0381	.0572	.0572
3	.0381	.0572	.0381	.0381	.0381	1.5813	.0572
4	.0381		.0381	.0381	.0381	.0572	.0572
5	.0381	.0572	.0381	.0191	.0381	.0381	.0572
6	.0381	.0572	.0191	.0381	.0381	.0572	.0572
7	.0381	.0572	.0191	.0191	.0381	.0572	.0572
8	.0381	.0381	.0191	.0381	.0381	.0572	.0572
9	.0572	.0381	.0191	.0381	.0572	.0572	.0572
10	.0381	.0572	.0381	.0572	.0381	.0572	.0572
11	.0381	.0572	.0381	.0572	.0572	.0572	.0381
12	.0572	.0572	.0381	.0572	.0381	.0572	.0381
13	.0572	.0572	.0381	.0381	.0381	.0381	.0381
14	.0381	.0572	.0381	.0381	.0381	.0572	.0381
15	.0381	.0572	.0381	.0381		.0381	.0381
16	.0572	.0572	.0191	.0381	.0381	.0381	
17	.0572	.0572	.0191	.0381	.0381	.0191	.0381
18	.0381	.0572	.0191	.0381	.0572	.0191	.0381
19	.0381	.0381	.0381	.0572	.0572	.0191	.0381
20	.0381	.0381	.0381	.0381	.0572	.0572	.0381
21	.0381	.0572	.0381	.0381	.0572	.0381	.0381
22	.0381	.0572	.0381	.0572	.0572	.0381	.0381
23	.0572	.0572	.0381	.0572	.0572	.0572	.0191
24	.0381	.0381	.0381	.0381	.0572	.0572	.0572
Max	.0572	.0572	.0381	.0572	.0572	1.5813	.0572
Min	.0381	.0381	.0191	.0191	.0381	.0191	.0191
Avg	.0429	.0514	.0326	.0413	.0464	.1112	.0464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164023 / 33/11 KV MOWAD

Feeder No / Name : 206 / 11 KV BORKHEDI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0572	.0381	.0381	.0191
2	.0381	.0572	.0381	.0572	.0381	.0381	.0191
3	.0381		.0381	.0572	.0381	.0381	.0191
4	.0381	.0572	.0381	.0572	.0381	.0572	.0381
5	.0191	.0381	.0191	.0572	.0381	.0381	.0381
6	.0191	.381	.0191	.0572	.0381	.0381	.0381
7	.0191	.0191	.0191	.381	.0572	.0381	.0381
8	.0191	.0191	.0191	.0572	.0572	.0381	.0191
9	.0191	.0191	.0191	.0572	.0572	.0381	.0191
10	.0191	.0191	.0191	.0572	.0762	.0762	.0191
11	.0191	.0191	.0191	.0762	.0762	.0381	.0381
12	.0191	.0762	.0191	.0572	.0762	.0381	.0381
13	.0381	.0762	.0953	.0191	.0381	.0191	.0572
14	.0572	.0953	.0762	.0191	.0381	.0381	.0572
15	.0381	.0572	.0572	.0191		.0381	.0572
16	.0191	.0572	.0572	.0191	.0191	.0381	.0572
17		.0572	.0572	.0191		.0191	.0572
18	.0572	.0762	.0572	.0191	.0191	.0381	.0572
19	.0572	.0762	.0572	.0191	.0191	.0191	.0381
20	.0762	.0762	.0572	.0381	.0381	.0191	.0381
21	.0572	.0572	.0381	.0381	.0381	.0191	.0381
22	.0381	.0572	.0381	.0381	.0381	.0191	.0381
23	.0381	.0572	.0572	.0381	.0381	.0191	
24	.0572	.0381	.0572	.0572	.0381	.0381	.0191
Max	.0762	.381	.0953	.381	.0762	.0762	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0365	.0663	.0429	.0572	.0433	.0349	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 201 / 11 KV NARKHED URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.8099	1.7909	1.7147	1.7147	1.7909	1.9052
2	1.8099	1.8099	1.7909	1.7147	1.7147		1.9052
3	1.8099	1.8099	1.7909	1.7147	1.7147	1.7909	1.7147
4	1.7147	1.7147	1.7909	1.5242	1.6194	1.7909	1.5242
5	1.6194	1.5242	1.6118	1.4289	1.5242	1.6118	1.4289
6	1.5242	1.3336	1.2536	1.3336	1.3336	1.4327	1.2384
7	1.3336	1.1431	1.2536		1.2384	1.0745	1.1431
8	1.1431	1.1431	1.0745	.9526	.9526	1.0745	1.0479
9	1.1431	.9526	1.0745	.9526	1.0479	.985	.9526
10	1.1431	.9526	1.0745	1.1431	1.1431	.8954	1.1431
11	1.2384	1.0745	1.1431	1.0745	1.2384	1.1431	1.2536
12	1.2384	1.0745	1.1431	1.0745	1.2384	1.1431	1.2536
13	1.3336	1.3432	1.3336	1.0745	1.3336	1.3336	1.2536
14	1.4289	1.4327	1.3336	1.2536	1.3336	1.3336	1.2536
15	1.4289	1.3432	1.3336	1.2536	1.3336	1.3336	1.4327
16	1.4289	1.2536	1.3336	1.2536	.9526	1.3336	1.4327
17	1.3336	1.2536	1.2384	1.0479	.8954	1.2384	1.0745
18	1.3336	1.2536	1.1431	1.0479	.985	1.1431	1.0745
19	1.2384	1.4327	1.3336	1.3336	1.2536	1.3336	1.2536
20	1.6194	1.6118	1.4289	1.5242	1.4327	1.5242	1.4327
21	1.8099	1.6118		1.7147	1.6118	1.8099	1.6118
22	1.9052	1.6118	1.6194	1.8099	1.7909	1.8099	1.7909
23	1.8099	1.7909	1.7147	1.8099	1.7909	1.9052	
24	1.9052	1.8099	1.7909	1.7147	1.7147	1.7909	1.9052
Max	1.9052	1.8099	1.7909	1.8099	1.7909	1.9052	1.9052
Min	1.1431	.9526	1.0745	.9526	.8954	.8954	.9526
Avg	1.5083	1.4205	1.4085	1.3681	1.3712	1.4184	1.3924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 202 / 11 KV YENIKONI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0154	.0191	.0191	.0154	.0191
2	.0191	.0191	.0154	.0191	.0191	.0154	.0191
3	.0191	.0191	.0154	.0191	.0191	.0154	.0191
4	.0191	.0191	.0154	.0191	.0191	.0154	.0191
5	.2477	.3429	.0154	.0191	.0191	.1543	.1905
6	.2858	.381	.0154	.0191	.0191	.1852	.2286
7	.2858	.381	.0154	.0191	.0191		.2858
8	.3239	.381	.0154	.0191	.0191	.216	.3239
9	.4382	.4382	.0154	.0191	.0191	.2469	.2858
10	.4001	.4001	.0154	.0191	.0191	.3086	.3429
11	.4001	.3241	.0191	.0154	.0191	.4191	.2778
12	.381	.3086	.0191	.0154	.0191	.4191	.2932
13	.0191	.0154	.4191	.3395	.381	.0191	.0154
14	.0191	.0154	.4001	.3241	.4001	.0191	.0154
15	.0191	.0154	.381	.3086	.381	.0191	.0154
16	.0191	.0154	.4191	.3241		.0191	
17	.0191	.0154	.4382	.4191		.0191	
18	.0191	.0154	.4572	.4001	.216	.0191	
19	.0191	.0154	.381	.381	.216	.0191	.0154
20	.0191	.0154	.362	.3429	.216	.0191	.0154
21	.0191	.0154	.0191	.0191	.0154	.0191	.0154
22	.0191	.0154	.0191	.0191	.0154	.0191	.0154
23	.0191	.0154	.0191	.0191	.0154	.0191	
24	.0191	.0191	.0154	.0191	.0191	.0154	.0191
Max	.4382	.4382	.4572	.4191	.4001	.4191	.3429
Min	.0191	.0154	.0154	.0154	.0154	.0154	.0154
Avg	.1278	.1342	.1468	.1307	.0957	.0972	.1216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 203 / 11 KV NARKHED RURAL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0166	.0191	.0191	.0166	.0191
2	.0191	.0191	.0166	.0191	.0191	.0166	.0191
3	.0191	.0191	.0166	.0191	.0191	.0166	.0191
4	.0191	.0191	.0166	.0191	.0191	.0166	.0191
5	.1715	.5335	.0166	.0191	.0191	.2321	.2286
6	.2477	.5716	.0166	.0191	.0191	.2652	.2667
7	.362	.6097	.0166	.0191	.0191	.2321	.3429
8	.4954	.6097	.0166	.0191	.0191	.2321	.381
9	.5144	.6097	.0166	.0191	.0191	.2486	.4382
10	.4763	.6097	.0166	.0191	.0191	.2486	.381
11	.4763	.5552	.0191	.0166	.0191	.2667	.3481
12	.4763	.5138	.0191	.0166	.0191	.2477	.2984
13	.0191	.0166	.724	.5801	.3048	.0191	.0166
14	.0191	.0166	.7049	.547	.3429	.0191	.0166
15	.0191	.0166	.6668	.5138	.3239	.0191	.0166
16	.0191	.0166	.6287	.4973	.3048	.0191	.0166
17	.0191	.0166	.6097	.5335	.2818	.0191	.0166
18	.0191	.0166	.6478	.5335	.2321	.0191	.0166
19	.0191	.0166	.5716	.4954	.2486	.0191	.0166
20	.0953	.0166	.5335	.4191	.2652	.0191	.0166
21	.0762	.0166	.0191	.0191	.0166	.0191	.0166
22	.0762	.0166	.0191	.0191	.0166	.0191	.0166
23	.0191	.0166	.0191	.0191	.0166	.0191	
24	.0191	.0191	.0166	.0191	.0191	.0166	.0191
Max	.5144	.6097	.724	.5801	.3429	.2667	.4382
Min	.0191	.0166	.0166	.0166	.0166	.0166	.0166
Avg	.1548	.2038	.2235	.1842	.1084	.0944	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV SARDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0633	.0762	.0762	.0633	.0762
2	.0762	.0762	.0633	.0762	.0762	.0633	.0762
3	.0762	.0762	.0633	.0762	.0762	.0633	.0762
4	.0572	.0762	.0633	.0762	.0572	.0474	.0572
5	.4001	.6287	.0474	.0381	.0572	.3637	.4382
6	.5144	.6478	.0158	.0191	.0191	.3953	.4572
7	.5716	.7811	.0158	.0191	.0191	.3321	.4763
8	.6668	.7811	.0158	.0191	.0191	.4111	.4763
9	.6287	.6478	.0474	.0191	.0191	.4428	.4763
10	.6097	.724	.0158	.0191	.0191	.4586	.4572
11	.6287	.6325	.0191	.0158	.0191	.5906	.3953
12	.6478	.6325	.0191	.0158	.0191	.5716	.3953
13	.0191	.0474	.8573	.68	.724	.0191	.0474
14	.0191	.0474	.8573	.6642		.0191	.0474
15	.0191	.0474	.8002	.6483	.7811	.0191	.0474
16	.0191	.0158	.724	.6325	.4954	.0191	.0474
17	.0191	.0158	.7811	.743	.3163	.0191	.0474
18	.0191	.0158	.8192	.724	.3479	.0191	.0158
19	.0191	.0474	.8002	.6668	.253	.0381	.0474
20	.0572	.0474	.7621	.6097	.4111	.0572	.0474
21	.0762	.0633	.0762	.0762	.0633	.0572	.0633
22	.0953	.0633	.0762	.0762	.0633	.0572	.0633
23	.0953	.0633	.0762	.0762	.0633	.0572	
24	.0762	.0762	.0633	.0762	.0762	.0633	.0762
Max	.6668	.7811	.8573	.743	.7811	.5906	.4763
Min	.0191	.0158	.0158	.0158	.0191	.0191	.0158
Avg	.2286	.2638	.2976	.2560	.1770	.1770	.1917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 205 / 11 KV KHARSOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2667	.2667	.2667	.2286
2	.2858	.2858	.2667	.2667	.2667	.2286
3	.2477	.2667	.2667	.2667	.2667	.2286
4	.1905	.2477	.2477	.2477	.2477	.2286
5	.1143	.1905	.5243	.6478	.4382	.2096
6	.0953	.0953	.5735	.6859	.5144	.1524
7	.0762	.0953	.639	.8002	.4954	.0953
8	.0762	.0762	.6718	.8573	.5525	.0953
9	.0762	.0762	.7045	.8192	.5716	.0953
10	.0953	.0762	.639	.8954	.5906	.0953
11	.1143	.1143	.724	.5243	.7621	.0953
12	.1334	.1334	.6859	.6882	.8192	.1143
13	.7621	.7209	.1715	.1334	.1143	.6287
14	.7811	.7537	.1905	.1524	.1334	
15	.7621	.7209	.1905	.1524	.1334	
16	.7621	.6882	.1524	.1143	.0191	
17	.7811	.7209	.1143	.0953	.0191	
18	.7811	.7373	.0762	.0762		
19	.7811	.7209	.1524	.1905	.1905	
20	.6287	.7045	.1905	.2286	.2096	
21	.2858	.2858	.2667	.2667	.2286	
22	.3048	.2858	.2858	.2858	.2477	
23	.3048	.2858	.2858	.2858	.2477	
24	.2858	.2858	.2667	.2667	.2667	.2286
Max	.7811	.7537	.724	.8954	.8192	.6287
Min	.0762	.0762	.0762	.0762	.0191	.0953
Avg	.3755	.3689	.3564	.3839	.3305	.1946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 206 / 11 KV PARSODI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0316	.0572	.0381	.0316	.0381
2	.0381	.0381	.0316	.0572	.0381	.0316	.0191
3	.0381	.0381	.0316	.0572	.0381	.0316	.0191
4	.0381	.0381	.0316	.0381	.0381	.0316	.0191
5	.0381	.0381	.2056	.2477	.2477	.0316	.0191
6	.0381	.0191	.253	.2858	.3239	.0158	.0191
7	.0191	.0191	.2688	.362	.3429	.0158	.0191
8	.0191	.0191	.3321	.4001	.4191		.0191
9	.0191	.0191	.3795	.4191	.381		.0191
10	.0191	.0191	.3795	.4382	.4001		.0191
11	.0191	.0316	.4191	.3637	.362		.0316
12	.0381	.0316	.381	.3479	.3239		.0316
13	.3239	.3163	.0381	.0316	.0191		.1581
14	.362	.3321	.0381	.0316	.0191	.2477	.1581
15	.3429	.3321	.0381		.0191	.2477	.1898
16	.381	.3321	.0381	.0158		.2286	.1581
17	.3429	.3321	.0191	.0191		.2286	
18	.3429	.3321	.0191	.0191		.2286	.1739
19	.3239	.3163	.0191	.0381	.0158	.1905	.1898
20	.1715	.2846	.0381	.0381	.0158	.1905	.1898
21	.0381	.0316	.0381	.0381	.0316	.0381	.0316
22	.0381	.0316	.0381	.0381	.0316	.0381	.0316
23	.0381	.0316	.0381	.0381	.0316	.0381	
24	.0381	.0381	.0316	.0572	.0381	.0316	
Max	.381	.3321	.4191	.4382	.4191	.2477	.1898
Min	.0191	.0191	.0191	.0158	.0158	.0158	.0191
Avg	.1294	.1275	.1308	.1495	.1512	.1054	.074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353] BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 207 / 11 kv Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.2286	.12	.1334	.1905	.2058	.0953
2	.381	.2096	.1029	.1143	.1905	.2058	.0953
3	.381	.1905	.1029	.1143	.1905	.1886	.0953
4	.4001	.1905	.0857	.1143	.1715	.1886	.0953
5	.4001	.2286	.1029	.0953	.1905	.2058	.1334
6	.4763	.2858	.12	.0953	.1905	.2401	.1524
7	.5716	.2667	.12	.1143	.1143	.1543	.2286
8	.6478	.4382	.4973	.1143	.2667	.5487	.2667
9	.4572	.4382	.6173	.362	.5335	.5658	.381
10	.743	.6097	.7202	.4572	.5525	.583	.4382
11	.724	.5487	.7621	.3772	.5716	.4763	.5144
12	.6668	.5316	.724	.3429	.6097	.4763	.5144
13	.6859	.583	.6668	.3601	.6097	.4763	.5144
14	.7049	.6173	.6668	.3772	.5906	.4763	.5144
15	.7049	.6001	.6097	.3772	.6097	.4572	.6173
16	.6097	.5376	.4572	.3601	.6097	.4572	.4115
17	.5716	.5658	.1715	.1905	.5144	.4572	.2915
18	.4763	.5487		.1905	.5316	.4572	.4801
19	.2667	.3086	.1524	.1524	.3086	.3239	.2915
20	.4191	.1372	.1524	.2477	.1886	.0953	.2058
21	.381	.1372	.1715	.2286	.2229	.0953	.2401
22	.3048	.12		.1905	.2743	.0953	.3086
23	.2667	.12	.1715	.1905	.2401	.0953	
24	.4001	.2286	.12	.1334	.1715	.2229	.0953
Max	.743	.6173	.7621	.4572	.6097	.583	.6173
Min	.2667	.12	.0857	.0953	.1143	.0953	.0953
Avg	.5017	.3613	.3371	.2264	.3602	.3229	.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 208 / 11 KV YENIKONI II

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.1638	.2286	.2096	.1802	.2096
2	.2096	.2096	.1638	.2286	.2096	.1802	.2096
3	.2096	.2096	.1581	.2286	.1905	.1802	.1905
4	.1905	.2096	.1581	.1905	.1905	.1638	.1905
5	1.2765	1.4289	.1265	.1334	.1334	.7045	.9907
6	1.3336	1.448	.0949	.0953	.0953	.7701	1.0288
7	1.4289	1.5051	.0633	.0762	.0762	.7045	1.1812
8	1.4861	1.6194	.0492	.0572	.0762	.6718	1.2384
9	1.467	1.6385	.0655	.0572	.0762	.8192	1.3717
10	1.5623	1.2765	.0655	.0572	.0762	.8848	1.3908
11	1.5813	1.1142	.0762	.0655	.0953	1.086	1.1961
12	1.5813	1.1469	.0762	.0819	.0953	1.086	1.0978
13	.1524	.1311	1.8671	1.5238	1.2193	.1334	.1311
14	.1334	.1311	1.8099	1.4255	1.2955	.1334	.1311
15	.1334	.1311	1.7528	1.2452	1.2384	.1334	.1311
16	.1143	.1147	1.6575	1.278	.7811	.1143	.0655
17	.1143	.0983	1.5813	1.467	.7209	.0953	.0492
18	.0953	.0819	1.6004	1.467		.0762	.0655
19	.0953	.1147	1.6004	1.4289	.852	.1143	.1311
20	.1715	.1311	1.6194	1.3908	.8684	.1524	.1475
21	.2096	.1802	.2667	.1524	.1802	.1715	.1638
22	.2286	.1966	.2477	.1715	.1802	.2096	.1802
23	.2286	.1802	.2286	.1715	.1802	.2096	
24	.2096	.2096	.1638	.2286	.2096	.1802	.2096
Max	1.5813	1.6385	1.8671	1.5238	1.2955	1.086	1.3908
Min	.0953	.0819	.0492	.0572	.0762	.0762	.0492
Avg	.6009	.5715	.6524	.5604	.4022	.3815	.5088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 209 / 11 KV Tinkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.0949	.1334	.1334	.0949	.3239
2	.1334	.1334	.0949	.1334	.1334	.0949	.3239
3	.1334	.1334	.0949	.1334	.1334	.0949	.3239
4	.1334	.1334	.0949	.1143	.1334	.0949	.3239
5	.1143	.1143	.4428	.5144	.381	.0949	.3239
6	.0953	.0762	.4744	.5716	.4954	.0791	.3239
7	.0762	.0762	.427	.5716	.5716	.0633	.3048
8	.0762	.0762	.4902	.5906	.5906	.0791	.2858
9	.0762	.0762	.4428	.6287	.6287	.0474	.1334
10	.0572	.0953	.5376	.6478	.6668	.0316	.1334
11	.0572	.0791	.6287	.506	.6478	.0381	.1898
12	.0572	.0633	.6097	.4902	.6097	.0572	.2056
13	.5716	.4902	.0762	.0633	.0953	.2858	.7907
14	.6287	.506	.0953	.0633	.0953	.2667	.8223
15	.6097	.4902	.0953	.0633	.0953	.2858	.759
16	.4763	.4902	.0762	.0633	.0381	.3048	.7432
17	.4954	.5218	.0572	.0572	.0474	.6859	
18	.5144	.5535	.0572	.0572	.0474	.7621	.4111
19	.5525	.5376	.0953	.0953	.0791	.7621	.4586
20	.5144	.506	.1143	.1143	.0949	.7811	.4902
21	.1334	.1107	.1143	.1334	.1107	.2858	.3637
22	.1334	.1107	.1334	.1334	.1107	.2667	.3637
23	.1334	.1107	.1334	.1334	.1107	.2667	
24	.1334	.1334	.0949	.1334	.1334	.0949	.2858
Max	.6287	.5535	.6287	.6478	.6668	.7811	.8223
Min	.0572	.0633	.0572	.0572	.0381	.0316	.1334
Avg	.2568	.2396	.2323	.2561	.2576	.2466	.3948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 201 / 11 KV SONOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5426	.4382	.5935	.5087	.3506	.4525
2	.4382	.5087	.4382	.5765	.5087	.3506	.4344
3	.4382	.5087	.4382	.5426	.5087	.3506	.362
4	.5735	.663	.3506	.5426	.5087	.3506	.2591
5	.5735	.6962	.3506	.5087	.4239	.3155	.2753
6	.6554	.7459	.2103	.3391	.3391	.1753	.2753
7	.6554	.7956	.1402	.1357	.1357	.1052	.2591
8	.6554	.8619	.1402	.1357	.1357	.1052	.4049
9	.6554	.9116	.1402	.1696	.1357	.1086	.4534
10	.7459	.8848	.1357	.1357	.1402	.1086	.4858
11	.6796	.852	.1357	.1357	.1402	.1086	.4858
12	.1357	.1402	.8288	.8288	.7373	.4858	.0905
13	.2543	.1402	1.0774	.9945	.9012	.4858	.181
14	.3052	.1753	.6299	.9282	.8192	.502	.2172
15	.2543	.1753	.9116	.9116	.7373	.3239	.2896
16	.2035	.1402	.9614	.8619	.1341	.2915	.0905
17	.1696	.1402	.9779	.8288	.1677	.2915	.0905
18	.1357	.1402	.9945	.8288	.2515	.2915	.0905
19	.1357	.1402	.9116	.7956	.2515	.2915	.0905
20	.2035	.2629	.2035	.2035	.1402	.3258	.2896
21	.5087	.5258	.4239	.4239	.3155	.4525	.2896
22	.5426	.5258	.5087	.5087	.3506	.543	.2896
23	.5935	.5258	.5935	.5256	.3506	.543	
24	.5258	.5935	.5258	.5935	.5256	.3506	.4525
Max	.7459	.9116	1.0774	.9945	.9012	.543	.4858
Min	.1357	.1402	.1357	.1357	.1341	.1052	.0905
Avg	.4402	.4832	.5194	.5437	.3820	.3170	.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 202 / 11 KV NANDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.4508	.4207	.4334	.4161	.3856	.439
2	.3681	.4334	.4207	.4161	.4161	.3681	.4024
3	.3544	.4161	.4207	.4161	.3988	.3681	.3841
4	.3856	.5375	.4031	.4161	.3988	.3681	.2785
5	.3688	.5087	.3681	.3814	.3467	.333	.2785
6	.3353	.4239	.2454	.3121	.208	.2454	.2622
7	.3185	.373	.1578	.156	.1387	.1402	.2458
8	.3856	.4748	.1227	.156	.0867	.1227	.3277
9	.426	.5087	.1052	.156		.128	.3441
10	.4239	.426	.0867	.1734	.1928	.1463	.3605
11	.373	.3768	.0867	.1907	.2103	.1463	.3605
12		.2103	.39	.39	.3441	.2785	.2012
13		.2804	.4239	.5087	.4915	.426	.2195
14		.3155	.4409	.5596	.4752	.4096	.2561
15	.2601	.3155	.4409	.4917	.3768	.3441	.2926
16	.2947	.2804	.4409	.4917	.0838	.2785	.1646
17	.2427	.2279	.4748	.4917	.0838	.2785	.1463
18	.1907	.1928	.5256	.4239		.2949	.1463
19	.2254	.2454	.4239	.39	.218	.2949	.2012
20	.3641	.333	.3052	.3294	.298	.3292	.3658
21	.4161	.4207	.3814	.3814	.3681	.4207	.4207
22	.4508	.4382	.4334	.4334	.4031	.4572	.439
23	.4681	.4207	.4508	.4334	.3856	.4572	
24	.4207	.4508	.4207	.4334	.4161	.3856	.439
Max	.4681	.5375	.5256	.5596	.4915	.4572	.439
Min	.1907	.1928	.0867	.156	.0838	.1227	.1463
Avg	.3552	.3776	.3496	.3736	.3071	.3086	.3033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 203 / 11 KV MALAPUR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.0857	.1052	.1029	.1029	.1052	.0934
2	.1052	.0857	.1052	.0857	.1029	.1052	.0934
3	.1052	.0857	.1052	.0857	.0857	.1052	.0934
4	.0876	.0857	.1006	.0857	.0838	.1006	.0934
5	.0876	.0857	.1006	.0838	.1006	.1006	.0934
6	.0701	.0857	.1006	1.2574	.1006	.0838	.056
7	.0526	.0514	.1006	.1006	.1006	.0838	.056
8	.0526	.0514	.1006	.1341	.1006	.1006	.056
9	.0526	.0514	.1341	.1341	.1006	.0972	.056
10	.0514	.0526	.1372	.1341	.1006	.0972	.056
11	.0514	.0526	.1341	.1677	.1006	.0972	.056
12	.0514	.1006	.0514	.0514	.0876	.056	.081
13	.0838	.1341	.0857	.0514	.0876	.056	.081
14	.1006	.1341	.0857	.0857	.0876	.056	.081
15	.1006	.1341	.0857	.0857	.0701	.056	.081
16	.1341	.1341	.0857	.0857	.0526	.056	.081
17	.1174	.1341	.0514	.0514	.0526	.056	.081
18	.1006	.1341	.0514	.0514	.0526	.056	
19	.0838	.1341	.0514	.0857	.0876	.056	.0486
20	.0514	.1052	.0857	.0857	.1052	.056	.056
21	.0857	.1052	.0857	.0857	.1052	.056	.0934
22	.0857	.1052	.0857	.0857	.1052	.0934	.0934
23	.0857	.1052	.1029	.0857	.1052	.0934	
24	.1052	.0857	.1086	.1029	.1029	.1052	.0934
Max	.1341	.1341	.1372	1.2574	.1052	.1052	.0934
Min	.0514	.0514	.0514	.0514	.0526	.056	.0486
Avg	.0836	.0966	.0934	.1402	.0909	.0804	.0761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 204 / 11KV MANNATH AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6447	.5959	.6268	.6268	.5434	.6099
2	.5959	.6268	.5784	.6089	.6089	.5611	.5914
3	.5784	.6268	.5609	.591	.6089	.5258	.5914
4	.5784	.6089	.9339	1.1283	.6089	.6062	.5729
5	.5609	.5373	.9503	1.153	.5373	.5898	.462
6	.3856	.4477	.9995	1.1869	.3045	.5735	.3696
7	.2279	.2328	1.0486	1.2209	.2149	.5571	.2218
8	.2103	.2149	1.1797	1.2378	.763	.6554	.2033
9	.2103	.2149	1.2125	1.2378	1.0174	.6796	.2218
10	.2507	.2454	1.3226	1.2548	1.1797	.6962	.2218
11	.2507	.2629	1.2717	1.2378	1.2125	.6962	.2012
12	.6613	.9012	.4119	.2865	.3155	.2957	.7293
13	.8478	1.1961	.4298	.3403	.4031	.3326	.7625
14	.9156	1.2616	.4477	.4119	.4207	.3511	.8453
15	.9835	1.278	.4298	.5194	.1928	.3881	.9116
16	1.0343	1.2452	.3761	.394	.1402	.1663	.7956
17	1.0513	1.1961	.3224	.197	.1753	.1663	.7459
18	1.0852	1.278	.1791	.197	.2454	.1478	.7293
19	1.2378	1.1797	.3224	.3224	.2804	.1478	.7956
20	.4835	.4382	.4835	.4477	.4557	.499	.462
21	.5731	.5959	.5731	.5373	.5258	.5914	.5729
22	.6626	.6135	.6268	.6089	.5609	.6283	.5729
23	.6626	.6135	.6447	.6268	.5609	.6468	
24	.6135	.6447	.6135	.6268	.6089	.5434	.6283
Max	1.2378	1.278	1.3226	1.2548	1.2125	.6962	.9116
Min	.2103	.2149	.1791	.197	.1402	.1478	.2012
Avg	.6357	.7127	.6881	.7083	.5237	.4829	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164028 / 33/11 KV SAWARGAON

Feeder No / Name : 205 / SAWARGAON FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.4207	.3605	.4031	.4031	.3688	.439
2	.3768	.4207	.3605	.4031	.4031	.3521	.439
3	.3768	.4031	.3605	.3856	.4031	.3521	.4207
4	.3605	.3856	.3561	.3856	.4031	.3521	.4024
5	.3521	.3506	.3391	.3506	.3506	.3353	.3841
6	.3018	.298	.2785	.3155	.2629	.285	.3658
7	.2347	.2103	.1966	.2279	.2454	.2012	.2195
8	.218	.2103	.2012	.2454	.2103	.1677	.2378
9	.2347	.2279	.218	.2454	.2103	.2195	.2561
10	.2454	.2347	.2454	.2629	.2515	.2378	.2743
11	.2804	.2683	.2804	.2804	.2683	.2561	.2926
12	.3155	.2683	.333	.3155	.3018	.2926	.3109
13		.3018	.3506	.333	.3353	.2926	.3109
14		.3277	.3856	.3681	.3521	.2926	.3292
15	.3155	.3441	.3506	.3681	.218	.3109	.3475
16	.2804	.3277	.3155	.3155		.3109	.2561
17	.2804	.285	.298	.2454		.3109	.2378
18	.2629	.2683	.2804	.2454	.1844	.3292	.2378
19	.2804	.285	.3155	.2804	.2515	.3292	.2926
20	.3681	.3185	.3506	.3506	.3113	.4024	.3841
21	.4207	.3605	.3856	.3856	.3441	.4207	.4024
22	.4382	.3768	.4207	.4207	.3605	.4572	.4024
23	.4557	.3768	.4207	.4207	.3688	.4572	
24	.3932	.4382	.3605	.4031	.4207	.3688	.4572
Max	.4557	.4382	.4207	.4207	.4207	.4572	.4572
Min	.218	.2103	.1966	.2279	.1844	.1677	.2195
Avg	.3266	.3212	.3235	.3316	.3118	.3210	.3348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 201 / 11 KV MOHGAON-JATAMZARI-
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3921	1.1012	1.1203	1.0279	.3174	.1494
2	.4108	.3734	1.1012	1.1203	1.0279	.3174	.1307
3	.3921	.3361	1.085	1.1763	1.0595	.3174	.112
4	.3921	.2987	1.085	1.1763	1.0467	.2987	.112
5	.2987	.2614	1.0688	1.1949	1.078	.2987	.0934
6	.1867	.2241	1.1012	1.2323	1.1248	.2614	.0747
7	.1307	.1494	1.247	1.4377	1.2654	.1867	.056
8	.1307	.112	1.587	1.7364	1.3272	.112	.0373
9	.112	.112	1.4899	1.7551	1.358	.0934	.056
10	1.2125	1.085	.1132	.112	.168	.6722	.0949
11	1.2146	1.5565		.168	.1867	.5851	.1457
12	1.4899	1.5223	.2241	.0934	.1494	.5851	.1619
13	1.2955	1.5384	.2614	.2614	.168	.4902	.2267
14	1.2955	1.3443	.2801	.2987	.168	.4428	.1619
15	1.2631	1.2955	.2427	.2614		.5693	.2105
16	1.3603	1.4413	.1867	.1494	.0747	.0949	.1943
17	1.3603	1.587	.168	.1307	.056	.0949	
18	.1307	.1132	.112	.1307	.0934	.056	.0373
19	.1494	.1463	.1494	.168	.168	.056	.1494
20	.2987	.3206	.2987	.2987	.2614	.0934	.5228
21	.3734	.3961	.3734	.3921	.3361	.1307	.5788
22	.4294	.4527	.4294	.4108	.3921	.1494	
23	.4294	.4527	.4481	.4294	.4294	.1494	
24	.4108	.4668	1.1012	.7468	1.0526	.3174	.1494
Max	1.4899	1.587	1.587	1.7551	1.358	.6722	.5788
Min	.112	.112	.112	.0934	.056	.056	.0373
Avg	.6324	.6657	.6632	.6667	.6095	.2787	.1645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 202 / 11 KV AGRA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7701	.7773	.1886	.1389	.1698	.3395	.3048
2	.7701	.7926	.1698	.1389	.1698	.3395	.3048
3	.7865	.7926	.1698	.1235	.1509	.3395	.2896
4	.7865	.7164	.1698	.1389	.1509	.3549	.2743
5	.8029	.7468	.132	.0926	.132	.3395	.2743
6	.8356	.884	.1132	.0772	.0943	.3858	.2743
7	1.0322	1.0822	.0566	.0617	.0566	.3858	.3353
8	.9995	1.1126	.0377	.0309	.0566	.4012	.4572
9	.9831	1.1431	.0377	.0309	.0566	.4167	.4572
10	.0566	.056	.4858	1.034	1.0688	.0463	.0747
11	.056	.0754		1.3927	1.2654	.056	.0377
12	.0747	.0943	1.2809	1.3108	1.1265	.0747	.0566
13	.0934	.1132	1.2037	1.2616	1.0648	.0934	.0754
14	.112	.1132	1.2346	1.1961	1.1111	.112	.0754
15	.112	.1132	1.2037	1.1633		.112	.0566
16	.0934	.1132	1.25	1.065	.1698	.0934	.0566
17	.056	.0754	1.1883	1.1142	.2006	.056	.0566
18	.056	.0377	.0463	.0566	.0463	.056	.0566
19	.056	.0566	.0772	.0754	.0617	.0934	.1132
20	.1494	.1509	.1235	.1509	.1235	.112	.1509
21	.168	.1698	.1389	.1886	.1543	.112	.1698
22	.2054	.2075	.1543	.1886	.1543	.1867	.1698
23	.2054	.2075	.1698	.1886	.1543	.1867	
24	.7611	.7164	.1886	.1389	.1886	.3086	.3048
Max	1.0322	1.1431	1.2809	1.3927	1.2654	.4167	.4572
Min	.056	.0377	.0377	.0309	.0463	.0463	.0377
Avg	.4176	.4312	.4270	.4733	.3447	.2084	.1925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 203 / 11 kv pipla feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1494	.2561	.2957	.1907	.1663	.1494
2	.1698	.1494	.2561	.2957	.1907	.1663	.1494
3	.1509	.1494	.2561	.2957	.1907	.1663	.1494
4	.1509	.1307	.2561	.2402	.1882	.1478	.1307
5	.1132	.1307	.2401	.2772	.1738	.1478	.1307
6	.0754	.112	.2561	.2957	.1738	.1294	.112
7	.0566	.0747	.2561	.2957	.2	.1109	.0747
8	.0566	.056	.2561	.3142	.2572	.0739	.056
9	.0566	.056	.3041	.3326	.2715	.0554	.056
10	.2294	.2315	.0566	.0739	.0739	.1663	.1337
11	.216	.2622		.0943	.0739	.1486	.2378
12	.1852	.2881	.0924	.0943	.0924	.1635	.2378
13	.2469	.2561	.1109	.1132	.1109	.1783	.208
14	.2469	.2721	.1478	.132	.1294	.1783	.208
15	.2469	.2721	.1294	.132		.1783	.1783
16	.2623	.2881	.1109	.0754	.0554	.1635	.1635
17	.2932	.3041	.0924	.0754	.0554	.1486	.2075
18	.0747	.0754	.0739	.0566	.0739	.056	.0566
19	.0747	.0943	.0924	.0943	.0924	.0747	.1132
20	.1494	.1509	.1478	.1509	.1294	.0934	.1509
21	.168	.1886	.1663	.1698	.1478	.112	.1698
22	.2054	.1886	.1848	.1698	.1663	.1867	.1698
23	.2054	.1886	.1848	.1698	.1663	.168	
24	.1698	.168	.2561	.2957	.208	.1663	.168
Max	.2932	.3041	.3041	.3326	.2715	.1867	.2378
Min	.0566	.056	.0566	.0566	.0554	.0554	.056
Avg	.1656	.1765	.1819	.1892	.1483	.1394	.1483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 201 / 11 KV KALMBHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2534	.2561	.2587	.2353	.2218	.2587
2	.2587	.2534	.2561	.2587	.2353	.2218	.2587
3	.2587	.2534	.2561	.3174	.2353	.2218	.3142
4	.2427	.2534	.2195	.2427	.2353	.2218	.2987
5	.2427	.2172	.2195	.2427	.2172	.2218	.2801
6	.1867	.1448	.1663	.1867	.181	.1663	.168
7	.1307	.1448		.1267	.1086	.1109	.112
8	.0934	.1086	.0905	.1075	.0905	.112	.0934
9	.0943	.0905	.0924	.0943	.0724	.1109	.112
10	.2204	.2035	.2984	.2683	.1696	.0829	.0678
11		.2486	.2713	.2591	.1658	.1341	.0678
12		.2652	.3222	.2429	.1658	.0848	.1017
13	.2652	.1823	.2713	.2267	.1823	.1017	.1187
14		.1844	.2543	.1781	.1658	.0848	.1187
15	.2155	.218	.2374	.1781	.1326	.0838	.1017
16	.2321	.2321	.2543	.1781		.0848	.0838
17		.2155	.2374	.1781	.0995	.0838	
18	.0724	.1109	.0943	.0724	.0739	.112	
19	.1267	.1294	.112	.1086	.1109	.112	
20	.2172	.1478	.2033	.1991	.1848	.2103	.1867
21	.2534	.2402	.2218	.2172	.2218	.2402	.1867
22	.2534	.2402	.2587	.2534	.2218	.2427	.2054
23	.2534	.2507	.2587	.2534	.2427	.2614	
24	.1982	.2534	.2534	.2614	.2353	.2218	.2614
Max	.2652	.2652	.3222	.3174	.2427	.2614	.3142
Min	.0724	.0905	.0905	.0724	.0724	.0829	.0678
Avg	.2037	.2017	.2220	.2046	.1732	.1563	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 202 / 11 KV ISAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5014	.5121	.5121	.5014	.4755	.5121
2	.5121	.4656	.5121	.5121	.5014	.4755	.5121
3	.499	.4477	.5121	.499	.5014	.4755	.5175
4	.4805	.394	.439	.4805	.4656	.439	.4805
5	.4435	.3761	.439	.462	.4119	.4024	.4435
6	.3361	.2507	.2926	.3361	.3224	.2926	.3142
7	.2402	.2149		.2149	.2149	.2195	.2218
8	.2033	.1075	.1791	.181	.1791	.2241	.1867
9	.1867	.1433	.1829	.1848	.1791	.2195	.2241
10	.5304	.6371	.7209	.6464	.5533	.4424	.6036
11	.6062	.663	.7377	.5506	.5571	.3149	.6036
12	.5441	.6718	.5365	.6316	.5407	.431	.5533
13	.4424	.4915	.503	.3887	.4915	.3812	.4862
14	.4973	.4973	.503	.4858	.4588	.3481	.4191
15		.5636	.503	.5182	.426	.3812	.4191
16		.5735	.6036	.583		.3315	
17		.6226	.6036	.5506	.2949	.3315	
18	.2149	.1097	.2241	.1791	.2378	.2033	
19	.2507	.2743	.2614	.2149	.2561	.2587	
20	.394	.4024	.3881	.3224	.3658	.3506	.2614
21	.4887	.4572	.4207	.4298	.4024	.439	.2241
22	.5373	.5121	.5304	.5014	.4755	.4755	
23	.5014	.5068	.5121	.5014	.4854	.5121	
24	.4641	.5014	.5014	.5121	.5014	.426	.5121
Max	.6062	.6718	.7377	.6464	.5571	.5121	.6036
Min	.1867	.1075	.1791	.1791	.1791	.2033	.1867
Avg	.4231	.4327	.4617	.4333	.4054	.3688	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 203 / 11 KV YENWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6447	.6516	.6219	.6447	.5792	.5853
2	.6219	.6447	.6584	.6767	.6447	.5792	.5853
3	.6219	.6516	.6584	.6036	.6447	.5792	.5853
4	.6099	.591	.6335	.6036	.6089	.543	.5853
5	.5729	.591	.5792	.5729	.5731	.5068	.5544
6	.3881	.3582	.3658	.4066	.4298	.3439	.3511
7	.2772	.2865		.2743	.2507	.2561	.2402
8	.2218	.2507	.1991	.2172	.1791	.2241	.2033
9	.2054	.2507	.2149	.2218	.1791	.2172	.2218
10	.6299	.7956	.7773	.6299	.6299	.2915	.3647
11	.5898	.779	.7459	.6154	.6154	.2486	.431
12	.583	.6962	.6796	.5506	.4424	.2652	.3812
13	.6226	.5571	.6299	.4858	.4973		.3647
14	.5898	.5967	.6299	.4858	.5079	.2984	.431
15	.6226	.663	.6796	.5344	.4915	.2984	.4144
16	.5898	.6882	.663	.583			.3018
17		.6554	.5967	.421	.2949	.2012	.1677
18	.2328	.2353	.2772	.197	.2686	.2218	
19	.2507	.1448	.2957	.2686	.1086	.2957	.3361
20	.4656	.4525	.4435	.4298	.3982	.4557	.4481
21	.5373	.5068	.5304	.5194	.4706	.5487	.4481
22	.6268	.6335	.6036	.591	.5611	.6219	.5601
23	.6447	.6516	.6584	.6268	.5975	.5487	
24	.6401	.6447	.6516	.6219	.6447	.5792	.5853
Max	.6447	.7956	.7773	.6767	.6447	.6219	.5853
Min	.2054	.1448	.1991	.197	.1086	.2012	.1677
Avg	.5124	.5404	.5575	.4900	.4645	.3956	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 204 / 11 KV GONHI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2012	.1991	.2054	.2012	.1791	.2241
2	.2054	.2012	.1991	.2033	.2012	.1791	.2241
3	.2054	.2012	.1991	.2033	.2012	.1791	.2241
4	.2054	.2012	.197	.2054	.1991	.1612	.2241
5	.2054	.1829	.1791	.2054	.1829	.1612	.2054
6	.1494	.128	.1267	.1307	.1463	.1433	.1494
7	.0943	.128		.0886	.1097	.0895	.112
8	.0943	.0914	.0526	.0709	.0732	.0747	.0754
9	.0754	.0732	.0905	.0754	.0732	.0716	.0754
10	.1526	.1543	.1781	.1187	.1543	.0648	.12
11	.1457	.1526	.1886	.1781	.1475	.0848	.1029
12	.1475	.1357	.1543	.1781	.1457	.1017	.0857
13	.1296	.1357	.1543	.1457	.1134	.1017	.1029
14	.1147	.1357	.1543	.1296	.0972	.0678	.0857
15	.1296	.1341	.1543	.1296	.0983	.0678	.0857
16	.1311	.1509	.1715	.1457	.064	.0848	
17		.1341	.1372	.1134		.0509	
18	.0732	.0724	.0754	.0732	.0739	.0754	.0934
19	.1097	.1267	.112	.1097	.1075	.1307	.1307
20	.1646	.1646	.168	.1646	.1629	.1753	.168
21	.2012	.197	.2054	.1829	.1791	.2054	
22	.2195	.2149	.2241	.2195	.197	.2241	
23	.2195	.2103	.2033	.2012	.2054	.2241	
24	.2054	.2012	.1928	.2054	.2012	.1791	.2241
Max	.2195	.2149	.2241	.2195	.2054	.2241	.2241
Min	.0732	.0724	.0526	.0709	.064	.0509	.0754
Avg	.1558	.1554	.1616	.1535	.1450	.1282	.1428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

SAWARGAON S/DN.[561] BU 0561

Substation No/ Name :- 164056 / 33/11 kv yenwa

Feeder No / Name : 205 / 11 KV KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2715	.2896	.2772	.2534	.2481	.2772
2	.2772	.2715	.2926	.2772	.2534	.2507	.2772
3	.2772	.2715	.2896	.2772	.2534	.2507	.2587
4	.2614	.2534	.2896	.2614	.2534	.2507	.2614
5	.2614	.2172	.2353	.2614	.2172	.2328	.2427
6	.168	.1267	.1433	.168	.181	.1433	.1494
7	.0943	.0905		.0905	.1086	.0895	.112
8	.0943	.0905	.0905	.0905	.0724	.0747	.0943
9	.0934	.0905	.0895	.0943	.0905	.0716	.0943
10	.4024	.4917	.5407	.5365	.5249	.144	.2035
11	.4096	.5365	.6104	.4534	.144	.1677	.2204
12	.4144	.5138	.5935	.421	.4641	.1677	.2543
13	.3441	.5304	.5765	.4049	.4588	.1677	.2204
14	.3725	.503	.5087	.421	.4372	.1677	.2035
15	.3978	.4973	.4748	.421	.3681	.1844	.2204
16	.4424	.4973	.5426	.4372		.1677	.1677
17		.5636	.5426	.3725	.1966	.1509	.1509
18	.0905	.0895	.112	.0905	.0905	.0943	.112
19	.1267	.1612	.1494	.1267	.1433	.1494	.1867
20	.2353	.2172	.1867	.2172	.2172	.2279	.2427
21	.2715	.2686	.2587	.2534	.2328	.2772	.2614
22	.3077	.2865	.2772	.2715	.2686	.2987	.2614
23	.2715	.2865	.2772	.2715	.2801	.2987	
24	.2801	.2715	.2715	.2772	.2534	.2534	.2801
Max	.4424	.5636	.6104	.5365	.5249	.2987	.2801
Min	.0905	.0895	.0895	.0905	.0724	.0716	.0943
Avg	.2683	.3082	.3323	.2822	.2506	.1887	.2066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 201 / 11 KV KACHARISAWANGA
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.4858	.4858	.0972	.4534	.0324	.0648
2	.1097	.4858	.5182	.0972	.4534	.0324	.0648
3	.1052	.4858	.4858	.0648	.4534	.0324	.0648
4	.0972	.421	.4858	.0648	.421	.0324	.0648
5	.0648	.3887	.4858	.0648	.421	.0324	.0648
6	.0648	.2915	.3155	.0648	.2591	.0324	.0648
7	.0732	.1943	.2267	.0324		.0324	.0648
8	.0648	.1943	.2267	.0648	.0324	.0324	.0486
9	.0648	.1943	.2267	.2267	.0324	.0162	.0648
10	.2915	.2591	.2915	.2915	.0324		.1296
11	.2591	.2915	.3239	.3239			.1943
12	.2267	.2591	.2915	.2915			.1619
13	.2267	.2591	.2267	.2915			.1619
14	.2915	.2591	.2267	.2591	.0648		.1619
15		.2915	.2267	.2591	.0648	.0648	.1296
16	.2915	.2915	.2591	.2915	.0324	.1134	.1296
17	.2591	.2915	.2267	.2267	.0324	.1296	.1296
18	.2915	.2267	.2267	.5182	.0324	.0648	.0648
19	.3239	.2591	.2591	.2591	.0324	.0648	.0648
20	.3887	.421		.3563	.0324	.0648	.0972
21	.4858	.4858		.3887	.0324	.0972	.0972
22	.4858	.5506	.0972	.4858	.0324	.0972	.0972
23		.5182	.0972	.4534	.0324	.081	
24	.0972	.4858	.5182	.0972	.4534	.0324	.081
Max	.4858	.5506	.5182	.5182	.4534	.1296	.1943
Min	.0648	.1943	.0972	.0324	.0324	.0162	.0486
Avg	.2119	.3455	.3058	.2321	.1700	.0571	.0986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 202 / 11 KV KHURSAPAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962	.663	.6962	.6962	.6962	.6299	.7293
2	.7316	.6299	.6962	.7293	.663	.6299	.7293
3	.6299	.5967	.7293	.6299	.6299	.6299	.7293
4	.6299	.5967	.7293	.5967	.6299	.5636	.7293
5	.5967	.5304	.6299	.5967	.6299	.5304	.663
6	.3978	.3647	.3978	.3647	.3647	.4641	.431
7	.2652	.2486	.2652	.2984	.2652	.2321	.2984
8	.2652	.2486	.2652	.2652	.2321	.2321	.2652
9	.2984	.2984	.2652	.2984	.2652	.2486	.2652
10	.8951	.663	.9282	.8619	.8619		.7625
11	.8619	.6962	.8951	.8619	.6962		.7625
12	.8619	.9282	.8619	.9282	.8288		.7956
13	.8619	.8619	.8326	.9282	.7625		.7293
14	.7956	.7956	.7625	.8619	.4973		.6962
15		.8951	.663	.8288	.431	.5636	.7293
16	.7956	.9614	.8288	.8288	.431	.5636	.5967
17	.8288	.9116	.7293	.8288	.4641	.6299	
18	.5304	.2321	.2984	.2984	.2984	.2984	.2321
19	.5636	.3647	.431	.4641	.6962	.3978	.3978
20	.663	.663		.663	.6962	.663	.6299
21	.7293	.7293		.6962	.6962	.7625	.7293
22	.7625	.7956	.7625	.7625	.6962	.7625	.663
23	.7293	.7293	.7625	.7293	.663	.7625	.5304
24	.6962	.6962	.6962	.6962	.6962	.6299	.7293
Max	.8951	.9614	.9282	.9282	.8619	.7625	.7956
Min	.2652	.2321	.2652	.2652	.2321	.2321	.2321
Avg	.6559	.6292	.6421	.6547	.5746	.5365	.6010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 204 / 11 KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6878	.724	.6878	.6516	.6878	.6154	.7602
2	.6516	.6878	.6516	.5792	.6516	.6154	.7602
3	.6516	.6516	.6154	.4706	.6154	.6154	.7602
4	.6154	.6154	.6154	.4706	.6154	.543	.7602
5	.5792	.5792	.6516	.4344	.6154	.5068	.724
6	.3982	.3982	.3982	.3982	.3982	.5068	.4344
7	.2896	.2896	.3258	.3258	.2896	.2896	.3258
8	.2896	.2896	.3258	.2896	.2896	.2534	.2896
9	.2534	.3258	.2896	.3258	.2896	.2534	.3258
10	.7602	.5973	.6878	.6516	.5792		.5792
11	.6154	.6878	.6878	.6516	.6516		.4344
12	.543	.4706	.724	.5792	.6154		.6154
13	.543	.5792	.5792	.6154	.6154		.5792
14	.6516	.543	.5792	.6154	.362		.543
15		.6335	.5792	.5792	.3258	.6154	.5068
16	.6878	.724	.5792	.362	.3258	.543	.5792
17	.5792	.5973	.543	.3982	.3258	.543	
18	.6154	.3258	.3258	.3258	.3506	.3258	.3258
19	.6154	.3982	.4706	.5068	.724	.4706	.5068
20	.6878	.6878		.6878	.724	.6878	.6516
21	.724	.724		.724	.724	.7964	.7602
22	.7602	.7964	.724	.7602	.724	.7964	.7602
23	.724	.7602	.724	.724	.6878	.7602	
24	.724	.724	.724	.6878	.724	.6154	.7602
Max	.7602	.7964	.724	.7602	.724	.7964	.7602
Min	.2534	.2896	.2896	.2896	.2896	.2534	.2896
Avg	.5934	.5754	.5677	.5340	.538	.5449	.5792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 205 / 11 KV KONDHALI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0867	1.0867	1.1218	1.1218	1.0867	.9465	1.1218
2	1.0517	1.0517	1.1218	1.0517	1.0517	.9465	1.1218
3	1.0974	1.0517	1.0517	1.0517	1.0166	.9465	1.1218
4	1.0166	.9816	1.0517	.9465	.9393	.8764	1.1218
5	.9877	.9465	1.0166	.8413	.9069	.8063	1.0517
6	.8413	.8063	.8413	.8063	.8413	.7712	.8413
7	.8063	.7362	.7773	.7712	.8063	.7011	.8413
8	.6661	.7537	.7449	.7011	.6661	.7011	.7011
9	.7011	.6836	.7362	.7011	.7011	.6661	.7362
10	.7011	.7011	.6478	.7011	.7362		.7712
11	.8764	.7011	.7011	.8063	.7362		.7712
12	.8764	.7712	.7712	.8764	.8413		.8063
13	.9114	.9465	.8063	.8764	.6661		.8413
14	.9114	.9465	.8764	.9114	.631		.9465
15		.9114	.8413	.9465	.5959	1.1218	.9114
16	.9114	.8764	.8413	.9114	.5959	1.0166	.8413
17	.8063	.8413	.7712	.8764	.5258	.9114	.631
18	.8764	.7712	.7011	.7011	.7011	.8764	.7362
19	.9465	.7712	.7712	.8063	.9816	.8764	.8764
20	1.0166	.631		.8764	1.0166	1.0517	.9114
21	1.1218	1.0166		.9465	1.0166	1.1218	.9816
22	1.1218	1.1218	1.1919	1.1218	1.0498	1.1218	1.0867
23	1.1218	1.1568	1.1919	1.1218	1.0166	1.1568	.8413
24	1.1218	1.1218	1.1218	1.1568	1.1218	.9465	1.1568
Max	1.1218	1.1568	1.1919	1.1568	1.1218	1.1568	1.1568
Min	.6661	.631	.6478	.7011	.5258	.6661	.631
Avg	.9381	.8910	.8954	.9012	.8437	.9244	.9071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 206 / 11KV MASOD NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0328	.0328	.0328	.0328	.0328	.0328
2	.0328	.0328	.0328	.0328	.0328	.0328	.0328
3	.0328	.0328	.0328	.0328	.0328	.0328	.0328
4	.0328	.0328	.0328	.0328	.0328	.0328	.0328
5	.0328	.0328	.0328	.0328	.0328	.0328	.0328
6	.0328	.0328	.0328	.0328	.0328	.0328	.0328
7	.0328	.0328	.0328	.0328	.0328	.0328	.0328
8	.0328	.0328	.0328	.0328	.0328	.0328	.0328
9	.0328	.0328	.0328	.0328	.0328	.0328	.0328
10	.0983	.0983	.0983	.1311	.1311		.0819
11	.1052	.1147	.1147	.1475	.1311		.0819
12	.0983	.1147	.0983	.1147	.1311		.0655
13	.0983	.1147	.0983	.1311	.1147		.0655
14	.0983	.1147	.1147	.1311	.0983		.0819
15		.0983	.1147	.1311	.0983	.0819	.0655
16	.0983	.0655	.0983	.0983	.0983	.0819	.0655
17	.0983	.0655	.1147	.0328	.1311	.0819	.0655
18	.0328	.0328	.0328	.0328	.0328	.2949	.0328
19	.0328	.0328	.0328	.0328	.0328	.0328	.0328
20	.0328	.0328		.0328	.0328	.0328	.0328
21	.0328	.0328		.0328		.0328	.0328
22	.0328	.0328	.0328	.0328	.0328	.0328	.0328
23	.0328	.0328	.0328	.0328	.0328	.0328	.0328
24	.0328	.0328	.0328	.0328	.0328	.0328	.0328
Max	.1052	.1147	.1147	.1475	.1311	.2949	.0819
Min	.0328	.0328	.0328	.0328	.0328	.0328	.0328
Avg	.0530	.0546	.0596	.0601	.062	.0543	.0458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 207 / 11 KV WW

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1753	.1402	.1753	.1753	.1753	.1052
2	.1097	.1753	.1753	.2103	.2103	.1753	.1052
3	.1753	.1753	.2103	.2103	.2103	.1753	.1052
4	.1753	.1753	.2195	.2454	.2454	.1753	.1052
5	.2172	.2103	.2103	.2454	.2454	.1402	.1753
6	.2103	.2454	.2103	.2454	.2454	.2103	.1753
7	.2103	.2454	.2103	.2804	.2454	.2103	.2103
8	.2454	.2454	.2454	.2804	.2804	.2279	.2103
9	.2454	.2279	.2454	.2804	.2804	.2103	.1753
10	.2804	.2454	.2804	.2561	.2804		.2103
11	.2804	.2454	.2804	.2804	.2454		.2103
12	.2804	.1402	.2804	.3155	.2454		.2103
13	.1578	.1402	.2804	.3155	.2629		.2103
14	.2103	.3155	.1753	.1052	.2103		.1402
15		.2804	.2804	.2454	.2103	.1753	.2454
16	.2629	.2454	.3155	.2804	.2103	.2103	.2103
17	.2804	.2103	.2804	.2804	.2103	.1753	.2454
18	.2454	.2454	.2804	.2804	.2103	.2103	.2103
19	.2454	.2454	.3155	.2454	.2103	.2103	.1753
20	.2454	.2454		.1753	.2103	.2103	.2103
21	.2454	.2454		.1402	.1402	.2103	.2103
22	.1578	.1402	.1753	.1402	.1402	.1753	.1052
23	.1753	.1402	.1753	.1402	.1402	.1052	.1052
24	.1052	.1753	.1052	.1402	.1753	.1753	.1052
Max	.2804	.3155	.3155	.3155	.2804	.2279	.2454
Min	.1052	.1402	.1052	.1052	.1402	.1052	.1052
Avg	.2116	.2140	.2315	.2298	.2184	.1873	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 402 / 33 KV Katol Kondhali

Incomer Feeder KV- 33 /
INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2003	6.6392	6.6392	5.7065	6.6941	4.1701	5.1578
2	6.0357	6.5295	6.6941	5.7065	6.5295	4.1701	5.1578
3	5.9259	6.2552	6.5295	5.487	6.4746	4.1701	5.1578
4	5.9259	6.0905	6.31	5.4321	6.5844	4.0055	5.048
5	5.5967	5.8162	6.0357	5.3224	6.4198	3.786	4.9383
6	5.048	5.1029	4.7737	4.5542	5.3772	3.7311	3.8409
7	4.3347	4.7188	4.1152	4.1701	4.4445	3.3471	3.2922
8	4.8285	4.8285	4.3347	4.4445	4.5542	3.3471	2.963
9	5.2126	5.1578	4.3896	4.4445	4.6639	3.0727	2.9081
10	7.8464	7.1879	7.572	7.572	7.2428		4.4993
11	7.572	6.8039	7.2428	6.4198	6.3649		5.3772
12	7.4623	7.0233	7.0782	7.3525			5.1029
13	7.3525	6.6941	6.749	7.4074	6.5844		5.2126
14	6.8587	5.3772	6.5844	7.3525	4.2798		5.3224
15		6.6392	6.6392	7.1879	4.1152	3.6214	5.1578
16	6.8587	7.8464	6.8039	7.1331	4.0604	3.8958	4.7737
17	7.6269	6.6941	6.1454	5.8711	4.6091	4.6639	1.6461
18	5.5967	4.4993	4.3896	4.3644	4.6091	3.786	3.8409
19	6.0357	4.7737	4.9383	5.5967	5.048	4.225	4.3347
20	6.5295	5.7613		6.2552	5.048	4.8285	5.1029
21	6.9685	6.8587		6.5295	4.8834	5.1578	5.7613
22	6.9136	7.2977	5.8711	6.8039	4.8285	4.9383	5.8162
23	6.8039	6.4198	5.8711	6.5844	4.3347	4.9383	1.5912
24	5.9808	6.749	6.8587	5.5418	6.6392	4.1701	5.1578
Max	7.8464	7.8464	7.572	7.572	7.2428	5.1578	5.8162
Min	4.3347	4.4993	4.1152	4.1701	4.0604	3.0727	1.5912
Avg	6.3267	6.1568	6.0257	5.9683	5.4082	4.1066	4.4650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 403 / 33 KV Kondhali B'gaon
outgoing Feeder KV- 33 /
INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3471	3.2922	3.2922	2.7435	3.4019	1.5912	2.1948
2	3.2922	3.2922	3.2922	2.8532	3.2922	1.5912	2.1948
3	3.1824	3.0727	3.1824	2.9081	3.2922	1.5912	2.1948
4	3.1824	3.0727	2.963	2.963	3.4019	1.5912	2.0851
5	3.0727	2.963	2.8532	2.963	3.2922	1.5912	2.0851
6	3.0178	2.8532	2.4691	2.5789	3.1276	1.6461	1.8107
7	2.5789	2.8532	2.0851	2.3045	2.7435	1.7558	1.4815
8	3.1824	2.963	2.3045	2.7435	2.9081	1.8107	1.3717
9	3.5665	3.2922	2.524	2.4691	3.0178	1.5912	1.262
10	4.6091	4.4993	4.3896	4.4993	4.4445		1.8656
11	4.3896	3.8958	4.0604	3.1824	3.7311		2.7435
12	4.3896	4.1152	3.8409	4.0055	3.7311		2.2497
13	4.3896	3.7311	3.8409	4.0055	3.7311		2.4691
14	3.7311	2.4143	3.6763	4.2798	2.2497		2.5789
15		3.2922	3.786	4.0055	2.2497	.8779	2.4143
16	3.6214	4.4993	3.7311	4.1701	2.2497	1.2071	2.1948
17	4.6091	3.5665	3.2922	2.963	2.7984	2.0851	.5487
18	2.8532	2.5789	2.4143	2.2497	2.9081	1.9204	2.1948
19	3.1824	2.5789	2.524	3.1824	2.1948	2.0851	2.1948
20	3.2922	2.9081		3.2922	2.1948	1.9753	2.4691
21	3.4019	3.4019		3.4019	2.0851	2.0302	2.7984
22	3.4019	3.6763	2.7435	3.2579	2.0302		2.9081
23	3.2922	2.9081	2.7435	3.1824	1.5912	1.8656	
24	3.0727	3.2922	3.4568	2.5789	3.2373	1.5912	2.1948
Max	4.6091	4.4993	4.3896	4.4993	4.4445	2.0851	2.9081
Min	2.5789	2.4143	2.0851	2.2497	1.5912	.8779	.5487
Avg	3.5069	3.2922	3.1575	3.1993	2.9127	1.6888	2.1089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 201 / 11 KV MASOD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2484	.2743	.2896	.2743	.2728	.2286	.2743
2	.2469	.2743	.2743	.2591	.2713	.2286	.2743
3	.2454	.2743	.2743	.2591	.2667	.2134	.2591
4	.2408	.2591	.2743	.2591	.2637	.1981	.2439
5	.2164	.2439	.2591	.2439	.2454	.1677	.2286
6	.1387	.1829	.1677	.1829	.1722	.1524	.1524
7	.1113	.1219	.0914	.1219	.1113	.1067	
8	.0823	.1219	.0914	.1067	.096	.0914	
9	.0914	.1219	.0945	.1128	.1067	.0914	.1128
10	.3506	.381	.3749	.3643	.3353		.2454
11	.3506	.3658	.3688		.3658		.2743
12	.2896	.3353	.3246		.2896		.2561
13	.2896	.2743	.2987	.1875	.2439		.2378
14	.1829	.2591	.285	.3582	.2743		.2393
15		.2134	.2362	.3612		.2134	.2561
16	.3506	.3963	.3109	.4191		.3048	.2911
17	.381	.381	.2743	.3673		.2286	
18	.1219	.1067	.1067	.1189		.1219	.1021
19	.1524	.1372	.1524	.0732		.1829	.1417
20	.2743	.2439		.2667	.2439	.2591	.285
21	.2896	.2896		.2957	.2591	.2896	.3125
22	.3048	.3048	.3201	.3033	.2743	.3048	.2911
23	.2896	.3048	.2743	.2911	.2439	.2896	
24	.2576	.2896	.2896	.2743	.2774	.2439	.2896
Max	.381	.3963	.3749	.4191	.3658	.3048	.3125
Min	.0823	.1067	.0914	.0732	.096	.0914	.1021
Avg	.2394	.2566	.2470	.2500	.2428	.2062	.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 202 / 11 KV DHURKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2408	.2439	.2286	.2286	.2439	.1372	.2439
2	.2347	.2439	.2286	.2286	.2362	.1372	.2286
3	.2362	.2286	.2134	.2286	.2347	.1219	.2134
4	.2271	.2134	.2134	.2134	.2332	.1219	.1981
5	.2164	.2134	.2134	.2134	.2149	.1219	.1981
6	.1387	.1372	.1372	.1372	.1326	.0914	.1372
7	.1235	.0457	.0914	.1067	.1021	.0762	.061
8	.0975	.0457	.0762	.0762	.0777	.061	.061
9	.0762	.061	.0884	.0854	.0762	.0762	.1021
10	.4268	.4572	.4908	.5243	.4725		.1997
11	.3963	.503	.4603	.4664	.4877		.2149
12	.4115	.4725	.4222	.4679	.4725		.2103
13	.3658	.4268	.4359	.439	.4115		.2103
14	.3048	.381	.4207	.4938	.4115		.2119
15		.381	.4268	.4268		.1677	.2347
16	.442	.4572	.5014	.4847		.1219	.253
17	.4725	.4877	.4725	.4588	.1524	.2134	
18	.0914	.0914	.1067	.0854		.1067	.0838
19	.1219	.1067	.1219	.1433		.1219	.1158
20	.2134	.2134		.2073	.1829	.1981	.1814
21	.2286			.2393	.2286	.2286	.218
22	.2591	.2439	.2439	.2545		.2591	.2225
23	.2439	.2439	.2286	.2454	.1829	.2591	
24	.2454	.2439	.2286	.2286		.1524	.2439
Max	.4725	.503	.5014	.5243	.4877	.2591	.253
Min	.0762	.0457	.0762	.0762	.0762	.061	.061
Avg	.2528	.2671	.2750	.2785	.253	.1460	.1838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 203 / 11 KV DHOTIWADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4877	.4877	.442	.4618	.442	.4877
2	.4908	.4877	.4877	.442	.4588	.442	.4572
3	.4893	.4725	.4725	.442	.4572	.442	.442
4	.4862	.4268	.442	.4268	.4435	.4268	.4268
5	.4344	.3963	.4268	.4268	.4191	.4115	.4268
6	.314	.3048	.2743	.2591	.2987	.2439	.3048
7	.2301	.1981	.1981	.1981	.2195	.1981	.2286
8	.1966	.1524	.1677	.1829	.2103	.1829	.1829
9	.1981	.1829	.1113	.1814	.1829	.1677	.1814
10	.3353	.3353	.3109	.2774	.3506		
11	.3963	.3506	.317	.3246	.3506		.285
12	.3048	.3353	.3246	.285	.3201		.2713
13	.3048	.3048	.317	.3231	.2896		.2698
14	.1829	.2286	.3003	.3079	.2743		.2652
15		.2286	.3079	.2865		.2134	.2454
16	.3048	.2896	.3246	.2789	.1524	.2286	.2378
17	.3048	.2896	.2896	.2637	.1219	.2286	
18	.1981	.2286	.1981	.2058		.2134	.1753
19	.2743	.2591	.2743	.3064		.3201	.2911
20	.4268	.4268		.4359	.4115	.4725	.285
21	.4877	.4877		.4923	.4725	.4877	.4908
22	.503	.5182	.503	.5778	.4725	.5335	.503
23	.503	.4877	.4725	.4893	.4572	.3658	
24	.5091	.503	.4877	.4572	.4618	.442	.4877
Max	.5091	.5182	.503	.5778	.4725	.5335	.503
Min	.1829	.1524	.1113	.1814	.1219	.1677	.1753
Avg	.3639	.3493	.3407	.3464	.3470	.3401	.3307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164061 / 33/11 KV Masod S/st

Feeder No / Name : 401 / 33 KV Masod B'gaon feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	.407	.4161	.4115	.4024	.3384	.4115
2	.4024	.4024	.4115	.4115	.3932	.3338	.3658
3	.3978	.3887	.4024	.3658	.3887	.3292	.3658
4	.3932	.3704	.3932	.3658	.3841	.3338	.3658
5	.3932	.3384	.3795	.3658	.3749	.3292	.3658
6	.2561	.2835	.2515	.2743	.2606	.2515	.2286
7	.1783	.1738	.1783	.1829	.1829	.1555	.1372
8	.1463	.1372	.1417	.1372	.1509	.1372	.0914
9	.1372	.1372	.1463	.1463	.16	.1372	.1463
10	1.2666	1.2803	1.3626	1.166	1.1431		.3932
11	1.2254	1.3717	1.4083	.9008	1.3946		.7819
12	1.0974	1.2666	1.2529	.823	1.1888		.7407
13	1.0288	1.1203	1.1888	1.0791	1.0059		.695
14	.7865	.9374	1.0974	1.2711	1.0059		.6722
15		.8779	1.0745	1.198		.4893	.7316
16	1.1706	1.3032	1.2574	1.2803	.1509		.7682
17	1.4175	1.3214	1.2346	1.2757	.3246	.6859	
18	.1738	.1692	.1829	.1646		.1829	.1463
19	.2515	.2195	.2286	.2469		.2743	.2195
20	.3658	.3795		.3612	.3384	.3658	.3567
21	.4252	.4207		.407	.3658	.4115	.4115
22	.4344	.439	.4115	.439	.3887	.4572	.4161
23	.4252	.4252	.4115	.4252	.3658	.4115	
24	.407	.4161	.4207	.4115	.3841	.3429	.4115
Max	1.4175	1.3717	1.4083	1.2803	1.3946	.6859	.7819
Min	.1372	.1372	.1417	.1372	.1509	.1372	.0914
Avg	.5734	.6078	.6478	.5879	.5121	.3315	.4192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 201 / 11 KV Yerkheda 1

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9368	1.7864	1.9605	1.9368	2.0121	1.9978	2.0121
2	1.8804	1.7488	1.9044	1.8804	1.8804	1.9605	1.9933
3	1.8428	1.6924	1.8671	1.7864	1.7864	1.9044	1.9556
4	1.7864	1.6924	1.8671	1.73	1.6924	1.8671	1.8804
5	1.73	1.6548	1.7924	1.6924	1.6548	1.7924	1.8428
6	1.5608	1.5796	1.587	1.542	1.5043	1.587	1.636
7	1.4667	1.4667	1.4563	1.3727	1.3915	1.4563	1.542
8	1.3163	1.4291	1.4003	1.3163	1.2599	1.4003	1.2787
9	1.2599	1.2787	1.3443	1.2411	1.2787	1.4003	1.2223
10	1.3163	1.2411	1.3443	1.3539	1.2975	1.307	1.3163
11	1.2599	1.2323	1.2599	1.2975	1.2696	1.3163	1.2883
12	1.2787	1.3256	1.2599	1.2975	1.3256	2.0685	1.4003
13	1.3539	1.3817	1.2787	1.3351	1.419	2.1813	1.4377
14	1.4291	1.4937	1.3539	1.4855	1.4377	2.4446	1.4563
15	1.4291	1.6057		1.4667	1.531	2.501	1.587
16	1.4291	1.4937	1.3163	1.4855	1.5123	2.501	1.587
17	1.3915	1.4003	1.2787	1.1659		1.3163	1.587
18	1.2411	1.363	1.2411			1.2599	1.587
19	1.2599	1.2883	1.2599	1.2787		1.2787	1.587
20	1.5043	1.4377	1.4291		1.8484	1.5043	1.6108
21	1.6548	1.4937	1.4667		1.6804	1.5608	1.7177
22	1.6548	1.6617	1.6172		1.7924	1.8052	1.7551
23	1.7676	1.9418	1.8428		1.9605	1.9933	1.7737
24	1.9368	1.7864	2.0351	1.8804	1.918	1.9791	2.0121
Max	1.9368	1.9418	2.0351	1.9368	2.0121	2.501	2.0121
Min	1.2411	1.2323	1.2411	1.1659	1.2599	1.2599	1.2223
Avg	1.5286	1.5198	1.5288	1.5024	1.5930	1.7660	1.6278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 202 / 11 KV NERI 1 Fdr

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6564	.6564	.6805	.6746	.6564	.788	.6564
2	.6381	.6564	.6447	.6746	.6564	.7522	.6381
3	.6199	.6381	.6447	.6564	.6564	.7164	.6381
4	.6017	.6381	.6447	.6381	.6381	.6805	.6381
5	.5834	.6017	.6447	.6381	.6381	.6447	.6017
6	.4741	.5105	.5014	.5105	.547		.5288
7	.4376	.4376	.4656	.4376	.4376	.4477	.4376
8	.547	.4558	.4298	.5105	.1641	.5014	.4011
9	.7111	.6928	.7522	.7111	.3647	.4835	.6928
10	.7783	.6564	.788	.7658	.4194	.5373	.784
11	.6564	.5731	.6928	.5834	.4298	.547	.7059
12	.6564	.6626	.7293	.6199	.4298	.5105	.7421
13	.7293	.7522	.7475	.6381	.4656	.547	.7602
14	.7293	.7343	.7293	.6381	.4477	.5834	.7783
15	.7293	.8059	.6928	.7293	.4656	.6017	.7783
16	.7293	.7164	.4923	.8752	.5014	.6017	.7783
17	.7293	.591	.7293	.5288		.547	.6335
18	.6199	.4835	.7293	.5105		.4376	.6335
19	.6564	.5552	.4741	.547		.4376	.6154
20	.7293	.6984	.6564	.6017	.6626	.547	.4525
21	.6928	.6805	.6564	.6381	.6805	.5652	.4163
22	.6928	.6447	.6928	.5834	.7701	.6381	.4163
23	.6928	.7164	.6928	.6564	.985	.6928	.5068
24	.6564	.6928	.6984	.6928	.6564	.788	.6564
Max	.7783	.8059	.788	.8752	.985	.788	.784
Min	.4376	.4376	.4298	.4376	.1641	.4376	.4011
Avg	.6561	.6355	.6504	.6275	.5558	.5911	.6204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 205 / 11 KV YERKHEDA 2 FDR
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0433	.0569	.0565	.0569	.0433	.0191	.038
2	.0288	.0569	.0565	.0613	.0865	.0191	.038
3	.0288	.0569	.0565	.0613	.0865	.0191	.038
4	.0433	.0569	.0565	.0613	.0865	.0191	.038
5	.0433	.0569	.0565	.0613	.0865	.0191	.038
6	.0288	.0569	.0565	.0613	.1154	.0191	.038
7	.0288	.0569	.0565	.1201	.1442	.049	.0599
8	.0288	.0569	.0565	.1444	.1875	.0781	.0749
9	.0433	.0569	.0565	.1733	.1731	.0781	.0749
10	.1298	.2166	.1486	.1733	.1731	.0503	.0599
11	.2022	.2474	.2311	.1731	.1772	.0749	.0721
12	.2311	.2647	.2311	.0577	.1593		.0577
13	.2311	.2647	.2311	.0433	.1457	.0599	.0577
14	.2311	.2555	.2311	.0577	.1457	.0599	.0577
15	.2311	.2272	.2166	.0577	.1457	.0599	.0721
16	.2022	.2272	.2022	.0433	.1174	.0749	.0721
17	.2022	.2272	.2022			.0599	.0865
18	.2022	.1724	.1733			.0749	.0288
19	.1877	.1448	.1155	.0433		.038	.0288
20	.0569	.0565	.0569	.0433	.0333	.038	
21	.0569	.0565	.0569	.0433	.0191	.0569	
22	.0569	.0565	.0569	.0433	.0191	.0569	.0288
23	.0569	.0565	.0569	.0433	.0191	.038	.0433
24	.0433	.0569	.0565	.0569	.0433	.0191	.0569
Max	.2311	.2647	.2311	.1733	.1875	.0781	.0865
Min	.0288	.0565	.0565	.0433	.0191	.0191	.0288
Avg	.1100	.1268	.1156	.0764	.1051	.0470	.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 207 / 11 KV MODI 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4661	1.448	1.3969	1.4661	1.3937	1.4506	1.448
2	1.4661	1.4118	1.3432	1.4299	1.3575	1.4148	1.4118
3	1.4842	1.4118	1.3432	1.3394	1.3032	1.3969	1.4118
4	1.5203	1.4118	1.3432	1.3394	1.267	1.3611	1.3756
5	1.5927	1.448	1.4506	1.5384	1.2127	1.3253	1.448
6	1.1584	1.2489	1.2178	1.1765	1.086	1.2894	1.267
7	1.0679	1.086	1.0924	1.0498	1.0498	1.1104	1.0498
8	.905	1.0136	1.0029	.9774	.9774	1.0387	.9774
9	.9231	.9412	.9313	.905	.9412	.985	.9593
10	.9955	.9412	.8954	.9593	.9955	1.0387	1.0136
11	1.086	1.0029	.9774	.9593	1.0566	1.0498	1.1041
12	1.1222	1.0745	1.086	1.1765	1.1462	1.1041	1.3032
13	1.1946	1.1104	1.1222	1.1765	1.2536	1.3394	1.3394
14	1.2308	1.1999	1.1765	1.3213	1.3253	1.3756	1.3756
15	1.2308	1.2357	1.2127	1.3575	1.379	1.448	1.3756
16	1.2308	1.2357	1.1946	1.3756	1.3611	1.448	1.3756
17	1.2127	1.2178	1.1584	1.086		1.4039	1.3756
18	1.1041	1.0566	1.1041	1.1765		1.2308	1.3756
19	1.1946	1.1283	1.1765	1.2308		1.2308	1.3756
20	1.3394	1.2894	1.3032	1.2308	1.5939	1.3575	1.3213
21	1.3394	1.2894	1.3394	1.2308	1.5223	1.3032	1.3394
22	1.3756	1.2894	1.3575	1.2851	1.5223	1.3756	1.3213
23	1.448	1.4327	1.4842	1.3756	1.5581	1.448	1.4118
24	1.4661	1.448	1.4148	1.5023	1.448	1.5402	1.448
Max	1.5927	1.448	1.4842	1.5384	1.5939	1.5402	1.448
Min	.905	.9412	.8954	.905	.9412	.985	.9593
Avg	1.2564	1.2239	1.2135	1.2361	1.2738	1.2944	1.3002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 209 / 11 KV YASHODHARA NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6393	.6845	.7023	.703	.677	.7023	.6845
2	.6205	.666	.6653	.6845	.6582	.7023	.6845
3	.6205	.666	.6653	.666	.6582	.6653	.666
4	.6582	.6475	.6283	.666	.6393	.6653	.6475
5	.6393	.629	.6283	.666	.6393	.6653	.6475
6	.5641	.5735	.5729	.592	.5641	.5914	.592
7	.4889	.481	.499	.4625	.5077	.5175	.5365
8	.4701	.4625	.462	.4625	.4701	.5175	.4995
9	.4513	.444	.4435	.4625	.5077	.499	.4995
10	.4889	.444	.4805	.518	.5265	.5359	.6105
11	.4995	.462	.4625	.5265	.5359	.5365	.5914
12	.518	.5175	.4995	.6017	.5544	.6105	.6283
13	.555	.5175	.518	.6017	.5914	.6475	.6283
14	.555	.6099	.555	.6582	.6283	.703	.6468
15	.555	.5914	.518	.6017	.6653	.703	.6468
16	.555	.5914	.444	.5652	.6283	.666	.6468
17	.5365	.5914	.481	.4701		.5735	.6468
18	.4625	.4805	.481			.4625	.6468
19	.481	.5175	.481	.3573		.481	.6468
20	.5735	.5544	.555	.4325	.7023	.5735	.5914
21	.592	.5914	.5735	.4701	.5914	.6105	.5792
22	.6845	.6283	.6475	.6205	.7207	.6475	.6653
23	.7215	.7023	.6845	.6697	.7392	.703	.6838
24	.7334	.703	.7023	.703	.6958	.7207	.6845
Max	.7334	.703	.7023	.703	.7392	.7207	.6845
Min	.4513	.444	.4435	.3573	.4701	.4625	.4995
Avg	.5693	.5732	.5563	.5722	.6143	.6125	.6250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTTEE(DRAGON
PALACE

Feeder No / Name : 210 / 11 kv Ramanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6774	.6516	.5792	.6878	2.3069	.6697	3.2217
2	.6408	.6516	.543	.6878	2.3069	.6335	3.1855
3	.6408	.6335	.543	.6697	2.3069	.5973	3.1855
4	.6225	.6335	.543	.6878	2.3802	.5973	3.1674
5	.6225	.6335	.7421	.7783	2.6731	.7783	3.2217
6	.5493	.5792	.5973	.5973	2.3802	.6154	2.7692
7	.5127	.5792	.4887	.543	1.7394	.543	2.6787
8	.4943	.5249	.5068	.4706	1.8126	.543	2.4977
9	.4577	.4344	.4887	.4706	1.7394	.5068	2.3891
10	.4943	.4344	.4887	.4706	1.8126	1.828	2.1357
11	.5068	.4706	.4887	.4943	1.828	1.8642	2.2744
12	.5068	.5068	.4706	1.9957	1.8099	1.9366	2.4356
13	.4887	.543	.4344	1.1168	2.0633	1.9909	2.5072
14	.4706	.5611	.4706	2.1605	2.0814	2.8416	2.6684
15	.5068	.5611	.4706	2.0506	2.1538	3.0045	2.6863
16	.3982	.543	.4887	2.0323	2.2081	3.0045	2.6863
17	.3982	.5068	.4706	1.8309		2.7692	2.6147
18	.4525	.4887	.4525	2.0506		2.6063	2.6147
19	.4706	.4887	.4887	2.0506		2.7692	2.6147
20	.5973	.5792	.5792	2.0506	.6154	2.9502	3.1161
21	.6335	.5973	.5973		.6335	2.9864	3.0982
22	.6516	.6154	.6154	2.1971	.6335	3.0045	3.1161
23	.6516	.6335	.6697	2.2886	.7059	3.095	3.0445
24	.6774	.6516	.5792	.6878	2.2886	.7059	3.2217
Max	.6774	.6516	.7421	2.2886	2.6731	3.095	3.2217
Min	.3982	.4344	.4344	.4706	.6154	.5068	2.1357
Avg	.5468	.5626	.5332	1.2639	1.8324	1.7851	2.7980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACE

Feeder No / Name : 211 / 11 kv J P NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5546	1.6045	1.5546	1.5316	1.5364	1.5912	1.568
2	1.5364	1.568	1.5546	1.5316	1.4998	1.5546	1.568
3	1.5181	1.568	1.5546	1.4951	1.4815	1.4998	1.5498
4	1.4998	1.568	1.5546	1.4951	1.4632	1.4632	1.5498
5	1.7558	1.6045	1.5912	1.7321	1.4449	1.4266	1.6045
6	1.2437	1.4039	1.2803	1.3128	1.3717	1.4449	1.3492
7	1.1157	1.2034	1.1157	1.1304	1.0974	1.1523	1.1669
8	1.0791	1.0575	1.0791	1.021	1.0059	1.0974	1.0393
9	1.0425	1.0028	1.0242	.9846	1.0242	1.0791	1.0393
10	.9877	.9663	1.0059	1.0028	.9877	1.0791	1.021
11	.9663	.9694	1.021	1.0425	1.0059	1.094	1.0425
12	1.021	1.0242	1.094	1.1157	1.0059	1.1669	1.134
13	1.094	1.1523	1.1487	1.1157	1.1523	1.2034	1.2071
14	1.1851	1.2437	1.2034	1.1706	1.2437	1.2398	1.2489
15	1.2398	1.2986	1.2034	1.1888	1.2803	1.3128	1.3535
16	1.2581	1.262	1.1851	1.2254	1.3352	1.3128	1.3535
17	1.2581	1.2071	1.1304	1.0425		1.2034	1.3169
18	1.0393	1.0791	1.0575	1.0059		1.021	1.3169
19	1.094	1.0974	1.0393	1.0425		1.0393	1.3169
20	1.2763	1.2986	1.2216	1.1706	1.5181	1.2034	1.3032
21	1.3675	1.3717	1.3128	1.3915	1.4449	1.3128	1.4998
22	1.4586	1.4632	1.3857	1.4266	1.5729	1.4769	1.5364
23	1.5316	1.5729	1.5498	1.5364	1.5912	1.5863	1.5364
24	1.6095	1.6227	1.5546	1.5863	1.5912	1.6461	1.5863
Max	1.7558	1.6227	1.5912	1.7321	1.5912	1.6461	1.6045
Min	.9663	.9663	1.0059	.9846	.9877	1.021	1.021
Avg	1.2805	1.3004	1.2676	1.2624	1.3169	1.3003	1.3420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON
PALACEFeeder No / Name : 401 / 33 KV DRAGON PALACE
INCOMMER Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.9659	6.9659	7.0216	7.1331	8.6934	7.3003	9.808
2	6.8544	6.8544	6.7987	7.0216	8.6934	7.1331	9.6408
3	6.7987	6.743	6.743	6.743	8.3591	6.8544	9.5851
4	6.743	6.6873	6.6873	6.6873	8.2476	6.743	9.4179
5	7.0216	6.6873	6.9659	7.2445	8.3033	6.743	9.5293
6		6.0185	5.8513	5.8513	7.6346	6.1857	8.3033
7	5.1269	5.4055	5.2383	5.2383	6.4086	5.4613	7.5789
8	4.8483	5.0712	4.9597	5.0154	5.9071	5.1826	6.9102
9	4.904	4.904	5.0712	5.0712	6.0743	5.0712	7.0216
10	5.1269	4.9597	5.2383	5.3498	6.2972	6.4643	7.0216
11	5.2941	5.0712	5.2383	4.7368	6.4866	6.5758	7.2074
12	5.4613	5.517	5.517	6.9102	6.5758	7.5789	7.54
13	5.7956	5.8513	5.5727	7.0773	7.2445	8.0804	7.7618
14	5.9071	6.1857	5.8513	7.5789	7.4674	9.3622	8.3162
15	6.0185	6.4643	5.7956	7.5232	7.7461	9.808	8.538
16	5.9071	6.1857	5.4055	7.6903	7.8018	9.7522	8.538
17	5.8273	5.8513	5.5727	6.0185		7.969	8.2053
18	5.2169	5.1826	5.3498	6.1857		7.1888	8.2053
19	5.4613	5.2941	5.1269	6.5758		7.4117	8.2053
20	6.13	5.9628	5.8513	5.517	7.0216	8.3033	8.1499
21	6.4086	6.1857	6.0743	5.8513	6.6315	8.5262	8.5934
22	6.6873	6.4643	6.4643	6.2414	7.0773	9.0835	9.0369
23	6.9659	7.1331	7.0773	6.6315	7.6346	9.6408	9.0369
24	7.1331	7.0773	7.1331	7.1888	8.6934	7.4674	9.808
Max	7.1331	7.1331	7.1331	7.6903	8.6934	9.808	9.808
Min	4.8483	4.904	4.9597	4.7368	5.9071	5.0712	6.9102
Avg	6.0263	6.0301	5.9419	6.3784	7.3809	7.4953	8.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 201 / 11 KV Bhilgaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2567	1.2696	1.1203	1.307	1.1458	1.2752	1.1949
2	1.2197	1.2136	1.0642	1.2883	1.1458	1.2382	1.1763
3	1.1827	1.1203	1.0642	1.2696	1.1203	1.2012	1.1763
4	1.1458	1.0829	.9709	1.2323	1.0719	1.1827	1.1203
5	1.1088	1.0269	.9335	1.2136	1.0719	1.1458	.9709
6	.9795	.9522	.8962	1.1203	.924	1.0903	.8775
7	.8871	.8962		.9522	.8871	.9425	.8402
8	.9335	.8215	.8215	.9335	.8316	.8501	.8215
9	1.1458	.8215	1.1389	.9149	.9795	.7392	.8215
10	.9149	.8962	.7762	.6653	.9709	.7762	.8589
11	1.2323	.8962	.7762	.7947	.9896	.7947	1.1088
12	1.1016	1.1203	.9795	1.2752	1.1389		1.2012
13	1.0269	1.3817	1.0029	1.0903	1.0829		.924
14	1.2323	1.2136	.9877	1.0349	1.0269		1.2382
15	1.4563	1.1949	.9694	1.1827	1.2136		1.3491
16	1.475	1.1016	.8596	.6722	1.3256		1.2936
17	1.363	1.0269	1.0829		1.0349	1.1763	1.423
18	1.2323	1.307	.8962	1.0164	1.1273	.9896	1.2197
19	1.2136	1.3256	1.1203	1.0719	1.0719	.9896	1.0349
20	1.2136	1.1389	1.1949	1.2197	1.1273	1.0456	1.1643
21	1.1949	1.0642	1.1576	1.0349	1.2197	1.1016	
22	1.1576	1.1203	1.2136	1.1273	1.3121	1.1576	1.0534
23	1.1576	1.251	1.307	1.2567	1.4045	1.2696	
24	1.2883	1.2696	1.1763	1.3256	1.1827		1.2136
Max	1.475	1.3817	1.307	1.3256	1.4045	1.2752	1.423
Min	.8871	.8215	.7762	.6653	.8316	.7392	.8215
Avg	1.1717	1.1047	1.0222	1.0869	1.1003	1.0537	1.0946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 202 / 11 KV Ranala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1458	1.1576	1.1763	1.1763	1.1088	1.1458	1.1576
2	1.1458	1.0456	1.1203	1.1576	1.0719	1.1273	1.1203
3	1.1273	.9149	1.1203	1.1576	1.0719	1.0719	1.1389
4	1.1088	.9149	1.0456	1.1389	1.0349	1.0349	1.0829
5	1.0164	.8589	.9335	1.1203	.924	.9979	1.0082
6	.8316	.8402	.8402	1.0829	.7762	.8589	.8215
7	.7392	.7468		.7468	.7023	.7655	.7468
8	.8316	.6161	.8589	.6908	.8131	.7207	.8402
9	.6653	.6348	.6908	.7282	.6838	.7207	.7282
10	.6161	.6348	.7023	.7095	.6348	.7392	.6722
11	.7468		.7023	.7207	.7282	.7392	.7207
12	.7468	.6348	.7577	.7655	.7282		.8131
13	.7468	.7468	.7577	.8316	.7842		.7762
14	.8402	.9149	.8775	.8686	.8215		.9055
15	.9522	.9709	.9055	.961	.8589		.961
16	.8775	.9709	.8775	.8501	.9149		.9795
17	.7655	.8589	.8413		.7762	.8402	.924
18	.6722	.6908	.7282	1.5893	.6283	.6161	.8131
19	.6908	.7282	.7095	.7207	.7577	.7842	.8131
20	.9149	.8962	.8589	2.1622	.924	.8402	.961
21	.9522	.9709	.8962	2.3101	.9425	1.0082	
22	1.0269	1.0829	.9896	2.4764	1.0534	1.0829	.9979
23	.6161	1.2136	1.1389	.2772	1.1643	1.1949	
24	1.1643	1.1763	1.2323	1.1949	1.0745	1.1827	1.2136
Max	1.1643	1.2136	1.2323	2.4764	1.1643	1.1949	1.2136
Min	.6161	.6161	.6908	.2772	.6283	.6161	.6722
Avg	.8725	.8792	.9027	1.1060	.8741	.9195	.9180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 203 / 11 KV Ankit Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8686	.7468	.8029	.8962	.924	.7392	.7655
2	.8501	.7468	.8029	.8775	.9425	.7095	.7468
3	.8686	.7095	.7655	.8402	.924	.6535	.7468
4	.8871	.7095	.7468	.8215	.8962	.6535	.7655
5	.8501	.6908	.7468	.8029	.8501	.6348	.8215
6	.8686	.6722	.7282	.8029	.7762	.5975	1.0269
7	.8131	.7282		.7655	.8316	.5788	1.0269
8	1.0608	1.6057	.9335	.8775	.8413	.5788	1.1389
9	1.1016	.9335	.7655	1.2136	1.0164	.5175	.8029
10	1.475	.6348	1.1643	1.2012	1.0269	.7207	1.9605
11	1.9044	1.6804	1.1763	1.2986		.6283	1.885
12	1.3817	1.4003	1.386	1.3491	1.1949		.5601
13	1.4377	1.1389	.9694	1.2012	1.475		.7947
14	1.307	1.4003	2.0513	1.0719	2.0725		.7947
15	1.531	1.1389	1.3717	1.2012	1.9044		.9979
16	1.9418	1.1949	1.4563	1.2382	1.1576		1.8839
17	1.3817	1.3256	1.2254		1.2197		2.3045
18	1.2136	1.2883	1.2696	1.251	1.1827	.6908	1.0534
19	1.6804	1.2136	1.0829	1.5729	1.1088	.8589	1.0719
20	.8962	.9709	1.0642	1.2936	2.2862	.8962	1.8839
21	.8962	.9896	.8589	1.0534	1.0349	.9149	
22	.8589	.8402	.8589	.9979	.9055	.9522	.7762
23	.7842	.8962	.9709	1.0903	.8316	.9896	
24	.8775	.7842	.8402	.9149	.924	.7762	.9709
Max	1.9418	1.6804	2.0513	1.5729	2.2862	.9896	2.3045
Min	.7842	.6348	.7282	.7655	.7762	.5175	.5601
Avg	1.1557	1.0183	1.0451	1.0710	1.1447	.7273	1.1263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 204 / 11 KV Suman Vihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	1.4563	1.2323	1.307	1.1203	1.4045	1.4377
2	.3326	1.4003	1.2136	1.2883	1.1016	1.3491	1.419
3	.3142	1.307	1.1949	1.2696	1.1203	1.2936	1.4003
4	.3511	1.251	1.1203	1.2696	1.0719	1.2936	1.307
5	.3696	1.1576	1.0642	1.251	1.1203	1.2382	1.1389
6	.3841	1.0829	1.0082	1.2323	1.1088	1.1088	.7468
7	.4251	1.307		1.2883	1.2936	1.3676	.9335
8	.9877	1.3817	1.3443	1.3443	1.2803	1.3121	.8402
9	1.4045	1.531	1.0456	1.251	1.4784	1.3717	.6161
10	1.6991	1.4937	1.2936	1.4784	1.6804	1.2936	1.475
11	1.6057	1.475	1.2936	1.4415	1.7364	1.2936	1.4969
12	1.6244	1.2136	1.2382	1.3717	1.3443		
13	1.5684	1.1389	1.2136	1.3121	1.3443		1.9387
14	1.5497	1.307	1.2254	1.2752	1.1949		1.7002
15	1.8298	1.307	1.2803	1.2382	1.531		2.0851
16	1.9605	1.6804	1.4632	1.6461	1.9418		1.848
17	1.7737	1.7737	1.386		1.829		1.5708
18	1.6804	1.4003	1.307	1.4784	1.4998	1.1203	.5359
19	1.363	1.4937	1.251	1.4784	1.5708	1.1203	.5041
20	1.363	1.5497	1.1949	1.4784	1.5912	1.0269	.499
21	1.3817	1.1389	1.1389	1.4784	1.4784	.9896	
22	1.4003	1.2136	1.2883	1.4784	1.423	.9335	.4668
23	1.5123	1.2136	1.4003	1.4632	1.3121	.9335	
24	.3142	1.531	1.307	1.307	1.386	1.4784	.9335
Max	1.9605	1.7737	1.4632	1.6461	1.9418	1.4784	2.0851
Min	.3142	1.0829	1.0082	1.2323	1.0719	.9335	.4668
Avg	1.1462	1.3669	1.2393	1.3664	1.3983	1.2183	1.1854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164044 / 33/11KV BHILGAON

Feeder No / Name : 205 / 11 KV Khasala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3734	.4668	.4481	.4294	.3734	.4294	.4294
24	.5975	.6161	.6348	.6348	.5975	.6348	.6535
Max	.5975	.6161	.6348	.6348	.5975	.6348	.6535
Min	.3734	.4668	.4481	.4294	.3734	.4294	.4294
Avg	.4855	.5415	.5415	.5321	.4855	.5321	.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 201 / 11 KV MES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.9145	1.1203	1.0374	1.086	.9145	1.086
2	.905	.9145	.924	1.0374	.905	.9335	1.086
3	.905	.9145	.9335	1.0374	.905	.8402	1.086
4	.724	.9145	.9335	1.0374	.9955	.8402	.905
5	.905	.823	.9335	1.0374	1.086	.9335	1.086
6	.905	.7316	.9335	1.0059	.905	.9335	1.086
7	.905	.7316	.9431	1.1317	.9431	.905	.9431
8	.905	.7545	.9431	.9431	.9431	.9145	.9431
9	1.086	.7468	.9431	.9431	1.1317	.9145	1.1317
10	1.0288	.9145	1.1317	1.1317	1.1317	1.0974	1.3203
11	.9431	.9431	1.0374	1.3203	1.3203	.9145	1.4146
12	1.0974	1.1317	1.0374	1.3203	1.1317	1.0974	1.307
13	1.0974	1.1317	.9431		1.1317	1.0974	1.307
14	1.0374	1.1317	.9431	1.5089	1.267	1.0974	1.307
15	1.0974	1.1317	1.0374	1.3203	1.1317	1.0974	1.307
16	1.0974	1.1317	1.1317	1.1317	1.1317	1.0974	1.4937
17	1.1317	.9431	1.0974	.9431	1.1317	1.086	1.307
18	1.0059	1.0374	1.0974	1.1317	1.1203	1.3203	1.307
19	.9145		1.0374	1.086	1.0974	1.1317	1.307
20	1.0974	1.1317	1.0374	1.3203	1.0974	1.3203	1.307
21	1.1317	1.1317	1.3203	1.0974	1.0974	1.4146	1.307
22	1.1088	1.1317	1.0374		.9145	1.1317	1.1203
23	1.0374	1.1317	1.0059	1.1317	1.0974	1.1317	1.1203
24	1.086	1.0059	1.1317	1.0374	1.1317	1.086	1.1317
Max	1.1317	1.1317	1.3203	1.5089	1.3203	1.4146	1.4937
Min	.724	.7316	.924	.9431	.905	.8402	.905
Avg	1.0099	.9772	1.0264	1.1223	1.0764	1.0521	1.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 205 / 11 KV AIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.5487	.4572	.6401	.6335	.3658	.543
2	.543	.5487	.462	.5487	.543	.3696	.543
3	.543	.5544	.462	.5658	.543	.3696	.4525
4	.362	.5544	.3696	.4572	.543	.2772	.362
5	.362	.462	.3696	.4572	.4525	.3696	.362
6	.362	.4572	.3696	.4572	.362	.3658	.362
7	.362	.3658	.3658	.362	.3658	.181	.3658
8	.362	.3658	.3658	.362	.3658	.362	.3658
9	.2715	.3772	.3658	.362	.3658	.2743	.3658
10	.2715	.3658	.3772	.362	.3658	.2715	.3658
11	.4525	.3658	.3658	.3658	.3658	.362	.3658
12	.3658	.3658	.3734	.362	.3658	.3658	.2772
13	.4572	.3658	.4572	.3658	.3658	1.2803	.2772
14	.4715	.3658	.4525	.3658	.3658	1.4632	.3696
15	.362	.3658	.4572	.3658	.3658	1.4632	.3696
16	.362	.3658	.362	.3658	.3658	1.2803	.5544
17	.4668	.3658	.362	.3658	.3658	1.267	.7392
18	.4572	.3658	.3658	.3658	.3658	.5487	.7392
19	.3658	.3658	.4572	.362	.2743	.3658	.5544
20	.5487	.3658	.4572	.3658	.2743	.3658	.924
21	.3658	.3658	.4572	.3658	.3658	.3658	.5544
22	.362	.3772	.6401	.362	.3658	.4572	.7392
23	.6401	.3658	.6401	.3658	.3658	.5487	.924
24	.6335	.6401	.3658	.6401	.6335	.2715	.5487
Max	.6401	.6401	.6401	.6401	.6335	1.4632	.924
Min	.2715	.3658	.362	.362	.2743	.181	.2772
Avg	.4251	.4170	.4241	.4149	.4061	.5672	.5010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 206 / 11 KV NCDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	.3658	.4572	.3658	.362	.362	.362
2	1.267	.3658	.462	.3658	.362	.5544	.362
3	1.086	.3658	.462	.2743	.362	.5487	.362
4	1.086	.3696	.462	.2743	.2715	.5487	.2715
5	1.267	.3658	.3696	.2743	.2715	.5487	.2715
6	.9955	.5487	.3696	.2743	.4525	.5487	.362
7	1.086	.3658	.3658	.362	.3658	.543	.3658
8	.362	.5487	.3658	.3658	.3658	.5487	.2743
9	.362	.5601	.3658	.3658	.3658	.543	.3658
10	.4525	.5487	.3658	.362	.3658	.362	.3658
11	.362	.362	.4572	.2743	.3658	.2715	.3658
12	.5487	.3658	.5487	.3658	.3658	.2715	.362
13	.5487	.3658	.543	.3658	.3658	1.4632	.362
14	.4572	.3658	.543	.3658	.3658	1.8099	.4525
15	.3658	.3658	.5487	.4572	.3658	2.1948	.4525
16	.362	.3658	.543	.4572	.362	2.0119	.4525
17	.3658	.4572	.362		.3658	2.1719	.4525
18	.3658	.4572		.3658	.5487	.3658	.362
19	.3658	.4572	.362	.362	.5487	.3658	.362
20	.5487	.4572	.3658	.3658	.5487	.3658	.2715
21	.5487	.4572	.3658	.3658	.5487	.362	
22	.5487	.4572	.4572	.362	.5487	.3658	.362
23	.3658	.4572	.4525	.4572	.7316	.3658	.4525
24	1.448	.3658	.4572	.4525	.3658	.7316	.3658
Max	1.448	.5601	.5487	.4572	.7316	2.1948	.4525
Min	.362	.362	.362	.2743	.2715	.2715	.2715
Avg	.6847	.4234	.4370	.3609	.4143	.7594	.3669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 208 / 11 KV KAMPTEE I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435	2.5339	2.5606	.823	2.5606	.0366
2	2.5606	2.7435	2.5339	2.3777	.823	2.5072	.0366
3	2.5606	2.5873	2.5339	2.3777	.7316	2.5072	.0366
4	2.3777	2.5873	2.3529	2.3777	.5487	2.3282	.0366
5	2.5606	2.7721	2.3529	2.5606	.7316	2.3529	.0366
6	2.1948	2.3777	2.1719	2.1948	.5487	2.1491	.0183
7	2.1948	2.3777	2.1719	1.8099	.543	1.9909	
8	2.0119	2.1948	1.9909	1.8099	.362	1.9909	.0362
9	2.0119	2.0119	1.9909	1.8099	.362	2.1719	.0362
10	1.7558	2.0328	2.1948	2.0119	.362	.4525	.0362
11	2.1033	1.9909	2.0119	2.1719	.362	.5121	.0362
12	2.1948	1.9909	2.2405	.905	.4525	.362	.0362
13	2.3777	2.1719	2.0814		.4572	.3658	.0358
14	2.2862	2.1719	2.1719	.905	.362		.0358
15	2.4691	2.3529	2.1948	.905	.4525		.0358
16	2.5339	2.1719	2.3529	.724	.4525		.0358
17	2.3777	2.1719	2.0119	.724	.362		
18	2.2862	1.9909	2.1948	.543	2.3529	.0362	.0358
19	2.3777	2.1719	2.1948	.5487	2.5606	.0362	.0358
20	2.5606	2.1719	2.5606	.724	2.7435	.0362	.0358
21	2.5606	2.3529	2.3777	.724	2.5606	.0362	.0358
22	2.7435	2.4434	2.3777	.724	2.3777	.0362	.0358
23	2.7435	2.5339	2.3529	.724	2.5606	.0362	.0358
24	2.7435	2.8349	2.6244	2.5339	.8145	2.5339	.0362
Max	2.7435	2.8349	2.6244	2.5606	2.7435	2.5606	.0366
Min	1.7558	1.9909	1.9909	.543	.362	.0362	.0183
Avg	2.3888	2.3313	2.2740	1.5107	1.0294	1.2501	.0353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 210 / 11 KV KAMPTEE II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.0119	1.97	2.1033	2.0119	2.0119	1.9909
2	2.0119	2.0119	1.9909	2.1033	2.0119	1.9909	1.8099
3	1.829	2.0119	1.9909	2.0119	2.0119	1.9909	1.8099
4	1.829	2.0119	1.9909	2.0119	1.829	1.9909	1.6289
5	2.0119	2.1033	2.1491	2.0119	2.1948	1.8099	1.9909
6	1.829	2.0119	1.97	2.0748	2.0119	1.8099	1.9909
7	1.6461	2.0119	1.8099	1.7194	1.8099	1.829	1.8099
8	1.4632	1.8861	1.8099	1.7194	1.6289	1.4632	1.8099
9	1.829	1.4632	1.6289	1.7194	1.6289	1.448	1.6289
10	1.4632	1.2803	1.6461	1.7375	1.448	1.448	1.448
11	1.6461	1.448	1.6032	1.448	1.448		1.448
12	1.2803	1.448	1.5546	1.448	1.448		1.4327
13	1.4632	1.6289	1.6289	1.4632	1.448	1.4632	1.6289
14	1.7375	1.8099	1.6289	1.6289	1.6289	1.8099	1.6289
15	1.6632	1.8099	1.6461	1.6289	1.6289	1.829	1.8099
16	1.6461	1.8099	1.448	1.448	1.6289	1.829	1.8099
17	1.7375	1.8099	1.5384	1.448	1.448	1.4632	1.8099
18	1.6461	1.448	1.5546	1.267	1.448	1.6289	1.6289
19	1.2803	1.448	1.5546	1.4632	1.4632	1.6289	1.6289
20	1.6461	1.6289	1.5546	1.6289	1.4632	1.6289	1.8099
21	1.6461	1.6289	1.5546	1.6289	1.6461	1.8099	1.6289
22	1.829	1.8099	1.829	1.8099	1.829	1.8099	1.8099
23	2.0119	1.9909	1.8099	1.8099	1.829	1.9909	1.9909
24	2.0119	2.1033	1.9909	2.0814	1.9909	1.9909	2.0119
Max	2.0119	2.1033	2.1491	2.1033	2.1948	2.0119	2.0119
Min	1.2803	1.2803	1.448	1.267	1.448	1.448	1.4327
Avg	1.7154	1.7761	1.7439	1.7256	1.7056	1.7580	1.7498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 402 / 33 KV Khaperkheda 2
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	4.768	4.9931	4.2798	4.2798	3.8409	4.4445
2	2.7984	4.4993	4.9383	4.1152	4.2798	3.8409	4.3347
3	2.6337	4.4353	4.6639	4.1152	3.9506	3.8409	4.3347
4	2.4691	4.3244	4.3896	3.9506	3.9506	3.7311	4.1152
5	2.4691	4.1581	4.2798	3.9506	3.786	3.7311	4.3439
6	2.4691	3.6763	4.1701	3.8409	3.6214	4.0604	4.1701
7	2.2497	3.7146	3.786	3.9609	3.3471	4.0604	3.8409
8	2.2497	4.1581	3.6763	3.6214	3.2373	4.1581	3.6763
9	1.6461	3.7311	3.8409	3.678	3.2922	3.7146	3.8958
10	2.1399	3.7146	3.8409	3.678	3.6214		4.0055
11	2.3045	4.0055	3.9506	4.1152	3.5117	3.2579	2.8532
12	2.4691	4.0604	3.9506	4.0604	3.7311	3.7146	3.786
13	4.4136	4.4445	4.4136	4.3347	4.4445	4.3896	4.4993
14	4.4993	4.5542	4.5268	4.4445	4.4993	4.7125	4.4445
15	4.269	4.6639	4.3896	4.6091	4.7188	4.6639	4.7188
16	4.4993	4.4993	4.3896	3.9506	4.5542	4.3896	4.4993
17	4.2798	4.3347	4.1307	3.786	4.0604	4.3896	2.6337
18	4.1027	4.1152	4.0055	3.786	3.9095	3.8958	4.225
19	4.3896	4.2798		4.1701	4.3896	4.1152	4.3347
20	4.8285	4.7188	4.4136	4.4445	4.6091	4.5542	4.2798
21	4.6639	4.9383	4.4993	4.4445	4.3896	4.3347	.2743
22	4.4353	4.9931	4.6091	4.7188	4.1152	4.5542	3.4019
23	5.1029	4.8285		4.8285	3.6763	4.5542	3.3471
24	2.7984	5.0412	5.1029	4.5268	4.1701	3.2922	4.5542
Max	5.1029	5.0412	5.1029	4.8285	4.7188	4.7125	4.7188
Min	1.6461	3.6763	3.6763	3.6214	3.2373	3.2579	.2743
Avg	3.3718	4.3607	4.3164	4.1421	4.0061	4.0781	3.8756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 404 / 33 KV SAGGU CASTING

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	8.7597	4.8731	9.0181	8.9621	8.7597	8.2053	8.514
9		5.2652					
16	13.3746	6.2094	9.6982	9.8176		1.6244	12.6755
24	11.5661	13.6111	10.7528	13.5551	13.4419	13.1956	12.6029
Max	13.3746	13.6111	10.7528	13.5551	13.4419	13.1956	12.6755
Min	8.7597	4.8731	9.0181	8.9621	8.7597	1.6244	8.514
Avg	11.2335	7.4897	9.8230	10.7783	11.1008	7.6751	11.2641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 408 / 33 KV MAHADULA I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4435	.4481	1.0082	1.0082	.9425	4.9897	5.7693
Max	.4435	.4481	1.0082	1.0082	.9425	4.9897	5.7693
Min	.4435	.4481	1.0082	1.0082	.9425	4.9897	5.7693
Avg	.4435	.4481	1.0082	1.0082	.9425	4.9897	5.7693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 167008 / 132 KV Uppalwadi S/S

Feeder No / Name : 409 / 33 KV MAHADULA II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	7.5955	6.7215	5.7133	5.7133	5.5996	4.8788	.5601
Max	7.5955	6.7215	5.7133	5.7133	5.5996	4.8788	.5601
Min	7.5955	6.7215	5.7133	5.7133	5.5996	4.8788	.5601
Avg	7.5955	6.7215	5.7133	5.7133	5.5996	4.8788	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 201 / 11KV VASAHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.056	.056	.056	.056	.056
2	.056	.056	.056	.056	.056	.056	.0373
3	.056	.056	.056	.0373	.056	.056	.0373
4	.056	.056	.056	.0373	.056	.056	.0373
5	.0373	.056	.056	.0373	.056	.056	.0373
6	.056	.056	.056	.056	.056	.056	.056
7	.056	.056	.0373	.0373	.056	.056	.056
8	.056		.056	.0373	.0373	.056	.056
9	.056	.056	.056	.056	.0373	.0373	.056
10	.056	.056	.056	.056	.0373	.0187	.056
11	.056	.056	.056	.056	.056	.0373	.056
12	.056	.056	.056	.056	.056	.0373	.056
13	.056	.056	.056	.056	.056	.0373	.056
14	.056	.056	.056	.056	.056	.056	.056
15	.056	.056	.056	.056	.056	.056	.0373
16	.056	.056	.056		.056	.056	.0373
17	.056	.056	.056	.056		.056	.0373
18	.056	.056	.056	.056	.056	.056	.0187
19	.112	.056	.056	.056	.056	.056	.0373
20	.0373	.056	.056	.056	.056	.056	.056
21	.0373	.056	.056	.056	.056	.056	
22	.056	.056	.056	.056	.0562	.056	.0373
23	.056	.056	.056	.056	.056	.056	.0373
24	.056	.056	.056	.056	.056	.056	.056
Max	.112	.056	.056	.056	.0562	.056	.056
Min	.0373	.056	.0373	.0373	.0373	.0187	.0187
Avg	.0560	.056	.0552	.0519	.0536	.0513	.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 202 / 11kv BORDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5228	.4481	.4294	.5041	.3921	.4481
2	.4854	.5228	.4481	.4108	.4854	.3921	.4294
3	.4481	.5228	.4481	.4108	.4854	.3921	.4108
4	.4481	.4854	.4481	.3734	.4481	.3921	.4108
5	.4854	.4481	.4108	.3734	.4108	.3921	.3921
6	.4294	.3734	.3921	.4294	.3734	.3921	.3734
7	.3734	.3734	.3921	.3547	.3361	.3177	.3174
8	.3361		.3361	.3734	.3547	.3174	.3734
9	.2987	.2801	.3395	.3174	.3734	.2614	.3361
10	.2801	.2801	.3361	.3361	.3921	.2614	.3361
11	.3361	.2614	.3361	.3734	.3547	.2987	.2987
12	.3734	.3547	.3734	.3734	.3547	.3361	.2427
13	.3921	.4294	.4108	.3734	.3921	.4108	.2801
14	.4108	.3547	.4294	.3547	.4108	.3547	.2987
15	.4108	.5041	.3734	.3734	.3921	.3921	.2987
16	.3547	.4294	.3361		.3547	.9335	.2987
17	.3174	.3547	.2987	.2801		.4294	.2614
18	.2614	.3361	.4108	.2614	.1494	.4668	.2427
19	.3174	.3734	.4854	.3547	.1307	.5228	.2614
20	.4481	.5041	.5228	.4668	.168	.5788	.2987
21	.4854	.5228	.5415	.5041	.1867	.5415	
22	.5228	.5601	.5041	.5041	.3174	.5041	.3734
23	.5228	.5601	.4854	.5041	.2987	.4668	.3734
24	.5415	.5228	.5415	.4481	.5041	.4108	.4481
Max	.5415	.5601	.5415	.5041	.5041	.9335	.4481
Min	.2614	.2614	.2987	.2614	.1307	.2614	.2427
Avg	.4076	.4294	.4187	.3905	.3555	.4232	.3393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 164068 / 33/11 KV NEW GONDEGAON

Feeder No / Name : 203 / 11 KV TEKADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3676	1.3817	1.307	1.2936	1.1203	1.2323	1.2567
2	1.3306	1.3817	1.307	1.2567	1.1203	1.2323	1.2197
3	1.3121	1.3443	1.2696	1.2197	1.0829	.056	1.1827
4	1.2936	1.307	1.2696	1.1827	1.0829	1.2323	1.1458
5	1.2752	1.2323	1.2696	1.1458	1.0642	1.1949	1.0903
6	1.2197	1.0269	1.1949	1.0903	1.0456	1.1389	1.0349
7	1.1273	.9896	.9522	.9055	1.0269	1.0642	.9425
8	.8131		.8589	1.0349	1.0269	.7468	.9055
9	.8871	.8775	.8215	.6653	1.0269	1.0642	.8501
10	.9055	.7095	.8402	.961	1.0456	1.0269	1.0082
11	.7842		.8316	.8962	.9522	1.0719	.9522
12	.8402	.7655	.8501	.8589	.9709	.9795	.9149
13	.4108	.8589	.8962	.9335	1.0082	.9425	.9335
14	.4108	.7468	.9425	1.1016	.8775	.8871	1.1016
15	.3734	1.0642	.9795		1.0642	1.1273	1.0642
16	1.1576	.4481	1.0349		1.0456	1.1827	.8215
17	1.0456	.7282	1.0903			1.2567	.9709
18	.8402	.5601	1.1643	1.1016	.8029	1.2936	.5228
19	.6535	.6722	1.2197	1.1576	1.1576	1.3817	1.0829
20	1.2696	1.2883	1.3352	1.2136	1.2136	1.5123	1.4937
21	1.363	1.4003	1.4632	1.2323	1.3443	1.46	
22	1.419	1.4377	1.46	1.2136	1.3443	1.3676	.056
23	1.363	1.3817	1.4045	1.1576	1.2696	1.3121	.8029
24	1.423	1.4003	1.4563	1.3491	1.0829	1.4003	1.2936
Max	1.423	1.4377	1.4632	1.3491	1.3443	1.5123	1.4937
Min	.3734	.4481	.8215	.6653	.8029	.056	.056
Avg	1.0369	1.0456	1.1341	1.0939	1.0772	1.1318	.9847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 201 / 11 KV VPM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191				
13		.0191			.0191		
14				.0191			
15						.0191	
16							.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 203 / 11 KV KANHAN U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191				
13		.0191			.0191		
14				.0191			
15							.0191
16						.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 205 / 11 KV KANHAN R

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191				
13					.0191		
14				.0191			
15						.0191	
16		.0191				.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 206 / 11 KV KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191	.0191	.0191				
13					.0191		
14				.0191			
15						.0191	
16							.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 207 / 11 KV WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191				
13		.0191			.0191		
14				.0191			
16						.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 209 / 11KV KFA II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191			
13		.0191		.0191		
16					.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 210 / 11 KV STATION T/F
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191		.0191				
13					.0191		
14				.0191			
15						.0191	
17							.0191
23		.0191					
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 211 / 11 KV REHAB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0191	.0191	.0191				
13					.0191		
14				.0191			
16						.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 400 / 33KV Mansar

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0572		.0572				
13		.0572			.0572		
14				.0572			
16						.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 401 / 33 KV KANHAN W/W
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0572		.0572				
13		.0572					
14				.0572			
16						.0572	.0572
23					.0572		
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360] BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 402 / 33KV GONDEGAON
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0572		.0572				
13		.0572			.0572		
14				.0572			
16						.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 403 / 33kv Dragon Palace fdr
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0572		.0572				
13		.0572			.0572		
14				.0572			
16						.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 201 / 11 KV GUMTHALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5093	.5335	.4801	.4715	.4763	.4458
2	.547	.5093	.5335	.4973	.4715	.4382	.4801
3	.5281	.4527	.4954	.5144	.4527	.4382	.4801
4	.4715	.4527	.4954	.4801	.415	.4191	.4287
5	.4527	.3772	.4763	.463	.415	.381	.3944
6	.3961	.3584	.4382	.3944	.415	.3429	.3258
7	.415	.3018	.4572	.3086	.3961	.362	.2743
8	.3772	.3206	.4763	.3772	.3772	.4191	.3258
9	.4191	.2743	.4954	.4382	.4338	.3961	.4191
10	.4572	.4115	.5335	.4763	.3772	.3772	.4382
11	.4382	.3601	.4954		.3772	.3772	.4763
12	.4763	.4458	.4572		.3772	.3961	.4954
13	.4382	.4115	.4763		.4115		.5525
14	.4763	.7716	.4572		.4115		.5335
15	.4382	.4458	.4382		.4287		.4763
16	.4572	.3601	.4763	.5281	.4904		.4763
17	.4338	.4763	.4115	.4715	.362		.4527
18	.4338	.4954	.463	.3961	.2667	.3944	.3772
19	.415	.5335	.4801	.3772	.3429	.4115	.4338
20	.5093	.5525	.3429	.4715	.4572	.3944	
21	.4904	.5716	.463	.5093	.4763	.3429	
22	.6413	.5906	.5144	.5281	.5144	.4115	.2263
23	.5281	.5335	.4973	.4904	.4763	.4287	
24	.5658	.5093	.5335	.463	.4715	.4763	.4287
Max	.6413	.7716	.5335	.5281	.5144	.4763	.5525
Min	.3772	.2743	.3429	.3086	.2667	.3429	.2263
Avg	.4730	.4594	.4767	.4560	.4204	.4044	.4258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 202 / 11 KV PALSAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.3734	.6001	.6602	.4668	.6859
2	.6602	.6602	.3734	.5144	.6602	.4294	.6859
3	.6602	.6602	.3361	.5144	.6602	.4294	.7716
4	.6602	.6413	.3361	.5144	.4715	.4108	.5144
5	.6602	.6036	.3734	.6001	.4715	.3734	.6001
6	.6602	.6036	.3361	.5144	.3772	.3921	.6859
7	.6602	.6602	.3361	.5144	.3395	.3734	.6001
8	.6602	.415	.3361	.4287	.6602	.4668	.6859
9	.6161	.6001	.3734	.7095	.679	.6602	.8962
10	.6535	.6859	.5228	.7468	.6859	.7733	.9709
11	.8962	.7716	.4854		.7716	.9054	1.0269
12	.9896	.6859	.5788		.7716	.9054	.9896
13	.8962	.7716	.7095		.7716		1.0829
14	.8029	.7716	.7655		.8573		.8589
15	.8962	.8573	.7095		.7716		.6722
16	.9335	.7716	.5975	.9054	.7545		
17	.9054	.7095	.6859	.8299	.6908		.9808
18	.8488	.6161	.463	.7733	.5601	.7716	1.0185
19	.7545	.6348	.4801	.9054	.5228		1.0562
20	.9054	.6161	.5144	.679	.4668	.5144	
21	.679	.5228	.7716	.679	.5228	.5144	
22	.6413	.4108	.6859	.6602	.5601	.6859	.6602
23	.5281	.4108	.6001	.6602	.5228	.6859	.6602
24	.6602	.6602	.3734	.6859	.6602	.4854	.7716
Max	.9896	.8573	.7716	.9054	.8573	.9054	1.0829
Min	.5281	.4108	.3361	.4287	.3395	.3734	.5144
Avg	.7454	.6417	.5049	.6545	.6196	.5691	.8036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 203 / 11 KV BHUGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955	1.0498	1.1203	.8745	.9774	.9335	.8573
2	.9955	1.0498	1.0829	1.0288	.9774	.8962	.9602
3	.9412	1.0136	1.0829	1.0631	.9412	.8402	.9945
4	.7602	.905	1.0269	1.0288	.8326	.8029	.9259
5	.7602	.905	.9896	.9088	.8145	.8029	.8916
6	.724	.8869	.9896	.823	.7783	.8402	.7202
7	.724	.8507	.9522	.823	.7602	.8775	.7373
8	.5068	.9593	.9896	.9259	.8145	.9149	.583
9	.8402	.9945	1.0456	1.0829	.8326	.905	.6535
10	.9149	.9774	1.1016	1.1763	.823	1.1041	.6161
11	1.0456	.9945	1.1576		.8573	1.1765	.6722
12	1.1389	.9259	1.2136		.823	1.267	.7282
13	1.0498	.9602	1.1576		.8573	1.086	.8215
14	1.1576	.9945	1.1949		.9602	1.086	.8402
15	1.0829	1.0631			.9259	.9955	.7468
16	1.0456	1.0288		1.0136	1.0136	.9955	.7468
17	.9774	1.2136	.7716		.7095	.9259	.6878
18	.9774	1.251	.8402	.6516	.6161	.9602	.5249
19	.9593	1.2136	.9259	.6697	.7095	.823	.6697
20	1.0498	1.1389	.8573	.9054	.9522		
21	1.1222	1.1576	.9774	1.0374	1.0269		
22	1.1222	1.1949	1.0802	1.0317	1.0829	.8059	
23		1.1576	1.0631	.9955	1.0456	.823	
24	1.0136	1.0498	1.2696	.9431	.9774	.9896	.8573
Max	1.1576	1.251	1.2696	1.1763	1.0829	1.267	.9945
Min	.5068	.8507	.7716	.6516	.6161	.8029	.5249
Avg	.9524	1.039	1.0405	.9435	.8795	.9478	.7618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 204 / 11 KV BHOWARI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.2263	.2401	.3734	.1509	.0171
2	.2241	.3361	.2263	.3086	.3361	.1509	.0171
3	.2263	.2241	.1886	.3086	.3361	.1886	.0171
4	.2241	.2241	.1886	.2743	.2987	.1886	.0171
5	.1867	.1867	.2263	.2572	.2987	.2263	.0171
6		.1867	.2075	.1543	.2987	.1886	.1372
7	.2427	.3361	.2263	.1372	.2896	.2263	.1543
8	.2241	.2987	.2452	.3086		.1886	.2401
9	.3395	.2572	.2452	.3584	.2054		.2263
10	.2263	.2229	.2829	.3961	.1886	.1509	.1886
11	.2075	.2401	.3395		.1715	.1867	
12	.1886	.3601	.3772		.2229	.2054	
13	.2075	.2915	.3584		.2401	.2241	.1132
14	.2452	.2401	.3961		.2229	.2427	.2263
15		.3429	.5281		.1886		.2641
16		.2743	.3584	.2241	.2614		.2452
17	.2241	.2829	.2572	.2427	.2263		.2987
18	.1867	.2641	.2401	.2614	.2075		.2801
19	.1698	.2452	.1886	.2614	.1886		.2427
20	.1494	.2452	.4115	.2054	.1509		
21	.2427	.2075	.2401	.2054	.1886	.1372	
22	.2801	.2263	.2743	.2987	.1886	.1543	.1886
23	.2614	.2452	.2401	.3734	.1698	.1543	.1886
24	.3361	.3361	.2263	.1886	.3734	.1509	.1029
Max	.3395	.3601	.5281	.3961	.3734	.2427	.2987
Min	.1494	.1867	.1886	.1372	.1509	.1372	.0171
Avg	.2329	.2671	.2791	.2634	.2446	.1833	.1591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 205 / 11 KV SAWALI GARLA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448	.1509	.1715	.0724	.1509	.4287
2	.1448	.1448	.1886	.3429	.0724	.1509	.5144
3	.1448	.1448	.2263	.3429	.0724	.1132	.5144
4	.1448	.1267	.1886	.3429	.0724	.1097	.5144
5	.1448	.1267	.2263	.3429	.0724	.1509	.4287
6	.1448	.1267	.2263	.2572	.0724	.1886	.2572
7	.181	.1267	.2641	.2572	.0724	.1886	.2572
8	.181	.1448	.2452	.2572	.1448	.2263	.2572
9	.3395	.1715	.2829	.3395	.2172	.2715	.3395
10	.547	.1715	.3395	.415	.1715	.362	.3772
11	.4904	.1715	.3018		.2572	.4163	.4338
12	.4527	.4287	.3395		.2572	.1629	.3961
13	.415	.3429	.3018		.2572	.2896	.415
14	.4527	.3429	.3206		.5144	.2715	.3961
15	.4904	.4287	.2829		.3429	.2534	.3772
16	.5281	.3429		.362	.362	.2896	.3584
17	.4344	.3395			.3395	.3429	.362
18	.2534	.3772		.112	.1886	.3429	.362
19	.181	.3395	.0857	.0905	.2263	.4287	.2896
20	.181	.2829	.1715	.0724	.2829	.3429	
21	.1629	.2452	.1715	.0724	.2263	.4287	
22	.1448	.1886	.4287	.0724	.1886	.5144	.0905
23	.1448	.1886	.2572	.0724	.1509	.4287	.0724
24		.1448	.1509	.1715	.0724	.1509	.3429
Max	.547	.4287	.4287	.415	.5144	.5144	.5144
Min	.1448	.1267	.0857	.0724	.0724	.1097	.0724
Avg	.2804	.2330	.2453	.2275	.1961	.274	.3539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 206 / 11 KV VAISHNAVI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0754	.0343	.0566	.0566	.0343
2	.0566		.0754	.0343	.0566	.0566	.0343
3	.0566	.0566	.0754	.0343	.0566	.0754	.0343
4	.0566	.0566	.0747	.0343	.0566	.0754	.0343
5	.0566	.0566	.1132	.0343	.0566	.0754	.0343
6	.0566	.0566	.0566	.0343	.0566	.0754	.0343
7	.0566	.0566	.0754	.0343	.0566	.0566	.0343
8	.0566	.0566	.1132	.0343	.0566	.0754	.0343
9	.0943	.0514	.1509	.1509	.0566	.0566	.1509
10	.132	.0857	.2263	.1886	.2572	.0566	.1886
11	.3395	.0857	.3395		.3429	.0377	.2263
12	.4904	.2572	.4904		.3429	.0377	.1886
13	.4338	.3429	.4338		.4287		.1886
14	.4715	.3429	.3961		.4287		.3395
15	.4338	.5144	.3395		.3429		.5281
16	.415	.3429	.8488	.0566	.3772		.4904
17	.1886	.3018	.0514	.0566	.1886		.1886
18	.132	.1886	.0514	.0566	.1132	.0343	.0566
19	.0566	.1132	.0514	.0566	.0754	.0343	.0566
20	.0566	.0754	.0514	.0566	.0754	.0343	.0566
21	.0566	.0754	.0514	.0566	.0566	.0343	.0566
22	.0566	.0754	.0514	.0566	.0566	.0343	.0566
23	.0566	.0754	.0514	.0566	.0566	.0343	.0377
24	.0566	.0566	.0754	.0514	.0566	.0566	.0343
Max	.4904	.5144	.8488	.1886	.4287	.0754	.5281
Min	.0566	.0514	.0514	.0343	.0566	.0343	.0343
Avg	.1635	.1470	.1800	.0588	.1545	.0525	.1300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 207 / 11KV WADODA INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3961	.4108	.3086	.7356	1.1203	.823
2	.3961	.3961	.4294	.3258	.7356	1.0829	.8573
3	.3961	.3961	.5228	.3429	.7167	1.0829	.8573
4	.3772	.3772	.4108	.3429	.7545	.9896	.8916
5	.3772	.3772	.4294	.3258	.7545	.9709	.823
6	.3772	.3772	.4294	.3601	.7922	.8962	.7716
7	.4715	.3961	.4668	.3944	1.1694	.7655	.7545
8	.5281	.3961	.4668	.4801	1.2071	.6908	.7888
9	.6348	.5144	.4294	.7095	1.4712	.7356	.9709
10	.7468	.8059	.5228		1.0288	.7545	1.531
11	.8589	.7888	.7095		.8573	.811	1.7924
12	.9335	1.0288	.8775	.9896	1.0288	.8299	.9896
13	.7842	.8573	.8402		.9431	.7922	.5041
14	.6908	.7716	.8676		1.989	.7922	.6161
15	.8962	.8059	1.0829		1.3717	.7545	.7468
16	.9335	.7888	1.1576	2.6406	1.1317	.679	.7095
17	.6602	.6161	.7716	1.358	1.3443	.583	.9431
18	.6602	.5228	.6859	1.1694	1.5497	.6344	1.5089
19	.5847	.4668	.6859	1.6975	1.1576	.6173	1.6975
20	.547	.3547	.5316	1.4146	1.1016	.3258	
21	.4338	.4294	.3944	1.226	1.1763	.7545	
22	.4904	.4668	.4287	1.1883	1.2883	.7545	.2075
23	.4338	.4294	.3944	.7356	1.2136	.7202	.8488
24	.4715	.3961	.4108	.3429	.7356	1.1576	.823
Max	.9335	1.0288	1.1576	2.6406	1.989	1.1576	1.7924
Min	.3772	.3547	.3944	.3086	.7167	.3258	.2075
Avg	.5867	.5482	.5982	.8607	1.0939	.8040	.9298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 208 / 11 KV CHIKHALI NIMBHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1448	.132	.12	.1448	.1698	.1029
2	.1448	.1448	.1509	.1543	.1448	.1509	.1372
3	.1448	.1448	.1509	.1886	.1448	.1509	.1543
4	.1267	.1448	.132	.1715	.1267	.132	.1372
5	.1267	.1448	.1509	.1372	.1267	.132	.12
6	.1267	.1448	.132	.1372	.1267	.1509	.0514
7	.1267	.1448	.1509	.1543	.1448	.1698	.1029
8	.1448	.1629	.1886	.1715	.1629	.2452	.1029
9	.1698	.1372	.1886	.1886	.181	.2534	.1509
10	.1886	.0514	.2263	.2075	.1543	.2715	.0566
11	.2263	.12	.1886		.1715	.2896	
12	.2452	.1543	.2075		.1543	.3077	.132
13	.1886	.1372	.3395		.1543	.2715	.132
14		.1372	.5093	.181	.2058	.2715	.1509
15		.2743	.2829	.1629	.1886	.2534	.1509
16	.1886	.1543	.1886	.1629	.1991	.2172	.1698
17	.181	.2263	.1543	.1267	.1509	.1886	.1448
18	.181	.2641		.1267	.1132	.2058	.1629
19	.181	.2263	.1715	.1267	.1886	.2229	.1448
20	.1448	.1886	.1372	.1267	.1509	.1372	
21	.1629	.1509	.1543	.1448	.1509	.1372	
22	.1629	.1509	.1886	.1448	.1698	.1372	
23	.1448	.1509	.1372	.1448	.1509	.12	.0543
24	.1448	.1448	.132	.1372	.1448	.1698	.12
Max	.2452	.2743	.5093	.2075	.2058	.3077	.1698
Min	.1267	.0514	.132	.12	.1132	.12	.0514
Avg	.1635	.1602	.1911	.1531	.1563	.1982	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 209 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0377	.0377	.0377	.0343	.0377	.0343
16	.0566		.0377			.0377
24	.0754	.0754	.0377		.0754	
Max	.0754	.0754	.0377	.0343	.0754	.0377
Min	.0377	.0377	.0377	.0343	.0377	.0343
Avg	.0566	.0566	.0377	.0343	.0566	.036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 201 / 11 KV BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.8495	.9526	.9145	.7888	.724	.7621
2	.7049	.8322	.9526	.9145	.7888	.724	.724
3	.6668	.8322	.9145	.8764	.7716	.7049	.724
4	.6668	.8149	.8954	.8764	.7716	.7049	.7049
5	.6097	.7975	.8573	.8383	.7545	.6668	.6668
6	.5716	.6371	.8002	.7621	.639	.5716	.5906
7	.5906	.6371	.7811	.7049	.5376	.5335	.5335
8	.6097	.5921	.8573	.724	.6009	.5525	.5525
9	.6478	.6562	.9145	.724		.5525	.6287
10	.6859	.6882	.8192	.7621	.6325	.5716	.5906
11	.5138	.8002	.9717	.6964	.8192	.5716	.5304
12	.6962	.8764	.9907	.7449	.8573	.3239	.5967
13	.6554	.8002	.9717	.7449	.8764	.6287	.6203
14	.7701	.9145	.9717	.7287	.8573	.6478	.6203
15	.7209	.8764	.9335	.7209	.8764	.6859	.6539
16	.6882	.8573	.8573	.7045	.8573	.6097	.6706
17	.6226	.8383	.8192	.4424	.5144	.5525	.6706
18	.6562	.8573	.8383	.4607		.5525	.6325
19	.7125	.8764	.8383	.6062	.6097	.4763	.2721
20	.8573	.9526	.9145	.7373	.724		
21	.8573	.9907	.9717	.7716	.7621	.724	.5493
22	.8745	1.0098	.9907	.7888	.7811	.7621	
23	.8669	.9907	.9526	.8059	.7621	.7621	.6201
24	.7621	.8669	.9526	.9335	.8059	.743	.7621
Max	.8745	1.0098	.9907	.9335	.8764	.7621	.7621
Min	.5138	.5921	.7811	.4424	.5144	.3239	.2721
Avg	.6964	.8269	.9050	.7493	.7449	.6238	.6217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 202 / NEW DHANLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5912	1.7147	1.6575	1.4842	1.5242	1.2384
2	1.7147	1.5912	1.7147	1.6575	1.4661	1.4861	1.2384
3	1.6575	1.5729	1.7147	1.6385	1.448	1.4861	1.1812
4	1.5623	1.5546	1.6766	1.6385	1.4299	1.448	1.1431
5	1.4289	1.5181	1.5813	1.5623	1.4118	1.3717	1.105
6	1.2765	1.2803	1.3336	1.2765	1.1946	1.2003	.9907
7	1.1431	1.1157	1.1431	.9907	.9465	1.0669	.8192
8	1.1812	1.0517	1.1622	.9526	.8589	.743	.8192
9	1.0669	.9816	.9335	.9717		.7811	.8192
10	1.0288	1.0166	.9526	1.0288	1.1043	.9526	.8002
11	1.086	1.0669	1.105	1.0454	1.1812	.362	.7522
12	1.1584	1.2765	1.2955	1.0985	1.2384	1.0669	.7522
13	1.2536	1.3717	1.3336	1.1694	1.3908	1.0288	.8417
14	1.1104	1.2955	1.2765	1.1871	2.2291	1.2003	.8775
15	1.1041	1.3146	1.2574	1.0808	2.2291	1.2193	.8238
16	.9955	.7621	1.086		2.0957	1.2193	.7522
17	1.0498	1.0288	1.0288	.4961	.743	.8764	.8238
18	1.267	1.086	1.0288	.8745		.4572	.8669
19	1.2226	1.1241	1.1431	1.0679	1.086		1.0029
20	1.6827	1.5623	1.5051	1.3575	1.4289		
21	1.6827	1.7337	1.6575	1.5203	1.5813	.7621	
22	1.701	1.7909	1.7337	1.5746	1.6004	1.2003	
23	1.6461	1.7528	1.6385	1.5384	1.5432	.9907	
24	1.7718	1.6095	1.7337	1.6004	1.5203	1.5242	1.2384
Max	1.7718	1.7909	1.7337	1.6575	2.2291	1.5242	1.2384
Min	.9955	.7621	.9335	.4961	.743	.362	.7522
Avg	1.3544	1.3354	1.3646	1.2602	1.4187	1.0894	.9443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 204 / 11 kv Pawaddona

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1267	.2286	.1715	.124	.1524	.1524
2	.1143	.1267	.2286	.1715	.124	.1524	.1524
3	.1143	.1267	.2096	.1715	.124	.1524	.1334
4	.0953	.1267	.1905	.1715	.124	.1524	.1334
5	.0953	.1267	.1715	.1524	.124	.1334	.1143
6	.0762	.0701	.1524	.1524	.0829	.1334	.1143
7	.0953	.0876	.1715	.1334	.08	.1524	.1334
8	.0953	.0819	.1715	.1524	.112	.1905	.1524
9	.1334	.1638	.1715	.1715		.2286	.2286
10	.1143	.1475	.1905	.1715	.144	.2477	.2477
11	.1326	.1905	.1905	.1406		.2286	.2006
12	.1326	.2286	.1905	.1406		.2096	.216
13	.128	.2286	.2286	.125		.0953	.1943
14	.144	.2858	.2477	.1562		.1143	.2105
15	.1326	.2667	.2477	.144		.1143	.2105
16	.1326	.2667	.2667	.112		.0953	.2267
17	.0995	.2096	.1905	.08	.0762	.1143	.208
18	.0926	.2667	.1715	.0753	.0762	.1905	.1957
19	.112	.2096	.1715	.0655	.0762	.1524	.1423
20	.1417	.2286	.1715	.1227	.1334		
21	.1417	.2286	.1905	.1402	.1524	.1524	.0914
22	.1417	.2286	.1905	.1402	.1524	.1524	
23	.1448	.2286	.1715	.1417	.1524	.1524	.0924
24	.1334	.1448	.2286	.1715	.1417	.1524	.1524
Max	.1448	.2858	.2667	.1715	.1524	.2477	.2477
Min	.0762	.0701	.1524	.0655	.0762	.0953	.0914
Avg	.1199	.1832	.1977	.1406	.1176	.1574	.1683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 205 / 11 KV NEHARVANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8589	.9907	1.0669	.8589	.6287	.8002
2	.8002	.8589	.9907	1.0669	.8589	.6287	.8002
3	.7621	.8413	.9907	1.0288	.8413	.6097	.7621
4	.724	.8238	.9526	1.0288	.8413	.6097	.7621
5	.6668	.8063	.9145	.9907	.8238	.5716	.6668
6	.6287	.6443	.8573	.8954	.6443	.4382	.6287
7	.5906	.6443	.8383	.8573	.5601	.3429	.5525
8	.5335	.6882	.9335	.9526	.6401	.381	.5906
9	.6668	.6081	.9907	.9717		.4763	.5906
10	.6859	.5921	1.0098	1.0288	.5921	.5144	.5906
11	.6133	.8383	1.0098	.4321	.8002	.6287	.5197
12	.6464	.9907	1.086	.9282	.8573	.6287	.6036
13	.7042	.9907		.8642	.9526	.6859	.6952
14	.7209	1.0669		.8642		.6859	.7291
15	.6706	1.0669	1.086	.9012		.6859	.6443
16	.6371	.9907	1.1241	.8192		.6668	.5087
17	.6539	.9526	1.086		.4763	.6287	.6613
18	.6167	.8954	1.0479	.4784		.5906	.4961
19	.6882	.9145	1.0288	.6371	.0762	.6668	.6203
20	.8495	1.0669	1.0288	.7712	.4382		
21	.9015	1.0669	1.0669	.8413	.6097	.7811	.6878
22	.8842	1.1241	1.105	.8589	.6287	.8764	
23	.8939	1.0669	1.086	.8939	.6287	.8573	.7964
24	.8383	.8764	1.0479	1.0669	.8764	.6287	.8383
Max	.9015	1.1241	1.1241	1.0669	.9526	.8764	.8383
Min	.5335	.5921	.8383	.4321	.0762	.3429	.4961
Avg	.7157	.8864	1.0124	.8802	.6845	.6179	.6611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 206 / 11 KV STATION XMER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715	.1715
2	.1715	.1715	.1715	.1715	.1715	.1715	.1715
3	.1715	.1715	.1715	.1715	.1715	.1715	.1715
4	.1715	.1715	.1715	.1715	.1715	.1715	.1715
5	.1524	.1715	.1715	.1715	.1715	.1715	.1715
6	.0572	.0572	.0572	.0572	.0381	.0381	.0572
7	.0381	.0572	.0381	.0572	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0572	.0381
9	.0381	.0381	.0381	.0381		.0572	.0381
10	.0381	.0572	.0381	.0381	.0572	.0381	.0572
11	.0381	.0572	.0381	.0572	.0572	.0381	.0572
12	.0381	.0572	.0572	.0572	.0572	.0381	.0572
13	.0572	.0572	.0572	.0572	.0572	.0381	.0572
14	.0572	.0572	.0572	.0572	.0572	.0572	.0572
15	.0572	.0572	.0572	.0572	.0572	.0572	.0572
16	.0572	.0572	.0572	.0572	.0572	.0572	.0572
17	.0572	.0572	.0572	.0572	.0572	.0572	.0572
18	.0572	.0572	.0572	.0572	.0572	.0572	.0572
19	.1143	.0572	.0572	.1143	.1524	.1715	.1143
20	.1715	.1715	.1905	.1524	.1524		
21	.1715	.1715	.1905	.1524	.1524	.1715	.1524
22	.1334	.1715	.1905	.1524	.1524	.1715	
23	.1715	.1715	.1715	.1715	.1715	.1715	.1143
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	.1715	.1715	.1905	.1715	.1715	.1715	.1715
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1000	.1032	.1032	.1024	.1061	.1019	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 201 / 11 KV MOUDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7737	1.8298	1.7918	1.8671	1.7737	1.8111	1.6289
2	1.7558	1.8111	1.7918	1.8298	1.8099	1.7737	1.6289
3	1.6289	1.7737	1.773	1.7924	1.7177	1.7737	1.5927
4	1.5384	1.7187	1.7551	1.7177	1.6804	1.6804	1.5384
5	1.4632	1.4937	1.643	1.4937	1.6409	1.6057	1.4632
6	1.4083	1.3769	1.4003	1.4003	1.3443	1.4937	1.3575
7	1.267	1.307	1.307	1.307	1.3256	1.307	1.2851
8	1.0974	1.1763	1.1576	1.1317	1.0974	1.1576	1.086
9	1.1041	1.1763	1.1389	1.1949	1.1016	1.1949	1.1765
10	1.1403	1.086	1.1763	1.3014	1.251	1.251	1.267
11	1.3817	1.363	1.3817	1.4523	1.3256	1.3394	1.4146
12	1.4861	1.4937	1.4937	1.6057	1.475	1.5384	1.5278
13	1.1643	1.6057	1.5684	1.6244	1.531	1.6289	1.6975
14	1.6991	1.6617	1.643	1.7364	1.587	1.5746	1.7177
15	1.6804	1.6617	1.587	1.7528	1.7737	1.647	1.6057
16	1.6804	1.643	1.4901	1.6461	1.7177	1.6651	1.7364
17	1.5497	1.475	1.4377	1.363	1.2136	1.3937	1.643
18	1.363	1.3256	1.419	1.262	1.1763	1.3032	1.5123
19	1.4449	1.419	1.3817	1.4098	1.363	.9231	1.4937
20	1.829	1.6632	1.643	1.6057	1.6244	1.3213	
21	1.9433	1.6975	1.7177	1.7147	1.6991	1.1946	1.4563
22	1.9231	1.8861	1.7924	1.8671	1.8298	1.828	1.307
23	1.8823	1.9231	1.9231	1.9814	1.9044	1.828	1.587
24	1.7737	1.9231	1.8484	1.8671	1.7551	1.8484	1.6644
Max	1.9433	1.9231	1.9231	1.9814	1.9044	1.8484	1.7364
Min	1.0974	1.086	1.1389	1.1317	1.0974	.9231	1.086
Avg	1.5408	1.5621	1.5526	1.5802	1.5299	1.5034	1.4951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 202 / 11 KV WADODA IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.3392	1.1506	1.094	.2035	.132	.128
2	1.7375	1.2136	1.1506	1.0751	.1867	.132	.128
3	1.5384	1.1694	1.1506	1.0374	.1867	.1509	.128
4	1.4632	1.1203	1.1317	.9997	.1848	.1698	.128
5	1.3717	1.0164	1.1317	.9431	.1663	.2075	.128
6	.905	.9511	1.094	.9242	.1478	.2263	.1463
7	.8688	.9979	1.0751	.8775	.1463	.2452	.1646
8	.9328	.9709	.9808	.8488	.2012	.2452	.1448
9	1.2071	1.2136	1.0751	1.2637	.1097	.2829	.1646
10	1.3535	1.2803	.3206	1.4146	.0914	.132	.0732
11	1.2765	1.3392	.7545	1.5242	.0943	.128	
12	1.3817	1.2637	1.0562	1.5123	.0754	.128	1.1506
13	1.1523	1.0751	.9054		.0943	.128	1.0374
14	1.2012	1.0751	1.2449	.0924	.0943	.1109	1.094
15	1.3336	1.0374	1.094	.168	.0943	.1086	1.094
16	1.1523	1.094	1.1385	.128	.0943	.1086	1.0751
17	1.1273	1.0562	.9997	.128	.0566	.0905	1.0185
18	1.0082	1.0562	1.0185	.1086	.0566	.0914	.9431
19	1.1203	1.1694	1.0374	.0732	.0754	.4024	1.0374
20	1.0425	1.0185	1.0185	.0924	.0754	.3658	
21	1.1016	1.1506	1.094	.0934	.132	.0914	
22	1.0679	1.094	1.0185	.112	.1698	.0924	
23	1.2323	1.2449	1.1506	.1886	.1698	.1478	
24	1.1706		1.226	1.0374	.1867	.132	.128
Max	1.7741	1.3392	1.2449	1.5242	.2035	.4024	1.1506
Min	.8688	.9511	.3206	.0732	.0566	.0905	.0732
Avg	1.2300	1.1281	1.0424	.6842	.1289	.1687	.5217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 203 / 11 KV WADODA R

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5359	.5144	.5243	.5729	.4858	.5611
2	.5014	.5544	.5144	.4858	.5792	.4534	.543
3	.4706	.5729	.5144	.4858	.5611	.4534	.5068
4	.4344	.5121	.5144	.6348	.5544	.4534	.4525
5	.3982	.4572	.4801	.4858	.567	.4372	.4344
6	.3582	.4207	.463	.4696	.4344	.421	.362
7	.3582	.462	.4409	.5182	.4207	.4049	.2715
8	.4525	.499	.4748	.5898	.4938		.3258
9	.4835	.5973	.5533	.664	.5121	.4858	.3801
10	.5014	.5544	.57	.664	.5788	.5668	.3077
11	.5304	.5304	.6001	.724	.4534	.6984	.3814
12	.5487	.5533	.6859	.6653	.583	.6984	.4161
13	.4163	.6539		.6283	.5182	.6984	.5028
14	.6099	.6539	.7362	.5973	.583	.6697	.4557
15	.6099	.6203	.6661	.6468	.639	.7164	.4908
16	.5611	.5533	.6154	.7164	.6154	.5068	.5083
17	.4755	.5533	.664	.5853		.4835	
18	.4572	.5304	.6316	.567	.3077	.4298	.4607
19	.5487	.547	.5992	.5304	.4534	.362	.4784
20	.6219	.6104	.6718	.5975	.4858	.3403	
21	.5847	.6104	.664	.6335	.4696	.362	.1214
22	.5847	.6274	.664	.6283	.502	.5068	.1052
23	.6283	.583	.6964	.6219	.502	.4706	.1612
24	.5373	.5914	.5658	.6154	.5792	.4858	.5552
Max	.6283	.6539	.7362	.724	.639	.7164	.5611
Min	.3582	.4207	.4409	.4696	.3077	.3403	.1052
Avg	.5088	.5577	.5870	.5950	.5203	.5039	.3992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 204 / 11 KV TARSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.1075	.128	.0876	.0362	.0526	.128
2	.0724	.1097	.128	.0876	.0366	.0351	.128
3	.0543	.1294	.1267	.0876	.0362	.0351	.1267
4	.0543	.128	.1086	.0876	.0354	.0351	.1267
5	.0543	.1109	.1086	.0876	.0358	.0351	.1629
6	.0549	.1109	.1086	.0876	.0362	.0351	.1829
7	.0732	.0895	.0905	.0876	.0366	.0351	.1991
8	.0724	.0924	.0905	.0701	.0366	.0351	.2172
9	.0905	.1086	.0895	.1227	.0185	.0351	.1991
10	.0724	.0905	.0895	.0701	.0366	.0175	
11	.0739	.0709	.0543	.1097	.0351	.0362	
12	.0554	.124	.0724	.0905	.0351	.0181	
13	.0724	.124	.0905	.0914	.0526	.0362	
14	.0924	.124	.0905	.0732	.0175	.0366	.2454
15	.0914	.1063	.0905	.0732	.0351	.0179	
16	.0709	.1063	.0876	.0739	.0351		
17	.0709	.124	.1227	.0354	.0526	.1086	.0549
18	.0724	.0886	.0876	.037	.0526	.1629	.1928
19	.0886	.1063	.1052	.0362	.0526	.2012	.0183
20	.112	.1254	.1052	.0549	.0526	.2172	
21	.1254	.1254	.1227	.0914	.0526	.2507	
22	.1063	.1267	.1227	.0549	.0526	.2715	.0549
23	.0886	.1267	.1753	.037	.0526	.2865	.0549
24	.0724	.0905	.128	.1052	.0362	.0526	.1267
Max	.1254	.1294	.1753	.1227	.0526	.2865	.2454
Min	.0543	.0709	.0543	.0354	.0175	.0175	.0183
Avg	.0777	.1103	.1052	.0767	.0400	.0890	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 205 / 11 KV NIMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0709	.0747	.0377	.0747	.0724	.0362
2	.0362	.0895	.0747	.0377	.0914	.0905	.0362
3	.0362	.0739	.0747	.0377	.0924	.0905	.0543
4	.0362	.0739	.0747	.0377	.0914	.0943	.0543
5	.0362	.0747	.056	.0377	.0724	.0943	.0543
6	.0362	.0732	.0747	.0373	.0724	.0943	.0543
7	.0362	.0709	.0554	.0377	.0549	.1132	.0543
8	.0362	.0532	.0554	.0377	.0366	.0566	.0543
9	.0362	.0537	.0554	.0377	.0354	.0566	.0543
10	.0362	.0543	.0554	.0351	.0549	.0566	.056
11	.0554	.0537	.0377	.0362	.0377	.0549	.0373
12	.0709	.0537	.0377	.037	.0377	.0549	
13	.0532	.0537	.0377	.0362	.0377	.0543	
14	.0543	.0566	.0377	.0543	.0566	.0724	.0554
15	.0709	.0566	.0377	.0549	.0566	.0543	.0537
16	.0543	.0754	.0377	.0724	.0377	.0724	.0537
17	.0543		.0377	.0914	.0377	.0724	.0543
18	.0724	.056	.0377	.0732	.0377	.0543	.0543
19	.0905	.056	.0566	.0914	.0377	.0724	.0532
20	.0886	.0747	.0754	.0914	.1132	.0362	
21	.0886	.0747	.0754	.0905	.0943	.0362	
22	.0914	.056	.0377	.0905	.0943	.0362	
23	.0895	.0566	.0377	.0914	.0943	.0362	.0724
24	.0543	.0543	.0566	.0373	.0914	.1132	.0362
Max	.0914	.0895	.0754	.0914	.1132	.1132	.0724
Min	.0362	.0532	.0377	.0351	.0354	.0362	.0362
Avg	.0563	.0637	.0538	.0551	.0642	.0683	.0515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 206 / 11 KV BAPDEO SUGAR FACTORY NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0354	.0377	.0189	.0362	.0189	.0366
2	.0366	.037	.0189	.0189	.0362	.0189	.0362
3	.0181	.037	.0189	.0189	.0366	.0189	.0362
4	.0181	.0366	.0189	.0189	.0362	.0189	.0362
5	.0181	.0358	.0189	.0189	.0362	.0189	.0362
6	.0181	.0373	.0189	.0189	.0181	.0189	.0362
7	.0181	.0354	.0377	.0189	.0366	.0189	.0362
8	.0362	.0366	.0189	.0189	.0362	.0189	.0362
9	.0181	.0181	.0189	.0189	.0177	.0189	.0362
10	.0181	.0181	.0189	.0189	.0181	.0189	.0181
11	.0183	.0189	.0189	.0373	.0189	.0181	.0189
12	.0177	.0377	.0189	.0181	.0189	.0181	.0189
13	.0181	.0189	.0187	.0183	.0189	.0181	.0377
14	.0181	.0189	.0187	.0177	.0189	.0181	.0377
15	.0366	.0377	.0189	.0177	.0189	.0181	.0189
16	.0177	.0189	.0187	.0732	.0189	.0181	.0189
17	.0183	.0377		.0183	.0187	.0181	.0189
18	.0177	.0377	.0189	.0354	.0189	.0181	.0189
19	.0354	.0373	.0189	.0366	.0189	.0181	.0377
20	.0354	.0377	.0189	.0362	.0189	.0181	
21	.0354	.0377	.0189	.0354	.0189	.0362	
22	.0354	.0189	.0754	.0366	.0187	.0362	.0189
23	.0354	.0377	.0189	.0366	.0189	.0362	.0377
24	.0362	.0362	.0377	.0187	.0362	.0189	.0181
Max	.0366	.0377	.0754	.0732	.0366	.0362	.0377
Min	.0177	.0181	.0187	.0177	.0177	.0181	.0181
Avg	.0255	.0316	.0238	.0260	.0246	.0207	.0293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 207 / 11 KV BORGAO (33 KV DCL
STN) Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.4163	.362	.3658	.4344	.3361	.2865
2	.2328	.4207	.362	.3439	.4163	.3361	.2715
3	.2172	.4024	.362	.3258	.439	.3258	.2715
4	.2172	.4066	.362	.3077	.3898	.3258	.2507
5	.2507	.3841	.3109	.2829	.3696	.3077	.2534
6	.2865	.3366	.2743	.2353	.3109	.2896	.2172
7	.2686	.3292	.2328	.2427	.2658	.2534	.1991
8	.2172	.2835	.2149	.2241	.2195	.2534	.181
9	.1991	.3439	.2195	.2641	.3012	.2614	.197
10	.2149	.362	.2353	.2801	.2534	.2534	.181
11	.4024	.3506	.2279	.2926	.2353	.2686	.2378
12	.4163	.3189	.2534	.3142	.2353	.2896	.2743
13	.3982	.3366	.2896	.2896	.2534	.2686	.2926
14	.3658	.3681	.3292	.3109	.2896	.3403	.3292
15	.3898	.333	.3734	.2835	.2534	.3224	.2926
16	.4251	.333	.4108	.2926	.2534	.3224	.2743
17	.3189	.3189	.362	.3109	.1991	.3045	.2561
18	.1417	.3012	.3258	.2378	.181	.2149	.2378
19	.2172	.3258	.3439	.2926	.1448	.2686	.2561
20	.3544	.3258	.362	.3721	.181	.3045	.0373
21	.4435	.3658	.3982	.4207	.3982	.2896	
22	.4382	.3841	.4163	.439	.4163	.3258	
23	.4477	.3511	.4108	.4119		.3258	.1307
24	.197	.4251	.3881	.3921	.4525	.415	.2865
Max	.4477	.4251	.4163	.439	.4525	.415	.3292
Min	.1417	.2835	.2149	.2241	.1448	.2149	.0373
Avg	.3039	.3551	.3261	.3139	.2997	.3001	.2370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359] BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 208 / 11 KV STATION XMER
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4715	
9	.1791			
16		.4338		.1509
24			.5658	
Max	.1791	.4338	.5658	.1509
Min	.1791	.4338	.4715	.1509
Avg	.1791	.4338	.5187	.1509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 201 / 11 KV TARSA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4045	1.3535	1.39	1.1523	1.4632	.9511	.7316
2	1.4045	1.2803	.924	1.0974	1.39	.9511	.8048
3	1.386	1.2437	1.3352	1.0608	1.39	.9511	
4	1.2936	1.2437	1.3717	1.0608	1.2803	.8413	.8596
5	1.1643	1.1888	1.39	1.0242	1.2071	.7682	.9145
6	.961	1.0242	1.0164	.8413	.823	.6584	.7316
7	.8686	.8779	.9694	.7499	.695	.6584	.6767
8	.6468	.7316		.695	.6584	.7316	.6584
9	.1829	.6584	.7023	.7499		.7133	.7133
10	.439	.7316	.7682	.7316	.695	.6036	.7682
11	.4572	.8131	.7682	.7682	.695	.5487	.7682
12	.8413	.7468	.8596	.8779	.9145		.823
13	.7865	1.1016	.8962	.9328	1.0242		.8029
14	.8596	1.1706	.9328	.9328	1.0608		.7842
15	.823	1.2437	.823	1.2254	1.0608	.9877	.6767
16	.8413	1.1827	.8413		.823	.8413	.7865
17	.7682	1.134	.7499	.7499		.6219	.7133
18	.7316	1.0242	.6584	.7682		.5121	.6219
19	.8413	1.0974	.8048	1.0242	.5121		.695
20	1.2071	1.0608	1.0608	1.1523	.7499		
21	1.2803	1.2803	1.1157	1.2803		.695	
22	1.4998	1.3717	1.2071	1.3169	.9145	.7865	
23	1.4998	1.4998	1.1523	1.5912	.9145	.7499	
24	1.46	1.4632	1.4815	1.1523	1.5364	.9511	.7316
Max	1.4998	1.4998	1.4815	1.5912	1.5364	.9877	.9145
Min	.1829	.6584	.6584	.695	.5121	.5121	.6219
Avg	.9853	1.1052	1.0095	.9972	.9904	.7643	.7506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 202 / 11 KV NIMKHEDA (DHANI STN)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	.8413	.924	.7095	.9145	.8048	.8962
2	.961	.8048	.924	.7282	.9145	.8048	.8589
3	.961	.7865	.8871	.7468	.8962	.8048	.8589
4	.924	.7865	.8501	.7468	.8779	.7682	.8215
5	.7947	.7865	.8131	.7468	.8779	.7316	.7842
6	.6653	.6219	.7577	.6722	.7316	.6219	.6348
7	.6099	.6219	.6838	.5601	.7316	.5487	.5975
8	.462	.6036		.5228	.6401	.4755	.5228
9	.6219	.5121	.6348	.4294		.5121	.5041
10	.6219	.6767	.7468		.6584		.5788
11	.7316	.7282	.6348	.6036	.7865	.6348	.6468
12	.8048	.7392	.7095	.695	.8596	.8402	.7947
13	.9145	.7682	.8029	.5853	.8413	.7095	
14	.8048	.7468	.7842	.5487	.8413		.6653
15	.7133	.7577	.8215	.6219	.9145	.7842	.7577
16	.7316	.7392	.5975		.823	.5975	.7468
17	.7316	.7577	.5228	.6036		.6535	.7207
18	.6584	.8131	.5415	.5304		.6908	.6838
19	.6219	.6767	.6535	.695	.4207		.7023
20	.7316	.8686	.8962	.8962	.5853		
21	.7682	.9511	.9896	.9145	.6036	.8775	
22	.9328	1.0608	1.0829	1.0608	.8596	.8402	
23	.9145	1.0456	.7842	1.0974	.8413	.8029	
24	1.0164	.8596	.924	.6908	.9694	.823	.8962
Max	1.0164	1.0608	1.0829	1.0974	.9694	.8775	.8962
Min	.462	.5121	.5228	.4294	.4207	.4755	.5041
Avg	.7774	.7731	.7812	.7003	.7899	.7163	.7196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 203 / 11 KV DUMMY FDR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18
HR	Load (MW)
17	.0183
Max	.0183
Min	.0183
Avg	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164075 / 33/11 KV DHANI STN

Feeder No / Name : 204 / 11 KV STN XMER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0366	.0373	.0377	.0366	.0366	.0377
2	.0343	.0366	.0373	.0377	.0366	.0366	.0377
3	.0343	.0366	.037	.0377	.0366	.0366	.0377
4	.0343	.0366	.0373	.0377	.0366	.0366	.0377
5	.0343	.0366	.0373	.0377	.0366	.0366	.0377
6	.0343	.0183	.037	.0377	.0183	.0366	.0377
7	.0343	.0183	.0185	.0377	.0183	.0183	.0377
8	.0171	.0183		.0377	.0183	.0183	.0377
9	.0183	.0183	.0185	.0189		.0183	.0377
10	.0183	.0183	.0189	.0189	.0183	.0183	.0189
11	.0183	.0373	.0189	.0183	.0183	.0189	.0187
12	.0183	.0187	.0189	.0183	.0183	.0189	.0187
13	.0183	.0187	.0189	.0183	.0183	.0189	.0187
14	.0183	.0185	.0189	.0183	.0183	.0189	.0187
15	.0183	.0185	.0189	.0177	.0183	.0189	.0185
16	.0183	.0185	.0189	.0183	.0183	.0189	.0185
17	.0183	.0185	.0189	.0183	.0177	.0189	.0185
18	.0366	.0185	.0189	.0183	.0183	.0189	.0187
19	.0366	.037	.0189	.0183	.0366	.0377	.0187
20	.0366	.037	.0377	.0366	.0366	.0377	
21	.0366	.0373	.0377	.0366	.0366	.0377	
22	.0366	.0373	.0377	.0366	.0366	.0377	
23	.0366	.037	.0377	.0366	.0366	.0377	
24	.0343	.0366	.0373	.0377	.0366	.0366	.0377
Max	.0366	.0373	.0377	.0377	.0366	.0377	.0377
Min	.0171	.0183	.0185	.0177	.0177	.0183	.0185
Avg	.0282	.0277	.0277	.0287	.0270	.0279	.0282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 401 / 33 KV GUMTHALA

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			4.0055	6.5535		5.7156	
16	8.6008	6.0014	7.9784	8.1162			5.8814
24			6.4506	7.6466	6.5638	6.1111	
Max	8.6008	6.0014	7.9784	8.1162	6.5638	6.1111	5.8814
Min	8.6008	6.0014	4.0055	6.5535	6.5638	5.7156	5.8814
Avg	8.6008	6.0014	6.1448	7.4388	6.5638	5.9134	5.8814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 403 / 33 KV VISAKHA

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			9.2181	8.8706		7.8418	8.2339
9						7.8418	
16	9.2587	9.8131	9.7119	6.8896	9.5913		9.0741
24			11.3655	10.7002	10.8665	9.7462	
Max	9.2587	9.8131	11.3655	10.7002	10.8665	9.7462	9.0741
Min	9.2587	9.8131	9.2181	6.8896	9.5913	7.8418	8.2339
Avg	9.2587	9.8131	10.0985	8.8201	10.2289	8.4766	8.654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 702 / 132 KV DCL 2

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			3.3951	3.3951		3.3951	3.2579
16	3.6214	3.6214	3.6214	3.6214	3.7311		3.6214
24			3.6214	3.3951		3.3951	
Max	3.6214	3.6214	3.6214	3.6214	3.7311	3.3951	3.6214
Min	3.6214	3.6214	3.3951	3.3951	3.7311	3.3951	3.2579
Avg	3.6214	3.6214	3.5460	3.4705	3.7311	3.3951	3.4397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 167022 / 132 KV MOUDA

Feeder No / Name : 703 / 132 KV PENNAR

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			5.0297	4.5725		4.5771	6.0997
16	4.177	3.8477	3.1367	3.6214	5.2584		4.0329
24			4.7531	5.6584	4.9291	4.5268	
Max	4.177	3.8477	5.0297	5.6584	5.2584	4.5771	6.0997
Min	4.177	3.8477	3.1367	3.6214	4.9291	4.5268	4.0329
Avg	4.177	3.8477	4.3065	4.6174	5.0938	4.5520	5.0663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 201 / 11 kV Chacher

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7628	.7545	.7356	.6762	.2641	.3772
2	.6036	.7455	.7545	.6979	.6588	.2641	.3772
3	.5658	.7108	.7167	.6602	.6415	.2641	.4904
4	.5281	.7108	.7167	.5658	.6344	.2641	.4715
5	.5093	.6762	.7167	.5281	.6173	.2641	.4527
6	.4715	.6516	.6036	.5281	.4458	.2452	.3395
7	.415	.4801	.5281	.5658	.4801	.2263	.3772
8	.415	.3887	.5281	.4527	.4801	.1886	.415
9	.5281	.5316	.5281	.5281	.4801	.1886	.2641
10	.679	.6859	.3772	.5658	.583	.1509	.3772
11	.6173		.6036	.5548	.6413	.1509	.2641
12	.6173	.8299	.679	.5487	.7167	.1886	.415
13	.6241	.8299	.7545	.583	.679	.2263	.4904
14	.5487	.679	.7922	.583	.6413	.2263	.2263
15	.6104	.7545	.679	.5028	.6036	.2263	.6036
16	.6783	.7545	.7167	.3601	.5658		.4904
17	.3944	.5281	.6036	.3814		.2641	.3772
18	.5895	.679	.6036	.3814		.2829	.4904
19	.5895	.6036	.5658	.4508			.5658
20	.6588	.7545	.679	.5548		.3018	
21	.6068	.7922	.7167	.6241			
22	.8063	.8299	.7545	.6588		.4527	.5658
23	.8063	.7922	.7922	.6935	.1509	.415	.6036
24	.7922	.7545	.7733	.7545	.6516		.415
Max	.8063	.8299	.7922	.7545	.7167	.4527	.6036
Min	.3944	.3887	.3772	.3601	.1509	.1509	.2263
Avg	.5988	.6924	.6641	.5608	.5749	.2528	.4295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 202 / 11 KV NAGARDHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.2851	1.4712	1.4146	1.3121	1.4335	1.3203
2	1.2826	1.2936	1.4712	1.358	1.3121	1.4146	1.2826
3	1.1694	1.262	1.4335	1.2826	1.2936	1.3769	1.1883
4	1.0751	1.2437	1.3957	1.226	1.2437	1.3769	1.1694
5	.9808	1.262	1.3769	1.1694	1.2437	1.3392	1.094
6	.9431	.8048	1.0751	1.094	.9412	1.1317	.9431
7	.7733	.7421	.811	1.1128	.8145	.8865	.8488
8	.9242	.7964	.8488	.9242	.7783	.9242	.7733
9	.811	.8145	.9242	.8865	.8145	.9242	.811
10	.7922	.724	1.1128	.9997	.8688	.9997	.8299
11	.8688	.811	.9808	.9412	.9619	1.0185	.8488
12	.8507	.9431	.9808	.9955	.9431	1.0562	.8488
13	.7783	1.0374	1.0562	1.0136	1.1128	1.0562	.9619
14	.8145	1.094	.6602	1.0317	1.0562	1.1128	.9808
15	.9496	1.0562	1.0374	1.0498	.9997	1.094	.9431
16	.8648	.8865	.9054	.8507	1.0185	.9997	.9808
17	.7783	.8676	.7167	.6697		.9808	.8676
18	.7421	.8488	.6979	.7421	.1509	.9431	.9054
19	.8316	.8865	.9619	.8779	1.094		.9054
20	1.1643	1.2637	1.2449	1.0974	1.3392	1.1128	1.1694
21	1.3491	1.4146	1.4712	1.2382	1.358	1.226	
22	1.4045	1.5278	1.6221	1.39	1.358	1.3769	1.3014
23	1.4784	1.5466	1.4712	1.3306	1.4523	1.3769	1.2637
24	1.4146	1.3306	1.5089	1.4523	1.3491	1.4335	1.3014
Max	1.4784	1.5466	1.6221	1.4523	1.4523	1.4335	1.3203
Min	.7421	.724	.6602	.6697	.1509	.8865	.7733
Avg	1.0166	1.0726	1.1348	1.0895	1.0790	1.1563	1.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 203 / 11 KV BELDONGRI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6024	.5281	.5658	.4508	.679	.4904
2	.5281	.567	.5658	.5281	.4508	.7167	.5093
3	.5093	.6878	.5658	.4527	.4835	.7167	.4715
4	.4715	.6626	.5281	.3772	.4784	.7356	.415
5	.4715	.7316	.5281	.3584	.3772	.8299	.3772
6	.5658	.6733	.4904	.3206	.4607	.7167	.3772
7	.6036	.6379	.3772	.3206	.3429	.6224	.3395
8	.6413	.8775	.4527	.2829	.3391	.7545	.3395
9	.9054	1.1317	.3772	.3772	.4115	.7922	.415
10	.9242	.8299	.4527	.3206	.5138	.8299	.5658
11	1.094	.7922	.415	.2743	.7733	.8488	.7545
12	.8676	.7545	.4904	.3086	.7167	.8488	.7167
13	1.2071	.7922	.5281	.3725	.8488		.7545
14	1.0562	.7167	.415	.4801	.6413	.7922	.6413
15	.8589	.7167	.4715	.4607	.4527	.6036	.5658
16	.7095	.6413	.4527	.3814	.4527	.5658	.5281
17	.4167	.5658	.415	.3856		.5658	.679
18	.3429	.5281	.3772	.4715	.415	.547	.679
19	.6219	.5281	.3395	.4481	.5658		.5658
20	.5792	.4904	.4715	.5658	.8488	.2829	.5658
21	.5853	.4904	.3772	.4904	.6036		.3584
22	.5544	.4527	.415	.415	.7167		.3395
23	.6415	.5658	.6036	.3856	.679	.415	.6602
24	.6036	.5721	.5658	.6224	.4115	.6413	.4904
Max	1.2071	1.1317	.6036	.6224	.8488	.8488	.7545
Min	.3429	.4527	.3395	.2743	.3391	.2829	.3395
Avg	.6802	.6670	.4668	.4153	.5406	.6752	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 205 / 11 KV Incomer I Nagardhan

Feeder KV- 11 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0814	2.2257	2.1502	1.9728	1.6975	1.6975
2		2.0452	2.2257	2.0559	1.9728	1.6787	1.6598
3		1.97	2.1502	1.9427	1.9366	1.6409	1.6787
4		1.9521	2.1125	1.7918	1.9004	1.6409	1.6409
5		1.9342	2.0936	1.6975	1.8625	1.6032	1.5466
6		1.4373	1.6787	1.4335	1.382	1.3769	1.2826
7		1.2226	1.3392	1.6787	1.2934	1.1128	1.226
8			1.3769		1.3112	1.1128	1.1883
9		1.3466	1.4523	1.4146	1.2795	1.1128	1.0751
10		1.4175	1.4901	1.5655	1.4529	1.1506	1.2071
11		.811	1.5844	1.4883	1.6032	1.1694	1.1128
12		1.773	1.6598	1.5581	1.6598	1.2449	1.2637
13		1.8673	1.8107	1.5947	1.7918	1.2826	1.4523
14		1.773	1.4523	1.6124	1.6975	1.3392	1.2071
15			1.7164	1.5415	1.6032	1.3203	1.5466
16		1.6409	1.6221	1.2048	1.5844	.9997	1.4712
17	1.182	1.3957	1.3203	1.0454		1.2449	1.2449
18	1.3432	1.5278	1.3014	1.1163	.1509	1.226	1.3957
19	1.4299	1.4901	1.5278	1.3253	1.094		1.4712
20	1.8088	2.0182	1.9239	1.6476	1.3392	1.4146	1.1694
21	1.9547	2.2068	2.4143	1.8642	1.358	1.226	
22	2.2081	2.3577	2.3765	2.0633	1.4335	1.8296	1.8673
23	2.2805	2.3388	2.2634	2.0271	1.6032	1.7918	1.8673
24		2.0774	2.2822	2.2068	1.9879	1.4335	1.7164
Max	2.2805	2.3577	2.4143	2.2068	1.9879	1.8296	1.8673
Min	1.182	.811	1.3014	1.0454	.1509	.9997	1.0751
Avg	1.7439	1.7584	1.8084	1.6533	1.5335	1.3761	1.4343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 206 / 11kv Incomer II Nagardhan

S/s Feeder KV- 11 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	.6024	.5281	.5658	.4508	.679	.4904
2	2.4143	.567	.5658	.5281	.4508	.7167	.5093
3	2.2445	.6878	.5658	.4527	.4835	.7167	.4715
4	2.0748	.6626	.5281	.3772	.3898	.7356	.415
5	1.9616	.7316	.5281	.3584	.443	.8299	.3772
6	1.9805	.6733	.4904	.3206	.4508	.7167	.3772
7	1.7918	.6379	.3772	.3206	.3429	.6224	.3395
8	1.9805	.8775	.4527	.2829	.3391	.7545	.3395
9	2.2445	1.1317	.3772	.3772	.4115	.7922	.415
10	2.3954	.8299	.4527	.3206	.547	.8299	.5658
11	2.5701	.7922	.415	.2743	.7733	.8488	.7545
12	2.384	.7545	.4904	.3086	.7167	.8488	.7167
13	2.6155	.7922	.5281	.3725	.8488	.7922	.7545
14	2.4326	.7167	.415	.4801	.6413	.7922	.6413
15	2.5766	.7167	.4715	.4607	.4527	.6036	.5658
16	2.4086	.6413	.4527	.3814	.4527	.5658	.5281
17	.4218	.5658	.415	.3856		.5658	.679
18	.3429	.5281	.3772	.4715	.415	.547	.679
19	.6219	.5281	.3395	.4481	.5658		.5658
20	.5792	.4904	.4715	.5658	.8488	.2829	.5658
21	.5853	.4904	.3772	.4904	.6036		.3584
22	.5544	.4527	.415	.415	.7167		.3395
23	.6415	.5658	.6036	.3856	.679	.415	.6602
24	2.8104	.5721	.5658	.6224	.4481	.6413	.4904
Max	2.8104	1.1317	.6036	.6224	.8488	.8488	.7545
Min	.3429	.4527	.3395	.2743	.3391	.2829	.3395
Avg	1.8031	.6670	.4668	.4153	.5422	.6808	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 202 / 11 KV Deolapar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.0164	1.1088	1.1431	1.0479	.9526	1.1088
2	1.1431	.924	1.1088	1.0479		.9145	1.1088
3	1.0479	1.0719	1.1088	.9526	1.0479	.9145	
4	1.0479	.924	1.1088	.8573	.9526	.9335	1.1088
5	.9526	.924	1.1088	.7621	.9526	.9335	1.0164
6	.8573	.924	.8316	.8573	.9526	.9526	.924
7	.7621	.924	.7392	.7621	.7621	.7621	.7392
8	.6668	.7762	.8316	.7621	.7621	.7621	
9	.7621	.924	.924	.7621	.5716	.7621	
10	.7392	.8316	.7762	.7621	.7621	.7621	
11	.8316	1.1088	.9526	.7621	.7621	.7392	.2286
12	.8316	.924	.9526	.8573	.8002	.7392	.9526
13	.924	.924	1.0098	.9526	.9526	.7762	.9526
14	.924	.924	.9526	.9526	.8954	.7392	.9526
15	.924	.924	.9526	.9526	.8573	.6468	.9526
16	.7392	.7392	.7621		.7621	.7392	.8573
17	.7392	.7392	.7621	.0953	.7621	.7392	.7621
18	.8316	.8316	.7621	.0953	.6668		.381
19	.924	1.1088	.9526	.9526	.9526		.8573
20	1.2012	1.2936	1.3336	1.3336	1.1431	1.2012	1.3336
21	1.2936	1.386	1.3336	1.3336	1.1431	1.2936	
22	1.2936	1.2936	1.3336	1.1431	1.2384	1.2936	
23			1.2384	1.1431	1.1431		1.2384
24	1.2384	1.1088	1.2012	1.1431	1.0479	1.1431	1.1088
Max	1.2936	1.386	1.3336	1.3336	1.2384	1.2936	1.3336
Min	.6668	.7392	.7392	.0953	.5716	.6468	.2286
Avg	.9486	.9802	1.0061	.8863	.9104	.8905	.9213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 203 / 11 KV TOTALADOH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0924	.1109	.0953	.0953	.1143	.1294
2	.0953	.0924	.1109	.0953	.0953	.1143	.1294
3	.0953	.0924	.1109	.0953	.0953	.1143	.1294
4	.0953	.0924	.1109	.0953	.0953	.1143	.1294
5	.0953	.0924	.1478	.0953	.0953	.1143	.1294
6	.0953	.1478	.1478	.0762	.0572	.1143	.1294
7	.0953	.1478	.1109		.0762	.0953	.1294
8	.0762	.1109	.1109	.0762	.0762	.0953	.1294
9	.0762	.0924	.1109	.0762	.0762	.0953	.8871
10	.0924	.1109	.1109	.0762	.0953	.0762	1.0479
11	.0924	.1109	.0953	.0953	.0953	.0924	.1143
12	.0924	.0924	.0953	.0953	.0762	.0739	.1143
13	.1109	.0924	.0953	.0953	.0762	.1294	.1334
14	.0924	.1109	.0953	.0953	.0762	.1109	.1334
15	.0924	.0924	.1143	.0953	.0762	.0924	.1334
16	.0924	.1109	.1143		.0762	.1109	.1143
17	.0924	.0924	.0953	.0953	.0762	.0924	.1143
18	.1294	.1109	.0762	.0762	.0762		.1143
19	.1109	.1294	.0762	.0953	.1334		.1524
20	.1478	.1294	.1143	.1143	.1524	.1294	.1524
21	.1478	.1294	.1143	.1143	.1524	.1478	
22	.1478	.1478	.1143	.1143	.1334	.1478	
23			.0953	.0953	.1143		.0953
24	.0953	.0924	.1294	.0953	.0953	.1143	.1294
Max	.1478	.1478	.1478	.1143	.1524	.1478	1.0479
Min	.0762	.0924	.0762	.0762	.0572	.0739	.0953
Avg	.1024	.1093	.1087	.0936	.0945	.1090	.2032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 204 / 11 KV Ambazari AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0185	.037	.0381	.0381	.0381	.037
2	.0381	.0185	.037	.0381	.0381	.0381	.0185
3	.0381	.0185	.037	.0381	.0381	.0381	.0185
4	.0381	.0185	.037	.0381	.0381	.0381	.0185
5	.0381	.0185	.037	.0381	.0381	.0381	.0185
6	.0381	.0185	.037	.0381	.0381	.0381	.0185
7	.0381	.037	.037	.0381	.0381	.0191	.0185
8	.0381	.037	.037	.0381	.0381	.0191	.0185
9	.0381	.037	.037	.0381	.0381	.0381	.0185
10	.0185	.037	.037	.0381	.0381	.0381	.0381
11	.0185	.037	.0381	.0381	.0381	.037	.0381
12	.0185	.037	.0381	.0381	.0381	.037	.0381
13	.0185	.037	.0381	.0572	.0381	.037	.0381
14	.0185	.037	.0381	.0762	.0381	.037	.0381
15	.0185	.037	.0381	.0762	.0381	.037	.0381
16	.0185	.037	.0381		.0191	.037	.0381
17	.037	.037	.0381	.0381	.0191	.037	.0381
18	.0554	.037	.0381	.0381	.0191		.0381
19	.0554	.037	.0381	.0381	.0381		.0381
20	.037	.037	.0381	.0381	.0381	.037	.0381
21	.037	.037	.0381	.0381	.0381	.037	
22	.037	.037	.0381	.0381	.0381		
23				.0381	.0381		
24	.0381	.037	.037	.0381	.0381	.0381	
Max	.0554	.037	.0381	.0762	.0381	.0381	.0381
Min	.0185	.0185	.037	.0381	.0191	.0191	.0185
Avg	.0334	.0322	.0376	.0422	.0357	.0357	.0302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 205 / 11 KV Incomer I Pauni

S/Stn Feeder KV- 11 /

INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2765	1.1273	1.2567	1.2765	1.2765	1.1431	1.2567
2	1.2765	1.0349	1.2567	1.1812	1.1812	1.1431	1.2567
3	1.1812	1.0349	1.2567	1.086	1.1812	1.1431	1.2567
4	1.1812	1.0349	1.2567	.9907	1.086	1.1431	1.2567
5	1.086	1.0349	1.2936	.8954	1.086	1.1431	1.1643
6	.9907	1.1088	1.0164	.9717	1.086	1.1431	1.0719
7	.8954	1.1088	.8871	.8954	.8764	.8573	.8871
8		.924	.9795	.8764	.8764	.9145	.1478
9	.8764	1.0534	1.0719	.8764	.6859	.8954	.9055
10	.8501	.9795	.924	.8764	.8954	.8764	.7621
11	.9425	1.2567	1.086	.8954	.8954	.8686	.381
12	.9425	1.0534	1.086	1.0098	.9145	.8501	1.1241
13	1.0534	1.0534	1.1431	1.1241	1.0669	.9425	1.1431
14	1.0349	1.0534	1.086	1.1241	.8954	.8871	1.1431
15	1.0349	1.0164	1.086	1.105	.8573	.7762	1.1431
16	.8501	.8871	.9145		.8764	.8871	1.0098
17	.8501	.8686	.8954	.2286	.8573	.9055	.9145
18	.9795	.961	.8764	.7811	.7621		.5335
19	1.0903	1.2752	1.0669	1.086	1.1241		1.0479
20	1.3676	1.46	1.4861	1.4861	1.3336	1.3676	1.5242
21	1.4784	1.5524	1.4861	1.4861	1.3336	1.4784	
22	1.4784	1.4784	1.4861	1.2955	1.4098	1.4784	
23			1.3717	1.2765	1.1431		1.3717
24	1.3717	1.2382	1.3676	1.2765	1.2765	1.3146	1.2752
Max	1.4784	1.5524	1.4861	1.4861	1.4098	1.4784	1.5242
Min	.8501	.8686	.8764	.2286	.6859	.7762	.1478
Avg	1.0949	1.1129	1.1516	1.0479	1.0407	1.0552	1.0262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164003 / 33/11 KV PAONI SUBSTATION

Feeder No / Name : 206 / 11 KV Standby Feeder Pauni SINGLE PHASING

I Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	1.848	2.3101	1.3336	1.1431	1.2384	1.6632
2	1.7528	1.6632	2.1253	1.3717	1.105	1.2384	1.5708
3	1.6194	1.6632	2.1253	1.2955	1.0479	1.2384	1.5708
4	1.5242	1.4784	2.1253	1.2384	1.0098	1.2384	1.4784
5	1.4289	1.4784	1.848	1.1431	.9526	1.2384	1.4784
6	1.3336	1.4784	1.6448	1.0479	.9907	1.0098	1.4784
7	1.1431	1.46	1.4969	1.4289	1.4098	1.3908	1.2382
8	1.1431	.9795	.9425	1.4289	1.3717	1.3336	.924
9	1.2384	.9795	1.1643	1.467	1.2765	1.3336	.9795
10	1.2197	1.1273	1.0903	1.448	1.4289	1.2003	1.0288
11	1.3306	1.1088	1.0479	1.5242	1.4289	1.3676	1.105
12	1.3121	1.1458	1.0098	1.5623	1.3908	1.423	1.1431
13	1.2567	1.1643	1.0098	1.5623	1.467	1.4415	1.1431
14	1.2382	1.1088	1.0098	1.5623	1.4861	1.4784	1.0288
15	1.1088	1.0164	.9335	1.5242	1.448	1.4784	1.0288
16	1.0903	1.386	1.3717		.8573	1.4045	1.4098
17	1.1088	1.4045	1.4098	1.1241	1.0669	1.1088	1.3336
18	1.1088	1.3491	1.3336	1.3336	1.1622		1.3336
19	1.885	2.0328	1.9433	2.2862	1.8099		1.8861
20	2.5873	2.6797	2.5911	2.4006	2.572	1.848	2.4768
21	2.6797	2.6981	1.5242	1.3336	1.448		
22	2.4394	2.5503	1.467	1.2955	1.467	1.7556	
23			1.4289	1.2384	1.3146		2.0195
24	1.848	2.3101	2.4025	1.4289	1.1812	1.2574	1.6632
Max	2.6797	2.6981	2.5911	2.4006	2.572	1.848	2.4768
Min	1.0903	.9795	.9335	1.0479	.8573	1.0098	.924
Avg	1.5307	1.5700	1.5565	1.4513	1.3265	1.3512	1.4083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 201 / Ramtek I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.0669	1.105		1.0288	1.105	1.0669
2	.9907	1.0479	1.105		.9526	1.105	1.0288
3	.9526	.9526	1.0479		.9145	1.0479	.9907
4	.8954	.8573	1.0479		.9145	1.0479	.9907
5	.8383	.8764	.9526		.8764	.9907	.9526
6	.8002	.8573	.8573	.8573	.8192	.8573	.9145
7	.7811	.8002	.7621	.7811		.7621	.8573
8	.724	.724	.6859			.7049	.7621
9	.7049	.6668	.6668	.8192		.6478	.724
10	.8192	.7049	.6668	.8002		.8002	
11	.8002	.8573	.8192	.8954	1.3527	.8954	.9526
12	.8002	.8764	.9145	.8383	1.1241	.9717	1.1431
13	.9145	.9526	.9717	1.0479	1.1431	1.0098	1.105
14	.9907	1.0098	1.0288	1.0479	1.1431	1.0288	1.0669
15	1.086	.9717	1.0098	1.0669	1.1431	1.0098	1.0288
16	1.0288	.9526	.9717	.9335	1.1431	1.0669	1.0098
17	.9526	.8383		.8192	.9907	.9907	.9526
18	.8764	.8383		.8192	.8764	.8383	.8954
19	1.105	.9145	.9526	.9145	.9526		
20	1.0288	1.086		.9526	1.0669	.7621	
21	1.105	1.086		.9907	1.0669	.4572	
22	1.105	1.1622		1.086	1.1431	.4001	
23	1.2003	1.1812		1.105	1.2193		
24	1.1241	1.1431	1.1431	1.1812	1.086	1.1431	1.105
Max	1.2003	1.1812	1.1431	1.1812	1.3527	1.1431	1.1431
Min	.7049	.6668	.6668	.7811	.8192	.4001	.724
Avg	.9447	.9343	.9283	.9420	1.0479	.8929	.9748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 202 / Ramtek II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1905	.1715		.1334	.1715	.1143
2	.1334	.1715	.1715		.1334	.1715	.1143
3	.1334	.1905	.1715		.1334	.1905	.1143
4	.1143	.1905	.1524		.0953	.1905	.0762
5	.1143	.1905	.1524		.0953	.2096	.0762
6	.1143	.1715	.1524	.1905	.0953	.2096	.0762
7	.0953	.1905	.0953	.1334	.1334	.1715	.1715
8	.1715	.1334	.1143		.1143	.1715	.1905
9	.2096	.1905	.1905	.1334	.0953	.1715	.1715
10	.3239	.2286	.3048	.2477	.2286	.2858	
11	.3429	.2858	.2667	.2096	.362	.3429	2.0957
12	.2858	.2858	.2667	.2667	.3429		.1143
13	.2858	.2858	.2667	.2477	.362	.3048	.1524
14	.2477	.2858	.2667	.3048	.362	.3239	.1905
15	.3429	.3429	.2286	.1524	.2858	.2667	.2286
16	.2096	.3429	.2667		.2286	.2477	.2477
17	.1905	.1905		.1334	.2858	.1715	.2286
18	.1905	.0953		.0762	.1143	.1524	.1905
19	.2286	.1715	.2286	.1334	.1334		
20	.0953	.1143			.1334	.1334	
21	.1334	.0953		.1334	.1905	.0762	
22	.1334	.1334		.1715	.0953	.1905	
23	.1334	.1334		.1715	.1524	.0762	
24	.1334	.1715	.1715	.2096	.1334	.1524	.1143
Max	.3429	.3429	.3048	.3048	.362	.3429	2.0957
Min	.0953	.0953	.0953	.0762	.0953	.0762	.0762
Avg	.1874	.1993	.2022	.1822	.1850	.1992	.2593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 204 / BORI SINGLE PHASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.1431		.9145	.9526	.2477
2	1.105	1.1812	1.1431		.9145	.9526	.2477
3	1.0288	1.105	1.0479		.8764	.9145	.2286
4	.9526	1.0479	1.0479		.8383	.9145	.2286
5	.8764	.9526	.9526		.8002	.8573	.1715
6	.8192	.9145	.8573	.7621	.743	.8002	.1715
7	.6668	.8573	.8002	.6478	.724	.7049	.1524
8	.5906	.5716	.6668		.6668	.6478	.1524
9	.6287	.6097	.7049	.5144	.7049	.6478	.1524
10	.5525	.6668	.7049	.4572	.6478	.7621	
11	.5716	.724	.724	.6668		.7811	.1143
12	.743	.8192	.7621	.6668	.9145	.8573	
13	.724	.8383	.743	.6478	.9145	.9145	
14	.6668	.8383	.7621	.6478	.9145	.8764	
15	.6668	.8002	.743	.2096	.8954	.8764	.0762
16	.5144	.724	.3048	.4763	.8383	.8002	.0762
17	.5335	.743		.5144		.7811	.1905
18	.5716	.7621		.6287	.5525		.5716
19	.9526	.8764	.9145	.8573	.8002		
20	1.2955	1.3336		1.2193	1.1812		
21	1.4098	1.3336		1.0479	1.0288		
22	1.3717	1.3717		1.0479	1.0669		
23	1.2765	1.3336		.9526	1.0288	.1715	
24	1.2003	1.2193	1.2193	1.2193	.9335	.9717	.2477
Max	1.4098	1.3717	1.2193	1.2193	1.1812	.9717	.5716
Min	.5144	.5716	.3048	.2096	.5525	.1715	.0762
Avg	.8692	.9486	.8468	.7324	.8591	.7992	.2020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 205 / 11 KV RAMTALAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.5242	1.5242		1.5242	1.5242	1.448
2	1.4861	1.4289	1.5242		1.448	1.5242	1.4098
3	1.4098	1.3908	1.4289		1.4098	1.4861	1.3336
4	1.3336	1.3336	1.4289		1.3336	1.4861	1.8099
5	1.2384	1.2384	1.3336		1.2574	.4763	1.2193
6	1.1812	1.2765	1.2384	1.2574	1.2574	1.2955	1.2193
7	1.1622	1.1812	1.1812	1.2193	1.1622	1.086	1.105
8	1.0288	1.0479	1.0098		1.105	1.0288	1.0098
9	.9335	1.0098	.8954		1.0288	1.0098	.9717
10	.9717	.9907	.9526	.5144	.9907	.9717	
11	1.0479	1.0479	1.105	1.3527	1.086	1.1812	1.0479
12	1.1431	1.1812	1.1241	1.2955	1.1812	1.3146	1.1241
13	1.1812	1.2384	1.2384	1.3527	1.2193	1.3146	1.1622
14	1.1241	1.2384	1.3146	1.3146	1.2384	1.3527	1.2384
15	1.1431	1.2384	1.3336	1.4289	1.3336	1.3908	1.2955
16	1.1431	.8573	1.2574	1.105	1.3717	1.3146	1.3336
17	1.0479	1.2574		.9717	1.1431	1.2193	1.2384
18	.8954	1.1431		.9907	1.0479	1.0098	1.1812
19	1.1431	1.2193	1.1812	1.1431	1.1241		
20	1.4861	1.4098		1.2955	1.3908	1.1431	
21	1.5432	1.448		1.3717	1.3908	1.467	
22	1.6194	1.6194		1.5051	1.5242	1.4098	
23	1.6385	1.6766		1.5813	1.6766	1.467	
24	1.6385	1.6004	1.6194	1.7147	1.5813	1.6004	1.5051
Max	1.6385	1.6766	1.6194	1.7147	1.6766	1.6004	1.8099
Min	.8954	.8573	.8954	.5144	.9907	.4763	.9717
Avg	1.2543	1.2749	1.2606	1.2597	1.2844	1.2641	1.2585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 206 / 11 KV Musewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18
HR	Load (MW)
16	.4763
19	.8573
Max	.8573
Min	.4763
Avg	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 400 / 33 KV Ramtek Transformer I

Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435	2.8006		2.6863	2.8006	2.6292
2	2.6292	2.6292	2.8006		2.5149	2.8006	2.572
3	2.5149	2.5149	2.6863		2.4577	2.7435	2.4577
4	2.3434	2.3434	2.6292		2.3434	2.7435	2.3434
5	2.1719	2.2862	2.4577		2.2291	2.6292	2.2291
6	2.1148	2.2862	2.2291	2.2862	2.1719	2.3434	2.2291
7	2.0576	2.1719	2.0576	.6287		2.0005	2.1148
8	1.9433	1.8861	1.829		1.2003		1.9433
9	1.829	1.829	1.7718	1.4861	1.1431		1.8861
10	2.1148	1.8861	1.9433	1.5432	1.2003	2.0576	
11	2.1719	2.1719	2.1719	2.4577	2.8006	2.4006	2.1719
12	2.2291	2.3434	2.2862	2.4006	2.6292	2.572	2.3434
13	2.2862	2.4577	2.4577	2.6292	2.7435	2.6292	2.4006
14	2.3434	2.5149	2.6292	2.6863	2.7435	2.6863	2.4577
15	2.572	2.572	2.572	2.6292	2.7435	2.6863	2.5149
16	2.3434	2.5149	2.1148	2.2862	2.7435	2.6292	2.572
17	2.1719	2.2862		1.9433	2.4006	2.4006	2.3434
18	1.9433	2.0576		1.8861	2.0576	2.0005	2.2291
19	2.4577	2.2862	2.1719	2.1719	2.2291		
20	2.6292	2.6292		2.4006	2.8006	2.0576	
21	2.8006	2.6292		2.5149	2.6292	2.0005	
22	2.8578	2.915		2.7435	2.7435	2.0005	
23	2.9721	2.9721		2.8578	3.0293	1.5432	
24	2.915	2.915	2.915	3.0864	2.8006	2.915	2.7435
Max	2.9721	2.9721	2.915	3.0864	3.0293	2.915	2.7435
Min	1.829	1.829	1.7718	.6287	1.1431	1.5432	1.8861
Avg	2.3815	2.4101	2.3624	2.2577	2.3931	2.4114	2.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164042 / 33 KV Ramtek

Feeder No / Name : 401 / 33 KV Ramtek Transformer

II Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.1431		.9145	.9717	.2286
2	1.086	1.1431	1.1431		.9145	.9717	.2286
3	1.0288	1.086	1.0288		.8573	.9145	.2286
4	.9717	1.0288	1.0288		.8573	.9145	.2286
5	.8573	.9145	.9717		.8002	.8573	.1715
6	.8002	.9145	.8573	.743	.743	.8002	.1715
7	.6859	.8573	.8002	.6287	.743	.6859	.1715
8	.5716	.5716	.6859		.6859	.6287	.1715
9	.6287	.5716	.6859	.5144	.6859		.1715
10	.5716	.6287	.6859	.4572	.6287	.743	
11	.5716	.743	.743	.6859	.8002	.8002	.1143
12	.743	.8002	.743	.6859	.9145	.8573	
13	.6859	.8573	.743	.6287		.9145	
14	.6287	.8573	.743	.6287	.9145	.8573	
15	.6287	.8002	.743	.2286	.9145	.8573	.0572
16	.5144	.743	.2858	.4572	.8573	.8002	.0572
17	.5144	.743		.5144		.8002	.1715
18	.5716	.743		.6287	.5144		.5716
19	.9717	.8573	.9145	.8573	.8002		
20	1.3146	1.3146		1.2003	1.2003		
21	1.4289	1.3146		1.0288	1.0288		
22	1.3717	1.3717		1.0288	1.086		
23	1.2574	1.3146		.9717	1.0288	.1715	
24	1.2003	1.2003	1.2003	1.2003	.9145	.9717	.2286
Max	1.4289	1.3717	1.2003	1.2003	1.2003	.9717	.5716
Min	.5144	.5716	.2858	.2286	.5144	.1715	.0572
Avg	.8645	.9383	.8415	.7271	.8547	.8065	.1982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 202 / 11 KV Moil

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18
HR	Load (MW)
24	.3921
Max	.3921
Min	.3921
Avg	.3921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 203 / 11 KV DEOLAPAR KANDRI
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18
HR	Load (MW)
24	.6962
Max	.6962
Min	.6962
Avg	.6962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 204 / 11 KV Ramtek U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18
HR	Load (MW)
24	1.4083
Max	1.4083
Min	1.4083
Avg	1.4083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 205 / 11 KV MANSAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18
HR	Load (MW)
24	.8402
Max	.8402
Min	.8402
Avg	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164071 / 33 KV Khat S/Stn

Feeder No / Name : 201 / 11 KV KHAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641	1.1765	1.267	1.1568	1.1919	.9231	1.3032
2	1.1104	1.1584	1.2308	1.1218	1.1568	.905	1.267
3	1.0745	1.1584	1.1946	1.0867	1.1218	.8688	1.267
4	1.2178	1.086	1.1765	1.0517	1.0867	.8326	1.2308
5	1.1104	1.0498	1.1403	1.0517	1.0517	.8145	1.1946
6	.985	1.0136	1.0136	1.0341	1.0166	.7783	1.1222
7	.8417	.9412	.8688	.9465	.964	.7602	.9412
8	.8775	1.0136	1.0136	.7888	1.0341	.6697	.8688
9	.9671	1.0317	.9774	.8413	1.1218	.724	1.0136
10	.7783	1.0317	1.0341	.8413	1.1403	.7783	1.0317
11	.8507	1.1584	1.0867	1.0517	1.1584	.8507	1.0341
12	1.0498	1.1765	1.0867	1.0517	1.267	.8507	.8063
13	1.086	1.3032	1.262	.9816	1.267	.905	.8589
14	1.1946	1.2851	1.2269	.8063	1.2489	.9412	.8589
15	1.1765	1.2127	1.1393	.7888	1.267	.9593	.8939
16	1.0136	1.1765	.964	.5434	1.1946	.8869	.8413
17	.9774	1.2308	.9465		.6516	.2353	.7888
18	1.0136	1.0498	.9816	.4733	.5973	.2896	.8413
19	1.0498	1.1946	.9991	.929	.6878	.7964	.8238
20	1.1222	1.3213	1.1744	1.0166	.9774	.8145	1.0517
21	1.2489	1.3756	1.2269	1.0517	.9593	.9412	
22	1.2851	1.4299	1.262	1.2269	1.0498	1.0498	
23	1.2851	1.3756	1.2269	1.2971	1.0136	1.3937	
24	1.182	1.1946	1.2851	1.2269	1.1919	.9774	1.3394
Max	1.2851	1.4299	1.2851	1.2971	1.267	1.3937	1.3394
Min	.7783	.9412	.8688	.4733	.5973	.2353	.7888
Avg	1.0693	1.1727	1.1160	.9724	1.0591	.8311	1.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 202 / 11 KV NAXI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3429	.815	1.0402	1.1488	.905	.3258	.3086
9		.9431	1.2197	1.2003	1.0631	.3982	.3772
10		1.2003	.9214	1.283	1.0288	.4801	.4887
11		1.2003	.9134	1.3169	1.0631	.5144	.4706
12		1.2003	1.2403	1.2803	.9945	.5144	.6268
13	.8149	1.0288	1.1517	1.1888	.9602	.5144	.5973
14			1.1517	.9145	.9259	.4801	.6268
15		.6859	.985	1.0059	.0857	.4801	.6626
16	.5028						
17	.7442						
18	.7442				.5304		
19					.4755		
20				.8145	.5121		
21					.5121		
22					.543		
23					.5068		
Max	.8149	1.2003	1.2403	1.3169	1.0631	.5144	.6626
Min	.3429	.6859	.9134	.8145	.0857	.3258	.3086
Avg	.6298	1.0105	1.0779	1.1281	.7219	.4634	.5198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 203 / 11 KV PULLAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.5601	.6802	.6859		.3563	
2	.4534	.5144	.6802	.6706		.3563	
3	.4534	.4854	.6802	.6706		.3563	
4	.421	.4854	.6802	.6097		.3563	
5	.3887	.4458	.6802	.6097		.3563	
6	.3401	.3978	.6478	.5335		.3563	
7	.3887	.4534	.583	.6249		.3887	
8	.4096	.5851	.7611	.7316		.421	.9878
9	.4696	.5898	.8097	.823		.5992	1.1174
10	.5668	.7537	.8421	.8951		.703	1.1984
11	.5668	.8192	.9069	.9686	.1943	.7499	1.2631
12	.5182	.7865	.9339	1.0467	.4858	.7499	1.2323
13	.5506	.7682	.8907	.8749	.502	.7343	1.1203
14	.4858	.3841	.8583	.9374	.5182	.703	1.2308
15	.5182	.8356	.9602	.8025	.5182	.6718	
16	.5182	.8322	.9945	.9259	.583		
17	.5506	.8173	.9945	1.0364	.4534		
18	.5506	.8025	1.0288		.3239		
19	.5093	.7042	.9088	.3258	.3401		
20	.6133	.6895	.8916	.4115	.3725		
21	.6344	.7362	.8745	.4458	.421		
22	.583	.7042	.823	.4287	.4049		
23	.5487	.6802	.7888		.3887		
24	.4696	.5316	.6802	.6859		.3563	
Max	.6344	.8356	1.0288	1.0467	.583	.7499	1.2631
Min	.3401	.3841	.583	.3258	.1943	.3563	.9878
Avg	.4984	.6401	.8158	.7157	.4235	.5134	1.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 204 / 11 KV KARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	1.1458	1.2384	1.2384	1.1088	.9526	.8192
2	.7865	1.1458	1.2384	1.2384	1.0534	.9526	.8192
3	.7865	1.1088	1.2384	1.2384	1.0534	.9526	.7865
4	.6882	1.0164	1.1431	1.1431	1.0164	.9526	.6882
5	.6554	.924	.9526	.9526	.9335	.7621	.6554
6	.6226	.6722	.7621	.6668	.6722	.6859	.5898
7	.3932	.6161	.5144	.5144	.4668	.5716	.426
8	.5898	1.0745	1.4289	1.4937	1.3146	.9526	.6554
9	.7537	1.267	1.5242	1.6804	1.3717	1.086	.7865
10	.9526	1.4327		1.8099	1.3435	1.1431	1.2003
11	1.0479	1.3927	.6516	1.8099	1.3108	1.1431	1.2346
12		1.3108	1.4022	1.7718	1.3763	1.1431	1.2003
13	1.2765	1.448	1.6289	1.7147	1.278	.9526	1.2003
14	1.3336	1.4746	1.6289	1.7147	***		1.2656
15	1.1431	1.448	1.5432	1.7147	1.0442	1.0098	1.2517
16	.9526	.5716	.6722	.5716	.5898	.4588	.6722
17	.8596	.5716	.6668	.2801		.5898	
18	.9671	.5144	.7621	.6335		.7209	.7621
19	.7282	.6668	1.1431	.724		.7865	.9526
20	1.1888	1.2574	1.2384	.9412		.8192	1.0479
21	1.1088	1.3146	1.2384	1.1888		.852	1.1431
22	1.2012	1.3146	1.3146	1.1888		.8192	1.2384
23	1.2012	1.2384	1.3146	1.1643	.9145	.8192	1.1431
24	.8192	1.2012	1.2384	1.2384	1.1088	.9907	.8192
Max	1.3336	1.4746	1.6289	1.8099	12.5507	1.1431	1.2656
Min	.3932	.5144	.5144	.2801	.4668	.4588	.426
Avg	.9062	1.0887	1.1515	1.1930	1.6949	.8746	.9286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 205 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191	.0191	.0191	.1991	.1991	.1886
2	.0171	.0191	.0191	.0191	.2012		.1886
3	.0171	.0191	.0191	.0191	.2012		.1715
4	.0171	.0191	.0191	.0191	.2012		.1715
5	.0171	.0191	.0191	.0191	.2012		.1715
6	.0171	.0191	.0191	.0191	.1991		.2229
7	.0171	.0191	.0191	.0191	.0191		.0171
8	.1372	.2172	.2172	.0191	.0191		.2401
9	.1029	.2172	.2172	.0191	.0191		.3258
10	.1267	.2534		.0191	.0171		.3641
11	.1629	.2715		.0191			.4207
12	.181	.2896	.2149	.0191			.4031
13	.1991	.2926	.2835	.0191		.2534	.3544
14	.2172	.2896	.298	.0191		.181	.3544
15	.2172	.2896		.0191		.2353	.3506
16	.0181	.0191		.0191		.2058	.0191
17	.0191			.0191		.2058	
18	.0191		.0191		.0191	.2229	.0191
19	.0191	.0191	.0191		.0191	.2229	.0191
20	.0191	.0191	.0191	.1463	.0191	.2229	.0191
21	.0191		.0191	.1646	.181	.2401	.0191
22	.0191	.0191	.0191	.1829	.181	.2229	.0191
23	.0191	.0191	.0191	.1991	.181	.2229	
24	.0171	.0191		.0191	.1991	.1991	.1886
Max	.2172	.2926	.298	.1991	.2012	.2534	.4207
Min	.0171	.0191	.0191	.0191	.0171	.181	.0171
Avg	.0680	.1128	.0822	.0471	.1222	.2180	.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 206 / 11 KV BHIWAPUR BUS STAND SHEDDABLE URBAN
FEEDE Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6099	.6154	.6268	.6036	.5973	.5973
2	.5792	.6099	.6154	.6268	.5853	.5973	.5973
3	.543	.5914	.6154	.6268	.5914	.5973	.5792
4	.5068	.5914	.543	.6447	.5544	.543	.543
5	.4706	.5544	.4525	.6447	.5544	.543	.5068
6	.4163	.4207	.3982	.6268	.4163	.4525	.4706
7	.3258	.3366	.3439	.4477	.362	.3801	.362
8	.3439	.3366	.3077	.3403	.3366	.362	.362
9	.3439	.3403	.3439	.3761	.3224	.3801	.3582
10	.4163	.394	.3982	.394	.4163	.439	.4163
11	.5068	.4119	.4163	.5194	.4163	.5304	.5068
12	.4887	.4344	.4656	.5121	.4887	.5304	.5316
13	.5068	.4656	.4887	.5304	.543	.567	.543
14	.543	.5014	.5249	.567	.543	.5068	.5792
15	.543	.4706	.5014	.5359	.5611	.4706	.5373
16	.5068	.4298	.4525	.5544	.5068	.4525	.5068
17	.4656	.4298	.4298	.4887	.3801	.2686	
18	.4706	.4119	.4298	.3801	.3801	.4344	.5068
19	.4706	.4681	.4298	.4525	.4163	.4344	.5249
20	.5853	.5375	.5373	.5544	.5249	.4525	.5249
21	.6219	.6219	.591	.5914	.5792	.5973	.6154
22	.6036	.6767	.6447	.6283	.6335	.6154	.6697
23	.6401	.6516	.6447	.6154	.6154	.6335	.6154
24	.5973	.6283	.6154	.6268	.6036	.5973	.6154
Max	.6401	.6767	.6447	.6447	.6335	.6335	.6697
Min	.3258	.3366	.3077	.3403	.3224	.2686	.3582
Avg	.5031	.4969	.4919	.5380	.4973	.4993	.5248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 207 / 11 KV BHIMADEVI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.4024	.3982	.362	.3658	.362	.3582
2	.3224	.4024	.3982	.362	.3511	.362	.3582
3	.3224	.4066	.3982	.362	.3511	.362	.3224
4	.3224	.3696	.362	.362	.3326	.362	.3224
5	.2865	.3511	.3258	.3258	.3224	.3258	.3045
6	.2328	.2896	.2715	.2715	.2534	.2715	.2507
7	.1791	.2507	.2172	.2172	.1949	.2172	.2328
8		.2328	.181	.197	.2303	.2353	.2328
9	.2149	.2507	.2172	.2507	.2303	.2172	.2507
10	.2353	.2507	.2328	.2534	.2328	.2534	.2686
11	.2534	.2328	.2303	.2896	.2686	.2896	.2686
12	.3258	.2686	.2835	.3045	.2865	.2896	.2865
13	.3258	.3077	.3155	.3224		.3258	.3403
14	.3258	.3258	.3045	.3582	.3582	.3077	.3189
15	.3439	.3258	.3189	.3761	.3582	.2896	.3582
16	.362	.3258	.3045	.3582	.3224	.2865	.3403
17	.3366	.3012	.2865	.3045	.2172	.2686	
18	.2865	.2835	.2715	.2534	.2534	.2865	.3077
19	.3045	.3189	.3077	.3077	.2534	.2865	.3077
20	.4163	.3544	.362	.3696	.3439	.3224	.362
21	.3982	.3658	.3982	.3326	.3439	.3403	.362
22	.4024	.4207	.4163	.3696	.362	.3582	.362
23	.4207	.4163	.394	.3658	.3801	.3761	.3801
24	.3582	.4207	.3982	.3982	.3658	.3801	.3761
Max	.4207	.4207	.4163	.3982	.3801	.3801	.3801
Min	.1791	.2328	.181	.197	.1949	.2172	.2328
Avg	.3189	.3281	.3164	.3198	.3034	.3073	.3162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 201 / JAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9907	.9907	.9145	1.0098	1.5623	1.3336
2	.9145	.9335	.9907	.8573	.9907	1.5623	1.2384
3		.8954	.9717	.8954	.9526	1.5432	1.1812
4	.8764	.8573	.9526	.8573	.9717	1.5432	1.1812
5	.8573	.8383	.9145	.8764	.9335	1.5242	.8573
6	.5716	.6287	.5716	.5525	.6287	.9526	.8002
7	.4191	.4954	.4191	.4001	.4382	.8002	.724
8	.4557	.9391	1.2346	1.4098	1.258	1.0166	1.166
9	.5434	.7796	1.3523	1.3203	1.4022	1.1218	1.2346
10	.5609	.8916	1.0749	1.286	1.4723	1.1218	1.2517
11	.7545	1.134	1.1241	.7888	1.4373	1.1393	1.2136
12	.6516	1.3032	.9907	.9221	1.4864	.6836	1.1393
13	.7011	1.3146	1.335	1.2071	1.5684	1.1393	1.1963
14	.9431	1.3253	1.2309	1.278	1.531	.9816	1.3032
15	.9774	1.3169	1.1096	1.2452	1.4327	.6135	1.2517
16	1.1431	.9907	1.3003	1.1961	1.3908	.6859	1.2955
17	1.1241	1.2384	1.0288	1.2003		.7621	.9709
18	1.0669	1.1812	1.086	.9717		.8573	1.0288
19	.5906	.5525	1.1431	.6668	.7522	.9717	1.0098
20	.9526	.9145	.8954	.9526	.8417	1.5432	1.4861
21	.9145	1.0479	1.086	1.0288	.8413	1.7718	1.7528
22	.9335	1.0479	1.1431	1.086	.8589	1.7147	1.7147
23	.8764	1.0288	1.0288	1.0669	1.5813	1.6385	1.7147
24	.9907	.9526	1.0288	.9526	1.0288	1.5813	1.4289
Max	1.1431	1.3253	1.3523	1.4098	1.5813	1.7718	1.7528
Min	.4191	.4954	.4191	.4001	.4382	.6135	.724
Avg	.8170	.9833	1.0418	.9972	1.1277	1.2013	1.2281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 202 / TATOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2126					
5		.1949					
8	.2149		.703	.4572	.567		.1254
9	.2865		.7282	.8059	.7265		.181
10	.4031	.7133	.7455	.7716			.1791
11	.4458	.7522	.7628	.6859	.7628	.1753	.1949
12	.463	.7865	.7802	.7545	.7522	.2103	.2629
13	.4557	.703	.7455	.7545	.7888	.2279	.2454
14	.4801	.7682	.7455	.7209	.7701	.1928	.2629
15	.4458	.7712	.7455	.7045	.7545	.1753	.2454
16				.6882			
17			.7455				
18			.8002				
19			.7621		.1254		
21					.333		
22					.2629		
Max	.4801	.7865	.8002	.8059	.7888	.2279	.2629
Min	.2149	.1949	.703	.4572	.1254	.1753	.1254
Avg	.3994	.6127	.7513	.7048	.5843	.1963	.2121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 203 / 11 KV PAHAMI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5316					
5		.5316					
8	.4207	.6201	.7011	.567	.6379	.8063	.7712
9	.5609	.7265	.7628	.5609	.5316	.8939	.8842
10	.5609	.7545	.7975	.5609	.7362	.8063	.9189
11	.5658	.7602	.7975	.5316	.6859	.7362	.8413
12	.6516	.7712	.8842	.5596	.7202	.7011	.8238
13	.6661	.8686	.8669	.503	.823	.7888	1.0402
14	.6173	.823	.8322	.4915	.8238	.7362	1.0802
15	.6516	.8596	.6415	.6226	.8238	.7362	1.1361
16				.639	1.4289		
19			.5716		.4835		
20					.5731		
21					.8589		
22					.7888		
23	.567						
24		.567					
Max	.6661	.8686	.8842	.639	1.4289	.8939	1.1361
Min	.4207	.5316	.5716	.4915	.4835	.7011	.7712
Avg	.5847	.7104	.7617	.5596	.7627	.7756	.9370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 204 / 11 KV Sarandi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2303					
5		.2303					
8	.197	.3189	.4031	.4382	.3761	.1402	.2103
9	.2865	.3721	.4031	.4382	.4835	.1928	.2865
10	.2804	.439	.4031	.4733	.443	.1753	.2865
11	.298	.3944	.4207	.4458	.4075	.2279	.3544
12	.3155	.4656	.4557	.4287	.439	.2454	.3366
13	.3544	.4115	.4681	.4239	.4287	.2103	.3721
14	.3814	.4477	.4681	.4191	.439	.1227	.2865
15	.3772	.4458	.5083	.4527	.4557	.0876	.3189
16				.3932			
17			.333				
18			.4001		.1524		
19			.4191		.1433		
20					.1791		
21					.1928		
22					.1928		
Max	.3814	.4656	.5083	.4733	.4835	.2454	.3721
Min	.197	.2303	.333	.3932	.1433	.0876	.2103
Avg	.3113	.3756	.4257	.4348	.3333	.1753	.3065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 402 / 33 KV INCOMER NO 2 JAWALI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	.9717	.9145	1.0288	1.5432	1.6004
2	.9145	.9145	.9717	.743	.9717	1.5432	1.2574
3	.9145	.9145	.9717	.9145	.9717	1.5432	1.1431
4	.8573	1.4289	.9717	.8573	.9717	1.5432	.9717
5	.8573	1.4289	.9145	.8573	.9145	1.5432	.8573
6	.5716	.6287	.5716	.5716	.6287	.9717	.8002
7	.4001	.5144	.4001	.4001	.4572	.8002	.743
8	.9522	1.6575	2.0302	1.9204	2.0576	1.9204	2.1148
9	1.1523	1.6004	2.1948	1.9753	2.1148	2.0851	2.3434
10	1.1523	1.6461	1.9753	1.9753	2.4006	2.0302	2.4006
11	1.4118	1.8404	1.9204	1.4266	2.3434	1.9753	2.2291
12	1.3575	2.1399	1.8656	1.5746	2.3045	1.4266	2.1148
13	1.4266	2.1091	2.1845	1.8461	2.2611	2.0302	2.4577
14	1.6289	2.1491	2.1948	1.9547	2.4577	1.8107	2.6292
15	1.7375	2.0805	1.7558	2.0633	2.2565	1.5364	2.6863
16	1.1431	.9717	1.3169	2.009	1.4289	.6859	1.3146
17	1.1431	1.2574	.9877	1.2003		.743	1.086
18	1.086	1.2003	1.086	.6859		.8573	1.0288
19	.5716	.5716	1.7147	.6859	1.262	.9717	1.0288
20	.9717	.9145	.9145	.9717	1.4266	1.5432	1.4861
21	.9145	1.0288	1.086	1.0288	1.7375	1.7718	1.7718
22	.9145	1.0288	1.1431	1.086	1.6832	1.4289	1.7147
23	1.4861	1.0288	1.0288	1.086	1.6004	1.2574	1.7147
24	.9717	.9717	1.0288	.9717	1.0288	1.6004	1.4289
Max	1.7375	2.1491	2.1948	2.0633	2.4577	2.0851	2.6863
Min	.4001	.5144	.4001	.4001	.4572	.6859	.743
Avg	1.0629	1.2916	1.3417	1.2383	1.5595	1.4651	1.6218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 406 / 33 KV Gokul WCL Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.3429	.4572	.4572	.4572
2	.4572	.4572	.4572	.3429	.4572	.4572	.4572
3	.4572	.4572	.4572	.3429	.4572	.4572	.4572
4	.4572	.4572	.4572	.3429	.4572	.4572	.4572
5	.4572	.4572	.4572	.3429	.4572	.4572	.4572
6	.4572	.4572	.4572	.4572	.4572	.3429	.4572
7	.4572	.4572	.3429	.3429	.3429	.3429	.4572
8	.3429	.3429	.4572	.4572	.3429	.4572	.4572
9	.3429	.4572	.3429	.4572	.4572	.4572	.4572
10	.3429	.4572	.3429	.4572	.4572	.4572	.4572
11	.4572	.3429	.3429	.4572	.4572	.4572	.4572
12	.4572	.3429	.3429	.4572	.4572	.4572	.4572
13	.4572	.4572	.3429	.4572	.4572	.4572	.4572
14	.4572	.4572	.3429	.4572	.4572	.4572	.3429
15	.4572	.4572	.3429	.3429	.4572	.4572	.3429
16	.4572	.4572	.3429	.4572	.4572	.3429	.3429
17	.4572	.4572	.3429	.4572		.3429	.3429
18	.3429	.4572	.3429	.4572	.4572	.3429	.4572
19	.4572	.3429	.3429	.4572	.4572	.3429	.5716
20	.4572	.3429	.3429	.4572	.4572	.3429	.4572
21	.4572	.4572	.3429	.4572	.4572	.3429	.5716
22	.4572	.4572	.3429	.4572	.4572	.4572	.5716
23	.4572	.4572	.3429	.4572	.4572	.4572	.4572
24	.4572	.4572	.4572	.3429	.4572	.4572	.4572
Max	.4572	.4572	.4572	.4572	.4572	.4572	.5716
Min	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.4382	.4334	.381	.4191	.4473	.4191	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 201 / 11 KV KUHI U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.724	.9335	.8573	.7811	.8764	.7621
2	.8573	.724	.9145	.8573	.7621	.8573	.7621
3	.8383	.7049	.9145	.8383	.743	.8573	.6859
4	.8383	.6859	.8954	.8383	.724	.8573	.6478
5	.8192	.5716	.8764	.8192	.7049	.8573	.6097
6	.6478	.5335	.6859	.6859	.5525	.8002	.5906
7	.5525	.5144	.6287	.5716	.4382	.5716	.5716
8	.5716		.5716	.5525	.4954	.5716	.5335
9	.6097	.5335	.5335	.5335	.5716	.5906	.5144
10	.5525	.5525	.5906		.5906	.6097	.5716
11	.5716	.6097	.6097	.5716	.6097	.6097	.6478
12	.6097	.7049	.6859	.6097	.6287	.6859	.724
13	.6287		.724	.6478	.6859	.7621	.7621
14	.6287	.724	.724	.6478	.724	.743	.7621
15	.6097	.724	.743	.6287	.7621	.724	.7621
16	.6097	.6668	.6668	.6287	.7621	.7049	.7621
17	.5906	.6287	.6478	.4572	.7621	.6859	.743
18	.5906	.5906	.6097	.4954	.6859	.6859	.743
19	.6859	.743	.7621	.5716	.6097	.6668	.743
20	.724	.8573	.8383	.6478	.8002	.6859	.2667
21	.7621	.8954	.8764	.724	.8573	.743	.7811
22	.8002	.9717	.9335	.7621	.8764	.7621	.8573
23	.7811	.9717	.9335	.8192	.9145	.7811	.8954
24	.8573	.7811	.9526	.9145	.8002	.8764	.8002
Max	.8573	.9717	.9526	.9145	.9145	.8764	.8954
Min	.5525	.5144	.5335	.4572	.4382	.5716	.2667
Avg	.6914	.7006	.7605	.6817	.7018	.7319	.6875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 202 / 11 KV CHAFEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.9526	.9526	.8383	.8764	.9145
2	.743	.6478	.9335	.9526	.8383	.8764	.8764
3	.743	.6097	.9335	.9335	.8383	.8573	.8383
4	.724	.5716	.9145	.9335	.8383	.8573	.8002
5	.7049	.5335	.9145	.9145	.8383	.8573	.7621
6	.5335	.6097	.8764	.7621	.7621	.7621	.7049
7	.4954	.6287	.8383	.6478	.6859	.6478	.6478
8	.5335	.6478	.9907	.6478	.6287	.6097	.6097
9	.5716	.8764	1.086	.6478	.6478		
10	.6097	.9907	.9717		.7621		
11	.6668	.9717	1.0479	.724	.8383	.8764	
12	.6097	.9907	1.105	.8954	.8954	.9526	
13	.3239	.9907	1.1431	.9335	.8764	1.0098	1.1622
14	.5716	.8573	.9526	.8764	.8383	.9526	.9907
15	.6478	.9335	.8573	.9717	.9526	.9907	1.0288
16	.6287		.7621	1.086	.9907	.9907	.9907
17	.6097	.6478	.6097	.9145	.9907	.9717	.9907
18	.5906	.6287	.5525	.724	.8383	.9526	.9907
19	.6859	.9145	1.0479	.8764	.7049	.9526	.9335
20	.7621	1.1812	1.3336	.9526	1.0479	1.0098	.9145
21	.8954	1.0098	1.0479	.9717	.9526	1.0669	.8764
22	.8383	1.0288	1.0479	.9335	.9145	1.0288	.8764
23	.7811	.9907	1.0288	.9145	.8954	.9907	.8764
24	.7621	.7621	.9526	.9907	.8764	.8764	.9717
Max	.8954	1.1812	1.3336	1.086	1.0479	1.0669	1.1622
Min	.3239	.5335	.5525	.6478	.6287	.6097	.6097
Avg	.6581	.8134	.9542	.8764	.8454	.9076	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 203 / 11 KV DONGARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.362	.4191	.4191	.1715	.4191	.4191
2	.4763	.362	.4191	.4001	.1905	.4191	.381
3	.4572	.381	.4191	.4001	.2096	.4191	.362
4	.4572	.381	.4001	.381	.1905	.4191	.3239
5	.4382	.381	.4001	.381	.1905	.4191	.2858
6	.2667	.3429	.381	.2858	.1524	.3048	.2667
7	.2477	.3429	.3048	.2286	1.6194	.2667	.2477
8	.2477		.3239	.1905	.1524	.1905	.2286
9	.2477	.362	.3239	.1524	.2096	.1905	.2096
10	.2858	.362	.4191		.1905	.2286	.2096
11	.3429	.362	.4191	.1524	.1905	.2667	.1905
12	.3429	.3429	.4382	.2667	.2286	.3048	.2858
13	.3239	.3239	.4382	.2858	.2286	.3429	.3239
14	.2286	.2858	.2858	.2858	.2667	.3239	.3429
15	.2477	.3239	.2858	.2667	.3048	.3429	.3239
16	.2667	.3048	.2477	.2667	.2667	.381	.3239
17	.2477	.1905	.2286	.2477	.2667	.3429	.4191
18	.2286	.1905	.1905	.2286	.2286	.3048	.4191
19	.3429	.3429	.2858	.2667	.2286	.2667	.4001
20	.4001	.4191	.4001	.2858	.2667	.2858	.381
21	.4191	.4572	.4572	.3239	.3048	.2858	.1715
22	.4001	.4572	.4572	.4954	.2667	.4954	.2096
23	.381	.4572	.4382	.4572	.4572	.4763	.2096
24	.4954	.362	.4382	.4191	.4191	.4191	.4572
Max	.4954	.4572	.4572	.4954	1.6194	.4954	.4572
Min	.2286	.1905	.1905	.1524	.1524	.1905	.1715
Avg	.3453	.3520	.3675	.3081	.3001	.3382	.3080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 204 / 11 KV SATARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.6097	.5906	.9526	.9907	1.0288	.724
2	.5335	.5906	.4763	.9526	.9717	1.0288	.7049
3	.5335	.5716	.4572	.9526	.9526	1.0098	.6859
4	.5525	.5335	.4572	.9526	.9335	1.0098	.6668
5	.5525	.5144	.4572	.9526	.8954	1.0098	.6478
6	.4001	.5525	.381	.8002	.4382	.5716	.5716
7	.4572	.5335	.3048	.8383	.5335	.7621	.6478
8	.5335	.5144	.2858	.9145	.6287	.8383	.6859
9	.5906	.4572		.9335	.724	.8954	.8002
10	.5716	.4382	.5716		.7621	.9145	.8764
11	.5335	.4763	.7621	.9145	.7621	.9526	.9335
12	.5716	.5906	.8764	.9145	.8192	.9145	.9526
13	.6478	.6478	.9335	.9145	.7621	.8764	.9526
14	.5335	.8383	.5716	.5716	.7049	.5716	.5906
15	.5716	.9145	.5906	.5144	.6668	.5335	.5906
16	.6097	.8192	.8764	.4763	.5716	.5144	.5906
17	.6478	.6478	.8954	.4572	.5335	.5716	.5716
18	.6668	.9145	.8954	.4191	.5716	.6287	.6287
19	.6859	.8002	.9145	.724	.6287	.6668	.6668
20	.7049	.6859	.9145	.8192	.8764	.8954	.9526
21	.724	.1715	.7811	1.105	1.0669	1.105	.9717
22	.6859	.4191	1.0098	1.0669	1.0669	.724	1.086
23	.6668	.5716	.9907	1.0479	1.0669	.7621	.8383
24	.5335	.6287	.6097	.9526	1.0288	1.0288	.7811
Max	.724	.9145	1.0098	1.105	1.0669	1.105	1.086
Min	.4001	.1715	.2858	.4191	.4382	.5144	.5716
Avg	.5859	.6017	.6784	.8325	.7899	.8256	.7549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 205 / 11 KV BHOJAPUR GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2477	.2858	.2667	.2858	.3429	.3239
2	.2858	.2477	.2858	.2667	.2858	.3429	.3048
3	.2667	.2286	.2858	.2667	.2667	.3239	.3048
4	.2667	.2286	.2667	.2477	.2667	.3239	.2858
5	.2667	.2096	.2667	.2477	.2667	.3239	.2858
6	.1905	.1905	.2286	.2096	.2286	.2667	.2667
7	.2096	.1905	.1905	.1905	.1905	.2286	.2667
8	.1905	.1905	.2667	.1905	.1905	.2286	.2477
9	.1715	.1905	.3048	.1905	.2096	.2477	.2477
10	.1905	.1715	.2477		.1905	.2286	.2477
11	.0572	.1905	.2286	.2286	.1905	.2096	.2477
12	.2286	.2286	.1905	.2286	.1715	.2667	.2667
13	.2667	.2286	.1715	.2286	.1905	.3048	.2858
14	.2667	.2286	.2286	.2286	.2286	.2667	.2858
15	.2858	.2286	.2477	.2096	.2667	.2286	.2477
16	.2858	.2286	.2286	.1905	.2286	.1905	.2096
17	.2477	.2286	.1905	.1715	.2286	.2096	.2477
18	.2096	.1905	.1715	.1524	.2286	.2477	.2477
19	.2286	.2286	.2096	.1524	.2286	.2667	.2286
20	.2667	.2667	.2477	.1524	.2667	.2858	.2667
21	.2858	.2858	.2858	.1524	.3239	.3048	.3048
22	.2667	.3048	.3048	.3048	.3429	.3048	.3429
23	.2667	.2858	.3048	.3239	.362	.3239	.3239
24	.2858	.2477	.2858	.2858	.3048	.3429	.3239
Max	.2858	.3048	.3048	.3239	.362	.3429	.3429
Min	.0572	.1715	.1715	.1524	.1715	.1905	.2096
Avg	.2405	.2278	.2469	.2212	.2477	.2755	.2755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 206 / 11 KV TITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5525	.5525	.5335	.5335	.4763	.4382
2	.5716	.5335	.5335	.5144	.5144	.4572	.4382
3	.5716	.5335	.5335	.5144	.4954	.4572	.4191
4	.5335	.5144	.5335	.4954	.4763	.4572	.4191
5	.5144	.5144	.5144	.4954	.4572	.4572	.4001
6	.4001	.4572	.4572	.3429	.3429	.1905	.4001
7	.4572	.5335	.4191	.2477	.2477	.2858	.4572
8	.4763	.5525	.4572	.2286	.2477	.2667	.4382
9	.4763	.5716	.4763	.2096	.2477	.2667	.4191
10	.4572	.5906	.4954		.2286	.2667	.381
11	.4382	.5716	.4954	.2667	.2096	.2858	.2858
12	.4382	.5716	.4763	.3239	.2096	.3429	.2667
13	.4382	.5335	.4763	.362	.2286	.4001	.2477
14	.4382	.5144	.381	.4191	.4191	.4572	.362
15	.4572	.4572	.3429	.4954	.4572	.4191	.381
16	.4572	.4191	.3048	.5335	.4572	.4382	.381
17	.4763	.362	.2667		.4572	.4382	.4191
18	.4954	.362	.2286	.381	.4572	.4191	.4001
19	.6097	.4954	.381	.4001	.4572	.4382	.4191
20	.5716	.5335	.4954	.4191	.4954	.4001	.4191
21	.5906	.5716	.5906	.4382	.4954	.4763	
22	.5906	.6097	.5906	.5335	.4954	.4763	.4954
23	.5716	.5906	.5716	.5716	.4763	.4572	.4954
24	.5906	.5716	.5716	.5525	.5716	.4763	.4572
Max	.6097	.6097	.5906	.5716	.5716	.4763	.4954
Min	.4001	.362	.2286	.2096	.2096	.1905	.2477
Avg	.5089	.5216	.4644	.4218	.4033	.3961	.4017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 207 / 11KV MIDC KUHI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1143	.2096	.2286	.1905	.1905	.2858
2	.1715	.1143	.1905	.2286	.1905	.1715	.2858
3	.2096	.1334	.1715	.2286	.2096	.1715	.2667
4	.1905	.1524	.1715	.2096	.2096	.1524	.2667
5	.2096	.1715	.1715	.2096	.2286	.1524	.2477
6	.1905	.1905	.1334	.2096	.2286	.1905	.2286
7	.0953	.2096	.1715	.2096	.2286	.2286	.2096
8	.1524	.2286	.1905	.2477	.2286	.2286	.1715
9	.2096	.2477	.1905	.2858	.2477	.2096	.1524
10	.2477	.2477	.3239		.3239	.2477	.2286
11	.3239	.2477	.3429	.3048	.381	.2858	.3048
12	.3048	.2286	.3429	.3239	.4191	.381	.3048
13	.2858	.2477	.3429	.362	.381	.5144	.3048
14	.2858	.2858	.3429	.4001	.3429	.4001	.381
15	.2667	.3048	.3239	.4382	.3429	.2667	.4191
16	.2667	.4572	.3429	.4572	.381	.1905	.4572
17	.2477	.4763	.381	.3239	.4763	.1334	.381
18	.2667	.3239	.4001	.2096	.3429	.1143	.3429
19	.1905	.3239	.2858	.1905	.1905	.0953	.2858
20	.1334	.2667	.2286	.2096	.1524	.1524	.1905
21	.0381	.1715	.2477	.1905	.1524	.2096	.0762
22	.0762	.2286	.1905	.1905	.1905	.2286	.2286
23	.0762	.2096	.2096	.2096		.2667	.2286
24	.1905	.0953	.1905	.1905	.1905	.1905	.2858
Max	.3239	.4763	.4001	.4572	.4763	.5144	.4572
Min	.0381	.0953	.1334	.1905	.1524	.0953	.0762
Avg	.2008	.2366	.2540	.2634	.2709	.2239	.2723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 208 / 11 KV BHOJAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.2667	.4001	.3429	.0762	.1143	.0381
2	.0572	.0381	.0953	.1334	.0762	.1143	.0381
3	.0572	.0381	.0953	.1334	.0953	.1143	.0381
4	.0572	.0381	.0953	.1334	.0953	.1143	.0572
5	.0572	.0572	.0953	.1143	.1143	.1143	.0572
6	.0572	.0572	.1334	.3048	.1143	.1524	.2096
7	.0381	.7811	.1143	.3429	.1143	.1905	.2477
8	.0381	.0953	.1143	.381	.0953	.2667	.3048
9	.0381	.0381	.1143	.4191	.0762	.3429	.3429
10	.0381	.0381	.1715		.0762	.362	.362
11	.0381		.1715	.4382	.1143	.381	.381
12	.0381		.1905	.4572	.1524	.4191	.4001
13	.0381	.0953	.1905	.4954	.1524	.4572	.4191
14	.381	.5525	.5144	.4572	.1524	.4382	.4001
15	.4001	.5716	.5335	.4191	.1524	.4191	.2477
16	.4001	.5335	.4954	.4001	.3048	.4001	.2477
17	.4191	.6097	.4572		.3429	.3429	.381
18		.6097	.4191	.0381	.3048	.0572	.0762
19	.381	.5335	.4001	.0762	.1905	.0572	.0762
20	.3239	.4572	.381	.0953	.1905	.0381	.0953
21	.2858	.4191	.362	.1143	.1905	.0381	.1143
22	.2858	.4191	.3429	.0953	.1524	.0381	.1143
23	.2858	.4001	.3429	.0762	.1334	.0381	.1143
24	.0762	.2667	.381	.3239	.0762	.1143	.0381
Max	.4191	.7811	.5335	.4954	.3429	.4572	.4191
Min	.0381	.0381	.0953	.0381	.0762	.0381	.0381
Avg	.1682	.3144	.2755	.2633	.1476	.2135	.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 201 / 11 KV MANDHAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.105	.5525	.5716	.381	.8192	.8573
2	1.2384	1.0669	.5525	.5716	.381	.8192	.8573
3	1.2003	1.0669	.5525	.5716	.362	.8192	.8573
4	1.2003	1.0669	.5335	.6097	.362	.8002	.8192
5	1.1622	1.0098	.5144	.6478	.362	.6859	.7621
6	1.0098	.9717	.4954	.5144	.381	.5906	.724
7	.8954	.8573	.5525	.5525	.4382	.6097	.4572
8	1.0669	1.105	.6097	.6859	.5144	.6478	.724
9	1.2574	1.2193	.6668	.7811	.5716	.724	.8192
10	1.0288	1.105	.724		.6287	.7811	.8954
11	.4001	1.086	.743	.724	.6287	.8002	.9145
12		1.105	.743	.6859		.7621	.8764
13		1.1812	.6478	.724	.6668	.7621	.8192
14		1.2003	.7049	.724	.6668	.7621	.8192
15	1.0669	1.2003	.6668	.6668	.6668	.743	.8002
16	1.0669	.5906	.6097	.6859	.5906	.743	.724
17	1.086	.5906	.6478	.6668	.4954	.6287	.6478
18	1.1241	.5906	.6478	.4572	.4763	.6287	.7049
19	1.1241	.5716	.5525	.4191	.6287	.6859	.5335
20	1.1622	.5525	.5716	.4572	.7811	.8002	.4763
21	1.2384	.5525	.6097	.4382	.8764	.8573	.5144
22	1.2384	.5716	.5906	.4382	.8764	.8954	.5335
23	1.2193	.5525	.5906	.4001	.8764	.8954	.5335
24	1.2765	1.105	.5525	.5716	.381	.8192	.8573
Max	1.2765	1.2193	.743	.7811	.8764	.8954	.9145
Min	.4001	.5525	.4954	.4001	.362	.5906	.4572
Avg	1.1096	.9177	.6097	.5898	.5649	.7533	.7303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 202 / 11 KV CHICHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.381	.362	.381	.381	.3429	.362
2	.2286	.381	.362	.381	.381	.3429	.362
3	.2667	.381	.3429	.381	.3429	.3429	.3429
4	.2667	.381	.3429	.4191	.3048	.3429	.3239
5	.2477	.3048	.3048	.4191	.2667	.2858	.3048
6	.1715	.2667	.2858	.2667	.2477	.2477	.2667
7	.1334	.2286	.1715	.2477	.1905	.1524	.1905
8	.1334	.1905	.2667	.2858	.2667	.1905	.2096
9	.1524	.2477	.2286	.2858	.3239	.1524	.2667
10	.1524	.2286	.2477		.3429	.2477	.2858
11		.2667	.2858	.3429		.2477	.2858
12	.1905	.2286	.2667	.3048	.3048	.2858	.3048
13	.2286	.3239	.2667	.3048	.3048	.2858	.2667
14	.2286	.3048	.3239	.3429	.3048	.2858	.2858
15	.2477	.2858	.3429	.3239	.2667	.2477	.2477
16	.2096	.2286	.2096	.2477	.2286	.2286	.2096
17		.1905	.1905	.2286	.1905	.1715	.1715
18	.1715	.1524	.1905	.1334	.1524	.1905	.1524
19	.2477	.1905	.2477	.1905	.2286	.2286	.2286
20	.4001	.381	.3429	.3239	.362	.3048	.3239
21	.4191	.4001	.4001	.362	.381	.3429	.381
22	.4191	.4191	.4191	.381	.381	.4001	.362
23	.4001	.381	.4191	.381	.362	.381	.362
24	.2667	.381	.362	.381	.381	.362	.362
Max	.4191	.4191	.4191	.4191	.381	.4001	.381
Min	.1334	.1524	.1715	.1334	.1524	.1524	.1524
Avg	.2459	.2969	.2993	.3181	.2998	.2755	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 203 / 11 KV DONGARMOUDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.7621	.8002	.8002	.6668		
2	.5525	.7621	.8002	.8002	.6668		
3	.5335	.7621	.7621	.7621	.6097		
4	.5335	.6859	.7621	.7621	.5716		
5	.381	.5716	.724	.724	.5335		
6	.5335	.4954	.5335	.5525	.5144		
7	.3239	.4382	.5906	.4954	.4763		
8	.2667	.5716	.7621	.8383	.5716	.6097	1.0098
9	.4001	.5335	.8002		.6097	.7811	.8192
10	.4001	.3048	.8573		.5716	.8383	1.2384
11	.4001	.7049	.4954	1.0479	.6668	.8573	1.2193
12		.724	.8954	1.0288	.6287		1.2384
13	.4572	.743	.8954	1.0479	.7049	.6859	1.2955
14	.5335	.7811	.8954	1.105	.7049	.7049	1.2193
15	.5525	.8192	.8764	1.1241	.724	.9526	1.1431
16	.4572	.4763	.4382	.724		.8192	
17	.362	.4382	.2667	.6668			
18	.3429	.1715	.4572				
19	.4572	.5525	.6287				
20	.8192	.8002	.8002	.381			
21	.8383	.8192	.9145	.6668			.8764
22	.8192	.8573	.8954	.724			.8573
23	.7811	.8192	.8573	.6859			.8573
24	.5525	.7811	.8002	.8383	.6859		
Max	.8383	.8573	.9145	1.1241	.724	.9526	1.2955
Min	.2667	.1715	.2667	.381	.4763	.6097	.8192
Avg	.5152	.6406	.7295	.7888	.6192	.7811	1.0704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 205 / 11 KV WAG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6478	.724	.724	.6668	.7049	.743
2	.6859	.6478	.724	.724	.6478	.7049	.743
3	.6859	.6478	.6859	.724	.6097	.7049	.724
4	.6478	.6097	.6668	.6859	.5716	.7049	.724
5	.6478	.6097	.6097	.6859	.5335	.6097	.6478
6	.4382	.5144	.5525	.5525	.4954	.5335	.5716
7	.362	.4954	.4763	.4572	.4191	.5525	.5525
8	.4001	.5525	.4763	.4191	.4954	.6097	.6478
9	.4382	.6097	.6478	.6287	.5335	.7049	
10	.4954	.5144	.5906		.5525	.6859	.724
11		.5906	.6668	.743	.6287	.7049	.8002
12	.5716	.6287	.7621	.7811	.7049	.743	.8383
13	.6668	.724	.724	.7621	.724	.8002	.8764
14	.7049	.7811	.8192	.8192	.724	.8383	.8002
15	.6478	.6668	.8002	.8002	.724	.8192	.743
16	.743	.5716	.6668	.724	.7049	.6668	.6097
17	.6287	.5716	.5906	.6668	.5716	.5716	.6287
18	.6097	.5716	.6097	.4382	.5144	.5716	.5716
19	.3048	.6097	.6287	.4191	.724	.6287	.5335
20	.5906	.7811	.8192	.6287	.743	.6478	
21	.7621	.8002	.8764	.6668	.8383	.724	.6859
22	.7621	.8192	.8573	.7049	.8002	.7811	.7049
23	.6859	.7621	.8002	.6859	.7621	.7621	.7049
24	.724	.6859	.743	.7621	.6668	.743	.743
Max	.7621	.8192	.8764	.8192	.8383	.8383	.8764
Min	.3048	.4954	.4763	.4191	.4191	.5335	.5335
Avg	.6055	.6422	.6883	.6610	.6398	.6883	.6963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 206 / 11 KV PUNARVASAN FFEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	.4382	.381	.4191	.381	.4001
2	.3429	.381	.4191	.381	.4191	.381	.4001
3	.3048	.381	.4191	.381	.381	.381	.4001
4	.3048	.381	.4001	.4191	.3429	.381	.4001
5	.2858	.3429	.381	.4191	.3429	.362	.381
6	.2858	.3048	.362	.3048	.3048	.3239	.3429
7	.2286	.2858	.1524	.2667	.2858	.3048	.2667
8	.2096	.2477	.2667	.3048	.2858	.3048	.2858
9	.2286	.2667		.3048	.2858	.2286	.3429
10	.2096	.2286	.2667		.2667	.3048	.3048
11	.2286		.2286	.3429	.2858	.3239	.3239
12	.2477	.2286	.1715	.3239	.2858	.362	.362
13	.2477	.3239	.2286	.3239	.2858	.362	.362
14	.2667	.3239	.2667	.362	.2858	.3429	.362
15	.2477	.3048	.2667	.362	.2667	.362	.3048
16	.2477	.2858		.2858	.2096	.2667	.2667
17	.2096	.2667		.2667	.1715	.2096	.2096
18	.2096	.2667	.2667	.1905	.1715	.2096	.1715
19	.2667	.2858	.3048	.2286	.2477	.2477	.2667
20	.381	.4382	.4191	.4191	.3429	.3429	.3429
21	.4191	.4572	.4763	.4191	.4001	.381	.4001
22	.4001	.4763	.4572	.4572	.4001	.4191	.4001
23	.4001	.4572	.4572	.4191	.381	.4191	.3429
24	.3429	.381	.4382	.4191	.4191	.381	.4001
Max	.4191	.4763	.4763	.4572	.4191	.4191	.4001
Min	.2096	.2286	.1524	.1905	.1715	.2096	.1715
Avg	.2858	.3346	.3375	.3471	.3120	.3326	.3350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 201 / 11 KV VELTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	1.0745	1.0174	1.0343	1.0343	1.0288	1.1022
2	.8648	1.0566	1.0174	1.0343	1.0343	1.0288	1.1022
3	.8139	1.0679	1.0174	1.0174	1.0004	1.0288	1.1022
4	.7545	1.0566	1.0174	1.0174	.9496	.9945	1.0852
5	.6859	.9671	.9665	.9326	.8817	1.0117	1.0513
6	.6588	.8859	.763	.7461	.763	.7888	.9496
7	.5895	.7164	.7291	.6783	.7461	.7291	.7969
8	.6762	.7373	.5197	.7042	.7291	.8817	.9556
9	.6859	.7545	.8886	.779	.8987	1.0174	1.0442
10	.7291	.7377	.9389	.8122	.8987	1.0288	.9282
11	.8139	.8122	.7956	.9282	.9156	1.0608	1.094
12	.8309	.8619	.9779	1.0174	1.0059	1.0608	.8951
13	.8139	.8619	1.0277	.9835	1.0343	.9614	1.0978
14	.7969	.8951	.9945	1.0004	1.0343	1.0277	1.094
15	.7716	.8785	.9556	.9892	1.0343	.9945	1.1105
16	.8238	.7459	.7202	.7122	.8859	1.2226	.9282
17	.8859	.663	.703	.6104	.6687	1.1163	.8951
18	.9134	.6299	.6443	.5596	.703	1.0631	.8139
19	1.1765	.5533	.8551	.8215	.6344	1.4175	.7042
20	1.0924	.8215	1.0174	.9496	1.1145	.9496	.9892
21	1.1104	1.0682	1.1022	1.1022	1.0974	1.0852	1.0174
22	1.1041	1.1191	1.073	1.0682	1.1022	1.153	1.0513
23	1.0745	1.0513	1.0562	1.0343	1.0974	1.1191	1.0343
24	.9389	1.0745	1.0174	1.0227	1.0343	1.0974	1.1022
Max	1.1765	1.1191	1.1022	1.1022	1.1145	1.4175	1.1105
Min	.5895	.5533	.5197	.5596	.6344	.7291	.7042
Avg	.8553	.8788	.9090	.8981	.9291	1.0361	.9977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 202 / 11 KV BHIWKUND

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.5373	.6626	.6697	.5853	.6089	.5068
2	.5087	.5316	.6626	.6516	.5853	.6268	.6516
3	.4578	.5611	.6626	.6335	.5853	.6268	.6089
4	.4287	.5611	.6447	.6154	.5487	.6401	.407
5	.3944	.543	.591	.5792	.543	.6024	.407
6	.3814	.439	.4477	.4887	.4119	.4298	.3561
7	.3121	.3898	.3761	.3475	.3366	.4252	.3052
8	.2601	.3601	.4424	.407	.3561	.4801	.4807
9	.2915	.3429	.4424	.4191	.4748	.5487	.4915
10	.3052	.3258	.4424	.4578	.4694	.583	
11	.2915	.3277	.4424	.4862	.4578	.5898	
12	.2743	.4424			.4578	.5407	.6464
13	.2543	.4424	.4807	.4578	.4973	.5571	.5801
14	.2713		.5138	.4359	.4458	.2785	
15	.2229		.5138	.4024	.4287	.2785	
16	.2507		.4207	.3467	.3403	.3768	.583
17	.3045	.3768	.3856	.3045	.3582	.3441	.583
18	.3224	.407	.3681	.2658	.3403	.4298	.5373
19	.543	.3582	.5548	.4961	.4252	.5552	.4784
20	.6219	.6805	.6485	.5731	.5194	.6089	.5373
21	.5731	.7343	.7108	.5493	.6335	.6805	.591
22	.6089	.6984	.691	.5792	.6268	.6805	.6447
23	.591	.6805	.6626	.5792	.6024	.6805	.6447
24	.5365	.5853	.6626	.6697	.5853	.6268	.6805
Max	.6219	.7343	.7108	.6697	.6335	.6805	.6805
Min	.2229	.3258	.3681	.2658	.3366	.2785	.3052
Avg	.3976	.4917	.5404	.4963	.4840	.5333	.5361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164062 / 33/11 KV AMBHORA

Feeder No / Name : 203 / 11 KV CHIKHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.285	.5194	.5792	.5304	.5249	.5304	.5304
2	.2713	.5304	.5792	.5304	.5249	.5304	.5304
3	.2713	.4938	.5792	.4938	.5249	.5121	.5121
4	.2572	.4835	.5792	.4887	.5014	.5121	.5121
5	.2401	.4525	.5249	.4163	.4477	.4938	.5121
6	.2254	.3696	.3801	.362	.3801	.3658	.3658
7	.1734	.2772	.3258	.2896	.3012	.3658	.3109
8	.1907	.2401	.2883	.2572	.2713	.3258	.3222
9	.2058	.3258	.2713	.3052	.3391	.407	.407
10	.2204	.3429	.3052	.3185	.3688	.39	.4578
11	.2883	.3391	.3391	.3185	.4024	.407	.4862
12	.2743	.3391		.3561	.407	.4239	.5087
13	.2883	.373		.3391	.3944	.4239	
14	.2713	.373	.3856	.3561	.3944	.407	.503
15	.2743	.3561	.3856	.3561	.3772	.4409	.4807
16	.2743	.362	.333	.3506	.3658	.3658	.4557
17	.2743	.3077	.3224	.3012	.362	.3109	.4207
18	.2534	.3077	.3012	.2353	.362	.3109	.3366
19	.394	.4887	.4508	.439	.3077	.3658	.3403
20	.5068	.543	.4908	.4938	.543	.4938	.5068
21	.5249	.6154	.5375	.567	.567	.5853	.543
22	.5249	.6154	.5552	.543	.5373	.5853	.5973
23	.5304	.5792	.543	.5304	.5028	.5487	.5194
24	.285	.4973	.5792	.5304	.5249	.5028	.5304
Max	.5304	.6154	.5792	.567	.567	.5853	.5973
Min	.1734	.2401	.2713	.2353	.2713	.3109	.3109
Avg	.3044	.4222	.4380	.4045	.4263	.4419	.4648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 201 / 11KV LANJALA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.108	.1715	.1072	.1072	.1081	.1143	.1143
2	.108	.1715	.1072	.1072	.1081	.1143	.1143
3	.108	.1524	.1072		.108	.1143	.1143
4	.1081	.1524	.1072	.0894	.1081	.1143	.1143
5	.108	.1334	.1072	.0894	.1081	.1143	.0953
6	.0901	.1334	.1072	.0894	.1081	.0953	.0953
7	.09	.1143	.1072	.0894	.0901	.1143	.0953
8	.09	.1524	.1966	.1608		.1524	.0953
9	.108	.1905	.1966	.1966	.1622	.1524	.1524
10	.126	.2286	.1608	.18	.1622	.1524	.1715
11	.1524	.1966	.1608	.18	.1905	.1524	.1715
12	.1905	.1787	.1787	.162	.1905	.1524	.1524
13	.2096		.1787	.162	.1905	.1524	.1143
14	.1715	.1787	.1787	.162	.1905	.1334	.0953
15	.1905	.2144	.1251	.162	.1905	.1143	.1143
16	.0953	.1608	.0894	.108	.0572	.0953	.0953
17	.0953	.143	.0894	.108		.0953	.0953
18	.0762	.0894	.0894	.09	.0953	.0762	.0953
19	.1524	.0894	.0894	.144	.0953	.0953	.1334
20	.2096	.0894	.143	.126	.1143	.0953	.1334
21	.2286	.1072	.1072	.1442	.1143	.0953	.0953
22	.2286	.1072	.1072	.1081	.0953	.0953	.1143
23	.2096	.1072	.1072	.1262	.0762	.1143	.1334
24	.108	.1715	.1072	.1072	.1262	.0953	.0953
Max	.2286	.2286	.1966	.1966	.1905	.1524	.1715
Min	.0762	.0894	.0894	.0894	.0572	.0762	.0953
Avg	.1401	.1493	.1273	.1304	.1268	.1167	.1167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 202 / 11 KV SASEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3541	.3048	.3628	.2997	.2361	.3429	.381
2	.3541	.3239	.3471	.2997	.2361	.3429	.381
3	.3372	.3048	.3313	.284	.2361	.3239	.381
4	.3372	.3239	.3155	.2682	.2361	.3239	.4191
5	.3035	.2858	.2997	.2524	.2192	.3239	.381
6	.2866	.2858	.2682	.2366	.1686	.2858	.3048
7	.2529	.381	.2524	.2051	.1349	.3048	.3429
8	.3035	.4382	.284	.3944	.2866	.3429	.4001
9	.4047	.381	.284	.4733	.3878	.381	.4763
10	.3878	.3239		.4721	.4024	.4191	.5144
11		.4102	.2714	.489	.4191	.5335	.5716
12	.4001	.4259	.447	.489	.381		.5716
13	.4191		.4733	.4721	.381		.5716
14	.4382	.3944	.4575	.4721	.4382	.4763	.5716
15	.4382	.5048	.4259	.4721	.4001	.4954	.5716
16	.2858	.5206	.3471	.1855	.2096	.381	
17	.2667	.3786	.1893	.118		.4763	
18	.3048	.1578	.1893	.118	.2858	.381	.4572
19	.3239	.2997	.2366	.2529	.381	.381	.4191
20	.3429	.3471	.284	.2429	.4382	.4001	.3429
21	.3429	.3786	.3313	.2529	.4191	.4763	
22	.362	.3786	.3155	.2529	.381	.4763	.2286
23	.362	.3786	.3155	.2361	.3429	.4382	.2286
24	.3541	.3239	.3628	.2997	.2361	.3429	.4763
Max	.4382	.5206	.4733	.489	.4382	.5335	.5716
Min	.2529	.1578	.1893	.118	.1349	.2858	.2286
Avg	.3462	.3588	.3214	.3141	.3155	.3932	.4282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 203 / 11 KV KHAPRI-MANGLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	.0762	.0843	.0843	.052	.0762	.0953
2	.052	.0762	.0674	.0843	.052	.0572	.0953
3	.052	.0572		.0674	.052	.0572	.0953
4	.052	.0572	.0674	.0674	.052	.0572	.0762
5	.052	.0572	.0674	.0674	.052	.0572	.0953
6	.052	.0762	.0506	.0506	.052	.0572	.0572
7	.0525	.0572	.0506	.0504	.052	.0572	.0572
8	.052	.0572	.0843	.0674	.052	.0762	.0572
9	.052	.0572	.0674	.0674	.052	.0953	.0762
10	.052	.0572	.0506	.052	.052	.0953	.0572
11	.0762	.0506	.0506	.052	.0572	.0953	.0572
12	.0762	.0674	.0506	.052	.0572	.0953	.0572
13	.0762	.0674	.0506	.0693	.0762	.0953	.0572
14	.0762	.0674	.0506	.072	.0762	.0953	.0572
15	.0762	.0674	.0506	.0693	.0572	.0953	.0572
16	.0762	.0674	.0506	.052	.0572	.0572	.0572
17	.0762	.0506	.0506	.052		.0572	.0572
18	.0572	.0506	.0506	.052	.0572	.0572	.0572
19	.0762	.0843	.0674	.0693	.0572	.0762	.0572
20	.0953	.0843	.0674	.052	.0762	.0572	.0762
21	.0762	.0843	.1012	.052	.0762	.0953	.0572
22	.0762	.0843	.0843	.052	.0762	.0762	.0572
23	.0572	.0843	.0843	.052	.0572	.0572	.0762
24	.052	.0572	.0843	.0843	.052	.0762	.0762
Max	.0953	.0843	.1012	.0843	.0762	.0953	.0953
Min	.052	.0506	.0506	.0504	.052	.0572	.0572
Avg	.0643	.0665	.0645	.0621	.0588	.0739	.0675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 201 / 11 kV ADAM FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2743	.3429	.3429	.2858	.3429	.3429
2	.1886	.2743	.3429	.3429	.2858	.2667	.3086
3	.1886	.2058	.3048	.3239	.2667	.2667	.2915
4	.1886	.1715	.3048	.3239	.1905	.2286	.2915
5	.1886	.1715	.2858	.3048	.1905	.2286	.2743
6	.1886	.1372	.2667	.2477	.1524	.2286	.2572
7	.1886	.12	.1715	.1524	.1524	.1524	.12
8	.2058	.2743	.381	.3048	.2286	.2477	.1715
9	.2401	.4001	.4572	.381	.3048	.3048	
10	.2229	.362	.4763		.3429	.2858	
11	.2058	.4382	.5144	.4191	.3429	.2743	
12	.2743	.4001	.5525	.4191	.3429	.2915	
13	.2743	.4382	.5144	.4572	.3429	.3086	
14	.2743	.4191	.5144	.4572	.3429	.3258	
15	.2743	.381	.4763	.381	.3429	.3258	
16	.1886	.2858	.1905	.1905	.2096	.1715	
17	.1886	.2096	.1715	.1715	.2096	.1543	
18	.1886	.1905	.2096	.2286	.2096	.1715	
19	.1886	.2096	.2477	.2286	.2286	.2401	
20	.2572	.4191	.2858	.3239	.3048	.2915	
21	.2743	.4191	.3239	.3239	.3429	.3601	
22	.3086	.381	.362	.3239	.362	.3772	
23	.3086	.381	.3429	.3239	.381	.3772	
24	.3086	.3086	.381	.3429	.3239	.362	.3429
Max	.3086	.4382	.5525	.4572	.381	.3772	.3429
Min	.1886	.12	.1715	.1524	.1524	.1524	.12
Avg	.2293	.3030	.3509	.3181	.2786	.2743	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 202 / 11 kV MAJARI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2572	.3048		.3048	.2858	.2572
2	.1715	.2572	.2667	.3239	.3048	.2858	.2572
3	.1715	.2401	.2667	.3239	.2667	.2667	.2401
4	.1715	.2229	.2667	.3048	.2667	.2667	.2229
5	.1715	.2229	.2286	.2858	.2286	.2286	.2058
6	.1715	.2058	.2286	.2096	.2286	.1905	.2058
7	.1715	.1886	.2286	.2286	.2477	.1905	.1886
8	.12	.1543	.2477	.2477	.2477	.2096	
9	.1715	.1905	.2286	.2667	.3239	.2096	
10	.1715	.2667	.2667		.3048	.2096	
11	.2058	.2286	.3048	.2286	.3239	.2572	
12	.2058	.2858	.3048	.2286	.362	.2915	
13	.2229	.3048	.3048	.2477	.3429	.3086	
14	.2401	.2858	.3048	.2477	.362	.3258	
15	.1372	.2667	.2858	.2286	.3429	.2572	
16	.1543	.2667	.2667	.2286		.2229	
17	.1715	.2667	.2286	.2858	.2096	.2572	
18	.1886	.2286	.2286	.2858	.1524	.2401	
19	.2229	.2667	.2667	.3048	.2477	.2401	
20	.2572		.3048	.3429	.3048	.2401	
21	.2743	.3239	.3048	.3239	.3048	.2743	
22	.2915	.3239	.3239	.3239	.3048	.2743	
23	.2743	.3429	.3239	.3239	.3048	.2743	
24	.2401	.2743	.3048	.3429	.3239	.3048	.2743
Max	.2915	.3429	.3239	.3429	.362	.3258	.2743
Min	.12	.1543	.2286	.2096	.1524	.1905	.1886
Avg	.1979	.2553	.2746	.2789	.2874	.2547	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164073 / 33/11 kV ADAM SUB-STATION

Feeder No / Name : 203 / 11 KV MANDHAL GAOTHAN
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	16-JUN-18
HR	Load (MW)
24	.4001
Max	.4001
Min	.4001
Avg	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 201 / 11 KV SIRSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1265	1.0682	1.0957	1.0751	.9825	.4887	1.1626
2	1.1025	1.0408	1.0408	1.0528	.9431	.4973	1.1591
3	1.0888	1.0219	.9962	1.0168	.8985	.5144	1.1334
4	.4715	.5024	.7733	1.0048	.8282	.5144	.4818
5	.5058	.6001	.787	.9791	.7493	.511	.4664
6	.4921	.6276	.7493	.667	.6773	.511	.4407
7	.5058	.631	.8179	.5573	.4921	.475	.6139
8	.571	.7373	.8659	.4955	.487	.571	.9722
9	.5658	.8762	.8059	.5487	.5401	.5933	.7716
10	.5864	.9208	.9294	.667	.631	.655	.691
11	.6704	.8471	.8591	.7802	.7185	.6533	.6224
12	.6413	.7545	.7768	.9088	.6293	.6739	.8711
13	.8539	.8882	.8779	1.07	.7356	.7047	.9722
14	.9191	.8951	.9311	1.0871	.8556	.6241	1.0219
15	.8848	.8728	.8265	1.0322	.8368	.523	.9757
16	.8265	.7476	.7356	.9654	.799	.5504	.8711
17	.5007	.6001	.643	.7956	.607	.5316	.7545
18	.3412	.511	.5316			.5658	.6464
19	.7116	.5898	.6464	.3858		.5333	.7819
20	1.0614	1.0357	.9945	.4595		1.13	1.0391
21	1.0014	1.0837	1.1437	.499		1.2431	1.2088
22	1.19	1.1917	1.19	.499		1.3049	1.2603
23	1.13	1.1643	1.1265	1.0305		1.2414	1.2157
24	1.154	1.094	1.1214	1.094	1.0237		1.1711
Max	1.19	1.1917	1.19	1.094	1.0237	1.3049	1.2603
Min	.3412	.5024	.5316	.3858	.487	.475	.4407
Avg	.7876	.8459	.8861	.8118	.7464	.6787	.8877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 202 / 11 kV Mahalgao

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8282	.7064	.7356	.9465	.6327	.4544	.9242
2	.8145	.7013	.703	.9294	.5933	.4578	.9105
3	.7973	.6944	.6636	.8779	.5487	.4527	.9002
4	.5384	.6087	.7116	.8522	.5127	.4595	.6653
5	.5538	.6499	.7682	.8333	.4698	.4715	.6687
6	.6121	.6962	.8282	.5384	.4081	.5041	.6224
7	.6722	.823	.9105	.4407	.3275	.5778	.7888
8	.703	.8693	1.0442	.4407	.3086	.7425	.9242
9	.8128	.8968	.8608	.4818	.3532	.7579	1.0117
10	.7699	.9294	1.0322	.5127	.3961	.7545	1.0974
11	.7545	.9276	1.0648	.595	.4167	.8076	.9602
12	.8676	.1235	.6447	.8899	.547	.8899	.6121
13	.6944	.1955	.7099	1.1746	.715	.9019	.6327
14	.583	.595	.7236	1.1831	.5898	.8076	.6619
15	.5556	.5658	.6447	1.0494	.5573	.691	.643
16	.4853	.5384	.571	1.0117	.4407	.7013	.4921
17	.3412	.451	.5247	.9928	.4012	.6653	.439
18	.619	.3515	.4047			.6687	.3755
19	.427	.4492	.5161	.5144		.6396	.4612
20	.7493	.7219	.9156	.559		.9362	.6722
21	.6567	.7922	1.0099	.5778		1.0254	.8282
22	.7699	.8213	1.0014	.5727		1.0219	.8608
23	.7339	.7836	.9345	.6722		.9808	.7973
24	.8471	.7099	.7596	.9551	.6636		.9842
Max	.8676	.9294	1.0648	1.1831	.715	1.0254	1.0974
Min	.3412	.1235	.4047	.4407	.3086	.4527	.3755
Avg	.6744	.6501	.7785	.7653	.4934	.7117	.7472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164004 / 33 KV SIRSI

Feeder No / Name : 402 / 33KV INCOMER(sirsi Stn)

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / INCOMING

UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.5638	1.5278	1.5998	1.4918	1.1626	1.5432
2	1.5792	1.5278	1.4609	1.5484	1.4095	1.1677	1.5226
3	1.5123	1.5021	1.3889	1.5226	1.2912	1.1471	1.4969
4	1.2294	1.322	1.6615	1.4815	1.214	1.1523	1.4969
5	1.2603	1.394	1.713	1.4455	1.0751	1.1368	1.3477
6	1.322	1.5072	1.7695	.9156	.9362	1.1677	1.2706
7	1.4043	1.677	2.0062	.7459	.7459	1.2191	1.6409
8	1.5226	1.8004	2.073	.7356	.7407	1.3117	1.8621
9	1.5895	1.9753	1.9856	.787	.7613	1.5638	2.0525
10	1.4866	2.0679	2.0885	.8745	.8488	1.5535	2.0165
11	1.5998	1.8776	2.0422	.9722	.9414	1.6358	1.8158
12	1.6872	.7922	1.07	1.8982	1.3786	1.7644	1.106
13	1.1626	.9105	1.2346	2.4743	1.5998	1.7541	1.2654
14	1.1883	1.1626	1.2088	2.4331	1.2449	1.6409	1.2912
15	1.1986	1.1163	1.1214	2.2068	1.25	1.4198	1.2706
16	1.0854	1.0288	.9979	2.1348	1.0957	1.4352	1.0648
17	.9208	.8488	.8385	1.965	.9722	1.3786	.9671
18	1.0751	.7253	.7253			1.4352	.8179
19	.9311	.8848	.9002	1.1111		1.4095	.9928
20	1.5689	1.4763	1.4815	1.2603		1.5638	1.4558
21	1.43	1.677	1.7181	1.2963		1.6667	1.7233
22	1.6821	1.7284	1.7335	1.2963		1.6975	1.7644
23	1.6152	1.6255	1.6152	1.5535		1.5844	1.6409
24	1.6615	1.5895	1.5895	1.6101	1.5535		1.5586
Max	1.6872	2.0679	2.0885	2.4743	1.5998	1.7644	2.0525
Min	.9208	.7253	.7253	.7356	.7407	1.1368	.8179
Avg	1.3878	1.4075	1.4980	1.4725	1.1417	1.4334	1.4577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 201 / 11 kV Pachgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4163	.4344	.4163	.3982	.4163	.4252
2	.4344	.4163	.3982	.4163	.3982	.4163	.4344
3	.4344	.3982	.4163	.4163	.3982	.4163	.4344
4	.3801	.3982	.4344	.4163	.3982	.3801	.4525
5	.362	.362	.3439	.3801	.362	.362	.4344
6	.3258	.3077	.3077	.3258	.3258	.3439	.3801
7	.3077	.2715	.3077	.3258	.2534	.3077	.3258
8	.3077	.2715	.2896	.362	.2896	.2896	.362
9	.3258	.3439	.3258	.362	.3258	.3439	.362
10	.3439	.362	.3982	.3801	.3439	.3801	.3982
11	.3982	.3258		.3982	.3439	.4344	.3982
12	.3801	.3439	.3982	.3801	.362	.3982	.4163
13	.362		.3982	.4163	.3801	.4163	.2715
14	.4163	.3982	.4163	.3982	.3801	.4344	.362
15	.3982	.4525	.4163	.3982	.3801	.4525	.4344
16	.3801	.4163	.3801	.4344	.362	.3439	.4163
17	.3258	.4163	.3801	.362	.3077	.362	.4163
18	.3258	.362	.3439		.2715	.2835	.362
19	.2896	.3801	.3801	.3077	.3439	.3258	.3077
20	.3801	.4163	.4344	.3982	.3801	.3982	.3982
21	.4163	.4344	.4706	.4163	.4344	.4344	
22	.4163	.4344	.4706	.4163	.4525	.4706	
23	.3982	.4344	.4525	.3982	.4344	.4525	.4344
24	.4344	.4163	.4163	.4075	.3982	.4163	.4525
Max	.4344	.4525	.4706	.4344	.4525	.4706	.4525
Min	.2896	.2715	.2896	.3077	.2534	.2835	.2715
Avg	.3741	.3817	.3919	.3884	.3635	.3866	.3945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 202 / 11 kV Surgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5281	.6036	.6036	.5847	.5658	.5847
2	.5658	.5281	.6224	.6036	.5847	.5658	.5973
3	.547	.547	.6224	.6036	.6036	.5658	.5973
4	.5658	.547	.5847	.6036	.5658	.5281	.6413
5	.5281	.5281	.5658	.5658	.5281	.4904	.6036
6	.4527	.4527	.547	.5281	.4715	.4715	.4715
7	.3961	.4904	.5658	.4904	.3961	.4715	.5093
8	.415	.4715	.4904	.5658	.3961	.5093	.5658
9	.4338	.4904	.415	.6036	.3772	.5658	.5249
10	.5093	.5093	.4715	.6036		.5658	.6036
11	.4527	.4338	.4338	.6413	.4715	.5847	.6036
12	.4715	.5658	.5658	.6602	.4715	.6154	.6036
13		.2263	.3395	.679	.4715	.543	.6602
14	.5281	.3206	.4961	.6413	.547	.6979	.679
15	.4904	.6036	.6224	.3206	.5658	.6036	.6413
16		.6413	.5658	.3206	.5658	.4784	.6413
17	.3544	.7545	.6036	.3018	.4338	.5611	.5281
18	.3206	.679	.6379	.415	.3961	.543	.6036
19	.5658	.547	.6036	.4715	.5281	.5093	.5658
20	.5847	.6979	.6602	.6036	.6413	.6224	.547
21	.6224	.7356	.6979	.6224	.6036	.6602	
22	.5658	.6602	.679	.6224	.6036	.6602	
23	.5281	.6224	.6602	.6036	.5658	.6602	.5281
24	.5847	.547	.6224	.6224	.5658	.5658	.6224
Max	.6224	.7545	.6979	.679	.6413	.6979	.679
Min	.3206	.2263	.3395	.3018	.3772	.4715	.4715
Avg	.5022	.5470	.5699	.5541	.5191	.5669	.5874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 203 / 11 KV Jassal Industrial
champa Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)
1		.1065
2		.1057
3		.0892
4		.1257
5		.1425
6		.2972
7		.3506
8		.3077
9		.8488
10		.6979
11		.4338
12		.4527
13	.0389	.8488
14	.1715	.2892
15	.2641	.4938
16	.1257	.7468
17	.0476	1.0479
18	.052	.9997
19	.0533	.3498
20	.065	.4144
21	.064	
22	.1219	
23	.0827	.4862
24		.2138
Max	.2641	1.0479
Min	.0389	.0892
Avg	.0988	.4477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 204 / 11 KV CHAMPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.3898	.3721	.4252	.3189	.3544	.3982
2	.3721	.3898	.3721	.4252	.3189	.3544	.3898
3	.3721	.3898	.3898	.4252	.3189	.3544	.3898
4	.3721	.3898	.3544	.4527	.3189	.3189	.3898
5	.3721	.3721	.3189	.4715	.3189	.3012	.3544
6	.3544	.4075	.2481	.4338	.2658	.3012	
7	.4075	.4075	.4075	.5281	.2481	.2835	
8	.4252	.3898	.443	.5847	.2481	.3366	.1417
9	.4252	.5138	.4252	.5658	.2835	.3544	.1772
10	.4784	.5138	.5138	.6036	.2835	.3544	.1949
11	.4784	.4961	.4607	.5316	.3366	.443	.2126
12	.4607	.3898	.5316	.5316	.3961		.3544
13	.4252	.3544	.5316	.4784	.3544	.4784	.567
14	.4252	.4075	.5493	.4961	.3898	.5138	.5493
15	.4252	.3898	.5493	.443	.3898	.4784	.4961
16		.3012	.567	.5316	.4338		.4961
17	.3721	.4607	.5493	.4961	.2835	.4252	.5138
18	.4961	.4961	.5138		.3544	.4525	.5316
19	.5316	.4252	.5138	.3012	.4075	.4252	.443
20	.5316	.5316	.5316	.3366	.3898	.443	.443
21	.4961	.4784	.5138	.3366	.3012	.443	
22	.4607	.4607	.5138	.3189	.3206	.4252	
23	.443	.4252	.4607	.3012	.3772	.4075	.2481
24	.3721	.4075	.3721	.4252	.3189	.3544	.3898
Max	.5316	.5316	.567	.6036	.4338	.5138	.567
Min	.3544	.3012	.2481	.3012	.2481	.2835	.1417
Avg	.4291	.4245	.4585	.4541	.3324	.3910	.3840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 205 / 11 KV PACHGAON II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.3203	1.1694	1.3957	1.358	1.3769	1.3203
2	1.3203	1.4335	1.3203	1.2071	1.3575	1.3957	1.3203
3	1.358	1.358	1.2637	1.2071	1.5466	1.4523	1.226
4	1.4335	1.3203	1.3014	1.2826	1.358	1.3769	1.3203
5	1.4523	1.094	1.226	1.226	1.2637	1.358	1.2826
6	1.3957	1.2826	1.1883	1.1506	1.3203	1.3392	1.2071
7	1.3203	1.226	1.226	1.4335	1.6409	1.4146	1.3957
8	1.905	1.1317	2.1691	1.6975	1.9239	1.4146	1.4146
9	2.1691	1.7918	2.7538	2.1502	2.5274	1.2637	2.0182
10	2.6029	2.0748	3.3196	3.0556	2.2257	1.2449	2.6406
11	2.6783	1.9239	2.8292	2.4897	2.7538	1.226	2.2634
12	2.7538	2.1502	3.1687	2.4897	3.0744	1.1694	2.6406
13	2.3765	2.037	2.8292	1.7918	2.1879	1.2826	2.3011
14	2.2257	1.9993	2.2634	1.9239	1.9427	1.226	2.3388
15	2.2634	2.0559	2.5463	2.8292	2.4709	1.1317	2.5463
16	1.9993	2.3765	2.5463	2.1125	2.7726	1.1317	2.3388
17		2.1502	3.0367		1.3392	1.094	2.6595
18	2.2634	1.0185	2.0748	1.226	2.6406	1.0751	1.6221
19	1.4335	1.7918	1.8484	1.3957	1.6221	.9808	1.358
20	1.1317	1.226	1.3203	1.1128	1.1694	1.2449	1.4712
21	1.2449	1.4146	1.3203	1.226	1.4335	1.226	
22	1.1694	1.358	1.3203	1.3957	1.3957	1.3203	
23	1.1317	1.1883	1.358	1.3203	1.4335	1.3957	1.3014
24	1.3957	1.226	1.2637	1.3203	1.3957	1.3957	1.3392
Max	2.7538	2.3765	3.3196	3.0556	3.0744	1.4523	2.6595
Min	1.1317	1.0185	1.1694	1.1128	1.1694	.9808	1.2071
Avg	1.7541	1.5812	1.9443	1.6713	1.8398	1.2724	1.7876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 206 / 11 KV CHAMPA II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4146	1.4901	2.0182	1.6598	1.094	1.5466	.8676
2	1.3769	1.4146	1.905	1.5089	1.094	1.773	.9431
3	1.3203	1.3769	1.9239	1.4712	1.094	1.8484	.9231
4	1.1506	1.4146	1.8484	1.4335	1.0374	1.6032	.9242
5	1.2449	1.4523	1.7164	1.5089	1.0185	1.5278	.9054
6	1.1883	1.4523	1.5655	1.4712	1.3014	1.4712	.8488
7	1.2449	1.1883	1.4335	1.4335	1.1317	1.5089	.8488
8	1.3957	1.1506	1.5466	1.5844	1.3203	1.6975	.9619
9	2.2822	1.9805	2.9613	1.9805	1.4232	1.5089	1.3769
10	2.3577	2.7538	3.0933	2.1502		1.5278	.9997
11	2.584		2.5086	1.7541	3.2442	2.037	1.7918
12	3.0367	2.6406	3.0933	2.6406	2.3765		1.1883
13	2.6406	3.4328	1.6975	1.7353	3.0367	1.2449	1.358
14	2.2445	1.9993	2.4143	2.3765	1.5655	.7545	2.5274
15	2.0748	3.6969	3.7723	2.9801	3.0556	.9431	2.6029
16		3.131	3.8855	2.8292	3.4139	.9431	2.3577
17		3.2065	2.8858		1.9616	.8865	1.8673
18		1.773	2.452		3.4328	.7545	2.6972
19	1.4901	1.9239	1.3203		2.0748	.7545	1.5466
20	1.3957	1.8107	.7733	.9431	1.773	.8488	.8488
21	1.3957	1.8673	1.358		1.5466	.8299	
22	1.9805	1.9427	1.9993	.9054	1.358	.8488	
23	1.8861	1.8296	1.6787	.8865	1.8861	.811	.3018
24	1.8484	1.2826	1.9427	1.6975	.9808	2.452	.7167
Max	3.0367	3.6969	3.8855	2.9801	3.4328	2.452	2.6972
Min	1.1506	1.1506	.7733	.8865	.9808	.7545	.3018
Avg	1.7882	2.0092	2.1581	1.7475	1.8357	1.3096	1.3365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 207 / 11KV Anand Mohta

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1143	.0953	.0953	.0953	.0953
2	.1524	.1334	.1143	.0953	.0953	.1143	.1143
3	.1334	.1334	.1143	.0953	.0953	.1143	.1143
4	.1334	.1334	.1143	.0953	.0953	.1143	.1143
5	.1334	.1334	.1143	.1143	.0953	.1143	.1143
6	.1524	.1334	.0953	.1143	.1143	.0953	.1143
7	.1143	.1143	.1143	.1143	.1143	.0762	.1143
8	.1715	.1143	.1143	.1143	.1143	.0953	.1143
9	.1524	.1334	.1143	.1143	.1143	.1143	.1143
10	.1524	.1334	.1143	.1334	.1143	.0953	.1143
11	.1143	.1143	.1715	.1143	.1143	.1143	.0953
12	.1334	.1334	.1905	.1143	.0953	.0953	.0953
13	.1905	.1334	.1905	.1143	.1143	.0953	.0953
14	.1905	.1524	.1715	.0953	.1143	.1143	.1143
15	.1715	.1334	.1715	.0953	.0953	.1334	.0953
16	.1715	.1334	.1715	.0953	.0953	.0953	.1143
17		.1334	.1715	.0953	.0953	.1143	.0953
18	.1524	.1334	.1524	.0953	.0762	.1143	.1143
19	.1143	.1334	.1334	.0953	.1143	.1143	.0762
20	.1334	.1334	.1524	.0953	.0953	.0953	.0953
21	.1334	.1334	.1334	.1143	.1143	.1143	
22	.1334	.1334	.1143	.1143	.0762	.1334	
23	.1334	.1334	.1143	.0953	.1143	.0953	.1143
24	.1334	.1143	.1143	.1334	.0953	.1143	.1143
Max	.1905	.1524	.1905	.1334	.1143	.1334	.1143
Min	.1143	.1143	.0953	.0953	.0762	.0762	.0762
Avg	.1458	.1310	.1365	.1064	.1024	.1072	.1065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 403 / 33KV DONGARGAO(KUHI SDN)

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4527	.3921	.3361	.3395	.499	.5658
2	.4435	.3881	.3921	.3395	.3395	.499	.5373
3	.439	.3961	.3326	.3361	.3395	.499	.5373
4	.4887	.3961	.2743	.3121	.3395	.4938	.5973
5	.463	.3961	.2772	.3086		.4344	.5973
6	.3681	.3395				.3801	.5041
7	.3601	.3395				.3189	.4252
8	.4252	.5041	.4681	.5601		.4527	.4733
9	.5784	.5601	.4372	.7842	.5601	.6104	.5658
10	.5784	.5041		.6241	.5601	.5721	.499
11		.5601	.4527	.6447	.6161	.7356	.5973
12	.5601	.7362	.7888	.7522	.5784		.6836
13	.5601		.7888	.7888	.631		.631
14	.5601	.5721	.7922	.7282	.6836		.6379
15	.5041	.4784	.7973	.631	.591	.5784	.4835
16		.6173	.4887			.4784	
17						.4115	
18						.3601	.5487
19					.3881	.4784	
20	.3361	.3921	.3361		.5544	.4887	
21	.5601	.4481	.3961	.3395	.6099	.6447	
22	.5601	.4481	.3881	.3395	.5601	.591	
23	.4481	.3921	.3921	.3395	.5041	.5973	
24	.5093	.4527	.3921	.3921	.3395	.5041	.6036
Max	.5784	.7362	.7973	.7888	.6836	.7356	.6836
Min	.3361	.3395	.2743	.3086	.3395	.3189	.4252
Avg	.4861	.4687	.4770	.5033	.5020	.5061	.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 405 / 33 kv Vidhi alloy pvt ltd. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.8107	1.5844	1.7541	1.8673	1.4146	1.6409
2	1.6975	1.9239	1.0751	1.5844	1.9805	1.3014	1.8107
3	1.4146	1.7541	1.5844	1.8107	1.5278	1.1317	1.8673
4	1.5844	1.6975	1.7541	1.9239	1.4712	1.3014	1.7541
5	1.8673	1.7541	1.6409	1.8107	1.6409	1.1883	1.8673
6	1.7541	1.5844	1.6409	1.9239	1.5844		1.8107
7	1.5278	1.8673	1.4146	1.6975	1.5278	1.4146	1.7541
8	1.4146	1.5278	1.6975	1.8673	1.4712	1.5278	1.6975
9	1.7541	1.6975	1.8673	1.1883	1.4146	1.5278	1.8673
10	1.9239	1.7541	1.8107	1.8673	1.6975	1.4146	1.9239
11	1.4712	1.6975	1.9239	1.8107	1.5844	1.4146	1.8107
12	1.5844	1.9805	1.8673		1.3014	1.6975	1.6975
13	1.6409	1.7541	1.9239	1.5844	1.358	1.9805	1.7541
14	1.6409	1.8673	2.1502	1.7541	1.4712	1.9239	1.8107
15	1.5844	1.6409	1.9805	1.4712	1.5278	1.9239	1.8107
16	1.5844	1.7541	1.8107	1.358	1.4146	2.037	1.8673
17	1.5278	2.037	1.9239	1.4712	1.5844	1.9805	2.037
18	1.6975	1.9239	1.7541	1.5844		1.6409	1.8673
19	1.5844	.5658	1.6975	1.6975	1.4712	1.9239	1.8107
20	1.6975	1.4146	1.8673	1.4146	1.5844	1.9239	1.8673
21	1.5278	1.8107	1.9239	1.7541	1.7541	1.7541	1.7541
22	1.5844	1.5278	1.9805	1.6975	1.6975	1.1883	1.8673
23	1.4146	1.5844	1.9239	1.6975	1.6975	1.1317	1.5844
24	1.8107	1.6975	1.4712	1.9239	1.6975	1.6409	1.6975
Max	1.9239	2.037	2.1502	1.9239	1.9805	2.037	2.037
Min	1.4146	.5658	1.0751	1.1883	1.3014	1.1317	1.5844
Avg	1.6244	1.6928	1.7612	1.6803	1.5794	1.5819	1.8013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 202 / 11 KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7964	.724	.8048	.8326	.5487	.6335	.439
2	.7602	.724	.7865		.5304	.6154	.7499
3	.6878	.724	.7682	.8326	.5121	.6516	.7316
4	.6878	.6878	.7316	.7783	.4755	.6154	.695
5	.6335	.6697	.695	.7783	.439	.6154	.6584
6	.6335	.6878	.6584	.7602	.4938	.5792	.5121
7	.6154	.6878	.5853	.7964	.5487	.6516	.5487
8	.6878	.905	.7682	.9231	.6219	.5792	.6584
9	.8145	.9593	.8779	1.0136	.5853	.6154	.7499
10	.7964	.905	1.0608	.9412	.5853	.6878	.7865
11	.724	.8779	1.0608	.9511	.5792	.6516	.7682
12	.8688	.9145	.9412	.9145	.8326	.7316	.7964
13	.6878	.6584	1.086	1.0608	.905	.695	.8688
14	.9593	.6219	1.086	.9511	.9412	.7316	
15	.905	.9877	.9774	.9145	.8688		.8326
16	.905	.9511	.9955	.9511	.8326	.567	.7602
17	.905	.9145	.9955	1.0059		.6584	.724
18	.905	.8779	.181	.1646		.695	.724
19	.7964	.6219	.9412	.4572		.6584	.7602
20		.9877	1.0136	.5487		.7499	.6878
21	.8145	.9877	.9774	.5487		.7316	.724
22	.7602	.9145	.905	.5853		.8048	.724
23	.7602	.8413	.8869	.567		.7682	.7421
24	.8507	.7421		.8688	.567		.7682
Max	.9593	.9877	1.086	1.0608	.9412	.8048	.8688
Min	.6154	.6219	.181	.1646	.439	.567	.439
Avg	.7807	.8156	.8602	.7889	.6392	.6676	.7135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 203 / 11 KV Daheli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.4525	.5335	.4656	.362	.3439	.4572
2	.2328	.4525	.5144	.4298	.3429	.3258	.4382
3	.2172	.4525	.4954	.394	.3429	.3258	.4382
4	.1791	.4344	.4572	.394	.2858	.3258	.4382
5	.2686	.4344	.381	.3582	.3048	.3077	.4191
6	.2686	.4344	.4191	.3224	.3429	.2715	.4191
7	.3045	.4706	.4572	.3224	.3429	.2896	.381
8	.3224	.5611	.4954	.394	.362	.362	.381
9	.3224	.6154			.4382	.3258	.3429
10	.3045	.6154	.381		.5335	.3258	.4382
11	.3224	.6668	.5716	.5525	.4163	.362	.4191
12	.6335	.724	.5731	.4572	.4344	.381	.4298
13	.6335	.6478	.6089	.5525	.5068	.4572	.4656
14	.5973	.5716	.6626	.724	.5068	.4954	
15	.5792	.6859	.6447	.743	.4887		.4656
16	.5611	.6859	.5731	.6478	.4706	.3048	.5014
17	.5973	.6287	.5373	.6859		.3429	.4656
18	.6335	.5716	.4656			.2286	.4298
19	.543	.4954	.4298	.2477		.3429	.394
20		.4954	.4656	.3429		.381	.4119
21	.4706	.5144	.5014	.362		.4572	.4656
22	.4706	.5335	.5014	.3429		.4763	.4656
23	.4525	.5525	.4835	.381		.4572	.4477
24	.2507	.4525	.5335	.4835	.362		.4572
Max	.6335	.724	.6626	.743	.5335	.4954	.5014
Min	.1791	.4344	.381	.2477	.2858	.2286	.3429
Avg	.4094	.5479	.5081	.4573	.4026	.3586	.4336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 401 / 33 KV PURTI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0549	.056	.0549	.056	.0549	.056
2	.0549	.0549	.056	.0549	.056	.0549	.056
3	.0549	.0549	.056	.0549	.056	.0549	.056
4	.0549	.0549	.056	.0549	.056	.0549	.056
5	.0549	.0549	.056	.0549	.056	.0549	.056
6	.0549	.0549	.056	.0549	.056	.0549	.056
7	.0549	.0549	.056	.0549	.056	.0549	.056
8	.0549	.0549	.056	.0549	.056	.0549	.056
9	.0549	.0549	.056	.0549	.056	.0549	.056
10	.0549	.0549	.056	.0549	.056	.0549	.056
11	.0549	.056	.056	.056	.0549	.0549	.056
12	.0549	.056	.0549	.056	.0549	.056	.0549
13	.0549	.0572	.0549	.056	.0549	.056	.0549
14	.0549	.056	.0549	.056	.0549	.056	.0549
15	.0543	.056	.0549	.056	.0549		.0549
16	.0549	.056	.0549	.056	.0549	.056	.0549
17	.0549	.056	.0549	.056		.056	.0549
18	.0549	.056	.0549	.056		.056	
19	.0549	.056	.0549	.056		.056	.0549
20		.056	.0549	.056		.056	.0549
21	.0543	.056	.0549	.056		.056	.0549
22	.0549	.056	.0549	.056		.056	.0549
23	.0549	.056	.0549	.056		.056	.0549
24	.0549	.0549	.056	.0549	.056		.056
Max	.0549	.0572	.056	.056	.056	.056	.056
Min	.0543	.0549	.0549	.0549	.0549	.0549	.0549
Avg	.0548	.0555	.0555	.0555	.0556	.0555	.0555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164006 / 33 KV BELA

Feeder No / Name : 402 / 33KV INCOMER(Bela)

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	2.9081	1.3889	1.5364	1.0288	4.5542	
2	1.3169	2.9081	1.3889	1.4815	.9774	4.6091	
3	1.3169	2.9081	1.3375	1.4815	.9259	4.5542	
4	1.262	4.4993	1.1317	1.4266	.823	4.5542	
5	1.2071	4.4445	1.0288	1.3169	.7202	4.2798	
6	1.2071	4.3896	1.0802	1.262	.7716	4.1152	
7	1.1523	4.8285	1.1317	1.4266	.7716	.8779	
8	1.2071	1.4815	1.286	1.6461	.9259	1.0425	
9	1.2071	1.6461	.9774	1.7558	1.0802	1.0425	
10	1.262	1.4815	1.5947	1.701	1.1831	1.0974	
11	1.262	1.286	1.5432	1.6461	1.2071	1.1523	
12	1.5364	1.4403	1.701	1.1317	2.3045	1.2346	
13	1.3169	1.6461	1.9204	1.6975	6.31	1.2346	
14	1.6461	1.3889	1.8656	1.5947	2.7984	1.1831	
15	1.5912	1.4403	1.7558	1.6461	2.5789		1.4815
16	1.5364	1.3375	1.7558	1.6461	2.524		1.4266
17	1.5912	1.6461	1.701	1.6975			1.3717
18	1.5912	1.4918	1.5364	.3086			1.3169
19	1.4815	1.2346	1.5912	.823			1.4266
20		1.5947	1.701	.9259			1.4815
21	3.0178	1.6461	1.6461	.9774			1.5912
22	3.2922	1.5947	1.6461	1.0974			1.701
23	3.0727	1.4918	1.5912	1.1523			1.6461
24	1.3717	2.963	1.4403	1.5364	1.0288		
Max	3.2922	4.8285	1.9204	1.7558	6.31	4.6091	1.701
Min	1.1523	1.2346	.9774	.3086	.7202	.8779	1.3169
Avg	1.6008	2.2374	1.4892	1.3715	1.6447	2.5380	1.4937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 201 / 11 KV SIRPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.285	.3086	.4409	.4049	.3018	.3429	.2915
2	.2683	.3086	.4287	.4049	.3018	.3429	.2915
3	.2683	.3086	.4115	.4049	.2683	.3429	.2915
4	.2515	.3086	.4115	.4049	.2683	.3086	.2915
5	.218	.2915	.3772	.3887	.2347	.2743	.2915
6	.1844	.2915	.3429	.2915	.1677	.2229	.1781
7	.1844	.2401	.1029	.2915	.2012	.1715	.1943
8	.2012	.3086	.3772	.3887	.2347	.1715	.1457
9	.0838	.3429	.4115	.3887	.2515	.1943	.2267
10	.2058	.2915	.4049	.3185	.2915	.2267	.2743
11	.2401	.2949	.4049	.3688	.3258	.2267	.2915
12	.2572	.3429	.421	.4024	.3772	.2591	.2915
13	.2743	.3601	.4372	.4144	.3772	.2753	.3086
14	.3086	.3772	.4534	.4144	.3601	.2915	
15	.3258	.4409	.421	.3978	.3429	.2591	
16	.3258	.4801	.3887	.3481	.3429	.1296	
17	.3086	.4458	.3887	.3315		.1457	.3086
18	.2058	.4115	.3239	.1677	.2058	.1943	.3086
19	.1372	.463	.3239	.218	.2229	.2105	.3086
20	.2058	.4458	.4372	.285	.3086	.3239	.4287
21	.3429	.4458	.4534	.3185	.3429	.3401	.4115
22	.3772	.463	.4696	.3185	.3772	.3725	.463
23	.3772	.4458	.4534	.3185	.3772	.3887	.4458
24	.3018	.3429	.4458	.4372	.3018	.3601	.3725
Max	.3772	.4801	.4696	.4372	.3772	.3887	.463
Min	.0838	.2401	.1029	.1677	.1677	.1296	.1457
Avg	.2558	.3650	.3971	.3512	.2950	.2657	.3055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 202 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.1886	.1829	.2172	.1526	.6516	.543
2	.2035	.1886	.1829	.2172	.1357	.6516	.543
3	.2035	.1886	.1829	.2172	.1357	.6516	.543
4	.2035	.1715	.1829	.2172	.1187	.6173	.543
5	.1696	.1715	.1829	.2172	.1017	.5658	.543
6	.1187	.12	.1829	.1267	.0848	.5144	.5068
7	.1017	.12	.1829	.1086	.0848	.4801	.4525
8	.1017	.1029	.2012	.0724	.0678	.4801	.5611
9	.0848	.0857	.2378	.0724	.1357	.543	.6878
10	.1029	.2195	.2353	.2374	.1715	.5973	.6335
11	.1029	.2561	.2534	.2374	.1886	.6154	.7499
12	.1715	.2926	.2534	.2374	.2058	.6516	.8048
13	.2058	.2743	.2534	.2374	.2058	.6516	.8413
14	.2058	.2743	.2534	.2204	.2058	.6516	.823
15	.2229	.2743	.2534	.2204	.2229		.8048
16	.2058	.2743	.2534	.2035	.2401	.5068	.6219
17	.1715		.2353	.2035		.5068	.695
18	.0857		.0724	.0848	.1715	.5068	.439
19	.0857		.1086	.1187	.5487	.5249	.5487
20	.1715	.1829	.1267	.1526	.7545	.6878	.7682
21	.2401	.2012	.2534	.1357	.7716	.7421	
22	.2401	.2012	.2534	.1526	.7716	.724	.1829
23	.2058	.2054	.2534	.1526	.703	.724	.439
24	.2204	.2058	.1829	.2534	.1526	.6859	.6335
Max	.2401	.2926	.2534	.2534	.7716	.7421	.8413
Min	.0848	.0857	.0724	.0724	.0678	.4801	.1829
Avg	.1686	.2000	.2067	.1797	.2753	.6057	.6047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 203 / 11 KV DAWWA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.2058	.1865	.2058	.1357	.2229	.2058
2	.2035	.2058	.1886	.2058	.1357	.2229	.2058
3	.2035	.1886	.1886	.2058	.1187	.2229	.2058
4	.1696	.1886	.1715	.2058	.1187	.2229	.2058
5	.1357	.1715	.1715	.1886	.1017	.1886	.2058
6	.1187	.1372	.12	.12	.1017	.1372	.1372
7	.1017	.1029	.0678	.0857	.1017	.1029	.0857
8	.0848	.0686	.0686	.0686	.1017	.1029	.0857
9	.0848	.0686	.0857	.0686	.0848	.1029	.0857
10	.2058	.3052	.2743	.0678	.1029	.1886	.3052
11	.2401	.2883		.2204	.1029	.2058	.2374
12	.2401	.2743	.2743	.0848	.1029	.2058	.2374
13	.2743	.2713		.2035	.2058	.2058	.2374
14	.2572	.2743	.2401	.2204	.2058	.0857	
15	.2572	.2743	.2572	.2374	.2229	.1372	
16	.2572	.2572	.2572	.2713	.2401	.0686	.2204
17	.1715	.2374	.2058	.2374		.1029	.2543
18	.1715	.1017	.0686	.0848	.1029	.1029	.1696
19	.1372	.1187	.1029	.1187	.1715	.1543	.1715
20	.1715	.1886	.2229	.1187	.2401	.2401	.1696
21	.2229	.2035	.2401	.1696	.2401	.2572	.1696
22	.2229	.2035	.2401	.1696	.2401	.2401	.1696
23	.2229	.1886	.2401	.1526	.2401	.2401	.1696
24	.2204	.2058	.1886	.2401	.1357	.2401	.2229
Max	.2743	.3052	.2743	.2713	.2401	.2572	.3052
Min	.0848	.0686	.0678	.0678	.0848	.0686	.0857
Avg	.1915	.1971	.1846	.1647	.1545	.1751	.1890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 204 / 11KV MIDC Water Works
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0308	.0304	.0311	.0308	.0308	.0304	.0308
2	.0308	.0291	.0329	.0308	.0308	.0304	.0308
3	.0308	.0291	.0311	.0308	.0308	.0304	.0308
4	.0308	.0304	.0329	.0308	.0308	.0304	.0308
5	.0308	.0304	.0311	.0308	.0308	.0304	.0308
6	.029	.0291	.0311	.0308	.029	.0304	.0308
7	.0308	.0304	.0311	.0308	.0308	.0304	.0308
8	.0308	.0291	.0311	.0308	.0308	.0304	.0308
9	.0308	.0304	.0311	.0308	.0308	.0326	.0308
10	.0304	.0311	.0308	.0308	.0291	.0326	.0326
11	.0291	.0311	.0308	.0308	.0309	.0308	.0329
12	.0304	.0311	.0326	.0308	.0309	.0326	.0311
13	.0304	.0329	.0326	.0308	.0322	.0326	.0091
14	.0291	.0329	.009	.0308	.0309	.0326	.0091
15	.0304	.0329	.0326	.0326	.0322	.0308	.0091
16	.0291	.0329	.0326	.0326	.0309	.0308	.0091
17	.0304	.0329	.0326	.0308		.0308	.0091
18	.0291	.0329	.0326	.029	.0304	.0308	.0091
19	.0291	.0311	.029	.0308	.0304	.0308	.0311
20	.0291	.0311	.0308	.0326	.0304	.0308	.0329
21	.0309	.0311	.0308	.0308	.0304	.0308	.0329
22	.0309	.0311	.0308	.0326	.0291	.0308	.0091
23	.0309	.0311	.0308	.0326	.0291	.0308	.0091
24	.0308	.0309	.0311	.0308	.0308	.0291	.0308
Max	.0309	.0329	.0329	.0326	.0322	.0326	.0329
Min	.029	.0291	.009	.029	.029	.0291	.0091
Avg	.0302	.0311	.0305	.0311	.0306	.0310	.0239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 205 / MIDC OLD WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0091	.0086	.0071	.0065	.0091	.0086	.0065
2	.0091	.0086	.0071	.0065	.0091	.0086	.0065
3	.0091	.0086	.0071	.0065	.0091	.0086	.0065
4	.0091	.0086	.0071	.0065	.0091	.0086	.0065
5	.0091	.0086	.0071	.0065	.0091	.0086	.0065
6	.0091	.0086	.0071	.0065	.0091	.0086	.0065
7	.0091	.0086	.0071	.0065	.0091	.0086	.0065
8	.0091	.0086	.0071	.0065	.0091	.0086	.0065
9	.009	.0086	.0071	.0065	.0091	.0065	.0065
10	.0086	.0071	.0065	.0091	.0086	.0065	.0073
11	.0086	.0071	.0065	.0091	.0086	.0065	.0073
12	.0086	.0071	.0065	.0091	.0086	.0065	.0073
13	.0086	.0071	.0065	.0091	.0086	.0065	.0073
14	.0086	.0071	.0065	.0091	.0086	.0065	.0073
15	.0086	.0071	.0065	.0091	.0086	.0065	.0073
16	.0086	.0071	.0065	.0091	.0086	.0065	.0073
17	.0086	.0071	.0065	.0091		.0065	.0073
18	.0086	.0073	.0065	.0091	.0086	.0065	.0073
19	.0086	.0071	.0065	.0091	.0086	.0065	.0073
20	.0086	.0073	.0065	.0091	.0086	.0065	.0073
21	.0086	.0071	.0065	.0091	.0086	.0065	.0073
22	.0086	.0071	.0065	.0091	.0086	.0065	.0073
23	.0086	.0071	.0065	.0091	.0086	.0065	.0073
24	.0091	.0086	.0071	.0065	.0091	.0086	.0065
Max	.0091	.0086	.0071	.0091	.0091	.0086	.0073
Min	.0086	.0071	.0065	.0065	.0086	.0065	.0065
Avg	.0088	.0077	.0068	.0080	.0088	.0073	.0070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 206 / 11KV GAOTHAN MAKARDHOKDA

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2624	.2401	.267	.2443	.2498	.2332	.2624
2	.2534	.2401	.2652	.2407	.2317	.2332	.257
3	.2462	.2315	.2597	.2407	.2208	.2332	.2534
4	.2389	.2315	.2561	.2389	.2172	.2229	.2443
5	.219	.2058	.2487	.2244	.1991	.2058	.2317
6	.1955	.1903	.1646	.1683	.1683	.1543	.181
7	.1665	.1372	.1481	.1647	.1484	.1509	.1448
8	.1502	.1269	.1646	.1412	.1376	.1372	.1448
9	.1557	.1646	.1829	.1357	.1665	.1484	.1629
10	.1406	.2012	.1864	.1412	.1612	.1484	.1792
11	.1337	.2012	.19	.1756	.18	.1593	.1792
12	.1715	.1884	.2244	.1919	.1903	.1665	.2195
13	.2126	.2195	.2262	.1937	.2058	.2172	.2195
14	.2401	.2433	.2353	.1955	.2092	.2226	
15	.2452	.2378	.2262	.1882	.2058	.2172	
16	.2058	.2195	.2118	.1738	.18	.1828	.2378
17	.1715		.1882	.1466		.114	.1719
18	.1715		.1285	.114	.1543	.1448	.1646
19	.18		.1629	.1575	.0086	.1991	.1829
20	.2401	.2561	.2244	.2244	.2058	.257	.2378
21	.2589	.2743	.2443	.248	.2401	.2896	.2378
22	.2623	.2798	.2643	.2534	.2486	.2715	.2926
23	.2572	.2743	.2624	.2534	.2401	.2715	.2743
24	.2715	.2486	.2689	.2534	.2552	.2383	.2679
Max	.2715	.2798	.2689	.2534	.2552	.2896	.2926
Min	.1337	.1269	.1285	.114	.0086	.114	.1448
Avg	.2104	.2196	.2167	.1962	.1924	.2008	.2158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 401 / 33KV INCOMER(makardhokda) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.463	.7842	.5658	.6173	1.0802	.9259
2	.463	.463	.7282	.5658	.6173	1.0802	.9259
3	.463	.463	.7282	.5658	.5658	1.0802	.9259
4	.4115	.463	.7282	.5658	.5658	1.0288	.9259
5	.3601	.4115	.6722	.5658	.463	.8745	.9259
6	.3086	.4115	.6161	.6173	.4115	.823	.7202
7	.3086	.3601	.3361	.3601	.4115	.7202	.6687
8	.3086	.4115	.6584	.463	.463	.7202	.7202
9	.1543	.4115	.7282	.463	.5087	.7716	.9259
10	.5658	.8962	.9259	.6613	.6173	1.0288	1.2883
11	.6173	.9522	.6687	.8551	.6687	1.0288	1.3443
12	.6173	1.0082	.9774	.763	.7202	1.1317	1.4003
13	.7716	1.0082	.9774	.8951	.823	1.1317	1.4563
14	.823	1.0082	.9774	.8951	.823	1.0288	.8402
15	.823	1.0642	.9774	.8951	.823	.4115	.823
16	.823	1.1203	.9259	.8453	.8745	.7202	.8962
17	.7716	.7842	.8745	.8048		.7716	1.3443
18	.3086	.5041	.4115	.2515	.5144	.6687	.9522
19	.2572	.5601	.4115	.3521	.8745	.8745	1.1203
20	.3601	.6161	.5658	.6104	1.1831	1.0802	1.4563
21	.5144	.7682	.6687	.6539	1.2346		.6722
22	.5658	.7842	.6687	.6613	1.286	1.1831	.8962
23	.5658	.7842	.6687	.6613	1.1831	1.1831	1.0402
24	.5144	.5658	.7842	.6173	.6173	1.1831	1.0802
Max	.823	1.1203	.9774	.8951	1.286	1.1831	1.4563
Min	.1543	.3601	.3361	.2515	.4115	.4115	.6687
Avg	.5058	.6784	.7276	.6315	.7333	.9393	1.0115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 201 / 11KV GANGAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0814	2.2177	2.1719	2.0655	2.0851		2.1762
2	1.9909	2.1437	2.0271	1.9364	2.0485		1.9918
3	1.8642	2.0698	1.9547	1.8258	2.0119		1.8258
4	1.8099	1.9185	1.8099	1.7151	1.8099		1.6783
5	1.5384	1.829	1.7375	1.6045	1.6289		1.5123
6	1.3756	1.701	1.5203	1.5123	1.4118		1.3647
7	1.2308	1.3575	1.1584	1.3463	1.1765		1.2172
8	1.086	1.2489	1.0679	1.1065	1.086		1.1803
9	1.0631	1.2048	1.0631	1.1157	1.1163		1.1694
10	1.0985	1.2403	1.0985	1.134	1.1694		1.2048
11	1.2178	1.382	1.3611	1.2803	1.3253		1.4685
12	1.2894	1.4864	1.379	1.4632	1.4685		1.5402
13	1.4327	1.5592	1.5402	1.5203	1.5043		1.6118
14	1.576	1.6834	1.576	1.6095	1.5223		1.6476
15	1.6289	1.7551	1.4842	1.6827	1.5927	1.5307	
16	1.5023	1.6476	1.4299	1.5181	1.5927	1.3647	1.7375
17	1.3535	1.448	1.3647	1.3717	1.4118	1.2541	1.6278
18	1.2437	1.3756	1.3463	1.0974	1.4118	1.1434	1.7375
19	1.5893	1.3394	1.3278	.1109		1.4938	.6283
20	1.701	1.7375	1.752	1.6632		1.6598	.7207
21	1.848	1.8823	1.8811	1.8111		1.9364	.7392
22	2.0328	2.1719	2.1024	2.0328		2.1393	.8686
23	2.3101	2.2443	2.25	2.2177		2.2684	.924
24	2.1719	2.2916	2.2081	2.1578	2.1622		2.2131
Max	2.3101	2.2916	2.25	2.2177	2.1622	2.2684	2.2131
Min	1.0631	1.2048	1.0631	.1109	1.086	1.1434	.6283
Avg	1.5848	1.7056	1.6088	1.5375	1.5545	1.6434	1.4255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 202 / 11KV SONEZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8823	1.9035	1.8461	1.8201	1.8656	1.9004	1.9488
2	1.8099	1.8665	1.7737	1.7282	1.7924	1.8099	1.8201
3	1.7737	1.8111	1.7194	1.6363	1.7193	1.7375	1.7098
4	1.6289	1.6827	1.6651	1.5627	1.6289	1.7556	1.5995
5	1.5203	1.5912	1.5565	1.4892	1.5384		1.4708
6	1.3032	1.4266		1.3973	1.3032	1.448	1.3605
7	1.1765	1.267	1.2489	1.2502	1.1584	1.2489	1.2502
8	.9774	1.1041	1.1222	1.1031	1.086	1.1403	1.1583
9	1.0985	1.134	1.1871	1.1888	1.1517	1.3237	1.2403
10	1.2403	1.1694	1.2403	1.262	1.2403	1.3789	1.3466
11	1.4327	1.3112	1.4327	1.4266	1.5043	1.4892	1.4685
12	1.4529	1.4685	1.5402	1.6095	1.7013	1.5811	1.6655
13	1.5043	1.5043	1.6118	1.6289	1.7909	1.7282	1.8099
14	1.5939	1.5402	1.7551	1.7558	1.8088	1.8385	1.8099
15	1.8099	1.7193	1.7193	1.8656	1.8099	1.8017	
16	1.6289	1.5402	1.6834	1.829	1.7737	1.6179	
17	1.6278	1.448	1.6914	1.5729	1.6832	1.434	
18	1.4998	1.5384	1.6179	1.3717		1.3421	
19	1.5339	1.5927	1.5444	1.5893	1.6832	1.5627	
20	1.5524	1.7375	1.7466	1.7926		1.6731	
21	1.6632	1.8099	1.8017	1.8296	1.9366	1.8201	
22	1.8111	1.9547	1.9121	1.8665	1.9909	1.9121	
23	1.9589	1.9909	1.9856	1.9589	2.0271	1.9856	
24	1.9366	1.9404	1.9728	1.8937	1.922	1.9185	1.9672
Max	1.9589	1.9909	1.9856	1.9589	2.0271	1.9856	1.9672
Min	.9774	1.1041	1.1222	1.1031	1.086	1.1403	1.1583
Avg	1.5591	1.5855	1.6250	1.6012	1.6416	1.6282	1.5751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 203 / 11KV KAWARAPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0185	.0181	.0187	.0274	.0018	.0187
2	.0181	.0185	.0181	.0187	.0238	.0018	.0375
3	.0181	.0148	.0109	.015	.0183	.0018	.0187
4	.009	.0128	.011	.0094	.0145	.0018	.0187
5	.009	.011	.0109	.0075	.0109	.0018	.0112
6	.0072	.0073	.0072	.0037	.0072	.0018	.0112
7	.0072	.0072	.0072	.0056	.0036	.0018	.0075
8	.0072	.0072	.0109	.0056	.0036	.0018	.0075
9	.0071	.0053	.0071	.0037	.0053	.0019	.0035
10	.0071	.0035	.0072	.0073	.0071	.0019	.0035
11	.0071	.0071	.0107	.0091	.0107	.0019	.0072
12	.0071	.0072	.0107	.011	.0107	.0019	.0107
13	.0072	.0072	.0107	.0109	.0107	.0019	.0107
14	.0072	.0072	.0072	.0128	.0072		
15	.0072	.0072	.0071	.0146	.0072		
16	.0036	.0072	.0072	.0073	.0109	.0187	
17	.0037	.0072	.0075	.0073	.0109	.0187	.0037
18	.0037	.0072	.0094	.0073		.0187	.0037
19	.0111	.0072	.0094	.0092		.0112	2.0328
20	.0146	.0181	.0112	.0111		.0112	1.9589
21	.0111	.0181	.0112	.0129	.0036	.0187	1.9959
22	.0148	.0181	.0131	.0148	.0037	.0187	2.0698
23	.0185	.0181	.0131	.0185	.0036	.0187	2.1068
24	.0181	.0185	.0181	.0169	.0259		.0375
Max	.0185	.0185	.0181	.0187	.0274	.0187	2.1068
Min	.0036	.0035	.0071	.0037	.0036	.0018	.0035
Avg	.0101	.0109	.0106	.0108	.0108	.0075	.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 204 / 11KV DREAM CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2489	1.2936	1.3575	1.2723	1.2803	1.267	1.3086
2	1.267	1.2567	1.267	1.1996	1.2437	1.1765	1.2359
3	1.1765	1.2197	1.2127	1.1269	1.2071	1.1403	1.1451
4	1.086	1.134	1.2127	1.0542	1.1403	1.086	1.036
5	1.0136	1.0608	1.086	.9997	1.0498	1.1389	.9451
6	.8688	.9145	.9412	.9451	.9231	1.0136	.8724
7	.7783	.8507	.8688	.8543	.8326	.8688	.7997
8	.724	.7964	.7602	.7634	.8145	.8145	.7997
9	.7265	.7619	.7619	.8048	.7973	.8361	.815
10	.7796	.7619	.8145	.8413	.815	.8543	.8505
11	.815	.8505	.8238	.8596	.9671	.8724	.8954
12	.8596	.8954	.8417	.8779	1.0029	.927	.9492
13		.9313	.9671	.9412	.9671	.9997	
14		1.0029	1.0387	1.0631	.788	1.0905	
15	.905	1.0387	1.0745	1.2071	.724	1.0542	
16	1.0136	1.0029	1.086	1.134	1.1222	.9451	
17	.9694	.9774	.9815	1.0059	1.0679	.8724	1.134
18	.9145	.905	.9633	.7865		.7997	1.0974
19	1.0164	.8688	.9451	.924	1.0679	.9633	1.0534
20	1.1088	1.086	1.0724	1.0719	1.0679	1.0542	1.1273
21	1.2012	1.1222	1.1632	1.2012	1.3756	1.2178	1.2197
22	1.2936	1.267	1.3086	1.2752	1.3575	1.3268	1.3491
23	1.3306	1.3394	1.4177	1.3676	1.3756	1.3813	1.4045
24	1.3032	1.3121	1.448	1.3632	1.2986	1.3032	1.345
Max	1.3306	1.3394	1.448	1.3676	1.3756	1.3813	1.4045
Min	.724	.7619	.7602	.7634	.724	.7997	.7997
Avg	1.0182	1.0271	1.0589	1.0392	1.0559	1.0418	1.0692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 205 / 11KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7421	.6838	.4525	.5818	.5487	.181	.5067
2	.724	.7207	.4706	.5442	.5304	.2172	.4692
3	.7059	.7392	.4344	.5067	.5121	.181	.4316
4	.724	.695	.3982	.4504	.4525	.181	.4692
5	.6878	.695	.3982	.5255	.4163	.1629	.4879
6	.724	.6767	.4706	.6381	.3982	.1629	.4879
7	.7602	.5792	.4344	.5067	.6697	.1629	.5255
8	.7964	.5068	.4525	.4504	.7602	.1991	.563
9	.815	.6201	.5316	.6401	.815	.2252	.6024
10	.8859	.7087	.6024	.9145	.8505	.244	.6556
11	.815	.7087	.8596	1.0059	.7164	.3003	.8238
12	1.0099	.8954	.9036	1.0517	.7164	.2627	2.5431
13	1.0745	.8238	.7701	1.0498	.7522	.3003	.8059
14	1.1104	.7164	.8238	1.0059	.8059	.319	.905
15	1.1584	.6805	.7164	.9145	.7783	.4879	
16	1.086	.7164	.9774	.8048	.7964	.7131	1.9547
17	1.0242	1.4766	.8257	.6401	.905	.7319	2.268
18	1.0242	.6516	.6756	.4938		.7131	
19	.924	.543	.5255	.5914	.905	.563	.5359
20	.6283	.5068	.4692	.6468		.4129	.6099
21	.6283	.3982	.4129	.5544	.1448	.5067	.6283
22	.5914	.3801	.4879	.6653	.181	.6005	.7392
23	.5544	.362	.6005	.7947	.181	.6381	.6283
24	.724	.7023	.4163	.6381	.5914	.181	.563
Max	1.1584	1.4766	.9774	1.0517	.905	.7319	2.5431
Min	.5544	.362	.3982	.4504	.1448	.1629	.4316
Avg	.8299	.6745	.5879	.6923	.6103	.3603	.8275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 401 / 33KV TATA EXP FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS) (NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2443	.2495	.2281	.2215	.2195	.2281	.2492
2	.2443	.2384	.2335	.2377	.2085	.2172	.2382
3	.2281	.2218	.2281	.2094	.2305	.2063	.2266
4	.2172	.214	.2063	.1864	.2118	.1955	.2149
5	.2118	.225	.19	.1184	.192	.2009	.2026
6	.1955	.1975	.1846	.1896	.2009	.19	.1745
7	.2009	.1792	.1738	.1347	.1629	.1846	.1842
8	.2063	.1466	.1357	.2035	.1738		.2035
9	.2551	.1754	.1807	.2359	.202	.2154	.2233
10	.2764	.2445	.2126	.2195	.2551	.2323	.2498
11	.2286	.2443	.2257	.214	.2149	.2167	.2686
12	.2924	.2364	.2042	.2634	.1773	.2229	.2848
13	.2042	.2471		.2226	.2118	.2013	.2498
14	.2443	.2203		.1701	.19	.1747	.2443
15	.2661	.2471	.1612	.2414	.2172	.2503	.2443
16	.2606	.2364	.1504	.2743	.2389	.2347	.2715
17	.2524	.2335	.2013	.2469	.2769	.219	.2359
18	.2085	.2281	.2129	.1975		.2307	.2469
19	.2329	.2335	.186	.2661		.2204	.2772
20	.255	.2281	.1973	.2495		.2045	.2329
21	.2661	.2118	.2089	.2329	.2063	.2153	.2273
22	.2439	.2172	.1934	.194	.1975	.1994	.194
23	.2218	.2226	.1662	.2162	.1955	.1887	.2107
24	.2443	.2717	.2172	.2	.2329	.2226	.2273
Max	.2924	.2717	.2335	.2743	.2769	.2503	.2848
Min	.1955	.1466	.1357	.1184	.1629	.1747	.1745
Avg	.2375	.2238	.1954	.2144	.2103	.2118	.2326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 201 / 11 kV Umrer U I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0189	.0183	.0183	.0189	1.2803	.0183
2	.0183	.0189	.0183	.0183	.0189	1.1888	.0183
3	.0183	.0189	.0183	.0183	.0189	1.086	.0183
4	.0183	.0189	.0183	.0183	.0189	1.0608	.0183
5	.0183	.0189	.0183	.0183	.0189	1.0059	.0183
6	.0183	.0189	.0183	.0183	.0189	.9511	.0183
7	.0183	.0189	.0183	.0183	.0189	.823	.0183
8	.0183	.0189		.0183	.0189	.695	.0183
9	.0183	.0189	.0183	.0183	.0189	.7682	.0183
10	.0183	.0189	.0183	.0183	.0189	.7682	.0183
11	.0189	.0183	.0183	.0189	.0183	.7682	.0189
12	.0189	.0183	.0183	.0189	.0183	.8413	.0189
13	.0189	.0183	.0183	.0189		.9511	.0189
14	.0189	.0183	.0183	.0189	.0183	.9145	.0189
15	.0189	.0183	.0183	.0189	.0183	.0183	.0189
16	.0189	.0183		.0189	.0183	.0183	.0189
17	.0189	.0183	.0183	.0189		.0183	.0189
18	.0189	.0183	.0183	.0189		.0183	.0189
19	.0189	.0183	.0183	.0189	.0183	.0183	.9145
20	.0189	.0183	.0183	.0189	.0183	.0183	1.0242
21	.0189	.0183	.0183	.0189	.2195	.0183	1.0791
22	.0189	.0183	.0183	.0189	1.3169	.0183	1.2803
23	.0189	.0183	.0183	.0189	1.3169	.0183	1.3169
24	.0183	.0189	.0183	.0183	.0189	1.3169	.0183
Max	.0189	.0189	.0183	.0189	1.3169	1.3169	1.3169
Min	.0183	.0183	.0183	.0183	.0183	.0183	.0183
Avg	.0186	.0186	.0183	.0186	.1519	.6077	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 202 / 11 KV UMRER U II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1646	.1829	.1463	.1463	.1463	.1646
2	.1463	.1646	.1829	.1463	.1463	.1463	.1646
3	.1097	.1463	.1646	.1463	.1463	.1097	.1646
4	.0732	.1463	.1448	.1097	.128	.1097	.1646
5	.0732	.128	.1463	.1097	.128	.0914	.1646
6	.0732	.1097	.1097	.1097	.1097	.0914	.1646
7	.0732	.0934	.1086	.128	.0914	.0914	.128
8	.1097	.0914	.1097	.128	.1097	.1097	.128
9	.1097	.0914	.1097	.128	.1097	.1463	.1097
10	.1097	.0914	.1097	.128	.1097	.1097	.1097
11	.1097	.1097	.1097	.1097	.1097	.1097	.1097
12	.1097	.1463	.1097	.1463	.1097	.1097	.132
13	.0914	.1463	.1097	.128		.128	.1097
14	.1097	.1463	.1097	.128	.1646	.128	.128
15	.1463	.128	.1463	.128	.1463	.1097	.1097
16	.1463	.1097	.1463	.1463	.1646	.0183	.1097
17	.1097	.1097	.1463	.1097		.0914	.128
18	.1097	.1097	.1463	.0732		.0914	.128
19	.1097	.1086	.1463	.0914	.1097	.1097	.128
20	.128	.1097	.1646	.128	.1463	.1097	.128
21	.128	.128	.1646	.1463	.1463	.1097	.128
22	.1463	.1463	.1829	.1646	.1097	.1463	.128
23	.1646	.1848	.1829	.1646	.1463	.1646	.1646
24	.1463	.1478	.1646	.1463	.1463	.1463	.1463
Max	.1646	.1848	.1829	.1646	.1646	.1646	.1646
Min	.0732	.0914	.1086	.0732	.0914	.0183	.1097
Avg	.1158	.1274	.1416	.1288	.1297	.1135	.1350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 203 / 11 KV HEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7682				.7316	.7316
2		.7316			1.3535	.7316	.6584
3		.695			1.3535	.695	.6219
4		.6584		.5853	1.3169	.6401	.5487
5		.6584		.6219	1.2437	.5731	.4755
6		.5487		.6584	1.0974	.5487	.4755
7		.3292		.6584	1.3169	.5487	.362
8		.5121		.6219	1.39	.4024	.3258
9		.0183		.6584	1.5364	.5487	.2926
10		.5304		.695	1.5546	.5853	
11	.0187	.695		.4527	1.6461	.5487	
12	.0366	.7682	.5792	.7316		.5487	.5304
13	.439	.7682	.7964	.6413		.5487	.8048
14	.439	.7634	.7964	.9511		.5121	.8413
15	.4755	.7682	.7682	.9145		.5121	.8048
16	.7133	.7316	.7682	.7499		.4755	.695
17	.695	.695	.7316			.4024	.695
18	.695	.695	.695	.3658	.4572	.4755	.6219
19	.7133	.7316	.724	.5121	.6401	.5487	.695
20	1.1706			.695	.695	.6036	.8048
21				1.4632	.8413	.5973	
22	.695			1.4266	.8048	.5487	.0732
23	.8048			1.39	.7682	.5487	.8048
24		.7682			1.3717	.7682	.7316
Max	1.1706	.7682	.7964	1.4632	1.6461	.7682	.8413
Min	.0187	.0183	.5792	.3658	.4572	.4024	.0732
Avg	.5747	.6417	.7324	.7786	1.1404	.5685	.5997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 205 / 11 KV MAKARDHOKDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487			.5304
2		.5121			.5121
3		.5121			.5121
4		.4938		.3658	.4938
5		.4755		.4024	.4938
6		.4572		.4024	.4572
7		.4572		.439	.5121
8		.4938		.5487	.5121
9		.5487		.5853	.567
10		.5487		.6219	.5853
11	.439	.5487		.6584	.5487
12	.5487	.5487	.543	.8779	
13	.4572		.724	.9877	
14	.5121		.7316	1.0242	
15	.5853	.6536	.695	.9877	
16	.567	.5792	.695	.7865	
17	.4572	.6584	.5487		
18	.4572	.6584	.5304		
19	.439	.5853	.5792	.2743	
20	1.2071			.6219	
21	.5121			.5487	
22	.5121			.5487	
23	.5853			.5487	
24		.5487			.567
Max	1.2071	.6584	.7316	1.0242	.5853
Min	.439	.4572	.5304	.2743	.4572
Avg	.5599	.5460	.6309	.6239	.5243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 207 / 11KV Express Water work
feeder Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732		.0914	.0732	.0914	1.0242	.0549
2	.0732		.0914	.0732	.1463	.9877	.0549
3	.0914		.0732	.0732	.1646	.9511	.0732
4	.1097		.0914	.0732	.1463	.8779	.0732
5	.1448		.1097	.0366	.128	.7682	.0732
6	.1463		.1433	.0366	.0549	.6584	.1097
7	.1463		.1086	.0732	.1463	.5853	.0914
8	.1448		.1646	.1463	.128	.5121	.0914
9	.1463		.1463	.1463	.1097	.5121	.0914
10	.1097		.1086	.128	.128	.5487	.0732
11	.1097		.1463	.1463	.1463	.5853	
12	.0549		.1463	.0914	.1463	.5853	.0366
13	.0183		.0914	.0732		.5853	.0366
14	.128		.1097	.1097	.1097	.5487	.0549
15	.1463		.1463	.128	.1463	.0549	.0366
16	.1463		.1463	.1646	.1097	.0549	.0366
17	.1097	.1097	.1463	.0732		.0549	.0732
18	.1463	.1097	.1463	.1463		.0549	.0732
19	.1097	.1097	.1463	.1646		.0732	.0732
20	.128	.1086	.128	.1097	.8413	.0732	.0914
21		.1086	.128	.1463	.7682	.0732	.0914
22		.0895	.1097	.1463	.8779	.1097	.0366
23		.0914	.0732	.1463	.9145	.128	.0549
24	.0732		.0914	.0732	.0914	.8048	.0366
Max	.1463	.1097	.1646	.1646	.9145	1.0242	.1097
Min	.0183	.0895	.0732	.0366	.0549	.0549	.0366
Avg	.1122	.1039	.1202	.1075	.2698	.4672	.0660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 208 / 11KV UMRER AG SEPERATED

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0366		.128	.1646	.0732	.1097	
11	.0366	.0732	.0366	.0914	.0924	.0732	.0549
12	.0549	.0732	.0732	.128	.0732	.0732	.0549
13	.0549	.0549	.128	.1829	.0914	.0366	.0549
14	.0732	.0905	.1463	.1646	.0905	.0732	.0366
15	.0732	.1086	.1829	.1646	.0905	.0732	.0366
16	.0914	.128	.1829	.1463	.0914		.0549
17	.0732	.128	.2012	.0366		.0732	.0549
20							.0189
21							.0189
Max	.0914	.128	.2012	.1829	.0924	.1097	.0549
Min	.0366	.0549	.0366	.0366	.0732	.0366	.0189
Avg	.0618	.0938	.1349	.1349	.0861	.0732	.0428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 402 / 33 KV PACHGAON -VIRANGANA- NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7133	.9774	.6516	.7133	1.3169	1.2489
2	.543	.7133	.8779	.6584	.7133	1.3169	1.2071
3	.543	.6584	.8779	.6584	.7133	1.3032	1.086
4	.3801	.6584	.8059	.5487	.7133	1.0974	1.086
5	.3801	.6036	.7682	.543	.6584	.9877	.8688
6	.3801	.6036	.6584	.543	.6036	.7682	.7059
7	.439	.4938	.499	.543	.6584	.7133	.7602
8	.4938	.5487	.8779	.6516	.6584	.9328	.9231
9	.5487	.7133	1.0974	.6516	.7133	.9877	1.086
10	.8145	.7682	1.1523	.7602	.7133	1.0425	1.3169
11	.9877		1.1946	1.0974	.7682	1.2489	1.3717
12	.823	1.1523	1.1946	1.0425	.7133	1.086	1.4815
13	.823	.9877	1.086	1.1523	.823	.9774	1.4815
14	.9877	1.0974	1.086	1.0425	.9774	.9774	.9328
15	1.0974	1.1523	1.086	1.0425	.9774	.6516	1.0974
16	1.0425	.7133	1.086	.9877	.9877	.6516	1.0425
17	.9877	.7133	.9774	.6584	.9877	.7059	1.3717
18	.439	.7133	.6516	.3841	1.0974	.7602	1.1523
19	.4938	.5973	.7522	.5487	1.3169	1.086	1.1523
20	.6584	.8779	.8596	.7682	1.3169	1.1946	1.5364
21	.7133	.8779	.8596	.7682	1.4266	1.1946	1.4266
22	.7682	.9774	.8688	.7682	1.4266	1.3032	.9328
23	.7133	.9328	.8688	.7682	1.3169	1.3032	.8779
24	.7059	.7133	.823	***	.7682	1.2071	1.3032
Max	1.0974	1.1523	1.1946	70.8049	1.4266	1.3169	1.5364
Min	.3801	.4938	.499	.3841	.6036	.6516	.7059
Avg	.6840	.7818	.9161	3.6685	.9068	1.0339	1.1437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 404 / 33 KV NCDC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8461	1.7558	2.1719	2.1719	1.9753	1.701	1.7375
2	1.6289	1.5364	2.0851	1.9547	1.7558	1.6461	1.6289
3	1.6289	1.8107	1.9204	1.9547	1.5364	1.5364	1.6289
4	1.4118	1.4815	1.6118	1.6289	1.5912	1.4266	1.4118
5	1.1946	1.5364	1.3575	1.5203	1.701	1.3169	1.086
6	1.086	1.5364	1.0974	1.4118	1.2071	1.1523	.9231
7	1.2071	1.701	1.6289	1.3032	1.4266	1.3169	1.086
8	1.5912	1.6461	1.4815	1.1946	1.1523	1.3169	1.4118
9	1.5203	1.6461	1.4815	1.3032	1.2071	1.2071	1.4118
10	1.5203	1.5912	1.262	1.3575	1.4266	1.4266	1.3575
11	1.4815	1.7558	1.6289	1.4266	1.7558	1.7918	1.6461
12	1.6632	1.701	1.4118	1.5364	1.7558	1.7918	1.8107
13	1.4815	1.262	1.1946	1.3717	1.4815	1.7375	1.4266
14	1.701	1.3169	1.3032	1.5364	1.5203	1.8461	1.4815
15	2.3045	1.4118	1.6289	1.701	1.9753	1.9547	1.5364
16	1.5364	1.9204	1.9547	1.8656	1.6461	1.9547	1.8107
17	1.7558	1.7558	1.8461	1.4815	1.3717	1.9547	1.6461
18	1.6461	1.8656	1.6289	1.4815	1.5364	1.9547	1.8656
19	2.0302	1.9753	1.6289		1.4266	1.8461	2.0302
20	1.9204	1.9753	1.5746	1.4266	1.3717	1.7375	2.0302
21	1.701	1.7558	1.5746	1.5912	1.3575		1.7558
22	1.8107	1.5912	1.8461	1.5364	1.4815	1.9004	1.6461
23	1.8656	1.6461	2.3348	1.9204	1.6461	1.9004	2.1948
24	1.9004	2.0851	1.9753	2.2262	1.8656	1.6461	1.7193
Max	2.3045	2.0851	2.3348	2.2262	1.9753	1.9547	2.1948
Min	1.086	1.262	1.0974	1.1946	1.1523	1.1523	.9231
Avg	1.6431	1.6775	1.6512	1.6044	1.5488	1.6549	1.5951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 201 / 11 KV TOWN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.5716	.4954	.381	.381	.5335
2	.381	.381	.5335	.4954	.381	.381	.5335
3	.381	.381	.5335	.4763	.381	.381	.5144
4	.381	.381	.5144	.4763	.2858	.381	.5144
5		.381	.5144	.4572	.2286	.381	.5335
6	.3429	.381	.4954	.4572	.2286	.381	.5335
7	.2286	.381	.5335	.5335	.381	.381	.4954
8	.3429	.381	.5335	.5335	.3429		.4763
9	.5716	.5716	.5716	.6859	.381	.1905	.5716
10	.8383	.5716	.5716	.8764	.6668	.381	.6478
11	.8573	.7621	.5716	.9145	.7621	.5716	.7621
12	.9145	.8764	.5335	.9526	.9526	.5716	.9526
13	.9526	.9145	.6097	.8764	.9526	.6097	.9526
14	.9335	.8383	.6097	.8383	.9526	.6859	.7621
15	.9526	.8383	.5716	.8383	.9526	.8002	.9526
16	.9526	.9907	.5716	.8573		.8002	.7621
17	.7621	.8383	.6097	.7621	.5716	.5716	.7621
18	.7621	.6859	.5335	.7621	.7621	.4382	.7621
19	.7621	.6478	.5335	.6097	.381		.5716
20	.5716	.4954	.5335	.5335	.381	.4191	.381
21	.7621	.5144	.5335	.4763	.4572	.4572	.381
22	.5716	.5335	.5525	.381	.4191	.4954	
23	.5716	.5525	.5335	.381	.381	.4572	.1905
24	.381	.381	.5716	.5144	.381	.381	.5335
Max	.9526	.9907	.6097	.9526	.9526	.8002	.9526
Min	.2286	.381	.4954	.381	.2286	.1905	.1905
Avg	.6329	.5858	.5518	.6327	.5202	.4772	.6122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 202 / 11 KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.6766	1.5623	1.9433	1.448	1.5242	1.0669
2	1.7147	1.7909	1.6004	1.9814	1.4098	1.448	1.105
3	1.6385	1.829	1.4861	1.9624	1.3717	1.4289	1.105
4	1.6766	1.9814	1.6385	1.8671	1.4098	1.448	1.086
5	1.5242	2.0957	1.2955	1.7528	1.3717	1.9433	1.105
6	1.6004	1.7147	.9526	1.5623	1.448	1.9433	1.1431
7	1.1431	.9526	1.2574	1.6004	1.6004	1.2193	1.0288
8	1.2193	.8383	1.3336	1.5242	1.7528		.9526
9	1.1431	1.1431		1.7528	1.3527	.7621	1.2574
10	1.448	1.2193	1.1431	1.8671	2.2481	.7621	1.2765
11	1.5242	1.448	1.6004	1.6766	1.8671	.8764	1.7909
12	1.5242	1.5242	1.7147	1.5242	1.1431		1.9052
13	1.5242	1.2193	1.6766	1.448	1.6766		1.6766
14	1.5242	1.0669	1.5432	1.3717	2.0005		1.2193
15	1.6766	1.6766	1.9814	1.448	1.6766	.8573	1.3717
16	1.5242	2.6673	2.553	1.6004		.9335	1.3908
17	1.9052	1.7147	2.5149	1.2193	1.5242	.8002	1.3717
18	2.2862	1.5242	2.4196	1.2193	1.6004	.8764	1.2955
19	2.1338	1.448	2.0576	1.6004	1.5242	.9145	1.2955
20	1.5051	1.2955	1.2574	1.2193	1.5623	1.0479	1.2193
21	1.5242	1.7909	1.6575	1.3336	1.6004	1.105	1.2193
22	1.6385	1.8861	2.0767	1.6004	1.6194	1.1431	1.1431
23	1.7909	1.4861	1.9814	1.5242	1.5242	1.105	1.1431
24	1.9052	1.7147	1.1812	1.829	1.448	1.6004	1.0479
Max	2.2862	2.6673	2.553	1.9814	2.2481	1.9433	1.9052
Min	1.1431	.8383	.9526	1.2193	1.1431	.7621	.9526
Avg	1.6202	1.5710	1.6733	1.6012	1.5730	1.1869	1.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 203 / 11 KV WENA FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.362	.381	.362	.381	.381
2	.362		.381	.381	.362	.381	.381
3	.362	.362	.381	.381	.362	.381	.381
4	.362	.362	.362	.381	.362	.3239	.4001
5	.362	.362	.362	.381	.362	.362	.381
6	.362	.362	.362	.381	.362	.362	.381
7	.362	.381	.362	.381	.362	.381	.4001
8	.362	.362	.362	.381	.362		.381
9	.4191	.362	.381	.381	.362		.381
10	.381	.381	.381	.4001	.381		.381
11	.381	.381	.381	.4001	.381		.381
12	.381	.381	.381	.381	.2096		.381
13	.381	.381	.381	.381	.2286		.381
14	.381	.381	.381	.381	.381	.1715	.381
15	.381	.4001	.381	.381	.381	.3239	.381
16	.4001	.4001	.381	.381	.2286	.4572	.381
17	.381	.381	.381	.3239	.381	.381	.381
18	.362	.362	.381	.362	.381	.381	.381
19	.362	.362	.381	.362	.362	.4001	.362
20	.362	.362	.381	.381	.362	.381	.362
21	.362	.362	.381	.381	.362	.4001	.362
22	.381	.362	.381	.362	.362	.381	
23	.381	.362	.381	.362	.362	.381	.362
24	.362	.362	.362	.381	.362	.381	.381
Max	.4191	.4001	.381	.4001	.381	.4572	.4001
Min	.362	.362	.362	.3239	.2096	.1715	.362
Avg	.3731	.3711	.3755	.3770	.3493	.3673	.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 204 / CHANVIM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762	.0953	.0762	.1143	.1143	.0953
2	.1524	.0762	.0953	.0762	.1143	.1143	.0953
3	.1334	.0572	.0953	.0762	.1143	.1143	.0762
4	.1334	.0572	.1143	.0762	.1143	.1143	.0762
5	.1143	.0762	.0953	.0762	.1143	.0953	.0762
6	.1524	.0762	.0953	.0762	.1143	.0953	.0762
7	.1143	.1334	.0762	.0762	.1143	.0953	.0762
8	.1143	.1905	.0762	.0762	.1905		.0953
9	.2858	.3429	.0762	.2667	.2477	.2286	.2667
10	.5144	.362	.1143	.3239	.3429	.3429	.3239
11	.5144	.381	.0762	.4572	.362	.3429	.381
12	.4763	.1905	.1143	.4382	.381	.381	.4191
13	.4191	.3429	.0953	.381	.3429	.4191	.4191
14	.4001	.3429	.0953	.3429	.3429	.362	.4382
15	.4763	.4191	.0762	.362	.3429	.3429	.4191
16	.4191	.4001	.0762	.381	.2858	.3239	.3429
17	.381	.3048	.0762	.2477	.2667	.3239	.3048
18	.2858	.2667	.0762	.2477	.2667	.2858	.2667
19	.2667	.2286	.0762	.2286	.2667	.2286	.2667
20	.1905	.2286	.0762	.1905	.1905	.2286	.1524
21	.1524	.1524	.0953	.1715	.1715	.1905	.1524
22	.1524	.1143	.0762	.1524	.1715	.1524	
23	.1524	.1143	.0762	.1524	.1524	.1524	.1905
24	.1524	.1524	.0953	.0762	.1143	.1524	.1143
Max	.5144	.4191	.1143	.4572	.381	.4191	.4382
Min	.1143	.0572	.0762	.0762	.1143	.0953	.0762
Avg	.2628	.2119	.0881	.2096	.2183	.2261	.2228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 206 / 11KV GONDKHAIRY AG SEP SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0381	.0381	.0381	.0191	.0381
2	.0381	.0191	.0381	.0381	.0381	.0191	.0381
3	.0381	.0381	.0381	.0381	.0381	.0191	.0381
4	.0381	.0381	.0381	.0381	.0191	.0191	.0381
5	.0381	.0381	.0381	.0381	.0191	.0191	.0381
6	.0381	.0191	.0381	.0381	.0191	.0191	.0191
7	.0381	.0191	.0191	.0381	.0381	.0191	.0191
8	.0381	.0381	.0191	.0381	.0381		.0191
9	.1143	.1524	.1143	.0762	.0953	.0381	.0381
10	.0762	.1905	.0762	.0762	.1143	.1334	.0762
11	.0762	.1905	.0953	.0762	.1334	.0953	.0762
12	.0762	.0953	.0953	.0762	.1334	.0572	.0572
13	.0953	.1143	.1143	.0762	.1334	.0381	.0953
14	.0953	.1334	.1334	.0762	.0762	.0381	.0572
15	.1143	.1143	.1143	.0762	.0762	.0381	.0572
16	.1143	.1143	.1334	.0762	.0381	.0572	.0762
17	.0191	.0191	.0191	.0191	.0191	.0191	.0381
18	.0191	.0191	.0381	.0191	.0191	.0191	.0381
19		.0191	.0381	.0381	.0191	.0381	.0381
20	.0191	.0381	.0381	.0381	.0381	.0381	.0381
21	.0191	.0381		.0381	.0191	.0381	.0191
22	.0191	.0381	.0381	.0381	.0191	.0381	
23	.0191	.0381	.0381	.0381	.0191	.0381	.0191
24	.0381	.0191	.0381	.0381	.0381	.0191	.0381
Max	.1143	.1905	.1334	.0762	.1334	.1334	.0953
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0530	.0651	.0605	.0492	.0516	.0381	.0439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 207 / 11 KV NEW TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.724	.8383	.8383	.6478	.7621	.8002
2	.8002	.724	.8383	.8383	.6478	.8002	.7811
3	.8002	.7049	.8002	.8002	.6097	.743	.7811
4	.743	.6859	.8002	.7621	.6097	.743	.6859
5	.743	.6668	.7621	.724	.5716	.6859	.6859
6	.5906	.6668	.724	.6668	.5144	.6097	.6097
7	.4954	.5716	.6478	.5716	.5144	.5716	.5716
8	.4954	.5335	.5906	.4954	.4954		.5525
9	.5335	.5906	.6287	.5716	.6287	.381	.6097
10	.6097	.6668	.6668	.743	.724	.6287	.7049
11	.8192	.7811	.6859	.8192	.8573	.6859	.8002
12	.9145	.8764	.6859	.8764	.8954	.8192	.8192
13	.8764	.8573	.724	.8002	.9526	.8573	.9145
14	.9335	.8573	.7811	.8764	1.0098	.4191	.9526
15	.8954	.9907	.8002	.9145	.9717	.8383	.9717
16	.8954	1.0669	.8192	.9526	.8383	.9335	.9907
17	.8573	.9907	.7811	.1715	.8954	.8954	.9717
18	.8192	.8954	.743	.5144	.8192	.8764	.8573
19	.8573	.8764	.7621	.6097	.8002	.8573	
20	.7621	.8573	.8002	.6097	.8383	.8383	.9335
21	.8383	.9145	.8573	.7621	.724	.8383	.9145
22	.8764	.9717	.9526	.8192	.8383	.8383	
23	.8002	.9145	.9526	.8192	.8002	.8192	
24	.8383	.7621	.8764	.8764	.724	.7811	.8192
Max	.9335	1.0669	.9526	.9526	1.0098	.9335	.9907
Min	.4954	.5335	.5906	.1715	.4954	.381	.5525
Avg	.7748	.7978	.7716	.7264	.7470	.7488	.7966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 401 / 33 KV NISHANT TUBE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0018	10.1166	10.1738	9.2593	8.6877	9.4879	9.2021
2	7.4303	10.2881	9.6022	9.3736	8.802	9.7165	8.6877
3	8.0018	10.7453	9.8308	9.7165	9.0306	8.802	9.0306
4	5.7156	11.2026	10.0595	8.8592	8.5734	7.4303	8.059
5	5.2584	9.145	9.3736	9.0306	8.0018	5.9442	8.4591
6	2.9721	9.0306	10.1166	8.6877	7.6589	5.3727	8.6877
7	6.0014	8.0018	10.0595	9.145	9.3164	7.316	9.7165
8	7.0302	7.7732	8.0018	8.802	7.0873		8.7449
9	8.6877	8.2876	8.4591	8.4591	6.8016	5.3727	8.059
10	7.7161	9.145	9.0306	8.6306	8.6877	6.7444	8.0018
11	10.3452	9.3736	9.2593	9.9451	9.0306	8.2876	8.2876
12	10.7453	9.0306	7.7732	9.5451	9.145	8.802	7.9447
13	10.1166	9.3736	8.2305	9.7165	8.8592	9.3736	6.5729
14	9.3736	9.145	9.0878	9.9451	9.3164	9.2021	5.7156
15	10.2881	8.0018	7.6589	10.0595	9.0878	8.9163	8.059
16	8.8592	7.0873	4.5153	9.5451	9.145	8.4019	8.5734
17	8.5734	6.6301	4.6868	8.8592	8.2876	8.802	8.0018
18	8.0018	8.802	7.2588	9.145	5.9442		7.4303
19	8.2876	9.6022	8.1162	8.5162	8.8592	7.4303	7.9447
20	7.7161	9.4307	7.8304	9.2021	8.2876	9.4307	8.5734
21	7.7732	9.6022	7.8875	8.7449	9.8308	9.2021	7.7161
22	7.8875	9.888	9.888	7.0873	9.6594	10.2881	
23	8.2876	9.145	8.8592	7.7161	10.2881	10.1738	4.5725
24	8.9735	9.145	8.2305	9.145	8.802	11.0883	8.9163
Max	10.7453	11.2026	10.1738	10.0595	10.2881	11.0883	9.7165
Min	2.9721	6.6301	4.5153	7.0873	5.9442	5.3727	4.5725
Avg	8.0018	9.0830	8.4996	9.0473	8.6329	8.4357	8.0416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 201 / 11 KV MIDC -I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.4335	1.5089	1.5089	1.0562	1.358	.3584
2	1.4918	1.3957	1.4712	1.4712	1.226	1.2826	.3395
3	1.6032	1.3957	1.4712	1.4712	1.2449	1.2071	.3395
4	1.5466	1.358	1.4335	1.4335	1.2826	1.1694	.3584
5	1.5089	1.358	1.3957	1.4335	1.1559	1.1694	.3395
6	1.4901	1.3203	1.3203	1.3957	1.226	1.1128	.3206
7	1.3392	1.2826	1.4146	1.358	1.4901	1.1506	.3206
8	2.1313	2.0182	1.9427	1.7918	2.1691	.7922	1.0374
9	2.584	2.3577	2.2257	2.2445	2.2445		1.448
10	2.584	2.2257	2.6029	2.2257	2.7349		1.7147
11	2.7349	2.452	2.452	2.5463	2.2634	.8676	1.7718
12	2.6972	2.7161	2.6029	2.4709	2.6406	.9619	1.2384
13	2.3388	2.3577	2.4897	2.4331	2.4709	.9808	2.0005
14	2.2257	2.6029	2.6029	2.3765	2.1125	.9808	2.0767
15	2.7349	2.3577	2.0936	2.32	2.4897	1.0374	2.1529
16	2.6029	2.3011	2.4143	1.9993	2.32	.9431	2.1338
17	2.4331	2.0936	1.9805	2.3577	2.3388	.7733	2.0767
18	2.1691	1.9239	1.9239	1.6975	1.8107		1.848
19	2.037	1.9239	1.7541	1.773	1.5844	.3395	1.9052
20	1.8484	1.7164	1.7353	1.8484	1.358	.3395	1.9433
21	1.8107	1.9805	1.7353	1.7918	1.6221	.3395	1.9814
22	1.7353	1.905	1.7353		1.5278	.3772	
23	1.6598	1.4901	1.7353	.6036	1.5278	.3772	
24	2.0748	1.4712	1.5089	1.5089	.642	1.4146	.3584
Max	2.7349	2.7161	2.6029	2.5463	2.7349	1.4146	2.1529
Min	1.3392	1.2826	1.3203	.6036	.642	.3395	.3206
Avg	2.0450	1.8932	1.8979	1.8287	1.7725	.9035	1.2756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 202 / 11 KV MIDC-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8865	.9431	.811	.5133	.5281	.3584
2	.9431	.8865	.8676	.7733	.5847	.5093	.3772
3	.9808	.8488	.7922	.7167	.5658	.5093	.415
4	1.0185	.811	.7545	.6413	.6036	.4904	.415
5	1.0185	.7733	.7167	.6036	.5682	.4904	.3772
6	.9431	.7167	.6413	.547	.6224	.4715	.3584
7	.9242	.679	.8676	.4904	.7545		.4904
8	.9242	.9054	1.3203	1.226	.8945	.3395	.7922
9	1.5089	1.0374	1.4523	1.2826	1.2449	.4338	.8954
10	1.5089	1.6032	1.1883	1.1317	1.4146	.4904	1.105
11	1.8296	1.6975	1.4523	1.6975	1.4712	.4338	1.2384
12	1.6975	1.8484	1.6221	1.905	1.2637	.5093	1.2384
13	1.358	1.1506	1.5466	1.1831	1.2637	.5658	.8764
14	1.4712	1.3014	1.2826	1.5655	1.2449	.6224	1.5623
15	1.5466	1.5844	1.6598	1.8107	1.6409	.4904	1.1622
16	1.6598	1.7541	1.5278	1.2071	1.4712	.5281	1.105
17	1.5655	1.8484	1.773	1.0185	1.4901		1.3146
18	1.226	1.3014	1.8484	1.094	.9242		.9526
19	.9054	1.2637	1.0562	1.0374	.7922	.415	.9526
20	.8488	.6413	.9431	.8745	.6979	.415	.6478
21	.9242	.8299	.811	.8676	.4904	.4715	.6287
22	.9619	.9054	.8488	1.094	.4527	.4338	.6287
23	.9997	.9997	.8676	.5481	.5281	.3961	.362
24	.8865	.9242	.9431	.8488	.5658	.5281	.3584
Max	1.8296	1.8484	1.8484	1.905	1.6409	.6224	1.5623
Min	.823	.6413	.6413	.4904	.4527	.3395	.3584
Avg	1.1864	1.1333	1.1553	1.0406	.9193	.4796	.7755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 203 / 11 KV GONDKHAIRY

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	1.2449	1.3203	1.2449	.7545		.3772
2	1.0562	1.2449	1.3203	1.2071	.7733		.3772
3	1.0374	1.2826	1.2826	1.2449	.7922		.3395
4	1.0185	1.3203	1.2826	1.2826	.7545		.3395
5	.9808	1.358	1.3203	1.3203	.7922		.3584
6	1.1317	1.3957	1.3957	1.358	.7922		.3584
7	1.226	1.4146	1.3957	1.3957	.7922		.3961
8	1.5466	1.8107	1.8296	1.7541	.8299		.4527
9	1.1317	1.9239	1.9993	1.8296	.9808		.5335
10	1.6032	1.9805	2.037	1.6787	1.0374		.6097
11	1.7353	1.8861	1.8484		.9242		.5144
12	1.4146	1.7353	1.8484		.9808		.4954
13	1.5466	1.6598	1.7353	1.3014	.9054		.6287
14	1.5844	1.5844	1.4712	1.4335	.9808		.5144
15	1.5655	1.6409	1.6032	1.4335	.8676		.5144
16	1.8484	1.7918	1.7164			.0566	.5906
17	1.9239	1.9993	1.6598	.6036		.5847	.6287
18	1.773	1.8861	1.6221	.679			.4954
19	1.4901	1.773	1.4712	.7733		.0566	.5144
20	1.3769	1.3957	1.358	.8676		.3772	.9717
21	1.3769	1.4335	1.3014	.8488		.3772	.9717
22	1.358	1.4146	1.2826	.8676		.3772	
23	1.2826	1.3769	1.3014			.3772	
24	1.1506	1.2826	1.358	1.2826	.7538		.3961
Max	1.9239	1.9993	2.037	1.8296	1.0374	.5847	.9717
Min	.9774	1.2449	1.2826	.6036	.7538	.0566	.3395
Avg	1.3807	1.5765	1.5317	1.2203	.8570	.3152	.5172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 204 / 11 kv Mohapa

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0566	.0377	.0377	.0189
2	.0377	.0377	.0377	.0566	.0377	.0377	.0189
3	.0344	.0377	.0377	.0566	.0377	.0377	.0189
4	.0377	.0377	.0377	.0566	.0377	.0377	.0189
5	.0189	.0377	.0377	.0566	.0377	.0377	.0189
6	.0189	.0377	.0377	.0566	.0377	.0377	.0189
7	.0189	.0377	.0377	.0566	.0377	.0377	.0189
8	.0377	.0189	.0377	.0377	.0377	.0377	.0189
9	.0377	.0377	.0377	.0377	.0189	.0377	.0191
10	.0377	.0377	.0377	.0377	.0377	.0377	.0381
11	.0377	.0377	.0377	.0566	.0377	.0377	.0191
12	.0189	.0377	.0377	.0377	.0377	.0377	.0381
13	.0566	.0377	.0377	.0377	.0377	.0377	.0381
14	.0566	.0566	.0377	.0377	.0377	.0377	.0381
15	.0377	.0377	.0377	.0377		.0377	.0381
16	.0377	.0377	.0377	.0189	.0189	.0377	.0381
17	.0377	.0189	.0377	.0377	.0377	.0377	.0381
18	.0377	.0377	.0377	.0189	.0377	.0377	.0191
19	.0377	.0377	.0377	.0189	.0377	.0377	.0191
20	.0566	.0377	.0566	.0377	.0566	.0377	.0762
21	.0566	.0377	.0566	.0377	.0566	.0566	.0572
22	.0566	.0566	.0566	.0377	.0566	.0566	.0381
23	.0566	.0566	.0566	.0566	.0566	.0566	.0381
24	.0377	.0377	.0566	.0566	.0377	.0377	.0377
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0762
Min	.0189	.0189	.0377	.0189	.0189	.0377	.0189
Avg	.0392	.0385	.0416	.0432	.0394	.0401	.0309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 206 / 11 KV STEEL ASSOCIATE
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3395	.3584	.3018	.3395	.3584
2	.3018	.3395	.3395	.3584	.3206	.3395	.3395
3	.3018	.3395	.3395	.3395	.3206	.3395	.3395
4	.3206	.3395	.3206	.3395	.3206	.3395	.3206
5	.3018	.3395		.3395	.3206	.3395	.3395
6	.3395	.3395	.3584	.3395	.3206	.3584	.3584
7	.3395	.3395	.3206	.3395	.3206	.3772	.3395
8	.3206	.3395	.3018	.3395	.3206	.3584	.2829
9	.3772	.3206	.3018	.3772	.2829		.3048
10	.5847	.3584	.3584	.3772	.2829		.2858
11	.8488	.4527	.5093	.4338	.7167	.3772	.4382
12	.8488	.5281	.9242	.4904	.6413	.3206	.6859
13	.679	.6413	.679	1.2637	.9997	.3584	.6478
14	.3961	.7733	.8488	.4527	.8488	.3584	.7811
15	.9054	.4527	.8299	1.1883	.6036	.3395	.6287
16	.679	.7545	.5281	.9088	.8676	.3584	1.6956
17	.7922	.6602	.9619	.6413	.5281	.3772	1.2384
18	.6413	.4527	.7922	.3206	.3395		.9526
19	.5281	.3395	.3395	.3584	.3395	.3772	.3239
20	.3395	.3395	.3584	.3395	.3584	.3395	.3429
21	.3395	.3584	.3584	.3395	.3584	.3584	.3239
22	.3395	.3018	.3584	.3395	.3395	.3584	.3239
23	.3584	.3584	.3584	.3395	.3395	.3584	.362
24	.3206	.3395	.3584	.3584	.3206	.3395	.3584
Max	.9054	.7733	.9619	1.2637	.9997	.3772	1.6956
Min	.3018	.3018	.3018	.3206	.2829	.3206	.2829
Avg	.4794	.4228	.4863	.4701	.4464	.3530	.5155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 208 / 11 KV KALMESHWAR U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7726	2.7915	2.8292	2.9424	2.8292	2.7915	2.9235
2	2.6783	2.6406	2.7161	2.8292	2.7915		
3	2.6406	2.4897	2.6406	2.6406	2.7349	2.5463	2.7915
4	2.6406	2.3765	2.4897	2.452	2.5463	2.452	2.6406
5	2.6783	2.2634	2.3765	2.2634	2.452	2.2634	2.452
6	2.452	2.0748	2.1691	2.0748	2.0576	2.1125	2.0559
7	1.8296	1.8484	1.8296	1.9616	1.6975	1.8484	1.7918
8	1.6409	1.7353	1.7353	1.7918	1.6409	1.6975	1.6598
9	1.7353	1.5655	1.6598	1.8484	1.6409	1.7353	1.6766
10	1.7918	1.6787	1.7541	1.8861	1.7541	1.6409	1.7718
11	1.8484	1.8107	1.8484	1.9616	1.7541	1.5466	1.829
12	1.9805	2.037	1.9993	2.1125	1.9805	1.6598	2.0576
13	2.2634	2.1691	2.1879	1.9376	2.1691	1.9239	2.2291
14	2.3765	2.2634	2.2634	2.4331	2.3388	2.3577	2.4577
15	2.4331	2.3765	2.3954	2.5086	2.4331	2.5463	2.4958
16	2.4143	2.3388	2.3388		1.8484	2.5274	2.4387
17	2.2634	2.1879	2.1879	.679	1.6787	2.2445	2.1338
18	2.0748	1.9993	1.9427	.8488	1.8107		1.9433
19	2.1879	2.0559	2.1502	1.773		1.9427	2.1719
20	2.6217	2.5086	2.4897	2.4143		2.5086	2.4577
21	2.8481	2.6972	2.6217	2.5086	2.7915	2.6783	2.6673
22	2.8292	2.8481	2.8292	2.3834	2.8481	2.8292	
23	3.0367	2.8481	3.1121	2.8292	2.9613	2.8292	2.7244
24	2.8481	2.999	2.8292	3.0556	2.8669	2.9235	2.8481
Max	3.0367	2.999	3.1121	3.0556	2.9613	2.9235	2.9235
Min	1.6409	1.5655	1.6598	.679	1.6409	1.5466	1.6598
Avg	2.3703	2.2752	2.3082	2.1798	2.2557	2.2548	2.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 210 / 11 KV AGSEPARATED GHOGLI
FEEDER Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0189	.0189	.0189	
2				.0189	.0189	.0189	
3				.0189	.0189	.0189	
4				.0189	.0189	.0189	
5				.0189	.0189	.0189	
6				.0377	.0189	.0377	
7				.0754	.0171	.0377	
8				.0377	.0189	.0943	
9				.0566	.0189		
10	.0377	.0754	.0943				.0191
11	.0754	.0754	.1132			.0189	.0381
12	.0754	.0943	.0943			.0189	
13	.0566	.0566	.0566				.0191
14	.0566	.0566	.0566				.0191
15	.0377	.0566	.0566				
16	.0754	.0377	.0377				
17	.0754	.0566	.0377				
18		.0566					
24				.0189	.0171		
Max	.0754	.0943	.1132	.0754	.0189	.0943	.0381
Min	.0377	.0377	.0377	.0189	.0171	.0189	.0191
Avg	.0613	.0629	.0684	.0321	.0185	.0302	.0239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 211 / 11 kv NEW DHAPEWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)
1		.0189
2		.0189
3		.0189
4		.0189
5		.0189
6		.0189
7		.0189
8		.0189
10		.0191
11		.0191
12		.7621
13	.0189	.8383
14		.8383
15	.0189	.8383
16	.0189	.8192
17	.0189	.7621
18		.724
19	.0189	
23	.0189	
24	.0189	.0189
Max	.0189	.8383
Min	.0189	.0189
Avg	.0189	.3217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164064 / 33 KV KALMESHWAR

Feeder No / Name : 212 / 11 KV GURUNANAK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.0943	.0943	.0754	.0943	.0943
2	.0943	.0943	.0754	.0943	.0754	.0754	.0943
3	.0943	.0754	.0754	.0754	.0754	.0754	.0754
4	.0943	.0754	.0754	.0754	.0754	.0754	.0754
5	.0754	.0754	.0943	.0754	.0754	.0754	.0943
6	.0754	.0754	.0943	.0754	.0754	.0943	.0943
7	.0566	.0754	.0943	.0754	.0754	.0943	.0754
8	.0943	.0754	.0754	.0754	.132	.0943	.0943
9	.3206	.0754	.3018	.0754	.415		.0953
10	.3395	.0754	.2829	.0943	.3961		.1143
11	.3395	.1886	.3584		.3584	.0754	.1334
12	.3018	.3395	.1509		.415	.0943	.0953
13	.1509	.2075	.0943		.2075	.0943	.1334
14	.3395	.1132	.3395		.2075	.0943	.1334
15	.3206	.3772	.3961	.0189	.415	.1132	.1143
16	.3772	.4338	.3395	.1132		.0943	.0953
17	.3206	.415	.3584	.0857	.2263	.0754	.0953
18	.2641	.3018	.0943	.0943	.0943		.0762
19	.0943	.0754	.0943	.0943	.0943	.0943	.0762
20	.0943	.1132	.0943	.0943	.0943	.0943	.0762
21	.0943	.1132	.0943	.0943	.0943	.0754	.0762
22	.0943	.1132	.0943	.0857	.0754	.0943	
23	.0943	.0943	.0943	.0943	.0754	.0943	.0762
24	.1132	.0943	.0943	.0943	.0857	.0943	.0943
Max	.3772	.4338	.3961	.1132	.415	.1132	.1334
Min	.0566	.0754	.0754	.0189	.0754	.0754	.0754
Avg	.1815	.1572	.1650	.084	.1702	.0889	.0949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 201 / 11 KV Dhapewada town
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6668	.5335	.4954		.5144	.4458
2	.4954	.6478	.5144	.4954		.5144	.4287
3	.4572	.6287	.5144	.4954		.4763	.4287
4	.4572	.6287	.4763	.4954		.4763	.4115
5	.4572	.6097	.4763	.4572		.4572	.3772
6	.4001	.5144	.4001	.381		.381	.3601
7	.3239	.4382	.3048	.3239		.3048	.2915
8	.3048	.4191	.2858	.2667		.2858	.2743
9	.2667	.4763	.2667	.3048		.3429	.2743
10	.3239	.4191	.362	.4382		.3601	.362
11	.381	.4572	.4001	.3429		.3772	
12	.362	.5335	.381	.362	.6097	.4115	
13	.4001	.5525	.4572	.4191	.6097	.4287	
14	.4572	.4572	.4572	.4001	.5525	.4458	
15	.4763	.4954	.4382	.4382	.5525	.4287	
16	.4382	.4763	.4001		.4763	.4287	
17	.381	.4001	.362		.362	.3601	
18	.362	.381	.3429		.3239	.3086	
19	.4001	.4382	.4001		.4382	.3772	.4001
20	.4954	.4572	.4572		.4763	.4115	.4954
21	.6668	.5144	.5144		.4763	.4287	.6287
22	.7049	.5716	.5525		.5335	.463	
23	.6859	.5525	.5525		.5335	.4801	.4191
24	.5335	.5716	.5335	.5335		.5144	.4458
Max	.7049	.6668	.5525	.5335	.6097	.5144	.6287
Min	.2667	.381	.2667	.2667	.3239	.2858	.2743
Avg	.4485	.5128	.4326	.4156	.4954	.4157	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 202 / 11 KV Dhapewada Ag
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4954	.4763	.4572		.4763	.4458
2	.4572	.4954	.4572	.4572		.4763	.4458
3	.4572	.4763	.4572	.4572		.4572	.4287
4	.4191	.4572	.4572	.4572		.4572	.4115
5	.4191	.4191	.4954	.4572		.4382	.3772
6	.4191	.4382	.5716	.4763		.381	.3429
7	.4763	.4954	.5716	.5144		.3429	.3429
8	.5335	.5716	.6668	.5906		.3429	.4287
9	.6097	.743	.8002	.7049		.381	.4115
10	.6668	.7621	.7811	.7049		.3601	.4572
11	.743	.724	.6859	.6287			
12	.6668	.7049	.6668	.6287			
13	.6478	.5144	.6668	.5716	.1334		
14	.6478	.5716	.6668	.5716	.4954	.463	
15	.6287	.6478	.6097	.6097	.4191	.4801	
16	.6287	.6859	.6478		.4382	.4287	
17	.6287	.724	.6287		.2858	.3772	
18	.5906	.743	.6097		.2858	.3086	
19	.5525	.5906	.4954		.362	.3944	.4001
20	.5906	.5906	.5144		.4191	.4287	.5144
21	.5525	.5144	.4954		.4763	.4801	.4954
22	.5525	.4954	.4954		.4954	.4801	
23	.5144	.4954	.4954		.4954	.4801	
24	.4763	.4954	.4763	.4763		.4763	.463
Max	.743	.7621	.8002	.7049	.4954	.4801	.5144
Min	.4191	.4191	.4572	.4572	.1334	.3086	.3429
Avg	.5557	.5771	.5787	.5477	.3914	.4243	.4261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164066 / 33 KV DHAPEWADA

Feeder No / Name : 203 / 11 KV Purti feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.0191		
11		.0191		.0343
12	.0191	.0191	.0191	.0171
13	.0191		.0381	
14	.0381	.0381	.0191	
15	.0381	.0381		
16	.0381	.0191		
17	.0381	.0191		
Max	.0381	.0381	.0381	.0343
Min	.0191	.0191	.0191	.0171
Avg	.0318	.0245	.0254	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 201 / 11 KV KALMESHWAR NEW URBAN SHEDDABLE URBAN
FEE Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2667	.2858	.2667	.2858
2	.2667	.2286	.2667	.2477	.2667	.2477	.2477
3	.2286	.1905	.2477	.2667	.2667	.2286	.2477
4	.1905	.1905	.2286	.2286		.2096	.2096
5	.1905	.1715	.2096	.1905	.1905	.1905	.1905
6	.1715	.1524	.1715	.1905	.1715	.1715	.1715
7	.2286	.1715	.1715	.1524	.1715	.1715	.1905
8	.2286	.1905	.1905	.1524	.2286	.1524	.1905
9	.2477	.2096	.2286	.3048	.1905	.2096	.1905
10		.4191	.4191	.362	.381	.3429	.2477
11	.362	.4382	.381	.4191	.3429	.3429	.2667
12	.3048	.4382	.381	.4382	.3429	.3239	.3239
13	.2477	.2477	.2477	.2477	.2286	.2096	.1905
14	.2858	.2858	.3048	.2667	.2286	.2477	.2477
15	.381	.4572	.3048	.3429	.4382	.3239	.2858
16	.2667	.2858	.3239		.1334	.2477	.3429
17	.4001	.3429	.2858	.381	.3429	.2477	.381
18	.2286	.2477	.2096	.1905	.1715		.1715
19	.2286	.2667	.2096	.2096	.2858	.2286	.2477
20	.2477	.3239	.2286	.3048	.3429	.2667	.2286
21	.2667	.2858	.1905	.2667	.2667	.2858	.3239
22	.2477	.2858	.2667	.2286	.2286	.2858	
23	.2667	.2858	.2286	.2477	.2477	.2477	.1524
24	.2286	.2667	.2286	.2286	.2667	.2477	.2667
Max	.4001	.4572	.4191	.4382	.4382	.3429	.381
Min	.1715	.1524	.1715	.1524	.1334	.1524	.1524
Avg	.2601	.2770	.2580	.2667	.2617	.2477	.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 202 / 11 KV STATION TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	21-JUN-18
HR	Load (MW)
11	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 203 / 11 KV KALMESHWAR AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0572	.0381	.0381	.0191		
2	.0572	.0572	.0381	.0381			
3	.0572	.0381	.0381	.0381			
4	.0381	.0381	.0572	.0572			
5	.0572	.0572	.0381	.0572	.0191		
6	.0381	.0762	.0572	.0381	.0381		
7	.0381	.0572	.0572	.0762	.0381	.0191	
8	.0762	.0762	.0572	.0953	.0381		
9	.0762	.0762	.0953	.0762	.0381	.0381	.0381
10	.0762	.0572	.0762	.0572	.0762	.0381	.0381
11	.0572	.0762	.0762	.0572	.0762	.0381	.0191
12	.0762	.0572	.0572	.0572	.0381	.0381	.0191
13	.0762	.0953	.0762	.0762	.0572	.0381	
14	.0762	.0762	.0762	.0762	.0762	.0191	
15	.0572	.0762	.1143	.0762	.0572	.0381	
16	.0762	.0572	.0762		.0953	.0381	.0191
17	.0953	.0953	.1143		.0191		.0191
18	.0762	.1143	.0762		.0191		
19	.1143	.0953	.0953	.0381		.0191	
20	.0762	.0762	.0572	.0191			
21	.0572	.0762	.0381	.0381			
22	.0572	.0572	.0381	.0191			
23	.0572	.0381	.0381	.0191			
24	.0381	.0572	.0381	.0381	.0191		
Max	.1143	.1143	.1143	.0953	.0953	.0381	.0381
Min	.0381	.0381	.0381	.0191	.0191	.0191	.0191
Avg	.0643	.0683	.0635	.0517	.0453	.0324	.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 204 / 11 KV DAHEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2667	.2858	.2667	.2286	.7049	
2	.2667	.2286	.2858	.2286	.1905	.6668	
3	.2286	.2286	.2667	.2286	.1905	.6287	
4	.2286	.1905	.2667	.1905	.1715	.6097	
5	.1905	.2286	.2477	.1905	.1905	.5335	
6	.2286	.2477	.3048	.2477	.2286	.4954	
7	.2667	.3048	.4001	.2858	.2286	.4954	
8	.2858	.381	.4191	.381	.2667	.5335	
9	.3239	.362	.362	.381	.2858	.5525	
10	.3048	.3048	.2858	.2858	.1715	.9907	
11	.2858	.2858	.3048	.2858	.1715	.5716	.1715
12	.2667	.3239	.362	.2858	.2286	.7049	.2858
13	.2858	.3239	.2096	.2667	.2477	.6097	.2858
14	.3239	.3239	.2096	.2858	.2096	.7811	.2667
15	.3429	.3048	.3048	.3048	.2286	.9145	.3048
16	.2667	.3239	.362			.9526	.2667
17	.2667	.381	.381	.1524	.1715	.1905	.2858
18	.3048	.3239	.3239	.1905	.1905		.1905
19	.3048	.381	.3048	.2096	.1905		.2667
20	.2858	.3429	.3048	.2477	.3429		.2667
21	.3048	.3429	.2858	.2667	.6097		.2667
22	.2858	.2858	.3048	.2667	.6859		
23	.2667	.2858	.2858	.2667	.7049		.2477
24	.2858	.2667	.2858	.2667	.2286	.7049	
Max	.3429	.381	.4191	.381	.7049	.9907	.3048
Min	.1905	.1905	.2096	.1524	.1715	.1905	.1715
Avg	.2786	.3016	.3064	.2601	.2767	.6467	.2588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164080 / 33 KV KALMESHWAR URBAN SS

Feeder No / Name : 205 / 11 KV GHORAD FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.1431	1.1431	1.105	.724	.8954	.8954
2	1.1812	1.105	1.105	1.0669	.724	.8764	.8573
3	1.0669	1.0479	1.086	1.0288	.6478	.8383	.8002
4	.9907	.9526	1.0479	.9907	.6097	.8002	.7621
5	.9145	.9907	.9907	.9907	.5716	.724	.7621
6	.9335	1.0288	1.0479	1.0479	.6097	.743	.743
7	.9907	1.1622	1.0288	1.2384	.6097	.7811	.724
8	1.448	1.3908	1.4098	1.3527	.6859	.8764	.8954
9	1.5432	1.3908	1.5623	1.5813	.6287	.9526	1.0479
10	1.105	.9526	1.6575	1.5242	.7049	.9526	.9907
11	1.2574	1.3908	1.5623	1.3908	.6859	.8954	1.0288
12	1.3336	1.3527	1.448	1.3527	.743	.7811	1.0288
13	1.2955	1.2384	1.4289	1.1431	.8383	.8764	1.0288
14	1.2955	.9717	1.4289		.8002	.8954	.9907
15	1.3146	1.0479	1.4098	1.2574	.5906	.8954	1.0669
16	1.3908	1.0288	1.448		.4763	.9526	1.0669
17	1.4861	1.1812	1.6004			.743	1.1431
18	1.5623	1.3717	1.5242	.2477			.8764
19	1.2955	1.448	1.4861		.2286	.7049	.9526
20	1.2193	1.2765	1.1812	.6478	.7621	.8383	.9145
21	1.086	1.2193	1.1431	.7621	.8002	.8764	.9717
22	1.105	1.2003	1.1431	.7621	.9335	.8764	
23	1.086	1.1812	1.1431	.7621	.9145	.9145	.7621
24	1.1431	1.086	1.1241	1.105	.743	.8954	.8954
Max	1.5623	1.448	1.6575	1.5813	.9335	.9526	1.1431
Min	.9145	.9526	.9907	.2477	.2286	.7049	.724
Avg	1.2177	1.1733	1.2979	1.0679	.6833	.8515	.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 400 / Station T/F

Feeder KV- 33 / OUTGOING

DATE	16-JUN-18	18-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
24	1.4118	1.4118	1.4118
Max	1.4118	1.4118	1.4118
Min	1.4118	1.4118	1.4118
Avg	1.4118	1.4118	1.4118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 401 / 33 kv INDUSTRIAL
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9					2.4897		
24	2.7726	2.7778	2.3765	1.0174		2.8578	2.0936
Max	2.7726	2.7778	2.3765	1.0174	2.4897	2.8578	2.0936
Min	2.7726	2.7778	2.3765	1.0174	2.4897	2.8578	2.0936
Avg	2.7726	2.7778	2.3765	1.0174	2.4897	2.8578	2.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 402 / 33 KV Kohali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	6.6204	7.0359	6.6204	6.653	6.5638	5.8814	6.2809
Max	6.6204	7.0359	6.6204	6.653	6.5638	5.8814	6.2809
Min	6.6204	7.0359	6.6204	6.653	6.5638	5.8814	6.2809
Avg	6.6204	7.0359	6.6204	6.653	6.5638	5.8814	6.2809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 405 / 33KV OMCO NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.1317	2.0348	1.5844	2.0176	1.1883	1.6804	1.8673
Max	1.1317	2.0348	1.5844	2.0176	1.1883	1.6804	1.8673
Min	1.1317	2.0348	1.5844	2.0176	1.1883	1.6804	1.8673
Avg	1.1317	2.0348	1.5844	2.0176	1.1883	1.6804	1.8673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 408 / 33 kV KSL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2263	.2858	.2263	.4001	.2263	.2858	.2263
Max	.2263	.2858	.2263	.4001	.2263	.2858	.2263
Min	.2263	.2858	.2263	.4001	.2263	.2858	.2263
Avg	.2263	.2858	.2263	.4001	.2263	.2858	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 409 / 33 kv Bazargaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	11.2037	10.7339	9.7891	8.9221	8.4877	10.6882	7.8087
Max	11.2037	10.7339	9.7891	8.9221	8.4877	10.6882	7.8087
Min	11.2037	10.7339	9.7891	8.9221	8.4877	10.6882	7.8087
Avg	11.2037	10.7339	9.7891	8.9221	8.4877	10.6882	7.8087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 410 / 33 KV DHAPEWADA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0185	1.1203	1.0185	1.0059	.9374	.9619
Max	1.0185	1.1203	1.0185	1.0059	.9374	.9619
Min	1.0185	1.1203	1.0185	1.0059	.9374	.9619
Avg	1.0185	1.1203	1.0185	1.0059	.9374	.9619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 168019 / 220 KV KALMESHWAR

Feeder No / Name : 806 / 220 kV Ispat

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	12.0713	16.1561	15.4664	14.5557	15.4664	18.0613	2.2634
Max	12.0713	16.1561	15.4664	14.5557	15.4664	18.0613	2.2634
Min	12.0713	16.1561	15.4664	14.5557	15.4664	18.0613	2.2634
Avg	12.0713	16.1561	15.4664	14.5557	15.4664	18.0613	2.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 201 / 11kV Khapa-U-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094		1.094	.9431			.9808
2	1.094		1.094	.9431			.9808
3	1.0185		.9808	.8299			.9242
4	1.0185		.9808	.8299			.9242
5	.9431		.9808	.7545			.9054
6	.9431		.8676	.7545			.9054
7	.7545		.7167	.7545			.9054
8	.7545		.7167	.7922			
9	.8299	.679			.4715	.679	
10	.8488	.679			.6036	.679	
11	.8488	.679			.6036	.6602	
12	.7545	.679			.6602	.6602	
13	.7545	.679			.6602	.6602	
14	.7545	.679			.6602	.679	
15	.7545	.6036			.6036	.679	
16	.823	.6036			.6036	.679	
17		.7167	.9808			.7167	.7545
18		.7922	.9808			.7167	.7545
19		.9054	1.094			.7922	.8488
20		.9808	1.094			.9054	.8488
21		1.0562	1.094			.9808	.8488
22		1.094	1.1128			.9808	.9431
23		1.094	1.1317			.9808	.9431
24	1.094		1.094				.9808
Max	1.094	1.094	1.1317	.9431	.6602	.9808	.9808
Min	.7545	.6036	.7167	.7545	.4715	.6602	.7545
Avg	.8872	.7947	1.0008	.8252	.6083	.7633	.8966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 204 / 11kV MOIL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3018	.2829			.3018
2	.3772		.3018	.2829			.3018
3	.3018		.3018	.2829			.3018
4	.3018		.3018	.2641			.3018
5	.2641		.3018	.2054			.3018
6	.2641		.2829	.2641			.3018
7	.2641		.2829	.2641			.2829
8	.3395		.3395	.3584			
9	.415	.5658			.8488	.547	
10	.5658	.6036			.8676	.6036	
11	.679	.6036			.8676	.6413	
12	.679	.7167			.7733	.7167	
13	.6979	.7167			.7922	.7167	
14	.6602	.547			.6602	.7356	
15	.6602	.2829			.2829	.3395	
16	.6036	.3018			.3018	.3018	
17		.5281	.3018			.415	
18		.6413	.3018			.547	
19		.679	.3018			.547	
20		.547	.3018			.5281	
21		.547	.3018			.5281	
22		.5281	.3018			.415	
23		.3772	.2829			.3772	
24	.3772		.3772	.2829			.3395
Max	.6979	.7167	.3772	.3584	.8676	.7356	.3395
Min	.2641	.2829	.2829	.2054	.2829	.3018	.2829
Avg	.4605	.5457	.3053	.2764	.6743	.5306	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 208 / 11 KV Kothulna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167		1.094	.9054			1.0562
2	.7167		.9808	.9054			1.0562
3	.6602		.7922	.8299			1.0562
4	.6602		.7167	.8299			.9808
5	.5658		.7167	.7545			.9054
6	.4904		.679	.6602			.6602
7	.3772		.5658	.547			.547
8	.4527		.3772	.5658			
9	.4527	.5281			.3206	.3018	
10	.4527	.4862			.3018	.3018	
11	.1886	.5658			.3018	.3018	
12	.4527	.503			.2829	.2829	
13	.5093	.6036			.2829	.3018	
14	.5658	.6036			.2829	.3018	
15	.5658	.7545			.2829	.2829	
16					.6036	.6036	
17			.7167				
18			.7545				
19		.6036	.8299				.4715
20		.7922	.9054				.4904
21		1.226	.9431				.5093
22		1.2826	1.0185				.4715
23		1.1694	1.094				.4527
24	.9431		1.1694	1.0185			1.094
Max	.9431	1.2826	1.1694	1.0185	.6036	.6036	1.094
Min	.1886	.4862	.3772	.547	.2829	.2829	.4527
Avg	.5482	.7599	.8346	.7796	.3324	.3348	.7501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 209 / 11 KV Waki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374		1.094	.9431			1.094
2	1.0374		1.0562	.9431			1.094
3	.9431		1.0562	.8299			1.0185
4	.9431		.9808	.8299			1.0185
5	.8299		.7922	.7545			.9808
6	.7356		.7167	.7545			.9054
7	.6036		.6224	.6413			.6602
8	.5658		.5281	.5658			
9	1.1316	.5281			.3206	.3961	
10	1.0802	.5658			.3395	.3961	
11	.9808	.6036			.415	.3961	
12	1.1316	.6036			.3961	.4527	
13	1.2072	.6036			.3961	.4527	
14	1.2449	.6036			.3961	.4904	
15	.6413	.8488			.3961	.4904	
16	1.2826	.8488			.547	.547	
17		.7922	1.0185			.6036	
18		.7922	1.0562				
19		.7356	1.2449			.8676	
20		.8488	1.3203			1.094	
21		1.1694	1.3769			1.1694	
22		1.1694	1.4146			1.2071	
23		1.094	1.3203			1.094	
24	1.1317		1.094	1.3203			.6036
Max	1.2826	1.1694	1.4146	1.3203	.547	1.2071	1.094
Min	.5658	.5281	.5281	.5658	.3206	.3961	.6036
Avg	.9722	.7872	1.0433	.8425	.4008	.6898	.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 401 / 33kv I/C Khapa- Parshioni

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5944	1.0562		
2			.5944	1.0562		
3			.6859	1.0562		
4			.6859	.9602		
5			.6859	.9602		
6			.6859	.9602		
7			.6859	.9602		
8			.6401	.9602		
9	1.0059	.048				
10	.9145	.048				
11	1.1317	.144				
12	.8488	.144				
13	1.1883	.096				
14	.9602	.048				
15	.7773	.048				
16	.0914	.048				
17		.048	1.0082		2.1502	.7682
18		.9602	1.0082		2.1502	1.0185
19		.9602	1.0082		2.3765	1.0185
20		.8642	1.0562		2.7161	.7202
21		.6241	1.0562		2.9424	.7682
22		.6241	1.0562		2.9424	.4801
23		.6241	1.0562		2.9424	.5761
24			.6241	1.0562		
Max	1.1883	.9602	1.0562	1.0562	2.9424	1.0185
Min	.0914	.048	.5944	.9602	2.1502	.4801
Avg	.8648	.3553	.8207	1.0029	2.6029	.7643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 201 / 11 kv Kochhi Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2382	1.0791	1.0719	.9431	.8688	1.2696	.9145
2	1.1827	1.0608	.924	.8573	.8413	1.1576	.9055
3	1.1523	1.0608	.8871	.9054	.7947	1.0642	.8962
4	1.1643	1.0242	.8316	.9054	.7392	1.0829	.8871
5	1.1458	.9328	.7762	.8299	.6838	.9709	.823
6	.924	.7133	.6468	.6283	.6036	.6722	.5853
7	.5914	.6401	.462	.5175	.439	.4066	.4572
8	.6283	.5544	.7023	.6089	.2883	.2033	.3841
9	.6626	.567	.6836	.7522	.3086	.2926	.3841
10	.7011	.695	.7011		.2058	.3292	.3841
11	.7207	.631	.6464	.6478	.2804	.3658	.3441
12	.6767	.631	.6962	.7045	.3155	.3658	.4024
13	.7133	.6379	.7293	.6882	.333	.4066	.4096
14	.7316	.7362	.7459	.6882	.3012	.4207	.4973
15	.7316	.7619	.6299		.2629	.4207	.4917
16	.8688	.333	.5765			.7499	.9412
17	.6283	.4024	.6089		.439	.5544	.8326
18	.5853	.5304	.6283		.5304	.6036	.567
19	.924	.6767	.7762		.8962	1.0242	.8048
20	1.0974	.8048	1.0774	1.0317	1.1523	1.0608	1.262
21	1.2936	.924	1.4003	1.1999	1.3491	1.2197	.8413
22	1.0242	1.0534	1.0562	.9328	1.386	.9511	
23	1.0608	1.1088	.9808	.9328	1.3121	.924	.4458
24	1.3121	1.0903	1.0719	.9431	.9145	1.2752	.9145
Max	1.3121	1.1088	1.4003	1.1999	1.386	1.2752	1.262
Min	.5853	.333	.462	.5175	.2058	.2033	.3441
Avg	.9066	.7771	.8046	.8176	.6629	.7413	.6685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 202 / 11 kv Sironji

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974		.9602	.8413		1.0242
2		1.0974		1.0562	.7865		1.0059
3		1.0791		.9808	.7316		1.0059
4		1.0974		.9054	.6767		1.0059
5		.823		.8215	.6219		.823
6		.6036		.6653	.5487		.567
7		.5068		.5175	.4024		.4207
8	.3511	.6099		.3582	.2561	.3696	.2743
9	.3658	.6036	.3841	.4435	.2743	.2743	.4755
10	.439	.3658	.4163		.1646	.2378	.4572
11	.439	.5121	.3582	.439	.2743	.3326	.2926
12	.439	.5121	.4298	.4344	.3475	.3292	.3658
13	.4755	.4024	.4298	.4525	.3841	.4805	.3475
14		.2743	.4298	.4344	.3475	.4755	.3841
15	.4755	.4755	.4298		.2743	.4805	.3658
16	.7682		.3658			.6584	.6401
17	.5304		.439			.5121	.8048
18	.5121		.4435			.4755	.5853
19	.8316		.5914	.8413		.961	.7865
20	1.0059		1.1203	.9694		.9979	1.2071
21	1.0608		1.1203	1.0791		1.0059	1.1523
22	1.0974		1.1949	1.0242		1.0059	
23	1.134		1.1317	.9694		1.0349	1.0425
24		1.134		1.1317	.8962		1.0059
Max	1.134	1.134	1.1949	1.1317	.8962	1.0349	1.2071
Min	.3511	.2743	.3582	.3582	.1646	.2378	.2743
Avg	.6617	.6997	.6190	.7623	.4893	.6020	.6974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 203 / 11 kv Industrial Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0183					
9	.0381						
10	.0381	.0183					.0183
11		.0566	.0537	.0339	.0377		.0492
12		.0566	.0358	.0332	.0381	1.448	.0335
13			.0537	.0332	.0377	.1463	.0335
14			.0358	.0497	.0381		.0514
15			.0537		.0381		.0347
16			.0537		.0381		.0339
17	.0183	.0189	.0549		.0381		.0351
18	.0183	.0191			.0189		
19	.0183				.0189		
20	.0181						
21	.0183				.0381		
22	.0183						
23	.0183						
24		.0183					
Max	.0381	.0566	.0549	.0497	.0381	1.448	.0514
Min	.0181	.0183	.0358	.0332	.0189	.1463	.0183
Avg	.0227	.0294	.0488	.0375	.0342	.7972	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 402 / 33kV Chargaon I/C from
Khapa Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1643	1.2071	1.1203	1.0751	.8779	1.1643	1.0974
2	1.1088	1.2197	1.0082	1.0751	.823	1.1088	1.0974
3	1.1088	1.1523	1.0082	1.0185	.7682	1.0082	1.0974
4	.9979	1.0974	1.0082	.9619	.7207	.9979	1.1088
5	.9979	1.0974	.8871	.9619	.6653	.8871	.9328
6	.8316	.7133	.6722	.7207	.6099	.5601	.7207
7	.6099	.4938	.4435	.499	.4481	.3921	.4938
8	1.0082	1.0974	1.0425	1.0208	.5721	.6099	.439
9	1.0974	1.1643	1.086	1.182	.5658	.6036	.823
10	1.2071	1.2489	1.1283		.3681	.6036	.8871
11	1.2071	1.1403	1.182	1.0814	.5316	.6036	.6613
12	1.1403	1.1523	1.3432	1.1797	.631	.6653	.7373
13	1.2071	1.182	1.3969	1.1797	.6379	.7207	.8139
14	1.262	1.2489	1.3969	1.1797	.5847	.7282	.9259
15	1.3169	1.2489	1.182		.5316	.7133	.8745
16	.823	.5487	.6984		.4344	.7133	.823
17	.7133	.5544	.6036		.439	.5487	.7202
18	.5487	.5544	.499		.4938		.5041
19	.9877	.8871	.6653	.4938	.7762		.7842
20	1.0974	.9979	1.1763	.9671	1.1088	1.1763	1.1946
21	1.1523	1.1088	1.2883	1.1403	1.2197	1.1523	1.0425
22	1.1523	1.1643	1.1203	1.0534	1.2883	1.0974	
23	1.1523	1.1763	1.1883	.9877	1.2197	1.1643	1.0425
24	1.2197	1.1523	1.1203	1.1317	.9328	1.1643	1.1523
Max	1.3169	1.2489	1.3969	1.182	1.2883	1.1763	1.1946
Min	.5487	.4938	.4435	.4938	.3681	.3921	.439
Avg	1.0463	1.0253	1.0111	.9952	.7187	.8356	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 201 / SBM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0343	.0343	.0362	.0305	.0293	.0305
2	.0305	.0362		.0362	.0305	.0293	.0305
3	.0305	.0362	.0343	.0362	.0305	.0293	.0305
4	.0305	.0362		.0362	.0305	.0293	.0305
5	.0305	.0343	.0343	.0362	.0305	.0293	.0305
6	.0305	.0343	.0343	.0343	.0305	.0293	.0305
7	.0305	.0362		.0343	.0305	.0293	.0305
8	.0305	.0362		.0362	.0305	.0293	.0305
9	.0305	.0362	.0343	.0362	.0305	.0293	.0305
10	.0362		.0362	.0305	.0293	.0305	
11	.0343	.0343	.0362	.0305	.0293	.0305	.0343
12	.0343	.0343	.0362	.0305	.0293	.0305	
13	.0343	.0343	.0362	.0305	.0293		.0343
14	.0362		.0362	.0305	.0293	.0305	
15	.0362	.0343	.0362	.0305	.0293	.0305	.0343
16	.0362	.0343	.0343		.0293	.0305	
17	.0362	.0343	.0343	.0305	.0293		.0343
18	.0362	.0343	.0343	.0305	.0293	.0305	
19	.0362	.0343	.0362	.0305	.0293	.0305	.0343
20	.0343		.0362	.0305	.0293	.0305	
21	.0362	.0343	.0362	.0305	.0293	.0305	.0343
22	.0362		.0343	.0305	.0293	.0305	
23	.0362	.0343	.0362	.0305	.0293	.0305	.0343
24	.0305	.0343	.0343	.0362	.0305	.0293	.0305
Max	.0362	.0362	.0362	.0362	.0305	.0305	.0343
Min	.0305	.0343	.0343	.0305	.0293	.0293	.0305
Avg	.0335	.0349	.0353	.0328	.0298	.0300	.0321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 202 / 11 kV Patansawangi R
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5668	.543	.5144	.6335	.9717	.6859	
2	.5668	.543	.5144	.6335	.9717	.6859	
3	.5668	.543	.5144	.6335	.8907	.6859	
4	.4858	.543	.5144	.543	.8097	.6859	
5	.4858	.543	.5144	.543	.7287	.6001	
6	.4858	.543	.5144	.543	.7287	.6001	
7	.4858	.543	.5144	.543	.6478	.6001	
8	.4858	.543	.5144	.543	.6478	.6001	
9	.4858	.543	.5144	.543	.7287	.5144	
10	.5144	.5144	.543	.5668	.7716	.4858	.0343
11	.5144	.5144	.543	.5668	.8573	.4858	.5144
12	.543	.6001	.6335	.5668	.8573	.5668	.5144
13	.6335	.6001	.6335	.5668	.8573		.5144
14	.6335	.6001	1.2336	.4858	.8573	.4858	.5144
15	.6335	.5316	1.267	.4858		.5668	.5144
16	.543	.5144	.543		.4287	.5668	.5144
17	.543	.5144	.543	.2429	.4801		.4287
18	.543	.4287	.543	.3239	.5144	.3239	.4287
19	.543	.4287	.543	.5668	.6001	.3239	.4287
20	.6335	.6001	.543	.8907	.6859	.5668	.6001
21	.724	.6859	.6335	1.0526	.7716	.6478	.6859
22	.6335	.6859	.6335	1.1336	.8573	.6478	
23	.6335	.6001	.6335	1.1336	.7716	.5668	.6201
24	.5668	.543	.5144	.6335	1.0526	.7716	.3239
Max	.724	.6859	1.267	1.1336	1.0526	.7716	.6859
Min	.4858	.4287	.5144	.2429	.4287	.3239	.0343
Avg	.5605	.5520	.6089	.6250	.7604	.5757	.4741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 203 / WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1765	1.0631	1.1765	.5544	1.1203	.924
2	1.2012	1.267	1.1517	1.1765	1.0164	1.2136	.924
3	1.386	1.267	1.1517	1.267	1.2012	1.307	1.0164
4	1.4784	1.448	1.2403	1.1765	1.386	1.307	1.0164
5	1.5708	1.5384	1.4175	1.1765	1.5708	1.4937	1.1088
6	1.6632	1.8099	1.5061	1.6289	1.5708	1.8671	.924
7	1.4784	1.5384	.8859	1.3575	.924	1.1203	.8316
8	.2772	.2715	.3544	.2715	.2772	.5601	.3696
9	1.2012	.9955	.3544	.905	.3696	.5601	.7392
10	1.6289	1.1517	1.086	1.2012	1.1203	1.1088	1.0631
11	1.7194	1.3289	1.5384	1.4784	1.4937	1.4784	1.3289
12	1.6289	1.5061	1.5384	1.2936	1.4937	1.4784	1.4175
13	1.6289	1.5947	1.7194	1.2012	1.6804		1.5947
14	1.5384		1.6289	1.1088	1.4937	1.386	1.6832
15	1.267	1.6832	.905	1.0164	1.2136	1.2012	1.6832
16	.8145	.8859	.6335		.2801	.462	.8859
17	.181	.8859	.8145	.1848	.2801		.3544
18	1.6289	1.2403	1.5384	1.5708	1.4003	1.2936	1.0631
19	1.6289	1.7718	1.9004	1.4784	1.7737	1.386	1.5061
20	1.9004	1.6832	1.6289	1.7556	1.6804	1.4784	1.5947
21	1.6289	1.5947	1.5384	1.6632	1.6804	1.4784	1.6832
22	1.448	1.3289	1.1765	1.6632	1.7737	1.386	
23	.543	1.1517	.0362	1.2936	1.4003	.7392	.3544
24	.6468	.8145	.8859	.9955	.2772	.9335	.2772
Max	1.9004	1.8099	1.9004	1.7556	1.7737	1.8671	1.6832
Min	.181	.2715	.0362	.1848	.2772	.462	.2772
Avg	1.2999	1.3015	1.1539	1.2192	1.163	1.1981	1.0584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 204 / Town APDRP SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269	1.086	1.0631	1.267	.964	1.0288	1.1393
2	1.1393	1.086	1.0631	1.267	.964	1.0288	1.0517
3	1.1393	1.086	1.0631	1.267	.8764	1.0288	.964
4	.964	.9955	1.0631	1.267	.8764	.9431	.964
5	.964	.9955	1.0631	1.267	.7888	.9431	.8764
6	.8764	.905	.8859	.905	.7888	.8573	.7888
7	.7888	.8145	.7888	.905	.7011	.7716	.7011
8	.7888	.8145	.7888	.6335	.6135	.6859	.7011
9	.7888	.8145	.7888	.8145	.6135	.6859	.7011
10	.8145	.8764	.8145	.7888	.6859	.7011	.7011
11	.8145	.8764	.9955	.8764	.6859	.7392	.7888
12	.9955	.964	.9955	.8764	.6859	1.7528	.7973
13	1.086	.9745	1.1765	.8764	.6001		.8859
14	1.086	1.0517	1.1765	.964	.6859	2.1033	.964
15	1.086	1.0631	1.086	1.0517	.8573	2.0683	.964
16	1.086	.9745	1.086		.7716	.8764	.9745
17	.9955	.9745	.905		.6859		.8764
18	.905	.8859	.8145	.4382	.8573	.3506	.7973
19	.8145	.8764	.905	.5258	.8573	.6135	.7973
20	1.1765	1.0517	1.086	.7888	.9431	1.1393	.964
21	1.267	1.1393	1.267	.964	1.0288	1.2269	1.1393
22	1.267	1.2403	1.267	1.0517	1.1145	1.2269	
23	1.267	1.2269	1.3575	1.0517	1.1145	1.1393	1.0517
24	1.2269	1.086	1.1517	1.267	.964	1.1145	1.1393
Max	1.267	1.2403	1.3575	1.267	1.1145	2.1033	1.1393
Min	.7888	.8145	.7888	.4382	.6001	.3506	.7011
Avg	1.0235	.9941	1.0272	.9597	.8219	1.0466	.9012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 205 / 11 KV Itangoti water
supply Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0905	.0876	.0362	.0857	.0857	.0857
2	.0857	.0905	.0876	.0905	.0857	.0857	.0857
3	.0857	.0905	.0876	.0905	.0857	.0857	.0857
4	.0857	.0905	.0876	.0905	.0857	.0857	.0857
5	.0857	.0905	.0876	.0905	.0857	.0857	.0857
6	.0857	.0905	.0876	.0905	.0857	.0857	.0857
7	.0857	.0905	.0914	.0905	.0857	.0857	.0857
8	.0857	.0905	.0876	.0905	.0857	.0857	.0857
9	.0905	.0905	.0876	.0905	.0857	.0857	.0857
10	.0905	.0857	.0905	.0857	.0857	.0857	.0876
11	.0905	.0876	.0905	.0857	.0857	.0857	.0876
12	.0905	.0857	.0905	.0857	.0857	.0857	.0876
13	.0905	.0876	.0905	.0857	.0857		.0876
14	.0905	.0857	.0905	.0857	.0857	.0857	.0876
15	.0905	.0876	.0905	.0857	.0857	.0857	.0876
16	.0905	.0876	.0905		.0857	.0857	.0876
17	.0905	.0876	.0905	.0857	.0857		.0876
18	.0905	.0857	.0905	.0857	.0857	.0857	.0876
19	.0905	.0876	.0905	.0857	.0857	.0857	.0876
20	.0905	.0876	.0905	.0857	.0343	.0857	.0876
21	.0905	.0876	.0905	.0857	.0857	.0857	.0876
22	.0905	.0876	.0905	.0857	.0857	.0857	
23	.0905	.0876	.0905	.0857	.0857	.0857	.0876
24	.0857	.0905	.0905	.0905	.0857	.0857	.0857
Max	.0905	.0905	.0914	.0905	.0857	.0857	.0876
Min	.0857	.0857	.0876	.0362	.0343	.0857	.0857
Avg	.0887	.0885	.0896	.0854	.0836	.0857	.0868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 401 / 33 KV SOOTGIRNI FEEDER
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.086	1.0974	1.086	1.0185	1.2323	1.358
2	1.3014	1.086	1.0974	1.086	1.0751	1.2323	1.2449
3	1.3014	1.1946	1.0974	.9774	1.1317	1.2323	1.3014
4	1.2449	1.1946	1.2071	.9774	1.1883	1.3443	1.3014
5	1.1883	1.1946	1.2071	.9774	1.1883	1.3443	1.358
6	1.1883	.9774	1.2071	1.1403	1.2449	1.4003	1.358
7	1.2449	.8688	1.2071	1.1403	1.1883	1.2323	1.2449
8	1.0751	1.1403	1.2071	1.0317	1.1317	1.1203	1.1883
9	1.0185	.9231	1.2071	.7602	1.0751	1.0082	1.0751
10	.8688	.9774	1.1946	1.0185	1.1203	1.3014	1.0974
11	.8145	.9774	1.086	1.1317	1.1203	1.1883	1.2071
12	1.0317	1.0974	.9231	.9619	1.0082	1.4146	1.0974
13	1.4118	1.2071	1.086	.9619	1.1203	1.358	1.0974
14	1.3032	1.3169	.9774	.9054	1.1203	1.4712	1.0974
15	1.3575	1.3169	1.1946	1.0185	1.0082	1.5278	1.0974
16	1.3575	1.2071	1.1946	.2263	1.0082	1.1317	1.0974
17	1.3575	1.0974	1.1946	1.1317	.8402	1.3014	1.0974
18	1.1403	1.0974	1.086	1.1317	1.1203	.9054	1.0974
19	1.2489	1.0974	1.1403	1.1317	1.1203	1.4146	1.0974
20	1.3032	1.0974	1.1946	1.1317	1.0082	1.1317	1.0974
21	1.0317	1.0974	7.1131	1.1317	1.2323	1.1883	1.0974
22	1.3575	1.0974	1.1946	1.1317	1.3443	1.3014	
23	1.086	1.0974	1.2489	1.0751	1.2323	1.5278	1.0974
24	1.358	1.086	1.0974	1.086	1.0185	1.2323	1.1317
Max	1.4118	1.3169	7.1131	1.1403	1.3443	1.5278	1.358
Min	.8145	.8688	.9231	.2263	.8402	.9054	1.0751
Avg	1.2062	1.1056	1.3942	1.0147	1.1110	1.2726	1.1712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 402 / 33 KV Incomer I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1024	3.0407	3.1493	3.2579		2.9321	2.2085
2	3.1024	3.095	3.4751	3.2579		2.9835	2.1559
3	3.2602	2.9864	3.4751	3.3122		3.0864	2.1559
4	3.1024	3.2036	3.5294	3.2036		2.9835	2.1559
5	3.2076	3.3122	3.7466	3.2036		3.0864	2.1033
6	3.155	3.4208	4.1267	3.2579		3.2922	1.893
7	2.9447	3.1493	3.4751	2.9321		2.572	1.6827
8	1.7878	1.8461	2.9321	1.6289		1.9547	1.262
9	2.6818	2.6063	2.8235	2.4977		1.8519	1.6301
10	3.2036	2.8235	3.5294	2.7869		2.4714	2.0633
11	3.3122	2.9864	4.1267	3.1024		2.8395	2.9321
12	3.3665	3.3665	5.2126	2.8921		3.9963	3.0407
13	3.5837	3.4751	5.7556	2.8395			3.2579
14	3.4751	3.5837	4.6696	2.7343		4.1015	3.4751
15	3.2036	3.5837	3.6923	2.7869	2.1091	4.0489	3.4751
16	2.6606	2.6606	2.4977		1.6461	2.1033	2.6606
17	1.9547	2.6606	2.4434		1.5947		1.9004
18	2.3891	2.8532	3.1493		2.7778	2.1033	2.552
19	3.2036	3.4019	3.5294		3.2407	2.4714	3.0407
20	3.9095	3.638	3.4751		3.3436	3.3653	3.4751
21	3.8009	3.6923	3.638		3.4979	3.5231	3.8009
22	3.5294	3.5294	3.1493		3.7551	3.4705	
23	2.6606	3.2579	2.9321		3.2922	2.6292	2.2805
24	2.6818	2.7149	2.9321	3.095		2.8807	1.9456
Max	3.9095	3.6923	5.7556	3.3122	3.7551	4.1015	3.8009
Min	1.7878	1.8461	2.4434	1.6289	1.5947	1.8519	1.262
Avg	3.0533	3.1203	3.5611	2.9243	2.8064	2.9431	2.4847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 403 / 33 KV Incomer II

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.6509	7.1674	6.31	6.4072	9.1478	1.2323	6.5421
2		7.0588	6.31	6.733	10.423	1.2323	7.7618
3	7.8172	6.8959	6.4746	6.6787	10.8665	1.2323	7.5955
4	7.8172	6.8959	6.6941	6.9502	11.2546	1.3443	7.2628
5	7.8727	7.1131	6.8587	7.3846	11.4209	1.3443	6.5421
6	7.8727	7.7103	7.1331	7.7646	11.5872	1.4003	6.154
7	5.9877	6.4072	6.0905	6.0814	8.8706	1.2323	5.2115
8	4.9343	5.2669	5.3772	5.2669	6.7638	1.1203	5.3778
9	5.2115	5.4841	5.7613	5.104	6.5975	4.0329	5.3778
10	5.3212	6.0357	7.3303	6.2094	9.2421	6.2649	6.1454
11	5.5927	6.2552	7.6017	7.0965	9.9703	10.7002	7.2428
12	6.3529	6.8587	7.3303	7.5955	10.5864	11.1437	7.1331
13	7.0588	7.8464	7.6017	5.8213	10.6424	11.0883	7.0233
14	7.276	7.2428	6.4615	7.4291	10.6424	11.8644	6.8587
15	7.7646	6.8039	5.8642	6.2094	1.0082	6.7084	1.0974
16	7.0588	6.2003	6.0271	.6653		5.3224	1.0974
17	5.2669	5.487	4.8868	4.4353		4.1581	4.9383
18	6.6244	6.31	6.19	8.8152		4.3244	6.0357
19	7.5474	6.8039	6.7873	9.7577		7.4846	7.1331
20	8.1447	7.1331	6.733	11.31	1.0082	8.0944	7.2428
21	5.4298	7.3525	7.1131	11.3655	1.2323	8.039	7.4074
22	6.1357	7.2428	6.8959	11.8644	1.3443	8.039	
23	6.9502	6.8587	6.6787	11.3655	1.2323	7.2628	4.9383
24	7.4291	7.0588	6.0357	6.2443	8.7597	1.2323	6.3203
Max	8.1447	7.8464	7.6017	11.8644	11.5872	11.8644	7.7618
Min	4.9343	5.2669	4.8868	.6653	1.0082	1.1203	1.0974
Avg	6.7442	6.7287	6.5228	7.2731	7.6300	5.2458	6.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 201 / 11 kV Lonara w/w
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.2858	.1905	.1905	.1905
2	.1905	.1905	.1905	.2858	.1905	.1905	.1905
3	.1905	.1905	.1905	.2858	.1905	.1905	.1905
4		.1905	.1905	.1905	.1905	.1905	.1905
5	.1905	.1905	.1905	.1905	.1905	.1905	.1905
6	.1905	.1905	.1905	.1905	.1905	.1905	.1905
7	.1905	.1905	.1905	.1905	.1905	.1905	.1905
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.1905	.1905	.1905	.1905	.1905
12	.1905	.1905	.1905	.1905	.2858	.1905	.2858
13	.1905	.1905	.1905	.1905	.2858	.1905	.2858
14	.1905	.1905	.1905	.1905	.1905	.1905	.2858
15	.1905	.1905	.1905	.1905	.1905	.1905	.2858
16	.2858	.1905	.1905	.1905	.2858	.1905	.2858
17	.1905	.1905	.1905		.2858	.1905	.2858
18	.1905	.1905	.1905	.2858	.1905	.1905	.1905
19	.1905	.1905	.1905	.1905	.1905	.1905	.1905
20	.2858	.1905	.1905	.1905	.1905	.1905	.1905
21	.2858	.1905	.2858	.1905	.1905	.1905	.1905
22	.2858	.1905	.2858	.1905	.1905	.1905	.2858
23	.2858	.1905	.2858	.1905	.1905	.1905	.2858
24	.1905	.2858	.1905	.2858	.1905	.1905	.1905
Max	.2858	.2858	.2858	.2858	.2858	.1905	.2858
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2112	.1945	.2024	.2112	.2064	.1905	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 204 / 11 kV Polefactory
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.381	.381	.381	.381	.381	.381	.381
3	.381	.381	.381	.381	.381	.381	.381
4	.381	.2858	.381	.381	.381	.381	.381
5	.381	.2858	.381	.381	.381	.381	.381
6	.2858	.2858	.2858	.2858	.2858	.2858	.2858
7	.2858	.1905	.2858	.1905	.1905	.2858	.2858
8	.1905	.1905	.1905	.1905	.1905	.1905	.1905
9	.1905	.1905	.1905	.1905	.1905	.1905	.1905
10	.1905	.1905	.1905	.1905	.1905	.1905	.1905
11	.1905	.1905	.2858	.1905	.2858	.2858	.2858
12	.0953	.1905	.2858	.2858	.2858	.2858	.0953
13	.1905	.2858	.2858	.381	.2858	.2858	.2858
14	.2858	.2858	.2858	.381	.2858	.381	.381
15	.2858	.2858	.2858	.381	.381	.381	.381
16	.2858	.2858	.2858	.2858		.381	.381
17	.2858	.2858	.2858		.2858	.2858	.381
18	.1905	.2858	.2858		.1905	.2858	
19	.2858	.2858	.2858	.2858	.2858	.2858	.2858
20	.381	.381	.381	.381	.381	.381	.381
21	.381	.381	.381	.381	.381	.381	.381
22	.4763	.381	.381	.381	.381	.381	
23	.4763	.381	.381	.381	.381	.381	.381
24	.381	.4763	.381	.381	.381	.381	.381
Max	.4763	.4763	.381	.381	.381	.381	.381
Min	.0953	.1905	.1905	.1905	.1905	.1905	.0953
Avg	.3016	.2977	.3136	.3204	.3106	.3255	.3204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 205 / 11 KV Ropeway

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18
HR	Load (MW)
7	.381
8	.2858
9	.2858
Max	.381
Min	.2858
Avg	.3175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 207 / 11 kV Mahadula

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.7621	.6668	.7621	.6668	.6668	.6668
2	.6668	.6668	.6668	.7621	.6668	.6668	.6668
3	.6668	.6668	.6668	.7621	.5716	.6668	.6668
4	.6668	.5716	.6668	.6668	.5716	.5716	.6668
5	.5716	.5716	.5716	.5716	.5716	.5716	.6668
6	.4763	.4763	.4763	.4763	.4763	.4763	.5716
7	.4763	.381	.4763	.381	.381	.4763	.4763
8	.381	.381	.381	.381	.381	.381	.381
9	.381	.381	.381	.381	.2858	.381	.381
10	.2858	.2858	.381	.381	.381	.2858	.381
11	.2858	.2858	.381	.381	.381	.381	.381
12	.381	.381	.381	.381	.381	.4763	.381
13	.381	.4763	.4763	.381	.4763	.4763	.381
14	.2858	.4763	.4763	.4763	.5716	.5716	.4763
15	.2858	.4763	.5716	.4763	.5716	.5716	.4763
16	.4763	.4763	.4763	.381	.5716	.5716	.381
17	.4763	.381	.4763		.381	.4763	.4763
18	.381	.381	.381	.381	.381	.4763	.4763
19	.4763	.4763	.4763	.4763	.4763	.4763	.4763
20	.5716	.5716	.5716	.5716	.5716	.5716	.5716
21	.6668	.5716	.6668	.5716	.5716	.5716	.5716
22	.6668	.6668	.6668	.6668	.6668	.6668	.5716
23	.7621	.7621	.7621	.6668	.6668	.6668	.6668
24	.6668	.7621	.6668	.7621	.6668	.6668	.6668
Max	.7621	.7621	.7621	.7621	.6668	.6668	.6668
Min	.2858	.2858	.381	.381	.2858	.2858	.381
Avg	.5001	.5120	.5319	.5260	.5120	.5319	.5200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 208 / 11 KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3336	1.3336	1.4289	1.2384	1.3336	1.3336
2	1.3336	1.3336	1.3336	1.4289	1.2384	1.3336	1.3336
3	1.3336	1.2384	1.3336	1.3336	1.1431	1.3336	1.3336
4	1.2384	1.2384	1.3336	1.2384	1.1431	1.3336	1.2384
5		1.1431	1.1431	1.1431	.9526	1.1431	1.1431
6	1.0479	.9526	.9526	.9526	.8573	1.0479	.9526
7	.8573	.8573	.8573	.8573	.8573	.9526	.8573
8	.7621	.7621	.7621	.7621	.7621	.8573	.8573
9	.7621	.8573	.7621	.8573	.7621	.8573	.8573
10	.8573	.8573	.8573	.9526	.7621	.9526	.9526
11		.8573	.9526	.9526	.8573		.9526
12	.8573	.9526	.9526	.9526	.8573		.9526
13	.8573	1.0479	1.0479	1.0479	1.0479		.9526
14	.9526	1.1431	1.1431	1.0479	1.0479		1.0479
15	.9526	1.1431	1.1431	1.0479	.9526		1.0479
16	1.0479	1.1431	1.0479		.0953	1.1431	1.1431
17	.9526	1.0479	1.0479		1.0479	.9526	1.0479
18	.8573	.9526	.9526	.8573	.9526	.9526	1.0479
19	1.0479	1.0479	1.0479	1.0479	1.0479	.9526	1.1431
20	1.1431	1.1431	1.2384	1.1431	1.2384	1.1431	1.3336
21	1.2384	1.2384	1.3336	1.1431	1.2384	1.2384	1.1431
22	1.3336	1.3336	1.3336	1.1431	1.2384	1.3336	
23	1.3336	1.3336	1.4289	1.2384	1.3336	1.4289	1.1431
24	1.3336	1.3336	1.3336	1.4289	1.2384	1.3336	1.3336
Max	1.3336	1.3336	1.4289	1.4289	1.3336	1.4289	1.3336
Min	.7621	.7621	.7621	.7621	.0953	.8573	.8573
Avg	1.0652	1.0955	1.1114	1.0912	.9963	1.1381	1.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 209 / 11 kV Koradi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.7621	.7621	.7621	.6668	.6668	.6668
2	.6668	.7621	.7621	.7621	.6668	.6668	.6668
3	.6668	.6668	.7621	.7621	.5716	.6668	.724
4	.6668	.6668	.7621	.6668	.5716	.6668	.6668
5	.6668	.5716	.6668	.6668	.5716	.5716	.5716
6	.5716	.4763	.4763	.5716	.4763	.381	.4763
7	.4763	.4763	.4763	.4763	.381	.381	.4763
8	.381	.381	.381	.381	.381	.381	.381
9	.381	.381	.381	.381	.381	.381	.381
10	.381	.2858	.381	.381	.381	.381	.381
11	.381	.2858	.381	.381	.381	.381	.381
12		.381	.4763	.381	.4763	.381	.381
13	.381	.4763	.5716	.4763	.4763	.4763	.381
14	.5716	.4763	.5716	.5716	.5716	.5716	.5716
15	.5716	.4763	.5716	.5716	.5716	.5716	.5716
16	.4763	.5716	.4763	.4763	.5716	.5716	.5716
17	.4763	.4763	.4763		.1905	.4763	.5716
18	.381	.4763	.4763	.381	.381	.4763	.4763
19	.4763	.5716	.4763	.4763	.4763	.4763	.5716
20	.5716	.6668		.5716	.5716	.5716	.5716
21	.6668	.6668	.6668	.5716	.5716	.5716	.5716
22	.6668	.6668	.6668	.6668	.6668	.6668	.6668
23	.7621	.6668	.7621	.6668	.7621	.6668	.7621
24	.7621	.7621	.7621	.7621	.6668	.7621	.6668
Max	.7621	.7621	.7621	.7621	.7621	.7621	.7621
Min	.381	.2858	.381	.381	.1905	.381	.381
Avg	.5508	.5438	.5716	.5550	.5160	.5319	.5462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 210 / 11 kV Lonkhairy

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2858	.2858	.2858	.2858	.1905
2	.2858	.2858	.2858	.2858	.2858	.2858	.1905
3	.2858	.2858	.2858	.2858	.2858	.2858	.1905
4	.2858	.2858	.2858	.2858	.2858	.2858	.1905
5	.1905	.2858	.2858	.1905	.1905	.2858	.1905
6	.1905	.1905	.1905	.1905	.1905	.2858	.1905
7	.1905	.1905		.1905	.1905	.2858	.1905
8	.1905	.2858		.1905	.1905	.1905	.1905
9	.1905	.2858	.2858	.1905	.1905	.1905	.1905
10	.2858	.2858	.2858	.2858	.1905	.1905	.1905
11	.1905	.2858	.2858	.2858	.1905	.1905	.1905
12	.1905	.1905	.1905	.1905	.1905		.1905
13	.1905	.1905	.1905	.1905	.1905		
14	.1905	.1905	.2858	.1905	.1905		.1905
15	.1905	.1905	.2858	.1905	.1905	.1905	.1905
16	.2858	.2858	.2858	.1905	.1905	.1905	.1905
17	.1905	.2858	.2858		.1905	.1905	.1905
18	.1905	.1905	.2858	.1905	.1905	.1905	.1905
19	.1905	.1905	.2858	.1905	.1905	.1905	.1905
20	.1905	.2858	.1905	.2858	.2858	.2858	.1905
21	.2858	.2858	.2858	.2858	.2858	.2858	.1905
22	.2858	.2858	.2858	.2858	.2858		.1905
23	.2858	.2858	.2858	.2858	.2858	.2858	
24	.1905	.2858	.2858	.1905	.2858	.2858	.1905
Max	.2858	.2858	.2858	.2858	.2858	.2858	.1905
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.2262	.2540	.2685	.2319	.2262	.2429	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 211 / 11 kV Gayatri Bricks
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0381	.0191	.0191	.0191	.0191	.0191	.0191
8	.0381	.0381	.0191	.0381	.0191	.0191	.0191
9	.0381	.0381	.0191	.0381	.0381	.0191	.0191
10	.0381	.0572	.0191	.0381	.0572	.0572	.0762
11	.0381	.0572	.0191	.0381	.0381	.0762	.0762
12	.0572	.0572	.0191	.0191	.0953	.0572	.0572
13	.0572	.0572	.0191	.0381	.0953	.0572	.0572
14	.0191	.0191	.0191	.0381	.0953	.0572	.0191
15	.0191	.0191	.0191	.0381	.0572	.0381	.0191
16	.0762	.0191	.0191	.0381	.0953	.0381	.0762
17		.0191	.0191		.0953	.0381	.0572
18	.0572	.0191	.0191	.0191	.0762	.0381	.0572
19	.0953	.0191		.0381	.0572	.0953	.0953
20	.0953	.0191	.0191	.0381	.0381	.0572	.0953
21	.0953	.0191	.0191	.0381	.0191	.0381	.0953
22	.0953	.0191	.0191	.0381	.0191	.0191	.0191
23	.0953	.0191	.0191	.0191	.0191	.0191	
24	.0191	.0381	.0191	.0191	.0191	.0191	.0191
Max	.0953	.0572	.0191	.0381	.0953	.0953	.0953
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0472	.0278	.0191	.0290	.0445	.0366	.0431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 213 / 11 KV Panjara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.4763	.4763	.4763
2	.4763	.4763	.4763	.4763	.4763	.4763	.4763
3	.4763	.4763		.381	.381	.4763	.4763
4	.4763	.381	.4763	.381	.381	.4763	.4763
5	.381	.381	.381	.381	.381	.381	.381
6	.2858	.2858	.2858	.2858	.2858	.2858	.2858
7	.2858	.2858	.2858	.2858	.2858	.2858	.2858
8	.2858	.2858	.2858	.2858	.2858	.2858	.2858
9	.2858	.2858	.2858	.2858	.2858	.2858	.2858
10	.2858	.2858	.2858	.2858	.2858	.2858	.2858
11	.2858	.2858	.2858	.2858	.2858	.2858	.2858
12	.2858	.2858	.2858	.2858	.2858	.2858	.381
13	.2858	.2858	.2858	.2858	.2858	.2858	.381
14	.2858	.381	.381	.2858	.381	.381	.381
15	.2858	.381	.381	.2858	.2858	.381	.381
16	.381	.381	.381	.2858	.381	.381	.381
17	.381	.2858	.2858		.2858	.2858	.381
18	.2858	.381	.2858	.2858	.2858	.2858	.2858
19	.381	.2858	.2858	.2858	.2858	.381	.381
20	.381	.381	.381	.381	.381	.381	.381
21	.381	.381	.4763	.381	.381	.381	.381
22	.4763	.4763	.4763	.381	.381	.4763	.381
23	.4763	.4763	.4763	.4763	.4763	.4763	.4763
24	.4763	.4763	.4763	.4763	.4763	.4763	.4763
Max	.4763	.4763	.4763	.4763	.4763	.4763	.4763
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.3652	.3652	.3645	.3438	.3493	.3691	.3771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 214 / NANDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4763	.5716	.5716	.381	.4763	.381
2	.5716	.381	.5716	.5716	.381	.4763	.381
3	.4763	.381	.4763	.4763	.381	.4763	.381
4	.4763	.381	.4763	.4763	.381	.381	.381
5	.381	.381	.381	.381	.381	.381	.381
6	.2858	.2858	.2858	.381	.2858	.381	.2858
7	.2858	.2858	.2858	.2858	.2858	.381	.2858
8	.2858	.2858	.2858	.2858	.2858	.2858	.1905
9	.2858	.381	.2858	.381	.381	.2858	.1905
10	.381	.381	.381	.4763	.4763	.381	.381
11	.5716	.381	.4763	.4763	.5716	.2858	.4763
12	.5716	.381	.4763	.5716	.4763	.2858	.5716
13	.5716	.4763	.5716	.5716	.5716	.2858	.5716
14	.5716	.4763	.5716	.5716	.5716	.381	.4763
15	.5716	.4763	.5716	.5716	.4763	.381	.4763
16	.5716	.4763	.4763	.5716	.4763	.381	.5716
17	.5716	.381	.4763		.4763	.381	.4763
18	.4763	.4763	.381	.4763	.381	.381	.4763
19	.4763	.5716	.381	.4763	.4763	.2858	.381
20	.5716	.6668	.4763	.5716	.5716	.381	.4763
21	.5716	.6668	.5716	.4763	.5716	.381	.381
22	.4763	.6668	.5716	.4763	.5716	.381	.4763
23	.5716	.6668	.5716	.4763	.4763	.381	.4763
24	.5716	.4763	.5716	.5716	.381	.4763	.381
Max	.5716	.6668	.5716	.5716	.5716	.4763	.5716
Min	.2858	.2858	.2858	.2858	.2858	.2858	.1905
Avg	.4882	.4525	.4644	.4846	.4445	.3731	.4128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 215 / NEW ROPEWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.4763	.4763	.4763	.4763
2	.4763	.4763	.4763	.4763	.4763	.4763	.4763
3	.4763	.381	.4763	.4763	.381	.4763	.4763
4	.4763	.381	.4763	.4763	.381	.4763	.4763
5	.4763	.381	.4763	.381	.381	.4763	.381
6	.381	.2858	.381	.381	.381	.381	.2858
7		.2858	.381	.2858	.2858	.381	.2858
8		.2858	.2858	.2858	.2858	.2858	.2858
9		.2858	.2858	.2858	.2858	.2858	.2858
10	.2858	.2858	.2858	.2858	.2858	.2858	.2858
11	.2858	.2858	.381	.2858		.381	.2858
12	.381	.2858	.381	.381		.381	.381
13	.381	.2858	.381	.381		.381	.381
14	.381	.381	.381	.381		.381	.381
15	.381	.381	.381	.381	.381	.381	.381
16	.381	.381	.381		.4763	.381	.381
17	.2858	.381	.2858		.381	.381	.2858
18	.2858	.2858	.381	.381	.2858	.381	.2858
19	.381	.381	.381	.4763	.381	.381	.381
20	.381	.4763	.381	.4763	.4763	.381	.4763
21	.4763	.4763	.381	.4763	.4763		.381
22	.4763	.4763	.4763	.381	.4763	.4763	.381
23	.4763	.4763	.4763	.4763	.4763	.4763	.4763
24	.4763	.4763	.4763	.4763	.4763	.4763	.4763
Max	.4763	.4763	.4763	.4763	.4763	.4763	.4763
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.4037	.3731	.3969	.3984	.3953	.4017	.3771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 216 / MODERN SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2384	1.2384	1.3336	1.1431	1.2384	1.1431
2	1.2384	1.2384	1.2384	1.3336	1.1431	1.2384	1.1431
3	1.1431	1.2384	1.2384	1.3336	1.0479	1.2384	1.1431
4	1.1431	1.1431	1.1431	1.2384	.9526	1.1431	1.0479
5	.9526	1.1431	.9526	1.0479	.9526	.9526	.9526
6	.7621	.9526	.7621	.8573	.7621	.8573	.7621
7	.7621	.7621	.7621	.8573	.7621	.7621	.7621
8	.6668	.6668	.6668	.7621	.6668	.6668	.6668
9	.6668	.6668	.6668	.7621	.7621	.6668	.6668
10	.7621	.8573	.7621	.8573	.9526	.6668	.9526
11	.8573	.9526	.9526	.9526	.9526	.7621	.9526
12	.9526	.9526	.9526	.9526	1.0479	.7621	1.0479
13	.9526	1.0479	1.0479	.9526	1.0479	.8573	1.0479
14	1.0479	1.0479	1.0479	.9526	1.1431	.9526	1.0479
15	1.0479	1.1431	1.0479	.9526	1.0479	.8573	1.0479
16	1.0479	1.1431	1.0479	.9526	1.0479	.8573	1.0479
17	.9526	1.0479	.9526		.8573	.9526	1.0479
18	.7621	.8573	.8573	.7621	.7621	.9526	.9526
19	.8573	.8573	.7621	.8573	.7621	.6668	.8573
20	.9526	.9526	.9526	.9526	.9526	.8573	1.0479
21	1.0479	.9526	1.1431	.9526	1.1431	.8573	.8573
22	1.0479	1.0479	1.1431	.9526	1.2384	1.0479	.9526
23	1.2384	1.1431	1.3336	1.1431	1.3336	1.1431	1.1431
24	1.2384	1.2384	1.2384	1.3336	1.1431	1.2384	1.1431
Max	1.2384	1.2384	1.3336	1.3336	1.3336	1.2384	1.1431
Min	.6668	.6668	.6668	.7621	.6668	.6668	.6668
Avg	.9725	1.0121	.9963	1.0023	.9844	.9248	.9764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 401 / 33 KV Incomer I(Uppalwadi NON SHEDDABLE EXPRESS HV FEEDERS
I) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.7147	1.7147	9.7165	9.4307
2		1.7147	1.7147	1.7147	9.7165	9.4307
3		1.7147	1.7147	1.4289	9.7165	9.4307
4		1.7147	1.7147	1.4289	9.4307	9.4307
5		1.4289	1.4289	1.4289	8.8592	9.4307
6		1.1431	1.1431	.8573	8.5734	7.1445
7		1.1431	1.1431	.8573	6.8587	6.5729
8		1.1431	.8573	.8573	5.4298	5.4298
9		1.1431	.8573	.8573	5.4298	5.4298
10		1.1431	1.1431	.8573	.8573	6.8587
11		1.1431	1.1431	.8573		7.1445
12	1.1431	1.1431	.8573	1.1431		7.4303
13	1.1431	1.1431	1.1431	1.1431		
14	1.1431	1.4289	1.1431	1.4289		
15	1.1431	1.4289	1.1431	5.7156	4.8583	
16	1.4289	1.1431	1.1431	6.2872	6.2872	
17	1.1431	1.1431		4.2867	7.4303	
18	1.1431	1.1431	.8573	5.7156	7.4303	
19	1.4289	1.1431	1.1431	1.4289	1.1431	
20	1.4289	1.4289	1.4289	8.5734	8.2876	
21	1.4289	1.7147	1.4289	9.145	8.5734	
22	1.7147	1.7147	1.7147	9.7165	9.4307	
23	1.7147	1.7147	1.7147	9.7165	9.4307	
24		1.7147	1.7147	1.7147	9.7165	9.7165
Max	1.7147	1.7147	1.7147	9.7165	9.7165	9.7165
Min	1.1431	1.1431	.8573	.8573	.8573	5.4298
Avg	1.3336	1.3813	1.3046	3.2865	7.3588	7.9139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 402 / 33 KV INCOMER II(UPPALWADI NON SHEDDABLE EXPRESS HV FEEDERS
 II) Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.7165	10.0023	8.2876	8.5734	7.7161	8.0018	
2	9.7165	9.7165	8.2876	8.5734	7.7161	8.0018	
3	9.7165	9.4307	8.2876	8.2876	7.1445	8.0018	
4	9.145	8.8592	8.0018	7.7161	6.8587	7.4303	
5	8.0018	8.5734	6.8587	7.1445	6.2872	6.5729	
6	6.8587	6.8587	6.0014	6.2872	5.7156	6.2872	
7	6.5729	6.5729	5.7156	5.4298	5.4298	5.4298	
8	5.7156	5.4298	5.144	5.144	4.8583	4.8583	
9	5.7156	6.2872	4.8583	5.144	4.8583	4.8583	
10		6.0014	5.144	5.7156	5.4298	5.4298	
11	6.2872	6.5729	6.0014	5.7156	5.144		
12	6.5729	6.0014	6.0014	6.2872	5.7156		
13	6.5729	6.2872	6.5729	6.5729	6.2872		7.4303
14	7.4303	6.8587	6.8587	6.8587	6.2872		8.0018
15	7.4303		7.1445	6.8587	6.8587		8.0018
16	8.0018		6.5729	4.0009			7.7161
17		6.2872	6.5729		5.7156		7.4303
18		5.7156	6.0014	5.4298	5.144		6.5729
19	7.1445	6.0014	5.7156	6.0014	5.7156		7.7161
20	8.5734	6.8587	6.5729	6.5729	6.8587		8.5734
21	8.8592	6.8587	7.7161	7.1445	7.4303		7.4303
22	9.7165	8.0018	8.0018	6.8587	7.4303		8.2876
23	10.2881	8.0018	8.5734	7.7161	8.0018		9.145
24	9.7165	10.2881	8.2876	8.5734	7.7161	8.0018	
Max	10.2881	10.2881	8.5734	8.5734	8.0018	8.0018	9.145
Min	5.7156	5.4298	4.8583	4.0009	4.8583	4.8583	6.5729
Avg	7.9882	7.3393	6.7992	6.6351	6.3617	6.6249	7.8460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 403 / 33 KV Rohana I

Feeder KV- 33 / INCOMING

DATE	16-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1715		8.0018
2			8.0018
3			7.7161
4			7.7161
5			7.4303
6			7.4303
7			5.7156
8			4.5725
9			4.5725
11			3.7151
12			3.4294
13			3.7151
14			4.2867
15		4.5725	
16		4.8583	
17		3.4294	
18		4.5725	
19		6.5729	
20		7.1445	
21		7.7161	
22		8.0018	
23		8.0018	
24			8.0018
Max	.1715	8.0018	8.0018
Min	.1715	3.4294	3.4294
Avg	.1715	6.0966	6.0218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 405 / 33 KV GODHANI RAILWAY
Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.8573	.8573	.8573	.8573	.8573
2	.8573	.8573	.8573	.8573	.8573	.8573	.8573
3	.8573	.8573	.8573	.8573	.8573	.8573	.8573
4	.8573	.8573		.8573	.8573	.8573	.8573
5	.8573	.8573	.8573	.8573	.5716	.5716	.8573
6	.8573	.5716	.8573	.8573	.5716	.5716	.8573
7	.5716	.5716	.8573	.5716	.5716		.5716
8	.5716	.5716	.8573	.5716	.5716		.5716
9	.5716	.5716	.5716	.5716	.5716		.5716
10	.5716	.5716	.5716	.5716	.5716	.5716	.5716
11	.5716	.8573	.8573	.5716	.5716	.2858	.8573
12	.5716	.8573	.8573	.8573	.8573	.2858	.8573
13	.5716	.8573		.8573	.8573	.2858	
14	.5716	.8573		.8573	.8573	.5716	.8573
15	.5716	.8573	.8573	.8573	.8573	.5716	.8573
16	.5716	.8573	.5716	.5716		.5716	.5716
17	.8573	.8573	.8573		.5716	.5716	.5716
18	.8573	.5716	.5716	.5716	.5716	.5716	.5716
19	.5716	.5716	.5716	.8573	.5716	.5716	.5716
20	.8573	.5716	.5716	.5716	.5716	.8573	.8573
21	.8573	.5716	.8573	.8573	.5716	.8573	.8573
22	.8573	.8573	.8573	.8573	.5716	.8573	.8573
23	1.1431	.8573	.8573	.8573	.8573	.8573	.5716
24	.8573	.8573	.8573	.8573	.8573	.8573	.8573
Max	1.1431	.8573	.8573	.8573	.8573	.8573	.8573
Min	.5716	.5716	.5716	.5716	.5716	.2858	.5716
Avg	.7383	.7502	.7757	.7579	.6958	.6532	.7455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 201 / 11 KV Rohana Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201	.6201	.6201	.6201	.6201	.7087	.6201
2	.6201	.5316	.6201	.6201	.6201	.6201	.5316
3	.6201	.5316	.5316	.5316	.5316	.6201	.5316
4	.6201	.5316	.5316	.443	.5316	.6201	.5316
5	.5316	.443	.5316	.443	.5316	.5316	.443
6	.5316	.443	.443	.443	.5316	.5316	.443
7	.443	.3544	.443	.3544	.5316	.5316	.443
8	.443	.3544	.443		.443	.5316	.443
9	.443	.443	.443	.3544	.443	.443	.443
10	.3544	.443	.443	.443	.443	.443	.443
11	.443	.443	.443	.443	.5316	.5316	.443
12	.443	.5316	.5316	.443	.443	.6201	.443
13	.5316	.5316	.5316	.443	.5316	.6201	.443
14	.5316	.5316	.5316	.443	.5316	.6201	.5316
15	.5316	.7087	.5316	.443	.5316	.6201	
16	.5316	.6201	.5316		.6201	.6401	
17	.5316	.5316	.5316	.2658	.5316	.443	.5316
18	.5316	.5316	.443	.3544	.5316	.443	.443
19	.5316	.5316	.443	.443	.5316	.443	.5316
20	.5316	.6201	.5316	.5316	.6201	.5316	.6201
21	.6201	.7087	.6201	.5316	.7087	.6201	.6201
22	.6201	.7087	.6201	.6201	.7087	.6201	.7087
23	.6201	.7087	.7087	.6201	.7087	.6201	
24	.7087	.6201	.7087	.6201	.6201	.7087	.6201
Max	.7087	.7087	.7087	.6201	.7087	.7087	.7087
Min	.3544	.3544	.443	.2658	.443	.443	.443
Avg	.5390	.5426	.5316	.4752	.5574	.5693	.5147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 203 / Silewara

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.924	.724	.9145	.7392	.9145	.924
2	1.086	1.1088	1.267	1.2803	.924	1.0974	1.1088
3	1.086	1.2012	1.267	1.0059	1.1088	1.829	1.2936
4	1.3575	1.2936	1.1765	.9145	1.2012	1.829	1.386
5	1.086	1.4784	1.4632	1.1888	1.2936	1.4632	1.386
6	1.267	1.4784	1.4632	1.2803	1.4784	1.4632	1.1088
7	.905	1.386	1.4632	.9145	1.5708	1.0974	.5544
8	.181	1.2012	.9145		.1848	.9145	.8316
9	.362	1.1088	.823	.5487	.2772	.1829	.7392
10	1.086	1.1765	1.4632	1.2803	1.0974	.9145	1.2803
11	.905	1.267	1.4632	1.4632	.9145	1.386	1.0974
12	.905	1.448	1.448	1.6461	1.1888	1.5708	.9145
13	.905	1.267	1.6461	1.6461	1.1888	1.1088	.9145
14	1.086	1.448	1.1888	1.4632	1.4632	1.2936	1.0974
15	1.8099	1.448	.9145	1.0974	1.0974	.924	
16	.905	.905	.3658	.1848	.7316	.8316	
17	.905	.8145	.3658	.7392	.1829	1.1088	.1829
18	.924	1.086	1.2803	1.4784	.3658	1.5708	1.2936
19	1.386	1.267	1.0974	.924	1.0974	1.2936	1.4784
20	1.4784	1.7194	1.2803	1.1088	1.4632	1.386	1.2936
21	1.386	1.267	1.0974	1.2936	1.4632	1.386	.924
22	1.1088	1.448	1.0974	1.1088	1.2803	1.2936	1.4784
23	.924	.905	.9145	.924	.9145	1.1088	1.0974
24	.905	.7392	.724	.3658	.3696	.7316	.7392
Max	1.8099	1.7194	1.6461	1.6461	1.5708	1.829	1.4784
Min	.181	.7392	.3658	.1848	.1829	.1829	.1829
Avg	1.0356	1.2244	1.1212	1.0770	.9832	1.1958	1.0511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 206 / 11 KV D point Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.829	1.7375	1.829	1.6461	1.7375	1.829
2	1.6461	1.829	1.7375	1.7375	1.6461	1.7375	1.6461
3	1.6461	1.7375	1.7375	1.7558	1.5546	1.7375	1.6461
4	1.6461	1.6461	1.7375	1.7375	1.5546	1.7375	1.5546
5	1.6461	1.6461	1.7375	1.7375	1.6461	1.7375	1.5546
6	1.6461	1.6461	1.6461	1.0974	1.7375	1.7375	1.0974
7	1.0059	1.7375	1.0974		1.0974	1.7375	1.1888
8	1.6461	1.5546	1.6461		1.7375	1.6461	1.7375
9	1.5546	1.4632	1.5729	1.5546	1.6461	1.4632	1.5546
10	1.0059	1.4632	1.4998	1.5546	1.5546	1.5546	1.4632
11	1.5546	1.0669	1.5546	1.5546	1.4815	1.5546	1.5546
12	1.5546	1.2003	1.5546	1.5546	1.5546	1.5546	1.5546
13	1.5546	1.0669	1.5546	1.5546	1.5546	1.5546	1.4632
14	1.5546	1.0669	1.5912	1.5546	1.5546	1.5546	1.4632
15	1.5546	1.6461	1.5912	1.5729	1.5546	1.6461	
16	1.5546	1.6095	1.0059	1.4815	1.0059	1.0974	
17	.823	1.5546	.9145	.9145	.2743	.3658	1.7375
18	1.5546	1.4632	1.5546	1.4632	1.5546	1.4632	1.6461
19	1.6461	1.6461	1.6461	1.6461	1.829	1.7375	1.7375
20	1.9204	1.9204	1.9204	1.829	2.0119	2.0119	2.0119
21		1.9204	1.9387	1.829	2.0119	2.0119	1.9204
22		1.9204	1.9204	1.829	1.9204	1.9204	1.829
23	2.0119	1.8656	1.9204	1.829	1.9204	1.829	1.829
24	1.829	1.9204	1.829	1.8656	1.7375	1.7375	1.829
Max	2.0119	1.9204	1.9387	1.8656	2.0119	2.0119	2.0119
Min	.823	1.0669	.9145	.9145	.2743	.3658	1.0974
Avg	1.5588	1.6008	1.6103	1.6128	1.5744	1.6194	1.6295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 207 / Walni I

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.5089	1.4632	1.0974	1.3203	1.4632	1.4146
2	1.6461	1.8861	2.0119	1.829	1.8861	1.829	1.6975
3	1.829	2.0748	2.0119	1.829	2.1691	1.829	1.9805
4	2.1948	2.2634	2.0119	2.0119	2.2634	1.829	2.0748
5	2.3777	2.3577	1.3717	2.1948	2.452	2.3777	2.1691
6	1.6461	2.452	1.5546	2.1948	1.8861	2.3777	1.8861
7	.9145	1.226	1.1888	1.2803	.7545	.7316	.7545
8	.1829	.9431	.7316		.3772	.2743	.3772
9	.9145	1.3203	1.4632	1.0974	.9431	.7316	1.1317
10	.1829	1.6461	2.3777	1.6461	2.1948	1.6461	2.1948
11	1.829	1.4632	2.3777	1.829	2.1033	2.0748	2.1033
12	2.1948	2.1033	1.829	2.3777	2.3777	2.1691	2.1948
13	2.1948	2.1948	2.1948	.823	2.0119	2.0119	1.829
14	2.1948	1.829	2.1948	2.3777	2.0119	2.0119	2.0119
15	1.6461	1.2803	1.2803	.9145	1.0974	1.5089	
16	1.0974	.9145	.9145	.1886	1.0974	.7545	
17	1.2803	1.829	1.2803	1.3203	1.4632	.9431	.5487
18	2.0748	1.829	1.6461	1.8861	2.1948	.9431	1.3203
19	2.452	1.829	2.0119	2.1033	2.1948	1.8861	1.5089
20	2.2634	1.829	2.0119	2.3577	2.0119	2.3577	1.8861
21	2.1691	1.3717	1.6461	2.0748	2.3777	2.0748	2.0748
22	2.1691	1.6461	1.829	2.2634	2.3777	2.2634	1.1317
23	1.1317	1.0974	1.2803	1.1317	1.2803	1.3203	
24	1.2803	1.1317	1.0974	1.0974	.9431	1.0974	1.1317
Max	2.452	2.452	2.3777	2.3777	2.452	2.3777	2.1948
Min	.1829	.9145	.7316	.1886	.3772	.2743	.3772
Avg	1.6311	1.6678	1.6575	1.6490	1.7412	1.6044	1.5915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 401 / 33 KV Incomer I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)
1		4.8325
2		5.3212
3		6.0905
4		6.0905
5		6.1357
6		6.19
7		4.0832
8		3.2602
10		1.6289
11		3.3608
12		3.3608
13		3.6408
14		3.9209
15	4.2798	
16	3.3436	
17	2.3663	
18	4.5748	
19	5.7013	
20	5.695	
21	6.653	
22	6.4866	
23	5.0412	
24		4.6491
Max	6.653	6.19
Min	2.3663	1.6289
Avg	4.9046	4.4689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 402 / 33 KV Incomer NON SHEDDABLE EXPRESS HV FEEDERS
 II(Bhagimari) Feeder KV- 33 / (NON-CONTINUOUS PROCESS)(NO
 INCOMING STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6571	4.9383	4.6571	4.4907	4.4353		4.9383
2	5.156	5.2126	5.7105	5.5441	5.2126		4.9383
3	5.3224	5.487	5.655	5.156	5.487		5.487
4	5.9877	5.7613	5.5996	5.156	5.487		5.487
5	5.8213	5.7613	5.2669	5.5418	6.0357		5.487
6	5.2115	6.0357	5.6013	5.0452	5.487		4.6639
7	3.3819	4.6639	4.3244	3.6591	4.1581		3.0807
8	2.4949	4.1581	3.8255		3.0807		3.6408
9	3.3265	4.4353	4.2353	3.5117	3.3608	2.8778	3.8809
10	2.6612	5.2669	5.7556	4.9897	5.2675	6.4312	5.4321
11	4.8234	5.2669	5.7556	5.3224	5.048	8.7792	5.2126
12	5.2115	5.8213	5.2669	6.0357	5.6516	9.0535	5.2126
13	5.3224	5.6013	5.9259	4.4445	5.3778	9.0535	
14	5.5441	5.2669	5.487	5.8711	5.655	9.3279	5.1029
15	5.7105	5.2669	4.4136	4.0055		4.6639	
16	4.1581	4.257	2.8567	1.9605		3.3608	
17	3.6591	4.9383	3.1367	3.3608		3.0807	2.8807
18	4.9383	5.0972	4.9851	5.2126		4.4353	4.6639
19	6.0357	5.4332	5.2115	5.2126		5.2126	5.2126
20	6.0357	6.154	5.7659	5.7613		6.31	5.7613
21	4.1581	5.4893	5.2126	5.7613		6.0357	5.487
22	3.8809	5.9374	5.4887	5.7613		6.0357	5.2126
23	4.6639	5.1532	4.8285	4.6639		4.6639	3.0178
24	4.8788	4.4353	4.5931	3.9918	3.8809		4.4353
Max	6.0357	6.154	5.9259	6.0357	6.0357	9.3279	5.7613
Min	2.4949	4.1581	2.8567	1.9605	3.0807	2.8778	2.8807
Avg	4.7100	5.2433	4.9816	4.8026	4.9083	5.9548	4.7255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 201 / 11 kV Khaperkheda
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1253	2.2862	2.3339	2.2405	2.0919	2.2862
2		2.0538	2.1948	2.2405	2.2032	2.0576	2.2862
3		1.9753	2.1948	2.1472	2.1658	1.989	2.1948
4		1.9404	2.2131	2.0328	2.0911	1.9376	2.1033
5		1.848	1.829	1.9605	1.9605	1.8861	1.829
6		1.6817	1.7193	1.8671	1.6991	1.6632	1.701
7		1.6078	1.4998	1.7364	1.5497	1.5432	1.5546
8		1.5154	1.4998	1.531	1.3817	1.406	1.4083
9		1.4415	1.5912	1.5497	1.4415	1.3717	1.4998
10		1.4784		1.5684	1.4784	1.4232	1.5546
11	1.7375	1.5023	1.6244	1.5729	1.3546	1.4998	1.6804
12	1.7375	1.6827	1.7372	1.6632	1.4575	1.3717	1.6244
13	1.7924	1.828	1.8671	1.829	1.8347	1.4998	1.9418
14	1.9204	1.9547	2.0698	1.9204	1.8861	2.5057	2.0513
15	1.9753	1.9753	1.9605	1.829	1.9204	2.1216	2.0911
16	1.829	1.7918	1.9605	1.4632	1.7318	2.0485	1.9791
17	1.5912	1.7918	1.8298	1.4266	1.5432	1.8656	1.8858
18	1.6644	1.701	1.7737	1.4998		1.5729	1.8111
19	1.8839	1.7558	1.8484	1.829	1.7318	1.9022	1.9418
20	2.1582	2.1948	2.0883	1.9936	2.0062	2.1622	2.2405
21	2.2131	2.2131	2.2546	2.0485	2.0748	2.2131	
22	2.2731	2.3228	2.3285	2.1033	2.1091	2.3045	1.0642
23	2.4025	2.3777	2.4949	2.1765	2.1434	2.4025	2.347
24		2.2916	2.3777	2.4025	2.2177	2.1434	2.3045
Max	2.4025	2.3777	2.4949	2.4025	2.2405	2.5057	2.347
Min	1.5912	1.4415	1.4998	1.4266	1.3546	1.3717	1.0642
Avg	1.9368	1.8771	1.9671	1.8635	1.8358	1.8743	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 202 / 11 kV Bhanegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9425	.9145	.9149	.8871	.9088	.9694
2	.7888	.8871	.8779	.8775	.8775	.823	.9511
3	.7202	.8589	.8779	.8215	.8215	.7888	.9511
4	.6516	.8131	.823	.7842	.7842	.7716	.9145
5	.6173	.7468	.823	.7468	.7468	.7545	.823
6	.6001	.6401	.7316	.7095	.6535	.823	.7316
7	.4801	.5601	.5121	.6161	.5788	.5487	.6401
8	.5487	.5914	.5853	.6224	.5544	.5658	.6401
9	.5316	.6653	.6036	.7095	.5914	.6173	.6584
10	.703	.6653		.7468	.6283	.6516	.7682
11	.7316	.7682	.6722		.6516	.7316	.8215
12	.7316	.7316	.6535	.7577	.7545	.7316	.8962
13	.8048	.8779	.7095	.7762	.823	.8596	.8962
14	.8779	.8413	.8029	.7577	.823	.8413	.8589
15	.9145	.8779	.8029	.7499	.823	.7865	.8589
16	.8688	.9145	.7842	.7682	.8059	.9328	.9896
17	.7682	.823	.7095	.6584	.7888	.8871	.8962
18	.6584	.7545	.6348	.6219	.6344		.7655
19	.7682	.7316	.6348	.6767	.6859	.7316	.7282
20	.8413	.7499	.8029	.695	.7202	.7316	.7655
21	.9145	.823	.8215	.7682	1.1488	.8779	
22	.961	.8779	.8962	.8316	.823	.9511	.8775
23	1.0164	.9145	.9896	.8962	.8916	.9511	.9896
24	.8916	.9979	.9145	.9709	.9055	.9088	.9694
Max	1.0164	.9979	.9896	.9709	1.1488	.9511	.9896
Min	.4801	.5601	.5121	.6161	.5544	.5487	.6401
Avg	.7603	.7939	.7643	.7599	.7668	.7902	.8418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 203 / 11 KV WCL BHANEGAON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	1.6263	1.6095	1.1016	1.1203	1.2517	1.1888
2	1.7833	1.643	1.6095	1.0269	1.0829	1.2346	1.1888
3	1.749	1.6244	1.5546	.9335	1.0642	1.2689	1.2803
4	1.8176	1.6078	1.5546	1.0642	1.1203	1.0802	1.3306
5	1.7147	1.5893	1.5546	1.2136	1.1576	1.0802	1.3169
6	1.6289	1.5893	1.4632	1.363	1.2136	1.3717	1.6095
7	1.6461	1.5684	1.4632	1.6057	1.1949	1.3375	1.4632
8	1.6632	1.5708	1.4632	1.3256	1.1949	1.3546	1.4632
9	.2743	1.5729	1.4632	1.307	1.2197	1.3717	1.5546
10	1.5432	1.6078		1.307	1.2382	1.406	1.5546
11	1.6644	1.5729	1.7002	1.643	1.166	1.5546	.5041
12	1.6827	1.4632	1.5684	1.6448	1.1317	1.4632	1.2883
13	1.6095	1.6095	1.7556	1.6263	1.406	1.4632	1.6804
14	1.6827	1.6095	1.6057	1.6461	1.4403	1.0974	1.4937
15	1.6827	1.6095	1.643	1.6461	1.4746	1.6461	1.7177
16	1.6461	1.6095	1.7177	1.6644	1.406	1.5912	1.7551
17	1.5546	1.6095	1.363	1.6095	1.3717	1.2437	1.8111
18	1.5181	1.6095	1.307	1.5912	1.3375	1.5546	1.6991
19	1.5546	1.6095	1.3443	1.5729	1.3546	1.4632	1.643
20	1.5912	1.5546	1.3443	1.5912	1.3889	1.4632	1.2136
21	1.5893	1.5546	1.363	1.6095	1.3717	1.4784	
22	1.5893	1.6095	1.3817	1.6278	1.3375	1.1458	1.6057
23	1.5524	1.6095	1.386	1.6278	1.3375	1.2437	.2641
24	1.8176	1.5893	1.6095	1.1576	1.5893	1.3546	1.1706
Max	1.8176	1.643	1.7556	1.6644	1.5893	1.6461	1.8111
Min	.2743	1.4632	1.307	.9335	1.0642	1.0802	.2641
Avg	1.5975	1.5925	1.5141	1.4378	1.2800	1.355	1.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 401 / 33 KV GCR1

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0998		.0008	.1064	.1029	
2	.1029	.0998		.0007	.1008	.1029	
3	.1029	.0998		.0007	.1008	.1029	
4	.1029	.0998		.0008	.1008	.1029	
5	.1029	.0998		.0007	.1008	.1029	
6	.1029	.0998		.0006	.1008	.1029	
7	.1029	.1008		.0007	.1008	.1029	
8	.1029	.0998		.0008	.1008	.1029	
9	.1029	.0998		.0008	.1008	.1029	
10	.1029	.0998		.0008	.0998	.1029	
11	.0988		.0008	.0998	.1029		.0008
12	.0977		.0009	.0998	.1029		.0009
13	.0977		.0007	.1008	.1029		.0008
14	.0988		.0008	.0998	.1029		.0008
15	.0988		.0007	.0988	.1029		.0008
16	.0988		.0008	.1053	.1029		.0008
17	.0988		.0008	.0998	.1029		.0008
18	.0988		.0008	.1008	.1029		.0008
19	.1109		.0008	.1097	.1029		.0008
20	.1109		.0009	.1043	.1029		.0009
21	.1109		.0008	.1109	.1029		
22	.1109		.0008	.1109	.1029		.0008
23	.1109		.0008	.1109	.1029		.0008
24	.1029	.0998		.0008	.1109	.1029	
Max	.1109	.1008	.0009	.1109	.1109	.1029	.0009
Min	.0977	.0998	.0007	.0006	.0998	.1029	.0008
Avg	.1031	.0999	.0008	.0567	.1026	.1029	.0008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 402 / 33 KV GCR2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0998	.1097	.0008	.1064	.1029	.1097
2	.1029	.0998	.1097	.0007	.1008	.1029	.1097
3	.1029	.0998	.1097	.0007	.1008	.1029	.1097
4	.1029	.0998	.112	.0008	.1008	.1029	.1097
5	.1029	.1008	.1097	.0007	.1008	.1029	.1097
6	.1029	.0998	.1097	.0006	.1008	.1029	.1097
7	.1029	.1008	.1097	.0007	.1008	.1029	.1097
8	.1029	.0998	.1097	.0008	.1008	.1029	.1097
9	.1029	.0998	.1097	.0008	.1008	.1029	.1097
10	.1029	.0998		.0008	.0998	.1029	.1097
11	.1043	.1097	.0008	.0998	.1029	.1097	.0008
12	.0977	.1097	.0009	.1064	.1029	.1097	.0009
13	.0988	.1097	.0007	.1008	.1029	.1097	.0008
14	.0988	.1097	.0008	.1008	.1029	.1097	.0008
15		.1097	.0007	.1053	.1029	.1097	.0008
16	.0988	.1097	.0008	.0998	.1029	.1097	.0008
17	.0988	.1097	.0008	.0998	.1029	.1097	.0008
18	.0988	.1097	.0008	.1053	.1029	.1097	.0008
19	.0988	.1097	.0008	.1043	.1029	.1097	.0008
20	.0988	.1097	.0009	.1109	.1029	.1097	.0009
21	.1109	.1097	.0008	.1109	.1029	.1097	
22	.1053	.1097	.0008	.1109	.1029	.1097	.0008
23	.1109	.1097	.0008	.1109	.1029	.1097	.0008
24	.1029	.1053	.112	.0008	.1053	.1029	.1097
Max	.1109	.1097	.112	.1109	.1064	.1097	.1097
Min	.0977	.0998	.0007	.0006	.0998	.1029	.0008
Avg	.1023	.1055	.0483	.0573	.1023	.1066	.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 403 / 33 KV Incomer I(KANHAN) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6749	4.768	4.8285	4.313	4.3244	4.4239	4.5462
2	2.572	4.5462	4.7188	4.145	4.2135	4.2181	4.4353
3	2.4691	4.4353	4.6091		3.9918	4.1152	4.4353
4	2.4691	4.3244	4.6091	3.8649	3.8809	3.9095	4.2798
5	2.3663	4.3244	4.2798	3.9209	3.77	3.8066	3.9506
6	2.3148	4.1027	4.0604	4.0329	3.6591	3.8066	4.1701
7	2.1605	3.9209	3.8409	4.0329	3.3265	3.6008	3.9506
8	2.2634	3.77	3.7311	3.5848	3.3608	3.4465	3.8409
9	.5144	3.6591	3.8409	3.6408	3.3608	3.4465	3.9506
10	2.2634	3.9209		3.8089	3.5482	3.6008	4.0329
11	2.524	4.1027	4.0889	4.2135	3.2922	3.9506	3.0247
12	4.2798	3.9918	4.145	4.3244	3.4979	3.8409	3.9209
13	4.2798	4.6091	4.537	4.4353	4.2181	4.0604	4.6491
14	4.4993	4.6091	4.7051	4.4993	4.321	4.6091	4.537
15	4.561	4.7188	4.537	4.3896	4.4239	4.9383	4.8171
16	4.3896	4.4993	4.5931	3.9506	4.2181	4.8285	4.9291
17	4.1701	4.4993	4.0889	3.7311	3.9095	4.1701	4.5931
18	4.0604	4.1701	3.8089	3.8409	3.6008	3.9506	4.369
19	4.3439	4.2798	3.9209	4.1701	4.0124	4.2798	4.481
20	4.7188	4.7188	4.313	4.4993	4.321	4.6091	4.369
21	4.8285	4.8285	4.537	4.7188	4.4239	4.4993	
22	4.768		4.7051	4.768	4.4239	4.4993	3.6408
23	5.1006	5.048	4.9851	4.8285	4.5268	4.7782	3.5288
24	2.7778	4.768	5.048	4.7051	4.8788	4.5268	4.6696
Max	5.1006	5.048	5.048	4.8285	4.8788	4.9383	4.9291
Min	.5144	3.6591	3.7311	3.5848	3.2922	3.4465	3.0247
Avg	3.3904	4.3746	4.3709	4.1921	3.9793	4.1631	4.2227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164037 / 33 KV TPS KHAPERKHEDA

Feeder No / Name : 404 / 33 KV Incomer II(ROHANA) NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	20-JUN-18
HR	Load (MW)
11	.1097
12	.1097
13	.1097
14	.1097
18	.1097
20	.1097
22	.1097
Max	.1097
Min	.1097
Avg	.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 201 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0683	.0709	.0886	.0709	.2303	.0709	.1772
2	1.9631	.0354	.0886	.0709	.2481	.0709	.1772
3	1.893	.0709	.0709	.0709	.2303	.0709	.1772
4	1.7878	.0532	.0709	.0709	.2481	.0709	.1772
5	1.7177	.0532	.0532	.0532	.2481	.0709	.1772
6	1.6827	.0532	.0532	.0709	.2303	.0709	.0532
7	1.6476	.1949	.2126	.1949	.2303		.0354
8		.1772	.2126	.1949	.2303	.2126	.1772
9	1.5775	.1949	.2126	.1949	.2658	.2126	.1949
10	1.6655	.2658	.1949	.2658	.2658	.2303	.2481
11	1.7364	.2658	.1949	.2658	.2658		.2303
12	.1949	.2481	.1949	.2303	.2658		.2126
13	.1949	.2126	.2126	.1063	.2303		.2126
14	.0532	.2303	.1772	.1063	.2658		.2303
15	.124	.2303	.1772	.1063	.2303		.2126
16	.2481	.2303	.1949	.1063	.2835		.2303
17	.2481	.2303	.1949		.2658		.2126
18	.3366	.2303	.0709	.1063	.2658		.2303
19	.3544	.2303	.0532	.1063	.0709		.1949
20	.3544	.2126	.0709	.2658	.1063		.1949
21	.2126	.0886	.0709	.2303	.0886		.1949
22	.0709	.0886	.0886	.2303	.0953	.0532	.1949
23	.0709	.0886	.0709	.2303	.0886	.0532	.0709
24	2.2085	.0709	.0886	.0709	.2303	.0709	.1772
Max	2.2085	.2658	.2126	.2658	.2835	.2303	.2481
Min	.0532	.0354	.0532	.0532	.0709	.0532	.0354
Avg	.9744	.1595	.1299	.1487	.2159	.1049	.1831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164078 / 33 KV KORADI

Feeder No / Name : 202 / 11 KV Jagdamba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0381
2	.0381	.1524	.0381
3	.0381		.0381
4	.0381		.0381
5	.0381		.0381
6	.0381		.0381
7	.0381		.0381
8	.0381		.0191
9	.0381		.0381
10	.0572		.0572
11	.0572		.0381
12	.0381		.0381
13	.0381		.0381
14	.0381		.0381
15		.0191	.0381
16		.0381	.0572
17		.0381	.0572
18		.0572	.0572
19		.0572	.0572
20		.0381	.0572
21			.0572
22		.0381	.0572
23		.0381	.0381
24	.0381		.0381
Max	.0572	.1524	.0572
Min	.0381	.0191	.0191
Avg	.0406	.0529	.0437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 201 / 11KV PARSEONI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.6859	.6859	.7202	.6859	.6859	.7373
2	.703	.6516	.6859	.7202	.6687	.6516	.7373
3	.6859	.6173	.6516	.6859	.6516	.6344	.6687
4	.6859	.6001	.583	.6859	.6344	.6001	.6687
5	.6516	.583	.583	.6001	.6001	.583	.6001
6	.5658	.5487	.5487	.5487	.5316	.5658	.5487
7	.463	.4801	.4973	.5144	.4973	.5144	.5144
8	.463	.463	.4973	.4801	.4801	.4801	.4801
9	.463	.4287	.4973	.4973	.4458	.4801	.4801
10	.4801	.463	.5144	.5487	.5144	.5144	.5144
11	.5487	.5144	.5144	.583	.5316	.5658	.5658
12	.583	.5316	.5144	.6001	.5487	.583	.5316
13	.6173	.5658	.5658	.6516	.6001	.6344	.4973
14	.6344	.6001	.6001	.6859	.6173	.6516	.583
15	.6687	.6173	.0343	.703	.6516	.6344	.6516
16	.6687	.5658	.5658	.5658	.6001	.6173	.6173
17	.583	.5487	.583	.5316	.5658	.6001	.6001
18	.583	.5316	.5316	.5316	.4973	.5487	.6173
19	.6344	.583	.6859	.5487	.6001		.6173
20	.6687	.6687	.6516	.6173	.6516	.6516	.6001
21	.6687	.6859	.6859	.6687	.6516	.6859	
22	.7202	.703	.7373	.6859	.6687	.7202	.6173
23	.7373	.7202	.7373	.703	.703	.7373	.6859
24	.7202	.7373	.7202	.7202	.6859	.703	.7373
Max	.7373	.7373	.7373	.7202	.703	.7373	.7373
Min	.463	.4287	.0343	.4801	.4458	.4801	.4801
Avg	.6209	.5873	.578	.6166	.5951	.6106	.6031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 202 / 11 KV PARASEONI RURAL SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.9945	.7888	.8916	.7202	.823	
2	.823	.9602	.7888	.8916	.703	.8059	
3	.823	.8916	.7545	.8745	.703	.7888	
4	.8059	.823	.7545	.8573	.6344	.7545	
5	.7888	.7545	.703	.7716	.583	.7202	
6	.7716	.6687	.6173	.6859	.4801	.6516	
7	.7373	.6344	.5144	.6516	.3944	.6001	
8	.703	.6001	.6344	.6344	.2915	.6344	
9	.6859	.6859	.7202	.7202	.3086	.5487	.6687
10	.703	.6859	.6859	.703	.2572	.5487	.6344
11	.7202	.703	.703	.6859	.1715	.583	.6001
12	.583	.7202	.7202	.703	.6001	.4287	.6173
13	.6516	.7202	.8059	.703	.6859	.6687	.6516
14	.5658	.7373	.7545	.6859	.6859	.6173	.6173
15	.7545	.7373	.6687	.6516	.6687	.7202	.583
16	.6344	.703	.6001	.2915	.6687	.6859	.6001
17	.6687	.6859	.463	.3944	.6516	.4801	.6173
18	.703	.6516	.703	.4973	.6173	.4801	.6516
19	.9602	.7888	.7373	.6001	.8402		.6859
20	.9602	.9602	1.0974	.6344	.8916	.8573	.703
21	.9602	.8745	1.0802	.7202	.9088	.8916	
22	.9259	.8402	.9774	.7888	.8573		.6859
23	.9088	.823	.9259	.7545	.8402	.8916	.6859
24	.8402	1.0288	.8059	.8916	.7202	.8402	
Max	.9602	1.0288	1.0974	.8916	.9088	.8916	.703
Min	.5658	.6001	.463	.2915	.1715	.4287	.583
Avg	.7716	.7780	.7502	.6952	.6201	.6828	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 203 / 11 KV SURYLATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2915	.2915	.3086	.2572	.3086	.3086
2	.2915	.2743	.2743	.3086	.2401	.2401	.3086
3	.2915	.2743	.2743	.3086	.2401	.2743	.3086
4	.2743	.2572	.2572	.2915	.2401	.2743	.2915
5	.2743	.2572	.2572	.2572	.2401	.2572	.2572
6	.2401	.2229	.2229	.2229	.2229	.2572	.2058
7	.1886	.2058	.2058	.1715	.1715	.2058	.1715
8	.1886	.2058	.1715	.1715	.1886	.1715	.1715
9	.2058	.2058	.1886	.1886	.2058	.1886	.2058
10	.2058	.2058	.1886	.1886	.2058	.1715	.1886
11	.1886	.2229	.2401	.1886	.2058	.2058	.1715
12	.2058	.2229	.2572	.1886	.2058	.2058	.1886
13	.2229	.2229	.2572	.2058	.2058	.2229	.1886
14	.2058	.2401	.2572	.2058	.2229	.2401	.1886
15	.1543	.2401	.2572	.2058	.2229	.2572	.2229
16	.1886	.2058	.2572	.0857	.2058	.2401	.2229
17	.1715	.1886	.2229	.12	.1715	.1886	.2229
18	.1543	.1886	.2058	.1543	.1886	.1886	.2058
19	.2058	.2229	.2401	.2058	.2743		.1886
20	.2915	.2915	.2915	.2401	.3086	.2572	.2572
21	.3086	.3086	.3086	.2572	.3086	.2743	
22	.3086	.2915	.3258	.2743	.3086	.3258	.2572
23	.2915	.2915	.3086	.2743	.3086	.3086	.2572
24	.2915	.2915	.2915	.3086		.3086	.3086
Max	.3086	.3086	.3258	.3086	.3086	.3258	.3086
Min	.1543	.1886	.1715	.0857	.1715	.1715	.1715
Avg	.2351	.2429	.2522	.2222	.2326	.2423	.2304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 204 / 11KV TAMSWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.9945	.583	.9088	1.2346	1.2003	.6687
2	.9088	.9602	.5658	.9088	1.1145	1.166	.6859
3	.9088	.9259	.5658	.9431	1.0974	1.1317	.7716
4	.8745	.8916	.5658	.9774	1.0802	1.0974	.8059
5	.8059	.8745	.5487	.8573	1.046	1.046	.7716
6	.7716	.8402	.4458	.8059	.9945	1.0117	.6859
7	.7202	.823	.4458	.7373	.9431	.9774	.6173
8	.6859	.6859	.4458	.7545	.9774	1.0117	.7202
9	.6859	.7716	.463	.7716	1.0288	1.0288	.703
10	.7716	.823	.703	.7545	.9602	.7373	.703
11	.7545	.8573	.823	.7202	.9259	.823	.7202
12	.8916	.9088	.7716	.7888	1.0288	.6001	.9259
13	.8916	.9088	.8059	.8745	1.1145	1.1317	1.0288
14	.8916	.9259	.9088	.8402	1.1317	.9945	1.0631
15	.9088	.9431	.823		1.1488	1.0974	1.0802
16	.823	.8745	.7545		1.0288	.9945	1.046
17	.6687	.7888	.8745	.6173	.8916	.8573	1.0117
18	.6687	.6687	.7716	.7888	.8573	.8573	.9945
19	1.0802	.8745	.8402	1.0631	1.0802		.9774
20	1.0802	1.0802	.9945	1.166	1.2517	.6859	.9602
21	1.0631	1.046	1.0974	1.2174	1.286	.7373	
22	1.0631	1.0288		1.286	1.2689	.7888	
23	1.046	.9945	1.0802	1.2517	1.2517	.9774	.2915
24	.9602	1.0288	.583	.9088	1.2517	1.2517	.6687
Max	1.0802	1.0802	1.0974	1.286	1.286	1.2517	1.0802
Min	.6687	.6687	.4458	.6173	.8573	.6001	.2915
Avg	.8681	.8966	.7157	.9065	1.0831	.9654	.8137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 205 / 11 kV MIDC Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0171	.0343
2	.0343	.0343	.0343	.0343	.0343	.0171	.0343
3	.0343	.0343	.0343	.0343	.0343	.0171	.0343
4	.0343	.0343	.0343	.0343	.0343	.0171	.0343
5	.0343	.0343	.0343	.0343	.0343	.0171	.0343
6	.0343	.0343	.0343	.0343	.0343	.0171	
7	.0343	.0343	.0343	.0343	.0343	.0171	.0343
8	.0343	.0343	.0343	.0343	.0343	.0171	.0343
9	.0343	.0343	.0343	.0343	.0343	.0171	.0343
10	.3258	.0343		.0343	.0343	.3086	.0343
11	.1543	.0343	.0343	.1543	.1886	.1886	.1543
12	.1543	.0343	.0343		.1715	.1715	.1543
13	.1715	.0343	.0343		.1372	.1886	.1715
14	.1372	.0343	.0343		.1372	.1715	.2058
15	.2229	.0343	.0343		.1543	.1372	.2401
16	.1715	.0343	.0343	.1715	.1715	.1715	.2229
17	.1543	.0343	.0343	.1372	.1715	.1543	.2058
18	.0343	.0343	.0343	.0857	.0171	.1715	.1372
19	.0343	.0343	.0343	.0343	.0171		.0343
20	.0343	.0343	.0343	.0343	.0343	.0171	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	
22	.0343	.0343	.0343	.0343	.0343	.0343	
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.3258	.0343	.0343	.1715	.1886	.3086	.2401
Min	.0343	.0343	.0343	.0343	.0171	.0171	.0343
Avg	.0850	.0343	.0343	.0549	.0700	.0857	.0923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSHIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 206 / 11 KV PARSHIONI URBAN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4458		.463
2	.4801	.4458		.463
3	.4801	.4287		.463
4	.463	.4287		.4458
5	.4287	.3944		.4287
6	.3429	.3258		.3429
7	.2572	.2572		.2058
8	.2401	.2572		.2743
9	.2401	.2401		.2743
10	.2572		.6135	.2572
11	.2743		.2229	.2401
12			.2401	.2743
13			.3258	.3086
14			.3429	.3258
15			.3086	.3429
16	.1886		.2915	.3086
17	.1715		.2401	.2915
18	.1886		.2401	.2915
19	.2229			.2743
20	.3086		.3429	.3601
21	.3944		.3772	
22	.4458		.463	.3772
23	.4801		.4801	.4458
24	.4801	.4458		.463
Max	.4801	.4458	.6135	.463
Min	.1715	.2401	.2229	.2058
Avg	.3412	.3670	.3453	.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 207 / AG SEPERATION FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-JUN-18
HR	Load (MW)
12	.0175
Max	.0175
Min	.0175
Avg	.0175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 201 / Bitoli AG Separated

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0189		.0328	.0377	.0343	.0328
2	.0328	.0189		.0328	.0377	.0343	.0328
3	.0328	.0189		.0328	.0377	.0343	.0328
4	.0328	.0377		.0328	.0377	.0343	.0328
5	.0328	.0377		.0328	.0377	.0343	.0328
6	.0328	.0189	.1132	.0328	.0377	.0343	.0328
7	.0819	.0377	.0343	.0328	.0377	.0343	.0328
8	.0983	.0377	.0343	.0655	.0377		.0328
9	.1132	.0514	.0328	.0566	.0171	.0328	.0373
10	.1132	.0857	.0819	.0754	.0514	.0655	.0934
11	.132	.1029	.0983	.1132	.0686	.0655	.1307
12	.132	.1029	.0983	.1132	.0686	.0819	.1307
13	.1509	.12	.0983	.1132	.0686	.0819	.1494
14	.1132	.12	.0983	.0754	.0686	.0655	.1494
15	.0943	.1372	.0983	.0754	.0686	.0819	.0934
16		.1372	.0983		.0686	.0819	.0934
17	.1132	.12	.1147	.0566	.0171	.0983	.0747
18	.0566	.0377	.0655	.0566	.0171	.0655	.1307
19	.0754		.0655	.0377	.0171		.0747
20	.0754		.0655	.0377	.0343	.0328	.0373
21	.0377		.0328	.0377	.0343	.0328	.0373
22	.0377		.0328	.0377	.0343	.0328	.056
23	.0377		.0328	.0377	.0343	.0328	.0747
24	.0549	.0189		.0328	.0377	.0343	.0328
Max	.1509	.1372	.1147	.1132	.0686	.0983	.1494
Min	.0328	.0189	.0328	.0328	.0171	.0328	.0328
Avg	.0745	.0663	.0720	.0544	.0420	.0512	.0691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 202 / INDUSTRIAL -H.T.-FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0754		.0362	.0377	.0343	.0362
2	.0543	.0754		.0362	.0377	.0343	.0362
3	.0543	.0754		.0362	.0377	.0343	.0362
4	.0362	.0566		.0362	.0377	.0343	.0362
5	.0543	.0566		.0362	.0377	.0343	.0362
6	.0543	.0566		.0362	.0377	.0343	.0362
7	.0543	.0566		.0362	.0377	.0343	.0362
8	.0362	.0377		.0362	.0377	.0343	.0362
9	.0377	.0343	.0543	.0566	.0343	.0362	.056
10	.0189	.0343	.0181	.0189	.0343	.0362	.0187
11	.0377	.0344	.0181	.0377	.0171	.0181	.0373
12	.0377	.0343	.0362	.0566	.0171	.0362	.0373
13	.0566	.0514	.0362	.0566	.0171	.0362	.0373
14	.0566	.0343	.0362	.0566	.0343	.0181	.0373
15	.0377	.0343	.0362	.0566	.0343	.0543	.0373
16		.0343	.0543	.0566	.0343	.0543	.0373
17	.0377	.0343	.0543	.0377	.0343	.0543	.0373
18	.0377		.0543	.0377	.0343	.0362	.0373
19	.0189		.0362	.0377	.0343	.0181	.0373
20	.0377		.0362	.0377	.0514	.0543	.056
21	.0377		.0543	.0377	.0514	.0543	.0373
22	.0377		.0362	.0377	.0686	.0543	.0373
23	.0377		.0362	.0377	.0686	.0362	.0373
24	.0543	.0566		.0362	.0377	.0514	.0543
Max	.0566	.0754	.0543	.0566	.0686	.0543	.056
Min	.0189	.0343	.0181	.0189	.0171	.0181	.0187
Avg	.0426	.0485	.0398	.0411	.0377	.0385	.0384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 203 / 11KV CHARGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1132		.1132	.0754	.1029	.132
2	.0943	.1132		.1132	.0754	.1029	.1132
3	.0943	.0943		.1132	.0754	.1029	.1132
4	.0754	.0943		.1132	.0754	.0857	.1132
5	.0754	.0754		.1132	.0566	.0857	.0943
6	.0754	.0377		.0943	.0566	.0857	.0943
7	.0754	.0754		.0943	.0566	.0686	.0943
8	.0377	.0754		.0943	.0566		.0943
9	.0377	.0686	.0943	.0754	.0514	.0754	.0943
10	.0566	.0686		.0566	.0514	.1132	.0943
11	.0754	.0686	.0754	.0754	.0686	.0943	.0754
12	.0754	.0686	.0754	.0754	.0857	.0943	.0754
13	.0754	.0686	.0754		.0857	.0943	.0943
14	.0566	.0686	.0754		.0857	.0943	.0943
15	.0566	.0686	.0754		.0857	.0754	
16	.0566	.0686	.0566		.0857	.0754	.0747
17	.0377	.0514	.0754		.0686	.0754	.0377
18	.0754		.0754		.0686	.0754	.0377
19	.1132		.1132	.0377	.1029	.0951	.0943
20	.1509		.1132	.1698	.1029	.132	.132
21	.1509		.132	.0754	.1029	.1509	.0943
22	.132		.132	.0754	.1029	.1509	.1132
23	.132		.132	.132	.1029	.1509	.132
24	.0943	.1132		.1132	.0754	.1029	.1523
Max	.1509	.1132	.132	.1698	.1029	.1509	.1523
Min	.0377	.0377	.0566	.0377	.0514	.0686	.0377
Avg	.0833	.0774	.0929	.0964	.0773	.0993	.0976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 204 / Bitoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4904		.4755	.4527	.4115	.4572
2	.4207	.4904		.4572	.4527	.3944	.439
3	.4207	.4715		.4207	.415	.3601	.4207
4	.4024	.415		.4024	.415	.3258	.4207
5	.3475	.3395		.3841	.3395	.2572	.4024
6	.2926	.3018		.3109	.3018	.2229	.3292
7	.2378	.2641		.2926	.2641	.2058	.2561
8	.2561	.0754		.2743	.2641		.2378
9	.2641	.0686	.2561	.2452	.2229	.2012	.2614
10	.2075	.2572	.2561	.2641	.2229	.1829	.2614
11	.2452	.2915	.2561	.3018	.2229	.2012	.2614
12		.3086	.2743	.3206	.2229	.2743	.2801
13		.3258	.3109	.3395	.2229	.3142	.2987
14	.3206	.3086	.3292	.3018	.2229	.3292	.2987
15	.3206	.2743	.3109	.2829	.2229	.3109	.0754
16		.2572	.2743	.2829	.2229	.2926	.3361
17	.2829	.2401	.2561	.1886	.2058	.2378	.2801
18	.2452		.2195	.2263	.1886	.2195	.2427
19	.3206		.2926	.2829	.3944	.2852	.3361
20	.4527		.439	.415	.4458	.4207	.4854
21	.4904		.4755	.4527	.4287	.439	.4481
22	.4715		.4938	.4904	.4287	.499	.4481
23	.4904		.4938	.4715	.4115	.4805	.4481
24	.4572	.4904		.4755	.4715	.4458	.4805
Max	.4904	.4904	.4938	.4904	.4715	.499	.4854
Min	.2075	.0686	.2195	.1886	.1886	.1829	.0754
Avg	.3517	.3150	.3292	.3483	.3193	.3179	.3419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 205 / 11 KV SATRAPUR Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	19-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187		.0171
2				.0171
3				.0171
4			.0191	.0172
5				.0171
6				.0171
7				.0171
8				.0171
9		.0171	.0171	
10		.0171	.0171	
11		.0171	.0171	
12		.0171	.0171	
13		.0171	.0171	
14		.0171		
15		.0171	.0171	
16		.0171		
17		.0171	.0171	
18	.0187			
19			.0171	
20			.0171	
21			.0171	
22			.0171	
23			.0171	
24				.0171
Max	.0187	.0187	.0191	.0172
Min	.0187	.0171	.0171	.0171
Avg	.0187	.0173	.0173	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 401 / 33 KV SMS RBC Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0566		.0537	.0566	.0514	.0537
2	.0537	.0566		.0537	.0566	.0515	.0537
3	.0537	.0566		.0537	.0566	.0514	.0537
4	.0537	.0566		.0537	.0566	.0514	.0537
5	.0537	.0566		.0537	.0566	.0514	.0537
6	.0537	.0566		.0537	.0566	.0514	.0537
7	.0537	.0566		.0537	.0566	.0514	.0537
8	.0537	.0566		.0537	.0566		.0537
9	.0566	.0514		.0566	.0514	.0537	.056
10	.0566	.0514		.0566	.0514	.0537	.056
11	.0566	.0514	.0537	.0566	.0514	.0537	.056
12	.0566		.0537	.0566	.0514	.0537	.056
13	.0566		.0537	.0566	.0514	.0572	.056
14	.0566		.0537	.0566	.0514	.0537	.056
15	.0566		.0537	.0566	.0514	.0537	.056
16			.0537		.0514	.0537	.056
17	.0566		.0537		.0514	.0537	.056
18	.0566		.0537		.0514	.0537	.056
19	.0566		.0537		.0514	.0572	.0549
20			.0537	.0566	.0514	.0537	.0549
21			.0537	.0566	.0514	.0537	.0549
22	.0566		.0537	.0566	.0514	.0572	.0549
23	.0566		.0537	.0566	.0514	.0572	.0549
24	.0537	.0566		.0537	.0566		.0572
Max	.0566	.0566	.0537	.0566	.0566	.0572	.0572
Min	.0537	.0514	.0537	.0537	.0514	.0514	.0537
Avg	.0554	.0553	.0537	.0553	.0534	.0536	.0551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 402 / 33 KV SMS LBC FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0566		.0549		
2	.0549	.0566		.0549		
3	.0549	.0566		.0549		
4	.0549	.0566		.0549		
5	.0549	.0566		.0549		
6	.0549	.0566		.0549		
7	.0549	.0514		.0549		
8	.0549	.0566		.0549		
9	.0566	.0566	.0549	.0566		
10	.0566		.0549	.0566		
11			.0549	.0566		.056
12			.0549	.0566	.0549	.0572
13	.0566		.0549	.0566	.0572	.0572
14	.0566		.0549	.0566	.0549	.0572
15	.0566		.0549	.0566	.0549	.0572
16			.0549		.0549	.0572
17	.0566		.0549		.0549	
18	.0566		.0549		.0549	
19	.0566		.0549		.0572	
20	.0566		.0549		.0549	
21	.0566		.0549		.0549	
22	.0566		.0549			
23	.0566		.0549			
24	.0549	.0566		.0549		
Max	.0566	.0566	.0549	.0566	.0572	.0572
Min	.0549	.0514	.0549	.0549	.0549	.056
Avg	.0559	.0561	.0549	.0556	.0554	.057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 201 / nanda

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1403	1.1812	.9907	1.5242	.724	.9526	.9526
2	1.1041	1.1431	.9907	1.4098	.724	.9145	.9526
3	1.0679	1.1431	.9526	1.3336	.724	.9145	.9145
4	1.0317	1.1431	.9526	1.2955	.7621	.8764	.7621
5	.9955	.9145	.9145	1.1431	.8002	.8383	.7621
6	.6335	.7621	.8002	.9907	.8002	.8002	.5716
7	1.086	.6859	.8002	.9907	.8002	.7621	.4572
8	.6335	.6097	.9907	.9907	.8383		.4954
9	.6335	.5525	.4191	1.0288	.8764		.5335
10	.7621	.5335	.4191	1.0288	.9526		.5716
11	.8383	.6859	1.1431	.4954	.9145		.9145
12	.3429	1.1812	1.1431	.4954	.9526		.9526
13	1.0288	1.1812	1.1812	.5144	.9526		.9526
14	1.105	1.2193	1.2574	.5335	.9526		.9907
15	1.105	1.2193	1.2955	.5525		.5716	.9526
16	1.105	1.2574	1.2955	.5716	.8764	.6097	.9526
17	1.1431	1.2574	1.2193	.5716	.8764	.6478	.9145
18	1.1431	1.2193	1.1812	.5335	.724	.724	.7621
19	1.2193	1.1812	1.1431	.5716	.6859	.7621	.7621
20	1.2574	.8954	1.2955	.6097	.8764	1.1431	.9145
21	1.2574	1.1622	1.7147	.6478	.9526	1.1812	.9526
22	1.1431	1.2955	1.8099	.6478	.9907	1.1812	.9526
23	1.1812	1.2765	1.8099	.6859	.9907	1.105	.4954
24	1.1765	1.2193	.9526	1.5242	.724	.9526	1.105
Max	1.2574	1.2955	1.8099	1.5242	.9907	1.1812	1.105
Min	.3429	.5335	.4191	.4954	.6859	.5716	.4572
Avg	1.0056	1.0383	1.1114	.8621	.8466	.8786	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 202 / KHAPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7621	.6859	.7621	.3048	.6287	.9145
2	.6878	.7621	.7621	.724	.3048	.6097	.9145
3	.6516	.7621	.7621	.724	.3048	.5335	.9145
4	.6154	.7621	.8764	.6859	.2858	.4954	.8383
5	.5973	.7621	.9145	.6478	.2858		.7621
6	.6154	.7621	.9526	.5716	.2667	.362	.7621
7	.6335	.7621	.9526	.5335	.2667	.3429	.7621
8	.6335	.8002	.8764	.5335	.2667		.724
9	.6697	.7621	.724	.4572	.2667		.6859
10	.5716	.7621	.724	.3239	.2858		.6097
11	.5716	.3048	.381	.5716	.5906	.4572	.5716
12	.5716	.4191	.381	.6478	.6478	.6097	.5335
13	.5716	.5335	.4191	.6097	.6859	.6478	.4954
14	.5335	.6097	.4191	.6097	.6859	.6859	.4954
15	.4191	.6097	.4572			.6478	.4954
16	.3048	.4954	.4572		.5335	.5716	.4191
17	.2667	.3429	.381	.5716	.5335	.5335	.381
18	.2667	.3048	.3429	.5716	.4954	.4954	.2286
19	.381	.3048	.3429	.2858	.4572	.4763	.5335
20	.4191	.5906	.6859	.3048	.6478	.6859	.6097
21	.4954	.724	.7621	.3048	.6859	.724	.6097
22	.5335	.7811	.8002	.3239	.7621	.724	.6097
23	.5716	.7811	.8002	.3429	.7621	.724	
24	.724	.7621	.7621	.7621	.3429	.6478	.7621
Max	.724	.8002	.9526	.7621	.7621	.724	.9145
Min	.2667	.3048	.3429	.2858	.2667	.3429	.2286
Avg	.5429	.6343	.6509	.5395	.4639	.5802	.6362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 203 / 11 kV Budhala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1905	.1905	.1524	.1524	.1524	.1524
2	.181	.1905	.1905	.1524	.1524	.1524	.1524
3	.181	.1905	.1905	.1524	.1524	.1524	.1524
4	.181	.1905	.1905	.1143	.1524	.1334	.1524
5	.1629	.1905	.2096	.1143	.1143	.1143	.1524
6	.1629	.2286	.2096	.1143	.1143	.1143	.1524
7	.1629	.2286	.2286	.1143	.1143	.1143	.1524
8	.1629	.2477	.2286	.1143	.1143		.1715
9	.1629	.2286	.2286	.1143	.1143		.1715
10	.1334	.2286	.2096	.1143	.1524		.1715
11	.1143	.1715	.1905	.1905	.1715	.1143	.0762
12	.1143	.1143	.1905	.2286	.1905	.1334	.0762
13	.0953	.1143	.1524	.2286	.1905	.1524	
14	.0762	.1143	.1524	.2286	.1905	.1524	.0762
15	.1143	.1143	.1524	.1905	.1905	.1524	.0762
16	.1143	.1143	.1524	.1905	.1905	.1524	.0762
17	.1143	.1143	.1143	.1905	.1905	.1524	.0762
18	.1143	.1334	.1143	.1524	.1715	.1143	.0762
19	.1524	.1334	.1143	.1524	.1524	.0762	.0762
20	.1524	.1715	.1524	.1524	.1524	.0762	.1143
21	.1905	.1715	.1524	.1905	.1524	.0762	.1143
22	.1905	.1905	.1905	.1905	.1524	.0762	.1143
23	.1905	.1905	.1905	.1905	.1524	.0762	
24	.181	.1905	.1905	.1905	.1905	.1524	.0762
Max	.1905	.2477	.2286	.2286	.1905	.1524	.1715
Min	.0762	.1143	.1143	.1143	.1143	.0762	.0762
Avg	.1494	.1731	.1786	.1635	.1572	.1234	.1186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 204 / 11 kV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	.8764	1.0098	.8764	.9526	1.0288	1.1431
2	1.1584	.8383	1.0479	.8764	.9526	1.0288	1.1431
3	1.1222	.8002	.9907	.8383	.9526	.9717	1.1431
4	1.086	.7621	.9907	.8383	.9145	.9907	1.1431
5	1.0136		.8002	.8002	.9145	.7621	1.1431
6	.9955	.6478	.6859	.8002	.8954	.7811	1.1431
7	.9774	.5716	.724	.9526	.8764	.8192	.9526
8	.9593	.5335	.743	1.0288	.9526		1.2384
9	.9412	1.1431	1.3146	1.1431	1.1431		1.3336
10	.8764	1.3717	1.5051	1.1812	1.4861		1.4289
11	.8383	1.4098	1.4861	1.5242	1.3908	1.1431	1.5242
12	.8002	1.4098	1.4861	2.1338	1.3527	1.2574	1.7147
13	.7621	1.4098	1.5242	2.0195	1.2003	1.2955	1.7147
14	.724	1.5242	1.5623	2.0576	1.2193	1.3717	1.829
15	.7621	1.5242	1.5623			1.3336	1.7147
16	.9526	1.5813	1.5242		1.105	1.3336	1.7147
17	.9907	1.5623	1.3336	1.1431	1.0669	1.3336	1.7909
18	.9907	1.3717	1.1431	1.1431	1.0288	1.2955	1.829
19	1.0288	1.1622	1.1431	1.0479	1.0479	1.2955	1.7147
20	1.0288	1.1431	1.0288	1.0669	1.0098	1.2955	.9907
21	.9526	1.1431	1.0288	1.0669	1.0098	1.2574	.9907
22	.9526	1.086	.8002	1.105	.9526	1.1431	.9907
23	.9526	1.0669	.9145	1.1431	.9335	1.1431	
24	1.2489	.9145	1.0669	.9145	1.1431	1.0098	1.1431
Max	1.2489	1.5813	1.5623	2.1338	1.4861	1.3717	1.829
Min	.724	.5335	.6859	.8002	.8764	.7621	.9526
Avg	.9712	1.1241	1.1423	1.1682	1.0653	1.1377	1.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 401 / 33 KV Incomer Umari SStn

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0633	2.2862	3.0293	3.5437	3.2007	2.6863	2.5149
2	2.0633	2.2862	2.915	3.5437	3.2007		2.5149
3	2.1176	2.2862	2.8578	3.4294	3.315		2.5149
4	2.1719	2.4006	3.0864	3.4294	3.315		2.4006
5	2.1719	2.4006	3.7151	3.4294	3.315		2.2862
6	1.2489	2.6292	3.7723	3.4865	3.4294		2.2862
7	1.6832	2.6292	3.8866	3.4294	3.2007		2.1719
8	1.6289	2.8578	3.8866	3.4294	3.4865		2.2862
9	1.5746	3.1436	2.6292	3.315	3.4294		2.4006
10	2.2862	3.5437	2.6292	3.2579	3.315		2.7435
11	2.8578	3.8866	2.8578	4.9154	3.6008	2.4006	2.7435
12	3.315	4.401	3.1436	2.4006	3.8295	2.4006	2.7435
13	3.4294	4.401	4.0009	2.2862	4.1152	2.4006	2.6863
14	3.7723	4.4582	4.0009	2.3434	4.1152	2.4006	2.6863
15	3.7723	4.5725	3.8866	.9145	.5716	2.4006	2.6292
16	1.8861	4.6296	3.8866	.8573	3.2007	2.4006	2.2862
17	1.8861	4.6296	3.4294	1.9433	3.0864	2.4006	1.829
18	1.8861	3.315	2.2862	1.7147	2.7435	2.2862	1.829
19	1.9433	2.1719	2.2862	1.829	2.1719	2.1719	1.829
20	1.9433	2.3434	2.2862	1.9433	2.2862	2.2862	2.4577
21	1.9433	2.3434	2.4006	1.9433	2.4006	2.2862	2.4577
22	1.9433	2.4577	2.4577	2.0576	2.4577	2.2862	2.2862
23	2.1719	2.4577	2.5149	2.6292	2.4577	2.5149	
24	2.0633	2.1719	2.4577	3.1436	2.7435	2.4577	2.5149
Max	3.7723	4.6296	4.0009	4.9154	4.1152	2.6863	2.7435
Min	1.2489	2.1719	2.2862	.8573	.5716	2.1719	1.829
Avg	2.2426	3.1126	3.0960	2.7173	3.0412	2.3853	2.3956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-STATION

Feeder No / Name : 402 / 63 Mah. Border check post NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572		.0572
2	.0572	.0572	.0572	.0572	.0572		.0572
3	.0572	.0572	.0572	.0572	.0572		.0572
4	.0572	.0572	.0572	.0572	.0572		.0572
5	.0572	.0572	.0572	.0572	.0572		.0572
6	.0572	.0572	.0572	.0572	.0572		.0572
7	.0572	.0572	.0572	.0572	.0572		.0572
8	.0572	.0572	.0572	.0572			.0572
9	.0572	.0572	.0572	.0572			.0572
10	.0572	.0572	.0572	.0572			.0572
11			.0572	.0572			.0572
12			.0572	.0572			.0572
13			.0572	.0572			.0572
14	.0572		.0572	.0572			.0572
15	.0572		.0572	.0572			.0572
16	.0572		.0572	.0572			.0572
17	.0572		.0572	.0572			.0572
18	.0572		.0572	.0572			.0572
19	.0572		.0572	.0572		.4572	.0572
20	.0572		.0572	.0572			.0572
21	.0572		.0572	.0572			.0572
22	.0572		.0572	.0572			.0572
23	.0572		.0572	.0572			
24	.0572	.0572	.0572	.0572	.0572		.0572
Max	.0572	.0572	.0572	.0572	.0572	.4572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.4572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.4572	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164014 / 33 KV UMRI SUB-SATION

Feeder No / Name : 403 / 33 KV Sawargaon out
going(umri Feeder KV- 33 /
INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.9717	1.7147	1.6004	.8573	.8002
2		1.3717	1.2003	1.7147	1.6004	.8573	.9145
3		1.3717	1.2574	1.6004		.743	.9145
4		1.3717	1.7718	1.6004	1.829	.8573	.9145
5		1.3717	2.1719	1.7147	1.829	.9145	.9145
6		1.6004	2.2291	1.7718	1.9433	.8002	.9145
7		1.6004	2.2862	1.7147	1.9433	.743	.6859
8		1.7147	2.2862	1.6004	2.0005		.6859
9		1.4289	.8002	1.6004	1.829		.8002
10		1.1431	.8002	1.5432	1.6575		.4572
11		1.6575	.8002	1.4861	1.5432	.9717	.4572
12	2.0576	2.2862	.9145	1.0288	1.6004	.9717	.4572
13		2.3434	.9145		1.7147	.9717	.4572
14	2.0576	2.2862	1.829		1.7147	.9717	.4572
15	2.0576	2.3434	1.829		.5716	.9717	.4572
16	.3429	2.3434	1.829		.5144	.9717	.4572
17	.3429	2.3434	1.7147		.4572	.9717	.3429
18	.3429	1.3717	.4001		.3429	.743	.3429
19	.4572	.2858	.4001	.4001	.3429	.4572	.5716
20	.4572	.6287	.4572	.4572	.5144	.6859	.6859
21	.4572	.5716	.6287	.4572	.6859	.6859	.6859
22	.4572	.6287	.743	1.0288	.743	.9717	.6859
23	.4572	.6287	.743	1.1431	.6287	.743	
24		.4572	.6287	1.3717	1.1431	.6859	.743
Max	2.0576	2.3434	2.2862	1.7718	2.0005	.9717	.9145
Min	.3429	.2858	.4001	.4001	.3429	.4572	.3429
Avg	.8625	1.4051	1.2336	1.3305	1.2500	.8356	.6436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 200 / 11 KV STATION TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381	.0191	.0381	.0381	.0381
2	.0191	.0381	.0381	.0191	.0381	.0381	.0381
3	.0191	.0381	.0381	.0191	.0381	.0381	.0381
4	.0191	.0191	.0381	.0191	.0381	.0191	.0381
5	.0191	.0191	.0191	.0191	.0381	.0191	.0381
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191		.0191	.0191	.0191
16	.0191	.0191	.0191	.0191	.0191	.0191	.0191
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0381	.0191	.0191	.0191	.0191	.0191
20	.0191	.0381	.0191	.0381	.0381	.0381	.0381
21	.0381	.0381	.0191	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0191	.0381	.0381	.0191	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0215	.0262	.0246	.0224	.0270	.0254	.0265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 201 / Kelod Town

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.462	.5335	.4191	.4572	.4251
2		.4763	.462	.5335	.4191	.4572	.4251
3	.4001	.4382	.4251	.4954	.381	.4382	.3881
4	.381	.381	.3696	.4572	.381	.4001	.3696
5	.3239	.3239	.3326	.381	.381	.4001	.3326
6	.2667	.2858		.3239	.3429	.381	.2957
7	.2477	.2477	.2402	.2096	.1715	.2286	.2402
8	.2286	.2858	.2622	.2286	.1905	.2477	.2926
9	.2286	.2896	.2949	.2286	.2096	.2195	.3239
10	.2477	.3224	.3429	.2667	.2096	.2378	.3429
11	.2858	.3582	.381	.2858	.2477	.2561	.362
12	.3048	.3222	.4001	.3239	.2858	.2743	.4191
13	.3048	.2883	.4001	.3429	.2858	.3109	.4572
14	.3239	.2374	.4001	.3429	.3048	.2926	.4572
15	.3429	.3932	.4954		.3048	.3292	.4191
16	.3239	.2957	.3048	.2286	.2858	.2926	.3048
17	.3048		.3048	.2096	.2286	.2561	.2858
18	.3048	.2353	.2667	.2096	.2096	.2012	.2477
19	.3429	.2534	.2477	.2667	.2667	.2561	.3429
20	.381	.362	.2477	.3239	.3239	.3658	.4001
21	.4191	.4024	.4954	.4191	.381	.4024	.4382
22	.4954	.4572	.5144	.4572	.4191	.439	
23	.4954	.4572	.5335	.4001	.4763	.439	.4382
24	.4572	.4763	.462	.5335	.4572	.4572	.4251
Max	.4954	.4763	.5335	.5335	.4763	.4572	.4572
Min	.2286	.2353	.2402	.2096	.1715	.2012	.2402
Avg	.3369	.3507	.3759	.3479	.3159	.3350	.3667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 202 / Jatamkhora

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1334	.1143	.2286	.2286	.2477	.1334
2	.0572	.1143	.1143	.2477	.2286	.2477	
3	.0572	.1143	.0953	.2477	.1905	.2667	
4	.0572	.0953	.0762	.2667	.1905	.2667	
5	.0381	.0953	.0572	.2667	.2286	.3048	
6	.0381	.0762	.0572	.3048	.2858	.2858	.0381
7	.0381	.0572	.0572	.0572	.0572	.0572	.0381
8	.1905	.2477	.2294	.0572	.0572	.0572	.1448
9	.2096	.2743		.0572	.0572	.0572	.2096
10	.2477	.3391	.381	.0572	.0572	.0572	.2286
11	.2858	.3481	.362	.0572	.0572	.0572	.2667
12	.3048	.3018	.3429	.0762	.0762	.0762	.2667
13	.3239	.2785	.3429	.1143	.0762	.0762	.1334
14	.3239	.2622	.3239	.0953	.0762	.0953	.2286
15	.3429	.2743	.4191	.0953	.0572	.0762	.2286
16	.0762	.0739	.0572	.0572	.0572	.0572	.0381
17	.0572	.0572	.0572	.0572	.0572	.0381	.0381
18	.0762	.0572	.0572	.0572	.0572	.0572	.0191
19	.0953	.0762	.0572	.0762	.0762	.0572	.0381
20	.1143	.1143	.0572	.0953	.0953	.1143	.0572
21	.1143	.1132	.3048	.2667	.2286	.132	.0762
22	.1334	.132	.2858	.2477	.2667	.1334	
23	.1524	.1334	.2667	.2477	.2667	.1334	.0572
24	.0572	.1334	.1143	.2286	.2286	.2477	.1334
Max	.3429	.3481	.4191	.3048	.2858	.3048	.2667
Min	.0381	.0572	.0572	.0572	.0572	.0381	.0191
Avg	.1437	.1626	.1839	.1485	.1358	.1333	.1249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 203 / 11 KV Parsodi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2957	.5335	.4572	.5144	.2957
2	.2667	.2858	.2957	.5144	.4382	.4763	.2957
3	.2667	.2667	.2587	.5144	.4382	.4763	.2587
4	.2667	.2286	.2402	.5144	.4382	.4954	.2402
5	.2286	.1905	.2218	.4954	.4191	.5144	.2218
6	.1524	.1715	.2033	.4954	.4191	.4954	.2033
7	.1334	.1334	.1478	.1334	.1143	.1524	.1294
8	.5335	.4572	.3521	.0953	.1143	.1334	.2294
9	.5716	.463	.3222	.0572	.1143	.1294	.4001
10	.5716	.4917	.4572	.1143	.1143	.1294	.4572
11	.6097	.4409	.4763	.1524	.1143	.1294	.4954
12	.6097		.4954	.1524	.1334	.1478	.4954
13	.6668	.4115	.4763	.1334	.1334	.1848	.4572
14	.7621	.4917	.4763	.1143	.1524	.2033	.4954
15	.7621	.5792	.5335		.1715	.2033	.4954
16		.181	.1715	.0762	.1524	.1109	.2096
17		.1663	.1715	.0953	.1524	.0924	.1905
18		.1294	.1524	.1334	.1334	.1294	.0953
19	.1905	.1294	.1334	.1524	.1715	.1463	.1905
20	.2286	.1663	.1334	.2096	.2096	.2378	.2286
21	.2858	.2033	.4191	.3429	.3239	.2378	.2858
22	.3239	.2772	.4763	.5716	.4382	.2926	
23	.3239	.2957	.5335	.5716	.4763	.2926	.2858
24	.2858	.3048	.2957	.5335	.4572	.5144	.2957
Max	.7621	.5792	.5335	.5716	.4763	.5144	.4954
Min	.1334	.1294	.1334	.0572	.1143	.0924	.0953
Avg	.3965	.2935	.3225	.2916	.2620	.2683	.3023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164039 / 33 KV KELOD

Feeder No / Name : 401 / 33 KV Incomer Kelwad SStn

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.9145	.8779	1.3146	1.086	1.2003	.823
2	.743	.8573	.8779	1.3146	1.086	1.2003	.7133
3	.743	.8002	.7682	1.2574	1.0288	1.2003	.6584
4	.6859	.6859	.6584	1.2574	1.0288	1.1431	.6036
5	.5716	.6287	.6036	1.1431	1.0288	1.2003	.5487
6	.4572	.5144	.5487	1.1431	1.0288	1.1431	.5487
7	.4001	.4572	.439	.4001	.3429	.4572	.3841
8	.9717	.9717	.8745	.4001	.3429	.4572	.639
9	1.0288	1.0174	1.1523	.3429	.4001	.3841	.9145
10	1.086	1.1191	1.2003	.4572	.4001	.439	1.0288
11	1.2003	1.1065	1.2003	.5144	.4001	.439	1.1431
12	1.2003	1.0974	1.2574	.5716	.5144	.4938	1.2003
13	1.3146	1.0425	1.2003	.5716	.5144	.5487	1.0288
14	1.4289	1.0974	1.2003	.5716	.5144	.6036	1.2003
15	1.4289	1.1797	1.4289		.5144	.6036	1.1431
16	.4001	.5487	.5144	.3429	.5144	.439	.5716
17	.3429	.4938	.5144	.3429	.4572	.3841	.5144
18	.4001	.439	.4572	.4001	.4001	.3841	.3429
19	.6287	.439	.4572	.5144	.5144	.439	.5716
20	.743	.6584	.4572	.6287	.6287	.7133	.6859
21	.8002	.7133	1.2003	1.0288	.9145	.7682	.8002
22	.9717	.8779	1.2574	1.2574	1.1431	.8779	
23	.9717	.8779	1.3146	1.2574	1.2003	.8779	.8002
24	.8002	.9145	.8779	1.3146	1.1431	1.2003	.8316
Max	1.4289	1.1797	1.4289	1.3146	1.2003	1.2003	1.2003
Min	.3429	.439	.439	.3429	.3429	.3841	.3429
Avg	.8359	.8105	.8891	.7977	.7144	.7332	.7694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 201 / SAONER URBAN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.2955		
9	1.1812	1.3336	1.2193	1.3336
10	1.2003	1.3717	1.2765	1.3717
11	1.2955	1.4289	1.2955	1.4861
12	1.3336	1.4289	1.3336	1.5242
13	1.4289	1.5242	1.4861	1.5623
14	1.5242	1.5813		
15	1.5813	1.6194		
16	1.6194	1.5623		
24			1.8671	
Max	1.6194	1.6194	1.8671	1.5623
Min	1.1812	1.2955	1.2193	1.3336
Avg	1.3956	1.4606	1.4130	1.4556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 202 / SAONER URBAN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671			1.848	
2	1.7528			1.7909	
3	1.6194			1.6004	
4	1.448			1.448	
5	1.3717			1.3717	
6	1.2765			1.2574	
7	1.2384			1.2574	
8	1.1812	1.2003		1.2193	
9	1.2574	1.2384	1.2955		.5716
10	1.3336	1.2955	1.3336		1.448
11	1.4289	1.3336	1.3717		1.5432
12	1.5242	1.4289	1.3908		
13	1.5623	1.5623	1.4289		
14	1.6194	1.6575			1.6385
15	1.6194	1.6194			1.7147
16	1.5242				1.7528
17		1.5432			1.5623
18		1.5623			1.1431
19		1.4861			
20		1.6385			
21		1.7147			
22					1.6194
23					1.6766
24	1.9052				
Max	1.9052	1.7147	1.4289	1.848	1.7528
Min	1.1812	1.2003	1.2955	1.2193	.5716
Avg	1.5017	1.4831	1.3641	1.4741	1.4670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 203 / patsaongi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			.4954	
2	.6478			.4763	
3	.5906			.4191	
4	.5335			.381	
5	.4954			.3429	
6	.5335			.362	
7	.5716			.362	
8	.5335	.5716		.3239	
9	.6668	.6287	.6097		.6668
10	.724	.6097	.6097		.6097
11	.724	.6287	.6287		.5716
12	.724	.6287	.6668		.6097
13	.7049	.6668	.6859		.6287
14	.7049	.7049			.6668
15	.7049	.724			.6478
16	.6668	.6478			.6668
17		.6859			.6097
18		.6668			.5335
19		.6478			
20		.7621			
21		.7811			
22					.6859
23					.6668
24	.7621				
Max	.7621	.7811	.6859	.4954	.6859
Min	.4954	.5716	.6097	.3239	.5335
Avg	.6455	.6682	.6402	.3953	.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 204 / telkamthi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145			.5716	
2	.8002			.5335	
3	.6859			.4572	
4	.6097			.4191	
5	.4763			.4572	
6	.4001			.5335	
7	.362			.5335	
8	.6097	.5716		.4191	
9	.6478	.6287	.5144		.6668
10	.6859	.6668	.5716		.724
11	.724	.724	.5906		.6859
12	.7621	.7621	.6287		
13	.8002		.6478		.7621
14	.8192	.8764			.8573
15	.8192	.9145			.8764
16	.5906	.4001			.3429
17		1.2764			.362
18		.5335			.381
19		.5716			
20		.743			
21		.8954			
22					.8002
23					.724
24	.9717				
Max	.9717	1.2764	.6478	.5716	.8764
Min	.362	.4001	.5144	.4191	.3429
Avg	.6870	.7357	.5906	.4906	.6530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 205 / nanda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239			.2477	
2	.2858			.2286	
3	.2477			.2286	
4	.2286			.1905	
5	.1905			.1524	
6	.1524			.1715	
7	.1905			.2096	
8	.0762	.2286		.1524	
9		.2667	.2286		.2667
10		.2858	.2286		.2477
11		.3048	.2286		.2286
12		.3048	.2286		
13			.2286		.2667
14		.3239			.2286
15		.3429			.2477
16		.2477			.1524
17		.1905			.1715
18		.2286			.1905
19		.2286			
20		.3048			
21		.3429			
24	.381				
Max	.381	.3429	.2286	.2477	.2667
Min	.0762	.1905	.2286	.1524	.1524
Avg	.2307	.2770	.2286	.1977	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 206 / kelod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764			.724	
2	.8002			.6668	
3	.7621			.6097	
4	.6097			.5716	
5	.4763			.4954	
6	.381			.5144	
7	.3429			.4191	
8	.6859	.6668		.4191	
9	.7049	.724	.4572		.6478
10	.724	.7811	.4572		.6668
11	.7621	.9145	.5335		.724
12	.8573	.9717	.5716		.6668
13	.9145	1.0288	.6287		.6478
14	.9335	1.0669			.6668
15	.9526	1.086			.6859
16	.4001	.5716			.7621
17		.6097			.6097
18		.5906			.4382
19		.4954			
20		.6478			
21		.8954			
24	.9335				
Max	.9526	1.086	.6287	.724	.7621
Min	.3429	.4954	.4572	.4191	.4382
Avg	.7128	.7893	.5296	.5525	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 401 / 33 KV Khapa outgoing

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1152				3.7723	
2	3.8866				3.5437	
3	3.7151				3.2007	
4	3.4294				3.0864	
5	3.2007				2.7435	
6	3.0864				2.4006	
7	2.915				1.8861	
8	4.0009	4.0009			2.4006	
9		4.4582		4.1152		3.4294
10		4.4582		4.8583		3.658
11		4.5725		***		
12		4.5725		4.9154		
13		4.5725		4.9726		
14		4.2867				
15		4.0009				
16		2.8578				4.1724
17		3.2007				3.7151
18		3.7723				3.1436
19		4.2295				3.4865
20		4.2867				4.2295
21		4.1724				4.6296
23						2.8006
24	4.2867		4.8583			
Max	4.2867	4.5725	4.8583	48.7541	3.7723	4.6296
Min	2.915	2.8578	4.8583	4.1152	1.8861	2.8006
Avg	3.6262	4.1030	4.8583	13.5231	2.8792	3.6961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365] BU 0365

Substation No/ Name :- 167024 / 132 K. V. BHAGEMAHARI.

Feeder No / Name : 401 / 33 kv Umri

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	20-JUN-18
HR	Load (MW)	Load (MW)
24	3.4294	3.1436
Max	3.4294	3.1436
Min	3.4294	3.1436
Avg	3.4294	3.1436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 201 / 11 KV APEX

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3292	.3109	.2926	.439		.3109
2	.3734	.3292		.3292	.439		.3475
3	.3734	.2926		.3292	.4024		.3841
4	.3921	.2926	.3109	.3658	.4024		.4207
5	.3658	.2926		.4024	.3658		.3292
6	.2987	.3292	.3841	.3841	.3658		.2926
7	.2926	.2926	.3841	.4024	.4024		.2926
8	.439	.2561	.3841	.3841	.439		.3109
9	.4481	.2926		.439	.4755	.2401	.3658
10	.4481	.439	.4572	.439			.4572
11	1.0242	.439	.4207	.439	.5121	.2926	.4024
12	.5487	.439	.4207	.439	.5121	.1646	.2561
13	.5121	.4481	.4572	.4755	.5121	.2195	.2926
14	.5487	.2561	.4572	.4755	.5041	.2743	.4755
15	.5853	.2561	.5121	.439	.4207	.2743	.4755
16	.6219	.2561	.3658	.3658	.4207	.3292	.4755
17	.5487	.439	.3658	.4024	.4207	.2743	.4755
18	.5121	.439	.4024	.439		.2378	.5121
19	.4755	.3109	.4024	.439		.2743	.439
20	.439	.3109	.4024	.4024	.3658	.3292	.3658
21	.4024	.3174	.3658	.3658		.3292	.3658
22	.3658	.3174	.3292	.3658	.4024	.3109	
23	.3292		.3292	.4024	.4108	.3109	
24	.3921	.3292	.3109	.2926	.439	.4481	.3109
Max	1.0242	.4481	.5121	.4755	.5121	.4481	.5121
Min	.2926	.2561	.3109	.2926	.3658	.1646	.2561
Avg	.4629	.3350	.3887	.3963	.4326	.2873	.3799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 202 / 11 KV BAZARGAON PAPER MILL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.0608	.9877	1.134	1.2803	.9511	1.2803
2	.9877	1.134	.9877	1.134	1.2437	.9511	1.2071
3	1.0059	1.0974	.9511	1.1706	1.2437	.9391	1.1706
4	1.0059	1.0791	.9511	1.1706	1.2071	.9896	1.134
5	1.0059	1.0974	1.0608	1.2071	1.2071	.9694	.8779
6	1.2986	1.1706	1.2254	1.1706	1.2071	.9694	.7865
7	1.0456	1.0974	1.2254	1.1706	1.0974	.9694	.9694
8	1.0456	.9145	1.2254	1.2071	.9877		1.1523
9	1.0608	1.1706	.2801	1.0974	1.2437	.2743	.8779
10	1.0608	.9877	.2987	.9877	1.2803	.7095	.2743
11	1.2437	1.1393	.2926	.9511	1.2803	.7682	.2926
12	1.3169	1.262	.2926	.9877	1.3169	.9877	.3292
13	1.3535	1.2254	.2926	1.0242	1.2437	1.0059	.3292
14	.2926	1.2254	.2926	.9877	1.1919	1.0059	.3292
15	.2926	1.2254	.2926	.9877	.2454	1.1706	.3292
16	.2926	1.2986	1.3169	1.0242	.2743	1.262	.3292
17	.2926	1.2696	1.3352	1.0974	1.0608	1.0791	.2926
18	.3292	1.0082	1.3352	1.2437	1.1523	.8962	.2926
19	.2926	1.0082	1.2437		1.0974	.9511	.2926
20	.2926	1.0456	1.134	1.2803	.9328	.9694	.2926
21	.2926	1.0456	1.134	1.2803	1.0867	1.0974	.3292
22	1.2803	1.0456	1.1523	1.2437	1.1043	1.1706	
23	1.2437		1.134	1.1706	1.134	1.2437	
24	1.0059	.9511	.9877	1.0974	1.0974	1.2696	1.2803
Max	1.3535	1.2986	1.3352	1.2803	1.3169	1.2696	1.2803
Min	.2926	.9145	.2801	.9511	.2454	.2743	.2743
Avg	.8477	1.1113	.8929	1.1229	1.0923	.9826	.6568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 203 / 11 KV UMBARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5144	.5144	.439	.4115	.3944	.4755
2	.4191	.5144	.5087	.439	.4115	.3944	.439
3	.4191	.4801	.5087	.4024	.3772	.3944	.4024
4	.4287	.4801	.4748	.4024	.3772	.3944	.3658
5	.3601	.4801	.4801	.439	.3772	.3429	.3292
6				.4572			.3292
7				.4755			.2195
14		.4458		.3772			
15		.5959	.2561	.5487		.3292	
16	.5487	.583	.7316	.583		.6036	.5144
17	.5487	.5144	.6584	.5487	.3772	.5487	.4115
18	.5144	.4973	.2378	.3429	.3944	.5304	.4115
19	.5144	.5144	.4024	.3772	.3944	.4938	.4115
20	.5487	.5144	.5304	.4115	.4287	.4572	.4115
21	.5144	.5144	.5304	.4115	.4287	.4572	.3772
22	.4801	.5144	.5121	.4115	.4287	.4938	
23	.4801		.4755	.4115	.4287	.4938	
24	.4191	.4458	.5087	.4755	.4115	.4031	.4755
Max	.5487	.5959	.7316	.583	.4287	.6036	.5144
Min	.3601	.4458	.2378	.3429	.3772	.3292	.2195
Avg	.4732	.5073	.4887	.4419	.4036	.4488	.3981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 204 / 11KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609	.5487	.5258	.5853	.4458	.4458	.4024
2	.5609	.5487	.5258	.5487	.4458	.4458	.4024
3	.5609	.5144	.4908	.5121	.4115	.4458	.3658
4	.5258	.5144	.4908	.5121	.4115	.4458	.3658
5	.5258	.4801	.4908	.4755	.3772	.4115	.4024
6				.4755			.4024
7				.5121			.2561
13		.2804					
14				.3429			
15		.631	.2561	.5144		.4024	
16	.6859	.6661	.3658	.4801	.2454	.6584	.6173
17	.6516	.6661	.3292	.5144	.5487	.5487	.583
18	.6173	.6173	.2926	.5487	.5609	.439	.583
19	.5487	.583	.6219	.5144	.5487	.4755	.5487
20	.5144	.5144	.695	.4458	.4908	.5121	.5144
21	.4801	.5258	.695	.4801	.4801	.4755	.4458
22	.4458	.5258	.6219	.4801	.4458	.439	
23	.4458		.6219	.4801	.4458	.439	
24	.5487	.4115	.4908	.5853	.4458	.4207	.4024
Max	.6859	.6661	.695	.5853	.5609	.6584	.6173
Min	.4458	.2804	.2561	.3429	.2454	.4024	.2561
Avg	.5480	.5352	.5009	.5004	.4503	.467	.4494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 205 / 11KV KONDALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3429	.3856	.3658	.3772	.3506	.3658
2	.3506	.3086	.3856	.3658	.3772	.3506	.3658
3	.3506	.3086	.3856	.4024	.3772	.3681	.3292
4	.3681	.2743	.3856	.4024	.3429	.3506	.3292
5	.3681	.2743	.3856	.3658	.3429	.3506	.2926
6	.4908	.4557	.5258	.3292	.4908	.3155	.2926
7	.4908	.4207	.3658	.3292	.4207	.3155	.5121
8	.3506	.3856	.3258	.3292	.3506		.4024
9	.3506	.3856	.3506	.3658	.4207	.2804	.3658
10	.3506	.3506	.3506	.3658	.4115	.3155	.3292
11	.3856	.4557	.3841	.3506	.6661	.3658	.3506
12	.4207	.4908	.3841	.3506	.7011	.439	.4207
13	.4908	.4557	.3841	.3506	.6661	.4755	.4557
14	.5014	.333	.3658	.3429	.5121	.5121	.4908
15	.5959	.3856	.3658	.3429	.4908	.3658	.4207
16	.4115	.3856	.4755	.3086	.3155	.3292	.4115
17	.3772	.3658	.4755	.3086	.3155	.3292	.3772
18	.3429	.3292	.4755	.3086	.3155	.2926	.3772
19	.3429	.3658	.439	.3086	.3506	.3658	.3772
20	.3772	.4207	.4024	.3429	.3429	.4024	.3772
21	.3429	.3856	.4024	.3429	.3506	.4024	.3429
22	.3429	.3856	.4024	.3429	.3506	.4024	
23	.3429		.3658	.3429	.3506	.3658	
24	.3506	.3429	.3856	.3658	.3429	.3506	.3658
Max	.5959	.4908	.5258	.4024	.7011	.5121	.5121
Min	.3429	.2743	.3258	.3086	.3155	.2804	.2926
Avg	.3936	.3743	.3981	.3471	.4159	.3650	.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 206 / 11KV POLO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0716	.0732	.0914	.1075	.0914	.0914
2	.0732	.0716	.0732	.0914	.1097	.0914	.0914
3	.0732	.0716	.0876	.0914	.1075	.0914	.0914
4	.0732	.0716	.0732	.0732	.1075	.0732	.0732
5	.0732	.0716	.0914	.0732	.1075	.0732	.0732
6	.0914	.0716	.0876	.0914	.1075	.0732	.0549
7	.0914	.0716	.0701	.0732	.1075	.0732	.0549
8	.0914	.0716	.0876	.0914	.1075		.0732
9	.0876	.0716	.0914	.0732	.0716	.0732	.0549
10	.0876	.1075	.0914	.0914	.0732	.0549	.0914
11	.1075	.2195	.2195	.1075	.1829	.1097	.1075
12	.2686	.2012	.2195	.2149	.1753	.2012	.1791
13	.2507	.2103	.2195	.2507	.1829	.2012	.1791
14	.2507	.2103	.2378	.2149	.1753	.2012	.2507
15	.2865	.4024	.2378	.1791	.1753	.1463	.2149
16	.2507	.4755	.2743	.1791	.0701	.1097	.1433
17	.1791	.1097	.2743	.1433	.1829	.1097	.1075
18	.1433	.1097	.2195	.1791	.1829	.1097	.1075
19	.1433	.0914	.1829	.1075	.0732	.1097	.1075
20	.1433	.0914	.1097	.1075	.0366	.0914	.1097
21	.1075	.0914	.1097	.1075	.0732	.0914	.1075
22	.0716	.0914	.1097	.1075	.0732	.0914	
23	.1075		.0914	.1075	.0732	.0914	
24	.0732	.1075	.0914	.0914	.1075	.0732	.0914
Max	.2865	.4755	.2743	.2507	.1829	.2012	.2507
Min	.0716	.0716	.0701	.0732	.0366	.0549	.0549
Avg	.1333	.1375	.1427	.1224	.1155	.1058	.1116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 208 / Adegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.6173	.5487	.6516	.6516	.7316
2	.5487	.583	.6173	.5121	.6516	.6516	.695
3	.5487	.5487	.6173	.4755	.6173	.6516	.6584
4	.5487	.5487	.6173	.439	.6173	.6173	.6219
5	.5487	.5487	.2401	.2926	.6173	.3772	.5121
6	.2743	.2374	.4801	.1646	.2374	.3772	.2012
7	.2374	.3052	.2743	.2561	.2374	.2401	.2195
8	.2378	.3391	.2572	.3475	.2543		.2561
9	.2572	.3391	.3086	.3475	.3052	.2374	.2561
10	.2572	.3391	.3086	.3475	.3086	.2279	.2561
11	.3052	.3429	.3292	.3052	.3086	.2378	.2713
12	.3391	.3258	.3109	.2713	.3086	.2378	.2713
13	.3391	.3258	.2926	.2374	.2915	.2195	.3052
14	.3391	.2629	.2561	.3052	.2915	.2195	.3052
15	.3391	.2572	.4572	.3086	.2629	.3292	.3391
16	.4458	.1715	.439	.4115	.2572	.3841	.4115
17	.3429	.3086	.3658	.2743	.2915	.3658	.3429
18	.3429	.3258	.3475	.2743	.2915	.3292	.3086
19	.5144	.6173	.5121	.4801	.583	.439	.3772
20	.6516	.695	.6767	.583	.6001	.7133	.6173
21	.6859	.7202	.6584	.6516	.6859	.7316	.6516
22	.4801	.7202	.6219	.6859	.6859	.7865	
23	.6516		.5853	.6516	.6443	.7865	
24	.6516	.6173	.6516	.5487	.6516	.6173	.7682
Max	.6859	.7202	.6767	.6859	.6859	.7865	.7682
Min	.2374	.1715	.2401	.1646	.2374	.2195	.2012
Avg	.4348	.4375	.4518	.4050	.4438	.4534	.4262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 209 / 11 KV ECONOMIC EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.2195	.3395	.1829	.2195	.3584	.1829
2	.3395	.2195	.3018	.1829	.2195	.3584	.1829
3	.3395	.2195	.3018	.1463	.2012	.3772	.1829
4	.3395	.2263	.3018	.1463	.2012	.3584	.1463
5	.3206	.1829	.2829	.1463	.2012	.3734	.1463
6	.3206	.1829	.2829	.1463	.2195	.3547	.1463
7	.4854	.2743	.2641	.1829	.2378	.3584	.1829
8	.5415	.3292	.2641	.2195	.2926		.2195
9	.679	.2926	.2641	.2561	.3109	.4481	.3292
10	.6722	.2561	.3206	.2561	.3475	.679	.3658
11	.8962	.7316	.3475	.439	.7842	.5853	.4755
12	.9145	.7682	.3475	.439	.8048	.5487	.4755
13	.4755	.811	.2926	.3292	.8299	.4755	.4755
14	.4755	.7922	.2926	.3292	.8299	.439	.4755
15	.439	.679	.2926	.439	.8299	.439	.4755
16	.439	.679	.3109	.439	.679	.4024	.439
17	.8779	.679	.2561	.439	.679	.3658	.439
18	.439	.5041	.2561	.439	.5304	.3292	.4024
19	.2743	.547	.2561	.3292	.547	.2926	.2743
20	.2743	.547	.2561	.3292	.547	.2561	.2743
21	.3292	.547	.2195	.2926	.4904	.2561	.2561
22	.3292	.5281	.2195	.2926	.4904	.2195	
23	.2561		.1829	.2926	.3772	.2195	
24	.3961	.2378	.415	.1829	.2195	.2829	.1829
Max	.9145	.811	.415	.439	.8299	.679	.4755
Min	.2561	.1829	.1829	.1463	.2012	.2195	.1463
Avg	.4672	.4545	.2862	.2865	.4621	.3816	.3059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 211 / 11 KV ORIENT EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0716	.0732	.1097		.0747	.1463
2	.0366	.0716	.0732	.1097	.0716	.0747	.1463
3	.0366	.0716	.0732	.1097	.0716	.0732	.1463
4	.0366	.0716	.0732	.0732	.0716	.0732	.1463
5	.0366	.0716	.0732	.0732	.0716	.0732	.1463
6	.0366	.0716	.0732	.0732	.0716	.0732	.1463
7	.0373	.0716	.0747	.1097	.0716	.1097	.1463
8	.0366	.0716	.0732	.1463	.0716		.1829
9	.0366	.0716	.0732	.1463	.0716	.112	.2195
10	.0549	.0716	.0914	.1829	.1075	.1494	.1829
11	.1052	.0747	.0732	.0716	.0732	.1463	.1075
12	.1433	.0732	.0732	.0716	.0732	.1829	.1075
13	.1075	.0747	.0732	.0716	.1463	.2195	.1075
14	.1075	.0747	.0732	.0716	.1463	.2195	.1433
15	.1075	.112	.0732	.0716	.1646	.2561	.0716
16	.1075	.112	.0732	.0716	.1463	.2561	.0716
17	.1075	.1097	.0732	.0716	.1867	.2195	.0716
18	.0716	.1097	.0732	.0716	.1867	.2195	.0716
19	.0716	.0732	.0732	.0716	.112	.2195	.0716
20	.0716	.0549	.0732	.0716	.1052	.1829	.0716
21	.0716	.0732	.1097	.0716	3.4568	.1829	.0716
22	.0716	.0732	.1097	.0716	.0732	.1463	
23	.0716		.1097	.0716	.0732	.1463	
24	.056	.0716	.0732	.1097	.0716	.0732	.1463
Max	.1433	.112	.1097	.1829	3.4568	.2561	.2195
Min	.0366	.0549	.0732	.0716	.0716	.0732	.0716
Avg	.0690	.0784	.0786	.0906	.2476	.1515	.1238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 401 / 33 kv kalmeshwar to baz
income Feeder KV- 33 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3772	5.3109	5.5453	5.2058	5.8894	5.6573	5.8282
2	5.3212	5.3109	5.5453	5.0926	5.7842	5.6573	5.6584
3	5.3212	5.1006	5.3772	4.9794	5.6264	5.7133	5.3755
4	5.3212	4.8903	5.3212	4.9228	5.4161	5.4893	5.036
5	4.9851	4.8377	4.8285	4.7531	5.3109	4.9931	4.4702
6	4.145	3.9638	4.481	4.5268	4.417	4.201	4.0741
7	4.481	4.4696	4.0889	5.036	4.3644	3.9769	4.5833
8	4.7611	4.3118	4.0889	4.5268	4.2067		4.4702
9	4.6799	4.8377	3.1367	4.8663	4.9954	3.5082	4.4136
10	4.9851	5.2058	3.3048	5.036	5.4321	4.0329	3.5082
11	5.679	5.6573	3.3385	5.1532	5.8711	4.1872	4.2067
12	6.0471	5.7133	3.2819	5.2584	6.0905	4.5268	4.1015
13	5.8894	5.7693	3.2819	4.7851	6.0494	4.6965	4.3118
14	4.3118	5.8814	3.2253	5.2058	5.8253	4.6965	4.5748
15	4.8903	6.7215	3.9609	5.8894	4.6491	5.4887	4.5222
16	5.8894	6.8336	5.6584	5.9419	4.201	6.2243	5.6264
17	6.0997	6.6655	5.4321	5.8894	5.8253	5.4887	5.3109
18	5.679	6.1054	4.9794	5.7316	5.8253	4.8663	5.2584
19	5.6264	5.8368	5.4887	5.7842	6.1054	5.4321	5.1006
20	5.679	6.1454	5.715	5.9419	5.8253	5.5967	5.2058
21	5.5213	6.4975	5.715	5.9945	6.1614	5.9414	4.6273
22	6.2049	5.7693	5.6019	5.8894	6.1054	5.9414	
23	5.4687		5.4321	5.7842	5.9374	5.998	
24	5.6013	4.9954	5.7133	5.2058	5.4687	5.8253	5.8282
Max	6.2049	6.8336	5.715	5.9945	6.1614	6.2243	5.8282
Min	4.145	3.9638	3.1367	4.5268	4.201	3.5082	3.5082
Avg	5.3319	5.5144	4.6893	5.3084	5.4743	5.1365	4.8224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 405 / 33 KV PIX

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2195		.6584
2		.2195		.6584
3		.2195		.5487
4		.2195		.439
5		.2195		.439
6		.2195		.5487
7		.439		.6584
8		.6584		.7682
9		.8779		.7682
10		.9877		.8779
11	.1097		.7682	
12	.1097		.8779	
13	.1097		.9877	
14	.1646		.9877	
15	.1646		.7682	
16	.1097		.7682	
17	.1097		.6584	
18	.1097		.6584	
19	.1097		.7682	
20	.2195		.7682	
21	.2195		.7682	
22	.2195		.6584	
23	.2195		.6584	
24		.2195		.6584
Max	.2195	.9877	.9877	.8779
Min	.1097	.2195	.6584	.439
Avg	.1519	.4090	.7766	.6385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 201 / CHIKNA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.3403	.3045	.3041	.2661	.2838	.2678
2	.3045	.3403	.3045	.3041	.2661	.2661	.2678
3	.2865	.3224	.3045	.2862	.2661	.2661	.2499
4	.2865	.3224	.2865	.2862	.2661	.2661	.2321
5	.2865	.2865	.2865	.2683	.2483	.2661	.2321
6	.2328	.2149	.2507	.2505	.2128	.1951	.2142
7	.2149	.2686	.3045	.2683	.2128	.2306	.2499
8	.3045	.2686	.3582	.3578	.2306	.337	.2499
9	.3045	.3403	.394	1.0018	.2128	.337	.3032
10	.3045	.2865	.4477	.4789	.2306	.3725	.482
11	.3761	.394	.5731	.4434	.2838	.3902	.357
12	.5014	.4835	.5367	.3902	.337	.4612	.4102
13	.4656	.394	.5367		.3902	.4115	.3567
14	.3224	.3403	.4115	.3547	.2838	.4472	.3032
15	.5552	.3224	.4472	.3547	.337	.3399	.2853
16	.4119	.4298	.3578	.408	.3725	.2326	.3745
17	.3761	.5373	.483		.1951	.3041	.2618
18	.4119	.4298	.4294		.2838	.1962	.2675
19	.3224	.394	.3041	.1596	.2306	.2147	.2318
20	.3403	.3224	.3578	.2483	.2838	.2497	.2497
21	.3403	.3582	.3399	.2661	.3015	.2675	.214
22	.3582	.3403	.3399	.3015	.3015	.1783	.2853
23	.3582	.3224		.3015	.2838	.2853	.2853
24	.3582	.3582	.3403	.322	.2838	.2838	.321
Max	.5552	.5373	.5731	1.0018	.3902	.4612	.482
Min	.2149	.2149	.2507	.1596	.1951	.1783	.214
Avg	.3477	.3507	.3782	.3503	.2742	.2951	.2897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 202 / Kirnapur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1043	.0869	.1043	.1044	.087	.1044	.087
2	.1043	.0869	.1043	.1044	.087	.087	.0873
3	.0869	.0869	.1043	.087	.087	.087	.0873
4	.0869	.0869	.1043	.087	.087	.087	.0873
5	.0869	.0869	.1043	.087	.0696	.087	.0698
6	.0695	.0869	.1043	.0696	.0522	.087	.0698
7	.0869	.0869	.0895	.0696	.0696	.1044	.0873
8	.0695	.0869	.087	.0696	.0696	.087	.0873
9	.0695	.0869	.1044	.087	.0696	.1044	.0873
10	.1029	.1043	.0869	.087	.0696	.087	.1047
11	.0869	.0869	.0869	.1218	.0857	.087	.0873
12	.1029	.0869	.087	.1044	.0696	.087	.1047
13	.1216	.1043	.087		.1044	.0696	.1047
14	.0521	.087	.087	.1044	.087	.0696	.0873
15	.0857	.087	.087	.1044	.087	.087	.0873
16	.0695	.0696	.087	.1044	.087	.0696	.0873
17	.0686	.0696	.087	.0522	.0522	.0696	.0698
18	.0695	.0696	.087		.0696	.0522	.0873
19	.0857	.0522	.087	.0522	.087	.0696	.0873
20	.0869	.1044	.1044	.0522	.087	.0696	.0873
21	.0869	.087	.1044	.0522	.1044	.087	.0698
22	.1029	.1044	.1218	.1044	.1044	.1044	.0873
23	.1043	.1044		.0696	.1044	.087	.0873
24	.1043	.0869	.1044	.1044	.087	.1044	.087
Max	.1216	.1044	.1218	.1218	.1044	.1044	.1047
Min	.0521	.0522	.0869	.0522	.0522	.0522	.0698
Avg	.0873	.0869	.0962	.0854	.0819	.0848	.0865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 203 / Adyali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4367	.6375	.6375	.6375	.4553	.4185	.5828
2	.4003	.6193	.6375	.6193	.4553	.4189	.5464
3	.4003	.5828	.5828	.6193	.4553	.4189	.51
4	.3821	.5464	.5828	.5828	.4189	.4007	.4736
5	.3821	.5464	.5464	.5464	.3825	.3825	.4736
6	.3275	.51	.5282	.5282	.3096	.3461	.4553
7	.3096	.5095	.51	.51	.3643	.3639	.4736
8	.3278	.4731	.5453	.51	.3278	.3643	.4371
9	.3821	.5458	.5998	.5828	.3825	.4918	.51
10	.4367	.5464	.5458	.6193	.4185	.51	.6011
11	.4549	.6011	.564	.6557	.4553	.6011	.6011
12	.5847	.5464	.5646	.6375	.4185	.6011	.6375
13	.4553	.5464	.5828		.4367	.6011	.6375
14	.4371	.5458	.6739	.6193	.4189	.6193	.6375
15	.6368	.5646	.6739	.6193	.4736	.5828	.6557
16	.6375	.6011	.4371	.6557	.4736	.6011	.6921
17	.5464	.5646	.6193		.3096	.4553	.6375
18	.5095	.51	.5828		.4189	.4189	.5828
19	.5464	.5828	.5828	.4189	.4189	.4371	.6011
20	.6557	.6739	.6921	.4189	.4189	.4736	.5828
21	.6739	.6739	.6557	.4553	.4007	.5464	
22	.6739	.6739	.6739	.4371	.4007	.6011	
23	.6921	.6921		.4553	.4371	.6193	
24	.4736	.6557	.6739	.6739	.4553	.4371	.5828
Max	.6921	.6921	.6921	.6739	.4736	.6193	.6921
Min	.3096	.4731	.4371	.4189	.3096	.3461	.4371
Avg	.4901	.5812	.5953	.5620	.4128	.4880	.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 204 / Pipla

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5449	1.6358	1.6358	1.0189	.9097	1.0189	1.0553
2	1.4904	1.6358	1.6358	.9461	.9097	1.0007	1.0007
3	1.454	1.5449	1.5449	.9097	.8551	1.0007	.9461
4	1.3632	1.454	1.454	.8733	.8188	.9097	.9097
5	1.2905	1.3632	1.3086	.837	.7642	.837	.8733
6	1.1087	1.1669	1.1632	.8188	.7278	.8006	.8188
7	.9997	1.036	.9997	.6732	.564	.746	.655
8	.9633	.9633	.9653	.6186	.6004	.6732	.6186
9	.927	.927	.856	.6186	.5822	.5822	.6186
10	.9097	.9633	.927	.6186	.5822	.655	.6186
11	.9825	1.0542	1.0178	.6732	.6732	.6914	.6914
12	.9451	1.1451	1.0735	.6921	.6732	.746	.7642
13	1.1269	1.3268	.746		.7096	.7278	.7824
14	1.1814	1.3813	.5822	.6732	.7824	.8188	.7824
15	1.2541	1.401	.5822	.7278	.8006	.837	.837
16	1.2528	1.3842	.8915	.8006	.837	.837	.837
17	1.1632	1.2178	.8551	.5276	.6914	.8006	.8188
18	1.0189	1.1451	.7642		.6004	.6914	.7824
19	1.1087	1.0905	.746	.6732	.7642	.3639	.7278
20	1.3086	1.2359	.8551	.7278	.8733	.8006	.8006
21	1.3086	1.3268	.8733	.8188	.8733	.8915	.6914
22	1.4359	1.4904	.9643	.8915	.9825	1.0007	.837
23	1.654	1.6358		.9643	1.0553	1.0917	.9825
24	1.6722	1.654	1.6626	1.0735	.9097	1.0371	1.0735
Max	1.6722	1.654	1.6626	1.0735	1.0553	1.0917	1.0735
Min	.9097	.927	.5822	.5276	.564	.3639	.6186
Avg	1.2277	1.2991	1.0480	.7807	.7725	.8150	.8135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 201 / Saibaba nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5041	.5041	.4854	.4854	.5041	.5041
2	.5041	.5041	.5041	.4481	.4668	.4854	.5041
3	.4668	.4668	.4854	.4294	.4668	.4854	.4854
4	.4294	.4668	.4481	.4108	.4481	.4481	.4854
5	.4108	.4108	.4294	.4481	.4294	.4481	.4481
6	.4108	.4668	.4108	.4108	.3734	.4108	.4108
7	.3734	.3734	.3921	.3921	.3547	.4108	.3921
8	.3547	.3547	.3734	.3547	.3361	.3734	.3361
9	.3361	.3361	.3361	.3174	.3547	.3547	.3174
10	.3361	.3174	.3174	.3174	.3547	.3361	.3547
11	.2987	.3734	.3361	.3734	.3174	.3547	.3547
12	.3361	.4108	.3547	.3921	.3547	.3921	.3921
13	.4108	.4294	.4294	.3921	.3361	.4108	.4294
14	.4294	.4854	.4668	.3921	.3734	.4481	.4481
15	.4481	.4668	.4481	.3734	.4294	.4294	.4668
16	.4294	.4854	.4294	.3921	.4481	.4481	.4481
17	.3921	.4108	.3734	.3174	.3734	.4108	.4108
18	.3734	.3547	.3734	.3174	.3734	.3547	.3921
19	.4108	.4108	.3547	.3921	.3921	.3734	.4294
20	.4481	.4481	.4668	.4108	.4668	.4294	.4668
21	.4481	.4668	.4854	.4294	.4668	.4668	.3921
22	.5041	.5041	.463	.4481	.4854	.5041	.3734
23	.4668	.5415	.5228	.4854	.5041	.5601	.4108
24	.5228	.5041	.5415	.5041	.4854	.5228	.5415
Max	.5228	.5415	.5415	.5041	.5041	.5601	.5415
Min	.2987	.3174	.3174	.3174	.3174	.3361	.3174
Avg	.4193	.4372	.4269	.4014	.4115	.4318	.4248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 202 / NAVNATH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.8775	.8775	.8215	.8029	.8589	.8589
2	.8402	.8775	.8589		.7842	.8589	.8215
3	.7842	.8402	.8215	.7468	.7468	.8215	.8215
4	.7095	.7842	.7842	.7095	.7095	.8215	.7842
5	.6348	.7468	.7468	.6908	.6722	.7842	.7282
6	.5975	.6908	.6908	.6535	.6348	.6722	.6908
7	.5788	.5601	.5788	.5975	.5415	.6161	.5601
8	.5415	.5415	.5228	.5041	.5228	.5788	.5415
9	.5415	.5041	.5228	.4854	.5228	.5415	.5228
10	.5228	.5041	.5228	.5041	.5228	.5601	.5601
11	.5041	.5601	.5601	.5228	.5415	.5415	.5601
12	.5415	.5975	.5788	.5788	.5601	.5788	.5975
13	.6161	.6535	.6348	.6348	.6161	.6348	.6535
14	.6348	.6908	.6908	.6161	.6161	.6908	.6908
15	.6908	.7095	.6722	.6161	.6535	.6908	.6348
16	.6535	.6722	.6535	.6348	.6535	.6722	.6908
17	.5788	.6161	.5788	.4294	.4854	.5975	.6161
18	.4668	.5975	.5601	.4854	.4668	.5041	.5601
19	.5601	.5975	.5601	.5228	.5415	.5041	.5788
20	.7095	.6908	.7468	.6535	.6908	.6161	.7095
21	.7468	.7282	.7842	.6908	.7842	.7282	.5788
22	.7842	.8589	.8215	.7468	.8215	.8775	.7655
23	.8775	.8962	.8962	.8029	.8589	.8962	.8589
24	.8962	.8775	.8962	.8589	.8029	.8775	.8962
Max	.8962	.8962	.8962	.8589	.8589	.8962	.8962
Min	.4668	.5041	.5228	.4294	.4668	.5041	.5228
Avg	.6620	.6947	.6900	.6307	.6480	.6885	.6784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 203 / 11 KV BAHADURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.3361	.3547	.3174	.5041	.5041	.3361
2	.5041	.3361	.3361	.2987	.4854	.4854	.3361
3	.4668	.2987	.3174	.2987	.4854	.5041	.3174
4	.4481	.2987	.3174	.2801	.4668	.4854	.3174
5	.4108	.2801	.3174	.2801	.4481	.4668	.3174
6	.3921	.2801	.2614	.2614	.3921	.4668	.2987
7	.3921	.2614	.2614	.2427	.3547	.4481	.2614
8	.3734	.2427	.2427	.2427	.3361		.2241
9	.3921	.2241	.2241	.2241	.3547	.2614	.2614
10	.3734	.2427	.2241	.2427	.3921	.2427	.2241
11		.2614	.2241	.2614	.3734	.2427	.2054
12	.2614	.2614	.2427	.2427	.4108	.2427	.2054
13	.4108	.2801	.2614	.2614	.4294	.2614	.2427
14	.1494	.2801	.2801	.2427	.4108	.2801	.2801
15	.2054	.2801	.2801	.2241	.4481	.2614	.2801
16	.2054	.2801	.2614	.2427	.4668	.2614	.2614
17	.1867	.2427	.2427	.1867	.3734	.2241	.2427
18	.1663	.2427	.2241	.2033	.3174	.2054	.2614
19	.1867	.2801	.2241	.3734	.3921	.2054	.2614
20	.3174	.3361	.2987	.4481	.4668	.2614	.3174
21	.3361	.3174	.3174	.4668	.5228	.3174	.2427
22	.3547	.3547	.3361	.5041	.5415	.3547	.2801
23	.3361	.3547	.3547	.5041	.5601	.3734	.3361
24	.5415	.3547	.3547	.3361	.5041	.5788	.3734
Max	.5415	.3547	.3547	.5041	.5601	.5788	.3734
Min	.1494	.2241	.2241	.1867	.3174	.2054	.2054
Avg	.3449	.2886	.2816	.2994	.4349	.3450	.2785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 204 / Dhangawali SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3174	.3174	.2987	.2987	.2987	.2987
2	.2987	.3174	.2987	.2987	.2801	.2987	.2987
3	.2614	.2987	.2614	.2801	.2801	.2987	.2987
4	.2427	.2801	.2427	.2614	.2614	.2801	.2801
5	.2241	.2801	.2427	.2614	.2427	.2614	.2801
6	.2054	.2427	.2241	.2241	.1867	.2241	.2427
7	.1867	.1848	.2054	.2054	.1867	.1867	.2054
8	.1867	.1848	.1867	.168	.1867	.1867	.2241
9	.1867	.1848	.1494	.168	.1663	.1867	.2054
10	.1663	.1663	.1867	.1867	.2054	.1867	.2427
11	.1848	.1867	.2054	.2033	.2054	.2241	.2427
12	.1867	.2054	.2241	.2241	.1867	.2241	.2427
13	.2241	.2054	.2241	.2241	.2614	.2427	.2801
14	.2241	.2614	.2427	.2427	.2614	.2241	.2801
15	.2427	.2614	.2427	.2218	.2614	.2241	.2614
16	.2614	.2241	.2241	.2427	.2427	.2241	.2427
17	.1867	.2427	.2241	.1294	.2241	.2241	.2241
18	.1867	.2054	.2054	.1494	.1867	.1867	.2054
19	.2241	.1867	.168	.1494	.2054	.1867	.1867
20	.2614	.2427	.2614	.2033	.2614	.2241	.2427
21	.2614	.2614	.2801	.2241	.2801	.2614	.1867
22	.2801	.2801	.2987	.2801	.2801	.2987	.2801
23	.2987	.2987	.3174	.2987	.3174	.3174	.2987
24	.3174	.2987	.2987	.2987	.2987	.3174	.3174
Max	.3174	.3174	.3174	.2987	.3174	.3174	.3174
Min	.1663	.1663	.1494	.1294	.1663	.1867	.1867
Avg	.2340	.2424	.2388	.2268	.2403	.2412	.2528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 201 / 11 kv NIT industrial 1

Feeder KV- 11 / OUTGOING

DATE	16-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0019	.0019	.0019	.0019	.0019
11		.0019	.0019	.0019	.0019
12	.0019	.0019	.0019	.0019	.0019
13	.0019	.0019	.0019	.0019	.0019
14	.0019	.0019	.0019	.0019	.0019
15	.0019	.0019	.0019	.0019	.0019
16	.0019		.0019	.0019	.0019
17	.0019	.0019	.0019	.0019	.0019
18					.0019
19					.0019
20					.0019
Max	.0019	.0019	.0019	.0019	.0019
Min	.0019	.0019	.0019	.0019	.0019
Avg	.0019	.0019	.0019	.0019	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 202 / 11 KV MAHURZARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2641	.3429	.2641	.2096	.2641	.2477
2	.3048	.2641	.3048	.2641	.2096	.2641	.2286
3	.3048	.2641	.3048	.2641	.2096	.2263	.2286
4	.2667	.2641	.3048	.2452	.2096	.2263	.2286
5	.2667	.2641	.2667	.2263	.1905	.2263	.2477
6	.2286	.2641	.2477	.2263	.1905	.1886	.2667
7	.2286	.2263	.2286	.2263	.1905	.2477	.2477
8	.2858	.2263	.2477	.3018	.2477	.2641	.2667
9	.4763	.4904	.3239	.3772	.3048	.3395	.5144
10	.4763	.3429	.1509	.4973	.3772	.3429	.3429
11	.4572	.3429	.2829	.4115	.3601	.3258	.3429
12	.381	.4458	.415	.3772	.2915	1.4232	.4973
13	.1143	.3772		.3429	.2915	1.7147	.3601
14	.1143	.3772	.3395	.3258	.2915	1.7661	.2743
15	.381	.3086	.3206	.3601	.3258	1.8519	.2915
16	.4001	.4115	.2641		.2058	.2572	.2572
17	.4001	.4287	.2263	.1372	.2572	.3086	.2572
18	.415	.4191	.2641	.2667	.2454	.1143	.2401
19	.2263	.2667	.2452	.2096	.2263	.2286	.2743
20	.2641	.3239	.2641	.2096	.2452	.2286	.2401
21	.2641	.2477	.2452	.2096	.2829	.2477	.2641
22	.3395	.362	.3395	.2286	.2263	.2286	
23	.2641	.362	.2641	.2286	.2641	.2286	
24	.3239	.2641	.3429	.2641	.2096	.2641	.2477
Max	.4763	.4904	.415	.4973	.3772	1.8519	.5144
Min	.1143	.2263	.1509	.1372	.1905	.1143	.2286
Avg	.3128	.3253	.2842	.2811	.2526	.4907	.2894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 203 / 11 kv Bodhala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7712	.6859	.7186	.6097	.6661	.6097
2	.5906	.7712	.6859	.7186	.6097	.6135	.6097
3	.5716	.7712	.6478	.7186	.5716	.5959	.5716
4	.5716	.7011	.6478	.7011	.5716	.5959	.5335
5	.6097	.7011	.6478	.7011	.5335	.5959	.5335
6		.7362	.6478	.7011	.5144	.5959	.5144
7	.7049		.7811	.7362	.4954	.5784	.4763
8	.7049	.8764	.8383	.8413	.5144	.2454	.4572
9	.8192	.9114	.8573	.9114	.5716	.7186	.4191
10	.8383	.7545	.8589	.7888	.5487	.7202	.4115
11	.8192	.8059	.8764	.7545	.5658	.7202	.463
12	.8002	.7545	.8063	.7545	.6173	.6516	.4801
13	.8383	.6859		.7716	.6001	.463	.5144
14	.9145	.7202	.1753	.5316	.6001	.5487	.5144
15	.8764	.8059	.5784	.583	.6173	.7716	.1715
16	.8954	.7716	.7712		.1029	.7716	.1543
17	.8383	.8059	.7888	.3772	.463	.7545	.4458
18	.7712	.5525	.7186	.4191	.4908	.4191	.4287
19	.7011	.7811	.6485	.1905	.4207	.4572	.463
20	.7186	.743	.7011	.5335	.5434	.5335	.5658
21	.8063	.7811	.7537	.5906	.6661	.6097	.5959
22	.8063	.743	.7712	.6859	.5784	.5906	
23	.7712	.743	.7186	.6478	.6661	.6287	
24	.6478	.7712	.724	.7186	.6478	.6661	.6287
Max	.9145	.9114	.8764	.9114	.6661	.7716	.6287
Min	.5716	.5525	.1753	.1905	.1029	.2454	.1543
Avg	.7506	.7591	.7100	.6563	.5467	.6047	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 204 / 11 kv fetari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4191	.3841	.381	.4024	.6478
2	.4191	.4572	.4191	.4024	.381	.4024	.6287
3	.381	.3658	.381	.4024	.362	.3658	.5906
4	.362	.3658	.381	.4024	.3429	.3658	.5716
5	.362	.3658	.3429	.3658	.3429	.3658	.5525
6	.3429	.3292	.381	.3658	.3239	.3292	.5144
7	.3239	.3292	.362		.3048	.3292	.4572
8	.3429	.3475	.4001	.3292	.2858	.3658	.5716
9	.381	.3292	.4001	.3658	.3239	.3658	.6097
10	.381	.2743	.439	.3601	.3086	.1543	.5658
11	.4001	.2743	.439	.3601	.3429	.3258	.2401
12	.4382	.3772	.439	.3258	.3601	.3258	.3086
13	.4191	.3772		.3258	.4115	.3258	1.1488
14	.4572	.3944	.4572	.3772	.3944	.3258	.4115
15	.4001	.3772	.4572	.3772	.4115	.3429	.3944
16	.4382	.4801	.4572		.3086	.3601	.4287
17	.4382	.463	.439	.2572	.3086	.3601	.4115
18	.3475	.4572	.3658	.2667	.3109	.2477	.3601
19	.3841	.4191	.4207	.362	.3658	.4191	.3429
20	.3841	.4572	.439	.381	.4024	.4954	.3944
21	.4024	.4382	.4024	.4001	.3658	.6478	.439
22	.4572	.4382	.439	.4191	.3658	.6287	
23	.4572	.4572	.439	.4001	.4024	.2477	
24	.4572	.4572	.4382	.439	.4191	.4024	.6668
Max	.4572	.4801	.4572	.439	.4191	.6478	1.1488
Min	.3239	.2743	.3429	.2572	.2858	.1543	.2401
Avg	.4014	.3954	.4156	.3668	.3553	.3709	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 205 / 11 kv industrial 2 jain

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4001	.381	.4191	.362	.4191	.3239
2	.381	.4001	.381	.4191	.362	.4191	.3239
3	.3429	.381	.381	.4191	.3429	.4572	.3239
4	.3429	.381	.381	.4191	.3429	.4572	.3239
5	.381	.381	.381	.4382	.3239	.4572	.3239
6	.4191	.381	.381	.4382	.3239	.4572	.3239
7	.4001	.4001	.381	.4382	.362	.4191	.3239
8	.4001	.4191	.381	.4572	.362	.381	.4572
9	.3239	.381	.3429	.4382	.362	.381	.2096
10	.3239	.3429	.381	.3944	.4115	.2743	.2572
11	.3239	.3086	.4191	.4287	.4115	.3086	.3086
12	.362	.4287		.4973	.4458	.3258	.3944
13	.362	.3258		.5144	.4115	.3086	.4115
14	.3429	.3601	.4191	.463	.4458	.3086	.4458
15	.3429	.3429	.4382	.463	.4115	.3086	.4115
16	.362	.3601	.4382		.1029	.3429	.463
17	.362	.3772	.4191	.3086	.3429	.3429	.4115
18	.4382	.4572	.4382	.362	.4572	.3429	.3772
19	.4572	.4763	.4572	.381	.4382	.362	.3601
20	.4763	.4191	.4763	.381	.4572	.3429	.3601
21	.4191	.4001	.4382	.4001	.4763	.3429	.4763
22	.4382	.4001	.4191	.4001	.4001	.3239	
23	.4001	.381	.3856	.381	.4191	.3239	
24	.4001	.4001	.4001	.4191	.362	.4191	.3239
Max	.4763	.4763	.4763	.5144	.4763	.4572	.4763
Min	.3239	.3086	.3429	.3086	.1029	.2743	.2096
Avg	.3826	.3877	.4055	.4209	.3807	.3678	.3607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 207 / 11 kv station transformer

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0191	.0381	.0191	.0191	.0191
2	.0191	.0381	.0191	.0381	.0191	.0191	.0191
3	.0191	.0381	.0191	.0381	.0191	.0191	.0191
4	.0191	.0381	.0191	.0381	.0191	.0191	.0191
5	.0191	.0381	.0191	.0381	.0191	.0191	.0191
6	.0191	.0381	.0191	.0381	.0191	.0191	.0191
7	.0191	.0381	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0171	.0191	.0171	.0171	.0171	.0171
11		.0171	.0191	.0171	.0171	.0171	.0171
12		.0171		.0171	.0171	.0171	.0171
13		.0171		.0171	.0171	.0171	.0171
14	.0191	.0171	.0191	.0171	.0171	.0171	.0171
15	.0191	.0171	.0191	.0171	.0171	.0171	.0171
16	.0191	.0171	.0191		.0171	.0171	.0171
17	.0191	.0171	.0191	.0171	.0171	.0171	.0171
18	.0191	.0191	.0191		.0191	.0191	.0171
19	.0191	.0191	.0381		.0191	.0191	.0171
20	.0191	.0191	.0381		.0191	.0191	.0171
21	.0381	.0191	.0381	.0191		.0191	.0191
22	.0381	.0191	.0381	.0191	.0191	.0191	
23	.0381	.0191	.0381	.0191	.0191	.0191	
24	.0191	.0381	.0191	.0381	.0191	.0191	.0191
Max	.0381	.0381	.0381	.0381	.0191	.0191	.0191
Min	.0191	.0171	.0191	.0171	.0171	.0171	.0171
Avg	.0218	.0248	.0234	.0251	.0184	.0184	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 213 / 11 kV Hudkeshwar Urban 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	19-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.3336	1.3336	1.3336	1.7147	1.5242	.1143	2.0957
Max	1.3336	1.3336	1.3336	1.7147	1.5242	.1143	2.0957
Min	1.3336	1.3336	1.3336	1.7147	1.5242	.1143	2.0957
Avg	1.3336	1.3336	1.3336	1.7147	1.5242	.1143	2.0957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUN-18 and 21-JUN-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 401 / 33 KV BESA LUXORA KHAPARI

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-JUN-18	16-JUN-18	17-JUN-18	18-JUN-18	20-JUN-18	21-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.3086	.3086	.3086	.3086	.3086	.3086
Max	.3086	.3086	.3086	.3086	.3086	.3086
Min	.3086	.3086	.3086	.3086	.3086	.3086
Avg	.3086	.3086	.3086	.3086	.3086	.3086