

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 201 / KATTIPAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.1578	.2035	.1619	.1372	.1052	
2	.1696	.1372	.1865	.2103	.124	.0886	
3	.1619	.1372	.2374	.2321	.128	.0914	
4	.2401	.1492	.2103	.1989	.1478	.1097	
5	.3086	.1677	.2105	.1865	.1578	.1267	
6	.2804	.2103	.2279	.2058	.1829	.1494	
7	.2454	.2686	.2374	.2374	.2241	.2033	.1696
8	.2035	.2713	.2629	.2572	.2328	.2126	.197
9	.2374	.3086	.3045	.2785	.2303	.3077	.1696
10	.2294	.3353	.3506	.3077	.1772	.2229	.1802
11	.2947	.3294	.2915	.3201	.181	.2058	.16
12	.3467	.4115	.2683	.2629	.1543	.2058	.2012
13	.2774	.3688	.3149	.2865	.1294	.1296	.16
14	.2126	.3222	.3185		.1753	.1619	.1254
15	.2774	.2915	.3201		.1772	.1619	.1433
16	.25	.3281	.3887		.208	.1619	.16
17	.3277	.3201	.3521		.1772	.1595	.1844
18	.2774	.3429	.3018		.2427	.1886	.2401
19	.3511	.3688		.0503	.298	.2543	.3018
20	.3292	.3077	.3086	.2614	.2641	.2374	.2641
21	.2772	.3052	.2804	.2241	.1886	.1715	.2241
22	.2218	.2629	.2241	.1791	.128		.1478
23	.2195	.2401	.1781	.1433	.1254	.0857	.1448
24	.1753	.1829	.2058	.16	.1402	.1097	.1017
Max	.3511	.4115	.3887	.3201	.298	.3077	.3018
Min	.1619	.1372	.1781	.0503	.124	.0857	.1017
Avg	.2549	.2719	.2689	.2192	.1805	.1674	.1820

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 202 / SITEPAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2883	.3506		.2267	.1097	.1267	.1357
2	.2743	.3601	.3944	.1658	.0905	.104	.1187
3	.3077	.3155	.3441	.16	.0914	.0914	.116
4	.3401	.3856	.4001	.1943	.1097	.1086	.0819
5	.6783	.3012	.407	.2591	.1294	.1463	.0983
6	.6802	.3366	.4641	.2915	.1494	.1612	.1402
7	.8764	.5792	.6344	.3201	.1698	.1829	.1715
8	.7611	.583	.7522	.5765	.3018	.1698	.2401
9	.7461	.6836	.8063	.763	.2641	.1886	.3052
10	1.0288	.7373	.8413	.8421	.2402	.2103	.1943
11	1.1443	.4973	.7537	1.0364	.2378	.1457	.3441
12	.8745	.7975	.5935	.8859	.5083	.1696	.2218
13	.5201	.7625	.7969	.6836	.4527	.1526	.4207
14	.7122	.7202	.5765	.1715	.2801	.1753	.5373
15	.6859	.4641	.7802		.1886	.1715	.567
16	1.1443	.4696	1.1517		.3856	.1696	.6219
17	.8718	.4752	.6371	.0244	.2054	.1134	.4656
18	.8149	.5373	.3725	.0943	.4527	.1823	.3511
19	1.0425	.7202	.3361	.112	.2987	.2458	.5041
20	.7023	.7362	.3391	.112	.2587	.2543	.2829
21	.5853	.57	.2713	.0739	.2054	.2103	.2263
22	.4656	.463	.2267	.1494	.1663		.1698
23	.4656	.3429	.1715	.112	.1433	.0995	.1629
24	.3601	.4252	.3681	.1865	.1029	.128	.1086
Max	1.1443	.7975	1.1517	1.0364	.5083	.2543	.6219
Min	.2743	.3012	.1715	.0244	.0905	.0914	.0819
Avg	.6821	.5256	.5399	.3382	.2309	.1612	.2744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 203 / BHOSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2267	.1052	.1981	.1677
2		.2374	.1063	.1898	.1457
3		.25	.0867	.1844	.1696
4		.2543	.1052	.1852	.1753
5		.2429	.12	.213	.2172
6		.2622	.1254	.2401	.1696
7		.2881	.1791	.2785	.2103
8		.3052	.1433	.2968	.2058
9		.3052	.1433	.2591	.213
10		.3429	.1402	.3045	.1966
11		.3401	.12	.2652	.1696
12		.301	.1254	.2204	.1882
13		.3102	.1134	.1254	.1907
14		.1814	.1406	.2155	.1957
15			.1581	.1989	.1614
16		.0857	.144	.208	.1635
17		.1113	.1581	.1543	.1635
18	.2591	.0983	.2031	.2294	.1981
19	.3239	.2427	.3475	.3086	.3326
20	.39	.2402	.3292	.3326	.3326
21	.3052	.181	.1646	.2454	.2896
22	.2543	.1214	.2241		.2058
23	.2267	.1227	.1829	.1475	.1677
24		.1989	.1029	.1833	.1372
Max	.39	.3429	.3475	.3326	.3326
Min	.2267	.0857	.0867	.1254	.1372
Avg	.2932	.2283	.1570	.2254	.1986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 204 / 11 KV SARKARTOLA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.096	.144	.1311	.0617	.0949	.1372
2	.1457	.1128	.1578	.1543	.0474	.0772	.0972
3	.1715	.0987	.1357	.1372	.048	.08	.0876
4	.1619	.1128	.1457	.1296	.0617	.1006	.1372
5	.1543	.1334	.1886	.1475	.064	.112	.116
6	.2035	.1718	.1715	.1619	.0671	.096	.0857
7	.1638	.1802	.181	.1781	.0791	.1094	.1134
8	.1781	.1581	.2035	.1509	.0819	.1147	.1326
9	.1802	.1718	.2058	.2058	.061	.125	.12
10	.16	.1852	.1886	.1753	.0633	.1357	.0983
11	.1875	.1875	.1886	.2035	.0617	.1017	.0819
12	.1781	.1829	.1219	.1829	.0457	.1029	.061
13	.1875	.1806	.1219	.1656	.0926	.1326	.0762
14	.1718	.1677	.1505	.1829	.061	.1492	.1017
15	.1677	.1806	.1524		.0914	.1543	.1067
16	.1718	.1981	.1372		.0903	.1372	.1067
17	.1783	.2107	.1524		.1067		.1054
18	.1943	.2454	.1677	.0474	.0753		.1524
19	.2454	.2572	.2267	.0937	.1475	.1526	.1677
20	.2279	.2401	.2012	.0937	.1475	.1402	.1524
21	.1966	.1928	.1865	.0926	.1147	.1326	.1423
22	.1505	.197	.1865	.0781	.0983		.1311
23	.1448	.1696	.1619	.0671	.0791	.0857	.1311
24	.1357	.132	.1696	.1526	.0655	.096	.0972
Max	.2454	.2572	.2267	.2058	.1475	.1543	.1677
Min	.1341	.096	.1219	.0474	.0457	.0772	.061
Avg	.1746	.1735	.1686	.1396	.0797	.1157	.1141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 201 / 11 KV irri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2402	.2587	.3881	.439	.12	.1509
2	.168	.2402	.2587	.3696	.4435	.0867	.1132
3	.1494	.1848	.2033	.3881	.439	.0867	.132
4	.1494	.2172	.2033	.3734	.3696	.0693	.132
5	.0934	.2378	.0924	.2829	.2614	.0701	.132
6	.112	.1629	.0934	.2452	.2534	.0526	.1509
7	.1494	.1463	.112	.1886	.2743	.052	.1509
8	.168	.0739	.112	.1886	.2587	.0347	.1509
9	.2427	.0934	.0747	.0732	.2614	.0503	.132
10	.112	.0566	.0747	.1097	.2614	.0934	.1307
11	.1646	.0943	.2033	.181	.3174	.1307	.2241
12	.2378	.1867	.4668	.4294	.3696	.1294	.2957
13	.3475	.2987	.2987	.4572	.2402	.1294	.2587
14	.2926	.3696	.1867	.2054	.3658	.112	.2241
15	.2561	.3511	.2801		.3174	.112	.2218
16	.2378	.3696	.1867		.3584	.1307	.2587
17	.2378	.4854	.1698	.2402	.2452	.1132	.2601
18	.2195	.4854	.1886	.462	.2829	.1307	.1886
19	.3292	.1109	.1509	.1463	.1288	.1509	.2204
20	.112	.1109	.1509	.3109	.0991	.1867	.0995
21	.112	.2772	.1698	.3658	.1147	.1509	.0838
22	.0747	.2587	.2427	.3881	.1187	.132	.0686
23	.2402	.2587	.3361	.4435	.1372	.1132	.052
24	.2452	.2402	.2587	.4251	.4344	.1372	.132
Max	.3475	.4854	.4668	.462	.4435	.1867	.2957
Min	.0747	.0566	.0747	.0732	.0991	.0347	.052
Avg	.1956	.2313	.1989	.3028	.2830	.1073	.1652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 202 / Anjora

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.6219	.5788	.5792	.3361	.4294	
2	.5544	.6219	.5601	.6219	.3361	.4338	.3174
3	.5544	.6219	.5041	.5853	.3361	.415	.3921
4	.5175	.6584	.4854	.5544	.3584	.415	.3174
5	.3881	.6516	.4668	.5544	.3584	.5228	.3361
6	.7762	.7421	.5175	.5281	.499	.6161	.3361
7	.9055	.8869	.6283	.6348	.5853	.6535	.4572
8	.9425	.8686	.6468	.6161	.4066	.6161	.4572
9	.8686	.7762	.6099	.6161	.3361	.5792	.439
10	.5359	.6908	.6653	.8215	.4108	.4557	.5544
11	.9425	.8131	.8413	.9896	.2829	.4733	.6283
12	.961	.7947	.9145	1.1203	.6584	.5493	.7207
13	1.0517	.8131	.695	1.1389	.8413	.5792	.5729
14	1.1458	.8316	.7023	.567	.6838	.543	.6219
15	1.0349	.8316	.8048		.724	.4938	.6584
16	1.1273	.7095	.9694		.6767	.6036	.5788
17	1.0498	.8402	.9511	.9955	.9511	.5853	.6516
18	.9593	.7655	.8316	1.0349	.8131	.6219	.7392
19	.8413	.7282	.8316	.9511	.7922	.5544	.7282
20	.8402	.8215	.6653	1.0349	.6224	.5544	.679
21	.6722	.7282	.5788	.7316	.5658	.4668	.6602
22	.6468	.5788	.5415	.499	.5601		.5975
23	.7207	.5228	.5601	.4572	.4854	.1509	.5788
24	.4805	.6767	.5788	.5601	.4024	.4481	.2241
Max	1.1458	.8869	.9694	1.1389	.9511	.6535	.7392
Min	.3881	.5228	.4668	.4572	.2829	.1509	.2241
Avg	.7916	.7332	.6720	.7360	.5426	.5113	.5325

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 203 / Amgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.3734	.6036	.5281	.2957	.3734	.2263
2	.5228	.2987	.5975	.4527	.2957	.2987	.2241
3	.5228	.2987	.5975	.3772	.2957	.3018	.2241
4	.5228	.5121	.5228	.3772	.439	.3018	.2263
5	.5228	.5121	.5228	.5228	.439	.5281	.2987
6	.6722	.6584	.7468	.5853	.6584	.679	.4481
7	.8962	.961	.9709	.7316	.8688	.8299	.8299
8	1.0456	1.0349	.9709	.8779	1.086	1.1317	.9709
9	1.0456	1.1088	.9709	1.0029	1.0974	1.1317	1.0349
10	.9709	.8962	.8962	1.0136	.9511	1.0562	.9511
11	.9709	.9709	.9808	.961	1.0242	.9054	.9412
12	.9709	.8962	.9054	.961	.8871	.8215	1.0029
13	.8215	.8962	.8215	.8215	.7468	.7468	.7087
14	.7468	.7545	.6722	.6722	.5658	.5975	.6379
15	.7468	.7545	.679		.7468	.5228	.6584
16	.7468	.7545	.7392		.7468	.4527	.5853
17	.8048	.8131	.8215	.8871	.7468	.5228	.8131
18	.9511	.961	.9511	1.0349	.9808	.6722	.9709
19	1.1706	1.1949	1.1584	1.0745	1.0562	.9808	1.1317
20	1.1088	1.1203	1.0456	1.0242	.9808	.9808	1.1317
21	.9412	1.0562	.9808	.8779	.9054	.8215	.9808
22	.7316	.9054	.8215	.7392	.7545	.4527	.7545
23	.6653	.7545	.679	.5175	.5975	.3018	.5281
24	.5975	.5175	.6036	.6036	.439	.4527	.3018
Max	1.1706	1.1949	1.1584	1.0745	1.0974	1.1317	1.1317
Min	.5228	.2987	.5228	.3772	.2957	.2987	.2241
Avg	.8039	.7918	.8025	.7565	.7336	.6610	.6909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 204 / 11 KV Salekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4108	.2614	.2641	.439	.6348	.0943
2	.3772	.4108	.2614	.2829	.439	.6161	.0943
3	.3395	.2614	.2241	.3018	.4572	.5788	.1132
4	.3584	.3292	.2241	.2641	.5121	.5658	.0943
5	.3961	.3547	.2427	.4854	.4961	.6413	.0943
6	.4527	.5175	.5281	.5228	.5194	.7167	.132
7	.5658	.6154	.5847	.6161	.7282	.7499	.1509
8	.6036	.7133	.6224	.6161	.7655	.7133	.1509
9	.5847	.6653	.5601	.5914	.7392	.695	.1867
10	.4715	.5415	.567	.6401	.6838	.5853	.2614
11	.3696	.5228	.5487	.5544	.4338	.3982	.1829
12	.3326	.5788	.7577	.7023	.695	.3801	.4207
13	.3511	.6283	.7947	.695	.724	.3841	.4251
14	.462	.5914	.7947	.4294	.695	.3841	.3326
15	.4805	.5729	.8501		.6036	.3841	.6335
16	.5175	.5914	.7282		.7023	.4251	.7499
17	.6283	.5093	.6535	.0549	.7947	.5175	.9145
18	.6584	.4904	.7207	.0549	.7095	.6401	.6348
19	.8145	.6602	.7499	.2378	.7167	.5415	.8676
20	.7133	.6224	.7095	.5611	.6908	.6838	.7167
21	.6154	.4668	.6535	.3982	.4668	.5914	.5847
22	.5544	.3734	.415	.3258	.7282		.4294
23	.4435	.2801	.3395	.2743	.6602	.1132	.5975
24	.4294	.4251	.2641	.2641	.2561	.6348	.0943
Max	.8145	.7133	.8501	.7023	.7947	.7499	.9145
Min	.3326	.2614	.2241	.0549	.2561	.1132	.0943
Avg	.4956	.5056	.5440	.4153	.6107	.5467	.3732



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 207 / 33/11 kv 10 MVA T/R

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.2883	1.2323	1.1763	.7922	1.0642	.3961
2	1.2449	1.0751	1.2883	1.1883	.7922	1.1088	.7356
3	1.2752	1.2883	1.2323	1.1883	.8488	1.1643	.8402
4	1.2323	1.2197	1.1763	1.4712	.9054	1.1643	.7356
5	1.0082	1.3306	1.1883	1.1883	1.0185	1.2197	.8488
6	1.6244	1.5684	1.4146	1.2449	1.1883	1.3014	.9054
7	1.9044	1.8484	1.6804	1.5278	1.4712	1.5123	1.3014
8	1.9959	1.9404	1.6804	1.5684	1.4563	1.6804	1.4563
9	1.9404	1.9605	1.7187	.6099	.3361	1.7364	1.5524
10	1.6632	1.7364	1.6632	1.9605	1.5844	1.4003	1.5684
11	2.0725	1.9605	1.8296	1.9959	1.6244	1.4563	.8871
12	1.9605	1.885	1.9404	2.0851	1.6804	1.386	1.7187
13	2.1285	1.7187	1.4969	1.9204	1.6804	1.262	1.4815
14	1.9044	1.6078	1.4415	1.1797	1.4969	1.2323	1.3575
15	1.885	1.6632	1.5364		1.5364	1.0534	1.3575
16	2.0513	1.5746	1.7558		1.4266	1.2071	1.3169
17	2.0165	1.6632	1.8296	1.9204	1.7558	1.1523	1.5912
18	1.9605	1.8484	1.8296	2.0513	1.7924	1.4003	1.7924
19	2.1502	2.037	1.9239	2.1285	1.9239	1.5844	1.9239
20	1.9805	2.037	1.8107	1.5844	1.6409	1.4712	1.8673
21	2.2068	1.8107	1.5844	1.5844	1.5278	1.358	1.6975
22	1.5123	1.5278	1.4003	1.2449	1.4003	.5716	1.3443
23	1.4003	1.3014	1.2883	1.0751	1.1763	.679	1.2323
24	1.1763	1.3443	1.2323	1.1883	.9619	1.0082	.679
Max	2.2068	2.037	1.9404	2.1285	1.9239	1.7364	1.9239
Min	1.0082	1.0751	1.1763	.6099	.3361	.5716	.3961
Avg	1.7233	1.6348	1.5489	1.5037	1.3341	1.2573	1.2745

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 208 / 33/11 KV 5 MVA T/R

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.6099	.5041	.6653	.7282	.5041	.1132
2	.6099	.5544	.5041	.6099	.7762	.4527	.1132
3	.6099	.5487	.4481	.6653	.7682	.439	.1132
4	.6161	.5544	.4481	.6722	.7762	.3841	.1715
5	.4435	.5373	.3361	.6722	.7059	.499	.168
6	.5601	.6722	.6161	.7356	.7762	.6653	.1663
7	.6099	.6653	.6722	.6722	.8871	.7133	.2829
8	.7207	.6584	.6099	.6722	.7682	.4801	.2829
9	.7133	.6584	.6036	.6584	.9134	.6584	.3395
10	.543	.5973	.5487	.5201	.7602	.5373	.3961
11	.5041	.4938	.8779	.8316	.6224	.4481	.4527
12	.5544	.7282	1.0534	1.0425	.9522	.4481	.6224
13	.6722	.9425	1.0534	1.3969	.8962	.4527	.679
14	.6653	.8316	.8779	.4652	.8962	.4527	.6099
15	.7282	.9036	1.0425		.7762	.4784	.8402
16	.7207		.8871		.9522	.4784	.8322
17	.8145	.9522	.8688	.3921	.9054	.5316	1.0082
18	.8059	.7762	.8316	.3395	.8488	.6224	.8402
19	.9054	.7356	.8402	.3921	.8002	.6859	.9619
20	.7842	.7356	.7842	.7282	.743	.6224	.7922
21	.6722	.7356	.7356	.8402	.5658	.6224	.6722
22	.5544	.6224	.6722	.6161	.6722	.0497	.439
23	.6722	.5041	.6584	.6099	.6161	.1698	.6836
24	.6653	.6099	.5041	.6653	.6099	.5601	.1698
Max	.9054	.9522	1.0534	1.3969	.9522	.7133	1.0082
Min	.4435	.4938	.3361	.3395	.5658	.0497	.1132
Avg	.6611	.6795	.7074	.6756	.7799	.4982	.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 401 / 33 KV SALEKASA FDR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4372	.5218	.5218	.4801	.2429	.2429	.2515
2	.4167	.4801	.5093	.4744	.2401	.2458	.2486
3	.499	.5418	.5093	.463	.2372	.2372	.2401
4	.3932	.5155	.5218	.4801	.2315	.2486	.2401
5	.5407	.583	.5596	.583	.2458	.3086	.3052
6	.7362	.8413	.8505	.8322	.3395	.4835	.4344
7	.9036	.9671	.9231	.8939	.3801	.3155	.6584
8	.9882	1.0099	.9568	1.0517	.6984	.3086	.7059
9	1.0174	.8939	.8842	1.0288	.691	.8596	.8059
10	.9259	.7802	.8648	.8842	.591		.6241
11	.9054	.823	.763	.3561	.631	.8842	.631
12	.8648	.7362	.7042	.8745	.463	.7802	.4207
13	.8951	.7802	.7282	.7116	.5144	.7802	.3601
14	.8848	.8322	.7202	.7362	.6173	.7956	.5596
15	.8745	.8139	.6613		.5658	.4527	.5721
16	.7042	.7865	.7459		.6241	.5658	.5784
17	.8648	.8551	.8745		.5784	.6613	.6173
18	.9991	1.1163	1.1283		.8871	.8779	.8059
19	1.386	1.4415	1.386		1.1883	1.0751	1.2323
20	1.2197	1.2197	1.1643	.6036	1.0642	.8871	1.0082
21	.9774	1.0317	.9134	.439	.2126	.7682	.8402
22	.7059	.7202	.6687	.3086	.4207	.144	.6036
23	.5533	.5407	.5281	.2458	.1989	.2915	.4207
24	.463	.4858	.5344	.4973	.2458	.2429	.0857
Max	1.386	1.4415	1.386	1.0517	1.1883	1.0751	1.2323
Min	.3932	.4801	.5093	.2458	.1989	.144	.0857
Avg	.7982	.8049	.7759	.6286	.5045	.5416	.5521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 402 / 33 KV DEORI feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8858	3.0247	3.2487	2.9424	1.1283	1.0208	1.5123
2	2.8292	3.1367	3.0727	2.9424	1.1283	1.0631	1.5123
3	2.7726	3.0247	3.1367	2.8858	1.1283	1.0099	1.4563
4	2.9424	3.1367	3.1367	2.9424	1.1403	1.0631	1.4563
5	3.0556	3.2487	3.3951	3.1687	1.262	1.6478	1.5684
6	3.8477	4.1307	4.3004	3.9043	1.7558	1.7187	2.1285
7	4.145	4.481	4.5931	4.369	1.9044	2.2068	2.4331
8	4.481	4.5462	4.8234	2.8829	2.2068	2.4577	2.4897
9	4.1581	4.8234	4.4353	1.7558	2.0936	2.572	2.2177
10	4.0472	4.4445	4.1152	4.2798	2.2634	3.0556	2.5503
11	3.9506	2.9081	3.9506	4.1089	1.8673	2.8292	2.524
12	3.9506	4.3347		4.3896	2.1148	2.8858	2.4897
13	3.9506	4.1152	4.0055	4.137	2.0576	2.8292	
14	3.9506	3.7311	4.2798	3.1893	1.8673	2.6595	3.3951
15	3.786	4.0181	4.3439		2.0576	2.2068	2.2068
16	4.0724	3.9758	3.9758	.1132	2.0005	2.5766	2.2405
17	4.0295	4.181	4.3519	.1132	1.9239	2.8006	2.6886
18	5.1006	5.5441	5.4332	2.037	2.4897	3.7912	3.8477
19	6.6204	6.5638	6.3375	3.0556	3.1687	5.144	5.4298
20	6.0545	6.3375	5.7716	3.0556	2.8292	4.2867	5.2584
21	1.3432	5.0926	4.9228	2.2965	1.5775	3.8866	3.5648
22	1.0631	3.9769	3.7912	1.4815	1.2752	1.4712	3.1687
23	.8842	3.4728	3.2819	1.262	1.2449	1.3014	2.6029
24	2.9127	3.1367	3.3608	3.0556	1.262	1.386	1.5684
Max	6.6204	6.5638	6.3375	4.3896	3.1687	5.144	5.4298
Min	.8842	2.9081	3.0727	.1132	1.1283	1.0099	1.4563
Avg	3.6181	4.1411	4.1767	2.7986	1.8228	2.4113	2.6222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 403 / 33 KV TEDHA FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.4563	1.4712	1.358		.591	.0063
2	1.2003	1.4003	1.4563	1.358		.6447	.0063
3	1.2574	1.4563	1.4563	1.358		.6584	.0063
4	1.2323	1.4563	1.4563	1.358		.6173	.0074
5	1.3146	1.5844	1.5844	1.4146		.6173	.0069
6	1.6409	1.9239	2.037	1.7718		.8413	.0074
7	1.9239	2.2405	2.4086	2.037		.9774	
8	2.0165	2.3285	2.2731	2.2731		1.3014	
9	2.2805	2.2497	2.1948	2.3348		1.0642	
10	2.1399	2.3348	2.0302	2.364		1.1883	
11	2.0851	2.3891	2.0851	2.1719		1.1883	
12	2.1399	2.2262	1.9959	2.1325		1.0642	.1663
13	2.0633	2.3102	2.0851	2.1033		1.1317	1.4415
14	1.5912	2.3102	2.1399		.0131	1.1317	1.386
15	1.9342	2.2857	2.0633		.7442	1.1317	.7922
16	2.1719	2.2857	2.2565		1.2003	1.2003	.7842
17	2.3102	2.3388	2.2028		1.2574	1.2574	.9328
18	2.5766	2.5503	2.4086		1.8107	1.5278	1.3306
19	2.8858	2.9424	2.7726		2.1285	1.9959	1.1191
20	2.6029	2.6326	2.5463		1.9044	1.7364	1.7558
21	2.2068	2.1502	2.037		.7202	1.386	1.2757
22	1.7364	1.6409	1.6975		.8688		.9882
23	1.5278	1.5278	1.4146		.823	.0377	.8048
24	1.2574	1.4563	1.4146	1.358		.7602	.0377
Max	2.8858	2.9424	2.7726	2.364	2.1285	1.9959	1.7558
Min	1.1883	1.4003	1.4146	1.358	.0131	.0377	.0063
Avg	1.8868	2.0616	1.9787	1.8138	1.1471	1.0457	.6766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 405 / 33/0.4 KV station  
transformer Feeder KV- 33 /  
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4664	.3658	.4275	.3887	.3544	.583	.3829
2	.4275	.4024	.4275	.3498	.3601	.583	.3447
3	.4275	.3772	.4275	.3447	.3715	.5361	.3447
4	.3887	.3544	.3887	.3018	.3658	.5361	.3064
5	.3887	.3601	.3887	.3018	.3658	.5361	.3064
6	.3109	.2926	.3498	.3887	.3658	.3064	.3064
7	.2721	.3018	.2721	.4275	.2835	.2298	.3064
8	.2721	.2835	.2332	.3887	.2195	.2681	.2681
9	.3109	.216	.2721	.3887	.216	.2681	.2195
10	.2721	.3064	.2721	.3498	.2332	.2681	.216
11	.2721	.3498	.2721	.2789	.2721	.3064	.216
12	.2721	.3498	.3109	.3018	.3109	.3064	.2926
13	.2721	.3109	.3109	.3018	.2332	.3064	.2972
14	.3109	.3109	.3498	.2835	.2332	.3064	.2972
15	.3109	.3498	.3498	.2926	.3109	.3064	.2972
16	.3109	.3498	.3498	.2881	.3498	.3064	.2972
17	.2926	.3109	.3887	.2972	.3498	.3829	.3447
18	.2926	.3109	.4275	.2926	.3887	.3829	.3447
19	.3715	.5053	.4275	.3601	.5441	.4595	.4978
20	.3715	.5053	.3887	.3544	.5441	.4212	.5744
21	.3658	.4664	.3887	.3658	.583	.4978	.5744
22	.3601	.4664	.4275	.3544	.583	.4595	.5744
23	.3658	.4664	.4275	.3772	.6219	.4212	.6127
24	.4275	.3715	.4275	.4275	.3658	.6219	.4212
Max	.4664	.5053	.4275	.4275	.6219	.6219	.6127
Min	.2721	.216	.2332	.2789	.216	.2298	.216
Avg	.3389	.3618	.3628	.3419	.3678	.4000	.3601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 406 / 33 KV KALIMATI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.8139	.9259	.8648	.4481	.5316	.3292
2	.7202	.8139	.9259	.8648	.4481	.5373	.3292
3	.7716	.8048	.9259	.8648	.4481	.5316	.3292
4	.7362	.8139	.8745	.8139	.4298	.5373	.3258
5	.7802	.8779	.9362	.8745	.4481	.5973	.3326
6	.9671	1.0208	1.1283	1.1043	.5658	.7207	.1715
7	1.3432	1.2226	1.3432	1.2094	.7842	.8779	.2829
8	2.5766	1.2483	2.5474	1.3003	1.6255	1.8695	.3921
9	1.2483	1.286	1.5083	1.4918	.7762	.7287	.8596
10	1.4563	1.4243	1.4403	1.4918	.6584	.8322	.5847
11	1.4918	1.3735	1.0682	2.8355	.6516	.7973	.7888
12	1.3889	1.3889	.9156	1.5261	.7602	.8413	.7888
13	.9156	1.4918	1.2209	1.2929	.6984	.7802	.8779
14	1.2209	1.1191	1.2574	.064	.6584	.6539	.9259
15	1.2717	1.1568	1.3923		1.0402	.6539	.9362
16	2.8595	2.8115	3.2716	.1698	2.1085	1.9559	1.889
17	1.4083	1.1568	1.3077	.1698	.7802	.5373	.9156
18	1.1963	1.4043	1.4883	.5041	1.0974	.6653	2.7298
19	1.7918	1.701	1.8107	.6224	1.358	1.2449	1.4815
20	1.5746	1.5912	1.5203	.6224	1.1763	1.0082	1.2752
21	1.3432	1.4118	1.2894	.7356	.2263	.7207	1.0974
22	1.0631	1.1043	1.1043	.5601	1.2757	.2241	.8059
23	.8842	.9882	.9259	.5041	.5973	.3361	.6836
24	1.677	2.0091	2.093	2.0502	.8733	1.1277	.3841
Max	2.8595	2.8115	3.2716	2.8355	2.1085	1.9559	2.7298
Min	.7202	.8048	.8745	.064	.2263	.2241	.1715
Avg	1.3090	1.2931	1.3842	.9799	.8306	.8046	.8132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 407 / 33 KV KAWARABANDH

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.5544	.6722	.5544	.1646	.6161	
2	.6653	.5544	.7682	.4435	.2743	.6161	
3	.6653	.5487	.7133	.439	.2829	.6161	
4	.7842	.6036	.7133	.4887	.2715	.5093	
5	.7207	.6036	.7762	.4938	.2829	.5093	
6	.8316	.7282	.8402	.6099	.3395	.5658	
7	.8871	.7762	.8962	.7207	.5093	.6224	.1143
8	.9522	.8316	.8962	.6584	.4527	.5093	.2218
9	.8871	.7207	.6722	.9328	.5658	.4527	.3361
10	.7207	.4344	.7282	.9328	.5658	.2801	.2241
11	.823	.6036	.7207	.8871	.7922	.2858	.5601
12	.8779	.7207	.8871	.7762	.7842	.1715	.2772
13	.6036	.6722	.8402	.7602	.5658	.2241	
14	.7682	.6722	.591	.7407	.1629	.2263	.3881
15	.9979	.7207	.9522		.3361	.1132	.8145
16	1.0534	.7133	.9979	.0566	.679	.2286	.3395
17	1.0534	.7059	.9979	.168	.5601	.3326	.3921
18	1.1763	.6722	1.0082	.1132	.7842	.5093	.5658
19	1.0751	.8316	1.0185	.5093	.9145	.8002	.8002
20	.9054	.9619	.8488	.5093	.9054	.5658	.743
21	.6722	.8488	.679	.4527	.7922	.5093	.5716
22	1.0642	.6161	.6224	.2263	.7356		.5658
23	.6036	.6722	.6099	.1698	.6224		.5041
24	.6584	.5544	.6722	.6099	.2829	.6224	
Max	1.1763	.9619	1.0185	.9328	.9145	.8002	.8145
Min	.6036	.4344	.591	.0566	.1629	.1132	.1143
Avg	.8380	.6801	.7968	.5328	.5261	.4494	.4636



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 201 / 11 KV Chichgad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1698	.1698	.1698	.1143		.132
2	.1524	.1663	.1524	.1509	.1143		.132
3	.1524	.168	.1524	.1509	.0953		.132
4	.1715	.168	.1698	.1509	.0953		.132
5	.1905	.168	.1886	.1886	.1524		.1698
6	.2477	.2427	.2641	.2641	.1867		.2075
7	.2477	.2614	.2614	.3018	.1867		.2096
8	.2641	.2772	.2772	.3361	.1886		.2096
9	.3018	.2402	.2926	.2641	.1886	.1109	.1698
10	.3109	.2427	.2218	.2427	.1886	.1663	.1698
11	.2534	.2218	.2241	.2263	.2075	.2033	.1509
12	.2801	.2218	.2427	.2987	.1294	.2075	.1867
13	.2987	.2402	.3109	.2987	.1494	.2263	.1886
14	.2957	.1867	.3109	.2774	.1294	.2075	.1848
15	.2957	.2452	.2772		.1097	.1905	.1478
16	.2772	.2241	.2801		.1109	.1905	.1663
17	.3326	.2641	.2987			.2096	.1867
18	.2957	.3361	.3734	.2641		.2477	.2614
19	.462	.4481	.4904	.3772		.3961	.415
20	.4251	.4108	.4382	.3772		.3584	.3772
21	.2957	.3206	.3395	.2263	.1698	.2829	.2957
22	.2241	.2263	.2263	.1509			.2241
23	.1867	.1886	.1886	.132		.1509	.2075
24	.1524	.1509	.1698	.1715	.1143		.132
Max	.462	.4481	.4904	.3772	.2075	.3961	.415
Min	.1524	.1509	.1524	.132	.0953	.1109	.132
Avg	.2611	.2412	.2634	.2391	.1462	.2249	.1995

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 202 / 11 KV Ganutola Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2452	.2075	.2263	.0762		
2	.1905	.2614	.2075	.2075	.0762		
3	.2096	.2772	.2096	.2075	.0762		
4	.1905	.2801	.2263	.2075	.0754		
5	.2286	.2641	.2263	.2452	.0934		
6	.2858	.3395	.2801	.3018	.112		
7	.2667	.3361	.2614	.3395	.1097		
8	.2054	.3584	.2477	.2641	.0754		
9	.1867	.2772	.2218	.1886	.0566		
10	.2195	.2587	.1646	.1848	.1524	.2427	.2054
11	.2172	.2587	.1663	.1886	.1886	.2054	
12	.2402	.2587	.2241	.1509	.1886	.2263	.2241
13	.2218	.2452	.2263	.2075	.1848	.2452	.2054
14	.2587	.1867	.2587	.2172	.1848	.2218	.1886
15	.1478	.2641	.2402		.1494	.2378	.1886
16	.1494	.2054	.2561		.1478	.2012	.2075
17	.1494	.1867	.2587			.2054	.2241
18	.2427	.3174	.2987			.2829	.3395
19	.462	.5041	.4904			.4763	.4904
20	.4435	.4854	.4338			.4191	.4527
21	.3326	.4338	.3772	.1097	.1494	.362	.3018
22	.2614	.2641	.2641	.0943			.2241
23	.2427	.1698	.2263	.0943			.2075
24	.2096	.2075	.2263	.2263	.0754		
Max	.462	.5041	.4904	.3395	.1886	.4763	.4904
Min	.1478	.1698	.1646	.0943	.0566	.2012	.1886
Avg	.2397	.2869	.2583	.2034	.1207	.2772	.2661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 203 / 11 KV Palandur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1867	.1524	.1698	.0943		
2	.1698	.1867	.1524	.1509	.0934		
3	.1509	.1698	.1334	.1509	.0943		
4	.1698	.1663	.1698	.132	.112		
5	.1886		.1905	.1886	.1307		
6	.2452	.2614	.2452	.2829	.168		
7	.1886	.2427	.2263	.2641	.1267		.1886
8	.2054	.2241	.2241	.2353	.128		.1509
9	.2012	.2033	.2218	.2328	.128		.1509
10	.1991	.2054	.1829	.2149	.1086	.0373	.1307
11	.1612	.1494	.1886	.2303	.0914	.0373	.132
12	.1663	.168	.1991	.2353	.1132	.0754	.1509
13	.1663	.168	.2561	.2195	.0934	.132	.1509
14	.1646	.1698	.2328	.1638	.0739	.1132	.1848
15	.2033	.2263	.2658		.0747	.1494	.1294
16	.2033	.2075			.0934	.1307	.1294
17	.2033	.2075	.2987			.1494	.1294
18	.2402	.2641	.2957	.0366		.1886	.1698
19	.3696	.3734	.3772	.0914		.1886	.2987
20	.3326	.3584	.3584	.2012		.2641	.2829
21	.2772	.2641	.2829	.1448	.132	.2075	.2075
22	.2033	.2075	.2263	.1132			.1494
23	.2054	.1886	.2075	.1132		.1132	.1509
24	.1698	.1886	.1698	.1886	.1132		.1132
Max	.3696	.3734	.3772	.2829	.168	.2641	.2987
Min	.1509	.1494	.1334	.0366	.0739	.0373	.1132
Avg	.2065	.2169	.2286	.1791	.1094	.1374	.1667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 201 / 11KV AMGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4938	.4755	.5093	.5359	.5249	.5093
2	.4904	.4755	.4904	.5093	.5415	.5304	.5093
3	.5093	.4938	.4572	.5093	.4854	.5249	.4938
4	.5144	.499	.4904	.5281	.4854	.5359	.5041
5	.5281	.5175	.5281	.5281	.5041	.5359	.4938
6	.547	.5729	.5658	.5658	.5415	.5729	.5121
7	.5281	.5601	.547	.5093	.5415	.5788	.5228
8	.5525	.5658	.5281	.5525		.5601	.4938
9	.4607	.5601	.5093	.5415	.5335	.6859	.5121
10	.4904	.5228	.5093	.499	.5716	.5525	.5228
11	.4755	.4854	.4904	.4805	.5716	.5335	.5175
12	.4715	.5041	.5093	.5729	.5335	.5281	.5175
13	.4755	.5041	.5335	.5544	.4904	.5281	.5359
14	.4755	.5228	.5525	.4668	.4904	.5281	.499
15	.439	.5041	.5335		.4904	.5281	.4805
16	.4755	.4854	.5281		.4954	.5144	.4854
17	.5175	.5093	.5525	.5281	.5228	.5228	.5144
18	.6036	.6348	.6224	.5601	.5847	.5788	.5716
19	.7545	.7842	.8002	.6722	.7167	.7282	.7356
20	.7282	.7468	.7356	.6535	.7167	.7282	.743
21	.6219	.6602	.6287	.6161	.6161	.6535	.6478
22	.5487	.547	.5525	.6161	.5359		.5658
23	.5121	.5281	.5144	.5601	.4066		.5658
24	.5093	.5121	.5093	.5093	.5415	.5249	.5041
Max	.7545	.7842	.8002	.6722	.7167	.7282	.743
Min	.439	.4755	.4572	.4668	.4066	.5144	.4805
Avg	.5302	.5496	.5485	.5474	.5414	.5681	.5399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 202 / 11 KV DEORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.439	.5228	.462	.3511	.4435	.3506
2	.3881	.4066	.5281	.4481	.3326	.4435	.3475
3	.4108	.4435	.4527	.4435	.3326	.4435	.3361
4	.4108	.4435	.4527	.4251	.3511	.4481	.3772
5	.4481	.499	.4715	.462	.3547	.3921	.3544
6	.5601	.5415	.5658	.5175	.5415	.4668	.4338
7	.6283	.5975	.6224	.5601	.5415	.5601	.567
8	.8402	.7922	.7545	.6838		.7095	.7545
9	.7922	.7842	.7207	.7468	.7207	.7577	.7545
10	.7545	.7468	.8501	.8316	.7762	.7947	.6722
11	.7733	.6653	.8501	.8775	.7947	.7392	.6535
12	.7133	.7207	.7947	.8589	.7392	.6908	.7468
13	.6584	.6653	.7023	.6468	.7468	.5914	.6468
14	.6036	.5788	.5601	.5601	.499	.5544	.5788
15	.6535	.7095	.6468		.5914	.5601	.5544
16	.6036	.6653	.6468	.3206	.5729	.6283	.5975
17	.6468	.7282	.6653	.3018	.6535	.5228	.6468
18	.7545	.9431	.8029	.7468	.7167	.6908	.7468
19	.9242	.9431	.8192	.7655	.8676	.8501	.8871
20	.8775	.8299	.7762	.7655	.7545	.8316	.8131
21	.7023	.7733	.7392	.6348	.6283	.7207	.6838
22	.6219	.6413	.6099	.5415	.462	.5175	.5914
23	.4755	.547	.5359	.4481	.3841	.4066	.4904
24	.4668	.4755	.5121	.4805	.5228	.439	.3921
Max	.9242	.9431	.8501	.8775	.8676	.8501	.8871
Min	.3881	.4066	.4527	.3018	.3326	.3921	.3361
Avg	.6307	.6492	.6501	.5882	.5755	.5918	.5824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 203 / 11 KV KAKODI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0867	.1075	.1132	.104	.0876	.0532	.0566
2	.0867	.1063	.1132	.0857	.0876	.0532	.0566
3	.0876	.1075	.1097	.0867	.0709	.0537	.0754
4	.1052	.1075	.1132	.1052	.0701	.0537	.0754
5	.104	.1086	.0934	.104	.0876	.0537	.0754
6	.104	.1254	.1463	.1214	.1086	.0724	.0943
7	.104	.1267	.1509	.1214	.1402	.1075	.1097
8	.1387	.1646	.1509	.156		.1086	.132
9	.128	.1402	.1214	.1267	.104	.104	.0943
10	.1307	.1227	.104	.1448	.0867	.0867	.0943
11	.1132	.1052	.104	.1433	.0867	.0867	.0716
12	.128	.1227	.1214	.124	.0693	.0867	.0716
13	.1494	.1227	.104	.124	.0693	.0693	.0537
14	.1698	.1227	.1214	.124	.0693	.052	.1075
15	.1132	.1227	.1227		.0693	.052	.0895
16	.1698	.1052	.1214		.0693	.0693	.0724
17	.1629	.1509	.1387	.0914	.1086	.104	.0693
18	.1829	.1829	.1734	.1063	.128	.1214	.104
19	.2195	.2075	.208	.1595	.1646	.1578	.156
20	.1991	.1829	.1907	.1417	.1463	.1578	.156
21	.1612	.0943	.1387	.1052	.0724	.1214	.1214
22	.124	.1132	.1214	.0886	.0543	.052	.104
23	.1075	.0943	.104	.0886	.0532	.0566	.0686
24	.0867	.1063	.1132	.104	.0876	.0532	.0701
Max	.2195	.2075	.208	.1595	.1646	.1578	.156
Min	.0867	.0943	.0934	.0857	.0532	.052	.0537
Avg	.1318	.1271	.1291	.1162	.0909	.0828	.0908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 204 / 11 KV KOHAMARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5735	.6602	.5487	.0343		.1097
2	.4161	.5668	.679	.5375	.0857		.0943
3	.4287	.5571	.6584	.5487	.0343		.0943
4	.4287	.547	.679	.5316	.0351		.1132
5	.4508	.5801	.6602	.5548	.0526		.1132
6	.4801	.5935	.7545	.6001	.0876	.2347	.1509
7	.6241	.7545	.9054	.7373	.0876	.3429	.1698
8	.7373	.9991	1.0562	.9088		.4115	.2263
9	.8048	.9945	.8916		.1029	.3601	.3658
10	.8488	.9774	.8059	.9389	.2374	.4458	.5281
11	.8488	.8916	.8059	.779	.2229	.5144	.4748
12	.8865	.9774	.8402	.8192	.2572	.4458	.4475
13	.8589	.9259	.8745	.8684	.2785	.463	.4752
14	.9335	.9088	.8842	.6554	.2753	.4578	.5079
15	.8488	1.0185	.8745		.3441	.463	.4752
16	.9335	.9088	.8573		.2785	.4115	.5197
17	.8817	.9619	.7802	.1387	.3978	.3812	.6001
18	.9816	1.094	.7455	.2572	.4144	.3978	.6344
19	.9568	.9619	.7802	.4115	.4748	.4807	.6859
20	.823	.9242	.7202	.3944	.4287	.431	.6516
21	.6952	.7922	.6687	.0343	.3441	.3772	
22	.6203	.679	.583	.0343	.1989		.3944
23	.5735	.6979	.5487	.0343	.1943	.0686	.3561
24	.4115	.5735	.679	.5487	.0354	.1966	.1029
Max	.9816	1.094	1.0562	.9389	.4748	.5144	.6859
Min	.4115	.547	.5487	.0343	.0343	.0686	.0943
Avg	.7035	.8108	.7664	.5182	.2131	.3824	.3605

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER MBCP NON SHEDDABLE EXPRESS HV FEEDERS  
 SIRP Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0377	.0377	.0381	.0377	.0377	.0377
2	.0377	.0377	.0377	.0381	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0381	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0366	.0189	.0189	.0189	.0377
8	.0191	.0377	.0183	.0191		.0189	.0189
9	.0183	.0189	.0191	.0189	.0191	.0189	.0189
10	.0189	.0189	.0189	.0189	.0191	.0191	.0189
11	.0189	.0189	.0191	.0189	.0191	.0189	.0189
12	.0183	.0189	.0191	.0189	.0191	.0189	.0189
13	.0183	.0189	.0189	.0189	.0189	.0191	.0189
14	.0187	.0189	.0189	.0189	.0189	.0191	.0189
15	.0189	.0189	.0191		.0189	.0191	.0189
16	.0183	.0189	.0189	.0189	.0189	.0189	.0189
17	.0189	.0187	.0189	.0189	.0189	.0189	.0191
18	.0189	.0189	.0191	.0187	.0189	.0377	.0377
19	.0377	.0183	.0381	.0377	.0377	.0377	.0381
20	.0377	.0377	.0381	.0377	.0377	.0377	.0381
21	.0377	.0377	.0381	.0377	.0377	.0377	.0381
22	.0377	.0377	.0381	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0381
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0381	.0377	.0381	.0381	.0377	.0377	.0381
Min	.0183	.0183	.0183	.0187	.0189	.0189	.0189
Avg	.0290	.0291	.0291	.0287	.0287	.0291	.0299



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 403 / 33KV OUTGOING KORCHI

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 33 /  
INCOMING(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.3014	1.358	1.1883	.2829	.2263	.7282
2	1.2323	1.3014	1.358	1.1883	.2829	.2263	.679
3	1.2449	1.3014	1.3014	1.1763	.2829	.2263	.679
4	1.2449	1.358	1.3014	1.1763	.2829	.1132	.679
5	1.3443	1.4712	1.358	1.3014	.5093	.1698	.7682
6	1.6244	1.6409	1.6975	1.5123	.2829	.2263	1.0082
7	1.5684	1.6975	1.6975	1.5684		.2829	1.0185
8	1.4712	1.2449	1.5278	1.5844		.2829	.9619
9	1.358	1.4712	1.4146	1.4146	.3961	.5093	.7922
10	1.3014	1.4712	1.2883	1.3014	.3961	.7922	.9054
11	1.3014	1.1317	1.1883	1.358	.5093	.7842	.9054
12	1.2449	1.3014	1.3443	1.4146	.3961	1.0185	.9054
13	1.3443	1.2449	1.4003	1.358	.3961	1.0642	.9619
14	1.4146	1.1317	1.5278	1.4146	.3961	1.0082	.3961
15	1.1883	1.3014	1.5278		.3361	1.0185	.3961
16	1.1763	1.3014	1.2449	.1132	.3395	.9619	.5093
17	1.3014	1.3014	1.5278	.1132		1.0751	1.0751
18	1.6409	1.9239	1.8107	.1132		1.5278	1.5278
19	2.4897	2.3765	2.4897	.4527		1.9239	2.2405
20	2.3765	2.3765	2.3525	.5658		1.9805	2.1502
21	2.037	1.9753	1.9805	.4527	.3395	1.6409	1.6975
22	1.5844	1.6409	1.5278	.3961		1.0751	1.4003
23	1.358	1.358	1.3443	.2829	.2829	.8488	1.1883
24	1.2449	1.358	1.358	1.2449	.2829	.2263	.8488
Max	2.4897	2.3765	2.4897	1.5844	.5093	1.9805	2.2405
Min	1.1763	1.1317	1.1883	.1132	.2829	.1132	.3961
Avg	1.4719	1.4993	1.5386	.9866	.3526	.8004	1.0176

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 201 / 11 KV Keshori  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5775	1.4918	1.5089	.6203	.7209	.503
2	1.3717	1.5775	1.4746	1.4403	.6203	.7042	.4862
3	1.3717	1.5604	1.4746	1.4746	.6371	.7042	.4862
4	1.3717	1.5604	1.4918	1.5089	.6371	.6874	.4862
5	1.406	1.5777	1.5089	1.5432	.6539	.7122	.4862
6	1.406	1.6289	1.5432	1.6804	.7042	.7545	.5533
7	1.5775	1.7147	1.6804	1.7833	.7377	.7377	.5868
8	1.7147	1.8519	1.8861	1.9033	.8886	.7291	.7042
9	1.7318	2.0062	1.8861	1.9376	.9724	.6874	.7545
10	1.7661	2.0576	1.9204	1.9951	1.0059	.6874	.7712
11	1.7833	1.9547	1.9376	1.8778	1.0562	.6539	.8048
12	1.869	1.989	2.0062	1.9616	1.0395	.6539	.788
13	1.9204	1.9719	2.0576	1.9281	1.0562	.6539	.7712
14	1.8519	1.989	2.1091	1.7939	1.0227	.6874	.8886
15	1.9033	1.9719	2.0062		.9724	.6874	.8718
16	1.8519	1.9547	2.0405		1.0059	.7377	.9221
17	1.9033	1.9547	1.9547		.9389	.6706	.9221
18	1.9033	1.869	1.9547	.2012	.9835	.7122	1.0227
19	1.8519	1.9033	1.9719	.9221	1.0898	.8309	1.0898
20	1.7661	1.8519	1.8861	.8383	1.0059	.763	1.0562
21	1.6632	1.7147	1.7833	.8383	.8718	.6613	.9724
22	1.6118	1.5947	1.7147	.6539	.8048	.6104	.8886
23	1.5947	1.5261	1.6804	.6371	.7545	.5087	.8383
24	1.3717	1.5947	1.5089	1.6461	.6203	.7042	.5087
Max	1.9204	2.0576	2.1091	1.9951	1.0898	.8309	1.0898
Min	1.3717	1.5261	1.4746	.2012	.6203	.5087	.4862
Avg	1.6639	1.7897	1.7904	1.4321	.8625	.6942	.7568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 202 / 11 KV Mahagaon Feeder From SHEDDABLE RURAL  
33k Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.1187	.1017	.0678	.2883		.1526
2	.0848	.1187	.1017	.0678	.2713		.1526
3	.0848	.1187	.1017	.0678	.2713		.1357
4	.0848	.1187	.1017	.0678	.3052		.1357
5	.0848	.1187	.1187	.0678	.3052		.1526
6	.1017	.1187	.1187	.0848	.3222		.1865
7	.1017	.1187	.1187	.0848	.3222	.3052	.2374
8	.1187	.1357	.1187	.0848	.407	.39	.2204
9	.1357	.1696	.1017	.1017	.4917	.4578	
10	.1357	.1696	.1017	.1017	.4748	.4409	.4239
11	.1696	.1526	.1017	.1017	1.5091	.4578	.4578
12	.1696	.1696	.0509	.1696	.4917	.4239	.4917
13	.1696	.1865	.0509	.1696	.4917	.39	.0678
14	.1696	.1865	.0509	.1357	.4748	.39	.1017
15	.1696	.1696	.0509		.4917	.407	.1017
16	.1865	.1696	.0509		.4748	.407	.1357
17	.1696	.1696	.0848	.1017	.4578	.407	.1526
18	.1696	.1357	.1187	.1696	.5256	.4239	.1357
19	.1526	.1357	.1017	.1017	.5765	.5087	.1357
20	.1357	.1357	.1017		.5087	.4748	.1187
21	.1357	.1017	.1017	.2713	.4748	.4748	.1017
22	.1357	.1017	.1357	.2713		.3561	.1017
23	.1357	.1017	.1017	.3052		.2035	.0848
24	.0848	.1187	.1017	.0848	.2883		.1526
Max	.1865	.1865	.1357	.3052	1.5091	.5087	.4917
Min	.0848	.1017	.0509	.0678	.2713	.2035	.0678
Avg	.1321	.1392	.0954	.1276	.4648	.4070	.1799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 203 / 11 KV Bondgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5316	.5596	.5426	
2	.5316	.5316	.5596	.5087	
3	.5316	.5144	.5596	.5426	
4	.5316	.5144	.5596	.5596	
5	.5487	.5144	.5935	.5596	
6	.5487	.5316	.5935	.5765	
7	.583	.5658	.6952	.6104	
8	.6516	.6173	.763	.6783	
9	.6516	.7202	.7969	.7122	
10	.6859	.703	.6783	.763	
11	.6687	.6613	.7202	.78	
12	.6173	.6952	.583	.7969	
13	.6859		.5487	.7969	
14			.6274	.78	.2622
15			.6443		.3113
16			.6104		.3277
17			.6783		.3277
18	.6859	.6952	.7202		.3932
19	.7202	.7122	.78		.5407
20	.6687	.6952	.6783		.4915
21	.6001	.6274	.6443		.4752
22	.5658	.5765	.5935		.4424
23	.5487	.5596	.5765		.4424
24	.5487	.5316	.5596	.5596	
Max	.7202	.7202	.7969	.7969	.5407
Min	.5316	.5144	.5487	.5087	.2622
Avg	.6053	.6052	.6385	.6511	.4014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 201 / 11 KV BHIVKHIDKI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.7202	.7796	.6344	.3467		.4572
2	.4908	.6952	.788	.631	.3467		.4477
3	.4908	.7202	.788	.6485	.3467		.4477
4	.4908	.7202	.7796	.6344	.3641		.4477
5	.5434	.7282	.763	.6516	.3641		.4733
6	.5721	.7975	.7773	.7042	.4207		.4973
7	.703	.8764	.9465	.8453	.4733	.1463	.583
8	.7888	.8573	1.0631	.8139	.4334	.4477	.6135
9	.823	.8648	.9709	.8848	.4801	.5258	.6173
10	.8939	.9221	1.0802		.4752	.5658	.5868
11	.9214	.9012	1.0004	.8619	.2401	.6173	.6133
12	1.0136	.852	.9326	1.0159	.2774	.5959	.6371
13	.9922	.9122	1.0056	.9779		.5959	.6796
14	.9036	.8962	1.046	1.0059	.5434	.5434	.663
15	.9671	.8684	1.046		.5201	.3258	.6796
16	1.0277		1.0631		.5658	.6556	.6718
17	1.0229	.9339	.9774		.583	.639	.7293
18	.9389	1.0111	.8848		.6836	.6415	.7969
19	1.1096	1.0867	1.0099	.2865	.823	.8413	.9412
20	.9945	1.0277	.9362	.3326	.7059	.7783	.8859
21	.8916	.9694	.8238	.2926	.5373	.6878	.7973
22	.7888	.8775	.7362	.4024		.5138	.724
23	.7545	.8238	.6687	.3856		.4607	.6556
24	.4854	.7202	.8059	.6516	.3641		.4572
Max	1.1096	1.0867	1.0802	1.0159	.823	.8413	.9412
Min	.4854	.6952	.6687	.2865	.2401	.1463	.4477
Avg	.7958	.8601	.9030	.6664	.4712	.5636	.6293

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 203 / 11 KV NAVEGAON/BANDH  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.4298	.4119	.4298	.2195	.2772	.3395
2	.5373	.4119	.4119	.4298	.2195	.2772	.3326
3	.5373	.4119	.4075	.443	.2195	.2772	.3511
4	.5194	.4119	.4075	.443	.2402	.2743	.3475
5	.5373	.4344	.4298	.443	.2402	.2801	.3475
6	.5731	.5121	.5138	.4908	.2801	.3142	.394
7	.5083	.567	.5731	.4908	.3921	.4024	.4835
8	.5895	.6154	.6485	.6173	.4251	.3982	.5552
9	.6241	.6089	.6588	.703	.4572	.567	.6135
10	.7888	.6733	.8149		.39	.3921	.4908
11	.7973	.5487	.7888	.7186	.5144	.4294	.6268
12	.8328	.4973	.7888	.7455	.4854	.3658	.543
13	.9134	.4359	.631	.7186		.3658	.4755
14	.8238	.3403	.7282	.591	.5138	.3326	.3292
15	.7973	.4207	.6762		.631	.3696	.4344
16	.8596		.7455		.5721	.2614	.5973
17	.8596	.5658	.7545		.4801	.4588	.4656
18	.5895	.6588	.6859		.4382	.5373	.4344
19	.7207	.6878	.6878	.4763	.5415	.7655	.5975
20	.6838	.6979	.6154	.4763	.5359	.6722	.5359
21	.6036	.5784	.5493			.567	.4668
22	.4938	.4835	.4938	.2957		.4477	.4481
23	.4706	.4298	.439	.2378	.2987	.4298	.3801
24	.591	.4344	.4075	.394	.2195	.2987	.3206
Max	.9134	.6979	.8149	.7455	.631	.7655	.6268
Min	.4706	.3403	.4075	.2378	.2195	.2614	.3206
Avg	.6576	.5155	.5946	.5080	.3959	.4067	.4546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 201 / 11KV ARJUNI MOR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.3921	.4066	.3142		.2561
2	.2601	.3174	.3734	.3881	.2772		.2614
3	.2774	.3174	.3734	.3696	.2772		.2614
4	.2774	.3174	.3547	.3696	.2957		.2614
5	.3174	.3547	.3921	.3881	.3326		.2801
6	.3361	.4108	.5041	.4251	.3326		.3109
7	.3921	.4668	.4854	.462	.3511		.3696
8	.4108	.5601	.5228	.4805	.4251	.499	.4251
9	.4508	.5415	.5228	.4805	.4251	.5175	.4294
10	.5975	.5975	.6908	.5359	.4251	.4733	.5175
11	.5601	.6908	.7207	.5729	.4251	.4854	.5788
12	.5788	.6908	.6653	.5544	.3696	.4805	.4854
13	.6535	.6722	.6838	.4805	.3511	.3696	.3547
14	.6161	.6535	.6468	.462	.3511	.3475	.3361
15	.5975	.6722	.5544		.3511	.3658	.3361
16	.5788	.5228	.6468	.462	.3881	.4207	.4294
17	.6908	.7282	.5729	.3696	.4066		.4668
18	.5788	.5788	.6283	.499	.499	.4755	.4294
19	.6535	.6722	.6653	.5544	.5544	.5914	.5601
20	.5975	.6535	.5914	.499	.5359	.5304	.5601
21	.5415	.5601	.5359	.4251		.462	.4854
22	.4668	.4668	.462	.3326		.3841	.4108
23	.3921	.4108	.4066	.3326	.3142	.2926	.3734
24	.2987	.3734	.3921	.4066	.3142	.2772	.2743
Max	.6908	.7282	.7207	.5729	.5544	.5914	.5788
Min	.2601	.3174	.3547	.3326	.2772	.2772	.2561
Avg	.4760	.5236	.5327	.4459	.3780	.4358	.3939

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 202 / 11 KV Gothangaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3688	.3353	.2949	.213	.213	.2294
2	.3185	.3856	.3353	.2785	.2294	.1966	.2294
3	.3185	.4024	.3353	.2785	.2294	.1966	.213
4	.3353	.3856	.3018	.3113	.2294	.1966	.2294
5	.3521	.4191	.3521	.3277	.2458	.213	.2458
6	.3856	.4191	.3856	.3277	.2458	.2458	.2622
7	.3688	.4191	.3856	.3605	.2622	.2622	.2949
8	.3856	.4359	.4191	.426	.2949	.2785	.3277
9	.4191	.4191	.4359	.426	.2949	.2622	.3441
10	.503	.4527	.4862	.426	.2949	.2622	.4424
11	.4359	.4359	.4752	.3277	.2458	.285	.4096
12	.4191	.4862	.4915	.3113	.213	.3113	.3932
13	.4191	.3688	.4424	.3113	.2294	.3113	.3605
14	.4191	.4694	.4424	.3113	.1638	.2785	.3768
15	.4359	.503	.4588		.2785	.3277	.3605
16	.4191	.4694	.4588		.2949	.3441	.4096
17	.3856	.4191	.4096	.0328	.213	.3277	.3605
18	.503	.4694	.4096	.3605	.3768	.426	.4752
19	.57	.57	.4915	.3932	.4424	.4424	.5243
20	.57	.5365	.4588	.3605	.4096	.4096	.4915
21	.4862	.4191	.426	.3113	.2949	.3441	.4424
22	.4527	.3856	.3441	.2458		.2949	.3605
23	.4191	.3521	.3113	.213	.2458	.2622	.3113
24	.3353	.3856	.3353	.2949	.213	.1966	
Max	.57	.57	.4915	.426	.4424	.4424	.5243
Min	.3185	.3521	.3018	.0328	.1638	.1966	.213
Avg	.4163	.4324	.4053	.3150	.2679	.2870	.3519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 203 / 11 KV Sangadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.5735	.8356	.852	.3277	.1638	
2	.4915	.5243	.8192	.852	.3605	.1638	
3	.4752	.5407	.8192	.8356	.4096	.1638	
4	.4752	.5407	.8029	.852	.4096	.1638	
5	.4915	.5898	.852	.852	.4424	.1966	
6	.5407	.6554	.9339	.8356	.4096	.213	
7		.7537	.7537	.8029		.213	.2949
8	.7537	.852	.8356	.8684	.1966		.3932
9	.8356	.8192	.852	.9831	.1802	.3932	.6226
10	.9012	.9012	.852	.9339	.2458	.3932	.5898
11	.9995	1.0159	.9012	1.0159	.2949	.4191	.639
12	.9995	.9831	.852	.9831	.3932	.4424	.6718
13	.9995	.9995	.8848	1.0159	.3932	.4752	.6718
14	.9831	.9175	.8848	.8848	.4424	.4096	.639
15	.9995	.9012	.9012		.4096		.6718
16	.8029	.8684	.8684		.4096	.2785	.5735
17	.8848	.8684	.8684	.1311	.3605	.5079	.4096
18	.9012	.9175	.9339	.2458	.5243	.5735	.6718
19	.9831	.9995	1.0322	.4424	.5898	.6554	.7865
20	.9175	.9995	.9667	.4915	.5243	.5735	.7045
21	.8029	.9339	1.0159	.3932		.4588	.6226
22	.6882	.8848	.852	.3277			.4915
23	.6226	.8192	.8192	.3277	.1638		.4588
24	.5079	.5898	.8356	.8356	.3113	.1638	
Max	.9995	1.0159	1.0322	1.0159	.5898	.6554	.7865
Min	.4752	.5243	.7537	.1311	.1638	.1638	.2949
Avg	.7630	.8104	.8739	.7165	.3714	.3511	.5831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 204 / 11 KV Mahagaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.0867	.1214	.1052	.0876	.0701	.0701
2	.1214	.0867	.1214	.1052	.0876	.0701	.0701
3	.104	.0867	.104	.1052	.0701	.0701	.0701
4	.1214	.104	.104	.1227	.0701	.0701	.0876
5	.1387	.1214	.1214	.1402	.0876	.0876	.0876
6	.1387	.156	.1387	.1402	.0876	.0876	.1052
7	.1387	.1387	.156	.1578	.0876	.1052	.1052
8	.1387	.1387	.1734	.1402	.1052	.1052	.1052
9	.156	.104	.1734	.1578	.1052	.1402	.1052
10	.1387	.1214	.104	.1227	.0876	.1402	.1052
11	.1214	.1214	.1227	.1753	.0876	.0876	.1227
12	.104	.1214	.1402	.1578	.0876	.1052	.0701
13	.1214	.1387	.1402	.1578	.0876	.0701	.0876
14	.1387	.1387	.1402	.1402	.0876	.0701	.0876
15	.1387	.1387	.1402		.1052	.0876	.0876
16	.1214	.1387	.1402	.0526	.1052	.1402	.0701
17	.156	.1387	.1402	.0526	.1227	.1227	.0701
18	.1734	.1907	.2279	.1578	.1928	.1578	.1578
19	.2774	.2601	.298	.2103	.2279	.2454	.2454
20	.2427	.2427	.2629	.1928	.1928	.2103	.2103
21	.1907	.1734	.2279	.1402	.1052	.1402	.1578
22	.1387	.1387	.1578	.0876		.1227	.1227
23	.1214	.1214	.1402	.0876	.0701	.0876	.0876
24	.1387	.104	.104	.1227	.0876	.0701	.0876
Max	.2774	.2601	.298	.2103	.2279	.2454	.2454
Min	.104	.0867	.104	.0526	.0701	.0701	.0701
Avg	.1467	.1380	.1542	.1318	.1059	.111	.1074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 205 / 11 KV SANGADI AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1235	.128	.08		
2			.1235	.144	.096		
3			.1235	.144	.112		
4			.1235	.16	.112		
5			.1389	.16	.08		
6			.1389	.16	.064		
8	.1235				.064		.0753
9	.1235				.112	.064	.0892
10	.1235				.112	.1562	.0762
11	.1389				.064	.0781	.112
12	.1543				.064	.0781	.128
13	.1389				.064	.0762	.128
14	.1389				.064	.0617	.112
15	.1389				.064		.112
21		.0772	.096	.064			
22		.0926	.096	.08			
23		.0926	.112	.08			
24			.1235	.128	.08		
Max	.1543	.0926	.1389	.16	.112	.1562	.128
Min	.1235	.0772	.096	.064	.064	.0617	.0753
Avg	.1351	.0875	.1199	.1248	.0821	.0857	.1041

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314031 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0736	.0754	.0736	.0811	.0641	.0622	.0698
2	.0698	.0754	.0684	.083	.0604	.0622	.0679
3	.0736	.0736	.0728	.083	.0622		.0698
4	.0736	.0717	.083	.083	.0566		.0736
5	.0717	.0773	.0868	.0868	.0717		.0754
6	.0905	.0962	.1151	.0905	.0811	.0981	.0792
7	.1056	.1019	.1139	.0981	.083	.1075	.0886
8	.0924	.0943	.0981	.1014	.0981	.0943	.0869
9	.0977	.1075	.1014	.1014	.0905		.0915
10	.0878	.0931	.0939	.1024	.0728	.1046	.0717
11	.0789	.0868	.0981	.0815	.0796	.0832	.0554
12	.0698	.1061	.1057	.0867	.076	.0796	.0695
13	.0746	.078	.0798	.0838	.0786	.0673	.067
14	.0832	.0823	.0916	.0806	.0766	.0698	.0698
15	.0754	.0744	.0944		.0713	.0716	.0649
16	.0838	.0896	.1061		.0771	.0776	.085
17	.0988	.0975	.1149		.0931	.0911	.072
18	.1146	.1382	.1587	.146	.1283	.1301	.1288
19	.2018	.1905	.198	.1811	.1773	.1848	.1867
20	.1792	.183	.1716	.1566	.1641	.1603	.1698
21	.1433	.1433	.1396	.1169	.1	.1207	.1452
22	.1037	.1169	.1094	.083	.0641	.0924	.1019
23	.0868	.0943	.0924	.0679	.0679	.0811	.0792
24	.084	.0849	.0905	.0868	.0641	.066	.0736
Max	.2018	.1905	.198	.1811	.1773	.1848	.1867
Min	.0698	.0717	.0684	.0679	.0566	.0622	.0554
Avg	.0964	.1013	.1066	.0991	.0858	.0952	.0893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314031 / 33/11 KV MAHAGAON

Feeder No / Name : 202 / 11 KV KHAMKHURA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1452	.1608	.1811	.181	.1386		.1158
2	.1433	.1589	.1774	.1846	.1405		.1139
3	.1396	.1568	.1774	.1846	.1344		.1158
4	.132	.1718	.1975	.1828	.1438		.1195
5	.1452	.1792	.2012	.1902	.1494		.1307
6	.1811	.1999	.2353	.2181	.1867		.1415
7	.2377	.2595	.2846	.257	.2315	.1218	.1773
8	.207	.2772	.2999	.2668	.2402	.1183	.1664
9	.2414	.2733		.2579	.2506	.1646	.1608
10	.2652	.3152	.3052	.3083	.2244	.2006	.184
11	.2664	.28	.3052	.3142	.2389	.2661	.1753
12	.28	.1991	.3256	.3256	.2262	.2221	.1612
13	.2549	.3167	.3155	.3152	.2641	.2126	.1486
14	.2687	.2658	.2984	.2693	.2624	.1481	.1612
15	.2699	.2516	.2641		.2481	.1719	.1811
16	.2548	.2666	.3137		.2268	.1593	.1522
17	.2427	.2401	.326	.1998	.2335	.1626	.1916
18	.3277	.329	.3621	.2913	.2838	.2689	.2278
19	.381	.4112	.3923	.3603	.332	.3188	.3206
20	.3603	.3885	.3621	.3056	.3074	.2829	.2905
21	.298	.3342	.3025	.2414	.2037	.2112	.232
22	.2207	.2527	.2365	.1774		.1622	.1718
23	.1738	.2063	.1939	.1515		.1358	.1419
24	.1679	.1646	.1959	.181	.1423		.1232
Max	.381	.4112	.3923	.3603	.332	.3188	.3206
Min	.132	.1568	.1774	.1515	.1344	.1183	.1139
Avg	.2335	.2525	.2719	.2438	.2186	.1958	.1710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314031 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV BUTAI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1339	.1425	.1526	.1606	.0396	.1087	.0688
2	.1134	.1409	.1492	.1619	.0415	.1192	.067
3	.1198	.1344	.1526	.1619	.0377	.1006	.0688
4	.1182	.1392	.1715	.1636	.0392	.104	.0724
5	.143	.1594	.1641	.1724	.0523	.1262	.0878
6	.1508	.1938	.1924	.1972	.0728	.1445	.1053
7	.1526	.1956	.1827	.2122	.0758	.1682	.1289
8	.1734	.2481	.2086	.2112	.075	.1332	.1343
9	.2105	.2327	.2445	.231	.0752	.1227	.116
10	.1959	.2401	.2241	.208	.0589	.1006	.1215
11	.2144	.2353	.2225	.2281	.1293	.1061	.1392
12	.1968	.2605	.2419	.2346	.1524	.0746	.1279
13		.2251	.2623	.2515	.1163	.0922	.1328
14		.2058	.2467	.2419	.1196	.0848	.128
15		.214	.2286		.1472	.0972	.136
16		.2015	.2152		.1684	.1107	.1265
17		.2121	.2433	.1263	.1457	.104	.1392
18	.2347	.2154	.2204		.2121	.122	.2112
19	.2629	.2914	.2524	.1245	.24	.1736	.21
20	.2289	.2641	.2323	.1094	.2077	.1643	.197
21	.1962	.2366	.2058	.0811	.1577	.128	.1718
22	.1603	.1869	.1811	.0547	.1266	.0988	.1357
23	.1469	.1619	.1724	.0504	.1122	.0776	.1174
24	.1286	.1406	.1715	.1704	.0434	.1069	.0724
Max	.2629	.2914	.2623	.2515	.24	.1736	.2112
Min	.1134	.1344	.1492	.0504	.0377	.0746	.067
Avg	.1727	.2032	.2058	.1692	.1103	.1154	.1257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA SUB-STATION

Feeder No / Name : 202 / 11KV SADAK ARJUNI FEEDER SHEDDABLE RURAL  
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3978	.3561	.3545			
2	.2572	.3978	.3561	.3521			
3	.0257	.3978	.3561	.3353			
4	.2601	.4024	.3688	.3353			
5	.2622	.4409	.3688	.3521			
6	.2949	.5144	.443	.4115			
7	.4252	.5487	.5434	.5201			
8	.4207	.5784	.5596	.5609		.2667	
9	.4915	.6443	.547	.5571		.2667	
10	.5138	.5668	.5121	.5898	.1715	.1715	
11	.5344	.5898	.5304	.6783	.2286	.2303	.2543
12	.5079	.5898	.5243	.6241	.2033	.2286	
13	.57	.5571	.4973	.5761		.2477	.823
14		.5668	.5079			.2667	.7682
15	.3163	.5868	.4359			.2667	.5895
16	.5506	.6226	.5344		.2126	.2477	.7762
17	.5898	.6062	.5243			.3048	.2328
18	.5898	.57	.5256		.2667	.3048	.2477
19	.5609	.5973	.5792		.3429	.3429	.3429
20	.5201	.5552	.5316		.3048	.3239	.3048
21	.5258	.4835	.4681		.2286	.2667	.2858
22	.4424	.39	.3932		.2286		.2667
23	.3978	.39	.3768		.1905		.2286
24	.2713	.3978	.3856	.3688		.1715	
Max	.5898	.6443	.5792	.6783	.3429	.3429	.823
Min	.0257	.39	.3561	.3353	.1715	.1715	.2286
Avg	.4174	.5163	.4677	.4726	.2378	.2605	.4267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA SUB-STATION

Feeder No / Name : 203 / 11KV PANDHRI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5761	.7655	.7316	.6733		.4988	
2	.5761	.7655	.7499	.6733		.5571	
3	.5761	.7282	.7682	.6733		.5636	
4	.5761	.7207	.7316	.6733		.5636	
5	.6226	.7316	.8048	.6762		.6241	
6	.6962	.7865	.9709	.8238		.7282	
7	.8413	.9149	1.0669	.9231		.7499	
8	.8596	.9694	1.0098	1.0059		.7499	
9	.9907	.9694	.9054	1.0288		.6613	.2743
10	.9145	1.0479	.8676	1.0479	.3048	.6081	.6401
11	.9335	1.086	.8402	1.0185	.5716	.5075	.4868
12	.9907	.9526	.7499	.9522	.6348	1.39	
13	.9526	1.0082	.8589	.924	.6535	1.0426	.5304
14	.9896	.9054	.8954			.5213	.5596
15	.9709	.9896	.8551			.571	
16	.9717	.8886	.9522		.6036	.6001	.5548
17	1.0098	.9335	.9896			.6173	.5658
18	1.1241	1.086	1.0751		.8328	.7042	.6171
19	1.2826	1.3014	1.2382		1.0208	.9389	.9389
20	1.1949	1.226	1.1088		.9774	.8421	.8642
21	1.0059	.9896	.9412		.7468	.7099	1.3546
22	.7888	.8413	.8145		.7023		.6722
23	.7011	.7499	.6859		.5898		.5601
24	.7049	.6836	.7316	.6588		.447	
Max	1.2826	1.3014	1.2382	1.0479	1.0208	1.39	1.3546
Min	.5761	.6836	.6859	.6588	.3048	.447	.2743
Avg	.8688	.9184	.8893	.8395	.6944	.6908	.6630



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 201 / 11KV KOKANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3988	.547	.5228	.5281	.1802	.0162	
2	.3944	.5281	.5281	.5281	.218	.016	
3	.3601	.5281	.5041	.5093	.176	.016	
4	.3641	.5281	.5041	.5281	.1638	.0164	
5	.3814	.547	.5041	.547	.1593	.0164	
6	.4207	.547	.547	.5847	.1905	.0033	
7	.4854	.6668	.6287	.6722	.1905	.0177	
8	.5658	.6805	.679	.6979		.0177	.1311
9	.6478	.7343	.6979	.7167	.4049	.0177	.2281
10	.6535	.8316	.7282	.7733	.2347	.2629	.2058
11	.7095	.9055	.8488	.7842	.1928	.2683	.2281
12	.8589	.9511	.8865	.7468	.2054	.2601	.2441
13	.8413	.9593	.8686	.7762	.2138		.2096
14	.823	.9328	.8316		.2054	.1269	.2281
15	.8316	.8215	.8589		.2235	.1158	.2241
16	.8402	.8501	.7947		.2016	.1128	
17	.7762	.8029	.7207		.2263	.1113	.3241
18	.7282	.7095	.679	.0953	.2905	.1113	.407
19	.743	.679	.679	.3429		.241	.5144
20	.7049	.6413	.6413	.2848	.3361	.2279	.4862
21	.6224	.6036	.6036		.2515	.2191	.4096
22	.5658	.5281	.5658	.176			.3593
23	.5525	.4904	.547	.1448	.0162		.3395
24	.3988	.547	.5281	.547	.1802	.0162	
Max	.8589	.9593	.8865	.7842	.4049	.2683	.5144
Min	.3601	.4904	.5041	.0953	.0162	.0033	.1311
Avg	.6112	.6900	.6624	.5254	.2124	.1053	.3026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 202 / 11KV TIDKA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1183	.1623	.1315	.1372	.0328	.0372	.0572
2	.1183	.1623	.1315	.1372	.0328	.0343	.0572
3	.1183	.144	.1315	.1353	.0328	.0343	.0572
4	.1183	.144	.1315	.1353	.0328	.0343	.0572
5	.1183	.1532	.1315	.1353	.0328	.0349	.0572
6	.1315	.1532	.1315	.1353	.0328	.0492	.0572
7	.1677	.1894	.1646	.2029	.0246	.0819	.0714
8	.1858	.2195	.1894	.1947	.0328	.0655	.0572
9	.2229	.2606	.1783	.2332	.06	.0572	.0572
10	.2494	.2572	.2029	.3018	.061	.0714	.0381
11	.2526	.2972	.2134	.2881	.0472	.041	.0434
12	.2751	.2435	.2469	.2881	.0472	.06	.0412
13	.2743	.2679	.23	.2743	.0572	.0381	.0476
14	.2705	.2397	.2435		.0429	.0543	.0389
15	.2705	.2256	.2435	.0975	.0429	.1	.0572
16	.2743	.2397	.2462	.0743	.0705	.0857	.0442
17	.2469	.2397	.2202	.061	.0556	.0857	.061
18	.2225	.1894	.1734	.061	.0572	.0714	.0572
19	.2143	.1715	.16	.061	.0819	.0983	.0819
20	.192	.1715	.1578	.061	.0819	.0983	.0819
21	.1783	.1429	.1509	.0488	.061	.0819	.0819
22	.1734	.1429	.1467	.0488	.0655	.0655	.0655
23	.16	.1429	.1353	.0488	.0572	.0655	.0655
24		.16	.1315	.1372	.0328	.0377	.0572
Max	.2751	.2972	.2469	.3018	.0819	.1	.0819
Min	.1183	.1429	.1315	.0488	.0246	.0343	.0381
Avg	.1980	.1967	.1760	.1434	.0490	.0618	.0580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 203 / 11KV FUTALA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3353	.3681	.5028	.2229	.2286	.1802
2	.3077	.3353	.3361	.4578	.2229	.2241	.1802
3	.3185	.3185	.3681	.4527	.2286	.2286	.1802
4	.3185	.3077	.3521	.4862	.2058	.2286	.1802
5	.3521	.3239	.3856	.5258	.2401	.2286	.1638
6	.3856	.3239	.503	.4908	.2915	.2477	.1638
7	.4359	.4527	.5258	.5487	.2572	.2667	.1753
8	.5087	.4801		.4748	.3048	.3048	.1753
9	.5087	.4973	.5138	.4508	.2507	.2835	.1802
10	.6415	.463	.5365	.5201	.2328	.2896	.1619
11	.583	.5304	.6274	.6588	.2658	.3258	.2683
12	.6173	.5087	.6443	.6241	.218	.2743	.2561
13	.5365	.4748	.5596	.6068	.362	.2915	.2686
14	.5197	.4917	.6104		.2667	.2915	.2658
15	.5087		.6371	.2818	.3361	.3113	.2947
16	.503	.4207	.4334	.2818	.2477	.3005	.3121
17	.5868	.4458	.4382	.2155	.285	.3321	.2543
18	.5765	.6344	.6687		.3944	.3321	.2896
19	.5868	.6001	.631	.4458	.3086	.4251	.3801
20	.6024	.4908	.583	.2915	.362	.3641	.381
21	.4252	.4854	.5365	.2229	.2477	.3467	.3429
22	.4338	.5609	.503	.1886	.2858		.2534
23	.4024	.5434	.4917	.2401	.2858		.2353
24		.3601	.4641	.5258	.2229	.2155	.1802
Max	.6415	.6344	.6687	.6588	.3944	.4251	.381
Min	.3077	.3077	.3361	.1886	.2058	.2155	.1619
Avg	.4773	.4515	.5095	.4315	.2727	.2882	.2385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 202 / 11KV DUGGIPAR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3988	.5144	.3772	.4161		.2254	.5068
2	.3814	.5144	.3429	.3988		.2254	.6154
3	.3814	.4973	.3429	.3988		.2254	.6516
4	.3814	.5028	.4287	.3988		.2427	.6878
5	.3988	.5201	.4801	.3988		.2601	.7316
6	.4508	.5201	.5316	.4681		.2601	.7602
7	.5721	.6173	.6173	.5548	.463	.2947	.7796
8	.6241	.6687	.6516	.6068	.463	.3467	.8215
9	.6415	.6859	.6516	.6588	.3258	.4161	.6274
10	.6068	.7802	.6859	.6859	.4024	.4755	.6485
11	.4508	.7975	.7802	.7373	.4755	.4668	.6135
12	.7282	.7975	.6935	.7373	.5304	.373	
13	.7975	.7802	.7108	.7373		.439	.1052
14	.7282	.6762	.7282		.495	.4854	.0876
15	.6935	.7108	.7282		.5304	.4024	.0876
16	.7455	.7108	.7108		.4904	.3658	.0876
17	.7108	.6935	.6588		.5375	.4024	.3467
18	.7282	.6588	.6588		.5548	.567	.5138
19	.7455	.7282	.6762		.5201	.5601	.5014
20	.703	.6415	.6588		.4508	.6535	.4334
21	.6344	.6068	.5895		.3467	.4854	.4024
22	.583	.5375	.4854		.3294		.3086
23	.5375	.4854	.4508	.3086	.2774	.3174	.285
24	.4161	.4858	.463	.4161	.2105	.2774	.4481
Max	.7975	.7975	.7802	.7373	.5548	.6535	.8215
Min	.3814	.4854	.3429	.3086	.2105	.2254	.0876
Avg	.5850	.6305	.5876	.5282	.4355	.3812	.4805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 203 / 11KV SAWANGI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1423	.1875	.1265	.1581		.0949	.0914
2	.1423	.1875	.1265	.1423		.0949	.0934
3	.1423	.1718	.1265	.1423		.0949	.0905
4	.1423	.1718	.1265	.1423		.1265	.1086
5	.1423	.1875	.1423	.1423		.1265	.1052
6	.1581	.1875	.1739	.1581		.1265	.1267
7	.2056	.1875	.1898	.2214		.1265	.1227
8	.2214	.2343	.2214	.2372	.1372	.1265	.1187
9	.253	.25	.1423	.253		.1107	.1357
10	.2812	.2372	.2214	.253		.1372	.0857
11	.2656	.2214	.2372	.253	.1886	.1526	.0905
12	.25	.253	.2372	.253	.1698	.1696	
13	.2187	.253	.2214	.2688	.0848	.1526	.1029
14	.2187	.2056	.2214		.128	.1357	.0857
15	.2187	.1898	.2372		.1526	.1341	.0857
16	.25		.253		.1886	.1829	.0857
17	.2656		.2214			.1357	.1265
18	.2656	.2688	.2372		.1423	.1696	.1619
19	.25	.2187	.253		.1898	.1526	.1802
20	.2343	.2187	.2372		.1739	.1696	.1581
21	.2187	.1875	.2056	.0316	.0949	.1494	.1389
22	.2031	.1562	.1581	.0791	.0949		.112
23	.1875	.1562	.1581	.1017	.0949	.112	.1134
24	.1423	.1677	.1581	.1581	.0819	.0949	.0838
Max	.2812	.2688	.253	.2688	.1898	.1829	.1802
Min	.1423	.1562	.1265	.0316	.0819	.0949	.0838
Avg	.2092	.2045	.1931	.1762	.1373	.1338	.1132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 204 / 11KV CHIKHLI NEW FEEDEER SHEDDABLE RURAL  
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1947	.2591	.3269	.2286		.1303	.1463
2	.1833	.2591	.3269	.2086		.1303	.1219
3	.1947	.2591	.3269	.1947		.1303	.1524
4	.1947	.2439	.3269	.1947		.1448	.1677
5	.1974	.2591	.3121	.2027		.1448	.1677
6	.2439	.2778	.3269	.2641		.1593	.1802
7	.3269	.3704	.4012	.3269		.1593	.2103
8	.4268	.4321	.4607	.431		.2056	.2204
9	.4012	.4062	.4755	.4365		.1898	.2012
10	.4161	.3807	.4161	.3948		.1943	.1372
11	.4633	.4344	.362	.4371	.0678	.2105	.1265
12	.4633	.4572	.3909	.4371	.1017	.0671	.1265
13	.3909	.4633	.3858	.423	.0648	.0838	
14	.4054	.4254	.4287		.0943	.1097	
15	.3909	.4458	.4001		.061	.0848	
16	.4012	.4633	.3841		.0838	.0848	
17	.4012	.4778	.4054	.4515	.1086	.112	.1907
18	.3864	.4199	.3311		.1086	.1017	.2267
19	.3269	.4641	.3932		.1086	.2105	.2543
20	.3121	.4475	.3887		.0905	.2515	.2515
21	.301	.4475	.3321	.0903	.0857	.1829	.2187
22	.2743	.3812	.2824		.1543		.1738
23	.2591	.3647	.2641	.1204	.1372	.1372	.1783
24	.1974	.2494	.3269	.2462	.1	.1303	.1341
Max	.4633	.4778	.4755	.4515	.1543	.2515	.2543
Min	.1833	.2439	.2641	.0903	.061	.0671	.1219
Avg	.3230	.3787	.3657	.2993	.0976	.1459	.1793

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 205 / 11KV BAMNI KHADKI FEEDER SHEDDABLE RURAL  
Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2526	.2469	.3563	.2675		.044	.1677
2	.2494	.2469	.3239	.2743		.0587	.1677
3	.2526	.2315	.3239	.2709		.0587	.1696
4	.2526		.3563	.2526		.0734	.1696
5	.2559	.2439	.3401	.2778		.0734	.2012
6	.2846	.2656	.3563	.3048		.0734	.2035
7	.3549	.3593	.4534	.3704		.0734	.2347
8	.4218	.4999	.5344	.4687		.0867	.2543
9	.4572	.5155	.5506	.4784		.0867	.2515
10	.4967	.1907	.5693	.5281	.1638	.1174	.2515
11	.4816	.5117	.5247	.5575	.2427	.1509	.2683
12	.4816	.5792	.5182	.5575	.2195	.2204	.2683
13	.4515	.5719	.5182	.5575	.2035	.2374	
14	.4666	.5182	.4877		.1829	.2743	
15	.4816	.5117	.4877		.2012	.2915	
16	.4214	.5182	.535		.2561	.2926	.3018
17	.4725	.4938	.4938	.5575	.2279	.2543	.286
18	.4115	.4475	.4167		.2454	.2543	.3441
19	.3658	.4801	.4144		.2279	.2713	.3391
20	.3395	.4458	.3768		.2103	.2713	.3353
21	.3086	.4458	.3201			.2035	.2915
22	.2778	.3944	.3086		.0701		.2439
23	.2623	.3772	.2743		.0701	.1886	.2315
24	.2559	.2656	.3563	.2709		.0587	.1696
Max	.4967	.5792	.5693	.5575	.2561	.2926	.3441
Min	.2494	.1907	.2743	.2526	.0701	.044	.1677
Avg	.3649	.4070	.4249	.3996	.1940	.1615	.2453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 201 / 11 KV Salekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.1029	.0983	.0848		.0678	.0514
2	.0678	.1029	.0983	.0678		.0503	.0514
3	.0678	.1029	.0983	.0678		.0503	.0514
4	.0509	.12	.0983	.0509		.0509	.0514
5	.0678	.12	.0492	.0678		.0503	.0514
6	.0848	.12	.0655	.1017		.0671	.0514
7	.1187	.1372	.0983	.1357		.1174	.1029
8	.1187	.1543	.0983	.1526	.1147	.1677	.12
9	.1543	.1526	.1341	.1802	.1341	.1696	.1006
10	.1372	.1147	.1357	.1638	.12	.1526	.0678
11	.12	.0983	.1174	.1802	.1677	.1187	.0848
12	.1029	.0926	.1174	.1147	.1753	.0848	
13	.1029	.1147	.1174	.1311		.1357	.0671
14	.1029	.1147	.1174	.1475	.0848	.1187	.0838
15	.1029	.0983	.0671		.0838	.0848	.0671
16	.1029	.1147	.1341		.0848	.1017	.0848
17	.12	.1311	.1357		.0678	.0686	.0848
18	.1543	.213	.1865		.2012	.12	.1187
19	.2572	.2622	.218		.1865	.2058	.2035
20	.2401	.213	.2204		.1696	.1715	.1865
21	.1886	.213	.1677		.1006	.12	.1526
22	.1372	.1475	.1017		.0671	.1029	.1187
23	.12	.1147	.0848		.0671	.0686	.1017
24	.0678	.1029	.0983	.0848		.0671	.0514
Max	.2572	.2622	.2204	.1802	.2012	.2058	.2035
Min	.0509	.0926	.0492	.0509	.0671	.0503	.0514
Avg	.1190	.1358	.1191	.1154	.1217	.1047	.0915



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 202 / 11 KV Tirkhedi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1981	.2235	.2103	.2105	.1315	.1183	.1315
2	.1981	.2235	.1972	.1981	.1315	.1052	.1052
3	.1858	.2202	.1972	.1981	.1315	.1052	.1183
4	.1734	.2332	.1709	.1858	.1315	.1166	.1183
5	.2229	.2761	.2235	.2105	.1315	.1425	.1446
6	.2934	.3024	.2761	.2936	.1709	.1425	.1709
7	.3191	.3498	.3812	.3191	.2235	.1555	.2498
8	.3702	.4016	.4075	.4212	.3286	.2235	.2761
9	.3498	.3944	.3628	.447	.298	.3344	.2721
10	.3628	.3286	.3757	.3944	.2366	.2972	.2721
11	.3239	.3418	.3418		.2761	.3957	.2761
12	.3418	.3418	.298	.3944	.298	.3447	.2591
13	.3286	.3549	.3109	.3549	.2462	.2936	.1166
14	.3286	.3549	.285	.3549	.2721	.2808	.2103
15	.3024	.3681	.2761		.2073	.1238	.1684
16	.3286	.3155	.2721		.2462	.2229	.184
17	.3681	.3286	.2972		.2332	.2591	.1981
18	.447	.4338	.4085		.3757	.3498	.3109
19	.5653	.5521	.5258	.2761	.4793	.5053	.4733
20	.5258	.5258	.4995	.3024	.4405	.4793	.4085
21	.447	.3812	.3319	.2235	.3812	.3887	.3591
22	.3155	.3024	.3064	.184	.1166		.2848
23	.2629	.2761	.2477	.1578	.0657	.1555	.2477
24	.1981	.2366	.2235	.2105	.1446	.1166	
Max	.5653	.5521	.5258	.447	.4793	.5053	.4733
Min	.1734	.2202	.1709	.1578	.0657	.1052	.1052
Avg	.3232	.3361	.3095	.2809	.2374	.2459	.2329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 203 / 11 KV Darekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0732	.0754	.0549	.0943	.0924	.0747
2	.0732	.0732	.0754	.0549	.0943	.0739	.0754
3	.0732	.0732	.0754	.0549	.0943	.0739	.0566
4	.0549	.0732	.0754	.0549	.0943	.0739	.0566
5	.0914	.0914	.0754	.0549	.0943	.0747	.0754
6	.1097	.1097	.1132	.0732	.1132	.0914	.0739
7	.128	.1097	.132	.0914	.132	.1109	.0934
8	.1132	.128	.1132	.1097	.132	.1109	.0934
9	.128	.0914	.1063	.1132	.1097	.0914	.0732
10	.0914	.0943	.0724	.0943	.1097	.0732	.0554
11	.0914	.0754	.0914	.1132	.0739	.0732	.0549
12	.0732	.0739	.0914	.0754	.0549	.0732	.0739
13	.0732	.0566	.0914	.132	.0739	.1097	.0732
14	.0732	.0754	.0732	.132	.0732	.1097	.0739
15	.0732	.0754	.0739		.0739	.1097	.0732
16	.0754	.0754	.0924		.0739	.0914	.0554
17	.0747	.0943	.0914		.0739	.0914	.0732
18	.112	.132	.1417		.2012	.1463	.124
19	.1867	.2075	.1772		.1848	.2195	.1949
20	.1829	.1886	.1772	.1886	.1848	.2012	.2126
21	.1463	.132	.128	.132	.168	.1829	.1829
22	.128	.0943	.0732	.1132	.1109	.1307	.128
23	.1097	.0943	.0732	.0943	.1109	.0747	.1097
24	.0732	.0732	.0754	.0549	.0943	.1097	.0934
Max	.1867	.2075	.1772	.1886	.2012	.2195	.2126
Min	.0549	.0566	.0724	.0549	.0549	.0732	.0549
Avg	.1004	.0986	.0985	.0943	.1092	.1079	.0938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 204 / 11 KV Water Works  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.0532	.0532	.0267		.0503	.0532
2	.0267	.0532	.0532	.0267		.0509	.0532
3	.0267	.0532	.0532	.0267		.0509	.0532
4	.0267	.0532	.0532	.0263		.0509	.0532
5	.0556	.0532	.0709	.0417		.0503	.0709
6	.0987	.1063	.1063	.0695		.1063	.1063
7	.0987	.1063	.1063	.0846		.1187	.1063
8	.0987	.1063	.1063	.0846		.0671	.1063
9	.124	.1063	.1006	.124		.0846	.1006
10	.1063	.1063	.1017	.1063		.0987	.1017
11	.0886	.1063	.1017	.1063	.0671	.0846	.1017
12	.1063	.0354	.0503	.0532	.1006	.0846	.0509
13	.0532	.1063	.1006	.1063	.1006	.0987	.0509
14	.0886	.1063	.1017	.1417	.1187	.0846	.1017
15	.0886	.1063	.1006		.0503	.0846	.1017
16	.1075	.1063	.1006		.0509	.0846	.1063
17	.1075	.124	.0846		.1017	.1063	.0846
18	.1075	.124	.0846		.1174	.1063	.0846
19	.1063	.1063	.0846		.1017	.1063	.0846
20	.1063	.0354	.0834		.1174	.0532	.0549
21	.0532	.0354	.0267		.0838	.0532	.0267
22	.0532	.0532	.0267		.0838	.0532	.0267
23	.0532	.0532	.0267		.1017	.0532	.0263
24	.0267	.0532	.0532	.0417		.1006	.0532
Max	.124	.124	.1063	.1417	.1187	.1187	.1063
Min	.0267	.0354	.0267	.0263	.0503	.0503	.0263
Avg	.0765	.0812	.0763	.0711	.0920	.0784	.0733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 211 / 11 kv Salekasa AGP Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0328	.061	.0316			.0328
2		.0328	.061	.0316			.0328
3		.0328	.061	.0316			.0332
4		.0328	.061	.0316			.0332
5	.0373	.0492	.061	.0474			.0332
6	.0373	.0492	.0914	.0829			.0328
7	.056						.0328
8	.0949						.0328
9	.0983					.037	.0335
10	.0983				.0503		.0503
11	.1475						.0339
12	.1311						
13	.1802	.0463	.0335			.0554	.0335
14	.1966	.0305	.0503			.0648	.0339
15	.1619	.0457	.0509			.0648	
16		.061	.0503				
17		.0457	.0554				
18		.0305	.037				
19		.0457	.0554				
20		.0305	.0554				
21		.061	.0474				
22		.0457	.0554			.0328	.0373
23		.0457	.0316			.0328	
24			.061	.0316			.0328
Max	.1966	.061	.0914	.0829	.0503	.0648	.0503
Min	.0373	.0305	.0316	.0316	.0503	.0328	.0328
Avg	.1127	.0422	.0544	.0412	.0503	.0479	.0346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 205 / 11KV SAKHRITOLA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715	.1543	.1372	.1029	.12	.1029
2	.1578	.1886	.1543	.1372	.1029	.12	.1029
3	.1578	.1886	.1543	.1543	.1029	.1372	.1187
4	.1753	.2058	.1543	.1715	.1029	.1372	.1187
5	.1949	.2058	.1543	.1696	.1029	.1543	.1187
6	.2126	.2229	.1886	.2058	.1372	.1543	.1187
7	.2303	.2229	.2058	.2481	.1715	.2058	.12
8	.2303	.2572	.2058	.3012	.1886	.2401	.1543
9	.2743	.2804	.2058	.2401	.1886	.1886	.1543
10	.2058	.2401	.2058	.3086	.1696	.2058	.1387
11	.2229	.2629	.1187	.3086	.1715	.1886	.1214
12	.2572	.2658	.1886	.2743	.1543	.1715	
13	.1886	.2172	.1753	.2572	.1526	.1372	.208
14	.2229	.2353	.1928	.1886	.1357	.1886	.156
15	.2401	.2378	.2658		.1357	.1886	.1734
16	.2743	.2572	.2835		.1526	.2401	.1214
17	.2743	.2401	.2896	.1543	.2058	.1886	.156
18	.3086	.3086	.3258	.2572	.2743	.2401	.1734
19	.3944	.3601	.3721	.2743	.3258	.3429	.3467
20	.3429	.3258	.3366	.2401	.3294	.2915	.3294
21	.2743	.2743	.3012	.2058		.2229	.2774
22	.2229	.2058	.2328	.1715	.1372		.1907
23	.1715	.1543	.1612	.1029	.12		.156
24	.1402	.1715	.1543	.1463	.1029	.12	
Max	.3944	.3601	.3721	.3086	.3294	.3429	.3467
Min	.1372	.1543	.1187	.1029	.1029	.12	.1029
Avg	.2296	.2375	.2159	.2116	.1638	.1902	.1663

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 206 / 11KV SONEKHARI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.1989	.1526	.1772	.128	.1294	.0905
2	.1402	.2155	.1526	.1791	.128	.1478	.0905
3	.1595	.2155	.1543	.197	.1267	.1478	.1254
4	.2103	.2321	.1578	.2303	.1267	.1663	.1254
5	.2481	.2321	.1578	.2481	.1267	.1663	.1254
6	.2835	.2486	.2587	.2658	.1791	.1848	.1433
7	.3189	.3258	.3224	.3012	.2427	.2614	.1463
8	.2915	.362	.2915	.2865	.2054	.2402	.1867
9	.298	.3077	.2515	.3155	.3174	.2534	.0914
10	.3155	.3077	.2454	.1886	.1698	.2172	.1595
11	.333	.333	.2804	.2743	.1663	.1753	.128
12	.298	.3045	.2658	.2915	.1478	.1791	.124
13	.2486	.2715	.2507	.2915	.1463	.1612	
14	.2949	.2561	.2507	.1715	.1463	.181	
15	.2949	.2561	.2865		.1463	.181	
16	.2753	.2865	.3258		.1753	.1357	.1214
17	.3563	.3224	.3258	.1227	.1433	.1696	.156
18	.3401	.3601	.362	.2957	.2686	.2507	.197
19	.4854	.4115	.4298	.4191	.3761	.415	.4001
20	.4668	.4108	.3982	.3048	.3224	.3584	.362
21	.3734	.3258	.3224	.2096	.197	.2829	.2858
22	.2686	.2629	.2353	.1867	.1478		.1905
23	.2204	.1734	.1928	.1307	.1294		.128
24	.1578	.1989	.1526	.1991	.1307	.1294	.0905
Max	.4854	.4115	.4298	.4191	.3761	.415	.4001
Min	.1387	.1734	.1526	.1227	.1267	.1294	.0905
Avg	.2841	.2841	.2593	.2403	.1831	.2061	.1651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 207 / 11KV HETI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1214	.1143	.1448	.1075	.0739		.0934
2	.1214	.1143	.1267	.1267	.0739		.0934
3	.1402	.1334	.1254	.1267	.0739		.112
4	.1402	.1334	.1267	.1463	.0739		.112
5	.1417	.1524	.1267	.1463	.0739		.1109
6	.1595	.1524	.1646	.1646	.128		.1109
7	.1949	.1715	.2353	.1772	.1307	.1715	.1132
8	.1928	.1715	.1907	.2149	.1478	.1524	.112
9	.1715	.1715	.1715	.1772	.1463	.1524	.112
10	.1372	.1494	.1402	.1772	.1463	.1524	
11	.1187	.1494	.1402	.2481	.128	.1478	
12	.1357	.1294	.1433	.1595	.1097	.1097	
13	.1524		.1433	.1406	.1063	.1097	
14	.1334	.1463	.1629	.125	.1063	.1109	
15		.1267	.1433		.1097	.1109	
16		.1267	.1448		.1063	.1109	
17	.1524	.1448	.1433	.0747	.124	.1097	
18	.2096	.1928	.2075	.1663	.1772	.2686	
19	.3239	.2774	.2658	.2587	.2658	.2858	.2477
20	.3048	.2772	.2481	.1829	.2303	.2477	.2477
21	.2477	.2172	.1629	.1307	.1715	.1905	.1905
22	.1715	.1791	.1448	.1109			.1715
23	.1334	.1402	.1086	.1109		.1509	.1524
24	.1214	.1143	.1372	.1086	.0747		.0943
Max	.3239	.2774	.2658	.2587	.2658	.2858	.2477
Min	.1187	.1143	.1086	.0747	.0739	.1097	.0934
Avg	.1694	.1602	.1604	.1537	.1263	.1614	.1383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 208 / 11kv kawarabandh

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.4191	.5847	.4527	.2075	.547	
2	.5415	.4572	.5847	.3734	.2263	.5847	
3	.5228	.4191	.5658	.3174	.2452	.5281	
4	.5601	.4382	.6036	.3361	.2452	.4904	
5	.6161	.4572	.6036	.3547	.2452	.415	
6	.6908	.4572	.6413	.3921	.2263	.4294	
7	.5975	.4954	.6224	.4481	.2641	.5281	
8	.6602	.5716	.5658	.3734	.2452	.3584	
9	.6348	.4527	.4338	.362	.2477	.3018	.2667
10	.4854	.4715	.4527	.381	.3239	.1132	.2667
11	.5041	.3018	.5281	.6413	.7356	.132	.3239
12	.6535	.4904	.5658	.5041	.7545	.0754	.3429
13	.547	.4904	.6413	.5041	.4904	.0754	.1143
14	.4854	.4904	.2641	.1905		.1109	.2667
15	.6036	.4904	.7733		.2096	.1294	.2858
16	.7733	.4715	.7356		.6602	.2402	.3239
17	.8299	.5093	.7922		.5658	.2641	.3048
18	.7356	.3395	.8299	.081	.4904	.2829	.3429
19	.5906	.415	.5281	.1052	.5847	.381	.4572
20	.4954	.5093	.3772	.128	.5415	.3772	.3772
21	.3239	.5093	.3734	.2427	.6287	.2829	.3584
22	.2858	.5525	.3018	.1307	.6036		.3395
23	.3429	.547	.5093	.1132	.5658		.415
24	.5601	.4382	.5658	.5093	.1509	.5847	
Max	.8299	.5716	.8299	.6413	.7545	.5847	.4572
Min	.2858	.3018	.2641	.081	.1509	.0754	.1143
Avg	.5675	.4664	.5602	.3305	.4112	.3287	.3191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 209 / 11kv sonpuri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0895	.0732	.0716	.0716	.1029	.0572
2	.0895	.0895	.0549	.0716	.0537	.1075	.0572
3	.0716	.0895	.0549	.0716	.0537	.1075	.0572
4	.0716	.0895	.0566	.0716	.0537	.1075	.0572
5	.0895	.1052	.0549	.0895	.0716	.1075	.0572
6	.0895	.1227	.0914	.1448	.0886	.128	.0762
7	.1433	.1526	.1463	.1267	.1227	.1663	.1143
8	.1075	.1543	.1227	.1448	.1448	.1097	.1143
9	.1543	.1387	.124	.1227	.1848	.1267	.0819
10	.1387	.1387	.1227	.1526	.1663	.0905	
11	.1214	.104	.1227	.1715	.0905	.0905	.0857
12	.104	.0876	.1254	.12	.0709	.0724	
13	.0867	.1052	.1063	.1227	.0905	.1086	
14	.1017	.1227	.124	.1029	.1086	.0895	.12
15	.1052	.1052	.1254		.0724	.0716	.1402
16	.1227	.1029	.124	.0701	.0905	.0895	.0876
17	.1402	.1029	.1433	.0739	.1063	.0716	.096
18	.1715	.1372	.1629	.1307	.128	.1478	.1075
19	.2149	.2075	.2402	.2033	.2033	.2096	.2149
20	.2058	.1886	.2033	.1663	.2033	.2075	.197
21	.1715	.1509	.1646	.1109	.1433	.1509	.1433
22	.12	.0914	.1097	.0739	.0358	.1524	.1267
23	.12	.0914	.0895	.0732	.0895	.0566	.0905
24	.0895	.0895	.0732	.0716	.0716	.1075	.0572
Max	.2149	.2075	.2402	.2033	.2033	.2096	.2149
Min	.0716	.0876	.0549	.0701	.0358	.0566	.0572
Avg	.1217	.1191	.1173	.1112	.1048	.1158	.1019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 210 / 11KV NAVEGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.12	.1372	.1214	.0514	.1147	
2	.0791	.12	.1326	.1214	.0514	.1147	
3	.0791	.12	.1326	.1214	.0514	.1147	
4	.0949	.12	.125	.1214	.0514	.096	
5	.096	.1265	.1406	.1214	.0514	.096	
6	.1029	.1423	.1677	.1387	.0857	.1227	
7	.144	.1638	.1875	.1433	.1341	.1326	.0354
8	.144	.1423	.2012	.1402	.0895	.116	.0354
9	.1372	.1844	.1326	.1296	.0709	.104	.0343
10	.1265	.1677	.1296	.1943	.0886	.1214	.0514
11	.1265	.1844	.144	.1739	.0709	.0347	.0983
12	.1423	.1475	.1619	.1739	.0503	.0867	.1227
13	.1406	.1311	.176	.1677	.1006	.052	.1227
14	.1406	.1311	.16	.1578	.0838	.0857	.1052
15	.125	.1638	.1265		.0838	.0514	.096
16	.1802	.1475	.128				.1147
17	.1638	.1698	.1296	.0362		.0343	.0857
18	.1802	.2229	.1578	.0543	.1772	.1029	.0983
19	.2652	.2172	.2353	.1463	.1949	.1886	.1638
20	.2949	.2715	.2353	.1646	.1772	.1698	.1475
21	.1739	.2126	.197	.0914	.1341	.1075	.0655
22	.1265	.1595	.1387	.0724	.1174		.0671
23	.1107	.1372	.12	.0514	.1174		.0671
24	.12	.12	.1372	.12	.0514	.1174	
Max	.2949	.2715	.2353	.1943	.1949	.1886	.1638
Min	.0791	.12	.12	.0362	.0503	.0343	.0343
Avg	.1406	.1593	.1556	.1256	.0948	.1030	.0889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 201 / 11KV KAMTHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5434	.5935	.724	.3366	.5194	.5493
2	.5028	.5258	.583	.7164	.3366	.4908	.5316
3	.5028	.5138	.583	.6984	.3155	.4557	.5083
4	.5258	.5138	.5609	.691	.3155	.4733	.5083
5	.5609	.567	.5609	.6024	.3366	.4733	.4908
6	.5784	.6135	.6626	.8322	.3856	.5316	.5609
7	.6588	.6516	.7421	.7888	.4382	.5658	.583
8	.6935	.6783		.8402	.4382	.6344	.6173
9	.7537	.6859	.788	.7716	.4458	.6783	.6344
10	.7045	.6762	.7712	.8063	.4115	.6133	.6068
11	.6882	.6588	.7293	.8238	.4239	.6062	.6241
12	.6718	.6001	.6962	.8495	.4748	.6478	.5596
13	.6718	.5935	.7377	.823	.4475	.664	.5935
14	.5967	.5765	.7377		.4807	.5921	.6443
15	.663	.6344	.6443		.4752	.5761	.6539
16	.6036	.6241	.6783		.4588	.5693	.7377
17	.6036	.6935	.7362	.2658	.4917	.6274	.6516
18	.6783	.7628	.7796	.2835	.5658	.7373	.7011
19	.8596	.8573	.9391	.5138	.7186	.8238	.8859
20	.7701	.8402	.9134	.4075	.7522	.8238	.8505
21	.7602	.7975	.8596	.4557	.6268	.7087	.7973
22	.6697	.6935	.8145	.3856	.5792	.6733	.7087
23	.5959	.6173	.7783	.3506	.5973	.5316	.7087
24	.5144	.5609	.5935	.7602	.3544	.5373	.5316
Max	.8596	.8573	.9391	.8495	.7522	.8238	.8859
Min	.5028	.5138	.5609	.2658	.3155	.4557	.4908
Avg	.6395	.6450	.7166	.6376	.4670	.6064	.6350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 202 / 11KV RAWANWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7762	.9335	.7762	.4108	.4854	.5729
2	.7762	.7392	.9149	.7842	.3921	.4668	.6838
3	.7577	.7468	.9149	.7655	.3961	.4435	.5487
4	.7468	.7282	.8871	.7762	.415	.4805	.5121
5	.7655	.7682	.8871	.724	.4338	.499	.4938
6	.7655	.8779	.8686	.8779	.4904	.5373	.5973
7	.9055	.9694	.9145	.8238	.6602	.6089	.7011
8	1.6834	1.0029	.9671	.985	.7167	.8589	.7362
9	.9774	.964	.8589	.7712	.6401	1.2094	.6068
10	.8573	.6836	.8149	.964	.5083	1.046	.6415
11	.8059	.7202	.7716	.9156		.6274	.631
12	.7716	.7888	.8059	.8478	.5487	.6203	.631
13	.8059	.763	.7461	.7969	.5144	.57	.5316
14	.7969	.763	.78		.407	.5365	.4961
15		.8059	.6443		.4748	.5533	.2804
16	.7969	.7802	.7461		.5087	.5197	.298
17	.8916	.8764	.788		.6068	.5493	.3224
18	.8328	.985	1.0059	.2987	.7682	.7762	.8871
19	1.2883	1.0985	1.2136		1.0269	1.0269	1.1273
20	1.1763	1.182	1.1389	.4294	.9709	.9522	1.0829
21	1.1016	1.0974	1.0534	.3361	.6036		1.0082
22	.9425	1.0059	.924	.3018	.5973		
23	.8871	.9145	.8316	.2641	.3547	.5914	.7655
24	.7865	.8131	.924	.7947	.415	.3326	.5544
Max	1.6834	1.182	1.2136	.985	1.0269	1.2094	1.1273
Min	.7468	.6836	.6443	.2641	.3547	.3326	.2804
Avg	.9089	.8688	.8890	.6965	.5592	.6496	.6396

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 203 / 11KV KATI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.3012	.3012	.2835	.2715	.1949	
2	.2915	.2865	.3012	.2658	.2561	.1734	.1578
3	.298	.2774	.3012	.2629	.2561	.156	.1578
4	.298	.2774	.298	.2454	.2353	.1715	.1387
5	.3121	.3121	.2804	.2401	.2353	.1715	.1734
6	.3086	.3086	.2774	.3258	.2353	.1844	.2601
7	.3052	.285	.333	.2883	.3045	.218	.4115
8	.2515	.2984	.3185	.3052	.2835	.2155	.2229
9	.2713	.2486	.3315	.3353	.2328	.2012	.208
10	.2947	.3277	.3277	.4475	.333	.2818	.2427
11	.3086	.3149	.3812	.426	.333	.2881	.2454
12	.463	.3315	.4694	.4475	.1734	.208	.333
13	.4973	.3688	.4527	.39	.2601	.2321	.1928
14	.4409	.4191	.3856		.1886	.2458	.1734
15	.3561	.4239	.3185		.1715	.2622	.1387
16	.3601	.4287	.3856		.1696	.2458	.208
17	.4458	.4115	.3086	.3582	.2229	.2572	.208
18	.4031	.3988	.333		.2204	.3121	.2427
19	.3982	.4252	.2804		.2865	.3681	.2804
20	.3982	.362	.3189	.4163	.2835	.2629	.2804
21	.3403	.3658	.3189	.3801	.2172	.2103	.3366
22	.3544	.3658	.3224		.1612	.1949	.2804
23	.3224	.3258	.2686	.2353	.1417	.1772	.2629
24	.3086	.3189	.3224	.2686	.2715	.2149	.1772
Max	.4973	.4287	.4694	.4475	.333	.3681	.4115
Min	.2515	.2486	.2686	.2353	.1417	.156	.1387
Avg	.3472	.3410	.3307	.3290	.2394	.2270	.2319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 204 / 11KV BANTHER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4862	.4481	.4424	.4064	.1027	.2818	.2143
2	.4973	.4428	.4372	.3763	.0903	.2652	.2378
3	.4973	.4372	.421	.3963	.0892	.2785	.208
4	.5138	.4321	.4161	.3963	.1054	.3018	.2134
5	.5079	.442	.4801	.3704	.1054	.3018	.2286
6	.5243	.4572	.5281	.4938	.1337	.3479	.2968
7	.5668	.4938	.5937	.5624	.1829	.4111	.3749
8		.5468	.6226	.5937	.2286	.4744	.427
9	.5898	.6081	.5992	.583	.2949	.4858	.3521
10	.5898	.5761	.5761	.5693	.213	.3841	.3841
11	.5735	.5535	.5441	.6722	.1619	.4801	.3887
12	.6299	.5441	.5601	.664		.4374	.3725
13	.6299	.639	.4902	.5407	.2984	.3749	.1943
14	.5898	.6062	.506		.3978	.3906	.3239
15	.583	.5967	.506		.4191	.3906	.3361
16	.4801	.6036	.5441		.3018	.4001	.2458
17	.5624	.6167	.5335	.125	.3932	.2378	.2743
18	.5144	.6167	.5792	.1562	.4167	.3475	.3864
19	.6516	.6722	.6171	.2709	.5487	.4199	.4988
20	.6249	.6478	.602	.2378	.5053	.4287	.4715
21	.5864	.5735	.5498	.1635	.381	.3286	.4144
22	.5155	.5243	.4607	.1614	.3163	.2256	.3521
23	.4801	.4696	.4054	.1337	.2915	.2115	.2934
24	.503	.4641	.4588	.3858	.132	.2915	.2143
Max	.6516	.6722	.6226	.6722	.5487	.4858	.4988
Min	.4801	.4321	.4054	.125	.0892	.2115	.1943
Avg	.5521	.5422	.5197	.3933	.2656	.3541	.3210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 205 / 11KV KATANGI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0754	.0566		.0377	.0566
2	.0377	.0566	.0754	.0514		.0377	.0754
3	.0566	.0754	.0754	.0377		.0377	.0754
4	.0566	.0566	.0754	.0377		.0566	.0566
5	.0566	.0754	.0754	.0754		.0566	.0754
6	.0554	.0754	.0943	.0754		.0754	.0754
7	.0754	.0943	.1132	.0377		.0754	.0754
8	.0754	.132		.0754		.0754	.0754
9	.0732	.1132	.132	.0943		.0943	.0754
10	.132	.1886	.1132	.1509		.0943	.1132
11	.132	.2263	.2263	.2452		.0754	.1509
12	.1509	.2641	.2075	.2829		.0754	.1698
13	.1886	.2829	.2829	.2263		.0754	.1509
14		.1886	.2263		.1509	.0754	.1698
15	.132	.2829	.2263		.1509	.0754	.1886
16	.1698	.3018	.2263		.132	.0754	.1509
17	.1509	.2641	.2641		.1886	.0754	.132
18	.1509	.1509	.2263		.1698	.0754	.132
19	.0754	.1509	.1509		.1509		.0943
20	.0566	.0566	.132		.132	.0754	.0943
21	.0566	.0566	.1132		.0943	.0566	.0943
22	.0943	.0754	.0943		.0566	.0754	.0943
23	.0754	.0754	.0566		.0566	.0754	.0943
24	.0566	.0754	.0754	.0566		.0377	.0566
Max	.1886	.3018	.2829	.2829	.1886	.0943	.1886
Min	.0377	.0566	.0566	.0377	.0566	.0377	.0566
Avg	.0942	.1407	.1451	.1074	.1283	.0680	.1053

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 201 / 11KV FULCHUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5415	.5601	.5415	.4668	.5601	.4481
2	.5228	.5228	.5228	.5415	.4481	.5415	.4481
3	.4854	.5228	.5228	.5415	.4294	.5228	.4294
4	.5041	.5228	.5601	.5415	.4294	.5228	.4294
5	.5975	.5788	.5975	.5415	.4481	.5228	.4108
6	.6535	.6161	.6722	.6161	.5601	.6348	.5228
7	.8029	.7468	.7282	.6908	.6722	.6908	.7095
8	.8215	.7655	.7655	.7842	.7655	.8215	.8029
9	.8775	.9335	.8215	.9335	.8402	.8402	.7655
10	1.0082	.9149	.8775		.7842	.8589	.7117
11	1.0829	.8962	1.0456	.9522	.8962	.8775	.8589
12	1.0269	1.0082	1.0082	1.0456	1.0082	.8775	.8215
13	.9335	.8962	1.0082	.8962	.9335	.8589	.8962
14	.7468	.6722	.7282		.7468	.6161	.5975
15	.7468	.9149	.8029	.6722	.7655	.6348	.7095
16	.8962	.7655	.7282		.8589	.5788	
17	.8962	.8029	.8029	.7842	.7468	.4108	.6348
18	1.1576	.9335	.9709	.8029	.8215	.7095	.7468
19	1.0829	1.0642	1.0269	.7842	1.1203	.7282	.9335
20	.8589	.8962	.9149	.6908	.9335	.7468	.8215
21	.7655	.8402	.8775	.6535	.7468	.6535	.7655
22	.7282	.7842	.7468	.5788	.7655	.5041	.6722
23	.6535	.6722	.7095	.5415	.6908	.4854	.5975
24	.5975	.5601	.6161	.5601	.4854	.5975	.4668
Max	1.1576	1.0642	1.0456	1.0456	1.1203	.8775	.9335
Min	.4854	.5228	.5228	.5415	.4294	.4108	.4108
Avg	.7920	.7655	.7756	.6997	.7235	.6582	.6609



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 203 / 11KV ADASI  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.362	.3258	.362	.2172	.2534	
2	.2715		.3258	.362	.1991		.0362
3	.2896	.362	.3258	.362	.1991		.0362
4	.2715	.362	.3258	.362	.2172		.0362
5	.3439	.362	.3258	.362	.2172		
6	.3801	.3982	.4163	.4163	.2896		.0362
7	.4887	.4706	.4525	.4525	.2534		.0373
8	.4163	.4525	.439	.4887	.2987	.181	.0362
9	.3982	.4706	.4252	.4525	.3077	.3403	.0373
10	.3801	.4706	.3801		.2353	.3258	.3361
11	.362	.4706	.3801	.4163	.2715	.3258	.3174
12	.4525	.4344	.362	.3801	.2896	.3439	.2614
13	.4887	.3982	.3801	.3439	.2534	.2896	.2241
14	.4525	.3982	.362		.2534	.3258	.2241
15	.4525	.4163	.3801	.3077	.2353	.2534	.2896
16	.4344	.3801	.4163		.2534	.2534	.2715
17	.4344	.3982	.4163	.0362	.2534	.2715	.2715
18	.5068	.4887	.3734	.0543	.3439	.362	.362
19	.6154	.5973	.6335	.2896	.5068	.4344	.543
20	.5973	.5792	.6154	.362	.4887	.4887	.5415
21	.5249	.4887	.5249	.3077	.3801	.4344	.4525
22	.4344	.3982	.4525	.2172	.2896		.362
23	.3982	.3258	.3801	.2172	.2715	.0362	.2987
24	.3258	.362	.3258	.3801	.2172	.2534	.0362
Max	.6154	.5973	.6335	.4887	.5068	.4887	.543
Min	.2715	.3258	.3258	.0362	.1991	.0362	.0362
Avg	.4171	.4281	.4060	.3301	.2809	.3043	.2294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 204 / 11 KV Bambleshwari  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.4294	.3361	.1867	.1494	.2241	.1307
2	.2054	.4294	.3361	.1867	.1494	.2427	.168
3	.2241	.4163	.2987	.1867	.168	.2427	.1494
4	.1307	.3921	.2987	.2172	.168	.2241	.1494
5	.112	.3734	.1867	.2353	.1494	.2054	.1307
6	.0934	.3734	.2427	.2427	.1307	.168	.1307
7	.1307	.3174	.2241	.1307	.112	.168	.112
8	.1494	.2801	.2054	.0747	.1307	.1494	.112
9	.168	.2241	.2054	.112	.112	.112	.0747
10	.0934	.2241	.3547		.1867	.2427	.0747
11	.168	.2353	.4481	.2614	.2987	.2614	.168
12	.2054	.2534	.4294	.3547	.2987	.2427	.2427
13	.2801	.2054	.3547	.3174	.3547	.2427	.1867
14	.3547	.1494	.3547		.3921	.0724	.2801
15	.3734	.1307	.3361	.168	.3174	.0934	.2241
16	.3734	.1494	.3734	.3361	.3361	.056	.2614
17	.3361	.2801	.4108	.3921	.3361	.056	.3361
18	.1494	.3547	.4108	.3547	.3734	.056	.3734
19	.1307	.3361	.2801	.3921	.3921	.056	.3921
20	.1991	.3547	.2241	.2801	.3921	.056	.3921
21	.3982	.3547	.2054	.112	.168	.056	.168
22	.4108	.3174	.2054	.1494	.2054		.1867
23	.4294	.3547	.1867	.1494	.2614	.0934	.1867
24	.1867	.4481	.3361	.2054	.1494	.2054	.1307
Max	.4294	.4481	.4481	.3921	.3921	.2614	.3921
Min	.0934	.1307	.1867	.0747	.112	.056	.0747
Avg	.2295	.3077	.3019	.2293	.2388	.1533	.1984

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 205 / 11KV MAHESHWARI INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.0953	.2286	.2096	.1905	.1334
2	.1334	.1334	.0762	.2096	.2096	.2096	.1715
3	.1334	.1334	.0762	.2096	.2096	.2096	.1715
4	.1334	.1334	.0762	.2096	.2096	.1905	.1905
5	.1334	.1334	.0762	.1905	.2096	.1334	.1867
6	.1334	.1143	.0572	.1524	.2096	.0953	.2096
7	.1143	.1143	.0572	.1524	.2096	.0953	.1905
8	.1143	.1143	.0953	.1905	.1905	.2096	.1905
9	.1524	.1143	.0572	.2286	.2286	.2096	.1867
10	.1715	.1334	.0953		.2096	.2286	.2241
11	.1715	.1524	.0572		.2477	.1905	.2614
12	.1715	.1715	.0572	.2096	.2858	.1905	.2286
13	.1524	.1524	.2096	.2096	.2858	.2286	.2477
14	.1715	.1524	.2286		.2667	.1715	.2614
15	.1905	.1905	.2096	.0762	.1905	.2096	.2054
16	.1524	.2477	.1524		.2477	.2096	.2427
17	.1524	.1715	.2096	.1524	.2667	.2096	.2054
18	.1524	.1524	.2286	.2096	.2477	.1334	.2477
19	.1524	.1524	.1715	.2286	.2477	.1715	.2427
20	.1334	.1524	.2477	.2286	.1905	.1267	.2427
21	.1334	.1334	.2286	.2286	.2477	.1086	.2241
22	.1334	.1334	.2427	.2096	.2286		.2054
23	.132	.1334	.2427	.2096	.2286		.2286
24	.1334	.1307	.1334	.2286	.2096	.1905	.1334
Max	.1905	.2477	.2477	.2286	.2858	.2286	.2614
Min	.1143	.1143	.0572	.0762	.1905	.0953	.1334
Avg	.1452	.1452	.1409	.1981	.2286	.1778	.2097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 206 / 11KV Saha Industrial  
feeder Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.4481	.4854	.4108	.3921	.2241	.168
2	.1494	.4481	.4108	.4108	.4108	.1867	.1494
3	.1307	.3734	.4108	.4108	.4108	.168	.1494
4	.1307	.3174	.4294	.4108	.4668	.1886	.112
5	.1307	.2427	.3734	.3734	.4668	.2641	.1307
6	.1494	.2427	.4668	.4481	.5041	.2263	.1307
7	.168	.4108	.4854	.6722	.5228	.3395	.1307
8	.2427	.4303	.5788	.5975	.5975	.3547	.2801
9	.3361	.6161	.6161	.6908	.6348	.2263	.1867
10	.4668	.7842	.5788		.4854	.2241	.2427
11	.6161	.9335	.6908	.8029	.6161	.168	.3921
12	.8029	.8215	.6908	.8775	.6348	.1867	.3921
13	.8029	.9149	.8215	.8962	.6348	.1494	.5788
14	.7468	.9335	.7655		.6348	.1867	.4294
15	.7095	.6722	.6908	.3361	.5228	.1307	.5041
16	.6908	.7282	.6908		.7842	.112	.5041
17	.7468	.7842	.7468	.2427	.7095	.112	.5041
18	.7282	.6161	.6908	.6908	.7655	.112	.4668
19	.5601	.5415	.6722	.7468	.5041	.112	.3174
20	.4668	.4481	.6161	.5415	.4481	.0934	.2801
21	.4294	.4668	.5788	.4294	.3547	.0934	.2801
22	.5228	.4854	.6535	.5228	.4668	.112	.3174
23	.4481	.5228	.5601	.4481	.4108	.1307	.3547
24	.2241	.4572	.5228	.5228	.3547	.2987	.168
Max	.8029	.9335	.8215	.8962	.7842	.3547	.5788
Min	.1307	.2427	.3734	.2427	.3547	.0934	.112
Avg	.4396	.5683	.5928	.5468	.5306	.1833	.2987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 207 / 11KV CIVIL LINE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4108	.4294	.4108	.3547	.3734	.3361
2	.3734	.3921	.4108	.4108	.3361	.3547	.3174
3	.3734	.3734	.3921	.4108	.3361	.3734	.3077
4	.3734	.3734	.3734	.4108	.3174	.3734	.3547
5	.3734	.4108	.4108	.4108	.3547	.3921	.3921
6	.4294	.4854	.4854	.4294	.5228	.4854	.3921
7	.5228	.5601	.5041	.4854	.5788	.4668	.5228
8	.6535	.6535	.6348	.5975	.6348	.6161	.6722
9	.6908	.6348	.6161	.6535	.6908	.6908	.7095
10	.6535	.6535	.6161		.5975	.7095	.6161
11	.5788	.6348	.6348	.6348	.5415	.6722	.5601
12	.4854	.5601	.5788	.5975	.4854	.6722	.5041
13	.4854	.4668	.4668	.5601	.4108	.4294	.4108
14	.4481	.4108	.4294		.3734	.3361	
15	.3734	.3361	.3921	.2614	.2987	.2801	.3174
16	.3361	.3734	.4108	.3361	.3174	.3547	.3361
17	.4108	.4481	.4294	.6535	.3921	.3547	.3734
18	.5415	.5041	.5601	.6161	.4668	.4854	.5228
19	.6348	.6161	.6161	.6535	.6161	.5415	.6161
20	.6348	.6535	.6161	.5788	.5601	.5601	.5975
21	.5788	.6161	.5415	.5415	.5601	.4854	.5601
22	.5228	.5415	.5228	.4668	.5228	.4294	.5041
23		.4854	.4481	.3921	.4294	.3734	.4294
24	.4108	.4108	.4481	.4294	.3547	.3921	.3361
Max	.6908	.6535	.6348	.6535	.6908	.7095	.7095
Min	.3361	.3361	.3734	.2614	.2987	.2801	.3077
Avg	.4903	.5002	.4987	.4973	.4605	.4668	.4647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 201 / 11KV DASGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6268	.6805	.6447	.6697	.5731	.4382	.5373
2	.5194	.4835	.4835	.6335	.4298	.4382	.591
3	.5014	.4835	.4835	.4887	.4298	.4557	.5731
4	.5014	.4656	.4835	.4706	.4119	.4557	.4656
5	.4835	.4835	.5014	.4887	.394	.4733	.5014
6	.5731	.591	.6089	.5792	.4656	.4908	.5552
7	.6626	.5373	.5194	.5249	.6268	.4031	.591
8	.4298	.4835	.4477	.5068	.3582	.4031	.394
9	.5552	.591	.6089	.6154	.5014		.5194
10	.6089	.6626	.6268	.5792	.4477		.5552
11	.6661	.6447	.6805	.6697	.4557		.5552
12	.6836	.8238	.7011	.9593	.4908		.7164
13	.7362	.8059	.7362	.9134	.5258		.7343
14	.8238	.7522	.7011		.5784		.6805
15	.7011	.6089	.6135		.5609	.631	.4656
16	.6661	.6268	.4733		.5784	.4908	.4835
17	.6485	.6268	.6661	.2865	.0543	.5083	.5014
18	.7421	.7701	.724	.3761	.5609	.6626	.5552
19	.7522	.7343	.724	.6984	.5434	.6805	.8238
20	.6805	.6984	.6516	.7164	.5784	.6447	.6089
21	.591	.7343	.6516	.6447	.5258	.591	.6447
22	.6447	.6089	.6878	.5014	.4908	.3224	.5373
23	.6447	.5731	.5611	.4298	.4557	.4656	.5014
24	.6447	.6805	.6447	.6878	.6089	.4557	.4477
Max	.8238	.8238	.7362	.9593	.6268	.6805	.8238
Min	.4298	.4656	.4477	.2865	.0543	.3224	.394
Avg	.6286	.6313	.6094	.5924	.4853	.5006	.5641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 203 / 11KV BIRSOLA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5899	.5875	.5396	.1799	.1772	.1174
2	.6691	.5899	.5875	.5533	.1799	.1595	.1174
3	.6691	.5899	.6367	.5396	.1966	.1772	.1174
4	.6524	.6055	.6367	.5396	.1966	.1772	.1174
5	.6512	.6378	.7171	.5719	.2134	.1928	.1341
6	.7183	.7373	.8009	.5899	.1966	.1928	.1844
7	.3185	.3185	.3521	.3353	.1174	.2126	.218
8	.3521	.3353	.3185	.3521	.2793	.5371	.4927
9	.3521	.3521	.3521	.3688	.2458	.6049	.5094
10	.3521	.3856	.3521	.4359	.2458	.6565	.4771
11	.4252	.4694	.3856	.4191	.2921	.7188	.4424
12	.4607	.4359	.5138	.4694	.2921	.7081	.4759
13	.4784	.5197	.4784	.4694	.2744	.7421	.5094
14	.5316	.5197	.5138		.4338	.7259	.5094
15	.4607	.4862	.567		.4161	.7421	.5083
16	.4784	.4359	.6556		.2126	.1949	.3018
17	.4784	.4527	.443	.2012	.2303	.2126	.2347
18	.4359	.4024	.3856		.2481	.2347	.285
19	.4359	.4024	.3856	.1341	.3012	.3185	.3521
20	.4024	.3856	.3688	.1341	.3366	.3018	.3185
21	.6905	.6402	.6245	.2302	.0177	.2012	.2515
22	.6234	.6367	.5899	.2134	.1772	.1341	.2012
23	.5899	.6043	.5563	.1966	.1772	.1341	.1509
24	.7027	.5899	.5875	.5228	.1966	.1772	.1174
Max	.7183	.7373	.8009	.5899	.4338	.7421	.5094
Min	.3185	.3185	.3185	.1341	.0177	.1341	.1174
Avg	.5256	.5051	.5165	.3908	.2357	.3597	.2977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 204 / 11KV Dasgaon AGP

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.25	.1875	.2187	.1875	.0625		
2	.25	.1875	.2187	.1875	.0625		
3	.25	.1875	.2343	.1875	.0625		
4	.25	.2031	.2343	.1875	.0625		
5	.2656	.2187	.2812	.2031	.0625		
6	.2656	.2343	.2812	.1875	.0625		
8					.0781	.1296	.1406
9					.0781	.1619	.1406
10					.0781	.1781	.125
11					.0972	.2105	.1406
12					.0972	.1943	.1406
13					.0972	.2105	.1406
14					.0972	.1943	.1406
15					.0972	.2105	.1562
21	.1875	.1875	.1718				
22	.1875	.2343	.1875	.0625			
23	.1875	.2187	.1875	.0625			
24	.25	.1875	.2187	.1875	.0625		
Max	.2656	.2343	.2812	.2031	.0972	.2105	.1562
Min	.1875	.1875	.1718	.0625	.0625	.1296	.125
Avg	.2344	.2047	.2234	.1615	.0772	.1862	.1406



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 201 / 11KV KAMTHA-BIRSI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4755	.4344	.4557	.2452	.2987	.3174
2	.3326	.4755	.4119	.4382	.2075	.2772	.2957
3	.3174	.4435	.3898	.443	.2218	.2561	.2772
4	.3511	.3734	.4119	.4607	.2614	.2772	.3326
5	.4024	.4108	.4525	.4784	.2957	.3361	.3881
6	.4668	.4435	.499	.5138	.3361	.3734	
7	.5544	.5175	.5487	.5731	.3772	.5415	
8	.5434	.5853	.6036	.5194	.415	.462	
9	.5611	.6516	.6268	.7888	.439	.5281	.5249
10	.5792	.7164	.5784	.5316	.3734	.4481	.443
11	.6089	.8063		.5959	.3881	.4656	
12	.5959	.6697	.6173	.5493	.3841	.4477	.5144
13	.7796	.6241	.4801	.503	.3403	.4163	.4287
14	.5138	.5434	.6379		.3721		.4854
15	.5658	.5784	.6371		.4458		.4681
16	.5721	.6935	.6203	.3258	.4748	.4784	.4748
17	.6135	.443	.6104	.4066	.4854	.3258	.5087
18	.6626	.6447	.6733	.4481	.5304	.3921	.6268
19		.7947	.7682	.6036	.6224	.6602	.8413
20	.8059	.7468	.6539	.547	.5658	.5847	.823
21	.6952	.6653	.6335	.4481	.4715	.4668	.6516
22	.8238	.5544	.5493	.3547	.3734	.3547	.4938
23	.4908	.4572	.4784	.3174	.3174	.3361	.4344
24	.4066	.4835	.4572	.4557	.2801	.2987	.3174
Max	.8238	.8063	.7682	.7888	.6224	.6602	.8413
Min	.3174	.3734	.3898	.3174	.2075	.2561	.2772
Avg	.5485	.5749	.5554	.4890	.3843	.4103	.4824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 202 / 11KV GIROLA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.1109	.1254	.1433	.0924	.112	
2	.0914	.0934	.1063	.1254	.112	.0924	
3	.112	.0934	.1075	.1063	.112	.0924	
4	.112	.1097	.1267	.1063	.0943	.0914	
5	.1294	.128	.1463	.1417	.112	.1097	
6	.1294	.1612	.1867	.181	.1132	.1294	
7	.1753	.1753	.1991	.2126	.1307	.1478	
8	.1578	.218	.2149	.1928	.1478	.1646	
9	.2035	.1865	.1949	.2103	.1629	.1433	
10	.1907	.1943	.1734	.1772	.1646	.1433	.0914
11	.1509	.1865	.1543	.2126	.1109	.1254	
12	.1526	.2035	.156	.2103	.0943	.1227	.1063
13	.1886	.1387	.156	.1658	.0924	.124	.1086
14	.128	.1696	.1715		.1187	.1341	.1063
15	.1372	.1715	.156		.124	.1029	.1075
16	.1326	.1526	.1865		.1086	.1526	
17	.1619	.1526	.2229		.1063	.0566	.1254
18	.2035	.2454	.2172		.2195	.0377	.1448
19	.2772	.2987	.2987		.2452	.1886	.2452
20	.2378	.2801	.2614	.132	.2263	.1886	.2263
21	.1991	.2054	.2218	.1509	.1886		.1698
22	.1646	.1848	.1646	.112	.1294		.1294
23	.128	.1463	.1433	.112	.112		.1267
24	.1109	.1109	.1448	.1433	.0934	.112	
Max	.2772	.2987	.2987	.2126	.2452	.1886	.2452
Min	.0905	.0934	.1063	.1063	.0924	.0377	.0914
Avg	.1569	.1716	.1765	.1575	.1338	.1225	.1406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 203 / 11KV SIRPUR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.5765	.6401	.5735	.2103	.3277	.1867
2	.5087	.5533	.6316	.5636	.1791	.3077	.1663
3	.4694	.4752	.6154	.5636	.1949	.2949	.1663
4	.5197	.4807	.6062	.6036	.2353	.3149	.1848
5	.5636	.5533	.639	.6203	.2658	.3521	.1791
6	.6274	.6104	.6962	.6539	.2865	.4287	
7	.6859	.6783	.6874	.6962	.3224	.5028	
8	.7042	.7042	.8718	.7865	.3658	.5375	
9	.7209	.7209	.8718	.763	.3641	.5144	.2683
10	.7045	.7459	.8356	.763	.3294	.5256	.2883
11	.7625	.8215		.8453	.2713	.4917	
12	.7545	.7373	.6962	.8097	.3185	.5138	.285
13	.78	.6371	.8048	.852	.3563	.5138	.2343
14	.7045	.779	.8309			.5571	.3395
15	.7045	.7625	.7537		.431	.5344	
16	.7125	.7611	.7459		.4534	.5344	.3953
17	.6802	.7287	.7449	.0572	.3887	.3201	.4374
18	.5258	.8383	.7865	.362	.5028	.4784	.5256
19	.8859	.9088	.8551	.4572	.6335	.499	.6556
20	.8764	.8939	.7712	.4382	.6154	.4251	.6556
21	.8328	.7969	.6796	.362		.3511	.583
22	.6874	.7127	.6062	.2865	.39	.1867	.4534
23	.6062	.6722	.5898	.2481	.3688		.4424
24	.5506	.5801	.6562	.5735	.2303	.3481	.1867
Max	.8859	.9088	.8718	.852	.6335	.5571	.6556
Min	.4694	.4752	.5898	.0572	.1791	.1867	.1663
Avg	.6708	.6970	.7224	.5657	.3506	.4287	.3491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 205 / 11KV Kudwa  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5303	.4744	.415	.5693	.5118	.4904	.5113
2	.4545	.4554	.4338	.5313	.4929	.4527	.4924
3	.4166	.4175	.415	.5503	.455	.4715	.4924
4	.4166	.4364	.3961	.5313	.4739	.4338	.4545
5	.4356	.4364	.4527	.5313	.4739	.4527	.4356
6	.4356	.4744	.4715	.5123	.4929	.4338	.4356
7	.4734	.5693	.5281	.4364	.5497	.4527	.4545
8	.4734	.5882	.4904	.4364	.5118	.4715	.4356
9	.4924	.4934	.4715	.4744	.4739	.5093	.4356
10	.4744	.4904	.4744	.4554	.3788	.5093	.5113
11	.6452	.4527	.5693	.6452	.4527	.6452	.5113
12	.6072	.4715	.5693	.6262	.547	.5865	.4545
13		.5093	.5693	.5503	.4527	.3985	.4545
14	.5882	.415	.4477		.415	.3985	.4734
15	.5693	.3772	.4934		.3961	.4934	.3788
16	.5313	.3206	.4554	.3226	.4527	.3036	.3788
17	.4744	.4338	.4934	.3036	.4904	.3795	.4166
18	.5503	.4904	.5123	.4744	.547	.4934	.4166
19	.528	.5281	.5693	.5308	.547	.4934	.4924
20	.6072	.5658	.5882	.5308	.547	.5123	.5303
21	.6262	.547	.5693	.5118	.5658	.4929	.5303
22	.5693	.5093	.5693	.5687	.6036		.4924
23	.5503		.5693	.5497	.5658	.5113	.4924
24	.5303	.5123	.4527	.5693	.5308	.5281	.5303
Max	.6452	.5882	.5882	.6452	.6036	.6452	.5303
Min	.4166	.3206	.3961	.3036	.3788	.3036	.3788
Avg	.5209	.4769	.4990	.5096	.4970	.4745	.4671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 206 / 11KV Pandharabadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4428	.4973	.6077	.5804	.4125	.422	.363
2	.4088	.4641	.5739	.5633	.396	.4051	.3461
3	.4428	.431	.557	.5633	.396	.3882	.3307
4	.4428	.4641	.5739	.5121	.3795	.4051	.33
5	.4769	.4973	.5908	.5121	.396	.4389	.3605
6	.545	.5967	.6752	.6487	.396	.5402	.426
7	.5961	.7293	.7934	.7511	.5115	.5908	.5788
8	.5961	.7459	.7596	.8023	.495	.557	.5274
9	.6983	.6299	.7427	.7852	.462	.5233	.4944
10	.7373	.6752	.5975	.6828	.4125	.5402	.3626
11	.8192	.709	.6658	.8192	.3714	.5121	.4779
12	.7865	.7427	.6999	.7865	.3207	.5292	.4944
13	.7209	.7765	.734	.7209	.287	.5121	.4614
14	.7209	.7427	.734		.2532	.4268	.4614
15	.6962	.6921	.78		.4051	.4268	.4944
16	.678	.709	.7969	.1311	.4895	.3756	.4944
17	.678	.7427	.8194	.213	.5739	.4268	.5274
18	.8269	.7934	.8365	.297	.6414	.5621	.5274
19	.9569	.9959	.9901	.5115	.844	.7852	.7581
20	.8085	.9115	.956	.4785	.7934	.7511	.7746
21	.7425	.8102	.8535	.363	.6752	.627	.6262
22	.627	.7258	.734	.297	.4895		.5768
23	.5801		.6828	.429	.4558	.396	.5768
24	.511	.5138	.6414	.5804	.4125	.422	.363
Max	.9569	.9959	.9901	.8192	.844	.7852	.7746
Min	.4088	.431	.557	.1311	.2532	.3756	.33
Avg	.6475	.6781	.7248	.5467	.4696	.5028	.4889

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 402 / 33KV GONDIA CKT-1

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.1788	7.2936	7.7918	7.3729	6.386	4.4798	4.6251
2	7.1742	7.0514	7.6218	4.4707	6.2228	4.2801	4.4077
3	6.7742	6.7264	7.1401	7.0505	6.1137	4.2276	4.3536
4	6.8828	6.8281	7.1878	6.9971	6.1126	4.3581	4.4631
5	7.0968	7.2157	7.4504	6.9453	6.3854	4.6112	4.8577
6	7.4194	7.5983	8.0921	7.3696	6.6029	4.9748	5.2844
7	9.66	8.9446	9.537	8.4465	8.1873	3.8357	6.657
8	10.0401	10.1472	9.8064	9.6151	9.4971	6.2745	7.4211
9	10.3068	11.0992	9.7776	10.0388	9.9869	6.4176	6.2268
10	9.6619	9.7375	9.4947	9.4204	9.6542	6.5091	6.879
11	10.1395	10.2789	10.4366	10.7896	9.3166	7.3435	6.5909
12	10.1381	9.8595	10.1655	10.5222	5.6298	6.2379	5.543
13	8.8457	9.3761	9.847	9.932	9.6428	5.8005	3.275
14	8.6292	8.8358	8.8869		5.5801	4.6649	4.9326
15	8.7983	8.5716	8.6745	1.6158	5.3102	4.5579	4.6517
16	8.9689	8.6294	8.3209	1.4009	5.0994	2.1515	4.9094
17	9.1284	9.4235	8.9541	5.7876	5.2581	2.2754	4.6094
18	10.6453	10.6571	10.8709	7.808	6.8137	2.8042	6.4505
19	12.4627	12.4258	11.9818	10.0377	3.724	7.4603	7.3669
20	11.5135	11.7402	11.2776	9.263	3.6062	7.086	7.3159
21	10.4518	10.7927	10.4199	8.5608	6.0653	3.4791	6.7715
22	9.0115	9.3892	9.0287	7.9656	6.1774	4.8931	5.9533
23	8.2182	3.6923	8.4894	6.722	5.0227	5.0592	5.0968
24	7.3959	7.6149	8.2622	7.5855	6.5495	4.8163	4.9458
Max	12.4627	12.4258	11.9818	10.7896	9.9869	7.4603	7.4211
Min	6.7742	3.6923	7.1401	1.4009	3.6062	2.1515	3.275
Avg	9.0226	8.9137	9.1465	7.6399	6.6227	4.9416	5.5662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 203 / 11KV GANGAZARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0532	.0532	.0532	.0354	.0358	.0354
2	.0354	.0532	.0532	.0532	.0354	.0358	.0354
3	.0354	.0532	.0709	.0354	.0354	.0354	.0354
4	.0537	.0532	.0886	.0354	.0354	.0354	.0354
5	.0537	.0532	.0886	.0709	.0354	.0532	.0354
6	.0358	.0532	.0886	.1063	.0354	.0709	.0532
7	.0537	.0886	.0886	.0886	.0532	.0532	.0709
8	.0716	.1063		.0886	.0532	.0354	.0354
9	.0537	.0532		.1063	.0532	.0354	.0354
10	.0716	.0709	.0532	.0709	.0354	.0354	.0354
11	.0532	.0709	.0709	.1063	.0354	.0354	.0532
12	.0354	.0354	.0895	.1063	.0354	.0354	.0532
13	.0532	.0532	.0895		.0354	.0354	.0354
14	.0709	.0886	.0886			.0354	.0354
15	.0886	.1063	.0886		.0354	.0354	.0532
16	.0709	.0886	.1063		.0354	.0354	.0532
17	.0886	.1063	.0886		.0354	.0354	.0354
18	.0886	.124	.0886		.0543	.0532	.0532
19	.1227	.1402	.1417		.0886	.0886	.0905
20	.1052	.1227	.1417		.0709	.0709	.0724
21	.0876	.0876	.0716		.0709	.0532	.0543
22	.0701	.0701	.0716		.0532	.0532	.0537
23	.0532	.0701	.0532		.0354	.0354	.0537
24	.0354	.0532	.0532	.0532			.0354
Max	.1227	.1402	.1417	.1063	.0886	.0886	.0905
Min	.0354	.0354	.0532	.0354	.0354	.0354	.0354
Avg	.0635	.0773	.0831	.0750	.0451	.0447	.0475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 204 / 11KV TOWN - V

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3921	.4108	.3734	.3142	.3361	.2957
2	.3511	.3547	.4668	.3547	.2987	.3142	.2957
3	.3547	.3734	.4481	.3921	.2987	.3174	.2957
4	.4481	.3547	.462	.3921	.3174	.3547	.2957
5	.4854	.3734	.462	.4854	.3174	.3696	.2957
6	.4435	.4108	.5041	.5415	.3361	.499	.3326
7	.5175	.4854	.4854	.5041	.4481	.4435	.499
8	.5601	.5601	.5041	.5041	.6535	.5415	.6099
9	.6535	.6161	.5975	.5975	.6722	.5788	.5175
10	.6535	.6161	.6468	.6161	.6224	.5544	.5914
11	.6535	.7095	.5788	.5601	.6161	.5175	.7023
12	.4668	.5975	.5175	.4481	.5415	.4435	.4805
13	.4668	.3921	.3881		.4294	.4066	.4066
14	.4668	.4481	.4435		.4435	.3696	.3696
15	.4294	.4294	.4294		.3696	.3696	.3326
16	.4294	.4294	.4481		.3511	.2957	.3258
17	.3734	.5228	.4854		.3174	.3326	.3511
18	.5415	.6161	.5415		.5788	.4251	.462
19	.6535	.6535	.6722		.5975	.5175	.5658
20	.7095	.6908	.6348		.5975	.4805	.5281
21	.5788	.5601	.499		.4481	.462	.5601
22	.5041	.6161	.5914		.5041	.462	.4854
23	.4668	.4108	.4481		.4294	.3326	.4481
24	.3881	.4108	.4108	.3921		.3547	.2957
Max	.7095	.7095	.6722	.6161	.6722	.5788	.7023
Min	.3511	.3547	.3881	.3547	.2987	.2957	.2957
Avg	.4986	.5010	.5032	.4739	.4566	.4199	.4309



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 205 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.2826	1.2071	1.2826	.9808	.4527	.5281
2	.9808	1.2071	1.226	1.2071	.9808	.5658	.4904
3	.9619	1.2449	1.2826	1.3014	1.094	.9431	.4904
4	1.0185	1.1883	1.1883	1.3014	1.0562	.7922	.5281
5	.7545	1.1506	1.1317	1.1694	1.0562	.9054	.4715
6	.7545	1.0374	1.094	1.094	1.1694	.9808	.4715
7	.6979	1.2071	1.0374	1.2071	1.2449	.9431	.5281
8	.7545	1.094	1.1317	1.0751	.9808	.7356	.5847
9	.8299	1.0562	1.2071	1.1694	1.2071	.679	.5658
10	1.4901	1.3957	1.6975	1.7353	1.4901	.6602	.6036
11	1.905	1.773	1.905	1.9239	1.7918	.6224	.7167
12	2.0182	2.037	1.9239	1.2826	1.905	.5658	.6602
13	1.9805	1.8861	1.5089		1.773	.5658	.6036
14	1.7541	1.9616	1.6032		1.9239	.5658	.7167
15	1.773	1.8861	1.7164		1.8107	.5658	.6413
16	1.8107	1.9239	1.7353		1.7353	.5658	.6413
17	1.5466	1.6032	1.6975		1.5278	.4338	.7167
18	1.3203	1.3957	1.6032		1.2071	.4715	.7167
19	1.1506	1.0479	1.1883		.9808	.4904	.9619
20	.9431	1.1883	1.2071		.7545	.5658	.7922
21	.9808	1.2071	1.1694		.7733	.5093	.9054
22	1.226	1.226	1.226		.8676	.547	.6602
23	1.226	1.1883	1.3014			.5093	.6979
24	1.1506	1.1506	1.2071	1.2826			.4904
Max	2.0182	2.037	1.9239	1.9239	1.9239	.9808	.9619
Min	.6979	1.0374	1.0374	1.0751	.7545	.4338	.4715
Avg	1.2567	1.3891	1.3832	1.3101	1.2869	.6364	.6326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 206 / 11KV WATER WORKS

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0905	.0754	.0732	.0724	.0554	.0377
2	.0543	.0914	.0943	.0554	.0543	.056	.0377
3	.0549	.112	.1132	.0554	.0537	.056	.0377
4	.0732	.0934	.0943	.0724	.0537	.0373	.0377
5	.0914	.0924	.1132	.1086	.0537		.0566
6	.0905	.128	.0943	.1254	.0724		.0566
7	.1267	.1267	.1132	.0914	.0724		.0754
8	.1097	.1294	.0943	.1097	.0724		.0754
9	.1097	.1294	.0943	.0739	.0724	.0566	.0566
10	.1294	.0886	.0924	.1109	.0549		.0554
11	.1267	.104	.1294	.1294	.0739	.0754	.0732
12	.1017	.1063	.1109	.1109	.0886	.0943	.0543
13	.1029	.1063	.1097	.1097	.0693	.0754	.0543
14	.124	.0876	.0914		.1715	.056	.0724
15	.1075	.0876	.1086		.0526	.056	.0724
16	.0914	.12	.1267		.0709	.056	.0543
17	.1646	.128	.1267		.0895	.0747	.0549
18	.1543	.128	.1433		.1075	.112	.0914
19	.2033	.0732	.1463		.132	.1307	.1307
20	.2218	.128	.1463		.1307	.132	.112
21	.1494	.1132	.112		.0747	.0754	.1109
22	.128	.1132	.0943		.0739	.0566	.0924
23	.1086	.0754	.0934		.0549	.0377	.0549
24	.0732	.0895	.0754	.0732		.0549	.0377
Max	.2218	.1294	.1463	.1294	.1715	.132	.1307
Min	.0543	.0732	.0754	.0554	.0526	.0373	.0377
Avg	.1154	.1059	.1081	.0928	.0792	.0710	.0664

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 401 / 33KV RAWANWADI  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4298	6.0814	6.2986	6.5295	5.8127	5.6042	4.5301
2	5.2732	5.7556	6.565	6.31	5.8688	5.0606	4.3142
3	5.2669	5.8099	6.1346	6.254	5.647	5.0601	4.3679
4	5.1584	5.7013	6.1877	6.3632	5.3704	4.9515	4.2215
5	5.3755	6.0271	6.4615	6.5295	5.5362	5.0481	4.3513
6	6.0266	6.6336	7.0045	7.5171	6.198	5.3669	5.2012
7	7.1131	7.4606	7.9979	7.5172	7.4829	6.418	6.1414
8	7.7235	8.0127	8.2168	8.0658	8.5426	7.3039	7.1331
9	7.779	8.2705	7.9276	8.0264	8.3025	8.2996	6.749
10	7.6561	7.8733	8.0722	8.746	7.1382	8.0659	6.6918
11	8.2877	8.2339	8.7186	9.1901	7.3526	6.9135	7.1205
12	8.4803	8.7729	9.3392	9.0947	6.0906	6.797	6.521
13	7.9962	8.2328	8.6106	8.1156	7.3297	5.9854	6.358
14	7.3926	.9231	7.8921		5.9854	5.1921	5.5573
15	7.1262	7.5178	7.4115	1.0425	5.8779	5.0909	5.5099
16	7.2211	7.4995	7.4669	1.0425	6.5798	5.2446	5.5059
17	7.6395	7.9973	8.394	1.0425	7.1731	4.6485	5.3978
18	8.4248	8.4477	8.7706	1.0974	8.1756	6.2552	7.3309
19	9.4771	9.7256	9.6571	1.3169	9.297	7.7584	8.8974
20	8.7855	8.9838	1.3169	1.1523	8.9861	6.9176	8.2471
21	8.1225	8.3814	8.359	1.0425	7.1376	5.7613	7.6937
22	7.6269	7.2188	8.0258	.9877	5.9191	4.2101	6.8588
23	6.9502	7.4389	7.4245	.9328	6.2523	4.7874	6.0368
24	5.6379	6.3529	6.8959	6.9685	.8779	5.6048	4.4764
Max	9.4771	9.7256	9.6571	9.1901	9.297	8.2996	8.8974
Min	5.1584	.9231	1.3169	.9328	.8779	4.2101	4.2215
Avg	7.1654	7.2230	7.4645	4.9950	6.6223	5.9311	6.0505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 402 / 33KV GONDIA CKT-I  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6153	4.7782	4.9954	4.8354	3.8272	2.9973	2.9235
2	4.5668	4.561	4.8868	4.7279	3.8803	2.8704	2.8704
3	4.4593	4.6205	4.7782	4.6742	3.8272	2.8704	2.9767
4	4.2896	4.4525	4.6153	4.4593	3.7209	2.9767	2.9767
5	4.6153	4.7737	4.9931	4.6153	3.7609	3.1161	3.1161
6	5.1578	5.2115	4.9931	5.1029	4.2798	3.6214	3.5665
7	6.2443	6.19	6.749	5.7613	5.7065	4.2353	4.6016
8	6.6941	6.7507	6.6941	6.4198	6.5844		5.3224
9	6.8039	7.2977	6.749	5.5996	6.8039	4.8285	4.6091
10	6.2986	6.5844	6.4072	6.5158	5.9728	5.1578	4.6153
11	6.9307	7.1674	6.9685	7.0919	6.2986	5.2669	4.7817
12	6.7696	6.8959	6.6787	6.9307	5.9728	4.465	4.1993
13	6.4472	6.4615	6.5009	5.9419	6.1248	3.8803	.8648
14	5.9534	5.8562	5.5876		3.5231	3.3808	3.5757
15	5.6876	5.5281	5.6344		3.6408	3.3288	3.3288
16	5.8471	5.7939	5.3155		3.7334	1.9765	3.3808
17	5.9002	6.1128	6.0174		3.8066	2.0285	3.2768
18	6.9307	7.3605	6.9845		4.5771	2.6326	4.6016
19	8.3951	8.3402	7.8189		3.4705	5.487	5.5967
20	7.8464	7.9012	3.3951		3.3311	4.9931	5.3224
21	7.0782	7.2977	3.4568		5.3755	3.1276	4.8834
22	6.2003	6.4072	3.4168		4.6091	3.155	4.4525
23	5.5384	5.8642	5.3755		3.9918	3.2236	3.774
24	4.8325	5.0497	5.3212	5.0497		3.2407	3.083
Max	8.3951	8.3402	7.8189	7.0919	6.8039	5.487	5.5967
Min	4.2896	4.4525	3.3951	4.4593	3.3311	1.9765	.8648
Avg	6.0043	6.1357	5.5972	5.5518	4.6443	3.6026	3.8625

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 403 / 33KV DHAPEWADA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5261	3.4928	1.5912	1.5592	.9036	.9036	.9882
2	1.5432	1.4255	1.4255	1.4083	.9568	.8939	.4115
3	1.3763	1.4575	1.3763	1.3923	.7973	.7888	.9362
4	1.2809	1.4089	1.4255	1.3923	.7973	.7973	.9774
5	1.4586	1.4918	1.4918	1.442	.9036	.8059	.8413
6	1.5729	1.7295	1.4918	1.6278	.8145	.9877	.9774
7	1.2289	1.2752	1.2489	1.3032	1.0534	1.1403	1.1403
8	.9945	1.2323	1.182	.8413	.8779	.9362	1.0802
9	1.17	1.3146	1.3003	1.2094	.9671	1.1568	1.2574
10	1.262	1.3889	1.4043	1.4043	.8059	1.2071	1.2071
11	1.4563	1.4403	1.3375	1.5261	.8059	1.17	1.1568
12	1.3889	1.6827	1.6124	1.7295	1.0317	1.2574	1.3077
13	1.5432	1.7164	1.6124	1.5912	1.086	1.2963	1.3426
14	1.6461	1.6124	1.4918		1.1831	1.0911	1.2574
15	1.4083	1.4918	1.3889		.8413	1.0814	1.1305
16	1.4083	.9665	1.3003		.8939	.9156	.9774
17	1.5089	1.4403	1.4723		.9991	1.0682	.9774
18	1.5249	1.6118	1.4815		1.2094	1.3575	1.2489
19	1.7924	1.6804	1.7558		1.4883	1.5684	1.5684
20	1.6244	1.5684	1.5524		1.1523	1.3306	1.4712
21	1.8073	1.9667	1.9959		.9054	1.2357	1.386
22	1.6975	1.749	1.6804		.9522	.8413	1.0974
23	1.5415	1.5592	1.5364		.8871	.9259	.9568
24	1.3889	1.5729	1.5592	1.6118		.9036	.9156
Max	1.8073	3.4928	1.9959	1.7295	1.4883	1.5684	1.5684
Min	.9945	.9665	1.182	.8413	.7973	.7888	.4115
Avg	1.4646	1.5948	1.4881	1.4313	.9701	1.0692	1.1088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 404 / 33 KV GONDIA CKT-II  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	5.1744	2.3765	5.2881	4.1872	2.8395	2.9081
2	4.6399	4.7531	2.4006	4.9469	4.074	2.728	3.414
3	4.5833	4.6965	2.2634	4.6399	2.9424	2.7675	3.2836
4	4.6965	4.6965	2.2634	4.8097	3.6214	3.2305	3.5082
5	4.6965	5.0612	2.4897	5.036	3.9609	3.1922	3.6945
6	4.9795	5.5452	2.6029	5.403	4.64	3.6591	4.1078
7	5.9979	6.1677	3.315	5.9156	5.2624	4.1307	4.7274
8	5.9093	6.677	3.2579	5.715	5.2624	5.3755	4.9223
9	5.3755	5.7447	5.8282	5.4887	4.8097	5.319	4.8342
10	4.4702	5.6019	5.6584	5.5745	4.0175	5.4018	4.5496
11	4.7068	5.9413	5.8282	6.3375	4.5834	5.1178	4.4348
12	5.2624	5.9414	5.8551	5.9979	3.678	4.8897	4.3004
13	4.8097	5.5453	5.9414	5.7133	5.2372	4.5484	6.6455
14	4.357	4.64	5.036		4.5833	4.1501	2.5926
15	4.4702	4.5834	5.3755	.5658	4.9794	3.5083	3.3951
16	3.8477	4.753	5.1492	.9054	4.7314	3.2413	1.9805
17	4.0506	5.0926	5.2903	.8488	5.4887	3.7912	3.7523
18	5.2623	5.9413	6.2488	1.9805	6.0237	4.4136	2.5463
19	6.7335	7.2823	7.4126	2.6029	6.3374	6.394	6.5638
20	6.677	6.8467	7.0165	1.7541	6.8261	5.9414	6.0545
21	6.0545	6.5638	6.3712	2.9424	5.1491	4.6022	5.715
22	5.6018	5.6584	5.2315	2.6029	3.1122	2.8344	5.0926
23	5.3446	5.4589	5.5453	2.4331	2.5326	3.019	4.5833
24	4.5056	5.1172	4.9794	5.3441	2.3765	2.951	2.8961
Max	6.7335	7.2823	7.4126	6.3375	6.8261	6.394	6.6455
Min	3.8477	4.5834	2.2634	.5658	2.3765	2.728	1.9805
Avg	5.0650	5.5618	4.7390	4.0368	4.5174	4.0853	4.1876

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 405 / 33 KV GOREGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5082	4.5113	4.2684	4.2009	1.9239	5.0806	3.8791
2	3.678	4.1787	4.1564	1.0082	1.6975	4.9674	3.9364
3	3.594	4.0895	4.1564	4.0992	1.8107	5.1349	3.7671
4	3.5648	4.0656	4.1564	3.9769	1.6976	4.7988	3.7677
5	3.7912	3.7625	4.8291	3.9209	1.7541	4.8554	3.9043
6	4.357	4.3222	4.8291	4.201	2.2634	5.1686	4.3004
7	2.9801	4.4513	5.2778	5.0018	2.5463	5.5053	4.8914
8	4.6611	4.4902	5.108	4.8337	2.6594	6.1831	5.2841
9	4.2364	4.5559	5.0578	4.4907	2.4966	5.9585	5.0926
10	1.0185	4.5199	4.8451	4.3638	3.1179	3.1121	5.4321
11	4.6588	5.1418	5.0029	5.3567	3.654	3.2253	5.9979
12	4.8926	5.5813	6.0322	4.9245	3.5425	3.7077	7.1422
13	4.8806	5.2109	5.3167	5.2292	3.4894	6.8862	5.6984
14	4.4416	5.1103	4.9314		3.794	6.2191	5.308
15	4.6805	5.3846	5.5492		5.5322	5.6418	5.2515
16	4.8063	4.9577	4.8274		7.4349	5.5287	4.7205
17	5.0721	4.9726	5.0161	.5658	7.3234	5.5287	5.5099
18	5.591	5.6927	4.9994	1.1203	8.1504	6.35	6.0099
19	6.006	6.2865	5.1675	1.1763	8.5963	7.2428	7.8138
20	5.4007	5.5013	5.2092	1.2323	8.1488	6.4861	6.9924
21	5.0103	4.8828	4.481	1.1203	3.2254	5.7339	6.1466
22	5.0704	4.7897	4.593	1.0082	3.1688	4.2536	5.2429
23	4.7365	4.4582	4.1129	1.0642	6.0145	3.9609	4.5102
24	3.7625	4.4027	4.3804	3.8917	1.0185	5.471	3.993
Max	6.006	6.2865	6.0322	5.3567	8.5963	7.2428	7.8138
Min	1.0185	3.7625	4.1129	.5658	1.0185	3.1121	3.7671
Avg	4.3500	4.8050	4.8460	3.1803	3.9609	5.2917	5.1914

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 406 / 33KV GAYATRI AIPL  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.5294	2.9424	3.0293	1.0099	3.2819
2		3.5294	2.9938	3.315	1.2752	2.999
3		4.5668	3.4728	2.1502	3.3951	4.4582
4		4.2353	3.1602	2.9424	2.8292	4.8097
5		4.0724	3.2579	3.8866	2.1068	1.3672
6		4.0724	4.201	3.4294	2.7435	.631
7		2.8292	3.4294	3.9609	2.7366	2.9767
8		2.6886	1.4861	1.7741	1.5003	3.1436
9		3.6037	1.4861	3.2579	.3612	2.8578
10		2.2497	2.8858	2.2634	.5658	2.8578
11		3.3608	3.2819	2.8567	1.8673	2.9721
12		2.8006		3.1121	.4481	2.9424
13		3.5082	3.2819	2.5766	2.3434	3.8866
14		1.9805		3.2922	2.4977	.5721
15		1.5844		4.3244	1.1437	1.2037
16		1.0082		2.8275	1.2717	1.3283
17		1.7364		3.1121	1.4712	1.2963
18	.9442	2.999		2.7161	3.1121	1.773
19	2.2634	2.9687		2.6029	3.1121	.5487
20	3.7311			3.0807	2.7721	.9619
21	4.3244			2.2177	4.5771	4.7125
22	4.3982			3.3819	2.8858	5.6013
23	4.4907	3.3265		1.6804	2.5766	5.0412
24		4.201	2.8006		1.6644	2.8578
Max	4.4907	4.5668	4.201	4.3244	4.5771	5.6013
Min	.9442	1.0082	1.4861	1.6804	.3612	.5487
Avg	3.3587	3.0882	2.9754	2.9474	2.0945	2.7117



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 201 / Town - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.8775	.9231	.9145	.8413	.1132	.0362
2	.9145	.905	.905	.8688	.8413	.0943	.0362
3	.8962	.8688	.905	.8869	.8413	.0709	.0181
4	.9145	.9145	.9055	.9231	.8962	.0747	.0181
5	.9694	.9511	.905	.9774	.9145	.0747	.0181
6	1.0059	.9979	1.0317	.9877	.9694	.132	.0185
7	1.2071	1.1827	1.134	1.0974	1.1157		.037
8	1.2437	1.2936	1.2071	1.0974	1.2803		.037
9	1.3169	1.4969	1.2308	1.251	1.3717		
10	1.3535	1.4083	1.39	1.2437	1.4266		
11	1.4083	1.8107	1.6651	1.4632	1.6278		
12	1.7372	1.8107	1.7741	1.5729	1.6461		
13	1.6817	1.7375	1.6632	1.4632	1.6289		
14	1.5893	1.6095	1.4784				
15	1.5893	1.5729	1.5339				
16	1.6078	1.6095	1.475				
17	1.6632	1.6461	1.5893	.5853			
18	1.957	2.0119	2.0328	1.39			
19	2.2177	2.1582	2.0725	1.5729		.0754	
20	2.0165	2.0851	1.9791	1.4266		.0754	
21	1.6817	1.7741	1.6263	1.2803		.0566	
22	1.3169	1.3213	1.2437	1.1523		.0566	
23	1.1273	1.1222	1.0974	.9877	.132	.0566	
24	1.0974	.9694	1.0317	1.0242	.9145	.1132	.0554
Max	2.2177	2.1582	2.0725	1.5729	1.6461	.132	.0554
Min	.8962	.8688	.905	.5853	.132	.0566	.0181
Avg	1.3936	1.4223	1.3667	1.1508	1.0965	.0828	.0305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 202 / Town - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	1.1946	1.3352	1.1946	.9795	1.0425	.9412
2	1.1946	1.0974	1.262	1.1765	.9425	1.0164	.905
3	1.086	1.0498	1.134	1.1584	.9425	.9694	.9593
4	1.1584	1.0903	1.1523	1.1584	.924	1.0242	.9145
5	1.1946	1.1706	1.2071	1.0498	1.0164	1.0903	1.134
6	1.3394	1.3121	1.386	1.1888	1.1273	1.3032	1.134
7	1.6832	1.5708	1.6817	1.4632	1.5154		1.6827
8	1.8461	1.7741	1.8111	1.8671	1.7187	1.8099	1.8461
9	1.9728	2.0513	1.7741	1.7551	1.8665	1.9004	1.9022
10	1.7741	1.7558	1.9204	1.6817	1.7926	1.9185	1.8107
11	1.6832	1.7375	1.9022	1.885	1.7372	1.9022	1.6651
12	1.6108	1.7924	1.7002	1.8665	1.8959	1.701	1.5364
13	1.4118	1.5181	1.701	1.6632	1.8959	1.5364	1.3756
14	1.3394	1.4266	1.4266		1.5565	1.2254	1.2048
15	1.5927	1.3394	1.386		1.3937	1.134	1.0808
16	1.6263	1.4118	1.2254		1.4118		1.2048
17	1.46	1.4842	1.2437	1.6448	1.3717		1.2178
18	1.6078	1.829	1.7375	1.5708	1.701		1.4148
19	1.957	2.0328	1.9404	1.7002		1.9728	1.8296
20	1.8665	1.9589	1.7002	1.6448		1.7918	1.6975
21	1.7002	1.7924	1.6263	1.5708	2.1033		1.4148
22	1.5339	1.6827	1.5729	1.3121	1.6461	1.5384	1.3432
23	1.39	1.5364	1.4266	1.1273	1.2757	1.2489	1.182
24	1.2803	1.2752	1.4266	1.2803	.9979	1.1827	1.1222
Max	1.9728	2.0513	1.9404	1.885	2.1033	1.9728	1.9022
Min	1.086	1.0498	1.134	1.0498	.924	.9694	.905
Avg	1.5210	1.5368	1.5283	1.4743	1.4460	1.4373	1.3550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 203 / Town - III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.499	.4805	.4805	.3881	.3734	.4066
2	.4251	.4854	.499	.4805	.3696	.3734	.4066
3	.4435	.4435	.4805	.499	.3881	.3734	.4066
4	.462	.4805	.4805	.499	.3881	.3881	.6535
5	.4805	.5228	.5175	.4805	.4251	.4435	.6535
6	.5544	.5788	.5914	.6099	.499	.5788	.6535
7	.7392	.7392	.7762	.7392	.7023	.7282	.8316
8	.8871	.8686	.7762	.8131	.8501	.8775	.9055
9	.8501	.8686	.8402	.8131	.8871	.9149	.9522
10	.7023	.7392	.7023	.8501	.8131	.9149	.7207
11	.7577	.7392	.6722	.8501	.6838	.7207	.6653
12	.5914	.6468	.6036	.7207	.6283	.6283	.5975
13	.5544	.5544	.6099	.6653	.5731	.4805	.5788
14	.462		.499		.4525	.4435	.4435
15	.4435	.462	.4854	.5729	.4525	.4066	.4066
16	.4435	.4435	.4435	.5175	.4344	.4251	.4108
17	.4435	.4805	.4557	.5359	.5068	.4481	.4805
18	.5175	.5544	.6401	.6283	.5121	.5975	.5544
19	.7468	.7392	.8589	.8316	.7207	.7842	.7023
20	.8215	.7947	.7842	.7207	.7316	.7282	.7762
21	.7095	.7762	.7468	.6653	.6468	.6535	.7023
22	.6535	.6653	.6535	.5544	.5788	.5601	.6099
23	.5914	.5914	.6348	.4251	.5041		.4805
24	.462	.5228	.5175	.5415	.4066	.4066	.439
Max	.8871	.8686	.8589	.8501	.8871	.9149	.9522
Min	.4251	.4435	.4435	.4251	.3696	.3734	.4066
Avg	.5911	.6172	.6146	.6302	.5643	.5760	.6016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 204 / Town - IV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4066	.4435	.4435	.2033	.1097	.0732
2	.3696	.3734	.4435	.4066	.1848	.0732	.0739
3	.3696	.3361	.4066	.4435	.1848	.0739	.1109
4	.3696	.3326	.3696	.4435	.1848	.0739	.1109
5	.3696	.3696	.4066	.3696	.2195	.0732	.1109
6	.462	.4108	.4435	.4435	.2218	.1097	.1463
7	.6283	.5601	.5544	.5175	.2218		.3326
8	.6653	.6722	.5544	.5914	.2587	.2926	.3326
9	.6283	.7762	.5853	.5914	.2957	.2561	.2218
10	.5914	.5544	.6283	.5914	.2957	.2561	.6283
11	.5914	.6468	.5914	.6283	.2218	.2957	.5121
12	.5601	.5544	.5121	.5544	.2218	.2218	.4435
13	.5228	.4805	.4435	.5914	.2172	.1848	.4435
14	.4481	.3696	.4435		.2218	.1478	.3658
15	.4108	.3696	.3734	.5914	.2218	.1478	.3326
16	.4481	.4805	.4435	.3696	.2218	.1478	.3696
17	.4435	.5544	.4435	.3696	.2561	.1463	.0924
18	.4481	.5175	.5853	.3696	.2926	.1463	.5359
19	.6653	.6653	.6584	.4805	.2957	.2195	.6838
20	.6653	.6283	.5853	.2587	.2195	.2195	.6653
21	.5853	.5914	.6219	.2587	.2195	.2195	.6283
22	.5914	.5544	.5121	.2957	.2195	.1463	.5544
23	.439	.5914	.439	.1848	.1463	.1463	.4805
24	.4435	.4435	.4435	.4435	.1478	.1478	.1463
Max	.6653	.7762	.6584	.6283	.2957	.2957	.6838
Min	.3696	.3326	.3696	.1848	.1463	.0732	.0732
Avg	.5051	.5100	.4972	.4451	.2248	.1676	.3498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 202 / Urban industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2427	.3174	.3921	.2054	.2801	.2801
2	.1867	.2801	.2987	.3734	.2241	.2614	.3174
3	.168	.2614	.2801	.3174	.2241	.2801	.2614
4	.1867	.2427	.2427	.2801	.2427	.2427	.2427
5	.1494	.2054	.2054	.2241	.2427	.2054	.2054
6	.0373	.1867	.168	.1494	.2614	.0747	.2054
7	.0373	.056	.1494	.2054	.1867	.112	.168
8	.0373	.0373	.168	.1494	.2241	.112	.0934
9	.0934	.0747	.1886	.1494	.1867	.0934	.056
10	.168	.168	.2452	.1867	.2054	.0934	.0747
11	.2054	.3734	.3772	.2241	.2241	.112	.0934
12	.2241	.3734	.4668	.2801	.2054	.112	.112
13	.2054	.3734	.4294	.2987	.2054	.0934	.1494
14	.2054	.3361	.3174		.2614	.0934	.168
15	.2241	.3361	.3547		.2987	.0934	.168
16	.2054	.4108			.2054	.0934	.168
17	.2614	.2054		.2241	.2987	.056	.1509
18	.2801	.3361		.2263	.2427	.056	.132
19	.168	.2427	.1132	.2054	.1494	.056	.0943
20	.168	.2427	.0747	.168	.112	.056	.0943
21	.168	.2241	.0934	.1307	.112	.0373	.0754
22	.2054	.2241	.2054	.112	.168	.0187	.2263
23	.2054	.2801	.3174	.1494	.3174	.2987	.3206
24	.1867	.2614	.3361	.3921	.1494	.3361	.2987
Max	.2801	.4108	.4668	.3921	.3174	.3361	.3206
Min	.0373	.0373	.0747	.112	.112	.0187	.056
Avg	.1743	.2490	.2547	.2304	.2147	.1362	.1732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 203 / Manohar Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2241	.2241	.2054	1.0456	.9522
2	.2054	.1867	.2241	.2241	.2054	.9709	.8589
3	.1867		.2054	.2241	.1867	.9335	.8402
4	.1867	.2241	.2054	.2054	.1867	.8962	.9149
5	.2427	.2427	.2427	.2427	.2241	.9522	.9896
6	.2801	.2987	.2801	.2641	.2614	1.0082	1.1016
7	.3921	.3734	.3921	.3734	.3361	1.0269	1.2696
8	.4481	.4481	.4527	.3734	.4481	1.3443	1.4003
9	.4108	.4294	.4108	.4108	.4294	1.4003	1.531
10	.3921	.3921	.3921	.3921	.4108	.1494	1.4563
11	.3734	.3174	.3547	.3734	.3734	.2801	1.6244
12	.3361	.3547	.3547	.3361	.3547	.6161	1.7924
13	.3174	.2987	.3547	.3547	.2614	2.3152	1.6617
14	.2614	.2241	.2641		.2427	2.0538	1.531
15	.2801	.2614	.2452		.2241	1.6244	1.475
16	.2427	.2614	.2427		1.8671	1.531	.9896
17	.2987	.2427	.2452	.3547	1.7551	1.4937	1.6632
18	.2987	.2987	.2987	.3174	2.0165	1.587	1.885
19	.4108	.3734	.3547	.3361	2.1472	1.6617	2.2314
20	.3734	.3361	.3174	.3361	2.0725	1.6991	2.0911
21	.3547	.3361	.3174	.2987		1.6244	1.8111
22	.3547	.3174	.2987	.2614		1.5684	1.5123
23	.2987	.2987	.2801	.2263	1.4937	1.0456	1.1203
24	.2241	.2614	.2427	.2427	.2241	1.0829	.9149
Max	.4481	.4481	.4527	.4108	2.1472	2.3152	2.2314
Min	.1867	.1867	.2054	.2054	.1867	.1494	.8402
Avg	.3081	.3044	.3000	.3034	.7239	1.2463	1.4008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 201 / Chotta Gondia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0189	.0189	.0189	.0189
2	.0189	.0189	.0189	.0189	.0189	.0189	.0189
3	.0189	.0189	.0189	.0189	.0189	.0189	.0189
4	.0189	.0189	.0189	.0189	.0189	.0189	.0189
5	.0189	.0189	.0189	.0189	.0189	.0189	.0173
6	.0377	.0377	.0189	.0189	.0377	.0189	.0189
7	.0377	.0377	.0377	.0189	.0377	.0189	.0189
8	.0377	.0377	.0377	.0189	.0377	.0189	.0377
9	.0189	.0189	.0189	.0189	.0377	.0189	.0189
10	.0377	.0377	.0189	.0377	.0189	.0189	.0189
11	.0377	.0189	.0377	.0377	.0189	.0377	.0189
12	.0377	.0754	.0377	.0566	.0189	.0189	.0189
13	.0189	.0377	.0377	.0377	.0189	.0189	.0189
14	.0189	.0377	.0377		.0189	.0189	.0189
15	.0189	.0377	.0377	.0189	.0754	.0189	.0189
16	.0189	.0377	.0377	.0189	.0189	.0189	.0189
17	.0189	.0754	.0377	.0377	.0189	.0189	.0189
18	.0189	.0754	.0377	.0377	.0189	.0189	.0377
19	.0566	.0754	.0377	.0377	.0377	.0377	.0377
20	.0566	.0566	.0377	.0377	.0377	.0189	.0377
21	.0566	.0377	.0377	.0377	.0377	.0189	.0377
22	.0377	.0377	.0377	.0189	.0189	.0189	.0189
23	.0377	.0377	.0377	.0189	.0189	.0189	.0189
24	.0377	.0377	.0377	.0377	.0189	.0189	.0189
Max	.0566	.0754	.0377	.0566	.0754	.0377	.0377
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0173
Avg	.0307	.0393	.0314	.0279	.0267	.0205	.0228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 202 / Govindpur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4805	.6099	.6468	.5544	.7577	.5914
2	.4805	.4435	.5544	.6099	.5175	.7392	.5544
3	.462	.4066	.5175	.5544	.5175	.7207	.5544
4	.462	.3881	.4805	.5729	.4805	.6838	.5359
5	.499	.462	.5544	.5914	.4805	.7023	.5175
6	.5544	.5729	.7023	.6283	.6468	.7023	.7023
7	.7207	.7023	.8131	.6468	.7023	.924	.8686
8	.7947	.7762	.8316	.7392	.7947	1.0349	1.1458
9	.7577	.9055	.7577	.7762	.8316	1.1458	1.2012
10	.6653	.7577	.7762	.8131	.8316	1.1088	.8686
11	.7577	.7392	.7762	.8131	.8131	.9795	.8501
12	.7577	.7392	.8501	.8131	.7392	.9425	.7947
13	.5729	.6283	.7392	.5914	.6468	.7392	.6283
14	.5544	.4805	.6468	.5914	.6099	.6468	.5729
15	.462	.5175	.6099	.5544	.5544	.5544	.5359
16	.5359	.4435	.6653	.5729	.7577	.6099	.5544
17	.6099	.5729	.6468	.5175	.8501	.5729	.6099
18	.7392	.5914	.6653	.6099	.8871	.7762	.7392
19	.8686	.8131	.7762	.7392	1.0349	.9425	.961
20	.7947	.7947	.7392	.6653	.9795	.8871	.8871
21	.7577	.7762	.7023	.6283	.9055	.8686	.8131
22	.6838	.7023	.6653	.6468	.8316	.6838	.7947
23	.5544	.6838	.7023	.6468	.8501	.6099	.6283
24	.5175	.5175	.6468	.6653	.5914	.7947	.5914
Max	.8686	.9055	.8501	.8131	1.0349	1.1458	1.2012
Min	.462	.3881	.4805	.5175	.4805	.5544	.5175
Avg	.6268	.6206	.6846	.6514	.7254	.7970	.7292



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 203 / Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4572	.4938	.439	.5228	.5228	.4108	.4108
12							.3921
13							.4294
14							.3361
15							.4108
16	.4938	.5487	.5121	.4854	.4668	.3174	.4108
17							.3361
18							.4108
19							.4108
20							.4108
21							.3921
22							.3734
23	.4207	.4938	.4668	.2987	.3921	.2427	.2772
24	.2926	.4024	.4755	.4481	.2801	.3547	.2241
Max	.4938	.5487	.5121	.5228	.5228	.4108	.4294
Min	.2926	.4024	.439	.2987	.2801	.2427	.2241
Avg	.4161	.4847	.4734	.4388	.4155	.3314	.3732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314029 / Katangtola

Feeder No / Name : 201 / 11 KV GAJANAN COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1463	.1433	.1254	.3403	.4477	.2865
2	.1097	.1097	.1433	.1254	.3403	.4298	.2507
3	.1097	.1097	.1254	.1254	.3224	.394	.2149
4	.1097	.1097	.1075	.1254	.2865	.3582	.1791
5	.1097	.128	.1075	.1254	.3224	.3582	.1791
6	.1097	.128	.0895	.1433	.3224	.3224	.3224
7	.1646	.1646	.1791	.1612	.4572	.5014	.4298
8	.2195	.2378	.197	.1791		.5731	.4298
9	.2378	.2561	.197	.2149	.5552	.6089	
10	.1829	.1791		.197	.5014	.5731	.2507
11	.1463	.181	.1791	.2149	.394	.5373	.1791
12	.1463	.1612	.1791	.1791	.4119	.4119	.1433
13	.128	.1254	.1433	.1612	.3224	.3403	
14	.1097	.3475	.1254		.3045	.3224	.0905
15	.1097	.1075	.1254	.1433	.3045	.3045	.1086
16	.1097	.1075	.1075	.0895	.3045	.3045	.1086
17	.1097	.1075	.1254	.1075	.3224	.3224	.1086
18	.1463	.1791	.1433	.1433	.4835	.3761	.1629
19	.1829	.1791	.1791	.1433	.4656	.4298	.181
20	.1829	.1791	.1612	.4298	.4656	.4298	.181
21	.1646	.1791	.1612	.394	.4298	.4477	.181
22	.1646	.1612	.1612	.3761	.4119	.3403	.1629
23	.1463	.1433	.1433	.3403	.3403	.3224	.1448
24	.128	.1463	.1433	.128	.3403	.4477	.2865
Max	.2378	.3475	.197	.4298	.5552	.6089	.4298
Min	.1097	.1075	.0895	.0895	.2865	.3045	.0905
Avg	.1433	.1614	.1464	.1901	.3804	.4127	.2083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314029 / Katangtola

Feeder No / Name : 203 / 11KV Angurbagicha

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3292	.3292	.3475	.2926		.2743
2	.3292	.3292	.3292	.3292	.2926		.2743
3	.3292	.3109	.2926	.3292	.3109		.2743
4	.3292	.3109	.2926	.3475	.3109		.2561
5	.3292	.3658	.3292	.3475	.3109		.2743
6	.3475	.439	.4207	.3841	.3109		.3292
7	.4755	.5121	.567	.4938	.462		.4024
8	.567	.5121	.567	.567	.5304		.4207
9	.5487	.5487	.5249	.567	.4938		.439
10	.4207	.4572	.4755	.567	.439		.4207
11	.3841	.4572	.439	.4755	.3658		.3658
12	.3841	.3475	.4572	.4572	.3109	.2926	.2926
13	.3841	.2195	.4024	.439	.2926	.2926	
14	.3292	.3475	.3475		.2926	.2378	.2378
15	.3475	.2561	.3658		.2743	.2561	.2378
16	.3475	.3109	.3841		.2743	.2743	.2561
17	.3658	.3841	.4207		.3109	.2378	.3658
18	.5487	.4938	.439	.439	.4207	.3658	
19	.5853	.567	.5853	.5487	.5121	.4024	.567
20	.5487	.5121	.5304	.4938	.4938	.439	.4973
21	.4755	.4755	.5121	.439	.4024	.3841	.439
22	.439	.439	.4572	.3658	.3658	.2926	.567
23	.4024	.3841	.3841	.2743	.3841	.2865	.3109
24	.3292	.3292	.3475	.3658	.2926		.2743
Max	.5853	.567	.5853	.567	.5304	.439	.567
Min	.3292	.2195	.2926	.2743	.2743	.2378	.2378
Avg	.4115	.4016	.4250	.4289	.3645	.3135	.3535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 201 / 11 KV GOREGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2667	.2534	.2241	.2172	.2054	.2241
2	.3077	.2667	.2534	.2241	.2195	.2054	.2427
3	.3018	.2477	.2353	.2054	.2743	.2054	.2614
4	.2896	.2477	.2172	.2054	.2926	.2054	.2801
5	.3292	.2801	.2353	.2218	.2926	.2241	.2801
6	.3326	.3361	.2896	.2402	.3258	.2801	.2801
7	.3658	.3734	.3258	.2772	.3547	.3361	.2801
8	.3439	.3326	.3258	.3475	.3292	.3547	.2801
9	.3439	.3547	.3258	.3475	.362	.3696	.2054
10	.3109	1.4563	.3174	.3326	.9145	.3658	.3142
11	.3109	.3361	.3109	.3658	.3258	.3109	.2715
12	.3142	.3361	.2896	.3077	.2896	.2715	.2534
13	.2957	.3326	.2743	.3292		.2195	.2534
14	.2772	.3142	.2743		.3258	.2172	.2328
15	.2772	.2534	.2715		.333	.2195	.2507
16	.2957	.2715	.2715		.2896	.2353	.2353
17	.3142	.2896	.2743		.3292	.2378	.2658
18	.4207	.4207	.2987		.4294	.2987	.3045
19	.4938	.4572	.4572		.4715	.4024	.4344
20	.4527	.4207	.4024		.4338	.3801	.3841
21	.415	.3658	.4066		.3584	.3696	.3439
22	.3584	.3326	.3326		.2829	.2743	.2926
23	.3239	.2772	.2801		.2054	.1829	.2172
24	.2561	.2858	.2587	.2427	.2865	.2054	.1829
Max	.4938	1.4563	.4572	.3658	.9145	.4024	.4344
Min	.2561	.2477	.2172	.2054	.2054	.1829	.1829
Avg	.3343	.3690	.2992	.2765	.3454	.2740	.2738

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 202 / 11 KV MUNDIPAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3734	.3856	.3155	.0177	.2715	.1086
2	.3544	.3734	.3856	.3506	.0175	.2715	.1097
3	.3898	.4108	.3982	.3429	.0175	.2715	.128
4	.4119	.4108	.3856	.3772	.0175	.2534	.128
5	.4252	.2801	.4207	.4115	.0177	.2534	.128
6	.4477	.4668	.4557	.4748	.0177	.3292	.128
7	.4525	.4887	.4733	.4409	.0171	.3658	.1254
8	.4755	.4854	.5083	.5426	.0351	.4024	.1267
9	.3772	.4854	.5258	.5596	.0177	.3582	.1433
10	.4115	.6161	.4382	.5426	.2454	.362	.0905
11	.5258	.6161	.4607	.5316	.3086	.3292	.12
12	.5434	.6535	.5258	.1753			.1734
13	.4908	.6722	.5493	.3258		.2743	.1543
14	.3506	.6173				.2865	.1543
15	.5784	.5533	.5487		.3258	.3077	.0171
16	.6135	.503	.5487		.3222	.3155	.2743
17	.6485	.4115	.543		.3353	.3189	.3258
18	.6485	.631	.5973		.373	.394	.2804
19	.7362	.7362	.6697		.6468	.6024	.6733
20	.6697	.6661	.6154		.5729	.5609	.5959
21	.6036	.6661	.543		.4668	.3898	.4784
22	.4024	.5609	.543		.3921		.3761
23	.3841	.3856	.3109		.3142	.1052	.3077
24	.3109	.3658	.3856	.3109	.0179	.2743	.0886
Max	.7362	.7362	.6697	.5596	.6468	.6024	.6733
Min	.3109	.2801	.3109	.1753	.0171	.1052	.0171
Avg	.4824	.5179	.4877	.4073	.2141	.3317	.2182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 203 / 11 KV INDUSTRIAL MILLTOLI SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.8573	.6535	.5601	.4572	.7577	.3429
2	.7577	.8573	.6535	.5601	.4191	.8131	.381
3	.7316	.7621	.6401	.5716	.4382	.8316	.4191
4	.6878	.6668	.5788	.5716	.4191	.7865	.4763
5	.7316	.6287	.6722	.5716	.381	.7316	.4763
6	.6401	.6668	.7842	.5716	.381	.6767	.4954
7	.4938	.8402	.8402	.6287	.362	.6653	.5144
8	.3696	.6722	.8402	.724	.5068	.5601	.6287
9	.5544	.8215	.8589	.7095	.4024	.5601	.4715
10	.6219	.8029	1.0562	.8316	.695	.5487	.5093
11	1.0269	.9335	.8413	1.1888	.9694	.5853	.6413
12	1.1016	1.2136	1.1584	1.1888	.9877	.695	.8962
13	1.1203	1.2136	1.2323	1.134	.9774	.7655	1.0082
14	1.1576	1.2696	1.1157		.5611	.695	.8131
15	1.1203	1.1888	1.086		.8326		.8596
16	.8775	1.2437	1.0974		.9412	.6516	.9145
17	1.0269	1.2437	1.1523		.9492	.5792	.7865
18	.7282	1.1088	.8507		.8002	.6036	.6878
19	.6535	1.1088	.8596		.6859	.5228	.7682
20	.7282	1.0164	.8326		.8383	.3292	.362
21	.8299	.9335	.823		.4954	.2667	.3841
22	.8299	.8962	.823		.9054	.2477	.2534
23	.8192	.8402	.7468	.3429	.905	.2286	.1905
24	.7655	.8383	.7095	.6161	.3239	.8048	.3048
Max	1.1576	1.2696	1.2323	1.1888	.9877	.8316	1.0082
Min	.3696	.6287	.5788	.3429	.3239	.2286	.1905
Avg	.7983	.9427	.8711	.7181	.6514	.6046	.5660

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810]

BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 205 / 11KV Hirdamali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4191	.4163	.3734	.1949	.2926	.3429
2	.4163	.381	.3982	.3734	.2149	.2926	.3429
3	.439	.381	.3982	.4191	.2353	.2715	.381
4	.5121	.4191	.362	.4191	.2561	.2715	.381
5	.543	.4572	.362	.4572	.2743	.3258	.4191
6		.5716	.5068	.5544	.3292	.3841	.4763
7	.6401	.6348	.6335	.5792	.4066	.5359	.4954
8	.6219	.6401	.5792	.6516	.3292	.5544	.5144
9	.567	.5853	.5068	.6283	.3077	.5121	.4715
10	.4477	.4382	.5175	.5359	.2195	.4755	.3961
11	.4207	.4557	.4755	.5175	.3841	.3658	.3361
12	.394	.4607	.4706	.4755	.2926	.3366	.3326
13	.394	.4252	.439	.4525	.2507	.2865	.2218
14	.3841	.3898	.3982		.2534	.2715	.2218
15	.394	.3768	.4207		.2534	.2328	.3361
16	.394	.3605	.4024		.2715	.2561	.3326
17	.4298	.4115	.4163		.2865	.2534	.3506
18	.5487	.5249	.5973		.4481	.3658	.4075
19	.7762	.724	.724		.6161	.5792	.6447
20	.6908	.6335	.6838		.5658	.5729	.6335
21	.6161	.5611	.6838		.4904	.4481	.5487
22	.5093	.5249	.499		.3961	.4024	.4525
23	.4572	.4525	.4108	.181	.3361	.2926	.3734
24	.362	.4191	.4163	.4294	.1829	.2987	.3018
Max	.7762	.724	.724	.6516	.6161	.5792	.6447
Min	.362	.3605	.362	.181	.1829	.2328	.2218
Avg	.4939	.4853	.4883	.4698	.3248	.3699	.4048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810]

BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 206 / 11 KV Katangi Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.381	.3658	.3696	.0724	.2772	.0191
2	.4163	.4191	.3658	.3696	.0914	.2743	.0191
3	.439	.4191	.3292	.3734	.1463	.2743	.0191
4	.3982	.4191	.3292	.4108	.1848	.2561	.0191
5	.4572	.4572	.3109	.4108	.2218	.2561	.0191
6	.4904	.5335	.5487	.4954	.2218	.3547	.0191
7	.4887	.6287	.5487	.5716	.2241	.4949	.0191
8	.439	.4954	.4572	.5144	.128	.5335	.0381
9	.3658	.4001	.3658	.4024	.1267	.3734	.0377
10	.4207	.3696	.3982	.4251	.1097	.3326	.0377
11	.3658	.3326	.2896	.4066		.2587	
12	.3475	.3511	.2534	.439		.2561	.0762
13	.3475	.362	.3841	.362	.362	.2353	.0762
14	.3109	.362	.3439		.3077	.2378	.0953
15	.3475	.3403	.3429		.2896	.2172	.1524
16	.3547	.3898	.3582		.3077	.2561	.1524
17	.3841	.5304	.3801		.3258	.2534	.2286
18	.5487	.5304	.5973		.5249	.4024	.3018
19	.7842	.7682	.7602		.7167	.6697	.5601
20	.7095	.695	.695		.6668	.6219	.4805
21	.5906	.5487	.5853		.4191	.4344	.4207
22	.5335	.5121	.695		.3174		.2957
23	.4572	.4207	.5544	.2172		.0191	.2172
24	.3582	.381	.4024	.4066	.0732	.2987	.0191
Max	.7842	.7682	.7602	.5716	.7167	.6697	.5601
Min	.3109	.3326	.2534	.2172	.0724	.0191	.0191
Avg	.4482	.4603	.4442	.4116	.2780	.3299	.1445



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314009 / 33KV TEDHA

Feeder No / Name : 203 / 11kv Gidhadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915		.5197	.4049		.3563	
2	.4915	.5243	.503	.4049		.4049	
3	.4915	.5243	.503	.4049		.421	
4	.4915	.5243	.503	.4049		.3725	
5	.5243	.5243	.5365	.4372		.4049	
6	.6062	.6062	.6539	.5487		.421	
7	.7293	.7537	.8048	.7202		.4748	
8	.8383	.852	.8551	.8383		.5087	
9	.8383	.7865	.8048	.8259		.5765	
10	.7712	.7373		.7773		.5935	
11	.6874	.7373	.7042	.6316	.3605	.6036	.3688
12	.7209	.7537	.7209	.7125	.426	.5182	.218
13	.6706	.7537	.7209	.8097	.4588	.5506	.2683
14	.7293	.7537	.6706			.4858	.2683
15	.6962	.7209	.7209		.3932	.502	.2683
16	.7293	.7045	.8215		.5079	.5344	.2683
17	.7459	.8029	.788		.5243	.5735	.3185
18	.8785	.852	.8139		.7701	.6443	.5197
19	.9945	1.0159	1.0402		.9088	.9709	.6796
20	.8619	.9339	1.0059		.823	.8779	.6299
21	.7293	.7377	.6626		.4049	.6135	.4144
22	.5735	.5868	.583		.3563		.3315
23	.5243	.5197	.4527		.3437	.4115	.3018
24	.5079	.5243	.5197	.421		.3605	
Max	.9945	1.0159	1.0402	.8383	.9088	.9709	.6796
Min	.4915	.5197	.4527	.4049	.3437	.3563	.218
Avg	.6801	.7056	.6917	.5959	.5231	.5296	.3735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 201 / 11KV Dhapewada

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2591	.2753	.2652	.1638	.1802	.2031
2	.2294	.2591	.2721	.2652	.1638	.1802	.2031
3	.2294	.2591	.2721	.2652	.1638	.1823	.2056
4	.2294	.2591	.2721	.2652	.1638	.1823	.2031
5	.2294	.2622	.2785	.2652	.1638	.1844	.2241
6	.2743	.2743	.3258	.3086	.2229	.208	.2713
7	.3086	.3086	.3467	.3353	.2279	.2103	.2713
8	.2915	.2818	.3113	.3841	.2401	.213	.2486
9	.2818	.3077	.3239	.3479	.2315	.213	.2591
10	.3239	.3361	.3361	.3563	.1966	.2267	.2006
11	.3201	.2623	.3361	.3637	.1658	.2056	.2031
12	.2846	.3361	.2721	.3125	.192	.2187	.1981
13	.25	.3041	.3239	.3549	.2294	.208	.1783
14	.2932	.3163	.3239		.3437	.2006	.1677
15	.2896	.2968	.2688		.3125	.2107	.1677
16	.2932	.2896	.2721		.1852	.208	.2258
17	.3048	.2968	.2846	.2058	.1875	.2031	.1981
18	.3401	.3353	.3561	.2658	.2804	.2683	.285
19	.4477	.4607	.4344		.4163	.3982	.4119
20	.4252	.4252	.4252	.3109	.3658	.3761	.3898
21	.3898	.4031	.3721	.2686	.2865	.3086	.3467
22	.3086	.3222	.3391	.1865	.2229	.2267	.2818
23	.2883	.2949	.3018	.1802	.2035	.2241	.2591
24	.2294	.2591	.2753	.2652	.1638	.1802	.2214
Max	.4477	.4607	.4344	.3841	.4163	.3982	.4119
Min	.2294	.2591	.2688	.1802	.1638	.1802	.1677
Avg	.2955	.3087	.3166	.2886	.2289	.2257	.2427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 203 / 11kv MIDC jackwell water  
works Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0791	.08	.08	.08	.0781	.0772	.0781
2	.0791	.08	.08	.08	.0781	.0772	.0781
3	.0791	.08	.08	.08	.0781	.0772	.0781
4	.0791	.08	.08	.08	.0781	.0772	.0781
5	.0791	.08	.08	.08	.0772	.0772	.0781
6	.001	.081	.081	.081	.0781	.0791	.0781
7		.0543	.0514	.081	.0791	.0791	.0791
8	.081	.0819	.0819	.0819	.0791	.0791	.08
9	.0819	.0819	.0819	.0819	.0791	.08	.08
10	.0819	.0819	.0819	.0819	.0829	.08	.08
11	.0829	.0829	.0829	.081	.08	.081	.081
12	.0829	.0848	.0829	.08	.081	.081	.032
13	.0829	.0838	.0829	.08	.081	.08	.08
14	.0819	.0829	.0829		.08	.08	.08
15	.0819	.0829	.0829		.08	.08	.08
16	.0819	.0819	.0819		.08	.08	.08
17	.0819	.0819	.0819	.0002	.08	.08	.08
18	.081	.0819	.081	.0791	.081	.08	.0537
19	.081	.081	.081	.0791	.08	.0791	.0543
20	.08	.08	.08	.0781	.0781	.0791	.0537
21	.081	.081	.08	.0781	.0781	.0781	.0532
22	.08	.08	.08	.0781	.0781	.0781	.0532
23	.08	.08	.08	.0781	.0781	.0781	.0526
24	.0791	.08	.08	.08	.0781	.0772	.0781
Max	.0829	.0848	.0829	.0819	.0829	.081	.081
Min	.001	.0543	.0514	.0002	.0772	.0772	.032
Avg	.0774	.0803	.0799	.0762	.0792	.0790	.0708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 204 / 11 KV AGP Dhapewada  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2469	.3102	.2961	.2643		.0381
2	.2469	.3102	.2961	.2643		.0381
3	.2606	.3102	.2921	.2643		.0381
4	.2606	.3144	.2921	.2643		.0381
5	.2606	.3144	.2961	.2643		.0381
6	.2643	.3429	.3429	.3144		.0381
7	.0709	.0867	.0724	.1063		.0543
8	.0914	.0934	.0924	.1063		.1
9	.0924	.0732	.0905	.1254		.0812
10	.0914	.0732	.0724	.1097		.0823
11	.0732	.0732	.0732	.0905		.0812
12	.0739	.0537	.0914	.0701		.0789
13	.0934	.104	.0914	.0514		.0648
14	.0924	.0867	.0914			.0823
15	.0739	.0732	.0716			.08
16	.0716	.0724	.0701			.0343
17	.0532	.0732	.0895		.0934	.0709
18	.0537	.0732	.0905		.0812	.0895
19	.0895	.0924	.1109		.0974	.1109
20	.0732	.0914	.1097		.0974	.1097
21	.3185	.2715	.2679		.0974	.0905
22	.3144	.2961	.2643		.0789	.0716
23	.3144	.2961	.2643		.0777	.0716
24	.2469	.3102	.3001	.2643		.0754
Max	.3185	.3429	.3429	.3144	.0974	.1109
Min	.0532	.0537	.0701	.0514	.0777	.0343
Avg	.1595	.1748	.1721	.1829	.0891	.0691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 201 / 11KV Tirora-U-

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8507	.5611	.5973	.5609	.4344	.4706	.3856
2	.8326	.543	.5973	.5434	.4344	.4525	.3681
3	.8326	.543	.5792	.5258	.4344	.4525	.0762
4	.8507	.543	.5792	.5258	.4344	.4525	.3856
5	.8869	.543	.6154	.5434	.4525	.4706	.4207
6	.9593	.5792	.6516	.5609	.4887	.4887	.4557
7	1.086	.7186	.7602	.6335	.7059	.6335	.6485
8	1.1946	.7362	.724	.7421	.7964	.7602	.7783
9	1.1765	.7011	.7421	.724	.7602	.8507	.724
10	1.1403	.7011	.724	.6878	.6836	.724	
11	1.086	.6485	.6516	.7421	.6135	.6516	
12	1.1403	.6485	.543	.6878	.1928	.5792	.4887
13	1.1222	.6661	.5068	.6516	.5784	.5611	.362
14	.4344	.7362	.5249		.4908	.5068	.3258
15	.1629	.5784	.4887		.1629	.4706	.2896
16	.5068	.5792	.4908	.8145	.5249	.4207	.181
17	.543	.6516	.5258	.6878	.5611	.4733	.5973
18	.2172	.8145	.8063	.5792	.4706	.6135	.7059
19	1.0317	1.0136	.9568	1.0136	.9412	.7712	.8869
20	.8869	.9412	.8859	.8688	.8507	.7537	.8145
21	.8145	.905	.7973	.7783	.724		.7602
22	.7059	.7602	.7011	.6335	.6335	.5434	.6335
23	.6154	.6697	.6135	.5068	.5249	.4382	.5068
24	.8507	.5611	.5973	.5609	.4525	.4706	.4031
Max	1.1946	1.0136	.9568	1.0136	.9412	.8507	.8869
Min	.1629	.543	.4887	.5068	.1629	.4207	.0762
Avg	.8303	.6810	.6525	.6624	.5561	.5656	.509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 202 / 11KV Mangezari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.181	.1086	.2103	.1267	.0189	.0373
2	.181	.181	.1086	.1928	.1086	.0189	.0373
3	.1629	.181	.1086	.1753	.1086	.0189	.0373
4	.181	.181	.1086	.2103		.0189	.0373
5	.2172	.1991	.1267	.2454		.0377	.0373
6	.2715	.2715	.1629	.2804		.1109	.0373
7	.2534	.2804	.1629	.2896		.1294	.0373
8	.2172	.2454	.1629	.2896		.1109	.0377
9	.1991	.2103	.2172	.2715		.1629	.1448
10	.1991	.1928	.2353	.2534	.1227	.1991	
11	.1629	.1928	.2172	.2353	.1227	.181	
12	.2172	.1753	.181	.2353	.1052	.1629	.1267
13	.1991	.2103	.181	.2353	.1227	.1629	.1267
14	.1448	.1753	.181		.1227	.1448	.1086
15	.1629	.1928	.1991		.1294	.1448	.1086
16	.181	.181	.1753	.0362	.1109	.1578	.0905
17	.2172	.2353	.2279	.1267	.1478	.1753	.1448
18	.3077	.3077	.3155	.2172	.2534	.2454	.2534
19	.4344	.4163	.4382	.3077	.362	.3155	.3801
20	.3982	.3982	.4031	.2715	.3439	.298	.362
21	.3439	.362	.333	.1991			.2896
22	.2534	.3258	.2629	.1448			.1991
23	.1991	.1267	.2103	.1448	.0189	.0373	.1629
24	.181	.1991	.1086	.2103	.1267	.0189	.0373
Max	.4344	.4163	.4382	.3077	.362	.3155	.3801
Min	.1448	.1267	.1086	.0362	.0189	.0189	.0373
Avg	.2278	.2343	.2057	.2174	.1521	.1305	.1288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 203 / 11KV Mandvi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2172	.2534	.2103	.1629	.181	.1052
2	.2172	.181	.2534	.1928	.1448	.181	.1052
3	.1991	.181	.2534	.1753	.1448	.1629	.1052
4	.1991	.181	.2534	.1928		.1629	.1052
5	.2172	.181	.2715	.2103		.1629	.1052
6	.2534	.2353	.2715	.2279		.181	.1267
7	.2353	.2103	.2353	.2172		.1991	.1227
8	.2172	.2279	.2534	.1991		.181	.1086
9	.1991	.2454	.2172	.2172		.2172	.1086
10	.2353	.2454	.2896	.2534	.1753	.1991	
11	.2353	.1928	.2172	.2172	.1753	.181	
12	.2172	.1928	.2534	.2353	.1578	.1629	.1448
13	.2534	.1578	.1991	.2172	.1753	.1629	.1086
14	.2172	.1753	.181		.1402	.1267	.1267
15	.2353	.1402	.1448		.1294	.1267	.1448
16	.2172	.1267	.1227		.1109	.1052	.1267
17	.1448	.1448	.1402	.0905	.1294	.1052	.181
18	.1991	.1991	.2103		.181	.1753	.181
19	.3077	.3077	.3155	.2172	.2896	.2629	.3258
20	.3439	.3258	.333	.2534	.3258	.2454	.362
21	.3439	.2896	.3155	.2172	.2715		.3258
22	.2353	.2715		.181	.181	.1052	.2353
23	.2353	.2715	.2103	.1629	.1629	.1052	.1991
24	.2353	.2353	.2534	.2103	.1629	.181	.1052
Max	.3439	.3258	.333	.2534	.3258	.2629	.362
Min	.1448	.1267	.1227	.0905	.1109	.1052	.1052
Avg	.2338	.2140	.2369	.2049	.1789	.1684	.1618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 204 / 11KV Paldongri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0566	.0724	.052	.0543	.0566	.052
2	.0543	.0566	.0724	.052	.0543	.0566	.052
3		.0566	.0724	.052	.0543	.0566	.052
4		.0566	.0543	.052	.0543	.0566	.0693
5		.0747	.0724	.0693	.0543	.0566	.0693
6		.0747	.0905	.0693	.0724	.0754	.0693
7		.0867	.0905	.0724	.0724	.0754	.0693
8	.0724	.0693	.0724	.0724	.0724	.0747	.0747
9	.0543	.052	.0543	.0724	.0724	.0747	.0747
10	.0543	.052	.0543	.0724	.0693	.0747	
11	.0543	.052	.0543	.0724	.052	.0747	
12	.0543	.052	.0543	.0724	.052	.0566	.0543
13	.0543	.052	.0543	.0543	.052	.0566	.0566
14	.0543	.0693	.0543		.052	.0566	.0377
15	.0543	.052	.0543		.0566	.0566	.0566
16	.0566	.0543	.052	.0543	.0566	.052	.0543
17	.0566	.0543	.052	.0724	.0566	.052	.0543
18	.0924	.0905	.0876	.1267	.1109	.0693	.0905
19	.1663	.1629	.1578	.1448	.1448	.1227	.1629
20	.1478	.1629	.1402	.1448	.1267	.1227	.1629
21	.1294	.1267	.1227	.0905	.0924		.1267
22	.0924	.1086	.0876	.0724	.0739	.0693	.0905
23	.0739	.0905	.0867	.0543	.0566	.052	.0724
24	.0543	.0739	.0724	.0693	.0543	.0566	.052
Max	.1663	.1629	.1578	.1448	.1448	.1227	.1629
Min	.0543	.052	.052	.052	.052	.052	.0377
Avg	.0753	.0766	.0765	.0757	.0695	.0676	.0752



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 205 / 11 kv mandvi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2534	.3077	.2103			
2	.2896	.2534	.3077	.2103			
3	.2896	.2534	.3077	.2103			
4	.2896	.2715	.3077	.2103			
5	.2896	.2896	.3258	.2629			
6	.3258	.3258	.362	.298			
8						.1086	.0377
9						.1448	.0377
10						.1109	
11						.1109	
12						.1109	
13					.0373	.1109	.0189
14					.0373	.1086	.0724
15					.0924	.1086	.0724
16					.1109		
17					.1109		
18					.0905		
21	.2353	.181	.1928				
22	.2715	.3077	.2279				
23	.2715	.3077	.2103				
24	.2534	.2534	.3077	.2103			
Max	.3258	.3258	.362	.298	.1109	.1448	.0724
Min	.2353	.181	.1928	.2103	.0373	.1086	.0189
Avg	.2787	.2697	.2857	.2303	.0799	.1143	.0478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 206 / 11KV Tiroda Town II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.4344	.4344	.4207	.3439	.3439	.2804
2	.0362	.4163	.4344	.4031	.3439	.3439	.2804
3	.0362	.4163	.4344	.3506	.3258	.3439	.2804
4	.0362	.4163	.4344	.3506	.3258	.3439	.2804
5	.0362	.4163	.4525	.333	.3077	.3439	.2804
6	.0362	.4706	.4525	.333	.3258	.3439	.2804
7	.0362	.4908	.5068	.362	.3982	.3801	.3506
8	.0362	.4557	.4344	.3982	.3681	.3982	.3982
9	.0362	.3506	.4163	.3801	.3856	.4706	.4163
10	.0362	.3856	.4344	.4163	.3856	.4525	
11	.0362	.4382	.4525	.4887	.4557	.4344	
12		.4382	.4887	.5068	.4733	.3439	.362
13		.4733	.4344	.4525	.4908	.3439	
14	.4344	.4207	.3801		.4382	.3077	
15	.3982	.4557	.3982		.3077	.3077	
16	.4163	.4344	.4031	.362	.3801	.2629	.3982
17	.5068	.5249	.4557	.4344	.3982	.298	.4344
18	.6516	.5611	.5316	.5068	.5068	.4382	.4525
19	.7783	.6878	.6379	.5792	.6516	.4908	.543
20	.6335	.543	.6024	.543	.5973	.4733	.5249
21	.6154	.5068	.4733	.4344	.4525		.4706
22	.5068	.4525	.5083	.4344	.4706	.3506	.3801
23	.4706	.4706	.4557	.3982	.3982	.298	.362
24	.0362	.4344	.4344	.4207	.362	.362	.2804
Max	.7783	.6878	.6379	.5792	.6516	.4908	.543
Min	.0362	.3506	.3801	.333	.3077	.2629	.2804
Avg	.2657	.4623	.4621	.4231	.4122	.3685	.3713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 201 / 11KV DAWNIWADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1629	.1543	.1543	.12		.1029
2	.1629	.1448	.1372	.1543	.12		.1029
3	.1629	.1448	.1372	.1715	.12		.12
4	.1629	.1629	.1543	.2058	.12		.12
5	.181	.181	.1715	.2058	.12		.1715
6	.2172	.1991	.2058	.2572	.1715		.1715
7	.2534	.2534	.2229	.2572	.1886		.1886
8	.2715	.2353	.2572	.2401	.1886	.2229	.1715
9	.2715	.1991	.2743	.2915	.1543	.1886	.1715
10	.2715	.3077	.2401	.3086		.1886	.1886
11	.3439	.2743	.2572	.3258	.0514	.2743	.2229
12	.2896	.2229	.2743	.3258	.0514	.2743	.2172
13	.2896	.2401	.2743	.2743	.2743	.1886	
14	.2715	.2058	.1886		.3258	.1715	.181
15	.2715	.2401	.2743		.3258	.2058	.2172
16	.2534	.2401	.2915		.2915	.1543	.2353
17	.2353	.2572	.2401		.2229	.1715	.181
18	.2715	.2743	.2572		.2401	.2058	.2353
19	.3439	.3601	.3601		.2572	.3086	.3258
20	.3258	.3258	.3429		.2915	.2743	.3077
21	.2896	.2743	.2915	.1698		.2058	.1629
22	.2172	.2058	.2401	.1886		.12	.1629
23	.181	.1715	.2058	.1372		.12	.1629
24	.181	.1629	.1543	.1715	.12		.1029
Max	.3439	.3601	.3601	.3258	.3258	.3086	.3258
Min	.1629	.1448	.1372	.1372	.0514	.12	.1029
Avg	.2459	.2269	.2336	.2258	.1877	.2047	.1837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 202 / 11KV DONGARGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2715	.2572	.2572	.0857	.0343	.2058
2	.3077	.2534	.2401	.2743	.0857	.0343	.1886
3	.2896	.2534	.2401	.2743	.0857	.0343	.1886
4	.3077	.2715	.2401	.3086		.0343	.2401
5	.3077	.3077	.2401	.3429		.0343	.2743
6	.3439	.3439	.2915	.3772		.0343	.3086
7	.3801	.4344	.3601	.3772		.0514	.3086
8	.3801	.4163	.3772	.4115		.1715	.3086
9	.362	.3982	.3944	.3772		.3429	.3429
10	.3801	.4163	.3944	.4458	.0686	.3772	.3086
11	.4163	.3944	.3772	.4115	.1543	.3086	.2572
12	.362	.4115	.3772	.4115	.1543	.3086	.2715
13	.3258	.3601	.3772	.3944	.2229	.2743	.2353
14	.362	.3772	.3772		.2229	.2572	.2353
15	.3439	.3772	.3601		.2229	.2572	.2534
16	.3982	.3772	.3429		.2401	.2058	.2715
17	.4163	.4115	.4115		.4287	.2572	.2353
18	.4525	.4287	.5316		.4287	.3258	.3982
19	.5792	.583	.5658		.4458	.5144	.543
20	.543	.5316	.4973	.1543	.4801	.4458	.5068
21	.4706	.4973	.4287	.1543		.3258	.3439
22	.3801	.1886	.3429	.1372			.3439
23	.2896	.2743	.2743	.0857		.2058	.2715
24	.3077	.2715	.2572	.2572	.0857	.0343	.2058
Max	.5792	.583	.5658	.4458	.4801	.5144	.543
Min	.2896	.1886	.2401	.0857	.0686	.0343	.1886
Avg	.3756	.3688	.3565	.3029	.2275	.2117	.2936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 203 / 11KV KACHEWANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0905	.0857	.0857	.0686	.0686	.0514
2	.1086	.0905	.0857	.0686	.0686	.0686	.0514
3	.1086	.0905	.0857	.0857	.0686	.0686	.0686
4	.1086	.0905	.0857	.0857	.0686	.0686	.0686
5	.1086	.1086	.1029	.0857	.0686	.0686	.0686
6	.1086	.1267	.12	.1029	.0857	.0857	.0857
7	.1086	.1086	.1029	.1029	.0857	.0857	.0857
8	.1267	.1267	.12	.1029	.0857	.1029	.0857
9	.1267	.1086	.1029	.0857	.0857	.0857	.1029
10		.1086	.1029	.1029	.0857	.1029	.1029
11	.1448	.1543	.1543	.1029	.0857	.0857	.0686
12		.1543	.1886	.1029	.0686	.0686	.0724
13	.1086	.12	.1886	.12	.0514	.0686	.0724
14	.0905	.1029	.1372		.0686	.0686	.0724
15	.1086	.1029	.1029		.0514	.0686	.0724
16	.1267	.1029	.1372		.0514	.0514	.0724
17	.1267	.0857	.1029	.0686	.0686	.0686	.1086
18	.1267	.12	.1372	.12	.0857	.12	.1991
19	.181	.1886	.1886	.1543	.12	.1886	.1629
20	.181	.1886	.1715	.1372	.1715	.1715	.1086
21	.1629	.1543	.1543	.1029		.1029	.1086
22	.1267	.12	.1372	.0686		.0857	.1086
23	.0905	.1029	.12	.0686		.0686	.0905
24	.1086	.0905	.0857	.1029	.0686	.0686	.0686
Max	.181	.1886	.1886	.1543	.1715	.1886	.1991
Min	.0905	.0857	.0857	.0686	.0514	.0514	.0514
Avg	.1226	.1182	.1250	.0980	.0792	.0872	.0899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 201 / 11 KV Sukadi (Dak)

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1629	.1772	.1663		.0181	.1629
2	.1595	.1629	.1772	.1663			.1629
3	.1543	.1629	.1595	.1663			.1448
4	.1949	.181	.2126	.1848			.1629
5	.1949	.2353	.2126	.2195			.181
6	.2658	.2715	.2835	.2561			.1991
7	.2743	.2534	.2835	.2743	.0377	.0724	.2353
8	.2303	.2172	.2126	.2561		.0181	.1991
9	.1991	.1991	.1663	.2012		.2353	.1991
10	.1448	.1629	.1663	.1848	.0566	.0362	
11	.1448	.1595	.1663	.181	.1663	.1991	
12	.1629	.1595	.2012	.2172	.0739	.0362	.1663
13	.1448	.1949	.1848	.1991	.1478	.1629	.1109
14	.1448	.2303	.1663		.1848	.181	
15	.1267	.1595	.1478		.1448	.1629	.1478
16	.1448	.1595	.1294	.2172	.1267	.2172	.1448
17	.1448	.1772	.1478	.1991	.1448	.2172	.181
18	.2534	.2835	.2743	.2743	.3077	.2896	.2353
19	.4163	.4075	.3982	.3658	.3982	.4344	.3801
20	.3982	.3898	.3801	.3292	.3801	.3982	.3801
21	.3439	.3366	.3475	.2926			.3258
22	.2534	.2481	.2561	.2012		.1991	1.7194
23	.181	.1949	.2012			.1629	.1991
24	.1772	.1629	.1949	.1848			.1629
Max	.4163	.4075	.3982	.3658	.3982	.4344	1.7194
Min	.1267	.1595	.1294	.1663	.0377	.0181	.1109
Avg	.2089	.2197	.2186	.2256	.1808	.1789	.2762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 202 / 11 KV Wadegao new

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6024	.5973	.6201	.5611	.4525	.3439	.3077
2	.5847	.5973	.6024	.543	.4525	.2896	.2715
3	.5493	.5973	.5847	.5611	.4525	.2715	.2715
4	.5493	.6697	.6201	.5611	.4344	.2896	.3439
5	.5487	.7059	.6379	.6089	.4344	.2715	.4706
6	.7087	.7059	.691	.6626	.543		.5792
7	.7619	.7059	.691	.7164	.543	.3077	.5068
8	.691	.724	.691	.7164	.543	.2534	.5068
9	.7421	.6335	.6447	.7164	.4706	.5249	.4525
10	.7087	.6878	.6805	.6626	.4525	.4887	
11	.6878	.691	.6447	.724	.3982	.4344	
12	.6697	.6379	.6268	.6878	.4163	.4163	
13	.6697	.691	.6089	.6335	.3982	.3801	
14	.6878	.6733	.6268		.3982	.3439	.3475
15	.6154	.691	.6626		.3801	.3801	.2926
16	.6335	.6733	.6626	.0905	.3801	.362	.362
17	.6516	.6556	.7164	.3077	.4163	.3982	.3439
18	.8145	.815	.8596	.2402	.6154	.4887	.4887
19	1.0136	1.0277	1.0454	.7522	.7964	.7602	.7783
20	.9774	.9922	.9568	.7164	.7421	.724	.7421
21	.8688	.8682	.8596	.6089	.4887		.6154
22	.6878	.691	.6805	.4525		.2172	.4344
23	.6154	.6379	.6089	.5249		.1991	.362
24	.6024	.6154	.6201	.5731	.5249		.3258
Max	1.0136	1.0277	1.0454	.7522	.7964	.7602	.7783
Min	.5487	.5973	.5847	.0905	.3801	.1991	.2715
Avg	.6934	.7077	.6935	.5737	.4879	.3879	.4402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 204 / 11 Kv Tirora Urban AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /  
OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0724	.0532	.0554	.0373		.0181
2	.0709	.0886	.0532	.0554	.0373		.0181
3	.0709	.0724	.0532	.0554	.0373		.0181
4	.0709	.0905	.0532	.0554	.0373		.0181
5	.0709	.0724	.0532	.0554	.0373		.0181
6	.0709	.0543	.0532	.0554	.0373		.0181
7	.0857	.0724	.0739	.0554	.0373		.0905
8	.0709	.0905	.0924	.0739	.0373		.0905
9	.0724	.0905	.0924	.0554	.0373	.0362	.0181
10	.0724	.1267	.0924	.0739	.0373		
11	.0724	.1063	.0924	.0709	.0373	.0181	
12	.0905	.0886	.0924	.0724	.0373	.0181	.0189
13	.0724	.1063	.1109	.0724	.0373	.0181	.0189
14	.0905	.1063	.0739		.0373	.0181	.0189
15	.0905	.1063	.0924		.0362	.0181	.0189
16	.1086		.0924	.0362	.0181	.0181	.0177
17	.1086	.0886	.0739	.0543	.0181	.0181	.0181
18	.0905	.0886	.0739	.0554	.0181	.0181	.0181
19	.1086	.0709	.0554	.0554	.0362	.0181	.0362
20	.0724	.0709	.0554	.0554	.0181	.0181	.0362
21	.0724	.0732	.0554	.0554	.0181		.0362
22	.0724	.0709	.0554	.0554		.0181	.0362
23	.0724	.0532	.0554	.0373		.0181	.0362
24	.0549	.0724	.0549	.0554	.0373		.0181
Max	.1086	.1267	.1109	.0739	.0373	.0362	.0905
Min	.0532	.0532	.0532	.0362	.0181	.0181	.0177
Avg	.0786	.0841	.0710	.0576	.0328	.0195	.0289



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 201 / KARTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3856	.3601	.3258		.1715	.2149
2	.3258		.3521	.3258		.1677	.2149
3	.2896	.3681	.3521	.3258		.1677	.2149
4	.2896	.3681	.3772	.3258		.2058	.2149
5	.3258	.3856	.3772	.362		.2229	.2149
6	.3982	.4207	.4382	.4163		.2629	.2686
7	.394	.4557	.4607	.4252		.2896	.3045
8	.3982	.4508	.4938	.4617		.2439	.3155
9	.2303		.2572	.4075		.2401	.2883
10	.2629	.2401	.2481	.4239		.2896	
11	.2279	.1966	.2835	.3856		.2658	
12	.2804	.218	.2481	.3605		.2658	.333
13	.2103	.2012	.2658	.3749	.0503	.2658	.298
14	.2103	.1677	.2715		.1269	.2481	.3052
15	.2103	.2105	.2481		.1429	.2658	.3155
16	.2279	.2347	.2658		.1593	.2507	.3506
17	.3018	.1966	.4252		.192		.3506
18	.373	.4458	.5138		.4382	.3155	.4031
19	.5792	.5784	.5611		.4287	.4435	.4557
20	.5792	.5487	.5249		.4287	.4207	.5068
21	.5068	.4908	.4887		.2915		.4024
22	.4382	.4458	.4163		.2515	.2279	.3086
23	.3856	.3944	.362		.2279	.2103	.2835
24	.3258	.3856	.3601	.3258		.1886	.2149
Max	.5792	.5784	.5611	.4617	.4382	.4435	.5068
Min	.2103	.1677	.2481	.3258	.0503	.1677	.2149
Avg	.3374	.3541	.3730	.3748	.2489	.2559	.3082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 202 / ARJUNI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1486	.181		.0572	
2	.1867		.1677	.1629		.0303	
3	.181	.1715	.1677	.1629		.04	
4	.1629	.1543	.1715	.1629		.0326	
5	.181	.1715	.1638	.181		.0734	
6	.2534	.2229	.2229	.2172		.1027	
7	.2534	.2229	.2401	.2353		.1219	
8	.2507	.2058	.218	.2353		.1027	.0693
9	.2149	.2058	.208	.2172		.1341	.0693
10	.2058	.1524	.2135	.208		.1629	
11	.1715	.1715	.2126	.1734		.1949	
12	.1886	.1677	.2149	.1715		.1791	.1886
13	.2058		.2149	.1372		.197	.1715
14	.2058	.1429	.2303			.1417	.1543
15	.2229	.1334	.2126			.1417	.1715
16	.2058	.1715	.2303		.16	.1448	.1174
17	.208	.1524	.2658		.141	.1387	
18	.2427	.2134	.2715		.1429	.1734	.1844
19	.3467	.3222	.3439		.208	.2601	.3018
20	.3294	.3018	.3077		.184	.2427	.2915
21	.2947	.2591	.2534		.1429		.2229
22	.2401	.2347	.2353		.0572		.1677
23	.1886	.2012	.1991		.0572		.1619
24	.181	.1715	.1677	.181		.0587	
Max	.3467	.3222	.3439	.2353	.208	.2601	.3018
Min	.1629	.1334	.1486	.1372	.0572	.0303	.0693
Avg	.2209	.1965	.2201	.1876	.1367	.1300	.1748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 203 / SONEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3113	.3688	.3258		.1128	.176
2	.3077		.373	.3258		.1143	.16
3	.3045	.2949	.39	.3258		.0846	.16
4	.3077	.2949	.3856	.3258		.0987	.16
5	.3077	.3113	.4024	.3801		.141	.176
6	.3439	.3441	.4359	.4075		.1829	.2126
7	.3898	.3932	.4748	.4607		.2347	.2481
8	.3721	.4001	.4458	.5258		.218	.2058
9	.4252	.427	.4801	.5316		.2294	.2035
10	.4239	.4191	.4908	.4784		.197	
11	.373	.4588	.4908	.5426		.1949	
12	.4239	.4458	.4908	.4725		.124	.1865
13	.4239		.4908	.4089		.2126	.2204
14	.3561	.3688	.4908			.1949	.1357
15	.4239	.4578	.4607			.1949	.2374
16	.4578	.463	.5316		.12	.2303	.2515
17	.3475	.4049	.4784		.1551	.1898	.2143
18	.4218	.5144	.5138		.213	.2601	.2683
19	.4733	.6201	.591		.3185	.3696	.3601
20	.4681	.5847	.5611		.285	.3475	.3641
21	.4115	.463	.4607		.1677		.3086
22	.3441	.4382	.3982		.1429	.1928	.2347
23	.3113	.4075	.362		.1677	.1638	.2427
24	.3045	.3113	.3688	.3439		.1128	.176
Max	.4733	.6201	.591	.5426	.3185	.3696	.3641
Min	.3045	.2949	.362	.3258	.12	.0846	.1357
Avg	.3763	.4152	.4557	.4182	.1962	.1914	.2228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 204 / 11 KV AGP Paraswada  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2921	.2743	.3239		.0442	
2	.3239			.3239		.0572	.0377
3	.3239	.306	.2713	.3239		.0564	.0377
4	.3239	.3199	.285	.3239		.0587	.0377
5	.3401	.3338	.3086	.3605		.0587	.0377
6	.3725	.3616	.3681	.3725		.0419	.0377
7	.0724		.0667	.1267		.0419	.0377
8	.0886		.0705	.1612		.0914	.1286
9	.124		.1174	.1612		.1143	.153
10	.1174		.1433	.2033		.1372	
11	.1174		.124	.2054		.1949	
12	.1006		.181	.1867		.1578	.1844
13	.1677		.1629				.1677
14	.1844	.0564	.181			.1928	
15	.1844	.1429	.2172			.1928	
16	.1677	.1219	.1772			.0354	.0198
17	.2054	.0947	.1595			.0566	.0251
18	.1848	.0846	.1417		.0419	.0377	.0213
19	.1294	.0564	.1267		.0564	.0566	.032
20	.0949	.0587	.1267		.0351	.0377	.0257
21	.3321	.285	.3077		.0419		.032
22	.306	.298	.3239		.0419	.0377	.0251
23	.2921	.298	.3401		.0419	.0377	.0303
24	.3239	.2921	.2683	.3401		.0503	.0377
Max	.3725	.3616	.3681	.3725	.0564	.1949	.1844
Min	.0724	.0564	.0667	.1267	.0351	.0354	.0198
Avg	.2167	.2126	.2062	.2626	.0432	.0814	.0584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-FEB-18 and 14-FEB-18

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 407 / 33 KV Paraswada

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-FEB-18	09-FEB-18	10-FEB-18	11-FEB-18	12-FEB-18	13-FEB-18	14-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	1.1065	1.1174	1.0688		.3344	.2721
2	.9831	1.1317	1.0688	1.0311		.3601	.2721
3	.9339	1.1065	1.0437	1.0311		.3601	.2721
4	.9339	1.1065	1.0911	1.0311		.4001	.2801
5	.9831	1.0174	1.1523	1.1248		.4527	.2801
6	1.0974	1.0288	1.2963	1.2654		.5007	.3201
7	.7773	.9374	1.0059	.9842		.5075	.3292
8	.7133	.9031	.9482	1.0185		.5498	.5075
9	.7316	.6859	.8688	1.0814		.643	.5944
10	.7773	.6401		1.0974		.643	
11	.6859	.6481	.9122	1.094		.6859	
12	.7316	.6167	.8642	1.0442		.6001	.5213
13	.7773	.6241	.8642	.9374		.5144	.535
14	.7316	.6722	.9122			.643	.6241
15	.7773	.7865	.8259		.2286	.6859	.6241
16	.8259	.8848	.9717		.427	.4515	.5944
17	.8951	.8356	1.0688		.57	.4572	.5487
18	.8951	1.1174	1.166		.503	.5487	.6859
19	.9556	1.3763	1.3603		.9145	.7773	.9145
20	1.1317	1.3117	1.2631		.8145	.7316	.9145
21	1.286	1.4089	1.4089		.5144	.5213	.7316
22	1.2574	1.3117	1.2631		.4024	.2469	.5487
23	1.1568	1.2146	1.166		.3658	.2469	.535
24	1.0322	1.0814	1.0688	1.0688		.2926	.2721
Max	1.286	1.4089	1.4089	1.2654	.9145	.7773	.9145
Min	.6859	.6167	.8259	.9374	.2286	.2469	.2721
Avg	.9189	.9814	1.0743	1.0627	.5267	.5064	.5081