

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 201 / 11 KV SAJAPUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1132	.1132	.0339	.0366	.0492	.0328
2	.1097	.1132	.0943	.0339	.0366	.0328	.0366
3	.0914	.132	.1132	.0339	.0366	.0328	.0509
4	.128	.1698	.132	.0339	.0366	.0492	.0514
5	.1696	.2054	.1509	.0328	.0366	.0655	.0848
6	.1829	.2614	.2452	.0514	.0543	.0492	.0905
7	.2195	.2801	.3018	.0549	.0716	.0655	.128
8	.2195		.2829	.1029	.1075	.1638	.168
9	.1097	.2054	.1646	.0848	.0895	.0983	.0686
10	.0747	.1578	.0848	.1052	.1052	.0876	.1578
11	.0351	.0351	.0339	.0701	.0876	.0876	.0701
12	.0526	.0526	.0366	.0701	.1052	.0526	.0701
13	.0526	.0351	.0366	.0526	.0701	.0701	.0701
14		.0526	.0549	.0351	.0701	.0701	.0351
15	.0526	.0526	.0566	.0526	.0526	.0701	
16	.0351	.0526	.0549	.0526	.0701	.0701	
17	.0351	.0526	.0514	.0701	.0526	.0701	.0701
18	.0543	.0492	.2204	.1132	.1132	.1097	.1509
19	.2054	.2075	.2204	.1867	.1886	.112	.2241
20	.2241	.2263	.213	.1698	.2641	.2896	.2801
21	.1698	.1509	.2012	.168	.1132	.2241	.2241
22	.1698	.132	.128	.1509	.132	.1267	.1698
23	.1509	.1132	.128	.132	.0943	.128	.1509
24	.1097	.132	.1132	.0339	.0366	.0492	.0339
Max	.2241	.2801	.3018	.1867	.2641	.2896	.2801
Min	.0351	.0351	.0339	.0328	.0366	.0328	.0328
Avg	.1201	.1297	.1347	.0802	.0859	.0927	.1099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 202 / 11KV DAULATABAD FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5487	.5243	.5765	.5144	.5243	.5256
2	.5426	.5316	.4915	.5596	.4973	.4915	.5256
3	.5426	.5487	.5243	.5765	.5144	.5079	.506
4	.5765	.6001	.5407	.5735	.5487	.5243	.5407
5	.6173	.6516	.5571	.6104	.583	.5407	.5533
6	.6613	.703	.6062	.6274	.6001	.639	.6371
7	.7122	.6859	.639	.6554	.6001	.6226	.6274
8			.6062	.6226	.6516	.6554	.695
9	.7499	.6173	.6104	.6613	.6344	.6718	.6767
10	.6274	.6135	.6516	.6836	.631	.7011	.6661
11	.7712		.6274	.5784	.6661	.6135	.5959
12	.7362	.5434	.5426	.5784	.5959	.5784	.5959
13	.6836	.631	.5596	.5609	.5434	.5609	.6135
14	.5784		.5765	.5784	.5434	.5609	.5609
15	.631	.5959	.6104	.5784	.5784	.6485	
16	.6661	.6485	.6516	.631	.6135	.5959	.631
17	.7186	.7186	.6882	.7011	.5959	.7011	.6485
18	.7716	.6554	.7682	.6173	.6554	.695	.6001
19	.6173	.6882	.6783	.6516	.7356	.6859	.7202
20	.6516	.6882	.6783	.6859	.8488	.7421	.7545
21	.6516	.6226	.7316	.6516	.6554	.6859	.7202
22	.6344	.6062	.695	.6344	.5898	.6767	.6859
23	.6001	.5898	.5935	.6001	.5571	.6401	.6344
24	.6219	.5487	.5407	.5975	.5487	.5243	.5426
Max	.7716	.7186	.7682	.7011	.8488	.7421	.7545
Min	.5426	.5316	.4915	.5596	.4973	.4915	.506
Avg	.6507	.6208	.6122	.6163	.6043	.6162	.6199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 203 / 11KV FATIYABAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1928	.1802	.695	.7095	.7167	.7059
2	.1543	.1753	.1966	.6697	.6722	.7356	.6878
3	.1509	.2103	.1802	.6878	.7095	.7545	.7059
4	.1715	.2279	.1966	.724	.7655	.7922	.7602
5	.1638	.2629	.1966	.763	.8589	.811	.8145
6	.1865		.3605		.8962	.9808	1.0242
7	.2572	.5487	.4588	.9328	.9522	.9242	.905
8			.5571	.8775	.8402	.7922	.7865
9	.5365	.583	.4458	.7499	.8029	.7356	.7316
10	.6535	.631	.5975	.5959	.5784		.5784
11	.6135		.5975	.3856	.298	.3681	.4031
12	.4908	.6135	.6401	.4382	.3681	.298	.4207
13	.5258	.6485	.6335	.3506	.3681	.4031	.4207
14	.631	.5258	.6104	.3681	.3856	.3506	.3506
15	.6485	.6135	.6767	.3681	.4382	.3856	.333
16		.6135	.695	.3856	.4031	.5258	.4382
17	.6661	.5959	.724	.4733	.4908	.5959	.3856
18	.8215	.7167	.4801	.3772	.3768	.3982	.463
19	.9149	.7922	.8507	.8215	.7356	.8145	.8775
20	1.0269	.9431	.9694	.9709	.9242	.8669	1.0082
21	.9522		.8478	.9335	.9242	.905	.9522
22	.8775	.8299	.8478	.8775	.8488	.8596	.8962
23	.7842	.7922	.7783	.7842	.7545	.7682	.8215
24	.2012	.2241	.1802	.7655	.7468	.7167	.724
Max	1.0269	.9431	.9694	.9709	.9522	.9808	1.0242
Min	.1509	.1753	.1802	.3506	.298	.298	.333
Avg	.5272	.5370	.5376	.6520	.6603	.6739	.6748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 204 / PARAS INDUSTRIAL Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
15		.4733
20	***	
Max	14.5222	.4733
Min	14.5222	.4733
Avg	14.5222	.4733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 205 / ASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2804	.2785	.7356	.6535	.6979	.7167
2	.2713	.2629	.2622	.7167	.6348	.679	.6979
3	.2883	.2804	.2949	.743	.6722	.7167	.743
4	.3222	.3155	.3277	.7811	.7095	.7356	.7682
5	.3391	.4287	.3441	.8192	.7655	.7545	.811
6	.39	.5316	.4752	1.105	1.0456	1.1317	1.105
7	.4752	.4973	.5079	.9619	.9709	.8865	.9907
8			.5243	.8002	.7842	.415	.7499
9	.4409	.4801	.4578	.679	.7095	.6413	.6584
10	.5658	.5434	.5525	.4031	.5609	.4908	.5784
11	.5258		.5281	.4031	.298	.3681	
12	.5434			.4207	.3856	.4207	.3681
13	.4733			.4031	.2454	.4207	.3856
14	.3506			.3506	.2454	.4733	
15	.5434			.3506	.333		.333
16	.5609			.4031	.3681	.3856	.4733
17	.5609		.724	.3856	.4031	.4207	.4908
18	.6722	.8676	.8002	.3155	.3395	.4372	.4801
19	.8029	.8676	.8488	.7468	.811	.7811	.7655
20	.8402	.9808	.8648	.9149	.9054	.9145	.9335
21	.8029	.8676	.9145	.8589	.811	.8192	.8402
22	.7655	.8676	.9145	.8029	.7733	.7811	.7655
23	.7282	.7733	.8002	.8962	.7167	.724	.7095
24	.2591	.3174	.2785	.7621	.6908	.6979	.6859
Max	.8402	.9808	.9145	1.105	1.0456	1.1317	1.105
Min	.2591	.2629	.2622	.3155	.2454	.3681	.333
Avg	.5145	.5726	.5631	.6566	.6180	.6432	.6841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 206 / 11 KV JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7842	.8299	.4748	.4801	.3277	.4854
2	.7621	.7468	.8488	.4458	.4458	.3441	.4572
3	.7842	.8215	.8865	.5068	.4801	.3768	.4887
4	.8676	.8962	.9431	.5087	.5144	.4096	.4917
5	.9431	1.0829	1.0185	.6104	.5487	.4915	.5144
6	1.1584	1.2936	1.358	.8916	.8817	.6882	.7842
7	1.358	1.2936	1.2449	.9496	.9503	1.0814	1.0159
8			1.3203	.9496	.9945	.9175	.8192
9	.9526	.8589	.9526	.8192	.6783	.852	.7712
10	.7621	.631	.7468	.5609	.4908	.7362	.631
11	.1753		.5765	.5258	.3506	.5959	.5258
12		.3856	.6783		.2454	.5609	.4908
13	.4557	.2454	.6173			.4557	.2454
14	.2804	.5258	.5426			.5258	.4908
15	.4207	.2629	.4409			.5609	.5258
16	.5258	.4207				.4908	.5609
17	.5609	.5959				.5959	.4908
18	.3429	.4588	.6584		.679	.7122	.7095
19	.9335	1.094	.7545	1.0456	.9431	1.0562	1.0082
20	.7842	1.2826	1.3336	1.3306	1.2071	1.2193	1.1949
21	1.0082	1.0185	1.2193	1.2323	1.094	1.105	1.0456
22	.9335	.9431	.9907	1.0456	.9808	1.0669	.9335
23	.8589	.8589	.8383	.8215	.9619	.9145	.8215
24	.8002	.7842	.8676	.4748	.4801	.3605	.3887
Max	1.358	1.2936	1.358	1.3306	1.2071	1.2193	1.1949
Min	.1753	.2454	.4409	.4458	.2454	.3277	.2454
Avg	.7486	.7857	.8940	.7761	.7056	.6852	.6621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 207 / SHAHAPUR BANJARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.2103	.213	.4191	.3921	.415	.415
2	.1543	.2103	.1966	.4001	.3734	.3961	.3734
3	.1526		.213	.4001	.4108	.4338	.3982
4	.1696		.2294	.4382	.4854	.5093	.407
5	.1865		.2829	.5144	.5601	.5658	.4748
6	.2743		.4424	.7049	.6722	.7356	.7733
7	.3222		.5079	.7049	.6722	.415	.7621
8			.4915	.4382	.5228	.0377	.4904
9	.3391		.4409	.4191	.4294	.3772	.4001
10	.2543	.2629	.3048	.333	.333	.3155	.3856
11	.2279		.2858	.3856	.298	.2804	.3856
12				.4031	.2804	.3155	.3856
13				.3681	.2804	.3155	.4557
14	.2629			.2629		.3856	.3856
15				.3155	.3506	.2454	.298
16	.2804			.2804			.3856
17	.2804		.3395	.1753	.333		.4382
18	.3361	.3961	.4191	.2804	.3932	.2801	.3814
19	.5228	.547	.4763	.4294	.4715	.5716	.4294
20	.5975	.6036	.6413	.5975	.6036	.6602	.6535
21	.5788	.6036	.5716	.5601	.5658	.5716	.5601
22	.5228	.5281	.5335	.5228	.4715	.4382	.4854
23	.4668	.4715	.4382	.4481	.4338	.4191	.4108
24	.1638	.2427	.2452	.4191	.4108	.415	.3961
Max	.5975	.6036	.6413	.7049	.6722	.7356	.7733
Min	.1457	.2103	.1966	.1753	.2804	.0377	.298
Avg	.3119	.4076	.3828	.4258	.4429	.4136	.4555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 208 / Paper Mill (Saptashrunji) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2427	.415	.3258	.2987	.2829	.2427
2	.3658	.2241	.3772	.3239	.2801	.3018	.2263
3	.3439	.2614	.3961	.2883	.2987	.2829	.2054
4	.362	.2801	.3772	.3292	.2801	.3206	.2035
5	.3439	.2987	.3961	.3222	.2614	.3395	.2054
6	.362	.3361	.3772	.3292	.2801	.3772	.1867
7	.3801	.3174	.3584	.3475	.3174	.3206	.2195
8			.3961	.3475	.3734	.3772	.2195
9	.3658	.2987	.3841	.3109	.3547	.3206	.2378
10	.3801	.3856	.3561	.2804	.3681	.4382	.2804
11	.2454		.4294	.3155	.2103	.4207	.1753
12		.3506	.4207	.333	.3155	.298	.2804
13		.333	.3561	.333	.3681	.3155	.2804
14		.3856	.3391	.3506	.3681	.2454	.2454
15		.3506	.4755	.333	.3155	.2103	.1578
16		.2804	.3361	.2804	.3856	.2454	.2103
17	.2103	.4557	.2561	.2279	.3506	.2804	.2103
18	.2614	.3584	.2561	.4066	.3018	.2054	.2614
19	.2801	.3395	.2374	2.6699	.3395	.2172	.1867
20	.2427	.3206	.2543	.1867	.2641	.2241	.2241
21	.2241	.3206	.2374	.2801	.2829	.2614	.2241
22	.2241	.415	.3109	.2987	.2641	.2561	.2054
23	.2241	.3206	.3361	.2987	.3584	.2561	.2054
24	.3601	.2614	.3206	.3174	.3174	.3206	.1867
Max	.3801	.4557	.4755	2.6699	.3856	.4382	.2804
Min	.2103	.2241	.2374	.1867	.2103	.2054	.1578
Avg	.3079	.3244	.3500	.4099	.3148	.2966	.2200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 201 / 11KV Chowka Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.3429	.381	.2477	.1905	.2858
2	.2667	.2286	.3429	.381	.2667	.1905	.2858
3	.3048	.2858	.381	.381	.2858	.381	.381
4		.4001	.4572	.4763	.3048	.4954	.381
5		.5335	.5906	.4763	.381	.5716	.4763
6		.7049	.7049	.5716	.5716	.6668	.5716
7		.5716	.7049	.6668	.6859	.6478	.6668
8		.5335	.6097	.5716	.6478	.6478	.6668
9		.4763	.4763	.4191	.6668	.5144	.4572
10		.381	.362	.3239	.381	.3429	.3048
11		.2858	.3048	.2858	.2858	.2286	.2477
12		.2858	.2667	.2096	.2858	.2477	.2286
13			.2477	.1905	.2858	.2477	.2286
14			.2286	.1905	.1905	.2286	.2477
15	.0953		.2477	.2477	.1905	.2286	.2096
16	.2858		.2667	.1905	.1905	.2858	.1905
17	.3239	.3048	.2858	.2286	.2477	.2858	.2477
18	.4191	.4001	.381	.2667	.3239	.381	.3429
19	.5335	.5335	.5716	.5144	.5335	.4763	.4382
20	.5906	.4954	.4763	.4382	.6478	.5716	.5335
21	.4954	.4382	.381	.3429	.5144	.4763	.381
22	.362	.362	.381	.3048	.381	.381	.3429
23	.2667	.3429	.381	.2667	.2667	.2858	.2667
24	.2286	.2477	.3429	.381	.2286	.2096	.2858
Max	.5906	.7049	.7049	.6668	.6859	.6668	.6668
Min	.0953	.2286	.2286	.1905	.1905	.1905	.1905
Avg	.3400	.4020	.4056	.3628	.3755	.3826	.3612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 202 / 11 KV SAWANGI Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4191	.4763	.381	.4382		.4763
2	.4382	.4191	.4763	.381	.4382		.4763
3	.4763	.4763	.5144	.381	.4382		.4763
4		.5335	.5335	.4763	.4763		.4763
5		.5716	.5716	.4763	.5335		.5716
6		.5716	.5716	.5716	.6859		.6668
7				.6668	.8764	.8764	.8573
8				.6668	.8002	.9145	.7621
9	.1524			.5906	.6668	.7621	.6668
10				.3429	.381	.4763	.4191
11			.7621	.381	.381	.4954	.4001
12			.8002	.4001	.381	.4763	.4763
13			.724	.4382	.381	.4763	.4572
14			.6859	.4763	.381	.4763	.4763
15	.5716		.5716		.381	.4191	.381
16	1.0479		.6097		.381	.4382	.4191
17	.9526	.6668	.5716		.5716	.4763	.5144
18	.7621	.6668	.5716	.5716	.5716	.5716	.5716
19	.5716	.5716	.4763	.5716	.5716	.4763	.5716
20	.5716	.5716	.381	.5716	.5716	.4763	.5716
21	.5716	.5716	.381	.5716	.5716	.4763	.5716
22	.4954	.5716	.381	.5144	.5144	.381	.5144
23	.4572	.4954	.381	.4763	.4763	.381	.4572
24	.4191	.4382	.4763	.381	.381		.381
Max	1.0479	.6668	.8002	.6668	.8764	.9145	.8573
Min	.1524	.4191	.381	.3429	.381	.381	.381
Avg	.5661	.5389	.5459	.4899	.5104	.5323	.5255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 203 / 11 KV CHOWKA Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0953	.0953	.0762	.0572	.0953
2	.1143	.0762	.0953	.0953	.0762	.0572	.0953
3	.1334	.0953	.1143	.0953	.0762	.0953	.0953
4		.1143	.1524	.0953	.0762	.0953	.0953
5		.1524	.1524	.1905	.0953	.1334	.0953
6		.1715	.1715	.1905	.1334	.1524	.1905
7		.3048	.362	.1905	.1334	.1715	.1905
8		.4191	.381	.1905	.1334	.0953	.1905
9			.3048	.1334	.1905	.1143	.1524
10			.1715	.1334	.0953	.1143	.1334
11			.1334	.1905	.1524	.1334	.1334
12	.1524		.1143	.2286	.2286	.1715	.1905
13			.1334	.2286	.2858	.2858	.2286
14			.1143	.2667	.1905	.2667	.1905
15	.0953		.1143	.2286	.1905	.2667	.2477
16	.0953		.1334	.2858	.1905	.3048	.2286
17	.2286	.0953	.1905	.2477	.1143	.2858	.3048
18	.1524	.0953	.1905	.1905	.1334	.1905	.2667
19	.1905	.0953	.1905	.1715	.1334	.1905	.1334
20	.1143	.0953	.1905	.1524	.1334	.1905	.1715
21	.0953	.0953	.0953	.1334	.0953	.0953	.1334
22	.0953	.0953	.0953	.1143	.0762	.0953	.1524
23	.0953	.0953	.0953	.0953	.0762	.0953	.1334
24	.0953	.0762	.0953	.0953	.0762	.0572	.0953
Max	.2286	.4191	.381	.2858	.2858	.3048	.3048
Min	.0953	.0762	.0953	.0953	.0762	.0572	.0953
Avg	.1252	.1346	.1620	.1683	.1318	.1548	.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 204 / Lingdari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0381	.0953	.0572	.0953	.0953
2	.0953	.0953	.1143	.0953	.0572	.0953	.0953
3	.0953	.1143	.1143	.0953	.1334	.1524	.0953
4		.1524	.1334	.0953	.0953	.1524	.1905
5		.1905	.1524	.0953	.1334	.1905	.1905
6		.2667	.1715	.0953	.1334	.1905	.1905
7		.2858	.1905	.0953	.1524	.2477	.2858
8		.2667	.1905	.0953	.1334	.1905	.2858
9			.1715	.0953	.0953	.1715	.1715
10			.1334	.0572	.0953	.1334	.1143
11			.1715	.0381	.0953	.1143	.1334
12			.1334	.0381	.0953	.1334	.0953
13			.1143	.0572	.0953	.0953	.0381
14			.0953	.0572	.0953	.0953	.0381
15	.1143		.0953	.0572	.0953	.0953	.0572
16	.1524		.0953	.0953	.0953	.0953	.0381
17	.1905	.2858	.0953	.0953	.0953	.0953	.0572
18	.3429	.1905	.0953	.0953	.1524	.1905	.0762
19	.1524	.1334	.0953	.0953	.2477	.1905	.0953
20	.1905	.1143	.0953	.0953	.2096	.0953	.1143
21	.1524	.1143	.0953	.0953	.1524	.0953	.1143
22	.1334	.0953	.0953	.0953	.1334	.0953	.0953
23	.1334	.0953	.0953	.0953	.1143	.0953	.0762
24	.0762	.1143	.0953	.0953	.0572	.0953	.0953
Max	.3429	.2858	.1905	.0953	.2477	.2477	.2858
Min	.0762	.0953	.0381	.0381	.0572	.0953	.0381
Avg	.1466	.1631	.1199	.0842	.1175	.1334	.1183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 205 / Sawangi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0288	1.1431	.7621	.7621	1.086	.9526
2	1.1431	1.0098	1.1431	.8573	.7621	1.0479	1.1431
3	1.1812	1.105	1.2384	.9526	.9145	1.2574	1.3336
4		1.2765	1.3336	1.1431	1.105	1.3908	1.4289
5		1.6194	1.6194	1.3336	1.1431	1.6766	1.5242
6		1.7528	1.8099	1.5242	1.3336	1.8671	1.6194
7		1.6194	1.8861	1.7147	1.5623	2.0576	1.7147
8		1.7147	1.7147	1.6194	1.448	1.5242	1.7147
9			1.5242	1.3717	1.1431	1.3336	1.2955
10			1.1431	1.1431	.9526	1.1431	1.1431
11			1.105	1.0288	.8002	1.0288	1.0288
12			.9526	.9717	.6668	.9526	.9526
13			.9526	.8764	.6668	.8573	.9145
14			.9145	.8383	.6668	.8573	.8573
15	.6668		.9526		.7621	.8573	.9526
16	1.0479		.9907		.8573	.9526	1.0098
17	1.6194	1.0479	1.0479		1.2574	.9526	1.1431
18	1.7718	1.2955	1.1431	1.4861	1.5242	1.1431	1.3336
19	1.8671	1.6194	1.5242	1.7147	1.5623	1.3336	1.5623
20	1.9433	1.4289	1.3336		1.7147	1.5242	1.7147
21	1.6575	1.3336	1.1431	1.4861	1.5432	1.4289	1.4861
22	1.4861	1.2384	.9526	1.3336	1.3336	1.1431	1.3336
23	1.3336	1.1431	.7621	1.1431	1.2384	.9526	1.1431
24	1.0288	1.1812	1.1431	.7621	.7621	1.1431	.9526
Max	1.9433	1.7528	1.8861	1.7147	1.7147	2.0576	1.7147
Min	.6668	1.0098	.7621	.7621	.6668	.8573	.8573
Avg	1.3703	1.3384	1.2281	1.2031	1.1034	1.2296	1.2606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 206 / 11 KV Tuljapur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.2858	.2858	.2858		.381
2	.2667	.2858	.2858	.2858	.2858		.381
3	.2667	.3048	.2858	.2858	.3048		.381
4		.3239	.2858	.2858	.3048		.381
5		.3429	.2858	.2858	.3048		.381
6		.3429	.2858	.2858	.362		.2858
7		.3048	.2858	.2858	.4572	.3048	.2858
8		.2858	.3239	.381	.4382	.7621	.2858
9			.381	.381	.381	.5144	.5335
10			.4382	.381	.381	.7621	.5716
11			.4001	.3429	.4382	.5716	.4382
12			.381	.3239	.4763	.5144	.4382
13			.3429	.4001	.4763	4.8773	.4954
14			.3048	.362	.381	.4572	.2858
15	.2858		.3048	.3429	.381	.4572	.3429
16	.2858		.3429	.3429	.381	.4191	.362
17	.2477	.3048	.2858	.3429	.3048	.381	.381
18	.3048	.3048	.2858	.362	.3239	.2858	.4001
19	.3429	.3048	.2858	.381	.3429	.381	.4382
20	.3239	.2858	.2858	.362	.4191	.381	.362
21	.3048	.2858	.2858	.362	.5335	.381	.3429
22	.3239	.2858	.2858	.3429	.5335	.381	.3429
23	.3429	.2858	.2858	.3048	.4382	.381	.3048
24	.2477	.3048	.2858	.2858	.2667		.381
Max	.3429	.3429	.4382	.4001	.5335	4.8773	.5716
Min	.2477	.2858	.2858	.2858	.2667	.2858	.2858
Avg	.2916	.3024	.3128	.3334	.3834	.7184	.3826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 207 / 11 KV Unique Stone crusher SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381	.0381	.0191	.0381	.0381
2	.0191	.0381	.0381	.0381	.0191	.0381	.0381
3	.0191	.0381	.0381	.0381	.0191	.0381	.0381
4	.0191	.0381	.0381	.0381	.0191		.0381
5		.0381	.0381	.0381	.0191		.0381
6		.0572	.0038	.0381	.0191		.0381
7		.0572	.0381	.0381	.0191	.0572	.0381
8		.0381	.0381	.0381	.0191	.0572	.0572
9			.0381	.0572	.0381	.0191	.0572
10			.0381	.0381	.0381	.0191	.0381
11			.0191	.0381	.0381	.0191	.0572
12			.0191	.0381	.0381	.0381	.0572
13			.0191	.0381	.0381	.0381	.1524
14			.0381	.0381	.0381	.0381	.1334
15	.0381		.0191	.0381	.0381	.0381	.0572
16	.0381		.0191	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0191	.0572	.0381	.0572
18	.0381	.0381	.0381	.0191	.0381	.0381	.0381
19	.0381	.0381	.0381	.0191	.0381	.0381	.0572
20	.0381	.0381	.0381	.0191	.0381	.0381	.0191
21	.0381	.0381	.0381	.0191	.0381	.0381	.0191
22	.0381	.0381	.0381	.0191	.0381	.0381	.0191
23	.0381	.0381	.0381	.0191	.0381	.0381	.0191
24	.0191	.0381	.0381	.0381	.0191	.0381	.0381
Max	.0381	.0572	.0381	.0572	.0572	.0572	.1524
Min	.0191	.0381	.0038	.0191	.0191	.0191	.0191
Avg	.0313	.0405	.0327	.0334	.0318	.0372	.0492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 201 / 11KV GROWTH CENTRE I

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2254	1.2003	1.2384	1.2071	1.2384	1.2193	1.262
2	1.1888	1.1622	1.2193	1.1888	1.2193	1.1812	1.1888
3	1.134	1.1431	1.105	1.1888	1.1812	1.1431	1.2254
4	1.0974	1.0669	1.0479	1.1523	1.105	1.105	1.1523
5	1.0974	.9526	.9907	1.1157	1.0669	1.0479	1.0791
6	1.0425	.8573	.8573	1.0791	1.0479	1.0479	1.0425
7	1.0059	.9717	.8573	1.0059	2.21	1.0288	1.0059
8	.9694	.9526	.8573	.823	.9526	.9717	.823
9	.8048	.8573	1.0288	.7865	1.0479	.8192	.823
10	.8573	.8002	.8048		.8954	.7499	.8573
11	.8192	.7811	.7865	.7865	.8192	.6767	.8573
12		.8002	.6401	.6668	.6668	.6767	.8573
13		.8573	.6401	.6668	.7049	.7499	.8573
14		1.0098		.6668	.6668	.7682	.7049
15		1.0479	.7865	.6859	.8573	.7865	.7621
16	1.0479	.8002	.7499	.8573	.8573	.7499	.8002
17	1.0098	.8192	.7499	.8573	.6668	.7865	.8573
18	.8573	.8573	.6401	.7811	.6668	.7499	.8192
19		.8383	.8048	.8573	.8573	.9328	.8954
20	1.2003	1.0479	1.0059	1.0098	1.0479	1.0059	1.0479
21	1.2384	1.0479	1.0425	1.2003	1.1431	1.0974	1.0479
22	1.2003	1.1431	1.1523	1.2193	1.2003	1.1888	1.2765
23	1.2193	1.2765	1.1888	1.2384	1.2384	1.262	1.2384
24	1.1888	1.2003	1.2384	1.2254	1.2384	1.2574	1.2254
Max	1.2384	1.2765	1.2384	1.2384	2.21	1.262	1.2765
Min	.8048	.7811	.6401	.6668	.6668	.6767	.7049
Avg	1.0634	.9788	.9319	.9681	1.0248	.9584	.9878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 202 / 11KV A.S.CLUB FEEDER Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0191	.0381	.1097	.0191	.0191	.0732
2	.0549	.0381	.0381	.1097	.0381	.0191	.0732
3	.0549	.0381	.0572	.1097	.0381	.0381	.0732
4	.0549	.0381	.0762	.1097	.0572	.0572	.0914
5	.0549	.0572	.0953	.1463	.0572	.0953	.128
6	.0549	.0572	.1143	.1463	.0762	.1143	.1646
7	.0732	.1715	.2858	.1829	.1524	.2286	.2195
8	.1829	.1905	.3429	.2195	.2477	.2667	.1829
9	.1829	.1905	.1905	.1829	.2096	.2477	.1829
10	.0762	.0381	.0549		.0762	.0366	.0572
11	.0762	.0762	.0549	.0732	.0572	.0366	.0572
12	.0572	.0572	.0549	.0953	.0572	.0366	.0572
13	.0572	.0572	.0366	.0762	.0762	.0366	.0381
14	.0572	.0762	.0366	.0762	.0572	.0366	.0381
15	.0381	.0762	.0366	.0572	.0572	.0366	.0572
16	.0572	.0572	.0549	.0762	.0762	.0366	.0572
17	.0953	.0572	.0366	.0762	.0762	.0549	.0762
18	.1143	.0572	.0732	.0762	.0953	.0549	.0762
19	.0953	.1334	.0732	.0762	.1143	.0732	.0953
20	.0762	.0572	.1097	.0953	.1143	.1097	.0953
21	.0762	.0381		.0762	.0762	.0732	.0572
22	.0381	.0381		.0572	.0572	.0549	.0572
23	.0381	.0381	.0549	.0572	.0381	.0732	.0572
24	.0549	.0191	.0953	.1463	.0191	.0191	.0732
Max	.1829	.1905	.3429	.2195	.2477	.2667	.2195
Min	.0381	.0191	.0366	.0572	.0191	.0191	.0381
Avg	.0740	.0699	.0914	.1057	.0810	.0773	.0891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 204 / 11KV Growth Center II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.4572	.4572	.4024	.4382	.4191	.439
2	.2012	.4382	.4382	.4207	.4382	.4001	.4207
3	.1829	.4382	.4191	.4207	.4191	.4001	.4207
4	.1829	.4001	.4572	.4207	.4001	.381	.4024
5	.1646	.4001	.4001	.4207	.4001	.362	.4024
6	.1463	.381	.381	.3841	.362	.3429	.4024
7	.1097	.381	.381	.3658	.3429	.362	.3841
8	.1463	.362	.381	.3292	.3429	.3239	.3475
9	.128	.2858	.381	.3292	.3429	.3048	.2926
10	.1334	.3429	.3841		.4001	.3109	.3239
11	1.2765	.4001	.3841	.3109	.4001	.2926	.3048
12	.1143	.3429	.3475	.3048	.2858	.2926	.2667
13	.0953	.3429	.3292	.3429	.2667	.3109	.3048
14		.3239	.3109	.3239	.2667	.3109	.2667
15		.3048	.3292	.3048	.3048	.2926	.3048
16		.3239	.3475	.3239	.3239	.2926	.3048
17	.4001	.2858	.3292	.0762	.3048	.2926	.3429
18	.4382	.3239	.3292	.3429	.2667	.2926	.3048
19	.4954	.362	.3475	.3048	.8573	.3658	.3429
20	.4382	.4001	.439	.4001	.4382	.4207	.4191
21	.4763	.4382	.4207	.4572	.4763	.4755	.4001
22	.4954	.4572	.439	.4763	.4954	.5304	.5335
23	.4572	.4763	.439	.4954	.4382	.4755	.5335
24	.2012	.4572	.4572	.439	.4382		.4572
Max	1.2765	.4763	.4572	.4954	.8573	.5304	.5335
Min	.0953	.2858	.3109	.0762	.2667	.2926	.2667
Avg	.3088	.3802	.3887	.3651	.3937	.3588	.3718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 205 / 11KV Sara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6385	1.6575	1.6278	1.7147	1.6766	1.6278
2	1.6461	1.6004	1.6194	1.5729	1.7147	1.6194	1.5729
3	1.5912	1.5623	1.5623	1.701	1.6575	1.6194	1.6461
4	1.5546	1.6385	1.7337	1.6461	1.6766	2.0767	1.6827
5	1.7558	1.8671	1.9052	1.7558	1.829	2.2481	1.7375
6	1.8107	2.1338	2.0195	1.8839	2.2672	2.2862	1.9022
7	1.9753	2.1148	2.1338	1.9936	2.21	2.1338	2.0668
8	1.8839	1.9243	2.0005	1.8839	2.0195	1.9624	1.8107
9	1.7924	1.8099	1.7909	1.6827	1.7147	1.6575	1.6644
10	1.6385	1.6004	1.6827		1.5051	1.3717	1.6575
11	1.6385	1.3717	1.6095	1.4815	1.3527	1.3717	1.467
12	1.5623	1.4861	1.5364	1.1812	1.4861	1.4449	1.467
13	1.5623	1.467	1.4998	1.1812	1.467	1.4998	1.4098
14		1.5242	1.4632	1.4098	1.4861	1.4449	1.467
15	1.4861	1.4861	1.5546	1.4098	1.4289	1.3717	1.448
16	1.4861	1.5051	1.4998	1.3717	1.4861	1.4083	1.5242
17	1.5432	1.5813	1.6278	1.4861	1.5623		1.5813
18	1.5813	1.6004	1.6461	1.5623	1.6766	1.5912	1.7147
19		1.7909	1.7741	1.7528	1.6194	2.1033	1.7909
20	2.0957	2.1338	2.0302	2.0767	2.0957	2.2497	2.1338
21	1.9433		1.9427	2.0957	2.0005	2.0302	2.0576
22	1.9052	1.8671	1.8656	1.9433	1.9243	1.8656	1.9814
23	.5335	1.7909	1.7193	1.848	1.8099	1.7558	1.8671
24	1.6644	1.6385	1.6956	1.6461	1.7337	1.7147	1.6461
Max	2.0957	2.1338	2.1338	2.0957	2.2672	2.2862	2.1338
Min	.5335	1.3717	1.4632	1.1812	1.3527	1.3717	1.4098
Avg	1.6498	1.7014	1.7321	1.6606	1.7266	1.7610	1.7052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 206 / 11KV South City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.5335	.4954	.5121	.4954	.4763	.4755
2	.7865	.5335	.4763	.5121	.4954	.4572	.4938
3	.823	.5144	.4763	.5121	.4572	.4382	.4572
4	.8048	.5144	.4572	.5121	.4572	.4572	.4572
5	.7499	.5335	.4382	.4938	.4572	.4572	.439
6	.7316	.5335	.4572	.4938	.5144	.4954	.4938
7	.7133	.5335	.4954	.4938	.5335	.5525	.567
8	.695	.5144	.5144	.439	.5144	1.3717	.4904
9	.695	.5144	.4763	.5121	.4954	.4572	.5304
10	.6859	.5335	.4938		.5144	.4527	.5144
11	.6668	.5525	.4755	.4572	.5144	.439	.5335
12		.4572	.439	.5335	.5335	.4207	.4954
13		.4954	.439	.5335	.4954	.4572	.4954
14		.4763	.439	.4763		.4755	
15		.4954	.439	.4763	.4191	.4938	.5144
16		.4572		.5525	.2096	.439	.5144
17	.6287	.4382	.4024	.4954	.2286	.5487	.5335
18	.724	.4763	.4572	.4954	.5335	.4938	.5335
19	.6287	.5525	.439	.5525	.5525	.5853	.5906
20	.6287	.5906	.5121	.5525	.5335	.6219	.6668
21	.5716	.5525	.4572	.5525	.5144	.567	.5716
22	.5335	.5335	.5121	.5525	.5144	.5121	.5525
23	.5335	.4954	.5304	.5335	.5144	.4938	.5144
24	.8048	.5335	.4954	.5121	.5144	.4763	.4755
Max	.823	.5906	.5304	.5525	.5525	1.3717	.6668
Min	.5335	.4382	.4024	.439	.2096	.4207	.439
Avg	.6953	.5152	.4703	.5112	.4788	.5267	.5178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 209 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.7621	1.105	.9328	1.0288	1.1431	1.0974
2	1.2254	.7621	1.0669	.9145	.9907	1.105	1.1157
3	1.1888	.743	1.0479	.9145	.9907	1.0479	1.134
4	1.1157	.7621	1.0288	.8779	1.0288	1.105	1.0974
5	1.0425	.7811	1.086	.9145	1.0669	1.1812	1.0974
6	.9328	.8002	1.1241	.9694	1.2193	1.2574	1.1157
7	.8413	.8573	1.0669	1.0242	1.3336	1.3717	1.0791
8	.8413	1.448	1.5432	.9328	1.3336	1.9624	1.6278
9	.9145	1.9433	2.2672	2.4691	2.4196	2.5149	2.1399
10	.8764	2.191	2.5423			2.524	3.0864
11		2.3624	2.9447	2.6155	2.8197	2.5972	2.9721
12		2.3815	2.9447	2.6101	2.4196	2.5423	2.6101
13		1.7147	2.5606	3.1245	2.3624	2.3045	2.1719
14		2.7625	2.0668	2.4768	2.553	2.5057	2.6863
15		2.7054	2.396	2.553	2.572	2.6155	2.7816
16		2.4196	2.1948	2.4958	2.9721	2.6703	2.7054
17		2.3053	1.6278	2.8006	2.934	2.963	2.6101
18	.724	2.4577		3.0102	2.5339	2.4143	2.4768
19	.724		1.4998	1.1241	1.9624	3.0178	.9907
20	.743	1.0479		1.4289	1.6575	1.4083	1.3527
21	.7621	.9907	1.0059	1.2193	1.5242	1.2986	1.3717
22	.6668	1.0479	.9511	1.086	1.3146	1.1523	1.0479
23	.7049	1.105	.9694	1.105	1.1241	1.134	1.0669
24	1.3352	.7811	1.1622	.9694	1.0288	1.1622	1.1523
Max	1.3352	2.7625	2.9447	3.1245	2.9721	3.0178	3.0864
Min	.6668	.743	.9511	.8779	.9907	1.0479	.9907
Avg	.9364	1.5275	1.6456	1.6769	1.7909	1.8749	1.7745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 201 / 11 KV Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4477	.443	.4706	.4835	.4784	.4784	.4887
2	.4887	.443	.4706	.4706	.4656	.4607	.4907
3	.4887	.4656	.4887	.4525	.4835	.4607	.4835
4	.5373	.4835	.4887	.4656	.5138	.4733	.5249
5	.5014	.5138	.5014	.5014	.5316	.5083	.5373
6	.567	.5316	.5552	.5316	.5609	.631	.5973
7	.5316	.5784	.591	.5847	.5784	.5784	.6268
8	.5658	.5609	.6201	.5258	.5316	.631	.5609
9	.6516	.5316	.5373	.7186	.6661	.5375	.7619
10	.7282	.5316	.7265	.7087	.7537	.5548	.7265
11	.6762	.7186	.7087	.4733	.7108	.5083	.7186
12	.7011	.631	.7011	.6588	.4854	.5258	.6762
13	.631	.6588	.5959	.6173	.4681	.4854	.5316
14	.4607	.6859	.4854	.5487	.463	.6173	.4973
15	.4784	.5658	.4854	.4458	.463	.703	.4973
16	.4908	.4801	.4801	.4801	.6935	.6516	.5144
17	.4908	.4973	.463	.5028	.5548	.5487	.5375
18	.5028	.4801	.4458	.5201	.5083	.7202	.4854
19	.5083	.4961	.5959	.703	.4557	.7442	.7537
20	.5083	.691	.7362	.7042	.7442	.7442	.8063
21	.5083	.7343	.6379	.6859	.7619	.7619	.7712
22	.4961	.6447		.6859	.4961	.724	.5434
23	.4961	.5194	.5373	.6135	.4961	.6335	.5258
24	.4477	.4656	.5068	.5014	.5316	.4784	.4835
Max	.7282	.7343	.7362	.7186	.7619	.7619	.8063
Min	.4477	.443	.4458	.4458	.4557	.4607	.4835
Avg	.5377	.5563	.5578	.5660	.5582	.5900	.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 202 / 11 KV Patoda Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2263	.2353	.2263	.1867	.2054	.2353
2	.2402	.2263	.2353	.2263	.1867	.2054	
3	.2587	.2641	.2534	.2075	.168	.2241	.2561
4	.2772	.2641	.2686	.2263	.1867	.2427	.2534
5	.3142	.3018	.2715	.2452	.2241	.2987	.2896
6	.3326	.3206	.3045	.2641	.3174	.3361	.362
7	.3511	.3506	.3582	.3018	.3734	.3547	.4119
8	.2957	.2829	.3721	.2829	.3921	.2772	.362
9	.3142	.2452	.3012	.2452	.3734	.2772	.3544
10	.2772	.2263	.3012	.2452	.3174	.2896	.3544
11	.7282	.8063	.9214	.964	.9259	.9015	1.0117
12	.8939	.8764	.929	.9882	.9774	.9465	1.0513
13	.8764	.8916	.9465	.9431	.9774	1.0341	1.073
14	.8859	.8916	.9709	.8916	.9835	1.0056	1.073
15	.8682	.8916	.9882	.8573	1.0004	.9774	1.0227
16	.8413	.8916	1.0117	.823	.9774	.8573	1.073
17	.8238	.8573	.9602	.8322	.9774	.6859	1.1191
18	.7975	.8059	.8573	.8322	.9709	.7373	1.1022
19	.2454	.2481	.1886	.2957	.2614	.3544	.2772
20	.2641	.2658	.3018	.2801	.2987	.3366	.3174
21	.2641	.2507	.2641	.2427	.2427	.2926	.2829
22	.2452	.2507		.2054	.2241	.2715	.2614
23	.2263	.2328	.2263	.1867	.2241	.2534	.2427
24	.2241	.2263	.2353	.2263	.1867	.2241	.2328
Max	.8939	.8916	1.0117	.9882	1.0004	1.0341	1.1191
Min	.2241	.2263	.1886	.1867	.168	.2054	.2328
Avg	.4612	.4623	.5088	.4600	.4981	.4829	.5661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 203 / WALDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.3814	.4207	.5316	.6001	.583		.7202
12	.5258	.7011	.631	.7373	.6859		1.0174
13	.5959	.7202	.7011	.823	.7202		1.1736
14	.6733	.7202	.7628	.8059	.8478		1.1401
15	.7087	.7545	.7282	.8059			1.0059
16	.7011	.7888	.5487	.8573			1.0059
17	.6661	.6859	.6516	.7802			.8478
18	.6241	.6516	.6859	.5548		.583	.9496
Max	.7087	.7888	.7628	.8573	.8478	.583	1.1736
Min	.3814	.4207	.5316	.5548	.583	.583	.7202
Avg	.6096	.6804	.6551	.7456	.7092	.583	.9826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 201 / Adgaon(Sarak)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2105	.1966	.1802	.1311	.1296	.1475	.1457
2	.2105	.1966	.1802	.1311	.1296	.1475	.1457
3	.2105	.213	.1966	.1311	.1296	.1475	.1457
4	.3239	.213	.1966	.1311	.1457	.1638	.1619
5	.421	.213	.213	.1475	.1619	.1638	.1781
6	.5506	.6226	.5735	.1802	.1943	.1966	.1943
7	.7449	.9175	.8029	.1638	.1619	.1802	.1781
8	.8097	.7865	.7209	.1311	.1296	.1475	.1457
9		.5407	.5407	.1134	.1147	.0328	.1311
10		.0819	.0983	.0972	.0983	.0983	.0983
11	.1311	.0492	.0819	.6478	.5898	.5243	.6062
12	.1311	.0492	.0819	.6964	.5243	.6062	.7209
13		.0655	.0819	.6316	.5735	.5243	.6554
14		.0819	.0655		.639	.4424	.5243
15	.0655	.0819	.0819	.4858	.5898	.3441	.3277
16	.0655	.0819	.0655	.5344	.5735	.6062	.426
17	.0819	.0819	.0983	.5344	.5571		.6226
18	.1147	.0819	.0819	.5344	.4915	.7373	.4752
19	.1475	.1147	.1147	.1134	.1966	.1638	.1311
20	.1638	.1475	.1475	.1781	.1802	.1619	.1802
21	.1638	.1311	.1475	.1619	.1802	.1619	.1638
22	.1475	.1311	.1638	.1475	.1638	.1638	.1638
23	.1311	.1311	.1311	.1457	.1638	.1619	.1475
24	.2105	.1966	.1802	.1311	.1296	.1475	.1619
Max	.8097	.9175	.8029	.6964	.639	.7373	.7209
Min	.0655	.0492	.0655	.0972	.0983	.0328	.0983
Avg	.2518	.2253	.2178	.2739	.2895	.2683	.2846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 202 / Mandki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0905	.1029	.1423	.1781	.2172	.1581
2	.0905	.0905	.1029	.1423	.1781	.2172	.1581
3	.0905	.0905	.1029	.1581	.1781	.3258	.192
4	.0905	.0905	.12	.176	.3401	.4887	.2241
5	.1086	.0905	.12	.192	.4372	.6516	.2753
6	.1267	.1086	.12	.3077	.5992	.724	.6802
7	.0905	.0905	.1543	.5668	.8192	1.0136	.6802
8	.1086	.0732	.1753	.502	.6964	.8145	.8907
9		.1029	.0953	.4424	.6516	.6722	.664
10		.0857	.0572	.1267	.0543	.1334	.0857
11	.724	.5197	.4001	.0543	.056	.0572	.1029
12		.5182	.5851	.0543	.0549	.0381	.0514
13		.5182	.6081		.0543	.0381	.0514
14		.5506	.427		.0549	.0381	.0686
15	.362	.5182	.3953	.0543	.0543		.0686
16	.7602	.502	.3906	.0543	.0543		.0686
17	.7059	.4534	.4161	.0543	.0543		.0686
18	.6335	.2683	.2881	.0549	.0543	.0572	.0686
19	.0905	.1029	.0914	.0724	.0724	.0953	.1029
20	.0905	.2012	.0732	.0905	.0905	.1524	.1029
21	.0905	.1578	.1143	.0724	.0905	.1143	.1029
22	.0905	.1543	.0762	.0732	.0724	.0762	.0857
23	.0905	.1543	.0572	.0905	.0543	.1143	.12
24	.0905	.0905	.1029	.1423	.1781	.2172	.1581
Max	.7602	.5506	.6081	.5668	.8192	1.0136	.8907
Min	.0905	.0732	.0572	.0543	.0543	.0381	.0514
Avg	.2382	.2343	.2157	.1647	.2137	.2979	.2179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 203 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.9328	.9189	.8779	.9694	.9328	.9425
2	.9877	.9877	.9189	.8779	.9694	.9328	.9425
3	.9877	.9877	.9922	.9511	.9694	.9328	.9795
4	1.0974	1.0974	1.0208	.9979	1.0974	1.0974	1.0642
5	1.1888	1.1706	1.134	1.0903	1.1888	1.1888	1.1389
6	1.4449	1.4449	1.4712	1.4523	1.4083	1.4632	1.5278
7	1.4815	1.2986	1.3256	1.3014	1.262	1.3717	1.4146
8	1.3169	1.2437	1.0099	1.2136	1.0425	1.0317	1.1949
9		.8402	.9055	1.0242	.9145	1.0349	.7716
10			.7682	.8596	.7316	.9425	.7545
11	1.0059	.583	.7059	.6584	.7133	.6335	.6344
12		.6173	.6878	.695	.695	.5973	.6687
13		.6687	.7865		.6584	.6516	.6859
14		.6859	.7577		.6219	.7316	.6859
15	.7865	.7716	.8871	.8779	.7133		.7202
16	.8048	.7545	.8501	.9328	.823		.7202
17	.9145	.8764	.8871	.9328	.8962		.7716
18	1.0425	.9774	1.0082	.9328	1.0242	1.1389	.8495
19	1.2127	1.0566	.8779	.9145	1.1706	1.3014	1.0679
20	1.1888	1.3203	1.2071	1.3535	1.2803	1.4146	1.2254
21	1.134	1.0974	1.0642	1.1157	1.1888	1.1949	1.1041
22	1.0791	.9816	.9709	1.0425	1.0974	1.1016	.9991
23	1.0059	.964	.961	1.0059	.9511	1.0082	.964
24	.9877	.9328	.9088	.8779	.9694	.8962	.9425
Max	1.4815	1.4449	1.4712	1.4523	1.4083	1.4632	1.5278
Min	.7865	.583	.6878	.6584	.6219	.5973	.6344
Avg	1.0871	.9692	.9594	.9994	.9732	1.0285	.9488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 204 / 11 KV Jatwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.2715	.2572	.2896	.2715	.2172	.2172
2	.2949	.2715	.2572	.2896	.2715	.2172	.2172
3	.2949	.3258	.2572	.2896	.2715	.2801	.2172
4	.4915	.3258	.3018	.3258	.3258	.3258	.2534
5	.5898	.3801	.3018	.362	.3801	.3801	.3258
6	.6882	.724	.5506	.5792	.4887	.543	.5068
7	.9831	1.0059	.7773	.6516	.543	.4887	.6335
8	.8848	.9511	.8421	.5611	.543	.3801	.4887
9		.7935	.6626	.4344	.4887	.3761	.4525
10			.362	.3801	.3801	.3439	.362
11	.3841	.3681	.3801	.4424	.543	.1791	.3772
12		.3801	.362	.5898	.5973	.1433	.463
13		.3258	.2896	.5407	.543	.1433	.4527
14		.3292	.2896	.4915	.3292	.1448	.4372
15	.2715	.2715	.362	.4915	.362	.181	.4534
16	.0543	.2896	.3077	.639	.3801	.788	.4534
17	.0543	.3292	.3439	.4424	.4344	.6447	.583
18	.5487	.4344	.3801	.3441	.3841	.5373	.1943
19	.6036	.4938	.3521	.3801	.3841	.5249	.4887
20	.543	.5175	.4801	.4344	.3841	.4706	.4344
21	.3801	.3841	.3801	.3801	.3292	.3982	.3292
22	.3841	.3258	.362	.3041	.2743	.4344	.3109
23	.3292	.2715	.3077	.3258	.2195	.2715	.2926
24	.3258	.2743	.2572	.2896	.2715	.2172	.2715
Max	.9831	1.0059	.8421	.6516	.5973	.788	.6335
Min	.0543	.2715	.2572	.2896	.2195	.1433	.1943
Avg	.4421	.4367	.3927	.4274	.3917	.3596	.3840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 201 / 11 Kv Sajapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3086	.3086		.3174	.2915	.6097
2	.3361	.3258	.3086		.2987	.3086	.5944
3	.3174	.3258	.3258		.2614	.2915	.5639
4	.2987	.3086	.3258		.2801	.2915	.5639
5	.3174	.3086	.3258		.3174	.3086	.5487
6	.3174	.3086	.3086		.3361	.3086	.5487
7	.3547	.3258	.3258		.3361	.2915	.503
8		.3258	.3258		.3361	.2743	.3086
9	.2915	.2915	.3086	.3174	.3361	.2743	.3258
10	.3086	.3258	.2987	.2801	.2743	.2572	.3547
11	.3429	.2915	.168	.2614	.2915	.2572	.3326
12		.2915	.2241	.2427	.2915	.2572	.3174
13		.3258	.2801	.2241	.2743	.2743	.3174
14		.3086	.2801	.2427	.2401	.2743	.3174
15		.3086	.3174	.2241	.2743	.3086	.3361
16		.3086	.3361	.2987	.1715	.3429	.3361
17		.3086	.3361	.2033	.2401	.3429	.3174
18		.2915	.3174	.2801	.2401	.3086	.3361
19		.2401	.2987	.3174	.2401	.2915	.3547
20	.3944	.3429	.3361	.3326	.3086	.2915	.3361
21	.3429	.3429	.3547	.3921	.3086	.3086	.3361
22	.3429	.3601	.3361	.3734	.3086	.3086	.3361
23	.3429	.3258	.3174	.3547	.2915	.3086	.3361
24	.3547	.3258	.3258		.3361		.6554
Max	.3944	.3601	.3547	.3921	.3361	.3429	.6554
Min	.2915	.2401	.168	.2033	.1715	.2572	.3086
Avg	.3345	.3136	.3079	.2897	.2879	.2945	.4119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 202 / 11kv Karodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.1543	.3944		.2241	.1372	.3086
2	.3734	.1543	.3944		.2427	.1219	.2915
3	.4108	.1715	.3772		.2614	.1543	.2572
4	.4481	.1886	.4115		.2801	.1543	.2058
5	.5228	.2058	.4115		.2987	.2058	.2058
6	.5601	.2572	.6001		.3174	.2401	.1886
7	.7282	.2915	.6516		.3174	.2743	.2915
8		.3258	.5487		.3174	.3429	.3086
9	.4115	.2401	.463	.3921	.2801	.2401	.3258
10	.3429	.2401	.3361	.3174	.3429	.3429	.4481
11	.1715	.2229	.3174	.2987	.2743	.3086	.3734
12		.2058	.2987	.2801	.2743	.2743	.3142
13		.1886	.2614	.2801	.2572	.2743	.2801
14		.2058	.2801	.2614	.2743	.3086	.2987
15		.2572	.2801	.2427	.2743	.3086	.3361
16		.2572	.2801	.2987	.2915	.3429	.3361
17		.2915	.2614	.3174	.3086	.3429	.2987
18		.2572	.2614	.3734	.3429	.3086	.2614
19		.4458	.5415	.4481	.4801	.3601	.5228
20	.2743	.4973	.5788	.4481	.4973	.3944	.6011
21	.2401	.4458	.5601	.4108	.4115	.463	.5544
22	.1886	.4115	.4854	.4108	.3772	.4287	.4481
23	.1715	.3772	.3734	.3734	.3429	.3772	.4108
24	.3734	.1543			.2427	.1029	.3429
Max	.7282	.4973	.6516	.4481	.4973	.463	.6011
Min	.1715	.1543	.2614	.2427	.2241	.1029	.1886
Avg	.3715	.2686	.4073	.3435	.3138	.2837	.3421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 203 / 11 kv INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.4115	.442	.5228	.7655	.9431	
2	.7095	.4458	.4801		.7468	.9088	
3	.6348	.4458	.4458	.5601	.7095	.8573	
4	.5601	.4287	.4458	.5415	.6722	.9259	
5	.5601	.4458	.4287	.4854	.7095	.9774	
6	.5788	.3944	.5144	.5975	.7468	.9602	
7	.5975	.4287	.5335	.7468	.9522	1.2174	
8		.6173	.6097	.8215	1.2696	1.0802	.7926
9	.5316	1.2174	1.1126	.8402	1.6617	1.5432	1.0974
10	.5144	1.1736	1.6057	1.1016	1.3203	1.2193	1.5123
11	.5144	1.2955	1.7364	1.2136	1.6289	1.387	1.419
12		1.2346	1.6057	1.2883	1.6289	1.4632	1.3121
13		1.1279	.8962	1.531	1.6804	1.387	1.419
14		1.1431	.8589	1.5497	1.4918	1.1888	1.531
15		1.1736	.6722	1.5684		1.2041	1.6991
16		1.1888	.5228		1.8176	1.2193	1.8671
17		1.2041	.7842	1.3817	1.5604	1.2193	1.6804
18		.9602	1.0082	1.1576	1.3717	1.0669	1.3256
19		.7011	.9709	.8962	1.6289	.945	1.1203
20	.3772	.884	.6348	.8589	.9945	.9145	.9522
21	.3601	.7164	.6348	.8215	.8916	.6859	.8962
22	.3772	.5792	.5975	.7468	.8573	.7011	.8215
23	.4458	.503	.5601	.8029	.823	.7316	.7842
24	.7842	.4287	.4877	.5788	.8029	.8916	
Max	.7842	1.2955	1.7364	1.5684	1.8176	1.5432	1.8671
Min	.3601	.3944	.4287	.4854	.6722	.6859	.7842
Avg	.5528	.7979	.7745	.9369	1.1623	1.0683	1.2644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 201 / 11 KV SUKHNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1143	.0953	.0953	.1143
2	.1905	.1905	.1905	.1143	.0953	.0953	.1143
3	.1905	.1905	.1905	.1143	.0953	.0953	.1143
4	.1905	.2858	.1905	.1143	.1905	.0953	.1143
5	.1905	.381	.2286	.1524	.1905	.0953	.1715
6	.4572	.4763	.4763	.3048	.381	.1143	.3429
7	.4572	.4763	.4763	.3239	.381	.1905	.5716
8	.4001	.381	.381	.3048	.381	.1905	.5144
9	.2667	.2858	.381	.2858	.381	.1143	.381
10	.2858	.2858	.2477	.2858	.2858		.2858
11	.2858		.1715	.1905	.1905		.2858
12	.2858	.1905	.2286	.1905			.1905
13	.2858	.1524	.2477	.1905			.1905
14	.2858	.1905	.1905	.1905			.1905
15	.2858	.1905	.2286	.1905			.1905
16	.2858	.1905	.2286	.1905		.1524	.1905
17	.2858	.2286	.2096	.1905	.1905		.1905
18	.1905	.1905	.2667	.1905	.2286		.2858
19	.381	.381	.3239	.2858	.2858		.381
20	.381	.381	.381	.381	.2858	.4191	.381
21	.2858	.2858	.2858	.2858	.2286	.3048	.381
22	.2858	.2286	.2667	.2858	.2286	.2667	.2858
23	.2858	.2286	.2477	.2858	.1905	.2667	.2858
24	.1905	.1905	.1905	.1143	.0953	.0953	.1143
Max	.4572	.4763	.4763	.381	.381	.4191	.5716
Min	.1905	.1524	.1715	.1143	.0953	.0953	.1143
Avg	.2842	.2684	.2675	.2199	.2316	.1727	.2612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 202 / 11 KV KHODEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1524	.2667	.1905	.2286	.2667
2	.0953	.0953	.1524	.2667	.1905	.2286	.2667
3	.1143	.1905	.1524	.2858	.1905	.2286	.2667
4	.1524	.1905	.1905	.3239	.2858	.2858	.3048
5	.2096	.2858	.1905	.4572	.381	.381	.4001
6	.2858	.381	.2858	.5335	.381	.5716	.5906
7	.2477	.381	.381	.4572	.4763	.4763	.5335
8	.2667	.4763	.2858	.4954	.4763	.4763	.4572
9	.3048	.381	.3048	.4572	.381	.381	.4191
10	.2858	.2858	.3429	.2858	.2858	.2858	.2858
11	.2858		.2477	.2858	.1905	.3048	.2858
12	.2858	.1905	.2286	.1905	.1524	.3239	.1905
13	.2858	.1905	.2477	.1905	.1905	.3429	.1905
14	.2858	.1905	.2286	.2858	.1905	.3429	.1905
15	.2858	.2286	.2286	.2858		.381	.1905
16	.2858	.1905	.2286	.2858	.2858	.2667	.2858
17	.381	.2286	.2858	.2858	.2286	.381	.2858
18	.4763	.381	.3429	.2858	.2858	.381	.2858
19	.4763	.4763	.4382	.381	.4763	.5144	.4763
20	.381	.4763	.4763	.4763	.7621	.5335	.4763
21	.381	.381	.381	.381	.381	.4001	.381
22	.2858	.2858	.3048	.2858	.2858	.3239	.2858
23	.2858	.2858	.2858	.2858	.2858	.2858	.2858
24	.1143	.1905	.1524	.2667	.2858	.2286	.2667
Max	.4763	.4763	.4763	.5335	.7621	.5716	.5906
Min	.0953	.0953	.1524	.1905	.1524	.2286	.1905
Avg	.2731	.2808	.2715	.3334	.3148	.3564	.3278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 203 / 11 KV MURADABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5716	.7621	.381	.4763		.381
2	.6668	.5716	.7621	.381	.381		.381
3	.6668	.7621	.7621	.381	.381		.4191
4	.7621	.7621	.7621	.4191	.4763		.5144
5	.8383	.9526	.7621	.5144	.5716		.6097
6	1.1812	1.3336	1.3336	.6478	.7621		.8954
7	.9907	1.2384	1.1431	.6097	.8573	.4763	1.0098
8	.8954	1.1431	1.1431	.5716	.8573		1.0098
9	.724	.9526	.9145	.5335	.7621		.9526
10	.5716	.7621	.6287	.4763	.5716	.7049	.7621
11	.5716		.4001	.4763	.4763	.5335	.5716
12	.381	.381	.4382	.4763	.4763	.4763	.381
13	.381	.5716	.4763	.4763	.4763	.4572	.381
14	.381		.381	.4763	.4763	.5144	
15	.381	.4763	.4191	.4763	.4763	.4763	.381
16	.4763	.381	.4954	.4763	.4763	.6478	.4763
17	.4763	.4763	.4763	.4763	.381	.6097	.5716
18	.5716	.5716	.5906	.4763	.381	.6478	.7621
19	1.1431	1.1431	.743	.9526	.7621	1.1622	1.1431
20	1.0479	1.1431	.6668	.7621	1.1431	1.1812	1.2384
21	.9526	.9526	.8573	.7621	.7621	.8573	.9526
22	.7621	.7621	.8002	.7621	.7621	.743	.7621
23	.6668	.7621	.8954	.6668	.7621	.6668	.5716
24	.6859	.5716	.7621	.3429	.381	.381	.4001
Max	1.1812	1.3336	1.3336	.9526	1.1431	1.1812	1.2384
Min	.381	.381	.381	.3429	.381	.381	.381
Avg	.7017	.7837	.7240	.5406	.5954	.6585	.6751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 204 / 11 KV RAJAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.9526	.4763	1.3336	1.3336	1.5242	1.3336
2	.7621	.7621	.4763	1.3336	1.3336	1.5242	1.3336
3	.7621	.9526	.4763	1.5242	1.5242	1.5242	1.5242
4	.9526	.9526	.4763	1.7909	1.5242	1.7147	1.8099
5	1.105	1.1431	.5716	2.0386	1.9052	2.0957	1.9624
6	1.3717	1.4289	1.1431	2.6292	2.0957	2.4768	2.553
7	1.6004	1.7147	1.3336	2.4768	2.2862	2.4768	2.3815
8	1.3908		1.7147	2.2481	2.0957	2.0957	2.2481
9	1.2574	1.3336	1.467	1.8099	2.0005	2.0957	2.0957
10	1.5242	1.8099	1.7147	1.7147	1.7147		1.7147
11	1.3336		1.2574	.9526	.5716	1.1812	1.7147
12	1.3336	1.5242		1.0479	1.1431	1.2765	1.5242
13	1.2384	1.5242	1.2765	1.1431	1.5242	1.2955	1.3336
14	1.2384	1.5242	1.2384	.9526	.5716	1.4098	1.1431
15	1.3336	1.5242	1.3527			1.4289	1.2384
16	1.4289	1.5242	1.3717			1.5242	1.3336
17	1.7147	1.5242	1.7528		1.1431	1.6385	1.3336
18	2.191	1.7147	2.0576	1.5242	1.5242	1.7147	1.5242
19	2.572	2.2862	2.2481	1.9052		2.4958	2.8578
20	2.3815	2.2862	2.0957	2.2862	2.2862	2.2862	2.572
21	2.0957	2.0957	1.9433	2.0957	2.2862	2.2481	2.0957
22	1.7147	1.9052	1.6575	1.9052	1.9052	1.9624	1.9052
23	1.5242	1.7147	1.467	1.5242	1.7147	1.6575	1.7147
24	.7621	.5716	.4763	1.3336	1.3336	1.5242	1.3336
Max	2.572	2.2862	2.2481	2.6292	2.2862	2.4958	2.8578
Min	.7621	.5716	.4763	.9526	.5716	1.1812	1.1431
Avg	1.4313	1.4895	1.3063	1.6938	1.6103	1.7901	1.7742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 205 / 11 KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.381	.381	.6668	.5716	.7621	.6668
2	.2667	.2858	.381	.6668	.5716	.7621	.6668
3	.2667	.2858	.381	.8573	.7621	.7621	.8573
4	.381	.381	.4191	.9907	.8573	.9526	.9907
5	.4954	.5716	.4763	1.086	1.0479	1.2384	1.1812
6	.7621	.7621	.7621	1.448	1.1431	1.7147	1.2574
7	.6478	.9526	.9526	1.2574	1.0479	1.5242	1.1622
8	.6668	.7621	.9526	1.2574	1.0479	1.4289	1.1622
9		.7621	.8002	1.1241	.9526	1.0479	
10	.7621	.9526	.8002	.9526	.9526	.9717	.9526
11	.7621		.6859	.5716	.4763	.6478	.9526
12	.5716	.5716	.6478	.7621	.5716	.6668	.7621
13	.5716		.5716	.7621		.6287	.7621
14	.6668	.7621	.5906	.5716	.4763	.5716	.5716
15	.6668	.5716	.5525	.5716	.5716	.5525	.5716
16	.6668	.7621	.5906	.4763	.381	.6287	.5716
17	.7621	.7621	.8764	.4763	.381	.8002	.5716
18	1.0479	.9526		.5716	.7621	.8764	.7621
19	1.2384	1.1431		1.1431	1.3336	1.3336	1.1431
20	1.0479	1.1431	1.2765	1.0479	1.2384	1.2765	1.2384
21	.9526	.9526	.9526	.9526	.9526	.9335	1.1431
22	.7621	.7621	.7811	.9526	.7621	.8192	.9526
23	.6668	.7621	.7049	.7621	.7621	.7811	.7621
24	.2667	.381	.381	.6668	.5716	.7621	.724
Max	1.2384	1.1431	1.2765	1.448	1.3336	1.7147	1.2574
Min	.2667	.2858	.381	.4763	.381	.5525	.5716
Avg	.6594	.7101	.6781	.8581	.7911	.9351	.8863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 206 / EHV THAPTI TANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4763	.1905	.5716	.2858	.3429
2	.381	.381	.4763	.1905	.1905	.2858	.3429
3	.4191	.381	.4763	.1905	.1905	.2858	.381
4	.5716	.5716	.5716	.2286	.381	.381	.4191
5	.7621	.7621	.7621	.3048	.4763	.5716	.4954
6	1.0669	.9526	.9526	.724	.9526	.7621	1.0669
7	1.0288	.9526	.9526	.8383	1.1431	1.5242	1.5242
8	.9526	.7621	.8573	.8764	1.1431	1.5242	1.2574
9	.8002	.5716	.7621	.8764	1.1431	.8573	1.2193
10	.7621	.4763	.5335	.7621	.5716	.724	1.1431
11	.7621		.381	.381	.4763	.4572	.9526
12	.7621	.4763	.4572	.2858	.381	.4191	.5716
13	.5716	.4763	.6097	.2858		.4572	.1715
14	.381	.4763		.381		.4191	
15	.381	.4763	.4954	.381		.4572	.381
16	.5716	.381		.4763		.4191	.4763
17	.7621	.5716	.0381	.4763		.5335	.4763
18		.4763	.0381	.5716		.6859	.5716
19	.8573	.6668	.0381	.9526		.8002	.7621
20	.5716	.8573		.9526	.7621	.9145	.9526
21	.5716	.7621	.6478	.7621	.6668	.6859	.9526
22	.381	.5716	.4572	.5716	.6668	.5716	.7621
23	.381	.4763	.381	.5716	.5716	.4572	.5716
24	.4191	.381	.4763	.1905	.2858	.2858	.3429
Max	1.0669	.9526	.9526	.9526	1.1431	1.5242	1.5242
Min	.381	.381	.0381	.1905	.1905	.2858	.1715
Avg	.6304	.5757	.5162	.5176	.6220	.6152	.7016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 207 / ANTERWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.381	.4763	.2858	.381
2	.5716	.5716	.5716	.381	.381	.2858	.381
3	.5716	.5716	.5716	.381	.381	.2858	.381
4	.6668	.7621	.6668	.381	.4763	.381	.381
5	.8764	.9526	.7621	.4382	.5716	.4763	.4763
6	1.3527	1.4289	1.4289	.7811	.9526	.5716	.7621
7	1.2765	1.3336	1.2384	.9335	1.1431	.7621	.9526
8	1.1812	1.1431	1.1431	.9907	.9526	.8573	.8192
9	.8954	.9526	.9145	.8573	.5716	.4763	.6859
10	.5716	.6668		.7621	.4763	.5716	.5716
11	.5716		.5144	.5716	.381	.4191	.5716
12	.7621	.4763	.6859	.5716	.2858	.4382	.381
13	.5716	.5716	.8002	.5716	.4763	.381	.381
14		.4763	.6478	.381	.4763	.4382	.4763
15	.5716	.4763	.7621	.381		.381	.4763
16	.6668		.6859	.5716		.4954	.5716
17	.6668	.5716	.6097	.5716	.4763	.5335	.7621
18	.5716	.6668	.5906	.5716	.5716	.8002	.8573
19	.9526	1.0479	.8954	.7621	.8573	1.0669	1.0479
20	1.1431	.9526	.9907	.9526	.9526	.9907	1.1431
21	.9526	.7621	.6287	.9526	.7621	.8002	.9526
22	.7621	.6668	.6668	.7621	.7621	.724	.7621
23	.5716	.5716	.6097	.5716	.6668	.6287	.6668
24	.6097	.5716	.5716	.4001	.381	.2858	.381
Max	1.3527	1.4289	1.4289	.9907	1.1431	1.0669	1.1431
Min	.5716	.4763	.5144	.381	.2858	.2858	.381
Avg	.7787	.7621	.7621	.6200	.6105	.5557	.6343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 201 / 11 KV KARMAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1132	.1132	.0857	.1006	.1006	.1341
2	.132	.1132	.1132	.0857	.1006	.1006	.1341
3	.132	.1132	.1132	.1029	.1006	.1006	.1341
4	.132	.1132	.1132	.12	.1006	.1174	.1341
5	.1509	.1509	.132	.12	.1677	.1006	.1341
6	.2263	.1886	.1509	.1372	.2012	.218	.2515
7	.2641	.2263	.1886	.2401	.2347	.3018	.2683
8	.1509	.1886	.1698	.2572	.2683	.3018	.3018
9	.1698	.1698	.1509	.2012	.2012	.285	.3353
10	.1132	.1132	.132	.1886	.1132	.1132	.1132
11	.2347	.2012	.2058	.1509	.1132	.132	.1132
12	.2347	.2347	.2515	.1509	.1132	.0754	.0377
13	.3018	.218	.2683	.1132	.1132	.0943	.0943
14	.2683	.2012	.2515	.1132	.132	.1132	.0943
15	.2012	.2012	.2683	.1509	.1132	.1132	.0943
16	.2012	.2347	.218	.1132	.1132	.0754	.1132
17	.2012	.2347	.1844	.1132	.132	.0943	.1132
18	.2347	.2012	.218	.1509	.1698	.0943	.1509
19	.1509	.1509	.1509	.1886	.1886	.1886	.1698
20	.1886	.1886	.1698	.1886	.1886	.2263	.1886
21	.1886	.1509	.132	.1886	.132	.1523	.1886
22	.1509	.132	.1132	.1509	.1132	.1698	.1698
23	.1132	.1132	.1132	.0754	.1132	.1509	.1509
24	.132	.1132	.1509	.0857	.1006	.1006	.1341
Max	.3018	.2347	.2683	.2572	.2683	.3018	.3353
Min	.1132	.1132	.1132	.0754	.1006	.0754	.0377
Avg	.1836	.1694	.1697	.1447	.1427	.1467	.1564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 202 / 11 KV GADHE JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359	.3688	.5365	.9619	1.0185	.9808	1.1317
2	.4359	.4024	.57	.9619	1.0562	1.0185	1.1317
3	.4359	.4024	.57	1.0374	1.094	1.094	1.1694
4	.503	.4024	.5868	1.1694	1.2071	1.1694	1.2826
5	.6036	.9724	.7042	1.4523	1.358	1.358	1.4335
6	1.073	1.0395	1.0395	1.7541	1.6598	1.773	1.9239
7	1.0395	1.1736	1.0059	1.6032	1.7353	1.7353	1.6975
8	1.0395	1.3413	.8718	1.6975	1.3957	1.5089	1.5089
9	1.0395	1.1904	.8383	1.2071	1.2449	1.1317	1.1317
10	1.0185	.7922	1.1317	.8299	.9431	.9431	1.1694
11	.8299	.7922	.8488	.8383	.6706		.8402
12	.7545	.679		1.2407	.8718	.9389	.7545
13	.7545	.679		1.0898	.7377	.7377	.6706
14	.7167	.7167		.9054	.7042	.8048	.6539
15	.7545	.8299	.9431	.9389	.7377	.7042	.5868
16	.7167	.7922	.9619	.7712	.8718	.8383	.8215
17	.8676	.9431	1.0185	.9054	.8718	.9389	1.0059
18	.7922	1.1317	.9431	.7712	.8383	.7712	.9389
19	1.3957		1.226	1.1883	1.094	1.3957	1.3203
20	1.3203		1.5089	1.5466	1.5089	1.6221	
21	1.1317		1.2637	1.4335	1.226	1.4335	1.3957
22	1.0562	.9808	1.1317	1.1317	1.0562	1.3203	1.1694
23	.9808	1.0185	1.0374	1.0185	1.0185	1.1317	1.0562
24	.4458	.4527	.5365	.9619	.9431	.9808	1.1317
Max	1.3957	1.3413	1.5089	1.7541	1.7353	1.773	1.9239
Min	.4359	.3688	.5365	.7712	.6706	.7042	.5868
Avg	.8392	.8143	.9178	1.1423	1.0776	1.1448	1.1272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 203 / 11 KV SHEKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.7377	.8048	1.0562	1.0185	1.0562	1.0562
2	.8048	.8048	.7712	1.0562	1.0562	1.0185	1.0562
3	.8048	.8718	.7377	1.1317	1.0185	.9808	1.0562
4	.8383	.9389	.7712	1.2071	1.0185	1.0562	1.0562
5	.9054	1.1401	.8048	1.3203	1.1694	1.2071	1.1694
6	1.5089	1.4754	1.4754	1.5844	1.4712	1.5089	1.5844
7	1.8778	1.576	1.7436	1.5089	1.7353	1.3957	1.5089
8	1.9448	1.9113	1.9784	1.4146	1.358	1.2449	1.4712
9	1.6766	1.576	1.8107	1.1317	.9431	.8676	1.2071
10	.7922	1.0185	.9808	1.0185	.9054	1.0562	.9808
11	.7922	.6413	.9431	1.643	1.4083	1.9448	1.8176
12	.8676	.9808	.9054	1.576	1.3748		2.146
13	.7922	.8299	.9054	1.5424	1.6766	1.7772	2.0119
14	.7545	.8676	.8488	.9054	1.5424	2.0119	1.8107
15	.8299	.9054	.2263	1.5424	1.4419	1.8107	1.7436
16	.8299	.9808	1.0562	1.576	1.7101	1.9448	1.7772
17	.8299	.9431	1.0562	1.576	1.4419	2.146	1.9784
18	1.0185	1.1317	1.094	1.5089	1.3413	1.8107	1.643
19	1.094	1.1317	1.3203	1.0185	1.2449	1.3203	1.2826
20	1.3957	1.5466	1.6598	1.3957	1.4335	1.5089	1.6221
21	1.2826	1.3203	1.358	1.2826	1.358	1.3957	1.4712
22	.9054	1.2449	1.2071	1.094	1.1317	1.226	1.2449
23	.8299	1.2826	1.1317	.9808	1.094	1.1317	1.1694
24	.8048	.7377	.9389	1.0562	1.0185	1.0562	1.0562
Max	1.9448	1.9113	1.9784	1.643	1.7353	2.146	2.146
Min	.7545	.6413	.2263	.9054	.9054	.8676	.9808
Avg	1.0411	1.1081	1.1054	1.2970	1.288	1.4120	1.4551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 205 / 11 KV GOLATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.0185	.3856	.4024	.503	.6036
2	1.1694	1.1694	1.0562	.3856	.4359	.5365	.6091
3	1.1694	1.2071	1.094	.4191	.4359	.5365	.6036
4	1.2826	1.2826	1.1694	.4694	.4359	.5365	.6371
5	1.4712	1.5844	1.4712	.5197	1.0059	.6203	.6706
6	2.1125	1.6975	1.5844	.7545	1.2742	1.1401	1.1401
7	1.8861	1.773	1.6598	.9054	1.5089	1.6766	
8	1.6221	1.5466	1.5089	1.0898	1.6766	1.5424	2.0454
9	1.2826	1.1694	1.094	1.2239	1.5424	1.6095	1.7436
10	.6036	.9431	.8865	.8676	.9054	.9431	.8865
11	.6036	.6036	.6173	.6036	.7922	.7545	.7733
12	.7712	.57	.9054	.6036	.6413	.8676	.7545
13	.7042	.8383	1.0059	.679		.8676	.7545
14	.6706	.7712	1.0395		.7922	.7922	.7733
15	.6706	.7042	.9054		.8299	.679	.7545
16	.7377	.8718	1.1065	.7922	.9054		.811
17	.7377	.7042	1.1401	.7167	.9054	.0377	.9054
18	.8048	.7042	1.0395	1.094	1.0185	1.2449	1.1317
19	1.4335	1.2071	1.358	1.3957	1.4335	1.6975	1.4712
20	1.5844	1.5844	1.6975	1.6975	1.6975	1.8484	1.773
21	1.3957	1.358		1.6221	1.4712	.6036	1.5089
22	1.2071	1.2071	1.1694	1.2826	1.2826	1.3203	1.3203
23	1.1694	1.0751	.9431	1.1317	1.2071	1.2449	1.1694
24	1.1317	1.1317	1.0562	.3944	.4024	.4694	.6036
Max	2.1125	1.773	1.6975	1.6975	1.6975	1.8484	2.0454
Min	.6036	.57	.6173	.3856	.4024	.0377	.6036
Avg	1.1397	1.1182	1.1533	.8652	1.0001	.9597	1.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 206 / 11 Kv Mirza industrial SHEDDABLE FEEDER HAVING WEEKLY
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 201 / 11 KV SHENDRA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7716	.7716	1.3717	.6859	1.4575	.1543
2	.7716	.7716	.7716	1.3717	1.3717	1.4575	.1543
3	.7716	.8573	.7716	1.3717	1.3717		.1629
4	.8573	.8573	.9259	1.5432	1.6118	1.4575	.1886
5	.9431	1.1145	1.4403	1.7147	1.7833	1.5432	.2058
6	1.3717	1.4575	1.6118	2.3148	2.0233	1.8861	.2229
7	1.5432	1.749	1.749	2.1434	1.7833	2.1776	.2229
8	1.7147	1.7661		2.0576	1.749	1.8861	.18
9	1.4575	1.3717	1.4575	1.6461	1.5432	.1715	1.5432
10	1.286	1.4403	1.4575	1.4403	1.286	.1372	
11		1.2003	1.286	1.0288	1.0288	.1286	1.4575
12	1.0288	1.2003	1.0288	1.3032	.8573	.1286	1.3717
13		.9602	1.1145	1.3717	.8573	.1286	1.286
14		1.0288	1.1145	1.0631	.8573	.12	1.286
15		1.166	1.1145	1.0631	.4458	.12	1.1145
16	1.286		1.286	1.0288	.4287	.1372	1.2003
17	1.6289		1.3717	.9945	1.0288	.1543	1.3717
18	1.5432	1.5089	1.3717	1.166	1.286	.12	1.3717
19	1.6289	1.6461	1.5432		1.286	.1629	1.7147
20	1.7147	1.7833	1.8004	1.6118	1.7147	.1886	1.8861
21	1.7147	1.7147	1.5432	1.5432	1.989	.1715	1.6289
22	1.5089	1.7147	1.4575	1.3717	1.5775	.1715	1.6289
23	1.3717		1.3717	1.2689	1.4746	.1629	1.4575
24	.7716	.7716	.7202	1.3717	1.3717	1.4575	.1543
Max	1.7147	1.7833	1.8004	2.3148	2.0233	2.1776	1.8861
Min	.7716	.7716	.7202	.9945	.4287	.12	.1543
Avg	1.2843	1.2787	1.2644	1.4418	1.3089	.6751	.9550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 202 / 11 KV MAHALPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.3086	.8573	.8573	.8573	.0789
2	.4287	.4287	.3086	.8573	.0857	.8573	.0789
3	.4287	.4287	.3429	.8573	.8573	.8573	.0857
4	.5144	.5144	.4458	.9431	1.0288	.8573	.1115
5	.6001	.6859	.583	1.1145	1.2689	1.0288	.1372
6	.8573	.8573	.6859	1.4575	1.5432	1.2003	.1543
7	1.1145	1.0288	.6859	1.4575	1.5089	1.4232	.1457
8	1.1145	1.2003	.6516	1.3717	1.3717	1.3717	.12
9	.8916	.8573	.6001	1.2346	1.1145	.1029	.7716
10	1.0288	.7888	.7716	.6173	.8573	.0943	
11	.7202	.6173	.5144	.7888	.8573	.0857	.6859
12	.6859	.6173	.6859	1.0974	.8573	.0857	.7716
13		.6173	.6001	.9602	.6859	.0772	.6001
14		.6173	.6001	.7888	.6001	.0772	.6001
15		.6173	.6001	.7202	.5144	.0772	.5144
16	.7716	.6516	.6859	.6859	.5144	.0772	.7716
17	.9945	.7202	.7716	.4801	.6859	.0789	.7716
18	1.0288	.7545	.8573	.7545	1.0288	.0789	.8573
19	1.2003	.9945	1.0288	1.0974	1.0631	.1029	1.0288
20	1.1317		1.2003	1.2689	1.0288	.1286	1.2003
21	1.0631		1.0288	1.0974	.9945	.12	1.0288
22	.9431		.9431	.9602	.9602	.1029	.8573
23	.8916		.8573	.8573	.8573	.0789	.8573
24	.4287	.4287	.2743	.8573	.8573	.8573	.0789
Max	1.2003	1.2003	1.2003	1.4575	1.5432	1.4232	1.2003
Min	.4287	.4287	.2743	.4801	.0857	.0772	.0789
Avg	.8222	.6927	.668	.9659	.9166	.4450	.5351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 203 / 11 KV BHALGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.7888	1.5432	1.5432	1.5432	.1543
2	.8573	.8573	.7888	1.5432	1.5432	1.5432	.1543
3	.8573	.8573	.8573	1.5432	1.5432	1.5432	.1715
4	.9431	1.0288	1.0288	1.7147	1.7147	1.6289	.1972
5	1.1145	1.2003	1.2689	1.8861	1.9547	1.8861	.2315
6	1.5432	1.3717	1.5432	2.4863	2.572	2.0576	.2572
7	1.9719	1.749	1.5432	2.4006	2.2977	2.6578	.2486
8	2.1434	1.7147	1.9547	2.0576	1.989	2.1434	.2058
9	1.7147	1.4746	1.7147	1.8176	1.7147	.1886	1.8861
10	1.5432	1.4746	1.7147	1.4403		.1715	1.286
11	1.3717	1.4403	1.3717	1.166	1.3717	.1457	1.3717
12	1.286	1.4403	1.1145		1.286	.2058	1.6289
13		1.0974	1.0288			.1972	1.3717
14		1.2003	1.1145	1.7147	.6859	.1715	1.3717
15		1.2689	1.2003	1.5775	.6001	.1457	.3429
16		1.2689	1.286	1.5432	.6001	.1372	.4287
17		1.3032	1.3717	1.4746	1.2003	.1372	
18	1.7147	1.3032	1.4575	1.3717	2.1434	.1543	
19	2.2291	1.8519	1.8004	1.7833	1.0288	.1972	2.2291
20	2.3148	1.9547	2.1434	2.2977	2.0405	.2143	2.3148
21	2.1776	1.8861	1.8861	1.9547	1.989	.1886	2.1434
22	1.749	1.7833	1.7147	1.7147	1.8861	.1886	1.8861
23	1.6632	1.7147	1.5432	1.6461	1.7147	.1629	1.7147
24	.8573	.8573	.7888	1.5432	1.5432	1.5432	.1543
Max	2.3148	1.9547	2.1434	2.4863	2.572	2.6578	2.3148
Min	.8573	.8573	.7888	1.166	.6001	.1372	.1543
Avg	1.5215	1.3732	1.3760	1.7373	1.5892	.7980	.9887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 205 / 11KV Om Gajanan Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0514	.0857	.0686	.0686	.0103
2	.0686	.0686	.0514	.0857	.0686	.0686	.0103
3	.0514	.0686	.0514	.0857	.0686	.0686	.011
4	.0514	.0686	.0514	.0857	.0514	.0686	.0086
5	.0514	.0686	.0343	.0686	.0514	.0686	.0069
6	.0514	.0686	.0343	.0686	.0343	.0686	.0069
7	.0514	.0686	.0343	.0686	.0343	.0686	.0069
8	.0514	.0857	.0343	.0686	.0514	.0686	.0069
9	.0514	.12	.0343	.12	.0686	.0086	.1029
10	.0857	.1715	.0686	.12		.012	.12
11	.0857	.1372	.1372	.1372	.12	.0171	.1372
12	.1715	.1372	.0857		.1372	.0137	.1372
13		.12	.0857		.1372	.0137	.1372
14		.1372	.0857		.1372	.0137	.1372
15		.12	.1029	.0857	.1372	.0137	.12
16		.1372	.0857		.1372	.072	.1372
17		.1029	.0686	.0686	.12	.0737	.0857
18	.0857	.1029	.0514	.0686	.0857	.0926	.12
19	.0857	.0857	.0857	.0686	.0686	.0086	.1029
20	.1029		.1029	.0686	.0857	.012	.1029
21	.12	.0686	.1029	.0686	.0857	.012	.1029
22	.1029	.1029	.1029	.0686	.0857	.012	.1029
23	.1029	.0857	.1029	.0686	.0857	.012	.0857
24	.0857	.0857	.0686	.0857	.0686	.0857	.0103
Max	.1715	.1715	.1372	.1372	.1372	.0926	.1372
Min	.0514	.0686	.0343	.0686	.0343	.0086	.0069
Avg	.0803	.0992	.0714	.0823	.0865	.0426	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 206 / 11 Kv R. K. Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0686	.0857	.0857	.0857	.0086
2	.0686	.0686	.0686	.0686	.0857	.0686	.0086
3	.0686	.0686	.0686	.0686	.0857	.0857	.0086
4	.0686	.0686	.0686	.0686	.0686	.0686	.0069
5	.0686	.0686	.0686	.0686	.0686	.0686	.0069
6	.0686	.0686	.0686	.0686	.0686	.0857	.0086
7	.0686	.0686	.0514	.0686	.0857	.0686	.0086
8	.0857	.0857	.1029	.0857	.0857	.1029	.0103
9	.0857	.0857	.1029	.12	.1029	.012	.12
10	.0857	.12	.0857	.1029	.1029	.012	
11	.0857	.1029	.0857	.1029	.12	.012	.0857
12	.0857	.1029	.12	.1029	.12	.012	.1029
13		.1029	.1029	.12	.1029	.012	.12
14		.12	.1029	.1029	.1029	.012	.1029
15		.1029	.1029	.0857	.12	.012	.12
16	.1029	.1029	.0857	.1029	.1372	.012	.1029
17	.1029		.0857	.1029	.1029	.012	.1029
18	.0857	.0857	.0857	.0857	.1029	.0086	.0857
19	.12	.1029	.0857	.1029	.12	.0103	.1029
20	.12	.1029	.1029	.12	.1029	.0103	.1029
21	.12	.1029	.1029	.1029	.1029	.0103	.1029
22	.0857	.0857	.1029	.1029	.0857	.0103	.0857
23	.1029	.0686	.0857	.0857	.0857	.0086	.1029
24	.0857	.0857	.0686	.0857	.0857	.0857	.0086
Max	.12	.12	.12	.12	.1372	.1029	.12
Min	.0686	.0686	.0514	.0686	.0686	.0086	.0069
Avg	.0882	.0895	.0864	.0922	.0972	.0369	.0659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 208 / 11 kv Omicron

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	11-JUN-18
HR	Load (MW)
12	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 201 / 11KV HARMAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	.7811	1.2955	.5716	1.4289	1.2384	1.4289
2	1.5242	.7811	1.1812	.5335	1.3336	1.2384	1.3336
3	1.2955	.7811	1.0479	.5335	1.2574	1.2384	1.3336
4	.9526	.7621	.9145	.5716	1.105	1.2193	1.3717
5	.9526	.724	.8192	.6668	.9526	1.2193	1.3336
6	.9526	.6097	.724	.7621	.8954	1.2193	1.3336
7	.8573	.9526	.724	.9526	1.2193	1.2193	1.2955
8	1.3717		.724	1.3336	1.6194	1.9814	1.3717
9	1.4289	1.6766	.7811	1.6385	1.8671	1.7147	1.9624
10	1.448	1.7147	.8573	1.6956	1.9052	1.7528	1.9052
11	1.448	1.6194	.8002	1.829	2.0195	1.7147	1.8671
12	1.1431	1.3717	.7621	1.9243	1.6766	1.6004	1.8099
13	1.0669	1.3336	.6097	1.848	1.5623	1.467	1.8099
14	1.4098	1.2955	.5716	1.7528	1.7147	1.9052	1.8099
15	1.4289	1.4098	.6097	1.848	1.7147	2.3243	1.9052
16	1.448	1.5432	.6478	2.0005	1.9814	1.8671	1.9433
17	.3048	1.4289	.6097	1.9243	2.0195	1.8671	1.7528
18	1.2193	1.2574	.5716	1.7718	1.7528	1.7909	1.6385
19	1.2574	1.4289	.5716	1.7718	1.2193	1.7909	1.6385
20	1.4098	1.467	.5716	1.6956	1.1812	1.7528	1.6766
21	1.448	1.4861	.5335	1.6194	1.2955	1.6004	1.7147
22	1.105	1.4861	.5335	1.5432	1.3336	1.4289	1.7147
23	.8002	1.448	.5716	1.5242	1.2574	1.5242	1.5623
24	1.8099	.8002	1.3717	.5716	1.4861	1.2574	1.5242
Max	1.8099	1.7147	1.3717	2.0005	2.0195	2.3243	1.9624
Min	.3048	.6097	.5335	.5335	.8954	1.2193	1.2955
Avg	1.2416	1.2243	.7669	1.3702	1.4916	1.5805	1.6266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 202 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	.7095	1.0288	.7621	.9907	.8954	.9145
2	1.1431	.6979	.9907	.8002	.9526	1.0669	.8573
3	.9526	.679	.9717	.8002	.9145	.8764	.8573
4	.9526	.6602	.9145	.7621	.8573	.8764	.7621
5	.8573	.6413	.8764	.7621	.8002	.8573	.7621
6	.8573	.6224	.8573	.8002	.7621	.8383	.7621
7	.6478	.6979	.8383	.7621	.8192	.8192	.7049
8	.5716	.7922	.8002	1.1431	.8954	.8954	.8002
9	.7621	1.1949	1.2003	1.3717	1.2003	1.1622	1.086
10	.8954	1.448	1.3336	1.6194	1.4289	1.3336	1.4289
11	.8954	1.4289	1.5242	1.6385	1.5051	1.5242	1.448
12	.5335	1.4098	1.5623	1.6766	1.5813	1.4098	1.4861
13	.5525	1.3527	1.5623	1.6004	1.3146	1.2955	1.5623
14	.5144	1.2955	1.5242	1.4861	1.5623	1.6194	1.5242
15	.5335	1.5242	1.5242	1.448	1.5813	1.6004	1.4289
16	.5716	1.8099	1.4289	1.4098	1.5623	1.5242	1.3717
17	.5228	1.5432	1.3336	1.6194	1.5432	1.5242	1.3336
18	.5601	1.2003	1.2955	1.5623	1.3527	1.2574	1.1812
19	.5788	1.1622	1.1431	1.1431	1.2003	1.1431	.9907
20	.724	1.1622	.9431	1.105	1.1241	1.1431	1.0479
21	.7282	1.1622	.9808	1.0669	1.0288	1.086	1.0479
22	.8215	1.105	.9431	1.105	.9907	1.0479	1.0479
23	.7282	1.086	.9808	1.086	.9145	1.0098	
24	1.3336	.7095	1.0669	.8573	1.0479	.8954	.9526
Max	1.3336	1.8099	1.5623	1.6766	1.5813	1.6194	1.5623
Min	.5144	.6224	.8002	.7621	.7621	.8192	.7049
Avg	.7698	1.0873	1.1510	1.1828	1.1638	1.1542	1.1025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 203 / 11KV KUMBHEPHAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4715	.4108	.4954	.4668	.4527	.4763
2	.4108	.4904	.4294	.5716	.4854	.4715	.4572
3	.4108	.5281	.4668	.6668	.5228	.4904	
4	.4294	.5658	.5041	.724	.5788	.4904	
5	.4854	.6036	.5601	.724	.6535	.5281	
6	.5601	.6413	.6348	.724	.7282	.5658	
7	.5975	.6979	.6668	.6535	.7095	.6602	
8	.6722	.6224	.6859	.6097	.6722	.5093	
9	.6859	.5847	.5716	.5228	.5601	.6097	
10	.547	.5788	.5716	.5228	.4527	.6287	.381
11	.5847	.5975	.5716	.5601	.4715	.6668	.4763
12	.547	.6348	.5716	.5788	.5144	.6287	
13	.4904	.6161	.5335	.5975	.3772	.6287	
14	.4338	.6161	.4763	.5975	.381	.6097	.5716
15	.4715	.6478	.5716	.5788	.4191	.5716	.6097
16	.4904	.6535	.5716	.5788	.4763	.6668	.6097
17	.5847	.6535	.6097	.5975	.5525	.6859	.6097
18	.5847	.6348	.6668	.5975	.5716	.7621	.6668
19	.5847	.7282	.5658	.5975	.6097	.6859	.5716
20	.5847	.6908	.5658	.6348	.6287	.6478	.5335
21	.6036	.6348	.5281	.6348	.4904	.5335	.5335
22	.4904	.5601	.5281	.5975	.4715	.4954	.5335
23	.4904	.5228	.5281	.5601	.4715	.4763	.4954
24	.4854	.4715	.4668	.4954	.5228	.4715	.4763
Max	.6859	.7282	.6859	.724	.7282	.7621	.6668
Min	.4108	.4715	.4108	.4954	.3772	.4527	.381
Avg	.5281	.6020	.5524	.6009	.5328	.5807	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 204 / 11KV BALIRAJA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	.7621	1.448	1.1812	1.1812	1.2193	
2	1.1431	.7621	1.3717	1.1431	1.1431	1.2003	
3	1.1431	.743	1.2574	1.2384	1.1241	1.2003	
4	.9526	.724	1.1431	1.2384	1.1241	1.2003	
5	.9526	.7049	1.0098	1.3336	1.086	1.1812	
6	.9526	.6478	.8764	1.3717	1.0669	1.1431	
7	.8002	.724	1.0288	1.4289	1.1622	1.1431	
8		.9145	1.2574	1.5242	1.2955	1.4098	
9	.5716	1.1431	1.3336	1.6194	1.4861	1.7147	
10	.8002	1.848	1.8099	1.8671	2.0195	2.0005	2.0005
11	.9907	2.0957	2.0005	1.9243	1.829	2.0386	2.191
12	.9526	2.2291	2.2481	1.9814	2.1719	2.2862	2.2481
13	.9526	2.4387	2.1338	2.2481	1.8671	2.2862	2.3815
14	.9335	2.553	2.0957	2.1529	2.2481	2.3243	2.4768
15	.9145	2.4768	1.9052	2.2862	2.2862	2.3624	2.2862
16	.8764	2.3815	2.0005	2.4387	2.3624	1.7147	2.0957
17	.9526	2.1338	1.7147	2.1338	2.4006	1.7528	1.9052
18	.9526	1.7718	1.3336	1.7718	2.0576	1.7147	1.7147
19	.9526	1.6385	1.3717	1.5242	1.8671	1.7528	1.7147
20	.9145	1.5813	1.3336	1.5051	1.7909	1.7528	1.6385
21	.8764	1.5051	1.3336	1.4861	1.7147	1.829	1.6385
22	.8764	1.6194	1.1431	1.2384	1.6766	1.9052	1.6194
23	.7811	1.5813	1.1431	1.2193	1.2193	2.0005	1.5242
24	1.4861	.7811	1.5242	1.1812	1.2193	1.2193	
Max	1.4861	2.553	2.2481	2.4387	2.4006	2.3624	2.4768
Min	.5716	.6478	.8764	1.1431	1.0669	1.1431	1.5242
Avg	.9592	1.4900	1.4924	1.6266	1.6416	1.6813	1.9596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 205 / 11KV VAISHNAVI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3961	.6348	.5975	.6722	.6478	
2	.415	.3961	.6348	.5975	.6722	.6287	
3	.3772	.415	.6161	.5975	.6908	.6287	
4	.2829	.3961	.6161	.5601	.7095	.6287	
5	.2829	.3772	.6161	.5601	.7095	.6097	
6	.2641	.3961	.6161	.5601	.7282	.6097	
7	.2452	.547	.6668	.6602	.7733	.6287	
8	.2075	.6413	.724	.7545	.811	.6668	
9	.2829	.6224	.8764	1.0288	.9907	.8192	
10	.2452	1.0098	.9526	1.0098	1.1431	1.0288	1.1431
11	.2263	1.0479	.9526	1.086	1.0288	1.1431	1.1431
12	.2263	1.0479	.9526	1.1431	.8954	1.1431	1.0479
13	.2452	1.086	.9907	1.0669	1.0479	.9526	1.0479
14	.2452	1.086	.9907	.9335	.9145	1.0288	1.0288
15	.2286	1.0669	.8573	.9526	.9145	1.0669	1.1431
16	.2096	.9907	.8002	.9526	.8573	1.2003	1.1812
17	.1886	.9335	.8002	.9145	.8383	1.1431	1.0479
18	.1886	.8573	.8002	.8573	.8954	1.0669	1.0288
19	.2075	.6602	.7621	.9717	.4954	.9526	.9145
20	.3395	.6602	.7621	.9145	.4763	.8002	.7621
21	.3772	.6535	.6668	.811	.6097	.6668	.6859
22	.4527	.6161	.6668	.6535	.6478	.7621	.6668
23	.415	.6348	.6097	.6535	.6478	.6478	.6097
24	.4527	.415	.6348	.5601	.6722	.6478	
Max	.4527	1.086	.9907	1.1431	1.1431	1.2003	1.1812
Min	.1886	.3772	.6097	.5601	.4763	.6097	.6097
Avg	.2910	.7064	.7584	.8082	.7851	.8383	.9608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 206 / 11KV SUSHMA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5525	.6535	.4954	.6908	.5716	
2	.5716	.5335	.6161	.4954	.6722	.5525	
3	.5716	.5525	.5975	.5281	.6722	.5525	
4	.5335	.5525	.5601	.5281	.6535	.5525	
5	.5335	.5525	.5415	.4904	.6348	.5335	
6	.5335	.5335	.5415	.4904	.6348	.5335	
7	.4954	.4954	.724	.5281	.6161	.5335	
8	.6478	.6859	1.0669	.9808	.5788	.5716	
9	.5716	.9145	1.105	1.1812	.9907	1.0288	
10	.6478	1.2574	.9526	1.3717	1.4098	1.2193	1.3717
11	.5335	1.3908	1.3717	1.4098	1.2955	1.6194	1.1431
12	.4954	1.467	1.4289	1.4289	1.3717	1.3336	1.0479
13	.4954	1.4289	1.1431	1.2574	.8383	1.2574	1.2574
14	.5716	1.3717	.9907	.7621	.8764	1.2955	1.2955
15	.4954	1.4861	1.2384	.9526	.9145	1.3336	1.2574
16	.4572	1.5813	1.3336	1.1812	1.1431	1.6385	1.2574
17	.5906	1.467	1.1812	1.1812	1.2955	1.6004	1.2574
18	.5906	1.2384	1.1431	1.1622	1.4098	1.3146	1.2574
19	.6097	1.2003	1.1431	1.2955	1.1431	.9526	.6859
20	.5525	1.0479	1.105	1.0479	.5335	.8002	.6097
21	.5335	.6979	.9526	.6979	.5716	.724	.6097
22	.5716	.7167	.9526	.7095	.6097	.724	.5716
23	.5525	.6979	.6668	.7095	.5716	.6668	.4763
24	.6859	.5525	.6602	.5716	.7095	.5716	
Max	.6859	1.5813	1.4289	1.4289	1.4098	1.6385	1.3717
Min	.4572	.4954	.5415	.4904	.5335	.5335	.4763
Avg	.5605	.9573	.9446	.8940	.8682	.9367	1.0070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 207 / 11KV Aurangabad Jalna
TollWays Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0566	.0914	.0914	.0457	.0572	
2	.0457	.0566	.0914	.0686	.0434	.0572	
3	.0305	.0377	.0572	.0343	.0412	.0572	
4	.0305	.0377	.0406	.0339	.0389	.0572	
5	.0305	.0377	.0343	.0335	.0297	.0572	
6	.0305	.0377	.0309	.0324	.0257	.0381	
7	.0305	.0377	.0171	.0324	.0234	.0381	
8	.0305	.0377	.016	.0316	.0217	.0377	
9	.0305	.0377	.0381	.0312	.0278	.0381	
10	.0377	.0244	.0381	.0312	.0381	.0381	.0381
11	.0377	.0244	.0381	.0305	.0381	.0381	.0381
12	.0377	.0236	.0381	.029	.0381	.0381	.0381
13	.0377	.0314	.0381	.0457	.0381	.0381	.0381
14	.0377	.0274	.0381	.044	.0381	.0381	.0381
15	.0377	.04	.0381	.0429	.0381	.0381	.0381
16	.0377	.0457	.0381	.0406	.0572	.0381	.0381
17	.0377	.0457	.0381	.0469	.0381	.0381	.0381
18	.0566	.0463	.0381	.0492	.0572	.0381	.0381
19	.0377	.0312	.0381	.0236	.0381	.0381	.0381
20	.0566	.061	.0762	.061	.0381	.0572	.0381
21	.0566	.0972	.0953	.1086	.0572	.0572	.0381
22	.1132	.0972	.0953	.1029	.0572	.0762	.0762
23	.0566	.1017	.0953	.1006	.0566	.0762	.0953
24	.0686	.0566	.0972	.0934	.081	.0572	
Max	.1132	.1017	.0972	.1086	.081	.0762	.0953
Min	.0305	.0236	.016	.0236	.0217	.0377	.0381
Avg	.0448	.0471	.0524	.0516	.0420	.0476	.0449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 201 / LADSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.4706	.5801		.6335	.7059	.5801
2	.8507	.4887	.7956		.5792	.7421	.663
3	.8869	.5249	.7459		.5973	.8688	.7459
4	.9412	.543			.6335	.9774	.8288
5	.9955	.5611			.6335	1.1041	.9116
6	1.0317	.5792			.724	1.1765	.9945
7	1.1765	.6878			.7964	1.2851	1.0774
8	1.1041	.7421			.8869	1.2308	.7459
9	.905	.7783			.8507	1.086	.5801
10	.7421	.8869		.9231	.7421	.9774	.724
11	.8145			1.0136	.4525		.905
12	.8869			1.086	.4887		.8326
13	.9774			1.0317	.5249		.724
14	1.0136			.9955	.5611		.724
15	.9593				.543		.7602
16	.9231			1.0498	.6516		.6878
17	.9774			1.0317	.6154		.724
18	1.0317			1.086	.5611		.6516
19				.9955	1.0317		.9955
20				1.086	1.1584		1.086
21	.9774			1.1765	1.0498		.905
22	.905			1.0317	.905		.724
23	.8145			.8507	.7421	.5801	.6516
24	.8145	.4344			.724	.6878	
Max	1.1765	.8869	.7956	1.1765	1.1584	1.2851	1.086
Min	.7421	.4344	.5801	.8507	.4525	.5801	.5801
Avg	.9338	.6088	.7072	1.0275	.7119	.9518	.7923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 202 / 11 KV ANJANDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2534			.3982	.4706	
2	.4525	.2715			.3734	.4887	
3	.4525	.3077			.3734	.5249	
4	.543	.3801			.4344	.5249	
5	.724	.4163			.4344	.543	
6	.8145	.4887			.4887	.543	.8288
7	1.1041	.5249	1.0774		.543	.5792	.9116
8	1.1403	.5792			.6335	.6697	
9	1.0317	.6154			.5792	.5792	1.0774
10	.724	.3801		.8145	.543	.3801	.8145
11	.5792			.7421	.724		.905
12					1.0679		.5868
13	.3801				1.1041		1.3032
14	.3982				1.1403		1.267
15	.362				1.1765		1.2308
16	.362				1.1041		1.086
17	.362			.6516	1.0498		.9774
18	.4344			.724	.9955		.724
19	.5068			.4525	.4344		.5792
20	.543				.5249		.724
21	.4344				.4163		.6516
22	.3801				.3801		.4534
23	.3258			.5249	.362	.4973	.4706
24	.3439	.2534			.5249	.5249	
Max	1.1403	.6154	1.0774	.8145	1.1765	.6697	1.3032
Min	.3258	.2534	1.0774	.4525	.362	.3801	.4534
Avg	.5548	.4064	1.0774	.6516	.6586	.5271	.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 203 / 11 KV PIMPALKHUTTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2896	.1658		.362	.4887	.4144
2	.3801	.3077	.1658		.362	.5249	.4973
3	.3982	.3801	.2486		.3801	.543	.5801
4	.4344	.543	.3315		.3801	.5792	.663
5	.4706	.6154	.4144		.3801	.6154	.4973
6	.5068	.6878	.4973		.4344	.7421	.5801
7	.5973	.5792	.4144		.6335	.8688	.5801
8	.6878	.4706			.7964	.7602	.5801
9		.3439				.5792	.3258
10	.362	.181		.3801	.3439	.2172	.362
11	.3258			.1448	.2715		.2715
12	.2715				.2172		.3258
13	.1991						
14	.3801						
15	.3982						
16	.4525						.2172
17	.4706						
18	.4525			.3077			.2896
19	.4344			.6154			.4525
20	.4525			.5611	.3801		.543
21	.3801			.4525	.4344		.5068
22	.362			.3439	.3439		.4344
23	.3077			.3077	.3077	.3315	.362
24	.362	.2715			.2896	.4344	
Max	.6878	.6878	.4973	.6154	.7964	.8688	.663
Min	.1991	.181	.1658	.1448	.2172	.2172	.2172
Avg	.4108	.4245	.3197	.3892	.3948	.5571	.4465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 204 / SAYYAIDPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.3801		.543	.7059	.5801
2	.5792	.4344		.5792	.7602	.663
3	.5792	.543		.6154	.7964	.7459
4	.6154	.7602		.6516	.9774	1.4918
5	.6516	.9231		.7059	1.2308	.9945
6	.724	.9955		.8326	1.4661	1.1603
7	.9593	.9955		1.086	1.5384	.8145
8	.724	.8869		1.6289	1.5746	1.1603
9	.5611	.8326		1.1584	1.3394	1.326
10	.4163	.5068	.7059	.5068	.4706	.4525
11	.6335		.7964	.3439		.362
12	.9593			.2896		.3801
13	1.0317			.3077		
14	.8688			.3077		.4344
15	.905			.3077		.5068
16	.9774			.3439		
17	.9593		.181	.3982		.543
18	.9231		.4706	.3801		.5068
19	.724			.724		.7783
20	.5068		.543	.724		.905
21	.4706		.5068	.543		.8326
22	.3801		.4344	.3982		.724
23	.362		.3801	.362	.5801	.543
24	.543	.3077		.4525	.6154	
Max	1.0317	.9955	.7964	1.6289	1.5746	1.4918
Min	.362	.3077	.181	.2896	.4706	.362
Avg	.6916	.6878	.5023	.5913	1.0046	.7574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 205 / 11 KV Hatmali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.362	.3315		.543	.6878	.4973
2	.6516	.3801	.4144		.6878	.7602	.5801
3	.724	.543	.4973		.6335	.8507	.663
4	.7421	.6335	.5801		.724	.9774	.8288
5	.7964	.7602	.7459		.7964	1.3575	.9945
6	.905	.9593	.8288		1.0498	1.4661	1.0774
7	1.0498	.7964			1.267	1.5746	1.1603
8	.7421	.724			1.4842	1.3756	1.2431
9	.6516	.5973			1.1403	.6335	.7459
10	.4706	.4344		.6154		.3077	.362
11	.5611			.2896			.2715
12	.6335				.2534		.3361
13	.5973				.2353		.362
14	.5611				.2353		.3801
15	.5792				.2172		.3258
16					.2172		.2801
17	.6516				.2172		
18	.5792			.362	.362		
19	.724			.6154	.4706		.7783
20	.5249			.5792	.5249		.8688
21	.5068			.4887	.5611		.8326
22	.3801				.4163		.5792
23	.3258			.3801	.3801	.4973	.5068
24	.543	.2896			.5249	.543	
Max	1.0498	.9593	.8288	.6154	1.4842	1.5746	1.2431
Min	.3258	.2896	.3315	.2896	.2172	.3077	.2715
Avg	.6319	.5891	.5663	.4758	.5883	.9193	.6511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 206 / BHAKARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.543		.2715	.3439	.3315
2	.3439	.5611		.2715	.3801	.4144
3	.362	.6335		.3258	.4706	.4144
4	.5249	.6878		.3801	.543	.4973
5	.6335	.7421		.6154	.6878	.663
6	.6697	.8869		.8869	.7421	.8288
7	.7421	1.267		.9774	.8145	.7956
8	.6516	1.3756		.905	.7421	.4144
9	.6154	1.2489		.724	.7059	.3315
10	.2534	.4163	.543	.4344	.4344	.2715
11	.1991		.724	.724		.362
12	.1086			1.3575		.8326
13	.1448		.7602	1.1403		1.0136
14	.1629		.7964	1.0679		1.0498
15	.1991		.905	1.0317		1.086
16	.2896		.9774	.9774		
17	.181		1.0317			
18	.3258		1.1041	.4344		
19	.6154		.5973	.6878		.5068
20	.543		.543	.724		.5792
21	.4706		.4706	.4344		.5068
22	.3982		.3982	.3982		.362
23	.362		.362	.3801	.3315	.2896
24	.2172	.4344		.2534	.3077	
Max	.7421	1.3756	1.1041	1.3575	.8145	1.086
Min	.1086	.4163	.362	.2534	.3077	.2715
Avg	.3876	.7997	.7087	.6697	.5420	.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 201 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.4287	.4287	.0171	.1715	.1715	.1524
2	.0343	.4287	.4287	.0171	.1715	.1715	
3	.0343	.4287	.4287	.0257	.2572	.1715	.1524
4	.0429	.5144	.5144	.0343	.3353	.1715	.1524
5	.0429	.6001	.6001	.0514	.4191	.2572	.1524
6	.0514	.7716	.7716	.0514	.5868	.5144	.4572
7	.0514	.5144	.5144	.0514	.6706	.6859	.6097
8	.0429	.4287	.4287	.0514	.6706	.7716	.6859
9	.0343	.3429	.3429	.0429	.5868	.6859	.6097
10	.0257	.2829	.2572	.0343	.3429	.2572	.2572
11	.1715	.1524	.0257	.1715	.1715	.1715	.0171
12	.1715	.1524	.0343	.1715	.1715	.1715	.0171
13	.2572	.2286	.0343	.1715	.1715	.1715	.0257
14	.2572	.2286	.0343	.1715	.1715		.0257
15		.2286	.0429	.1715	.1715		.0257
16	.2572	.2515	.0514	.1715	.2572	.2572	.0257
17	.3429	.3353			.1715	.1715	.0257
18	.2572	.2515		.2572	.3429	.3429	.0343
19	.4287	.4904		.4287	.5144	.5658	.0514
20	.6001	.6602	.0429	.5144	.5144	.5658	.0514
21	.5144	.5658	.0514	.4287	.4287	.4715	.0429
22	.5144	.5658	.0429	.4287	.4287	.4715	.0429
23	.4287	.4715	.0343	.3429	.3429	.3772	.0343
24	.0343	.4287	.4287	.0171	.1715	.1715	.1886
Max	.6001	.7716	.7716	.5144	.6706	.7716	.6859
Min	.0257	.1524	.0257	.0171	.1715	.1715	.0171
Avg	.2013	.4064	.2637	.1662	.3434	.3531	.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 202 / EKLAHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086	.0857	.0857	.0514	.8383	.6859	.6097
2	.0086	.0857	.0857	.0514	.8383	.6859	.6097
3	.0086	.0857	.0857	.06	.8383	.7716	.6859
4	.0086	.0857	.0857	.06	.9221	.7716	.6859
5	.0171	.1715	.1715	.0686	1.0059	.7716	.6859
6	.0257	.2572	.2572	.0857	1.2574	1.1145	1.0898
7	.0171	.1715	.1715	.1029	1.4251	1.286	1.1431
8	.0171	.1715	.1715	.1115	1.4251	1.5432	1.3717
9	.0086	.0857		.1115	1.4251	1.4575	1.2955
10	.0086	.0857		.0086	.0857	.0857	.0857
11	1.0288	.9145	.0943	.0857	.0857	.0857	.0086
12	1.0288	.9145	.1115	.0857	.0857		.0086
13	1.1145	1.0059	.12	.0857	.0857	.0857	.0086
14	1.0288	.9145	.12		.0857	.0857	.0086
15	1.0288	.9145	.12			.0857	.0086
16	1.0288	.9145	.12	.0857		.0857	
17	1.0288	.9145	.1286	.0857		.0857	
18	.9431	.8535	.1286	.0857		.0857	
19	.0857	.0943	.0086	.0857	.1715	.1715	
20	.0857	.0857	.0171	.1715	.1715	.1715	
21	.1715	.6859	.0171	.1715	.1715	.1715	.0171
22	.0857	.0857	.0086	.1715	.0857	.0857	.0171
23	.0857	.0857	.0086	.1715	.0857	.0857	.0171
24	.0086	.0857	.0857	.0514	.8383	.7716	.8383
Max	1.1145	1.0059	.2572	.1715	1.4251	1.5432	1.3717
Min	.0086	.0857	.0086	.0086	.0857	.0857	.0086
Avg	.3701	.4065	.1001	.0931	.5964	.4883	.4840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 203 / CHITEPIMPALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0772	.6859	.6706	.0686	.6859	.6001	.6001
2	.0857	.6859	.6706	.0686	.6859	.6859	.6859
3	.0943	.7716	.7545	.0772	.6859	.6859	.6097
4	.1115	.8573	.8383	.0857	.7716	.8573	.8573
5	.12	.9431	.9221	.0943	.7716	.9431	1.0374
6	.1372	1.286	1.2717	.1286	1.1145	1.3717	1.5089
7	.1457	1.3717	1.3413	.1372	1.286	1.286	1.286
8	.1543	1.4575	1.5927	.1286	1.2003	1.1145	1.1145
9	.1372	1.3717		.1029	1.0288	1.0288	1.0288
10	.0772	.8488		.0772	.8573	.8573	.8573
11	.5144	.5658	.0686	1.2574	.6859	1.0669	.1629
12	.5144	.5144	.0686	1.6766	1.3717	1.3413	.18
13		.5144	.06	1.8442	1.5432	1.3717	.18
14	.5144	.5144	.06		1.7147	1.5242	.1886
15	.6001	.6001	.06	1.3413	1.5432	1.6095	.18
16	.6859	.6859	.0686	1.5927	1.7147	1.6766	.1715
17	.6859	.6859	.0686	1.3413	1.5432	1.5089	.18
18		1.0288	.0857	1.1736	1.6289	1.5927	.18
19	1.0288	1.0288	.1029	1.2003		1.226	.0943
20	1.1145	1.1145	.1029	1.1145	1.1145	1.226	.1029
21	.8573	.8573	.0943	.9431	.8573	.8573	.0943
22	.7716	.7716	.0857	.7716	.8573	.9431	.0857
23	.6859	.6859	.0686	.6859	.6859	.7545	.0686
24	.0686	.6859	.6706	.0686	.6859	.6859	.7545
Max	1.1145	1.4575	1.5927	1.8442	1.7147	1.6766	1.5089
Min	.0686	.5144	.06	.0686	.6859	.6001	.0686
Avg	.4174	.8556	.4421	.6948	1.0884	1.1173	.5087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 204 / pachod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.3429	.3353	.0429	.5144	.4287	.4287
2	.0514	.3429	.3353	.0429	.5144	.4287	.4287
3	.06	.3429	.3353	.0429	.5144	.4287	.4287
4	.0772	.3429	.3353	.0514	.6001	.5144	.5144
5	.0857	.4287	.4191	.06	.7716	.6859	.6859
6	.1029	.7716	.7545	.0686	.8573	.9431	.9431
7	.1115	1.0288	1.0898	.0772	.8573	.8573	.8573
8	.1286	1.2003	1.1736	.0686	.7716	.6859	.6859
9	.1115	1.1145		.0514	.6859	.6001	.6001
10	.0514	.5658		.0514	.5144	.5144	.5658
11	.3429	.3429	.0429	.6706	.6001	.5335	.0857
12	.2572	.2572	.0429	.9221	.5144	.6602	.12
13	.3429	.3429	.0343	.5868	.9431	.9221	.1029
14	.3429	.3429	.0343	.6706		.9145	.1029
15	.3429	.3429	.0343	.6706	1.0288	1.0898	.1029
16	.3429	.3429	.0343	.6706	1.1145	.9907	.1029
17	.4287	.4287	.0343	.5868	1.2003	1.1736	.1115
18	.5144	.5144	.0514	.8383	.8573	.8383	.1115
19	.6859	.6859	.0686	.6001	.6859	.7545	.0686
20	.7716	.7716	.0772	.7716	.7716	.8488	.0772
21	.6001	.6001	.0772	.6001	.6001	.6602	.0686
22	.5144	.6516	.0514	.5144	.5144	.5144	.06
23	.4287	.4287	.0429	.5144	.5144	.5658	.0514
24	.0429	.3429	.3353	.0429	.5144	.5144	.5658
Max	.7716	1.2003	1.1736	.9221	1.2003	1.1736	.9431
Min	.0429	.2572	.0343	.0429	.5144	.4287	.0514
Avg	.2829	.5365	.2609	.3841	.7157	.7112	.3279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 205 / Pimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.8573	.8573	.0343	.3353	.3429	.3048
2	.0943	.8573	.8573	.0343	.3353	.3429	.3048
3	.0943	.9431	.9431	.0429	.3353	.3429	.3048
4	.1029	.9431	.9431	.0514	.4191	.4287	.3048
5	.12	1.0288	1.0288	.06	.4191	.4801	.381
6	.1286	1.2003	1.2003	.06	.503	.5144	.4572
7	.1115	1.1145	1.1145	.0514	.503	.6001	.5335
8	.1029	.9431	.9431	.0514	.5868	.6001	.5335
9	.0943	.8573	.9431	.0514	.503	.6001	.5335
10	.0943	.7716	.7716	.0772	.7716	.8573	.8573
11	.3429	.3429	.0429	.6859	.7716	.8573	.0857
12	.3429	.3429	.0429	.6859	.7716	.7716	.0772
13	.4287	.381	.0429	.6859	.7716	.7716	.0772
14	.3429	.3048	.0429	.6859	.7716	.7716	.0772
15	.4287	.3353	.0429	.6859		.7716	.0857
16	.3429	.3353	.0429	.7716	.8573	.8573	.0857
17	.4287	.4191	.0514	.8573	.8573	.8573	.0857
18	.3429	.3391		.8573	.9431	.9431	.0857
19	.9431	1.0374	.1029	.9431	1.0288	1.1317	.1115
20	1.1145	1.226	.1115	1.2003	1.1145	1.226	.1286
21	1.1145	1.226	.1029	1.0288	1.1145	1.226	.12
22	1.1145	1.226	.1029	1.0288	1.1145	1.226	.1115
23	1.0288	1.1317	.1029	1.0288	1.0288	1.1317	.1115
24	.1029	.9431	1.0374	.0343	.3353	.4287	.3353
Max	1.1145	1.226	1.2003	1.2003	1.1145	1.226	.8573
Min	.0943	.3048	.0429	.0343	.3353	.3429	.0772
Avg	.3940	.7961	.4988	.4873	.704	.7534	.2539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 206 / Bafana feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086	.0857	.0762	.0086	.0857	.0857	.0762
2	.0086	.0857	.0857	.0086	.0857	.0857	.0762
3	.0086	.0857	.0857	.0086	.0857	.0857	.0762
4	.0086	.0857	.0857	.0086	.0857	.0857	.0762
5	.0086	.0857	.0857	.0086	.0857	.0857	.0762
6	.0086	.0857	.0857	.0086	.0857	.0857	.0762
7	.0086	.0857	.0857	.0086	.0857	.0857	.0762
8	.0086	.0857	.0838	.0086	.0857	.0857	.0762
9	.0086	.0857	.0857	.0086	.0857	.0857	.0762
10	.0086	.0762	.0857	.0086	.0857	.0857	.0857
11	.0857	.0762	.0086	.0857	.0857	.0762	.0086
12	.0857	.0762	.0086	.0857	.0857	.0762	.0086
13	.0857	.0762	.0086	.0857	.0857	.0857	.0086
14	.0857	.0762	.0086	.0857	.0857	.0857	.0086
15	.0857	.0857	.0086	.0857	.0857	.0857	.0086
16		.0857	.0086	.0857	.0857	.0857	.0086
17	.0857	.0762	.0086	.0857	.0857	.0762	.0086
18	.0857	.0762	.0086	.0857	.0857	.0762	.0086
19	.0857	.0762	.0086	.0857	.0857	.0857	.0086
20	.0857	.0762	.0086	.0857	.0857	.0762	.0086
21	.0857	.0762	.0086	.0857	.0857	.0857	.0086
22	.0857	.0762	.0086	.0857	.0857	.0943	.0086
23	.0857	.0762	.0086	.0857	.0857	.0857	.0086
24	.0086	.0857	.0857	.0086	.0857	.0857	.0838
Max	.0857	.0857	.0857	.0857	.0857	.0943	.0857
Min	.0086	.0762	.0086	.0086	.0857	.0762	.0086
Avg	.0488	.0810	.0435	.0504	.0857	.0841	.0403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 207 / Ambikarpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086	.0857	.0857	.0171	.0857	.0857	.0762
2	.0086	.0857	.0857	.0171	.0857	.0857	.0762
3	.0086	.0857	.0857	.0257	.1715	.0857	.0762
4	.0086	.0857	.0857	.0257	.1715	.0857	.0762
5	.0171	.1715	.1715	.0257	.2515	.1715	.1524
6	.0257	.3429	.3429	.0343	.4191	.2572	.2286
7	.0171	.1715	.1715	.0343	.5868	.5144	.4572
8	.0171	.1715	.1715	.0429	.6706	.6859	.6097
9	.0086	.0857	.0857	.0343	.5868	.5144	.4572
10	.0086	.0857	.0857	.0086	.0857	.0857	.0857
11	.1715	.1524	.0257	.0857	.0857	.0857	.0086
12	.2572	.2286	.0257	.0857	.0857	.0857	.0086
13	.2572	.2286	.0257	.0857	.0857	.0857	.0086
14	.1715	.1524	.0257	.0857	.0857	.0857	.0086
15	.1715	.1677		.0857	.0857	.0857	.0086
16	.1715	.1524	.0343	.0857	.0857	.0857	.0086
17	.2572	.2286	.0429	.0857	.0857	.0857	.0086
18	.1715	.1524	.0343	.0857	.0857	.0943	.0086
19	.1715	.1715	.0086	.1715	.0857	.0857	.0086
20	.1715	.1715	.0171	.1715	.1715	.1715	.0171
21	.0857	.0857	.0171	.1715	.1715	.1886	.0171
22	.0857	.0857	.0086	.0857	.0857	.0857	.0086
23	.0857	.0943	.0086	.0857	.0857	.0857	.0086
24	.0086	.0857	.0857	.0171	.0857	.0857	.0838
Max	.2572	.3429	.3429	.1715	.6706	.6859	.6097
Min	.0086	.0857	.0086	.0086	.0857	.0857	.0086
Avg	.0986	.1470	.0753	.0689	.1869	.1654	.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 201 / GANDHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.7468		.2801	.2804	.3361	.2915
2	.7202	.7655	.7842	.2987	.3155	.3547	.2743
3	.8745	.8029	.8029	.2801	.3155	.3361	.3429
4	1.0117	.8402	1.0269	.4108	.3506	.3734	.6001
5	1.1317	1.1016	1.1203	.5415	.5083	.5415	.6516
6	1.2346	1.4563	2.5789	.6161	.7011	.6722	.6859
7	1.2346	1.4937	1.2003	.6161	.7712	.8871	.8573
8	2.2805	1.4377	1.3203	.6908	.6687	.8589	.8059
9	.9088	1.046	1.1317	.5788	.5144	.8316	.8059
10	.9259	.9259	1.0288	.7888	.5316	.9602	.8916
11	.4973	.4115	.4458	.7202	.6535	.7545	.5487
12	.5316	.5144	.4458	.7202	.6535	.5658	.6516
13	.5487		.463	.6173	.6348	.5144	.6344
14	.5144	.4801	.6516	.583	.5788	.5487	.6001
15	.4973	.4973	.4801	.6173		.6344	.6001
16	.3086	.5658	.4458		.7282	.6001	.6173
17	1.2895	.5316	.6348		.8589	.7468	.4458
18	.6722	.5228	.5788	.8589	.9896	1.0082	
19	1.1389	1.1203	.6722	.9149	1.2323	1.1203	1.3443
20	1.1088		.7282	1.1576	1.2323	1.1576	1.2136
21	1.0456		1.0082	1.1203	1.0082	1.0642	1.0642
22	.9896		.9149	.8589	.9055	1.0269	1.0269
23	.8029		.7655	.724	.7468	.0747	.7964
24	.6859	.7468	.8029	.2987	.2743	.3174	.2915
Max	2.2805	1.4937	2.5789	1.1576	1.2323	1.1576	1.3443
Min	.3086	.4115	.4458	.2801	.2743	.0747	.2743
Avg	.9009	.8425	.8710	.6497	.6719	.6786	.6975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 202 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2427	.2658	.5415	.5249	.5601	.5792
2	.2915	.2427	.2658	.5975	.5601	.5788	.5792
3	.3772	.2427	.4961	.5868	.5601	.5601	.724
4	.4287	.2614	.5316	.7282	.7095	.6161	.8145
5	.4801	.3361	.5316	.8589	.9335	.7282	.905
6	.5487	.6722	.567	1.1389	1.0269	.9795	1.1222
7	.7202	.9149	.5658	1.1949	1.1763	.961	1.1576
8	.8402	.9335	.463	.9709	.9593	.9055	1.1016
9	.703	.7373	.463	.9522	.724	.7392	.9231
10	.583	.6173	.5144	.583	.7059		.6344
11	.4801		.4287	.2229	.4973		.2572
12	.4458	.5487	.3772		.4801	.583	.3258
13			.463	.2229		.3944	.463
14		.5658	.3601	.463		.6001	.4287
15		.5316	.3772	.4801		.5487	.3944
16	.4973	.4287	.3772	.463	.3921	.6516	.4973
17	.5658	.4115	.5415	.3772	.5041	.6516	.4801
18	.5415	.5975	1.251			.5144	.5068
19	.8962	.8215	1.2883	.6535		.7468	.8029
20	.9335		1.1016	1.0269		.8775	.7468
21	.8589		.7095			.6535	.7095
22	.7282		.6535	.6535	.6161	.6535	.6722
23	.6161		.5975	.6535	.6722	.6722	.5792
24	.1886	.2427	.2658	.5601	.5249	.5788	.5792
Max	.9335	.9335	1.2883	1.1949	1.1763	.9795	1.1576
Min	.1886	.2427	.2658	.2229	.3921	.3944	.2572
Avg	.5697	.5194	.5607	.6633	.6804	.6707	.6660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 203 / SINDHON BINDHON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7095	.5847	.4481	.4525	.4108	.3982
2		.7468	.7087	.4435	.4525	.4481	.3982
3	.6344	.8029	.7087	.4854	.4668	.4294	.5601
4	.703	.8589	.7442	.5415	.5068	.4668	.724
5	.9945	.9335	.7973		.543	.7282	.724
6	1.0631	1.3256	.8682	1.0269	.6535	.9055	.8029
7	1.2689	1.475	.9602	1.1016	.7095	.7947	1.1203
8	1.2174	1.363	1.0117	.9335	.4887	.9979	1.1016
9	1.166	1.0117	1.0117	.8029	.5068	.7762	.6154
10	.4458	.3601	.3601	.4115	.362	.3772	.3429
11	.3944	.2915	.2915	.7716	.5144	.9602	.7545
12	.3258	.2229	.2743	1.0117	.6535	.9774	.7373
13	.3429		.2743	.9945	.5041	1.046	.7888
14	.3086	.2915	.2915		.8962	.9945	1.0288
15	.3086	.1886	.3258	.3086	.9149	.9774	1.0117
16	.3258	.3601	.3258	.2743	.8962	.9602	1.0288
17	.4458	.3772	.4854	.2572	1.0456	1.0117	1.046
18	.4108	.6348	.5975		.9896	.9431	1.1222
19	.7655	.6908	.6535	.3547	.5601	.7468	.8402
20	.7095		.6348	.7842	.5041	.6908	.8402
21	.7282		.5975	.7095	.4481	.6908	.5415
22	.5788		.5601	.4294	.4108	.6908	.5415
23	.4668		.4668	.5975	.3921	.3547	.4163
24	.4458	.6722	.5847	.4668	.4525	.3734	.3982
Max	1.2689	1.475	1.0117	1.1016	1.0456	1.046	1.1222
Min	.3086	.1886	.2743	.2572	.362	.3547	.3429
Avg	.6347	.7009	.5883	.6264	.5968	.7397	.7452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 204 / 11 KV EXP.MAHANANDA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0373	.0724	.0754	.0934	.0934	.0934
2	.0857	.0373	.0905	.0747	.0934	.0934	.0934
3	.0857	.0187	.0747	.056	.0934	.0747	.0934
4	.0686	.0373	.056	.0373	.0934	.0747	.0934
5	.0514	.0373	.056	.0373		.056	.0747
6	.0171	.0373	.0373	.0373	.056	.056	.0373
7	.0514	.0373	.0514	.0373	.0373	.037	.0373
8	.0171	.056	.0514	.056	.056	.0739	.0373
9	.12	.0857	.0686	.0747	.0747	.1109	.0857
10	.1029	.0857	.1029	.1029	.0934	.1372	.1029
11	.12	.12	.0857	.1029	.0905	.1543	.0857
12	.0857	.1029	.0857	.0857	.0905	.12	.0857
13	.1029		.0857	.0857		.0686	.0857
14	.12	.12	.1029	.9088		.0514	.12
15	.12	.12	.12	.12	.1307	.12	.12
16	.12	.12	.1029	.1029	.1307	.12	.1029
17	.0857	.12	.1307	.1029	.112	.1448	.1029
18		.1307	.0747	.0747	.0747	.1267	.0934
19	.056	.056	.0934	.112	.056	.0934	.0747
20	.056		.0747	.0056	.056	.0747	
21	.0747		.0747	.0747	.056	.0747	.0747
22	.056		.0934	.056	.0566	.0747	.056
23	.0747		.0934	.0747	.0373	.0747	.056
24	.0343	.056	.0724	.0934	.0934	.0934	.0934
Max	.12	.1307	.1307	.9088	.1307	.1543	.12
Min	.0171	.0187	.0373	.0056	.0373	.037	.0373
Avg	.0772	.0745	.0813	.1079	.0798	.0916	.0826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 205 / PRATIK METAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1149	.1112	.168	.1307		.1494	.168
2	.1149	.1307		.112		.168	.168
3	.1115	.1307	.168	.1307		.168	.168
4	.1183	.112	.168	.1307		.168	.168
5	.1132	.112	.168	.1307		.168	.1494
6	.12	.1307	.168	.1307		.168	.1494
7	.1149	.1307	.1543	.1494		.1663	.168
8	.12	.1307	.1543			.1663	.168
9	.12	.12	.1372	.1494		.1663	
10	.1029	.1029	.1372	.1372		.2058	.1715
11	.12	.12	.1543	.12		.2572	.1886
12	.1029	.1715	.1715	.12		.2401	.2229
13	.1029		.1372	.12		.2229	.1372
14	.12		.1543	.1543	.2614	.1715	.1543
15	.12	.1372	.1543	.1372	.3174	.2401	.1886
16		.1372	.1372	.1543	.2427	.2401	.2058
17		.1372	.1494	.12	.2427	.2241	.2058
18	.1158		.168		.1867	.1867	.2054
19	.112		.168		.2241	.1867	.168
20					.2241	.1867	
21	.1307				.2054	.1867	.1494
22	.112		.1307		.1867	.1867	.1587
23	.112		.112		.168	.1494	.1494
24	.1166	.112	.168	.112		.168	.168
Max	.1307	.1715	.1715	.1543	.3174	.2572	.2229
Min	.1029	.1029	.112	.112	.168	.1494	.1372
Avg	.1150	.1267	.1537	.1317	.2259	.1892	.1718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 206 / 11 KV MGM FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.0187	.0187	.0187	.0187	.0187	.0187
2	.0154	.0187	.0187	.0187	.0187	.0187	.0187
3	.0103	.0187	.0187	.0187	.0187	.0187	.0187
4	.0154	.0187		.0187	.0187	.0187	.0187
5	.0103	.0373		.0187	.0187	.0187	.0187
6	.0103	.0187		.0187	.0187	.0187	.0187
7		.0187	.0171	.0187	.0187	.0185	.0187
8	.0171	.0187	.0171	.0187	.0187	.0185	.0187
9	.0171	1.046	.0171	.0187	.0187	.0185	.0243
10	.0171	.0171	.0171	.0343	.0261	.0343	.0171
11	.0343	.0171		.0343	.0373	.0514	.0514
12	.0171	.0171		.0171	.0373	.0514	.0514
13	.0171			.0171	.028	.0514	.0343
14	.0171	.0171	.0171	.0171	.0373	.0514	.0343
15	.0343	.0171	.0171	.0171	.0373	.0343	.0343
16	.0343	.0343	.0171	.0343	.056	.0686	.0171
17				.0171	.0373		.0171
18		.0149	.0373		.0187		.0187
19	.168	.0168	.0187	.0168	.0187	.0168	.0187
20	.1494		.0373	.0187	.0187	.0149	
21	.0187		.0187	.0187	.0187	.0168	.0149
22	.0187		.0373	.0243	.0187	.0168	.0168
23	.0187		.0187	.0187	.0187	.0168	.0187
24	.0137	.0187	.0187	.0187	.0187	.0187	.0187
Max	.168	1.046	.0373	.0343	.056	.0686	.0514
Min	.0103	.0149	.0171	.0168	.0187	.0149	.0149
Avg	.0385	.0769	.0213	.0205	.0248	.0278	.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 201 / Khodegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.7545	.7922	.3258	.2896	.3109	.3982
2	.6413	.7167	.7545	.3258	.2926	.3224	.4066
3	.6413	.679	.8488	.3506	.3258	.3403	.462
4	.6413	.7545	.9431	.4239	.3982	.4031	.4938
5	.7545	.8676	1.0374	.4191	.5144	.4908	.5853
6	.8676	1.0374	1.2826	.5182	.6706	.5487	.8215
7	.9619	.9808	1.1317	.4915	.852	.9116	1.1203
8	1.1317	.811	1.094	.7209	.8583	1.0402	1.0164
9	.9997	.6036	.6036	.6882	.8356	.7969	.8871
10	.3898	.6036	.6036	.5281	.6161	.6001	
11	.3982	.2686	.5087		.4715	.4287	
12	.2715		.6001	.2075	.415	.4681	
13	.4334	.543	.4424	.1886	.3772	.5201	
14	.4578	.631	.5087	.2263	.415	.4973	.5596
15	.3887	.5973	.4973	.2075	.415	.4973	.6602
16	.431	.6661	.5144	.1698	.4715	.4329	.7167
17	.4973	.6687			.5281	.8145	.7356
18	.4428	.6371		.7545	.6413	.905	.8488
19	.8676	.8676	.679	1.094	.6602	1.0164	.7356
20	.9054	.9431	.9431	1.1506	.6224	.9795	.9431
21	1.0185	.9054	.9054	.8676	.6036	.8775	.9242
22	.811	.8676	.7922	.8676	.5658	.7468	.6602
23	.7733	.7545	.7356	.8488	.547	.6535	.5281
24	.7167	.7545	.7922	.2926	.3109	.3109	.362
Max	1.1317	1.0374	1.2826	1.1506	.8583	1.0402	1.1203
Min	.2715	.2686	.4424	.1698	.2896	.3109	.362
Avg	.6694	.7354	.7732	.5303	.5291	.6214	.6933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 202 / Kachner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1829	.1463	.4715	.4715	.4904	.4904
2	.1612	.1829	.128	.4904	.4904	.4715	.4904
3	.1791	.2149	.1463	.5281	.5658	.5093	.547
4	.2149	.2507	.1829	.6979	.6602	.5658	.7167
5	.3045	.333	.3292	.7842	1.1203	.7356	.9808
6	.4298	.4908	.3856	1.2567	1.307	1.3203	1.3957
7	.5194	.5731	.6001	1.1576	1.3256		
8	.591	.5373	.7042	1.094	1.1317		.7545
9	.5731	.4572	.7042	.9054	1.1883	1.2449	1.1317
10	.547	.6602	.7282			.9431	
11	.547	.5281	.7545	.4458			
12	.547	.4715	.7356	.4191		.5093	.5087
13	.6413	.415	.4904	.3561		.5658	.4409
14	.5281	.3961	.5281	.3681		.4715	.4191
15	.6036	.4338	.5281	.3856		.4715	.4694
16	.6602	.5658	.4904	.3944	.4801	.547	.5426
17		.6036		.4862	.5609	.6602	.5426
18	1.0185	.9431		.5533	.6556	.6413	.5197
19		1.1317		1.094	.9431	1.0374	1.0374
20	.9431		.5658	1.0374	.7733	.9808	.9431
21	.8488	.7356	.7922	.7545	.5847	.8488	.7545
22	.5847	.679	.6602	.5658	.5658	.7545	.8488
23	.4904	.6036	.5093	.5658	.547	.6036	.5281
24	.1433	.1478	.181	.4715	.4904	.4904	.5093
Max	1.0185	1.1317	.7922	1.2567	1.3256	1.3203	1.3957
Min	.1433	.1478	.128	.3561	.4715	.4715	.4191
Avg	.5108	.5016	.4900	.6645	.7701	.7078	.6939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 203 / Gadiwat

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3887	.5868	.5658	.5281	.5281	.5093
2	.3155	.4001	.6706	.5281	.5281	.5281	.547
3	.333	.4321	.8048	.415	.547	.547	.5658
4	.333	.4858	1.0174	.4527	.5658	.6036	.5658
5	.3856	.5407	1.0526	.4904	.6036	.6602	.6036
6	.4207	.6554	1.1203	.5658	.7167	.7167	.6602
7	.4733		1.0936	.547	.7167	.6413	.6979
8	.4908	.4694	1.4864	.4527	.6413	.6036	.6602
9	.6661	.6859	1.2967	.4527	.6413	.5281	.5658
10	.5658		.3921	.3018	.415	.4904	.415
11		.3584	.415	.9389	.4572	1.1128	
12	.3018	.2829	.3961	1.0227	.4572	1.358	.7545
13	.3772	.3584	.3961	.8718		1.4523	1.0059
14	.3395	.4904	.3961	.9945	.9214	1.5089	1.0898
15	.3772	.2829	.415	.9831	1.0536	1.5089	1.0898
16	.4338		.3961	1.0059	1.0595	1.4146	
17	.4904			.7968	.9488	1.3203	1.1904
18		.3961	.5121	.6401	.8162	1.0185	
19	.547	.3961	.6602	.3772	.9997	1.0374	.7545
20	.6979	.5658	.7167	.5847	.3961	.8865	.7095
21	.6413	.6224	.679	.5281	.4904	.6602	.679
22	.5658		.6602	.5281	.4715	.6036	.6036
23	.4715	.5658	.6036	.5281	.4338	.5093	.5658
24	.3155	.3887	.3018	.5847	.5658	.5658	.5093
Max	.6979	.6859	1.4864	1.0227	1.0595	1.5089	1.1904
Min	.3018	.2829	.3018	.3018	.3961	.4904	.415
Avg	.4481	.4614	.6987	.6315	.6511	.8668	.7020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 204 / 11 Kv Power Grid

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-JUN-18	10-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8		.3961	
11	.3584		
23			.5658
Max	.3584	.3961	.5658
Min	.3584	.3961	.5658
Avg	.3584	.3961	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 205 / 11 KV Shri 1008 Chintamani NON SHEDDABLE EXPRESS HV FEEDERS
Jai Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	10-JUN-18
HR	Load (MW)
7	.0168
13	.0006
15	.1509
Max	.1509
Min	.0006
Avg	.0561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 201 / 11KV Hiwara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3429	.3772	.3772	.4115	.3688
2	.373	.3772	.4287	.3429	.4287	.4287	.4191
3	.407	.4115	.4287	.4287	.4578	.4578	.4287
4	.4409	.4409	.6001	.5087	.5658	.5087	.5144
5	.7122	.5426	.7716	.6274	.6173	.6104	.5144
6	.852	.6443	.9431	.7888	.7122	.7545	.5426
7	1.0395	.7042	1.0288	.6952	.6104	.7209	.583
8	1.1736	.9556	1.2003	.57	.5197	.6706	.4527
9	1.0562	1.0174	1.1488	.4748	.4527	.4287	.3429
10	.3222	.2915	.3086	.3258	.2915	.3086	.3222
11	.2058	.2572	.2572	.6952	.7377	.6097	.78
12	.208	.2374	.2401	.9389	.3353	.7712	.8478
13	.2149	.218	.2743	.9221	.8048	.823	.6104
14	.208	.2401	.2915	.9054	.6706	.8383	.6613
15	.2401	.2347	.2743	.788	.57	.8573	.6783
16	.2401		.2572	.7209	.8383	.5658	.8817
17	.2204	.3018	.2915	.2515	.9389	.9556	.9326
18	.2915	.4287	.3429	.7042	.8383	.5144	.8478
19	.4917	.503	.4557	.4458	.3944	.373	.5144
20	.4917	.57	.5959	.5935	.5426	.4024	.6001
21	.4748	.583	.5959	.4748	.4578		.5083
22	.4578	.503	.5731	.463	.4458	.4024	.4908
23	.4458	.4801	.5083	.4409	.4287	.4239	.4557
24	.3429	.3944	.3856	.4287	.4287	.4115	.407
Max	1.1736	1.0174	1.2003	.9389	.9389	.9556	.9326
Min	.2058	.218	.2401	.2515	.2915	.3086	.3222
Avg	.4703	.4643	.5227	.5797	.5611	.5760	.5710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 202 / 11KV KARMAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2717	1.286	1.2346	.4801	.4287	.463	.503
2	1.2548	1.2689	1.286	.4458	.4458	.4458	.5144
3	1.2548	1.3032	1.286	.4458	.4409	.4801	.6001
4	1.2717	1.3226	1.3717	.4239	.5144	.4917	.6001
5	1.3226	1.3904	1.4575	.4239	.5658	.5256	.6783
6	1.4243	1.4922	1.4918	.5658	.6613	.57	.7716
7	1.4419	.8215	1.4575	.6104	.6783	.7377	.7888
8	1.3077	1.2742	1.3375	.6203	.7712	.7042	.7888
9	1.2574	1.153	1.3203	.5426	.6706	.7042	.7202
10	1.3226	1.1361	1.2689	1.2174	1.166		1.2517
11	.6173	.5365	.6344	1.0343	1.2574	1.1401	1.1869
12		.5765	.6344	1.1065	1.1736	.823	1.2887
13		.5935	.6516	1.0898	1.2071	.8573	1.2548
14		.6001	.6687	1.1401	1.1233	.9945	1.2039
15	.7202	.6173	.6516		1.0898	1.1145	
16	.6344	.6516	.6173		1.2071	1.2517	1.2378
17	.6613	.6443	.6344	1.4251	1.1736	1.2517	1.2039
18	.6859	.6104	.6001	1.5592	1.1568	1.3203	1.2378
19	.9496	1.2887	1.4899	1.4746	1.406	1.3916	1.4575
20	1.4922	1.3904	1.595	1.56	1.4243	1.5261	1.5947
21	1.4752	1.4582	1.4899	1.5769	1.5261	1.5775	1.6126
22	1.4413	1.4243	1.4373	1.4575	1.4746	1.4586	1.5249
23	1.3546	1.3565	1.3847	1.3904	1.406	1.406	1.4723
24	1.3203	1.3395	1.2742	.4287	.4287	.463	.4862
Max	1.4922	1.4922	1.595	1.5769	1.5261	1.5775	1.6126
Min	.6173	.5365	.6001	.4239	.4287	.4458	.4862
Avg	1.1658	1.0640	1.1365	.9554	.9749	.9434	1.0426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 203 / 11KV Ladgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5487	.4801	.4287	.3772	.3086	.4287
2	.5087	.5658	.5144	.4801	.4287	.3429	.5144
3	.4917	.6001	.5144	.5144	.4578	.3772	.503
4	.5087	.6104	.4287	.5596	.5658	.4239	.6001
5	.5765	.6783	.8745	.5935	.7202	.6104	.6859
6	.7122	.8817	.7888	.823	.9326	.9221	.8573
7	.7545	.8215	.7712	.8478	.9665	1.0898	1.0974
8	.7042	.7209	.6687	.9221	.9054	1.0395	.9774
9	.5487	.5426	.503	.9665	.9724	1.0288	.8478
10	.4578	.4694	.3856	.3601	.3944	.3688	.5144
11	.5487	.7209	.6104	.3391	.3688	.3521	
12		.8551	.763	.3521	.3688	.3688	.373
13		.9326	.7373	.3521	.3688	.3688	.373
14		.8817	.703	.3521	.4024	.3772	.39
15		.8478	.703	.3521	.4024	.4024	
16		.8139	.703	.4024	.4359	.4024	.4578
17		.8987	.7202	.4024	.4191	.4801	.4748
18		.8817	.703	.4359	.4527	.503	.5087
19	.7461	.5087	.6661	.5487	.5487	.6516	.6001
20	.7122	.6274	.7712	.7291	.6952	.6371	.6859
21	.6613	.5935	.7011	.6443	.5765	.6173	.5959
22	.6104	.5426	.6268	.6001	.583	.6001	.6135
23	.5658	.5144	.5434	.5144	.5487	.5487	.5434
24	.5316	.5144	.503	.3944	.2915	.2743	.3601
Max	.7545	.9326	.8745	.9665	.9724	1.0898	1.0974
Min	.4578	.4694	.3856	.3391	.2915	.2743	.3601
Avg	.5973	.6905	.6410	.5381	.5493	.5457	.5910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 201 / 11KV DUDHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.4973	.4915	.2949	.2622	.3277	.3647
2	.5243	.5304	.4915	.3113	.2949	.3605	.3481
3	.5735	.547	.4915	.3277	.2949	.3768	.3812
4	.6226	.6299	.6226	.3605	.3441	.426	.3812
5	.6718	.7459	.7701	.5898	.426	.4752	.6299
6	.9339	1.0111	1.065	.8029	.9012	1.0159	1.0774
7	.9831	.9116	.9503	1.278	1.1797	1.1142	1.21
8	.7956	.8453	.7701	1.3272	1.278	1.2616	1.2597
9	.6796	.6962	.6226	1.278	1.0322	1.1469	1.1603
10	.4475	.5138	.4915	.5243	.5243	.4588	.431
11	.3812	.7287	.7373	.4049	.3605	.3441	.4096
12	1.1603	.9503	1.0159	.3932	.3441		.3605
13	.9945	.9503	.9667	.3441	.3605		.2949
14	1.0442	.8848	.8684	.3605	.3277	.426	.2949
15	.6962	.7865	.852		.3277	.426	.3932
16	.7956	.8848		.3932	.3441	.426	.2984
17	.7625	.9175		.3932	.3932	.4752	.2818
18	.7459	.9069	1.0814	.4372	.4424	.4915	.431
19	.547	.6226	.2949	.6154	.5571	.6882	
20	.7625	.7701	.852		.8192	.779	.8122
21	.6299	.639	.6882	.6882	.6718	.6962	.6133
22	.5636	.6226	.5898	.5898	.5735	.6133	.6133
23	.5304	.5182	.5571	.4915	.5243	.5801	.5636
24	.5243	.4973	.5079	.2785	.2622	.3277	.3812
Max	1.1603	1.0111	1.0814	1.3272	1.278	1.2616	1.2597
Min	.3812	.4973	.2949	.2785	.2622	.3277	.2818
Avg	.7039	.7337	.7172	.5675	.5352	.6017	.5648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 202 / 11KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5935	.5935	.5533	.7545	.7042	.763	.7122
2	.5935	.6274	.5533	.7545	.7545	.763	.7291
3	.6274	.6443	.5533	.7716	.8048	.7969	.763
4	.6613	.7122	.6371	.8059	.8886	.8817	.8478
5	.6783	.8987	.7042	1.1145	.9389	1.0174	.9665
6	1.2717	1.2209	1.1568	1.3203	1.2574	1.2378	1.1361
7	1.8652	1.4752	1.5424	1.1317	1.1142	1.0513	1.0513
8	1.543	1.6108	1.6766	.8402	.8886	.8478	.8817
9	1.3735	1.1869	1.4255	.6859	.5967	.6783	.763
10	.5087	.5087	.6036	.4287	.3856	.4917	.4409
11	.39		.3856	1.046	.6173	.9835	1.1361
12	.3391	.4024	.373	1.1401	.9945	1.1869	.9835
13	.373	.4359	.407	1.1736	1.1831	.9665	.9496
14	.39	.4191	.407		.763	.8139	.7461
15	.4239	.4024	.5596	.8048	.8478	.78	.78
16	.4578	.4024	.4239	.9503	.9326	.9496	.9326
17	.5596	.426	.4748	.9831	.9326	.8817	1.2887
18	.7291	.4973	.583	.9282	.9326	1.1022	1.153
19	.78	.9503	.7373	.663	.6613	.7969	.8139
20	.9326	.9389	1.0631		.9835	.9496	.9665
21	.8139	.9259	.8916	.8059	.8309	.8817	.8478
22	.763	.8215	.8059	.8059	.8139	.7122	.78
23	.7122	.7716	.7716	.7209	.7969	.6783	.7461
24	.6104	.5596	.5533	.7545	.7042	.763	.6783
Max	1.8652	1.6108	1.6766	1.3203	1.2574	1.2378	1.2887
Min	.3391	.4024	.373	.4287	.3856	.4917	.4409
Avg	.7496	.7579	.7435	.8811	.8470	.8740	.8789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 201 / BIDKIN AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0678		.081	.1619
2				.0678		.081	.1619
3				.0678		.0972	.1619
4				.0678			.1619
5				.0678		.1296	.1619
6				.1017		.2429	.2429
7				.1017		.2915	.3239
8				.1357	.2429	.3563	.3239
9				.1357	.2429	.3077	.3239
11	.1715	.1715	.1696				
12	.2058	.1372	.1696				
13	.2229	.1715	.1357				
14	.2229	.2058					
15	.2229	.1372					
16	.2401	.1372	.1017				
17	.2401	.1372	.1017				
18	.1372	.1715					
24				.0678		.0857	.081
Max	.2401	.2058	.1696	.1357	.2429	.3563	.3239
Min	.1372	.1372	.1017	.0678	.2429	.081	.081
Avg	.2079	.1586	.1357	.0882	.2429	.1859	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 202 / INDUSTRIAL STONE CRUSHER SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.5144	.5487	.4409	.7468	.2801	.6535
2	.2743	.3429	.4115	.4409	.8402	.1867	.7468
3	.3429	.3429	.5144	.407	.8402	.1867	.9335
4	.3772	.3429	.5487	.407	.7468	.2241	.7468
5	.3086	.3601	.4115	.6104	.7468	.2427	.9335
6	.3429	.9774	.7888	.4409	.2801	.4481	.4668
7	.5144	.3601	.5487	.407	.4668	.3361	.5601
8	.5487	.2229	1.8519	.3391	.5601	.2054	.2572
9	.3086	.4801	.2743	.2713	.2801	.2241	.2801
10	.3944	.5487	.2035	1.643	.3601	.3734	.2543
11	.8745	.583	.2374	.5601	.7545	.4668	.5087
12	.9088	.2058	.4748	.7468	.7888		.5087
13	.9259	.2401	.3391	.7468	.8402	.2829	.2374
14	.7373	.3086	.5087	.8402	.9088	.2801	.2374
15	.583	.3086	.407	.7468	.9431	.2801	.78
16	.7373	.4115	.5426	.6535	.7888	.2801	.373
17	.9088	.3086	.2035	.9335	.6516	.0934	.6443
18	.6173	1.8861	.1357	.9335	.5144	.1867	.3052
19	.4287	.0686	.2035	.7468	.5144	.2801	1.0174
20	.2915	.0686	.373	.2801	.5144	.2801	.2374
21	.5487	.2058	.407	.7468	.5144	.2801	.2035
22	.823	.2401	.6104	.8402	.5144	.2801	.8139
23	.7373	.5144	.3052	.9335	.4287	.2801	.8478
24	.3429	.6344	.4115	.4409	.8402	.3429	.6535
Max	.9259	1.8861	1.8519	1.643	.9431	.4668	1.0174
Min	.2743	.0686	.1357	.2713	.2801	.0934	.2035
Avg	.5494	.4365	.4692	.6482	.6410	.2748	.5500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 203 / LAKHEGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0857	.2058				
2	.0343	.0857	.3086				
3	.0343	.1029	.3086				
4	.0343	.1029	.3429				
5	.0343	.12	.3086				
6	.0343	.12	.3429				
7	.0343	.0857	.3772				
8	.0343		.3429				
9	.0343		.5426				
11				.3239	.3429	.4668	.5087
12					.583		.6104
13					.5658	.4049	.6443
14					.5487	.5601	.6104
15					.5144	.4858	.6104
16				.6478	.5144	.4858	.6104
17				.8097	.5144	.6535	.5765
18				.4858	.5144	.4858	
19							.5426
24	.0343	.0857	.0686				
Max	.0343	.12	.5426	.8097	.583	.6535	.6443
Min	.0343	.0857	.0686	.3239	.3429	.4049	.5087
Avg	.0343	.0986	.3149	.5668	.5123	.5061	.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 204 / PANGRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2401	.3086				
2	.1372	.2401	.3429				
3	.1715	.2401	.3772				
4	.1715	.2572	.4115				
5	.1715	.2572	.3429				
6	.4115	.3772	.3429				
7	.7888	.4287	.6173				
8	.8916	.7888	.6687				
9	.7545	.823	.8139				
11				.4049		.8402	.4409
12				.9717	1.1145		.7122
13				.9717	1.1488	.7287	
14				.8097	1.1831	.4858	.3391
15				1.0526	1.2003	.5668	.6783
16				.9717	1.1145	.4858	.78
17				.6478	1.046	.6478	.7122
18				.4049	.9774	.4858	.4748
19				.4049			
24	.1715	.2401	.2401				
Max	.8916	.823	.8139	1.0526	1.2003	.8402	.78
Min	.1372	.2401	.2401	.4049	.9774	.4858	.3391
Avg	.3807	.3893	.4466	.7378	1.1121	.6058	.5911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 205 / NILAJGAON Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2035	.2429	.1619	.2429
2				.2035	.2429	.1619	.2429
3				.2035	.2429	.1943	.2429
4				.2035	.2429	.2267	.2429
5				.2713	.3239	.2591	.3239
6				.407	.5668	.6478	.6478
7				.5426	.9717	1.0202	1.2955
8				.8139	1.2955	1.3927	1.3765
9				.6443	.9717	1.2631	1.1336
11	.5316	.3086	.6783				
12	.6516	.4115	.8139				
13	.7716	.5144	1.0174				
14	.7373	.4458	1.0174				
15	.703	.3772	1.0174				
16	.7888	.3429	.5426				
17	.8745	.5144	.78				
18	.3772	.4801	.6783				
22			.6783				
24				.6783	.2429	.1715	.2429
Max	.8745	.5144	1.0174	.8139	1.2955	1.3927	1.3765
Min	.3772	.3086	.5426	.2035	.2429	.1619	.2429
Avg	.6795	.4244	.8026	.4171	.5344	.5499	.5992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 206 / 11KV BIDKIN WATER SUPPLY

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.017	.0023	.0023	.0187
2	.0171	.0171	.0171	.017	.0023	.0023	.0187
3	.0171	.0171	.0171	.017	.0023	.0023	.0187
4	.0171	.0171		.017	.0023	.0023	.0187
5	.0171	.0171	.0187	.017	.0023	.0023	.0187
6	.0171	.0114	.0171	.017	.0023	.0023	.0187
7	.0171	.0171	.0187	.017	.0023	.0023	.0187
8	.0171	.0171	.0171	.017	.0023	.0023	.0187
9	.0171	.0171	.017	.017	.0023	.0042	.0187
10	.0171	.0171	.017	.0187	.0171	.0023	.017
11	.0171	.0171	.017	.0187	.0171	.0048	.017
12	.0171	.0171	.017	.0187	.0171		.017
13	.0171	.0171	.017	.0023	.0171	.0023	.017
14	.0171	.0171	.017	.0048	.0171	.0023	.017
15	.0171	.0171	.017	.0048	.0171	.0023	.017
16	.0171	.0171	.017	.0023	.0171	.0023	.017
17	.0171	1.6461	.017	.0162	.0171	.0023	.017
18	.0171	.0171	.017	.0048	.0171	.0023	
19	.0171	.0171		.0023	.0171	.0023	.017
20	.0171	.0171	.017	.0023	.0171	.0187	.017
21	.0171	.0171	.017	.0023	.0171	.0187	.017
22		.0171	.017	.0023	.0171	.0187	.017
23	.0171	.0171	.017	.0023	.0171	.0187	.017
24	.0171	.0171	.0171	.017	.0023	.0171	.0187
Max	.0171	1.6461	.0187	.0187	.0171	.0187	.0187
Min	.0171	.0114	.017	.0023	.0023	.0023	.017
Avg	.0171	.0847	.0172	.0114	.0109	.0060	.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 207 / INDUSTRIAL BIDKIN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572	.2743	.407	.3734	.3361	.3734
2	.3086	.2572	.3086	.407	.3734	.3361	.3734
3	.2743	.2572	.3429	.4409	.3734	.3361	.3734
4	.3086	.2572	.3086	.4748	.3734	.3547	.3734
5	.3086	.2572	.3429	.5087	.4668	.3734	.3734
6	.2743	.1886	.4115	.5087	.4668	.4294	.3734
7	.2058	.2401	.3772	.407	.5601	.4481	.4668
8	.1715	.3429	.3772	.4748	.5601	.4715	.3734
9	.2058	.463	.4748	.3391	.4668	.7282	.4668
10		.4801	.6104	.7468	.5316	.4668	.5087
11		.5487	.5426	.5601	.6516	.5601	.4748
12		.4115	.373	.5601	.3944		.373
13	.2058	.3772	.5765	.5601	.4458	.5601	.4409
14	.2058	.3429	.5087	.5601	.4973	.4668	.5087
15	.1886	.3086	.5087	.5601	.5316	.5601	.5087
16	.1886	.3429	.5087	.5601	.5316	.5601	.5087
17	.1886	.3086	.3391	.5601	.5316	.4668	.5426
18	.1715	.2743	.6104	.5601	.5316	.5601	.373
19	.2058	.3429	.5087	.3734	.5316	.4668	.4748
20	.2572	.3086	.4748	.3734	.5144	.4715	.4409
21	.2743	.3086	.407	.3734	.5144	.3734	.4748
22	.2743	.3429	.5087	.5601	.4973	.3734	.4409
23	.2572	.3772		.5601	.4115	.3734	.3391
24	.3429	.2572	.3429	.407	.4668	.3429	.3734
Max	.3429	.5487	.6104	.7468	.6516	.7282	.5426
Min	.1715	.1886	.2743	.3391	.3734	.3361	.3391
Avg	.2425	.3272	.4364	.4935	.4832	.4529	.4304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 209 / BIDKIN Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.2003	1.2003	1.1869	1.307	1.307	1.307
2	1.3375	1.2003	1.2346	1.2887	1.4003	1.1736	1.307
3	1.4403	1.3375	1.3717	1.3904		1.307	1.307
4	1.6804	1.6632	1.6118	1.6278	1.9605	1.6244	1.587
5	3.0178	2.0576	2.2462	2.0008	2.4272	1.9605	2.3339
6	3.0178	2.8807	1.8176	2.2721	2.894	3.006	2.894
7	2.572	2.5892	1.6804	2.2043	2.894	2.5766	2.5206
8	2.0233	1.9719	1.5432	2.2043	2.6139	2.1472	2.1472
9	1.6118	1.6804	.8139	1.5939	2.0538	1.7737	2.2405
10		1.166	1.2887	1.1203	1.6975	1.6804	1.6108
11	1.1488	.8573	1.0174	1.0269	1.1145	1.1203	1.2548
12	1.1317	.8916	.8817		1.046		.9156
13	1.1145	.9259	.78		1.0974	1.1203	.9156
14	1.0802	.8573	.9496		1.1488	1.0269	.9156
15	1.046	.823			1.1831	.9335	.9496
16	1.2689	.8573	.8478	1.4003	1.3546	1.0269	.9156
17	1.5089	1.6461	1.0174	1.4937	1.5432	1.7737	1.6617
18	2.1091	2.0233	1.3226	1.9605	1.7147	2.2405	
19	1.5947	2.0233	2.1195	2.2405	1.989	.5601	2.2721
20	1.3889	1.8861	2.34	2.1472	1.8176	2.2405	2.0348
21	1.3889	1.749	1.5261	1.8671	1.5432	1.7737	1.1869
22	1.3889	1.5432	1.5261	1.6804	1.2689	1.587	.8817
23	1.3032	1.3375	1.2548	1.307	1.2346	1.307	1.0174
24	1.2003	1.2346	1.2174	1.1869	1.307	1.2003	1.307
Max	3.0178	2.8807	2.34	2.2721	2.894	3.006	2.894
Min	1.046	.823	.78	1.0269	1.046	.5601	.8817
Avg	1.5902	1.5168	1.3743	1.66	1.6787	1.5855	1.5428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 210 / Bidkin Town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.4575	1.3717	1.4922	1.6804	1.4937	1.4937
2	1.6118	1.4575	1.4746	1.5261	1.6804	1.4937	1.4937
3	1.749	1.5432	1.5775	1.5939	1.6804	1.5684	1.4937
4	1.8861	1.6118	1.6804	1.6278	1.8671	1.7177	1.6975
5	2.0576	1.6461	2.0233	1.6617	2.0538	1.8484	1.7737
6	2.0576	2.1091	2.1948	2.2043	2.3339	2.2965	2.3339
7	2.0576	2.1262	2.0576	2.2382	2.4272	2.2405	2.5206
8	1.8861	2.0748	1.8519	2.0687	2.2405	2.1658	2.2405
9	2.0233	1.869	2.0348	2.0348	2.0538	2.0538	2.0538
10	1.4746	1.8861	1.5261	1.9605	1.749	1.9605	1.7804
11	1.749	1.749	1.5261	1.8671	1.5775	1.8671	1.6617
12	1.5432	1.7147	1.3565	1.6804	1.5432	1.8671	1.5939
13	1.3375	1.6804	1.4582	1.6804	1.5089	1.7737	1.4922
14	1.4232	1.4746	1.4582	1.6804	1.4746	1.6804	1.4922
15	1.5261	1.3717	1.3904	1.587	1.4575	1.6804	1.4582
16	1.5947	1.2346	1.4243	1.6804	1.5604	1.6804	1.5261
17	1.6804	1.4403		1.8671	1.6632	1.9605	1.6956
18	2.2291	1.8861	1.0852	2.0538	1.749	2.1472	1.8991
19	2.0576	1.8519		2.1472	1.989	2.2405	1.933
20	1.9376	2.0576	2.4417	2.3339	1.749	2.1472	1.933
21	1.8004	1.749	1.9669	2.0538	1.6975	1.9605	1.7974
22	1.6632	1.5432	1.6956	1.8671	1.6118	1.7737	1.6278
23	1.5775	1.5775	1.5939	1.6804	1.5775	1.587	1.4922
24	1.5432	1.4918	1.5432	1.5261	1.6804	1.5432	1.587
Max	2.2291	2.1262	2.4417	2.3339	2.4272	2.2965	2.5206
Min	1.3375	1.2346	1.0852	1.4922	1.4575	1.4937	1.4582
Avg	1.7504	1.6918	1.6697	1.8381	1.7753	1.8645	1.7530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 201 / BARANAGAR I
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18
HR	Load (MW)	Load (MW)
1		.056
2		.0747
3	.0914	.0934
4	.1067	.0747
5	.1372	.0934
6	.1524	.0934
7	.2286	
8	.2229	.1867
9	.2058	.2801
10		.1867
24		.056
Max	.2286	.2801
Min	.0914	.056
Avg	.1636	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 203 / 11 KV KAPUS WADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JUN-18
HR	Load (MW)
1	.0934
2	.0934
3	.112
4	.1307
5	.1494
6	.1867
7	.3734
8	.3734
9	.3734
24	.0934
Max	.3734
Min	.0934
Avg	.1979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 204 / 11 kv Balanagar Gaothan
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18
HR	Load (MW)	Load (MW)
1	.8688	
2	.8688	.9335
3	.9955	1.0269
4	1.2696	1.307
5	1.643	1.6804
6	2.0559	2.1472
7	2.2257	2.3339
8	2.1125	2.1472
9	2.0559	1.6244
10	1.5023	1.251
11	.9335	
12	.7468	.7468
13	.8402	.7468
14	.7468	.7468
15	.7468	.8962
16	1.0269	1.1203
17	1.4003	1.307
18	1.6804	1.6804
19	1.6804	
20	1.587	
21	1.307	
22	1.0269	
23	.9335	
24	.905	.9335
Max	2.2257	2.3339
Min	.7468	.7468
Avg	1.2983	1.3311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 205 / Ginning
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0934	.1867
2	.1029	.0934	.1867
3	.1029	.0934	.1867
4	.1029	.0934	.1867
5	.1029	.0934	.1867
6	.0914	.0934	.1867
7	.1029	.112	.112
8	.1372	.112	.112
9	.1715	.2241	.1867
10	.1524	.2614	.1867
11	.2054	.2801	.1867
12	.2241	.2427	.1867
13	.168	.1867	.1867
14	.168	.2241	.2241
15	.1307	.2241	.2427
16	.1867	.2241	.1867
17	.168	.1867	.1867
18	.1494		.168
19	.112		.112
20	.112		.112
21	.112		.0934
22	.112		.0924
23	.0934		.0934
24	.1029	.0934	.1867
Max	.2241	.2801	.2427
Min	.0762	.0934	.0924
Avg	.1328	.1629	.1657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 206 / kherda
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18
HR	Load (MW)	Load (MW)
11	.112	
12	.1307	.2987
13	.2241	.3734
14	.168	
15	.4668	.4668
16	.4668	.5228
17	.3361	.5601
Max	.4668	.5601
Min	.112	.2987
Avg	.2721	.4444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 201 / 11 KV HARSHI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0572	.0762	.1029	.1475	.1715
2	.0566	.0566	.0381	.0762	.1357	.1475	.1715
3	.0566	.0566	.0572	.0762	.1357	.1638	.2096
4	.0566	.0566	.0381	.0671	.1696	.1966	.2286
5	.0566	.0566	.0381	.0655	.2155	.213	.2477
6				.1353	.3277	.3113	.2858
7				.2058	.4534	.4424	.3429
8				.2572	.5155	.426	.4001
9				.16	.4111	.4096	.4572
11	.1638		.1646				
12	.1475		.2195				
13	.1475		.2397				
14	.1475		.2778				
15	.1638		.1353				
16	.1475		.2058				
17	.1638		.1235	.0191	.0189	.0572	.0191
18	.1475		.1353	.0191	.0377	.0381	.0572
19	.0377		.0381	.0377	.0566	.0572	.0762
20	.0566		.0572	.0943	.0566	.0381	.0953
21	.0566		.0572	.0943	.0566	.0572	.0953
22	.0566		.0381	.0943	.0566	.0572	.0953
23	.0566		.0572	.0377	.0566	.0762	.0953
24	.0566	.0566		.0762	.1029	.1147	.1524
Max	.1638	.0566	.2778	.2572	.5155	.4424	.4572
Min	.0377	.0566	.0381	.0191	.0189	.0381	.0191
Avg	.0965	.0566	.1099	.0937	.1712	.1737	.1883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 202 / 11KV DADEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.1638	.1429	.0953	.1494	.1509	.1524
2	.2321	.1802	.1593	.0953	.112	.1509	.1143
3	.2321	.213	.1932	.1143	.112	.1509	.0953
4	.2321	.2949	.2315	.1143	.1132	.1509	.0953
5	.2652	.3113	.2675	.1143		.1509	.1143
6	.3563	.3768	.3086				
7	.5441		.3749				
8	.578		.4961				
9	.5735		.5761				
11				.4096	.4096	.6859	.5287
12					.4096	.7621	.6687
13				.5182	.426	.8764	.6573
14				.5937	.4424	.8383	.6173
15				.5693	.639	.8383	.5761
16				.5312	.5992	.7621	.6344
17	.0189		.0191	.4843	.583	.9145	.7253
18	.0377		.0191	.4111	.0754	.7621	.6241
19	.0943		.0953	.0943	.1509	.0762	.0895
20	.0943		.1067	.1307	.1132	.0762	.1402
21	.0943		.1433	.1494		.0953	.1494
22	.0943		.1334	.1867	.132	.1143	.1463
23	.0943		.1132	.1698	.132	.1524	.1463
24	.2347	.1475		.0953	.1698	.1509	.1143
Max	.578	.3768	.5761	.5937	.639	.9145	.7253
Min	.0189	.1475	.0191	.0943	.0754	.0762	.0895
Avg	.2359	.2411	.2113	.2710	.2805	.4137	.3363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 203 / 11KV KUTUBKHEDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0381	.0549	.1357	.1638	.2477
2	.0566	.0566	.0572	.0412	.1526	.1802	.2858
3	.0566	.0566	.0572	.048	.2012	.1966	.3048
4	.0566	.0566	.0572	.0429	.1989	.2294	.4001
5	.0566	.0566	.0762	.0429	.2486	.2785	.4763
6				.0541	.4049	.3113	.5335
7				.1097	.4801	.426	.6097
8				.12	.4801	.5407	.7621
9				.0743	.4481	.583	.6668
11	.1638		.1646				
12	.2294		.3475				
13	.2785		.3858				
14	.2785		.2469				
15	.2785		.3429				
16	.2949		.192				
17	.3441		.0823	.0381	.0189	.0381	.0191
18	.3113		.0823	.0377	.0189	.0381	.0191
19	.0566		.0191	.0754	.0189	.0381	.0762
20	.0566		.0191	.0754	.0377	.0572	.0572
21	.0566		.0191	.0754	.0377	.0572	.0762
22	.0566		.0191	.0754	.0377	.0762	.0572
23	.0566		.0191	.0566	.0377	.0572	.0572
24	.0566	.0566		.0762	.1029	.1475	.1905
Max	.3441	.0566	.3858	.12	.4801	.583	.7621
Min	.0566	.0566	.0191	.0377	.0189	.0381	.0191
Avg	.1475	.0566	.1237	.0646	.1800	.2011	.2847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 204 / 11KV DAWARWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.1147	.1524	.0381	.0381	.0566	.0572
2	.0838	.1311	.1715	.0381	.0377	.0566	.0572
3	.0838	.1311	.1677	.0381	.0377	.0566	.0572
4	.0829	.1475	.2031	.0381	.0377	.0377	.0381
5	.1492	.1475	.2429	.0381	.0377	.0566	.0381
6	.2294	.1966	.2932				
7	.4049		.3401				
8	.4481		.3593				
9	.3605		.3906				
11				.2753		.2667	.2705
12				.3163	.213	.3048	.443
13				.253	.3932	.4191	.3704
14				.3125	.3605	.4954	.3018
15				.2214	.3768	.5716	.16
16				.2688	.4096	.6097	.3841
17	.0189		.0191	.253	.4588	.6478	.4475
18	.0189		.0191	.2056	.3277	.4763	.3572
19	.0377		.0572	.0191	.0566	.0381	.0381
20	.0566		.0762	.0381	.0566	.0572	.0572
21	.0566		.0572	.0377	.0566	.0572	.0762
22	.0566		.0191	.0377	.0566	.0381	.0572
23	.0566		.0381	.0377	.0566	.0572	.0381
24	.1017	.1147		.0381	.0377	.0566	.0572
Max	.4481	.1966	.3906	.3163	.4588	.6478	.4475
Min	.0189	.1147	.0191	.0191	.0377	.0377	.0381
Avg	.1371	.1405	.1629	.1318	.1694	.2295	.1740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 205 / 11 KV NANDAR AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0754	.1353	.1865	.213	.2858
2	.0566	.0566	.0762	.1372	.2012	.2294	.3429
3	.0566	.0566	.0572	.1429	.1989	.2458	.4001
4	.0566	.0566	.0953	.1572	.1989	.2949	.5144
5	.0566	.0566	.0953	.1572	.2267	.3605	.5906
6				.2343	.2429	.4372	.6478
7				.3292	.4111	.5506	.8192
8				.3286	.5218	.6802	.8954
9				.3704	.6093	.7287	.9526
11	.3932		.2378				
12	.3932		.3292				
13	.3605		.3246				
14	.3932		.439				
15	.4424		.3704				
16	.4752		.3102				
17	.5079		.2115	.0191	.0189	.0381	.0191
18	.3932		.2841	.0377	.0377	.0381	.0381
19	.0566		.0381	.0566	.0566	.0572	.0572
20	.0566		.0762	.0377	.0566	.0572	.1494
21	.0566		.0543	.0377	.0566	.0762	.0762
22	.0566		.0381	.0377	.0566	.0762	.0572
23	.0566		.0312	.0377	.0566	.0762	.0381
24	.0566	.0566		.1372	.1865	.1966	.1905
Max	.5079	.0566	.439	.3704	.6093	.7287	.9526
Min	.0566	.0566	.0312	.0191	.0189	.0381	.0191
Avg	.2095	.0566	.1747	.1408	.1955	.2562	.3573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 206 / 11 KV GFSS-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3277	.3593	.3144	.3932	.3277	.5525
2	.421	.3768	.4001	.3429	.4049	.3441	.5716
3	.4481	.4588	.5155	.4144	.4321	.3768	.6097
4	.5121	.5571	.7655	.5068	.5281	.4588	.8002
5	.6483	.7373	1.0692	.6706	.6562	.7287	1.0288
6	1.1126	.9393	1.1984	.9877	1.0822	1.004	1.2384
7	1.1736		1.1012	1.0288	.9686	1.085	1.2955
8	1.0623		.9722	1.1904	.9755	1.0202	1.3717
9	1.3209		.8436	.8916	.7811	.8421	1.2384
10			.5401	.487	.578	.8002	.5498
11	.6062		.2743	.3953	.4096	.6859	.4144
12	.4424		.3292	.3479	.3932		.439
13	.3768		.3429	.3281	.3932	.4191	
14	.3932		.3572	.3479	.3932	.4954	.3374
15	.3932		.3243	.3437		.4954	.3292
16	.4096		.3246	.4111	.426	.5335	.3858
17	.4096		.5761	.4586	.4915	.8002	.4858
18			.6944		.7287	.9907	.7186
19	1.0688		.8488	.9414	.9231	1.2003	.828
20	.7287		.8745	.8749	.6802	.7811	.8745
21	.5898		.6093	.6562	.6226	.6097	.5502
22	.4096		.463	.4843	.4588	.5335	.439
23	.3605		.3923	.4428	.4096	.4572	.4534
24	.4111	.3277		.3201	.4111	.3277	.4763
Max	1.3209	.9393	1.1984	1.1904	1.0822	1.2003	1.3717
Min	.3605	.3277	.2743	.3144	.3932	.3277	.3292
Avg	.6223	.5321	.6163	.5733	.5887	.6660	.6951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 207 / 11 KV GFSS-II FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2785	.2332	.2172	.2347	.2785	.381
2	.2486	.3113	.3658	.2343	.2515	.3113	.4001
3	.2652	.3605	.4687	.2572	.2818	.3441	.4382
4	.3113	.4588	.5937	.3429	.3361	.4588	.5525
5	.4481	.5407	.7343	.4115	.4801	.639	.6668
6	.7811	.7537	1.0136	.9808	.8124	.7373	.8954
7	.828		.852	.743	.7343	.8029	.8764
8	.7811		.7701	.7164	.7186	.7287	.9717
9	.7537		.7202	.6401	.6167	.6802	.724
10	.4588		.4696	.4531	.4321	.5906	.3704
11	.3441		.4161	.2915	.2785	.5335	.2606
12	.2622		.25		.2458	.4382	.2164
13	.213		.2	.2721	.213	.3239	.2
14	.2294		.2134	.2267	.2294	.3048	.2
15	.213		.2	.2401	.2294	.3239	.2027
16	.2458		.2429	.2429	.2949	.3239	.2439
17	.3113		.5335	.3239	.3277	.4001	.3292
18	.4752		.4725	.4161	.5407	.4572	.5155
19	.6802		.6668	.6093	.664	.5906	.6802
20	.5344		.6562	.5864	.5344	.6287	.6226
21	.426		.4001	.3953	.4096	.4572	.3963
22	.3932		.2896	.3041	.3605	.4382	.2881
23	.3113		.2721	.2721	.3113	.381	.2469
24		.2785		.25	.2591	.2785	.3239
Max	.828	.7537	1.0136	.9808	.8124	.8029	.9717
Min	.213	.2785	.2	.2172	.213	.2785	.2
Avg	.4238	.426	.4798	.4099	.4082	.4771	.4585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 201 / 11KV NATH MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0425	1.0924		1.1706	
2				1.0029		1.1888	
3						1.1888	
4						1.2254	
5						1.1523	
6						1.0974	
7						.9694	
8	.9955					.9877	
9	.9492	1.0242	.9694			1.0242	1.0242
10	.9134	1.0242	1.0242			1.0242	.9511
11	.9412	.9328				1.0059	.9328
12	.9313	.9694				.9877	1.1523
13	.9593	.9877				.9511	.9511
14	.9134	.9511				.9328	.905
15	.9313	.9511				1.0242	.9511
16	1.0208					1.0242	1.0242
17	1.086				1.0242	.9816	1.0924
18					1.134	1.0985	1.0745
19					1.2437	1.2308	1.2178
20					1.2803	1.3611	1.4175
21					1.2071	1.1104	1.3073
22					1.1706	1.1104	1.2536
23	.9955				1.2071	1.1041	
24		1.0387				1.0974	.964
Max	1.086	1.0387	1.0425	1.0924	1.2803	1.3611	1.4175
Min	.9134	.9328	.9694	1.0029	1.0242	.9328	.905
Avg	.9670	.9849	1.0120	1.0477	1.181	1.0854	1.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 204 / 11 KV OPEN JAIL
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.7652	
2					1.9109	
3					1.8785	
4					1.9271	
5					2.3594	
6					2.17	
7					2.5263	
8	.0372				2.6235	
9		.0566	.0754		2.6558	2.9504
10	.0572	.0566	.0566		.0377	
11	1.4327	1.7284			.0377	
12	1.4937	1.8122			.0377	
13	1.4632	1.8747			.0377	
14	1.6613	1.9372			.0377	
15	1.5851	2.0622			.0377	
16	1.6872	2.0679			.0566	
17	1.5242			.0549	.0383	.04
18				.0549	.0383	.0423
19				.0549	.0383	.04
20				.0549	.0511	.0533
21				.0549	.0511	.0572
22				.0366	.048	.0533
23				.0366	.0619	
24					1.9433	1.9292
Max	1.6872	2.0679	.0754	.0549	2.6558	2.9504
Min	.0372	.0566	.0566	.0366	.0377	.04
Avg	1.2158	1.4495	.066	.0497	.9321	.6457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 205 / 11 KV CHANGATPURI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0914	
2					.0914	
3					.0732	
4					.0732	
5					.0732	
6					.0914	
7					.0914	
8	.8543				.0732	
9	.724	1.2041	1.3937		.0732	.0754
10	.0372	.0754	.1132		.0754	.0754
11	.0526	.0377			2.17	1.9919
12	.0701	.0566			2.4577	2.4615
13	.0701	.0189			2.4741	2.6216
14	.0526	.0189			2.4741	2.6871
15	.0526	.0189			2.652	2.6871
16	.0701	.0189			2.6852	2.6707
17	.0701			2.3644	2.4413	2.5587
18				2.3967	2.4741	1.8976
19				.0914	.0867	.1267
20				.0914	.0876	.0876
21				.0914	.0867	.0693
22				.0732	.0693	.0867
23				.0732	.0701	
24					.0732	.0693
Max	.8543	1.2041	1.3937	2.3967	2.6852	2.6871
Min	.0372	.0189	.1132	.0732	.0693	.0693
Avg	.2054	.1812	.7535	.7402	.8795	1.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 206 / 11kV Telwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.3927	
2					1.4089	
3					1.4251	
4					1.4413	
5					1.4413	
6					1.4575	
7					1.6518	
8	.0943				1.6842	
9	.0754		.0754		1.749	2.1765
10			.0754		.1132	.0943
11		.9783			.1132	.1132
12	.9755	.9482				.0943
13	1.0517	1.189				.0943
14	1.0669	1.2041				.1132
15	1.0822	1.189				.1132
16	1.0974	1.2651				.1509
17	1.2193			.1463		.1509
18				.0914	.1886	.1886
19				.0914	.0943	.1886
20				.0732	.1132	.1886
21				.0732	.1132	.1886
22				.0914	.0754	.1698
23	.9755			.0914	.0754	
24					1.3765	1.7918
Max	1.2193	1.2651	.0754	.1463	1.749	2.1765
Min	.0754	.9482	.0754	.0732	.0754	.0943
Avg	.8487	1.1290	.0754	.0940	.8842	.3878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 207 / 11kV Nath Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0183	
2					.0183	
3					.0183	
4					.0183	
5					.0183	
6					.0183	
7					.0183	
8					.0183	
9		.0189	.0189		.0183	.0189
10	.0171	.0189	.0189		.0189	.0189
11	.0171	.0189			.0189	.0189
12	.0171	.0189			.0189	.0189
13	.0171	.0189			.0189	.0189
14	.0171	.0189			.0189	.0189
15	.0171	.0189			.0189	.0189
16	.0171	.0189			.0189	.0189
17	.0171			.0183		.0181
18	.0171			.0183		.0171
19				.0183	.0171	.0171
20				.0183	.0171	.0171
21				.0183	.0171	
22				.0183	.0171	.0171
23	.0171			.0183	.0171	
24					.0183	.0171
Max	.0171	.0189	.0189	.0183	.0189	.0189
Min	.0171	.0189	.0189	.0183	.0171	.0171
Avg	.0171	.0189	.0189	.0183	.0182	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 208 / 11kV Urban Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6219	
2					.567	
3					.6036	
4					.7133	
5					.8779	
6					1.5729	
7					1.4998	
8	1.5278				1.6644	
9		1.2071	1.4266		1.3169	1.0608
10		.9694	1.0425		1.3169	1.0425
11		.6584			.823	.5853
12	.6516	.5487				.567
13	.5792	.5487				.5487
14	.6154	.5487				.5304
15	.6335	.567				.5304
16	.6878	.6219				.5249
17	.8048				.8238	
18					.8059	.9511
19					1.4118	1.2986
20				1.3169	1.3756	1.2851
21				1.0242		.905
22				.8048	.7316	.695
23				.695	.6584	
24					.5853	.6219
Max	1.5278	1.2071	1.4266	1.3169	1.6644	1.2986
Min	.5792	.5487	1.0425	.695	.567	.5249
Avg	.7857	.7087	1.2346	.9602	.9983	.7962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 209 / 11KV GHARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0549	
2					.0549	
3					.0549	
4					.0732	
5					.0732	
6					.0732	
7					.0914	
8	1.2651				.0732	
9	1.1431	1.387	1.6255		.0732	.0566
10	.0372	.0566	.0377		.0377	.0566
11	.0372				2.5888	2.8841
12	.0495				3.0167	3.3813
13	.0495				3.1161	3.4145
14	.0372				3.1493	3.4476
15	.0372				3.2322	3.3482
16	.0372				3.1493	3.2819
17	.0495			2.7854	3.1417	3.1786
18				2.6397	3.0769	2.8988
19				.0914	.0383	.04
20				.0732	.0533	.0533
21				.0732	.0533	.0518
22				.0732	.0366	.0372
23	1.2651			.0732	.0372	
24					.0732	.0389
Max	1.2651	1.387	1.6255	2.7854	3.2322	3.4476
Min	.0372	.0566	.0377	.0732	.0366	.0372
Avg	.3643	.7218	.8316	.8299	1.0593	1.7446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 201 / 11KV DHORKIN GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3547	.3734	.3734	.3734	.3734
2	.3734	.4108	.3547	.3734	.3734	.4108	.3734
3	.3734	.4668	.4108	.4108	.3734	.5228	.4854
4	.4668	.5601	.5041	.4668	.4668	.5975	.5601
5	.6535	.7095	.5975	.6535	.6535	.7095	.6348
6	.7842	.8029	.8215	.6535	.7842	.7842	.8029
7	.7842	.7655	.7468	.5975	.7468	.7468	.7468
8	.6535	.6908	.6348	.5975	.7095		.5788
9	.6161	.5601	.5601	.5601	.6161		.5601
10	.5228	.5041	.4481	.4668	.5601		.4481
11	.4108	.3361	.3734	.3734	.4294	.3734	.2987
12	.3361	.3361	.3734	.3361	.3734	.2987	.2987
13	.3547	.2987	.3734	.3361	.3361	.2801	.3734
14	.3361	.3361	.2987	.3361	.3547	.2801	.3361
15		.3361	.2987	.2987	.3547	.3361	.3361
16	.3734	.3547	.2801	.3174	.3547	.3734	.3734
17	.4668	.3921	.3734	.3174	.3734	.4668	.4481
18	.5415	.5228	.4668	.4668	.3734	.5228	.5601
19	.5975	.6161	.6535	.6161	.5228	.6161	.5975
20	.5975	.5975	.5975	.5975	.4854	.5601	.5975
21	.4481	.4668	.4668	.5601	.4481	.4668	.4481
22	.4108	.4294	.4108	.3734	.4108	.3734	.4108
23	.3734	.3734	.3734	.3734	.3734	.3734	.3921
24	.3734	.3734	.3547	.3734	.3734	.3734	.3734
Max	.7842	.8029	.8215	.6535	.7842	.7842	.8029
Min	.3361	.2987	.2801	.2987	.3361	.2801	.2987
Avg	.4879	.4839	.4637	.4512	.4675	.4686	.4753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 202 / 11KV DHORKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2343	.1562	.2134	.1494	.1524	.2096	.2096
2	.2343	.2031	.2134	.1494	.1524	.2096	.2286
3	.2343	.2343	.2591	.1307	.1524	.2286	.2286
4	.3125	.2343	.3048	.1307	.1524	.2286	.2286
5	.3437	.2656	.3506	.168	.1524	.2477	.2096
6	.3906	.2812	.4115	.1867	.1905	.2667	.1715
7	.4218	.4531	.5335				
8	.4374	.5468					
9	.5155	.3906	.5182				
10			.4877				
11				.5487	.4268	.5601	.5335
12				.5487	.4999	.7202	.6405
13				.5487	.578	.6401	.6874
14				.5487	.6093	.6401	.703
15				.5335	.703	.7287	.5937
16				.5335	.703	.6478	.6249
17				.381	.703	.6478	.7186
18				.381	.703	.9231	.6483
19	.0381	.0762	.2241	.0953	.0572	.2477	.1905
20	.1905	.0953	.1867	.1334	.2096	.2286	.2286
21	.1334	.1143	.1494	.1905	.2096	.2286	.2096
22	.1334	.1143	.1494	.1905	.2096	.2096	.2096
23	.1334	.0953	.1494	.1715	.2096	.2096	.2096
24	.2286	.1524	.1829	.1307	.1524	.2096	.1905
Max	.5155	.5468	.5335	.5487	.703	.9231	.7186
Min	.0381	.0762	.1494	.0953	.0572	.2096	.1715
Avg	.2655	.2275	.2889	.2925	.3463	.4116	.3832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 203 / 11KV KARKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0924	.0747	.1067	.0714	.0648	.0549
2	.0747	.0739	.0747	.1067	.0714	.0777	.0686
3	.0747	.0739	.0747	.1067	.0714	.0777	.0834
4	.0754	.0739	.0934	.1097	.0714	.092	.1128
5	.0754	.0739	.0934	.1097	.0857	.1052	.1143
6	.0747	.0739	.0934	.141	.1	.1467	.1286
7				.141	.2229	.2364	.3185
8				.1692	.2972	.2715	.3081
9				.1833	.2143	.2934	.2503
11	.0766	.0884					
12	.1067		.2195				
13	.093	.16	.2267				
14	.0894	.1296	.2134				
15	.084	.1021					
16	.0991	.12					
17	.1181	.153					
18	.0995	.153					
19	.0914	.112	.0532	.0566	.0747	.0189	.0373
20	.0914	.0934	.0934	.0566	.056	.0189	.0373
21	.0914	.0934	.0187	.0566	.0187	.0189	.0373
22	.0924	.0934	.0187	.0566	.0187	.0189	.0373
23	.0924	.0934	.2801	.0377	.0187	.0189	.0187
24	.0754	.0924	.0747	.1067	.1067	.0518	.04
Max	.1181	.16	.2801	.1833	.2972	.2934	.3185
Min	.0747	.0739	.0187	.0377	.0187	.0189	.0187
Avg	.0875	.1024	.1135	.1030	.0999	.1008	.1098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 204 / 11KV DHANGAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0279	1.1043	1.1717	.056	.0377	.0914	.0739
2	1.0279	1.166	1.1717	.056	.0377	.0914	.0739
3	1.0279	1.2146	1.2186	.056	.0377	.0914	.0739
4	1.1069	1.247	1.2651	.056	.0377	.0914	.0739
5	1.2651	1.3279	1.4403	.056	.0377	.0914	.0739
6	1.2651	1.4251	1.6644	.056	.0366	.0914	.0739
7	1.5384	1.5708	1.8623				
8	1.4403	1.6804	1.8623				
9	1.3603	1.7764	1.8623				
11				1.8884	1.6194	1.8023	2.3537
12				2.1052	1.8679	2.5396	2.7349
13				2.3266	2.0645	2.6216	2.5692
14				2.2405	2.1792	2.6216	2.652
15				2.3758	2.3102	2.5911	2.6852
16				2.3758	2.2939	2.6235	2.652
17				2.0809	2.3102	2.5911	2.6686
18				1.7166	2.3266	2.4129	2.4577
19	.0362	.037	.1494	.0566	.0914	.0724	.0373
20	.0543	.0373	.056	.0377	.0747	.0724	.0934
21	.0876	.056	.0373	.0377	.0747	.0724	.0747
22	.0701	.056	.0373	.0377	.0732	.0724	.0747
23	.0701	.056	.0373	.0377	.0724	.0724	.0747
24	.9602	1.0155	1.3443	.0373	.0251	.0914	.0732
Max	1.5384	1.7764	1.8623	2.3758	2.3266	2.6235	2.7349
Min	.0362	.037	.0373	.0373	.0251	.0724	.0373
Avg	.8226	.9180	1.0120	.8845	.8804	1.0403	1.0822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307	.0791	.1307	.112	.168	.1867
2	.112	.1307	.0791	.0934	.112	.168	.1867
3	.112	.1307	.08	.0934	.112	.1494	.1867
4	.112	.1307	.08	.0934	.112	.1494	.1867
5	.112	.1307	.08	.0934	.112	.1307	.168
6	.112	.1307	.08	.0934	.112	.112	.0943
7	.0934	.1494	.08	.1307	.0934	.112	.056
8	.1307	.1494	.1829	.1494	.2241	.112	.112
9	.1307	.1867		.1494	.1307	.056	
10	.1307	.168	.0171	.2427	.2614	.1307	
11	.2054	.4191	.2715	.4294	.3921	.2241	
12	.3361	.4001	.4108	.3921	.4668	.2801	.381
13	.4294	.3395	.4108	.3921	.3547	.2801	.362
14	.3547	.4382	.3734	.3734		.2987	.381
15		.3361	.3361	.5041		.2614	.2987
16	.0934	.3174	.2801	.3734		.3174	.3734
17	.2801	.2987	.1867	.4108	.3547	.3361	.4668
18	.2801	.2987	.112	.0373	.4294	.3174	.3361
19	.2987	.2614	.1494		.3361	.3174	.2801
20	.2801	.3361		.1307	.3361	.2987	.2241
21	.0747	.1107	.112	.2987	.3361	.2614	.2987
22	.1494	.0949	.112	.056	.3361	.1867	.3547
23	.1307	.096	.1494	.056	.3174	.1867	.168
24	.112	.1307	.0934	.1867	.056	.1867	.1867
Max	.4294	.4382	.4108	.5041	.4668	.3361	.4668
Min	.0747	.0949	.0171	.0373	.056	.056	.056
Avg	.1818	.2215	.1707	.2135	.2427	.2100	.2518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 207 / 11KV DMIC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.1086	.0532	.0179	.0526	.0554	.0724
2	.0526	.0905	.0532	.0179	.0526	.0549	.0724
3	.0526	.0905	.0351	.0179	.0526	.0549	.0732
4	.0526	.0724	.0351	.0183	.0526	.0549	.0732
5	.0701	.0724	.0351	.0183	.0526	.0549	.0549
6	.0701	.0543	.0351	.0181	.0701	.0549	.037
7	.0934	.0362	.0351	.0181	.0351	.056	.0554
8	.112	.0362	.0175	.0351	.0351	.0747	.2033
9	.056	.0362	.0549	.1267	.1052	.2241	.0747
10	.0934	.2987	.128	.2172	.1267	.3361	.1494
11	.2427	.0532	.0701	.2427	.1307	.3734	.1494
12	.2427	.3734	.0701	.3361	.1307	.3734	.1494
13	.1494	.3361		.3361	.0934	.112	.1494
14	.2987	.1086	.0175	.2987	.0747	.1867	.0732
15	.3361	.3734	.0175	.3174	.168	.4481	.1109
16	.3734	.2987	.0179	.2915	.1494	.4294	.1494
17	.3734	.2054	.0179	.1494	.1494	.4668	.1494
18	.168	.1867	.0179	.0934	.1494	.3174	.1307
19	.168	.1307	.0187	.0351	.1867	.1307	.1097
20	.0373	.0549	.0187	.0351	.0747	.0934	.0549
21	.0747	.0537	.0187	.0351	.0747	.0747	.0732
22	.0934	.0354	.0187	.0351	.0747	.0739	.0732
23	.1307	.0354	.0179	.0701	.0747	.0739	.0532
24	.0351	.1097	.0532	.0181	.0351	.056	.0732
Max	.3734	.3734	.128	.3361	.1867	.4668	.2033
Min	.0351	.0354	.0175	.0179	.0351	.0549	.037
Avg	.1429	.1355	.0373	.1166	.0917	.1763	.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 211 / NANDALGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1467	.1429	.153	.1715
2				.1467	.1429	.1833	.1715
3				.1467	.1429	.2143	.1858
4				.1467	.1429	.2286	.2
5				.2201	.1429	.2572	.2143
6				.2641	.1429	.2896	.2317
7				.3102	.3286	.4778	.3185
8				.3668	.4572	.4633	.5213
9				.3858		.4489	.3909
11	.1715	.1174					
12	.2286	.1614					
13	.2614	.2347	.3227				
14	.2286	.2201	.2934				
15	.2572	.0579	.2201				
16	.2572	.0579					
17	.2858	.0579					
18	.1286						
24				.0734	.1467	.1391	.141
Max	.2858	.2347	.3227	.3858	.4572	.4778	.5213
Min	.1286	.0579	.2201	.0734	.1429	.1391	.141
Avg	.2274	.1296	.2787	.2207	.1989	.2855	.2547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 212 / 11KV KARKIN GAOTHAN FEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3547		.3361	.3361	.3547	.3734
2	.3361	.3734		.3361	.3361	.3734	.3734
3	.3361	.4108		.3361	.3734	.3734	.4668
4	.4668	.5041		.4668	.4668	.4481	.5601
5	.6161	.5601		.5601	.6535	.6722	.5975
6	.7095	.6161		.7468	.7842	.7842	.8029
7	.7842	.6722		.7468	.7095	.6161	.7282
8	.6535	.5788		.5975	.6722	.5975	.6535
9	.5975	.5041		.5601		.5788	.5415
10	.4668	.4294	.4108	.4668		.3734	
11	.3361	.3174		.3361	.3547	.2801	
12	.2987	.2614		.2801	.2801	.2801	.2987
13	.3174	.2614	.2987	.2614	.2427	.2801	.2614
14	.2987	.2241	.2987	.2614	.2614	.2801	.2987
15	.2987	.2241	.2801	.2427	.2614	.2801	.2987
16	.3361	.2427	.2801	.2427	.2987	.3361	.3547
17	.3734	.3547	.2801	.2614	.3734	.4668	.4294
18	.5228	.4481			.4854	.5975	.4854
19	.0373	.6348	.6535		.5975	.7095	.6161
20	.4854	.5601	.6535	.6161	.5415	.5415	.5788
21	.4294		.5601	.4481	.4668	.4668	.4108
22	.3734	.3734	.3734	.3734	.3547	.4294	.3734
23	.3361	.3361	.3734	.3361	.3547	.3734	.3361
24	.3734	.3361	.3174	.3361	.3361	.3547	.3734
Max	.7842	.6722	.6535	.7468	.7842	.7842	.8029
Min	.0373	.2241	.2801	.2427	.2427	.2801	.2614
Avg	.4217	.4164	.3983	.4159	.4337	.452	.4642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 201 / 11KV Ranjangaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3258	.3429	.2915	.3086	.3429	.3429
2	.2915	.3258	.3429	.2915	.3086	.3258	.2896
3	.3086	.3601	.3429	.2743	.3086	.3258	.3258
4	.3429	.4115	.4115	.3086	.3772	.4115	.3772
5	.5487	.583	.6516	.6516	.5611	.5973	.5973
6	.6687	.8916	.7392	.8501	.8316	.924	.724
7	.823	.823	.7762	.7842	.8131	.8962	.7577
8	.7716	.7202	.8501	.7468	.9149	.8029	.8962
9	.6344	.6344	.6154	.5788	.7602	.7023	.6878
10	.4801	.381	.5068	.3982	.5487	.5611	.4115
11	.3601	.2896	.4344	.3258	.4458	.4525	.381
12	.3086	.3506	.4458	.2915	.4115	.3772	.3353
13	.3086	.2743	.3429	.2401		.3429	.3201
14	.3086	.2743	.3258	.2229	.3772	.3772	.3201
15	.2915	.2743	.3258		.3772	.4115	.3201
16	.2743	.2743	.3429		.4458	.4887	.3353
17	.3772		.3772	.4287	.5144	.543	.4572
18	.6173	.6697	.4344		.6516	.5973	.6097
19	.6859	.7947	.543	.8131	.7202	.7577	.7011
20	.583	.6154	.5792	.6516	.6344	.7762	.6401
21	.5144	.543	.5068	.463	.4458	.543	.4572
22	.3772	.3772	.3772	.4287	.4115	.4287	.3963
23	.3429	.3429	.3086	.3772	.3772	.3772	.3658
24	.3086	.3258	.3429	.2915	.3429	.3772	.3429
Max	.823	.8916	.8501	.8501	.9149	.924	.8962
Min	.2743	.2743	.3086	.2229	.3086	.3258	.2896
Avg	.4515	.4723	.4694	.4624	.5169	.5308	.4747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 202 / Marhola

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.1029	.4572	.381	.3963	.4115
2	.0914	.0937	.1029	.4877	.381	.0914	.4268
3	.1067	.0156	.1029	.4877	.3963	.4268	.4572
4	.1067	.125	.12	.4877	.442	.4572	.5335
5	.1219	.1562	.1543	.5792	.5335	.5658	.6097
6	.1219	.2187	.2058	.6097	.6249	.6859	.6859
7	.1524	.1829	.12	.6249	.6859	.8535	.9217
8	.1677	.1829	.1886	.6401	.8124	.8749	.9374
9		.1524	.1715	.6249	.7343	.7968	.6554
10			.1543	.0762	.1219	.12	.1219
11	.4877		.5335	.12	.1372	.1029	.1143
12	.5792	.4268	.6249	.12	.1372	.12	.0762
13	.5944	.4572	.6706	.12		.1372	.0762
14	.6097	.6401	.7011	.1372	.0762	.12	.0953
15	.6401	.7011	.7316	.1715	.0914	.12	.1334
16	.6706	.7316	.6859		.0914	.1372	.1334
17	.7164	.7316	.6554		.1219	.1372	.1334
18	.4877	.7316	.6249		.1524	.1715	.1524
19	.0914		.12	.1886	.1372	.1886	.1524
20	.1219		.1372	.1886	.1524	.1886	.1524
21	.1219	.1372	.12	.1543	.1219	.1886	.1219
22	.0914	.1372	.1372	.1543	.1067	.1543	.1219
23	.0937	.1029	.1029	.1372	.1067	.1029	.1334
24	.0914	.0781	.0914	.3506	.381	.4268	.3963
Max	.7164	.7316	.7316	.6401	.8124	.8749	.9374
Min	.0914	.0156	.0914	.0762	.0762	.0914	.0762
Avg	.2890	.3047	.3067	.3294	.3012	.3152	.3231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 204 / AURANGPURWADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6716			.2439	.2134
2	1.5242	1.6872			.2439	.2187
3	1.5546	1.6872			.2743	.2134
4	1.6004	1.7284			.2743	.2286
5	1.6766	1.7604			.2591	.1981
6	1.829	1.9204			.2286	.1677
7	1.9814	2.2672			.2439	.1829
8	2.0424	2.2348			.2286	.1981
9	2.0576	2.2996			.1829	.1677
10						.1829
11			2.0805	2.6063	2.2348	1.8442
12			2.4326	2.6825	2.2024	2.1338
13			2.7686		2.6686	2.1643
14			2.1052	2.5149	2.6189	2.1338
15				2.7435	2.6189	2.0576
16				2.6216	2.652	2.1338
17					2.4741	2.1643
18			2.332	2.4387	2.3266	2.21
19					.2439	.2286
20					.2134	.2286
21					.2439	.2134
22				.2439	.2743	.2134
23				.2439	.2286	
24	1.4937	1.6716			.2439	.2134
Max	2.0576	2.2996	2.7686	2.7435	2.6686	2.21
Min	1.4937	1.6716	2.0805	.2439	.1829	.1677
Avg	1.7269	1.8928	2.3438	2.0119	1.0184	.8657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 205 / DARGHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0156	.0152	.9374	.9686	.9686	.8436
2	.0152	.0156	.0152	.953	.9842	.9998	.8592
3	.0152	.0156	.0152	.953	.9998	1.0155	.9061
4	.0152	.0156	.0152	.9842	1.0467	1.0311	.9686
5	.0152	.0156	.0152	1.0623	1.0936	1.1092	.9686
6	.0152	.0156	.0152	1.2186	1.2029	1.2029	1.2186
7	.0152	.0156	.0171	1.1561	1.2811	1.2654	1.2967
8	.0152	.0156	.0152	1.1405	1.3123	1.3592	1.3123
9	.0152	.0156	.0152	1.1405	1.2346	1.2186	1.3904
10	.0152	.0152	.0152	.0152	.0152	.0152	.0191
11	1.0517	1.1279	1.3592	.0152	.0152	.0152	
12	1.1888	1.1888	1.4373	.0152	.0152	.0152	.0191
13	1.1888	1.2193	1.4842	.0152		.0152	.0191
14	1.2193	1.2803	1.4998	.0152	.0152		.0191
15	1.2346	1.3717	1.4685		.0152		.0191
16	1.2498	1.387	1.406	.0152	.0152		.0191
17	1.2955	1.3717	1.3748	.0152	.0152	.0152	.0191
18	1.0974	1.3565	1.2967	.0152	.0152	.0152	.0191
19	.0156	.0152	.0152	.0152	.0152	.0152	.0191
20	.0156	.0152	.0152	.0152	.0152	.0152	.0191
21	.0156	.0152	.0152	.0152	.0152	.0152	.0191
22	.0156	.0152	.0152	.0152	.0152	.0152	.0191
23	.0156	.0152	.0152	.0152	.0152	.0152	.0191
24	.0152	.0156	.0152	.8688	.9374	.9297	.8592
Max	1.2955	1.387	1.4998	1.2186	1.3123	1.3592	1.3904
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0191
Avg	.4071	.4396	.4822	.4614	.4895	.5365	.4727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 201 / Wadwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.0354		
2	.6706	.0354		
3	.7316	.0354		
4	.7316	.0526		
5	.7716	.0532		
6	.7926	.0532		
7	.8535	.0716		
8	.9755		.1063	
9			.1052	
10			.0895	
11			1.4022	
12			1.4937	
13			1.5242	
14			1.5851	
15			1.6156	
16			1.6461	1.6667
17				1.6975
18				1.7284
19				.1063
20				.0937
21				.0949
22				.0937
23				.1075
24	.6097	.0354		
Max	.9755	.0716	1.6461	1.7284
Min	.6097	.0354	.0895	.0937
Avg	.7530	.0465	1.0631	.6986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 202 / Anantpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.7116		
2	.0183	.7116		
3	.0173	.8002		
4	.0183	.7621		
5	.0177	.8383		
6	.0177	.8535		
7	.0177	.8535		
8	.0177	1.0185	1.2346	
9			1.2803	
10			.0154	
11			.0177	
12			.0177	
13			.0179	
14			.0177	
15			.0177	
16			.0177	.0177
17			.0177	.0183
18				.0177
19				.0177
20				.0183
21				.0179
22				.0183
23				.0177
24	.0177	.4572		
Max	.0183	1.0185	1.2803	.0183
Min	.0173	.4572	.0154	.0177
Avg	.0178	.7785	.2654	.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 203 / Apegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.503		
2	.0177	.503		
3	.0177	.5155		
4	.0175	.5182		
5	.0177	.6081		
6	.0177	.6097		
7	.0114	.6944		
8	.0177		1.1126	
9			1.1873	
10			.0351	
11			.0179	
12			.0179	
13			.0179	
14			.0177	
15			.0177	
16			.0177	.0354
17				.0354
18				.0362
19				.0354
20				.0362
21				.0354
22				.0366
23				.0366
24	.0177	.503		
Max	.0177	.6944	1.1873	.0366
Min	.0114	.503	.0177	.0354
Avg	.0170	.5569	.2713	.0359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 204 / WADWALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4075	.4344		
2	.4784	.4207		
3	.6401	.4477		
4	.6805	.5014		
5	.8505	1.0498		
6	.8993	1.0166		
7	1.1963	1.0166		
8	1.0924	.9536	1.0749	
9			.929	
10			.6733	
11			.591	
12			.5028	
13			.4508	
14			.4298	
15			.6805	
16			.6447	.4572
17			.4119	.7265
18				.7888
19				.9313
20				.8775
21				.5493
22				.4024
23				.3856
24	.3475	.4298		
Max	1.1963	1.0498	1.0749	.9313
Min	.3475	.4207	.4119	.3856
Avg	.7325	.6967	.6389	.6398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 205 / 11kvWAGHADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.0177		
2	.0152		
3	.0177		
4	.0183		
5	.0177		
6	.0177		
7	.0177		
8	.0183	.0354	
9		.0354	
10		.0354	
11		1.2018	
12		1.3125	
13		1.3592	
14		1.3565	
15		1.4661	
16		1.4548	1.5242
17		1.3413	1.9022
18			1.8804
19			.0351
20			.0366
21			.0366
22			.0354
23			.0354
24	.0183		
Max	.0183	1.4661	1.9022
Min	.0152	.0354	.0351
Avg	.0176	.9598	.6857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 208 / 11KV Naigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	11-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.0177		
2	.4115	.0177		
3	.4115	.0366		
4	.4374	.0366		
5	.4572	.0366		
6	.5155	.0358		
7	.571	.0358		
8	.5864	.0709	.0177	
9			.0175	
10			.0177	
11			1.2226	
12			1.1702	
13			1.2643	
14			1.2809	
15			1.3117	
16			1.3117	1.1736
17			1.1888	1.2037
18				1.1883
19				.0354
20				.0354
21				.0354
22				.0366
23				.0179
24	.3658	.0177		
Max	.5864	.0709	1.3117	1.2037
Min	.3658	.0177	.0175	.0179
Avg	.4597	.0339	.8803	.4658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 209 / 11KV Maigaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
1	.4572	
2	.4938	
3	.6268	
4	.5864	
5	.7164	
6	.7164	
7	.6718	
8	.8775	1.0822
9		1.0822
24	.4096	
Max	.8775	1.0822
Min	.4096	1.0822
Avg	.6173	1.0822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 201 / UDYOGMITRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9671	.7362	1.1145	1.0288	1.0498	1.0166	1.1203
2	.985	.7011	1.1145	.9945	1.0498	.9816	1.1203
3	.9671	.7362	1.1317	.9945	1.086	.9816	1.1203
4	.985	.7362	1.1317	.9945	1.086	.9816	1.1203
5	.985	.7362	1.1831	1.0288	1.086	.964	1.1203
6	.8954	.7888	1.182	1.0288	1.086	1.0166	1.1576
7	.8238	.9745	1.1104	1.0288	1.086	.9816	1.2136
8	.8328	.9214	1.1641	1.1641	1.448	1.0985	1.2883
9	.8059	1.0454	1.2357	1.3432	1.3756	1.134	1.3443
10	.7973	1.2883	1.2536	1.4842	1.3289	1.3443	1.3432
11	.7973		1.3432	1.448	1.4327	1.2883	1.2536
12	.7796	1.2323	1.2536	1.3717	1.3611	1.1203	1.2536
13	.7796	1.307	1.4327	1.2803	1.2536	1.307	1.3432
14	.7973	1.3256	1.4327	1.4632	1.3969	1.3256	1.2536
15	.7973	1.3443	1.5223	1.4632	1.3969	1.419	1.1641
16	.7087	1.363	1.2536	1.4632	1.4327	1.251	1.2178
17	.7619	1.307	1.2536	1.4632	1.2536	1.2323	1.2536
18	.7796	1.307	1.2536	1.4632	1.2178	1.2136	1.1104
19	.7442	1.2003	1.2536	1.2803	1.1462	1.2696	1.1641
20	.7186	1.1317	1.1641	1.2803	1.0745	1.2696	1.1145
21	.7362	1.0631	1.1104	1.086	1.0387	1.2696	1.1145
22	.7362	1.0974	1.1104	1.1222	1.0631	1.1949	.9431
23	.7362	1.1145	1.1104	1.086	1.0631	1.1203	1.1145
24	.985	.7362	1.1145	1.0288	1.086	1.0277	1.1203
Max	.985	1.363	1.5223	1.4842	1.448	1.419	1.3443
Min	.7087	.7011	1.1104	.9945	1.0387	.964	.9431
Avg	.8293	1.0519	1.2179	1.2246	1.2041	1.1587	1.1821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 202 / NAIGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9313	.7362	.8059	.8573	.8954	.8764	.9709
2	.9313	.7362	.7888	.823	.8688	.8413	.9335
3	.9313	.7537	.7888	.823	.8688	.8764	.9335
4	.8954	.8063	.823	.8916	.9313	.9114	.9709
5	.985	.8859	.8573	.9431	.985	1.0166	1.0456
6	1.2178	1.3969	1.182	1.0974	1.1462	1.382	1.643
7	1.5223	1.3611	1.1999	1.0974	1.3432	1.4175	1.6991
8	1.2536	1.2894	1.3432	1.0288	1.3575	1.382	1.643
9	1.0745	1.2178	1.1462	.9945	1.2803	1.2536	1.5123
10	.985	1.2536	1.1462	1.0745	1.1641	1.3443	1.1641
11	.8505	1.2136	1.1104	1.0745	1.1283	1.2323	1.1104
12	.815	1.1389	1.0387	.985	1.0745	1.1389	.9431
13		1.1203	.8916	.7522	.8859	1.0829	.9431
14		1.0642	.8916	.6984	.9214	.9709	
15		1.1203	1.0208		.9492	1.0642	.9431
16	.8859	1.251	1.0208		1.1104	1.0829	1.0745
17	1.0277	1.4563	1.1104		1.1641	1.1576	1.2894
18	1.0985	1.2894	1.0745		1.2894	1.419	1.1641
19	1.1462	1.2536	1.0387		1.1641	1.4563	.985
20	.9568		1.1462	1.2536	1.0924	1.307	.9431
21	.8859	.9088	.985	.985	1.0277	1.1576	.9431
22	.8238	.8573	.8573	.9593	.9922	1.0829	.8916
23	.7537	.8059	.8916	.9412	.9214	.9709	.8573
24	.985	.7537	.8059	.8573	.9412	.8764	.9709
Max	1.5223	1.4563	1.3432	1.2536	1.3575	1.4563	1.6991
Min	.7537	.7362	.7888	.6984	.8688	.8413	.8573
Avg	.9979	1.0726	.9985	.9546	1.0626	1.1376	1.1119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 203 / 11 KV CHITEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9465	.9114	.9602	.9602	1.1218	.9465	1.0829
2	.9465	.8764	.9602	.9259	1.1218	.9114	1.0829
3	.9114	.8764	.9945	.9259	1.1568	.9465	1.1203
4	.9465	.9816	1.0288	.9259	1.1919	1.0166	1.1203
5	1.0867	1.134	1.0631	1.0631	1.2269	1.1218	1.2323
6	1.262	1.5238	1.3611	1.5043	1.3321	1.4175	1.307
7	1.4022	1.382	1.4685	1.4685	1.4723	1.382	1.419
8	1.2971	1.3466	1.3611	1.3611	1.2971	1.3112	1.4937
9	1.2269	1.3466	1.3969	1.4327	1.2971	1.2403	1.307
10	1.1694	1.4937	1.4685	1.4022	1.5061	1.3443	1.3253
11		1.3443	1.3253	1.3321	1.4175	1.2696	1.1104
12		1.307	1.0745	1.2971	.9922		1.0745
13		1.2323	1.1462	1.2269	.9568		.9945
14	1.0985	1.1949	1.2894	1.2269	1.0277		1.0288
15	1.0631	1.2696	1.3611	1.2269	1.0277	1.3443	1.0631
16	1.0631	1.307	1.3253	1.262		1.307	1.1462
17	1.2048	1.2696	1.2894	1.2971		1.307	1.2536
18	1.2403	1.419	1.5043	1.3672	1.258	1.307	1.2894
19	1.2757	1.2894	1.4327	1.4022	1.2048	1.419	1.2536
20	1.3466	1.2003	1.4327	1.5074	1.382	1.3443	1.3611
21	1.2048	1.166	1.2536	1.4022	1.2403	1.307	1.2536
22	1.0517	1.0631	1.1317	1.2971	1.0985	1.2323	1.0974
23	.9816	.9945	.9945	1.1568	.9816	1.0829	.9945
24	.9816	.9114	.9945	.9602	1.1568	.9465	1.0829
Max	1.4022	1.5238	1.5043	1.5074	1.5061	1.419	1.4937
Min	.9114	.8764	.9602	.9259	.9568	.9114	.9945
Avg	1.1289	1.2017	1.2341	1.2472	1.2031	1.2145	1.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 205 / 11 KV CHITEGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7796	.5609	.7888	.6516	.6268	.7712	.8215
2	.7973	.5959	.7888	.6173	.6089	.7712	.8215
3	.7973	.5959	.823	.6173	.6268	.7537	.8215
4	.7442	.631	.823	.6173	.6089	.7362	.8215
5	.7087	.6661	.823	.6859	.6089	.7011	.8402
6	.6733	.7011	.7888	.7202	.6268	.7362	.8215
7	.6135	.7011	.6859	.7202	.6089	.7011	.8029
8	.5493	.8859	.9088	.7373	.8954	1.0631	1.0269
9	.6733	.9922	.8059	1.0288	1.1222	1.2403	1.0974
10	.6379	1.4377	1.1462	1.267	1.6289	1.6057	1.4327
11	.6733	1.3817	1.2894	1.3575	1.5746	1.5684	1.829
12	.6379	1.8111	1.2178	1.3756	1.4327	1.9418	1.576
13	.6024	1.8298	1.166	1.3394	1.1462	1.8671	1.2178
14	.6733	1.8298	1.2003	1.267	1.5223	1.6991	1.2178
15	.6733	1.8671	1.2894	1.701	1.5581	1.643	1.3611
16	.7087	1.8671	1.3611	1.6461	1.576	1.4003	1.3611
17	.7796	1.9231	1.2536	1.6827	1.5223	1.419	1.3611
18	.6379	1.8671	1.2536		1.4864	1.475	1.2656
19	.5959	.9431	.8916		1.0029	1.1389	.8596
20	.631	.823	.7202	.5014	.9313	.8962	.7716
21	.5959	.7888	.6516	.6089	.8505	.8215	.6859
22	.5959	.7888	.6173	.6089	.8063	.8215	.6859
23	.5609	.7888	.6859	.6089	.7888	.8215	.6859
24	.7973	.5609	.7888	.6516	.6089	.7712	.8215
Max	.7973	1.9231	1.3611	1.701	1.6289	1.9418	1.829
Min	.5493	.5609	.6173	.5014	.6089	.7011	.6859
Avg	.6724	1.1183	.9487	.9551	1.0321	1.1402	1.0420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 201 / RAPDRP NEW KAWSAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.6154	.5975	.7095	.7095	.7316	.6335
2	.5611	.5973	.5975	.6722	.6722	.695	.6335
3	.5973	.5973	.6348	.6722	.7095	.695	.6516
4	.6335	.5973		.6348	.6908	.7316	.6697
5	.6878	.6335	.6722	.5975	.7468	.8048	.6878
6	.724	.7964	.8589	.5975	.8589	.8413	.7602
7	.7783	.7783	.7468	.6348	.7964	.7865	.8326
8	.724	.7059	.7095	.6908	.7059	.7682	.6878
9	.6335	.5973	.5975	.7095	.5792	.6219	.6697
10	.5792	.5973	.6535	.6348	.5249	.6219	.5973
11	.5249	.5973	.6348	.6161	.6516	.6401	.5973
12	.5068	.5973	.6161	.5975	.6036	.6036	.6335
13	.5792	.5611	.5975	.5975	.6036	.6401	.5792
14	.543	.543	.5975	.5975	.6219	.6584	.5611
15	.543	.5792	.5975	.6161	.6401	.6219	.6335
16	.5973	.5975	.6348	.6348	.6219	.6401	
17	.5973	.6722	.6348	.6348	.6219	.6516	.9149
18	.6154	.7282	.6348	.6161	.6036	.6154	.6908
19	.6516	.8029	.6722	.6348	.6584	.6697	.7842
20	.7783	.7842	.7095	.8029	.7316	.8145	.8962
21	.724	.7655	.7468	.8029	.7865	.7783	.8402
22	.724	.7468	.7842	.7842	.8048	.724	.8402
23	.6516	.7468	.7842	.7842	.7316	.724	.7842
24	.6516	.6154	.7095	.7468	.7468	.724	.7059
Max	.7783	.8029	.8589	.8029	.8589	.8413	.9149
Min	.5068	.543	.5975	.5975	.5249	.6036	.5611
Avg	.6343	.6606	.6705	.6675	.6843	.7001	.7080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 202 / RAPDRP POWER HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	.9593	1.0082	1.0082	1.0269	1.0059	1.0136
2	.905	.905	.9709	.9709	.9896	1.0059	.9955
3	.9231	.9231	.9896	.9335	.9335	.9145	1.0136
4	.9955	.9412	.9709	.9335	1.1389	.9511	1.1041
5	1.0498	.9593	.9709	.9709	1.1203	.9877	1.086
6	1.1041	1.0136	1.0456	1.0082	1.1203	1.0608	1.0498
7	1.1222	1.0136	1.1203	1.2136	1.0317	1.0608	1.0498
8	1.1946	1.1041	1.1763		1.1041	1.0608	1.1222
9	1.1765	1.086	1.1576	1.1389	1.0608	1.0425	1.086
10	1.1584	1.0136	1.1576	1.1203	.9877	1.134	1.1041
11	1.1584	1.0679	1.1389	1.1949	1.134	1.1157	1.086
12	1.086	1.086	1.1203	1.1389	1.0974	1.134	1.1222
13	1.1041	1.0317	1.2696	1.1203	1.0974	1.134	1.1222
14	1.086	.9955	1.1576	1.0829	1.1157	1.134	1.1222
15	1.086	1.0498	1.1389	1.1203	1.134	1.1706	1.086
16	1.1222	1.0269	1.1576	1.1763	1.0974	1.1888	1.1946
17	1.086	1.1576	1.1763	1.1763	1.2803	1.267	1.2136
18	1.1946	1.307	1.251	1.4377	1.3717	1.4118	1.3256
19	1.3032	1.4003	1.2323	1.3443	1.3169	1.3032	1.363
20	1.2851	1.307	1.2696	1.4377	1.2986	1.3213	1.5497
21	1.1765	1.2696	1.3817	1.2883	1.1523	1.1765	1.3256
22	1.0679	1.2136	1.1949	1.1203	1.0974	1.1041	1.2323
23	1.0317	1.1016	1.1763	1.0829	1.0974	1.0136	1.1203
24	.9774	.9593	1.0456	1.0082	1.0642		1.0136
Max	1.3032	1.4003	1.3817	1.4377	1.3717	1.4118	1.5497
Min	.905	.905	.9709	.9335	.9335	.9145	.9955
Avg	1.0973	1.0789	1.1366	1.1316	1.1195	1.1173	1.1459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11 KV JAMGAON FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.0343
9			.0343
10			.7888
11			.9945
13		.9945	
14		1.0288	
15		1.0288	
16		1.1145	
17		1.0288	
18		.0343	
21		.0343	
22	2.4006		
23		.0343	
Max	2.4006	1.1145	.9945
Min	2.4006	.0343	.0343
Avg	2.4006	.6623	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11 KV MANJARI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.0171
14		.0343	
16	1.5089		
17	1.4403		
18	.0686		
19	.0514		
21		.0514	
22		.9088	
23		1.1488	
Max	1.5089	1.1488	.0171
Min	.0514	.0343	.0171
Avg	.7673	.5358	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11 KV MALUNJA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.3772
9			.2915
10			1.3375
11			1.9376
13		2.0576	
14		2.1262	
15		1.9547	
16	.1715	2.0062	
17	.12	2.0576	
18		.2058	
19	.1715	.1715	
20	.1715	.2401	
21	.12	.3429	
22	.7545	.2915	
23	.7545	.2915	
Max	.7545	2.1262	1.9376
Min	.12	.1715	.2915
Avg	.3234	1.0678	.9860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / TOWN I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			1.2517
9		1.0631	1.1145
10		1.0288	1.0631
11		.9774	1.166
12		1.0288	
13		1.0288	
14		1.0288	
16	1.3717	1.0974	
17	1.0288		
18		.1372	
19	1.2689	1.3203	
20	1.406	1.2346	
21	1.3032	1.3375	
22	1.2003	1.2517	
23	1.1488	1.286	
Max	1.406	1.3375	1.2517
Min	1.0288	.1372	1.0631
Avg	1.2468	1.0631	1.1488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 205 / TOWN II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.7716
9		.6859	.7716
10		.6859	.6859
11		.583	
12		.6001	
13		.583	
14		.5144	
16	.7373	.6001	
17	.6344	.6859	
18		.6859	
19	.6001	.6001	
20	.6859	.5487	
21	.6344	.6344	
22	.6344	.583	
23	.5487	.5658	
Max	.7373	.6859	.7716
Min	.5487	.5144	.6859
Avg	.6393	.6112	.7430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 206 / TOWN III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.4458
9		.3772	.4287
10		.3944	.3772
11			.3429
12		.3429	
13		.2915	
14		.3429	
16	.3429	.3429	
17	.2915	.4801	
18		.4115	
19	.4115	.3772	
20	.4115	.3429	
21	.4115	.4115	
22	.3429	.3772	
23	.3086	.3429	
Max	.4115	.4801	.4458
Min	.2915	.2915	.3429
Avg	.3601	.3719	.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 207 / 11 KV WARKHED FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.0343
9		.0343	
17	.6001		
22		.6344	
23		.7545	
Max	.6001	.7545	.0343
Min	.6001	.0343	.0343
Avg	.6001	.4744	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 208 / 11 kv NAWABPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.9088
9				.7545
10				.3772
11				.4458
14			.6173	
15			.583	
16	.4973	.3772	.5144	
17	.5658	.5144	.6173	
18		.583	.5144	
19	.583	.7888	.9088	
20	.8059		.8573	
21	.6344		.6859	
22	.5144		.5144	
23	.4287		.4287	
Max	.8059	.7888	.9088	.9088
Min	.4287	.3772	.4287	.3772
Avg	.5756	.5659	.6242	.6216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 209 / 11KV NEW INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.0857
9			.0857
10		.0686	
11		.0686	
12		.1029	
13		.1715	
14		.1543	
16	.0686	.1715	
17	.0686	.1715	
18		.1715	
19	.0857	.1715	
20	.0857	.12	
21	.0857	.0857	
22	.0857	.0857	
23	.1715	.0857	
Max	.1715	.1715	.0857
Min	.0686	.0686	.0857
Avg	.0931	.1253	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 201 / 11KV TURKABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2035		.0381	.0381	.0381	
2		.2429		.0381	.0381	.0381	
3		.2515		.0381	.0572	.0762	
4		.2915		.0381	.0572	.0762	
5		.3052		.0572	.0572	.0762	
6		.3391		.0762	.0762	.0762	
7	.4191	.3563		.0572	.0381	.1143	
8	.0381	.0339		.0191	.0381	.0762	
9	.0381	.0381		.0191	.0381	.0381	
10		.0381	.0381	.3048	.2401	.3239	.4191
11		.0381	.0191	.381	.3429		.5716
12				.4191	.3772	.3353	.5716
13				.4115	.3429	.3647	.5716
14			.0191	.4458	.4191	.3978	
15			.0191		.381	.3978	.4572
16			.0381	.3429	.381	.3647	.4572
17			.0381	.3772	.3429	.3239	.3772
18			.0762	.0343	.0381	.0328	.0381
19			.0762	.0381	.0762	.0335	.0762
20			.0572	.0381	.0762	.0328	.0762
21			.0381	.0381	.0381	.0324	.0381
22			.0381	.0381	.0381	.0324	.0381
23			.0381	.0381	.0381	.0324	.0381
24		.1943		.0381	.0381	.0381	
Max	.4191	.3563	.0762	.4458	.4191	.3978	.5716
Min	.0381	.0339	.0191	.0191	.0381	.0324	.0381
Avg	.1651	.1944	.0413	.1446	.1503	.1457	.2869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 202 / 11 KV SHIVRAI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0819		.9526	1.2574	1.2955	
2	.0953	.0972		.9526	1.3336	1.3717	
3	.0953	.1147		.9526	1.4098	1.4098	
4	.1143	.1187		.9907	1.448	1.4861	
5	.1143	.1357		1.0288	1.5242	1.5242	
6	.1143	.1638		1.1431	1.3717	1.5242	
7	.1334	.1696		1.2517	1.406	1.5089	
8	.1143	.1296		.1715	.0953	.1143	
9	.0953	.1524		.1334	.0953	.1143	
10		.9526	1.2003	.1143	.0762	.081	.1143
11		1.4098	1.2346	.0762	.0572	.081	.0953
12		1.3336	1.2003		.0572	.081	.0953
13			1.2003	.0953	.0572	.0648	.0953
14				.0762	.0762	.0671	
15			1.0288	.0762	.0572	.0648	.0762
16			1.0631	.0762	.0762		.0953
17			1.0117	.0381	.1143	.081	.0953
18			.1524	.0381	.1143	.0838	.1143
19			.1905	.0572	.1143	.081	.1905
20			.1524	.0762	.1143	.081	.1524
21			.1524	.0762	.0953	.0972	.1524
22			.9717	1.0288	1.0669	.7545	1.2955
23			.9907	1.0669	1.1431	.7773	1.3336
24	.0953	.081		.9907	1.1431	1.2574	
Max	.1334	1.4098	1.2346	1.2517	1.5242	1.5242	1.3336
Min	.0953	.081	.1524	.0381	.0572	.0648	.0762
Avg	.1086	.3800	.8115	.4984	.5960	.6088	.3004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 203 / 11 KV DAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0648		.1143	.1524	.2667	
2	.0953	.0848		.1143	.1905	.2667	
3	.1143	.1357		.1143	.1905	.3048	
4	.1334	.1357		.1334	.2286	.3429	
5	.1334	.1696		.1905	.2286	.3048	
6	.1524	.2035		.2286	.2667	.3048	
7	.1334	.2204		.3429	.3048	.4458	
8	.1334	.2035		.1905	.0762	.4572	
9	.0953	.2286		.1524	.1143	.1905	
10		.1905	.1524	.1143	.0953	.1677	.0762
11		.1905	.1715	.1143	.0762	.1341	.0381
12			.2572	.0953		.1357	.0381
13			.2572	.0953			.0381
14			.3086	.0762	.1143		
15			.2058	.0762	.0953		.0572
16		.1143	.2401	.0572	.0762		.0953
17			.2401	.0191	.0953		.1524
18			.2286	.0191	.0762	.0838	.1715
19			.1905	.0381	.1143	.0838	.1905
20			.1524	.0572	.1524	.1006	.1905
21			.0762	.0381	.1524	.0995	.1524
22			.1143	.0381	.2667	.1619	.1524
23			.1143	.1905	.2286	.1677	.1143
24	.0762	.0486		.1143	.1524	.2286	
Max	.1524	.2286	.3086	.3429	.3048	.4572	.1905
Min	.0762	.0486	.0762	.0191	.0762	.0838	.0381
Avg	.1162	.1531	.1935	.1135	.1567	.2236	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 204 / 11 KV MANGEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2035		.0381	.0191	.0381	
2	.2667	.2515		.0381	.0191	.0381	
3	.2667	.3052		.0381	.0191		
4	.2667	.3391			.0381	.0572	
5	.3239	.373		.0381	.0381	.0572	
6	.4191	.373		.0381	.0381	.0572	
7	.4954	.4049		.0381	.0381	.0762	
8	.0191	.0335		.0191	.0191	.0572	
9	.0191	.0381		.0191	.0191	.0381	
10			.0191	.4458	.3772	.4534	.5144
11			.0191	.5144	.5487	.4534	.5658
12		.0191	.0191	.5487	.5144	.4696	.6001
13			.0191	.5144	.583	.4858	.6173
14			.0191	.4801	.5144	.4858	
15			.0191	.4115		.5138	.4458
16			.0572	.4458	.0191		.4287
17			.1143	.3429		.4049	.3772
18			.0572	.0191	.0381	.0168	.0191
19			.0762	.0381	.0381	.0168	.0381
20			.0762	.0572	.0381	.0162	.0381
21			.0762	.0381	.0381	.017	.0381
22			.0572	.0191	.0381	.017	.0191
23			.0381	.0191	.0381	.0162	.0191
24	.2286	.2035		.0381	.0191	.0381	
Max	.4954	.4049	.1143	.5487	.583	.5138	.6173
Min	.0191	.0191	.0191	.0191	.0191	.0162	.0191
Avg	.2553	.2313	.0477	.1826	.1387	.1738	.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 205 / 11 kv DAHEGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.763		.7621	.9145	.7621	
2	1.0669	.8478		.7621	.9145	.7621	
3	1.1431	.9835		.8764	1.0669	.8764	
4	1.6956	1.2209		.9145	1.1431	.9526	
5	1.7528	1.2574		1.2955	1.448	1.2574	
6	1.8861	1.6108		1.7528	1.6385	1.4861	
7	1.6766	1.5091		1.4918	1.5242		
8	1.8861	1.3565		1.4861	1.3336		
9	1.5432	1.3336		1.2384	1.0669	.9907	
10		1.1812	1.0669	1.1431	.9526	.9326	.9907
11		.7621	.9145	1.1431	.8764	.8048	.8002
12			.6859	.8764		.7773	.743
13			.724	.7621		.7287	.8383
14				.7621	.8764	.6478	
15			.724	.724	.7621	.6478	.7811
16			.8002	.7621	.8764	.7122	.9526
17			1.0098	.8764	.9526	.7545	1.105
18			1.2384	1.0669	1.2574	.8886	1.3146
19			1.6004	1.2574	1.3336	.8907	1.5623
20			1.2955	1.3336	1.6385	.9835	1.4098
21			1.0669	1.448	1.5242	.8886	1.105
22			.9335	1.3336	1.2574	.7545	.8764
23			.8002	.8764	.7621	.6706	.8002
24	.7621	.7122		.7621	.9145	.7621	
Max	1.8861	1.6108	1.6004	1.7528	1.6385	1.4861	1.5623
Min	.7621	.7122	.6859	.724	.7621	.6478	.743
Avg	1.4289	1.1282	.9892	1.0711	1.1379	.8605	1.0215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 206 / 11 KV TURKABAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.763		.8002	.9526	.7621	
2		.8987		.8002	.9526	.8002	
3		1.0174		.8764	1.0669	.8764	
4		1.166		.9335	1.1431	.9526	
5		1.3565		1.1812	1.448	1.3908	
6		1.5424		1.6004	1.5242	1.5242	
7	1.7147	1.4575		1.5432	1.3336	1.7147	
8	1.7147	1.326		1.5051	1.2574	1.5242	
9	1.6956			1.2955	1.1431	1.2574	
10		1.1812	1.0669	1.1812	.9526	.9717	1.0288
11		.8764	.8383	1.1431	.8764	.9326	.8002
12				.9526	.7621	.8097	.6668
13				.8764	.724	.7773	.6859
14			.8002	.7621	.7621	.763	
15			.8002		.8383	.6802	.2858
16			.8764	.6859	.8764	.6478	1.0288
17			.9145	.8764	.9526	.7545	
18			1.1812	1.1431	1.0669	.9231	1.3146
19			1.4098	1.4098	1.1431	1.004	1.6194
20			1.1812	1.5242	1.448	.8886	1.5242
21			1.0669	1.6766	1.3336	.8478	1.105
22			.9526	1.2574	1.1431	.7287	.9907
23			.8192	.8764	.8764	.6478	.8764
24		.6478		.8002	.9145	.7621	
Max	1.7147	1.5424	1.4098	1.6766	1.5242	1.7147	1.6194
Min	1.6956	.6478	.8002	.6859	.724	.6478	.2858
Avg	1.7083	1.1121	.9923	1.1174	1.0622	.9559	.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 207 / 11 KV YESGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.017		.2286	.1905	.2286	
2	.0381	.017		.2858	.2286	.2286	
3	.0381	.017		.2858	.2667	.2667	
4	.0381	.0162		.2858	.3048	.3048	
5	.0381	.017		.3429	.3429	.3429	
6	.0381	.0162		.381	.381	.4191	
7	.0191	.017		.4458	.381	.381	
8	.0191	.0162		.0191	.381	.0381	
9	.0191	.0191		.0191	.0191	.0381	
10		.0953	.2058	.0191	.0191	.0339	.0191
11		.1143	.3086	.0191			.0191
12			.3086	.0191			.0191
13				.0191			.0191
14				.0191			
15			.3258	.0191		.0168	.0191
16			.3086	.0191		.0162	.0191
17			.2743	.0191	.0191	.0162	.0191
18			.0381	.0191	.0191	.0168	.0191
19			.0381	.0191	.0191	.0162	.0381
20			.0381	.0191	.0191	.0168	.0381
21			.1524	.0191	.0191	.0162	.0381
22			.1715	.2286	.2286	.1943	.1905
23			.1905	.2286	.1905	.6478	.2286
24	.0381	.017		.2286	.1905	.2286	
Max	.0381	.1143	.3258	.4458	.381	.6478	.2286
Min	.0191	.0162	.0381	.0191	.0191	.0162	.0191
Avg	.0324	.0316	.1967	.1337	.1789	.1734	.0528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 208 / 11KV ARYANSH IND FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5365		.724	.7621	.6859	
2	.7621	.5182		.724	.7621	.6859	
3	.8002	.4696		.7621	.8002	.724	
4	.8002	.4696		.8002	.8002	.7621	
5	.8002	.4858		.8383	.8002	.7621	
6	.8764	.4858		.8764	.8383	.8002	
7	.6478	.5087		.8764	.8002	.7621	
8	.7621	.5087		1.105	.8002	.724	
9	.8002	.4954		1.1241	.7621	.381	
10		.5716	.3048	1.0669	.8383	.3563	.9145
11		.4382	.3429	.9907	.9526	.3563	.9907
12			.3429	.8764	.9526	.4049	.9907
13			.3429	.7621	.9526	.426	1.0288
14			.3048	.6859	.8764	.431	
15			.3048	.5716	.8383	.4144	1.2765
16			.3048	.6097	.8002	.4748	1.2955
17			.3048	.6859	.7621	.4534	1.2384
18			.3429	.7621	.8764	.4858	.7049
19			.4191	.724	.8383	.4858	.6859
20			.5716	.6859	.8002	.5668	.6668
21			.6097	.724	.7621	.5992	.6478
22			.6478	.724	.7621	.5668	.6478
23			.6478	.7621	.724	.5668	.6478
24	.7621	.5256		.724	.7621	.6859	
Max	.8764	.5716	.6478	1.1241	.9526	.8002	1.2955
Min	.6478	.4382	.3048	.5716	.724	.3563	.6478
Avg	.7697	.5011	.4137	.7994	.8177	.5651	.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 209 / SAVERA IND FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5426		1.105	.9526	.8764	
2		.5935		1.105	.9526	.8764	
3		.5668		1.1431	.9526	.7621	
4		.6783		1.1431	.9907	.9145	
5		.6783		1.105	.9907	.9526	
6		.6802		1.0288	.9526	.9907	
7		.6802		.9335	.9907	1.0669	
8	.6859	.6783		1.105	1.0288	1.0288	
9	.6859	.8002		1.086	1.0288	1.0669	
10		.7621	.6097	1.0288	.9526	.8907	.9335
11		.9145	.6097	.9526	.9526	.8745	.9907
12			.6287	.9907	.9907	.8421	1.086
13			.6097	.9526	1.0669	.8259	1.105
14			.6097	.7621	.9907	.8421	
15			1.105		.9526	.8097	.8383
16			1.1241	.9526	.9526	.8097	.8764
17			1.1431	.9907	.8764	.8259	.9145
18			1.105	1.0288	.9145	.8259	.9717
19			1.0479	1.0288	.8764	.8097	.8573
20			1.0288	.7621	.8383	.8421	.8002
21			1.0098	.8764	.8764	.8619	.7811
22			.9907	.9526	.9145	.8097	.7621
23			.9526	.8764	.8764	.8551	.743
24		.5182		1.105	.9145	.8764	
Max	.6859	.9145	1.1431	1.1431	1.0669	1.0669	1.105
Min	.6859	.5182	.6097	.7621	.8383	.7621	.743
Avg	.6859	.6744	.8982	1.0006	.9494	.8807	.8969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 201 / 11 KV SHENDURWADA 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18
HR	Load (MW)
1	1.0374
2	1.0374
3	1.226
4	1.3203
5	1.4146
6	1.5089
24	1.4529
Max	1.5089
Min	1.0374
Avg	1.2854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 206 / 11KV GURUDHANORA 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18
HR	Load (MW)
1	.3772
2	.3772
3	.4715
4	.5658
5	.7545
6	.9431
7	.9431
8	.9054
24	.4338
Max	.9431
Min	.3772
Avg	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 201 / 11 KV SAWANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.381		.5716	1.086		.5716
2	.5716	.381		.6668	1.0288		.6668
3	.5716	.4382		.7621	.9907		.7621
4	.7621	.4763		.8573	1.2574		.8573
5	.9526	.5716		.9526	1.3336		.8764
6	1.0479	.6097		1.0479	1.5242		.9526
7	.9526	.5716		1.0288	1.448		1.2955
8	.7621	.6668		.9526			1.0669
9	.6668	1.0098		.9145	1.0669		
10	.5716	1.0479		.6173	.4801	.9526	1.0098
11	.6287	1.1812	1.6004	.6516	.7621	1.1431	1.2193
12	.8573	1.0479	1.6004	.6104	.7621		1.1431
13	.9907	.8954		.5765	.7621	1.0288	.8573
14		.9145	.9526	.5765	.6668	.9526	.6668
15		.8764	.8573	.5426	.6668	1.0669	.7621
16	1.0288	1.2193	.7621	.5426	.5716	1.105	.8954
17	1.2384	1.1431	.6668	.5087		1.2193	.9145
18	.7621	.9526	.8573			.8573	
19			1.2384			1.0479	.6668
20	.8573		1.1812			.9526	.5716
21	.9526					.8192	.4763
22	.8573					.743	.4954
23	.7621		1.1812			.7049	.7621
24	.6668	.5716		1.2384	1.0669		.6668
Max	1.2384	1.2193	1.6004	1.2384	1.5242	1.2193	1.2955
Min	.5335	.381	.6668	.5087	.4801	.7049	.4763
Avg	.8093	.7872	1.0898	.7566	.9671	.9687	.8253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 202 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9145			.9145		.9526
2	1.0288	.9526			.9335		1.0479
3	1.0479	1.0288			.9335		1.086
4	1.086	1.0479			1.0082		1.1431
5	1.1431	1.105			1.0349		
6	1.2574	1.1431			1.0974		
7	1.2193	1.2003			.9511		
8	.9526	.8764			.9511		
9	1.0098	.8764	.8764	.7682	.9412		
10	1.0479	.9526	.9145	.9774	.9412	.9526	.9526
11	1.1431	.8573	.8383	.9511		1.1431	.9145
12	1.2003	1.1431	1.0669	.9511		1.0669	.9526
13	1.3146	1.1812	.8573			1.105	.9907
14			.9526			1.0479	1.0479
15	.9526		1.105			1.1431	.9526
16	1.105		1.0479			1.2003	.724
17	1.1812		1.1431				.7621
18	1.1431		1.2384			1.1431	.8573
19	.9526		1.2955			1.2193	1.2955
20	1.1812		1.2384			1.2003	1.3336
21	1.1812		1.3336			1.1431	1.3717
22	1.2955		1.2955			1.2193	1.2384
23	1.2003		1.2384			1.1431	.8573
24	1.2384	1.1431		1.1431	.9511		1.1431
Max	1.3146	1.2003	1.3336	1.1431	1.0974	1.2193	1.3717
Min	.9526	.8573	.8383	.7682	.9145	.9526	.724
Avg	1.1249	1.0302	1.0961	.9582	.9689	1.1329	1.0328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 203 / 11 KV RAIPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381		.4191	.381		
2	.5716	.4763		.4763	.381		
3	.6668	.5716		.5335	.381		
4	.7621	.6668		.5716	.381		
5	.8573	.7621		.4763	.4572		
6	.9526	.9526		.3429	.5335		
7	.9145	.8002		.381	.4572		
8	.6097	.381		.4763	.4572		
9	.3429	.2858		.4763	.381		
10	.0572	.2286	.381			.6668	.4191
11	.2858	.2286	.381				
12	.2477	.1905	.4191				.3429
13	.2286	.1524	.4001			.4191	.381
14			.3429				.2286
15	.2667						.4191
16	.1905		.4001				.4191
17	.1905		.4382				.4763
18	.2858		.4763				.5335
19			.4954				.2858
20			.4763				
21	.4191		.381				
22	.381		.4763				
23	.3429		.4954				.5716
24	.3429	.381		.5335	.381		
Max	.9526	.9526	.4954	.5716	.5335	.6668	.5716
Min	.0572	.1524	.3429	.3429	.381	.4191	.2286
Avg	.4473	.4613	.4279	.4687	.4191	.5430	.4077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 204 / 11 KV MALIWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4763					
2	.5716	.5716		.381			
3	.7621	.6668		.4191			
4	.9526	.8573		.5716			
5	1.1431	1.0479		.6097			
6	1.3336	1.1812		.6859			
7	1.2955	1.3146		.724			
8	1.086	1.0098		.6668	.9431		
9	.4763	.8383		.7621	.6859		
10	.5716	.4191		.3429	.5335	.5716	.5716
11	.4763	.3429	.4191			.4763	.4191
12	.4191	.3429	.4763			.381	.5335
13	.381	.3048	.5716			.4191	.5335
14	.4572		.6668				.4763
15	.4954		.5335				.381
16	.5144		.4763				.4954
17	.4763		.4572				.5335
18	.9907		.4954				.5716
19	.9526		.724				.7621
20	.8954		.6668				.8573
21	.8573		.7621				.9526
22	.7621		.8383				.6668
23	.5716		.6859				.4763
24	.4763	.4763		.5335			
Max	1.3336	1.3146	.8383	.7621	.9431	.5716	.9526
Min	.381	.3048	.4191	.3429	.5335	.381	.381
Avg	.7224	.7036	.5979	.5697	.7208	.462	.5879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 206 / 11 kv GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572			
2		.0572			
4		.0381			
5		.0381			
6		.0572			
7		.0572			
8		.0572	.0572		
9		.0572	.0572		.0572
10	.0572	.0572	.0572	.0381	.0572
11	.0572		.0572	.0572	.0572
12	.0572		.0572	.0572	.0572
13	.0572		.0572	.0572	.0572
14	.0572		.0572		.0572
15	.0572		.0572		.0572
16	.0572		.0572		.0572
17	.0572				
18	.0572				.0572
19	.0572				.0762
20	.0572				.0572
21	.0572				.0572
22	.0572				.0572
23	.0572				.0572
24		.0381			
Max	.0572	.0572	.0572	.0572	.0762
Min	.0572	.0381	.0572	.0381	.0572
Avg	.0572	.0515	.0572	.0524	.0586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 208 / SULTANABAD AG SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429		.362			.3429
2	.3429	.381		.381			.381
3	.4191	.4191		.4763			.4763
4	.4763	.4382		.5716			.5716
5	.5144	.4763		.6668			.7621
6	.5716	.5716		.7811			.724
7	.5906	.4763		.6859			.5716
8	.4572	.362		.4001	.4954		.4763
9	.381			.3429	.381		
10	.3048		.3239		.3429	.2858	.2667
11	.2286	.1905	.1715			.4763	.4763
12	.1905		.1524			.362	.4763
13	.1524	.2667	.1524			.3239	.3429
14	.1905		.1905			.3048	.3239
15	.1905		.1715			.3239	.362
16	.2286		.2286			.381	.4001
17	.2667		.2096			.4191	.4191
18	.3048		.3239			.3429	.4382
19	.381		.4191			.4763	.3429
20	.3429		.381			.5716	.2858
21	.381		.2858			.381	.2286
22	.4191						.1905
23	.3048		.2667			.2286	.2096
24	.2858	.2858		.2286			.1905
Max	.5906	.5716	.4191	.7811	.4954	.5716	.7621
Min	.1524	.1905	.1524	.2286	.3429	.2286	.1905
Avg	.3429	.3828	.2521	.4896	.4064	.3752	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 201 / 11 KV SILLEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0476		.5487		.6401	.6001
2	.0476		.5487		.6401	.6001
3	.0476		.5487		.6401	.6859
4	.0476		.6401		.7316	.9431
5	.0953		.7316		.9145	1.0288
6	.0953		.8954		1.1888	1.2003
7	.0476		1.0745		1.2536	1.286
8	.0476		.0476		.0476	.0953
9	.0476		.0476		.0476	.0476
10	.6001		.0476		.0476	.0476
11		.823	.0476	.0476	.0476	.0476
12		.9145	.0476			.0476
13		.8954		.0476		.0476
14				.0476		.0476
15		.7316		.0476		.0476
16		.9145		.0476	.0476	
17		.7316		.0476	.0476	
18		.0476		.0476	.0476	.0476
19		.0476		.0476	.0476	.0476
20		.0476		.0476	.0476	.0476
21		.0476		.0476	.0476	.0476
22		.6401		.7316	.7716	.0476
23		.6401		.6401	.6001	
24	.0476		.5487		.6401	.6001
Max	.6001	.9145	1.0745	.7316	1.2536	1.286
Min	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.1065	.5401	.4442	.1540	.4248	.3624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 202 / 11KV MALUNJA (BK) AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867		.0953		.0476	.0476
2	.1867		.0953		.0476	.0476
3	.2801		.0953		.0476	.0476
4	.2801		.0953		.0476	.0476
5	.3658		.0953		.0953	.0476
6	.3658		.1429		.0953	.0953
7	.3658		.1429		.0953	.0953
8	.0953		.1429		.0953	.0953
9	.0953		.0953		.0953	.0953
10	.0476		.6401		.7316	.5335
11		.0476		1.0745	.6859	.7716
12		.0476		.8954	1.0288	.8573
13		.0476		.6401	1.0288	.8573
14		.0476		.823	.9431	
15		.0476		.823	.8573	.7716
16		.0476		.8954	.7716	.7716
17				.8954	.8573	.8573
18				.0476	.0476	.0953
19		.0953			.0953	.0953
20		.0953			.0953	.0953
21		.0953			.0953	.0953
22		.0953			.0476	.0953
23		.0953		.0476	.0476	.0476
24	.1867		.0953		.0476	.0476
Max	.3658	.0953	.6401	1.0745	1.0288	.8573
Min	.0476	.0476	.0953	.0476	.0476	.0476
Avg	.2233	.0693	.1578	.6824	.3353	.2874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 203 / 11 KV GAJGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953		.2229		.2286	.2858
2	.0953		.2286		.2286	.2286
3	.0953		.2286		.3048	.3048
4	.0953		.2286		.3048	.381
5	.1905		.3048		.4801	.6668
6	.1905		.3906		.4801	.5335
7	.1905		.5601		.0953	.6859
8	.1905		.0953		.0953	.0953
9	.0953		.0953			.0953
10	.2572		.0953		.0953	.0953
11		.3125		.0953	.0953	.0953
12		.3125				.0953
13		.2286		.0953		.0953
14				.0953		.0953
15		.2286		.0953		.0953
16		.2286		.0953	.0953	
17		.3906		.0953	.0953	
18		.0953		.0953	.0953	.0953
19		.0953		.0953	.0953	.0953
20		.0953		.0953	.0953	.0953
21		.0953		.0953	.0953	.0953
22		.2229		.2972	.3048	.1905
23		.2229		.3048	.2858	.1524
24	.0953		.2229		.2286	.2858
Max	.2572	.3906	.5601	.3048	.4801	.6859
Min	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1446	.2107	.243	.1296	.2000	.2209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 204 / 11 KV KATEPIMPALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335		.381		.381	.381
2	.5335		.381		.381	.381
3	.5335		.381		.381	.381
4	.703		.381		.4763	.381
5	.9602		.4763		.5716	.4763
6	1.8842		.5716		.5716	
7	2.2939		.5716		.5716	.4763
8	.4763		.381		.4763	.4763
9	.381		.2858		.381	.0953
10	.1429		.8802		1.1203	.2858
11		.2858		1.3927	1.7147	1.2193
12		.0953			1.7147	1.5242
13		.1905			1.6289	1.2193
14		.1905			1.2003	1.1431
15		.1905		.6401	1.286	.7621
16		.1905		.8002	1.2955	.9907
17				.8192	1.3717	1.3717
18				.1905	.2858	.381
19				.381	.381	.381
20		.381		.4763	.4763	.381
21		.381		.4763	.4763	.381
22		.381		.4763	.4763	.381
23		.381		.381	.381	.381
24	.6249		.381		.381	.381
Max	2.2939	.381	.8802	1.3927	1.7147	1.5242
Min	.1429	.0953	.2858	.1905	.2858	.0953
Avg	.8243	.2667	.4610	.6034	.7659	.6188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 205 / 11 KV SHILLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.5144		.5144	.5144
2	.5144		.5144		.5144	.5144
3	.7888		.7888		.8059	.6001
4	1.0974		1.0745		1.0974	.7716
5	1.2136		1.2803		1.307	1.1145
6	1.4003		1.4937		1.4937	1.4575
7	1.2136		1.4003		1.4937	1.3717
8	1.2136		1.307		1.2803	1.2003
9	.9145		1.0974		1.0974	.9431
10	.7716		.7164		.8954	.7716
11		.6268		.6135	.6001	.6859
12		.5258			.7716	.5144
13		.5144		.5144		.5144
14				.6001		.5144
15		.5144		.6135		.5144
16		.6135		.6135	.6859	
17				.7164	.7716	
18				.9145	.8573	.8573
19		1.1203		1.0974	1.1145	1.0288
20		1.2136		1.2136	1.0288	.9431
21		.9145		.823	.7716	.8573
22		.7164		.7164	.6001	.6859
23		.5258		.6135	.5144	.5144
24	.5144		.5144		.5144	.5144
Max	1.4003	1.2136	1.4937	1.2136	1.4937	1.4575
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.9233	.7286	.9729	.7542	.8919	.7911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 206 / 11 KV Shahapur AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0476		.1867		.2801	.2572
2	.0476		.1867		.2801	.2572
3	.0476		.1867		.2801	.2572
4	.0476		.2801		.3734	.3429
5	.0476		.3658		.3734	.5144
6	.0953		.4572		.3658	.6859
7	.0953		.695		.3658	.7716
8	.0953		.0953		.0953	.0953
9	.0953		.0953		.0476	.0476
10	.2572		.0476		.0476	.0476
11		.3658		.0476	.0476	.0476
12		.3658				.0476
13		.2801		.0476		.0476
14						.0476
15		.2801				.0476
16		.2743			.0476	.0476
17		.3658			.0476	.0476
18		.0476			.0476	.0476
19					.0953	.0476
20		.0476		.0953	.0953	.0476
21		.0476		.0476	.0476	.0476
22		.1867		.2801	.2572	.1429
23		.1867		.2801		.2572
24	.0476		.1867		.2801	.2572
Max	.2572	.3658	.695	.2801	.3734	.7716
Min	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.084	.2226	.2530	.1331	.1829	.1857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 207 / 11 KV Wadali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658		.0476		.0476	.0476
2	.3658		.0476		.0476	.0476
3	.4572		.0476		.0476	.0476
4	.5487		.0476		.0476	.0476
5	.7164		.0953		.0953	.0476
6	.8954		.0953		.0953	.0953
7	.8059		.0953		.0953	.0953
8	.0953		.0476		.0953	.0953
9	.0953		.0476		.0476	.0953
10	.0476		.4668		.5487	.8573
11		.0476		.7316	.6859	.6859
12		.0476		.5487	.6859	.8573
13		.0476		.4572	.8573	.8573
14		.0476		.6268	.6859	.7716
15		.0476		.7164	.6859	.6859
16		.0476		.7164	.6859	.6859
17		.0476		.7316	.6001	.7716
18		.0476		.0476	.0857	.0953
19		.0476		.0476	.0476	.0476
20		.0476		.0476	.0476	.0476
21		.0476		.0476	.0476	.0476
22		.0476		.0476	.0476	.0476
23		.0476		.0476	.0476	.0476
24	.3658		.0476		.0476	.0476
Max	.8954	.0476	.4668	.7316	.8573	.8573
Min	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.4327	.0476	.0987	.3703	.2678	.2989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 208 / 11 KV Katepimpalgaon

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.0857		.2572	.9431
2	.3429		.0857		.2572	.2572
3	.4382		.0857		.3429	.3429
4	.5373		.0857		.4477	.4287
5	.7468		.1753		.6401	.6859
6	.8402		.2686		.7468	.8573
7	.7468		.2686		.7468	.6859
8	.6535		.1867		.6401	.6001
9	.5487		.3582		.5487	.3429
10	.4287		.3582		.3582	.3429
11		.4382		.3506	.3429	.3429
12		.3429		.3429	.2572	.3429
13		.3429			.0857	.3429
14		.2572			.2572	.2572
15		.2572		.2572	.3429	.2572
16				.3506	.3429	.2572
17				.3506	.3429	.3429
18		.3506		.4477	.4287	.5144
19		.4572		.5487	.6001	.6001
20				.6535	.6001	.5144
21		.5487		.4572	.4287	.4287
22		.0857		.3506	.3429	.3429
23		.0857		.3429	.2572	.2572
24	.3429		.0857		.2572	.2572
Max	.8402	.5487	.3582	.6535	.7468	.9431
Min	.3429	.0857	.0857	.2572	.0857	.2572
Avg	.5426	.3166	.1858	.4048	.4113	.4394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 201 / 11KV JAMGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.4006	2.6406	1.1576	1.1389	1.0269	1.307
2	2.7092	2.3663	2.7092	1.1576	1.1949	1.0829	1.363
3	2.7092	2.4863	2.7778	1.1949	1.2323	1.1203	1.4003
4	2.7435	2.572	2.8292	1.1763	1.2696	1.3817	1.4937
5	2.7778	2.6578	2.9492	1.2136	1.419		1.5684
6	2.8807	2.8807	3.0693	1.307			
7	3.2579	3.1207	3.0007	1.4377			
8	1.6804	1.7924	1.406		1.7177	1.8298	1.7924
9	.4915	1.419	1.4937			1.307	1.531
10	.6859	.9896	1.1016	2.332	2.8807	3.1554	3.0693
11	.703	.8215	.9149	3.035	3.2922	3.4637	3.3608
12		.7468		3.4465	3.6008	3.6008	3.6351
13		.7095	.7095	3.1379	3.6008	3.6351	3.6008
14		.7468	.7468	3.155	3.4979	3.2407	3.4637
15	.6859	.7842	.7842	2.9664	3.3779	3.4637	3.4979
16	.7716	.8402	.9896	3.0693	3.3779	3.5151	3.6008
17	.823	.9709		3.035	3.3265	3.6008	3.7894
18	1.0117	1.2696	1.5123	1.531		1.1145	1.6057
19	1.5261	1.7924	1.8298	1.643	1.8298	1.5684	1.7177
20	1.5947	1.6057	1.4937	1.4937	1.6057	1.7147	1.7551
21	1.3375	1.5123	1.4003	1.3443	1.6617	1.7364	1.6804
22	2.4006	2.6578	1.1949	1.2696	1.4003	1.2883	1.3717
23	2.4863	2.6406	1.1203	1.1016	.9896	1.2136	1.4937
24	2.6406	2.4177	2.6063	1.1389	1.1016	1.0082	1.2136
Max	3.2579	3.1207	3.0693	3.4465	3.6008	3.6351	3.7894
Min	.4915	.7095	.7095	1.1016	.9896	1.0082	1.2136
Avg	1.8328	1.7584	1.7855	1.9247	2.1758	2.1461	2.2414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 202 / 11KV L.I.S. FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9492	2.5206	2.8121	.112	.0747	.0857	.112
2	3.0007	2.5377	2.8635	.112	.0747	.0857	.112
3	3.0007	2.572	2.915	.112	.0747	.0953	.112
4	3.0521	2.6578	2.9492	.112	.0747	.0953	.112
5	3.0864	2.7092	3.0178	.112	.0747	.0953	.1307
6	3.1722	2.7606	3.0864	.112	.0934	.1143	.1494
7	3.1207	2.9492	3.3265	.1494	.0934	.1132	.1494
8	.0686	.1494	.0934	.112	.0934	.0857	.1494
9	.0572	.112	.0934	.1307		.0686	.1307
10	.0343		.056		3.3436	3.4294	1.8861
11	.0343	.0373	.0373	2.6886	3.7723	3.7723	3.4294
12		.0373	.0373	3.5475	3.9266	3.7723	3.7409
13		.0373	.0373	3.5322	3.7037	3.8923	3.7409
14		.0373	.0373	3.4294	3.7723	3.8752	4.0295
15	.0381	.0373	.0373	3.3608	3.6523	3.8237	3.9438
16	.0381	.056	.0373	3.2407	3.858	3.9609	3.8409
17	.0343	.1494	.056	3.2922	3.9781	3.9952	3.8752
18	.0343	.112	.056	.0857	.0747	.0343	.0934
19	.0686	.168	.0934	.0934	.0934	.0566	.0934
20	.0686	.168	.1494	.0934	.0934	.0686	.0934
21	.0514	.168	.1307	.0934	.0934	.0686	.0747
22	2.452		.112	.0934	.0934	.0572	.0747
23	2.4863	2.6235	.0934	.0934	.0934	.0381	.0747
24	2.9492	2.5377	2.7949	.0934	.0747	.0857	.0373
Max	3.1722	2.9492	3.3265	3.5475	3.9781	3.9952	4.0295
Min	.0343	.0373	.0373	.0857	.0747	.0343	.0373
Avg	1.4189	1.1426	1.0385	1.0783	1.3599	1.3237	1.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 203 / 11KV NEVARGAON 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5601	.5788		2.9127	2.6578	2.4691
2	.5487	.5487	.5601		2.6749	2.7435	2.4348
3	.5658	.6173	.6535		2.692	2.7778	2.6406
4	.6001	.6859	.8215		2.692	2.8292	2.7778
5	.7373	.823	1.0082		2.7092	2.9835	2.8121
6	1.0117	.9896	1.0802		3.2236	3.1893	2.8635
7		.9896	1.0117		3.1036	3.2236	2.7606
8	.9431	.9335	1.0082		.9522	.7655	.7888
9	.6344	.7468	.8029		.7095	.4108	.7545
10	2.1605	2.3152	2.6749	.0747	.5601	.4108	.4973
11	2.5549	2.95	2.9492	.5975	.3921	.3734	.5601
12		2.9874	2.9835	.4715	.4854	.5228	.5228
13		2.9874	2.9835	.4854	.3921	.5228	.4854
14		3.062	2.9835	.4668	.4481	.4481	.5041
15	2.4863	2.8121	2.8807	.3547	.5041	.5415	.4668
16	2.572	2.8121	2.915	.5601	.5041	.5601	.4854
17	2.3663	2.5206	2.8121	.5788	.5228	.5788	.5601
18	.6173			.6722	.4481	1.0082	.5041
19	.7888	.9149		.9149	.7282	.8215	.7095
20	.8745	.9709		.8215	.6722	.7095	.6722
21	.9259	.7842		.6722	.6535	.6535	.7468
22	.703	.6722		2.452	2.8193	2.4006	2.0919
23	.5487	.6161		2.6749	3.0807	2.6139	2.332
24	.5788	.5601	.5975		2.6749	2.7263	2.452
Max	2.572	3.062	2.9835	2.6749	3.2236	3.2236	2.8635
Min	.5316	.5487	.5601	.0747	.3921	.3734	.4668
Avg	1.1375	1.4722	1.7392	.8427	1.5231	1.5197	1.4122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.0754	.056	.0373	.0187	.0187	.056
2	.1543	.0747	.056	.0373	.0187	.0187	.0934
3		.0747	.0373	.0373	.0187	.0187	.0747
4		.0747	.0373	.0187	.0187	.0187	.0747
5		.0747	.0373	.0187	.0187	.0187	.0934
6		.0747	.0187	.0187	.0187	.0187	.0934
7		.0747	.0373	.0747	.0187	.0187	.0373
8		.0373	.0373	.0187	.0187	.0373	.0373
9	.0572	.0934	.0747	.0934	.0934	.112	.112
10	.0514	.0187	.056	.0934	.0934	.0934	.1307
11	.0857	.056	.0934	.056	.0747	.2241	.0747
12		.056	.0373	.0934	.112	.1867	.0747
13			.0373	.0747	.112	.0373	.0747
14		.0373	.0373	.0373	.0373	.0373	.056
15	.0953	.0747			.1867	.0747	.056
16	.0686	.056		.112	.0934	.0747	.0934
17	.0953	.0934		.0747	.1307	.056	.1307
18		.0934	.0747	.0373	.0934	.1307	.056
19	.0343	.056	.0373	.0373	.0373	.112	.056
20	.0857	.0187	.0373	.0373	.0373	.0934	.1307
21	.056	.0187	.0373	.0373	.0187	.0747	.0187
22	.0373	.0747	.0187	.0747	.0187	.168	.0187
23	.0373	.056	.0747	.056	.0187	.0747	.0187
24	.168	.0747	.056	.0373	.0187	.0187	.0373
Max	.168	.0934	.0934	.112	.1867	.2241	.1307
Min	.0343	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0843	.0625	.0471	.0528	.0553	.0724	.0708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 205 / 11Kv KANADGAON 1PHASING SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3734	.3174	3.1741	2.8807	2.915	3.0864
2	.3086	.3921	.3734	3.1367	2.8464	2.9835	3.0178
3	.4115	.5041	.4481	3.1181	2.8807	3.0864	3.155
4	.5144	.6722	.5601	3.0994	2.9321	3.1893	3.3608
5	.6001	.7468	.6722	3.2114	2.9835	3.2922	3.3608
6	.423	.8215	.7655	3.5662	3.5151	3.3265	3.6199
7	1.2517	.7282	.7468	3.6595	3.5151	3.3265	.5068
8	.6516	.6348	.6722	.6001	.5601	.5658	.5041
9		.4668	.5788	.5228	.5041	.3429	
10		2.4863	2.6749	.3547	.2987	.3429	
11	3.1722	3.3608	3.0178	.2801		.2915	
12		3.3234	2.9835	.2241		.2915	
13		3.2301	3.5837	.2054			
14		3.3048	3.3779	.2054	.2987		
15	2.915	3.0521	3.3779	.2427	.2614	.2572	
16	2.4863	3.0521	3.1893	.2801	.2987	.2572	.2987
17	1.5775	3.0178	3.0521	.3361	.3547	.3921	.3547
18	.5487	.4108	.4294	.4481	.5415	.4458	.4108
19	.5658	.6535	.5975	.6161	.5601	.4801	.4481
20	.6516	.5975	.5788	.5601	.5228	.7282	.5601
21	.6001	.4854	.4854	.4854	.4481	.3772	.5041
22	.5144	.3921	2.7633	2.3663	2.9874	2.6578	2.7778
23	.3429	.3361	3.1741	2.6749	3.4355	2.7435	2.8635
24	.3174	.3734	.3361	3.2114	2.8292	2.9321	3.1036
Max	3.1722	3.3608	3.5837	3.6595	3.5151	3.3265	3.6199
Min	.2915	.3361	.3174	.2054	.2614	.2572	.2987
Avg	.9550	1.3923	1.6148	1.5241	1.6883	1.6011	1.8784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 206 / 11 KV NEW LIS SHANTAI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.4163	.4668	.4706	.3772	.4887
2		.2987	.4163	.4668	.4706	.4115	.5068
3		.2987	.4163	.4668	.4706	.4287	.5068
4		.3174	.4163	.4668	.4706	.4458	.5068
5		.3174	.4163	.4668	.4706	.4801	.5068
6		.3174	.4163	.4668	.4887	.4801	.5249
7		.3174	.5068	.5041	.4887	.4801	.5068
8		.4108	.4706	.4525	.4525	.4458	.4887
9		.2427	.4706	.4525	.4525	.463	.5068
10		.5041	.4706	.4525	.4887	.4973	.5068
11		.5041	.4887	.3982	.4481	.4115	.5068
12		.5228	.4706	.4344	.4481	.4115	.4706
13		.5228	.4706	.4163	.4481	.4287	.4706
14		.5228	.2534	.4344	.4481	.4287	.4706
23		.4163	.4525	.4706	.4108	.4715	.1629
24	.1991		.4163	.4668	.4706	.3772	.5041
Max	.1991	.5228	.5068	.5041	.4887	.4973	.5249
Min	.1991	.2427	.2534	.3982	.4108	.3772	.1629
Avg	.1991	.3875	.4355	.4552	.4624	.4399	.4772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 207 / 11KV BAGADI Ag 1-PHASING SINGLE PHASING
FEEDE Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3174	.3174	.7842	.7716	.7716	.7888
2	.3086	.2987	.3361	.7468	.7888	.7888	.8402
3	.3429	.3361	.3734	.7842	.8059	.823	.8916
4	.4115	.4668	.4294	.8029	.823	.823	.9945
5	.5144	.5228	.5041	1.0456	.823	.9335	1.1576
6	.6687	.5788	.5601	1.046	.9602	.8916	1.0974
7	.6344	.6348	.5788	1.0117	.9431	.9602	1.0802
8	.6001		.5415	.5228	.5144	.3734	.5228
9		.4108	.3921	.4668	.4854	.4108	
10		.7282	.9709	.3174	.3361		
11	.9945	.8775	1.0082	.2614	.2801	.2801	
12		.9335	1.0631	.2241	.2241	.2801	.2427
13		.9709	1.0117		.1867		.2614
14		.9896	1.0631	.1867	.1867		.2427
15	.7373	.9259	.9522	.112	.1867	.2054	.2427
16	.7716	.9431	.8573	.1307	.2241	.2054	.2614
17	.9259	.9431		.1867	.3018	.2427	.2801
18	.3944	.3734		.3361	.3361	.5041	.3547
19	.4973	.4481	.5228	.5228	.5041	.5601	.3734
20	.5601	.5601	.6161	.5041	.4854	.3921	.4108
21	.6535	.4108	.4481	.4854	.4854	.3921	.4668
22	.4481	.3361	.8215	.8589	.8402	.8962	.8573
23	.3921	.3174	.8215	.8402	.8589	.7888	.9088
24	.3174	.3361	.3361	.8215	.7716	.7888	.8215
Max	.9945	.9896	1.0631	1.046	.9602	.9602	1.1576
Min	.2915	.2987	.3174	.112	.1867	.2054	.2427
Avg	.5508	.5939	.6603	.5652	.5468	.5863	.6237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 201 / 11 KV BHENDALA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2388	3.0864	2.8578	3.6199	3.6199	3.5437	3.2198
2	3.2007	3.0864	2.8578	3.4484	3.6199	3.4294	3.2007
3	3.1245	3.0483	2.934	3.2388	3.6199	3.4294	3.1817
4	3.2198	3.0483	2.934	3.2198	3.6199	3.4675	3.2388
5	3.2388	3.0483	2.9721	3.5056	3.6199	3.4675	3.3913
6	3.315	3.0483	3.0483	3.6199	3.6199	3.4294	3.5056
7	.0381	.1143	.1143	.0953	.0953	.1143	.0572
8	.0381	.1143	.1143	.0572	.0953	.1143	.0953
9	.0381	.1143	.1524	.0762	.0953	.0762	.0953
10	.0762	.1143	.1524	.0762	.0953	.0762	.0762
11	.0572	.1143	.1524	.0762	.0953	.1143	.0762
12	.0953	.1143	.1143	.0953	.1143	.0572	.0762
13	.0953	.1143	.0953	.0953	.1143	.0762	.0762
14	.0953	.0953	.0572	.0953	.1143	.0572	.0762
15	.0953	.0953	.0572	.0953	.1143	.0572	.0953
16	.0953	.0953	.0762	.0953		.0572	.0953
17	.0953	.1143	.0953	.0762		.0572	.0953
18	.0953	.1143	.0953	.0953	.1143	.0762	.0953
19	.0953	.1334	.0762	.0953	.1143	.0762	.0953
20	.0953	.0953	.1143	.0953	.1334	2.0957	.0953
21	.0953	.1334	2.4577	2.8578	3.0102	2.6482	3.2388
22	3.0483	2.8578	3.2198	3.6199	3.4294	3.315	3.3722
23	3.0864	2.8959	3.4484	3.6199	3.5056	3.6389	3.4294
24	3.2388	3.0483	2.934	3.677	3.6199	3.5818	3.2579
Max	3.315	3.0864	3.4484	3.677	3.6199	3.6389	3.5056
Min	.0381	.0953	.0572	.0572	.0953	.0572	.0572
Avg	1.2463	1.2019	1.2971	1.4853	1.6627	1.5440	1.4265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 202 / 11 DHOREGAON FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	.2667	.3048	.4191	.2667	.2667
2	.362	.381	.3048	.2667	.4191	.3048	.2286
3	.362	.381	.3429	.3048	.4191	.3048	.362
4	.381	.381	.3429	.362	.4572	.3429	.381
5	.4572	.4572	.3429	.4191	.4572	.381	.4191
6	.4954	.4572	.381	.4572	.4572	.381	.4572
7	.4572	.4572	.4191	.4572	.4572	.4191	.4763
8	.4001	.4191	.381	.4191	.5335	.381	.4191
9	3.5818	.4191	3.5437	.4001	.5335	.3048	.381
10	3.8866	3.5246	3.5818	.362	.3429	.2286	.3429
11	3.8104	3.5246	3.5818	.2667	.3048	.1905	.2286
12	3.6199	3.4294	3.4675	.2286	.1524	.2096	.2286
13	3.2388	3.3913	3.3722	.2286	.1524	.2286	.2286
14	3.2579	3.4294	3.3913	.2286	.1524	.2096	.2286
15	3.2388	3.4294	3.2388	.2286	.1524	.2286	.2286
16	3.2388	3.4294	3.2579	.2286		.1905	.2286
17	.1905	.2286	.3429	3.6199		4.039	4.0009
18	.5335	.3048	.362	3.6199	3.5818	4.0581	4.039
19	.4191	.381	.3429	3.6199	3.6199	3.9819	4.0009
20		.381	.4191	3.5246	3.8104	3.8866	3.8104
21	.381	.381	.4572	3.4294	3.7723	3.7913	3.8485
22	.381	.3048	.4191	3.6199	3.6961	3.7342	3.8485
23	.381	.3048	.3429	3.6199	3.5818	3.7723	3.8485
24	.3429	.381	.3048	.362	3.6199	3.5056	3.5056
Max	3.8866	3.5246	3.5818	3.6199	3.8104	4.0581	4.039
Min	.1905	.2286	.2667	.2286	.1524	.1905	.2286
Avg	1.4678	1.2733	1.3836	1.2741	1.4133	1.4725	1.5003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 203 / 11 KV AMALNER FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1905	.1143	3.0483	3.0483	2.7816	3.2007
2	.1143	.1905	.1143	3.0293	3.0483	3.0483	3.2198
3	.1524	.1905	.1524	3.0102	3.0483	3.2007	3.1817
4	.1524	.2286	.1524	3.1055	3.0483	3.2388	3.2198
5	.2286	.2286	.1524	3.1626	3.0483	3.4294	3.315
6	.2667	.3048	.1524	3.2198	3.2388	3.4294	3.3913
7	.1905	.3048	.1905	3.2388	3.2388	3.5056	3.4294
8	.2286	.3048	.1524	3.2769	3.2388	3.1245	3.2388
9	.2286	.3048	.1524	.2286	.1905	.1524	.1143
10	.1905	.2286	.1524	.2667	.1905	.1524	.1143
11		.1905	.1905	.2286	.1524	.1524	.2286
12		.1524	.1715	.2286	.1524	.1334	.2286
13		.1143	.1524	.2286	.1524	.1524	.2286
14		.1143	.1524	.2286	.1524	.1715	.2286
15		.1143	.1524	.1905	.1524	.1715	.2667
16		.1143	.1715	.1524		.1715	.3239
17	2.7625		3.0864	.2667		.1715	.2667
18	3.0483		3.1626	.2667	.1524	.2286	.2667
19	3.0483	3.4294	3.3532	.2667	.2286	.2286	.2667
20	3.0483	3.5056	3.2579	.2667	.2286	.2667	.3048
21	3.0483	3.4294	3.2769	.2667	.1905	.2096	3.8485
22	3.0102	3.4294	3.2388	.2667	.1524	.2286	.2286
23	3.0102	3.4294	3.1436	.2667	.1524	.2096	.2286
24	3.4484	3.0102	3.3532	3.0864	.2286	.1524	.2286
Max	3.4484	3.5056	3.3532	3.2769	3.2388	3.5056	3.8485
Min	.1143	.1143	.1143	.1524	.1524	.1334	.1143
Avg	1.4617	1.0686	1.1812	1.3249	1.2470	1.1963	1.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 205 / 11kv Kokan agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2286	.2286	.362	.2858	.3429	.5525
2	.0762	.2286	.2286	.4191	.2858	.3429	.5335
3	.0762	.2286	.2667	.381	.2858	.362	.4572
4	.0953	.2286	.2667	.4001	.2858	.362	.4001
5	.0762	.2286	.2477	.4191	.2858	.3429	.4382
6	.1143	.2286	.2286	.4382	.3429	.2286	.5335
7	.1143	.2286	.2477	.4572	.3429	.1905	.5906
8	.1524	.2286	.4572	.4763	.3429	.1905	.6097
9	.1524	.2286	.743	.743	.381	.2477	1.1622
10	.1143	.3048	1.1431	1.1241	.9526	.9526	1.6194
11		.1143	1.1812	1.5432	1.1812	2.1529	1.4289
12			1.2574	.8002	1.0669	1.2003	1.2384
13		.724	1.4289	1.3336	.9335	.9526	1.1812
14		.6859	1.0288	1.3336	1.0669	1.086	1.1431
15		.6859	1.1622	1.1812	1.086	1.2955	1.0479
16		.724	1.4098	1.1812		1.3908	.7621
17	.1524	.6859	1.1622	1.1241		1.105	.6859
18	.2286	.6097	.8954	.8573	.8764	.9907	.6097
19	.2286	.5716	.5906	.8573	.4954	.8573	.6097
20	.4191	.5335	.5716	.7621	.5335	.743	.4763
21	.4191	.4191	.5525	.3429	.381	.6859	.4954
22	.2858	.4572	.4954	.4763	.381	.6668	.4763
23	.2858	.4191	.4191	.2858	.3429	.4954	.4763
24	.3048	.2286	.4191	.4001	.2858	.3048	.6478
Max	.4191	.724	1.4289	1.5432	1.1812	2.1529	1.6194
Min	.0762	.1143	.2286	.2858	.2858	.1905	.4001
Avg	.1990	.4009	.6930	.7375	.5646	.7287	.7573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 206 / 11 KV GALNEEMB AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381	.0191	.0381	.0381	.0191
2	.0191	.0381	.0381	.0191	.0381	.0381	.0191
3	.0191	.0381	.0381	.0191	.0381	.0381	.0191
4	.0381	.0381	.0381	.0191	.0381	.0381	.0191
5	.0381	.0381	.0381	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0191	.0381	.0381	.0381
9	.0191	.0381	.0572	.0191	.0381	.0381	.0191
10	1.8099		1.6004	1.7147	1.7147	1.6766	1.7337
11	2.3243	1.9624	2.1338	1.7909	1.7147	2.1529	2.5149
12	2.572	1.9624	1.7909	2.2862	2.0957	2.2862	2.4768
13	2.572	2.0957	1.6194	2.3815	2.1338	2.3243	2.4387
14	2.572	2.0957	1.5242	2.3815	2.0957	2.3434	2.4768
15	2.572	2.0576	1.3717	2.3243	2.0386	2.3815	2.5149
16	2.5149	2.0576	1.3336	2.3243		2.4196	2.5339
17	2.5149	2.0195	1.7718	2.3243		2.3815	2.5339
18	.0953	.0381	.0191	.0381	.0762	.0381	.0381
19	.0381	.0762	.0191	.0381	.0381	.0191	.0381
20	.0381	.0572	.0381	.0381	.0381	.0191	.0381
21		.0381	.0381	.0381	.0381	.0191	.0381
22	.0381	.0381	.0191	.0381	.0381	.0191	.0381
23	.0381	.0381	.0191	.0381	.0381	.0191	.0381
24	.0191	.0381	.0381	.0191	.0381	.0381	.0191
Max	2.572	2.0957	2.1338	2.3815	2.1338	2.4196	2.5339
Min	.0191	.0381	.0191	.0191	.0381	.0191	.0191
Avg	.8689	.6486	.5708	.7502	.5655	.7700	.8216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 207 / 11Kv Lakhmapur Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0767		2.0957	.1334	.2286		.1524
2	2.191		2.0957	.1524	.2286	.1905	.1524
3	2.2481		2.1338	.1524	.2286	.1905	.1715
4	2.3624		2.1338	.1715	.2667	.2286	.1905
5	2.4768		2.21	.1715	.3048	.2286	.2286
6	2.553		2.4387	.2286	.2667	.2286	.2667
7	2.6482		2.7054	.2667	.3048	.2286	.3048
8	2.5911		2.6292	.2286	.3048	.2286	.2667
9	.2096		.2286	2.9721	3.4294	3.1626	3.1626
10	.1905		.1905	3.0102	3.4294	3.3532	3.2388
11	.1143		.1524	3.0674	3.4294	3.3913	9.5069
12	.1524			3.0483	3.3532	3.4294	3.0483
13	.1524			3.0483	3.2388	3.4675	3.0483
14	.1524		.2667	2.8959	3.315	3.2198	3.0864
15	.1524		.2096	2.8959	3.3532	3.2769	3.0483
16	.1524			2.8959		3.4294	3.0483
17	.1905		.1524	.1524		.1715	.1905
18			.1715	.2667	.1905	.1905	.1905
19			.1905	.2667	.1143	.2096	.1905
20		.1905	.1715	.2667	.2286	.2286	.3048
21		.1905	.1715	.2667	.2286	.2096	.2667
22		.1905	.1905	.2286	.2286	.2096	.2286
23		.1905	.1715	.2286	.1905	.1905	.2286
24	.1905		.1905	.1524	.2286	.1905	.1715
Max	2.6482	.1905	2.7054	3.0674	3.4294	3.4675	9.5069
Min	.1143	.1905	.1524	.1334	.1143	.1715	.1524
Avg	1.1558	.1905	.9952	1.1320	1.2314	1.2980	1.4456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 208 / 11 kv MAUJABAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	.4191	.2667	.4572
2				.2667	.6097	.2286	.4763
3				.3429	.4191		.4763
4				.381	.6097		.5335
5				.4191	.6097		.6097
6				.5144	.8573		.743
7				.6859	.8573	.3429	.8383
10	.3429	.381	.2286				
11		.381	.381				
12	.5335		.5525				
13	.4763		.724				
14	.5335		.6287				
15	.4191		.6478				
16	.5335	.381	.6859				
17	.5335	.381	.6478				
21					.3429		
22			.2667	.381	.3429	.5144	.4763
23			.3429	.381	.4191	.5144	.4763
24				.381	.381	.381	.4954
Max	.5335	.381	.724	.6859	.8573	.5144	.8383
Min	.3429	.381	.2286	.2667	.3429	.2286	.4572
Avg	.4818	.381	.5106	.4096	.5334	.3747	.5582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 209 / 11 KV BHIVDHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1241	1.2384	1.1812	1.1241	1.2384	1.1812	1.1812
2	1.1431	1.2384	1.1812	1.2765	1.2384	1.1812	1.1622
3	1.2193	1.2384	1.2193	1.3146	1.2384	1.2193	1.3146
4	1.3717	1.7528	1.2955	1.4098	1.7147	1.2574	1.448
5	1.6575	2.191	1.448	1.6956	2.1529	1.2955	1.7337
6	2.0957	2.4577	2.0195	2.0957	2.4387	1.9243	2.6863
7	2.3243	2.4768	2.6292	2.6482	2.5149	2.4387	2.553
8	2.1719	2.4387	2.4006	2.3053	2.4006	2.191	2.3434
9	1.8099	2.2291	2.0957	1.7909	2.3624	1.8671	1.6956
10	1.5432	1.2384	1.3336	1.5623	2.0005	1.6004	1.467
11	1.2955	.9526		1.3336	1.3717	1.2193	1.3717
12	1.1812	.9907	1.2384	1.2384	1.2193	1.1622	1.1431
13	1.1431	1.0669	1.1431	1.3336	1.086	.9907	1.1431
14	.9907	1.0288	.6668	1.1431	1.0669	1.0669	1.1431
15	.9907	.9907	1.105	1.1812	1.0479	1.1241	1.5623
16	1.2574	.9907	1.1812	1.1812		1.2193	1.6194
17	1.3717	1.105		1.3146		1.4861	1.7528
18	1.829	1.2193	1.7337	2.0005	1.5813	1.6004	1.8099
19	2.1719	1.3336	1.9243	2.0195	1.8671	2.3053	2.191
20	2.4006	1.7147	2.2672	2.2291	2.2291	2.2672	2.572
21	1.8861	1.7147	1.7528	2.4006	1.829	1.6956	2.0005
22	1.3336	1.5623	1.5242	1.7528	1.3717	1.5051	1.5623
23	1.3336	1.2955	1.2003	1.3336	1.2955	1.3908	1.3146
24	1.1431	1.2955	1.2193	1.1431	1.2955	1.1812	1.2574
Max	2.4006	2.4768	2.6292	2.6482	2.5149	2.4387	2.6863
Min	.9907	.9526	.6668	1.1241	1.0479	.9907	1.1431
Avg	1.5329	1.4900	1.5346	1.6178	1.6619	1.5154	1.6678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 201 / NARAYANPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.112	.112	1.1191	.8002	1.6278	1.1309
2	.1143	.112	.112	1.1869	.7907	1.6956	1.1309
3	.1143	.1307	.112	1.3565	.7907	1.6617	1.0829
4	.1143	.1494	.132	1.3717	.7907	1.8652	1.1109
5	.1334	.1494	.1509	1.5261	.8192	1.9669	1.1483
6	.1334	.168	.1698	1.5729	.9335	2.0517	1.2826
7	.1334	.168	.1509	1.5432	1.1431	2.1628	1.302
8	.1334	.1494	.1307	.1029	.1494	.1307	.1334
9	.1143	.112	.112	.1307	.0572	.0934	.1334
10	.8288	1.7551	.9795	.1334	.0762	.0934	.1132
11	1.7166	1.2016	2.0538	.0953	.0747	.056	.0762
12	1.749		2.5766	.1143	.1307		.0953
13	1.8461	1.0501	2.5206	.0953	.0747		.0572
14	1.749	1.1208	1.166	.0953	.056		.0572
15	1.6518	1.1271	1.9669	.0762	.0943	.056	.0762
16	1.4737	1.04	1.8023	.1524	.0747	.056	.0762
17	1.3765	.9997	1.6448		.0934	.0747	.0762
18	.0762	.0747	.0747	.0572	.0934	.0747	.0762
19	.1307	.0934	.0943	.0953	.0934	.0934	.1143
20	.1307	.132	.112	.1143	.112	.1132	.112
21	.1307	.132	.112	.1143	.112	.0943	.0953
22	.1307	.1307	1.153	.1524	1.6991	.9896	
23	.1307	.112	1.2378	.8383	1.5893	1.0804	1.7976
24	.1143	.112	.112	1.2209	.8192	1.4746	1.1107
Max	1.8461	1.7551	2.5766	1.5729	1.6991	2.1628	1.7976
Min	.0762	.0747	.0747	.0572	.056	.056	.0572
Avg	.5975	.4492	.7829	.5767	.4778	.8339	.5387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 202 / RANJANGAON S.P.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0538	2.4025	2.2405	2.4086	2.2405	2.4272
2		2.0538	2.4025	2.2405	2.4086	2.1658	2.3525
3	.415	2.2405	2.4394	2.5766	2.4086	2.4025	2.2916
4	.4527	2.5393	2.5503	2.6886	2.4646	2.5393	2.3285
5	.4527	2.5206	2.6886	2.7633	2.5393	2.7633	2.4272
6	2.4272	2.6139	3.0178	2.8006	2.4086	3.062	2.8753
7	2.6326	2.6139	2.9047	2.8753	2.2405	2.8006	2.7633
8	2.5766	2.3899	2.6783	2.6886	2.2068	2.4646	2.6406
9	2.6326	2.2405	2.6406	2.4646	2.4272	2.3525	2.452
10	2.4086	2.0165	2.5766	2.3899	2.3525	2.2405	2.3899
11	2.2965	2.1658	2.2405	2.1845	2.2965	2.2405	2.2405
12	2.3525	2.1437	2.3525	1.9044	2.3525	2.2546	2.2592
13		2.0538	2.3525	1.9791	2.2405	2.2177	2.2592
14		2.2032	2.3899	2.0725	2.2405	2.2177	2.2965
15	2.4272	2.3152	2.3899	2.1845	2.2032	2.2314	2.3152
16	2.5019	2.3152	2.3899		2.3899	2.3655	2.268
17	2.5393	2.1068	2.3525		2.5393	2.5393	2.5393
18	2.3152	2.2546	2.3899	1.9044	2.4272	2.5766	2.4272
19	2.4272	2.6513	2.6513	2.6886	2.5019	2.6406	2.6513
20	2.7633	2.6783	3.0994	3.0807	3.062	3.1687	2.9874
21	2.6886	3.2065	3.0994	2.9874	2.9874	3.131	3.1927
22	2.6886	3.0178	2.9127	2.7446	2.726	3.0178	3.0247
23	2.4646	2.6886	2.6513	2.5766	2.6513	2.6699	2.6886
24	2.5206	2.4272	2.5206	2.5019	2.4646	2.2405	2.5652
Max	2.7633	3.2065	3.0994	3.0807	3.062	3.1687	3.1927
Min	.415	2.0165	2.2405	1.9044	2.2032	2.1658	2.2405
Avg	2.1992	2.3963	2.5872	2.4790	2.4562	2.5226	2.5276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 203 / PIMPARKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3361	.3395	.3361	.3734	.3361	.3547
2	.3547	.3734	.3361	.3734	.3547	.3734	.3547
3	.3547	.4108	.3547	.4108	.3547	.3734	.3361
4	.3921	.4108	.3921	.4481	.4294	.4108	.3921
5	.4854	.4481	.4568	.4854	.4668	.4481	.4481
6	.5041	.4108	.4904	.5228	.4668	.4854	.5415
7	.4854	.4294	.5281	.4854	.4668	.4668	.5041
8	.5041	.4108	.4904	.4294	.4481	.4668	.4904
9	.4854	.4481	.4715	.4108	.4481	.4481	.4338
10	.4481	.415	.4527	.3921	.3734	.4108	.4187
11	.4294	.415	.4481	.3921	.3547	.3772	.3734
12	.3921	.2801	.4294	.3547	.3361	.3772	.3547
13	.3547	.2427	.3547	.3547	.3361	.3361	.3547
14	.3361	.2241	.2427	.3547	.3361	.3361	.3361
15	.3361	.3547	.3734	.3547	.3547	.3361	.3734
16	.3361	.2987	.3734	.4108	.5228	.4108	.3734
17	.3921	.3734	.3734	.4108	.2614	.4481	.4668
18	.4481	.4668	.4481	.4481	.4481	.4481	.4854
19	.4108	.5093	.4668	.4854	.5041	.4854	.4854
20	.4854	.4904	.4668	.5041	.5041	.5093	.4854
21	.4294	.4904	.4294	.4294	.4527	.4715	.4668
22	.4108	.4338	.3921	.4108	.415	.415	.4108
23	.3734	.3921	.3734	.3921	.3734	.3961	.3921
24	.3734	.3361	.3734	.3547	.3547	.3361	.3734
Max	.5041	.5093	.5281	.5228	.5228	.5093	.5415
Min	.3361	.2241	.2427	.3361	.2614	.3361	.3361
Avg	.4123	.3917	.4107	.4146	.4057	.4126	.4169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 204 / JOGESHWARI
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6244	1.307	1.5339	1.4937	1.587	1.307	1.531
2	1.587	1.2323	1.5497	1.419	1.587	1.307	1.4937
3	1.6244	1.419	1.4969	1.475	1.6244	1.4937	1.5123
4	1.6244	1.4937	1.5684	1.6057	1.643	1.7924	1.5912
5	1.7924	1.6057	1.6804	1.6804	1.8484	1.8671	1.7558
6	1.9605	1.6617	1.8296	1.8671	1.9605	1.9978	1.9035
7	1.9044	1.7551	1.9616	1.9605	1.9044	1.7737	1.773
8	1.7737	1.7551	1.7918	1.7551	1.7364	1.6244	1.7164
9	1.7737	1.4003	1.8296	1.587	1.587	1.4003	1.6787
10	1.587	1.3817	1.7353	1.5497	1.587	1.5497	1.5123
11	1.4003	1.4563	1.6804	1.4003	1.419		1.5123
12	1.4937	1.5684	1.7737	1.2136	1.251	1.4377	1.4003
13	1.587	1.4969	1.587	1.4003	1.307	1.4045	1.4003
14		1.46	1.587	1.419	1.4003	1.4003	1.5123
15		1.5278	1.5497	1.419	1.363	1.4003	1.5684
16	1.7737	1.587	1.587	1.4003	1.587	1.46	1.587
17	1.7737	1.5524	1.587		1.5497	1.5524	1.6057
18	1.5497	1.5339	1.363	1.587	1.4003	1.475	1.587
19	1.7737	1.587	1.4937	1.643	1.587	1.6991	1.587
20	1.9418	2.037	1.9605	1.9605	1.7737	2.1068	1.9418
21	1.9605	1.9805	1.9978	1.8111	1.9231	2.0182	2.0911
22	1.7918	1.9605	1.9418	1.7737	1.8858	1.9427	1.8671
23	1.7364	1.7551	1.7737	1.7364	1.7364	1.8111	1.7737
24	1.6057	1.4937	1.587	1.6804	1.587	1.4937	1.587
Max	1.9605	2.037	1.9978	1.9605	1.9605	2.1068	2.0911
Min	1.4003	1.2323	1.363	1.2136	1.251	1.307	1.4003
Avg	1.7109	1.5837	1.6853	1.6016	1.6181	1.6224	1.6454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 205 / 11 kv NANDEDA gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.2323	1.3121	1.307	1.307	1.2323	1.2752
2	1.1576	1.2323	1.2936	1.2323	1.307	1.307	1.2567
3	1.1576	1.2883	1.2936	1.419	1.363	1.475	1.2567
4	1.2071	1.7924	1.386	1.6617	1.4377	1.6057	1.386
5	1.4563	1.7924	1.6448	1.7924	1.8484	1.6804	1.7177
6	1.8484	1.8671	1.9774	1.8671	1.9605	2.0165	2.1285
7	1.9605	2.0351	1.9978	2.0538	2.0725	1.9605	2.0559
8	1.7737	1.8111	1.9231	1.8484	1.9044	1.9605	1.8296
9	1.5684	1.5497	1.6804	1.6057	1.5497	1.6804	1.6787
10	1.2883	1.475	1.531	1.419	1.4377	1.4003	1.475
11		1.2071	1.307	1.2936	1.3256	1.2449	1.0534
12		1.2803	1.1203	1.0903	1.2323	1.2936	1.2382
13		1.086	1.1576	1.1088	1.2323	1.2567	1.1827
14		1.0456	1.1763	1.2012	1.1763		1.1827
15	1.2323	.8078	1.2883	1.2012	1.0269	1.386	1.1827
16	1.3443	1.0719	1.2136	1.1273	1.1016	1.2936	
17	1.4377	1.2883	1.2136		1.2136	1.3491	1.46
18	1.643	1.419	1.2883	1.4415	1.419	1.5524	1.6991
19	1.7551	1.587	1.7364	1.7002	1.6617	1.8484	1.8484
20		1.9418	1.9418	1.9044	1.7364	2.0911	1.885
21	1.643	1.6787	1.6991	1.643	1.6244	1.7551	1.7177
22	1.4563	1.5339	1.5497	1.4937	1.4937	1.531	1.4937
23	1.3443	1.4415	1.4377	1.4003	1.3817	1.4003	1.4003
24	1.363	1.307	1.3676	1.3817	1.3443	1.307	1.5497
Max	1.9605	2.0351	1.9978	2.0538	2.0725	2.0911	2.1285
Min	1.1576	.8078	1.1203	1.0903	1.0269	1.2323	1.0534
Avg	1.4668	1.4488	1.4807	1.4867	1.4649	1.5490	1.5197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 206 / 11 KV Waluj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6644	1.6057	1.6991	1.4937	1.6827	1.4632	1.6632
2	1.6644	1.6804	1.6804	1.7924	1.6827	1.7924	1.6078
3	1.7741	2.0538	1.6632	2.0538	1.7193	2.0538	1.6448
4	1.8665	2.2405	1.7924	2.2405	1.9589	2.3339	1.7924
5	2.2177	2.5393	2.1948	2.5206	2.4025	2.6406	2.2592
6	2.5503	2.6139	2.6612	2.9874	2.7536	2.7446	2.9047
7	2.6797	2.6326	2.7538	2.7633	2.6057	2.7633	2.8104
8	2.6427	2.5206	2.6217	2.6513	2.3655	2.6326	2.6699
9	2.3655	1.9978	2.4143	2.3712	2.1622	2.3525	2.3388
10	2.1068	1.8861	2.1313	2.1807	1.9404	2.1098	1.9791
11	1.9044	1.773	1.8671	1.848	1.9231	1.773	1.8665
12	1.9044	1.5339	1.8298	1.701		1.6991	1.6448
13	1.8671	1.4415	1.7551	1.5729	1.7924	1.6975	1.6461
14	1.7924	1.3717	1.6991	1.6632	1.6617	1.7551	1.7741
15	1.7177	1.475	1.7551	1.701	1.7364	1.8298	1.848
16	1.6804	1.587	1.8298	1.7375	1.6991	1.9605	1.922
17	1.9044	1.9035	1.9605		2.0538	2.1125	2.0883
18	2.4459	2.2405	2.1879	2.2731	2.4272	2.3954	2.3655
19	2.3152	2.4331	2.3339	2.4949	2.5019	2.5503	2.4579
20	2.1658	2.5274	2.3899	2.5688	2.4832	2.7538	2.6057
21	2.0538	2.2068	2.0351	2.2546	2.2032	2.3525	2.1622
22	1.8484	1.9589	1.9231	1.9959	1.8858	1.9605	1.9978
23	1.7177	1.8111	1.7737	1.8296	1.8484	1.8107	1.8858
24	1.701	1.6804	1.7364	1.7364	1.7002	1.4937	1.7177
Max	2.6797	2.6326	2.7538	2.9874	2.7536	2.7633	2.9047
Min	1.6644	1.3717	1.6632	1.4937	1.6617	1.4632	1.6078
Avg	2.0229	1.9881	2.0287	2.1057	2.0517	2.1263	2.0689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 207 / 11 KV Ghanegaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.9335	.506	.1307	.1334	.2054	.2614
2	.5093	.8962	.506	.1307	.1334	.2614	.2614
3	.5093	.9335	.5218	.1867	.1334	.2987	.2801
4	.5093	1.0269	.5535	.2241	.1524	.2987	.3174
5	.6481	1.0456	.6316	.2054	.1905	.3361	.3734
6	.7907	1.1203	.7293	.2614	.2667	.3921	.4715
7	1.0562	1.1389	.7956	.3174	.2858	.4108	.4481
8	.3429	.2801	.2987	.1867	.2286	.4481	.3547
9	.2858	.2614	.2801	.3361	.2477	.3174	.3174
10	.2477	.2641	.2241	.5921	.7362	.9335	.9448
11	.1677	.2075	.1867	.7209	1.0269	1.186	1.3927
12	.1677	.2054	.168	1.0978	.9896	1.2334	1.6712
13	.1829	.2054	.1494	1.1142		1.3283	1.6385
14	.1829	.2075	.1307	1.1797			1.3603
15	.1829	.2054	.1494	1.3108		1.3426	1.2955
16	.1829	.2075	.1494		1.643		1.491
17	.2134	.2241	.1307		1.7364	1.442	1.4419
18	.2134	.2452	.1494		.168	.2987	.2477
19	.2743	.2263	.168		.2054	.3395	.3048
20	.3174	.2263	.168	.2096	.2987	.3961	.3239
21	.3174	.2075	.168	.1905	.2614	.3547	.2858
22	.5376	.4428	.168	.1905	.2427	.3142	.2286
23	.6348	.506	.1307	.1524	.2241	.2987	.1981
24	.6481	.7468	.5376	.1307	.1334	.1867	.2801
Max	1.0562	1.1389	.7956	1.3108	1.7364	1.442	1.6712
Min	.1677	.2054	.1307	.1307	.1334	.1867	.1981
Avg	.4042	.4985	.3167	.4434	.4494	.5738	.6746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 208 / 11 KV East West Industri SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5601	.6413	.4108	.4904	.5228	.6722
2	.5281	.5975	.6413	.4481	.4904	.5228	.7167
3	.5281	.5228	.5658	.4481	.4527	.4755	.7167
4	.4527	.5975	.5658	.5228	.415	.5601	.679
5	.4527	.6348	.5975	.5601	.4904	.5975	.6413
6	.415	.6722	.5601	.6036	.5658	.5601	.679
7	.3772	.6348	.5975	.5601	.679	.4854	.679
8	.3772	.7842	.6722	.7468	.8299	.7842	.8299
9	.5281	1.0829	.823	1.0082	1.0608	1.307	1.1317
10	.6036	1.0456	.8676	1.0974	1.3535	1.307	.9431
11	.6722	1.4003	.9335	1.2437	1.358	1.1949	1.0082
12	.7095	1.1694	.9335	1.2437	1.1694	1.5844	.9877
13	.7842	1.2449	.8962	1.0608	1.1203	1.5466	.679
14	.7468	1.1317	.9335	1.1706	1.307	1.531	1.3169
15	.8215	1.1694	.9335	1.134	1.2323	1.531	1.4118
16	.6348	1.1694	.8962	1.2437	1.2323	1.4937	1.448
17	.5975	1.0829	.8962	1.134	1.1949	1.3957	1.2308
18	.4481	.7842	.6722	.7095	.6722	1.1694	.9511
19	.5228	.7468	.5975		.7468	.7167	.7167
20	.6722	.7842	.4481	.4527	.6348	.7095	.7167
21	.5601	.7468	.4481	.6036	.7468	.7095	.7167
22	.5975	.7167	.6348	.6413	.6348	.6722	.5975
23	.6036	.679	.4854	.5281	.6722	.6036	.6348
24	.7545	.5601	.679	.4108	.4904	.5487	.679
Max	.8215	1.4003	.9335	1.2437	1.358	1.5844	1.448
Min	.3772	.5228	.4481	.4108	.415	.4755	.5975
Avg	.5814	.8549	.7050	.7818	.8350	.9387	.8660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 201 / 11 KV GAJGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0819	.2667	.2572	.2667	.2622
2	.1143	.0953	.0819	.2667	.2801	.3048	.3277
3	.1143	.1143	.0819	.3429	.3429	.381	.3605
4	.1524	.1334	.0819	.381	.3429	.4763	.3932
5	.1509	.1524	.0819	.381	.4287	.5716	.3932
6	.1524	.1905	.0819	.4382	.5144	.6668	.4752
7	.132	.1715	.0819	.5716	.6344	.8002	.4915
8	.1143	.1143	.0983	.0762		.1524	.5243
9	.0953	.0953	.1143	.0762	.0953	.1143	.0655
10	.381	.1802	.4191	.0566	.0762	.0655	.0191
11	.4763	.3277	.5144	.0572	.0572	.0492	.0762
12	.5716	.373	.4763	.0572	.0381	.0655	.0381
13	.5335	.3932	.381	.0572	.0381	.0492	.0381
14	.4954	.4409	.381	.0572	.0381	.0492	
15	.5335	.426	.381	.0754	.0381	.0655	.0381
16	.5335	.4424	.381	.0762	.0572	.0655	.0381
17	.4954	.4588	.381	.0754	.0572	.0633	.0381
18	.0762	.1017	.0762	.0953	.0762	.0655	.0762
19	.1143	.0655	.0762	.0953	.0953	.0819	.0953
20	.1143	.0819	.0953	.1143	.1143	.0655	.0953
21	.0953	.0655	.1334	.1334	.1143	.0983	.0953
22	.0953	.0655	.1524	.1334	.2286	.1638	.1905
23	.0953	.0655	.1715	.2103	.2286	.2374	.2858
24	.0943	.0953	.0983	.2286	.2229	.2667	.1966
Max	.5716	.4588	.5144	.5716	.6344	.8002	.5243
Min	.0762	.0655	.0762	.0566	.0381	.0492	.0191
Avg	.2428	.1977	.2043	.1801	.1903	.2161	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 202 / 11 kv RANJANGAON POL AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5716	.5571	.3429	.4763	.381	.3932
2	.5144	.5716	.5898	.3429	.4763	.381	.4752
3	.5487	.6287	.5571	.381	.5281	.381	.4915
4	.6001	.6859	.5898	.381	.5335	.4191	.5571
5	.6706	.7621	.6554	.4191	.5093	.4191	.5735
6	.7202	.8383	.6882	.4191	.4763	.4763	.4915
7	.7716	.9145	.7209	.381	.4191	.4191	.426
8	.4763	.3429	.2949	.3429	.381	.381	.4752
9	.381	.2858	.3429	.1905	.381	.3429	
10		.2294	.2858	.4287	.6668	.426	
11		.1966	.2286	.5144	.8002	.4915	.4572
12		.1966	.2286	.6001	.8573	.4915	.4382
13		.1966	.2286	.583		.426	.4382
14		.2294	.1905	.5487		.4915	
15		.2622	.1905	.5144		.3932	.6668
16		.2458	.1905	.5144			.7621
17		.2294	.1905				.7811
18		.2949	.1905	.3772			.3429
19	.381	.3277	.2286	.4715	.4763	.2949	.381
20	.4191	.3277	.2667	.4715	.4763	.2713	.381
21	.4763	.426	.2667	.4715	.4763	.3277	.381
22	.5716	.6226	.381	.4763	.381	.3932	.381
23	.5716	.6554	.4001	.4191	.381	.426	.381
24	.5144	.5716	.5407	.3429	.4763	.381	.3932
Max	.7716	.9145	.7209	.6001	.8573	.4915	.7811
Min	.381	.1966	.1905	.1905	.381	.2713	.3429
Avg	.5421	.4422	.3752	.4319	.5096	.4007	.4794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 203 / 11 KV GAWALI SHIVARA

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3429	.2949	.3292	.3326	.3048	.2622
2	.3326	.4001	.3113	.381	.3696	.3429	.2949
3	.462	.4763	.3113	.4024	.462	.4572	.3277
4	.5544	.5716	.3277	.4572	.5487	.5716	.4752
5	.6401	.6668	.426	.5335	.6468	.6668	.6274
6	.7316	.724	.4588	.5716	.7392	.724	.4915
7	.6767	.6859	.3277	.5906	.6767	.6859	.4915
8	.6468	.5906	.5571	.5487	.5914	.6097	.426
9	.499	.4763	.3292	.4382	.462	.4954	.3932
10	.4191	.2622	.2667	.3696	.381		.3292
11	.3429	.2294	.2286	.2772	.2667		.1829
12	.2858	.1802	.2477	.2587	.2286		.2012
13	.2477	.1802	.2378	.2241	.1905		.2012
14	.2477	.1966	.2477	.1867	.1905		
15	.3048	.2294	.2286	.2054	.1905		.2195
16	.381	.213	.1905	.2054	.2286		.2561
17	.4763	.2294	.2858	.2241	.2858		.2926
18	.6097	.3475	.439	.3704	.381		.3292
19	.6668	.3277	.4024	.462	.4954		.3658
20	.5716	.3605	.4191	.4572	.4763		.3109
21	.4763	.3932	.381	.3658	.381		.2561
22	.381	.2458	.381	.3326	.3429		.2195
23	.3048	.2294	.2286	.2957	.3048		.2195
24	.3174	.3048	.2622	.2561	.3142	.3048	.1966
Max	.7316	.724	.5571	.5906	.7392	.724	.6274
Min	.2477	.1802	.1905	.1867	.1905	.3048	.1829
Avg	.4539	.3693	.3246	.3643	.3953	.5163	.3204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 204 / 11 KV RAJANGAON POL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /
OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3048	.2294	.3048	.2772	.2667	.2294
2	.3361	.3429	.2458	.3429	.3142	.3048	.2622
3	.3696	.4001	.2458	.381	.3696	.3429	.2622
4	.4066	.4572	.2458	.4191	.4066	.4954	.3113
5	.462	.4954	.3113	.4763	.4572	.6097	.4588
6	.462	.5335	.3277	.4763	.499	.6668	.426
7	.5121	.4763	.2949	.3658	.462	.6097	.3277
8	.462	.4191	.3277	.3429	.4066	.5335	.2622
9	.3658	.3429	.3292	.3239	.3696	.3429	.213
10	.3048	.1802	.3109	.2772	.3048		.2195
11	.2477	.1966	.2286	.2241	.1905		.2012
12	.2286	.1802	.2286	.2054	.2286		.2286
13	.2096	.1802	.2286	.1867	.2286		.2286
14	.2096	.1638	.1905	.1867	.2286		
15	.2096	.1802	.1829	.1867	.2286		.1829
16	.2286	.1966	.1905	.2054	.2667		.1829
17	.3048	.2294	.2286	.2241			.1848
18	.381	.3277	.2477	.3142			.2195
19	.4763	.3277	.2561	.3696	.381		.2561
20	.4191	.2949	.3429	.4066	.381		.2926
21	.381	.3222	.381	.3658	.3239		.2587
22	.3048	.2294	.2858	.3142	.2858		.2286
23	.2667	.1966	.2477	.2772	.2667		.2012
24	.2801	.2667	.2294	.2667	.2801	.2667	.1966
Max	.5121	.5335	.381	.4763	.499	.6668	.4588
Min	.2096	.1638	.1829	.1867	.1905	.2667	.1829
Avg	.3379	.3019	.2641	.3102	.3253	.4439	.2537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1802	.1143	.0953	.0762	.0983
2	.2058	.2286	.1638	.1143	.0953	.0953	.0819
3	.2401	.2858	.1802	.1143	.1143	.0953	.0983
4	.2572	.3429	.1966	.1143	.1143	.0953	.0983
5	.3429	.4001	.3277	.1143	.1143	.1143	.0983
6	.4287	.4763	.2949	.1143		.1334	.0819
7	.6344	.5335	.3932	.1143	.0953	.1143	.0983
8	.0953	.0572	.017	.0572	.0754	.0762	.0983
9	.0762	.0191	.0191	.0381	.0762	.0191	.0983
10	.0381	.0509	.0191	.2629	.381		.3429
11	.0191	.0655	.0191	.3429	.4954		.4001
12	.0191	.0655	.0191	.4287	.4572		.381
13	.0191	.0655	.0191		.381		.381
14	.0191	.0655	.0191	.3429	.381		
15	.0191	.0655	.0191	.2915	.381		.381
16	.0191	.0655	.0191	.2572	.3429		.381
17	.0191	.0655	.0191	.2572	.3429		.4572
18	.0191	.0983	.0191	.0953	.0191		.0572
19	.0953	.0819	.0191	.1143	.0191		.0572
20	.0953	.0655	.0572	.1143	.0953		.0572
21	.0762	.0732	.0953	.0943	.0953		.0762
22	.1524	.1802	.0953	.0943	.0762		.0762
23	.1524	.2294	.0953	.0953	.0762		.0762
24	.1753	.1524	.1638	.1143	.0953	.0762	.0819
Max	.6344	.5335	.3932	.4287	.4954	.1334	.4572
Min	.0191	.0191	.017	.0381	.0191	.0191	.0572
Avg	.1412	.1635	.1029	.1653	.1921	.0896	.1764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 206 / 11 KV GAWALI SHIWARA AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0655	.1334	.0886	.1143	.0983
2	.1143	.0762	.0655	.1524	.1052	.1334	.1311
3	.1143	.0953	.0655	.1524	.1029	.1334	.1638
4	.1524	.1143	.0655	.1524	.12	.1715	.1802
5	.1524	.1143	.0655	.1524	.1372	.1905	.2294
6	.1524	.1334	.0678	.1715	.1715	.2477	.2622
7	.1334	.1143	.0678	.2286	.2572	.3239	.2622
8	.1143	.1143	.1017	.0572	.0953	.1143	.2949
9	.0953	.0953	.1143	.0572	.0762	.0953	.0328
10	.1334	.0983	.1143	.0572	.0572		.0381
11	.2096	.1311	.0953	.0566	.0381		.0381
12	.2096	.1311	.1524	.0572	.0191		.0381
13	.2096	.1311	.1524	.0572	.0191		.0381
14	.1905	.1475	.0953	.0572	.0191		
15	.1715	.1311	.0953	.0762	.0191		.0381
16	.1524	.1475	.1334	.0762	.0191		.0381
17	.1334	.1475	.1334	.0754	.0381		.0381
18	.0762	.0655	.1524	.0953	.0572		.0572
19	.0953	.0819	.0572	.0953	.0953		.0762
20	.0953	.0655	.0572	.0953	.0953		.0953
21	.0953	.0655	.0572	.0953	.0953		.0953
22	.0762	.0678	.0572	.0886	.1143		.0953
23	.0762	.0655	.0572	.0953	.1143		.0953
24	.0953	.0762	.0655	.1334	.0953	.1143	.0655
Max	.2096	.1475	.1524	.2286	.2572	.3239	.2949
Min	.0762	.0655	.0572	.0566	.0191	.0953	.0328
Avg	.1310	.1036	.0898	.1029	.0854	.1639	.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 207 / 11KV KBS INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0164	.0191	.0191	.0191	.0328
2	.0191	.0191	.0164	.0191	.0191	.0191	.0328
3	.0191	.0191	.0164	.0191	.0191	.0191	.0328
4	.0191	.0191	.0164	.0191	.0191	.0191	.0328
5	.0191	.0191	.0164	.0191	.0191	.0191	.0328
6	.0191	.0191	.0164	.0191	.0191	.0191	.0492
7	.0191	.0191	.017	.0191	.0191	.0191	.0492
8	.0189	.0191	.017	.0191	.0189	.0191	.0492
9	.0191	.0191	.0191	.0191	.0191	.0191	.0492
10	.0191	.0164	.1905	.0191	.0381	.0328	.0381
11	.0191	.0164	.0191	.0191	.0381	.0164	.0381
12	.0191	.0164	.0191	.0191	.0381	.0328	.0381
13	.0191	.0164	.0191	.0191	.0381	.0366	.0381
14	.0191	.0164	.0191	.0191	.0381	.0492	
15	.0191	.0164	.2858	.0191	.0381	.0328	.0572
16	.0191	.0164	.3048	.0191	.0381	.0328	.0572
17	.0191	.0164	.0191	.0191	.0381	.0492	.0572
18	.0191	.0164	.0191	.0191	.0381	.0328	.0572
19	.0191	.0164	.0191	.0191	.0191	.0328	.0572
20	.0191	.0164	.0191	.0191	.0191	.0328	.0572
21	.0191	.0164	.4001	.0191	.0191	.0328	.0572
22	.0191	.0164	.0191	.0191	.0191	.0328	.0572
23	.0191	.017	.0191	.0191	.0191	.0328	.0381
24	.0191	.0191	.0164	.0191	.0191	.0191	.0164
Max	.0191	.0191	.4001	.0191	.0381	.0492	.0572
Min	.0189	.0164	.0164	.0191	.0189	.0164	.0164
Avg	.0191	.0176	.0642	.0191	.0262	.0279	.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 208 / Dhananjay auto
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.3048	.2543	.2667	.1494	.3048	.1475
2	.1494	.3048	.2458	.2667	.1509	.3048	.1638
3	.1494	.3048	.2458	.3048	.168	.3048	.1802
4	.1867	.3048	.2374	.3048	.168	.3048	.1802
5	.1663	.3048	.2713	.3048	.1663	.3048	.1802
6	.1867	.3048	.2214	.3048	.1867	.3048	.1638
7	.1905	.3048	.2374	.1905	.1829	.3048	.1638
8	.1494	.2096	.2713	.1905	.2286	.2096	.1475
9	.1524	.2096	.2286	.2286	.2286	.2096	.1475
10	.1715	.1966	.2286	.1867	.2096	.1802	.1905
11	.1715	.1802	.2096	.1905	.2096	.1802	.1905
12	.2667	.213	.1905	.168	.2667	.1966	.1905
13	.2667	.2294	.1524	.1867	.2667	.1802	.1905
14	.2096	.1802	.0953	.1867	.2858	.1638	.1905
15	.2096	.1966	.0953	.1663	.2858	.1638	.1905
16	.2096	.1802	.1334	.1663	.2858	.1475	.1905
17	.2096	.1802	.1334	.1478	.2858	.1638	.1905
18	.2096	.1638	.1334	.1494	.2858	.1802	.1905
19	.3048	.1357	.1334	.1715	.2858	.2035	.1905
20	.3048	.1526	.1334	.1715	.2858	.2294	.1905
21	.3048	.1311	.2286	.1524	.2858	.1966	.1905
22	.3048	.1475	.3239	.1524	.2858	.1802	.1715
23	.3048	.1475	.3239	.1524	.2858	.1802	.1715
24	.1711	.3048	.2294	.2286	.1663	.3048	.1311
Max	.3048	.3048	.3239	.3048	.2858	.3048	.1905
Min	.1494	.1311	.0953	.1478	.1494	.1475	.1311
Avg	.2133	.2205	.2066	.2058	.2336	.2252	.1764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 201 / 11 KV AMINABAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1869	.9221	1.0867	.2987	.3018	.3361	.2829
2		1.0227	1.1643	.2987	.3018	.3734	.3395
3	1.4089	1.1401	.7202	.3361	.3395	.3734	.3395
4	1.6108	1.2407	1.0974	.3696	.3395	.4668	.3772
5	1.8233	1.3413	1.5432	.4066	.3772	.4668	.415
6	2.2085	1.5089	2.0576	.4805	.4527	.5228	.4527
7		1.643	2.6063	.4108	.4527	.4668	.415
8	.3547	.3395	.4108	.2987	.3018	.3734	.2829
9	.3361	.2263	.3174	.2614	.2263	.2987	.2263
10		.2075	.2614	1.4083	1.1736	1.5261	1.1736
11		.1478	.2241	1.7269	1.3108		1.8138
12		.1848	.1886	2.3472	1.9433	2.1795	1.1934
13		.1294	.2263	2.1795	1.9006	1.9784	1.6575
14		.1307	.1867	2.0119	1.8023	1.8442	1.5912
15	.132	.1663	.1867	1.8442	1.8442	1.6766	1.6244
16	.1886	.168	.1886	1.9113	1.6385	1.8442	1.6385
17	.1886	.2033	.1867	1.8442	1.6385	1.5592	1.6766
18	.2829	.2241	.1867	.2075	.1867	.2075	.1867
19	.3018	.2987	.2957	.2829	.3174	.3772	.2587
20	.3206	.3142	.3696	.3584	.3174	.4338	.4066
21	.2829	.2218	.3326	.3018	.4108	.3961	.3734
22	.2452	1.0349	.3326	.2829	.3734	.3395	.3361
23		.9945	.2987	.2641	.3734	.2829	.2614
24	1.2003	.8488	1.0517	.2987	.2641	.3361	.2452
Max	2.2085	1.643	2.6063	2.3472	1.9433	2.1795	1.8138
Min	.132	.1294	.1867	.2075	.1867	.2075	.1867
Avg	.7545	.6108	.6467	.8513	.7745	.8113	.7320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 202 / 11 KV WARKHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.168	.1132	.1132	1.0174	1.3413
2	.1494		.168	.1132	.1132	1.0898	1.4083
3	.1494		.1646	.1132	.132	1.0774	1.4922
4	.1867		.1663	.132	.132	1.1869	1.576
5	.1867		.1629	.1509	.1509	1.4251	1.6766
6	.1867		.1848	.1886	.1509	1.7695	1.8778
7	.1867		.168			1.7604	2.146
8	.1494		.112			.0934	.132
9	.0934		.0924			.112	.1132
10	.8383		.8573		1.1904	.0747	.1132
11	1.2071		1.2346				.1132
12			1.1317			.0754	.1132
13		.9945	1.073			.0754	.1132
14	1.1568					.0754	.1132
15	1.1568	1.0117	.5487			.0566	.0754
16	1.4419	1.0974	.9602	.0754	.9831	.0566	.0754
17	1.291	1.2346	1.0631	.0943	.0747	.0566	.0566
18		.0857	.1132	.0377	.0754	.0754	.0754
19		.1494	.1132	.0754	.1494	.1509	.132
20		.2402	.1886	.1698	.1494	.1886	.2263
21		.2241	.1509	.1132	.1494	.132	.1886
22		.2241	.1132	.1132	1.2003	1.1317	1.2346
23		.168	.1132	.1132	1.1145	1.1568	1.2003
24	.1494		.168	.1132	.1132	1.0174	1.2407
Max	1.4419	1.2346	1.2346	.1886	1.2003	1.7695	2.146
Min	.0934	.0857	.0924	.0377	.0747	.0566	.0566
Avg	.5424	.5430	.4007	.1144	.3745	.6024	.7014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 203 / 11 KV WAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0754	.056	.7888	.6706	.6706	1.3957
2	.0373	.0754	.056	.7888	.7042	.7545	1.4712
3	.0373	.0754	.0554	.8383	.7712	.7545	1.3748
4	.0373	.0754	.056	.9054	.8048	.8288	1.4754
5	.0373	.0754	.056	.9724	.8383	.9012	1.5592
6	.0373	.0754	.0747	1.1065	.8551	.9831	1.8442
7	.0373	.0566	.056	.9945	.9389	1.3279	1.8778
8	.0373	.0566	.056	.5658	.0566	.0934	.0377
9	.0373	.0377	.0554			.0934	.0566
10	.3429	.4359	.5487		.0377	.0373	.0377
11	.4862	.7545	.7377	.0377	.0373	.0377	.0377
12		.8573	.8383	.0189	.0373	.0377	.0377
13		.7888	.8718	.0189	.0373	.0566	
14		.8505	.9724	.0189	.0373	.0566	
15	.4862	.815	1.0059	.0189	.0373	.0566	
16	.6371	.8063	.823	.0189		.0189	
17	.8718	.8682	.7716	.0189		.0189	
18	.0566	.0373	.0377	.0189	.056	.0189	
19	.0566	.0373	.0943	.0754	.056	.0377	
20	.0943	.056	.0943	.0377	.0373	.0566	.0943
21	.0943	.056	.0566	.0377	.0373	.0566	.0754
22	.0754	.0554	.8764	.503	.8573		
23	.0754	.056	.8916	.503	.7716		.9602
24	.056	.0754	.056	.8573	.5868	.6783	1.1568
Max	.8718	.8682	1.0059	1.1065	.9389	1.3279	1.8778
Min	.0373	.0373	.0377	.0189	.0373	.0189	.0377
Avg	.1756	.2981	.3832	.4157	.3936	.3444	.8433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 204 / 11KV GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.1509	.4251	.3696	.3772	.4668	.3772
2	.4239	.1509	.4251	.4066	.4715	.4668	.4715
3	.5601	.1509	.4251	.4805	.5658	.5601	.4715
4	.6468	.1698	.5914	.5914	.6602	.6535	.6602
5	.7468	.1698	.7392	.7316	.9808	.8402	.8299
6	.8589	.1698	.9795	.9511		.961	1.0562
7	.8871	.1509	.8871	.9145	.9997	.924	1.0185
8	.8316	.1509	.7842	.8779	.9431	.8962	.547
9	.7842	.4527	.6908	.7316		.7023	.8676
10	.6838	.4527	.6099	.6036	.415	.6161	.6602
11		.5975	.4805	.3961	.2801		.4435
12		.4481	.4066	.3395	.3734	.415	.1848
13		.5175	.3326		.3326	.415	.168
14		.3326	.3326			.3584	.2587
15	.4338	.4435	.2957	.3772	.3361	.3584	.2957
16	.5281	.4294	.3326	.3772	.2801	.415	.3326
17	.6602	.4805	.3696	.415	.3174	.4904	.3696
18		.5729	.4435	.547	.7392	.6602	.5914
19		.8048	.7682	.7545	.8962	.9242	.8413
20		.8316	.8048	.7545	.6602	.8676	.7682
21		.5544	.5175	.5281	.5601	.547	.5853
22	.132	.4805	.4066	.5093	.5228	.4715	.4435
23	.1509	.4435	.3696	.4715	.4668	.415	.4066
24	.3696	.1509	.4294	.3696	.3772	.4108	.3772
Max	.8871	.8316	.9795	.9511	.9997	.961	1.0562
Min	.132	.1509	.2957	.3395	.2801	.3584	.168
Avg	.5646	.3857	.5353	.5681	.5503	.6015	.5428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 205 / 11KV MUDDESH WADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174		1.2003	.0754	.1132	.1494	.1132
2	1.0174		1.2003	.0754	.1132	.1307	.1132
3	1.0774		.9774	.0943	.132	.1307	.132
4	1.2289		1.0288	.1132	.132	.1307	.132
5	1.3108		1.1568	.1132	.1509	.1494	.1509
6	1.3763		1.442	.132	.1509	.1494	.1509
7	1.5402		1.5746	.1132		.1509	.1132
8	.112		.1307	.0943	.132	.0934	.0943
9	.0934		.112	.0566	.0943	.0934	.0754
10	.0747		.0754	1.1233	1.1736	1.3904	1.1065
11	.0754	.056	.0943	1.5089	1.6385		1.5729
12		.0554	.0943	1.3916	1.7204	1.643	1.5592
13		.0554	.0943	1.6263	1.6876	1.5257	1.4586
14		.0739	.0754	1.4251	1.491	1.576	1.3927
15	.0566	.0554	.0754	1.6263	1.5402	1.6095	1.3763
16	.0754	.0554	.0754	1.6095	1.3108	1.6095	1.4089
17	.0754	.0739	.0754	1.5089	1.3757	1.6263	1.3923
18		.0924		.132	.0934	.1132	.0754
19		.0924		.1132	.112	.1132	.0754
20		.1294	.1132	.132	.1494	.1132	.1509
21		.1109	.0943	.132	.1494	.132	.1132
22		1.2012	.0943	.132	.1494	.1132	.1132
23		1.1317	.0754	.1132	.1494	.1132	.132
24	.9431		1.2357	.0754	.1132	.1307	.1132
Max	1.5402	1.2012	1.5746	1.6263	1.7204	1.643	1.5729
Min	.0566	.0554	.0754	.0566	.0934	.0934	.0754
Avg	.6716	.2449	.5044	.5632	.6032	.5647	.5465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 201 / 11 KV DONGAON AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1772	.2984	.3361	.3206	.3961	.415
2	.1715	.208	.3315	.3395	.3772	.4527	.415
3	.2058	.208	.3315	.3734	.4715	.4527	.547
4	.4191	.2947	.3978	.3881	.5658	.4904	.6413
5	.503	.3258	.4973	.4239	.7545	.5658	.6979
6	.547	.3856	.4973	.6371	.7545	.7356	.8488
7	.4807	.3681	.5304	.663	.8865	.7356	.6413
8	.6602	.6602	.4973	.5365	.6413	.6602	.547
9		.547	.415	.4917	.5847	.5658	.4715
10	.4527	.3206	.3547	.1677	.2321	.2743	.2241
11	.415	.2829	.3361		.1989	.2743	.2035
12	.3772	.3018	.3326	.2515	.2155	.2374	.218
13	.3395	.3018	.1696	.2515	.1823	.1865	.2155
14	.3206	.2829	.1677	.2012	.1658	.1844	.2012
15	.3772	.3018	.1658	.1844	.1677	.2012	.1802
16	.3961	.3772	.3521	.1677	.1989	.2035	.2515
17	.3772	.3961	.2486	.1844	.2155	.218	.2883
18	.415	.4527	.2543	.3206	.4904	.3772	.3222
19	.4527	.5658	.3881	.4904	.415	.5093	.4668
20	.5847	.6602	.7842	.6224	.6413	.5658	.5788
21	.547	.3961	.4854	.4904	.4338	.4338	.4668
22	.2103	.1989	.4338	.3584	.3772	.4338	.4294
23	.1753	.1823	.3921	.3206	.3395	.415	.3734
24	.1543	.1772	.1823	.3772	.3018	.3206	.3961
Max	.6602	.6602	.7842	.663	.8865	.7356	.8488
Min	.1543	.1772	.1658	.1677	.1658	.1844	.1802
Avg	.3798	.3489	.3685	.3729	.4138	.4121	.4184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 202 / 11 KV RAIPUR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2915	.431	.3772	.5847	.6036	.6413
2	.3429	.298	.431	.3734	.6036	.6036	.6602
3	.4287	.3155	.4641	.4481	.6602	.6413	.7167
4	.5868	.3429	.4807	.4805	.7545	.679	.7545
5	.6706	.4527	.5967	.4917	.8488	.7545	.8299
6	.7127	.5365	.6299	.9054	.9431	.9054	1.1128
7	.663	.5144	.6962	.9448	1.094	.9619	.7922
8	.7922	.7922	.679	.8215	.8488	.7545	.7356
9	.679	.6602	.5658	.6613	.7922	.679	
10	.4715	.4338	.3921	.2515	.3812	.4239	.2801
11		.4904	.4481	.2347	.3315	.4527	.3391
12	.4338	.5281	.3881	.4191	.3149	.3688	.3353
13	.415	.4904	.2713	.4359	.2984	.3688	.3481
14	.415	.4527	.285	.4024	.1989	.3185	.3018
15	.4527	.4904	.3149	.3521	.3315	.3185	.2294
16	.4715	.5281	.3521	.3353	.3481	.3018	.3018
17	.4527	.5658	.4144	.3688	.3647	.3018	.3561
18	.547	.6224	.4239	.547	.415	.547	.4191
19	.6036	.7922	.6653	.679	.7545	.6413	.6161
20	.7922	.8488	.7842	.811	.8488	.7545	.8775
21	.7356	.7356	.6161	.6979	.7356	.7356	.6161
22	.3856	.3772	.5281	.6224	.6413	.6224	.5601
23	.3506	.3315	.4854	.5658	.5847	.5658	.5658
24	.1715	.2947	.2818	.4481	.5658	.5658	.5658
Max	.7922	.8488	.7842	.9448	1.094	.9619	1.1128
Min	.1715	.2915	.2713	.2347	.1989	.3018	.2294
Avg	.5114	.5078	.4844	.5281	.5935	.5779	.5633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 203 / 11 KV PADALSA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6036	.6036	.3395	.3429	.4641	.503
2	.7545	.6036	.6413	.3734	.4287	.4973	.5426
3	.9431	.6413	.679	.4108	.5144	.5967	.6371
4	1.226	.6979	.7167	.4251	.5868	.663	.6539
5	1.3203	.7167	.7545	.4239	.6706	.8288	.788
6	1.4146	.7545	1.0185	.6539	.6962	.9614	.9282
7	1.2826	.7545	1.1883	.8619	.9448	1.0442	1.0277
8	1.094	.6602	1.2071	1.0227	1.1128	1.0374	1.0562
9	.8865	.6036	.9054	.8817	1.0185	.9242	.8865
10	.4191	.3978	.3921	.5093	.5281	.4715	.5975
11	.4024	.3812	.4294	.4527	.431	.415	.373
12	.3353	.3315	.3696	.415	.4527	.3584	.2347
13	.285	.2984	.2883	.3772		.3395	.2486
14	.2883	.2486	.2984	.3772	.3961	.3584	.285
15	.3239	.2652	.2984	.3584	.3772	.3772	.2949
16	.3856	.2984	.3018		.3584	.3772	.3185
17	.3601	.3481	.2984		.3772		.3391
18	.415	.3961	.5087	.4904	.811	.6036	.6371
19		.8488	.8316	.7922	.8676	.8676	.8589
20		1.1317	1.0456	1.094	1.1128	.7356	1.1576
21	.8865	.9242	.7842	.811	.7167	.6602	.7095
22	.8048	.8299	.3395	.3601	.3647	.503	.5601
23	.7545	.7356	.2987	.3429	.3481	.4694	.5228
24	.5144	.7167	.679	.3174	.3258	.3149	.4862
Max	1.4146	1.1317	1.2071	1.094	1.1128	1.0442	1.1576
Min	.285	.2486	.2883	.3174	.3258	.3149	.2347
Avg	.7119	.5912	.6199	.5496	.5993	.6030	.6103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 201 / 11 KV ZANZARDI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.2672	2.2455	.0924	.0377	.0566	.0671
2	2.4478	2.2024	2.2455	.0924	.0377	.0566	.0671
3	2.4143	2.2024	2.2138	.0924	.0566	.0566	.0838
4	2.3472	2.2672	2.2138	.1109	.0566	.0566	.0838
5	2.2466	2.3594	2.3087	.1307	.0566	.0566	.1006
6	2.3137	2.4249	2.372	.1698	.0566	.1132	.1174
7	2.3472	2.5232	2.4352	.1886	.1509	.132	.1006
8	.1006	.112	.1109	.1509	.0943	.0943	.0671
9	.0838	.0924	.0924	.132		.0754	.0671
10	.1006	.0732	.0924	1.8343	2.2405	.0754	2.5617
11		.0732	.0732		2.4996	2.9508	3.2007
12		.0732	.0549			3.0178	3.0727
13		.0732	.0549		2.5301	2.9172	3.1367
14		.0732			2.0805	2.9843	3.0727
15		.0732	.0549	2.2138			3.0407
16		.0732	.0732			2.9508	2.9767
17		.0732	.1307			2.934	2.9287
18	.0537	.0732	.112		.0754	.1006	.0732
19	.1109	.0732	.112		.0754	.1174	.0732
20		.0732	.1307	.0566	.0943	.1174	.0732
21	.0716	.0732	.1509	.0754	.1132	.1006	.0732
22	2.2672	2.1822	.1509	.0377	.0754	.1006	.0549
23	2.332	2.3087	.1109			.0671	.0549
24	2.4143	2.2245	2.4036	.0924	.0377	.0566	.0503
Max	2.5149	2.5232	2.4352	2.2138	2.5301	3.0178	3.2007
Min	.0537	.0732	.0549	.0377	.0377	.0566	.0503
Avg	1.5104	1.0019	.8671	.3647	.5761	.8343	1.0499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 202 / 11 KV PENDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0549	.0549	.4268	1.0279	1.2334	1.5424
2	.1006	.0549	.0549	.4268	1.0279	1.2334	1.576
3	.1006	.0549	.0549	.4268	1.1069	1.186	1.6095
4	.0838	.0739	.0732	.5487	1.0883	1.186	1.643
5	.1006	.0934	.0732	.7716	1.2003	1.2492	1.6766
6	.1006	.112	.0914	.9568	1.3441	1.4582	1.643
7	.0838	.0934	.1109	1.2037	1.7604	1.7236	1.8442
8	.0671	.0924	.0924				
9	.0671	.0732	.0732				
10	.2347	.2286	.2439				
11	.2721	.2286					
12		.2439	.9568				
13		.2591	.5792				
14		.2743	1.0185				
15		.2743	.5792				
16		.2286	.5487				
17		.2134	.5182				
18	.0543	.0732					
19	.0739	.0732					
20	.0716	.0732					
21	.0739	.0732					
22	.0554	.0732	.3353	.5535		1.3413	.9259
23	.0554	.0732	.3963			1.4083	1.0494
24	.0838	.0554	.0732	.4268	.9374	.9962	1.5089
Max	.2721	.2743	1.0185	1.2037	1.7604	1.7236	1.8442
Min	.0543	.0549	.0549	.4268	.9374	.9962	.9259
Avg	.0980	.1312	.3120	.6379	1.1867	1.3016	1.5019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 203 / 11KV BABARGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18
HR	Load (MW)	Load (MW)
10	.5365	.6173
11	.7287	.6481
12		.7099
13		.6944
14		.6636
15		.6481
16		.5182
17		.3353
Max	.7287	.7099
Min	.5365	.3353
Avg	.6326	.6044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 204 / 11KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0171	.0335	.0335	.0177	.0168	.0335
2	.0168	.0173	.0335	.0335	.0175	.0168	.0335
3	.0168	.0173	.0335	.0335	.0177	.0168	.0335
4	.0168	.0173	.0335	.0335	.0177	.0168	.0335
5	.0168	.0175	.0335	.0335	.0177	.0168	.0335
6	.0168	.0175	.0335	.0335	.0181	.0168	.0335
7	.0335	.0175	.0335	.0335	.0187	.0335	.0335
8	.0503	.0554	.0335	.0335	.0543	.0503	.0671
9	.0503	.0754	.0549	.0335	.0543	.0838	.0838
10	.0671	.0732	.0732	.0549	.056	.0503	.0335
11	.0754	.0732			.0566	.0503	.0537
12		.0732	.0549		.056	.0503	.0924
13		.0732	.0732	.0566		.0671	.0924
14		.0732	.0924	.0754		.0838	.0924
15		.0732	.0924			.1006	.037
16		.0732	.0732			.1006	.1109
17		.0732	.0732	.0543	.0173	.1006	.1109
18		.0335	.0537	.0526		.0671	.0732
19		.0335	.0537	.056	.0168	.0671	.0335
20		.0335	.0335		.0503	.0503	.0335
21	.0179	.0335	.0335		.0335	.0503	.0335
22	.0175	.0335	.0335	.0351	.0335	.0335	.0335
23	.0173	.0335	.0335		.0335	.0335	.0335
24	.0335	.0171	.0335	.0335	.0354	.0335	.0335
Max	.0754	.0754	.0924	.0754	.0566	.1006	.1109
Min	.0168	.0171	.0335	.0335	.0168	.0168	.0335
Avg	.0320	.044	.0491	.0423	.0328	.0503	.0535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 201 / 11KV KHULTABAD-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7888	.9516	.823	.823	.823	.9516
2	.7716	.7888	.8676	.7888	.823	.8059	.8676
3	.7888	.7888	.8755	.7545	.823	.7716	.8755
4	.823	.7716	.8755	.7202	.8059	.7716	.8755
5	.8402	.7716	.9516	.7373	.8059	.7716	.8755
6	.823	.7716	.9431	.823	.7888	.7545	.9431
7	.8059	.7545	.8374	.7888	.7888	.7545	.8755
8	.8573	.7373	.8755	.7202	.7545	.703	.9431
9	.8402	.7373	.8755	.823	.6516	.7202	.9516
10	1.0278	.7202	.823	.8048	.7804	.6859	.9694
11	1.0185	.7888	.8596	.823	.7613	.7545	.9054
12	.9516	.823	.8596	.8413	.9516	.7545	.8596
13	.9431	.8573	.9145	.9145		.7888	.8488
14	.9516	.8573	.9145	.9145		.8573	.823
15	1.0278	.823	.8779	.8779		.9259	.7888
16	.9431	.8573	.8413	.9877		.8916	.9431
17	.8402	.8916	.823	.8745		.9431	.9602
18	.8402	.8573	.8059	.8573	1.1317	1.0278	.9431
19	.8745	.8573	.8059	.8402	1.0117	1.0185	.9602
20	.9259	.9774	.9602	.9259	1.0631	1.1317	.9259
21	.9431	.9602	.9259	.8916	1.0288	1.142	.9088
22	.9259	.9602	.9088	.8916	.9602	1.0278	.8573
23	.8745	.9602	.8745	.8916	.9088	.9808	.8402
24	.8059	.823	.9808	.8402	.823	.823	.9516
Max	1.0278	.9774	.9808	.9877	1.1317	1.142	.9694
Min	.7545	.7202	.8059	.7202	.6516	.6859	.7888
Avg	.8833	.8302	.8845	.8398	.8676	.8595	.9019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 202 / 11 KV SULIBHANJAN AG
FEEDER Feeder KV- 11 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.3944	.5093	.2134	.2401	.2401	.2665
2	.5487	.3944	.4949	.2286	.2401	.2401	.2641
3	.6097	.4287	.4949	.1981	.2401	.2401	.2641
4	.7316	.6516	.4904	.2134	.2743	.2572	.3018
5	.9907	.7716	.4949	.2439	.3086	.2743	.3018
6	1.2041	1.2003	1.3323	.2591	.3601	.3086	.4568
7	1.3717	1.4232	1.713	.2743	.3772	.3772	.3997
8	.2591	.2915	.2641	.1829	.2915	.2229	.3772
9	.2286	.2058	.2665	.1372	.2058	.2284	.3045
10	.0381	.1677	.1341	.3018			.5533
11	1.0185	.1524	.1174	1.0242	.6602	.9297	.4191
12	.0381	.1524	.1174	1.0227	.6662	.6706	.2374
13	.0377	.1219	.1006	.6203		.5182	.2378
14	.1132	.1372	.1097	.6371		.2591	.218
15	.1523	.0914	.1006	.3521		.6859	.1981
16	.132	.1372	.1006	.57		.381	
17	.1029	.1067	.1067			1.0751	.2286
18	.1715	.0914	.1219	.0686	.1543	.1132	.2439
19	.2401	.1677	.2134	.3086	.2229	.2263	.2591
20	.2401	.2286	.1981	.2572	.2401	.2641	.2591
21	.2401	.1829	.1829	.2572	.2401	.2641	.2439
22	.4287	.3963	.1981	.2572	.2572	.3807	.2286
23	.4458	.3658	.2134	.2401	.2572	.3045	.2134
24	.4572	.3944	.4568	.1981	.2401	.2401	.2641
Max	1.3717	1.4232	1.713	1.0242	.6662	1.0751	.5533
Min	.0377	.0914	.1006	.0686	.1543	.1132	.1981
Avg	.4299	.3606	.3555	.3507	.3042	.3783	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 203 / 11 KV T. V. Centre
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0171				.0171	
5	.0171	.0343		.0171	.0171	.0343	
6	.0343	.0343	.0381	.0343	.0343	.0343	.0381
7	.0343	.0343	.0377	.0343	.0343	.0343	.0381
8	.0343	.0343	.0381	.0343	.0343	.0343	.0377
9	.0343	.0343	.0381	.0343	.0343	.0381	.0381
10		.0686	.0377	.0366	.0377		.0377
11		.0857	.0377	.0324	.0381	.0343	.0566
12	.0381	.0686	.0366	.0366	.0381	.0343	.0503
13		.0343	.0341	.0366		.0343	.0377
14	.0571	.0343	.0366	.0366		.0343	.0366
15	.0571	.0343	.0914	.0366		.0343	.0343
16	.0566	.0343	.0366	.0366		.0343	.0514
17	.0343	.0343	.0343	.0343		.0566	.0514
18	.0343	.0343	.0343	.0343	.0343	.0377	.0343
19	.0343	.0343	.0343	.0343	.0343	.0952	.0343
20	.0343	.0343	.0857	.0343	.0343	.0381	.0343
21	.0343	.0343	.0857	.0343	.0343	.0381	.0343
22	.0343	.0343	.0343	.0343	.0343	.0381	.0514
23	.0343	.0343	.0343	.0343	.0343	.0381	.0343
24	.0343	.0343	.0377	.0343	.0343	.0343	.0381
Max	.0571	.0857	.0914	.0366	.0381	.0952	.0566
Min	.0171	.0171	.0341	.0171	.0171	.0171	.0343
Avg	.0375	.0392	.0444	.0340	.0339	.0387	.0405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 204 / 11KV ELLORA MANDIR
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.583	.679	.5144	.5144	.6001	.679
2	.6516	.583	.571	.5316	.5144	.6001	.679
3	.6859	.6001	.5658	.5144	.5487	.6001	.7167
4	.6859	.6516	.571	.583	.6001	.6516	.5658
5	.7202	.6859	.7613	.6001	.6859	.6859	.7613
6	.7716	.7202	.9516	.7202	.7545	.7716	.8374
7	.6859	.703	.8374	.7373	.7202	.7545	.8676
8	.6687	.6173	.7994	.823	.6859	.6859	.7545
9	.7202	.6173	.6852	.6516	.9774	.6001	.7613
10	.7613	.5316	.7499	.6219	.7994	.583	.695
11	.6471	.5487	.6584	.5487	.3772	.6344	.6584
12	.7613	.5144	.6219	.439	.3772	.5144	.5853
13	.6471	.4801	.503	.439		.4287	.6401
14	.6852	.5487	.5121	.439			.6584
15	.6852	.6516	.6767	.4024		.6516	.583
16	.6091	.5487	.7499	.439		.6516	.5487
17	.6859	.6344	.823	.6173		.7545	.6516
18	.7545	.6516	.8916	.8573	.463	.7613	.6859
19	.6687	.7373	.6344	.7716	.8745	.8676	.7202
20	.6687	.7888	.7202	.5658	.9431	.8755	.6859
21	.6687	.6859	.6344	.6859	.823	.8755	.6687
22	.6516	.6859	.6001	.6516	.7202	.7613	.6859
23	.6687	.6173	.583	.6001	.6687	.679	.6516
24	.6516	.583	.6852	.5658	.5487	.6173	.6852
Max	.7716	.7888	.9516	.8573	.9774	.8755	.8676
Min	.6091	.4801	.503	.4024	.3772	.4287	.5487
Avg	.6850	.6237	.6861	.5967	.6630	.6785	.6844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 205 / 11 KV KASABKHEDA
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2058	.2641	.2743	.2915	.3258	.3807
2	.2743	.2058	.2641	.3048	.2915	.3258	.3807
3	.2591	.2058	.3018	.3658	.3086	.3772	.4568
4	.2896	.2401	.3045	.3963	.4801	.4458	.4527
5	.3353	.2743	.3426	.442	.5487	.6516	.4904
6	.381	.3086	.4949	.4572	.8916	.8059	1.1317
7	.3963	.4287	.4904	.5792	.9774	1.0631	1.2449
8	.3353	.3258	.3807	.3506	.4115	.4973	.4904
9	.2896	.2743	.3045	.3353	.3429	.3601	.3772
10	.5658	.3963	.4409	.3018	.1903	.2439	.1844
11	.6852	.5658	.6203	.2347	.1142	.1981	.2012
12	.7613	.4572	.6539	.2012	.1142		.218
13	.6852	.4115	.6539	.2561			.218
14	.571	.4572	.503	.2347			.218
15	.571	.4572	.5197	.2204			.1829
16	.571	.442	.57	.2012			.2134
17	.5144	.4725	.4877	.3086			.2439
18	.3086	.1677	.2134	.2229	.3944	.4904	.2591
19	.2915	.2743	.2134	.3258	.3429	.5281	.2743
20	.2743	.2896	.2439	.3429	.3086	.4949	.3048
21	.2058	.2286	.1981	.2743	.2915	.3807	.3185
22	.2058	.2134	.2439	.2915	.3086	.4527	.3353
23	.2058	.2134	.2439	.3258	.3258	.4568	.3201
24	.2439	.2058	.2665	.2439	.2915	.3258	.3772
Max	.7613	.5658	.6539	.5792	.9774	1.0631	1.2449
Min	.2058	.1677	.1981	.2012	.1142	.1981	.1829
Avg	.3950	.3217	.3842	.3121	.3803	.468	.3864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 206 / 11 KV PALASWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1372	.1903	.1677	.1715	.1886	.1903
2	.2439	.1372	.1886	.1524	.1715	.1886	.1886
3	.2743	.1715	.1903	.1524	.2229	.1886	.2263
4	.3048	.2401	.2263	.1829	.2058	.2058	.2263
5	.3353	.3086	.2263	.1981	.2229	.2401	.2641
6	.4115	.4115	.3807	.2286	.2572	.2572	.3045
7	.4268	.4973	.5658	.2134	.2401	.2743	.2641
8	.2134	.2058	.2284	.2134	.2058	.2058	.2641
9	.2743	.2058	.1903	.1524	.1886	.1886	.2665
10	.1886	.1677	.1844	.2347	.2284	.1981	.2012
11	.1903	.1677	.1174	.2683	.3045	.4458	.439
12	.1903	.1829	.1307	.3353	.2665	.3658	.4409
13	.1903	.1829	.1341	.4024		.3048	.4024
14	.1523	.1677	.1844	.4024		.3353	.3353
15	.1523	.1524	.1844	.3185		.2743	.3353
16	.1523	.1677	.2012	.3113		.3201	.3201
17	.1372	.1219	.1372	.3601		.3807	.2134
18	.2229	.1524	.1372	.1372	.1372	.1886	.2591
19	.1715	.1524	.1524	.1715	.2229	.1886	.1981
20	.1715	.1829	.2134	.1886	.3086	.2665	.1677
21	.1715	.1829	.0762	.2743	.2743	.2665	.1981
22	.1715	.1524	.1677	.2229	.2401	.2263	.1677
23	.1372	.1524	.1524	.1715	.2058	.1903	.1524
24	.1829	.1372	.1886	.1524	.1715	.1886	.1903
Max	.4268	.4973	.5658	.4024	.3086	.4458	.4409
Min	.1372	.1219	.0762	.1372	.1372	.1886	.1524
Avg	.2200	.1974	.1979	.2339	.2235	.2532	.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 207 / 11KV MTDC(EXPRESS)
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.019	.0171	.0171	.0171	.0189
2	.0152	.0171	.0189	.0171	.0171	.0171	.019
3	.0152	.0171	.0189	.0171	.0171	.0171	.019
4	.0152	.0171	.019	.0171	.0171	.0171	.019
5	.0152	.0171	.019	.0171	.0171	.0171	.019
6	.0152	.0171	.0189	.0171		.0171	
7	.0152				.0171		
10			.0754	.0189			.0189
11			.0189	.0183			.0189
12			.0189	.0189			.0189
13			.0183	.0189			.0339
14			.0189	.0189			.0671
15			.0189	.0189			.0171
16			.0189	.0189			
18							.0171
19	.0171	.0171	.0171	.0171	.0171		.0171
20	.0171	.0171		.0171	.0171	.019	.0171
21	.0171	.0171	.0171	.0171	.0171	.019	.0171
22	.0171	.0171	.0171	.0171	.0171	.019	.0171
23	.0171	.0171	.0171		.0171	.0189	.0171
24	.0171	.0171	.0189	.0171		.0171	.019
Max	.0171	.0171	.0754	.0189	.0171	.019	.0671
Min	.0152	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0162	.0171	.0216	.0178	.0171	.0178	.0217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 208 / 11KV CAVES

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0686	.0754	.061	.0514	.0514	.0761
2	.061	.0514	.0754	.061	.0514	.0514	.0754
3	.0457	.0514	.0754	.0457	.056	.0514	.0754
4	.0457	.0514	.0754	.061	.0514	.0514	.0761
5	.061	.0514	.0754	.061	.0514	.0514	.0754
6	.061	.0514	.0754	.061	.0514	.0514	.0761
7	.0457	.0514	.0761	.0457	.0514	.0514	.0571
8	.061	.0686	.0761	.061	.0514	.0514	.0754
9	.0457	.0686	.0754	.061	.0514	.0377	.0761
10	.0761	.061	.0838	.0671	.0571	.0914	.0754
11	.0761	.061	.0838	.0732	.0571	.061	.0838
12	.0761	.061	.0838	.0671	.0571	.061	.0943
13	.0754	.061	.0671	.0671		.061	.0838
14	.0952	.061	.0671	.0671		.0762	.1006
15	.0952	.061	.0838	.0732		.0762	.061
16	.1142	.061	.0838	.0838		.0762	.0762
17		.0762	.0762	.0857		.0754	.061
18	.0686	.061	.061	.0514	.0686	.0377	.0762
19	.0857	.0457	.061	.0514	.0857	.0943	.061
20	.0857	.061	.0457	.0686	.0857	.0754	.061
21	.0686	.061	.0914	.0686	.0686	.0761	.0457
22	.0514	.061	.0914	.0686	.0686	.0754	.0305
23	.0514	.061	.0762	.0514	.0514	.0754	.061
24	.061	.0686	.0754	.0762	.0514	.0514	.0754
Max	.1142	.0762	.0914	.0857	.0857	.0943	.1006
Min	.0457	.0457	.0457	.0457	.0514	.0377	.0305
Avg	.0682	.0599	.0755	.0641	.0589	.0630	.0713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 209 / 11kv kagzipura

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2229	.2855	.2401	.2058	.2229	.2474
2	.2058	.2229	.2855	.2229	.2058	.2229	.2452
3	.2229	.2229	.3206	.2401	.2229	.2229	.2474
4	.2401	.2401	.3206	.2229	.2401	.2401	.2855
5	.2915	.2743	.0189	.2572		.2743	.2829
6	.3944	.3429	.4187	.2743		.3258	.3807
7	.3258	.3258	.3807	.3258		.3086	.3807
8	.3086	.3258	.3772	.3258		.3258	.3395
9	.2915	.3258	.3045	.2915		.3086	.3045
10	.3045	.2915		.2195	.3395	.2229	.2561
11	.2665	.2572	.0154	.2195	.3426	.2743	.2374
12	.2641	.2401	.0183	.2195	.3426	.2401	.7545
13	.3045	.2229	.1829	.2195		.2572	.2012
14	.2665	.2401	.2561	.2378		.2572	.1646
15	.2641	.2401	.2743	.2378		.2229	.1715
16	.2665	.2229	.3292	.2743		.2401	.2401
17	.3086	.2058	.2401	.2572		.3018	.2572
18		.2915	.2572	.2572	.3429	.3807	.2743
19		.3258		.2915	.3601	.3807	.3429
20	.2743	.3772	.0514	.2572	.3772	.3807	.3772
21	.3086	.3429	.3429	.0514	.3086	.3772	.3429
22	.2743	.2915	.2743	.1715	.2743	.3045	.3086
23	.2572	.2598	.2572	.2401	.2229	.2474	.2915
24	.2401	.2229	.3045	.2229	.2058	.2229	.2855
Max	.3944	.3772	.4187	.3258	.3772	.3807	.7545
Min	.2058	.2058	.0154	.0514	.2058	.2229	.1646
Avg	.2774	.2723	.2507	.2407	.2851	.2818	.3008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 201 / 11KV BAZAR SAWANGI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.1524		.0953	.0191	.0381
2	.2286	.2858	.1905		.0953	.0191	.0381
3	.2286	.3048	.1905		.0953	.0191	.0381
4	.2286	.3429	.2286		.1143	.0191	.0381
5	.5716	.5716	.3048		.1715	.1334	.0762
6	.8573	.7621	.381		.3429	.1524	.0762
7	.8764	.9335	.5335			.1524	.1143
10				.362	.5144	.2096	.2858
11				.6287	.5525	.7207	.5525
12				.6097	.2286	.5729	
13				.6478	.3429	.6653	.4382
14				.5716		.4668	.381
15					.3048	.381	.362
16					.3239	.4854	.381
17				.4191	.362	.4001	.4382
19	.0953			.1905	.0953		
20	.2858	.0953		.2096	.0381	.1334	.2096
21	.1905	.0953			.0191	.1334	.1905
22	.2858	.0953		.0953	.0191	.0953	.0953
23	.2667	.0953		.0953	.0191	.0381	.0762
24	.2667	.2858	.1334		.0953	.0191	.0381
Max	.8764	.9335	.5335	.6478	.5525	.7207	.5525
Min	.0953	.0953	.1334	.0953	.0191	.0191	.0381
Avg	.3576	.3461	.2643	.3830	.2016	.2418	.2036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 202 / 11 KV. Bodkha AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1143	.1143	.6668	.7621	.3048	1.0719
2	.0762	.1143	.1143	.7049	.7621	.3239	1.1088
3	.0762	.1143	.1143	.743	.8573	.362	1.1827
4	.0953	.1524	.1524	.7811	.9526	.4001	1.2197
5	.1143	.1905	.1524	.8383		.5335	1.2752
6	.2667	.2477	.1524	.9335		.5975	1.3306
7			.1524	.9717	1.1241	.6908	1.2752
10		.7762	.7621				
11	1.0098	1.0534	.9907				
12	.7621	.9425	1.105				
13	.7049	.7392	1.0098				
14	.7621	.7947	.9335				
15	.8002	.8131	.9335				
16	.8573	1.0719	.8954				
17	.8383	.961	1.1241				
19	.1524		.1524	.1524	.2286		
20	.2477	.2096	.1524	.1524	.2667		.1905
21	.2286	.2096	.1334	.1715	.1524		.1524
22	.1334	.1524	.6668	.7621	.4001	.7392	.8764
23	.1143	.1143	.6668	.7621	.362	.9425	.8573
24	.1143	.1143	.1143	.7049	.743	.3048	1.0164
Max	1.0098	1.0719	1.1241	.9717	1.1241	.9425	1.3306
Min	.0762	.1143	.1143	.1524	.1524	.3048	.1524
Avg	.3911	.4677	.5044	.6419	.601	.5199	.9631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 203 / 11 KV. KANATGAON. AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191			.0762	.1143	.1143	.1524
2	.0191			.0953	.1143	.1143	.1524
3	.0191			.0953	.1143	.1334	.1905
4	.0191	.0191		.1334	.1524	.1715	.1905
5	.0381	.0572		.1524	.1905	.2286	.2286
6	.0762	.0762	.0381	.2096	.2858	.3239	.3048
7			.0762	.2286	.3429	.362	.3239
10	.1524	.1334	.2477				
11	.2477	.2477	.1715				
12	.1524	.1524	.1524				
13	.1524	.1524	.1524				
14	.1143	.1334	.1524				
15	.0953	.1524	.1334				
16	.1143	.1334	.1143				
17		.1334	.1334				
19		.0381	.0572	.0191	.0572		
20	.0572	.0762	.0381	.0191	.0572	.1143	
21		.0572		.0191		.0953	
22		.0381	.0762	.1143	.1715	.0953	.2286
23			.0762	.1143	.0953	.1334	.2096
24	.0191			.0762	.0953	.0953	.1334
Max	.2477	.2477	.2477	.2286	.3429	.362	.3239
Min	.0191	.0191	.0381	.0191	.0572	.0953	.1334
Avg	.0864	.1067	.1157	.1041	.1493	.1651	.2115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 204 / 11KV YESGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.3048	.0762	.0572	.1524	.0572
2	.2286	.2858	.3429	.0762	.0572	.1524	.0572
3	.2858	.3048	.362	.0762	.0572	.1715	.0572
4		.3048	.3429	.0762		.1524	.0572
5	.381	.3429	.3429	.0762	.0762	.1715	.0572
6	.4954	.381	.4191	.0762	.0953	.1715	.0572
7	.4954	.5525	.5716	.0762		.1334	.0762
10				.3429	.2667	.2858	.2858
11				.4572	.4001	.4001	.381
12				.362	.362	.3048	.3048
13				.362	.3048	.2858	.2667
14				.3048	.2477	.2858	.2858
15				.3239	.2667	.2286	.3048
16				.2286	.3048	.3239	.2858
17					.362	.3048	.2858
19	.1524	.0381	.0762	.0381	.1334		
20	.0572	.0572	.0762	.0381	.1334	.0572	
21	.0191	.1143	.0572		.1524	.0572	.0381
22	.1905	.1905	.0572	.0381	.1524	.0762	.0381
23	.2286	.2667	.0762	.0572	.1524	.0762	.0191
24	.2667	.2667	.2858	.0762	.0572	.1524	.0572
Max	.4954	.5525	.5716	.4572	.4001	.4001	.381
Min	.0191	.0381	.0572	.0381	.0572	.0572	.0191
Avg	.2556	.2609	.255	.1664	.1915	.1972	.1564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 205 / 11KV TAJNAPUR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.3048	.2477		.2286	.1905
2	.2096	.2477	.3429	.2477		.2477	.1905
3	.2286	.2667	.3429	.2667		.2858	.2286
4	.2286	.2858	.4191	.2858		.2858	.2667
5	.5716	.3429	.381	.2858		.3048	.3048
6	.724	.5716	.4954	.3239		.3429	.3429
7	.6668	.743	.6287	.362		.381	.4001
10				.2858		.3048	.2667
11				.4001			.4001
12				.3239		.362	.3048
13				.3239		.2858	.1905
14				.3048	.4191	.2858	.2096
15				.2096	.3239	.2477	.2286
16					.3239	.3429	.3048
17					.3048	.3239	.381
19	.1524	.2286			.2667		
20	.381	.362	.2667		.3048	.3239	.381
21	.2667	.3429	.2858		.2667	.2858	.3048
22	.2477	.3048	.2477		.2286	.2286	.2286
23	.2286	.2667	.2477		.2286	.2096	.2096
24	.2286	.2286	.2858	.2286		.2286	.1905
Max	.724	.743	.6287	.4001	.4191	.381	.4001
Min	.1524	.2286	.2477	.2096	.2286	.2096	.1905
Avg	.3356	.3415	.3540	.2926	.2963	.2898	.2762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 206 / 11KV Yesgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.2667	.2858	.2858	.2858	.2286
2	.2858	.2858	.3429	.3048	.2858	.2858	.2667
3	.3048	.2858	.381	.3429	.2858	.3048	.3048
4	.2858	.3048	.4191	.4001	.3048	.3429	.3429
5	.381	.381	.4572	.4572	.4763	.4001	.4572
6	.8573	.5716	.4954	.5525	.6097	.5415	.5601
7	.7621	.7621	.7049	.6859	.8002	.7282	.6348
8	.6097	.6287	.6097	.6287	.6668	.6348	.6348
9	.5716	.4763	.4954	.4763	.5906	.4481	.4668
10	.362	.3239	.362	.3429	.3048	.362	.3048
11	.2667	.2286	.3048	.2477	.2286	.2858	.2477
12	.2667	.2286	.2477	.2477	.2477	.2858	.2286
13	.2286	.2858	.2858	.2477	.2477	.2096	.2286
14	.2286	.2286	.2667	.2286	.2477	.2286	.2286
15	.2286	.2096	.2477	.2477	.2477	.2477	.2477
16	.2858	.1905	.2286		.2477	.2477	.2858
17	.3239		.3239	.1524	.2667	.3048	.3429
18	.381	.4382	.4382	.4763	.4191	.4001	.4382
19	.5906	.5228	.5906	.5335	.4572	.5041	.5716
20	.5335	.5601	.5335	.4382	.5335	.5415	.6478
21	.381	.4481	.4001		.4191	.4481	.6097
22	.3429	.362	.3429	.3429	.3429	.381	.381
23	.3239	.2858	.3048	.3048	.3048	.2858	.3429
24	.2667	.2858	.2286	.2858	.2858	.3048	.2286
Max	.8573	.7621	.7049	.6859	.8002	.7282	.6478
Min	.2286	.1905	.2286	.1524	.2286	.2096	.2286
Avg	.3906	.3731	.3866	.3741	.3795	.3754	.3846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 207 / 11KV VIKAS GINNING EXP
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191		.0191	.0191
2	.0191	.0191	.0191	.0191		.0191	.0191
3	.0381	.0191	.0191	.0191	.0191	.0191	.0191
4	.0381	.0191	.0191	.0191	.0191	.0191	.0191
5	.0381	.0191	.0191	.0191	.0191	.0191	.0191
6	.0381	.0191	.0191	.0191	.0191	.0191	.0191
7	.0381	.0191	.0191	.0572	.0191	.0191	.0191
8	.0381	.0191	.0191	.0191	.0572	.0953	.0762
9	.0381	.0381	.0572	.0762	.0381	.0572	.0762
10	.0381	.0381	.0381	.0381	.0191		.0381
11	.0381	.0191	.0191	.0572	.0381	.0572	.0762
12	.0191	.0572	.0191	.0381	.0191	.0191	.0381
13	.0191	.0381	.0381	.0381	.0191	.0381	.0381
14	.0191	.0191	.0191	.0191	.0381	.0572	.0381
15	.0191	.0381	.0191	.0381	.0191	.0572	.0381
16	.0191	.0191	.0191	.0191	.0191	.0381	.0381
17	.0191	.0191	.0191	.0381	.0572	.0381	.0381
18	.0191	.0191	.0191	.0191	.0572	.0572	.0381
19	.0191	.0191	.0191	.0191	.0381	.0191	.0381
20	.0191	.0191	.0191	.0191	.0191	.0191	.0381
21	.0191	.0191	.0191		.0191	.0191	.0381
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0381		.0191	.0191	.0191	.0191	.0191
Max	.0381	.0572	.0572	.0762	.0572	.0953	.0762
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0270	.0241	.0223	.0290	.0278	.0332	.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 208 / Bodhaka Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2667	.2286	.2667	.2286	.2667
2	.3048	.2286	.3048	.2477	.2667	.2477	.3048
3	.3048	.2667	.3429	.2858	.2858	.2667	.3429
4	.3239	.3048	.381	.3429	.2858	.3048	.381
5	.3239	.381	.4954	.4001	.3429	.3429	.4572
6	.7621	.5716	.6097	.5525	.5716	.4954	.5601
7	.6668	.743	.7621	.6097	.7621	.6535	.6722
8	.5716	.5335	.7049	.5144	.6668	.4854	.5975
9	.5335	.5144	.4763	.4191	.5906	.362	
10	.2858	.3239	.3048	.3048	.381	.3048	.3048
11	.2096	.2477	.2858	.3239	.2667	.2477	.1905
12	.2286		.2667	.2667	.2286		.1905
13	.2286		.2858	.2667	.2096	.1905	.1715
14	.1905		.3048	.2096	.2286		.1905
15	.1905	.2477	.2667	.2477	.1905	.2858	.2096
16	.2667	.1905	.2096	.2286	.2858	.2667	.1905
17	.2667	.1905	.3429	.2477	.3429	.2286	.1905
18	.381	.0953	.4001		.3429	.3239	
19	.4954	.4763	.5716	.2667	.4001	.4854	.5716
20	.6097	.6535	.5335	.2858	.4763	.5788	.6668
21	.4191	.4191	.362	.4954	.381	.4001	.5716
22	.3429	.3429	.3048	.3429	.2858	.362	.362
23	.3239	.2858	.2667	.3048	.2477	.3239	.3048
24	.2858		.2286	.2286	.2667	.2286	.2667
Max	.7621	.743	.7621	.6097	.7621	.6535	.6722
Min	.1905	.0953	.2096	.2096	.1905	.1905	.1715
Avg	.3660	.3623	.3866	.3313	.3572	.3461	.3620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 209 / 11 kv BAZARSAWANGI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2096	.1524	.1715	.1715	.1524	.1524
2	.2096	.2096	.1905	.1905	.1715	.1715	.1905
3	.2286	.2286	.1905	.2286	.1715	.1715	.2286
4	.2286	.2667	.2286	.2858	.1905	.1905	.2286
5	.2667	.3429	.2667	.3429	.2858	.2286	.2667
6	.4191	.4001	.3429	.4001	.381	.3239	.3048
7	.4191	.4191	.4001	.4382	.4382	.381	.362
8	.381	.362	.362	.381	.381	.381	.362
9	.2858	.3048	.3239	.2858	.2667	.2477	.3048
10	.2286	.2286	.2286	.1715	.2477	.2286	.2096
11	.1715	.2286		.2096	.1905	.1905	.2096
12	.1715	.2096		.1905	.2096	.1905	.2096
13	.1715	.1715		.1905	.2286	.1905	.1905
14	.1715	.2096	.2858	.1905	.2286	.1715	.1905
15	.1715		.2667	.1715	.2286	.1905	.2096
16	.1905	.1905	.2286	.1905	.2096	.2096	.2096
17	.2096	.2096	.1905	.2096	.2096	.1905	.1905
18	.3048	.2477	.2477	.4954	.2477	.2477	.2667
19	.3239	.2858	.362	.2858	.3048	.3048	.3429
20	.381	.381	.3239	.2667	.362	.362	.381
21	.2858	.3048	.2667		.2096	.3048	.3048
22	.2286	.2477	.2096	.1905	.1905	.2286	.2286
23	.2096	.1715	.1905	.1715	.1715	.1715	.2096
24	.2096	.2096	.1524	.1715	.1524	.1524	.1524
Max	.4191	.4191	.4001	.4954	.4382	.381	.381
Min	.1715	.1715	.1524	.1715	.1524	.1524	.1524
Avg	.2532	.2626	.2576	.2535	.2437	.2326	.2461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 201 / 11 KV Bhadji AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.12	.0686	.0686	.0709
2				.12	.0514	.0857	.0526
3				.1543	.0857	.0857	.0354
4				.1715	.1029	.1029	.0886
5				.2743	.1029	.0857	.1402
6				.3429	.4801	.4917	.5083
7				.3429	.5487	.5658	.6379
10	.1417	.1886	.12				
11	.3189	.2915	.3086				
12	.3012	.1029	.2743				
13	.1772	.1886	.2572				
14	.1417	.1372	.2229				
15	.1595	.1543	.2401				
16	.1753	.1734	.2572				
17	.2303	.2572	.2572				
22			.0514	.0686	.0686		.0857
23			.0857	.0686	.0514	.1052	.0686
24				.0857	.0686	.0701	.0914
Max	.3189	.2915	.3086	.3429	.5487	.5658	.6379
Min	.1417	.1029	.0514	.0686	.0514	.0686	.0354
Avg	.2057	.1867	.2075	.1749	.1629	.1846	.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 202 / 11KV GADANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1949	.208	.1048	.2058	.2075	.2286
2	.2229	.2303	.2058	.1048	.1886	.2263	.2286
3	.2229	.2804	.2229	.1143	.2058	.2263	.2477
4	.2572	.3155	.2254	.1143	.2229	.2452	.2667
5	.3086	.3856	.3601	.1238	.2229	.2452	.2858
6	.7888	.9465	.7291	.1238	.2058	.2452	.2858
7	.9945	.7265	.9556	.1334	.1886	.2075	.2477
8	.1715	.1048	.1698	.1048	.1543	.1698	.1905
9	.1715	.1905	.1509	.0857	.12	.1132	.1715
10	.0953	.1698	.0667	.4458	.1334	.631	.3944
11	.0762	.1132	.0572	.6344	.1334	.6379	.5144
12	.0572	.0754	.0476	.5316	.1334	.5083	.4287
13	.0572	.0754	.0381	.463	.3856	.4382	.3086
14	.0572	.0754	.0857	.4287	.3898	.3155	.2915
15	.0566	.0754	.0476	.3772	.2126	.298	
16	.0381	.0943	.0381	.2915	.2641	.3544	.3429
17	.0762	.0943	.0476	.3429	.7122	.2858	.5487
18	.1097	.1132	.0476	.0857	.0943	.0732	.0686
19	.1143	.132	.0572	.1543	.1132	.1097	.12
20	.1143	.2829	.0762	.1543	.1886	.2263	.1372
21	.1715	.2641	.0953	.1715	.3018	.2286	.1715
22	.3898	.3944	.1143	.2058	.2263	.2477	.2058
23	.2804	.2103	.1048	.2058	.2075	.2195	.2058
24	.2572	.2303	.2103	.0953	.2058	.2075	.2286
Max	.9945	.9465	.9556	.6344	.7122	.6379	.5487
Min	.0381	.0754	.0381	.0857	.0943	.0732	.0686
Avg	.2206	.2406	.1817	.2332	.2257	.2778	.2661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 203 / 11 KV Bhandegaon AG.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1334		.1715	.1715	.12	.1417
2	.2058	.1334	.1048	.1886	.1886	.1227	.1417
3	.2058	.1334		.2058	.2058	.1402	.1417
4	.2229	.1334		.3086	.2572	.1886	.2126
5	.2401	.1429		.4115	.3086	.2743	.3048
6	.2401	.0857		.6173	.6859	.6952	.7619
7	.2058	.0476	.0953	.5144	.7202	.8478	.8063
8	.1543	.0953	.0762	.0953	.1715	.0667	.0953
9	.1372	.0572	.0572	.0762	.12	.0572	.0572
10	.0762	.0686	.1715	.12	.0381	.0381	.0857
11	.0762	.3086	.3258	.0857	.0286	.0476	.0857
12	.3721	.3086	.2915	.0857	.0381	.0286	.0686
13	.3189	.2401	.2401	.0686	.0381	.0286	.0686
14	.2835	.1543	.2058	.0514	.0286	.0286	.0686
15	.2835	.1886	.2572	.0514	.0476	.0332	.0686
16	.2658	.3294	.2915	.0514	.0191	.0381	.0686
17		.3601	.3429	.0514	.0286	.0286	.0686
18	.0476	.0381	.0476	.0686	.0286	.0286	.0686
19	.0476	.0572	.0667	.0857	.0381	.0572	.12
20	.0857	.1048	.0762	.1372	.0762	.0762	.12
21	.0953	.0857	.0857	.1029	.0572	.1097	.1372
22	.1143	.1048	.1715	.1372	.12	.1646	.1886
23	.1238	.0953	.1886	.1372	.1029	.1402	.1715
24	.1886	.1334		.2058	.1715	.104	.1417
Max	.3721	.3601	.3429	.6173	.7202	.8478	.8063
Min	.0476	.0381	.0476	.0514	.0191	.0286	.0572
Avg	.1817	.1475	.1720	.1679	.1538	.1444	.1747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 204 / 11KV GADANA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.128	.132	.1029	.1029	.132	.0914
2	.12	.128	.132	.12	.1029	.132	.0914
3	.12	.128	.1509	.1372	.12	.132	.1097
4	.1715	.1417	.168	.1715	.12	.1698	.1463
5	.1886	.1578	.168	.1886	.1372	.1886	.1772
6	.2229	.2303	.2587	.2229	.2229	.2829	.2126
7	.1886	.1646	.2452	.1886	.1886	.1698	.1772
8	.1886	.1772	.1698	.1543	.1886	.1698	.1753
9	.1543	.1463	.1698	.1543	.1543	.132	.1595
10	.1417	.1132	.1029	.1029	.128	.1097	.1029
11	.0886	.1132	.1029	.12	.0732	.0886	.1372
12	.0914	.132	.0857	.12	.0732	.1097	.12
13		.132	.0857	.1029	.0914	.128	.1372
14	.0914	.132	.0857	.1029	.0914	.124	.1372
15	.1097	.0943	.1029	.1029	.0732	.128	
16	.0914	.132	.1372	.12	.1132	.1417	.1029
17	.1097	.132	.1543	.12	.1509	.1463	.1029
18	.1949	.1698	.2058	.1715	.1509	.1772	.1543
19	.1949	.1886	.2229	.1715	.2075	.1772	.1715
20	.1949	.1886	.1886	.2058	.2452	.2303	.2572
21	.1949		.1543	.1372	.2075	.1829	.2058
22	.1463	.1509	.1372	.1372	.1509	.1463	.1715
23	.1463	.1509	.12	.12	.132	.128	.1372
24	.12	.1417	.132	.1029	.12	.132	.1063
Max	.2229	.2303	.2587	.2229	.2452	.2829	.2572
Min	.0886	.0943	.0857	.1029	.0732	.0886	.0914
Avg	.1474	.1467	.1505	.1408	.1394	.1525	.1472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 205 / 11 KV Takali R.R.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0762	.0943	.1715	.2058	.132	.1097
2	.0686	.0762	.0943	.1886	.1886	.1254	.1097
3	.0857	.0762	.0943	.2572	.2058	.1387	.1063
4	.0857	.0953	.0943	.3601	.2229	.1543	.2126
5	.1029	.0953	.1132	.463	.2401	.1907	.2481
6	.1029	.1334	.1509	.6344	.823	.7042	.7265
7	.1372	.1143	.1509	.703	1.046	1.1191	.9922
8	.0857	.0914	.1132	.0572	.1372	.0943	.0572
9	.0857	.0762	.0943	.0572	.0514	.0377	.0381
10	.2658	.298	.2572	.0686		.0953	.0171
11	.4607	.6344	.5144	.0514	.0381	.0762	.0171
12	.5138	.5658	.463	.0343	.0191	.0762	.0343
13		.5093	.4287	.0343	.0191	.0762	.0171
14	.3898	.3429	.3944	.0343	.0189	.0762	.0171
15	.3721	.3772	.4287	.0514	.0762	.0572	.0171
16	.443	.3681	.4801	.0514	.0189	.0572	.0171
17	.5493	.3429	.5316	.0514	.0189	.1143	.0171
18	.0381	.0377	.0286	.0343	.0189	.0572	.0171
19	.1143	.0754	.0286	.0686	.0566	.0953	.0171
20	.0953	.0943	.0286	.1029	.0754	.1143	.0171
21	.0762	.0943	.0286	.0686	.0754	.1143	.0686
22	.0762	.0943	.12	.1886	.1886	.1646	.1543
23	.0762	.0943	.1029	.1886	.2075	.2012	.1543
24	.0686	.0762	.0943	.1372	.2058	.12	.1417
Max	.5493	.6344	.5316	.703	1.046	1.1191	.9922
Min	.0381	.0377	.0286	.0343	.0189	.0377	.0171
Avg	.1897	.2017	.2054	.1691	.1808	.1747	.1385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 206 / 11 KV TAKALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2286	.2641	.2572	.2572	.2452	.1905
2	.2401	.2103	.3018	.2572	.2572	.2829	.2286
3	.2572	.2667	.3584	.3086	.2915	.3584	.2667
4	.3086	.3429	.4108	.3944	.3258	.3881	.4191
5	.4801	.4572	.4294	.463	.4458	.462	.5335
6	.583	.6097	.6161	.5658	.5487	.6653	.6219
7	.583	.5716	.6224	.5658	.5144	.6036	.5959
8	.5316	.5335	.547	.5144	.5144	.6036	.4908
9	.463	.4191	.4733	.4115	.4801	.4527	.4572
10	.4001	.3395	.3086	.2743	.2858	.5144	.3429
11	.2858	.2263	.2915	.2572	.2858	.2667	.2915
12	.2858	.2452	.2572	.2058	.3048	.2477	.2743
13	.2286	.1886	.1334	.2058	.2667	.2477	.2743
14	.2096	.1698	.2229	.2058	.2477	.1905	.2915
15	.1949	.2263	.2572	.2229	.2286	.1905	.3086
16	.2286	.2829	.3086	.2572	.2452	.2477	.3258
17	.3239	.3584	.3429	.3429	.3584	.2858	.3601
18	.4075	.4527	.3944	.3944	.4527	.4382	.4115
19	.4763	.4527	.4287	.4458	.4904	.4763	.4801
20	.4763	.5658	.3601	.4801	.547	.5525	.4287
21	.381	.415	.3258	.3429	.5093	.4382	.3772
22	.3048	.3206	.2915	.3086	.3395	.3239	.3258
23	.2477	.2829	.2743	.2743	.2829	.2858	.3086
24	.2572	.2477	.2641	.2572	.2572	.2452	.2667
Max	.583	.6097	.6224	.5658	.5487	.6653	.6219
Min	.1949	.1698	.1334	.2058	.2286	.1905	.1905
Avg	.3498	.3506	.3535	.3422	.3640	.3755	.3697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 207 / 11 KV Viramgaon AG.
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1595	.1715	.1143	.2058	.2263	.2286
2	.1372	.1578	.1928	.1143	.2229	.2263	.2286
3	.1543	.2279	.2075	.1238	.2401	.2263	.2286
4	.1715	.2629	.2103	.1334	.2572	.2452	.2477
5	.2572	.3506	.3294	.1429	.2401	.2641	.2667
6	.7716	.7186	.763	.1429	.2401	.3018	.3048
7	.9259	.9391	.9496	.1143	.2229	.2452	.2667
8	.1715	.2096	.2075	.0762	.1715	.2075	.2096
9	.1543	.1334	.1509	.0572	.0857	.132	.1715
10	.0953	.0943	.0572	.463	.4207	.3239	.3258
11	.0762	.0754	.0381	.6344	.4908	.5853	.4973
12	.0762	.1509	.0381	.583	.4961	.4908	.3086
13	.1143	.132	.0476	.4287	.4961	.4961	.2915
14	.1524	.132	.0476	.3772	.3721	.4001	.2572
15	.1143	.132	.0381	.3429	.298	.381	
16	.0762	.132	.0381	.3944	.3772	.5525	.4115
17	.0953	.0754	.0381	.4115	.3944	.5144	.3772
18	.0953	.0566	.0476	.0343	.1132	.1143	.1029
19	.1715	.1132	.0667	.0514	.1509	.1524	.1886
20	.1334	.1698	.0857	.0686	.2075	.1905	.1886
21	.1143	.1132	.0953	.1715	.2075	.1905	.2229
22	.2477	.2058	.1048	.1886	.2075	.2286	.2743
23	.1905	.2103	.1048	.1886	.2075	.2286	.1886
24	.1715	1.7718	.1715	.1143	.2058	.2263	.2286
Max	.9259	1.7718	.9496	.6344	.4961	.5853	.4973
Min	.0762	.0566	.0381	.0343	.0857	.1143	.1029
Avg	.2002	.2802	.1751	.2280	.2722	.2979	.2616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 208 / 11KV NAKODA GINNING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0122	.0126	.0038	.0343	.0126	.0122
2	.0343	.0122	.0126	.0038	.0343	.0126	.0122
3	.0343	.0122	.0126	.0038	.0343	.0133	.0122
4	.0343	.0122	.0126	.0038	.0343	.0133	.0122
5	.0343	.0122	.0126	.0038	.0343	.0133	.0122
6	.0343	.0122	.0126	.0038	.0343	.0126	.0122
7	.0343	.0122	.0126	.0038	.0343	.0126	.0122
8	.0343	.0122	.0126	.0038	.0343	.0126	.0122
9	.0343	.0122	.0126	.0038	.0343	.0126	.0122
10	.0122		.0038	.0343	.0122	.0122	.0343
11	.0122	.0133	.0038	.0343	.0122	.0122	.0343
12	.0122	.0126	.0038	.0343	.0122	.0122	.0343
13	.0122	.0133	.0038	.0343	.0122	.0122	.0343
14	.0122	.0377	.0038	.0343	.0122	.0122	.0343
15	.0122	.0126	.0038	.0343	.0122	.0122	
16	.0122	.0126	.0038	.0343	.0126	.0122	.0343
17	.0122	.0126	.0038	.0343	.0126	.0122	.0343
18	.0122	.0126	.0038	.0343	.0126	.0122	.0343
19	.0122	.0133	.0038	.0343	.0126	.0122	.0343
20	.0122	.0126	.0038	.0343	.0126	.0122	.0343
21	.0122	.0126	.0038	.0343	.0126	.0122	.0343
22	.0122	.0126	.0038	.0343	.0126	.0122	.0343
23	.0122	.0133	.0038	.0343	.0126	.0122	.0343
24	.0343	.0122	.0126	.0038	.0343	.0126	.0122
Max	.0343	.0377	.0126	.0343	.0343	.0133	.0343
Min	.0122	.0122	.0038	.0038	.0122	.0122	.0122
Avg	.0214	.0136	.0075	.0216	.0215	.0125	.0247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 209 / 11KV LODHA STONE CRUSHER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0189	.0943	.0171	.0171	.0189	.0189
2	.0171	.0189	.0943	.0171	.0171	.0189	.0189
3	.0171	.0189	.0943	.0171	.0171	.0189	.0183
4	.0171	.0189	.0943	.0171	.0171	.0189	.0189
5	.0171	.0189	.0943	.0171	.0171	.0189	.0189
6	.0171	.0189	.0943	.0171	.0171	.0189	.0189
7	.0171	.0189	.0943	.0171	.0171	.0189	.0189
8	.0171	.0189	.0943	.0171	.0171	.0189	.0189
9		.0189	.0943	.0171	.0171	.0189	.0189
10	.0189		.0857	.0171	.0191	.0189	.0857
11	.0189	.0943	.12	.0857	.0189	.0183	.1372
12	.0189	.132	.0476	.1543	.0189	.1829	.1543
13		.0943	.0476	.0857	.0189	.0914	.0857
14	.0189	.1698	.0857	.1029	.0177	.0914	.0857
15	.0189	.132	.1372	.1029	.1097	.0943	.0857
16	.0189	.1132	.2058	.1029	.1698	.2743	.1029
17	.0189	.1698	.1715	.12	.1698	.1132	.1029
18	.0189	.0943	.0171	.0171	.0189	.0183	.0171
19	.0189	.0943	.0171	.0171	.0189	.0189	.0171
20	.0189	.0943	.0171	.0171	.0189	.0189	.0171
21	.0189	.0943	.0171		.0189	.1132	
22	.0189	.0943	.0171	.0171	.0189	.0189	
23	.0189	.0943	.0171	.0171	.0189	.0189	.0171
24	.0171	.0189	.0943	.0171	.0171	.0189	.0183
Max	.0189	.1698	.2058	.1543	.1698	.2743	.1543
Min	.0171	.0189	.0171	.0171	.0171	.0183	.0171
Avg	.0182	.0722	.0811	.0447	.0345	.0534	.0498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 210 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1334	.1886	.1029	.1886	.1509	.1334
2	.1372	.1715	.2075	.1029	.1715	.1698	.1524
3	.1543	.2103	.2075	.12	.1886	.2075	.1646
4	.1715	.2804	.2641	.12	.2401	.2263	.2667
5	.2572	.3155	.3206	.1372	.3429	.2641	.3429
6	.3429	.3681	.3584	.1543	.3086	.3142	.2477
7	.3429	.3721	.3395	.2572	.3429	.2829	.2667
8	.3429	.3189	.3018	.2058	.2058	.2263	.1227
9	.3429	.2835	.3018	.2058	.3086		.1417
10	.2667	.2263	.1715	.2401	.3429	.2286	.2058
11	.1772	.2075	.1543	.1886	.3429	.2286	.1372
12	.1417	.1886	.1372	.1715	.3429	.2286	.12
13	.1097	.1509	.12	.1372	.3189	.2286	
14	.1097	.1509	.1029	.12	.3189	.2286	
15		.1698	.0857	.12	.1063	.1715	
16	.124	.1698		.12		.1646	.1372
17	.1595	.2263	.0857	.12	.4527	.1646	.1543
18	.2126	.2641	.12	.2058	.1698	.2481	.2058
19	.2658	.3018	.1372		.1698	.3189	.2743
20	.362	.3018	.1372	.3944	.3018	.381	.2572
21	.3048	.2829	.1543	.2743	.2829	.2561	.2401
22	.2477	.2075	.1543	.2229	.2263	.2481	.2229
23	.1949	.1886	.1372	.2058	.1886	.1949	.1715
24	.1715	.1772	.1886	.12	.1886	.1509	.1715
Max	.362	.3721	.3584	.3944	.4527	.381	.3429
Min	.1097	.1334	.0857	.1029	.1063	.1509	.12
Avg	.2207	.2362	.1903	.1759	.2631	.2297	.1970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 201 / 11 KV GALLE BORGAEON AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715	.132	.1848	.0781	.1219	.1219
2	.1524	.1715	.1334	.1663	.081	.1219	.1265
3	.1715	.1715	.1524	.1663	.081	.1457	.1619
4	.1905	.1905	.1886	.1848	.1134	.1943	.1966
5	.2286	.2286	.2075	.2012	.2458	.2622	.285
6	.2667	.3048	.3018	.2378	.3018	.3277	.3688
7	.3239	.3048	.2829	.2743	.373	.4024	.4359
8			.2075	.2075	.2858	.2286	.2477
9	.2286	.2096	.2263	.2286	.2096	.2477	.2286
10	.1326	.2195	.2241	.2096	.1905	.1524	.1905
11	.1823	.2743	.2772	.1143	.1524	.1524	.1334
12	.1658	.3142	.3109	.0953	.1334	.1334	.1334
13	.1989	.2957	.2926		.1143	.1715	.1143
14	.1989	.2772	.2561	.1334		.1334	.1334
15	.2155	.2772	.2378	.0953		.1524	.1524
16	.2321	.2587	.2402	.1524		.1524	
17	.2321	.2587		.1143		.2096	.132
18		.0739	.1307	.0953	.1334	.1905	.1334
19	.1334	.1663	.1509	.1524	.2477	.2096	.1698
20	.2286	.2218	.2641	.1143	.2096	.2096	.1886
21	.1715	.1886	.2263	.1715	.1905	.1143	.1698
22	.1715	.1698	.1867	.1143	.1219	.1067	.1294
23	.1715	.1509	.1663	.0953	.1219	.1372	.1663
24	.1524	.1715	.1307	.1663	.0762	.1219	.1219
Max	.3239	.3142	.3109	.2743	.373	.4024	.4359
Min	.1326	.0739	.1307	.0953	.0762	.1067	.1143
Avg	.1948	.2205	.2142	.1598	.1731	.1833	.1844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 202 / 11 KV Akhatwada AG. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.116	.08	.1509	.1524	.1524	.1524
2	.1326	.1326	.08	.1509	.1524	.1334	.1524
3	.1989	.1492	.096	.1698	.1524	.1334	.1715
4	.1989	.1658	.1296	.2075	.1905	.1715	.1905
5	.2321	.2321	.1943	.2452	.2286	.2286	.2096
6	.3481	.2652	.2949	.3206	.2858	.2858	.2477
7	.4807	.4144	.426	.3018	.2858	.2667	.2477
8			.2263	.2829	.2477	.2286	.2286
9	.1715	.1524	.1698	.0762		.1715	.1524
10	.0953	.132	.1132	.1067	.1492	.1326	.116
11	.0953	.1132	.0943	.1981	.2155	.2652	.2652
12			.0943	.2429	.1823	.2321	.2486
13			.0754	.1457	.0166	.116	.1989
14		.1886	.0943	.1107		.1334	.1989
15		.2452	.1132	.1134		.2155	.1823
16		.3018	.1132	.1311		.1823	.1829
17		.3395	.1132	.061		.1658	.1848
18		.3584	.1886	.0953	.1143	.0762	.1509
19	.2096	.3961	.2263	.1334	.1905	.1905	.1509
20	.1905	.415	.2641				.1886
21	.1524	.3395	.2263	.1715	.1524	.1524	.2075
22	.1326	.0943	.1886	.1524	.1524	.1524	.1886
23	.0829	.0943	.1698	.1524	.1524	.1524	.1715
24	.0995	.0995	.08	.1509	.1524	.1524	.1524
Max	.4807	.415	.426	.3206	.2858	.2858	.2652
Min	.0829	.0943	.0754	.061	.0166	.0762	.116
Avg	.1825	.2260	.1605	.1683	.1763	.1779	.1892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 203 / 11 KV Tisgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2054	.2075	.1991	.1991	.1629
2	.2058	.1886	.2054	.2075	.1991	.1991	.1629
3	.2058	.2058	.2241	.2263	.2353	.1991	.1829
4	.2743	.2401	.2987	.2829	.3109	.2743	.2195
5	.3086	.2915	.3921	.3361	.4024	.3841	.2561
6	.4458	.4458	.4854	.4854	.4854	.462	.3174
7	.3772	.3944	.4294	.3921	.4481	.3734	.2614
8			.3921	.3361	.4251	.3921	.2378
9	.2401	.2572	.3361	.2401	.2915	.3077	.1646
10	.1372	.2241	.2801	.1886	.2572	.2286	.1372
11	.1372	.2241	.2427	.1372	.2058	.1715	.12
12			.2054	.1372	.1543	.1543	.12
13			.1867	.1372	.1372	.12	.1372
14	.1524	.1867	.168	.1372		.12	.12
15		.2241	.168	.1372		.1372	.1029
16		.2241	.1867	.1227		.1372	.1307
17			.2801	.1578		.1372	.2241
18			.2427	.1402	.2058	.2743	.2987
19	.4287	.3921	.3921	.2126	.2572	.2743	.3174
20	.3944	.3881	.4108			.2572	.3547
21	.2858	.3361	.3361	.3142	.3326	.2534	.2801
22	.2401	.2801	.2801	.2772	.2987	.1991	.2427
23	.2229	.2427	.2427	.2241	.2241	.181	.2054
24	.1886	.2229	.2054	.2054	.2054	.1991	.1629
Max	.4458	.4458	.4854	.4854	.4854	.462	.3547
Min	.1372	.1867	.168	.1227	.1372	.12	.1029
Avg	.2608	.2714	.2832	.2279	.2776	.2348	.2050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAON

Feeder No / Name : 204 / 11 KV Galleborgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.1905	.1905	.2096	.2096	.1905
2	.2096	.1905	.1905	.1905	.2096	.1905	.1905
3	.2286	.1905	.2096	.1905	.2096	.1905	.1905
4	.2286	.2096	.2096	.2096	.2286	.2286	.2096
5	.2477	.2286	.2286	.2477	.2667	.2477	.2286
6	.2667	.2667	.3048	.2858	.2858	.2858	.2667
7	.2667	.2858	.2667	.2477	.2858	.2667	.2858
8			.2286	.2286	.2286	.2477	.2477
9	.2096	.2096	.2286	.1715	.1905	.2096	.2286
10	.1905	.2286	.2286	.1524		.2667	.1905
11	.2096	.1905	.2096	.1905	.2096	.2096	.1905
12	.2096	.2096	.2096	.2096	.1905	.2096	.1905
13	.1905	.2096	.1905	.2286	.1715	.2096	.1905
14	.1905	.1905	.1905	.2286		.1905	.2096
15	.1905	.2096		.1905		.1905	.1905
16	.1905	.2286	.1905	.1905		.1905	.1905
17	.1905	.2096	.2477	.1715		.2477	.2096
18	.1905	.2096	.2477	.1524	.2858	.2286	.2477
19	.2286	.2286	.2286	.1905	.2667	.2286	.2667
20	.2477	.2477	.2477	.2667	.2858	.2477	.2477
21	.2286	.2286	.2286	.2286	.2858	.2286	.2286
22	.2096	.2286	.2286	.2286	.2477	.2096	.2286
23	.1905	.2096	.2096	.2096	.2286	.2286	.2096
24	.2096	.1905	.1905	.1905	.2096	.2096	.1905
Max	.2667	.2858	.3048	.2858	.2858	.2858	.2858
Min	.1905	.1905	.1905	.1524	.1715	.1905	.1905
Avg	.2145	.2170	.2220	.2080	.2367	.2239	.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 205 / 11 KV Palasgaon AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1326	.1307	.1334	.1143	.0953	.0953
2	.1492	.1492	.1478	.1334	.1143	.0953	.0953
3	.1658	.1658	.1478	.1334	.1143	.0953	.0953
4	.1989	.2486	.1848	.1524	.1334	.1143	.1143
5	.2652	.3315	.2926	.1905	.1334	.1334	.1143
6	.4807	.4973	.5068	.2096	.1143	.1334	.1334
7	.7293	.7293	.7186	.1334	.0953	.1143	.0953
8			.0762	.0953	.0762	.0953	.0953
9	.0762	.0572	.0762	.1143	.0572	.0762	.0762
10	.0572	.0572	.0572	.2187	.116	.2818	.1658
11		.0572	.0762	.4372	.3315	.5636	.3481
12			.0762	.4915	.4144	.547	.3978
13			.0762	.3277	.4475	.431	.2984
14		.0381	.0381	.3647		.3481	.2155
15		.0381	.0381	.3277		.2155	.2321
16		.0572	.0381	.3113		.3149	.2587
17		.0381	.0381	.2105		.2321	.2402
18	.0381	.0762	.0381	.0381	.0762	.0381	.0381
19	.0572	.0572	.0572	.0572	.0953	.0572	.0572
20	.0762	.0762	.1334			.0953	.0953
21	.0953	.0953	.1715	.1143	.1143	.0953	.1143
22	.1492	.1524	.1524	.1143	.0953	.1143	.1143
23	.1658	.1524	.1334	.1143	.0953	.0953	.0953
24	.1326	.1326	.1334	.1143	.1143	.0953	.0953
Max	.7293	.7293	.7186	.4915	.4475	.5636	.3978
Min	.0381	.0381	.0381	.0381	.0572	.0381	.0381
Avg	.1868	.1590	.1475	.1973	.1501	.1866	.1534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 206 / 11 KV Pimpri AG.

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.2984	.2801	.1524	.0953	.1334	.1524
2	.3647	.3647	.2957	.1524	.0953	.1334	.1524
3	.431	.4641	.3326	.1524	.0953	.1334	.1715
4	.4641	.5801	.3881	.1715	.1524	.1715	.2096
5	.6299	.663	.6401	.2096	.2096	.2096	.2286
6	.6796	.779	.8145	.2667	.2667	.2477	.2667
7	1.0442	.9282	1.0517	.2286	.2286	.2858	.2858
8			.1524	.1905	.1905	.1715	.1905
9	.1524	.1715	.1524	.1715	.1715	.1524	.1143
10	.0762	.1334	.1334	.3887	.2818	.5138	.4475
11		.1143	.1143	.639	.547	.7956	.6464
12	.0762		.0953	.6706	.4641		.5967
13			.0762	.4527	.2652	.7459	.5304
14		.0762	.1143	.57		.7625	.4144
15		.0762	.0953	.6036		.6299	.4475
16		.0572	.0572	.5868		.6299	.462
17		.0762	.0572	.3277		.5138	.4435
18	.1334	.1143	.0762	.0572	.1715	.1143	.0953
19	.1524	.1143	.1334	.1143	.1524	.1334	.1334
20	.1715	.1905	.1905			.2096	.2286
21	.1715	.1715	.2286	.1334	.1334	.1524	.2096
22	.2818	.362	.1905	.1143	.1524	.1524	.1905
23	.2652	.3048	.1715	.1143	.1334	.1143	.1524
24	.3315	.2486	.3048	.1524	.0953	.1334	.1524
Max	1.0442	.9282	1.0517	.6706	.547	.7956	.6464
Min	.0762	.0572	.0572	.0572	.0953	.1143	.0953
Avg	.3406	.2995	.2561	.2879	.2054	.3148	.2884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 202 / 11KV KANADGAON GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2241	.2263	.1623	.2614	.2241	.2641
2		.2427	.2263	.1623	.2614	.2241	.2641
3		.2427	.2829	.1623	.2614	.2241	.2641
4		.2614	.3395	.1758	.3361	.2614	.3018
5	.3206	.3734	.3961	.216	.3734	.3361	.3395
6	.415	.4481	.4527	.2743	.4108	.4668	.3772
7	.415	.3734	.4527	.2629	.4481	.4481	.4338
8	.3584	.3921	.3961	.2362	.3734	.3734	.3395
9	.3361	.3395	.1951	.1915	.2801	.2829	.3018
10	.2614		.1787	.2263	.2427	.2829	.2452
11	.2241		.1669	.2263	.2241	.2641	.2263
12	.2241	.2829	.1448	.2263	.2241	.2263	.2263
13	.2054	.2452	.1486	.1886	.112	.1886	.2452
14	.2241	.2641	.1486	.1886	.2241	.1886	.2263
15	.2241	.2263	.1486	.1886	.2241	.1886	.2263
16	.2241	.2263	.1486	.1886	.2427	.2263	.2263
17	.2241	.2452	.1783	.2263	.2427	.2452	.2263
18	.2427	.2829	.1867	.2452	.2614	.2829	.2641
19	.3734	.3018	.204	.3772	.4108	.3772	.3395
20	.4108		.2743	.3961	.4108	.3961	.4338
21	.3734	.3772	.1886	.3772	.2614	.3772	.3206
22	.2427	.2641	.1758	.2614	.2427	.2641	.2829
23	.2241	.2263	.1623	.2614		.2641	.2263
24	.2263	.2241	.2263	.1623	.2614	.2241	.2641
Max	.415	.4481	.4527	.3961	.4481	.4668	.4338
Min	.2054	.2241	.1448	.1623	.112	.1886	.2263
Avg	.2846	.2888	.2354	.2327	.2866	.2849	.2861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV KANADGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1494	.1307	.1189	.1494	.2241	.2263
2	.1307	.1494	.1307	.1189	.1494	.2241	.2263
3	.1494	.1494	.1494	.1337	.1867	.2241	.2263
4	.1867	.1494	.1867	.1593	.2801	.3361	.3395
5	.2241	.2614	.2427	.2	.3361	.3734	.4715
6	.3174	.3734	.3174	.216	.4108	.5041	.5658
7	.3174	.3361	.3174	.2652	.5601	.5788	.6224
8	.2614	.2987	.2801	.1654	.3361	.1867	.3772
9		.2614	.1593	.1509	.2801		.2241
10	.1867	.2054	.1189	.112	.1494	.1132	.1494
11	.2987	.3174	.0743	.0747	.056	.1132	.112
12	.2241	.2987	.0892	.0747			.0934
13	.2987	.2801		.0747		.1132	.0934
14	.2241	.2427	.168	.0747		.1132	.112
15	.2987	.2427	.18	.0747		.1132	.112
16	.2987	.2241	.192	.0747	.1494	.1132	.0934
17	.2801	.2054	.1829	.112	.1494		.0934
18	.1494	.1307	.104	.1307	.1494	.1698	.1307
19	.2427	.1867	.104	1.9231	.1867	.2641	.2614
20	.2241	.2054	.1758	.1867	.2427	.2075	.2614
21	.1867	.1867	.1337	.1867	.2054	.1886	.168
22	.1494	.168	.1189	.1307	.2241	.1509	.1867
23	.1494	.1307	.104	.1494	.2241	.1509	.2054
24	.1307	.1494	.1307	.1189	.1494	.2241	.1509
Max	.3174	.3734	.3174	1.9231	.5601	.5788	.6224
Min	.1307	.1307	.0743	.0747	.056	.1132	.0934
Avg	.22	.2209	.1648	.2094	.2287	.2232	.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 201 / GINNING AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0924	.0895	.0848	.0791	.0857	.0914
2	.0934	.0924	.0857	.0914	.081	.0857	.0762
3	.0943	.0924	.0857	.0895	.081	.0857	.0762
4	.0934	.0934	.0857	.0914	.0857	.0857	.0762
5	.0934	.0943	.0876	.0914	.0857	.0857	.0857
6	.0934	.0943	.0924	.0838	.1753	.1524	.1753
7	.0934	.0943	.0924	.16	.1696	.2343	.2515
8	.0934	.0943	.0895	.0934	.0857	.1867	.0943
9	.0934	.0857	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	.0857	.0857	.0857
11	.0857	.0857	.0857	.0857	.0857	.0934	.0857
12	.0857	.0857	.0857	.0857	.0857	.0934	.0857
13	.0857	.0857	.0857	.0857	.0857	.0924	.0857
14		.0857	.0857	.0857	.0857	.0924	.0857
15	.0857	.0857	.0857	.0857	.0857	.0934	.0857
16	.0695	.0857	.0762	.0857	.0857	.0934	.0934
17	.0667	.0762	.0762	.0905	.0857	.0924	.0934
18	.0886	.0905		.0934	.0857	.0924	.0934
19	.0934	.0914	.0934	.0924	.0895	.0934	.0934
20	.0934	.0914	.0934	.0934	.0905	.0934	.0934
21	.0934	.0895	.0934	.0934	.0876	.0943	.0934
22	.0934	.0905	.0838	.0848	.0905	.0781	.0838
23	.0934	.0905	.0838	.0838	.0857	.08	.0838
24	.0943	.0934	.0895	.0838	.0838	.0857	.0772
Max	.0943	.0943	.0934	.16	.1753	.2343	.2515
Min	.0667	.0762	.0762	.0838	.0791	.0781	.0762
Avg	.0894	.0895	.0869	.0911	.0928	.1017	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 202 / 11 KVV- PAL-AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1696	.1524	.1867	.1829	.1791	.1867
2	.1638	.1696	.1524	.1867	.1848	.1715	.1867
3	.1638	.1715	.1524	.1867	.1848	.1715	.1867
4	.141	.1753	.2286	.1886	.1848	.181	.1867
5	.2458	.2715	.2286	.1886	.2801	.2772	.1867
6	.6097	.4334	.3906	.3772	.3772	.2801	.2829
7	.5735	.4973	.4744	.3772	.2801	.2829	.2829
8	.4668	.2801	.2572	.2829	.1715	.2801	.2801
9	.3734	.1715	.1715	.2572	.1715	.1715	.1715
10	.2572	.1715	.1715	.2572	.1715	.2572	.1715
11	.1715	.0857	.1715	.2572	.3429	.2372	.2572
12	.1715	.0857	.0857	.2572	.2572	.2686	.1715
13	.1715	.0857	.0857	.1715	.1715	.2372	.1715
14	.1715	.0857	.1715	.1715	.1715	.1562	.1715
15	.1715	.1715	.1715	.1715	.1715	.1581	.1715
16	.1829	.0857	.1867	.2572	.1524	.2343	.1524
17		.1791	.1867	.1524	.1524	.2229	.2286
18	.1829	.1829	.1867	.0924	.0857	.0934	.1867
19	.1848	.181	.1867	.1829	.1848	.1867	.1867
20	.1848	.2801	.2801	.1867	.1867	.1867	.2829
21	.1848	.1848	.1867	.1867	.181	.1848	.1886
22	.2515	.2286	.1867	.1867	.1848	.1848	.1867
23	.1715	.1524	.1867	.1848	.1848	.1867	.1867
24	.2458	.1581	.1524	.1867	.1867	.181	.1848
Max	.6097	.4973	.4744	.3772	.3772	.2829	.2829
Min	.141	.0857	.0857	.0924	.0857	.0934	.1524
Avg	.2439	.1941	.2002	.2139	.2001	.2071	.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 203 / 11KV PHULAMBRI GAONTHAN SHEDDABLE URBAN
FEEDER Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7164	.724	.7316	.6401	.6268	.6401
2	.823	.7164	.7164	.7316	.6401	.6268	.6335
3	.823	.724	.7164	.7316	.6401	.6335	.6401
4	.823	.8145	.724	.7316	.6401	.6335	.7316
5	.7316	.7316	.724	.7316	.6401	.7316	.7316
6	.823	.8316	.7392	.7468	.7316	.8402	.8316
7	.9145	.8316	.9431	.9335	.8402	.8488	.924
8	.823	.8488	.7716	.8402	.6859	.8316	.8316
9	.823	.7716	.7716	.6859	.7716	.7716	.6859
10	.7716	.7716	.7716	.7716	.7716	.7716	.6859
11	.7716	.6859	.6859	.6001	.7716	.8145	.6859
12	.6859	.6859	.6859	.6001	.6859	.7164	.6859
13	.7716	.7716	.6859	.6001	.6859	.724	.7716
14	.6859	.7716	.6859	.6859	.6859	.724	.6859
15	.6859	.6859	.6859	.6859	.7716	.8145	.7716
16	.7973	.6859	.7316	.7973	.8145	.8145	.823
17	.8059	.823	.823	.8059	.8145	.8059	.823
18	.8954	.8316	.7316	.8059	.8145	.9145	.9145
19	.8059	.8402	.9145	.8954	.8402	.8954	.9145
20	.823		.9145	.9145	.9335	.9145	.823
21	.823	.7392	.823	.823	.8145	.823	.823
22	.724	.7316	.823	.7316	.724	.7316	.7316
23	.724	.724	.7316	.7316	.6268	.7316	.7316
24	.7316	.724	.724	.7316	.6335	.6335	.7316
Max	.9145	.8488	.9431	.9335	.9335	.9145	.924
Min	.6859	.6859	.6859	.6001	.6268	.6268	.6335
Avg	.7879	.7591	.7603	.7519	.7341	.7656	.7605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 205 / 11 KV DEOGIRI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1791	.181	.2286	.2058	.2286	.2201
2	.1867	.1829	.1791	.2401	.2058	.2286	.2258
3	.1867	.1791	.181	.2401	.2029	.2286	.2229
4	.1867	.1829	.181	.2515	.2172	.2286	.301
5	.1867	.1829	.1848	.3048	.2229	.3125	.3125
6	.3734	.3772	.3772	.4572	.5087	.4744	.6706
7	.3734	.2801	.3772	.4458	.5335	.6401	.7459
8	.2801	.2801	.2572	.2801	.2572	.2801	.2829
9	.2801	.2572	.3429	.1715	.1715	.2572	.2572
10	.3429	.3429	.3429	.1715		.1715	.1715
11	.3429	.4287	.4287	.0857		.1715	.1715
12	.3429	.3429	.3429	.0857	.1715	.0876	.0857
13	.3429	.3429	.3429	.0857	.1715	.1753	
14	.2572	.2572	.1715	.0857	.1715	.1715	.0857
15	.2572	.2572	.3429	.0857	.0857	.0876	.2572
16	.1972	.2572	.3048	.0876	.0857	.1829	.1867
17	.2029	.2286	.3048	.1734	.0857	.181	.1867
18	.1772	.1829	.1867	.0857	.1848	.1791	.1867
19	.1791	.1848	.1867	.181	.1848	.2772	.2801
20	.1829	.8402	.2801	.1829	.2801	.2772	.2801
21	.181	.1848		.181	.181	.181	.2801
22	.181	.181	.2286	.2229	.2286	.301	.3048
23	.181	.1848	.2286	.2172	.2286	.2972	.3048
24	.1867	.1791	.1829	.2458	.2115	.2286	.2896
Max	.3734	.8402	.4287	.4572	.5335	.6401	.7459
Min	.1772	.1791	.1715	.0857	.0857	.0876	.0857
Avg	.2412	.2707	.2668	.1999	.2180	.2437	.2744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 206 / 11KV BILDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3467	.3048	.1886	.1886	.1715	.1867
2	.3544	.3391	.3048	.1867	.1886	.1715	.1886
3	.2658	.3506	.3048	.1867	.1886	.1715	.1867
4	.2401	.3506	.3048	.1867	.1867	.1715	.2801
5	.3048	.4477	.3048	.2801	.2772	.2572	.2801
6	1.0279	.9745	.8697	.4715	.4668	.4572	.4572
7	.964	1.0517	1.0526	.4715	.4334	.5658	.4382
8	.3734	.3658	.3429	.3734	.3429	.362	.3506
9	.2801	.2572	.2572	.2572	.2572	.1715	.2572
10	.2572	.1715	.1715	.6001	.4801	.2572	.5144
11	.1715	.1715	.1715	.7716	.5144	.7202	.6859
12	.1715	.1715	.1715	.7716	.5144	.5335	.5144
13	.1715	.1715	.1715	.3429	.3429	.3906	.3429
14	.1715	.1715	.1715	.5144	.3429	.4687	.5144
15	.1886	.1715	.1715	.4287	.3429	.4801	.4287
16	.1886	.1715	.1886	.2572	.3858	.5801	.4001
17	.1886	.1715	.1886	.362	.381	.6249	.5401
18	.2772	.1753	.1867	.1886	.1753	.1867	.1886
19	.2801	.2686	.2801	.2829	.2629	.2772	.3734
20	.2772	.3506	.3734	.3772	.3658	.3658	.3734
21	.2801	.2629	.2829	.2801	.2743	.2801	.2801
22	.4525	.381	.1867	.1867	.1715	.2801	.2829
23	.3277	.3048	.1886	.2829	.1715	.1867	.1867
24	.3429	.2658	.3048	.1886	.1886	.1715	.1867
Max	1.0279	1.0517	1.0526	.7716	.5144	.7202	.6859
Min	.1715	.1715	.1715	.1867	.1715	.1715	.1867
Avg	.3292	.3277	.3023	.3516	.3102	.3460	.3516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 207 / 11KV DARI-GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.1791	.2572	.2572	.181	.1715	.1867
2	.362	.1829	.2572	.2601	.1829	.1715	.1829
3	.362	.1791	.2572	.2715	.1829	.1715	.1848
4	.462	.2715	.2629	.2715	.2772	.2629	.2772
5	.5544	.2743	.2629	.2715	.2801	.2629	.2801
6	.8402	.4668	.462	.4668	.4715	.3696	.4715
7	.7392	.3696	.3734	.3734	.3734	.3696	.3772
8	.6535	.4572	.3429	.2801	.3429	.2772	.3696
9	.543	.2572	.2572	.2572	.2572	.2572	.2572
10	.4287	.1715	.1715	.1715	.2572	.6859	.1715
11	.3429	.1715	.1715	.1715	.1715	.1715	.1715
12	.3429	.1715	.1715	.1715	.1715	.1715	.1715
13	.3429	.1715	.1715	.1715	.1715	.1696	.1715
14		.1715	.1715	.1715	.1715	.1696	.1715
15	.1677	.1715	.1715	.1715	.1715	.1696	.1715
16	.1677	.1715	.2543	.1753	.1734	.1677	.1772
17	.2486	.1753	.1715	.1658	.1715	.1696	.1772
18	.2572	.2686	.1715	.2543	.1753	.2772	.2572
19	.3582	.2743	.181	.2658	.2743	.2686	.3734
20	.3658	.3696	.3734	.3658	.2743	.3658	.362
21	.2686	.2686	.2715	.2743	.2772	.2743	.2601
22	.2715	.2686	.2572	.1848	.181	.1829	.1715
23	.1791	.2629	.2572	.1829	.1715	.1829	.1715
24	.362	.1772	.1715	.2572	.1829	.1753	.1829
Max	.8402	.4668	.462	.4668	.4715	.6859	.4715
Min	.1677	.1715	.1715	.1658	.1715	.1677	.1715
Avg	.3905	.2460	.2446	.2444	.2311	.2465	.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 208 / 11 KV WAREGAON- AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0886	.0857	.0876	.0943	.0857	.1886
2	.0876	.0886	.0857	.0876	.0943	.0857	.1886
3	.0876	.0886	.0857	.0895	.0943	.0857	.1886
4	.0876	.1772	.181	.1753	.1886	.1524	.1867
5	.1734	.1753	.1848		.1867	.2286	.2829
6	.2629	.3506	.2829	.3506	.3734	.3906	.4668
7	.2601	.3467	.2829	.3772	.4191	.3953	.4668
8	.2629	.2629	.2572	.2743	.2572	.1867	.2629
9	.1753	.1715	.1715	.1715	.1715	.1715	.1715
10	.1715	.1715	.1715	.1715		.0857	.1715
11	.1715	.2572	.1715	.0857		.0886	.0857
12	.1715	.1715	.1715	.0857	.0857	.0857	.0857
13	.2572	.0857	.1715		.0857	.0876	.0857
14	.1715	.1715	.1715		.0857	.0886	.0857
15	.1772	.1715		.0857	.0857	.0886	.0857
16	.1886	.0857	.0905	.0886	.0857	.0876	.0857
17	.1772	.0762	.1753	.0934	.0857	.0924	.0914
18	.0886	.181	.1753	.0886		.0914	.181
19	.1753	.1867	.1753		.181	.1772	.181
20	.0867	.1867	.1753	.0886	.1848	.1734	.2715
21	.1772	.1848	.1753	.1829	.1791	.0886	.1753
22	.0886	.0876	.1715	.0943	.0857	.1886	.1886
23	.0886	.0857	.0876	.0943	.0857	.0943	.1753
24	.0876	.0886	.0857	.0934	.0943	.0857	.1886
Max	.2629	.3506	.2829	.3772	.4191	.3953	.4668
Min	.0867	.0762	.0857	.0857	.0857	.0857	.0857
Avg	.1569	.1642	.1646	.1433	.1526	.1411	.1892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 209 / 11 KV GADEKAR INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0781	.0857	.0838	.08	.0857	.08
2	.0819	.0667	.0857	.0762	.0724	.0857	.08
3	.0705	.0686	.0857	.0743	.0724	.0857	.0781
4	.0648	.0743	.0857	.0743	.0781	.0857	.081
5	.0514	.0791	.0857	.0762	.0781	.0857	.0781
6	.0333	.0724	.0857	.0705	.0791	.0857	.0714
7	.0572	.0772	.0857	.0686	.0762	.0857	.0495
8	.0819	.0724	.0857	.0686	.0857	.0857	.0905
9	.0819	.0857	.0857	.0857	.0857	.0857	.1715
10	.0857	.0857		.1715	.1715	.1715	.1715
11	.0857	.2572	.2572	.1715	.1715	.1829	.1715
12	.0857	.1715	.1715	.1715	.1715	.1715	.1715
13	.0857	.0857	.1715	.0857	.1715	.1867	.1715
14	.0857	.0857	.1715	.1715	.1715	.1848	.1715
15	.0876	.1715	.1715	.1715	.1715	.1829	.0857
16	.0876	.0857	.0943	.0895	.0905	.1848	.0914
17	.0762	.1867	.0943	.1886	.0857	.1886	.0762
18	.081	.1848	.0943	.0876	.0895	.0886	.0819
19	.0619	.0895	.0943	.0791	.0886	.0876	.0838
20	.0781	.1867	.0943	.0914	.0876	.0914	.1886
21	.0934	.0895	.0943	.0914	.0857	.0819	.1886
22	.0743	.0876	.0943	.0943	.0857	.0876	.1886
23	.0819	.0857	.0943	.0943	.0857	.0867	.0762
24	.0457	.0781	.0857	.0838	.08	.0857	.0724
Max	.0934	.2572	.2572	.1886	.1715	.1886	.1886
Min	.0333	.0667	.0857	.0686	.0724	.0819	.0495
Avg	.0748	.1086	.1111	.1051	.1048	.1181	.1155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 202 / 11 KV BORGAON ARJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.1677	.3353	.1886	.1698	.2829	.0943
2	.2543	.1677	.3353	.1886	.1509	.2829	.1509
3	.2543	.2515	.3353	.1886	.1509	.2829	.1509
4	.2543	.2515	.4191	.1886	.2263	.3772	.1886
5	.3391	.503	.4191	.2829	.3772	.3772	.3395
6	.5801	.6706	.503	.3772	.3772	.3772	.3395
7	.663	.5868	.5868	.4715	.3206	.2829	.3772
8	.3772	.3772	.1886	.3772	.2829	.1886	.3206
9		.3772	.1886	.2829	.2641	.1886	.3206
10		.2829	.1886	.3391	.2515	.3353	.3353
11			.1509	.663	.503	.3353	.503
12			.1509	.663	.503	.3353	.503
13			.1509	.5801	.4191	.3353	.4191
14			.1509	.5087	.4191	.3353	.4694
15	.132		.132	.5087	.4191	.3353	.4191
16	.1886	.1886	.132	.5087	.4191	.3353	.4191
17	.2263	.1886	.132	.3353	.4191	.3353	.503
18	.2829	.1886	.1886	.2829	.2829	.2263	.1886
19	.415	.3772	.2829	.3206	.2829	.3206	.2452
20	.3206	.3772	.3772	.2829	.3772	.3206	.3772
21	.3206	.3772	.2829	.2263	.3772	.2829	.3772
22	.2012	.3353	.2829	.2263	.3772	.1886	.3206
23	.2012	.3353	.1886	.1886	.2829	.1698	.2452
24	.2543	.1677	.3353	.1886	.1698	.2829	.1698
Max	.663	.6706	.5868	.663	.503	.3772	.503
Min	.132	.1677	.132	.1886	.1509	.1698	.0943
Avg	.3066	.3248	.2682	.3487	.3260	.2964	.3240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 203 / 11 KV ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2829	.3391	.2515	.3353	.3353
2	.1886	.1886	.2829	.3391	.2515	.3353	.3353
3	.1886	.1886	.2829	.3391	.2515	.4191	.3353
4	.1886	.1886	.3772	.3391	.3353	.503	.3353
5	.2829	.3772	.3772	.5087	.4191	.503	.4191
6	.3772	.4715	.3772	.663	.5868	.5868	.6706
7	.3772	.3772	.2829	.7459	.6706	.5868	.7545
8	.3772	.3772	.1886	.2829	.2829	.1886	.3395
9		.3772	.1886	.2829	.2641	.1886	.3206
10		.503	.4191	.1509	.2263	.1886	.2452
11		.503	.4191	.132	.1886	.1698	.2452
12		.503	.4191	.0943	.1886	.1886	
13		.503	.4191	.0943	.1886	.1698	.1886
14		.503	.4191	.0943	.1886	.1698	.1886
15	.4191	.4191	.4239	.0943	.1886	.1509	.1886
16	.4191	.4191	.4239	.0943	.1886	.1886	
17	.503	.4191	.4239	.2263	.1886	.2641	.1886
18	.1886	.2829	.1886	.2641	.2829	.2641	.1886
19	.3206	.2829	.2829	.3206	.2829	.3584	.2452
20	.3772	.3772	.3772	.3206	.3772	.3584	.3772
21	.3584	.3772	.2829	.3206	.3772	.3206	.3772
22	.3206	.2829	.3391	.3353	.3353	.4191	.3353
23	.2829	.2829	.3391	.2515	.3353	.3353	.3353
24	.1886	.2263	.2829	.3391	.2515	.3353	.3353
Max	.503	.503	.4239	.7459	.6706	.5868	.7545
Min	.1886	.1886	.1886	.0943	.1886	.1509	.1886
Avg	.3082	.3591	.3375	.2905	.2959	.3137	.3311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 204 / 11 KV PEDGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3353	.3353	.1886	.0943	.2829	.0943
2	.3391	.2515	.3353	.1886	.0943	.2829	.0943
3	.3391	.2515	.3353	.1886	.0943	.2829	.0943
4	.3391	.2515	.4191	.1886	.2641	.3772	.0943
5	.4239	.503	.503	.2829	.3772	.3772	.2452
6	.5801	.503	.503	.3772	.3584	.3772	.3206
7	.663	.5868	.5868	.3772	.3206	.2829	.2829
8	.3772	.1886	.1886	.3772	.2829	.1886	.2452
9		.1886	.1886	.2829	.1886	.1886	.2452
10		.3772	.1886	.5801	.4191	.3353	.4191
11			.1509	.5801	.503	.4191	.503
12				.5801	.503	.4191	.503
13			.132	.4973	.4191	.4191	.4191
14		.1886	.132	.5087	.4191	.2515	.4191
15	.0943	.1886	.0943	.4239		.3353	.4191
16	.2263	.1886	.0943	.4239	.4191	.3353	.4191
17	.7545	.1886	.0943	.3353	.4191	.4191	.503
18	.1886	.2829	.1886	.3206	.2829	.1886	.1886
19	.2263	.2829	.2829	.2829	.2829	.2641	.2452
20	.2829	.3772	.3772	.2263	.3772	.3584	.3772
21	.2263	.3772	.2829	.1886	.3772	.2641	.3772
22	.4191	.3353	.2829	.1698	.3772	.1886	.3206
23	.4191	.3353	.1886	.132	.2829	.132	.2452
24	.3391	.2515	.3353	.1886	.0943	.2829	.132
Max	.7545	.5868	.5868	.5801	.503	.4191	.503
Min	.0943	.1886	.0943	.132	.0943	.132	.0943
Avg	.3654	.3064	.2704	.3288	.3153	.3022	.3003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 206 / 11 KV LOANEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.0943	.2829	.2543	.1677	.3353	.2515
2	.1886	.0943	.2829	.2543	.1677	.3353	.2515
3	.1886	.0943	.2829	.2543	.1677	.3353	.2515
4	.1886	.1886	.3772	.2543	.3353	.4191	.2515
5	.2829	.2829	.3772	.3391	.4191	.4191	.503
6	.3772	.3772	.3772	.5087	.5868	.503	.5868
7	.3772	.3772	.2829	.5087	.503	.503	.5868
8	.3772	.2829	.1886	.1886	.2263	.1886	.2263
9		.1886	.1886	.1886	.1886	.1886	.1886
10		.3353	.3353	.132	.1698	.1886	.132
11		.4191	.3353	.0943	.1886	.132	.132
12		.4191	.2515	.0943	.1886	.0943	.132
13		.4191	.2515	.0943	.1886	.0943	.0943
14		.4191	.2515	.0943	.1886	.0943	.0943
15	.3353	.4191	.2543	.0943	.1886	.0943	.0943
16	.3353	.3353	.2543	.0943	.1886	.0943	.0943
17	.3353	.3353	.2543	.132	.1886	.132	.132
18	.7545	.2829	.1886	.2263	.2829	.1698	.132
19	.7545	.2829	.2829	.2829	.2829	.2641	.1509
20	.2263		.3772	.2829	.3772	.2829	.1886
21	.1698	.3772	.2829	.2641	.3772	.2263	.1886
22	.1509	.2829	.2543	.2515	.3353	.2012	.1677
23	.132	.2829	.2543	.2515	.3353	.2515	.1677
24	.1886	.0943	.2829	.2543	.1677	.3353	.2515
Max	.7545	.4191	.3772	.5087	.5868	.503	.5868
Min	.132	.0943	.1886	.0943	.1677	.0943	.0943
Avg	.3084	.2906	.2813	.2248	.2671	.2451	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 201 / 11 kv Bodhegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3086	.3086	.5144	.463	.3429	.463
2	.3429	.3086	.3086	.5716	.5144	.4115	.4973
3	.4191	.3086	.3086	.6287	.5658	.4801	.5658
4	.4668	.3772	.3772	.6878	.6516	.6001	.6859
5	.543	.5144	.5144	.7842	.7202		.7716
6	.6535	.6516	.5144	.8764	.7545	.823	.8573
7	.5658	.7202	.6687	.7716	.7888	.8745	.823
8	.7202	.703	.6344	.7888	.7202	.7202	.6859
9	.5788	.4115	.5316	.5601	.5658	.583	.5144
10		.3258	.4001	.3772	.3258	.5144	.3772
11		.3258	.362	.4287	.3944	.3944	.4115
12		.2915		.4458	.4287	.3258	.3772
13		.3429		.4115	.3429	.4287	.3429
14		.3601		.3944	.3086	.3258	.3086
15		.3258	.3048	.3772	.2915	.3772	.2743
16		.3086	.3921	.3772	.3258	.4458	.2743
17	.3772	.3429	.3982	.1372	.3772	.4115	.2401
18	.4801	.4801	.4344	.3429	.3429	.4801	.4115
19	.6001	.6001	.5487	.5487	.463	.5144	.4801
20	.7545	.7545	.7202	.7202	.6173	.6859	.6173
21	.5487	.5487	.6535	.6001	.5144	.6344	.6859
22	.3086	.3086	.4801	.4801	.4801	.4801	.4801
23	.3086	.3086	.4954	.4458	.463	.3944	.4115
24	.2477	.3086	.3086	.4572	.4115	.3944	.3258
Max	.7545	.7545	.7202	.8764	.7888	.8745	.8573
Min	.2477	.2915	.3048	.1372	.2915	.3258	.2401
Avg	.4836	.4265	.4602	.5303	.4930	.5062	.4951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 202 / 11 KV Babra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.2572	.2572	.5716	.5144	.4801	.6001
2	.5716	.2572	.2572	.6097	.5487	.5144	.6687
3	.6722	.2572	.2572	.6668	.6001	.5658	.6859
4	.7468	.3429	.3429	.7468	.6859	.7202	.823
5	.7842	.4287	.4287	.7545	.7545	.8573	.8573
6	.9412	.5144	.5487	.9335	.8573	.9431	1.0117
7	1.0288	.8059	.6001	.8745	.9774	.8573	.9431
8	.9431	.8573	.8745	.8573	.8916	.7373	.7373
9	.6859	.4973	.5716	.6335	.5658	.5144	.6687
10	.5144	.3429	.5716	.3429	.1715	.4287	.1715
11		.4287	.5144	.3772	.3772	.3258	.1886
12		.1715	.4572	.3429	.4458	.3429	.2058
13		.2743	.4763	.3086	.3944		.2229
14		.3086	.4191	.2743	.3429	.3429	.2401
15		.3429	.4481	.1715	.3086	.3944	.2401
16	.3772	.3772	.4572	.3429	.2572	.4458	.2572
17	.5144	.3429	.5601	.1715	.3258	.463	.2572
18	.6001	.6001	.5041	.463	.2915	.3772	.4115
19	.7545	.7545	.7716	.7716	.4458	.4973	.6001
20	.6001	.6001	.8745	.8745	.6687	.5658	.6859
21	.5144	.5144	.7468	.6859	.5144	.6687	.583
22	.2572	.2572	.5975	.5487	.5144	.6001	.5487
23	.2572	.2572	.6535	.6001	.5316	.4287	.5144
24	.4191	.2572	.2572	.5716	.5144	.4973	.3258
Max	1.0288	.8573	.8745	.9335	.9774	.9431	1.0117
Min	.2572	.1715	.2572	.1715	.1715	.3258	.1715
Avg	.6136	.4187	.5186	.5623	.5208	.5465	.5187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 203 / 11 Kv Nidhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-JUN-18
HR	Load (MW)
22	.2743
23	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 204 / 11KV LEHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.3429	.3429	.1905	.1715	.4973	.3258
2	.5335	.3429	.3429	.2286	.2058	.6001	.3772
3	.5975	.3429	.3429	.2858	.2572	.6516	.4801
4	.7095	.4115	.4115	.3429	.3086	.6859	.5658
5	.7545	.6001	.6001	.381	.3429	.6859	.6859
6	.8402	.8059	.7373	.4001	.3601	.7716	.7373
7	.7202	.703	.6859	.4287	.6173	.6001	.6001
8	.6001	.6344	.583	.4458	.4801	.4973	.4801
9	.463	.6001	.5144	.2427	.3772	.3944	.3086
10	.1372	.2058	.1715	.2058	.2058	.3429	.1372
11	.2915		.2096	.2058	.1715	.3086	.1372
12		.4973	.1905	.2572	.1543	.2401	.2401
13		.5144	.2096	.3086	.1543		.3429
14		.4801	.2096	.2743	.1372		.3086
15		.4287	.2286	.2229	.1715		.2401
16		.2572	.3048	.1886	.2229		.2058
17	.2743	.2058	.3361	.2058	.2401	.2058	.1886
18	.1372	.1372	.2172	.2401	.2743	.3258	.4115
19	.4458	.4458	.4382	.3944	.3258	.4458	.4973
20	.4115	.4115	.583	.583	.4973	.6001	.6687
21	.4115	.4115	.5601	.5144	.3772	.5144	.5487
22	.3429	.3429	.1524	.1372	.1543	.1372	.2401
23	.3429	.3429	.181	.1715	.1543	.1372	.2743
24	.381	.3429	.3429	.1715	.1543	.1715	.1715
Max	.8402	.8059	.7373	.583	.6173	.7716	.7373
Min	.1372	.1372	.1524	.1372	.1372	.1372	.1372
Avg	.4649	.4264	.3707	.2928	.2715	.4407	.3822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 205 / 11KV NAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1715	.1715	.3429	.3086	.3429	.3772
2	.3429	.1715	.1715	.4191	.3772	.4973	.4458
3	.381	.1715	.1715	.4763	.4287	.5658	.4973
4	.4481	.2572	.2572	.5716	.5144	.6001	.5658
5	.5601	.3772	.3772	.6908	.6344	.6687	.6344
6	.724	.5144	.4458	.8215	.7545	.7545	.7716
7	.6859	.6859	.463	.6516	.7888	.7545	.703
8	.6344		.5316	.4801	.6344	.583	.5658
9		.1715	.4191	.3921	.4973	.5487	.4801
10		.1886	.2477	.4115	.1886	.3772	.2058
11		.1715	.1524	.4458	.2229	.3086	.2401
12		.1715	.1905	.4115	.3086	.2743	.2401
13		.1372	.2096	.3772	.2572	.1715	.2229
14	.2058	.1715	.1905	.3086	.2401	.2229	.2401
15	.1886	.1715	.1905	.1886	.2743	.1715	.2401
16	.2058	.1886	.2054	.0857	.3258	.3086	.2229
17	.2058	.1372	.1905	.2915	.2401	.3944	.2229
18	.2229	.2229	.2096	.1886	.1715	.3429	.3772
19	.3772	.3772	.3086	.3086	.2915	.3944	.4973
20	.4458	.4458	.5658	.5658	.3772	.4973	.6859
21	.3429	.3429	.4854	.4458	.3086	.3772	.6173
22	.1715	.1715	.2915	.2915	.2915	.3429	.583
23	.1715	.1715	.2987	.2743	.2915	.1886	.4801
24	.2667	.1715	.1715	.3239	.2915	.2743	.1715
Max	.724	.6859	.5658	.8215	.7888	.7545	.7716
Min	.1715	.1372	.1524	.0857	.1715	.1715	.1715
Avg	.3624	.2505	.2882	.4069	.3758	.4151	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 206 / 11KV KHAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.2572	.4954	.4458	.3944	.4973
2	.4001	.2572	.2572	.5228	.4801	.4973	.5658
3	.5144	.2572	.2572	.6097	.5487	.6001	.6001
4	.5658	.3429	.3429	.7282	.6687	.6859	.7373
5	.6161	.4458	.4458	.7716	.7373	.7716	
6	.7095	.6001	.5144	.9945	.7716	.4973	
7	.6173	.7202	.6344	.9431	.7373	.6687	
8	.7888	.7888	.6859	.7716	.7373	.6344	
9	.583	.4801	.5316	.7095	.5144	.6173	
10	.4115	.3772	.4191	.4115	.2401	.5487	
11		.3086	.2667	.4458	.3258	.5144	
12		.2572	.2858	.4801	.3772		
13			.3048	.4458	.3086		
14		.3086	.381	.3772	.3429		
15		.3429	.362	.3429	.3944	.3429	
16	.3429	.2915	.3547	.3429	.2401	.3429	
17	.3772	.3086	.3077	.3429	.2572	.3944	
18	.4801	.4801	.4801	.4801	.2743	.4973	
19	.6516	.6516	.6001	.6001	.4458	.5658	
20	.7888	.7888	.7888	.7888	.6001	.6687	
21	.5487	.5487	.7095	.6516	.5316	.6001	
22	.2572	.2572	.4801	.4801	.4973	.4973	
23	.2572	.2572	.4525	.4287	.4458	.3772	.3772
24	.3048	.2572	.2572	.4572	.4115	.3772	.3086
Max	.7888	.7888	.7888	.9945	.7716	.7716	.7373
Min	.2572	.2572	.2572	.3429	.2401	.3429	.3086
Avg	.5030	.4167	.4324	.5676	.4722	.5283	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 201 / 11 kv Shevata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1417		.1886	.1905	.1886	.1905
2	.124	.1417		.1886	.1886	.2075	.1886
3	.1402	.1595		.2263	.2263	.2452	.2263
4	.1753	.2103		.3206	.3018	.3206	.3206
5	.208	.2774		.4904		.3961	.3961
6	.2743	.3429		.6224	.5041	.5281	.5415
7	.2229	.3561		.5281	.4338	.415	.4108
8	.2829	.3584		.3206	.3395	.3395	.3018
9	.2263	.2263		.2075	.1698	.2075	.1698
10	.0943	.0754		.1187	.1402	.1132	.1052
11	.0943	.0566	.0943	.1227	.1696	.1402	.1677
12	.0754	.0566	.0943	.1227	.1311	.1595	.1509
13	.0754	.0943	.0943	.1402	.0819	.1227	.116
14	.0754	.0943		.1227	.1311	.1052	.0838
15	.0943	.1132		.0876	.1296	.1052	.1006
16	.0943	.1132	.0943	.1052	.0926	.1227	
17	.0943	.0943	.1132	.1052	.1638	.1227	
18	.1886	.1509	.2075	.1886	.1886	.2075	.1886
19	.3772	.2452	.3584	.3018	.2075	.3395	.2641
20	.3395	.2452	.4338	.3206	.3584	.3018	.3772
21	.2641	.2452	.2641	.2829	.2263	.2452	.2829
22	.1772	.1006	.2641	.2452	.2452	.2075	.2263
23	.1595	.081	.2641	.2075	.2075	.1886	.2263
24	.1417	.1595	.1063	.2263	.1886	.1886	.2075
Max	.3772	.3584	.4338	.6224	.5041	.5281	.5415
Min	.0754	.0566	.0943	.0876	.0819	.1052	.0838
Avg	.1718	.1725	.1991	.2413	.2181	.2299	.2383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 202 / 11 kv NARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0709	.0709	.1132	.1143	.1132	.1143
2	.0709	.0709	.0709	.1132	.1132	.1132	.1132
3	.0701	.1052	.1063	.1509	.1509	.1509	.132
4	.1052	.1402	.1402	.2263	.2075	.2075	.1886
5	.1387	.208	.2454	.3584	.3395	.3584	.3395
6	.1886	.2915	.2915	.4904	.5041	.5093	.4668
7	.1886	.3391	.2883	.415	.4527	.4527	.4481
8	.3584	.3395	.3395	.3018	.3961	.3772	.3206
9	.1886	.2452	.2263	.1698	.2075	.2481	.1509
10	.132	.0754	.1698	.1526	.0701	.132	.0876
11	.0943	.0566	.0943	.1595	.1052	.1052	.1174
12	.0943	.0754	.0754	.1578	.1174	.0876	.0838
13	.0943	.0943	.0943	.1052	.112	.0876	.0829
14	.1132	.0819	.0943	.1052	.104	.1052	.0838
15		.0754	.1132	.1227	.0655	.1227	.0671
16		.0754	.0943	.1052		.1578	.1006
17	.1509	.1132	.0943	.0876	.104	.1578	.1006
18	.1886	.1509	.132	.1698	.1867	.1886	.1698
19	.3584		.3206	.3206	.2829	.2452	.3018
20	.3584	.3395	.3772	.3584	.3018	.415	.3584
21	.2641	.2263		.2641	.3395	.2641	.2075
22	.0886	.1063	.1886	.1886	.1698	.1698	.1509
23	.0754	.0709	.1509	.1509	.132	.132	.132
24	.0709	.0709	.0709	.132		.1132	.1132
Max	.3584	.3395	.3772	.4904	.5041	.5093	.4668
Min	.0701	.0566	.0709	.0876	.0655	.0876	.0671
Avg	.1574	.1488	.1674	.2050	.2080	.2089	.1846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 203 / 11 kv Pathri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6224	.6224	.2328	.2303	.2601	.2303
2	.6602	.6224	.6413	.2328	.2303	.2229	.2481
3	.7167	.6979	.7167	.2481	.2481	.2835	.2454
4	.9054	.9808	1.0185	.3155	.3155	.2984	.3121
5	1.1576	1.3392	1.3392	.4854	.5548	.4321	.5028
6	1.531	1.6598	1.6221	.6001	.8402	1.0059	.9259
7	1.4003	.1509	1.5089	.6001	.8059	.9709	.823
8	1.226	1.3014	1.2826	1.1694	1.2071	1.2637	1.2826
9	.8865	.8865	.9619	.8865	.9054	1.0751	.8676
10	.3155	.3584	.2949	.6224	.5658	.5847	.6224
11	.3277	.3391	.426	.5281	.4527	.4527	.4338
12	.3605	.3121		.415	.3584	.3584	.4527
13	.2949	.3294		.3961	.3395	.3395	.4527
14	.2294	.3052	.1638	.4338	.4338		.4527
15	.2785	.3467	.1966	.4715	.5281	.3395	.4715
16	.2458	.2263	.3563	.4904	.4668	.3772	.4904
17	.2652	.3544	.3441	.5658	.5658	.5658	.5093
18	.7922	.679	.6224	.7167	.7167	.679	.6979
19	1.1317	.9431	1.0751	.9054	.8987	1.226	1.0374
20	1.2449	1.2071	1.3014	1.1694	1.2637	1.1694	1.2826
21	.8865	.9054	.9619	.9054	.9054	.8676	.9242
22	.6979	.7922	.3045	.3544	.2429	.2835	.3045
23	.6413	.6602	.2686	.2804	.2601	.2658	.2686
24	.6413	.6413	.6224	.2507	.2481	.2601	.2481
Max	1.531	1.6598	1.6221	1.1694	1.2637	1.2637	1.2826
Min	.2294	.1509	.1638	.2328	.2303	.2229	.2303
Avg	.7285	.6942	.7569	.5532	.5660	.5905	.5869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 204 / 11kv Wadod Bazar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2303	.2149	.2328	.5658	.5716	.5658	.5716
2	.2481	.2149	.2149	.5658	.5658	.5658	.5658
3	.2629	.2507	.2507	.6224	.6036	.5847	.6036
4	.3155	.3012	.3189	.7356	.6413	.6224	.6602
5	.3467	.4031	.4207	.9054	.7167	.7167	
6	.4458	.4681	.5028	1.0185	.6722	1.0185	.9709
7	.4973	.5487	.4801	1.0185	.8299	.9465	.9709
8	.5658	.811	.679	.8299	.8676	.8676	.547
9	.5847	.6602	.6036	.7167	.6979	.7356	.547
10	.4904	.5281	.6224	.3294	.298	.3201	.1753
11	.5847	.5658	.547	.3189	.2229	.2804	.2035
12	.4904	.5281	.4527	.2804	.1898	.2279	.1543
13		.4904	.4715	.2804	.1562	.2454	.2713
14	.5847	.4715		.2454	.1932	.2454	.2713
15	.547	.4904		.298	.2427	.2454	.2915
16	.547	.5658	.6602	.2804	.3812	.2629	.3086
17	.6036	.5281	.6036	.298	.2622	.3155	.3601
18	.7356	.7167	.811	.7922	.7095	.679	.4715
19	.8488	.7922	.8299	.8299	.7922	.811	.8488
20	.7922	.9431	.8299	.8865	.7356	.811	.8676
21	.7167	.679	.7545	.7545	.679	.7356	.7167
22	.2507	.2865	.679	.6413	.6413	.6413	.6602
23	.2328	.2686	.6224	.6036	.6036	.6036	.6036
24	.2481	.2149	.2328	.5658	.5658	.5658	.5658
Max	.8488	.9431	.8299	1.0185	.8676	1.0185	.9709
Min	.2303	.2149	.2149	.2454	.1562	.2279	.1543
Avg	.4856	.4976	.5373	.5993	.5350	.5672	.5307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 205 / 11 KV RAJENDRA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2829	.2829	.2829	.3018	.2987	.2641
2	.2641	.2829	.2829	.2829	.3018	.2987	.2641
3	.2641	.2829	.2829	.2829	.2829	.2896	.2829
4	.2641	.2829	.2829	.2829	.3018	.2774	.2641
5	.2641	.2829	.2829	.2829	.2829	.3018	.2641
6	.2452	.2829	.2829	.2641	.2829	.2801	.2452
7	.2452	.3018	.3018	.2641	.2829	.2829	.2263
8	.2641	.2829	.3018	.2641	.2829		.2641
9	.2641	.3018	.2829	.2641	.2829	.2641	.2452
10	.3018	.3018	.3018	.2452	.2829	.2641	.2075
11	.3018	.3206	.2452	.2452	.2641	.2641	.2263
12	.3018	.3189	.2641	.2263	.2515	.2452	.2452
13	.3018	.3174	.2452	.2263	.2429	.2641	.3018
14	.3018	.3206	.2829	.2263	.2829	.3018	.3018
15	.3018	.3206	.3018	.2452	.2374	.2829	.2829
16	.3018	.3206	.3018	.2452		.2641	.3018
17	.3206	.3395	.3018	.2452	.2374	.2452	.2452
18	.3018	.2829	.2829	.2452	.2829	.2641	.2452
19	.2829	.3206	.2829	.2452	.2801	.2641	.2641
20	.3018	.2829	.2641	.2641	.2829	.2641	.2452
21	.3018	.2641	.3018	.2641	.2641	.2641	.2641
22	.2829	.2641	.2829	.2829	.2641	.2641	.2641
23	.2829	.2829	.3018	.3018	.3018	.2641	.2641
24	.2641	.2829	.2829	.2829	.2829	.2987	.2641
Max	.3206	.3395	.3018	.3018	.3018	.3018	.3018
Min	.2452	.2641	.2452	.2263	.2374	.2452	.2075
Avg	.2829	.2968	.2845	.2609	.2766	.2743	.2601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 201 / 11KV JATEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.0934	.112	.1372		.2054	.1029
2	.1494	.0934	.112	.1372		.208	.1029
3	.1494	.0934	.112	.1543		.208	.12
4	.1494	.0934	.112	.1677		.2107	.1715
5	.168	.112	.1307	.2134		.2107	.2439
6	.2241	.112	.168	.3048		.6722	.4268
7	.2241	.1494	.1494	.3048		.6249	.3658
8	.1867	.0934	.0934	.1307		.112	.0934
9	.1867	.0934	.0747	.0934		.0934	.0747
10		.1337	.1829	.0934		.0747	.056
11	.1494	.2229	.1981	.0934		.056	
12	.2614	.1806		.0934		.056	
13	.2241	.1635		.0747	.0747	.056	
14	.2241	.1337		.0747	.0187	.056	
15	.1867	.1783		.0747	.0187	.056	
16	.1867	.2258	.2743	.0934		.056	.056
17	.2241	.1932	.3048	.0934	.0187	.056	.0187
18	.056	.0373	.0373	.0934	.0187	.056	.0187
19	.0747	.056	.0373	.112	.0747	.0747	.0373
20	.0914	.0934	.056	.1307	.0747	.0686	.0747
21	.0934	.112	.0747	.1494	.0747	.0747	.0747
22	.0934	.112	.1543		.2229	.0686	
23	.0934	.112	.12		.208	.0686	
24	.056	.0934	.112	.1372		.2054	.0857
Max	.2614	.2258	.3048	.3048	.2229	.6722	.4268
Min	.056	.0373	.0373	.0747	.0187	.056	.0187
Avg	.1566	.1242	.1308	.1344	.0805	.1512	.1249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 202 / 11KV DHAMANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.1158	.0934	.056	.0373	.056
2	.1463		.1337	.0747	.056	.0373	.056
3	.1463		.1337	.0747	.056	.0373	.056
4	.1867		.1337	.0934	.056	.0373	.0747
5	.3361		.2258	.0934	.056	.056	.0747
6	.3734		.3311	.112	.056	.0373	.0747
7	.3734		.2258	.112	.056	.0373	.0747
8	.056		.0747	.0934	.0373	.0373	.056
9	.0373		.056	.056	.0373	.0187	.0373
10	.0373			.1867	.0572	.0187	.112
11	.0373		.0373		.1486	.1067	.168
12	.0373		.0373	.3734		.1067	
13	.0183		.0373			.1067	.1494
14			.0373		.0724	.2134	.112
15		.0187	.0373		.1014	.2286	.1494
16		.0187	.0377	.3361	.1014	.2439	
17		.0187	.056		.1494	.1677	.2987
18	.0373	.0187	.056	.0373	.056	.0171	.056
19	.0373	.0187	.056	.056	.0187	.0343	.056
20	.0373	.056	.0754	.0549	.0187	.056	.056
21	.0373	.056	.0747	.056	.0373	.0747	.056
22	.0934	.104	.0934	.056	.056	.0566	.056
23	.1494	.1189	.0934	.056	.0373	.0566	.056
24	.056		.1189	.0934	.056	.0373	.0171
Max	.3734	.1189	.3311	.3734	.1494	.2439	.2987
Min	.0183	.0187	.0373	.0373	.0187	.0171	.0171
Avg	.1192	.0476	.0991	.1110	.0626	.0775	.0865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 203 / 11KV BABHULGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0187	.0373	.0686	.0434	.0714	.1029
2	.0373	.0187	.0373	.0686	.0429	.0724	.1029
3	.0366	.0187	.0373	.0686	.0429	.0724	.12
4		.0187	.0373	.0762	.0429	.088	.1524
5		.0187	.056	.0914	.0429	.0892	.2134
6		.0187	.0747	.1219	.1158	.1337	.3658
7		.013	.0747	.2591	.1486	.1204	.2439
8		.0187	.056	.0373	.0373	.0187	.0373
9			.056	.0187	.0187	.0187	.0187
10	.112		.1829	.013	.0187	.0187	.0187
11	.1867		.1829	.0187	.0187	.0187	.0187
12		.1158	.1677	.0187	.0187	.0187	
13	.0747	.1806	.1524	.0187	.0187	.0187	
14	.056	.1635	.1524	.0187	.0187	.0187	
15	.0549	.1189	.1372	.0187	.0187	.0189	
16	.0549	.0724	.1372		.0187	.0187	
17	.056	.1337	.1524	.0187	.0187	.0187	.0187
18	.0187	.0187	.112	.0373	.0187	.0373	.0187
19	.0373	.0373	.0747	.0373	.0187	.0343	.0373
20	.0187	.0373	.056	.0373	.0187	.0343	.0373
21	.0373	.056	.0566	.0373	.0187	.0343	.0373
22	.0373	.056	.0747	.056	.0714	.0747	.112
23	.0187	.0373	.0686	.056	.0714	.1132	.112
24	.0373	.0187	.0373	.0686	.0434	.0724	.0914
Max	.1867	.1806	.1829	.2591	.1486	.1337	.3658
Min	.0187	.013	.0373	.013	.0187	.0187	.0187
Avg	.0536	.0567	.0922	.0550	.0394	.0515	.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 204 / 11 KV JATEGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2801	.2987	.2835	.2801	.2987	.2658
2	.3361	.2801	.2987	.2835	.2801	.2987	.2835
3	.3361	.3734	.3174	.3012	.2801	.3174	.2835
4	.5601	.4481	.3547	.439	.3734	.4108	.4024
5	.7468	.8962	.7922	.6722	.5601	.6535	.6722
6	.8775	.9709	.9808	.8589	.9054	1.0082	.9522
7	.8402	.8402	.7655	.7468	.8402	.9619	.8215
8	.8402	.7282	.7655	.6722	.8402	.8299	.7468
9	.5228	.4481	.6219	.4481	.5975	.6348	.4854
10	.3734	.2987	.1463	.3734	.3547	.2561	.168
11	.2801	.0934	.1595	.2241	.2427	.1063	.3174
12	.2801	.0934	.2126	.1867	.0924	.0886	.112
13	.2241	.1307	.1772	.112	.0739	.0709	.1494
14	.2241	.1478	.1772	.112	.2801	.2427	.1494
15	.2241	.1294	.1772	.112	.2801	.2126	.1494
16	.2241	.1294	.2195	.2427	.3547	.1417	
17	.2987	.2987	.2926	.2801	.4108	.1417	.2987
18	.4481	.4668	.4481	.3921	.2987	.2572	.5041
19	.7468	.6535	.6348	.6722	.7468	.6516	.7842
20	.6535	.6908	.4854	.5601	.5228	.5144	.7095
21	.5601	.4294	.3734	.4481	.4854	.4115	.3734
22	.3361	.3361	.3109	.3734	.3921	.3429	.3361
23	.2801	.3174	.2658	.3361	.3361	.3429	.2801
24	.2801	.2801	.2987	.2658	.2987	.3174	.2801
Max	.8775	.9709	.9808	.8589	.9054	1.0082	.9522
Min	.2241	.0934	.1463	.112	.0739	.0709	.112
Avg	.4489	.4067	.3989	.3915	.4220	.3964	.4141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 205 / 11KV SULTANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1486	.1494	.112	.0747	.1307
2	.1867	.1867	.1486	.1494	.1494	.0747	.132
3	.2241	.1867	.1486	.1494	.168	.0747	.1494
4	.2241	.1867	.1656	.1867	.1867	.0934	.1867
5	.3361	.2241	.2258	.2241	.1867	.112	.2241
6	.3361	.3361	.2559	.2614	.2241	.168	.2427
7	.3921	.3547	.3161	.2614	.2801	.2241	.2614
8	.2801	.2801	.3311	.2614	.2241	.1867	.2614
9	.2801	.1867	.2427	.1867	.1867	.1307	.2241
10	.2241	.1486		.1867	.0892	.1524	.2987
11	.1494		.1867	.1867	.1337	.1219	.2263
12	.1307		.2614	.1494		.1219	.2241
13	.112		.2241	.1494		.1524	.1867
14		.168	.2241	.1494	.088	.0914	.1867
15			.2054	.1494	.0572	.1029	.1867
16			.1867	.1867	.0572	.0857	.2241
17		.2241	.1867	.1867	.104	.1981	.2801
18	.2054	.2801	.2241	.1867	.2427	.2641	.1867
19	.2054	.2801	.1867	.2241	.168	.2614	.0373
20	.2054	.2427	.2075	.2054	.1307	.2075	.2241
21	.1867	.2054	.2054	.1867	.112	.1867	.2241
22	.2241	.1505	.1867	.1494	.0934	.1543	.1867
23	.1867	.1486	.168	.1189	.112	.1372	.1867
24	.1494	.1867	.1486	.168	.1189	.0934	.1372
Max	.3921	.3547	.3311	.2614	.2801	.2641	.2987
Min	.112	.1486	.1486	.1189	.0572	.0747	.0373
Avg	.2213	.2191	.2080	.1839	.1466	.1446	.2004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 201 / 11KV KINGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1989	.2303	.124	.132		.132
2	.1677	.1989	.2229	.1254	.132		.132
3	.1677	.1989	.2401	.1204	.1509		.1509
4	.2134	.2984	.2572	.1772	.1698		.1698
5	.3048	.4424	.2713	.2926	.1698		.1698
6	.4572	.5079	.4633	.2926	.1886		.2452
7	.6097	.6802	.5858	.3292	.2075		.1886
8	.2427	.2263	.3012	.3292	.1886		.3206
9	.2075	.2075	.2481	.2829	.2263		.1886
10	.1698	.1307	.181	.2267	.2429		.3772
11	.0943	.112	.1595	.3909	.282	.4372	.4409
12	.1132	.112	.1254	.3567	.2606	.4372	.3688
13	.0943	.0934	.1063	.3477	.2397	.3605	.285
14	.1132	.0934	.1097	.2896	.2225	.2622	.2883
15	.1132	.112	.0886	.2606	.2256	.2949	.2683
16	.1132	.0934	.1417		.2286	.2915	.3521
17	.1698	.1307	.1417	.333	.2896	.3932	.3688
18	.2263	.1307	.1629	.1509	.2258	.2075	.168
19	.1886	.2054	.1656	.1698	.2658	.3018	.2614
20	.2452	.2054	.1949	.2075	.2507	.3018	.2241
21	.2075	.1494	.1417	.2452	.2303	.1886	.1867
22	.2818	.2801	.1417	.1509	.1417	.1509	.1867
23	.2486	.2658	.124	.1509		.1509	.1494
24	.2134	.2486	.2126	.124	.132		.132
Max	.6097	.6802	.5858	.3909	.2896	.4372	.4409
Min	.0943	.0934	.0886	.1204	.132	.1509	.132
Avg	.2149	.2218	.2091	.2382	.2088	.2906	.2398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 202 / 11KV PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0934	.0934	.0714	.0857	.0695	.112
2	.0857	.0934	.0934	.0714	.0857	.0714	.112
3	.1029	.0934	.112	.0724	.1029	.0846	.1307
4	.1372	.1494	.1494	.1	.12	.1014	.1307
5	.1715	.2241	.1663	.1448	.1715	.1429	.168
6	.2378	.2241	.141	.2143	.2229	.2027	.2801
7	.3018	.2614	.1715	.1882	.2401	.1882	.2801
8	.2641	.2427	.1429	.1882	.2829	.141	.2241
9	.2012	.168	.1303	.1372	.1372	.1158	.2241
10	.168	.1307	.1014	.0857	.1269	.1494	.1867
11	.1494	.112	.0857	.1029	.0857	.1494	.0934
12	.0934	.112	.0714		.0724	.112	.0934
13	.0934	.112	.0724		.0714	.0934	.0747
14	.112	.112	.0724		.0695	.0934	.0747
15	.112	.112	.0714	.1029	.0705	.112	.0934
16	.112	.112	.0429	.0655	.0857	.1307	.0934
17		.1307	.0429	.0819	.1158	.1307	.112
18		.1867	.1448		.1158	.1494	.1494
19	.2614	.2054	.1593	.1147	.1692	.2054	.2241
20	.2801	.2218	.1692	.2378	.1429	.1494	.1867
21	.168	.168	.1429	.1029	.1158	.1494	.168
22	.1307	.112	.0857	.1463	.0869	.1307	.1307
23	.112	.112	.0724	.1029	.0705	.1307	.112
24	.0857	.0934	.0934	.0705	.0819	.0705	.112
Max	.3018	.2614	.1715	.2378	.2829	.2054	.2801
Min	.0857	.0934	.0429	.0655	.0695	.0695	.0747
Avg	.1575	.1493	.1095	.1201	.1221	.1281	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 203 / 11KV GANORI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1143	.0335	.141	.1341
2	.1132	.1132	.112	.1158	.0335	.1738	.1326
3	.132	.1132	.1307	.1158	.0328	.2172	.1475
4	.1698	.1509	.1307	.1738	.0316	.2858	.1802
5	.2263	.1509	.1494	.3041	.0324	.362	.1966
6	.2829	.2075	.2126	.3765	.0474	.5068	.4696
7	.3395	.2452	.3439	.443	.0469	.6308	.664
8	.2829	.2075	.3012	.2462	.0377	.3721	.415
9	.2263	.132	.2353	.2075	.0189	.2303	.2075
10	.1943	.2126	.2429	.1698	.0177	.2263	.1494
11	.3768	.2743	.2858	.1132	.0177	.132	.0934
12	.3113	.3052	.3185	.132	.0177	.1132	
13	.2785	.3185	.3041	.1509		.1132	
14	.1989	.3185	.2896	.132			
15	.2458	.3185	.2679	.1132			
16	.1966	.3149	.2858			.2075	
17	.2949	.2818	.3475	.0943	.2835	.2075	.1494
18	.1698	.2987	.1448		.2303	.2075	.1867
19	.2263	.1867	.2126	.2641	.2126	.1698	.1867
20	.2075	.168	.1772	.2263	.1572	.1698	.1867
21	.132	.1494	.1303	.1132	.1417	.1132	.1867
22	.1132	.1132	.1715	.0914	.1463	.1509	.1949
23	.1132	.1132	.1303	.0324	.1429	.1509	.1463
24	.1132	.1132	.1132	.1286	.0328	.1429	.1341
Max	.3768	.3185	.3475	.443	.2835	.6308	.664
Min	.1132	.1132	.112	.0324	.0177	.1132	.0934
Avg	.2108	.2050	.2146	.1754	.0858	.2284	.2190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 204 / 11 KV DONGERGAON-SHIRODI SEPARATED AG FEEDERS HAVING SPECIAL
 AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277	.3544	.3366	.3239	.2481	.3018
2	.3353	.3315	.3544	.3403	.3239	.2481	.3018
3	.3441	.3605	.3641	.3544	.3429	.2507	.3206
4	.3768	.3605	.3772	.3544	.381	.2534	.3206
5	.4191	.4049	.3944	.3161	.4001	.2561	.3206
6	.4877	.5182	.5357	.3311	.4191	.2378	.3961
7	.4801	.583	.5357	.3161	.381	.2378	.3772
8	.362	.3584	.3311	.3189	.3429	.2481	.3584
9	.3429	.3206	.2709	.3048	.3239	.2507	.3018
10	.3018	.2987	.2408	.3201	.3102	.3277	.3222
11	.2829	.2987	.2835	.2743	.3286	.3932	.3052
12	.2829	.3018	.2926	.2629	.3286	.3647	.3018
13	.2801	.2829	.2172	.2858	.2896	.3441	.3391
14	.2829	.2829	.2658	.2858	.2961		.3391
15	.2829	.2829	.2743		.2858	.3605	.3429
16	.2829	.2801	.2658		.3041	.3441	.3429
17	.3018	.2801	.2258		.362	.3277	.373
18	.3018	.2801	.3366	.0953	.2172	.3018	.2801
19	.3206	.2987	.3982	.362	.2835	.3206	.3174
20	.3584	.3361	.3189	.362	.2481	.3206	.3547
21	.2785	.3174	.3012	.3239	.2507	.3206	.3361
22	.3812	.4207	.3544	.3239	.2534	.3206	.3206
23	.3605	.3658	.362	.3048	.2481	.3018	.3018
24	.3772	.3688	.3544	.2481	.3048	.2481	.3018
Max	.4877	.583	.5357	.362	.4191	.3932	.3961
Min	.2785	.2801	.2172	.0953	.2172	.2378	.2801
Avg	.3397	.3442	.3337	.3058	.3146	.2968	.3282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 205 / 11 KV WAREGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2614	.2614	.1858	.2229	.1833	.2614
2	.2572	.2614	.2614	.2143	.2229	.1833	.2614
3	.3086	.2614	.2801	.2606	.2629	.2115	.3361
4	.4207	.3361	.3921	.362	.333	.2715	.4854
5	.5658	.5041	.5729	.5001	.463	.4199	.6161
6	.8488	.7842	.5716	.5792	.7167	.7095	.8775
7	.7733	.7468	.6226	.6516	.547	.5502	.6908
8	.811	.7095	.5357	.4858	.5281	.4371	.8029
9	.5658	.4481	.4778	.5281	.547	.4287	.5228
10		.3511	.2317	.3018	.2538	.3734	.4066
11	.2427	.2241	.2115	.2572	.1429	.2801	.2402
12	.2054	.2241	.1858	.2279	.141	.2614	.2033
13	.1867	.2241	.1882	.1715	.1429	.2054	.1867
14	.168	.2218	.0724	.1802	.0714	.2427	.1307
15	.2241	.2218	.0724	.1802	.0705	.2427	.1867
16	.2241	.0934	.1692	.1886	.0857	.2054	.2241
17	.2241	.3142	.2143	.2401	.1692	.2614	.2957
18	.3174	.3696	.362	.2743	.2896	.3734	.4066
19	.6535	.6283	.5213	.3658	.5716	.5975	.6838
20	.7468	.7577	.5858	.6602	.6226	.7468	.7392
21	.5601	.5359	.4001	.6602	.4054	.4854	.5975
22	.4481	.4481	.3429	.3961	.2896	.3921	.2987
23	.3361		.2896	.3155	.2538	.3361	.2772
24	.2401	.2614	.3174	.2	.2378	.1833	.2614
Max	.8488	.7842	.6226	.6602	.7167	.7468	.8775
Min	.168	.0934	.0724	.1715	.0705	.1833	.1307
Avg	.4160	.3995	.3392	.3495	.3163	.3576	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 206 / 11 KV WANEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1494	.1417	.1457	.1269	.1658
2	.1509	.1509	.1494	.1629	.1581	.1429	.1658
3	.1698	.1509	.168	.1829	.1739	.1551	.2294
4	.2263	.1698	.2241	.1949	.2372	.2143	.2984
5	.2641	.2263	.2614	.1806	.2812	.5068	.3768
6	.3206	.2641	.3012	.2658	.5335	.7095	.7537
7	.3584	.3018	.3582	.2865	.5792	.6516	.4096
8	.2829	.2452	.2715	.3012	.2263	.1949	.3206
9	.2075	.1698	.1829	.1509	.1509	.1254	.2075
10		.2572	.2715	.1886	.0886	.1132	.168
11		.3688	.3666		.0716	.0943	.168
12		.3521	.4001		.0709	.0943	.132
13		.285	.2317		.0716	.0754	.0566
14		.2883	.2317	.1509	.0709	.0566	.0754
15		.3018	.2172	.0377	.0709	.0566	.0754
16	.1989	.3185	.2538	.0754	.0716	.0566	.0754
17		.3315	.2896	.1132	.0709	.0754	.0747
18	.0943	.2987	.1303	.0943	.0886	.0943	
19	.1886	.168	.2303	.1509	.1417	.132	
20	.2452	.1867	.1772	.0943	.1612	.2829	.1867
21	.2263	.2054	.1595	.1509	.1417	.2075	.2641
22	.1886	.2241	.1595	.2187	.1267	.2683	.2835
23	.1886	.1867	.1417	.1739	.1551	.2012	.2481
24	.1698	.1698	.168	.1448	.1562	.153	.1696
Max	.3584	.3688	.4001	.3012	.5792	.7095	.7537
Min	.0943	.1509	.1303	.0377	.0709	.0566	.0566
Avg	.2136	.2405	.2290	.1648	.1685	.1995	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 201 / 11 KV PIRBAWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1526	.3584	.4191	.4001	.4001
2	.1402	.1905	.1509	.415	.4763	.4382	.4001
3	.2204	.2353	.1677	.4527	.5525	.4382	.4572
4	.285	.3121	.407	.5093	.6668	.5335	.5716
5	.4807	.4287	.4694	.7167	.8192	.6859	.724
6	.5761	.5533	.5365	1.0562	.9907	.8402	.7621
7	.4961	.5083	.4807	.8676	.8764	.7621	.7811
8	.7733	.6097	.6097	.6979	.7049		.6478
9	.4904	.5716	.4527	.3395		.4763	.4572
10	.3395	.3475	.3048	.2743		.16	.2286
11	.3239	.3048	.2075	.2658		.2477	.2454
12	.3239		.3018	.2601		.2477	.1802
13	.3239		.2075	.2267	.2865	.2286	.2035
14	.3048	.3239	.3584	.2321	.1791	.2858	.1658
15	.3048	.362	.3584	.218		.3429	.1715
16	.3239	.3239	.3772	.2279	.3224	.4001	.1677
17	.381	.381	.3772	.1991	.3439	.3429	.2279
18	.4191	.4191	.3961		.4191	.5335	.4382
19	.7049	.5525	.7167		.6668	.6097	.4954
20	.6478	.5658	.5281	.743	.5716	.6097	.7621
21	.4954	.4527	.4904	.5335	.4572	.5335	.6287
22	.3048	.2054	.3961	.4763		.4572	.5144
23	.2477	.197	.3395	.4382	.4001	.4191	.4763
24	.2561	.1715	.1715	.3239		.4001	.4001
Max	.7733	.6097	.7167	1.0562	.9907	.8402	.7811
Min	.1402	.1715	.1509	.1991	.1791	.16	.1658
Avg	.3894	.3722	.3733	.4469	.5384	.4519	.4378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 202 / 11 KV RANJANGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1509	.0183	.0381	.0762	.0762
2	.1698	.1905	.1509	.0351	.0381	.0572	.0762
3	.2075	.2477	.1698	.032	.0572	.0762	.1143
4	.3206	.2858	.2075	.0332	.0953	.1524	.1715
5	.5281	.4001	.2075	.1006	.1715	.2286	.3048
6	.6602	.5525	.3395	.128	.2667	.2614	.3429
7	.5847	.5144	.4715	.1886	.2667	.3429	.3086
8	.4715	.4763	.4572	.3395	.5144	.3429	.4191
9	.3206	.2858	.3206	.1698	.381		.2858
10	.0566	.0366	.0572	.1143	.1715		.1524
11	.0716	.0572	.0678	.1143	.1143		.0762
12	.0857	.0572	.0732	.0953	.0762	.0762	.0953
13	.0655	.0572	.0514	.0953	.0895	.0953	.0953
14	.0678	.0381	.0339	.1524		.1143	.0953
15	.0486	.0381	.0509	.1143		.0953	.1143
16	.0514		.0509	.1143	.1075	.1334	.0953
17	.0709		.0509	.1143	.181	.0953	.0762
18	.2096	.2096	.2075	.1715	.1905	.2477	.1905
19	.362	.2477	.3395	.362	.4001	.3048	.3048
20	.4191	.4338	.4715	.4572	.4572	.4763	.5335
21	.3429	.2641	.3395	.2667	.2858	.2667	.3239
22	.2096	.1886	.0373	.0572		.0953	.0762
23	.1905	.1698	.0189	.0572	.0762	.0953	.0762
24	.1334	.1905	.1509	.0187	.0381	.0762	.0762
Max	.6602	.5525	.4715	.4572	.5144	.4763	.5335
Min	.0486	.0366	.0189	.0183	.0381	.0572	.0762
Avg	.2417	.2324	.1865	.1396	.1913	.1767	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 203 / 11 KV GEOVRAI PAIGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2667		.0701	.1143		.2667
2	.2641	.3048		.0686	.1524		.2667
3	.415	.381		.0848	.2286		.2896
4	.5658	.4954		.1006	.2835		.3506
5	.679	.6478		.1658	.3772		.4801
6	.7922	.8002		.2321	.4915		.583
7	.6413	.7049		.1989	.5426		.6516
8	.5281	.4954		.1886	.5335		.5716
9	.4904	.3429		.1132	.3429		.4572
10	.1132	.1829	.0381	.0381	.1905	.3429	.2667
11	.2507	.2667	.0678	.1143	.1905	.2286	.1524
12	.3429	.3429	.0754	.2667	.1524	.1905	.1905
13	.1966	.3048	.1017	.1905	.1433	.1905	.2286
14	.2035	.2667	.2347	.1905	.1433	.0381	.1524
15	.2267	.2667	.2881	.1905	.1143	.0381	.1524
16	.3086		.2683		.1791	.0381	.1524
17	.3189	.1524	.0671		.2172	.0381	.1524
18	.3429	.0762		.3048	.3048	.2667	.2667
19	.4954			.4191	.6097	.5716	.5144
20	.6097		.1886	.6097	.6478	.6859	.6097
21	.4572		.1509	.4191	.4191	.4191	.4954
22	.3429		.0377	.1524		.3048	.1905
23	.2667		.0554	.1524		.3048	.1524
24	.3239	.2667		.0537	.1143		.2858
Max	.7922	.8002	.2881	.6097	.6478	.6859	.6516
Min	.1132	.0762	.0377	.0381	.1143	.0381	.1524
Avg	.3949	.3647	.1312	.1966	.2951	.2613	.3283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 201 / 11KV GEVRAE GUNGI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.0838	.0838	.1886	.1886	.1886	.1886
2	.4191	.0838	.0838	.1886	.3772	.2829	.1886
3	.3353	.1677	.1677		.2829	.3772	.2829
4	.2515	.3353	.2515		.3772	.4715	.3772
5	.1677	.4191	.3353		.4715	.4715	.4715
6	.2515	.3353	.4191		.3772	.5658	.4715
7	.3353	.3353	.3353		.5658	.5658	.4715
8	.4715	.2829	.3772	.2829	.4715	.4715	.3772
9	.3772	.3772	.2829	.1886	.2829	.3772	.3772
10	.2829	.0943	.1886	.1677	.1677	.1677	.1677
11	.0943	.0943	.1886	.1677	.1677	.1677	.1677
12	.0943	.0943	.0943	.1677	.1677		.1677
13	.0943	.0943	.0943		.1677	.0838	.1677
14	.0943	.0943	.0943	.0838	.1677	.0838	.2515
15	.0943	.0943	.0943	.0838	.1677	.0838	.0838
16		.1886	.1886	.1677	.2515	.1677	.1677
17	.1886	.1886	.1886	.0838	.1677	.1677	.1677
18	.3772	.2829	.1886	.1886	.1886	.2829	.1886
19	.3772	.3772	.3772	.1886	.2572	.3772	.3772
20	.2829	.3772	.3772	.2829	.2829	.2829	.2829
21	.1886	.1886	.1886	.0943	.1886	.1886	.1886
22	.1677	.0838	.1886	.1886	.1886	.1886	.1886
23	.0838	.0838	.1886	.1886	.1886	.1886	.2829
24	.0838	.0838		.0943	.1886	.1886	
Max	.4715	.4191	.4191	.2829	.5658	.5658	.4715
Min	.0838	.0838	.0838	.0838	.1677	.0838	.0838
Avg	.2369	.2017	.2164	.1665	.2626	.2779	.2633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 202 / kolte takli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.1677	.1677		.4715	.3772	.3772
2	.3353	.2515	.2515		.3772	.3772	.3772
3	.4191	.2515	.3353		.4715		.4715
4	.3353	.3353	.3353		.3772	.6602	.5658
5	.4191	.4191	.4191		.4715	.6602	.6602
6	.503	.503	.3353		.4715	.7545	.6602
7	.3353	.3353	.3353		.5658	.7545	.7545
8	.7545	.4715	.4715	.7545	.6602	.5658	.6602
9	.6602	.5658	.3772	.5658	.5658		.6602
10	.5658	.2829	.4715	.1677	.2515	.3772	.0838
11	.2829	.2829		.2515	.2515	.4191	.1677
12		.2829		.2515		.3353	.2515
13	.1886	.2829	.2829	.2515	.3353	.3353	.2515
14	.2829	.2829	.2829	.2515		.3353	.2515
15	.2829	.2829	.2829	.1677		.3353	.3353
16	.2829	.3772	.2829			.3353	.3353
17	.4715	.3772	.3772	.1677		.3353	.3353
18	.5658	.5658	.5658	.2829		.5658	.5658
19	.6602	.6602	.6602	.4715		.6602	.6602
20	.5658	.7545	.5658	.6602		.5658	.7545
21	.4715	.4715		.5658		.5658	.5658
22	.2515	.1677		.4715		.3772	.6602
23	.1677	.1677		.3772		.4715	.5658
24	.1677	.1677			.5658	.3772	
Max	.7545	.7545	.6602	.7545	.6602	.7545	.7545
Min	.1677	.1677	.1677	.1677	.2515	.3353	.0838
Avg	.4118	.3628	.3778	.3772	.4489	.4791	.4770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 201 / 11KV BANOTI-AG- FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.8764	1.1812	1.2193	1.2574	1.2574	1.5242	1.6385
13	.9907	1.3717	1.1431	1.3717	1.6385	1.5242	1.6004
14	1.0288	1.4098	1.1431	1.3336	1.6004	1.4289	1.4098
15	1.0669	1.2574	1.0288	1.1431	1.448	1.2955	1.2765
16	1.0669	1.1431	1.0669	1.1812	1.2955		1.2574
17	1.0669	1.2574	1.0669		1.2193		1.2193
18	.8383		.9526		1.1812	1.448	
19	.6859	1.1431	.6859		.9526	1.105	.9526
Max	1.0669	1.4098	1.2193	1.3717	1.6385	1.5242	1.6385
Min	.6859	1.1431	.6859	1.1431	.9526	1.105	.9526
Avg	.9526	1.2520	1.0383	1.2574	1.3241	1.3876	1.3364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 202 / 11 KV NANDGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.2667	.3048	.3429	.3429
2		.3048	.2286	.3048	.3048	.3429
3		.3048	.3048	.3048	.3429	.4191
4		.3429	.3429	.3429	.381	.5335
5		.381	.381	.381	.4572	.724
6		.7621	.4954	.9145	.9526	.8764
7		.9526	.4954	1.1812	1.2574	1.2193
8		.7621	.5335	1.105	1.2193	.9907
9		.8383	.6097	.9526	.8764	.724
10		.8002	.6478	.8764	.6859	.7621
11						.724
16	.4572					
17	.7621					
Max	.7621	.9526	.6478	1.1812	1.2574	1.2193
Min	.4572	.3048	.2286	.3048	.3048	.3429
Avg	.6097	.5792	.4306	.6668	.6820	.6963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 203 / 11 K V WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.1524	.4954	.2667	.1524			.5525
13	.5335	.4191			.5716	.4572	.5716
14	.4954	.5335			.5335	.4191	.5335
15	.4191	.4954	.381		.5335	.381	.4001
16	.4191	.4191	.3429		.5335	.381	.4001
17	.381	.4954	.3429		.5716	.4572	.381
18	.1905				.4572	.3048	.2667
19	.1905	.4191			.3429	.2286	.2286
Max	.5335	.5335	.381	.1524	.5716	.4572	.5716
Min	.1524	.4191	.2667	.1524	.3429	.2286	.2286
Avg	.3477	.4681	.3334	.1524	.5063	.3756	.4168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 204 / 11 KV BANOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.3048	.2096	.2096	.2858	.2667	.2667
2	.2477	.2667	.2286	.2286	.2858	.3048	.3048
3	.2667	.3048	.3429	.3429	.3048	.3429	.3429
4	.381	.3429	.381	.381	.3429	.381	.381
5	.6097	.4954	.4572	.4572	.4191	.4572	.4572
6	.724	.7621	.724	.6859	.7621	.7049	.724
7	.7049	.724	.6859	.724	.7621	.6287	.724
8	.6668	.6097	.2096	.6668	.6859	.5716	.6478
9	.4954	.4572	.4763	.4763	.5335	.4191	.6097
10	.4191	.3429	.4191	.3429	.3429	.3048	.381
11	.3429	.2096	.3048	.2858	.3048	.2667	.3429
12	.3048	.2667	.2477	.2858	.2858	.2477	.2667
13	.3048	.2667	.2858	.2858	.2667	.2477	.2667
14	.3048	.2667	.2667	.2858	.3048	.3048	.2667
15	.2667	.3429	.2858		.3429	.2858	.2477
16	.3048	.381	.3429	.3429	.3429		.3239
17	.381		.3048		.381		.381
18	.4572	.4191	.4191		.4954	.4191	.4954
19	.724	.6859	.6668		.6097	.6859	.5906
20	.724	.6097	.6097	.6859	.5716	.6478	.381
21	.4572	.5335	.4191	.4763	.381	.4001	.4191
22	.381	.381	.3048	.3429	.3429	.3239	.3239
23	.3429	.2667	.2667	.3048	.3048	.3048	.3048
24	.2477	.3048	.2286	.2477	.2858	.2667	.2667
Max	.724	.7621	.724	.724	.7621	.7049	.724
Min	.2477	.2096	.2096	.2096	.2667	.2477	.2477
Avg	.4295	.4150	.3786	.4029	.4144	.3992	.4048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 205 / Hanumantkheda gaothan
feeder Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.2286	.2286	.1715	.2096	.2096
2	.1715	.1715	.2286	.2286	.1524	.2096	.2096
3	.1715	.1905	.1905	.2477	.1715	.2286	.2286
4	.1905	.2286	.2477	.2667	.1905	.2286	.2667
5	.2096	.2667	.2667	.3429	.2477	.2667	.3429
6	.2477	.4382	.381	.4382	.4572	.4191	.381
7	.2858	.3429	.4191	.362	.2858	.381	.3429
8	.3048	.3048	.2667	.3239	.2858	.3429	.2858
9		.2667	.1905	.2286	.3048	.2477	.2286
10		.1905	.1143	.1905	.1905	.1905	.1715
11		.1905	.0762		.1524	.1524	.1334
12		.1524	.0953		.1334	.1524	.0953
13		.1334	.1143		.1524	.1715	.1334
14		.1334	.1143		.1524	.1905	.1334
15			.1143		.1334	.1905	.1524
16			.1143	.1715	.1905	.1905	.1524
17		.1905	.1524		.2667	.2286	.1524
18	.2286				.3048	.2667	.2286
19	.3429	.3048			.3429	.3239	.3048
20	.2286	.3429	.1905	.2096	.4001	.3429	.381
21		.381	.1905	.2858	.381	.2477	.3048
22	.2667	.2667		.2477	.2667	.2096	.2096
23	.2286	.1905	.1524	.2096	.1905	.1905	
24	.0953	.2096	.1524	.1334	.1715	.1143	.1905
Max	.3429	.4382	.4191	.4382	.4572	.4191	.381
Min	.0953	.1334	.0762	.1334	.1334	.1143	.0953
Avg	.2245	.2422	.1905	.2572	.2374	.2373	.2278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 206 / Wakdi Gaothan feeder
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0572	.0762
2	.0762	.0762	.0572	.0762	.0572	.0762	.0762
3	.0762	.0953	.0953	.0953	.0762	.0762	.0953
4	.0953	.1143	.1143	.1143	.0953	.0953	.1143
5	.1524	.1524	.1524	.3429	.1143	.1143	.1524
6	.2096	.2667	.3048	.2286	.2858	.1524	.2477
7	.1905	.2286	.2667	.2286	.2096	.2286	.1905
8	.1715	.2096	.2286	.2096	.1905	.1905	.1905
9	.1715	.1524	.1334	.1905	.1905	.1524	.1715
10	.0953	.1143	.0953	.1143	.1143	.0953	.0762
11	.0762	.0762	.0572	.0762	.0762	.0762	.0572
12	.0762	.0762	.0381	.0381		.0762	.0572
13	.0762	.0381	.0572	.0572	.0953	.0572	.0762
14	.0762	.0381	.0572	.0572	.0762	.0762	.0762
15	.0762	.0381	.0572	.0572	.0762	.0762	.0762
16	.0762	.0762	.0381	.0572	.0953	.0762	.0572
17	.0762	.1143	.0381		.1143	.0762	.0381
18	.1334		.0953		.1524	.1143	.0953
19	.2286	.1524	.1524		.1905	.1524	.1715
20	.2286	.2286	.1715	.1524	.2286	.2286	.2096
21	.1715	.1905	.1143	.1715	.1334	.1524	.1334
22	.1143	.1143	.0762	.1143	.1143	.0953	.0762
23	.0953	.0762	.0572	.0953	.0762	.0762	.0762
24	.0953	.0762	.0572	.0572	.0762	.0572	.0762
Max	.2286	.2667	.3048	.3429	.2858	.2286	.2477
Min	.0762	.0381	.0381	.0381	.0572	.0572	.0381
Avg	.1215	.1209	.1080	.1243	.1267	.1096	.1111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 207 / 11 KV GONDEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.7621	1.1812	.6097			.9907	.9907
13	1.1431	1.2955	.5716	.8764		1.5242	
14	.9145	1.1431	.5335	1.2955			1.1812
15	.7621	1.0288	.6097	1.1812	.5335	.9145	1.3336
16	.8383	1.0669			.7621	.9145	1.2193
17	.9145	1.0288			.9145	1.4861	1.0669
18	.6097				1.1431	.9145	.9907
19	.6859	.9526	.3048		.8002	.9907	.9145
20					.7621		
Max	1.1431	1.2955	.6097	1.2955	1.1431	1.5242	1.3336
Min	.6097	.9526	.3048	.8764	.5335	.9145	.9145
Avg	.8288	1.0996	.5259	1.1177	.8193	1.1050	1.0996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 208 / 11 K V HANUMANT KHEDA SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.3048	.3048	.3048	.3048	.3429
2		.3429	.3048	.3048	.3048	.2667	.3429
3		.3429	.3429	.3429	.3048	.3048	.4191
4		.3429	.381	.5335	.3429	.3429	.5716
5		.381	.5335	.6859	.381	.4191	.9145
6		.6478	.9526	.8383	1.0288	.8764	1.0669
7		.9145	1.0669	1.2384	1.4098	1.2574	1.3717
8		.9526	1.1431	1.0669	1.3717	1.3717	1.2574
9		.8383	.7621	.9907	.8764	.8002	.9145
10		.7621	.7621	.7621	1.0288	.724	.5716
11							.5335
18	.8002						
19	.9907						
Max	.9907	.9526	1.1431	1.2384	1.4098	1.3717	1.3717
Min	.8002	.3429	.3048	.3048	.3048	.2667	.3429
Avg	.8955	.5906	.6554	.7068	.7354	.6668	.7551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 209 / 11 KV GONDEGAON GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2286	.2286	.381	.0381	.3429
2	.3429	.3048	.2286	.2286	.3429	.0381	.9145
3	.3429	.3048	.3048	.3048	.381	.0381	.381
4	.381	.3429	.381	.381	.4191	.0381	.4572
5	.381	.4191	.4954	.4954	.4572	.0381	.5335
6	.6097	.5716	.6859	.6097	.6859	.0381	.6478
7	.6097	.5716	.6478	.5716	.6097	.0381	.5716
8	.6097	.5335	.5716	.5716	.5335	.0381	.5716
9	.4954	.4572	.381	.4572	.4572		.5335
10	.381	.4191	.381	.381	.4191		.4763
11	.381	.3429	.381	.381		.4572	.4191
12	.3429	.3048	.381	.381	.2858	.4191	.381
13	.381	.3429	.3048	.381	.3429	.4572	
14		.381	.3048	.381		.4572	.4191
15	.381	.381	.381	.381	.381	.4572	.4572
16	.4191	.4191	.381	.4572	.381	.4572	.4191
17	.4191	.4572	.381		.4191	.4572	.4191
18	.4572		.4191		.5335	.5335	.4572
19	.6097	.6478	.4954		.6478	.5716	.5144
20	.6859	.6097	.6097	.6859	.6097	.6478	.5716
21	.4954	.4954	.5335	.5335		.5335	.5335
22	.4572	.4191	.4572	.4572	.0381	.4954	.4572
23	.4191	.6097	.4191	.4191	.0381	.4572	.4382
24	.381	.381	.2667	.381	.381	.0381	.4191
Max	.6859	.6478	.6859	.6859	.6859	.6478	.9145
Min	.3429	.3048	.2286	.2286	.0381	.0381	.3429
Avg	.4489	.4374	.4175	.4318	.4164	.3066	.4929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 210 / 11 KV Nandgaon Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1905	.1905		.1905	.1905
2	.1905	.1524	.1905	.1905		.1905	.1905
3	.1905	.1715	.2286	.2286		.2286	.2286
4	.2096	.2096	.2667	.2667		.2667	.2667
5	.2286	.2477	.3048	.3048		.3048	.3048
6	.3048	.3429	.4191	.4191		.4191	.381
7	.3429	.3429	.381	.381		.381	.3429
8	.3239	.2858	.3429	.3429		.381	
9	.2858	.2667	.3048	.1905		.2667	.2667
10	.2286	.2286	.2667	.1524	.2667	.2286	.2477
11	.1905	.1905	.1905	.1524	.2286	.1905	.2286
12	.1524	.1524	.1524	.1524	.1905	.1905	.1905
13	.1524	.1524	.1524	.1524	.1524	.1524	.1334
14	.1524	.1524	.1143	.1524	.1524	.1524	.1334
15	.1715	.1524		.1524	.1334	.1524	.1334
16	.1905	.1905	.1524	.1905	.2286	.1905	.1524
17	.2286	.2667	.1905		.3048	.2286	.1715
18	.2858				.3429	.2667	.2286
19	.3429	.3429			.381	.3429	.3048
20	.3429	.2286	.4191		.4191	.381	.381
21	.2858	.3048	.381	.2858	.3429	.3048	.3048
22	.2477	.3429	.3048	.2477	.3048	.2667	.2286
23	.2096	.2667	.2286	.2096	.2286	.2286	.1905
24	.1905	.1905	.2286	.1905		.1905	.1905
Max	.3429	.3429	.4191	.4191	.4191	.4191	.381
Min	.1524	.1524	.1143	.1524	.1334	.1524	.1334
Avg	.2350	.2328	.2576	.2277	.2626	.254	.2344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 201 / 11 K V SOYEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-JUN-18
HR	Load (MW)
10	.5441
Max	.5441
Min	.5441
Avg	.5441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 202 / 11 K V GALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-JUN-18
HR	Load (MW)
10	.3045
Max	.3045
Min	.3045
Avg	.3045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 203 / JARANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JUN-18
HR	Load (MW)
21	.2561
Max	.2561
Min	.2561
Avg	.2561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 205 / 11KV LIHA FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
10		.2949
21	.2865	
Max	.2865	.2949
Min	.2865	.2949
Avg	.2865	.2949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 204 / 11 KV SAWALADBARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0953	.0953	.0953	.0953	.0953	.0762	.0953
Max	.0953	.0953	.0953	.0953	.0953	.0762	.0953
Min	.0953	.0953	.0953	.0953	.0953	.0762	.0953
Avg	.0953	.0953	.0953	.0953	.0953	.0762	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 205 / 11KV Molkheda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.0288	.8573	.8573	.8573	.8573	1.0288	.9907
Max	1.0288	.8573	.8573	.8573	.8573	1.0288	.9907
Min	1.0288	.8573	.8573	.8573	.8573	1.0288	.9907
Avg	1.0288	.8573	.8573	.8573	.8573	1.0288	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 201 / 11 KV KINHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381		.9145	.9431	1.0479
2	.0191	.0381	.0762	.6668	1.0669	1.0288	1.1431
3	.0191	.0381	.0572		1.1431	1.0974	1.3336
4	.0191	.0381	.0572	.724	1.2193	1.2003	1.5623
5	.0191	.0381	.0572		1.2955	1.3748	1.7147
6	.0191	.0381	.0572	.743	1.3908	1.643	1.7528
7	.0191	.0381	.0572		1.448	1.4251	1.8861
8	.0191	.0381	.0572	.8573	1.4289	1.5402	1.8861
9	.0191	.0381			1.2003	1.3375	1.7147
10	.0381	.0381	.0381	1.0288	1.5089	1.5242	1.3717
11		.0381			.0762	.1143	
12		1.105	1.2765		.0572	.1905	.0191
13		1.4289			.0572		
14		1.448			.0953	.1143	.0191
15	.7373	1.4861			.0762	.0953	
16		1.5242	1.6385	.0191	.1143	.0953	.0381
17	1.166	1.5242			.1334	.1143	
18	1.1488				.0953	.0953	.0572
19	.7202	.9907			.1334	.0953	
20	.0572	.0762	.0191	.1905	.1334	.1143	.0953
21	.0572	.0953			.1143	.1143	
22	.0381	.1143	.0381	.0953	.1143		.0762
23	.0762	.0953	.0381	.0762	.0953		.0572
24	.0381	.0762	.0572	.0381	.0762	.1143	.0953
Max	1.166	1.5242	1.6385	1.0288	1.5089	1.643	1.8861
Min	.0191	.0381	.0191	.0191	.0572	.0953	.0191
Avg	.2236	.4515	.2375	.4439	.5828	.6844	.8817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 202 / 11 KV KINHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2667	.2667	.2667	.2667	.2667
2	.2477	.2858	.3048		.2858	.2667	.2858
3	.2858	.3429	.3429	.3048	.2858	.3429	.362
4	.381	.4191	.4572		.3429	.381	.5716
5	.4954	.4954	.5144	.4763	.5525	.4191	.6097
6	.5525	.5316	.5716		.5335	.4801	.6668
7	.4001	.5144	.6478	.5335	.5906	.5487	.5716
8	.4954	.5487	.5525		.5144	.5144	.5335
9	.4001	.4801		.4001	.4572	.4801	.5144
10	.3429	.3048	.3429		.381	.381	.381
11	.2096	.1905		.2667	.2477	.2858	
12	.2096	.1905	.2667		.2096	.2667	.2667
13	.2096	.1905		.2286	.2286	.2286	
14	.2096	.2286			.2286	.2667	.2477
15	.2477	.2477		.2286	.2477	.2286	
16	.2477	.3048	.2858		.2096	.2286	.2858
17	.2667	.362			.2477	.2667	
18	.362				.381	.362	.381
19	.5144	.6097			.4572	.5525	
20	.4973	.5906	.4954		.463	.6097	.5335
21	.362	.4191		.381	.381	.4191	
22	.2858	.3239	.3239		.3429	.3429	.3429
23	.2858	.3048	.2858	.2858	.3048	.2858	.2858
24	.2477	.2858	.2858	.2667	.2858	.2858	.2858
Max	.5525	.6097	.6478	.5335	.5906	.6097	.6668
Min	.2096	.1905	.2667	.2286	.2096	.2286	.2477
Avg	.3335	.3669	.3963	.3308	.3519	.3629	.4107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 203 / 11 KV WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2286	.2286		.0381	.0381	.0572
2	.3048	.2286	.2667	.0381	.0381	.0381	.0572
3	.3048	.2858	.3048		.0381	.0381	.0572
4	.3048	.3429	.3429	.0381	.0381		.0572
5	.3048	.4191	.5335		.0381	.0381	.0381
6	.3429	.5121	.6859	.0381	.0381	.0381	.0572
7	.5525	.7202	.724		.0381	.0381	.0381
8	.4954	.583	.724	.0381	.0381	.0381	.0381
9	.4382	.4801				.0381	.0381
10	.2286	.439	.4382	.0191		.0381	.0381
11	.0381	.0572				.0572	
12	.0381		.0381	.4572			.362
13	.0381	.0381					
14	.0381	.0381		.381		.6478	.5716
15	.0381	.0381				.6859	
16	.0381	.0381	.0381	.3429		.7621	.5716
17	.0381	.0381				.8764	
18	.0381		.0191		.9774	.724	.6097
19	.0381				.6516	.4572	
20		.0381	.0381	.0381	.4458	.0572	.0381
21	.0381	.0381			.381	.0572	
22	.0381	.0572	.0381	.0381	.0381	.0572	.0381
23	.0381	.0572	.0381	.0381	.0381	.0572	.0381
24	.0381	.0381	.0572	.0381	.0381	.0572	.0572
Max	.5525	.7202	.724	.4572	.9774	.8764	.6097
Min	.0381	.0381	.0191	.0191	.0381	.0381	.0381
Avg	.1773	.2246	.2822	.1254	.1917	.2305	.1535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 201 / 11Kv Ghosla new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.362	.4191	.3048
2	.381	.3239	.4572	.3429
3	.4001	.2667	.4763	.381
4	.4572	.4191	.4572	.4191
5	.4763	.6287	.4954	.5335
6	.4954	.8383	.6287	.6859
7	.6478	.9526	.8383	.6097
8	.6478	1.105	.9526	.4763
9		.5716	.8192	
10	.4572	.4572	.4954	.3239
11	.2858	.2286	.2096	.2858
12		.2667	.2477	1.0288
13	.2858	.3048		1.0098
14	.3048	.3429	.2858	.8192
15	.3239	.3048	.2667	.5335
16	.3048	.3239	.2858	.5525
17	.3239	.381	.3239	.5144
18	.381	.4382		.381
19	.4954			.1905
20	.5525	.5906	.5525	.4763
21	.4763	.4763	.4572	.4001
22	.381	.362	.381	.3429
23			.3429	.3048
24		.381	.381	.3048
Max	.6478	1.105	.9526	1.0288
Min	.2858	.2286	.2096	.1905
Avg	.4210	.4694	.4654	.4879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 202 / 11Kv Bahulkheda new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3429	.1905	.362	.4191
2	.4954	.3239	.2096	.4191	.4763
3	.5335	.362	.2286	.5144	.5144
4	.5906	.381	.2477	.5906	.5906
5	.6097	.4191	.2286	.6287	.6859
6	.6287	.381		.6859	.8002
7	.6859	.4001		.8954	.8954
8	.724	.381		1.0288	1.0479
9				.8573	
10	.2667		.3048	.5716	
11	.2477	.2667	.2858		
12	.743	.6668	.4001		
13	.7811	1.1241			
14	.8383	1.0479	.5144	.4001	
15	.8954	.9145	.6287	.3429	
16	.8002	.6859	.7049	.362	
17	.724	.7049	.724	.381	
18	.6668	.724	.5335		
19	.5906		.4763	.362	
20	.4572		.4572	.4954	
21	.4382	.1715	.3429	.4382	
22	.4001	.2096	.3429	.4382	
23			.3048	.4191	
24		.3239	.1715	.3048	.381
Max	.8954	1.1241	.724	1.0288	1.0479
Min	.2477	.1715	.1715	.3048	.381
Avg	.5988	.5174	.3840	.5249	.6456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 203 / 11Kv Jarandi new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3239	.362	.362	.381
2	.4001	.3429	.381	.381	.4191
3	.381	.362	.4001	.4191	.4572
4	.4572	.4001	.381	.4572	.5144
5	.5335	.4382	.4191	.4954	.5906
6	.5906	.4763	.3429	.5525	.6668
7	.4763	.5144	.2858	.7621	.8192
8	.362	.4572		.724	1.0288
9		.381	.2477	.6097	
10	.2858	.3239	.2286	.6097	
11	.2667	.3239	.2096	.2858	
12	.7811	.6287	.1905	.2477	
13	.7621	.9717		.2858	
14	.7811	.9145	.4191		
15	.8002	.8764	.5335	.3239	
16	.8192	.8383	.5716	.3429	
17	.8573	.724	.4763	.362	
18	.743	.6287	.4382	.362	
19	.5906		.4191	.4572	
20	.4763	.4191	.4572	.4954	
21	.4382	.381	.4001	.4191	
22	.4001	.3429	.362	.362	
23			.3429	.362	
24		.3048	.3239	.3239	.3239
Max	.8573	.9717	.5716	.7621	1.0288
Min	.2667	.3048	.1905	.2477	.3239
Avg	.5516	.5170	.3724	.4349	.5779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 201 / 11 KV WADALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3969	.3562	.3416	1.1374	1.2644	1.2496	1.1592
2	.3969	.3753	.2989	.8351	1.295	1.3315	1.23
3	.4347	.4129	.3869	.9025	1.3175	1.2742	1.2915
4	.6615	.4854	.797	.9698	1.4415	1.4447	1.4452
5	.8505	.5249	1.0405	1.1045	1.5508	1.6442	1.6912
6	1.0773	.5041	1.0551	1.3739	1.8967	1.8505	1.9065
7	.9072	.9729	.9496	1.7839	2.3704	1.9443	2.1217
8	.756	.844	.8089	1.6883	2.4045	1.9767	2.091
9	.6804	.7138	.7211	1.8198	1.826	2.0875	
10	.4563	.4504	.4744	1.5924			
11		.3226	.2257		.2657	.4554	
12	1.7888	1.5493	1.8428	.1858	.2277	.3969	.1471
13	1.8204	1.6901	1.918	.1858	.1518	.3803	.2213
14	1.826	1.6251	1.8804		.1518	.3423	
15	1.6718	1.5908	1.8052	.185	.4175	.3042	
16	1.6718	1.4934	1.73		.4554	.2662	.2954
17	1.7407	1.6232	1.4556			.3803	.3275
18	1.702	1.5908	1.31	.2975	.3985	.4183	.3688
19	1.8111		1.3682	.5544	.5693	.3803	.6557
20	.7438	.7211	.6113	.8123	.759	.7986	.8006
21	.559	.6831	.4658	.559	.6831	.6084	.5476
22	.4129	.4934	.3493	.4268	.4554	.4162	.4731
23	.3738	.4175	.2911	.334	.3795	.3405	.4045
24	.3969	.3558	.3795	.3412	.3347	.3605	.3405
Max	1.826	1.6901	1.918	1.8198	2.4045	2.0875	2.1217
Min	.3738	.3226	.2257	.185	.1518	.2662	.1471
Avg	1.0059	.8607	.9378	.8545	.9371	.8979	.9220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 202 / 11KV NIMDONGRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.417	.3601	.3528	.4914	.4515	.5357	.464
2	.417	.399	.3425	.3804	.4696	.5688	.5164
3	.417	.453	.4572	.3804	.4696	.6006	.5164
4	.5118	.5276	.5639	.4097	.5948	.7142	.5648
5	.7204	.7514	.6858	.4536	.8841	.909	.7262
6	.7772	.8513	.8168	.6877	.9923	1.0726	1.0489
7	.7204	.7514	.6843	.7755	1.3323	1.2676	1.2587
8	.5497	.3941	.4045	.8487	1.205	1.185	1.291
9	.436	.4864	.3985	.8641	1.0814	1.109	1.1135
10	.3033	.3605	.3605	.7449	1.0247	1.0194	.9359
11	.2884	.2467	.2437	.2167	.2657	.2657	.2154
12	1.0409	1.2714	1.1436	.1987	.2081	.2029	.2163
13	1.0157	1.0726	1.1623	.1987	.2087	.2273	.2345
14	.9153	.9426	1.0873	.217	.2277	.2273	.2353
15		.7828	.9749	.2165	.2087	.2841	.2172
16	.8102	.6915	1.0686		.2087	.2651	.2172
17	.9542	.7792	1.1061		.2459	.2651	.2177
18	1.0317	.8278	.7934	.2333	.2657	.2651	
19	.8803	.6811	.6429	.3244	.3416	.5103	
20	.5923	.6452	.4788	.6495	.6452	.6048	.6683
21	.5321	.4934	.4104	.4979	.5503	.5292	.5682
22	.4553	.4744	.342	.4412	.4364	.4725	.4172
23	.429	.4351	.3146	.3688	.4175	.3969	.37
24	.417	.3897	.4175	.3969	.3421	.3784	.378
Max	1.0409	1.2714	1.1623	.8641	1.3323	1.2676	1.291
Min	.2884	.2467	.2437	.1987	.2081	.2029	.2154
Avg	.6362	.6278	.6355	.4544	.5449	.5782	.5632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 203 / 11 KV NANDGIRWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4275	.3486	.2936	.4874	.5315	.5044	.5497
2	.4275	.332	.3585	.4924	.5315	.487	.5329
3	.4632	.3138	.4275	.5303	.5516	.523	.5329
4	.5344	.3132	.4778	.606	.5853	.6276	.6471
5	.6235	.5217	.5261	.7007	.6584	.7386	.7233
6	.6769	.6067	.5755	.8143	.8265	.8175	.7994
7	.8551	.7554	.6577	.7954	.7514	.7132	.7233
8	.8907	1.0021	.7665	.6439	.5798	.6617	.6281
9	.8551	.793	.7339	.4934	.6136	.5213	.571
10	.6947	.7401	.6034	.4175	.5123	.4364	
11	.3753			.3639	.4744	.4175	.4367
12	.3515	.4175		.8031	.8278	.7749	.8587
13	.3715	.3649	.4954	.6936	.7638	.6652	.7304
14		.3653	.4763	.6368	.6176	.6807	.6235
15	.4549	.3823	.4382	.6725	.559	.526	.6348
16	.4979	.3823	.4572		.6125	.5879	.6241
17	.4534	.417	.381			.5724	.6241
18	.4701	.4865	.3937	.7642	.6412	.6343	.5552
19	.6067	.6262	.5062	.7824	.6013	.4932	.564
20	.6767	.7757	.7499	.8153	.759	.6363	.7074
21	.6388	.6072	.6562	.6732	.6635	.5568	.5822
22	.5764	.6072	.6374	.6361	.6072	.606	.5073
23	.5348	.6072	.5812	.5798	.5693	.5681	.5041
24	.4988	.5095	.5481	.5812	.5629	.5503	.5303
Max	.8907	1.0021	.7665	.8153	.8278	.8175	.8587
Min	.3515	.3132	.2936	.3639	.4744	.4175	.4367
Avg	.5633	.5337	.5337	.6356	.6261	.5958	.6170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 204 / 11KV HIWARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6458	.5249	.4566	.8676	.802	.8316	.8479
2	.6458	.5426	.5261	.8659	.7778	.8316	.8496
3	.6798	.5533	.6417	.9035	.8148	.834	.8685
4	.7987	.5902	.6742	.9976	.9055	.9741	1.0195
5	.9007	.7267	.77	1.0918	1	1.0285	1.114
6	.9857	.8359	.8181	1.2047	1.1145	1.0761	1.2272
7	1.1046	1.2074	.9634	1.1895	1.184	1.112	1.2461
8	1.2236	1.2198	1.2394	1.1517	1.1168	1.0263	1.0762
9	1.1216	1.1446	1.1253	1.8107	.9374	.9209	.9251
10	.8663	1.0247	.9785	.8676	.759	.778	
11	.7514				.6642	.7401	.7008
12	.5653			1.147	1.1863	1.1841	1.1088
13	.563	.6452	.724	1.2923	1.4786	1.1392	1.1088
14	.5249	.556	.724	1.0708		1.0314	.9009
15	.6086	.6081	.7049	1.1065	.325	.9236	.9406
16	.6803	.7298	.743		.3588	.9698	.9774
17	.6824	.7993	.8002			1.0006	1.1031
18	.8299	1.0206	.958	1.0112	1.0888	.939	.8131
19	.9347	1.0395	.8641	.9928	1.12	.8802	.8316
20	1.0154	1.0584	1.0708	.9037	.9488	.8488	1.0164
21	.8861	.9108	.9393	.9454	.9478	.8016	.9288
22	.8308	.8892	.9017	.8861	.8349	.9072	.8757
23	.7671	.8505	.8641	.8165	.8513	.8694	.8299
24	.7478	.7938	.7938	.8865	.7947	.8349	.8505
Max	1.2236	1.2198	1.2394	1.8107	1.4786	1.1841	1.2461
Min	.5249	.5249	.4566	.8165	.325	.7401	.7008
Avg	.8067	.8305	.8310	1.0481	.9096	.9368	.9635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 205 / 11KV BAHIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6747	.677	.6686	.7938	.913	.8368	.8483
2	.7266	.6501	.7852	.7482	.9044	.8019	.7913
3	.7612	.7095	.8535	.7838	.8624	.8523	.7913
4	.865	.7301	.8473	.9263	.913	.9741	.932
5	1.0034	.9719	.856	1.0332		1.0785	1.1606
6	1.0553	1.0434	.9536	1.247	1.2949	1.1828	1.354
7	1.4012	1.2817	1.1538	1.4251	1.3457	1.2524	1.3189
8	1.4358	1.4204	1.2026	1.1401	1.221	1.1667	1.2485
9	1.1936	1.28	1.0274	.9069	1.0729	1.0264	.932
10	1.1417	1.0413	.9133	.6892	.797	.9298	
11	.6224	.5693	.5113	.6542	.5545	.6262	.7131
12	.5853	.4865	.3977	1.2235	1.1687	.9758	1.2489
13	.5647	.4865	.4545	1.3512	1.2012	1.0812	1.1888
14		.5039	.5303	1.201	.9913	1.0328	1.1632
15	.4879	.5213	.606	1.1962	.9751	.9198	1.0847
16	.5442	.5386	.6249		.9415	.8875	.7698
17	.5233	.6255	.6249		.9739	.8875	.9758
18	.5601	.9209	.6646	1.1962	1.1096	.9682	1.0296
19	1.0269	1.1351	.8123	1.2761	.7747	.8356	.8971
20	1.2203	1.2096	1.3846	1.2949	1.2334	1.1469	1.2787
21	1.1225	1.0626	1.1446	1.1588	1.0626	1.0159	1.1134
22	1.0353	1.0017	1.0523	1.0895	1.0437	1.0656	1.0498
23	.9233	.9072	.9231	.9758	1.0057	.9211	1.0093
24	.865	.8453	.8539	.9046	.9571	.9507	.885
Max	1.4358	1.4204	1.3846	1.4251	1.3457	1.2524	1.354
Min	.4879	.4865	.3977	.6542	.5545	.6262	.7131
Avg	.8843	.8591	.8269	1.0553	1.0138	.9757	1.0341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 206 / WADALI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0951	.0897	.0722	.7621	.0574	.0836	.0762
2	.0913	.0828	.0608	.0723	.0619	.0741	.0743
3	.0761	.0644	.055	.0665	.0648	.0721	.0743
4	.1084	.0723	.0531	.0894	.0674	.0987	.0953
5	.1426	.1076	.129	.1103	.0968	.1159	.141
6	.1692	.1274	.1518	.1768	.1482	.1214	.1543
7	.1749	.1282	.1082	.1787	.1477	.1457	.1677
8	.1407	.1218	.0911	.1597	.1331	.1784	.1791
9	.135	.1017	.1387	.1521	.1396	.1632	.1448
10	.0989	.0892	.1064	.1008	.0969	.1026	.101
11		.0569	.0667	.0478	.0608	.0513	.0641
12	.0341	.0323	.0305	.033	.0417	.0475	.0514
13	.0296	.0285	.0266	.0261	.0304	.0305	.0277
14	.0297	.0323	.0343		.0342	.0304	.0278
15	.0296	.0323	.038	.0325	.038	.0343	.0296
16	.0276	.0304	.0495		.0323	.0476	.0299
17	.031	.038	.0456		.0474		.0431
18	.0537	.0608	.0723	.0361	.0513	.0343	.0696
19	.0839	.1063	.0646	.0803	.0854	.1067	.0834
20	.1126	.1366	.1448	.1408	.1558	.1867	.1499
21	.1017	.1176	.1445	.109	.1385	.1124	.1251
22	.0892	.1214	.1008	.0849	.1101	.1353	.1112
23	.0695	.0797	.0762	.0753	.0911	.0914	.1215
24	.1065	.0427	.0721	.0724	.0643	.0835	.0819
Max	.1749	.1366	.1518	.7621	.1558	.1867	.1791
Min	.0276	.0285	.0266	.0261	.0304	.0304	.0277
Avg	.0883	.0792	.0805	.1241	.0831	.0934	.0927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 201 / 11 KV WADNER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1241	.1242		.0775		.0351	.0775
2	.1241	.1242		.0775		.0175	.0775
3	.1241	.1242		.0775		.0175	.0775
4	.1551	.1242		.0775		.0175	.0775
5	.1551	.1553		.0775		.0175	.0775
6	.1551	.2329		.0775		.0175	.0775
7	.2326	.2329		.0775		.0175	.0775
8	.3102	.1863		.0775		.0175	.0775
9	.2326	.1553		.0775		.0175	.0775
10	.2326	.1553	.3506	.0775		.0175	.0775
11	.0776	.0876	.0465	.0776		.0155	.0776
12	.0311	.0701	.0775	.2329		.3877	.7764
13	.0311	.0701	.0775	.3105			.854
14	.0466	.0701	.0775		.6135		.854
15	.0466	.0701	.0775		.6135		.7453
16	.0466	.0351	.0775				.6987
17	.0466	.0351	.0775		.1753		.7764
18	.0776		.0775		.1753	.6979	.6987
19	.0776		.0775		.1753	.6203	.7764
20	.0466	.0351	.0775		.0526	.0775	.0776
21	.0466	.0526	.0775		.0351	.0775	.0776
22	.0466	.0526	.0775		.0351	.0775	.0776
23	.0466	.0351	.0775		.0351	.0775	.0776
24	.0775	.0466	.0351	.0775		.0351	.0775
Max	.3102	.2329	.3506	.3105	.6135	.6979	.854
Min	.0311	.0351	.0351	.0775	.0351	.0155	.0775
Avg	.1080	.1034	.0908	.1053	.2123	.1189	.3092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 202 / 11 KV AMBA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0786	.0948	.1052	.0786	.0948	.1052	.0786
2	.0786	.0948	.1052	.0786	.0948	.1052	.0786
3	.0786	.0948	.1052	.0786	.0948	.1052	.0786
4	.0786	.0776	.1052	.0786	.0948	.1052	.0786
5	.0786	.0948	.1402	.0786	.1137	.1052	.0786
6	.0786	.1517	.1402	.0786	.1327	.1402	.0786
7	.1572	.1896	.1753	.0786	.1137	.2103	.0786
8	.1572	.2275	.2103	.0786	.1137	.2103	.0786
9	.1572	.1517	.2103	.0786	.1137	.2103	.0786
10	.1572	.1517	.1753	.0786	.0948	.0876	.0786
11	.0948	.0876	.0472	.0948		.0314	.0948
12	.0948		.0786	.7583		.6287	.7583
13	.0948		.0786	.7583	.3506	.6287	.7583
14			.0786	.5687	.5258	.5501	.7583
15			.0786	.417	.5258	.3929	.7583
16			.0786	.2329	.4382	.3929	.7583
17	.0948		.0786	.2329	.7888	.3929	.7583
18	.1137		.0786	.3791	.5258	.3144	.7583
19	.0948		.0786	.2844	.3506	.3144	.7583
20	.0948	.0526	.0786	.1137	.1402	.0786	.1327
21	.0948	.1052	.0786	.1137	.2103	.0786	.1327
22	.0948	.1052	.0786	.1137	.1753	.0786	.1137
23	.0948	.1052	.0786	.1137	.1753	.0786	.0948
24	.0786	.0948		.0786	.1137	.1052	.0786
Max	.1572	.2275	.2103	.7583	.7888	.6287	.7583
Min	.0786	.0526	.0472	.0786	.0948	.0314	.0786
Avg	.1022	.1175	.1071	.2102	.2446	.2271	.3125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 203 / 11 KV KOLWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0774		.0351	.1238	.1239	.1402	.0774
2	.0774		.0351	.1238	.1549	.1753	.0774
3	.0774		.0351	.1547	.1549	.1753	.0774
4	.0774		.0351	.1547	.1859	.2103	.0774
5	.0774		.0351	.2321	.2014	.2103	.0774
6	.0774		.0351	.2321	.2323	.3506	.1547
7	.0774	.031	.0351		.3408	.4382	.2321
8	.0774	.031	.0701		.1859	.5258	.2321
9	.0774	.0774	.0351		.2323	.7011	.2321
10	.0774	.0465	.0351		.2323		.1547
11	.0774	.0526	.0309				.0774
12	.0774	.2629	.1547				.031
13	.0774	.2629	.2321				.0155
14	.1549	.2629	.3094			.0464	
15	.2275	.2629	.3094				
16	.1859	.2629	.3094				
17	.1859	.2629	.3094	.0774	.0351		.0465
18	.1549		.3094	.0774	.0701		.0774
19	.1549	.2629	.3094	.0465	.0701		.0774
20	.0465	.0526	.0774	.0774	.0351	.0464	.0774
21	.0465	.0526	.0786	.0929	.0351	.0464	.1239
22	.0465	.0526	.0774	.0929	.0351	.0464	.1239
23	.031	.0526	.0774	.0929	.0351	.0464	.0774
24	.0774	.031	.0351	.0774	.0929	.0526	.0464
Max	.2275	.2629	.3094	.2321	.3408	.7011	.2321
Min	.031	.031	.0309	.0465	.0351	.0464	.0155
Avg	.0966	.1365	.1253	.1183	.1363	.2141	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 204 / 11 KV MUNDWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0876	.1578	.3155	.3856	.2629	.298
2	.0876	.0876	.1578	.3506	.4207	.2629	.3506
3	.0876	.0876	.1578	.4382	.4382	.2629	.4382
4	.0876	.1052	.1753	.4382	.4382	.3506	.4557
5	.0876	.1052	.1753	.4908	.4908	.4382	.6135
6	.0876	.1052	.1753	.5258	.5609	.5258	.7011
7	.0876	.1227	.2804	.5258	.7362	.7888	.8413
8	.0876	.1052	.1402	.6836	.631	.8764	.9991
9	.0876	.0876	.1402	.5784	.6661	.7888	.8238
10	.0876	.0876		.5609	.1753	.6485	.7537
11		.0876	.0351	.0876		.1402	.0876
12		.3506	.6135	.0876		.1052	.0526
13		.4382	.6836	.0876		.0876	.0351
14			.5959			.0876	.0351
15		.7011	.5784	.0876	.0351	.0876	.0526
16		.7011	.4382	.0876	.0351	.0876	.0876
17		.7011	.929	.1052	.1402	.0876	.0876
18	.4207		.5784	.1052	.1402	.0876	.1052
19	.4382		.4908	.0876	.1753	.0876	.1402
20	.0876		.0876	.0876	.1753	.0876	.1227
21	.0876		.0876	.1052	.1753	.0876	.1052
22	.0876	.1402	.0876	.1052	.1753	.0876	.1052
23	.0876	.1402	.0876	.1052	.1753	.0876	.0876
24	.0876	.0876	.1402	.0876	.1052	.1753	.0876
Max	.4382	.7011	.929	.6836	.7362	.8764	.9991
Min	.0876	.0876	.0351	.0876	.0351	.0876	.0351
Avg	.1278	.2279	.3041	.2667	.3138	.2746	.3111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 205 / 11KV WADNER GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.303	.3219	.2629	.2841	.3598	.298	.3409
2	.303	.3219	.2629	.2841	.3598	.298	.3409
3	.3788	.3219	.2629	.3788	.3409	.298	.4356
4	.5871	.4545	.3506	.7386	.4545	.4207	.7575
5	.9279	.6439	.5258	.9658	.6439	.6135	1.0605
6	1.0794	.909	.8589	.7754	1.1552	1.0517	1.0984
7	.9848	.8333	.7362	.8711	1.0416	.8764	.9848
8	.8711	.7575	.7362	.8333	.8333		.8711
9	.5871	.4924	.4207	.6818	.4734		.606
10	.3788	.3409	.333	.3409	.4545		.4166
11	.2841		.303	.2083	.2804	.2841	.2462
12	.303	.2804	.2083	.2273	.2629	.2462	.2462
13	.2273	.2629	.2462	.2462	.1928	.1894	.2462
14	.2273	.1753	.2083	.2462	.2629	.1894	.2651
15	.2273	.1753	.2083	.303	.2804	.2273	.2841
16	.303	.2103	.2651		.2629	.2083	.303
17	.3977	.4207	.3219	.3409	.3506	.2462	
18	.6249		.5698	.4734	.4207	.6439	.6249
19		.8413	.7954	.909	.8589	.8522	.8522
20	.6439	.7362	.9279	.7954	.8413	.7386	.8143
21	.5303	.6135	.6628	.5303	.5258	.5681	.5303
22	.3977	.4557	.4356	.4545	.3856	.4734	.4545
23	.3219	.3506	.303	.3788	.3506	.3977	.3598
24	.303	.3219	.2454	.303	.3598	.3155	.3598
Max	1.0794	.909	.9279	.9658	1.1552	1.0517	1.0984
Min	.2273	.1753	.2083	.2083	.1928	.1894	.2462
Avg	.4866	.4655	.4355	.5031	.4897	.4494	.5434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 206 / 11KV KOLWADI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.114	.095	.0876	.095	.076	.1052	.095
2	.114	.095	.0876	.095	.076	.1052	.095
3	.152	.095	.1052	.152	.076	.1227	.171
4	.2469	.095	.1753	.2469	.095	.1753	.2849
5	.3419	.152	.1753	.3419	.1899	.298	.3609
6	.3419	.2659	.2804	.3039	.2659	.333	.3039
7	.2469	.2279	.2454	.2279	.1899	.2279	.2659
8	.171	.114	.1753	.171	.171	.1753	.1899
9	.171	.133	.1578	.152	.152	.1753	.152
10	.152	.076	.1052	.095	.095	.0876	.095
11		.0526	.057	.057	.0526	.057	.076
12		.0526	.057	.076	.0526	.076	.038
13		.0526	.057	.057	.0526	.057	.038
14		.0526	.038	.057		.057	.038
15	.057	.0526	.038	.057	.0351	.057	.038
16	.057	.0526	.057	.057	.0701	.076	.057
17	.057	.0526	.057	.057	.0701	.095	.057
18	.076		.057	.076	.0876	.095	.095
19	.114		.114	.171	.1578	.171	.171
20	.114		.2279	.133	.2103	.2089	.2279
21	.095		.1899	.114	.1753	.2469	.133
22	.095	.1052	.133	.095	.1052	.1899	.114
23	.095	.1052	1.1397	.076	.1052	.114	.076
24	.1136	.095	.1052	.095	.076	.1052	.095
Max	.3419	.2659	1.1397	.3419	.2659	.333	.3609
Min	.057	.0526	.038	.057	.0351	.057	.038
Avg	.1463	.1011	.1635	.1274	.1147	.1421	.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 207 / 11KV AMBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848		.1402	.1848	.1848	.1753	.1848
2	.1848		.1402	.1848	.1848	.1753	.1848
3	.2402		.1402	.2402	.1848	.1753	.2587
4	.3326		.2103	.3326	.2218	.2279	.3881
5	.3881		.298	.4435	.2957	.298	.5359
6	.4435		.4207	.499	.5914	.4207	.4805
7	.462		.4908	.462	.4805	.3681	.4435
8	.3696		.3506	.3696	.3142	.298	.3696
9	.3326	.2402	.3155	.2772	.2772	.2804	.2772
10	.2772	.1848	.298	.2033	.1478	.2103	.1848
11	.1478	.1227	.1109	.1109		.1294	.1478
12	.1294		.1109	.1294		.1109	.1109
13	.1109		.1109	.1109	.0876	.0924	.1109
14	.1109		.0924	.1109	.1052	.0924	.1109
15	.1294		.0924	.0924	.0876	.0924	.1109
16	.1663		.0924	.1294		.1109	.1294
17	.1848		.0924	.1478	.2279	.1294	.1848
18	.2957		.1478	.2772	.298	.2402	.2772
19	.4066		.2957	.3881	.3506	.3326	.4251
20	.2587	.298	.3696	.3511	.3506	.3696	.3881
21		.3681	.3326	.2587	.3155	.3326	.2957
22		.2629	.2772	.2218	.2103	.2772	.2218
23		.2279	.2402	.2033	.1753	.2402	.2033
24	.1848		.1753	.2033	.2033	.1753	.2033
Max	.462	.3681	.4908	.499	.5914	.4207	.5359
Min	.1109	.1227	.0924	.0924	.0876	.0924	.1109
Avg	.2543	.2435	.2227	.2472	.2521	.2231	.2595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 208 / 11KV KALIMATH GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0351	.0377	.0377	.0351	.0377
2	.0377	.0377	.0351	.0377	.0377	.0351	.0377
3	.0566	.0377	.0351	.0566	.0377	.0526	.0566
4	.0754	.0566	.0876	.0943	.0754	.0526	.1132
5	.1132	.0943	.1052	.1509	.0943	.1052	.1698
6	.1509	.1509	.1227	.1509	.1698	.1578	.1698
7	.132	.1509	.1227	.1509	.1509	.1578	.1509
8	.132	.132	.1227	.132	.132	.1227	.1509
9	.0943	.1132	.1052	.1132	.1132	.1402	.0943
10	.0754	.0739		.0754	.0754	.0701	.0754
11	.0377	.0351	.0377	.0377	.0526	.0377	.0377
12	.0377	.0351	.0189	.0377	.0351	.0377	
13	.0377	.0351	.0189	.0377	.0351	.0189	.0377
14	.037	.0351	.0189	.0377	.0351	.0189	.0377
15	.0377	.0351	.0189	.0377	.0351	.0377	.0377
16	.0377	.0351	.0377	.0377	.0526	.0377	.0377
17	.0566	.0526	.0377	.0566	.0526	.0377	.0566
18	.0754		.0566	.0566	.0876	.0566	.0754
19	.132		.1132	.1509	.1052	.1132	.132
20	.1132	.1227	.1509	.1509	.1227	.132	.132
21	.0943	.1227	.0943	.0943	.1227	.1132	.0943
22	.0754	.0526	.0566	.0566	.0526	.0943	.0754
23	.0566	.0526	.0566	.0566	.0526	.0566	.0566
24	.0377	.0566	.0351	.0566	.0377	.0526	.0377
Max	.1509	.1509	.1509	.1509	.1698	.1578	.1698
Min	.037	.0351	.0189	.0377	.0351	.0189	.0377
Avg	.0738	.0707	.0662	.0794	.0751	.0739	.0828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 201 / 11KV HATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6154	.5487	.2949	.2743	.426	.427
2	.5487	.5973	.6001	.3277	.3258	.3605	.4062
3	.583	.5792	.6344	.3887	.4287	.3277	.3953
4	.6344	.724	.6859	.421	.463	.3277	.3795
5	.8402	.9412	1.0117	.5441	.6859	.3277	.3795
6	1.166	1.2308	1.2346	.6401	.7545	.7865	.8421
7	1.1488	1.2308	1.2003	.7682	1.0974	.9831	.9488
8	1.166	1.086	1.166	.8002	1.0288	.852	.9488
9	1.2127	.5658	.8573	.6401	.8048	.6554	.7682
10	.6516	.7545	.7964	.5761	.4115	.5761	.6401
11	.5068	.5281	.6516	.5281	.5281	.6036	.5792
12	.4752	.583	.5761	.5281	.5281	.5281	.543
13	.5243	.5761		.679	.5281	.5281	
14	.4588	.5121			.6036	.6036	.6516
15	.4588	.5182	.7682		.4527	.6036	.6878
16	.4481	.583	.6401		.6036	.6036	.6516
17	.5121	.583	.7682	.6173	.6516	.679	.6878
18	.5182	.5487	.5121	.823	.8688	.724	.724
19	.5243	.5144	.4858	.9774	.8688	.8299	.9313
20	1.0136	1.046	1.0745	1.166	1.086	.9412	.8954
21	.724	.8916	1.0029	.8745	.905	.8688	.7964
22	.724	.7716	.8688	.7716	.724	.724	.724
23	.5792	.6173	.724	.6859	.6516	.6516	.6878
24	.6173	.5792	.6001	.4706	.6344	.5792	.5792
Max	1.2127	1.2308	1.2346	1.166	1.0974	.9831	.9488
Min	.4481	.5121	.4858	.2949	.2743	.3277	.3795
Avg	.6925	.7157	.7913	.6439	.6629	.6288	.6641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 202 / 11 KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1638	.0857	.2353	.2572	.1991	.2481
2	.0857	.1802	.0857	.2172	.2572	.2172	.2715
3	.0857	.1966	.1029	.2534	.2915	.2172	.2835
4	.12	.2294	.1029	.3258	.4287	.2715	.3439
5	.1543	.2622	.2401	.4525	.6001	.3077	.3898
6	.3944	.2949	.3258	.8145	.8059	.8507	.8505
7	.4287	.3932	.5144	.7059	.7373	.724	.7701
8	.463	.4424	.4801	.6516	.7202	.6878	.6024
9	.4096	.3841	.3772	.5068	.5658	.5658	.6516
10	.2949	.3281	.3113	.3206	.3395	.3961	
11	.1448		.2172	.2263	.1932	.2452	
12	.1629		.1463	.2675	.1677	.3353	
13	.181		.1463	.2972	.1783	.3086	.2591
14	.181		.181	.2201	.208	.2896	.2267
15	.181	.1886	.2353	.1806	.1524	.1677	.2429
16	.2263	.1886	.181	.1189	.2439	.2229	.2267
17	.2452	.2427	.1991	.2401	.2949	.3418	.2915
18	.3206	.2743	.1991	.2572	.2785	.3605	.3239
19	.5792	.463	.3801	.2401	.2294	.2241	.2915
20	.5611	.5487	.5792	.5144	.5611	.5973	.3801
21	.3982	.4287	.5068	.3601	.2534	.4887	.362
22	.3077	.2915	.4163	.3086	.2715	.362	.2715
23	.2353	.1886	.3439	.2743	.2715	.2534	.2715
24	.2058	.181	.1886	.2534	.2401	.2353	.2629
Max	.5792	.5487	.5792	.8145	.8059	.8507	.8505
Min	.0857	.1638	.0857	.1189	.1524	.1677	.2267
Avg	.2688	.2935	.2728	.3434	.3561	.3696	.3725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 203 / 11 KV TAPARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.3605	.583	.4887	.4458	.3715	.5249
2	.8402	.4588	.6859	.5249	.4458	.5611	.5792
3	.8573	.6554	.8059	.543	.4973	.5792	.5611
4	.8573	.7865	.9088	.5973	.583	.6516	.6516
5	.8916	.9012	.9774	.6878	.6859	.6878	.7964
6	.9259	.9831	1.0288	.7783	.7716	1.0136	.8764
7	1.2346	1.2616	1.286	.8507	.7373	.8688	.815
8	1.3717	1.1469	1.3717	.7059	.5144	.724	.7602
9	1.2944	1.0254	1.3717	.5611		.679	.6878
10	1.1469	1.0402	1.1203	.5281		.6224	.5611
11	.3439	.415	.4163			.3772	.3801
12	.4163	.415	.4525	.9907		1.2193	.6401
13	.3439	.415	.3801			1.2963	1.3123
14	.2896	.415	.362	.3864	1.0669	1.4148	1.3443
15	.4163	.415	.362	.3269	1.2193	1.3717	1.4723
16	.3772	.3772		.2675	1.2193	1.3717	1.5203
17	.3772	.3734			1.1797	1.448	1.5364
18	.5093	.3772	.4163		1.1469	1.4403	1.5203
19	.6154	.5658	.6516		1.1469	1.4232	1.5524
20	.6697	.7202	.7964	.6001	.8326	.8326	.6878
21	.5792	.6344	.7602	.6859	.7421	.724	.7421
22	.5249	.5487	.6878	.583	.6697	.6335	.5973
23	.4525	.463	.6335	.463	.5611	.5792	.543
24	.4801	.4525	.4458	.5249	.4287	.543	.5083
Max	1.3717	1.2616	1.3717	.9907	1.2193	1.448	1.5524
Min	.2896	.3605	.362	.2675	.4287	.3715	.3801
Avg	.6940	.6336	.7502	.5839	.7839	.8931	.8821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 204 / 11 KV JAITAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2172	.1715	.3605	.3772	.3277	.4424
2	.1715	.2172	.1715	.3887	.4287	.3932	.4428
3	.1715	.2534	.2401	.4372	.463	.4588	.4744
4	.2572	.3439	.2743	.4801	.5144	.4752	.4744
5	.3601	.4887	.4115	.5441	.5487	.4752	.4915
6	.5144	.5611	.4801	.5761	.583	.6718	.7116
7	.4287	.4525	.4287	.7042	.9088	.8356	.8223
8	.3429	.3982	.3772	.7842	.9259	.8848	.8697
9	.2715	.3395	.2915	.8002	.724	.7282	.8322
10	.2172	.2263		.6241	.5601	.6539	.7362
11	.1629	.1509		.1509	.1886	.1132	.128
12	.639	.6321	.8322	.1509	.132	.1132	.1097
13	.6882	.5647	.6722	.1509	.132	.1132	.181
14	.6226	.5498	.7522	.1509	.1886	.1698	.128
15	.5735	.5647	.6401	.1698	.1509	.132	.1097
16	.5182	.602	.6241	.2641	.1509	.1509	.128
17	.5182	.5502	.6722	.2058	.1448	.2263	.181
18	.5864	.6859	.6401	.1372	.2534	.2715	.2715
19	.5735	.6859	.6401	.3086	.4163	.4108	.3077
20	.362	.3601	.3439	.4115	.4887	.4887	.362
21	.3077	.3258	.362	.2229	.362	.3982	.3439
22	.2715	.2572	.3258	.2058	.2353	.3077	.3077
23	.2353	.2229	.2896	.2058	.2715	.2715	.2896
24	.2058	.2353	.2058	.2534	.1715	.2534	.2534
Max	.6882	.6859	.8322	.8002	.9259	.8848	.8697
Min	.1629	.1509	.1715	.1372	.132	.1132	.1097
Avg	.3836	.4119	.4476	.3620	.3883	.3885	.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 201 / 11KV JEHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4191	.2507	.2267	.2481	.2743
2	.4191	.4572	.4191	.2658	.2812	.2629	.3048
3	.4382	.5144	.4763	.3012	.3437	.298	.3125
4	.5335	.5716	.5335	.3641	.4374	.3294	.3479
5	.6859	.6478	.5716	.4287	.4999	.4031	.4049
6	.9335	.724	.7621	.6274	.5468	.5258	.5365
7	.6668	.8192	.7049	.57	.6401	.7293	.5967
8	.5906		.7621	.5407	.5182	.6081	.6718
9	.5335		.6287	.4858	.4999	.4218	.5601
10	.381		.4572	.4382	.3437	.3658	.3125
11	.381		.362	.381	.3239		.2858
12	.4268		.3241				
13	.4268	.4641	.3418				
14	.4374	.442	.4254				
15	.4049	.442	.4458				.381
16		.4531	.3864				.3429
17	.4725	.4372	.3374		.3429		.4001
18	.442	.442	.3161		.5144	.4572	
19	.442	.4744	.3601	.4572	.6859	.6478	.6287
20	.724			.8002	.724	.8002	.8192
21	.6668	.5335	.5906	.6097	.6287	.6478	.6287
22	.5716	.5906	.5716	.5525	.5906	.6097	.5716
23	.5335	.5335	.5525	.5144	.5525	.5335	.5335
24	.4954	.5144	.4954	.5144	.4763	.5144	.4954
Max	.9335	.8192	.7621	.8002	.724	.8002	.8192
Min	.381	.4372	.3161	.2507	.2267	.2481	.2743
Avg	.5254	.5299	.4889	.4766	.4830	.4943	.4704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 202 / 11 KV CHIWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1219	.1829	.3048	.2858	.362	.2858
2	.1524	.1562	.1829	.3239	.3239	.381	.2477
3	.1852	.1875	.2343	.3239	.4191	.381	.2858
4	.218	.2429	.2591	.362	.5335	.4191	.3429
5	.2229	.2812	.2949	.4572		.4763	.4191
6	.2454	.3048	.3647	.743	.7621	.5716	.4763
7	.3898	.3201	.4191	.6859	.7049	.5525	.6097
8		.3658	.503	.6287	.6287	.5335	.5144
9	.3521	.3906	.4527	.4572	.4763	.4572	.4001
10	.2622	.2286	.2486	.3239	.3239	.3048	.2858
11	.1715	.2096	.2096	.1905	.1905	.1715	.1372
12	.1715	.1715		.4572	.4191	.5992	.6405
13	.1524	.1715		.6287	.4748	.4534	
14	.1524	.1715	.1334			.381	.6097
15	.1524	.1715	.1715	.5144			
16	.1524	.1905	.2096				.4374
17	.1715	.2477	.2096		.5801	.5937	
18	.362	.381	.3048	.2286		.6249	.502
19		.4954	.5335	.4001	.4287	.5801	.3353
20	.5144		.6097	.5716	.6287	.4954	.5144
21	.5335	.4382	.4191	.4572	.3429	.4572	.381
22	.4763	.3429	.4001	.381	.362	.4001	.381
23	.4191	.2858	.362	.3429	.362	.3239	.381
24	.2858	.381	.2858	.3048	.3239	.3429	.3048
Max	.5335	.4954	.6097	.743	.7621	.6249	.6405
Min	.1524	.1219	.1334	.1905	.1905	.1715	.1372
Avg	.2680	.2721	.3178	.4327	.4511	.4483	.4044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 203 / 11KV NIPANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0762	.061	.2667	.2477	.2096	.2286
2	.061	.1094	.061	.2667	.2286	.2286	.2096
3	.0781	.1457	.0781	.2858	.2858	.2286	.1905
4	.1134	.1562	.112	.3048	.362	.3239	.2477
5	.1326	.1875	.1619	.362	.4763	.4954	.3429
6	.1715	.2006	.2458	.4763	.6287	.743	.5335
7	.1991	.2134	.3018	.5335	.5144	.5144	.6859
8	.1949	.2896	.3441	.6097	.5335	.4763	.6287
9	.1972	.1875			.4191	.4382	.4572
10		.2343	.2321	.362	.362	.2667	.3429
11		.1715		.2667		.2286	.1677
12		.1334	.1334	.3239	.2683	.2408	.2343
13		.1143	.1524		.2984	.2538	.2812
14	.2477	.0953	.1524	.2858	.4458	.2378	.2315
15	.1905	.0953	.1524	.2286	.3988	.2201	.2286
16	.1524	.1143	.1715	.2667	.3772	.2439	.2753
17	.2096	.1715	.1715		.2883	.2934	.2812
18	.3048	.2096	.5335		.2915	.2256	.2187
19	.4572	.2858	.362		.2572	.1781	.1981
20	.5716		.5144	.4763	.4382	.4954	.4954
21	.5335	.362	.4001	.362	.362	.381	.381
22	.4763	.3429	.3429	.3239	.3048	.3429	.362
23	.4572	.2858	.3048	.2858	.2858	.2667	.3429
24	.2858	.381	.2667	.2858	.2667	.2477	.2667
Max	.5716	.381	.5335	.6097	.6287	.743	.6859
Min	.061	.0762	.061	.2286	.2286	.1781	.1677
Avg	.2548	.1984	.2389	.3459	.3627	.3242	.3263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 201 / 11KV CHAPANER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1341	.1372	.4715	.3429	.2572	.2801
2	.1334	.1341	.1372	.5658	.381	.2572	.2801
3	.1715	.1677	.1715	.5658	.4382	.3086	.3361
4	.2096	.2012	.2058	.5658	.5144	.2743	.4108
5	.2477	.2347	.2401	.8299	.6478	.5144	.4481
6	.2858	.2683	.2743		.7621	.6001	.5415
7	.362	.3521	.2915	.8865	.9335	.8573	.9335
8		.3018	.2743	.8488	.8383	.5144	.6722
9	.1905	.2683	.2572	.6979	.6478	.5144	.6348
10	.2096			.547		.6001	.5415
11	.168	.4108	.4715	.4572	.1543	.5041	.415
12	.5041	.4108	.4715	.4001	.1715	.3353	.2829
13	.4481	.3734	.3772	.2477	.1886	.2515	.2829
14	.4294	.3734	.3772	.2096	.2058	.1844	.2263
15	.4668	.4108	.3772	.1524	.2229	.1677	.1886
16	.5228	.4108	.4715	.1905	.2572	.1677	.2263
17	.5415	.4108	.3772	.2096	.2572	.218	.1886
18	.5415	.4294	.415	.2286	.2572	.2347	.2263
19	.5975	.5975		.2286	.2572	.2347	.2075
20	.5601		.8676	.743	.3429	.3547	.811
21	.4668	.4854	.5658	.6287	.3429	.5228	.5093
22	.3921	.5041	.4904	.4954	.4287	.5041	.415
23	.3361	.3734	.2743	.4572	.3772	.4854	.1715
24	.3174		.2743	.3772	.4001	.3361	
Max	.5975	.5975	.8676	.8865	.9335	.8573	.9335
Min	.1143	.1341	.1372	.1524	.1543	.1677	.1715
Avg	.3572	.3454	.3545	.4785	.4074	.3833	.4013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 202 / 11KV SIRAJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2347	.2572	.2263	.2096	.1715	.2614
2	.2858	.2347	.2572	.2829	.2477	.1715	.2614
3	.3239	.2683	.3086	.3772	.2858	.2058	.2987
4	.381	.3018	.3772	.3772	.362	.2572	.3361
5	.4382	.4024	.3086	.415	.4382	.2572	.4481
6	.5335	.4694	.4458	.5658	.5144	.3429	.4854
7	.8192	.5197	.583	.6979	.7049	.5144	.6348
8	.6478	.5197	.4801	.3772	.6287	.4287	.5601
9	.5525	.5365	.4801	.4338	.4382	.4287	.4668
10	.4763	.4024	.2915	.3018	.2667	.3429	.2987
11	.168	.168	.1698	.2667	.2572	.2054	.2075
12	.168	.168	.132	.3429	.3429	.2347	.3018
13	.1867	.1494	.132	.2477	.3429	.2515	.3018
14	.1867	.1494	.1698	.3429	.3429	.2683	.3584
15	.2614	.2054	.1509	.4001	.3601	.2683	.2452
16	.2801	.2427	.1886	.381	.3601	.285	.3395
17	.2801	.2054	.1886	.362	.3601	.4024	.3206
18	.2829	.3174		.3429	.3258	.4191	.4904
19	.5041	.4854		.3239	.3258	.3521	.2829
20	.4481		.6224	.5144	.3429	.3921	.5847
21	.3734	.2987	.1886	.4572	.3429	.3921	
22	.3547	.3174	.3206	.3429	.3772	.3734	.1886
23	.2801	.2987	.2641	.2858	.4115	.2614	.2058
24	.2614	.2614	.2401	.2829	.2477	.2614	
Max	.8192	.5365	.6224	.6979	.7049	.5144	.6348
Min	.168	.1494	.132	.2263	.2096	.1715	.1886
Avg	.3650	.3112	.2980	.3729	.3682	.312	.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 203 / 11KV TAKLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4108	.3086	.1886	.362	.2572	.57
2	.4382	.4108	.3086	.1698	.4572	.2572	.57
3	.5525	.4108	.3772	.1698	.5525	.4287	.6371
4	.743	.4481	.3772	.1509	.6478	.6001	.6706
5	.8383	.4668	.4801	.1698	.7811	.7716	.8048
6	.7049	.5228	.5144	.1698	.9145	.8573	.8383
7	.4382	.4854	.4973	.1886	1.105	.8573	1.0395
8	.4763	.4108	.3429	.2829	1.0288	.5144	1.251
9	.381	.3734	.3601	.6979	.9907	.5144	.57
10		.2801	.2743	.5847		.6001	
11	.1867	.168		.4382	.2572		
12	.1677	.1844	.1886		.3429	.3734	
13	.1677		.1886	.2858	.3429	.4481	
14	.2347		.2829	.3048	.2572		
15	.2012		.2263	.3429	.2401	.3361	
16	.2012	.218	.1698	.381	.2401	.4108	
17	.1677	.2347	.1698	.4001	.2572		
18	.1509		.1698				.4904
19	.218	.1844			.3429	.6908	.811
20	.3734			.6478		.6908	1.0562
21	.3734			.8383	.4287	.7842	.8299
22	.4481	.3258		.7621	.5144	.7095	.5658
23	.5228	.3258	.1509	.6478	.5144	.7095	.5658
24	.5228		.3429	.1509	.5716	.7095	
Max	.8383	.5228	.5144	.8383	1.105	.8573	1.251
Min	.1509	.168	.1509	.1509	.2401	.2572	.4904
Avg	.3873	.3448	.3016	.3796	.5309	.5761	.7514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 204 / Banshendra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1006	.1543	.1698	.1334	.1543	.1867
2	.1334	.1006	.1543	.1509	.1905	.1543	.1867
3	.1334	.1006	.1715	.1886	.2286	.1715	.1867
4	.1524	.1174	.1715	.2263	.2858	.2572	.2241
5	.1715	.1341	.2401	.1886	.362	.3429	.2614
6	.2096	.1677	.2743	.4338	.4382	.4287	.3361
7	.2286	.1844	.2401	.4338	.5144	.4801	.4294
8	.2286	.1677	.2401	.1886	.362	.2572	.2987
9	.2477	.1677	.2572	.2829	.2858	.1715	.1867
10	.2096	.1494	.1543	.1886	.2667	.1715	.168
11	.1307	.112	.1132	.1905	.2401	.1307	.1509
12	.1307	.112	.132	.2096	.1715	.1174	.1509
13	.0934	.112	.132	.1715	.1715	.1006	.132
14		.1307	.1509	.1715	.1543	.1006	.1698
15		.168	.1509	.1524	.2058	.1341	.1698
16		.168	.1509		.2401	.1509	.1886
17	.1494	.168	.1886	.1524	.1372	.1174	.1698
18	.1867	.2054	.1698	.1143	.1372	.1174	.132
19	.3018	.2427		.0762	.1372	.1006	.0943
20	.2614		.415	.3429	.3086	.2241	.415
21	.2241	.1715	.2829	.3239	.2915	.2801	.3772
22	.2054	.2229	.2829	.2858	.2572	.2614	.3772
23	.2054	.1715	.1698	.2286	.1715	.1867	.1886
24	.1494		.1543	.1886	.1524	.168	
Max	.3018	.2427	.415	.4338	.5144	.4801	.4294
Min	.0934	.1006	.1132	.0762	.1334	.1006	.0943
Avg	.1842	.1534	.1979	.2200	.2435	.1991	.2252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 205 / 11 KV GUDAMA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1174	.1543	.2263	.1334	.1372	.2054
2	.1334	.1174	.1715	.2263	.1715	.1543	.2054
3	.1524	.1341	.1715	.2829	.2096	.1715	.2241
4	.1524	.1341	.2058	.3018	.2667	.2572	.2614
5	.1715	.1677	.2743	.3772	.3239	.2915	.3361
6	.2096	.2012	.2915	.6036	.362	.3429	.3547
7	.2286	.2515	.1886	.4904	.4191	.3772	.4668
8	.1905	.1844		.1886	.3429	.2572	.3174
9	.1524	.1844	.1886	.2263	.2667	.1715	.1867
10	.0953	.1174	.12	.1509		.1715	.168
11	.112	.112	.132		.1715	.112	.1132
12	.0934	.0747	.0943	.1905	.1886	.0838	.1509
13	.0747	.0747	.0943	.2286	.1886	.0671	.132
14	.0754	.0747	.0943	.1905	.1715	.0671	.132
15	.0934	.112	.1132	.1524	.1543	.0838	.1886
16	.1494	.1307	.1132		.1543	.1174	.1698
17	.1867	.1307	.1886	.1334	.1372	.1341	
18	.2054	.2241	.1886	.1524	.1543	.1509	.1132
19	.2987	.3395		.1334	.12	.1174	.1698
20	.2614		.415	.2096	.1372	.2241	.415
21	.2241	.1715	.1886	.2477	.1543	.2614	.2452
22	.1867	.1886	.2829	.2096	.2058	.2241	.1886
23	.1867	.1715	.1886	.1715	.1715	.1867	.1886
24	.1867		.1543	.1886	.1143	.168	
Max	.2987	.3395	.415	.6036	.4191	.3772	.4668
Min	.0747	.0747	.0943	.1334	.1143	.0671	.1132
Avg	.1648	.1552	.1825	.2401	.2052	.1804	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 201 / 11kv ANDHANER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6859	1.1203	1.0669	1.1203	1.1765	1.086
2	.6668	.6668	1.0269	.9955	1.2136	1.1765	1.1203
3	.6287	.6668	1.1203	.9955	1.267	1.267	1.1765
4	.8573	.7621	1.1203	1.267	1.307	1.448	1.267
5	1.0669	.9526	1.1203	1.7147	1.4937	1.448	1.448
6	1.3203	1.3394	1.1203	1.7814	1.448	1.6289	1.6289
7	1.3717	1.5023	1.1203	1.749	1.8099	1.8099	1.9909
8	1.4232	1.5089	1.1203	1.5708	1.8099	1.8099	1.8099
9	1.2346	1.3203	1.094	1.2793	1.448	1.086	
10	1.3203	1.267	1.3392	1.0288	1.1336	1.0288	
11	.9808	.6602	.679	.9431			
12	.8488	.6602	.6413	1.2146	1.1336	1.2955	1.1336
13	.679	.3961		1.1431	1.1736	1.2346	1.4089
14	.679	.3961	.7167	1.2308	1.1822	1.1584	
15	.679	.3772	.7167	1.0669	1.166	1.267	1.1336
16	.7545		.7733		1.1336	1.2146	1.0669
17	.7545			1.2955	1.1822	1.1584	1.0669
18	.8402	.7468	1.0562	.5601	1.1336	1.267	1.1279
19	1.307	.8402	1.1203	.8402	1.1498	1.1584	
20	1.8099		2.0538	1.307	1.4937	1.7918	1.9366
21	1.448	1.267	1.448	1.307	1.2955	1.448	1.6289
22	1.086	1.1203	1.086	1.307	1.2146	1.267	1.3575
23	.9335	.9335	1.1203	1.1203	1.0288	1.1203	1.086
24	1.1431	.9145	.9335	.9526	1.1203	1.086	1.1203
Max	1.8099	1.5089	2.0538	1.7814	1.8099	1.8099	1.9909
Min	.6287	.3772	.6413	.5601	1.0288	1.0288	1.0669
Avg	1.0208	.9040	1.0749	1.2060	1.2808	1.3194	1.3471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 203 / 11KV GARADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3734	.8002	.9335	.9709	1.086
2	.3429	.381	.3734	.7716	1.0269	1.086	1.3575
3	.3429	.381	.4108	.7716	1.1203	1.1765	1.6804
4	.381	.4191	.4294	1.0288	1.267	1.3575	1.7737
5	.4191	.4763	.4481	1.1145	1.448	1.448	1.8099
6	.5144	.5144	.4668	1.1488	1.448	1.6289	1.8099
7	.4954	.4763	.4668	1.2955	1.6289	1.8099	1.9004
8	.4954	.4382	.3734	1.166	1.8099	1.9004	1.9004
9	.5144	.4294	.3772	1.1174	1.6289	1.6289	1.6289
10	.4715	.4338	.2263	1.0974	1.2955	1.2955	1.3765
11	1.358	.3772	.2263	.381	.4572	.4191	.381
12	1.3032	1.226	1.2826	.4191	.4572	.4191	
13	1.6598	1.3203	1.2826	.4763	.4382	.4382	.4382
14	1.5089	1.4146	1.4146	.4763	.4954	.5335	.724
15	1.4335	1.4901	1.3769	.4191	.5335	.5041	.6097
16	1.3957	1.3957	1.358	.362	.5906	.5716	.6097
17	1.3957		1.4146	.4572	.5906	.724	.5716
18	1.3575	.9335	1.4712	.4854	.5716	.6516	
19	1.267	.2614	1.267	.5601	.6668	.6335	.5525
20	.5601	.4668	.3734	.5228	.5906	.5611	.5601
21	.5601	.4108	.5601	.5601	.5716	.5228	.5228
22	.4668	.3734	.4668	.5228	.5335	.4294	.4668
23	.4668	.3734	.4108	.4668	.4572	.3734	.4668
24	.4191	.4763	.3734	.381	.4668	.4481	.3734
Max	1.6598	1.4901	1.4712	1.2955	1.8099	1.9004	1.9004
Min	.3429	.2614	.2263	.362	.4382	.3734	.3734
Avg	.8121	.6448	.7177	.7001	.8762	.8972	1.0273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 204 / 11KV KALIMATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.7602	.7468	.8764	1.1203	1.267	1.307
2	.7621	.7202	.7468	.8145	1.3575	1.3575	1.3575
3	.724	.724	.8402	.8145	1.448	1.448	1.448
4	.7621	.8145	.9335	.905	1.6289	1.6289	1.8099
5	.8002	.8688		1.0288	1.6289	1.8099	1.9909
6	.8573			1.0974	1.8099	1.8099	1.9909
7	.7621	.9593	.9335	1.3032	1.8099	1.9909	1.9909
8	.3429	.547		1.3279	1.8099	1.9909	1.8099
9	.4382	.547		1.1822	1.448	1.8099	1.448
10	1.2637	.4338		.9231	1.2146	1.3717	1.2193
11	.415	.3772		.4382		.2667	.2858
12	.4338	1.226	1.6032	.362		.2858	.2858
13	1.5089	1.5089	1.6032	.3429		.3048	.3239
14	1.2637	1.6032	1.6032	.3048			.3429
15	1.2637			.3048		.2987	.381
16	1.3014			.3048		.381	.381
17	1.3014	1.3957	1.5089	.4763	.5906	.4763	.4108
18	1.267	.9335	1.3769	.5601	.5716	.5792	
19	1.086			.5601	.7783	.7282	
20	.9335	.7468	.7468	.9335	.8916	.8962	.5975
21	.8402	.9335	.9335	.9335	.8573	.9335	.905
22	.7468	.9335	.9335	.9335	.9145	.9335	.9335
23	.7468	.7468	.9335	.9335	.8764	.8402	.905
24	.8962	.7202	.7468	.9145	.7468	.8402	.7842
Max	1.5089	1.6032	1.6032	1.3279	1.8099	1.9909	1.9909
Min	.3429	.3772	.7468	.3048	.5716	.2667	.2858
Avg	.8982	.8750	1.0794	.7740	1.1946	1.0543	1.0413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 205 / 11KV GARADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1867	.1905	.2241	.2241	.2241
2	.1715	.1905	.2241	.1905	.2427	.2427	.2427
3	.1715	.1905	.2614	.1905	.2614	.2987	.2801
4	.2286	.2286	.3361	.2667	.3361	.3734	.3361
5	.3429	.3429	.4108	.3429	.4108	.4294	.3734
6	.5335	.5335	.4481	.5335	.4668	.4854	.4481
7	.4382	.4382	.4668	.4191	.4668	.4854	.4668
8	.362	.3584	.4481	.381	.4294	.4108	.4108
9	.3239	.3584	.2829	.2667	.3734	.3361	.3361
10	.2829	.2452	.1886	.2286	.3429	.2286	.2858
11	.1463	.132	.1886	.1905	.1715	.1715	.2096
12	.1463		.1509	.1334	.1715	.1715	.1715
13	.1509	.0943	.1509	.1334	.1334	.1715	.0953
14	.132	.0943	.1509	.1334	.1334	.1524	.1143
15	.132	.0943	.1509	.1524	.1524	.168	.1334
16	.2263	.132	.1509	.1715	.1715	.1905	.1334
17	.2263		.2075	.2667	.2286	.2286	.1905
18	.3361	.2427	.2641	.3734	.2286	.2801	.3239
19	.3734	.3734	.3921	.3361	.4001	.3547	.4001
20	.3734	.3361	.3734	.3361	.2286	.2987	.3361
21	.2987	.2987	.3361	.2987	.2286	.2987	.2987
22	.2427	.1867	.2614	.2427	.2286	.2614	.2801
23	.2427	.2054	.2614	.2241	.2096	.2241	.2614
24	.1905	.2286	.2054	.2286	.2054	.2241	.2241
Max	.5335	.5335	.4668	.5335	.4668	.4854	.4668
Min	.132	.0943	.1509	.1334	.1334	.1524	.0953
Avg	.2602	.2498	.2708	.2596	.2686	.2796	.2740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 206 / 11KV Rail Single Phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.362	.2987	.1905	.2427	.2241	.2241
2	.3429	.4191	.3361	.1715	.2427	.2427	.2614
3	.381	.4191	.3734	.1715	.2614	.2614	.2987
4	.5335	.5335	.4481	.2858	.2987	.2987	.3361
5	.4191	.5716	.5041	.4191	.3361	.3547	.3734
6	.4001	.6478	.5601	.5335	.3921	.4668	.4668
7	.5716	.7655	.5788	.5144	.4854	.5228	.5041
8	.6859	.7167	.8402	.4382	.4108	.4481	.4481
9	.5144	.679	.7545	.3048	.1867	.3361	.3361
10	.1509	.6602	.5847	.2667	.1715	.2286	.3429
11	.1509	.2829	.2263	.2667		.1715	.3429
12	.1509		.1698	.7842	.6859	.6859	.5973
13	.1509	.132	.1509	.7125	.7421	.7373	.7059
14	.1509	.132	.1509	.7611	.7421	.5973	.6668
15	.1509	.132	.1509	.724	.664	.6516	.6097
16	.2075	.132	.1509	.6478	.7602	.6154	.5716
17	.2075	.1886	.1509	.5973	.6478	.7421	.6668
18	.2241	.2614	.1698	.5601	.7811	.7095	.7964
19	.2614	.3734	.2987	.4668	.4191	.5415	.5792
20	.4481	.3734	.4108	.4108	.3239	.4294	.4294
21	.3734	.2987	.3734	.3734	.2858	.3734	.3361
22	.3174	.2614	.2987	.3361	.2667	.2427	.2987
23	.2241	.2054	.2614	.2614	.2096	.2241	.2801
24	.2858	.2286	.1867	.2286	.2241	.2054	.2241
Max	.6859	.7655	.8402	.7842	.7811	.7421	.7964
Min	.1509	.132	.1509	.1715	.1715	.1715	.2241
Avg	.3178	.3816	.3512	.4345	.4252	.4296	.4457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 201 / 11 KV Deogaon Urban SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0005	1.6461	.7865	.8145	.7888	.7202	.823
2	2.0005	1.6632	.7865	.7964	.7716	.7202	.823
3	1.9814	1.7147	.8048	.8145	.7716	.7202	.8413
4	1.9814	1.869	.823	.8507	.7888	.7716	.9511
5	2.0386	1.9033	1.0608	.905	.8916	.8059	1.2071
6	2.572	2.2291	1.1523	1.1765	1.2517	1.0802	1.2437
7	2.4006	2.0919	1.0974	1.3575	1.2517	1.2517	1.4815
8	1.8347	1.749	1.0059	1.3032	1.1488	1.0631	1.3535
9	1.5947	1.5432	.9145	1.0136	1.0631	1.0608	1.0631
10	1.4232	1.3817		.9431	.7716	.9694	.7888
11	1.4575	1.363	1.3527	1.4289	1.3032	1.307	1.406
12	.9088	1.0974	1.4289	1.3908	1.3375	1.2136	1.5089
13	.8745	1.0608	1.2765	1.4289	1.3546		1.2689
14	.8916	.9694	1.3336	1.4098	1.3546	1.8111	1.3889
15	.8573	.9511	1.3336	1.4861	1.4232		1.3889
16	.9088	1.0082		1.5623	1.4575	1.6617	1.7147
17	.8916	.9328	1.8099	1.6004		1.7737	1.5775
18		.9877		1.6766	1.6461	1.5123	1.7147
19	.8745	.8779	2.0005	1.6004	1.6289	1.9231	1.6118
20	2.1605	2.0911	2.4768	2.2481	2.0576	2.2032	2.0576
21	1.989	2.1098	2.2291	2.1338	1.9033	2.0725	1.9204
22	1.989	2.0165	2.191	2.0195	1.869	1.9791	2.0767
23	1.7833	1.9044	2.0005	2.0005	1.749	1.9791	
24		1.7318	1.9044	1.9243	1.749	1.6804	1.8671
Max	2.572	2.2291	2.4768	2.2481	2.0576	2.2032	2.0767
Min	.8573	.8779	.7865	.7964	.7716	.7202	.7888
Avg	1.6097	1.5372	1.4176	1.4119	1.3188	1.3764	1.3947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 202 / 11KV Mategaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.2	.2801	.2858	.2858	.1524	.2987
2	.4115	.2286	.2801	.2858	.2858	.1524	.2987
3	.4287	.2286	.2801	.2858	.2858	.1715	.3361
4	.4287	.2286	.2987	.3429	.2858	.1905	.3361
5	.463	.2572	.3361	.3429	.3429	.2096	.3734
6	.5487	.5144	.3734	.3429	.4763	.2858	.3734
7	.823	.5144	.3734	.3429	.4191	.2286	.4108
8	.7716	.5658	.3361	.3429	.3048	.1905	.3734
9	.7716	.5658	.2987	.2286	.2858	.3361	.3429
10	.463	.4572	.2286	.1905	.0953	.3361	.2286
11	.1143	.2241	.2286	.1905	.0953	.2987	.5487
12	.0953	.2614	.7059	.6173	.5144	.5601	.6173
13	.0953	.2614	.6859	.6173	.5144		.6173
14	.0762	.2614	.5716	.6173	.2858	.5544	.6516
15	.0953	.2614	.6859	.5144	.2858	.5487	.6516
16	.0953	.2987		.2058	.2286	.5121	.6516
17	.0953	.2987	.6516	.0686	.5316	.5121	.583
18	.0953	.2987			.2858	.5544	.5487
19	.2286	.3361	.2858	.3772	.2858	.5487	.4801
20	.2096	.4108	.4572	.4954	.2286	.3734	.4115
21	.1905	.4108	.3429	.3429	.2	.3734	.3772
22	.1905	.3734	.3429	.3048	.1905	.3734	.3048
23	.1715	.3361	.3429	.3048	.1715	.3361	
24	.3048	.1524	.2987	.2858	.2858	.1715	.2987
Max	.823	.5658	.7059	.6173	.5316	.5601	.6516
Min	.0762	.1524	.2286	.0686	.0953	.1524	.2286
Avg	.3158	.3311	.3948	.3449	.2988	.3465	.4397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 205 / 11KV TADPIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.9259	.5788	.6516	.6516	.6001	.7316
2	1.2193	.9431	.5853	.6335	.6173	.6001	.7316
3	1.2384	.9431	.6219	.6335	.6859	.6001	.7682
4	1.2384	.9602	.695	.6335	.724	.6859	.8779
5	1.448	1.0631	.8779	.724	.7202		1.2136
6	1.7909	1.2174	.9145	.9955	1.0288		1.2254
7	1.406	1.0631	.9328	1.1222	1.166	.8916	1.4003
8	1.2003	.9602	.9145	.905	.9602	1.1317	1.0974
9	1.0288	.8573	.6401	.8145	.9431	1.0242	1.1431
10			.5144	.7202		.7316	1.0288
11	.8745	.567	.8573	.7049	.823		.7621
12	.6344	.6401	.6859	.724		.8402	.6516
13	.6859	.6401	.7621	.6478	.6859	.8029	.6859
14	.6173	.6584		.6478	.6687	.7468	.7202
15	.6001	.695		.6097	.6859	.8215	.6859
16	.6173	.695	.7811	.6478	.703	.9335	.7545
17	.7888	.7865	.7811		.7716	.9335	.7716
18		.8048	.8573	.6668	.8059	.9709	.7716
19	.8059	.6401	.8764	.9526	.9774	1.2323	1.0288
20	1.2003	1.2696	1.6004	1.3717	1.286	1.587	1.3375
21	1.2517	1.3817	1.3336	1.3336	1.166	1.4937	1.286
22	.8745	1.307	1.2574	1.2384	1.1488	1.4003	1.2384
23	1.046	1.2136	1.2003	1.2193	1.0802	1.2696	
24	1.1812	.9774	1.1576	1.1812	1.0631	1.0288	1.2323
Max	1.7909	1.3817	1.6004	1.3717	1.286	1.587	1.4003
Min	.6001	.567	.5144	.6097	.6173	.6001	.6516
Avg	1.0440	.9222	.8830	.8600	.8801	.9679	.9628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 201 / TOWN-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3658	.4344	.5121	.4572	.4458	.4458
2	.5487	.5121	.4706	.5121	.4572	.4458	.4458
3	.5487	.5281	.439	.5487	.4755	.4458	.5144
4	.583	.5304	.4755	.5853		.4458	.5144
5	.583	.5658	.4706	.6036	.4755	.4801	.5487
6	.583	.5601	.5121	.5601	.5487	.4801	.583
7	.6173	.5487	.5853	.5601	.6036	.5144	.5487
8	.6173	.5121	.5487	.5975		.5487	.4801
9	.695	.5121	.5144	.5121	.4755	.5144	.4854
10	.6584	.4344	.4458	.5487	.4755	.4801	.4755
11	.5853	.4755	.4115	.439	.4344	.4115	.439
12	.5487	.4706	.4115	.4755	.4024	.4458	.4854
13		.362	.3772	.439	.4024	.4458	.5121
14		.4024	.3772	.439	.4024	.4801	.4854
15		.4024	.3429	.439	.439	.4801	.3658
16	.5121	.4344	.4458	.4755	.4755	.5144	.5121
17	.4755	.4706	.4801	.5487	.5121	.5144	.5487
18	.4755	.5121	.4458	.5853	.439	.5487	.5304
19	.4024	.4755	.4458	.5121	.4755	.5144	.5121
20	.6219	.4854	.5487	.5975	.4755	.583	.6161
21	.6348	.5121	.5144	.5487	.5121	.5144	.5121
22	.5853	.4755	.4801	.5121	.4755	.4801	.5281
23	.5853	.4755	.4801	.4755	.4755	.4973	.4854
24	.5144	.5658	.439	.5281	.4854	.4755	.4458
Max	.695	.5658	.5853	.6036	.6036	.583	.6161
Min	.4024	.362	.3429	.439	.4024	.4115	.3658
Avg	.5678	.4829	.4624	.5231	.4716	.4878	.5008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 202 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9044	1.7164	1.7177	1.7924	1.6461	1.8298	1.7924
2	1.9044	1.6461	1.6804	1.7558	1.6461	1.7551	1.7924
3	1.8671	1.6461	1.7177	1.7193	1.6644	1.8298	1.8298
4	1.8671	1.6644	1.7551	1.7924	1.7353	1.8671	1.8298
5	1.8671	1.6827	1.7551	1.829	1.6827	1.8671	1.8671
6	1.8671	1.7558	1.7551	1.8671	1.7558	1.9044	1.8298
7	1.8298	1.829	1.8671	1.829	1.9022	1.9418	1.9044
8	1.7924	1.6461	1.7551	1.7558		1.8298	1.7551
9	1.7551	1.5424	1.6057	1.6461	1.6126	1.6804	1.6461
10	1.7924	1.4723	1.6804	1.5546	1.4373	1.6057	1.5364
11	1.6827	1.4022	1.6804	1.4266		1.6057	1.5364
12	1.6057	1.5203	1.643	1.419		1.643	1.5364
13	1.5364	1.4373	1.643	1.4632		1.6804	1.5546
14	1.4998	1.4022	1.6057	1.4998	1.7878	1.6804	1.7558
15	1.5181	1.3672	1.5684	1.5364	1.7878	1.7551	1.6827
16	1.5364	1.4022	1.6804	1.643	1.7878	1.7551	1.6278
17	1.6787	1.4022	1.7551	1.7375	1.7878	1.7551	1.829
18	1.8107	1.4022	1.8298	1.829	1.4022	1.7924	1.829
19	1.6095	1.7878	1.6804	1.7558	1.7177	1.8298	1.829
20	1.9753	1.7528	1.9044	1.9204	1.7878	1.9791	2.0119
21	1.9418	1.7528	1.9418	1.8656	1.8229	1.9418	1.9993
22	1.9204	1.7878	1.9418	1.829	1.7528	1.9418	1.9418
23	1.9022	1.7177	1.8298	1.8673	1.7528	1.8671	1.9044
24	1.8671	1.7558	1.7551	1.7375	1.6827	1.8298	1.7924
Max	1.9753	1.829	1.9418	1.9204	1.9022	1.9791	2.0119
Min	1.4998	1.3672	1.5684	1.419	1.4022	1.6057	1.5364
Avg	1.7722	1.6038	1.7395	1.7113	1.7076	1.7987	1.7756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 203 / Town 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.439	.4458	.5121	.5093	.4801	.4458
2	.5144	.439	.4115	.5487	.4938	.4115	.4458
3	.5487	.5121	.3772	.5658	.4755	.4115	.4801
4	.5487	.4755	.4115	.5487	.5121	.4801	.4801
5	.583	.5281	.4458	.5975	.5121	.4801	.5144
6	.583	.5121	.4801	.5601	.5121	.4458	.5144
7	.6173		.4458	.5487	.5121	.4458	.4801
8	.583	.5121	.5144	.5853		.4801	.4801
9	.6219	.543	.5144	.5853	.4706	.4801	.5487
10	.567	.5121	.4801	.6219	.4706	.4458	.567
11	.6219	.4755	.583	.6219	.4706	.4801	.5487
12	.5853	.4706	.5144	.6219	.5487	.5144	.5304
13	.5601	.5068	.5144	.5853	.4706	.5144	.5853
14	.5121	.4706	.4801	.5853	.4706	.5487	.5281
15	.4755	.5487	.4801	.5853	.543	.5487	.5121
16	.5121	.5792	.5487	.5853	.6154	.583	.4755
17	.6219	.6516	.6173	.695	.6516	.583	.6219
18	.695	.6878	.6516	.7133	.6878	.6516	.6584
19	.5121	.4706	.5144	.6722	.5487	.583	.6219
20	.5487	.5068	.5144	.6722	.5121	.5487	.6219
21	.5121	.5487	.5144	.5487	.5121	.5144	.5487
22	.5304	.5068	.4801	.5228	.5121	.4801	.5304
23	.5487	.5121	.4801	.5041	.5121	.4458	.5121
24	.4801	.5228	.4458	.5121	.5121	.4801	.4458
Max	.695	.6878	.6516	.7133	.6878	.6516	.6584
Min	.4755	.439	.3772	.5041	.4706	.4115	.4458
Avg	.5582	.5188	.4944	.5875	.5233	.5015	.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 204 / Town 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5853	.5144	.6219	.5853	.3772	.6173
2	.583	.567	.4801	.6219	.5853	.4115	.6173
3	.583	.5487	.5144	.5853	.567	.4458	.583
4	.6173	.5487	.5487	.5853	.5853	.4801	.6173
5	.6173	.6036	.583	.6219	.6036	.5144	.583
6	.583	.6224	.6173	.6219	.6161	.5144	.583
7	.6173	.6219	.5487	.6219	.6219	.5487	.5487
8	.6173	.5853	.583	.6219		.5487	.583
9	.7095	.6154	.6173	.6722	.6219	.6173	.679
10	.8048	.6154	.6173	.7316	.6878	.6516	.695
11	.7842	.6219	.7202	.7316	.7316	.7202	.7682
12	.7682	.6584	.7202	.7316	.7682	.6516	.7682
13	.7682	.6584	.6859	.8589	.7682	.6516	.7682
14	.6219	.6878	.6859	.8413	.695	.6859	.7682
15	.7922		.6859	.823	.7316	.6859	.7682
16	.7682	.7316	.6516	.8413	.7682	.7202	.7682
17	.823	.7602	.6859	.823	.7682	.7202	.8048
18	.823	.7602	.7202	.8779	.724	.823	.8215
19	.7499	.695	.7545	.8048	.7602	.7202	.8048
20	.7499	.6516	.7202	.8413	.724	.7545	.8048
21	.7468	.6154	.6859	.7095	.724	.7202	.8048
22	.5975	.6219	.6859	.695	.6878	.6859	.7316
23	.7316	.6154	.6173	.6584	.6154	.6516	.7095
24	.583	.6219	.5487		.6584		.6687
Max	.823	.7602	.7545	.8779	.7682	.823	.8215
Min	.583	.5487	.4801	.5853	.567	.3772	.5487
Avg	.6941	.6354	.6330	.7193	.6782	.6218	.7028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 205 / Ritthi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.724	.4801	.6219	.5304	.3772	.5487
2	1.0456	.7842	.5144	.695	.5304	.3772	.5487
3	1.0456	.7888	.6516	.695	.5121	.3429	.583
4	1.1949	.8962	.6859	.7316	.5121	.3429	.583
5	1.1949	.8962	.823	.7316	.5121	.3772	.6173
6	1.2323	1.286	.8573	.7682	.5975	.4115	.6173
7	1.4563	1.4403	1.4937	.7682	.6219	.4801	.6516
8	1.531	1.5729	1.3443	.695		.4458	.4801
9	1.2883	1.4373	1.2323	.6584	.5121	.4115	.3018
10	.1867	1.3032	1.2323	.5487	.3292	.4115	.3361
11	.2561	.1463	.1715	.439	.2172	.1715	1.829
12	.1509	.2534	.2058	1.6827		1.6057	1.7918
13	.3361	.3258	.2743	1.6655	1.5775	1.6057	1.7375
14	.2926	.362	.2743	1.5775	1.3672	1.531	1.7558
15	.3292	.4024	.3086	1.4632	1.3321	1.4937	1.6095
16	.4024	.3982	.4115	1.4632	1.2971	1.419	1.5123
17	.5121	.5249	.4458	1.5364	1.2971	1.419	1.4998
18		.4755	.6173	1.4746	1.3321		1.4815
19	.4481	.362	.6516	1.134	1.1919	1.2323	1.4937
20		.3292	.6516	.4755	.4024	.5487	.6036
21	.3658	.2926	.6859	.4755	.439	.5487	.6348
22	.3292	.3982	.6173	.5121	.439	.5487	.6584
23	.3174	.362	.583	.5121	.439	.5487	.6219
24	.4458	.3109	.3429	.6219	.5658	.3772	.5487
Max	1.531	1.5729	1.4937	1.6827	1.5775	1.6057	1.829
Min	.1509	.1463	.1715	.439	.2172	.1715	.3018
Avg	.6969	.6697	.6482	.9145	.7525	.7403	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 206 / Industrial SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1646	.1372	.2263	.2263	.1372	.2058
2	.1715	.1646	.1494	.2195	.2012	.1372	.1715
3	.2058	.1646	.1097	.2195	.2263	.1029	.1715
4	.2058	.2012	.1463	.2195	.2195	.1029	.1715
5	.2058	.2195	.1829	.2195	.2195	.1029	.1715
6	.2401	.2012	.2195	.2263	.2012	.1372	.1715
7	.2401	.2012	.1867	.1463	.2012	.1372	.1715
8	.2058	.2195	.1829	.1463		.1029	.1029
9	.2263	.0732	.2195	.1829	.2172	.1372	.1097
10	.3361	.1086	.3292	.128	.2195	.2401	.2743
11	.2926	.1448	.3734	.2561	.0366	.2058	.2926
12	.2926	.1448	.3658	.2561	.0724	.2058	.3018
13	.439	.1448	.3361	.2926	.1097	.2058	.4024
14	.2926	.181	.3292	.2926	.181	.2058	.3361
15	.2743	.2195	.3292	.2926	.2172	.2058	.3361
16	.4024	.2561	.3734	.2743	.2534	.2401	.3292
17	.3772	.2896	.3658	.1829	.2534	.2058	.3658
18	.3475	.2926	.3361	.1829	.2534	.3086	.3658
19	.2743	.2172	.2926	.3292	.362	.2743	.3658
20	.2926	.2195	.3361	.3658	.362	.3429	.3734
21	.2012	.2172	.3292	.2926	.3258	.2743	.2561
22		.2195	.2561	.128	.2172	.2401	.3292
23	.2012	.1463		.2561	.181	.2401	.3395
24	.1715	.1646	.1715	.2561	.2561	.1715	.2058
Max	.439	.2926	.3734	.3658	.362	.3429	.4024
Min	.1715	.0732	.1097	.128	.0366	.1029	.1029
Avg	.2653	.1907	.2634	.233	.2180	.1944	.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 201 / 11KV NAGAD AG(WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6478	.1905	.5335	.4763	.4191	.4763
2	.8002	.724	.1905	.5335	.4954	.381	.4763
3	.8192	.724	.1715	.5335	.4954	.381	.5144
4	.8383	.7621	.2096	.5525	.5335	.4001	.5335
5	.9335	.7811	.2096	.5525	.5525	.4191	.5525
6	1.0479	.8383	.2477	.5525	.5716	.4382	.5525
7	.9526	.9526	.3239	.5525	.5525	.5144	.5716
8	.9907	1.0669	.1905	.5525	.5716	.5144	.5906
9	.8383	1.086	.3048	.5525	.5335	.5335	.4954
10	.8383	.9526	.3239	.5335	.4954	.5716	.5525
11		.5525	.3048	.5525	.5144	.5335	.5525
12	.3429	.4763	.8573	1.2574		1.3336	1.6575
13	.381	.4763	.9526	1.2384	.2858	1.6575	1.6194
14	.4191	.5144	1.1431	1.1812	1.467	1.5242	1.6385
15	.4191	.5335	1.2574	1.1812	1.6575		1.6194
16	.381	.5716	1.3336	1.2003	1.6385		1.6004
17	.4382	.5525	.9526	1.2765	1.467		1.5242
18	.4572			1.1622	1.3717	.3239	1.5432
19	.5525		.8573	1.1622	1.2384	.4382	1.5051
20			.5525	.5716	.4954	.5716	.5525
21	.4572		.5525	.5525	.4954	.5144	.5525
22	.381	.2858	.5525	.5716	.4572	.4763	.5525
23	.381	.1905	.5525	.5335	.4572	.4382	.5525
24	.5525	.3429		.5525	.4763	.4572	.4001
Max	1.0479	1.086	1.3336	1.2765	1.6575	1.6575	1.6575
Min	.3429	.1905	.1715	.5335	.2858	.3239	.4001
Avg	.6356	.6516	.5560	.7684	.7522	.6115	.8827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 202 / 11KV SAIGAWN AG (WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.5335		.5144	.5144	.5144	.4191
2	.2667	.5335		.5335	.4954	.5144	.4572
3	.2858	.5525		.5525	.3429	.5335	.4382
4	.2858	.5906		.5335	.3239	.4954	.4763
5	.3048	.6478		.5525	.3239	.4954	.5144
6	.3048	.9145		.5525	.381	.4572	.5525
7	.3048	1.1431		.5525	.5144	.5335	.4191
8	.2858	1.3717		.5525	.5525	.5335	.5144
9	.4763	1.2955		.5525	.5906	.4572	.5335
10	.381	1.1241		.3239	.5335	.5335	.5525
11		.362		.4191	.5144	.5716	.5525
12			1.3717	1.5051		1.8099	1.6194
13		.2858	1.3908	1.2384	1.7337	2.0576	1.6385
14	.2096	.3429	1.4098	1.2765	1.7528	1.9052	1.6575
15	.4001	.4191	1.4289	1.3908		1.9814	1.6385
16	.4572	.5525	1.448	1.5051		1.9052	1.5242
17	.4954	.5716	.9526	1.5051	2.0767	1.8671	1.448
18	.4572		.9526	1.4289		1.3336	1.2574
19	.4572		.8764	.9907		1.3717	.9907
20			.5525	.4001	.3048	.5716	.5525
21	.4191		.5525	.381	.381	.5335	.5525
22	.381	.4191	.5525	.4191	.4572	.5525	.5525
23	.3429		.5525	.4001	.5335	.5144	.5525
24	.1905	.3429		.5525	.4191	.5335	.5716
Max	.4954	1.3717	1.448	1.5051	2.0767	2.0576	1.6575
Min	.1905	.2858	.5525	.3239	.3048	.4572	.4191
Avg	.3486	.6668	1.0034	.7764	.6708	.9407	.8327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 203 / 11 KV BELKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	.4954	.7621	.7621	.6097	.5906
2	.2286	.1524	.4954	.8002	.8383	.6097	.6287
3	.2477	.1524	.5144	.8764	.9526	.6668	.7049
4	.2667	.1905	.5335	.9335	.9526	.724	.9717
5	.2858	.1905	.5716	.9526	.9717	.7811	.5525
6	.3048	.2477	.5716	1.1431	1.0669	.9907	1.0098
7	.3239	.2667	.9335	1.2193	1.5432	1.7147	1.4289
8	.3429	.2477	.8573	1.2384	1.2384	1.5432	1.448
9	.3239	.2477	.8573	1.1431	1.1431	1.1431	1.1241
10	.3048	.1905	.7621	1.0288	.8764	.8383	.7621
11		.1524	.2667	.2477	.2096	.381	.1715
12	.724	.7049	.2477			.2096	.1524
13	.8954	.8002	.2477	.1905	.1905	.2096	.1715
14	.9335	.9145	.2477	.1715	.2096	.2477	.1905
15	.8383	1.0288	.2667	.2096	.2667	.1334	.1905
16	.7621	1.105	.2667	.2096		.2477	.2286
17	.6859	1.0288	.3048	.2477	.3048	.2667	.2667
18	.7621		.3048	.2286	.2667	.2667	.2858
19	.7621		.1905	.2286	.3048	.2858	.3048
20			.3239	.2858	.2667	.2667	.3239
21	.2667		.3048	.2858	.2667	.2477	.3048
22	.2096	.2286	.2286	.2477	.2096	.1715	.2286
23	.1905	.2477	.2096	.2096	.1905	.1715	.2477
24	.2667	.1905		.1905	.1524	.1905	.1524
Max	.9335	1.105	.9335	1.2384	1.5432	1.7147	1.448
Min	.1905	.1524	.1905	.1715	.1524	.1334	.1524
Avg	.4616	.4220	.4349	.5674	.5993	.5382	.5184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 204 / 11kv Nagad gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2667	.2667	.2477	.2667	.2667	.2477
2	.2477	.2667	.2667	.2477	.2667	.2667	.2477
3	.2667	.2858	.3048	.2477	.2858	.2858	.2667
4	.3048	.3429	.3239	.2667	.3239	.3239	.3048
5	.381	.381	.4001	.381	.362	.4001	.3048
6	.4763	.4382	.4572	.4763	.4001	.4572	.5144
7	.4954	.4191	.381	.4191	.381	.4001	.362
8	.4572	.4001	.381	.381	.3239	.381	.3239
9	.4001	.362	.381	.362	.3048	.3239	.3429
10	.3429	.3429	.381	.3239	.2667	.2858	.3048
11	.2858	.2858	.362	.2858	.2667	.2477	.2858
12	.2667	.2667	.362	.2858		.2286	.2667
13	.2096	.2858	.3239	.2286	.2667	.2477	.2667
14	.2667	.3239	.3239	.3048	.2858	.2286	.2667
15	.2667	.3239	.3429	.2858	.3048		.2667
16	.2667	.3429	.362	.2858	.2667		.2477
17	.2858	.3239	.4191	.2477		.3239	.2667
18	.3239		.4382	.3239	.3429		.2858
19	.4572		.4382	.3429	.4001		.381
20			.4572	.4382	.4191	.4572	.4191
21	.362		.4001	.381	.4572	.3429	.381
22	.3048	.3429	.5525	.2667	.3429	.3048	.3239
23	.3048	.3429	.2667	.2667	.3048	.2858	.3048
24	.3239	.2858		.2667	.2286	.2858	.2667
Max	.4954	.4382	.5525	.4763	.4572	.4572	.5144
Min	.2096	.2667	.2667	.2286	.2286	.2286	.2477
Avg	.3280	.3315	.3736	.3151	.3213	.3172	.3104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 205 / 11kv Belkheda gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2477	.2477	.2667	.2477	.2096	.2286
2	.2667	.2477	.2477	.2667	.2477	.2096	.2286
3	.2858	.2667	.2858	.2858	.2667	.2477	.2477
4	.3239	.3429	.3429	.3048	.3048	.3048	.2858
5	.4191	.381	.4382	.381	.381	.4572	.381
6	.5525	.5716	.5525	.5906	.5335	.5716	.5716
7	.5144	.4954	.4954	.4954	.4763	.5906	.5335
8	.4572	.4763	.4382	.4763	.4191	.4191	.4763
9	.381	.3429	.3048	.3048	.3239		.3429
10	.2477	.2286	.3048	.2286	.1905		.2096
11		.1715	.2096	.2096	.1334		.1905
12	.1905	.1524	.1715	.1905		.2096	.1334
13	.2096	.1905	.1905	.1715	.1143	.1905	.1143
14	.2096	.2096	.2096	.1524	.1334	.1715	.0953
15	.1905	.1905	.2096	.1905	.1334	.1715	.1143
16	.2477	.2096	.2096	.2096	.1715	.1524	.1715
17	.2477	.2286	.3048	.2667	.2477	.1905	.1905
18	.3429		.3048	.2858	.2667	.3429	.3048
19	.4763		.4191	.2858	.4382	.4191	.4572
20			.381	.4191	.362	.4382	.4191
21	.3048		.3239	.3429	.3429	.381	.3239
22	.2858	.2667	.3048	.2858	.3048	.3239	.2858
23	.2667	.2286	.2858	.2667	.2667	.3239	.2667
24	.2286	.2667		.2667	.2477	.2477	.2667
Max	.5525	.5716	.5525	.5906	.5335	.5906	.5716
Min	.1905	.1524	.1715	.1524	.1143	.1524	.0953
Avg	.3144	.2858	.3123	.2977	.2850	.3130	.2850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 206 / 11kv saigawan gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858		.2477	.2667	.2667	.2667
2	.2667	.2858		.2667	.2858	.2667	.2667
3	.2858	.2858		.2667	.3239	.2096	.2858
4	.362	.3429		.2667	.381	.3048	.3239
5	.4954	.4572		.381	.4572	.4572	.4191
6	.5335	.5716		.5716	.5716	.5335	.5906
7	.5144	.4763		.5525	.5144	.5144	.5525
8	.4763	.4572		.4954	.4763	.3429	.4763
9	.381			.3239	.381	.3048	.381
10	.3048		.4001	.2858	.2667	.2858	.2667
11			.381	.2858	.2096	.3239	.2477
12			.2096	.2477		.2477	.2286
13			.1905	.2286	.1905	.2667	.2286
14	.3048	.2477	.2096	.2858	.1905	.2286	.1905
15	.2667	.3048	.2286	.3048	.1905	.2286	.2096
16	.2667	.2858	.3048	.3429			.2477
17	.3048	.3429	.3239	.3048	.2096	.3429	.2667
18	.3239		.3239	.3239	.3048	.362	.3048
19	.4572		.381	.362	.381	.381	.4763
20			.4191	.4572	.4191	.4763	.4954
21	.3429		.362	.362	.5335	.381	.5144
22	.3048	.2286	.3429	.3239	.381	.362	.3048
23	.3048	.2477	.3239	.3429	.3429	.3429	.2858
24	.2667	.2858		.3048	.3048	.2667	.3429
Max	.5335	.5716	.4191	.5716	.5716	.5335	.5906
Min	.2667	.2286	.1905	.2286	.1905	.2096	.1905
Avg	.3515	.3404	.3144	.3390	.3447	.3346	.3405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 201 / 11 KV NADARPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	1.1431	
7		.4191
13	.1494	
24		.1715
Max	1.1431	.4191
Min	.1494	.1715
Avg	.6463	.2953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 202 / 11 KV PISHOR Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	1.1431	
7		.9526
13	.6283	
24		.743
Max	1.1431	.9526
Min	.6283	.743
Avg	.8857	.8478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 203 / 11kv KOLAMBI AG WITH SDT SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	.4001	
7		.6097
13	.6036	
24		.1905
Max	.6036	.6097
Min	.4001	.1905
Avg	.5019	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 204 / 11 KV RAMNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	.6668	
7		.4001
14	.1698	
24		.1715
Max	.6668	.4001
Min	.1698	.1715
Avg	.4183	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 205 / 11kv Nadarpur gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	.1524	
8		.1715
13	.0373	
24		.0381
Max	.1524	.1715
Min	.0373	.0381
Avg	.0949	.1048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 206 / 11KV Palashi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	.0953	
7		.4001
14	.4024	
24		.0572
Max	.4024	.4001
Min	.0953	.0572
Avg	.2489	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 207 / 11KV KOLAMBI GAONTHAN

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-JUN-18	13-JUN-18
HR	Load (MW)	Load (MW)
6	.5335	
7		.4763
13	.168	
24		.1905
Max	.5335	.4763
Min	.168	.1905
Avg	.3508	.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 204 / 11 KV TAKLI (A)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18
HR	Load (MW)
20	.1445
Max	.1445
Min	.1445
Avg	.1445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 205 / 11 KV Wadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1987	.2167	.6283	.3839	.4696	.3643	.2987
2	.2529	.2529	.6849	.4537	.51	.4007	.3319
3	.289	.289	.7504		.5599	.4326	.3983
4	.2881	.3251	.8377	.5238	.578	.4587	.4315
5	.5057	.3973	.89		.6921	.5418	.4646
6	.9211	.3612	.6704	.5418	.8378	.5418	.5144
7	.2593	.3251	.5235	.5057	.6921	.5418	.4978
8	.2701	.3251	.4886	.4696	.4141	.4015	.4315
9	.289	.289	.2618	.4515	.349	.3612	.3651
10		.2709	.2792	.3793	.3241	.4321	.3319
11		.2167	.3176	.0903	.4681	.4515	.15
12			.1808		.18	.1806	.1
13			.1802		.1084	.1626	.0834
14			.2443		.1445	.1442	.0667
15	.1445	.2167	.2094		.1806	.1396	.0834
16	.1445	.1825	.1745	.0722	.2117	.1571	.0834
17	.1806	.1806	.0873	.1445	.2521	.18	.1
18	.289	.4696	.1802	.1806	.2881	.2334	.1
19	.289	.6502	.2783	.2709	.3251	.2667	.15
20	.3251	.9211	.2523	.3251	.4681	.3001	.2501
21		1.2462	.2523	.289	.5041	.3178	.3001
22	.2529	.8669	.2163	.2709	.4681	.2334	.2
23	.1825	.6502	.2094	.2167	.3973	.2	.15
24	.2167	.1806	1.0994	.4138	.4234	.3251	.2667
Max	.9211	1.2462	1.0994	.5418	.8378	.5418	.5144
Min	.1445	.1806	.0873	.0722	.1084	.1396	.0667
Avg	.2944	.4206	.4124	.3324	.4103	.3237	.2562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 206 / 11 KV NEW NEVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3665	.3141	.2792	.3839	.3839	.3665	.2864
2	.3839	.3665	.3141	.4686	.4523	.4188	.2864
3	.4014	.4686	.3665	.4335	.5218	.4537	.3182
4	.4532	.4886	.4537	.5218	.7155	.5235	.3341
5	.5585	.5235	.6849	.349	.8001	.5934	.4136
6	.6632	.8377	.7853	.5418	.4537	.6283	.4454
7	.9012	.6981	.6981	.6806	.6632	.541	.4136
8	.9075	.5585	.4712	.487	.51	.5227	.4136
9		.5235	.4886	.3785	.4537		.3182
10		.6488	1.0471	.2792	.3839		
11		.7132	1.0645	.2792			
12		.8468	1.1997	.89	.9598	.6283	.9341
13		1.0122	1.1657	.9424	1.0837	.8377	.8866
14		1.1169	1.0471	.9075	1.1535	1.1169	.8233
15	.1802	1.0645	.8821	.8551	1.0645	1.1518	.7916
16	.192	.89	1.4819	.8028	.8377	1.0645	.7916
17	.2094	.89		.8377	.89	1.0232	.7599
18		.9012	.3528	.8726	.9174	.8909	.7441
19	.9773	.8651	.8028	.89	.8821	.8113	.7124
20	.9211	.8743	.6108	.9372	.8651	.7636	.4454
21	.7405	.7679	.5293	.8377	.4686	.7	.3977
22	.6283	.7155		.7155	.349	.6045	.3341
23	.2094	.8651	.4234	.6488	.349	.2864	.2227
24	.3665	.2792	.2094	.349	.3528	.3141	.2545
Max	.9773	1.1169	1.4819	.9424	1.1535	1.1518	.9341
Min	.1802	.2792	.2094	.2792	.349	.2864	.2227
Avg	.5329	.7179	.6981	.6371	.6744	.6781	.5149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 201 / 11 KV NACHANWEL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	.1715	.1715	.1715	.1886	
2	.1715	.0857	.1715			.2829	
3	.1715		.1715				
4	.2572	.1715	.1715				
5	.3429	.1715	.2572	.3429	.5144		
6	.3429	.2572	.2572			.5144	
7	.3429	.3429	.3429			.6859	
8	.3429	.3429	.3429				
9	.2572	.2572	.2572				
10	.2572	.2572	.2572	.3429	.1715		
11	.2572	.2572	.2572				
12	.3429	.3429	.3429			.1715	.1715
13	.3429	.4287	.3429				
14	.3429	.4287					
15	.3429	.4287		.1715			
16	.4287	.4287					
17	.3429	.4287	.3429	.2572			
18	.3429		.3429				
19	.2572		.2572				
20	.1715			.1715			
21	.1715				.1715		
22	.1715				.1886		
23	.1715				.1886		
24	.1886	.0857	.1715	.0857	.1715	.0943	.1715
Max	.4287	.4287	.3429	.3429	.5144	.6859	.1715
Min	.1715	.0857	.1715	.0857	.1715	.0943	.1715
Avg	.2722	.2824	.2622	.2205	.2254	.3229	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 202 / 11 KV DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.1715	.0857	.0857		
2	.1715	.1715	.1715				
3	.1715	.2572	.2572				
4	.2572	.2572	.2572				
5	.3429	.2572	.3429	.1715	.1715		
6	.3429	.3429	.4287				
7	.3429	.4287	.4287				
8	.3429	.4287	.2572				
9	.2572	.3429					
10	.2572	.2572	.1715	.1715	.2572		
11	.1715	.0857	.1715				
12	.1715	.0857	.1715			.1715	.1715
13	.1715	.0857	.1715				
14	.1715		.0857				
15	.0857	.0857	.0857	.2572	.2572		
16	.0857	.0857	.0857				
17	.0857	.1715	.0857	.1715	.1715		
18	.1715		.0857				
19	.1715		.2572				
20	.1715			.0857			
21	.1715				.1715		
22	.1715						
23	.1715						
24	.0943	.1715	.0857	.0857	.0857	.0857	.0857
Max	.3429	.4287	.4287	.2572	.2572	.1715	.1715
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1933	.2169	.1985	.1470	.1715	.1286	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 203 / 11 KV SAROLA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.0857		
2	.1715	.1715	.1715				
3	.2572	.2572	.2572				
4	.3429		.3429				
5	.3429		.4287	.3429	.2572		
6	.4287	.4287	.4287				
7	.3429	.4287	.4287				
8	.3429	.4287	.3429				
9	.3429	.3429	.3429				
10	.2572	.2572	.1715	.2572	.2572		
11	.2572	.0857	.1715				
12	.1715	.0857	.1715			.1715	.1715
13	.0857	.0857	.1715				
14	.0857	.0857	.1715				
15	.0857	.0857	.1715	.1715	.1715		
16	.0857	.0857	.1715				
17	.0857	.0857	.1715		.0857		
18	.1715		.1715				
19	.1715		.2572				
20	.2572			.1715			
21	.1715				.2572		
22	.1715						
23	.0857						
24	.1886	.0857	.0857	.1715	.0857	.0857	.1715
Max	.4287	.4287	.4287	.3429	.2572	.1715	.1715
Min	.0857	.0857	.0857	.1715	.0857	.0857	.1715
Avg	.2115	.1983	.2401	.2144	.1715	.1286	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 204 / 11KV DONGARGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857		
2	.0857	.0857	.0857				
3	.1715	.0857	.0857				
4	.2572	.1715	.1715				
5	.3429	.1715	.2572	.2572			
6	.3429	.2572	.2572				
7	.3429	.3429	.2572				
8	.2572	.3429	.2572				
9	.1715	.2572	.1715				
10	.1715	.1715		.1715	.1715		
11	.0857	.0857	.0857				
12	.0857	.0857	.0857			.0857	.0857
13	.0857	.0857	.0857				
14	.0857	.0857	.0857				
15	.0857	.0857	.0857	.0857	.0857		
16	.0857	.0857	.0857				
17	.0857	.0857	.0857				
18	.0857		.1715				
19	.1715		.1715				
20	.2572			.2572			
21	.1715				.1715		
22	.1715						
23	.0857						
24	.0943	.0857	.0857	.0857	.0857	.0857	.0857
Max	.3429	.3429	.2572	.2572	.1715	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1611	.1476	.1399	.1572	.1200	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 205 / 11 kv NACHANWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.1715	.2572	.2572		
2	.2572	.2572					
3	.3429	.2572	.2572				
4	.5144	.3429	.3429				
5	.6859	.5144	.5144	.6001	.5144		
6	.7716	.6859	.6001				
7	.6859	.6001	.6859				
8	.6001	.5144	.4287				
9	.4287	.4287					
10	.4287	.4287	.3429	.2572	.4287		
11	.4287	.3429	.3429				
12		.2572	.2572			.1715	.2572
13		.2572	.2572				
14		.2572	.2572				
15		.2572	.2572	.2572	.2572		
16		.2572					
17	.3429	.2572	.3429				
18	.5144		.4287				
19	.6859		.5144				
20	.6001			.7716			
21	.4287				.4287		
22	.2572						
23	.2572						
24	.2829	.2572	.1715	.2572	.2572	.1715	.2572
Max	.7716	.6859	.6859	.7716	.5144	.1715	.2572
Min	.2572	.2572	.1715	.2572	.2572	.1715	.2572
Avg	.4616	.3572	.3631	.4001	.3572	.1715	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 206 / 11 kv SAROLA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857		
2	.0857	.0857	.0857				
3	.1715	.1715	.1715				
4	.2572	.1715	.2572				
5	.3429	.2572	.3429	.3429	.4287		
6	.4287	.4287	.4287				
7	.4287	.4287	.4287				
8	.4287	.3429	.3429				
9	.2572	.2572	.2572				
10	.2572	.1715	.1715	.2572	.3429		
11	.1715	.0857	.1715				
12	.1715	.0857	.0857			.0857	.1715
13	.1715	.0857	.0857				
14	.1715	.0857	.0857				
15	.1715		.0857	.1715	.1715		
16	.0857	.0857	.0857				
17	.1715	.1715	.0857		.1715		
18	.2572		.1715				
19	.4287		.2572				
20	.4287			.4287			
21	.1715				.2572		
22	.1715						
23	.0857						
24	.0943	.0857	.0857	.0857	.0857	.0857	.0857
Max	.4287	.4287	.4287	.4287	.4287	.0857	.1715
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2290	.1815	.1886	.2286	.2205	.0857	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 207 / MOHADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1715	.0857			
2	.0857	.0857	.1715				
3	.0857	.1715	.1715				
4	.0857	.2572	.2572				
5	.0857	.2572	.3429	.1715			
6	.0857	.2572	.3429				
7	.0857	.3429	.0343				
8	.0857	.3429	.2572				
9	.0857	.3429	.1715				
10	.0857	.2572	.1715	.2572			
11	.0857	.0857	.0857				
12	.0857	.0857	.0857			.1715	.1715
13	.0857	.0857	.0857				
14	.0857	.0857	.0857				
15	.0857	.0857	.0857	.2572	.1715		
16	.0857	.0857	.0857				
17	.0857	.0857	.0857		.2572		
18	.0857		.0857				
19	.0857		.0857				
20	.0857			.1715			
21	.0857				.0857		
22	.0857						
23	.0857						
24	.0857	.0857	.0857	.0857		.0857	.0857
Max	.0857	.3429	.3429	.2572	.2572	.1715	.1715
Min	.0857	.0857	.0343	.0857	.0857	.0857	.0857
Avg	.0857	.1714	.1475	.1715	.1715	.1286	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 210 / MOHRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.1715	.1715		
2	.1715	.1715	.0857				
3	.1715	.1715	.1715				
4	.2572	.2572	.1715				
5	.3429	.2572	.2572	.3429	.4287		
6	.3429	.2572	.3429				
7	.3429	.3429	.3429				
8	.2572	.3429	.2572				
9	.2572	.3429					
10	.2572	.2572	.1715	.2572	.2572		
11	.1715	.0857	.1715				
12	.1715	.1715	.1715				.0857
13	.2572	.1715	.1715				
14	.2572	.1715	.1715				
15	.3429	.1715	.1715	.0857	.1715		
16	.3429	.1715					
17	.2572	.1715	.2572		.0857		
18	.2572		.2572				
19	.2572		.1715				
20	.1715			.1715			
21	.1715				.0857		
22	.1715						
23	.1715						
24	.0857	.1715	.0857	.0857	.0857	.0857	.1715
Max	.3429	.3429	.3429	.3429	.4287	.0857	.1715
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2322	.2096	.1953	.1858	.1837	.0857	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 201 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.4763	.4001	.2572	.3239	.2858	.2829
2	.7716	.4763	.4001	.2572	.3239	.3239	.3018
3	.7716	.4763	.4001	.3429	.4191	.381	.3772
4	.8573	.5716	.4801	.5144	.4763	.4572	.5658
5	1.0288	.6097	.8002	.6001	.5716	.6097	.6602
6	.9878	1.2765	.9602	.6001	.6859	.743	.7167
7	1.0688	1.1498	1.1843	.583			.6413
8	.9774	1.0202	1.0082	.583	.5921		.6979
9	.8162	.9717	.9069	.4287	.5281	.4458	.5906
10	.6722	.8097	.7125	.463	.4801	.3429	
11	.2241	.2401	.2286	.2058	.4321		
12	.208	.2572	.2858	1.0688	.6401	1.0802	
13		.2572	.362	.9088	.5601		.7621
14	.192	.2572		.7716	.5601		
15	.2241	.2058		.5992		.8745	.6478
16	.2753	.2229	.3429	.4858	.5921	.8745	.8097
17	.2096	.2401	.3601	.6097	.9526	.8162	1.0631
18	.381	.3201	.3772	.5182	.8764	.7202	.8097
19	.5525	.3841	.463	.4858	.724	.6081	.5668
20	.4572	.4161	.5144	.4696	.3429	.5658	.4115
21	.381	.2721	.3429	.4049	.3429	.4527	.3429
22	.381	.2721	.2572	.381	.2858	.3206	.2572
23	.3239	.2721	.2572	.3239	.2858	.3018	.2572
24	.2058	.3239	.2721	.2572	.2858	.2858	.2829
Max	1.0688	1.2765	1.1843	1.0688	.9526	1.0802	1.0631
Min	.192	.2058	.2286	.2058	.2858	.2858	.2572
Avg	.5485	.4908	.5144	.5050	.5128	.5521	.5523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 202 / 11KV NIMBHORA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1509	.4858	.7621		.2058
2	.1715	.1905	.1509	.4858	.7621	.4763	.2058
3	.1715	.1905	.1886	.5668	.8573	.4763	.2572
4	.2572	.1905	.2263	.6478	.9526	.5716	.4458
5	.3429	.2286	.2829	.7287	.8097	.5716	.5792
6	.3944	.2286	.3018	.8097	1.0526	.6478	
7	.3601	.4382	.3395	1.004			
8	.2743	.2667	.3018	.8421	.9602		1.0669
9	.1619	.1886	.1905	.5668	.7202	.6001	1.1431
10		.1029	.1905	.5144	.5601	.12	.9526
11	.1509	.12	.1905	.0857	.1509		.1143
12	.6859	.9602	1.0479	.1372	.1509		
13	.8002	.8592	.9878		.1509		
14	.8002	.8097	.8907		.1509		
15	.8002	.7888	.7611		.1509		
16	.7202	.8573	.7125		.1509		
17	.8192	.6859	.8259				
18	.7621	.6097	.6802		.1905		
19		.5335	.5668	.2667	.1905	.2263	.4801
20	.2667	.1886	.1715	.2667	.1524	.3395	.3429
21	.2477	.1509	.1372	.2286	.1143	.3018	.2572
22	.2286	.1509	.1372	.1905	.1524	.2829	.1715
23	.2286	.1509	.1372	.1905	.1524	.2452	.1715
24	.1715	.4191	.1509	.1372	.1905	.1524	.1886
Max	.8192	.9602	1.0479	1.004	1.0526	.6478	1.1431
Min	.1509	.1029	.1372	.0857	.1143	.12	.1143
Avg	.4085	.3958	.4050	.4531	.4312	.3855	.4388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 204 / 11 KV MEHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.381	.2591	.2572	.2858	.2286	.3584
2	.6859	.4763	.2591	.2572	.3239	.2858	.3584
3	.7716	.4763	.2591	.3429	.381	.3239	.3772
4	.8573	.4763	.4115	.4287	.4191	.381	.4904
5	.8573	.6859	.7621	.5144	.4763	.4763	.6224
6	.9602	1.085	.9145	.6001	.5906	.5906	.6602
7	1.166	1.085	1.0669	.4287			.5658
8	.9393	.9717	1.226	.5144	.5658		.4904
9		.664		.4458	.4904		.4001
10	.5792	.664	.8002	.3772	.3961		
11	.2439		.2667	.3429			
12	.2881		.4191	1.1317	.8802		1.0364
13	.2881		.4572	1.1488	.5763	1.166	.8097
14	.3041			.8573	.7621	1.0288	.7049
15	.3772		.381	.823	.6859		.7621
16	.3772		.3429	.8745	.6722		.8097
17	.4572		.2572	.9526		1.0364	
18	.4382	.3772	.3429	.7125	.9907	.9145	.8259
19	.5335	.415	.5144	.7449	.8192	.7621	.6964
20	.4954	.5658	.5144	.4572	.381	.5281	.5144
21	.4191	.415	.4287	.4191	.3048	.4527	.4287
22	.3429	.3772	.3429	.3429	.2286	.3395	.3429
23	.3048	.3584	.2572	.2858	.2286	.3395	.3429
24	.2572	.3048	.3206	.2572	.2858	.2286	.3584
Max	1.166	1.085	1.226	1.1488	.9907	1.166	1.0364
Min	.2439	.3048	.2572	.2572	.2286	.2286	.3429
Avg	.5454	.5752	.4911	.5632	.5116	.5677	.5693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 205 / 11KV NIMBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.0754	.0857	.0953	.0953	.0943
2	.0857	.0762	.0754		.0953	.0953	.0943
3	.1029	.0762	.0943		.0953	.0953	.132
4	.1715	.1143	.1509		.1524	.1524	.1886
5	.2229	.1524	.1886		.2096	.1905	.2452
6	.2572	.1905	.2263		.2667	.2667	.2829
7	.2572	.2477	.2829		.2667		.2829
8	.2229	.2096	.2263		.2452		.2452
9	.1886	.1372	.1715		.1886	.1543	.1905
10		.0857	.1524		.1132	.0857	.1143
11	.0754	.0686	.0762		.0943		.0762
12	.0754	.0514	.0762		.0943		
13	.0754	.0514	.0572		.0943		
14	.0754	.0514	.0572		.0754		
15	.0754	.0514	.0572		.0754		
16	.0943	.0514	.0514		.0754		
17	.0762	.0943	.0686		.0572		
18	.1143	.1886	.1029		.0953		
19	.2096	.2263	.1715	.1905	.2096	.2075	.1543
20	.1715	.1886	.1715	.2286	.1905	.1886	.1886
21	.1143	.1132	.12	.1905	.1143	.1698	.1372
22	.0953	.1132	.0857	.1524	.0953	.1132	.1029
23	.0762	.0754	.0857	.0953	.0953	.0943	.0857
24	.0857	.0762	.0754	.0857	.0953	.0953	.0943
Max	.2572	.2477	.2829	.2286	.2667	.2667	.2829
Min	.0754	.0514	.0514	.0857	.0572	.0857	.0762
Avg	.1308	.1153	.1209	.1470	.1329	.1432	.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 206 / 11KV WASADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.0953	.0857	.0953	.0953	.0943
2	.0857	.0762	.0953	.0857	.0953	.0953	.0943
3	.1029	.0762	.0953	.1029	.0953	.1524	.1509
4	.1372	.0762	.1143	.1372	.1524	.1905	.1886
5	.1715	.1143	.1524	.1715	.1905	.2286	.2452
6	.2229	.2477	.1905	.2401	.2477	.2667	.3018
7	.1715	.2477	.2286	.2401	.2477		.2452
8	.1886	.2096	.2286	.2058	.2263		.2263
9	.1886	.1543	.1524	.1715	.1886	.1372	.1715
10	.1698	.1372	.1334	.1372	.1509	.0857	
11	.132	.0857	.1143	.0857	.1132		
12	.0943	.1029	.0953	.0857	.1509	.1029	
13		.0686	.0953	.0857	.1509	.0857	.0953
14	.132	.0686		.0857	.1886		
15	.132	.0686		.0857	.1886	.12	.0381
16	.1132	.1029	.1372		.1509	.0857	.1143
17	.0953	.1132	.12	.1143	.1524	.1509	.1543
18	.1334	.1886	.1372	.1334	.1334	.1886	.1372
19	.2286	.2263	.1543	.1715	.1524	.2263	.1543
20	.1905	.2075	.1715	.1715	.1905	.1886	.1715
21	.1524	.1132	.12	.1524	.1334	.1698	.1372
22	.1143	.1132	.0857	.0953	.0953	.1509	.1029
23	.0762	.0943	.0857	.0953	.0953	.1132	.0857
24		.0762	.0943	.0857	.0953	.0953	.0943
Max	.2286	.2477	.2286	.2401	.2477	.2667	.3018
Min	.0762	.0686	.0857	.0857	.0953	.0857	.0381
Avg	.1418	.1269	.1317	.1315	.1534	.1465	.1502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 207 / 11KV MEHGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1143	.1334	.1715	.1143	.1143	.1509
2	.12	.1143	.1334	.1715	.1143	.1143	.1509
3	.1372	.1524	.1905	.2572	.1905	.1905	.1886
4	.2572	.1905	.3048	.3429	.3048	.3048	.3018
5	.3429	.2667	.381	.4287	.381	.381	.4527
6	.463	.4763	.4572	.4801	.4954	.4954	.547
7	.3086	.4001	.4001	.3429	.381		.3772
8	.3429	.4572		.4115	.3206		.4527
9		.3086	.2858	.2743	.3018		.3239
10	.2452	.2058	.2858	.2229	.2452		.2286
11	.2263		.2096	.1543	.1886		.1334
12	.1509		.1524	.1372	.1886		.1143
13	.1509		.1524	.12	.1698	.1372	.1143
14	.1509			.12	.1698	.1372	.1143
15	.1509		.1143	.1372	.1886		.1143
16	.1886		.1543	.1372	.1698		.1334
17	.1524		.1543	.1524	.1715	.2263	
18	.1905	.3018	.2058	.1905	.1905	.3018	.1886
19	.3429	.3772	.2572	.1715	.2858	.3772	.3086
20	.3429	.3584	.3429	.3048	.2286	.3018	.3429
21	.2858	.1886	.3429	.2477	.1905	.1886	.2572
22	.2096	.1509	.1715	.1905	.1524	.1509	.1715
23	.1524	.132	.1715	.1524	.1143	.1509	.1372
24	.12	.1143	.112	.1715	.1143	.1143	.132
Max	.463	.4763	.4572	.4801	.4954	.4954	.547
Min	.12	.1143	.112	.12	.1143	.1143	.1143
Avg	.224	.2535	.2324	.2288	.2238	.2304	.2364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 201 / 11 KV KARANJKHEDA AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1029	.0762	.381	.4115		.4572
2	.0572	.1029	.0762	.381	.4458		.4877
3	.0572	.0857	.0762	.3963	.4973		.503
4	.0572	.0857	.0762	.4115	.583		.5182
5	.0572	.0857	.0762	.442	.6859		.5182
6	.0953	.0857	.0762	.6249	.8402		.884
7	.0572	.12	.0762	.8535	.9774		.9602
8		.1029	.0762	.7621	.8573		.9145
9	.0191	.12	.0762	.6706	1.1145		
10		.0171	.0191	.6097		.6706	
11	.0171	.0171	.0381				
12	.6859	.7935	.8078				
13	.7202	.8097	1.0082				
14	.7373	.8421	.8078				
15		.8745	.7926				
16	.8402	.8097	.7011				
17	.8573	.7773	.7926	.0686	.0171	.0191	.0171
18	.8916	.7125	.7621		.0187	.0191	.0171
19	.7716	.6316	.6097	.0857	.0171	.0191	.0171
20	.0686	.0762	.0572		.0171	.0572	.0171
21	.0343	.0762	.0572	.12	.0343	.0572	.0171
22	.0514	.0762	.0572	.12	.0343	.0572	.0171
23	.0686	.0762	.0572	.1029	.0343	.0572	.0171
24	.0572	.0514	.0762	.056	.12	.0171	.0572
Max	.8916	.8745	1.0082	.8535	1.1145	.6706	.9602
Min	.0171	.0171	.0191	.056	.0171	.0171	.0171
Avg	.2980	.3139	.3054	.3804	.3945	.1082	.3387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 202 / 11 KV NAGAPUR AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1029		.1219	.2058	.1296	.1372
2	.0934	.12	.1494		.2401	.1372	.1524
3	.112	.0857	.1494	.1219	.0171	.1886	.1524
4	.112		.1494	.1372	.4973	.2572	.1677
5	.1307	.1372	.168	.1524	.5144	.3563	.1829
6	.1991		.1867	.3048			.5335
7	.1494	.1543	.1867	.4115			.5335
8		.12	.112	.3353			.3963
9	.1307	.0857	.0747	.2439			.3048
10		.0857	.056			.3048	
11	.1029	.0686	.0934				
12	.3258	.4481	.3658				
13	.3429	.3239	.3506				
14	.3601	.3239	.3048				
15		.3077	.2439				.0171
16	.2058	.3077	.2743				
17	.4115	.3361	.3506		.0514	.0187	.0171
18	.3258	.2915	.3506		.0686	.112	.0171
19	.3086	.1943	.1524	.12	.0686	.1867	.0857
20	.1372	.1494	.1867	.12	.0686	.1867	.2058
21	.1372	.1448	.1307	.1029	.1029	.1494	.1543
22	.12	.1307	.112	.1029	.0514	.112	.0857
23	.12	.112	.112	.1029	.0514	.112	.1372
24	.0934	.0343	.1494	.112	.1029	.0514	.112
Max	.4115	.4481	.3658	.4115	.5144	.3563	.5335
Min	.0934	.0343	.056	.1029	.0171	.0187	.0171
Avg	.1910	.1848	.1917	.1778	.1570	.1645	.1885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 203 / 11 KV PURANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3258		.0934	.0857		.112
2	.2439	.4973		.112	.0857		.112
3	.2591			.112			.112
4	.2743			.112	.1029		.112
5	.2896			.112			.112
6	.6097			.112	.1029		.112
7	.9145			.056	.1029		.056
8				.0187	.1029		.0373
9	.6097	.6859		.0187	.1029		.0187
10		.8907			.1029	.0373	
11				.0171	.1029	.0187	.0171
12				.6859	.9393	.6401	.6859
13				.7716	.8907	.7842	.9431
14				.8573	.6478	.503	.8573
15				.7716	.5506	.4572	.7202
16	.0857				.4858	.4572	.5144
17	.0857	.1543	.0187	.6859	.4696	.503	
18	.0686	.1543	.0187	.6859	.4534	.4877	.4458
19	.0857	.0686	.056	.6859	.3401	.3201	.4287
20	.0857	.0747	.0747	.0686	.0857	.112	.1029
21	.0857	.0747	.1086	.1029	.1029	.112	.1029
22	.1029	.0747		.0343	.1029	.112	.1029
23	.0514	.0747	.112	.1029	.1029	.112	.1029
24	.056	.0343		.0934	.1029	.0686	.112
Max	.9145	.8907	.112	.8573	.9393	.7842	.9431
Min	.0514	.0343	.0187	.0171	.0857	.0187	.0171
Avg	.2433	.2592	.0648	.2868	.2803	.3150	.2691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 204 / 11kv KARANJKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.3429	.3734	.4668	.4287	.4481	.4481
2	.4854	.3601	.3921	.4854	.4458	.4481	.4854
3	.5228	.4115	.4481			.5228	.5228
4	.5975	.4973	.5601	.5975	.5487	.5601	.5601
5	.7468	.6859	.7095	.7095	.6516	.6348	.6722
6	.9335	.823	.8215	.8775	.8059	.8589	.8589
7	.8962	.8402	.8589	.8215	.703	.8775	.8402
8		.8573	.8029			.7468	.8215
9	.7842	.7202	.7842		.6859	.8215	.7095
10		.6908	.5975			.6908	
11	.4973	.5601	.4108	.463	.6535		.4973
12		.5041	.4481	.4115	.5415		.4458
13		.4854	.4481	.3944	.4668	.5041	
14		.4854	.4668	.3772		.5601	
15		.4668	.4854	.3772	.6348	.5601	.4115
16		.5601	.5228		.6908	.5601	.3944
17		.6535	.5975	.5144	.7095	.5788	.4287
18	.7202	.7655	.7468		.7468	.7842	.4973
19	.703	.7842	.8029		.2614	.8402	.6859
20	.703	.7468	.8402		.7468	.8215	.6859
21	.6859	.6722	.6535	.3429	.8215	.6535	.5658
22	.5144	.5975	.5601	.3601	.5975	.5228	.4801
23	.5144	.5601	.5041	.3429	.5601	.4854	.4458
24	.4854	.4458	.4854	.4668	.3258	.4854	.4481
Max	.9335	.8573	.8589	.8775	.8215	.8775	.8589
Min	.4668	.3429	.3734	.3429	.2614	.4481	.3944
Avg	.6411	.6049	.5967	.5005	.6013	.6348	.5669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 205 / 11KV REULGAON AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601	.4572	.0191	.0171		.0191
2		.4115	.5335	.0191			.0191
3		.4458	.5792	.0191	.0171		.0191
4		.5144	.6097	.0191			.0191
5			.6859	.0191	.0171		.0191
6		.7716	.8383	.0191			.0191
7		.8573	.9907	.0191	.0171		.0191
8		.7888	.9145				.0191
9	.3963	.6859	.884		.0171		.0191
10		.6478	.5639		.0171	.0191	
11				.6516	.0171	.0191	
12				.6859	.8259	.884	.6859
13					.8421	1.0364	.7888
14				.7716	.8583	1.0059	.6859
15				.7888	.8907	1.0059	
16				.8059	.8907	.884	
17	.0171	.0171	.0191	.823	.9231	.9145	
18		.0171	.0953		.9393	.8535	
19	.0171	.0171	.0191	.0686	.8259	.7621	
20	.0171	.0191	.0191	.0857	.0171	.0191	
21	.0171	.0191	.0191	.1029	.0171	.0191	
22	.0171	.0191	.0191		.0171	.0191	
23	.0171	.0191	.0191	.1029		.0191	
24	.0191	.0171	.0191	.0191	.0857	.0171	.0191
Max	.3963	.8573	.9907	.823	.9393	1.0364	.7888
Min	.0171	.0171	.0191	.0191	.0171	.0171	.0191
Avg	.0648	.3311	.4048	.2800	.3817	.4985	.1809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 206 / CHIMNAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2058	.2241	.2241	.2058		.2427
2	.2427	.2401	.2614	.2427	.2401		.2614
3	.2614	.2743	.2987	.2614	.2743		.2987
4	.2987	.1715	.3174	.2987	.2915		.3361
5	.3361	.3429	.3734	.3547	.2915		.3921
6	.5041		.3734	.5041			.5788
7	.3734	.3601	.056	.3361	.4115		
8		.3429	.3547		.3944		.3361
9	.2715	.3086	.2614		.3429		.2801
10		.168	.168		.3547		
11	.1543	.1307	.1307	.1543	.1307		
12	.0857		.0934	.1543	.112		
13	.1372	.1307	.112		.112		.2401
14	.1372	.1307	.112	.1543	.1307		.1543
15	.1543	.1494	.112	.1715	.168	.168	.1372
16	.1715	.2054	.1867	.2058	.168	.168	.1543
17	.2058	.2427	.1867	.2401	.1867	.2054	.12
18		.2801	.2801	.2743	.2427	.4294	.1372
19	.3601	.2987	.3174	.2058	.2987	.4294	.2401
20	.3086	.3734	.3734	.2401	.3734	.4481	.463
21	.2572	.2614	.2614	.2229	.4481	.3361	.3429
22	.2572	.2241	.2229	.2058	.2427	.2987	.3429
23	.2401	.2054	.2241	.2058		.2614	.2401
24	.2241	.2229	.2054	.2241	.1886		.2427
Max	.5041	.3734	.3734	.5041	.4481	.4481	.5788
Min	.0857	.1307	.056	.1543	.112	.168	.12
Avg	.2479	.2395	.2294	.2440	.2550	.3049	.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 203 / 11kV JAMADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.5316	.703	.7716	.5144	.7545	.7716
2	.8573	.6001	.703	.8573	.7202	.7545	.8573
3	.9431	.6001	.7202	.9431	.9431	.7716	.9431
4	1.0974	1.286	.823	1.0288	1.0288	.8916	1.0288
5	1.6289	1.5604	1.286	1.286	1.0802	1.2003	1.5432
6	1.749	1.9033	2.0062	1.5432	1.7147	2.0748	1.8519
7	2.0576	1.7318	1.8004	1.8861	1.7661	1.7318	1.6289
8	1.5432	1.2689	1.5089	1.3717	1.6118	1.5775	1.5432
9	1.1145		1.1488	1.1488	1.1831	1.1488	1.1145
10			.6344	.5144	.6173	.7202	.6344
11		.7545	.6001	.5144	.463	1.0631	.3772
12		1.6804	1.2003	.6859	.9088	1.0288	1.1488
13		1.5432	1.3717	.9431	.703	1.0288	.9945
14		1.0974	1.2003		.7545	.9431	.823
15	.6344	1.0974	1.1145	1.0288	1.2689	.8916	.8573
16	.6859	1.1145	1.1145	1.0802	1.286	.8916	.9088
17	.6687	1.1488	1.1145	.703	1.3203	1.1145	1.0631
18	.7545	1.2003	1.166	.7202	.9431	1.1488	1.2003
19	1.1145	.823	.8573	.6859	.8059	1.1145	.823
20	.7202	1.4232	1.1145	.7716	1.2517	1.0288	1.3889
21	.8573	1.046	.9774	.9088	.9431	.8916	.9259
22	.7716	.7888	.8573	.8573	.8916	.7716	.8402
23	.7716	.7545	.7716	.7716	.823	.7716	.7888
24	.7716	.5144	.7202	.7716	.3429	.7888	.7716
Max	2.0576	1.9033	2.0062	1.8861	1.7661	2.0748	1.8519
Min	.6344	.5144	.6001	.5144	.3429	.7202	.3772
Avg	1.0270	1.1122	1.0631	.9475	.9952	1.0460	1.0345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 201 / 11 KV DEULGAON(BZ) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772					.1886
2	.3395	.2263			.1698	
3	.3018					
4	.3772	.3395			.3018	
5	.3772					
6	.415	.4527			.4715	
7	.3772	.4715			.3772	
8	.4338	.3018			.415	
9		.2829				
10	.2263	.2263		.1886	.3018	.2452
11		.2452				
12	.1357	.1658		.1311	.1326	.0857
13		.1341				
14	.0972	.1017		.0895	.1017	
15		.0857				
16	.1029	.1029		.1052	.0867	.0781
17		.1187				.0857
18				.0886		.1075
19					.1867	
20	.3772			.3772		
22	.2829			.2263		
23	.2263			.1886		
24	.1132	.1886	.1509		.1509	.3772
Max	.4338	.4715	.1509	.3772	.4715	.3772
Min	.0972	.0857	.1509	.0886	.0867	.0781
Avg	.2850	.2296	.1509	.1744	.2451	.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 202 / 11 Kv Kotnandra SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7655
2	.6283	.5544		.4024	
4	.567	.823		.6468	
6	.6379	1.0745		.905	
7				1.1568	
8	.6241	.8669		.9431	
9		.6836	.5506		
10	.4207	.5792	.4572	.5609	1.1633
11		.5658			
12	.415	.4904	.3772	.6602	.5658
13		.5281			
14		.5281	.4715		
16		.415	.3772	.4715	.3772
17		.3772			.415
18			.4904		.4715
19				.8676	
20	.8488		1.3203		
22	.679		.9431		
23	.6036		.679		
24	.6036	.5658		.4481	.679
Max	.8488	1.0745	1.3203	1.1568	1.1633
Min	.415	.3772	.3772	.4024	.3772
Avg	.6028	.6194	.6296	.7062	.6339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 203 / 11 Kv Ghatnandra SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676				1.1506
2	.7842	1.2449		1.1694	
3	.7842				
4	.8589	1.5089		1.6032	
5	1.0829				
6	.9335	1.7918		1.6975	
7	.9522	1.8107		1.8107	
8	1.0829	1.7353		1.6032	
9		1.4937			
10	1.3203		1.1694	1.1317	1.2323
12	.7011	.8951	.3906	.6036	1.0631
13		.8192			
14	.5144	.6962	.5121	.4915	
15		.57			
16	.4961	.6344	.6154	.5201	.5937
17		.7011			.7202
18			.7011		.815
19				.724	
20	1.7353		1.7918		
22	1.6221		1.6032		
23	1.4335		1.226		
24	1.1203	1.226		1.0562	.679
Max	1.7353	1.8107	1.7918	1.8107	1.2323
Min	.4961	.57	.3906	.4915	.5937
Avg	1.0181	1.1636	1.0012	1.1283	.8934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 204 / 11 KV SHINDEPHAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263					.6722
2	.2987	.3292			.3658	
3	.631					
4	.5144	.5544			.5175	
5	.5365					
6	.5079	.7888			.7602	
7	.4687	.9709			.9671	
8	.5944				.7282	
9		.6554				
10	.2774	.4572		.3086	.3898	.4062
11		.7202				
12	.4527			.3584	.3395	.3277
13		.6036				
14	.3772	.4715		.3772	.415	
15		.4338				
16		.415		.3772	.4527	.3961
17		.415				.5281
18				.6036		.6602
19					.9431	
20	1.0562			1.0374		
22	.8488			.679		
23	.679			.5658		
24	.5847	.6036	.679		.4904	.415
Max	1.0562	.9709	.679	1.0374	.9671	.6722
Min	.2263	.3292	.679	.3086	.3395	.3277
Avg	.5369	.5707	.679	.5384	.5790	.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 205 / 11 Kv Charner SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	11-JUN-18	12-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3395
2	.3018	.415		.3018	
4	.415	.6036		.4904	
6	.4904	.8488		.8676	
7		.7545		.6602	
8	.5093	.6036		.5658	
9		.4904			
10	.2263	.4715	.1886	.2263	
11		.3772			
12		.6622	.4858	.5487	.5487
13	.6923	.5792			
14	.5944	.4755	.4214	.4401	
15		.3763			
16	.4515	.5213	.4161	.5268	.4967
17		.6241			.4268
18			.3311		.3201
19				.2972	
20	.4904		.6602		
22	.415		.4904		
23	.415		.3395		
24	.5847	.3772		.2829	.679
Max	.6923	.8488	.6602	.8676	.679
Min	.2263	.3763	.1886	.2263	.3201
Avg	.4655	.5454	.4166	.4734	.4685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 201 / 11Kv Golegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.4163	.2126	.2454	.1928	.2012	.543
2	.3506	.4477	.2427	.3012	.1753	.2347	.6024
3	.4252	.5487	.2865	.3681	.2103	.2683	.6805
4	.5316	.6516	.3292	.4334	.4075	.4024	.724
5	.7522	.7701	.4607	.4733	.4382	.5197	.7682
6	1.1157	1.0454	.543	.691	.4961	.57	1.0387
7	.9745	1.0387	.5552	.5609	.5493	.5533	.9134
8	.8145	.9313	.4961	.6762	.6556	.5365	.9313
9	.8589	.9328	.3681	.5493	.4527	.567	.6024
10	.6068	.6219	.3366	.3506	.4024	.3681	.567
11	.6268		.2507	.2804	.2561	.5194	.5316
12	.3582	.2683	.2378	.2629		.6626	.5138
13	.3292	.3018	.2896	.2804	.5487	.5853	.4207
14	.3258	.3018	.2149	.3155	.2012		.3506
15	.3439	.285	.2481	.2481	.2561	.7059	.3155
16	.3439	.285	.3045	.2629	.2561		.3155
17	.3988	.3018	.3439	.333	.3292	.7164	.3506
18	.4733	.3688	.5493		.4024	1.0029	.333
19	.5493	.4207	.8145	.4784	.4755	1.2254	.3721
20	.7421	.7164	.7316	.7522	.439	1.0498	.8869
21	.6219	.695	.6154	.4784	.3841	.8326	.7522
22	.5487	.5249	.5014	.4075	.3292	.6805	.4382
23	.4887	.543	.4525	.3681	.2561	.5792	.4557
24	.3681	.443	.5014	.3898	.3155	.2195	.5014
Max	1.1157	1.0454	.8145	.7522	.6556	1.2254	1.0387
Min	.3258	.2683	.2126	.2454	.1753	.2012	.3155
Avg	.5549	.5591	.4119	.4133	.3665	.5909	.5795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 202 / 11Kv Undengaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.7316	.3856	.4075	.4252	.4024	.724
2	.5316	.7602	.4161	.4334	.4961	.4359	.8048
3	.567	.815	.5138	.5014	.5316	.57	.8688
4	.8596	.8775	.5197	.5316	.7164	.6706	.9412
5	1.0974	.9511	.7712	.5609	.7964	.7712	1.0029
6	1.3306	1.1999	.6706	.9015	1.0791	.8886	1.4529
7	1.3306	1.1584	.6836	1.258	1.2071	1.0227	1.3032
8	1.1888	.8688	.6706	1.2094	1.1523	1.1233	1.1403
9	.9774	.695	.631	.7701		1.0166	.8869
10	.7865	.6401	.5028	.4784	.6036	.6068	.7164
11	.7164	.6219	.8682	.7701	.6584		.9774
12	.8859	.7377	.788	.6984	.823		1.134
13	.7186	.57	.695	.7522		1.1706	.8869
14	.5721	.57	.8145	.9231	1.0791	1.086	.788
15	.5316	.6036	.788	.788	1.0608	.9922	.7164
16	.4908	.5868	.7602	.8688	1.0242	1.1403	.788
17	.6661	.6036	.7701	.905	.9694	.9671	.6984
18	.5721	.6371	.823		1.134	1.2403	.6201
19	.4961	.5959	.8779	.9412	1.2986	1.3213	.6805
20	1.1104	.9671	.9134	1.0974	1.0059	1.1999	1.2254
21	.9877	.9145	.8326	1.0317	.9877	1.1157	.9231
22	.8326	.8688	.7164	.9231	.9328	1.0242	.788
23	.6733	.8596	.6219	.8869	.8048	.8596	.6805
24	.567	.7421	.8326	.5792	.8238	.6952	.7442
Max	1.3306	1.1999	.9134	1.258	1.2986	1.3213	1.4529
Min	.4908	.57	.3856	.4075	.4252	.4024	.6201
Avg	.7918	.7740	.7028	.7921	.8914	.9237	.8955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 203 / 11Kv Khedi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1928	.1772	.4207	.3761	.2804	.2012	.1753
2	.2103	.1907	.3721	.4075	.2804	.2561	.208
3	.2454	.2279	.4656	.5014	.3155	.3292	.2629
4	.3681	.2774	.543	.5493	.3681	.5121	.3189
5	.5316	.3467	.695	.6335	.6733	.7133	.3641
6	.6379	.6135	.7421	.8059	.7701	.9694	.7265
7	.6201	.6201	.691	.7602	.7522	.8779	.6135
8	.5493	.5895	.6447	.6401	.6379	.7682	.5721
9	.4207		.4252	.4607	.4755	.591	.4784
10	.2774		.2865	.3155	.3109	.4024	.4075
11	.2149		.2561	.1928	.2195	.3582	.2629
12	.1991		.5138	.567	.8383	.5847	
13	.2012		.4887	.4784	1.2574	.4733	
14	.181		.439	.4207	.6874	.4252	
15	.2012		.3898	.2454	.6371	.3467	
16	.2149		.4344	.1753	.5197	.4207	.2804
17	.2353		.443	.2629	.503	.4908	.3506
18	.439		.3856		.5365	.4607	.567
19	.567	.6268	.3506	.2804	.5868	.4161	.7164
20	.5068	.5853	.4344	.788	.4024	.5373	.7964
21	.4477		.4075	.7164	1.2574	.5068	.6379
22	.4024	.5138	.3721	.4784	.3841	.4572	.5316
23	.362	.4706	.3658	.3681	.3292	.3982	.3681
24	.3506		.4298	.3258	.333	.4024	.4163
Max	.6379	.6268	.7421	.8059	1.2574	.9694	.7964
Min	.181	.1772	.2561	.1753	.2195	.2012	.1753
Avg	.3574	.4366	.4582	.4674	.5565	.4958	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 205 / 11Kv Panwadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4784	.4607	.9134	.724	.5316	.7865	.3189
2	.5316	.4908	.8688	.7796	.5847	.8413	.3814
3	.5847	.5548	1.0029	.905	.6201	.9877	.4908
4	.8059	.6661	1.1706	1.1584	1.4415	1.2071	.6024
5	1.2071	.7455	1.2851	1.4266	1.6804	1.4815	.6984
6	1.4937	1.4352	1.3466	1.7375		1.7558	1.3466
7	1.46	1.2971	1.4661	1.5402	1.7177	1.6095	1.2757
8	1.2254	1.1043	1.5203	1.258		1.3717	1.1568
9	.6485	.6539					.788
10	.5895	.5365				.8059	.6201
11	.4656		.5373	.6733		.6335	.5609
12	.4755	.4755	1.2757	.9412	.6874	1.3289	.6201
13	.4887	.6036	.7975	.7164	.4191	.8063	.5316
14	.4656	.695	.7537	.8238	.4862	.6762	.6201
15	.5121	.7499	.7712	.7164	.7377	.5847	.5847
16	.543	***	.815	.7522	.4862	.6241	.6024
17	.695	1.0974	.8413	.7701	1.0562	.9214	.6201
18		1.2178	.8328		1.0242	.9114	.9231
19	1.3394	1.39	.7975	.8688	.7377	.7108	1.4449
20	1.1641		1.0745	1.0974	1.1523	.8596	1.2071
21	1.0277	.8326	.8682	.9231	1.0608	.8059	.9231
22	.905	1.0425	.8417	.9231	.9877	.7602	.788
23	.8048	.9134	.7964	.7164	.8413	.7316	.7164
24	.6201	.6805	.8505	.7522	.6733	.7865	.7059
Max	1.4937	132.2727	1.5203	1.7375	1.7177	1.7558	1.4449
Min	.4656	.4607	.5373	.6733	.4191	.5847	.3189
Avg	.8057	6.8144	.9740	.9621	.8908	.9560	.7720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 207 / 11Kv Mandna feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333	.3544	.1052	.1417	.1227	.1341	.4298
2	.3155	.3761	.1214	.156	.1402	.1677	.4755
3	.3681	.4477	.1928	.1753	.1578	.2347	.5014
4	.5316	.543	.2481	.2126	.3155	.3018	.5611
5	.6556	.6401	.333	.2507	.3506	.4024	.6201
6	.7442	.8869	.4161	.5493	.4382	.4755	.8145
7	.6556	.7682	.3681	.5721	.4961	.5533	.7522
8	.6556	.7682	.3403	.4207	.4784	.5365	.7133
9	.5068	.5304	.3155	.333	.298	.3681	.4031
10	.1791	.2561	.1734	.2629	.2012	.2254	.333
11	.1063	.1646	.1595	.1753	.128	.1612	.2279
12	.3189	.3185	.1267	.1543	.1829	.1433	.333
13	.298	.285		.1402	.1829	.1646	.3155
14	.2658	.2683		.1753	.2012	.181	.2629
15	.2427	.2347	.197	.1578	.1829	.2172	.2454
16	.2353	.2347	.2149	.1753	.2012	.2378	.2103
17	.2427	.2515	.2303	.2629	.2743	.3224	.2454
18	.2804	.285	.5121	.2629	.5121	.5487	.3189
19	.3403	.333	.724	.6379	.6584	.6805	.3681
20	.6805	.6335	.6379	.8238	.4755	.6219	.8688
21	.567	.5014	.5611	.6733	.1829	.5373	.691
22	.4835	.394	.5014	.5138	.4755	.4607	.4784
23	.439	.3801	.4572	.4382	.439	.4163	.4075
24	.3506	.3982	.3475	.3761	.3681	.3475	.3761
Max	.7442	.8869	.724	.8238	.6584	.6805	.8688
Min	.1063	.1646	.1052	.1402	.1227	.1341	.2103
Avg	.4082	.4272	.3311	.3351	.3110	.3517	.4564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 201 / 11Kv Sirsala Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.12	.1543	.2058	.2134	.1029
2	.1372	.1543	.12	.1543	.2572	.2134	.1029
3	.1372	.1543	.12	.2058	.2572	.2134	.1372
4	.1543	.1715	.1372	.2058	.2572	.2134	.1372
5	.1543	.1886	.1543	.2229	.3429	.2743	.1543
6	.1886	.1886	.2058	.3086	.4458	.381	.1715
7	.1715	.1715	.1886	.2743	.3258	.4115	.1715
8		.1715	.2058	.2401		.3048	.12
9		.1543	.1524	.2229	.2134	.2915	.12
10	.0857	.0686	.0914	.12	.1677	.1029	
11	.1029	.0857	.0457	.0686	.0457	.0686	.0686
12	.2229	.2229	.0457	.0686	.0457	.0343	.2058
13	.2401	.1715	.0191	.0857	.0457	.0343	.2915
14	.1372	.1543	.0191	.0857	.061	.0343	.2915
15	.2572	.1543	.0191	.0857		.0343	.2591
16	.2229	.2058	.0343	.0857		.0171	.2439
17	.2401	.2229	.0343	.0857		.0171	.2439
18	.3429	.2229		.0857	.061	.0343	.1677
19	.2229	.1372	.0343	.0857	.0762		.1829
20	.1715	.0686	.0857	.1543	.1067	.1372	.1219
21	.1715	.0686	.0857	.1543	.1372	.1543	.1219
22	.1715	.0686	.0857	.1372	.1219	.1029	.1372
23	.1715	.0686	.1029	.1372	.1219	.12	.1372
24	.1372	.1715	.0686	.1029	.12	.1219	.1029
Max	.3429	.2229	.2058	.3086	.4458	.4115	.2915
Min	.0857	.0686	.0191	.0686	.0457	.0171	.0686
Avg	.1808	.1500	.0946	.1472	.1708	.1535	.1649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 202 / 11KV HATTI FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1029	.0686		.0857	.0762	.0857
2	.12	.1029	.0686		.0857	.0762	.0857
3	.12	.1029	.0686		.0857	.0762	.1029
4	.1372	.1029	.0686		.1029	.0762	.1029
5	.1543	.2229	.0686		.12	.0914	.1372
6	.5487	.5658	.0857		.1543	.1219	.2058
7	.4458	.3429	.0857	.0514	.12	.0914	.2915
8	.1886	.2915	.0857	.0857	.1029	.0914	.2915
9	.1372	.2229		.0857		.0686	.1543
10	.12	.1886	.0457	.0686	.0457	.0686	.12
11	.0514		.0305	.0514	.0457	.0514	
12			.2439		.2286	.3429	
13			.2439	.4115	.2743	.3086	.0343
14			.1677	.3601	.2286	.2058	.0343
15			.1524	.1372	.1981	.2229	.0305
16	.0514	.0514		.2401	.2591	.2915	.0305
17	.0514	.0514			.1829	.2401	.0305
18	.0857	.0514			.1219	.1886	.0457
19	.1029	.0686		.0514	.1372	.1372	.061
20	.1029	.0686		.1372	.0914	.0857	.061
21	.1029	.0686		.1372	.1143	.0857	.0762
22	.1029	.0686		.12	.0762	.0857	.0762
23	.1029	.0857		.12	.0762	.0857	.061
24	.0857	.0686	.0686		.0857	.0762	.0857
Max	.5487	.5658	.2439	.4115	.2743	.3429	.2915
Min	.0514	.0514	.0305	.0514	.0457	.0514	.0305
Avg	.1466	.1489	.1035	.1470	.1314	.1353	.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 203 / 11Kv Ambhai Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0343	.0343	.0343	.0305	.0171
2		.0171	.0343	.0514	.0343	.0305	.0171
3		.0171	.0343	.0343	.0343	.0305	.0171
4		.0171	.0343	.0343	.0343	.0305	.0171
5		.0171	.0686	.0686	.0514		.0343
6		.0171	.1029	.1886	.0514	.1677	.0343
7		.0171	.1029	.12	.0343	.1219	.0343
8		.0171	.1029	.12	.0343	.1372	.0171
9		.0171	.0762	.1029	.0762	.1372	.0171
10	.0171	.0171	.0762	.1029	.1067	.0857	
11	.0171	.0171	.0305	.0171	.0152	.0171	.0171
12	.12	.1715	.0305	.0171	.0152	.0171	.1029
13	.0686	.1372	.0305	.0171	.0152	.0171	.1372
14	.0343	.1029	.0305	.0171	.0191	.0171	.0857
15	.0857	.0686	.0305	.0171		.0171	.0762
16	.0857	.0857	.0171	.0171		.0171	.0762
17	.0514	.1715	.0343	.0171		.0171	.0914
18	.0857	.1715		.0171	.0191	.0171	.1067
19	.0857	.0686	.0171	.0171	.0305	.0171	.061
20	.0171	.0171	.0171	.0171	.0191	.0171	.0305
21	.0171	.0171	.0171	.0171	.0191	.0171	.0381
22	.0171	.0171	.0171	.0171	.0191	.0171	.0381
23	.0171	.0171	.0171	.0171	.0191	.0343	.0305
24		.0171	.0171	.0171	.0171	.0152	.0171
Max	.12	.1715	.1029	.1886	.1067	.1677	.1372
Min	.0171	.0171	.0171	.0171	.0152	.0152	.0171
Avg	.0514	.0521	.0423	.0457	.0333	.0446	.0484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 204 / 11Kv Chinchpur feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.12	.0171	.0171	.0171	.0191	.0514
2	.0514	.1029	.0171	.0171	.0171	.0191	.0514
3	.0686	.1029	.0171	.0171	.0171	.0191	.0514
4	.0857	.1543	.0171	.0171	.0171	.0191	.0514
5	.12	.3429	.0171	.0171	.0171	.0191	.0514
6	.4287	.3429	.0171	.0171	.0171	.0191	.1372
7	.3772	.2915	.0171	.0171	.0171	.0191	.2401
8	.2401	.2058	.0171	.0171	.0171	.0191	.1715
9	.1543	.1886		.0171		.0171	.2058
10	.12	.12	.0152	.0171	.0191	.0171	.1543
11	.0171		.0152	.0171	.0152	.0171	
12			.2743	.4115	.3353	.4287	
13			.3353	.3258	.3658	.2401	.0171
14			.2134	.2572	.2591	.1543	.0171
15			.1524	.2229	.1677	.1372	.0191
16	.0171	.0171	.2572	.2058	.2134	.1543	.0152
17	.0171	.0171	.2229	.1029	.1829	.2229	.0152
18	.0171	.0171	.1715	.0857	.1219	.1372	.0191
19	.0171	.0171	.1029	.0686	.0762	.0514	.0191
20	.0171	.0171	.0171	.0171	.0191	.0171	.0191
21	.0171	.0171	.0171	.0171	.0191	.0171	.0191
22	.0171	.0171	.0171	.0171	.0191	.0171	.0191
23	.0171	.0171	.0171	.0171	.0191	.0171	.0152
24	.0171	.0171	.0171	.0171	.0171	.0191	.0171
Max	.4287	.3429	.3353	.4115	.3658	.4287	.2401
Min	.0171	.0171	.0152	.0171	.0152	.0171	.0152
Avg	.0934	.1119	.0862	.0814	.0864	.0757	.0626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 205 / 11KV AMBHAI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3429	.3772	.3944	.3429	.4268	.3772
2	.3944	.3429	.3944	.3944	.3086	.2667	.3772
3	.4287	.3429	.3944	.4115	.3429	.3353	.4115
4	.5487	.4458	.5144	.4801	.4115	.381	.4801
5	.6001	.5144	.583	.583	.5144	.503	.583
6	.6859	.583	.5487	.6516	.6001	.5335	.6001
7	.4287	.2229	.3601	.3258	.4973	.4268	.3772
8		.2058	.3601	.3086	.3601	.2439	.3944
9		.463	.4877	.5144	.3201	.4287	.5144
10	.5658	.3258	.4268	.3944	.3048	.4287	
11	.6173	.4115	.3658	.3429	.381	.3772	.3772
12	.4973	.3772	.3658	.3944	.3353	.4115	.3772
13	.4801	.3429	.3658	.4115	.3353	.3772	.3944
14	.4801	.3601	.3658	.3601	.3048	.3086	.4287
15	.5487	.3772	.3658	.3086		.2743	.381
16	.5144	.5144	.4973	.2743		.2743	.4115
17	.2915	.3429	.583	.3429		.3429	.4572
18	.6344	.6859		.4458	.6097	.5316	.4572
19	.6001	.6001	.6516	.4458	.5335	.5487	.4572
20	.5316	.583	.583	.5487	.4572	.583	.4572
21	.463	.4458	.463	.5144	.4572	.4287	.4115
22	.4287	.4115	.4287	.3601	.381	.4115	.3658
23	.3944	.4115	.4115	.3429	.3353	.3944	.3506
24	.3944	.3944	.4115	.4115	.3429	.3353	.3944
Max	.6859	.6859	.6516	.6516	.6097	.583	.6001
Min	.2915	.2058	.3601	.2743	.3048	.2439	.3506
Avg	.4965	.4187	.4481	.4151	.4036	.3989	.4277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 206 / 11Kv Nanegaon feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.0686	.1372	.1029	.061	.0343
2		.1029	.0686	.1372	.1372	.0381	.0343
3		.1029	.0686	.1372	.1372	.061	.0343
4		.1029	.0686	.1372	.1372	.061	.0343
5		.1029	.0686	.1372	.1715	.061	.0343
6		.1029	.0686	.2572	.1715	.1677	.0343
7		.1372	.0686	.4115	.2572	.381	.0343
8		.0857	.0457	.2401	.1886	.3048	.0343
9		.0857	.0914	.2229	.1219	.2401	.0686
10	.0686		.1067	.1372	.1219	.1372	
11	.0857		.0457	.0514	.0457	.0686	.0514
12	.1715	.3429	.0457	.0686	.0457	.0857	.1715
13	.1543	.2915	.0457	.0686	.061	.0857	.2743
14	.0857	.2058	.0457	.0686	.0457	.1029	.2743
15	.1715	.1715	.0457	.0514		.1029	.2134
16		.1886	.0686	.0514		.0514	.1981
17		.2572	.0686	.0514			.1829
18	.3086	.2058		.0514	.1067	.0514	.2286
19	.2229	.1029	.12	.1029	.1067	.0514	.1677
20	.1029	.0686	.1029	.0857	.0762	.0514	.1067
21	.1029	.0514	.1029	.0857	.0762	.0343	.0762
22	.1029	.0514	.0857	.0857	.0762	.0343	.0762
23	.1029	.0514	.0857	.0857	.0762	.0343	.0762
24		.1029	.0514	.0857	.0857	.0762	.0343
Max	.3086	.3429	.12	.4115	.2572	.381	.2743
Min	.0686	.0514	.0457	.0514	.0457	.0343	.0343
Avg	.1400	.1372	.0712	.1229	.1119	.1019	.1076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 207 / 11Kv Ghatambri Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.0171	.0171		.0191	.0343
2	.0514	.0343	.0171	.0171		.0191	.0343
3	.0686	.0686	.0171	.0171		.0152	.0514
4	.0857	.0857	.0171	.0171		.0191	.0514
5	.0686	.0857	.0171	.0171		.0152	.0514
6	.12	.1029	.0171	.0171		.0191	.1372
7	.12	.1543	.0171	.0171		.0191	.1543
8	.1029	.1543	.0191	.0171		.0191	.1372
9	.12	.1715		.0171		.0171	.1029
10	.1029	.12	.0152	.0171	.0152	.0171	.1372
11	.0171		.0191	.0171	.0191	.0171	
12			.061	.1715	.1219	.1886	
13			.061	.1715	.1524	.1886	.0171
14			.0762	.1543	.1524	.1372	.0171
15			.0914	.1543	.1219	.12	.0191
16	.0171	.0171	.1029	.0171		.0857	.0191
17	.0171	.0171	.12			.1372	.0191
18	.0171	.0171	.1543		.1829	.1372	.0152
19	.0171	.0171	.0857		.0914	.0857	.0152
20	.0171	.0171	.0171		.0152	.0171	.0191
21	.0171	.0171	.0171		.0191	.0171	.0191
22	.0171	.0171	.0171		.0191	.0171	.0191
23	.0171	.0171	.0171		.0191	.0171	.0152
24	.0171	.0171	.0171	.0171		.0191	.0171
Max	.12	.1715	.1543	.1715	.1829	.1886	.1543
Min	.0171	.0171	.0152	.0171	.0152	.0152	.0152
Avg	.0531	.0613	.0440	.0514	.0775	.0568	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 208 / 11Kv Hatti Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.0686	.3086	.3086	.2591	.3086
2	.3086	.3086	.0686	.3086	.3086	.2591	.3086
3	.3086	.3086	.0686	.3429	.3086	.2591	.3086
4	.3258	.3772	.0686	.4287	.3772	.3048	.3429
5	.4115	.6001	.0686	.4801	.5487	.442	.5144
6	.7202	.8745	.1029	.7888	.823	.7164	.8059
7	.6001	.7888	.1029	.5658	.7545	.6706	.7888
8	.6859	.6516	.5335	.4801	.6173	.6401	.6173
9	.5144	.5316		.3772		.3944	.4287
10	.2743	.3258	.3353	.2915	.2286	.2572	.2743
11	.2572		.2286	.2058	.2439	.2401	
12			.1829	.2058	.2286	.2401	
13			.1829	.1715	.2286	.2229	.1715
14			.1829	.1715	.2134	.2229	.2058
15			.1981	.2058	.1829	.2401	.1981
16	.3086	.3086	.2401	.2743	.2286	.2572	.2286
17	.3944	.3601	.2915	.2743	.2439	.3429	.2591
18	.5144	.4973	.583	.3772	.4268	.4801	.381
19	.6344	.6859	.6516	.6001	.5182	.6001	.5335
20	.6344		.583	.6173	.5792	.583	.5335
21	.4458	.0686	.4458	.5487	.381	.3772	.3506
22	.3429	.0686	.3772	.3601	.3048	.3429	.3048
23	.3086	.0686	.3429	.3258	.2743	.3086	.3048
24	.3086	.3086	.0686	.3429	.3086	.2591	.3086
Max	.7202	.8745	.6516	.7888	.823	.7164	.8059
Min	.2572	.0686	.0686	.1715	.1829	.2229	.1715
Avg	.4304	.4134	.2599	.3772	.3756	.3717	.3854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 201 / 11Kv Jalki Bazar Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.4805	.6348	.6535	.7392	.7095	.567
2	.6335	.6283	.7468	.7655	.8029	.7468	.6201
3	.8059	.7023	.8215	.7842	.8316	.8215	.7973
4	.8954	.8596	.8871	.8402	1.0164	1.0903	.8859
5	1.1462	1.0791	.9335	.9425	1.1458	1.46	1.134
6	1.3146	1.2071	.9214	1.386	1.386	1.7187	1.2403
7	1.2445	1.2254	.9391	1.2936	1.1088	1.4415	1.2403
8	.9214	.7762	.9568	1.0059	.8316	1.2197	.9214
9	.9055	.7087	.7888	.5175	.4435	.7468	.8859
10	.7468	.6379	.7265	.3326	.3326	.4668	.5083
11	.3921	.3544	.7095	.3326	.3292	.3734	.3881
12	.3734	.3658	.3921	.7087	.5853	.5316	.5601
13	.3734	.4024	.4108	.6733	.567	.6733	.5359
14	.4294	.4024	.4435	.631	.5487	.5138	.5228
15	.4481	.439	.4805	.567	.5853	.5316	.5601
16	.5175	.439	.5175	.5316	.7316	.6024	.6468
17	.5544	.4755	.6099	.5609	.8779	.8328	.8775
18	.7762	.7316	.7577	.5959		.9036	.9522
19	1.0269	1.134	1.1088	.4557	.6653	.6201	1.2197
20	1.3443	1.4266	1.1643	.695	1.2197	1.1203	1.1088
21	1.2197	1.2437	1.39	.8775	1.1088	.9335	.9335
22	.6722	1.134	1.2197	.7865	.8131	.8962	.9149
23	.6535	1.1203	.9425	.7762	.7762	.8215	.8316
24	.6535	.9335	.9335	.9522	.7392	.7468	
Max	1.3443	1.4266	1.39	1.386	1.386	1.7187	1.2403
Min	.3734	.3544	.3921	.3326	.3292	.3734	.3881
Avg	.7764	.7878	.8099	.7361	.7907	.8551	.8197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 202 / 11Kv Shivna Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.8686	.9709	.9328	1.39	.8775	.6733
2	.7522	.7762	.9922	.9328	1.4415	.8962	.7442
3	.815	.8871	1.0517	1.0136	1.5154	.961	.815
4	.9214	.9877	1.0985	1.0498	1.6461	1.1458	.9214
5	1.0631	1.1523	1.134	1.086	1.7193	1.2752	1.0631
6	1.1919	1.4266	1.2048	1.2071	1.9185	1.3121	1.2048
7	1.262	1.3169	1.2048	1.2127	1.8461	1.3121	1.1694
8	1.2269	1.1088	1.1218	1.1946	1.7558	1.3121	1.1694
9	1.3676	.9922	1.0631	1.3032	1.4003	1.1203	1.0454
10	1.6632	.8859	1.0277	1.3756	1.3443	1.0456	.9214
11	1.7372	.8048	.8939	1.3756	1.3306	1.0642	.924
12	1.7177	.7316	.7087	1.1317	1.2803	1.0277	.8589
13	1.6804	.7316	.7655	1.1919	.9694	1.0454	.8402
14	1.6632	.6584	.6535	1.2269	.9694	.8328	.8589
15	1.6078	.8048	1.0642	1.1616	1.0059	.8859	.8686
16	1.8296	.8779	1.0269	1.1269	1.0608	.9214	.9335
17	1.9044	.9511	.9896	1.1043	1.0974	.9922	.9896
18	1.9404	1.1523	1.1706	1.0517		1.1517	1.2012
19	1.9978	1.2986	1.4083	.8764	1.0608	1.0985	1.6817
20	1.6632	1.7924	1.5546	1.8404	1.3306	1.1576	1.2136
21	1.4415	1.4937	1.6644	1.6651	1.2883	1.1389	1.1389
22	1.1203	1.3443	1.4632	1.4373	1.0269	1.1203	1.1458
23	1.0719	1.2696	1.3352	1.448	.9522	1.0456	1.0719
24	1.4045	1.0082	1.0082	1.1273	1.4118	.9709	
Max	1.9978	1.7924	1.6644	1.8404	1.9185	1.3121	1.6817
Min	.6805	.6584	.6535	.8764	.9522	.8328	.6733
Avg	1.4052	1.0551	1.1073	1.2114	1.3375	1.0713	1.0197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 203 / 11Kv Amsari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.5175	.3544	.3921	.5601	.5601	.2658
2	.3292	.4435	.3898	.4108	.5975	.5415	.3189
3	.3982	.462	.4607	.5041	.6348	.6161	.3898
4	.4706	.5544	.4607	.5601	.7095	.7023	.4607
5	.543	.6838	.5316	.6535	.8029	.8686	.5316
6	.6268	.7577	.567	.9896	1.0164	1.0164	.6024
7	.7973	.6838	.5609	.9055	.5975	.6838	.4252
8	.6268	.4435	.6024	.6161	.4668	.4066	.443
9	.6838	.3898	.4252	.3734	.4435	.3734	.4252
10	.5729	.3189	.3898	.2801	.4066	.2614	.443
11	.4435	.1829	.4207	.112	.4024	.3921	.4435
12	.4251	.1829	.2658	.2896	.439	.3898	.4481
13	.3734	.2195		.3258	.6219	.4252	.4435
14	.3142	.2561		.3582	.5853	.4252	.4294
15	.2772	.2926		.4525	.5487	.4252	.4481
16	.4108	.3658		.5014	.6219	.4252	.4481
17	.462	.439		.5014	.6401	.4252	.5415
18	.5601	.6219		.4854		.4607	.4668
19	.6468	.6219	.6535	.4525	.2772	.4252	.5729
20	.7207		.8215	.6099	.7023	.4481	.5175
21	.6838		.8316	.7023	.6468	.4481	.4481
22	.6468	.4755	.8871	.6535	.6161	.4108	.4481
23	.5975	.5121	.462	.5975	.5975	.3734	.3881
24	.5228	.439	.4435	.4668	.5601	.3361	
Max	.7973	.7577	.8871	.9896	1.0164	1.0164	.6024
Min	.2772	.1829	.2658	.112	.2772	.2614	.2658
Avg	.5171	.4484	.5293	.5081	.5867	.4934	.4500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 204 / 11Kv Pimpaldari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.4784	1.4563	1.3121	.5601	.5914	1.4563
2	1.419	1.4784	1.4563	1.2986	.5975	.6099	1.419
3	1.531	1.4415	1.419	1.3575	.6283	.5544	1.531
4	1.6804	1.7372	1.6804	1.267	.7023	.6401	1.6804
5	1.7551	1.8296	1.7177	1.2489	.7392	.7316	1.7551
6	1.9589	1.9404	1.8111	.8059	.7392	.7682	1.9791
7	2.0328	1.9774	1.4045	.724	.7762	.823	2.0538
8	2.0698	1.885	1.3306	.7602	.8413	.8131	1.307
9	1.8111	1.4266	1.4415	.7316	.7316	.7011	1.3306
10	1.8296	1.134	1.1389	.7316	.6516	.5609	1.2936
11	1.8107	1.0974	1.1576	1.1946	.6767	1.531	1.1576
12	.8413	.3898	1.0631	1.5893	1.3306	1.5684	.8589
13	.8779	.4607	.4607	1.5524	1.1088	1.643	.8871
14	.823	.4607	.4908	1.531	1.1088	1.6804	.8859
15	.7499	.4961	.6733	1.5524	1.1576	1.7551	1.1517
16	.7316	.5316	.691	1.6632	1.2752	1.8298	1.2269
17	.7577	.5316	.7087	1.7551	1.2936	1.9044	1.4352
18	.6767	.7796	.7577	2.0485		2.1285	1.7177
19	.5914	.695	.6653	2.1437	1.2936	2.2405	.7087
20	1.885	2.0538	.7023	1.9959	1.4415	1.6804	1.2696
21	1.8296	1.8111	.8871	1.848	1.3443	1.2696	1.2752
22	1.8111	1.8111	.9425	1.5524	1.2567	1.307	1.2197
23	1.6804	1.7177	1.3121	1.5154	1.1203	1.2323	1.1273
24	1.4937	1.5684	1.5893	1.5708	1.4784	1.1949	
Max	2.0698	2.0538	1.8111	2.1437	1.4784	2.2405	2.0538
Min	.5914	.3898	.4607	.724	.5601	.5544	.7087
Avg	1.421	1.2805	1.1232	1.4063	.9936	1.2400	1.3360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 205 / 11Kv Halda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6979	.5975	.6468	.5175	.499	.6722
2	.6413	.6535	.5975	.5729	.6219	.5359	.6722
3	.7167	.6722	.6348	.5853	.695	.5544	.7095
4	.8215	.8962	.6348	.5487	.8326	.7023	.8215
5	.9709	.961	.6348	.6154	.9774	.8962	.9709
6	1.1389	1.0719	.6468	.5304	1.1694	1.0059	1.1389
7	1.0269	.9425	.6722	.4887	1.0277	.9511	1.0082
8	.8589	.6653	.7023	.4525	.8859	.9425	.9335
9	.7545	.6584	.7468	.4656	.567	.7468	.8402
10	.5093	.5487	.6468	.4706	.4207	.4908	.5415
11	.3734	.4755	.2772	.4481	.439	1.0082	.6283
12	.5487	.567	.4607	.4338	.5544	1.1203	.7796
13	.5853	.6379	.5434	.4108		1.1949	.7087
14	.5914	.6379	.5847	.3921	.4854	.8962	.7442
15		.7087	.5138	.4108	.5175	1.0082	.8505
16		.7442	.4784	.4668	.5601	1.1203	.8859
17		.7442	.2218	.5041	.5601	1.2323	.9568
18	.4755	.6733	.3326	.5415		1.3443	1.0517
19	.5975	.6024	.3696	.9335	1.0829	1.6804	.7087
20	1.2197		.6283	1.0829	1.1088	1.3443	1.2323
21	1.1203		.6468	1.0269	1.0082	.9335	1.307
22	.9335		.7095	.9709	.7167	1.0829	1.3306
23	.8865	1.0719	.7392	.8962	.679	1.0082	.924
24	.7095	.7922	.924	.8402	.8402	.9335	
Max	1.2197	1.0719	.924	1.0829	1.1694	1.6804	1.3306
Min	.3734	.4755	.2218	.3921	.4207	.4908	.5415
Avg	.7695	.7344	.5810	.6140	.7394	.9680	.8877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 206 / 11Kv Digras feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	.6908	.7468	.724	.4805	.7392	1.1203
2	1.1203	.7282	.7468	.7316	.5121	.7762	1.1949
3	1.0829	.8962	.8962	.724	.6219	.8131	1.1949
4	1.2136	1.0456	1.0082	.8145	.7316	.8871	1.2323
5	1.4003	1.1643	1.1203	.9134	.8048	.9055	1.3443
6	1.531	1.2197	1.1576	1.0608	.905	.9145	1.4937
7	1.4937	1.1458	.8589	.905	.9671	.7682	1.4937
8	1.5684	1.1088	.7468	.9328	.8505	.6838	1.307
9	1.1576	.9145	.7655	.8596	.6767	.5258	1.1088
10	.9335	.695	.8402	.8954	.5544	.4784	1.1088
11	.8962	.5487	.8775	1.0456	.5853	1.0456	1.0719
12	.6653	.4252	.5487	1.0082	.6653	1.0456	.9036
13	.7133	.4607	.4525	.9709	.7842	1.0456	.8764
14	.5914	.4961	.4706	.9335	.7468	1.0642	1.0277
15	.6283	.4961	.4252	1.0456	.7468	1.0829	.9745
16	.6468	.5316	.4163	1.1576	.8215	1.1203	1.0454
17	.6468	.5316	.4525	1.307	.8686	1.1389	1.0631
18	.5544	.4961	.5014	1.531		1.307	1.1517
19	.4854		.5359	1.6057	1.1088	1.5123	1.262
20	1.3443	1.3443	1.2936	1.6804	1.1763	1.1576	1.2936
21	1.307	1.307	1.2437	1.5684	1.1016	.8962	1.1576
22	1.2136	1.2696	.9522	1.4937	.9335	.8962	.9335
23	.7545	.7842	.7468	1.4563	.8775	.9335	.8316
24	1.2136	.6908	.7468	.7282	1.3443	.8589	
Max	1.5684	1.3443	1.2936	1.6804	1.3443	1.5123	1.4937
Min	.4854	.4252	.4163	.724	.4805	.4784	.8316
Avg	1.0149	.8257	.7730	1.0872	.8202	.9415	1.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 207 / Water Supply FDR

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0175	.0173	.0173	.0175	.0347	.0173	
8	.0347	.0347	.0175	.0175	.0347	.0173	.0177
9	.0347	.0171	.0173	.0173	.0347	.0171	.0173
10	.0173	.0343	.0173	.0175	.0173	.0171	.0173
11	.0173	.0171	.0173	.0175	.0173	.0171	.0347
12	.0173	.0343	.0173	.0175	.0173	.0343	.0173
13	.0173	.0343	.0173	.0347	.0173	.0343	.0173
14	.0173	.0343	.0173	.0347	.0173	.0343	.0173
15	.0173	.0343	.0173	.0347	.0173	.0343	.0347
16	.0347	.0343	.0173	.0347	.0347	.0343	.0173
17	.0347	.0171	.0173	.0351	.0347	.0171	.0173
18		.0171	.0173	.0347		.0171	.0347
19				.0351	.0347	.0171	.0173
20				.0347	.0347	.0171	.0173
21				.0173	.0173	.0171	.0347
22				.0173	.0173	.0171	.0173
23						.0171	.0173
24						.0171	
Max	.0347	.0347	.0175	.0351	.0347	.0343	.0347
Min	.0173	.0171	.0173	.0173	.0173	.0171	.0173
Avg	.0236	.0272	.0173	.0261	.0254	.0219	.0217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 201 / 11KV BHAVAN (NILLOD)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4854	.4854	.4854	.2452	.2294	.3361
2	.547	.4752	.5228	.4887	.2801	.2622	.3361
3	.5847	.5407	.5914	.6224	.3174	.3277	.3734
4	.6602	.9522	.6878	.7468	.3511	.4096	.4066
5	.9054	1.4563	.905	.8488	.3881	.5079	.4854
6	1.4003	1.278	1.2803	1.307	.7023	.8192	.8686
7	1.3443	1.2696	1.3213	1.251	.9425	.7712	
8	1.2449	1.1203	1.2449	1.0642	.7922	.7842	
9		.8865	.8215	.8775	.5658	.5975	
10		.6036	.3361	.6224	.3277	.439	.503
11		.3961	.3921	.4338	.2949	.3841	.4294
12		.4527	.4338		.3361	.3961	.4338
13		.5281	.4163	.4527	.2949	.3881	.3206
14			.4108	.5658		.4066	.3961
15	.4024	.3856		.4527	.3547		.3584
16	.4424	.5093		.3584	.3605	.462	.3772
17	.4854	.4694	.6335	.4715	.3932	.6224	.415
18	.407	.3881	.4854	.4904	.4915	.7133	.6224
19	.4096	.499	.5914	.4904	.7865	.9412	.8299
20	.9175	.9054		.9619	.9503	1.0642	.9808
21	.7461	.7167	.7282	.6224	.5898	.6722	.6224
22	.5256	.6036	.5973	.5658	.4915	.5175	.5658
23	.3768	.5658	.5601	.5093	.4588	.5175	.4904
24	.5093	.3932	.5415	.4887	.4527	.4668	.5093
Max	1.4003	1.4563	1.3213	1.307	.9503	1.0642	.9808
Min	.3768	.3856	.3361	.3584	.2452	.2294	.3206
Avg	.6889	.6905	.6660	.6599	.4856	.5522	.5077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 202 / 11 KV BORGAON KH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2949	.2801	.2926	1.1128	1.0829	1.1317
2	.2683	.3605	.2926	.2987	1.1694	.9831	1.1403
3	.285	.4096	.3258	.3077	1.2071	1.0486	1.3717
4	.3018	.4588	.3361	.3361	1.3014	1.1469	1.4815
5	.3353	.5975	.4024	.3772	1.7918	1.6598	1.6804
6	.5197	.7209	.7167	.6908	2.0165	1.8671	2.0883
7	.5533	.7045	.8326	.9145	1.9418	1.5402	2.0538
8	.6602	.6718	.7207	.7356	1.7353	1.5684	1.8484
9		.5281	.4887	.5228	1.2637	1.226	1.358
10		.3521	.3395	.3881	.852	.8865	.9242
11		.6602	.6722	.679	.7045		.7167
12		.6413	.6697	.7392	.6718	.7207	.5658
13		.6602	.6335	.7545	.6062	.6653	.4715
14		.7545	.7282	.7922	.4424	.4887	.4191
15	.788	.811	.7762	.7545	.3605	.543	
16	.8684	.8676	.8326	.8865	.407	.6036	
17		.9808	.8962	.9242	.4294	.5853	
18		1.2449	1.3443	1.2071	.4424	.5658	.7042
19		1.4335	1.4937	1.5844	.4191	.5041	.6602
20	1.4243	1.4523	1.6244	1.643	1.3435	1.5154	1.6409
21	1.3226		1.4003	1.3957	1.1797	1.2449	1.3957
22	1.2696	1.3392	1.1946	1.3203	1.2696	1.1946	1.2449
23	1.0322	1.2826	1.1523	1.2449	1.0852	1.1523	1.2071
24	1.1883	.9831	1.2071	1.0974	1.2071	.9995	1.1389
Max	1.4243	1.4523	1.6244	1.643	2.0165	1.8671	2.0883
Min	.2347	.2949	.2801	.2926	.3605	.4887	.4191
Avg	.7368	.7917	.8067	.8286	1.0400	1.0345	1.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 203 / 11 KV PALASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.9831	1.0829	.7922	.3018	.373	.3734
2	1.1506	.9503	1.1389	.7602	.3395	.3932	.3841
3	1.2071	1.0829	1.1584	.823	.3734	.6062	.4527
4	1.3014	.8848	1.2489	.9522	.4108	.5079	.5281
5	1.3957	1.0456	1.3575	1.094	.4481	.6226	.5975
6	1.8671	.9175	1.7737	1.4377	.3142	1.0082	1.1763
7	1.643	.9831	1.7177	1.3491	.3511	1.0829	1.419
8		1.5238	1.5546	1.2323	.4805	1.0642	1.1523
9		1.2826		.9709	.6203	.5121	.924
10		.8865	.8686	.3142	.4915	.4481	.5365
11		.679	.4344	.2829	.5571	.543	.6036
12		.6706	.8316		.4481	.6036	.5847
13		.5658	.7133	.5093	.5898	.5973	.6203
14		.7545	.7282	.5729	.7291	.6154	.679
15	.9054	.6036	.695	.4527	.8192	.8402	.7545
16	.8775	.7545	.7392	.5544	.8029	.8962	.7922
17	.4108	.8488	.7282		.8356	1.1203	.8676
18		.8131	.7356	1.0164	1.17	1.2071	1.1506
19	.8402			.811	1.3108	1.3756	1.6032
20	1.4746	1.475		.811	1.1961	1.6032	1.5844
21	1.2407	1.2449	.7922	1.3014	1.065	1.2127	1.3203
22	1.065	1.1041	.6161	1.2071	.9831	1.0498	1.2449
23	1.0159	.9955	.7356	1.1506	.8848	1.0425	1.1317
24	1.0562	.9831	1.0242	.7842	1.094	.8356	1.0082
Max	1.8671	1.5238	1.7737	1.4377	1.3108	1.6032	1.6032
Min	.4108	.5658	.4344	.2829	.3018	.373	.3734
Avg	1.1591	.9579	.9845	.8718	.6924	.8400	.8954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 204 / 11Kv Bhagawati Agro
Express Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0124	.0172	.0174	.0182	.0165	.0174
2	.0181	.0124	.0692	.0174	.0182	.0164	.0174
3	.0182	.0124	.0173	.0174	.0182	.0165	.0173
4	.0181	.0171	.0173	.0173	.0182	.0182	.0173
5	.0181	.0182	.0174	.0173	.0182	.0188	.0173
6	.0181	.0144	.0174	.0173	.0182	.0188	.0173
7	.0181	.015	.0173	.0173	.0182	.0164	.0173
8	.0181	.0131	.0173	.0173	.0182	.0165	.0173
9		.0181	.0174	.0172	.0182	.0173	.0182
10		.0181	.0172	.0181	.0939	.0173	.0182
11		.0181	.0173	.0182	.0939	.0174	.0182
12		.0181	.0174	.0182	.0939	.0173	.0182
13		.0181	.0173	.0182	.0939	.0174	.0182
14		.0182	.0173	.0182	.033	.0174	.0182
15	.0627	.0182	.0172	.0182	.0376	.0173	.0182
16	.0824	.0182	.0173	.0182	.0341	.0173	.0182
17	.0939	.0182	.0174	.0182	.0341	.0172	.0182
18	.0939	.0182	.0172	.0182		.0173	.0182
19	.0376	.0182	.0174	.0182	.0341	.0172	.0181
20	.0328	.0173	.0173	.0182	.0328	.0173	.0182
21	.0165	.0172	.0172	.0182	.0328	.0173	.0182
22	.0124	.0173	.0173	.0182	.0341	.0173	.0182
23	.0165	.0173	.0173	.0182	.0341	.0172	.0182
24	.0181	.0124	.0173	.0172	.0182	.0171	.0173
Max	.0939	.0182	.0692	.0182	.0939	.0188	.0182
Min	.0124	.0124	.0172	.0172	.0182	.0164	.0173
Avg	.0340	.0165	.0195	.0178	.0376	.0173	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 205 / 11Kv Nillod Dharan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0126						
6	.0501			.0472			
7	.0377	.0564	.0786	.0786			
8	.0126	.0564		.0472			
9		.0251		.0314			
10		.0126		.025			
12					.0376	.0472	.0627
13					.0376	.0472	.0627
14					.0494	.0314	.0496
15					.0659	.0314	.0496
16					.0682	.0314	.0372
17						.0157	.0124
18					.0188	.0163	.0124
19					.0171	.0157	
Max	.0501	.0564	.0786	.0786	.0682	.0472	.0627
Min	.0126	.0126	.0786	.025	.0171	.0157	.0124
Avg	.0283	.0376	.0786	.0459	.0421	.0295	.0409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 201 / 11 KV PALOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3018	.2105	.2105	.285		.415
2	.4527	.3185	.2267	.2105	.3018		.415
3	.4527	.3521	.2267	.2267	.3353		.415
4	.5658	.4191	.2429	.2267	.4024		.5658
5	.7167	.4862	.2591	.2753	.4694		.679
6	.7545	.5197	.421	.6478	.6371		.7545
7	.7167	.5533	.4696	.7449	.7042		.6979
8	.6413	.502	.4858	.57	.5365		.6036
9	.4338	.421	.4534	.503	.5344	.4527	.5093
10	.3206	.3725	.421	.1677	.3401	.3772	.3772
11	.2641	.3018	.2829	.2641	.3206	.3395	.3018
12	.5197	.3018	.3395	.2829	.2829	.8642	.6371
13	.4694	.3018	.3206	.3018	.2829	.7287	.503
14	.4359	.3206	.3395	.3018	.3018	.5182	.4694
15	.4191	.3395	.3395	.3206	.3018	.4858	.4024
16	.3688	.3772	.3018	.3584	.2829	.502	.4191
17	.4191	.3772	.2829	.4338	.3772	.5344	.4359
18	.3856	.4527	.4527	.5093	.4338	.4858	.3688
19	.3185		.5281	.6036	.5658	.3441	.3353
20		.6413	.6602	.6413	.679	.6413	.6036
21	.547	.5658	.5658	.5658	.547	.5658	.5281
22	.4715	.5281	.5281	.4527	.4527	.4904	.4715
23	.4338	.4904	.4904	.415	.4527	.4527	.415
24	.4527	.415	.4904	.4527	.3772	.4527	.4527
Max	.7545	.6413	.6602	.7449	.7042	.8642	.7545
Min	.2641	.3018	.2105	.1677	.2829	.3395	.3018
Avg	.4788	.4200	.3891	.4036	.4252	.5147	.4907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 202 / 11 KV ANWI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.2012	.1619	.1619	.2012		.4527
2	.415	.218		.1943	.218		.4527
3	.415	.2683	.1619	.2267	.2683		.4527
4	.5281	.3353	.1943	.2267	.3688		.6036
5	.679	.3688	.2591	.2591	.4359		.7545
6	.7167	.3856	.4534	.4858	.5365		.8299
7	.6979	.4191	.5182	.4858	.57		.811
8	.6224	.3887	.421	.5365	.57		.7167
9	.4527	.3239	.421	.3353	.421	.415	.3961
10	.3395	.2591	.3563	.3353	.3401	.3395	.3206
11	.3206	.3395	.3018	.3018	.3206	.3395	.2829
12	.4338	.3961	.3018	.3206	.3206	.5281	.4024
13	.3688	.3961	.2829	.3206	.3018	.4696	.3018
14	.3353	.415	.3018	.3395		.3239	.2683
15	.2347	.4904	.3206	.3206		.3239	.2515
16	.3353	.415	.3018	.3395	.3395	.4049	.2347
17	.3856	.4338	.3018	.3772	.3772	.4049	.4024
18	.3688	.547	.4338	.415	.4527	.3605	.3521
19	.285	.7545	.5658	.4904	.547	.2949	.3185
20	.6036	.6602	.6036	.5658	.5658	.6036	.5658
21	.4904	.5281	.5281	.5093	.4527	.5658	.5093
22	.4338	.4715	.4715	.4338	.415	.4904	.4338
23	.3961	.4527	.4338	.3772	.415	.4527	.3772
24	.415	.3772	.4527	.415	.3584	.415	.4527
Max	.7167	.7545	.6036	.5658	.57	.6036	.8299
Min	.2347	.2012	.1619	.1619	.2012	.2949	.2347
Avg	.4453	.4102	.3717	.3656	.3998	.4208	.4560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 203 / RAHIMABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.2683	.1619	.2267	.2347		.4527
2	.4527	.2683	.1619	.2591	.2515		.4527
3	.4527	.3018	.1943	.2591	.3018		.4527
4	.5658	.4359	.1943	.2915	.4024		.679
5	1.0374	.5197	.2591	.3563	.503		.9808
6	1.0562	.6203	.421	.8421	.8215		
7		.6539	.5506	.7773	.9389		
8	.7733	.6979	.5344	.7712	.7042		.9431
9	.6979	.4372	.5344	.4694	.4534	.4904	.7167
10	.3772	.3725	.4534	.3018	.3563	.3018	.4338
11	.2829	.2829	.2829	.1886	.3018	.2641	.3018
12	.6036	.2641	.3018	.2263	.2829	.8322	.7356
13	.4862	.2452	.3018	.2829	.2641	.664	.6413
14	.4527	.3018	.3206	.3018	.2641	.5344	.4359
15	.3185	.3206	.3018	.3395	.3018	.4534	.3856
16	.3688	.3395	.3395	.3584	.3018	.4049	.3521
17	.4527	.3772	.3395	.4904	.3395	.502	.3856
18	.4694	.5281	.4904	.6036	.5281	.4588	.3688
19	.3856		.7545	.6979	.7545	.4424	.3521
20	.7167		.679	.6413	.7922	.7733	.7167
21	.4715		.4715	.5658	.4715	.679	.4715
22	.4527		.4527	.5093	.4527	.4904	.4527
23	.415		.4338	.4338	.4527	.4527	.415
24	.4527	.415		.4338	.415	.4527	.4527
Max	1.0562	.6979	.7545	.8421	.9389	.8322	.9808
Min	.2829	.2452	.1619	.1886	.2347	.2641	.3018
Avg	.5302	.4026	.3885	.4428	.4538	.5123	.5263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 204 / ASADI AG MIX

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1677	.1296	.1296	.1677		.2263
2	.2263	.1844	.1457	.1296	.1677		.2263
3	.2263	.218	.1619	.1296	.2012		.2263
4	.2641	.2683	.1619	.1619	.2683		.2829
5	.4527	.3018	.1943	.1943	.3185		.4527
6	.4527	.3856	.3563	.4858	.3353		.4527
7	.415	.4191	.3563	.3887	.3521		.3961
8	.3772	.2915	.2429	.2683	.3185		.3395
9	.2829	.1943	.2105	.1844	.2591	.1886	.2452
10	.132	.1457	.1619	.1677	.1619	.1509	.1886
11	.1132	.1132	.132	.0943	.1698	.132	.1509
12	.3856	.1132	.1132			.4801	.3688
13	.2515	.1132	.1132	.1132	.1698	.3077	
14	.218	.1132	.1509	.132	.1886	.1943	.2347
15	.1677	.132	.132	.1132	.1886	.2105	.218
16	.1844	.132	.132	.132	.1698	.1943	.218
17	.2012	.1509	.132	.1698	.1886	.3239	.285
18	.2683	.2075	.2075	.2075	.2075	.2294	.2347
19	.218	.3206	.3018	.3395	.3018	.1966	.218
20	.3206	.2641	.3395	.3018	.3395	.3018	.3018
21	.2452	.2829	.2263	.2263	.2263	.2641	.2263
22	.2263	.2641	.2075	.1886	.2263	.2641	.1886
23	.1886	.2641	.2075	.1698	.2263	.2263	.1698
24	.2263	.1698	.2452	.2075	.1698	.2263	.2263
Max	.4527	.4191	.3563	.4858	.3521	.4801	.4527
Min	.1132	.1132	.1132	.0943	.1619	.132	.1509
Avg	.2613	.2174	.1984	.2015	.2314	.2432	.2642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 201 / 11 kv Dhawda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0838	.0663	.08	.1448	.0474	.0655
2	.0716	.0848	.0829	.0972	.1829	.0633	.081
3	.0895	.1214	.1174	.1006	.1829	.064	.1174
4	.124	.1402	.1372	.1357	.1991	.08	.1341
5	.1402	.208	.1907	.2035	.2454	.081	.1677
6	.2103	.3086	.3812	.285	.2947	.1966	.2321
7	.2572	.5197	.3749	.2812	.3561	.2241	.2486
8	.2229	.3391	.3361	.3201	.2818	.2134	.218
9	.1341	.2572	.2846	.2229	.218	.1467	.1658
10	.2401	.16	.2408	.1783	.125	.1094	.108
11	.0943	.132	.1886	.0754	.0943	.1132	.0381
12	.0762	.1132		.0754	.0754	.0754	.0381
13	.0762	.132		.0566	.0754	.0754	.0381
14	.0566	.132	.1698	.1132	.0943	.0943	.0572
15	.0572	.1509	.1509	.132	.0943	.0754	.0572
16	.132	.1509	.1132	.1698	.0754	.0943	.0762
17			.1132	.132	.0943	.0943	.0572
18		.2075	.1698	.1886	.132	.132	.0953
19		.3772	.2452	.3206	.132	.2075	.1524
20	.3395	.3961	.3206	.415	.2452	.2641	.2075
21	.3018	.3395	.3206	.2829	.3206	.1886	.1886
22	.2641	.2641	.2641	.2641	.2641	.1698	.1886
23	.2263	.2075	.2075	.2263	.2075	.1509	.1334
24	.2263	.1698	.1886	.1886	.1886	.1886	.132
Max	.3395	.5197	.3812	.415	.3561	.2641	.2486
Min	.0566	.0838	.0663	.0566	.0754	.0474	.0381
Avg	.1633	.2172	.2120	.1894	.1802	.1312	.1249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 202 / 11 kv Jambhai

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.2507	.2772	.2054	.2241	.2715	.1848
2	.2241	.2686	.3142	.2587	.2427	.3077	.2195
3	.2587	.3292	.3361	.3326		.3475	.2561
4	.3292	.3696	.3696	.3881	.3326	.9145	.3475
5	.3982	.5121	.4108	.4805	.3326	.3881	.4938
6	.4572	.6036	.543	.5853	.3658		.6878
7	.5304	.5249	.2804	.4344	.3761	.5487	.5552
8	.5121	.2743	.1387	.3801	.3721		.5068
9		.2195	.1886	.2772	.3641	.3696	.3292
10		.2172	.1463	.1991	.2534	.1886	.181
11	.5658		.5041	.4481	.4904	.3361	.4715
12	.4527	.4904		.4338	.3584	.3547	.415
13	.4904	.5281		.5281	.4338	.3772	.3584
14	.5281	.5658	.5658	.5281	.5281	.4527	.3772
15	.5847	.6036	.6036	.5658	.6036	.5847	.4338
16	.5847	.6602	.6413	.6224	.7356	.6602	.547
17	.6413	.7167	.679	.6602	.811	.811	.6979
18		.8676	.8676	.8676	.8488	1.0269	.9808
19		1.1694	1.1763	1.2323	1.2071	1.1763	1.0185
20	.9709	1.1128	1.2883	1.226	1.094	1.1576	1.1317
21	.9522	1.0562	1.0642	1.0751	.9997	.8775	.9431
22	.9335	.9242	.8962	.9242	.8488	.7842	.811
23	.8402	.811	.811	.8488	.7733	.7095	.6979
24	.679	.7167	.7356	.7545	.7733	.7167	.6413
Max	.9709	1.1694	1.2883	1.2323	1.2071	1.1763	1.1317
Min	.168	.2172	.1387	.1991	.2241	.1886	.181
Avg	.5551	.5997	.5835	.5940	.5813	.6073	.5536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 203 / 11 kv Amthana

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5847	.547	.5658	1.1128	.6036	.5658
2	.5847	.5658	.5658	.547	.5658	.6224	.5658
3	.6413	.6224	.6224	.5847	.6036	.6979	.6036
4	.7167	.7922	.6979	.7167	.6979	.7733	.7356
5	.7733	.9522	.8676	.9619	.9997	.9242	.9619
6	1.0185	1.1576	1.2449	1.226	1.2071	1.226	1.1763
7	1.1883	1.094	1.2449	1.1128	1.1506	1.2071	1.1949
8	1.0751	.9431	1.1694	1.094	1.0751	1.094	1.1763
9	.9997	.8299	.9808	.7545	.8865	.9054	.9335
10	.6413	.6602	.679	.6224	.6036	.6602	.679
11	.5093	.4904	.4904	.4904	.547	.5847	.5281
12	.7202	.7449		.4534	.8488	.7956	.5533
13	.6874	.639		.5182	.6958	.5801	.5898
14	.6203	.4915	.8192	.5668	.6226	.503	.4915
15	.5197	.4973	.823		.4973	.3688	.421
16	.5365	.5138	.6882		.5079	.4191	.3563
17	.5426		.6464		.5344	.4973	.4588
18		.6203	.4908	.7293	.4752	.5197	.5144
19			.3658	.6554	.4207	.5426	.4557
20	1.0374	.9997	1.1016	1.1883	.9808	1.0829	1.1317
21	.8299	.8865	.8299	.811	.8299	.8215	.811
22	.7167	.7545	.6979	.7167	.7545	.7095	.6979
23	.6602	.6602	.6224	.679	.7167	.6602	.6036
24	.6224	.6413	.5847	.5658	.5658	.6602	.6036
Max	1.1883	1.1576	1.2449	1.226	1.2071	1.226	1.1949
Min	.5093	.4904	.3658	.4534	.4207	.3688	.3563
Avg	.7367	.7337	.7627	.7410	.7458	.7275	.7004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 204 / 11 kv JOGESHWARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6602	.7167	.7356	.7167	.724	.7095
2	.6413	.6036	.743	.6979	.7545	.7621	.6535
3	.679	.5658	.7811	.7167	.7922	.7922	.6979
4	.7356	.6224	.8299	.7922	.811	.8573	.7922
5	.7733	.8402	.9997	.9242	.9054	1.0751	.8676
6	.9054	1.1016	1.1128	1.1506	1.094	1.2071	1.0456
7	.9242	1.1317	1.094	1.0751	.8865		1.0269
8	.9242	1.1317	1.1694	1.0562	.8865	1.2071	.8962
9	.8865	.9997	.9997	.7922	.8299	1.1317	.9522
10	.7356	.7356	.7167	.6722	.7356	.9619	.7733
11	.8488	.5658	.6161	.5788	.6668	.6167	.6602
12	.6371	.7537		.4694	.7209	.7682	.6464
13	.7293			.5365	.8029	.7202	.7449
14	.7042	.5407	1.0279	.5624	.7459	.6722	.7209
15	.6036	.9503	.9602		.7127	.5921	.6882
16	.57	.9116	.8802	.7449	.6874	.6401	.6722
17	.547	.7956	.8421	.639	.663	.7125	.7045
18		.6464	.6001	.7291	.6371	.7209	.7545
19		.6104	.3856	.6068	.4854	.5144	.583
20	1.0082	.9619	.9149	.9054	.9997	1.0082	1.0374
21	.8775	.811	.547	.7167	.9619	.8215	.8299
22	.7842	.7733	.8299	.6979	.8488	.7655	.7545
23	.7545	.7356	.7655	.6413	.7733	.7468	.7167
24	.6979	.7095	.724	.7167	.6224	.7356	.7095
Max	1.0082	1.1317	1.1694	1.1506	1.094	1.2071	1.0456
Min	.547	.5407	.3856	.4694	.4854	.5144	.583
Avg	.7532	.7895	.8298	.7460	.7809	.8154	.7766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 205 / Kelgaon murdeshwar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.2012	.2126		.3174	.3439	.3544
2	.168	.2427	.2328		.3734	.3982	.4119
3	.2378	.3155	.2715		.4066	.439	.4525
4	.2743	.4207	.3077		.5304	.4938	.6154
5	.3109	.4681	.3511		.6154	.5914	.7343
6	.3982	.5487	.6584		.7442	.9955	.9568
7		.6024	.9214		.7973	1.0808	1.1393
8	.4251	.5083	.8322		.7442	.9492	1.1744
9	.3109	.3681	.6485	.7373	.6135	.6024	.6626
10	.1848	.3052	.4807	.7377	.4191	.4694	.591
11	.2641	.362	.3772	.4527		.3584	.4904
12	.2452	.3206		.4527	.3395	.3584	.3772
13	.2641	.3429		.4338	.3239	.3772	.4715
14	.2641	.3048	.3772	.5093	.3239	.3772	.4527
15	.2641	.3584	.415	.4904	.3018	.415	.4527
16	.2829	.3961	.4527	.4904	.3584	.4338	.4904
17	.3206		.5658	.5658	.4572	.4715	.5093
18		.6602	.679	.7545	.547	.811	.8299
19		1.0751	.9619	.8676	.9808	1.0642	.9997
20	.8299	.8865	1.0374	.9619	1.0562	1.1203	1.1883
21	.7545	.7733	.7545	.7733	.9054	.8029	.8488
22	.6602	.7167	.679	.6979	.811	.7842	.811
23	.6413	.6668	.6036	.6602	.6859	.7356	.6979
24	.547	.5847	.5716		.6036	.5906	.679
Max	.8299	1.0751	1.0374	.9619	1.0562	1.1203	1.1883
Min	.1478	.2012	.2126	.4338	.3018	.3439	.3544
Avg	.3712	.4969	.5633	.6390	.5764	.6277	.6830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 201 / 11 KV LONAWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.4163	.4163	.5228	.7392	.7468	.5415
2		.4163	.4163	.5041	.7392	.7468	.5415
3		.4525	.4525	.6653	.7762	.7842	.8316
4		.5249	.5249	.9055	.8316	.8402	.9425
5		.6447	.6447	1.0534	1.0242	1.0456	1.0903
6		.7701	.7701	1.2437	1.2986	1.3256	1.1888
7		1.0277	1.0277	1.134	1.0974	1.0974	1.2254
8		.788	.788	.9795	1.0974	1.1706	1.0829
9			.5552		.8779	1.0164	.7095
10		.4344	.4344		.7655	.7947	.5041
11		.5228	.6468	.8402	.6348	.4481	.5228
12	.5729	.5729	.5729	.6401	.5601	.5249	.5601
13	.5415	.5359	.5041	.5914	.6348	.5731	.5975
14	.5041	.5041	.4481	.5359	.5601	.4887	.5041
15	.5228	.5228	.4854	.5175	.6348	.4344	.4481
16	.5544	.5544	.5415	.499	.7095	.4887	.5041
17	.5729	.5729	.5729		.5975	.6268	.6535
18	.6468	.6468	.7762	.2957	.5601	.8328	.8775
19	1.2254	1.2254	1.2437	.5359	.5415	.9391	.9896
20	1.3352	1.3352	1.3169	1.0719	1.0829	1.3717	1.4003
21	1.0903	1.0903	.9055	1.2197		1.1888	1.2136
22	.7392	.7392		.9055	.9149	.9425	.9522
23	.6468	.6468	.5041	.8779	.8962	.6283	.6348
24	.5914	.6099	.6099	.5228		.8402	.5041
Max	1.3352	1.3352	1.3169	1.2437	1.2986	1.3717	1.4003
Min	.1867	.4163	.4163	.2957	.5415	.4344	.4481
Avg	.6950	.6763	.6590	.7648	.7988	.8290	.7925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 202 / 11 KV ANDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1991	.2172	.5914	.6535	.6535	.5228
2	.2534	.2353	.2353	.5914	.6653	.6722	.5415
3	.3258	.2896	.2896	.7207	.6838	.7095	.7762
4	.4525	.3801	.3801	.8501	.7392	.7468	.8871
5	.4887	.4525	.4525	1.0164	.9055	.9149	.9425
6	.4887	.5068	.5731	1.1706	1.1458	1.1949	.961
7	.5552	.5068	.5373	1.1157	1.0719	1.134	1.1523
8	.4706	.4706	.5731	1.0903	.9979	.961	.9522
9	.4344	.3801	.4344	.9328	.7392	1.1706	1.0642
10	.3801	.2715	.3982	.8501	.3734	.7577	
11	.6653	.5544	.5914	.7602	.4668	.6468	.8402
12	.6653	.6653	.5228	.2534	.3734		.1867
13	.5914	.5914	.5415	.2353	.2614	.2172	.1867
14	.6099	.6099	.5544	.2218	.2614	.1991	.1867
15	.6468	.6468	.5914	.2402	.2801	.181	.2241
16	.6653	.6653	.6283	.2378	.2987	.2534	.2614
17	.6838	.6838	.6838	.2378	.3174	.2896	.2987
18	.8501	.8501	.8871	.362	.3734	.2896	.3734
19	1.0791	1.0903	1.0534	.4572	.4108	.3801	.3921
20	1.134	1.134	1.1888	.8962	.9149	1.1888	1.2136
21	.8686	.8686	.8871	.8596	.0878	1.1157	1.251
22	.7023	.7023	.7392	.6036	.7655	.8686	.8775
23	.6468	.6468	.6468	.6401	.6161	.6653	.6908
24	.6099	.6283	.6283	.5914		.6161	.5415
Max	1.134	1.134	1.1888	1.1706	1.1458	1.1949	1.251
Min	.1991	.1991	.2172	.2218	.0878	.181	.1867
Avg	.6028	.5846	.5931	.6469	.5827	.6881	.6663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 203 / 11 KAV ANDHARI - I SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1629	.1991	.6283	.567	.5788	.5041
2	.2172	.1991	.181	.6283	.5544	.5601	.5415
3	.2896	.2534	.2534	.7207	.6036	.6161	.7947
4	.3801	.3439	.3439	.7577	.6584	.6722	.9425
5	.4344	.4525	.4525	1.134	.7499	.7655	1.0164
6	.4706	.5552	.5552	1.4083	.8316	1.1203	1.0903
7	.5249	.7522	.5373	.9425	.7392	1.0164	1.1523
8	.5068	.6984	.4887	.7023	.6468	.8871	1.0829
9	.3982	.5249	.362	.5304	.6099	.9979	.9709
10	.3077	.3258	.2534	.4572	.2987	.8316	
11	.5544	.4481	.5415	.4755	.2241	.4294	.7842
12	.4668	.4668	.4481	.3475	.2427	.4525	.3174
13	.4481	.4481	.4294	.3292	.2801	.4887	.3361
14	.4294	.4294	.3921	.3292	.2241	.4344	.2987
15	.4481	.4481	.4108	.2378	.3361	.362	.3361
16	.4854	.4854	.5041	.2195	.3734		.3734
17	.5041	.5041	.5914	.2561	.3361	.362	.4108
18	.7577	.7577	.9055	.3841	.3921	.3801	.4481
19	.9055	.9055	1.0974	.4435	.3174	.2715	.5601
20	1.1888	1.1888	1.134	.7316	.7468	1.134	1.1576
21	.8871	.8871	.9795	.7865	.7865	1.0164	1.0269
22	.7023	.7023	.8501	.7316	.7468	.8871	.8962
23	.6468	.6468	.7023	.5487	.5601	.5729	.6161
24	.6838	.6653	.6653	.6468	.5729	.5601	.5228
Max	1.1888	1.1888	1.134	1.4083	.8316	1.134	1.1576
Min	.1991	.1629	.181	.2195	.2241	.2715	.2987
Avg	.5349	.5522	.5533	.5991	.5166	.6694	.7035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 201 / 11 KV INDUSTRIAL EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
FEED Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0754	.0754	.0943	.0943	.0754	.0754
2	.0754	.0754	.0754	.0943	.0943	.0754	.0754
3	.0754	.0747	.0754	.0943	.0943	.0754	.0754
4	.112	.0754	.0754	.0943	.0943	.0754	.0754
5	.1132	.0754	.0754	.0943	.0934	.0754	.0754
6	.1132	.1132	.0754	.0943	.0934	.0747	.1132
7	.112	.1132	.1132	.0943	.0924	.0747	.1132
8	.0754	.0943	.1132	.0914	.1109	.0754	.1132
9	.0747	.132	.0754	.0943	.1109	.0754	.1132
10	.0754	.1132	.0754	.0943	.0924	.1132	.1132
11	.0747	.0754	.0943	.0934	.0857	.0754	.0905
12	.0754	.0754	.0943	.0934	.0934	.1132	.0943
13	.0754	.1132	.0876	.0924	.0943	.1132	.0876
14	.0754	.1132	.0943	.0934	.0754	.1132	.0943
15	.0754	.1132	.0943	.0934	.0754	.1132	
16	.0754	.1132	.0905	.0934	.0747	.1132	
17	.0754	.1132	.0934	.0934	.0754	.1132	.0943
18	.0943	.1132	.0943	.0924	.0754	.0754	.0934
19	.0943	.0754	.0934	.0739	.0754	.0754	.0934
20	.112		.0934	.0739	.0754	.0754	.0943
21	.0943	.0754	.0914	.0747	.0943	.0754	.0943
22	.0943	.0754	.0934	.0747	.0754	.0754	.0943
23	.0754	.0754	.0943	.0747	.0754	.0754	.0934
24	.0754	.0754	.0754	.0943	.0943	.0754	.0754
Max	.1132	.132	.1132	.0943	.1109	.1132	.1132
Min	.0747	.0747	.0754	.0739	.0747	.0747	.0754
Avg	.0870	.0934	.0881	.0896	.0879	.0864	.0928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 202 / TILAKNAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8402	.7602	.7468	.8299	.7468	.7964
2	.8402	.8402	.7602	.7545	.8299	.7468	.7964
3	.8402	.8402	.724	.7468	.7922	.7468	.7602
4	.8402	.8402	.724	.7468	.8299	.7468	.7602
5	.8589	.8215	.724	.905	.8962	.8962	.7964
6	.8589	.8215	.7602	.9335	.924	.8962	.8326
7	.8215	.9709	.7964	.9335	.961	.9335	.8688
8	.9335	.9709	.8145	.8402	.7947	.8962	.905
9	.8962	.7095	.8145	.7011	.8048	.8215	.8145
10	.8299	.7468	.7964	.7468	.7577	.8215	.724
11	.7842	.724	.724	.8402	.8215	.8145	.7011
12	.7468		.7468	.8131	.8402	.7602	.724
13	.8402	.724	.7011	.7947	.7842	.7602	.724
14	.8402	.724	.7011	.8131	.8402	.8326	.724
15	.8402	.724	.724	.8048	.7468	.8326	.724
16	.7545	.724	.8402	.8596	.8215	.8326	.7468
17	.7842	.7602	.8145	.8048	.8402	.905	.7545
18	.8402	.8326	.7468	.8316	.8962	.8871	.8145
19	.8402	.8688	.8145	.8048	.9335	.905	.8402
20	.9335	.8326	.8402	.9979	.9511	.905	.8145
21	.8962	.8326	.905	.924	.9335	.905	.8402
22	.8589	.8326	1.0517	.8962	.8402	.8688	.8402
23	.8402	.8326	.9335	.8589	.7842	.8145	.8145
24	.7842	.8402	.8131	.7468	.8676	.7468	.8145
Max	.9335	.9709	1.0517	.9979	.961	.9335	.905
Min	.7468	.7095	.7011	.7011	.7468	.7468	.7011
Avg	.8393	.8110	.7930	.8269	.8467	.8343	.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 203 / NEW TOWN 2 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7468	.6653	.7468	.679	.6535	.6468
2	.7468	.7468	.6653	.724	.679	.6535	.6468
3	.7468	.7468	.6468	.7468	.6413	.6535	.6468
4	.7468	.7468	.6468	.7468	.7167	.6535	.7023
5	.8589	.7468	.6653	.7499	.7095	.7095	.7023
6	.8402	.7468	.7023	.6706	.8316	.7095	.7392
7	.8215	.8131	.8316	.7011	.7762	.7655	.7392
8	.8402	.7762	.8871	.724	.7392	.8402	.7762
9	.8402	.7842	.8316	.724	.7762	.8402	.7762
10		.7842	.7392	.7468	.7947	.7842	.8131
11		.7762	.724	.8131	.8215	.7762	.724
12		.7023		.7762	.8402	.7392	.7011
13	.8402	.6653	.724	.7207	.7095	.7392	.7011
14	.8215	.6653	.4382	.7392	.7468	.6653	.724
15	.8402	.7023	.4525	.7316	.7468	.7023	.724
16	.8215	.7023	.7468	.961	.7468	.7392	.7011
17	.8589	.8131	.8402	.9145	.7468	.8316	.9431
18	.961	.8501	.905	.9425	.7842	.924	.905
19	.8962	.8501	.8402	.924	.8962	.8871	.8145
20	.7842	.7762	.8145	.961	.8589	.8501	.8402
21	.8215	.7392	.7888	.8131	.6908	.7762	.7468
22	.7468	.7392	.7468	.7392	.6602	.7392	.7545
23	.7468	.7392	.7011	.7468	.6348	.7392	.7468
24	.7167	.7468	.6653		.7167	.5975	.7023
Max	.961	.8501	.905	.961	.8962	.924	.9431
Min	.7167	.6653	.4382	.6706	.6348	.5975	.6468
Avg	.8116	.7544	.7247	.7854	.7477	.7487	.7466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 204 / TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8402	.7392	.7468	.7922	.8215	.8316
2	.7468	.8402	.7392	.724	.7922	.8402	.8316
3	.7468	.8402	.7392	.7468	.7545	.8402	.8131
4	.7468	.8402	.7392	.724	.7545	.8402	.7762
5	.8402	.8402	.7392	.7468	.7842	.8402	.7762
6	.8402	.8215	.7762	.9335	.924	.8402	.8131
7	.8215	.8402	.8131	.905	.8871	.8402	.7762
8	.8589	.924	.8316	.724	.8131	.8402	.8501
9	.8962	.8402	.8501	.8145	.8131	.8402	.8501
10		.8402	.8501	.7468	.8686	.9335	.8501
11			.7888	.9055	.8962	.924	.905
12		.8871	.8402	.9055	.9335	.8871	.8764
13	1.2936	.8501	.8402	.9425	.9335	.8871	.9335
14	1.2382	.8501	.9335	.9425	.9335	.924	.9335
15	1.2323	.8501	.9335	.9511	.8402	.7947	.8764
16	1.0829	.8501	.8764	.961	.9896	.8871	.9335
17	1.2567	.961	1.0269	1.0974	.9335		.9335
18	1.1458	.9979	1.0269	1.0719	1.0269	1.2567	1.0269
19	1.1203	1.0349	.9335	1.2197	1.0829	1.1088	1.0269
20	1.0269	.924	.8764	1.0719	1.0974	1.0349	.8764
21	.9709	.8501	1.0269	.924	.8402	.961	.9335
22	.8589	.8131	1.1203	.8215	.8402	.8871	.9335
23	.8402	.8131	.905	.7655	.7468	.8871	.905
24	.7468	.8215	.7392	.7468	.811	.8402	.8501
Max	1.2936	1.0349	1.1203	1.2197	1.0974	1.2567	1.0269
Min	.7468	.8131	.7392	.724	.7468	.7947	.7762
Avg	.9555	.8683	.8619	.8808	.8787	.9025	.8797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 206 / 11 KV BALAJINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.5658	.5544	.5601	.5658	.5601	.5544
2	.6535	.5658	.5544	.543	.5658	.5601	.5544
3	.6535	.5658	.5544	.5601	.5658	.5601	.5544
4	.6535	.5658	.5175	.5601	.7167	.5601	.5544
5	.6535	.5658	.5175	.6335	.7356	.5658	.5914
6	.6535	.6348	.5544	.6335	.7392	.5658	.5914
7	.6722	.6348	.6283	.6535	.7023	.6722	.5914
8	.7095	.5658	.6653	.543	.6653	.6535	.5914
9	.7468	.5975	.5544	.5258	.5914	.5658	.5914
10	.7468	.5658	.5175	.5601	.5544	.6535	.5914
11	.7468	.5175	.5601	.5359	.6602	.5914	.362
12	.5658	.4435	.5601	.4805	.6602	.5175	.4525
13	.4715	.5175	.4668	.462	.5601	.5175	.4382
14	.4715	.4805		.4805	.5658	.5175	.5258
15	.4904	.5175		.5175	.5601	.5175	.543
16	.4904	.5175	.4668	.5359	.5281	.5544	.5258
17	.5281	.5544	.5601	.5359	.5658	.5914	.543
18	.6602	.5544	.543	.5914	.7167	.5544	.5601
19	.6535	.6653	.6535	.5544	.6722	.6283	.6535
20	.6535	.5914	.6335	.7577	.7468	.6653	.5258
21	.6535	.5914	.6535	.6468	.6602	.6653	.5601
22	.6535	.5914	.6535	.5601	.6602	.6283	.543
23	.6161	.5914	.6535	.5975	.6535	.5914	.543
24	.6036	.5975	.5544	.5601	.6036	.5975	.5544
Max	.7468	.6653	.6653	.7577	.7468	.6722	.6535
Min	.4715	.4435	.4668	.462	.5281	.5175	.362
Avg	.6273	.5650	.5717	.5662	.6340	.5856	.5457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 202 / YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0724	.0663	.0747	.0905	.0829	.0663
2	.0829	.0724	.0829	.056	.0905	.0829	.0838
3	.1174	.0905	.1174	.0924	.1086	.0995	.1174
4	.1781	.1448	.1823	.168	.1448	.1296	.1844
5	.2155	.181	.218	.1867	.181	.1658	.218
6	.1823	.2353	.218	.2427	.2353	.1823	.218
7	.2321	.2715	.2347	.2149	.2715	.2486	.2347
8	.2486	.2896		.2218	.2715	.218	.2012
9	.2321	.181	.2012	.2241	.181	.1823	.1677
10		.1823	.2402	.1448	.1006	.1677	.1492
11		.1492	.2218	.0905	.1174	.1492	.1174
12		.116		.0905	.0829	.116	.0829
13		.0829	.0747	.0905	.0663	.0829	.0663
14	.0905	.0995	.1075	.0905	.0663	.0663	.0671
15	.1086	.1341	.1494	.0905	.0648	.081	.0503
16	.1629	.1326	.1494	.1086	.0995	.0995	.0503
17	.1991	.1174	.2054	.1448	.1134	.0995	.1006
18	.2353	.1823	.1848	.1991	.2012	.1326	.1677
19	.181	.1677	.1867	.2172	.2012	.1844	.1844
20	.1448	.1341	.1848	.181	.1677	.1341	.1658
21	.0905	.0829	.168	.1448	.1326	.0829	.1341
22	.0905	.0829	.168	.0905	.1174	.0829	.1174
23	.0724	.0663	.112	.1086	.1006	.0663	.0995
24	.0724		.0663	.1086		.0995	
Max	.2486	.2896	.2402	.2427	.2715	.2486	.2347
Min	.0671	.0663	.0663	.056	.0648	.0663	.0503
Avg	.1502	.1421	.1609	.1409	.1394	.1265	.1324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 204 / MAHADEV MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.724	.5868	.6535	.724	.6478	.5801
2	.663	.7421	.6478	.7468	.724	.663	.663
3	.7625	.7783	.7449	.8316	.7602	.6802	.7625
4	.8907	.8688	.8069	.9335	.7964	.7293	.9116
5	.9614	.9412	.9724	1.0059	.8145	.7545	.9614
6	.8383	.9955	.8619	.9955	.905	.8383	.8718
7	1.0111	1.0498	.9448	1.1203	1.0136	.9448	.788
8	1.0608	1.086	1.0442	1.1088	1.0498	1.0111	.8048
9	1.086	1.1041	1.0774	1.1273	.9774	.9945	.8215
10	1.086	1.0059	1.1888	1.0317	.9556	.9724	.8383
11	.905	.9614	1.1203	1.0136	.9389	.8048	1.0227
12	.8145		.9425	.905	.8383	.7377	1.0395
13	.724		.9335	.7964	.7377	.6478	.8215
14			.7842	.7059	.6316	.7042	.8886
15	.8145	.8288	.8316	.8145	.7287	.6539	.7545
16	.9412	.8551	.8316	.905	.7042	.8288	.6299
17	1.0498	.9116	1.0164	.9955	.8718	.8951	.8048
18	1.1765	1.004	1.0974	1.1946	.9389	.9779	.9054
19	1.0498	.9724	1.2136	1.1222	1.073	1.073	.9069
20	.905		1.1088	1.0679	.9892	.8288	.9892
21	.8507	.779	1.0974	1.0317	.9448	.779	.9448
22	.8145	.7287	.9335	.905	.8288	.7459	.8288
23	.724	.7468	.8402	.8326	.7625	.663	.7625
24	.6878		.6878	.7783		.7127	.6299
Max	1.1765	1.1041	1.2136	1.1946	1.073	1.073	1.0395
Min	.5868	.724	.5868	.6535	.6316	.6478	.5801
Avg	.8871	.8991	.9298	.9426	.8569	.8037	.8305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 205 / AURANGABAD NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.6335	.5182	.5975	.6335	.5801	.5365
2	.6535	.6516	.5801	.6468	.6335	.5868	.5868
3	.6299	.6697	.6154	.6722	.7059	.6316	.6299
4	.6706	.7059	.6478	.7316	.724	.663	.6706
5	.664	.724	.6796	.8596	.7602	.6802	.6874
6	.5668	.7421	.5182	.8775	.724	.5668	.5304
7	.6464	.7602	.5304	1.1088	.724	.6371	.7209
8	.6802	.8688	.5967	1.0082	.7602	.7042	.788
9	.8551	.8507	.6796	.8954	.9955	.7377	.8383
10		.8048	.7842	.8688	.7545	.8048	.7956
11		.8383	.7842	.8507	.8048	.8288	.6706
12		.6371		.724	.788	.7459	.7545
13		.7377	.7468	.724	.6478	.7611	.7042
14	.543	.8453	.7762	.724	.6706	.7125	.6371
15		.6962	.8316	.7602	.6802	.7461	.9724
16	.6335	.7377	.8316	.7783	.6802	.7287	.7545
17	.8145	.7625	.9335	.905	.8097	.779	.788
18	.9955	.8785	.9425	.9955	.8551	.9054	.9116
19	.905	.8288	.8589	1.0498	.9614	.8383	.9945
20	.8326	.7625	.8402	.9412	.8718	.7625	.852
21	.7783	.7127	.8402	.8688	.8048	.7127	.7956
22	.724	.663	.7468	.724	.6706	.6706	.7468
23	.6697	.5992	.7842	.6878	.6299	.6133	.6371
24	.6335		.5668	.5973		.547	.5868
Max	.9955	.8785	.9425	1.1088	.9955	.9054	.9945
Min	.5365	.5992	.5182	.5973	.6299	.547	.5304
Avg	.7070	.7439	.7232	.8165	.7517	.7060	.7329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044108 / 33/11Kv Borgaon Bazar

Feeder No / Name : 201 / 11Kv Didgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.7468		.5434	.5788	.5788	.7844
2	.5258	.7655		.6661	.7095	.5601	1.0094
3	.6485	.8589		.7202	.7783	.7095	1.1595
4	.7442	.9896		.9709	1.0082	.7842	1.3174
5	.8417	1.307		1.0867	1.1694	1.307	1.5398
6	.9991	1.6244		1.5238	1.4335	1.8858	1.6711
7	.7888	1.9605		1.56	1.6263	1.4563	1.3982
8	.7783	1.9978		.3048	1.3203	1.5123	1.3466
9	.7421	1.4377		1.2883	.9431	1.2136	1.2094
10	.724	.8402	.9328	.7282	.8589	.8014	1.0692
11	.7655	.3764	.5258	.5228	.5973	.5798	.5609
12	.3801	.3764	.6024	.5601	.5249	.4604	.6241
13	.3439		.6516	.4706	.4887	.2899	.703
14	.3258		.7455	.4108	.3982	.2543	.7202
15	.2896		.8322	.3921	.4344	.3922	.6762
16	.3077		.8939	.3921	.4706	.324	.6241
17	.4163		.7455	.4294	.5068	.5646	.5375
18			.5258	.4481	.3801	.4448	.4854
19			.6661	.4668	.8869	.5456	.5784
20	1.6804		1.2757	1.3817	1.7364	.4619	1.0341
21	1.2136		1.0692	1.0829	1.0829	.6672	.8939
22	.9709		.7362	.7095	.6908	.7015	.6556
23	.9335		.6661	.5611	.5975	.5646	.6556
24	.4733	.7842		.5375	.5228	.5601	.5646
Max	1.6804	1.9978	1.2757	1.56	1.7364	1.8858	1.6711
Min	.2896	.3764	.5258	.3048	.3801	.2543	.4854
Avg	.7011	1.0820	.7763	.7399	.8227	.7342	.9091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044108 / 33/11Kv Borgaon Bazar

Feeder No / Name : 202 / 11kv Borgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	1.094			.8589	.8402	1.1976
2	.5973	1.0374			.9522	.9335	1.3003
3	.7442	1.1128		.8589	1.0562	1.1389	1.42
4	.8507	1.1694		1.0692	1.1389	1.4003	1.6424
5	.9391	1.6598		1.1963	1.2696	1.4937	1.6767
6	1.0867	1.7164		1.7511	1.5123	2.1285	
7	1.0117	2.1502		1.6478	1.8671	2.0911	1.7622
8	.9955	2.037		1.4723	1.7177	1.7737	1.595
9	1.0136	1.5844		1.475	1.5684	1.5684	1.5074
10	.9774	1.3769	.929	1.3256		1.4713	1.2094
11	1.4842		.5609			1.1292	.6661
12	.6697		.6661	.8029	.7421	.6139	.7011
13	.6516		.7455	.7095	.7964	.4962	.8063
14	.6154		.823	.6535	.6697	.4619	.8413
15	.5973		.8842	.6908		.4619	.7888
16			.9465	.7282	.724	.7186	.7537
17	.7964		.8495	.7842	.8869	.7844	.7108
18			.8063	.7421	.7602		.6836
19			.8745	.7316	1.4842	.6139	.7362
20	1.8671		1.4548	1.9605	1.6244	1.0265	1.2226
21	1.6598		1.2226	1.4937	1.5497	1.1634	.101
22	1.6221		.8322	1.2136	1.2696	1.2318	.8939
23	1.4335		.7619	.8962	.9522	1.1976	.7701
24	.567	1.2826		.631	.7842	.8402	1.1416
Max	1.8671	2.1502	1.4548	1.9605	1.8671	2.1285	1.7622
Min	.5249	1.0374	.5609	.631	.6697	.4619	.101
Avg	.9860	1.4746	.8826	1.0873	1.1517	1.1121	1.0490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 201 / BHAGOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458		.3772	.3944	.3772	.3772	.3429
2	.4801		.3429	.4115	.4115	.3772	.3429
3	.4801		.3429	.4458	.4115	.3772	.5487
4	.4801		.3086	.6173	.4801	.583	.6516
5	.4801		.2743	.7202	.6173	.6859	.7202
6	.5144		.3429	.7373	.7888	.7888	.7545
7	.823		.4458	.6001	.6516	.6516	.6687
8	.8059		.6516	.5658	.6173	.6173	.5658
9	.6516	.6516	.6173	.5144	.3086		
10	.6516	.2572	.4801	.3772	.3086		.3429
11	.4458	.2572	.2058	.2572	.3429	.5144	.3086
12	.3086	.2572	.2401	.3429	.3429	.5487	.3086
13	.2401		.2401	.4287	.2743	.5487	.3086
14	.2058		.2058	.4115	.1715	.5487	.2743
15			.2058	.5658	.1372	.5144	.2743
16	.2229	.2743		.583	.4973	.4115	.2743
17		.2743	.2401		.4801	.4801	.4115
18	.5487		.2743	.5144	.4458	.5144	.4458
19	.6516	.3429		.5487	.4801	.5316	.5144
20	.7202	.3772	.5316	.7202	.6173	.6001	.6516
21	.6173	.4458	.4115	.6516	.6173	.4801	.5487
22	.5487	.4115	.3944	.4115	.6859	.4115	.4115
23	.4458	.4115	.3772	.4115	.6859	.3772	.3772
24	.4458		.3772	.3772	.3772	.6173	.3601
Max	.823	.6516	.6516	.7373	.7888	.7888	.7545
Min	.2058	.2572	.2058	.2572	.1372	.3772	.2743
Avg	.5097	.3601	.3585	.5047	.4637	.5253	.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 202 / JATEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916		.7545	.4115	.7202	.9602	.6516
2	.8916		.7545	.4458	.7202	.9602	.6516
3	.9602		.823	.6516	.9259	1.0288	.7202
4	1.166		.9259	.6516	.9945	1.1317	1.3032
5	1.3032		1.0288	.7888	1.3032	1.1317	1.406
6	1.3904		1.0288	.823	1.5432	1.1317	1.4091
7	1.3203		1.166	1.0974	1.749	1.8861	1.9989
8	1.4575		1.2003	1.3032	2.0576	2.2291	1.9662
9	1.3717	.8916	1.0974	1.2003	1.9334	2.1125	2.0233
10	.7545	.4801	.7202	1.166	1.9006	1.8991	
11	.6859	.4973	1.166	.4801	.5144	.5487	
12	1.0288	1.0631	1.0974	.4801	.5144	.5144	
13	1.2003	1.3032	1.2209	.4458	.4458	.4458	
14	1.3032	1.2887	1.3904	.4115	.3772	.4115	.3772
15	1.3375	1.0288	1.1869	.4115	.3429	.5487	.4115
16	1.2346	1.2209	1.0288	.4115	.3429	.5144	.6173
17		1.2346	1.3717		.5144	.6173	.4801
18			1.2346	.7202	.6516	.9602	.9259
19	.823	1.3032	1.0802	1.0974	.6516	1.3032	1.3032
20	.823	1.2003	1.0974	1.3375	.823	1.3717	1.406
21	.823	1.0974	.9602	1.2003	.9945	1.3032	1.3375
22	.7888	.8573	.7888	.823	1.0631	.9602	.823
23	.7545	.8573	.7545	.7888	.9945	.9259	.7888
24	.8916		.7545	.7202	.6516	.9602	.8573
Max	1.4575	1.3032	1.3904	1.3375	2.0576	2.2291	2.0233
Min	.6859	.4801	.7202	.4115	.3429	.4115	.3772
Avg	1.0546	1.0231	1.0263	.7768	.9471	1.0774	1.0729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 203 / MAHALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173		.9602	.5487	.823		.4801
2	.6173		.9602	.5487	.8916		.4801
3	.7202		.9945	.6516	.9259		.6173
4	.9602		1.0631	.9945	.9602		.823
5	1.166		1.0974	1.0631	.9945		1.0631
6	1.2346		1.3717	1.0974	1.166		1.0974
7	1.5089		1.6461	1.0974	1.1317		.9602
8	1.5261		1.5432	.8916	1.0974		.7545
9	1.4746	.4801	1.4746	.8916	1.0631	.9945	.9602
10	1.3717		1.3032	.6859	1.0288	.9259	.7202
11				.8573	.823	.8916	.7888
12	.6859	.6173		.9259	.8916	.9945	.8916
13	1.0288	.6859		1.0288	.8916	1.0974	.9602
14	.6859	.6859	.6173	1.0288	.9259	1.3032	1.0974
15	.6859	.6173	.6173	.9431	.9602	1.3375	1.0631
16	.7545	.6173	.6173	.8573	1.0288	1.406	.9945
17		.6859		.8916	1.3032	1.3565	.6173
18	.6173		.8916	.9259	1.3717	1.2209	.7202
19	.7888	.6859	1.2346	.8916	1.3375	1.2346	1.0974
20	1.0974	.7888	1.0288	1.166	1.3032	.9602	1.3375
21	1.0288	.9259	.9945	1.2689	1.166	.823	1.3032
22	.9602	1.0288	.6173	.8573	1.0974	.6173	1.0974
23	.9259	1.0288	.583	.823	1.0631	.5487	1.0631
24	.6173		.9602	.5487	.823		.5487
Max	1.5261	1.0288	1.6461	1.2689	1.3717	1.406	1.3375
Min	.6173	.4801	.583	.5487	.823	.5487	.4801
Avg	.9579	.7373	1.0288	.8952	1.0445	1.0475	.8974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 206 / PANVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.823	.7202	.823	.7545	.7202
2	.823		.9259	.7202	.9259	.6859	.823
3	.823		.9259	.7202	.9259	.6859	.823
4	.823		.9602	1.166	1.166	.823	.9602
5	.823		1.0288	1.166	1.2689	1.0974	1.166
6	.8573		1.2003	1.2003	1.2003	1.2346	1.2003
7	1.3032		1.3375	1.1317	1.0974	1.2003	1.0631
8	1.3904		1.5432	1.0974	1.0288	1.3032	.8573
9	1.0288	.4115	1.3032	.9259	1.0288	.9602	.7888
10	1.0288	.583	1.0974	.6859		.7202	.7202
11	1.0288	.4458	.4801	.583		.5487	.6859
12			.4115	1.0288	.9945	1.0974	1.166
13	.4458	.5144	.4458	1.2003	.9602	1.166	1.2346
14	.4458	.4801	.4458	1.1145	.9945	1.2003	1.2003
15	.4801	.5144	.4115	1.0288	1.0288	1.166	1.0288
16	.583	.5144	.3772		.9945	1.3032	.3429
17		.6173		1.0288	1.0288	1.3032	1.3717
18	.7202		.6859	.9945	.7202	1.2003	1.2346
19	.6173	.9945	.7545	1.0974	.7202	1.0974	1.0974
20	.6173	1.0288	.9602	1.166	.6859	.8916	.9945
21	.583	1.0288	.8916	.9945	.6859	.8916	.9259
22	.5487	.8916	.8573	.8573	.7888	.8573	.8573
23	.5487	.8573	.823	.8916	.7888	.7888	.823
24	.823		.823	.7545	.823	.6859	.7545
Max	1.3904	1.0288	1.5432	1.2003	1.2689	1.3032	1.3717
Min	.4458	.4115	.3772	.583	.6859	.5487	.3429
Avg	.7802	.6832	.8484	.9684	.9400	.9860	.9516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 207 / MALISAGAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166		.583	.5487	.7202	.4801	.5487
2	1.166		.583	.5487	.7888	.6173	.6516
3	1.166		.583	.6516	.7888	.6173	.6516
4	1.166		.6173	.7202	.823	.6859	.7888
5	1.166		.6173	.7202	.8573	.7888	.823
6	1.2003		.5487	.7716	.8573	.8916	.8573
7	1.0802		.5144	.8573	.8573	1.2003	1.0974
8	.9945		.5144	.9259	.8573	1.1317	1.0288
9	.8573	.8916			.4115	.9945	.9259
10	.6859	.4801			.3944	.8916	.8916
11	.6859	.4458			.4801	.4458	.5144
12	.6859	.4458			.4801		.4801
13	.4973	.4458			.4458		.4115
14	.5144	.4287			.4801	.4801	.3601
15			.7716	.3772	.4973	.4458	.3772
16	.4801	.5658			.5144	.4801	.3944
17		.583	.6859		.6173	.3772	.583
18			.6173	.4458	.7202	.703	.7888
19	.9945	.7888		.823	.7202	1.0631	1.166
20	.9259	1.0288	.7888	1.166	.8573	1.2689	1.3717
21	.8916	1.3032	.9945	1.1317	.9259	1.166	1.2689
22	.823	1.3032	1.1488	1.0631	.9259	1.0974	1.1317
23	.7888	1.2003	1.1317	.9945	.9259	1.0631	1.0974
24	1.1488		.583	1.0974	.7202	.4458	1.0631
Max	1.2003	1.3032	1.1488	1.166	.9259	1.2689	1.3717
Min	.4801	.4287	.5144	.3772	.3944	.3772	.3601
Avg	.9088	.7624	.7052	.8027	.6944	.7880	.8030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 208 / SIRASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602		.583	.5316	.7202	.6173	.6001
2	.9945		.8573	.823	.7545	.6173	.6516
3	.9945		.9259	.9602	.823	.6173	.6516
4	1.4091		1.0288	.9945	.9259	.7888	.9602
5	1.6057		1.0288	.9945	.9945	.9259	.9945
6	1.8023		1.7147	1.0288	1.0631	1.0288	1.046
7	2.556		1.8861	1.0288	1.0288	1.1317	1.0631
8	2.4577		2.1605	.9602	.9602	.9602	1.1145
9	2.4006	.6516	1.933	.9602	.9602	.9945	.9945
10	1.6461		1.4746	.6516		.7202	
11	.6516		.4801	.583	.5144	.5144	
12	.6516		.4115	1.0288	.9602	2.1262	
13	.6516	.5144	.4115	1.4746	1.0974	1.989	
14	.6516	.5487	.3772		1.2346		1.7833
15	.7202	.5487	.5487		1.2689	1.749	1.8176
16	.6516	.6001	.6173		1.7695	1.8778	1.9547
17		.6516	.5658		1.8861	1.9334	1.9204
18		.8573	.6344	1.1317	1.8347	1.8515	1.6804
19	.4115	.8573		1.166	1.7147	1.7204	1.6118
20	.4458			1.2346	1.0288	.8916	.8573
21	.6173	.9259	.7888	1.0974	1.0288	.823	.8573
22	.6516	.6516	.6859	.6859	.9259	.7202	.7888
23	.6173	.6516	.6516	.6859	.9259	.7202	.7202
24	.9088		.5487	.5658	.6516	.8573	.6516
Max	2.556	.9259	2.1605	1.4746	1.8861	2.1262	1.9547
Min	.4115	.5144	.3772	.5316	.5144	.5144	.6001
Avg	1.1117	.6781	.9234	.9294	1.0901	1.1381	1.1360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 209 / CHINCHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202		.7545	.3601	.583	.3429	.3601
2	.7202		.7545	.3772	.6173	.3429	.3772
3	.823		.7545	.4801	.6516	.3429	.4801
4	.9602		.823	.6173	.7888	.4801	.6173
5	.9945		.8916	.6859	.9259	.6173	.7202
6	1.0802		.8573	.7202	.9945	.6859	.823
7	.9774		.8573	.9259	1.0288	.9602	1.2689
8	.9088		.8573	.8573	1.0974	.8573	1.0631
9	.8573	.9945	.7202	.6859	1.0631	.7888	.9945
10	.583		.5487	.3429		.7202	
11	.3429		.6516	.4115	.4115	.4115	
12	.3429		.7202	.3772	.3772	.4458	
13	.6687	.5487	.6859	.3429	.3429	.3429	
14	.5487	.5487	.6173	.3086	.3429		.3086
15	.5144	.5144	.6001	.3086	.3429	.2743	.3086
16	.6859	.6516	.5316	.3429	.3086	.2743	.3086
17		.6516	.823		.5144	.3429	.4801
18				.4115	.5487	.4801	.6516
19				.583	.6173	.823	.9945
20	.4458	.8573		.823	.7202	.823	1.0631
21		.8573	.7202	.9259	.823	.7888	.9259
22		.8573	.6859	.7202	.8916	.7202	.6859
23		.8573	.6516	.6859	.9259	.7202	.6516
24	.7202		.7545	.6173	.583	.3429	.6344
Max	1.0802	.9945	.8916	.9259	1.0974	.9602	1.2689
Min	.3429	.5144	.5316	.3086	.3086	.2743	.3086
Avg	.7164	.7339	.7267	.5614	.6739	.5621	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 201 / LADGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.6001	.2829	.1715	.9717	.3429	.3772
2	.8097	.6001	.2829	.1715	.9717	.3429	.3772
3	.8097	.6001	.2829	.1715	.9717	.3429	.3772
4	.8097	.6001	.2829	.1715	.9717	.3429	.3772
5	.9717	.6859	.2829	.2572	.9717	.4287	.4668
6	1.1336	.7716	.2629	.3429	1.1336	.5144	.5601
7	1.4575	1.0288	.2629	.5144	1.6194	.3429	.4668
8	1.0526	1.2003	.1829	.4287	1.5384	.3429	.3772
9	1.2146	1.0288	.0943	.3858	1.4575	.3429	.2829
10	1.2003	.9221		.4287	1.3717	.2829	.2801
11	.2572			.2829	.1715	.2829	
12	.2572				.1715	1.3927	1.5623
13	.2572			.2801	.1715	1.3927	1.5623
14	.2572	.1886		.2829		1.6385	1.6404
15	.2572	.2829		.2829	.1715	1.7204	1.6404
16	.2572	.2829	.2829	.2829	.2572	1.8023	1.5565
17	.1715	.2829	.2829	.2829	.3429	1.4918	1.5565
18		.2829	.2801	.2829	.2572	1.6575	1.3927
19	.1715	.2829		.2801	.2572	1.4918	1.5623
20	.4287	.3772	.4668	.4668	.4287	.4668	.4668
21	.4287	.3772	.4668	.4668	.3429	.4668	.4668
22	.3429	.3772	.4668	.4668	.3429	.3772	.3734
23	.3429	.3772	.4668	.3734	.3429	.3772	.3734
24	.3772	.3429	.2829	.4668	.3772	.3429	.3772
Max	1.4575	1.2003	.4668	.5144	1.6194	1.8023	1.6404
Min	.1715	.1886	.0943	.1715	.1715	.2829	.2801
Avg	.6120	.5473	.3067	.3279	.6789	.7720	.8032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 202 / SAWKHED GANAGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.2829	.2801	.2829	.3429	.3506
2	.3772	.3772	.2829	.2801	.2829	.3429	.3772
3	.3772	.3429	.2829	.2801	.2829	.3429	.3772
4	.3772	.3429	.2829	.3734	.2829	.3429	.3772
5	.4668	.3429	.3772	.4668	.4668	.8573	.4334
6	.5544	.5144	.5601	.5601	.5544	.5144	.6001
7	.4668	.4287	.5544	.5601	.4668	.8573	1.0059
8	.3734	.3429	.3734	.4668	.3734	.9431	1.0774
9	.2829	.3429		.4668	.3772	.9431	1.0774
10	.1715	.2829		.2829	.2572	.7545	.8383
11	.1715			.1886	.1715	.2829	.1867
12	.6001		.6478	.5668	.6001	.1886	.1867
13	.7716	.5144	.6478	.6154	.5144	.1886	.1867
14	.7716	.6859	.7287	.5668	.1715	.1886	.1867
15	.8573	.6001	.7287	.5668	.1715	.1886	.1867
16	.9431	.6783	.7287	.5668	.5144	.1886	.1867
17	.8573	.6001	.7287	.4858	.8573	.1886	.1867
18		.6001	.8097	.4858	.8573	.2829	.2801
19	.3429	.503	.6401	.6154	.7716	.2829	.3734
20	.4287	.4668	.4668	.4668	.5144	.5601	.4668
21	.3429	.4668	.3734	.3734	.3429	.5601	.4668
22	.3429	.3772	.2801	.2829	.3429	.4668	.3734
23	.3429	.3772	.2801	.2829	.2572	.3772	.2801
24	.3772	.3429	.2829	.2801	.2829	.2572	.2829
Max	.9431	.6859	.8097	.6154	.8573	.9431	1.0774
Min	.1715	.2829	.2801	.1886	.1715	.1886	.1867
Avg	.4772	.4488	.4924	.4317	.4166	.4351	.4310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 203 / PURANGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287		.7316		1.2003	
2		.4287		.7316		1.2003	
3		.4287		.7316		1.2003	
4		.4287		.7316		1.2003	
5		.5144		.9145		1.5432	
6		.6001		1.1888		1.8861	
7		.5144		1.0288		2.2291	
8		.6001		.9145		2.1434	
9				.6401		2.3148	
10	.6001						1.5623
11	.6001						.6401
12	1.6289						.3734
13	1.8004				2.0576		
14	1.8004				2.2291		
15	1.8004				2.2291		
16	1.8004				2.0576		
17	.8573				2.1434		
18					2.2291		.4668
19	.6001		1.5565		1.9719		.7316
20	.6001		.9431		1.0288		1.1469
21	.4287		.8573		.9431		.9831
22	.4287		.8573		.8573		.8573
23	.4287		.823		.6859		.8573
24		.4287		.7716		.6859	
Max	1.8004	.6001	1.5565	1.1888	2.2291	2.3148	1.5623
Min	.4287	.4287	.823	.6401	.6859	.6859	.3734
Avg	1.0288	.4858	1.0074	.8385	1.6757	1.5604	.8465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 204 / 11KV KAPUS WADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2572	.1791	.2801	.2572	.2572	.2829
2	.3353	.2572	.1791	.2801	.2572	.2572	.2829
3	.3353	.2572	.1791	.2801	.2572	.2572	.2829
4	.3353	.2572	.1791	.2801	.3353	.2572	.2829
5	.4191	.2572	.2629	.3429	.4191	.3429	.3772
6	.5668	.2572	.4334	.5144	.6478	.4287	.056
7	.9717	.3429	.6001	.7716	.8097	.3429	.3772
8	.9717	.4287	.7287	.8573	.8097	.2572	.2829
9	.9717	.4287	.7287	.7621	.8097	.2572	.1886
10	.8573	.2715		.8097	.6859	.1886	.1867
11	.1715	.1886		.1886	.1715	.1886	
12	.1715	.1886			.1715	.763	.6859
13	.1715	.0943		.1886	.1715	.7545	.8383
14	.1715	.0943		.1886		.8383	.9145
15	.1715	.0943		.1886	.1715	.8288	.9145
16	.1715	.0943	.1886	.1886	.1715	.8383	.8383
17	.1715	.0943	.1886	.1886	.1715		.9145
18		.1886	.1886	.2829	.1715	.763	.8383
19	.1715	.1886		.2801	.2572	.6783	.6859
20	.2572	.2829	.3734	.2801	.3429	.3772	.2801
21	.2572	.3772	.2801	.2829	.2572	.3772	.3734
22	.2572	.2829	.2801	.2829	.2572	.2829	.2801
23	.2572	.2829	.2801	.2829	.2572	.2829	.2801
24	.2829	.2572	.2829	.2801	.2829	.2572	.2829
Max	.9717	.4287	.7287	.8573	.8097	.8383	.9145
Min	.1715	.0943	.1791	.1886	.1715	.1886	.056
Avg	.3819	.2385	.3254	.3601	.3541	.4381	.4664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 205 / 11KV BABHULGAON GANGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2572	.2829	.2801	.2829	.6859	.763
2	.3772	.2572		.2801	.2829	.6859	.763
3	.3772	.2572		.2801	.2829	.6859	.7545
4	.4715	.2572		.3734	.3734	.6859	.8383
5	.5544	.3429		.3734	.4668	.6859	.9945
6	.6468	.5144		.5601	.5544	1.2003	1.326
7	.4668	.3429		.4668	.4668	1.4575	1.5565
8	.3734	.2572		.3734		1.6289	1.7204
9	.2829	.2572		.2801	.2801	1.5432	1.7204
10	.2572	.2829		.2829	.2572	1.4746	1.5623
11	.2572			.2829	.2572	.3772	.2801
12	1.1145		.181	1.0526	.6859		.1867
13	1.2003	1.326	.9717	1.0526	.6859		.1867
14	1.2003	1.326		1.0526	1.286		.1867
15	1.2003	1.326		.9717	1.2003	.2829	.1867
16	1.2003	1.326	1.3765	.9717	1.2003	.2829	.1867
17	1.2003		1.2955	.9717	1.2003	.2829	.2801
18			1.2146	1.0526	1.286	.3772	.2801
19	.8573	1.0059	1.0669	1.0526	1.2003	.3772	.3734
20	.4287	.3772	.4668	.3734	.3429	.4668	.5601
21	.2572	.4668	.4668	.462	.4287	.4668	.5601
22	.2572	.3772	.3734	.3734	.3429	.4668	.4668
23	.2572	.3772	.3734	.3734	.3429	.4668	.4668
24	.3772	.2572	.2829	.3734	.2829	.3429	.3772
Max	1.2003	1.326	1.3765	1.0526	1.286	1.6289	1.7204
Min	.2572	.2572	.181	.2801	.2572	.2829	.1867
Avg	.6084	.5596	.6960	.5820	.6083	.7107	.6907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 206 / BHAOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.5144	.6468	.6859	.6478	.8573	.8316
2	.8097	.5144	.5935	.6859	.6478	.8573	.8316
3	.8097	.5144	.7392	.6859	.6478	.8573	.8316
4	.8097	.5144	.6783	.8573	.6478	.8573	.924
5	1.0526	.6859	.9221	.8573	.8097	1.2003	1.086
6	1.3765	.7716	1.1603	1.1145	1.1336	1.3717	1.4175
7	1.7814	1.0288	1.6194	1.6604	1.6194	1.2003	1.3289
8	1.9433	1.0288	1.7814	1.7185	1.9433	1.0288	1.1641
9	1.7814	1.0288	1.6194	1.4746	1.7004	.8573	.9955
10	1.5432		1.6194	1.2955	1.7147		.8573
11	.5144		.6468	.7316			.6859
12	.5144		.5544	.5544		1.0774	1.8976
13	.5144	.5544	.5544	.5544	.5144	1.8842	1.6404
14	.5144	.5544	.5544	.5544	.5144	1.6385	1.5623
15	.5144	.5601	.5544		.5144	1.4746	1.5623
16	.5144	.5544	.5544	.5544	.5144	1.1736	
17	.5144	.5601	.5544	.5544	.6001	1.8023	
18		.7392	.6468	.6468	.5144	1.8233	1.8976
19	.9431	.8954	.9431	.8145	.6859	1.5089	1.8976
20	1.0288	1.1641	1.2289	1.2003	1.1145	1.4022	1.3108
21	.8573	1.2536	1.1145	1.0631	1.0288	1.3289	1.1469
22	.8573	1.0745	1.0288	.905	.8573	1.1765	.9831
23	.6859	.9145	1.0288	.8145	.8573	.905	.9431
24	.823	.6859	.7392	.9431	.823	.8573	.8316
Max	1.9433	1.2536	1.7814	1.7185	1.9433	1.8842	1.8976
Min	.5144	.5144	.5544	.5544	.5144	.8573	.6859
Avg	.9354	.7672	.9201	.9099	.9114	1.2337	1.2103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 207 / mhaski

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.2572	.2658	.3858	.3353	.3429	.3772
2	.503	.2572	.2658	.3858	.3353	.3429	.3772
3	.503	.2572	.2658	.3858	.3353	.3429	.3772
4	.5668	.2572	.2658	.3858	.3353	.3429	.4668
5	.6478	.2572	.2658	.4572	.4191	.5144	.5601
6	.8907	.2572	.6001	.7621	.5735	.6859	.7392
7	1.2955	.2572	1.1336	1.0669	.8097	.2572	
8	.8097	.3429	1.2146	1.2955	.9717	.2572	.5601
9	.8907	.2572	1.0526	.9145	1.0526	.2572	.4668
10	.8573			.8907	.8573	.4668	.4668
11	.3429			.4668	.4287		
12	.3429	.2829				1.4089	1.3108
13	.3429	.2829		.3734		1.4918	1.5623
14	.3429	.2829		.3734		1.1603	1.7966
15	.5144	.2829		.3734		1.326	1.9605
16	.5144	.2829	.4668	.3734			1.6404
17	.5144	.2829	.4668	.4668			1.6404
18				.4668	.5144	1.4746	1.4746
19		.3772		.5601	.6859	1.4089	1.3108
20	.4287	.7392	.8573	.6468	.7716	.5601	.6401
21	.5144		.7316	.7316	.6859	.5601	.5601
22	.4287		.6401	.6468	.5144	.5601	.5601
23	.3429	.5601	.5601	.5544	.5144	.4668	.5601
24	.4668	.3429	.4668	.5601	.4668	.5144	.3772
Max	1.2955	.7392	1.2146	1.2955	1.0526	1.4918	1.9605
Min	.3429	.2572	.2658	.3734	.3353	.2572	.3772
Avg	.5711	.3220	.5950	.5880	.5893	.7020	.8993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 201 / 11KV PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.5487	.543	.7468	.7316	.8316	.679
2	.2957	.6348	.543	.6535	.7316	.924	.7545
3	.3734	.7468	.543	.6535	.823	1.0974	.8488
4	.4668	.7842	.543	.7468	.823	1.2803	.8488
5	.3734	.7842	.7164	.8402	.905	1.3717	.9431
6	.6535	.8048	.8954	1.0164	1.3575	1.5546	1.1883
7	.663	.8215	1.1641	1.0974	1.267	1.5844	1.2637
8	.6539	.5601	.985	1.0059	1.0974	1.5729	1.1317
9	.6874	.4572	.8954	.9145	.9145	.7545	.9997
10	.5601	.6335	.7164	.7316	.7392	.4715	.6468
11	.5658		.5601	.5544		.415	
12	.5975	.462	.4668	.8059		.3795	.6468
13	.6348	.4668	.3734	.7164		.4428	.7316
14	.3772	.5228	.3734	.7164	.8131	.4744	
15	.4481	.4668	.3734	.543	.8501	.506	.6335
16	.4854	.4668	.3734	.724	.8589	.5281	.7164
17	.5281	.5544	.4668		.8131	.5506	.7164
18	.5601	.6468	.5601		.5601	.5668	.7164
19	.6413	.823	.8316		1.6632	.7287	.6268
20	.679	.823	1.0974	1.086	.924	1.3014	1.086
21	.7545	.8779	1.0059	1.086	.8501	.9431	.9955
22	.7842	.8145	.8316	.9955	.8316	.8316	.9955
23	.8215	.6335	.823	.9145	.7095	.8488	.823
24	.7392	.7316	.7316	.7468	.7316	.7095	.679
Max	.8215	.8779	1.1641	1.0974	1.6632	1.5844	1.2637
Min	.2957	.4572	.3734	.543	.5601	.3795	.6268
Avg	.5716	.6550	.6839	.8236	.9045	.8612	.8487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 202 / 11KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.543	.8402	.7316	.8316	.8488
2	.1867	.4481	.4525	.6468	.7316	.8316	.8488
3	.3734	.5601	.362	.6535	.823	.9145	.8488
4	.4668	.5601	.4525	.6535	.905	1.0059	1.0185
5	.5228	.5228	.6268	.7468	.905	1.1888	1.0185
6	.5601	.4854	.8059	.924	1.0059	1.3717	1.2637
7	.8453	.4481	.8954	1.0164	1.0059	1.2803	1.1883
8	.8551	.4344	.8954	.823	.905	.8215	1.0374
9	.6874	.4525	.7164	.7316	.823	.7922	.7733
10	.7545	.543	.5373	.6401	.5601	.5658	.543
11	.5975	.4668	.5601	.5544		.415	
12	.6413	.3734		.7164		.3841	.4525
13	.679	.4668	.3734	.6268		.4428	.543
14	.6584	.4481	.3734	.6268	.6348	.4586	.543
15	.5975	.4294	.3734	.5373	.6722	.4744	.5373
16	.6348	.4668	.3734	.6268	.7095	.5121	.4525
17	.6722	.4668	.4668	.6335	.7392	.5506	.6335
18	.6722		.5601	.543	.7842	.583	.6335
19	.6413	.7316	.8316	.6268	.8131	.8192	.5373
20	.6154	.823	1.0974	.9955	1.0059	1.1317	1.086
21	.679	.8779	1.0059	1.0059	.7947	.9431	1.086
22	.8402	.823	.8316	.905	.8316	.9431	.9955
23	.7468	.7701	.823	.9145	.8316	.9242	.9145
24	.7392	.7042	.7316	.7468	.7316	.8316	.9054
Max	.8551	.8779	1.0974	1.0164	1.0059	1.3717	1.2637
Min	.1867	.3734	.362	.5373	.5601	.3841	.4525
Avg	.6267	.5511	.6386	.7390	.8069	.7924	.8134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 203 / 11KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.7842	.9145	.462	.4525	.4668	.3582
2	1.0242	.905	.905	.5544	.4525	.4668	.4525
3	1.0974	.9335	.9955	.5544	.543	.5601	.4525
4	1.1888	.6036	.9955	.6468	.543	.5601	.543
5	1.2803	1.1203	.6401	.823	.6335	.6535	.543
6	1.3352	1.1203	.823	.9145	.985	.7947	.543
7	1.226	1.1949	.924	.9145	1.0745	.7377	1.267
8	1.1883	1.0456	.924	1.0059	.9955	.7468	1.0442
9	1.094	.9955	.7316	1.0059	.724	.8059	.9282
10	1.0242	.7316	.5601	.905	.6535	.724	.8954
11	.9335		.7392	.6401		.0114	
12	.9335	.6335	.9145	.6401		.1143	.6468
13	.9335	.724	.8316	.5544		.1143	.6468
14	.8215	.7522	.8316	.5544	.6348	.5093	.6767
15	.9774	.7522	.8316	.6099	.8131	.5093	.6468
16	.5975	.6335	.8316	.5544	.7762	.6535	.7316
17	.5601	.905	.8316	.6468	.8131	.7095	.7316
18	.5853	.905	.9145	.6468	.8131	.9054	.823
19	.6584	.7164	1.0974	.7316	.9145	1.0374	1.0059
20	.6722	1.0059	1.2803	1.2536	1.2803	1.4146	1.2536
21	.6413	1.086	1.1888	1.2536	1.0242	1.1317	1.1765
22	1.0456	1.0059	1.0059	1.1765	.9145	1.094	1.0974
23	.8764	.9511	.9335	.9955	.8686	1.0374	.9955
24	1.0242	.8779	.9145	.8316	.9145	.8316	.9054
Max	1.3352	1.1949	1.2803	1.2536	1.2803	1.4146	1.267
Min	.5601	.6036	.5601	.462	.4525	.0114	.3582
Avg	.9469	.8862	.8983	.7865	.8011	.6913	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 201 / 11kv Darga

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6468	.6722	.6908	.6348	.6838	
2	.5975	.5914	.6535	.6722	.6161	.6468	.6908
3	.6161	.5975	.6348	.6722		.6535	.6535
4	.6535	.5975	.6535	.7095	.8029	.5975	.7095
5	.7468	.6722	.7023	.7023	.7095	.6722	.7468
6	.8029	.7468	.7133	.7133	.7316	.695	.7842
7	.6722	.7733	.7207	.7133	.7499	.695	.7095
8	.7468	.7922	.7095	.6838	.7023	.7133	.7282
9	.7095	.7282	.6908	.5975	.7468	.7133	.6348
10		.6348	.5975	.6535	.5788	.6161	.6283
11	.7762	.5975	.6224	.7095	.5788	.5788	.6099
12	.7577	.5788	.5975	.5975	.5601	.6348	.5601
13	.7392	.5601	.5975	.5788		.6161	
14	.6468	.5601	.5975	.5228	.7095	.5975	
15	.5601	.5041	.6348	.5975	.6722	.5228	.6908
16	.5415	.6348	.6722	.5975	.6722	.5601	.7282
17		.6468	.6722	.6535		.5975	.7842
18		.6767	.6722	.6653		.7468	.8215
19	.7316	.724	.679		.8779	.7282	.7733
20	.7865	.7783	.7922	.8316	.9145	.7095	.9431
21	.7682	.7783	.7545	.7577	.823	.7655	.8488
22	.7133	.7133	.7468	.7207	.7865	.8029	.811
23	.7023	.7392	.7282	.7282	.7577	.7842	.7922
24	.6371	.6838	.6908	.7023	.6535	.7207	.7468
Max	.8029	.7922	.7922	.8316	.9145	.8029	.9431
Min	.5415	.5041	.5975	.5228	.5601	.5228	.5601
Avg	.6933	.6649	.6752	.6727	.7139	.6688	.7331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 202 / 11 Rotegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7392	.6626	.7842	.7842	.7577	.8215
2	.7095	.6838	.6135	.7282	.7842	.7392	.7655
3	.6535	.6535	.6068	.7282	.8215	.7468	.8402
4	.8962	.6535	.6173	.8402	.8402	.8962	.9335
5	.8962	.7468	.6443	1.1088	1.0349	1.0642	1.0642
6	.9149	.7468	.9724	1.2567	1.5364	1.2254	1.1949
7	1.1016	.7922	1.1633	1.4998	1.3032	1.5729	1.475
8	1.0829	.9054	.9116	1.2197	1.1403	1.262	1.363
9	1.0164		.8215	1.2136	1.0136	1.1157	1.1763
10		.7186	.5967	.9979	.8507	.8962	1.0082
11	.7947	.8238	.6908	.8501	.8215	.8775	.8215
12	.7762	.7602	.7468	.7522	.7468		.8299
13	.7207	.7865	.7468	.8063	.7842	.8962	.811
14	.7207	.6838	.7468	.6516	.8215	.7842	.7545
15	.7468	.7392	.7842	.6203	.8215	.8962	
16	.7468	.7207	.8215	.6962	.7842	.9556	.9431
17	.8215	.7316	.8775	.6443	.7762	.9709	.8775
18	.8775	.7602	.9709	.6415	.7577	.8589	.8402
19	.9877	.8059	1.0751	.7186	.8048	.9149	
20	1.0608	1.1999	1.3392	1.0679	.9145	.9522	
21	.9511	1.0679	1.0751	1.0059	.9877	1.0082	1.094
22	.8413	.9328	.9709	.8962	.9145	.9522	1.0185
23	.8871	.8501	.9149	.8131	.8501	.8589	.9431
24	.8402	.9425	.8402	.8501	.7947	.7947	.8215
Max	1.1016	1.1999	1.3392	1.4998	1.5364	1.5729	1.475
Min	.6535	.6535	.5967	.6203	.7468	.7392	.7545
Avg	.8605	.8020	.8421	.8913	.9037	.9564	.9713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 203 / 11kv Tilakroad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.267	1.2382	1.307	1.307	1.3443	1.2936	1.3256
2	1.2696	1.2012	1.2883	1.307	1.3256	1.2567	1.251
3	1.2136	1.2136	1.2696	1.2696	1.307	1.2136	1.2136
4	1.2696	1.2696	1.2883	1.3256	1.3817	1.2136	1.2696
5	1.3575	1.3443	1.3121	1.3491	1.3676	1.2696	1.3256
6	1.4661	1.4003	1.3535	1.46	1.4449	1.3535	1.363
7	1.4003	1.3014	1.2197	1.4083	1.3032	1.2986	1.4563
8	1.3256	1.3014	1.1576	1.3491	1.267	1.262	1.4377
9	1.2696	1.2323	1.1576	1.2696	1.2986	1.2803	1.4712
10	1.2936	1.2696	1.251	1.3256	1.1888	1.2323	1.3676
11	1.2197	1.2696	1.2637	1.3817	1.2936	1.1576	1.2936
12	1.2567	1.2323	1.2696	1.2696	1.3306		1.2883
13	1.3121	1.2136	1.2323	1.3256	1.2936		1.251
14	1.2936	1.1949	1.2136	1.2696	1.2197	1.251	1.2696
15	1.307	1.1203	1.1763	1.2323	1.2567	1.3256	1.307
16	1.2696	1.2136	1.1203	1.1949	1.3121	1.4003	1.3443
17	1.251	1.2567	1.1576	1.307	1.2936	1.4937	1.363
18	1.2136	1.262	1.2323	1.2567	1.2936	1.531	1.3817
19	1.419	1.3575	1.3203	1.3535	1.3535	1.6244	1.6975
20	1.5123	1.5746	1.5844	1.5729	1.5729	1.587	1.773
21	1.4266	1.4449	1.5655	1.5339	1.5181	1.6057	1.6409
22	1.3717	1.4415	1.4784	1.4969	1.4632	1.5497	1.5466
23	1.3491	1.4003	1.419	1.4377	1.386	1.419	1.4712
24	1.2742	1.2752	1.3256	1.3443	1.3817	1.3306	1.3443
Max	1.5123	1.5746	1.5844	1.5729	1.5729	1.6244	1.773
Min	1.2136	1.1203	1.1203	1.1949	1.1888	1.1576	1.2136
Avg	1.3170	1.2929	1.2902	1.3478	1.3416	1.3613	1.3939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 204 / town 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	.8501	.8402	.8402	.8402	.7762	.8589
2	1.0829	.8131	.8215	.8402	.8215	.7392	.8775
3	1.0269	.7842	.8029	.8215	.8029	.7468	.8962
4	1.0829	.7842	.7842	.8775	.8215	.8215	.9335
5	1.0642	.8589	.7947	.8871	.9335	.8962	.9522
6	1.0456	.8962	.823	.8871	.924	.8048	.9335
7	1.0642	.8299	.7947	.8413	.8048	.7682	.9709
8	.8962	.811	.8029	.8686	.7316	.7682	.7468
9	.8402	.7468	.7655	.7655	.7023	.7499	.7095
10		.7282	.6722	.7282	.7392	.7468	.7023
11	1.0164	.7842	.7545	.7095	.7468	.7095	.7023
12	.961	.7842		.6908	.7282	.7095	.6535
13	.8316	.7468	.8402	.6908	.7095	.6908	.6722
14	.8316	.7842	.9335	.6535	.6908	.7282	.7468
15	.8215	.7842	.8775	.6908	.7282	.6908	.7842
16	.8215	.7655	.8215	.7282	.7655	.7095	.7842
17	.7842	.7762	.7842	.7282	.7392	.7468	.7842
18	.7468	.567	.7468	.7762	.6838	.7282	.7655
19	.8779	.7964	.7545	.823	.7865	.8402	
20	.9328	.9412	.9619	.9328	.8596	.8775	
21	.9694	.8596	.9242	.9425	.8962	.9335	1.2071
22	.9877	.9055	.9335	.9425	8.9986	.9709	1.1317
23	.961	.8962	.9149	.8962	.9055	.8718	1.0185
24	1.0456	.8871	.8589	.8775	.8775	.8501	.8962
Max	1.0829	.9412	.9619	.9425	8.9986	.9709	1.2071
Min	.7468	.567	.6722	.6535	.6838	.6908	.6535
Avg	.9459	.8075	.8264	.8100	1.1349	.7865	.8513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 205 / pahade express feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0185	.1307	.1494		.0185	.0187
2	.0187	.0185	.1307	.1494		.0185	.0187
3	.0187	.0187	.112	.1494		.0187	.0335
4	.0373	.0187	.1307	.1494		.0187	.0373
5	.0259	.0187	.1494	.1663		.0187	.0187
6	.0373	.0187	.1494	.1478	.0187	.0183	.0187
7	.0187	.0189	.1307	.1109		.0183	.0187
8	.0187	.1509	.112			.0183	.0187
9	.0187	.1307	.112		.0924	.1463	.1307
10	.0924	.1494	.112		.1109	.1494	.1294
11	.1109	.0934	.132		.112	.1494	.1109
12	.1109	.112	.1307		.0934		.112
13	.1294	.112	.0934		.0934		.1307
14	.1478	.112	.0934		.0934	.1307	.1494
15	.1494	.1494	.0934		.0934	.112	.0187
16	.1867	.112	.112		.112	.112	.168
17	.1867	.0934	.112		.1294	.1307	
18	.1494	.1494	.1494		.1478	.1494	
19	.1463	.1663	.1509		.1463	.1494	.132
20	.1646	.1848	.132	.0187	.1463	.1307	.1886
21	.0183	.1494	.1698	.0187	.0183	.0187	.0377
22	.0183	.1494	.168		.0183	.0187	
23	.0185	.1494	.1494		.0185	.0373	
24	.0187	.0185	.1307	.1478		.0185	.0187
Max	.1867	.1848	.1698	.1663	.1478	.1494	.1886
Min	.0183	.0185	.0934	.0187	.0183	.0183	.0187
Avg	.0775	.0964	.1286	.1208	.0903	.0728	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 206 / water supply Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0248	.0255	.0137	.0133	.0141	.0259	.0373
2	.0373	.0255	.0135	.0135	.0143	.0259	.0373
3	.0373	.0259	.0133	.0271		.0259	.0187
4	.0373	.0259	.0131	.0263	.0705	.0389	.0373
5	.0373	.0389	.013	.0267	.0686	.0389	.0373
6	.112	.0518	.0511	.0648	.0812	.0377	.056
7	.0743	.0657	.0518	.0907	.0667	.0377	.0747
8	.0518	.0789	.0533	.0907	.0789	.0377	.0747
9	.0383	.0657	.0686	.0766	.0907	.088	.0671
10		.0533	.0533	.0777	.0907	.056	.0648
11	.0511	.0686	.0394	.0934	.092	.056	.0907
12	.0511	.0705	.0389	.0777	.092	.056	
13	.0638	.0714	.0255	.0638	.0657	.0373	
14	.0638	.0434	.0259	.0619	.0526	.0373	
15	.0648	.044	.0255	.0126	.0526	.0373	.0657
16	.0648	.0429	.0255	.0124	.0394	.0373	.0657
17	.0648	.0141	.013	.0126		.0373	.0667
18		.0137	.0133	.013		.0373	.0667
19	.0251	.0267	.0131	.0133	.0255	.056	.0676
20	.0377	.013	.0133	.0137	.0255	.0373	.0676
21	.0377	.0133	.0135	.0133	.0255	.0373	.0133
22	.0251	.0137	.0135	.0135	.0255	.0373	.0135
23	.0255	.0139	.0137	.0271	.0259	.0373	.0135
24	.0373	.0255	.0141	.0137	.0137	.0259	.0373
Max	.112	.0789	.0686	.0934	.092	.088	.0907
Min	.0248	.013	.013	.0124	.0137	.0259	.0133
Avg	.0483	.0388	.0264	.0396	.0529	.0408	.0511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 207 / 11 KV MGM

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2202	.2772	.3174	.2987	.3174	.3326	.3174
2	.2987	.2402	.2987	.2987	.2987	.2957	.2987
3	.2801	.2241	.2987	.3174	.2987	.2987	.3174
4	.2801	.2241	.2987	.3174	.3361	.2987	.2801
5	.2801	.2614	.3142	.2957	.3696	.3361	.2987
6	.3174	.2801	.2743	.2957	.3511	.3292	.2801
7	.2801	.2829	.3142	.2926	.2957	.3292	.2801
8	.2801	.3206	.2801	.2587	.2772	.2743	.2801
9	.2614	.2614	.2614	.2987	.3174	.2926	.3395
10	.499	.3547	.3174	.3734		.3921	.3511
11	.5175	.3547	.3772	.4481		.3734	.3511
12	.499	.3734	.3734	.5041		.4481	.4108
13	.462	.3734	.3734	.4854	.6535	.4668	.4854
14	.462	.3547	.3547	.4668	.5975	.4481	.4481
15	.4854	.3921	.3734	.4481	.5601	.4294	.4294
16	.4854	.4481	.3734	.4668	.5041	.4191	.4294
17	.4854	.4251	.3734	.5041	.4805	.4481	.4668
18	.4854	.4207	.3547	.4805	.462	.4294	.4668
19	.4572	.439	.3584	.4938	.4572	.4481	.4715
20	.439	.439	.3961	.4938	.439	.3921	.4904
21	.4024	.3696	.3395	.4066	.4024	.3547	.415
22	.3292	.3361	.3174	.3511	.3658	.3547	.3961
23	.3326	.3174	.3174	.3361	.3511	.3361	.3772
24	.3361	.2957	.3174	.2987	.3174	.3511	.3174
Max	.5175	.4481	.3961	.5041	.6535	.4668	.4904
Min	.2202	.2241	.2614	.2587	.2772	.2743	.2801
Avg	.3823	.3361	.3323	.3846	.4025	.3699	.3749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 201 / 11 KV CHINCHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2454	.2984	.4915	.5243	.4915	.4973
2	.3086	.2454	.2984	.4915	.5243	.4915	.4973
3	.3086	.2454	.3315	.4915	.5243	.4915	.5138
4	.3086	.2629	.3647	.4915	.5898	.5735	.5304
5	.3772	.2804	.3978	.5571	.6554	.6554	.5636
6	.7202	.2804	.431	.6554	.7209	.7209	.6299
7	.8573	.4908	.5304	.6554	.6882	.7865	.7293
8	.8916	.7362	.4641	.5243	.6226	.6226	.5898
9	.8573	.5258	.4144		.4915	.5243	.4588
10	.583	.4207	.3086	.1638	.3978	.2294	.3277
11	.3277	.2486	.1966	.1311	.2622		.2622
12	.2622	.2818	.1638	.3605	.7888		.6226
13	.2949	.2321	.1638	.3277	.4908		.7209
14	.2949	.2155	.1638	.2949	.5258	.6962	.6882
15	.2622	.2321	.1638	.2622		.6962	.6554
16	.2622	.2486	.1638	.2622	.5609	.6962	.5898
17	.2294	.2155	.1966	.2622	.7011	.7956	.6554
18	.3605	.1823	.2622	.1966	.6135	.8122	.5898
19	.3932	.2818	.3605	.1966	.5258	.7293	.5243
20	.5898	.5967	.6882	.3605	.639	.5967	.6802
21	.5243	.5967	.6554	.5898	.5243	.5636	.6554
22	.5243	.5636	.5898	.6226	.5243	.5636	.5243
23	.4915	.4641	.5898	.5898	.4915	.5304	.5243
24	.5487	.4915	.3978	.4915	.5571	.4915	.5138
Max	.8916	.7362	.6882	.6554	.7888	.8122	.7293
Min	.2294	.1823	.1638	.1311	.2622	.2294	.2622
Avg	.4536	.3577	.3581	.4117	.5628	.6076	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 202 / 11 KV AGARSAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3441	.3315	.2321	.2321	.2804	.3315
2	.3772	.3441	.3315	.2321	.2321	.2804	.3315
3	.3772	.3441	.3647	.2321	.2321	.2804	.3481
4	.4115	.3932	.3978	.2321	.2652	.3155	.3978
5	.4458	.426	.4973	.2984	.2984	.3506	.4641
6	.5144	.4752	.5967	.3647	.3647	.4031	.5636
7	.5144	.4096	.547	.5304	.663	.631	.663
8	.4458	.3441	.3978	.4807	.6299	.7186	.5801
9	.3429	.2949	.2622	.3647	.5636	.5959	.4475
10	.3086	.2294	.1989	.3315	.3647	.4578	.3647
11	.1966	.1326	.1658	.1658	.1966	.1492	.1658
12	.3506	.2321	.3647	.1658	.213	.1326	.1326
13	.3681	.2984	.3647	.1658	.1638	.1457	.1658
14	.3155	.3978	.3647	.1658	.1638	.1492	.1658
15	.3155	.3315	.3315	.1658	.1966	.6962	.1658
16	.3506	.3481	.3315	.1658	.213	.1658	.1989
17	.2804	.431	.3647	.1658	.1966	.1823	.2683
18	.3155	.4475	.3978	.3315	.2294	.2155	.3018
19	.2804	.3647	.2486	.3647	.3277	.3978	.4024
20	.3768	.3978	.4475	.4641	.4752	.431	.503
21	.3768	.3812	.431	.4973	.3605	.3987	.4641
22	.3768	.3647	.3978	.4641	.3605	.3978	.3647
23	.3277	.3315	.3647	.431	.3277	.3812	.3315
24	.3601	.3441	.3481	.3481	.3978	.3113	.3647
Max	.5144	.4752	.5967	.5304	.663	.7186	.663
Min	.1966	.1326	.1658	.1658	.1638	.1326	.1326
Avg	.3628	.3503	.3687	.3067	.3195	.3528	.3536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 201 / 11 KV BHAGGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18
HR	Load (MW)
1	1.3817
Max	1.3817
Min	1.3817
Avg	1.3817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 403 / 33 KV VAIJAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.145	3.8255	3.9769	4.0472	3.9209	3.8809	3.3608
2	4.0329	3.5482	3.8649	3.9363	3.8649	3.7146	3.9209
3	3.8649	3.5288	3.7529	3.9918	3.2487	3.6969	3.9769
4	4.0889	3.5848	3.8649	4.2135	4.257	3.9209	4.201
5	4.481	3.9769	3.9918	4.5462	4.4907	4.313	4.481
6	4.7051	4.201	4.4445	4.8234	5.1029	4.4993	4.6491
7	4.5068	4.1307	4.4525	5.0452	4.5068	4.7188	4.9851
8	4.425	4.4136	4.1027	4.4907	4.2798	4.3896	4.6491
9	4.1581	3.1927	3.9363	4.2135	4.3244	4.4445	4.5268
10	1.885	4.145	3.6591	4.201	3.6037	4.0889	4.269
11	4.5462	4.0329	3.8255	4.257	3.6969	3.9209	3.9918
12	4.4353	3.9769	3.1602	3.9769	3.5848	1.7924	3.8649
13	4.3244	3.9209	3.8809	4.0329	3.6408	2.6886	3.3608
14	4.2135	3.7529	3.9363	3.6969	4.201	4.0329	3.3608
15	4.145	3.7529	3.9363	3.6969	4.257	4.0889	3.3048
16	4.145	3.9209	3.8809	3.8089	4.201	4.313	4.481
17	3.5848	3.9918	3.9363	3.8809	3.4374	4.425	4.3244
18	3.4728	3.8409	4.0472	3.8409	3.3265	4.481	4.3244
19	4.6639	4.2896	4.313	3.4208	4.4445	4.7611	3.1367
20	4.9383	5.1583	5.2092	4.8868	4.8834	4.481	3.4168
21	4.6091	4.6639	4.7125	4.6091	4.6639	4.7051	5.2092
22	4.2798	4.4445	4.6491	4.4353	4.4993	4.7051	4.8731
23	4.3244	4.3244	4.481	4.257	4.3244	4.425	4.537
24	4.425	4.1581	4.201	4.257	4.0889	4.1027	4.201
Max	4.9383	5.1583	5.2092	5.0452	5.1029	4.7611	5.2092
Min	1.885	3.1927	3.1602	3.4208	3.2487	1.7924	3.1367
Avg	4.1833	4.0323	4.0923	4.1903	4.1187	4.1079	4.1419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 201 / shivoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2572	.2572	.4344	.4481	.4298	.4163
2	.3239	.3258	.3086	.5068	.4854	.4656	.4163
3	.3887	.3944	.3772	.543	.5228	.5552	.4525
4	.4534	.4115	.4287	.5792	.5601	.6268	.5068
5	.4858	.4458	.5144	.6697	.6348	.6626	.543
6	.5668	.4973	.5658	.7783	.6535	.7343	.6335
7	.5668	.6001	.7716	.8145	.6161	.7522	.7783
8	.5668	.5658	.583	.6335	.5788	.591	
9	.5344	.4287	.4287	.4668		.4477	
10	.4287	.3601	.4525	.4294	.4119	.2715	
11	.7343	.6335	.6335	.4294	.4119	.4525	
12		.5973	.6697	.5668	.7373	.5316	.6335
13	.7164	.5973		.502	.6687	.6001	.7421
14	.6268	.5973	.7964	.4372	.6001	.6001	.6878
15	.6626	.6335	.7964	.5668	.6001	.6344	.6335
16	.6268	.5973	.8145		.6001	.7716	.6335
17			.7783		.6001	.7716	.6335
18		.8145	.7421		.6001	.6516	.6335
19		.9231	.724		.6001	.6001	.8145
20		.8869	.6697		.591	.543	.6335
21	.985	.8507	.4525	.6535	.6268	.4887	.5611
22	.8954	.8145	.4525		.591	.4706	.5068
23	.8417	.543	.4887		.5373	.4706	.4525
24	.7468	.6268	.6335	.5068		.4477	.4344
Max	.985	.9231	.8145	.8145	.7373	.7716	.8145
Min	.3239	.2572	.2572	.4294	.4119	.2715	.4163
Avg	.6039	.5827	.5800	.5599	.5762	.5655	.5873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 202 / sudamwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5194	.5068	.2896		.2058	.1886
2	.4481	.5194	.5068	.3077		.2229	.2572
3	.5228	.5014	.543	.3077		.2572	.3086
4	.5228	.5014	.6335	.3258		.2915	.4287
5	.5601	.5194	.6878	.362		.3086	.4801
6	.6722	.5552	.7421	.3982		.3258	.5144
7	.5601	.591	.6154	.543		.4287	.7716
8	.4668	.4298	.4887	.5611		.2865	
9	.4108	.3582	.4887			.2572	.4801
10	.2686	.2896	.362		.3258	.2058	.3982
11	.3761	.2715	.3439		.197	.362	.2715
12	.2572	.3429	.4525		.2507		.2715
13	.3258	.2743	.3801		.2686		.3439
14	.2743	.3429			.2686	.362	.362
15	.3086	.3772			.2686	.4706	.4163
16	.3045	.4115			.2686	.3601	.4344
17		.2915	.6516		.3403	.4458	.4887
18		.3772	.4706		.3582		.4887
19			.4706		.3045	.6173	.5068
20		.543	.6516		.5373	.6878	.5792
21		.6335	.5249		.5373	.724	.6516
22	.6626	.5792	.543		.5552	.6878	.5611
23	.6089	.543	.5068		.5373	.6516	.5249
24	.6161	.5373	.543	.4525		.5373	.543
Max	.6722	.6335	.7421	.5611	.5552	.724	.7716
Min	.2572	.2715	.3439	.2896	.197	.2058	.1886
Avg	.4534	.4483	.5292	.3942	.3584	.4141	.4466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1254	.3258	.0905	.0648	.0857	.0686
2	.1494	.1254	.1448	.1086	.0648	.0857	.0686
3	.1494	.1075	.181	.1267	.081	.0857	.0686
4	.1867	.1075	.1991	.1448	.081	.1029	.0905
5	.2241	.1075	.2353	.1448	.0972	.1029	.0857
6	.2614	.1075	.2715	.1629	.0972	.12	.0857
7	.2241	.1075	.3077	.181	.1619	.2229	.1886
8	.1867	.2149	.2534	.1448	.2105	.1543	
9	.0934	.1612	.1086			.12	.1886
10	.0537	.1086	.1086		.12		.1267
11	.0537	.1086	.1267		.0179	.0543	.0362
12	.12	.1372	.1448		.0537	.0362	.0181
13	.12	.1991	.181		.0537	.0514	.0181
14	.0514		.1448		.0537	.0343	.0362
15	.12		.0724		.0716	.0343	.0362
16		.0686	.1448		.0716	.0362	.0362
17		.1715	.1448		.0716	.0905	.1267
18		.12			.0895	.0905	.0362
19		.1448			.0895	.0905	.0905
20		.1267	.1086		.1254	.0905	.1267
21	.1612	.1991	.1086		.1254	.1267	.1629
22	.1433	.181	.1267		.1254	.1267	.1267
23	.1254	.1448	.1267		.1254	.1267	.1086
24	.1494	.1254	.1448	.1267		.1254	.1086
Max	.2614	.2149	.3258	.181	.2105	.2229	.1886
Min	.0514	.0686	.0724	.0905	.0179	.0343	.0181
Avg	.1413	.1364	.1687	.1368	.0933	.0954	.0887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3403	.3258	.1448	.1457	.1543	.1886
2	.4481	.3403	.3258	.181	.1619	.1715	.1886
3	.4854	.3224	.3982	.2172	.1943	.2058	.2229
4	.5228	.3045	.5258	.2534	.2267	.2229	.2572
5	.5601	.3403	.6335	.2896	.2429	.2572	.3429
6	.6348	.3403	.6697	.3077	.2591	.2743	.4525
7	.4854	.3403	.4706	.2534	.2915	.3601	.4801
8	.3547	.3045	.3982	.2353	.2915	.2229	
9	.2614	.1791	.2715			.1372	.3086
10	.1433	.0905	.1991			.12	.181
11		.0905			.1075	.0724	.0724
12	.1715		.2534		.1075	.0905	.0543
13	.1543		.1991				.0724
14	.0514	.1543	.2715				
15	.1029	.12	.181		.0895	.0724	.0724
16	.0857	.0724	.1991		.0895	.0724	.0905
17		.1543	.2353		.1075	.0905	.0905
18		.1372	.1991		.1791	.181	.1086
19		.181	.2896		.3582	.2896	.2353
20		.2715	.3982		.4656	.3258	.2896
21	.4119	.4525	.3077		.4656	.362	.3982
22	.3582	.4163	.2896		.4119	.3258	.3439
23	.3403	.3982	.2896		.3403	.3077	.3077
24	.3734	.3403	.3439	.2715		.2686	.2896
Max	.6348	.4525	.6697	.3077	.4656	.362	.4801
Min	.0514	.0724	.181	.1448	.0895	.0724	.0543
Avg	.3345	.2587	.3337	.2393	.2387	.2084	.2294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 205 / BOLTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.6089	.7602	.2896	.3563	.2915	.2743
2	.6722	.591	.8145	.3258	.421	.3258	.2743
3	.7842	.6089	.8688	.362	.4858	.3601	.3086
4	.9335	.6626	.905	.3982	.5506	.5144	.3429
5	1.0829	.6984	.9593	.5068	.583	.6001	.5249
6	1.2136	.7164	1.0679	.8688	.6478	.7701	.905
7	.9335	.7522	1.0317	.9412	.6154	.6859	.7716
8	.7095	.591	.6697	.8326	.5668	.7202	
9	.6535	.5731	.6154	.5992		.4287	.6516
10	.394	.4344	.4525	.4534	.1886	.3258	.3982
11	.3224	.4706		.4854	.3761	.3258	.4344
12	.583	.2572		.3734	.3403	.3258	.3258
13	.5658		.6335		.3045	.2401	
14	.4115		.543	.3547	.2686		.3258
15	.4458	.4115	.3439	.3921	.3045	.2353	.362
16	.463	.3944	.4887		.3582		.362
17		.4973	.4525		.3403	.4525	.3982
18		.2743	.4163		.3224	.4525	.4525
19		.3982	.5792		.4298	.5973	.6154
20		.5792	1.0498		.8417	.6878	.8145
21	.7701	.8507	.8869	.9335	.8596	.7783	.8869
22	.8417	.8145	.7602		.8059	.724	.7964
23	.6984	.7602	.7059		.7164	.6878	.6878
24	.7282	.6089	.724	.6878		.6626	.6335
Max	1.2136	.8507	1.0679	.9412	.8596	.7783	.905
Min	.3224	.2572	.3439	.2896	.1886	.2353	.2743
Avg	.6883	.5706	.7150	.5503	.4856	.5087	.5248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 206 / BANGLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.12	.1715	.4163	.4481	.4656	.5068
2	.1943	.1543	.2058	.4344	.4668	.5194	.4801
3	.2267	.1886	.2058	.4525	.4854	.591	.543
4	.2915	.2229	.2572	.4887	.5041	.6268	.543
5	.421	.2572	.2572	.5068	.5601	.6447	.6335
6	.502	.2915	.2915	.5249	.5788	.6805	.6687
7	.4534	.3944	.4973	.5068	.5228	.6447	.6516
8	.4049	.4115	.5144	.3258	.3734	.5552	
9	.4049		.3429			.5014	.4525
10	.2401	.2743	.362		.3045	.3429	.362
11	.4119	.2896	.4163		.3086		.3077
12	.5014	.3077	.3982			.5144	.2353
13	.5014	.3772	.4525		.5487	.583	.1991
14	.4298	.3982	.4525		.5316	.4287	.2172
15	.4656	.362			.463	.3601	.2534
16	.5014	.5611	.4163		.3772	.2572	.4344
17		.3982	.3982		.463	.308	.543
18		.4887	.4887		.4973		.4887
19		.5792	.3801		.4801	.2915	.2896
20		.5973	.4887		.6447	.4525	.5249
21	.5194	.6335	.4163		.6089	.6335	.6335
22	.4477	.6154	.5611		.5373	.5973	.5973
23	.4119	.5792	.4525		.5194	.5792	.543
24	.4668	.4119	.543	.4344		.4835	.543
Max	.5194	.6335	.5611	.5249	.6447	.6805	.6687
Min	.1457	.12	.1715	.3258	.3045	.2572	.1991
Avg	.3971	.3876	.39	.4545	.4868	.5028	.4631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVVOOR

Feeder No / Name : 207 / Ex.BANGLA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1715	.1372	.1448	.1134	.1715	.1715
2	.1943	.1886	.1372	.1448	.1134	.1715	.1715
3	.1943	.1886	.12	.1267	.1296	.1715	.1991
4	.1781	.2058	.12	.1267	.1296	.1886	.1715
5	.1781	.2058	.12	.1267	.1296	.2058	.1886
6	.1781	.2058	.1372	.1267	.1296	.2229	.1886
7	.1943	.2058	.1372	.1448	.1296	.2229	.1372
8	.2105	.2058	.1372	.1448	.1296	.2743	
9	.3401	.2058	.2058	.1943		.3258	.12
10	.3429	.1886	.1991	.1943	.1543	.3258	.1991
11	.2915	.2229	.1991	.1781	.1886		.1991
12		.2058	.2353	.1781			.1991
13	.3429	.2058	.1448	.1781	.3086		.1991
14	.3258	.2058	.1448	.1781	.3258		.1991
15	.3258	.2058		.1781	.3086	.2915	.1991
16	.3258	.2058	.1448		.3086	.2572	.1991
17		.2058	.1448		.3086	.1886	.1991
18		.2058	.1448		.2915	.1886	.2172
19		.2229	.1448		.2915	.2058	.1991
20		.1715	.1448		.1886	.1715	.1991
21		.1543	.1267	.1296	.1886	.181	.1448
22	.1543	.1543	.1448		.1886	.1715	.1448
23	.1715	.1543	.1448		.1886	.1715	.1448
24	.1457	.1886	.1543	.1448		.1886	.1715
Max	.3429	.2229	.2353	.1943	.3258	.3258	.2172
Min	.1457	.1543	.12	.1267	.1134	.1715	.12
Avg	.2382	.1951	.1508	.1553	.2021	.2148	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 208 / KORADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1029	.2229	.2353	.2614	.2865	.2534
2	.1296	.1029	.2572	.2534	.2801	.3045	.2715
3	.1619	.1543	.2572	.2896	.3361	.3403	.2715
4	.1943	.1715	.2743	.3258	.3361	.3582	.2896
5	.2915	.2058	.2896	.3982	.3547	.4298	.3258
6	.3239	.2401	.3086	.4525	.3734	.5014	.3982
7	.2591	.2743	.3258	.3439	.3361	.394	
8	.2105	.2915	.3086	.2534	.3174	.2507	
9	.1943	.1886	.2229			.1791	
10	.1543	.1543	.1448		.0895		.0543
11		.0905			.0686		.0543
12	.0716		.0905				.2172
13	.0716	.0724	.1086		.1886	.2572	.1991
14	.0716	.0686	.1086				
15	.1254	.1086	.0905			.2401	.2172
16	.0716	.0724			.2058	.2058	.2715
17		.0905	.1267			.2896	.2896
18		.1267	.181			.2058	.3258
19		.1991	.2896			.1715	.2715
20		.2172	.2896		.2149	.2172	.3258
21	.3403	.2896	.3077		.3582	.2896	.3439
22	.2865	.2715	.2896		.3761	.2896	.3077
23	.2686	.2715	.2715		.3403	.2715	.2715
24	.2801	.2686	.2353	.2715		.3045	.2715
Max	.3403	.2915	.3258	.4525	.3761	.5014	.3982
Min	.0716	.0686	.0905	.2353	.0686	.1715	.0543
Avg	.1914	.1754	.2273	.3137	.2773	.2893	.2615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 202 / KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	.8865	.9335	.3353	1.0669	.5068	.3567
2	1.105	.9808	.9896	.3353	.9526	.5068	.3353
3	1.2955	1.0562	1.0456	.3353	.9145	.543	.4161
4	1.3336	1.3203	1.1576	.4024	.6668	.5973	.4607
5	1.448	1.3957	1.2883	.4359	.6668	.6878	.5201
6	1.4937	1.5655	1.363	.503	.6722	.724	.6241
7	1.4937	1.4146	1.5497	.6706	.8775	.9593	.7095
8	1.4937	1.358	1.307	.6706	1.1431	1.086	.7727
9	1.6194	1.3392		.6706	1.105	.8402	.6687
10	1.3203	.3601	.0373	.724	1.0317	.5647	.6706
11	1.1317	1.0288	.0373	.9145	1.0374	.7202	1.1203
12	1.1222	.5316	.503	.5144	.9431	.8478	.8962
13	.0943	.5182	.7377	.0953	.9054	.8505	.0373
14	.0566	.4161	.8383	.0953	.9997	.7373	1.0082
15	.7059	.5213	.8383	1.2574	1.0562	.8573	1.1203
16	.7095	.4755	.7377	1.4289	1.2071	.9156	1.1949
17	.4706	.5502	.6706	1.3717	1.1317	1.1488	1.2323
18	.4525	.6859	.6371	1.5242	.9242	1.0631	1.307
19	.3982	.4607	.6371	1.5242	1.3014	1.2269	1.419
20	1.1694	.8383	.6371	1.5242	1.3203	1.0802	1.4937
21	1.2637	1.1576	1.4937	1.5242	1.4146	.9945	1.307
22	1.1317	1.1576	1.4937	1.3717	1.358	.9602	1.1203
23	1.0562	1.0829	1.1949	1.3336	1.1317	.8573	1.0456
24	1.2765	.9808	1.0456	1.1203	1.2384	.8488	.7888
Max	1.6194	1.5655	1.5497	1.5242	1.4146	1.2269	1.4937
Min	.0566	.3601	.0373	.0953	.6668	.5068	.0373
Avg	1.0343	.9201	.9206	.8618	1.0444	.8385	.8594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 203 / DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3772	.3734	.2683	.3048	.1629	.1524
2	.3429	.4527	.3921	.2683	.3048	.1629	.2056
3	.381	.5281	.4294	.2683	.381	.181	.2378
4	.5335	.5847	.5228	.2683	.4382	.2353	.3567
5	.6859	.6602	.5601	.3353	.4763	.2896	.4344
6	.724	.7545	.5975	.4024	.4763	.3077	.7545
7	.7049	.7167	.6722	.503	.9054	.9231	.7529
8	.5716	.5847	.5601	.4359	.3239	1.2308	.8109
9	.4191	.4904	.4108	.4024	.6859	.7727	.6984
10	.2829	.2229	.3361	.4382	.6878	.4458	.6706
11	.3206	.1372	.2347	.1905	.1698	.2058	.2987
12	.4525	.1715	.3734	.1143	.2075	.2058	.1494
13	.4706	.1783	.4359	.1524	.2452	.2374	.1494
14	.4525	.1486	.4359	.1524	.2452	.1715	.1494
15	.4525		.4694	.1524	.2263	.1715	.1494
16	.362		.503	.2096	.2075	.2058	.1494
17	.2172	.2743	.503	.1905	.2829	.2229	.1867
18	.2534	.3909	.503	.2858	.3772	.3086	.2614
19	.2896	.2824	.57	.4954	.3961	.4557	.3734
20	.4338	.4481	.5601	.4572	.4338	.5487	.6348
21	.4904	.5228	.5601	.5144	.5093	.5144	.5601
22	.415	.4668	.5228	.4572	.4904	.4458	.4854
23	.3772	.3734	.5228	.381	.4527	.3772	.4854
24	.4572	.3395	.4108	.3734	.381	.3961	.3429
Max	.724	.7545	.6722	.5144	.9054	1.2308	.8109
Min	.2172	.1372	.2347	.1143	.1698	.1629	.1494
Avg	.4347	.4139	.4775	.3215	.4004	.3825	.3938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 204 / Borsar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2075	.2241	.4481	.3429	.4338	.3429
2	.381	.2075	.1677	.4481	.3429	.4338	.3086
3	.381	.2829	.2347	.4481	.381	.4715	.3772
4	.381	.3772	.2515	.4481	.4572	.4715	.4287
5	.4763	.3772	.2515	.5601	.6097	.4904	.4287
6	.4763	.415	.4359	.7095	.6478	.4904	.6173
7	.6287	.5068	.5365	.7842	.6668	.3395	.6859
8	.6097	.543	.503	.5601	.5716	.2452	.5487
9	.5335	.543	.4527	.4481	.4191	.2401	.4115
10	.4525	.3567	.4359	.381	.3206	.2572	.3734
11	.2641		.3353	.3048	.2641	.2743	.3361
12	.2829		.2347	.3429		.3864	1.2742
13	.2829		.3734	.381		.3418	.3353
14	.3018		.4481	.3429	.3772	.2675	.4359
15	.2641		.4481	.362	.4344	.3269	.4359
16	.2829	.3086	.3361	.4572	.4525	.3864	.4359
17	.3206	.3601	.3361	.4763	.4525	.4199	.4359
18	.3961	.4115	.2801	.3429	.4525	.3567	.4694
19	.5281	.5316	.4854	.3048	.4344	.4161	.503
20	.4904	.6348	.5601	.4954	.415	.5144	.5601
21	.4715	.5415	.5601	.5335	.3395	.583	.6348
22	.3772	.4854	.4854	.4382	.3772	.4801	.4481
23	.3772	.4108	.4481	.381	.3772	.4115	.3734
24	.4572	.2829	.3734	.4481	.381	.3961	.3086
Max	.6287	.6348	.5601	.7842	.6668	.583	1.2742
Min	.2641	.2075	.1677	.3048	.2641	.2401	.3086
Avg	.4067	.4097	.3832	.4519	.4326	.3931	.4796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 205 / parsoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.2896	.381	.7468	.6859	.6979	.4801
2	.5716	.3439	.3567	.7468	.7621	.7922	.5144
3	.5716	.362	.4161	.7468	.7811	.8676	.5316
4	.5716	.4706	.4489	.8589	.8002	.9808	.6001
5	.6668	.4887	.5868	1.0456	1.1431	1.094	.7202
6	.7095	.5068	.7042	1.1203	1.2384	1.226	.8573
7	.8589	.6878	.9389	1.2323	1.1431	1.1506	1.166
8	.8775	.6878	.8383	1.1203	.724	1.0185	.9088
9	.8299	.7059	.7042	.9335	.7621	.6859	.823
10	.5973	.4607	.6706	.5906	.679	.5487	.6722
11	.5658	.4115	.5601	.4001	.5093	.535	.5601
12	.4904	.5144	.5601	.4572	.4525	.703	.503
13	.4527	.3772	.4481	.7621	.4344	.5796	.503
14	.4527	.3932	.4481	.9145	.5611	.7202	.503
15	.4715	.4458	.4481	.7811	.6516	.6661	.6706
16	.4715	.3772	.4481	.5716	.724	.743	.8383
17	.4527	.3944	.4481	.8192	.905	.7529	.8383
18	.5847	.4973	.5601	.8954	.543	.6836	.8383
19	.8676	.7373	.7468	.8573	.6154	.5053	.6706
20	.8488	.9335	1.0456	.9526	.7545	.7202	.9335
21	.8299	.8589	.9335	.9526	.811	.6687	1.0456
22	.7545	.7842	.7842	.8002	.7545	.6516	.7468
23	.679	.6908	.7468	.7621	.7167	.6173	.7468
24	.6859	.5792	.6001	.7468	.7621	.7167	.5487
Max	.8775	.9335	1.0456	1.2323	1.2384	1.226	1.166
Min	.4527	.2896	.3567	.4001	.4344	.5053	.4801
Avg	.6447	.5416	.6176	.8256	.7464	.7636	.7175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 206 / KHADI CENTER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.5281	.3018	.4024	.1905	.3206	
2	.0762	.5281	.3353	.4024	.1905	.2641	
3	.0381	.4904	.3856	.4024	.1524	.3018	
4	.0572	.4904	.2683	.4024	.1524	.2829	
5	.0381	.4527	.2515	.4024	.2286	.2829	
6	.0381	.3018	.2012	.1006	.2477	.0943	
7	.0762	.3206	.1677	.1006	.1334	.0377	
8	.0572	.2263	.0671	.1006	.1524	.0189	
9	.4572	.0566	.0671	.1006	.1524	.0819	
10	.6154	.3601	.3353	.381	.1509	.1696	
11	.3772	.4915	.3353	.4191	.1698	.0983	
12	.4527	.4588	.2347	.381	.2452	.1543	
13	.4527	.407	.3018	.2667	.3772	.1326	
14	.5658	.3772	.3353	.2667	.3584	.1715	
15	.6413	.4696	.4024	.4954	.3206	.2229	
16	.7545	.4115	.4024	.5716	.3206	.2622	
17	.4904	.3125	.4024	.5716	.2829	.3086	
18	.3772	.2458	.2683	.2096	.132	.1526	
19	.2641	.0686	.0335	.0762	.0377	.0686	
20	.2829	.0838	.0335	.1143	.0377	.1372	
21	.3206	.1174	.2347	.1905	.0377	.1783	
22	.3206	.1509	.2347	.1524	.1698	.2317	
23	.3395	.2683	.2614	.3048	.2263	.2709	
24		.3395	.2683	.2347	.2667	.2452	.213
Max	.7545	.5281	.4024	.5716	.3772	.3206	.213
Min	.0381	.0566	.0335	.0762	.0377	.0189	.213
Avg	.3117	.3316	.2554	.2938	.1972	.1871	.213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 201 / Babhulgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4477	.4527	.5601	.3429	.3281	.4458	.3593
2	.4784	.5658	.5601	.3688	.3637	.5144	.3906
3	.5552	.6413	.6036	.3688	.3681	.583	.4801
4	.6335	.7167	.7922	.426	.4049	.6173	.506
5	.7522	.811	.8962	.4858	.4641	.6859	.5601
6	.9593	.9431	.9808	.5344	.5506	.7202	.6483
7	1.0059	.8676	.7762	.583	.6316	.823	.7362
8	.8145	.7356	.7282	.6154	.7209	.7373	.7449
9	.6447	.5847	.6413	.5668	.583	.6859	.7202
10				.4534	.4961	.6173	.5668
11	.5847			.4298	.4715	.4904	.5228
12	.6859	.5556	.6464	.3898			.4108
13	.6344	.5851	.6036	.3856	.4338	.415	.3734
14	.6001	.5761	.5533	.3898	.415	.4108	.4294
15	.583	.4999	.503	.3856	.3961	.3961	.4668
16	.5487		.4527	.3898	.4338	.4481	.5041
17	.7202	.4531	.503	.4477	.4668	.4715	.5601
18	.5316	.5851	.57	.4784	.547	.5281	.5975
19	.5487	.6325	.5735	.6878	.6602		
20	.8676	.7922	.7682	.823	.7922	.9054	.8048
21	.7733	.6908	.6584	.6878	.7545	.7842	.6584
22	.6979	.6602	.5853	.591	.6413	.6413	.6348
23	.6224	.6224	.5121	.4656	.5281	.5658	.5975
24	.3898	.3961	.5658	.4108	.4252	.4338	.5281
Max	1.0059	.9431	.9808	.823	.7922	.9054	.8048
Min	.3898	.3961	.4527	.3429	.3281	.3961	.3593
Avg	.6556	.6366	.6379	.4878	.5164	.5873	.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 202 / Rahegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.2641	.4338	.3086	.2812	.3258	.3086
2	.3582	.3584	.4294	.3944	.2846	.3429	.3479
3	.4119	.3772	.4527	.3856	.3201	.3601	.3749
4	.4525	.415	.4904	.4191	.3361	.4458	
5	.6219	.4338	.5847	.4424	.3887	.5487	
6	.7316	.4527	.7167	.5182	.421	.6173	
7	.5068	.3772	.6036	.4858	.5735	.6687	.4534
8	.4835	.3961	.5601	.4534	.5668	.6001	.5601
9	.4298		.4338	.426	.4001	.5144	.4428
10	.3544			.3887	.3841	.5144	.3681
11	.3018						
12	.3772	.25	.4191				.1867
13	.4458	.2778	.3688		.3018		.2241
14	.3429	.2812	.3353	.2303	.3018	.2075	.1867
15	.3601	.2812	.3688	.2328	.2641	.2263	.1867
16	.3772	.2812	.4024	.2328	.2829	.2075	.2241
17	.4287		.3856	.2658	.2829	.1698	.2241
18			.3521	.3045	.3018	.1886	
19		.3479			.5093		
20	.6224	.5658	.5121	.5973	.547	.4904	.439
21	.5658	.6036	.5853	.5014	.5093	.4481	.5487
22	.4527	.5093	.4938	.394	.4904	.4338	.4854
23	.3584	.4715	.4108	.3366	.3395	.3772	.3734
24	.298	.2263	.4338	.3547	.3366	.2452	.3361
Max	.7316	.6036	.7167	.5973	.5735	.6687	.5601
Min	.298	.2263	.3353	.2303	.2641	.1698	.1867
Avg	.4364	.3774	.4654	.3836	.3829	.3966	.3484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 203 / Nalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1715	.1562	.1886	.1595	.1698	.2075
2	.1423	.2058	.1898	.2263	.1791	.2263	.2054
3	.16	.2058	.192	.2241	.2126	.2452	.2075
4	.1581	.2641	.2187	.2801	.2149	.2641	.2452
5	.192	.2572	.2688	.3109	.2328	.3018	.3174
6	.2515	.2743	.3005	.3841	.2715	.415	.415
7	.3113	.3601	.3887	.3292	.2507	.3772	.3174
8	.2753	.3772	.3887	.2987	.2328	.3018	.3018
9	.2401	.3258	.3681	.2801	.2126	.1886	.2641
10	.2056		.2591	.2241	.1417		.2263
11	.1509	.1509	.1307	.1417	.1509	.0943	
12	.1132	.1509	.0943	.2846	.3206	.2656	.3086
13		.132	.0754	.3077	.2829	.2846	.3018
14	.1132	.132	.0754	.2753	.2829	.2372	.3353
15	.1132	.1307	.0943	.2785	.2641	.2343	
16	.1132		.0943	.2683	.2572	.2372	
17	.132		.132	.285		.2881	.3018
18	.1509	.132		.2721	.2743	.1698	.3018
19	.2452		.2614	.2915	.2401	.2688	.3353
20	.2641	.2452	.2926	.2743	.2829	.3018	.3109
21	.2452	.2263	.2427	.2328	.3018	.2801	.2378
22	.2263	.2241	.2241	.2126	.2452	.2263	.2614
23	.1886	.2075	.1867	.2126	.2263	.2427	.2614
24	.1063	.1509	.1886	.1867	.1578	.1509	.2263
Max	.3113	.3772	.3887	.3841	.3206	.415	.415
Min	.1063	.1307	.0754	.1417	.1417	.0943	.2054
Avg	.1836	.2162	.2097	.2612	.2346	.2509	.2805

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 204 / AMANSPURWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.3086	.2778	.2614	.2481	.2452	.2987
2	.3201	.3429	.2846	.2987	.2865	.2829	.3018
3	.3521	.4115	.3201	.3361	.3012	.3018	.3772
4	.3887	.5144	.3479	.3921	.3403	.3584	.4338
5	.4858	.6001	.4801	.4207	.3721	.415	.5093
6	.5601	.6344	.5506	.4572	.4298	.547	.6099
7	.6154	.7202	.7773	.5121	.5121	.4904	.4715
8	.9503	.7716	.7287	.4207	.3582		.4715
9	.8421	.8573	.7127	.3174	.2686		.3584
10	.6562	.3429	.6401	.2987	.2303		.3018
11	.3395	.2829	.2241	.2303	.2263		.2427
12	.3018	.2452	.1494	.4902	.3086		.3429
13	.3018		.1494	.7773	.3429		
14	.3018		.132	.639		.5121	
15	.3018		.1509	.4801		.6478	
16	.3395	.1509	.1698	.421	.3429		.8907
17		.1867		.3681	.3429	.6958	.8421
18		.2263		.2846	.7888		.8097
19	.3018	.2641	.3361		.6173	.4428	.7773
20	.4338	.3018	.4755	.3189	.415	.4108	.5121
21	.3961	.3206	.3841	.2865	.3961	.3961	.4024
22	.3395	.2829	.3475	.2658	.3772	.3772	.4108
23	.2641	.2427	.2987	.2103	.3018	.3395	.2987
24	.2126	.2263	.2263	.2801	.2279	.2263	.3018
Max	.9503	.8573	.7773	.7773	.7888	.6958	.8907
Min	.2126	.1509	.132	.2103	.2263	.2263	.2427
Avg	.4223	.3921	.3711	.3812	.3652	.4181	.4745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 205 / dhondalgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.2641	.3206	.3086	.2846	.3086	.2031
2	.3224	.3584	.3361	.3429	.3125	.3258	.2372
3	.3403	.3961	.3395	.3856	.3321	.3429	.2881
4	.4163	.4338	.4527	.4191	.3681	.4115	.3201
5	.4572	.5281	.5228	.4588	.4049	.4801	.3521
6	.5792	.6979	.6036	.502	.4321	.5487	.4534
7	.567	.6036	.5093	.5344	.4534	.703	.5992
8	.4525	.4715	.415	.5668	.5407	.6516	.6154
9	.3761	.3584	.3772	.502	.4534	.5316	.5601
10	.3403	.3018	.3395	.3563	.4001	.463	.5182
11	.3395	.2829		.2481	.2829	.3395	.3547
12	.4458	.427	.2515	.2507	.3018	.2427	.2614
13		.4111	.2683	.2328	.3206	.2641	
14	.4973	.4161	.2515	.2481	.2641	.2641	
15	.4801	.3906	.2515	.2454	.2263	.2641	
16	.4287	.4111	.2347	.2658	.3018	.2641	
17	.5144	.4481		.3045	.3018	.2641	.2987
18	.5144	.427			.3206	.2829	.3658
19	.3429		.5571		.415	.4294	.439
20	.547	.4527	.3841	.567	.4904	.4715	.5487
21	.4904	.415	.4755	.4706	.4527	.4338	.4755
22	.415	.3772	.4024	.3761	.415	.3961	.4294
23	.3395	.3395	.3734	.3045	.3361	.3772	.3601
24	.2804	.2263	.3206	.3174	.3012	.2452	.3772
Max	.5792	.6979	.6036	.567	.5407	.703	.6154
Min	.2804	.2263	.2347	.2328	.2263	.2427	.2031
Avg	.4248	.4104	.3803	.3731	.3630	.3877	.4029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 206 / sanjarpurwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562	.2058	.1235	.2263	.1417	.2263	.2054
2	.1739	.2229	.1562	.2641	.1772	.2263	.2075
3	.208	.2401	.1562	.2614	.1791	.2452	.2263
4	.2267	.2743	.2372	.3174	.1949	.2641	.2829
5	.2561	.3258	.2561	.3734	.2328	.3018	.3361
6	.3887	.3772	.2688	.4024	.2353	.3772	.4338
7	.6081	.6001	.5121	.3475	.2715	.3772	.4527
8	.7537	.6516	.5182	.3174	.2149	.3206	.3961
9	.4858	.583	.5407	.2801	.197	.1886	.3206
10	.4321	.4801	.4049	.2241	.1595	.1509	.2427
11	.1509	.1132	.1307	.1417	.1132	.1509	.1867
12	.1509	.0754	.0943	.3681	.1509	.3749	.4458
13	.1509	.0754	.0943	.4372		.4111	.4694
14	.1132	.0943	.1132			.3281	.4191
15	.1132	.1132	.1132	.4096	.1715	.3201	.4527
16	.1132	.1132	.132	.3887	.3772	.3593	.4191
17	.132	.1307	.132	.4001	.4115	.3681	.4424
18	.1509	.1867	.168		.5144		.4588
19	.2452	.2263	.1867	.3041	.4801	.3201	.4915
20	.3206	.3018	.3361	.2507	.2829	.3206	.3292
21	.3018	.2829	.2987	.2353	.3206	.2829	.2743
22	.2452	.2452	.2614	.2126	.2829	.2641	.2801
23	.2263	.2263	.2241	.1753	.2263	.2452	.2427
24	.1578	.1698	.2075	.2241	.1402	.1886	.2263
Max	.7537	.6516	.5407	.4372	.5144	.4111	.4915
Min	.1132	.0754	.0943	.1417	.1132	.1509	.1867
Avg	.2609	.2631	.2361	.2983	.2489	.2875	.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 201 / 11 KV GARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2801	.2818	.2801	.2572	.4239	.2883
2	.2241	.2543	.3174	.3292	.2743	.4239	.3475
3	.2801	.2543	.2622	.3658	.2915	.4668	.3481
4	.4481	.3391	.3113	.439	.3121	.5087	.3841
5	.5601	.3391	.3801	.5228	.3467	.5658	.431
6	.6722	.4715	.3315	.5601	.3856	.6602	.5281
7	.5228	.4715	.362	.5853	.3688	.6602	.6348
8	.4668	.5658	.3561	.5068		.5935	.4858
9	.4207	.4715		.567	.2743	.5087	.4424
10	.3174	.3772	.3041	.2241	.3856	.3052	.3932
11		.3391	.2614		.2801	.3772	
12	.3258	.3391	.2241		.2614	.3174	
13	.3772		.1829	.2054	.2801	.2241	
14	.3772		.1463	.1867	.2515	.2172	
15	.3772	.3277	.1463	.1867	.2829	.2715	.3734
16		.2883	.1848		.2263	.3077	.4481
17	.4715	.2105	.2218	.2801	.2515		.4854
18	.3772	.2321	.2801	.2614	.2263		.5175
19	.2829	.2012	.3224	.3734	.2829	.4534	.415
20	.5601	.2195	.3582	.4108	.3734	.4748	.4298
21	.4191	.2374	.4572	.5601	.3391	.4755	.5014
22	.3734	.2429	.4108	.3734	.2515	.3521	.3547
23	.3772	.2561	.3921	.2801	.3772	.3239	.3292
24	.2801	.3772	.3475		.2241	.3772	.2801
Max	.6722	.5658	.4572	.5853	.3856	.6602	.6348
Min	.2241	.2012	.1463	.1867	.2241	.2172	.2801
Avg	.3979	.3225	.2975	.3749	.2958	.4222	.4209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 202 / 11 KV MANOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.4715	.3978	.4481	.3258	.4239	.5121
2	.3734	.4715	.431	.4481	.3429	.4715	.4424
3	.4108	.4715	.4641	.4854	.3772	.4715	.4938
4	.5601	.5658	.5601	.5175	.4287	.5658	.4755
5	.823	.5658	.5197	.7095	.4359	.5935	.4755
6	.9036	.6602	.415	.6653	.4801	.7545	.4525
7	.7682	.6602	.5041	.7842	.463	.763	.6299
8	.6733	.6602	.4409	.7468		.8488	.567
9	.5138	.5658	.3856	.7095	.6203	.7545	.3201
10	.4075	.5087	.415	.2801		.2035	.3403
11	.3174	.3395	.2753	.3361		.1886	
12	.2915	.3395	.3961	.3174		.3292	
13	.2829		.3292	.2987	.3772	.4163	.3881
14	.2829		.3174	.2801	.3772	.3239	.4481
15	.2035	.5344	.2801	.2241	.3807		.5121
16	.3772		.2587	.2427	.2829	.3563	.3982
17	.3772	.3521	.2427	.3734	.3772	.4572	.3582
18	.2829	.3768	.2614	.3547	.2515		.394
19	.2713	.3201	.2987	.5041	.2543	.7291	.6219
20	.6443	.3361	.3696	.7316	.4715	.8402	.5975
21	.5658	.3605	.4435	.8779	.5658	.7316	.5792
22	.5087	.3725	.5228	.7973	.5658	.6767	.6805
23	.4715	.3978	.5544	.695	.5658	.5182	.5228
24	.3734	.4239	.5228		.4668	.5658	.4108
Max	.9036	.6602	.5601	.8779	.6203	.8488	.6805
Min	.2035	.3201	.2427	.2241	.2515	.1886	.3201
Avg	.4592	.4645	.4003	.5142	.4205	.5447	.4828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 203 / 11 KV POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2801	.5087	.6348	.4668	.5601	.502
2	.3601	.2829	.6161	.6653	.4854	.5087	.6154
3	.3772	.2829	.6299	.6283	.5601	.7468	.7682
4	.4024	.3772	.7773	.6348	.7095	.7545	.9145
5	.4359	.3772	1.1142	.7207	.9335	.9431	1.0814
6	.4527	.3772	1.4575	.7842	1.0985	1.1317	1.2266
7	.4359	.4715	.9328	.8215	1.0631	1.1022	1.0974
8	.4191	.4715	.695	.7577		1.226	.8215
9	.4024	.2829	.5975	.6722	.5041	1.1317	.5596
10	.2572	.2829	.5281			.2035	
11	.1867	.1867	.285	.3292	.2427	.1886	
12	.168	.1886	.415	.1886	.3353	.2622	
13	.1696		.4481	.2229	.4715	.3239	.2427
14	.1696		.4805	.2058	.4715	.3391	.2561
15	.1886	.1943	.5228	.1907	.4715	.2561	.3292
16	.2829	.1658	.4668	.2279	.3772	.1991	.3696
17	.2829	.144	.3881	.1715	.3772		.4066
18	.5601	.2622	.4108	.1715	.3772	.2622	.4481
19	.6602	.3978	.3734	.156	.3734	.2294	.3696
20	.7545	.407	.4481	1.0974	.6535	.2721	.4108
21	.6602	.4525	.4854	1.0277	.6602	.3391	.4755
22	.6602	.4938	.5415	.8859	.5935	.3768	.5601
23	.5658	.5121	.6348	.7316	.5087	.431	.4706
24	.695	.5658	.6653		.5601	.5658	.4481
Max	.7545	.5658	1.4575	1.0974	1.0985	1.226	1.2266
Min	.168	.144	.285	.156	.2427	.1886	.2427
Avg	.4118	.3390	.6009	.5421	.5588	.5371	.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 201 / biloni SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.3429	.4096	.5281	.5281	.5281	.5847
2	.1677	.3467	.4424	.5281	.5281	.5281	.5847
3	.1989	.3429	.4588	.5658	.5658	.547	.5847
4	.2294	.3429	.4915	.6036	.679	.5658	.6036
5	.2622	.3429	.5935	.6413	.7167	.5658	.6036
6	.3239	.4607	.6783	.7167	.7545	.7545	.6036
7	.4586		.763	.6413	.7167	.811	.6036
8	.4999	.7335	.7449	.5658	.7167	.6413	.6036
9	.4586		.373	.5281		.2829	.4904
10	.423	.4108	.4372		.4904		.4527
11	.2829		.3206	.415	.3395	.2641	.2829
12	.2829	.2587	.3206	.5944	.3155	.2949	.6019
13	.3547	.2587	.3395	.5468	.3525	.3688	.5247
14	.3395	.2957	.3584	.0625	.1334	.4024	.5247
15	.3395	.2957	.3584	.0655	.3807	.4359	.5093
16	.3206	.3326	.3277	.0655	.4161	.4694	.5556
17	.4854	.3772	.3772	.5407	.503	.5201	.6327
18		.4527	.415	.5898	.4287	.5028	.7316
19		.5601	.415	.6554	.4268	.4801	.6554
20		.8215	.6036	.6413	.6602	.6413	.679
21	.3584	.7842	.6036	.6413	.6413	.6413	.679
22	.4338	.7545	.5847	.5658	.6413	.6036	.6602
23	.3961	.679	.547	.5281	.5847	.6036	.6602
24	.5093	.3772	.5658	.5281	.5281	.5281	.6036
Max	.5093	.8215	.763	.7167	.7545	.811	.7316
Min	.1677	.2587	.3206	.0625	.1334	.2641	.2829
Avg	.3473	.4558	.4804	.5113	.5238	.5209	.584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 202 / jarul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4715	.5601	.2683	.2561	.2984	.4321
2	.4904	.4715	.5601	.2683	.2561	.3018	.4321
3	.4904	.4715	.5601	.2984	.2881	.3353	.4321
4	.5093	.4904	.5601	.2984	.2812	.3353	.463
5	.5093	.4904	.5788	.3277	.3125	.3688	.6249
6	.5281	.4904	.5975	.3605	.381	.503	.703
7	.4338		.5975	.5182	.5944	.7343	.8592
8	.3584	.4481	.5228	.6325		.7316	.7186
9	.3018			.3077		.4988	.5182
10		.3109	.3206		.2976		.4784
11	.2241		.2452	.1867	.2835		.2075
12	.2534	.2195	.3277	.1886	.3258	.156	.2829
13	.2469	.2469	.426	.2241	.3658	.2774	.2829
14	.2743	.282	.4588	.2587	.2715	.2774	.3018
15	.2743	.3102	.2984	.2772	.2926	.3189	.3584
16	.2591	.306	.3277	.2772	.3292	.3544	.3772
17	.1858	.2976	.3605	.3326	.4024	.3982	.415
18	.2721	.2976	.2622	.4805	.462	.4938	.3961
19		.3201	.4752	.4805	.4805	.5914	.547
20		.5975	.7356	.5544	.5914	.6283	.679
21	.5788	.5975	.679	.5914	.6838	.6283	.679
22	.5788	.6161	.6413	.5914	.6468	.6348	.6602
23	.5415	.6348	.6036	.5729	.6535	.6348	.6602
24	.6224	.5041	.6348	.2683	.5544	.6348	.5788
Max	.6224	.6348	.7356	.6325	.6838	.7343	.8592
Min	.1858	.2195	.2452	.1867	.2561	.156	.2075
Avg	.4011	.4226	.4928	.3724	.4096	.4607	.5037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 203 / lakh khandala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584		.2263	.2347	.1875	.2267	.2743
2	.3584		.2263	.2347	.1875	.2429	.2743
3	.3584		.2263	.2683	.2187	.2622	.2743
4	.3961		.2452	.2683	.3125	.2622	.3048
5	.415		.2641	.2984	.3749	.2949	.3953
6	.4904		.2829	.3149	.3963	.4641	.4744
7	.3395		.3206	.4534	.5937	.6706	.6325
8	.2452		.2641	.427	.6249	.7977	.7907
9	.2263		.2263	.3725		.5944	.6001
10	.1509	.2241	.1132		.3111	.3681	.4904
11	.132		.1132	.0943	.0724	.0747	.1132
12	.3018	.2366	.426	.0943	.0943	.112	.1509
13	.2761	.2629	.4696	.132	.1509	.1494	.1509
14	.2841	.2934	.3932	.1867	.132	.1494	.1509
15	.2881		.426	.2241	.1109	.1494	.1886
16	.3382	.3246	.426	.2241	.1294	.1867	.1886
17		.3517	.3932	.2801	.1829	.1867	.1886
18	.2477	.3841	.3441	.2801	.2012	.2033	.1509
19		.3246	.3605	.2054	.2957	.2218	.2452
20		.3206	.3961	.3772	.3018	.3584	.3772
21		.3206	.3772	.3772	.3772	.3584	.3772
22		.3395	.3772	.3772	.3772	.3584	.3772
23		.3395	.3584	.3584	.3772	.3584	.3772
24	.3584		.3584	.2347	.3584	.3584	.3584
Max	.4904	.3841	.4696	.4534	.6249	.7977	.7907
Min	.132	.2241	.1132	.0943	.0724	.0747	.1132
Avg	.3092	.3102	.3173	.2747	.2769	.3087	.3294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-18 and 14-JUN-18

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044109 / 33 KV Khandala

Feeder No / Name : 201 / 11 KV JANEFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JUN-18	09-JUN-18	10-JUN-18	11-JUN-18	12-JUN-18	13-JUN-18	14-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.1886	.2075	.1311	.1475	.1802	.1638
2	.2452	.1886	.1886	.1638	.1638	.1966	.1802
3	.2641	.2075	.2263	.1638	.1802	.1966	.213
4	.2829	.2263	.2452	.1638	.1966	.2458	.2458
5	.2829	.2641	.2452	.1966	.2458	.2458	.2785
6	.3018	.2829	.2263	.2294	.2785	.2622	.3277
7	.3395	.2641	.2263	.2458	.2949	.2949	.3441
8	.2263	.2452	.1886	.213	.2622	.3113	.3605
9	.1886	.2263		.1802	.1638	.2622	.3768
10	.1509	.1886	.132	.1802	.1638	.1966	.3441
11	.1132	.1886	.1132	.0943	.1132		.1132
12	.2622	.2622	.1638	.0943	.1132		.132
13	.2294	.2458	.1966	.1132	.132	.0754	.0754
14	.213	.2458	.1802	.1698	.1132	.0754	.0943
15	.1966	.2622	.1638	.1698	.0943	.0754	.0943
16	.2294	.2785	.1638		.1132	.0943	.1132
17		.2949	.1966		.132	.1132	.132
18		.2622	.213		.1509	.1132	.132
19		.2294	.2458		.1509	.2452	.1509
20		.1886	.2829	.1698	.1886	.2829	.1698
21	.2452	.2263	.2641	.2829	.2075	.2641	.3018
22	.2641	.2452	.2452	.2641	.2263	.2452	.2641
23	.2452	.2263	.2075	.2641	.2263	.2452	.2641
24	.2263	.2263	.2641	.1886	.2452	.2075	.2075
Max	.3395	.2949	.2829	.2829	.2949	.3113	.3768
Min	.1132	.1886	.1132	.0943	.0943	.0754	.0754
Avg	.2376	.2360	.2081	.1839	.1793	.2013	.2116