

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.9145	.6478	.6287		.5335
2		.6668	.9145	.6097	.6478		.5716
3		.6287	.8383	.5716	.6668		.5716
4		.6097	.7621	.5716	.6478		.5906
5		.6859	.6859	.6097	.6097		.6097
6		.724	.6097	.6478	.6478		.6097
7		.6668	.6097	.6478	.6859		.5906
8		.5716	.5906	.7621	.6668		1.0288
9	.9145	1.1241	.6478	.8764	.9907	.724	1.1812
10	1.0479	1.1431	.724	.9907		.724	1.2955
11	1.2955	1.1812	.9526	.9717		.7621	1.2955
12	1.4289	1.2193	1.2193	.9145		.8002	1.3336
13	1.0669	1.2384	1.1431	.8383		.8383	1.2955
14	.9907	1.2574	.8764	.7621		.8764	1.2193
15	1.0479	1.2574	.9145	.724		.9145	1.1812
16	1.1431	1.2765	.9526	.7049		.9145	1.2003
17	1.105	1.2574	.9526	.6668		.8383	
18	1.0669	1.2193	.8954	.6478		.7621	1.1431
19	.9145	1.1812	.8764	.5906		.6859	1.1812
20	.8192	1.1812	.7621	.6668		.6097	1.1431
21	.8002	1.1431	.8002	.6287		.6097	1.105
22	.8002	1.1431	.8383	.6287		.5716	.9526
23	.724	1.1431		.6478		.5716	.8764
24	.8002	.6668	1.0669	.6859	.6668	.5335	.5335
Max	1.4289	1.2765	1.2193	.9907	.9907	.9145	1.3336
Min	.724	.5716	.5906	.5716	.6097	.5335	.5335
Avg	.9979	.9931	.8499	.7089	.6859	.7335	.9584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV N. DATTA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362	.3429	.381	.3048		.2286
2		.3429	.3429	.3429	.2858		.2286
3		.3429	.3429	.3429	.2858		.2667
4		.3239	.3429	.3429	.2858		.2667
5		.3429	.3048	.3048	.2858		.3048
6		.381	.3048	.3048	.3048		.3048
7			.3048	.3048	.3429		.3048
8		.3239	.3048	.3429	.4001		.381
9	.4954	.4572	.4572	.381	.4382	.5335	.381
10	.6859	.6097	.6478	.3429		.5335	.6859
11	.724	.6859	.8002	.3429		.4572	.7621
12	.7811	.6859	1.0288	.381		.4572	.8383
13	.9145	.7621	.9526	.362		.381	.8002
14	.8764	.7621	.8383	.381		.381	.7621
15	.8383	.8383	.9145	.4191		.3048	.7621
16	.8002	.8383	1.1431	.4382		.3048	.7621
17	.7621	.7621	1.0288	.4191		.3048	.7621
18	.7621	.7621	.7621	.4382		.3048	.724
19	.6859	.6859	.6859	.4191		.3048	.743
20	.6097	.6859	.5716	.4572		.3048	.6478
21	.5335	.6097	.5335	.4382		.3048	.6097
22	.5144	.5716	.5335	.381		.3048	.5716
23	.4763	.381		.3429		.2667	.5335
24	.4572	.381	.381	.4191	.3239	.4572	.2286
Max	.9145	.8383	1.1431	.4572	.4382	.5335	.8383
Min	.4572	.3239	.3048	.3048	.2858	.2667	.2286
Avg	.6823	.5608	.6030	.3762	.3258	.3691	.5358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.381	.3429	.3429		.381
2		.4001	.381	.3429	.362		.3429
3		.4191	.4572	.3429	.3429		.3429
4		.4382	.4572	.3429	.3239		.3048
5		.4572	.4572	.3429	.362		.3429
6		.4954	.5335	.381	.4191		.381
7		.4763	.5335	.381	.4572		.381
8		.5335	.5335	.381	.4954		.8383
9	.5716	.6287	.6859	.381	.7811	.6097	.9145
10	1.105	.6859	.8002	.4191		.6097	.9526
11	1.2574	.7621	.8764	.4572		.6859	1.0288
12	1.3908	.8383	.9145	.4382		.6859	.9907
13	.9335	.9145	.9145	.362		.6859	.9526
14	.9526	.9145	.9145	.4191		.7621	.8764
15		.9907	.9526	.4191		.7621	.8764
16	1.105	.9907	.9907	.4572		.7621	.8383
17	1.0669	1.0669	.9145	.4191		.6859	.7621
18	.6859	.9907	.7621	.381		.6859	.724
19	.6859	.9145	.6859	.381		.6097	.6859
20	.5335	.8383	.6478	.381		.5335	.6478
21	.4954	.7621	.5335	.4001		.5335	.5335
22	.4572	.6859	.381	.381		.4572	.4572
23	.4191	.4191		.3429		.4191	.381
24	.7621	.4382	.381	.3429	.3429	.5335	.381
Max	1.3908	1.0669	.9907	.4572	.7811	.7621	1.0288
Min	.4191	.4001	.381	.3429	.3239	.4191	.3048
Avg	.8281	.6867	.6561	.3850	.4229	.6264	.6382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1905	.1905	.2096		.1905
2		.2096	.1905	.1905	.2096		.1905
3		.1905	.2286	.1715	.1905		.2286
4		.2286	.2286	.1715	.1905		.2667
5		.2286	.2667	.1715	.2286		.3048
6		.2858	.3048	.1905	.2667		.3239
7		.2858	.3048	.2477	.3239		.3429
8		.3239	.3239	.2477	.362		.3048
9	.2286	.3239	.2858	.2477	.3239	.2667	.2858
10	.2858	.3429	.2858	.2477		.2667	.3048
11	.3048	.3429	.2858	.2286		.2477	.3239
12	.2477	.3239	.2858	.2286		.2477	.3239
13	.2667	.3048	.2667	.2286		.2477	.3429
14	.2477	.3048	.2477	.2096		.2286	.381
15	.2286	.2858	.2667	.2096		.2286	.381
16	.2477	.2667	.2667	.2096		.2286	.381
17	.2667	.2858	.2286	.2286		.2667	.381
18	.2667	.3048	.2286	.2477		.2858	.381
19	.3048	.3048	.2286	.3048		.3048	.362
20	.2667	.2858	.3048	.2858		.3239	.3429
21	.2477	.2667	.3048	.2858		.2858	.3048
22	.2477	.2477	.2667	.2477		.2667	.2667
23	.2096	.2286		.2286		.2286	.2477
24	.2667	.2096	.2096	.2286	.2096	.2286	.2096
Max	.3048	.3429	.3239	.3048	.362	.3239	.381
Min	.2096	.1905	.1905	.1715	.1905	.2286	.1905
Avg	.2584	.2747	.2609	.2270	.2515	.2596	.3072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4382	.4572	.381	.2667		.2286
2		.4382	.4572	.381	.2858		.3048
3		.4572	.381	.3429	.2667		.3048
4		.4191	.381	.3429	.2667		.3048
5		.4572	.381	.3429	.2667		.381
6		.4954	.4572	.381	.2858		.381
7		.4763	.4572	.4572	.3048		.381
8		.5144	.4572	.4572	.3048		.4572
9	.4572	.5335	.5335	.4572	.4763	.5335	.4572
10	.9145	.6097	.6478	.4572		.5335	.724
11	.9907	.6859	.9145	.4572		.5335	.9145
12	1.1241	.6859	.9145			.4572	1.0669
13	.9907	.7621	.9907	.381		.4572	1.105
14	.9526	.8383	.9145	.4191		.4572	1.1812
15	1.2384	.9145	.9145	.4572		.381	1.2193
16	1.2574	.9145	.9145	.4191		.381	1.2193
17	1.1812	.9145	.8002	.381		.381	1.1431
18	.9145	.7621	.7621	.362		.381	1.1431
19	.8383	.7621	.6859	.3239		.3048	1.0669
20	.8002	.7621	.5716	.3048		.3048	.8764
21	.5716	.6859	.5335	.2858		.3048	.7621
22	.4954	.6859	.4572	.2858		.3048	.6097
23	.4954	.5335		.3048		.2286	.4572
24	.5335	.4572	.5335	.4191	.2667	.5716	.2286
Max	1.2574	.9145	.9907	.4572	.4763	.5716	1.2193
Min	.4572	.4191	.381	.2858	.2667	.2286	.2286
Avg	.8597	.6335	.6312	.3827	.2991	.4072	.7049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7909	2.0195	1.829	1.829		2.0576
2		1.7528	2.0005	1.829	1.8099		2.0195
3		1.7528	1.9814	1.829	1.7909		2.0005
4		1.7909	1.9433	1.7909	1.8099		2.0195
5		1.8099	2.0005	1.7909	1.829		2.0576
6		1.8671	2.0576	1.829	1.9814		2.0957
7		1.9814	2.0957	1.9243	2.0386		2.1719
8		1.9243	2.0957	1.9433	2.0767		2.0576
9	1.9433	1.9433	2.1338	1.9433	2.0957	1.9433	2.0386
10	2.0386	1.9814	2.21	1.9433		1.9433	2.21
11	2.2481	2.0576	2.2481	1.9624		1.9624	2.2862
12	2.2862	2.0957	2.2862	2.0005		1.9814	2.4196
13	2.2862	2.1338	2.2862	2.0576		2.0005	2.4768
14	2.3053	2.191	2.2862	2.0386		1.9814	2.4387
15	2.2862	2.21	2.3243	2.0386		1.9814	2.4768
16	2.3434	2.21	2.3434	2.0576		1.9624	2.4958
17	2.3815	2.3243	2.4387	2.1338		2.21	2.6292
18	2.5911	2.4768	2.5149	2.3434		2.3624	3.0102
19	2.6863	2.7054	2.8197	2.7054		2.6292	3.2579
20	2.7435	2.6292	2.9721	2.7435		2.572	3.2007
21	2.4768	2.3815	2.5911	2.6673		2.4387	2.9721
22	2.3624	2.2862	2.4768	2.3243		2.2862	2.6292
23	2.0195	2.0957		2.0386		2.191	2.0957
24	2.4387	1.829	2.0576	1.9433	1.9243	1.829	2.0957
Max	2.7435	2.7054	2.9721	2.7435	2.0957	2.6292	3.2579
Min	1.9433	1.7528	1.9433	1.7909	1.7909	1.829	2.0005
Avg	2.3398	2.0925	2.2688	2.0711	1.9185	2.1422	2.3839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0074		.5658				
2	.0074		.5658				
3	.0074		.5281				
4	.0074		.5281				
5	.0074		.5658				
6	.0074		.5975				
7	.0073		.8215				
8	.0091	.9694	.9335	.0091	.7095	.7468	
9	.0091		.7682				
10	.7164					.0073	
11						.0073	
12		.0073				.0073	
13						.0073	
14						.0073	
15	.5853					.0073	
16		.0073			.6219	.0091	
17			.0073		.6154		
18			.0073		.6089		.0073
19		.9511	.0091		.8131		.0091
20					.7682		.011
21				.7842	.7842		.0091
22					.7922		
23	.6413	.679	.0073	.6979		.7545	.0091
24	.0073		.6036	.0073			
Max	.7164	.9694	.9335	.7842	.8131	.7545	.011
Min	.0073	.0073	.0073	.0073	.6089	.0073	.0073
Avg	.1554	.5228	.4649	.3746	.7142	.1727	.0091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0222		1.8298				
2	.0222		1.8107				
3	.0222		1.8107				
4	.0222		1.773				
5	.0219		1.8107				
6	.0222		1.9044				
7	.0238		2.1068				
8	.0238	2.1622			2.1992	1.9959	
9	.0256		2.0119				
10	1.828					.0238	
11			1.9387			.0073	
12		.0238				.0238	
13						.0238	
14						.0238	
15	1.848					.0238	
16		.0219			1.9959	.0256	
17			.0238		1.9589		
18			.0238		2.1068		.0256
19		2.4394	.0274		2.5503		.0293
20					2.5318		.0311
21				2.384	2.4949		.0311
22					2.4272		
23	2.0351	2.0911	.0274	2.1658		2.2218	.0293
24	.0219		1.8671	.0238			
Max	2.0351	2.4394	2.1068	2.384	2.5503	2.2218	.0311
Min	.0219	.0219	.0238	.0238	1.9589	.0073	.0256
Avg	.4569	1.3477	1.3547	1.5245	2.2831	.4855	.0293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0069		.3224				
2	.007		.3045				
3	.007		.3077				
4	.007		.2896				
5	.0086		.3045				
6	.0088		.3544				
7	.0088		.4161				
8	.0086	.4557	.443	.0105	.443	.3856	
9	.0086		.4508				
10	.431					.0123	
11			.4475			.0123	
12		.0123				.0123	
13						.0123	
14						.0105	
15	.3086					.0105	
16		.0105			.4359	.014	
17			.0105		.503		
18			.0105		.4858		.0123
19		.407	.0105		.4191		.0123
20					.407		.0105
21				.3944	.3944		.0105
22					.3681		
23	.3155	.3294	.0088	.3121		.3721	.0088
24	.0069		.3224	.0088			
Max	.431	.4557	.4508	.3944	.503	.3856	.0123
Min	.0069	.0105	.0088	.0088	.3681	.0105	.0088
Avg	.0872	.2430	.2669	.1815	.4320	.0935	.0109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 201 / 11 KV Vivekanand Chowk
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716				.9431		
2	.6859				.9431		
3	.6859				.9431		
4	.6859				.8573		
5	.7716				.9431		
6	.8573				.0154		
7	1.0631				1.0631		
8	1.0288				1.0631		
9	.9259	.9259	.9945	.9945			
10	.8573	.823	.8916	.9945			
11	.7888	.7716	.7545	.8916			
12	.7716	.8402	.7373	.8059			
13	.7545	.823	.6859	.7545			
14	.7202	.7545	.6859	.7373			
15	.6687	.7545	.7202	.7545			
16	.7202	.7888	.7202	.7716			
17	.7716	.823	.7202	.7716	.823	.8916	.7888
18	.8573	.8573	.7888	.823	.9259	.9259	.9431
19	1.0974	1.166	1.0974	1.0974	1.0288	1.166	1.166
20	1.0974	1.166	1.0974	1.166	1.2003	1.1488	1.166
21	1.0974	1.166	1.0631	1.1317	1.166	1.1145	1.166
22	1.0631	1.0974	1.0631	1.0288	1.1317	1.0631	1.0631
23	1.0288	1.0631	1.0288	1.0288	1.0974	1.0288	1.0117
24	.8573	.9945	.8573	1.0288	.9431	1.0631	.9259
Max	1.0974	1.166	1.0974	1.166	1.2003	1.166	1.166
Min	.6687	.7545	.6859	.7373	.0154	.8916	.7888
Avg	.8595	.9259	.8691	.9238	.9430	1.0502	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 203 / 11 KV Gandhi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716				.8573		
2	.7716				.8573		
3	.7716				.8573		
4	.7716				.7716		
5					.7716		
6	.8573				.8573		
7	.8573				.9431		
8	.9945				.9602		
9	1.286	.9259	1.166	.823			
10	1.3717	1.2346	1.3717				
11	1.5089	1.5261	1.5432				
12	1.7147	1.6461	1.6289	1.4575			
13	1.7318	1.5775	1.6804	1.3717			
14	1.6804	1.4746	1.6804	1.2003			
15	1.4232	1.4403	1.6461	1.2003			
16	1.5261	1.4746	1.6289	1.166			
17	1.6118	1.5775	1.5432	1.166	1.749	1.1317	1.7318
18	1.7147	1.7147	1.6118	1.2346	1.749	1.166	1.7833
19	2.0919	2.0233	2.0919	1.3717	1.9204	1.2003	2.3834
20	1.8861	1.9204	1.7147	1.3032	2.0233	1.1831	2.1948
21	1.6804	1.7833	1.7147	1.2346	1.7147	1.166	1.8004
22	1.2003	1.2689	1.2517	1.0288	1.4403	1.0631	1.4575
23	1.1317	1.2003	1.0288	.9431	1.0974	.9945	1.0974
24	.8573	1.0631	1.0288	1.0288	.8573	1.0288	.9088
Max	2.0919	2.0233	2.0919	1.4575	2.0233	1.2003	2.3834
Min	.7716	.9259	1.0288	.823	.7716	.9945	.9088
Avg	1.3136	1.4907	1.5207	1.1807	1.2142	1.1167	1.6697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429				.3429		
2	.3429				.3429		
3	.3429				.3429		
4	.3429				.3429		
5	.3429				.3429		
6	.3772				.4287		
7	.4287				.4458		
8	.5144						
9	.823	.4801	.6516	.5144	.4287		
10	.823	.6001	.823	.6001			
11	.8573	.7202	.9431	.6516			
12	.8916	.9259	1.0288	.7716			
13	.9431	.9259	1.0631	.8059			
14	.9259	.9431	1.0631	.8059			
15	.9431	.9431	1.0288	.7716			
16	.9259	.9602	1.046	.7888			
17	.9088	1.0288	1.0288	.7716	1.0974	.583	1.1145
18	1.0288	1.1317	1.1317	.8573	1.1317	.6173	1.2346
19	1.3032	1.3375	1.3375	.9945	1.166	.6516	1.406
20	1.166		1.2689	.9259	1.2689	.6516	1.3717
21	1.0631		1.2003	.6859	1.166	.6001	1.1488
22	.6173		.8916	.6173	1.166	.5144	.8573
23	.6173	.5487	.4801	.6001	.5144	.4287	.4801
24	.3429	.583	.5487	.4458	.4287	.4458	.3944
Max	1.3032	1.3375	1.3375	.9945	1.2689	.6516	1.406
Min	.3429	.4801	.4801	.4458	.3429	.4287	.3944
Avg	.7173	.8560	.9709	.7255	.6848	.5616	1.0009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 205 / 11 KV Hattenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859				.6859		
2	.6859				.6859		
3	.6001				.6859		
4	.6001				.6859		
5	.6001				.6859		
6	.6001				.6859		
7	.7202				.7716		
8	.7202				.8573	.7888	
9	.7202	.7545	.7202	.7545			
10	.703	.7716	.7202	.7545			
11	.703	.8059	.6859	.7202			
12	.703	.8059		.703			
13	.6859	.7716	.8402	.703			
14	.6001	.7373	.7716	.703			
15	.6344	.703	.7716	.7202			
16	.6344	.6859	.7202	.703			
17	.6687	.6859	.7202	.7202	.6859	.6516	.703
18	.6859	.7545	.9602	.7545	.7545	.7202	.7888
19	.823	.8916	1.0974	.8916	.7888	.8573	.9431
20	.823	.8916	1.0288	.8573	.8916	.8916	.8573
21	.823	.8573	.9259	.823	.8573	.8745	.8402
22	.823	.8573	.8916	.7545	.8573	.8573	.8059
23	.7888	.7888	.823	.6859	.7888	.8059	.7888
24	.6859	.7202	.7202	.7888	.6859	.7888	.7373
Max	.823	.8916	1.0974	.8916	.8916	.8916	.9431
Min	.6001	.6859	.6859	.6859	.6859	.6516	.703
Avg	.6966	.7802	.8265	.7523	.7534	.804	.8081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001				.6001		
2	.6001				.6001		
3	.6001				.6001		
4	.6001				.6001		
5	.6001				.6001		
6	.6859				.6859		
7	.8745				.7716		
8	.8745				.7545		
9	.6516	.823	.6859	.7888			
10	.6516	.7716	.6859	.7888			
11	.6344	.7716	.6516	.6859			
12	.5144	.7373	.5487	.6001			
13	.3944	.6859	.4973	.583			
14	.5487	.6001	.4973	.5487			
15	.5658	.5658	.5316	.5487			
16	.583	.583	.5316	.583			
17	.6173	.5487	.5144	.5658	.583	.6516	.583
18	.6859	.6516	.583	.583	.583	.7716	.5487
19	.7545	.8573	.7545	.7888	.6859	.7716	.9088
20	.7888	.8573	.8573	.7888	.8573	.8059	.823
21	.7545	.7888	.823	.7545	.7545	.7716	.8059
22	.7202	.7888	.7888	.7202	.7545	.7202	.7716
23	.7202	.7202	.7545	.6859	.7545	.6859	.7202
24	.6001	.6859	.6859	.7545	.6859	.7545	.6516
Max	.8745	.8573	.8573	.7888	.8573	.8059	.9088
Min	.3944	.5487	.4973	.5487	.583	.6516	.5487
Avg	.6509	.7148	.6495	.6730	.6794	.7416	.7266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4334	.2774	.2947	.2058	.6097	.6478	.5658
2	.4287	.3467	.3429	.2572	.6478	.7049	.6602
3	.4239	.4801	.463	.3772	.6859	.743	.7167
4	.4748	.6859	.5426	.4801	.8299	.7545	.8299
5	.5316	.8139	.5087	.6104	.9431	.811	.9808
6	.6344	.8478	.7712	.763	1.094	.8299	1.1694
7	.9724	.8886	.8951	.8886	1.1506	.8865	1.2449
8	1.0277	1.1768	.9503	.9054	1.0374	.9619	1.0751
9	.9339	.9724	.9175	.852	.7922	.7167	.9808
10	.6602	.6413	.5658	.6036	.3641	.3944	.4115
11	.5281	.6224	.4904	.5281	.7461	.788	.7122
12	.5093	.5281	.415	.547	.7545	.2915	.8309
13	.5658	.4904	.4338	.5093	.7377	.7377	.7969
14	.547	.4527	.4527	.4715	.78	.7545	.7377
15	.5093	.4527	.4715	.4715	.763	.7625	.7209
16	.6036	.4527	.4904	.4527	.8139	.8619	.7293
17	.6602	.5093	.4715	.4904	.8453	.8383	.8288
18	.6224	.4904	.547	.5658	.3961	.5658	.4527
19	.679	.6036	.7545	.7167	.5658	.8865	.8299
20	.7545	.8299	.7545		.8299	.8865	.8865
21	.7167	.7922	.7167		.7922	.8299	.811
22	.6859	.7545	.7545	.6859	.7811	.7733	.7356
23	.6287	.7049	.5658	.6478	.7049	.679	.6668
24	.443	.2103	.2427	.1886	.5906	.6287	.5847
Max	1.0277	1.1768	.9503	.9054	1.1506	.9619	1.2449
Min	.4239	.2103	.2427	.1886	.3641	.2915	.4115
Avg	.6239	.6260	.5755	.5554	.7607	.7389	.7900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 203 / 11KV NANDGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3048	.3048	.3018	.4854	.4681	.2774
2	.2858	.3239	.3429	.3395	.5201	.6001	.3086
3	.2858	.3429	.381	.3395	.6516	.6859	.3772
4	.3239	.3772	.4338	.415	.7545	.7373	.4458
5	.3584	.4904	.4715	.4715	.8139	.8139	.5144
6	.5093	.5658	.5281	.5281	.8478	.8551	.583
7	.5847	.6224	.5658	.547	.8718	.9389	.6859
8	.547	.547	.4338	.4904	1.0227	1.0442	.8551
9	.4338	.4527	.415	.3961	.9724	.9945	.8383
10	.823	.3772	.4115	.6415	.2075	.3018	.2452
11	1.0852	1.0227	1.0174	1.0974	.1886	.2829	.2263
12	1.1233	.2572	1.0852	1.0513	.1698	.2452	.1886
13	1.0774	.3429	1.0395	.9326	.1886	.2452	.1886
14	1.065	1.0562	1.0227	.8987	.1886	.2452	.2075
15	1.0322	1.0395	.9945	.9221	.1698	.2263	.2263
16	1.0814	1.1506	.9945	1.0111	.2075	.2263	.2263
17	1.0978	.8951	1.0774	.9945	.2075	.3018	.2641
18	.3018	.2641	.1698	.2075	.2452	.3206	.2263
19	.3772	.3395	.3395	.3772	.3395	.4338	.3206
20	.4338	.4904	.415	.4338	.415	.4527	.4715
21	.415	.4338	.3772	.415	.3772	.4338	.4338
22	.381	.3584	.3772	.381	.4001	.3772	.3772
23	.3429	.3239	.3206	.3429	.362	.3395	.3429
24	.2858	.3048	.3048	.3018	.4207	.3988	.2774
Max	1.1233	1.1506	1.0852	1.0974	1.0227	1.0442	.8551
Min	.2858	.2572	.1698	.2075	.1698	.2263	.1886
Avg	.6057	.5285	.5760	.5766	.4595	.4987	.3795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 204 / 11KV NAGZARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8718	.9259	.8402	.6001	.2667	.2667	.2452
2	.8718	1.0288	.9156	.6001	.2667	.2477	.2452
3	.9156	1.2209	1.0343	.6443	.2858	.2477	.2641
4	.9156	1.3565	1.2071	.7122	.2829	.3018	.2829
5	.9602	1.4754	1.3245	.763	.3018	.3206	.3206
6	1.1145	1.5424	1.442	.8383	.3395	.3584	.3395
7	1.5581	1.5746	1.5746	.8551	.3772	.3395	.3772
8	1.7166	1.9006	1.7204	1.0059	.2829	.2452	.2829
9	1.704	1.7368	1.6712	1.6221	.2263	.2641	.2641
10	.2263	.2263	.1886	.1886	.8309	.9665	1.0682
11	.1698	.1698	.1698	.2263	.7377	1.7238	1.7295
12	.1509	.1698	.1509	.2075	1.2431	1.7859	1.4419
13	.1886	.1509	.1509	.1509	1.5893	1.7695	1.7436
14	.1886	.1698	.1509	.1698	1.5893	1.7004	1.8233
15	.2075	.1698	.1698	.1886	1.5729	1.668	1.7736
16	.1886	.1509	.1886	.1698	1.704	1.8785	1.8842
17	.2075	.132	.1698	.1698	1.7532	1.8515	1.9334
18	.2075	.132	.1698	.1886	.1886	.1886	.1886
19	.2641	.2452	.2641	.3018	.2829	.3206	.3206
20	.3395	.3584	.3395	.3584	.3584	.3584	.3395
21	.3395	.3395	.3206	.3395	.3395	.3395	.3395
22	.3048	.3206	.3018	.3048	.3048	.3395	.3206
23	.2667	.2858	.2829	.2858	.2858	.2829	.2858
24	.8573	.7455		.6001	.2858	.2858	.2641
Max	1.7166	1.9006	1.7204	1.6221	1.7532	1.8785	1.9334
Min	.1509	.132	.1509	.1509	.1886	.1886	.1886
Avg	.6140	.6887	.6412	.4788	.654	.7521	.7533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 205 / Rajeshwari Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018	.0018	.0018	.0018
2	.0018	.0018	.0018	.0018	.0018	.0018	.0018
3	.0018	.0018	.0018	.0018	.0018	.0018	.0018
4	.0018	.0018	.0018	.0018	.0018	.0018	.0018
5	.0018	.0018	.0018	.0018	.0018	.0018	.0018
6	.0018	.0018	.0018	.0018	.0018	.0018	.0018
7	.0018	.0018	.0018	.0018	.0018	.0018	.0018
8	.0018	.0018	.0018	.0018	.0018	.0018	.0018
9	.0018	.0018	.0018	.0018	.0018	.0018	.0018
10	.0018	.0018	.0018	.0018	.0018	.0018	.0018
11	.0018	.0018	.0018	.0018	.0018	.0018	.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13	.0018	.0018	.0018	.0018	.0018	.0018	.0018
14	.0018	.0018	.0018	.0018	.0018	.0018	.0018
15	.0018	.0018	.0018	.0018	.0018	.0018	.0018
16	.0018	.0018	.0018	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	.0018
18	.0018	.0018	.0018	.0018	.0018	.0018	.0018
19	.0018	.0018	.0018	.0018	.0018	.0018	.0018
20	.0018	.0018	.0018	.0018	.0018	.0018	.0018
21	.0018	.0018	.0018	.0018	.0018	.0018	.0018
22	.0018	.0018	.0018	.0018	.0018	.0018	.0018
23	.0018	.0018	.0018	.0018	.0018	.0018	.0018
24	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Max	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0018	.0018	.0018	.0018	.0018	.0018	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 206 / harangul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5426	.6516	.6344	.5487	.4572	.4382	.4572
2	.5365	.7545	.7716	.6516	.4954	.4954	.5144
3	.5935		.9496	.6783	.5716	.5906	.6097
4	.6706	1.1869	1.153	.8309	.8002	.743	.7621
5	.8048	1.2742	1.2574	.9221	.9526	.8764	.9145
6	.8916	1.3413	1.3413	1.073	1.0669	.9907	1.0669
7	1.5432	1.3592	1.3757	1.2597	1.1431	1.105	1.2574
8	1.6095	1.5729	1.4255	1.3592	1.0669	1.0669	1.1812
9	1.4582	1.3592	1.3927	1.3927	.8764	.9526	1.105
10	.6668	.724	.5335	.5144	.7202	.7461	.8817
11	.5144	.5335	.3429	.381	1.094	1.2266	1.1869
12	.4763	.4191	.2667	.3239	1.1934	1.3108	1.3077
13	.4001		.2858	.2858	1.3077	1.3108	1.3413
14	.362	.3429	.3048	.3048	1.2597	1.3108	1.326
15	.3048	.3048	.3239	.3429	1.2929	1.3108	
16	.2858	.362	.3429	.4001	1.3435	1.3108	1.1797
17	.6097	.381	.381	.4191	1.3763	1.3763	1.3108
18	.6478	.4572	.4191	.4572	.4382	.5716	.4191
19	.6859	.5716	.6097	.6478	.6097	.7621	.7621
20	.724	.6668	.724	.7621	.743	.8383	.724
21	.5716	.743	.6097	.6859	.6478	.6859	.6478
22	.4954	.5144	.5335	.5716	.5906	.5335	.4763
23	.4191	.381	.381	.4572	.4382	.4763	.4382
24	.5426	.5201	.5487	.4801	.4191	.4001	.4572
Max	1.6095	1.5729	1.4255	1.3927	1.3763	1.3763	1.3413
Min	.2858	.3048	.2667	.2858	.4191	.4001	.4191
Avg	.6815	.7464	.7045	.6563	.8710	.8929	.8838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.1848					
6						.4694	
7		.3326				.5365	
8	.3086				.583	.5967	
9	.2957		.2058	.2229	.2401	.6173	.6859
10	.3978						
11	.57						
12	.5967						
15	.547						
16	.6796		.583	.5144	.0686	.0686	
17							.0747
19							.2587
23	.12						
24	.1029	.1294			.0857	.1658	
Max	.6796	.3326	.583	.5144	.583	.6173	.6859
Min	.1029	.1294	.2058	.2229	.0686	.0686	.0747
Avg	.4020	.2156	.3944	.3687	.2444	.4091	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.3361					
6						.1844	
7		.5175				.2486	
8	.4287				.2915	.1844	
9	.3881		.2915	.3258	.1715	.1715	.2401
10	.1326						
11	.1658						
12	.1844						
15	.1677						
16	.218		.1543	.1543	.1715	.1372	.1372
17							.1848
19							.3326
23	.1886						
24	.1886	.2218			.1029	.0995	
Max	.4287	.5175	.2915	.3258	.2915	.2486	.3326
Min	.1326	.2218	.1543	.1543	.1029	.0995	.1372
Avg	.2292	.3585	.2229	.2401	.1844	.1709	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 203 / 11KV BHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.7712					
6						.5729	
7		1.4251				.7095	
8	1.5604				.4458	.5228	
9	1.5089		1.286	.9774	.3601	.3944	.3944
10	.3881						
11	.3142						
12	.2033						
15	.2218						
16	.2054		.1715	.1715	1.1145	1.0802	
17							1.1233
19							.5228
23	.2915						
24	.2058	.3149			.2915	.2772	
Max	1.5604	1.4251	1.286	.9774	1.1145	1.0802	1.1233
Min	.2033	.3149	.1715	.1715	.2915	.2772	.3944
Avg	.5444	.8371	.7288	.5745	.5530	.5928	.6802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 204 / 11KV SOLVANT
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)
8		.0343
23	.0343	
24		.0343
Max	.0343	.0343
Min	.0343	.0343
Avg	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / SHIRSHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.8436	.823			.3772
2	.8573		.8905	.8745			.3772
3	.8916		.9374	.9431			.415
4	.9259		.9686	1.0288			.4904
5	1.0288		1.0155	1.0974			.5281
6	1.3032		1.0623	1.3032	.5788	.6722	.7167
7	1.8347		1.4003	1.5242		.7095	.7167
8	1.7375		1.5718	1.7661	.6161		.679
9	1.5718	1.8519	1.9418	1.4718	.4458		.5041
10	.3584	.3772	.4481	.415	.5487		1.2883
11	.3395	.2743		.3395	1.2803		
12	.3018	.2229		.2641	1.4632		
13	.2829	.2401		.2075	1.4175		2.1472
14	.2641			.2075	1.4175		
15	.2641			.2263	1.4784		
16	.3018		.2987		1.5699		1.9605
17		.2641	.2058	.2241	1.6244	1.286	1.6918
18		.3395	.2572		.2241	.2829	.2743
19		.4904	.463		.5041	.5658	.4458
20		.6224	.4973	.5601	.5601	.5093	.5144
21		.547	.5144			.5093	.5487
22		.4904	.4801		.4668	.4338	.463
23		.4904	.3429			.3772	.3944
24	.7716		.3725	.7716			.3018
Max	1.8347	1.8519	1.9418	1.7661	1.6244	1.286	2.1472
Min	.2641	.2229	.2058	.2075	.2241	.2829	.2743
Avg	.8152	.5176	.7638	.7804	.9464	.594	.7417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / PTS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0377	.0343			.0377
2	.0343		.0377	.0343			.0377
3	.0343		.0377	.0343			.0377
4	.0343		.0377	.0343			.0377
5	.0343		.0377	.0343			.0377
6	.0343		.0377	.0343	.0373	.0373	.0377
7	.0343		.0377	.0343		.0373	.0377
8	.0343		.0377	.0343	.0373		.0377
9	.0377	.0343	.0373	.0377	.0343		.0373
10	.0377	.0343	.0373	.0377	.0343		.0373
11	.0377	.0343		.0377	.0343		
12	.0377	.0343			.0343		
13	.0377	.0343			.0343		.0373
14	.0377	.0343		.0377	.0343		
15	.0377	.0343		.0377	.0343		
16	.0377	.0343	.0373		.0343		.0373
17		.0377	.0343	.0373	.0373	.0377	.0343
18		.0377	.0343		.0373	.0377	.0343
19		.0377	.0343		.0373	.0377	.0343
20		.0377	.0343	.0373		.0377	.0343
21		.0377	.0343			.0377	.0343
22		.0377	.0343		.0373	.0377	.0343
23		.0377	.0343			.0377	.0343
24	.0343		.0377	.0343			.0377
Max	.0377	.0377	.0377	.0377	.0373	.0377	.0377
Min	.0343	.0343	.0343	.0343	.0343	.0373	.0343
Avg	.0359	.0359	.0364	.0357	.0356	.0376	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115		.3887	.3601			.8215
2	.4115		.421	.3601			.8299
3	.4115		.4534	.3601			.8589
4	.4287		.5182	.3772			.8589
5	.5144		.5506	.4287			.8775
6	.6516		.583	.5144	.9149	1.0642	1.1949
7	1.0288		.8124	.823		1.2883	1.363
8	1.1317		.9998	.9259	1.363		1.3443
9	.9061	1.1317	1.0269	.8749	.9145		
10	.8775	.8916	.8775	.9149	.5658		.6722
11	.7356	.6859		.8029	.8059		
12	.6413	.5658		.679	.7716		
13	.6224	.5658		.5847	.7202		.8215
14	.679	.5658		.5658	.7373		
15	.7167	.5316		.547	.7202		
16	.7356	.5144	.5601		.7545		.8775
17		.6413	.6001	.6348	.8775	.7968	.7888
18		.7655	.6001		.5975	.7545	.5658
19		1.0082	.9774		1.1016	1.1576	.9945
20		1.1576	1.0288	1.1203		1.094	1.0288
21		1.0642				1.0082	.9088
22		.9896	.8402		.9896	.8962	.8916
23		.7842	.7202			.8402	.7888
24	.4115		.3563	.3772			.8029
Max	1.1317	1.1576	1.0288	1.1203	1.363	1.2883	1.363
Min	.4115	.5144	.3563	.3601	.5658	.7545	.5658
Avg	.6656	.7909	.6842	.6251	.8453	.9889	.9100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916		.8436	.6859			.7167
2	.8383		.9374	.7926			.7167
3	.8993		.9998	.8688			.7545
4	1.0059		1.0936	.945			.7922
5	1.0669		1.1248	1.0364			.8299
6	1.4022		1.1873	1.1736	.9896	.8775	1.251
7	1.768		1.6004	1.7223		1.0456	.9896
8	2.2558		1.8004	1.9204	.9709		1.0185
9	1.729	1.9814	2.3339	1.8433	.8916		.7282
10	.679	.4287	.7095	.7356	.8573		1.3256
11	.3772	.5658		.4715	1.4937		
12	.415	.463		.415	1.6613		
13	.4527	.3772		.3584	1.6918		1.2883
14	.4527	.2743		.3772	1.1279		
15	.4338	.3772		1.3392	1.3565		
16	.4715	.3601	.2801		1.7528		1.9791
17		.415	.2572		2.0165	1.8433	1.8747
18		.4715	.4287		.3361	.4338	.5144
19		.7167	.8745		.9896	.9335	.823
20		1.1016	.9431	1.0829		.8962	1.0288
21		.8589	.8059			.8215	.9431
22		.7095	.703		.8029	.7282	.7202
23		.6413	.6516			.679	.6687
24	.7621		.6964	.6401			.6602
Max	2.2558	1.9814	2.3339	1.9204	2.0165	1.8433	1.9791
Min	.3772	.2743	.2572	.3584	.3361	.4338	.5144
Avg	.9354	.6495	.9616	.9652	1.2099	.9176	.9812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 207 / 11KV SHELU SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1509	.1372			.6249
2	.1372		.1886	.1372			.6562
3	.1372		.2263	.1372			.7186
4	.1372		.2263	.1543			.7811
5	.1715		.2452	.1886			.8124
6	.2401		.2452	.2401	1.0642	.9335	.9842
7	.2743		.3018	.2743		1.307	1.1574
8	.2572		.2641	.2229	1.4003		1.2431
9	.2641	.1543	.2241	.2263	1.2803		1.6991
10	.7449	.7164	.9709	.828	.1715		.1867
11	1.2186	1.1126		1.2717	.1029		
12	1.2967	1.3413		1.286	.0686		
13	1.3904	1.3717		1.3003	.0857		.112
14	1.2431	1.2955		1.286	.0857		
15	1.2146	1.3108		1.2717	.0857		
16	1.2717	1.2346	1.4937		.0857		.0934
17		1.3289	1.2193		.0934	.0943	.0686
18		.0943	.1372		.112	.1132	.0857
19		.1886	.2229		.2241	.1886	.1715
20		.2641	.2401	.2241		.2263	.2229
21		.2263	.1886			.2263	.1886
22		.2075	.1715		.1867	.2075	.1886
23		.1886	.1543			.2075	.1715
24	.1372		.1509	.1372			.5624
Max	1.3904	1.3717	1.4937	1.3003	1.4003	1.307	1.6991
Min	.1372	.0943	.1372	.1372	.0686	.0943	.0686
Avg	.6043	.7357	.3696	.5484	.3605	.3894	.5364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 208 / 11 KV SAI DAIRY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514		.0754	.0686			.0377
2	.0514		.0754	.0514			.0377
3	.0514		.0754	.0343			.0754
4	.0343		.0754	.0343			.0754
5	.0343		.0566	.0343			.0754
6	.0343		.0566	.0343	.0373	.0373	.0377
7	.0343		.0566	.0343		.0373	.0754
8	.0343		.0377	.0343	.0373		.0377
9	.0377	.0343	.0373	.0377	.0343		.0373
10	.0377	.0686	.0373	.0377	.0343		.0373
11	.0377	.0857		.0566	.0343		
12	.0377	.0514		.0566	.0343		
13	.0377	.0514		.0754	.0343		.0373
14	.0377	.0514		.0754	.0686		
15	.0377	.0514		.0754	.0343		
16	.0377	.0514	.0373		.0343		.0373
17		.0754	.0343		.0373	.0377	.0343
18		.0566	.0343		.0373	.0377	.0343
19		.0566			.0373	.0377	.0343
20		.0566	.0343	.0373		.0377	.0343
21		.0566	.0514			.0377	.0343
22		.0754	.0514		.0373	.0377	.0514
23		.0754	.0514			.0377	.0514
24	.0514		.0754	.0686			.0377
Max	.0514	.0857	.0754	.0754	.0686	.0377	.0754
Min	.0343	.0343	.0343	.0343	.0343	.0373	.0343
Avg	.0399	.0599	.0530	.0498	.0380	.0376	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3944		.3429	.8573		
2	.2743	.3772		.4115	.8916		
3	.3429	.4801		.4115	.9602		
4	.4801	.583		.4801	.9602		
5	.6173	.6859		.7545	.9602	1.3717	
6	.9602	.8916		.8573	1.2003		1.2346
7	.9945	.9945	1.0288	.9259	1.6975	1.6461	
8	.823		.9602	.8573	1.7661	1.7147	
9	.7545		.6859				1.6289
10	.7545	.7888	1.166	.5487			.7545
11	1.5775	1.6461	1.6804	1.6461			.583
12	1.6461	1.7318	1.6632	1.5775			.4801
13	1.7147	1.8004	1.6804			.4115	.4115
14		1.7147	1.5432			.4115	.3601
15	1.5775	1.6975		1.5775	.2743	.4801	.3429
16	1.7147	1.7318	1.6461	1.5775			.3429
17	1.749		1.7147	1.749	.3429		.3772
18	.4973		.4115	.3772	.4115		.3772
19	.6859		.6173	.7202			.7545
20	.7202		.6859	.6859			.6859
21	.583		.5487	.6173			.6173
22	.4801		.4801	.5144			.5487
23	.4458		.4115	.4458			.4458
24	.3429	.3944	.3429	.3429	.823	.7545	
Max	1.749	1.8004	1.7147	1.749	1.7661	1.7147	1.6289
Min	.2743	.3772	.3429	.3429	.2743	.4115	.3429
Avg	.8715	1.0608	1.0157	.8296	.9288	.9700	.6216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715		.1372	.4115		
2	.1372	.1715		.1715	.4115		
3	.1715	.2058		.2743	.4115		
4	.2058	.3086		.2743	.4115		
5	.2743	.3429		.3429	.4115	.7545	
6	.4801	.5144		.4115	.6859		.9602
7	.5487	.6516	.5487	.5487	.7545	.823	
8					.8916	.9602	
9							.9431
10	.3429	.6173	.583	.3429			
11	.7545	.8916	.8916	.7545			.2743
12	.8916	.8916	.8916	.823			.2058
13	.9602	.8573	.8916			.2058	.1715
14		.823	.8573			.1372	.1372
15	.7545	.7545		.823	.1715	.1029	.1029
16	.8916	.8916	.8573	.6859			.1029
17	.8916		.9602	.7545	.1029		.1715
18	.2058		.2058	.1715	.1372		.2058
19	.3429		.2743	.3429			.3429
20	.3772		.3429	.4115			.3086
21	.3086		.2743	.2743			.2743
22	.2401		.2058	.2058			.2058
23	.2058		.1715	.1715			.1715
24	.1715	.1715	.2058	.1372	.3772	.3429	
Max	.9602	.8916	.9602	.823	.8916	.9602	.9602
Min	.1372	.1715	.1715	.1372	.1029	.1029	.1029
Avg	.4426	.5510	.5441	.4029	.4315	.4752	.3052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4458		.2743	.0343		
2	.4115	.3772		.4115	.0343		
3	.4801	.4458		.5487	.0343		
4	.6173	.4458		.6859	.1715		
5	.6859	.5144		.7545	.1886	.1372	
6	.7545	.6859		.7545			.2401
7	1.0288	1.0288	1.2346	1.0288			
8	1.2346	1.166	1.3032	1.0974	.2572		
9	1.166	.4801	1.0974	1.166			.1715
10			.7888	.1372			.4115
11				.0686			.9259
12				.0514			1.1145
13						1.166	1.0974
14						.6173	1.1317
15	.0686			.0514	1.0974	1.0288	
16	.0857		.0514	.0514			
17	.1029		.1029	.0514	1.3032		1.0288
18	.0857		.1372	.0686	.1372		.0686
19	.1372		.1715	.1715			.1543
20	.12		.2058	.1372			.1372
21	.0857		.1715	.1029			.1029
22	.0686		.1372	.0686			.0686
23	.0343		.1029	.0514			.0514
24	.2743	.3429	.4115	.2743	.0343	.0514	
Max	1.2346	1.166	1.3032	1.166	1.3032	1.166	1.1317
Min	.0343	.3429	.0514	.0514	.0343	.0514	.0514
Avg	.4097	.5933	.4551	.3640	.3292	.6001	.4789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 204 / 11 KV SALGARA II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.3717		.9602	.7888		
2	.9602	1.3375		1.0288	.7888		
3	1.166	1.4403		1.2346	.7888		
4	1.3717	1.4403		1.3032	1.0288		
5	1.5089	1.5432		1.6461	1.2003	.7545	
6	1.7833	1.8861		1.7833			.9945
7	2.4006	2.6063	2.332	2.332			
8	2.7435	2.7435	2.4006	2.4006	1.5432		
9	2.7435	2.4863	2.0576	2.4691			.7888
10			.7888	.6173			1.4746
11				.4801			2.2291
12				.3429			2.4006
13						2.4691	2.332
14						.6173	2.2977
15	.2743			.2058	1.5432	2.332	
16	.3429		.4115	.2058			
17	.4458		.3429	.5144	2.4006		2.2634
18	.5487		.4115	.9774	.4801		.4801
19	.9259		.6859	.9774			.9602
20	.8916		.7545	1.0631			1.2003
21	.8573		.7545	.9259			.9774
22	.7888		.7545	.823			.7545
23	.7545		.6859	.7545			.6859
24	.823	.7545	.823	.8916	.7545	.6859	
Max	2.7435	2.7435	2.4006	2.4691	2.4006	2.4691	2.4006
Min	.2743	.7545	.3429	.2058	.4801	.6173	.4801
Avg	1.1696	1.7610	1.0156	1.0881	1.1317	1.3718	1.4171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 201 / 11KV KAWA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.1509	.1886	.4475	.3749	.4001
2	.1494	.168	.1509	.1886	.4531	.3749	.4001
3	.1698	.168	.1509	.2075	.4531	.4428	.4321
4	.1867	.1867	.1509	.2452	.4744	.4428	.4801
5	.2054	.2241	.1886	.2829	.4801	.4858	.5601
6	.2452	.2987	.2829	.3018	.5121	.502	.6722
7	.2452	.3174	.3206	.3018	.7042	.664	.7202
8	.2829	.2801	.3018	.3018	.8162	.8259	.8322
9	.2641	.2801	.2641		.7773	.8097	.7682
10	.4534	.5155	.5218	.4481	.1886	.2075	.1886
11	.7611	.9231	.7682	.7842	.132	.132	.132
12	.8259	.9762	.8322	.8802	.1132	.1509	.1132
13	.7287	1.0082	.8642	.8802	.0924	.0754	.0943
14	.8907	.9762	.8322	.8962	.0943	.132	.0943
15	.8745		.8002	.8802	.0934	.132	.0943
16	.9717	.8162	.7842	.8962	.132	.1132	.0754
17	.9804	.9282	.8162	.8482	.0934	.1698	.1132
18	.168	.132	.1307	.132	.1294	.1509	.1509
19	.2427	.1886	.2054	.2263	.2241		.2263
20	.2614	.2452	.2427	.2641	.2801	.3018	.2829
21	.2241	.2263	.2452	.2263	.2241	.2263	.2452
22	.1867	.1698	.2075	.2263	.2054	.1886	.2075
23	.1867	.1509	.1867	.1886	.1867	.1886	.2075
24	.168	.168	.1509	.168	.381	.2812	.3201
Max	.9804	1.0082	.8642	.8962	.8162	.8259	.8322
Min	.1494	.132	.1307	.132	.0924	.0754	.0754
Avg	.4093	.4249	.3979	.4332	.3203	.3206	.3255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2267	.2968	.213	.168	.168	.168
2	.3201	.2267	.2968	.2267	.168	.168	.168
3	.3521	.2401	.3005	.2591	.168	.1867	.1867
4	.3768	.2429	.3163	.3277	.1867	.2241	.1867
5	.4096	.3239	.3163	.3725	.1867	.2241	.2241
6	.4372	.3725	.3681	.4372	.2614	.2614	.2427
7	.4696	.421	.4961	.5121	.2427	.2614	.2614
8	.502	.502	.1581	.4752	.2614	.2614	.2427
9	.5182	.4858	.4961		.2241	.2241	.2054
10	.0934	.1494	.1494	.1307	.3185	.2591	.3201
11	.056	.0747	.0747	.112	.4424		.4161
12	.0373	.0934	.056	.112	.4534	.1219	.4321
13	.0373	.0187	.0934	.0934	.4915	.4902	.4641
14	.0934	.0747	.0934	.0934	.4424	.2056	.4801
15	.0934	.0934	.0934		.4534	.2846	.4641
16	.1307	.0934	.0934	.0934	.3239	.3521	.4961
17	.1494	.112	.0934	.0934	.4372	.3681	.5281
18	.1494	.112	.112	.1307	.112	.1307	.112
19	.2614	.2054	.168	.2241	.2427	.2614	.2614
20	.2858	.2641	.2054	.2614	.2241	.2614	.2614
21	.2427	.2241		.2427	.2241	.2427	.2241
22	.1867	.1886		.2241	.2054	.2054	.2241
23	.1867	.1698		.1867	.1867	.2054	.2054
24	.2267	.2267	.2778	.2294	.168	.168	.1867
Max	.5182	.502	.4961	.5121	.4915	.4902	.5281
Min	.0373	.0187	.056	.0934	.112	.1219	.112
Avg	.2475	.2143	.2169	.2296	.2747	.2407	.2901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2753	.3201	.2429	.0762	.0762	.0762
2	.3201	.2753	.3201	.2401	.0762	.0762	.0762
3	.3681	.3239	.3201	.2721	.0762	.0762	.0762
4	.4049	.3201	.3521	.3077	.0953	.0953	.0953
5	.4696	.3841	.4161	.3725	.1524	.1143	.1334
6	.5506	.4372	.4161	.4372	.2096	.1334	.1334
7	.6154	.5668	.5601	.502	.1715	.1905	.1524
8	.6062	.5668	.5761	.5344	.1524	.1524	.1715
9	.5506	.3887	.5441		.1143	.1143	.1334
10	.0762	.0953	.0381	.0381	.3077	.3086	.4321
11	.0572	.0572	.0191	.0191	.5182	.4902	.4961
12	.0381	.0381	.0381	.0191	.5441	.6401	.5121
13	.0381	.0381	.0381	.0191	.5182	.6081	.5601
14	.0381	.0191	.0191	.0191	.5079	.6316	.5441
15	.0381	.0191	.0191	.0381	.5243	.6154	.5601
16	.0381	.0191	.0191	.0381	.421	.6316	.6081
17	.0381	.0191	.0191	.0191	.4696	.5668	.6154
18	.0572	.0191	.0191	.0381	.0191	.0572	.0381
19	.1334	.0572	.0572	.0762	.0762	.0953	.1143
20	.1143	.0953	.0953	.0953	.0762	.0953	.1143
21	.1143	.0953	.0762	.1143	.0953	.0762	.0953
22	.0953	.0762	.0762	.0953	.0953	.0762	.0953
23	.0762	.0572	.0572	.0953	.0953	.0762	.0762
24	.3077	.2429	.2968	.2267	.0762	.0762	.0762
Max	.6154	.5668	.5761	.5344	.5441	.6401	.6154
Min	.0381	.0191	.0191	.0191	.0191	.0572	.0381
Avg	.2279	.1869	.1964	.1678	.2279	.2531	.2494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3704	.6001	.5201	.4877	.1337	.0171	.1783
2	.4321	.6173	.5796	.5487	.1189	.1543	.1783
3	.4938	.6516	.6241	.5792	.1337	.1543	.1783
4	.7099	.6859	.6836	.6401	.1337	.1543	.1783
5	.8642	.823	.7133	.6859	.1486	.1715	.1783
6	.9259	1.1145	.743	.7164	.1783	.1886	.1932
7	1.034	1.2174	.9659	1.1431	.1932	.0171	.1932
8	1.1111	1.3032	1.0997	1.1584	.1486	.1886	.1486
9	1.142	1.1888	1.142	1.0551	.1715	.1486	.1337
10	.1372	.0892	.1235	.104	.8059	.535	.7727
11	.12	.0892	.1235	.104	1.046	.9957	
12	.12	.104	.0926	.104	1.0288	1.0997	.9957
13	.1029	.0594	.0772	.0892	1.1488	1.0997	1.0551
14	.1029	.0594	.0926	.0892	1.1145	1.0848	1.0105
15	.1029	.0594	.0926	.0892	1.0288	1.1443	1.0402
16	.1029	.104	.0926	.0892	1.0974	1.1443	1.2037
17	.0686	.1337	.0926	.0743	1.2003	1.1443	1.1443
18	.1029	.1189	.1235	.0892	.12	.0892	.0892
19	.1715	.1486	.1829	.1783	.1886	.1783	.1635
20	.2058	.1635	.1981	.1783	.2058	.1783	.1783
21	.2058	.1635	.1829	.1783	.2058	.1783	.1783
22	.2058		.1829	.1635	.1886	.1932	.1783
23	.1715	.2675	.1677	.1635	.1886		.1783
24	.3086	.5658	.4904	.4572	.1486	.1715	.1783
Max	1.142	1.3032	1.142	1.1584	1.2003	1.1443	1.2037
Min	.0686	.0594	.0772	.0743	.1189	.0171	.0892
Avg	.3880	.4490	.3911	.3819	.4615	.4535	.4316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11KV GANGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5556	.6516	.6516	.6588	1.0056	1.0631	1.1145
2	.6241	.6516	.6344	.6415	1.0576	1.1145	1.2346
3	.6588	.6859	.6516	.6762	1.1269	1.2003	1.406
4	.7628	.9431	.7545	.7628	1.283	1.5432	1.6289
5	.8669	1.2174	1.2346	.7282	1.6644	1.8861	1.6804
6	1.1789	1.3032	1.3717	1.335	2.0978	2.2634	1.8861
7	1.2309	1.0974	.9945	1.0056	2.2885	2.4348	2.3148
8	1.2136	.9431	.7888	.9362	2.3926	2.572	2.5034
9	.8495	.9945	1.0056	1.0576	2.1948	2.3663	.5316
10	1.1488	.9945	.9709	.6935	.5658	.7202	
11	1.9033	2.1776	1.9244	1.8031	.2572	.6344	.6068
12	2.2291	2.3148	2.0805	2.0285	.4973	.463	.4681
13	2.1434	2.1605	2.1498	.7628	.3944	.463	.4161
14	2.2119	2.2291	1.7684	1.7337	.3944	.463	.3988
15		2.3491	1.8204	2.0631	.7202	.463	.3814
16	2.2462	2.3148	2.3579	2.1325	.4115	.463	.3641
17	2.3834	2.4006	2.4272	2.3405	.3772	.4801	.3814
18	.6859	.4458	.4161	.4854	.5144	.5658	.5028
19	.9945	.8573	1.0402	.9882	.9945	1.046	1.0229
20	1.046	1.0117	1.0749	1.1096	1.046	1.0631	1.0749
21	.8916	.9431	1.0056	.9709	.9088	1.0288	1.0056
22	.823	.8916	.9015	.8669	.8573	.8573	.9015
23	.703		.7545	.7628	.7373		.7975
24	.6588	.6516	.6859	.7108	.9189	.9945	.9431
Max	2.3834	2.4006	2.4272	2.3405	2.3926	2.572	2.5034
Min	.5556	.4458	.4161	.4854	.2572	.463	.3641
Avg	1.2178	1.3143	1.2277	1.1356	1.0294	1.1369	1.0246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.4287	.4696	.4435	.3481	.3772	.3725
2	.4066	.4287	.5182	.5175	.3315	.3772	.3563
3	.4435	.5144	.5668	.5914	.3315	.4287	.3887
4	.5914	.5487	.583	.6283	.3647	.463	.4049
5	.7023	.7373	.5992	.6653	.547	.5487	.5668
6	.8501	.9774	.5992	.6838	.7293	.6687	.6802
7	1.0534	1.2174	.8383	1.1269	.8619	.703	.7611
8	1.3676	1.286	1.0059	1.1789	.6796	.5487	.664
9	1.3306	1.0974	1.1088	1.0277	.583	.5668	.5506
10	.463	.4115	.4805	.4641	.6516	.5182	.5636
11	.3429	.3506	.4066	.431	.9259	.9231	.7293
12		.2896	.3326	.2486	.9602	.9069	.8785
13	.2572	.2591	.2587	.2155	1.0974	.9069	.8619
14	.2743	.2105	.2587	.2321	.9774	.9069	1.0111
15	.2572	.1781	.2402	.2321	.8916	.9069	.9945
16	.3258	.1943	.2402	.2321	.9431	.9231	1.0774
17	.3772	.2429	.2218	.2321	.9602	1.0364	1.0608
18	.4115	.3077		.3315	.3086	.3563	.2984
19	.6173	.5668	.6468	.5801	.6001	.5792	.5801
20	.6001	.6316	.6653	.5636	.6001	.5668	.5801
21	.5144	.5668	.5914	.547	.5144	.5182	.5304
22	.4458	.4801	.5175	.4641	.4458	.421	.4641
23	.4115		.3881	.4144	.4287		.4144
24	.3142	.3772	.3887	.4066	.3647	.3772	.3725
Max	1.3676	1.286	1.1088	1.1789	1.0974	1.0364	1.0774
Min	.2572	.1781	.2218	.2155	.3086	.3563	.2984
Avg	.5542	.5349	.5185	.5191	.6436	.6317	.6318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / K R REFINARY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0171	.0191	.0191	.0191	.0171	.0191
2	.0191	.0171	.0191	.0191	.0191	.0171	.0191
3	.0191	.0171	.0191	.0191	.0191	.0171	.0191
4	.0191	.0171	.0191	.0191	.0191	.0171	.0191
5	.0191	.0171	.0191	.0191	.0191	.0171	.0191
6	.0191	.0171	.0191	.0191	.0191	.0171	.0191
7	.0191	.0171	.0191	.0191	.0191	.0171	.0191
8	.0191	.0171	.0191	.0191	.0191	.0171	.0191
9	.0191	.0191	.0191	.0191	.0171	.0191	.0191
10	.0171	.0191	.0191	.0191	.0171	.0191	.0191
11	.0171	.0191	.0191	.0191	.0171	.0191	.0191
12	.0171	.0191	.0191	.0191	.0171	.0191	.0191
13	.0171	.0191	.0191	.0191	.0171	.0191	.0191
14	.0171	.0191	.0191	.0191	.0171	.0191	.0191
15	.0171	.0191	.0191	.0191	.0171	.0191	.0191
16	.0171	.0191	.0191	.0191	.0171	.0191	.0191
17	.0171	.0191	.0191	.0191	.0171	.0191	.0191
18	.0171	.0191	.0191	.0191	.0171	.0191	.0191
19	.0171	.0191	.0191	.0191	.0171	.0191	.0191
20	.0171	.0191	.0191	.0191	.0171	.0191	.0191
21	.0171	.0191	.0191	.0191	.0171	.0191	.0191
22	.0171	.0191	.0191	.0191	.0171	.0191	.0191
23	.0171		.0191	.0191	.0171		.0191
24	.0191	.0171	.0191	.0191	.0191	.0171	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0171	.0191	.0191	.0171	.0171	.0191
Avg	.0179	.0183	.0191	.0191	.0179	.0183	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4715	.4115	.4287	.8316	.7716	.7122
2	.4458	.547	.4801	.3944	1.0608	.8916	.823
3	.4801	.6602	.6001	.4458	1.2894	1.0288	.9945
4	.5658	.7356	.7716	.4973	1.5061	1.2346	1.2689
5	.7202	.8402	.9431	.6516	1.5604	1.3717	1.406
6	.8573	.8501	1.0974	1.2003	1.6095	1.5775	1.6289
7	1.1317	.8871	1.2003	1.286	1.8351	1.6975	2.0405
8	.9431		.8745	1.0802	1.8623	1.8347	2.1365
9		.9431	.7468		1.8482		1.989
10	1.0974		.9667	.9431	.7373	.703	.7545
11	1.5775		1.4746	1.5775	.5426	.6516	.5281
12	1.749		1.5223	1.8519	.373	.5658	.3961
13	1.7661	1.7147	1.8296	1.8347	.373	.463	.3772
14	1.7318		1.4899	1.749	.3222	.3601	.3584
15	1.6975	1.6632	1.1843	1.6632	.3086	.3944	.3395
16	1.7318		1.4575	1.749	.3258	.4287	.415
17		1.5604	1.6461	1.6842	.3601	.4239	.4287
18	.7545	.5144	.9088	.547	.6516	.4801	.6344
19	.7922	.6859	.9431	.6602	.7202	.9774	.8745
20	.7545	.7202	.7716	.7167	.6859	.9536	.8059
21	.6979	.6173	.6687	.6468	.6859	.8916	.5658
22	.6413	.5144	.6001	.6099	.6001	.78	.4973
23	.5281	.4458	.4801		.4973	.5256	.4287
24	.4115	.4527	.4287	.4287	.6602	.7202	.6687
Max	1.7661	1.7147	1.8296	1.8519	1.8623	1.8347	2.1365
Min	.4115	.4458	.4115	.3944	.3086	.3601	.3395
Avg	.9767	.8235	.9791	1.0294	.8853	.8577	.8780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	1.4784	1.2003	1.286	1.2696	1.0288	1.0974
2	1.3375	1.5546	1.286	1.5261	1.1458	1.046	1.0631
3	1.3717	1.7924	1.6289	1.6632	1.2012	1.166	1.0749
4	1.4232	2.3167	1.8861	1.8519	1.307	1.3032	1.3375
5	1.5604	2.5968	2.2291	1.9547	1.5708	1.5261	1.2003
6	2.5377	3.1341	2.572	2.0062	1.6448	1.6118	1.6804
7	2.9321	3.4179	3.0864	2.9321	1.8296	1.7661	1.749
8	3.3093	3.4848	1.1831	2.6235	1.8111	1.6289	1.5775
9	2.692	2.8292	.9511	2.7949	1.2346		1.4232
10	1.1488		1.1088	1.0974	1.1317	1.0117	1.6804
11	1.0288			.9945	2.1434	1.6804	2.1672
12	.9259		1.0349	.9088	2.4863	2.3663	2.3061
13	.8916	.9431	.9979	.8402	2.5034	2.5377	2.3739
14	.8916	.8745	.9425	.823	2.452	2.6749	2.6282
15	.8745	.8059	.9055	.8059	2.4177	2.3148	2.6235
16	.9602		.8686	.8402	2.6749	2.7263	2.9673
17		.8916	.9088	.8871	2.7949	2.7778	2.8292
18	1.2536	1.2346	1.0288	.9335	1.0631	.9431	.9088
19	1.475	1.406	1.406	1.2752	1.2517	1.5604	1.3546
20	1.5912	1.3717	1.4403	1.6078	1.4403	1.595	1.4575
21	1.4784	1.2517	1.3717	1.5708	1.3375	1.5074	1.3889
22	1.4045	1.166	1.3032	1.5339	1.2517	1.387	1.3375
23	1.3676	1.0974	1.2003		1.1831	1.283	1.2003
24	1.2517	1.0099	1.0802	1.0802	1.3306	1.0631	1.1317
Max	3.3093	3.4848	3.0864	2.9321	2.7949	2.7778	2.9673
Min	.8745	.8059	.8686	.8059	1.0631	.9431	.9088
Avg	1.5200	1.7329	1.3748	1.4712	1.6865	1.6742	1.6899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 203 / 11KV AGRAWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1372	.1543	.12	.1372	.1698
2	.1372	.1715	.12	.1372	.12	.1372	.168
3	.12	.1543	.12	.1372	.1372	.1372	.1494
4	.12	.1543	.12	.1715	.1543	.1372	.168
5	.1372	.1715	.12	.1715	.1372	.1372	.1494
6	.1543	.1715	.1372	.1715	.1372	.1372	.1494
7	.1886	.1715	.1543	.1715	.1543	.1372	.1509
8	.1886	.2229	.1715	.1543	.1543	.1543	.1698
9	.1543	.2058	.1886	.12	.1509		.132
10	.2058		.2401	.1543	.1509	.1029	.1715
11	.2572		.2743	.1543	.1867	.12	.1886
12	.2915		.3086	.1543	.2427	.1372	.2058
13	.2915	.2743	.2743	.1543	.2452	.1543	
14	.3086	.2401	.2915		.2263	.1715	.2229
15	.3086	.2915	.2572	.1543	.2075	.1543	.2401
16	.2743	.3601	.2743	.1543	.2829	.1543	.1886
17		.2915	.2401	.1372	.2058	.1698	.1886
18	.2401	.2229	.2229	.1715	.1886	.1509	.1886
19	.2058	.1886	.1886	.1543	.1715	.1509	.1715
20	.1715	.1715	.1029	.1372	.1543	.1698	.1715
21	.1372	.1715	.12	.1372	.1543	.168	.1715
22	.1543	.1543	.1372	.1543	.1543	.168	.1886
23	.1372	.1543	.1715		.1543	.1886	.1886
24	.1543	.1715	.1715	.1715	.1372	.1543	.1867
Max	.3086	.3601	.3086	.1715	.2829	.1886	.2401
Min	.12	.1543	.1029	.12	.12	.1029	.132
Avg	.1946	.2033	.1893	.1535	.1720	.1491	.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 204 / PANAN MAHASANGH

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857	.0857	.0857	.0867
2	.0857	.0857	.0857	.0857		.0857	.0876
3	.0857	.0857	.0857	.0857	.0857	.0857	.0876
4	.0857		.0857	.0857	.0857	.0857	.0867
5	.0857	.0857	.0857	.0857	.0857	.0857	.0867
6	.0857	.0857	.0857	.0857	.0857	.0857	.0857
7	.0857	.0857	.0857	.0857	.0857	.0857	.0857
8	.0857	.0857	.0857	.0857	.0857	.0857	.0857
9	.0857	.0857	.0857	.0857	.0857		.0857
10	.0857		.0857	.0857	.0857	.0857	.0857
11	.0857		.0857	.0857	.0857	.0857	.0857
12	.0857		.0857	.0857	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857	.0857	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17		.0857	.0857	.0857	.0857	.0857	.0857
18	.0857	.0857	.0857	.0857	.0857	.0857	.0857
19	.0857	.0857	.0857	.0857	.0857	.0857	.0857
20	.0857	.0857	.0857	.0857	.0857	.0867	.0857
21	.0857	.0857	.0857	.0857	.0857	.0876	.0857
22	.0857	.0857	.0857	.0857	.0857	.0867	.0857
23	.0857	.0857	.0857		.0857	.0876	.0857
24	.0857	.0857	.0857	.0857	.0857	.0857	.0876
Max	.0857	.0857	.0857	.0857	.0857	.0876	.0876
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0857	.0857	.0857	.0857	.0860	.0861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 201 / 11KV MALVATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0288	
4			1.7147	
5			2.0576	
6			2.572	
7			2.572	
8			2.572	1.7909
9			2.6749	2.1719
10			.2743	2.1719
11				.1905
13				.2667
15				.2477
16				.2286
24	.3429	.2572		
Max	.3429	.2572	2.6749	2.1719
Min	.3429	.2572	.2743	.1905
Avg	.3429	.2572	1.9333	1.0097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 202 / 11KV KOLPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743	
4			.3429	
5			.3429	
6			.4115	
7			.4115	
8			.3429	.3658
9			.3429	2.1491
10			.3429	
11				.7621
13				.8573
15				.8573
16				.9145
24	.4115	.3086		
Max	.4115	.3086	.4115	2.1491
Min	.4115	.3086	.2743	.3658
Avg	.4115	.3086	.3515	.9844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 203 / 11KV BHATKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	
4			.1715	
5			.1715	
6			.2401	
7			.2401	
8			.2401	.3582
9			.2401	
10			.1715	.3982
15				1.3336
24	.4801	.3086		
Max	.4801	.3086	.2401	1.3336
Min	.4801	.3086	.1715	.3582
Avg	.4801	.3086	.2058	.6967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 201 / 11KV BHATANGALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.024	.0373	.0362	.2241	.3953	.2439
2	.037	.024	.0373	.0362	.2267	.4744	.2743
3	.0362		.0373	.0362	.2915		.3353
4	.0366	.024	.0373	.0358	.3201	.5535	.4268
5	.0362	.024	.0373	.0358	.3841	.5851	.4999
6	.0358	.024	.0373	.0358	.4858	.6325	.5624
7	.0354	.024	.0373	.0347	.6154	.7116	.5937
8	.0351		.0373	.0343	.6093	.6958	.6874
9	.0343	.0358	.0286	.024		.7042	.7116
10	.3658	.3715	.2172	.3601		.0366	.024
11	.6097	.6874	.6019			.037	.9842
12	.7011	.7655	.6722	.4081		.0358	.0316
13	.6874	.7655	.6401			.0362	.024
14	.7186	.7655	.6249	.5693	.0373	.0347	.024
15	.7499	.7655	.7291		.0373	.0347	.024
16	.7926	.7968	.5468	.6173		.0343	.024
17	.6001	.5312	.5335	.6722		.0343	.0366
18	.024	.0373	.0377	.0312		.0343	.0362
19	.024	.0373	.0366	.0297		.0343	.037
20	.024	.0373	.0366	.0297		.0373	.0362
21		.0373	.0366	.0297		.0373	.0362
22		.0373	.0362	.0293		.0373	.0362
23		.0373	.0362	.0297		.0373	.0362
24	.037	.024	.0373	.0362	.1852	.3163	.1829
Max	.7926	.7968	.7291	.6722	.6154	.7116	.9842
Min	.024	.024	.0286	.024	.0373	.0343	.024
Avg	.2694	.2671	.2146	.1501	.3106	.2422	.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 202 / 11KV CHIKHALTHANA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.2401	.3125	.3681		.012	
2	.427	.3953	.3437	.3887			
3	.4321	.4744	.4374	.3887			
4	.4321	.4744	.4999	.3841		.012	
5	.4641	.506	.5468	.4001		.012	
6	.5407	.5535	.5624	.4321		.012	
7	.664	.4321	.5639	.5218		.012	
8	.664		.5937	.5693		.012	
9	.6097	.6299	.5441	.5218			.012
10				.012		.4218	.3163
11				.12		.5218	.3001
12				.012		.4374	.4744
13						.5624	.3841
14				.012	.4374	.5556	.4321
15					.6249	.5624	.506
16					.6249	.6009	.5851
17	.012					.578	.6081
18	.012						
19	.012						
20	.012						
24	.3795	.3163	.1875	.3201		.012	
Max	.664	.6299	.5937	.5693	.6249	.6009	.6081
Min	.012	.2401	.1875	.012	.4374	.012	.012
Avg	.3623	.4469	.4592	.3179	.5624	.2883	.4020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 203 / 11KV BAMNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3953	.2812	.2652	.044	.036	.0686
2	.3481	.4744	.4062	.3185	.0446	.036	.0716
3	.3932	.506	.4687	.3315	.0572	.06	.0895
4	.4191	.5535	.5312	.3944	.0734	.072	.1075
5	.4096	.5851	.5335	.4161	.1014		.1612
6	.5087	.5851	.5792	.4973	.1014	.108	.2054
7	.7293	.6009	.5792	.6464	.1448	.144	.2241
8	.6796		.6249	.639		.132	.1467
9	.5487	.5761	.5792	.6009		.0977	.096
10	.08	.0709	.0572	.06		.3149	.3479
11	.0533	.0326		.048		.5735	.3321
12	.04	.032	.0579	.0532		.4111	.3906
13	.04	.0314	.0572	.036		.5601	.463
14	.04	.0337	.0429	.036	.3125	.583	.4999
15	.04	.0349	.0457		.4999	.5281	.5155
16	.04	.0326	.0446	.0429	.5155	.6226	.5312
17		.04	.0349	.0434		.5792	.6062
18		.0533	.0472	.0579		.0533	.0648
19		.1067	.0674	.0869		.1067	.0884
20		.12	.0899	.1014		.12	.1029
21		.0934	.0686	.1027		.1067	.0663
22		.08	.0572	.0734		.0934	.0562
23		.0667	.0442	.0579		.0667	.045
24	.2915	.3637	.1562	.2267	.044	.036	.0667
Max	.7293	.6009	.6249	.6464	.5155	.6226	.6062
Min	.04	.0314	.0349	.036	.044	.036	.045
Avg	.2935	.2378	.2371	.2233	.1762	.2366	.2228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 201 / 11KV water supply feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3109			.3292			.3109
8	.4024	.4938	.439	.4572	.4755	.3658	.3475
9	.4572						
10	.6859			.4382	.4938	.3658	.4801
11		.4572					
12	.743	.5487	.6219	.439	.6767		.583
14	.5853	.4938		.5144	.6767		.5316
16	.7621	.5487	.5853	.4207	.695	.439	.5144
17						.4024	
18	.6668	.4572		.3561	.5487		.4973
20	.4607	.4024		.3658	.3658		.5658
22	.4024	.3658		.2835	.3292		
24	.2926			.3475			.2743
Max	.7621	.5487	.6219	.5144	.695	.439	.583
Min	.2926	.3658	.439	.2835	.3292	.3658	.2743
Avg	.5245	.4710	.5487	.3952	.5327	.3933	.4561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 202 / 11KV AIRPORT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9593			.9774			.9593
8	1.1946	1.1523	1.2536	1.1765	1.2574	1.2178	1.1584
9	1.1523						
10	1.1431			.9511	1.2536	.905	1.1145
11		1.0745					
12	1.2384	.9313	.9231	.8505	1.1462		1.0631
14	1.0425	.8059		.5765	1.0745		1.0974
16	1.3336	.9492	.9511	.4854	.985	1.086	1.3032
17						1.1041	
18	.9907	.9492		.78	1.0745		1.2003
20	.691	.8954		.8505	.8954		1.0117
22	.6733	.6805		.7282	.7164		
24	.6516			.6878			.8145
Max	1.3336	1.1523	1.2536	1.1765	1.2574	1.2178	1.3032
Min	.6516	.6805	.9231	.4854	.7164	.905	.8145
Avg	1.0064	.9298	1.0426	.8064	1.0504	1.0782	1.0803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 203 / 11KV Goodwill feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2641			.1509			.1132
8	.3018	.1387	.381	.0754	.2481	.381	.1509
9	.4904						
10	.4572			.1734	.2858	.2263	.3772
11		.381					
12	.5335	.381	.5281	.3121	.381		.4801
14	.3292	.381		.1638	.381		.3086
16	.5335		.4527	.2835	.4191	.1886	.3086
17						.2641	
18	.5716	.381		.3391	.4191		.3429
20	.3189	.381		.4024	.381		.2743
22	.4024	.381			.3429		
24	.3772			.1886			.1509
Max	.5716	.381	.5281	.4024	.4191	.381	.4801
Min	.2641	.1387	.381	.0754	.2481	.1886	.1132
Avg	.4163	.3464	.4539	.2321	.3573	.265	.2785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0171			.0171			.0171
8	.0171	.0503	.0164	.0171	.0509	.0164	.0171
9	.0171						
10	.0492			.0328	.0164	.0171	.0514
11		.0164					
12	.0328	.0164	.0171	.0328	.0164		.0514
14	.0164	.0164		.0164	.0164		.0514
16	.0164	.0164	.0171	.0164	.0164	.0171	.0514
17						.0171	
18	.0492	.0164		.0164	.0164		.4973
20	.0158	.0164		.0335	.0164		.0514
22	.0164	.0164		.0168	.0164		
24	.0171			.0171			.0171
Max	.0492	.0503	.0171	.0335	.0509	.0171	.4973
Min	.0158	.0164	.0164	.0164	.0164	.0164	.0171
Avg	.0241	.0206	.0169	.0216	.0207	.0169	.0895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 205 / KANHAIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2012			.1646			.1646
8	.1646	.2126	.2743	.1646	.1341	.2012	.1463
9	.1463						
10	.3814			.1526	.1829	.1463	.4115
11		.1829					
12	.4572	.4024	.3658	.1734	.2926		.4115
14	.1357	.3292		.1341	.3109		.2915
16	.2658	.3841	.439	.1357	.3292	.128	.4973
17						.128	
18	.2481	.4207		.1147	.3292		.4287
20	.1772	.2743		.1187	.2195		.2743
22	.1772	.2195		.1174	.1463		
24	.2012			.2561			.128
Max	.4572	.4207	.439	.2561	.3292	.2012	.4973
Min	.1357	.1829	.2743	.1147	.1341	.128	.128
Avg	.2324	.3032	.3597	.1532	.2431	.1509	.3060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9709			.9709
8	.3921	.9145	.9709	.8962
10	.8505	.9709	.8589	.9259
12	.9335	1.0642		.8745
14	.8682	1.0082		.9088
16	.8505	1.0456	.9896	.9774
17			.9335	
18	.8505	.9709		.8745
20	.8596	.9335		.8573
22	.8682	.9335		
24	.9149			.9335
Max	.9709	1.0642	.9896	.9774
Min	.3921	.9145	.8589	.8573
Avg	.8359	.9802	.9382	.9132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 207 / 11 KV Dhoot feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3086			.2572			.2058
8	.2572	.2515	.2374	.2743	.1802	.2543	.2229
9	.2743						
10	.2515			.2515	.2204	.2743	.2915
11		.2035					
12	.3121	.3052	.2743	.2622	.3391		.3429
14	.2515	.2543			.3052		.3258
16	.3294	.2543	.3601	.2515	.3391	.3086	.3944
17						.2915	
18	.2883	.2883		.1802	.3561		.3086
20	.2347	.2543		.1844	.3391		.2743
22	.2515	.2374		.1865	.3391		
24	.2572			.2915			.2058
Max	.3294	.3052	.3601	.2915	.3561	.3086	.3944
Min	.2347	.2035	.2374	.1802	.1802	.2543	.2058
Avg	.2742	.2561	.2906	.2377	.3023	.2822	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 208 / 11 KV Kalantri feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.1317			1.1506			.9054
8	1.1694	1.2323	1.2193	1.1883	.8859	.8764	.6413
9	1.4335						
10	1.5623			1.3527	1.2384	.7733	.8916
11		1.4289					
12	1.6766	1.7147	1.7918	1.5051	1.1431		1.1145
14	1.6385	1.3336		1.134	1.0479		1.2689
16	1.7528	1.6194	1.7353	1.1888	1.2574	.5658	1.406
17						.679	
18	1.8099	1.467		1.1871	1.2765		1.3203
20	1.3908	1.2955		1.0229	1.2003		1.1488
22	1.1523	1.2003		.7802	1.2003		
24	1.1694			1.226			.679
Max	1.8099	1.7147	1.7918	1.5051	1.2765	.8764	1.406
Min	1.1317	1.2003	1.2193	.7802	.8859	.5658	.6413
Avg	1.4443	1.4115	1.5821	1.1736	1.1562	.7236	1.0418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 201 / 11KV Nagazari SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.9945	.7011	.6859	.1886	.2058	.1829
2	.9145	1.1145	.7164	.9602	.1886	.2058	.2058
3	.9907	1.3717	.7773	1.2003	.2058	.2401	.2058
4	1.0364	1.6289	.9907	1.4746	.2401	.2743	.2572
5	1.0669	1.7147	1.1279	1.6118	.3086	.3086	.2915
6	1.1736	1.8861	1.448	1.749	.3772	.3258	.3772
7	1.7528	1.9204	1.7223	1.8347	.3772	.4115	.3772
8	1.6004	1.8004	1.6766	1.8176	.3429	.4115	.3086
9	1.6004	1.1145	1.6156	1.749	.3086	.3086	
10	.2572	.2915		.2401	.5335	.8688	
11	.1715	.2058	.1715	.1715	1.5242	1.6156	
12	.1886	.1372	.1715	.1886	1.6309	1.6766	1.5851
13	.1543		.1372	.1543	1.6766	1.5546	1.6766
14	.1715	.1543	.1372	.1543	1.6766	1.1888	1.4327
15	.2058	.1372	.1372	.1543	1.6461	1.5242	1.4175
16	.2058	.1372	.12	.1543	1.5851	1.6004	1.5699
17	.2572	.1543	.12	.1543	1.6766	1.5851	1.5242
18	.2401	.2401	.1543	.1715	.1886	.1981	.2058
19	.2743	.3601	.3429	.2743	.3429	.3601	.3429
20	.3086	.3258	.3429	.2572	.3601	.3944	.3601
21	.2743	.2915	.3429	.2915	.3086	.2915	.3429
22	.2058	.2572	.2743	.2229	.2743	.2572	.3086
23	.1715	.2229	.2058	.1886	.2401	.2058	.2401
24	.7926	.6859	.4287	.4458	.1886	.2058	.2058
Max	1.7528	1.9204	1.7223	1.8347	1.6766	1.6766	1.6766
Min	.1543	.1372	.12	.1543	.1886	.1981	.1829
Avg	.6208	.7455	.6027	.6794	.6829	.6758	.6390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 202 / 11 KV SAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1715	.1715	.442	.4877	.5182
2	.1543	.1715	.1715	.1372	.4877	.5792	.5335
3	.1715	.1715	.1886	.1715	.4877	.6401	.6516
4	.2058	.2058	.2229	.2058	.5792	.7316	.6401
5	.2058	.2743	.2401	.2743	.6249	.7926	.7316
6	.2229	.3086	.3429	.3086	.7926	.8383	.9774
7	.2915	.3429	.3258	.3429	1.286	.9755	1.1431
8	.2572	.2915	.2915	.3429	1.2193	1.0974	1.0364
9	.2058	.2058	.2058	.12	1.2498	1.0059	1.1431
10	.7316	.7373	.7373	.7202	.1067	.1715	.0762
11	1.1431	.9755	.8573	.8993		.12	
12	1.406	1.0364	1.0288			.1029	.1372
13	1.286		1.166	.9297		.1029	.1029
14	1.2689	1.0822	1.2003	1.1736	.1029	.12	.1029
15	1.286	1.2498	1.2174	.9755	.1029	.1029	.0857
16	1.4575	1.2651	1.3717	1.0669	.1029	.0857	.1029
17	1.5604	1.3413	1.4575	1.0974	.1029	.1029	.1029
18	.1372	.1829	.0857	.0762	.1029	.1372	.0857
19	.1715	.2743	.1372	.1677	.2229	.2572	.2058
20	.2058	.2572	.2401	.2401	.2572	.2743	.2572
21	.2058	.2229	.2401	.2058	.2401	.2401	.2401
22	.1886	.2058	.2058	.1715	.2058	.2058	.2058
23	.1715	.1886	.1886	.1372	.1715	.1715	.1715
24	.1372	.1543	.1715	.1715	.3944	.3048	.4973
Max	1.5604	1.3413	1.4575	1.1736	1.286	1.0974	1.1431
Min	.1372	.1543	.0857	.0762	.1029	.0857	.0762
Avg	.5504	.4913	.5194	.4394	.4420	.402	.4239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 203 / 11 KV RAIWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.3048	.3353	.4268
2	.3429	.3772	.3429	.3429	.3048	.4268	.4572
3	.3772	.4115	.3601	.3772	.3658	.4877	.4572
4	.4801	.5144	.4115	.4458	.4268	.5487	.5182
5	.5144	.5487	.463	.4801	.503	.6097	.5639
6	.6344	.6001	.6173	.5487	.5792	.6401	.7011
7	.6344	.6344	.6001	.6344	.8383	.7926	.823
8	.583	.6001	.5658	.6001	.945	.884	.9602
9	.5316	.5144	.463	.5144	.9755	.884	1.0364
10	.5335	.5487	.6173	.5144	.3201	.3506	.3201
11	.8078	.8078	.7545		.2229	.3429	.2915
12	.9431	.8688	.8573	.823	.2401	.2401	.2743
13	.8573		.9259	.8688	.2286	.2915	.2743
14	.9431	.8383	.9259	.8688	.2743	.3086	.2572
15	1.0288	.8993	.9259	.6706	.2572	.2743	.2401
16	1.0631	.9145	.9431	.7164	.2401	.2572	.2401
17	1.1145	.9145	.9602	.7164	.2572	.2743	.2572
18	.4287	.2591	.2572	.2439	.2743	.2915	.2572
19	.5144	.5316	.3429	.4458	.5487	.5487	.5144
20	.5487	.583	.4801	.5487	.583	.583	.583
21	.5487	.5316	.4801	.4973	.5487	.5144	.5487
22	.5144	.4458	.4458	.4458	.5144	.463	.4801
23	.4458	.3944	.3944	.3772	.4801	.3772	.4115
24	.3429	.3429	.3601	.3772	.3086	.2439	.3944
Max	1.1145	.9145	.9602	.8688	.9755	.884	1.0364
Min	.3429	.2591	.2572	.2439	.2229	.2401	.2401
Avg	.6282	.5837	.5766	.5392	.4392	.4571	.4703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 201 / 11KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.1578	.156	.1629	.1543	.156	.156
2	.1417	.156	.1372	.1595	.1387	.1543	.1543
3	.1448	.1372	.1357	.1595	.1387	.1543	.1526
4	.1267	.1372	.1357	.1595	.1387	.1543	.1326
5	.1433	.1372	.1357	.156	.1698	.1578	.1326
6	.1448	.1595	.1372	.1612	.1629	.156	.156
7	.1772	.156	.1578	.1629	.1578	.1612	.1829
8	.197	.1848	.181	.1829	.181	.1829	.1829
9	.2054	.168	.197	.181	.197	.2172	.2012
10	.2054	.2075	.2126	.1791	.2126	.2149	.2172
11	.2801	.168	.2172	.1791	.2328	.2328	.2149
12	.2033	.1867	.2328	.181	.2172	.2561	.2012
13	.1848	.168	.1829	.1646	.2172	.2126	.2195
14	.1663	.1595	.1629	.1612	.2149	.1753	.1949
15	.168	.1417	.1646	.1646	.2012	.1612	.181
16	.1646	.1663	.1791	.1629	.1791	.181	.1772
17	.2054	.1612	.2012	.1448	.1646	.181	.1949
18	.1829	.1629	.1612	.1448	.1646	.1629	.1848
19	.181	.1991	.2012	.1646	.1848	.1646	.2241
20	.181	.1772	.2012	.1578	.1791	.1646	.2195
21	.1829	.1772	.181	.1753	.1772	.181	.1612
22	.1829	.1772	.1791	.1772	.181	.1791	.1829
23	.1829	.1772	.1791	.1772	.1578	.1791	.1791
24	.1595	.1578	.1578	.1629	.1595	.1578	.1612
Max	.2801	.2075	.2328	.1829	.2328	.2561	.2241
Min	.1267	.1372	.1357	.1448	.1387	.1543	.1326
Avg	.1780	.1659	.1745	.1659	.1784	.1791	.1819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 202 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9795	1.0374	1.0185	1.0751	1.0751	1.1506	1.1317
2	.9593	.9997	1.0185	.9997	1.094	1.0562	1.0751
3	.8962	.9808	.9808	.9997	1.0185	1.0562	1.0374
4	.905	.9808	.9808	.9997	1.0185	1.0562	1.0185
5	.9877	.9808	1.0185	1.0374	1.094	1.0751	1.0562
6	1.0903	1.0185	1.1694	1.094	1.2071	1.1694	1.2071
7	1.2127		1.251	1.2323	1.2883	1.2696	1.4003
8	1.2254	1.2803	1.1827	1.2197	1.1643	1.2197	1.262
9	1.0974	1.2071	1.0498	1.1765	1.1157	1.1157	1.1041
10	1.134	1.0631	1.1643	1.1157	1.1222	1.0498	1.2567
11	1.0974	1.0631	1.1706	1.0903	1.2567	1.134	.6516
12	1.0985	1.2048	1.2012	1.0456	1.2489	1.0903	.9979
13	1.0631	1.2048	1.1763	.9511	1.2437	.9955	1.2894
14	1.0277	1.1222	1.086	.9955	1.1765	.9694	1.2851
15	1.0277	1.0498	1.1273	1.0425	1.1458	.905	1.2851
16	1.134	1.086	1.1888	1.0136	1.262	1.0974	1.3169
17	1.1706	1.1584	1.1104	1.0791	1.3032	1.0608	1.3169
18	1.2357	1.2127	1.2894	1.0974	1.3937	1.1706	1.3611
19	1.4815	1.4842	1.4998	1.2803	1.5729	1.4083	1.7013
20	1.39	1.5181	1.4815	1.3352	1.5364	1.4003	1.7193
21	1.3306	1.3306	1.3306	1.2437	1.4266	1.3306	1.5524
22	1.2197	1.251	1.2883	1.2323	1.363	1.3676	1.4377
23	1.1458	1.1949	1.2449	1.1949	1.251	1.2752	1.3443
24	1.0562	1.0751	1.094		1.1458	1.1949	1.1949
Max	1.4815	1.5181	1.4998	1.3352	1.5729	1.4083	1.7193
Min	.8962	.9808	.9808	.9511	1.0185	.905	.6516
Avg	1.1236	1.1524	1.1718	1.1109	1.2302	1.1508	1.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 203 / 11KV KANHERI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6602	.6287	.6287	.6859	.7167	.6287
2	.679	.6413	.5906	.5906	.6287	.6413	.6287
3	.6348	.6287	.5716	.5906	.5906	.6413	.6097
4	.6468	.6287	.5716	.5906	.5906	.6413	.5906
5	.6722	.6287	.5906	.6668	.6097	.679	.6668
6	.7356	.679	.7811	.724	.724	.743	.7811
7	.8501	.9054	.8865	.7922	.8488	.8029	.8865
8	.8316	.8589	.8029	.7733	.8215	.7655	.8131
9	.8029	.7577	.7655	.6838	.7842	.7655	.7282
10	.7577	.6878	.7842	.6722	.6653	.7207	.7655
11	.7762	.6878	.7545	.6348	.7733	.6979	.7922
12	.7421	.6878	.7811	.5847	.7282	.6348	.7468
13	.6878	.6697	.7468	.5601	.7468	.6979	.6468
14	.6154	.5788	.7023	.5847	.7282	.6535	.7356
15	.6154	.6161	.6979	.5729	.7545	.6348	.7468
16	.7316	.6224	.7282	.5601	.7655	.6413	1.358
17	.8316	.7095	.7499	.5975	.7499	.679	.8029
18	.7577	.8596	.823	.5975	.8413	.7468	.8238
19	.924	.8779	.9425		1.0425	.8316	1.0791
20	.9149	.9425	.9055	.8215	.924	.8215	.9877
21	.8215	.8775	.8775	.8402	.9425	.8299	.9425
22	.8215	.8029	.8299	.811	.8589	.8488	.9149
23	.7842	.7545	.7733	.7545	.8029	.7922	.8029
24	.7049	.679	.6668	.679	.6979	.7356	.6036
Max	.924	.9425	.9425	.8402	1.0425	.8488	1.358
Min	.6154	.5788	.5716	.5601	.5906	.6348	.5906
Avg	.7508	.7268	.7480	.6657	.7627	.7235	.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.9404		2.0351	
8		2.0513		2.0328	
9					1.7926
10					1.4415
11		1.1831			
14	1.3032	1.166			
15		1.1831			1.1763
16		1.1831			1.1458
17			1.4045		1.2254
18	1.4377		1.4563		1.363
19			1.7703		
23	1.1273				
24	1.0898		.9221		
Max	1.4377	2.0513	1.7703	2.0351	1.7926
Min	1.0898	1.166	.9221	2.0328	1.1458
Avg	1.2395	1.4512	1.3883	2.0340	1.3574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 202 / 11 KV MURUD RURAL FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
16		1.829
24	2.0394	
Max	2.0394	1.829
Min	2.0394	1.829
Avg	2.0394	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 203 / 11 KV DHORALA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
24	2.3158	.6762
Max	2.3158	.6762
Min	2.3158	.6762
Avg	2.3158	.6762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0732		.0549	
8		.0732		.0543	
9					.2241
14	.0857				
15					.1829
16					.4294
17			.0351		.2987
18	.2743		.0183		.181
19			.037		
22	.7545				
23	.0366				
24	3.1758		.0332		
Max	3.1758	.0732	.037	.0549	.4294
Min	.0366	.0732	.0183	.0543	.181
Avg	.8654	.0732	.0309	.0546	.2632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 205 / 11 KV WATAWADA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
11		1.0059
14	.8078	1.1431
15		1.1126
16		1.0974
24	1.1022	
Max	1.1022	1.1431
Min	.8078	1.0059
Avg	.955	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 206 / 11 KV KARKATTA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.2801		.2987	
8		.2353		.2987	
9					.2012
14	.1029				
15					.1109
16					.128
17			.1097		.1097
18	.1991		.1109		.1663
19			.2218		
23	.112				
24	1.1022		.0848		
Max	1.1022	.2801	.2218	.2987	.2012
Min	.1029	.2353	.0848	.2987	.1097
Avg	.3791	.2577	.1318	.2987	.1432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		2.3101		1.8665	
8		2.4272		1.9231	
9					.0934
15					1.7528
16					2.0271
17			.0497		1.8671
18	.0739		.0549		.0747
19			.1097		
23	.112				
24	1.0898				
Max	1.0898	2.4272	.1097	1.9231	2.0271
Min	.0739	2.3101	.0497	1.8665	.0747
Avg	.4252	2.3687	.0714	1.8948	1.1630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 208 / 11 KV GUMPHAWADI -AG-

FEEDER Feeder KV- 11 /

OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
14	.9297
24	2.5149
Max	2.5149
Min	.9297
Avg	1.7223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 209 / 11 KV HOSPITAL (SEPERATE)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
14	.0171
24	1.0898
Max	1.0898
Min	.0171
Avg	.5535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 201 / 11 KV MURUD AKOLA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		2.2672			.8097	
10		.3395		.679	.9503	
11		.3772			2.3266	
12		.0943			2.6216	
18	.6224		.4715			
23				.5658		.5658
24		.6516			.5093	
Max	.6224	2.2672	.4715	.679	2.6216	.5658
Min	.6224	.0943	.4715	.5658	.5093	.5658
Avg	.6224	.7460	.4715	.6224	1.4435	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10				.2058		
11		.9831				
12		1.2955				
18	1.262		.2103			
23	.2263			.2075		.1886
24	1.065				.3391	
Max	1.262	1.2955	.2103	.2075	.3391	.1886
Min	.2263	.9831	.2103	.2058	.3391	.1886
Avg	.8511	1.1393	.2103	.2067	.3391	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
10		.3688	
11		.7287	
12		.7287	
18	.6859		
24	1.0898		.1696
Max	1.0898	.7287	.1696
Min	.6859	.3688	.1696
Avg	.8879	.6087	.1696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 204 / HT Chaitanya STEEL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.3077
Max	1.3077
Min	1.3077
Avg	1.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 201 / 11 KV GADWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 202 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 203 / 11 KV MASLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.0898
Max	1.0898
Min	1.0898
Avg	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 204 / 11 KV WANJARKHEDA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.0898
Max	1.0898
Min	1.0898
Avg	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 205 / 11 KV SATYA SAIBABA
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 201 / 11 KV BOPLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9374			.828		
2	.9842			.9259		
3	1.0494			.7716		
4	1.0822			1.6461		
5	1.326			1.6004		
6	1.4175			1.5546		
7	1.6004			1.6049		
8	1.5242			1.6766		
9		1.6461			.4534	
10		.2429			.9374	
11		.1457				
12		.0983			1.7071	1.406
13		.0819			1.6156	
14		.0655			1.5546	
15		.0819			1.4352	
16		.1311			1.6358	
17			.0983			1.5546
18			.1802			.1619
19			.5761			.421
20			.5281			.3563
21			.2753			.2915
22			.2105			.2429
23			.1638			.1943
24	2.192			.6325		
Max	2.192	1.6461	.5761	1.6766	1.7071	1.5546
Min	.9374	.0655	.0983	.6325	.4534	.1619
Avg	1.3459	.3117	.2903	1.2490	1.3342	.5786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 202 / 11 KC CHATA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328			.0655		
2	.0328			.0655		
3	.0328			.0328		
4	.0328			.0328		
5	.1296			.0983		
6	.192			.2429		
7	.2561			.3239		
8	.2401			.2429		
9		.1966			.6874	
10		.5761			.0648	
11		.8381			.0648	
12		.8436			.0164	
13		.8951			.0328	
14		.787			.0324	
15		.7716			.0324	
16		.6481			.0324	
17			.6874			.0164
18			.0328			.0164
19			.1296			.0486
20			.1296			.0972
21			.1134			.1943
22			.0655			.1296
23			.0655			.0972
24	1.0898			.0655		
Max	1.0898	.8951	.6874	.3239	.6874	.1943
Min	.0328	.1966	.0328	.0328	.0164	.0164
Avg	.2265	.6945	.1748	.1300	.1204	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 203 / 11 KV Takli FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937			.2401		
2	.6325			.096		
3	.7186			.192		
4				.192		
5	.9414			.176		
6	1.0669			.2401		
7	1.1431			.5281		
8	1.1431			.4801		
9		1.0822			.1638	
10		.0983			.6874	
11		.0983			.6944	
12		.0655			.9907	
13		.0492				
14		.0328			.9145	
15		.0492			.9907	
16		.0655			1.0212	
17			.0328			.945
18			.0328			.0648
19			.1147			.1619
20			.1296			.1619
21			.0972			.1296
22			.0972			.0972
23			.0972			.081
24	1.4413			.176		
Max	1.4413	1.0822	.1296	.5281	1.0212	.945
Min	.5937	.0328	.0328	.096	.1638	.0648
Avg	.9601	.1926	.0859	.2578	.7804	.2345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 204 / 11kv MBF Express old
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 206 / 11 kV Ekurga new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077			.3932		
2	.3077			.3441		
3	.3887			.4096		
4	.4481			.4696		
5	.5281			.5506		
6	.6241			.4858		
7	.6722			.6081		
8	.6562			.6241		
9		.5921			2.3777	
10		1.9997			.4858	
11		2.4387			.3563	
12		2.5301			.2267	
13		2.5911			.2105	
14		2.5911			.1966	
15		2.4539			.2622	
16		1.5623			.1966	
17			2.5149			.1966
18			.3239			.2915
19			.5601			.5344
20			.5441			.5668
21			.421			.4696
22			.3932			.3239
23			.2785			.2915
24	1.0898			.3113		
Max	1.0898	2.5911	2.5149	.6241	2.3777	.5668
Min	.3077	.5921	.2785	.3113	.1966	.1966
Avg	.5581	2.0949	.7194	.4663	.5391	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 207 / 11 KV MBF New
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381			.0381		
2	.0381			.0381		
3	.0381			.0381		
4	.0381			.0381		
5	.0381			.0381		
6	.0381			.0381		
7	.0381			.0381		
8	.0381			.0191		
9		.0381			.0381	
10		.0381			.0381	
11		.0754			.0381	
12		.0747			.0191	
13		.0934			.0381	
14		.0747			.0191	
15		.0747			.0191	
16		.0747			.0191	
17			.0566			.0934
18			.0381			.0566
19			.0381			.0566
20			.0381			.0381
21			.0381			.0381
22			.0381			.0381
23			.0381			.0381
24	1.153			.0381		
Max	1.153	.0934	.0566	.0381	.0381	.0934
Min	.0381	.0381	.0381	.0191	.0191	.0381
Avg	.1620	.0680	.0407	.0360	.0286	.0513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5639	.5801	.6021	.6568	.5944		1.2346
2	.5944	.6299	.6001	.6548	.823		1.3375
3	.6097	.6962	.6173	.7109	1.3108		1.3413
4	.6706	.9614	.6516	.9193	1.4937		1.6575
5	.884	1.1603	.775	1.1608	1.5242		1.9662
6	.9755	1.2929	.9221	1.3315	1.5242		2.0243
7	1.0364		1.1736		1.89		2.2996
8	1.0974	1.1271	1.1401	1.3144	1.9814	2.2542	2.2119
9	.8535	1.1271	1.0584	1.0059	1.89	1.7939	1.9662
10	1.9227	1.6385	1.4117	.8535	.663	.7796	.5959
11	2.1051	1.8842	1.8127	1.7071	.4475	.5316	.4168
12	2.2874	1.9989	1.925	1.829	.3647	.4252	.3204
13	2.3205	2.0481	1.9319	1.8442	.3647	.3801	.3001
14	2.1548		1.9319	1.7223	.3481	.4287	.3243
15	2.3537	1.9662	1.7646	1.7071	.3481	.4458	.3566
16	2.3868	2.0885	1.7967		.3481	.4801	.3073
17	2.2542	2.13	1.8127	1.7833	.3481	.5144	.3157
18	.9945	.4908	.4373	.442		.5144	.4501
19	1.1105	.905	1.1823	.945	.9448	.8573	.8021
20	.9614	1.1317	1.1876	.9755	1.1105	1.0974	1.03
21	.8619	.8573	.9355	.7926	.8453	.8573	.8899
22	.7293	.7888	.898	.6706	.779	.7545	.7335
23	.6299	.6889	.6821	.5792	.663	.6859	.6668
24	1.1401	.5801	.6173	.6756	.4725	.9945	1.0288
Max	2.3868	2.13	1.9319	1.8442	1.9814	2.2542	2.2996
Min	.5639	.4908	.4373	.442	.3481	.3801	.3001
Avg	1.3124	1.2169	1.1612	1.1037	.9165	.8115	1.0241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2812	.3258	.3334	.0305		.0377
2	.2591	.2812	.3258	.3334	.0305		.0377
3	.2591	.2812	.3628	.3334	.0305		.0377
4	.2896	.2812	.4115	.3334	.0305		.0377
5	.2896	.3437	.4801	.3753	.0305		.0377
6	.3658	.4687	.583	.3929	.0305		.0377
7	.5487	.5312	.6516	.563	.0305		.0377
8	.6097		.6859	.5775	.0305	.0313	.0377
9	.4572	.4999	.5152	.5182	.0305	.0377	.0377
10	.0313	.0362	.033	.0305	.2812	.3982	.3429
11	.0313	.0377	.0341	.0305	.578	.6154	.5058
12	.0313	.0377	.0375	.0305	.5937	.7087	.5901
13	.0313	.0377	.0375	.0305	.5937	.6661	.5168
14		.0377	.0375	.0305	.5937	.6135	.5121
15		.0377	.0375	.0305	.6249	.6135	.478
16		.0377	.038	.0305	.578		.5274
17	.0313	.0377	.038	.0305	.4374	.5258	.6147
18	.0313	.0377	.038	.0305	.0313	.0362	.0374
19	.0313	.0377	.038	.0305	.0313	.0362	.038
20	.0313	.0377	.0377	.0305	.0313	.0362	.038
21	.0313	.0377	.038	.0305	.0313	.9412	.038
22	.0313	.0377	.038	.0305	.0313	.0362	.038
23	.0313	.0377	.038	.0305	.0313	.0362	.038
24	1.3077	.2656	.3077	.3753	.0305	.0313	.0377
Max	1.3077	.5312	.6859	.5775	.6249	.9412	.6147
Min	.0313	.0362	.033	.0305	.0305	.0313	.0374
Avg	.2376	.1635	.2154	.1901	.1989	.3352	.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	1.1728	1.0059	1.4339	.1067		.1448
2	1.2041	1.3032	1.0059	1.4323	.1219		.1448
3	1.2193	1.4009	1.0395	1.4494	.1219		.1448
4	1.2803	1.4335	1.073	1.451	.2134		.181
5	1.3565	1.6289	1.1603	1.7212	.2896		.2715
6	1.4022	1.7104	1.4918	1.8709	.3353		.3258
7	1.6309	2.0688	1.9662	2.0005	.3658		.4607
8	1.829	1.971	2.0243	1.8695	.3658	.4235	.543
9	1.829	1.8896	2.2519	1.6613	.2896	.132	.4812
10	.1955	.2572	.1877	.1829	1.4498	1.5384	.4115
11	.1629	.1715	.0938	.0762	1.7918	1.8024	1.8128
12	.114	.1029	.0938	.0762	1.8896	1.8652	1.8128
13	.114	.1029	.0938	.061	1.8896	2.1502	1.8004
14	.114	.1029	.0938	.0762	1.7593	1.9448	1.6671
15	.114	.1029	.0938	.0762	1.7593	1.9559	1.6337
16	.1792	.1029		.0762	1.7104	1.8896	1.7151
17	.1955	.1029		.0762	1.7814	1.8778	1.6363
18	.3258	.1372	.1521	.0914	.2281	.2534	.1283
19	.3909	.3086	.3203	.2439	.2936	.3189	.2834
20	.2932	.2572	.3423	.2743	.3584	.3544	.3529
21	.2281	.1886	.2261	.1981	.1955	.2481	.2219
22	.1629	.1715	.1901	.1524	.1629	.1791	.1684
23	.1303	.1372	.1501	.1219	.1303	.1448	.1483
24	1.2717	1.0099	1.0059	1.3731	.0914	.1303	.1448
Max	1.829	2.0688	2.2519	2.0005	1.8896	2.1502	1.8128
Min	.114	.1029	.0938	.061	.0914	.1303	.1283
Avg	.7042	.7431	.7301	.7519	.7376	1.0123	.6931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	07-MAR-18
HR	Load (MW)
2	.0377
Max	.0377
Min	.0377
Avg	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0556	.0545	.0733	.0457		.0724
2	.0762	.0556	.0543	.0735	.0457		.0724
3	.061	.0556	.0724	.0735	.0457		.0905
4	.061	.0742	.0724	.0735	.0457		.0905
5	.061	.0742	.0905	.0735	.0457		.0543
6	.061	.0742	.0905	.0735	.0457		.0543
7	.061	.0742	.0905	.0919	.0457		.0543
8	.061	.0927	.0905	.0917	.061	.0927	.0543
9	.061	.0926	.0916	.0762	.0762	.0905	.0724
10	.0742	.0943	.0916	.0762	.0741	.0905	.0724
11	.0742	.1029	.0919	.0762	.0926	.0905	.0927
12	.0742	1.0802	.1101	.0762	.0926	.0905	.0929
13	.0742	.1029	.1101	.0762	.0926	.0905	.0926
14	.0742	.0943	.1284	.0762	.1483	.0905	.0929
15	.0927	.0943	.1284	.0762	.1481	.0905	.0916
16	.1483	.0943	.0907	.0762	.1481	.0905	.0919
17	.1483	.0943	.0916	.0762	.1111	.0724	.0907
18	.1298	.0754	.0916	.0762	.1111	.0905	.0735
19	.1298	.0754	.0926	.0762	.1112	.0905	.0926
20	.1298	.0754	.0916	.0762	.1111	.0724	.0928
21	.1298	.0754	.0735	.061	.0926	.0724	.0926
22	.1112	.0758	.0735	.061	.0926	.0724	.0926
23	.0927	.0754	.0919	.061	.0926	.0724	.0929
24	1.2717	.0927	.0543	.0897	.061	.0927	.0724
Max	1.2717	1.0802	.1284	.0919	.1483	.0927	.0929
Min	.061	.0556	.0543	.061	.0457	.0724	.0543
Avg	.1389	.1230	.0883	.0755	.0849	.0854	.0809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.5377	2.5377	2.6578	2.452			
10					1.2517	1.5089	1.4403
16	.4973	.2058	.2572	.2915	2.6406	2.2291	2.6235
24	2.3025	1.0974	1.2346	1.166	.4115	2.3491	.3944
Max	2.5377	2.5377	2.6578	2.452	2.6406	2.3491	2.6235
Min	.4973	.2058	.2572	.2915	.4115	1.5089	.3944
Avg	1.7792	1.2803	1.3832	1.3032	1.4346	2.0290	1.4861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6001	.6344	.5658	.583	1.6118
15					.1029
16	1.6975		1.4918	1.2689	
24	.1886	1.2784	.1886	.2058	.4801
Max	1.6975	1.2784	1.4918	1.2689	1.6118
Min	.1886	.6344	.1886	.2058	.1029
Avg	.8287	.9564	.7487	.6859	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8745	.7373	.8402	.823
16	.4973	.3429	.3086	.2915
24	.3429	.4443	.3601	.3601
Max	.8745	.7373	.8402	.823
Min	.3429	.3429	.3086	.2915
Avg	.5716	.5082	.5030	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 204 / 11 KV Kanadi Borgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6289	1.5261	1.5261	1.3546			
10					.3772	.8573	1.2174
16		.1886	.2229	.1886	1.406		1.5089
18	.6516						
24	.9774	.4973	.8573	.7202	.5316	.5316	.5144
Max	1.6289	1.5261	1.5261	1.3546	1.406	.8573	1.5089
Min	.6516	.1886	.2229	.1886	.3772	.5316	.5144
Avg	1.0860	.7373	.8688	.7545	.7716	.6945	1.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 206 / 11KV Tandulja AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0343	.0343	.0171	.0343	.463	.583	.7545
16	.4973	.6687	.6173	.5487			
24		.0171			.2058	.2058	.4115
Max	.4973	.6687	.6173	.5487	.463	.583	.7545
Min	.0343	.0171	.0171	.0343	.2058	.2058	.4115
Avg	.2658	.2400	.3172	.2915	.3344	.3944	.583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7362	.7291	.905	.6859	.1372	.1475	.1143
2	.7712	.8309	.8859	.7619	.1372	.1311	.1143
3	.8322	.9221	1.0517	.78	.1227	.1311	.1524
4	.8916	.9945	1.0402	.8309	.1372	.1147	.1905
5	1.0288	1.1105	1.1022	.8619	.1867	.1492	.2286
6	1.1869	1.2266	1.1736	.8951	.2401	.1966	.2286
7	1.387	1.2929	1.2266	1.1142	.2743	.2458	.2477
8	1.4243	1.3108	1.1797	1.2616	.2543	.2294	.2858
9	1.5242	1.1961	1.1469	1.2944	.2058	.1658	.2286
10	.2096	.2075	.1294	.1696	.1715	.2321	.2622
11	.1143	.1905		.1372	1.2567	1.1218	1.2963
12	.0572	.0953		.1372	1.166	1.3032	1.3757
13	.1524	.0762	.0953	.1029	1.1469		1.3435
14	.1524	.1143	.0934	.0848	1.0883	1.3748	1.3599
15	.1334	.1143	.0934	.0972	1.2163	1.3923	1.3599
16	.1334	.1143	.0754	.0848	1.2431	1.4091	1.3757
17	.1524	.1334	.0953	.1017	1.2955	1.2431	1.326
18	.1715	.1334	.1143	.1017	.1134	.0934	.1029
19	.2286	.2477	.2477	.2374	.1619	.2477	.2347
20	.2587	.2286	.2667	.2204	.1943	.2858	.2058
21	.2353	.1905	.2286	.2035	.1802	.2667	.2058
22	.197	.1905	.1905	.1638	.1802	.2286	.1715
23	.1578	.1524	.1494	.1357	.1638	.2096	.1658
24	1.1022	.2454	.1905	.3239	.1372	.1619	.1715
Max	1.5242	1.3108	1.2266	1.2944	1.2955	1.4091	1.3757
Min	.0572	.0762	.0754	.0848	.1134	.0934	.1029
Avg	.5516	.5020	.5310	.4495	.4755	.4818	.5312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 203 / 11 Kv Samangaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 204 / 11 KV Natural FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0191		.0377	
2				.0191	.0191	.0189	.0191
3				.0191	.0191	.0189	.0191
4				.0381	.0191	.0377	.0191
5				.0191	.0191	.0381	.0191
6					.0191	.0191	.0191
7			.0191		.0191	.0377	.0381
8					.0191	.0381	.0191
9					.0191	.0381	.0191
10			.0191		.0191	.0377	.0189
11			.0164		.0191	.0191	
12			.0156		.0191	.0191	.0377
13					.0191		.0377
14			.0145		.0191	.0191	.0566
15					.0191	.0191	.0189
16					.0191	.0191	.0019
17			.013		.0191	.0191	.0019
18			.0225		.0381	.0191	.0019
19		.0381	.0221		.0381	.0191	.0019
20		.0381	.0213		.0381	.0381	.0038
21		.0381	.0206		.0381	.0191	.0038
22		.0381	.0191		.0381	.0191	.0038
23		.0191	.0124	.0171	.0381	.0191	.0038
24	1.0898			.0137	.0171	.0381	
Max	1.0898	.0381	.0225	.0381	.0381	.0381	.0566
Min	1.0898	.0191	.0124	.0137	.0171	.0189	.0019
Avg	1.0898	.0343	.0180	.0208	.0240	.0264	.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 201 / 11 KV Shiur Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.0526
Max	1.0526
Min	1.0526
Avg	1.0526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3353						
7	.5365	.4239			2.0957	2.0687	
8	.4527	.4748	.39	.503	1.9784		2.1195
9						2.0348	
10		1.5769	1.6095	1.4419			
11					.1696		
12			1.9281			.1526	
14	2.2891	2.1026	1.8778	2.3304			
15					.1357		
16			1.8778	2.2634	.1187		
17						.1696	.1187
18	.3052		.1341		.1696		
19				.3185			
20		.1696	.3521				
22				.2683			
23					.3052		.3052
24	1.0526	.3052		.2347	1.3748	.8648	1.3226
Max	2.2891	2.1026	1.9281	2.3304	2.0957	2.0687	2.1195
Min	.3052	.1696	.1341	.2347	.1187	.1526	.1187
Avg	.8286	.8422	1.1671	1.0515	.7935	1.0581	.9665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4694						
7	.7545	1.2717			.5365	.5426	
8	.788	1.2717		1.3748	.5868		.4917
9			1.4074			.5256	
10		.3391	.1677	.3521			
11					1.1869		
12			.1006			1.3226	1.3904
14	.1187	.0678	.1006	.0671			
15					1.2717		
16			.1006	.1006	1.2717		
17						1.3565	1.3565
18	.2883		.1509		.1696		
19				.3353			
20		.373	.3018				
22				.2012			
23					.2543		.3052
24	1.1022	.8478		.8048	.2012	.2543	.2374
Max	1.1022	1.2717	1.4074	1.3748	1.2717	1.3565	1.3904
Min	.1187	.0678	.1006	.0671	.1696	.2543	.2374
Avg	.5869	.6952	.3328	.4623	.6848	.8003	.7562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 204 / 11 KV WATER WORKS EXP NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0671						
7	.0671	.0678			.0671	.0678	
8	.0168	.0678	.017	.0671	.0671		.0678
9						.0678	
10		.0678	.0168	.0671			
11					.0678		
12			.0671			.0678	.0339
14	.017	.017	.0168	.0671			
15					.0339		
16			.0168	.0168	.0339		
17						.0678	.0678
18	.0678		.0168		.0339		
19				.0671			
20		.017	.0168				
22				.0671			
23							.0678
24	1.1022	.0678		.0671	.0671	.0678	.0678
Max	1.1022	.0678	.0671	.0671	.0678	.0678	.0678
Min	.0168	.017	.0168	.0168	.0339	.0678	.0339
Avg	.223	.0509	.0240	.0599	.0530	.0678	.0610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 205 / 11 KV Bhoyra New SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4527						
7	.6203				.8551	1.0343	
8	.6203	.3052	.3052	.3353	.9221		1.0682
9						1.0174	
10		.6104	.6706	.2683			
11					.0848		
12			.788			.0848	.0678
14	1.1191	.7461	.7545	.6203			
15					.0848		
16			.7377	.6706	.0678		
17						.0848	.0848
18	.4239		.1006		.1187		
19				.2683			
20		.2883	.2683				
22				.2012			
23					.1526		.1357
24	1.1022	.1357		.1677	.4191	.3391	.5087
Max	1.1191	.7461	.788	.6706	.9221	1.0343	1.0682
Min	.4239	.1357	.1006	.1677	.0678	.0848	.0678
Avg	.7231	.4171	.5178	.3617	.3381	.5121	.3730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 206 / 11 KV Ankoli new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2012						
7	.3521	.6443			1.1904	1.1869	
8	.3185	.5765	.4578	.5868	1.0898		1.2717
9						1.1191	
10		.8817	.8215	.3353			
11					.1865		
12			1.0395			.2035	
14	.9326	1.0682	1.0227	1.1233			
15					.1357		
16			.9221	1.1065	.1526		
17						.2204	.2204
18			.3185		.3052		
19				.1006			
20		.4748	.4862				
22				.3185			
23					.373		.3391
24	1.1022	.3391		.3521	.5365	.5087	.5596
Max	1.1022	1.0682	1.0395	1.1233	1.1904	1.1869	1.2717
Min	.2012	.3391	.3185	.1006	.1357	.2035	.2204
Avg	.5813	.6641	.7240	.5604	.4962	.6477	.5977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 207 / 11 KV Dhanori SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4694						
7	.57				.1677	.1696	
8	.6371	1.1191	1.1869	1.0898	.1006		.0848
10		.0678	.0168	.0335			
11					1.0343		
12			.0168			1.17	1.0513
14	.0339	.017	.0168	.0168			
15					1.1022		
16			.0168	.0168	1.1022		
17						1.1191	1.0513
18			.0335		.0339		
19				.1006			
20		.1187	.0838				
22				.0671			
23					.0848		.0848
24	1.1022	.3052		.4191	.0671	.0848	.0678
Max	1.1022	1.1191	1.1869	1.0898	1.1022	1.17	1.0513
Min	.0339	.017	.0168	.0168	.0339	.0848	.0678
Avg	.5625	.3256	.1959	.2491	.4616	.6359	.468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3401	.4481	.3887	.4251	.4075	.3563	
2	.3239	.4251	.3887	.4435	.3982	.3401	
3	.3563	.4481	.4049	.4525	.4344	.3725	
4	.4372	.5228	.4696	.5068	.5121	.4696	
5	.5182	.6401	.6154	.6219	.6335	.583	
6	.6154	.7602	.6802	.7602	.8859	.7287	
7	.583	.7783	.7287	.8059	.9391	.7773	.9593
8	.583	.7865	.6154		.8779	.6802	.8145
9	2.2348	2.0805	2.4006		.6516	.5506	.724
10	2.3158	2.372	1.8185		.4525	.4525	.5138
11	2.3122	2.5101		2.5692	.2753	.3801	.4163
12	2.4669	.8097	2.372	2.5692	.2683	.3258	.3077
13	2.4215	2.4777	2.4806	2.6155	.2591	.3077	.3258
14	2.372	2.5263	2.5606	2.4531	.1943		.3258
15	2.4006	2.6558	2.6092	2.6155	.2105		.2743
16	2.4006	2.7044	2.7044	2.649	.2591		.2534
17	.439	.2591	.2896	.3258	2.8178		3.0664
18		.3077	.4294	.3982	2.834	2.9007	3.1493
19	.6348	.6154	.6535	.6878	2.5911	2.7349	2.7349
20	.6535	.5668	.7468	.724	2.5101		2.6023
21	.6161	.583	.6602	.6335	2.251		2.7349
22	.5601	.4858	.5601	.5487	2.251		
23	.5304	.421	.5228	.4607	2.2024		2.5692
24	1.3226	.4854	.3725	.4668	.4344	2.1862	2.4034
Max	2.4669	2.7044	2.7044	2.649	2.834	2.9007	3.1493
Min	.3239	.2591	.2896	.3258	.1943	.3077	.2534
Avg	1.1930	1.1112	1.1075	1.1301	1.0646	.8841	1.4221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.3734	.3077	.3395	1.6575	1.3603	
2	.2591	.4108	.3401	.3206	1.643	1.4575	
3	.2915	.4435	.3725	.3734	1.6244	1.5384	
4	.3563	.4854	.421	.4481	1.6907	1.8461	
5	.5506	.6767	.583	.7316	1.7404	2.0405	
6	.6802	.8688	.8259	.9774	1.8233	2.2348	
7	.6316		.9069	.9511	1.989	2.4615	
8		.9593	.8583		1.989	2.1862	2.1879
9	.5344	.6401	.695		.6805	.6802	.6335
10	.3239	.4887	.4706		.3982		.4024
11		.3239	.2195	.3258	.2267		.3077
12	.2865	.2105	.1991	.2561	.1943		
13	.2896	.1457	.1448	.181	.1457	.2195	
14	.2686	.1296	.1448	.1829	.1619		
15	.362		.1463	.1433	.1619		.2012
16			.1267	.181	.1619		.2328
17	2.4006	2.3805	2.3205	2.0719	.1457		.2172
18	2.1348	2.5911	2.2885	2.2634	.2591	.2926	.2353
19	1.906	2.332	2.0083	2.1216	.5506	.6335	.6335
20	1.7394	2.2672	1.9433	2.0957	.583		.7964
21	1.7284	2.17	1.8404	1.9062	.5182		.695
22	1.6804	1.9433	1.8023	1.8233	.3563		.4525
23	1.9239	1.9919	1.7078	1.7404	.3077		.362
24	1.1022	1.6032	1.8623	1.7004	1.7101	.2753	.3439
Max	2.4006	2.5911	2.3205	2.2634	1.989	2.4615	2.1879
Min	.2591	.1296	.1267	.1433	.1457	.2195	.2012
Avg	.9385	1.1160	.9390	1.0064	.8633	1.3251	.5501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.8097	.8745	.8288	.1086	.0648	
2	.8421	.8482	.8745	.8907	.1086	.081	
3	.8907	.8745	.9069	.8802	.0914	.081	
4	.9555	.8962	.9393	.9069	.128	.1296	
5	1.1336	1.0279	1.0364	.9393	.181	.2429	
6	1.4251	1.1843	1.1012	.9602	.2743	.2753	
7	1.5061	1.3603	1.4899	1.5223	.362	.3077	
8	1.5546	1.4232	1.5061		.3258	.2915	.2715
9	.2915	.2172	.2534		1.326	1.1984	1.2574
10	.1781	.144	.1433		1.4586		1.326
11	.1097	.081	.0543	.0732	1.5384	1.326	1.3757
12	.0716	.0648	.0537	.0724	1.5061		1.4089
13		.0486	.0537	.0549	1.4899	1.4918	1.4586
14	.0716	.0486	.0543	.0549	1.4413		1.4251
15	.1086	.0486	.0532	.0549	1.3927		1.3757
16	.0914	.0486	.0537	.0549	1.3441		1.4754
17	.2172	.0486	.0566	.0543			.0549
18	.2378	.0972	.0754	.0724	.0648	.1097	.0914
19	.3018	.2267	.2641	.2715	.2105	.2743	.2378
20	.2452	.2267	.1886	.2353	.2105		.2353
21	.1509	.1619	.1509	.1772	.1296		.2172
22	.1132	.0972	.1132	.1086	.1134		.181
23	.0943	.0648	.0943	.0905	.081		.0905
24	1.1022	.0747	.0648	.0754	.1086	.081	.0905
Max	1.5546	1.4232	1.5061	1.5223	1.5384	1.4918	1.4754
Min	.0716	.0486	.0532	.0543	.0648	.0648	.0549
Avg	.5436	.4218	.4357	.3990	.6085	.4254	.7396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 201 / 11 KV RAMEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5636			
3	.9614	.9831			.2641		
6		1.004		.9448	.4527		
7	1.1934	1.3603			.4904		.4144
8	1.326	1.4899		1.0814	.4904		.4475
9						.4001	
10	.3395			.2641			.3315
11	.1886	.1334		.1509	1.1003	1.0608	1.2955
12	.1509			.1132			1.3279
13	.1509		.1492	.0754	1.1336	1.5083	1.4575
14	.1132			.0754			1.4575
15	.1132	.1	.0995	.1132		1.5249	1.2308
16				.1132			1.2631
17	.2641		.0829	.1132			1.3927
18	.2641						.1509
19	.3018	.1667		.2641	.2334		
20	.2641			.3772			.3772
23	.1509			.2641			.2641
24	.7545	.6962			.2263		
Max	1.326	1.4899	.1492	1.0814	1.1336	1.5249	1.4575
Min	.1132	.1	.0829	.0754	.2263	.4001	.1509
Avg	.4358	.7417	.1105	.3224	.5489	1.1235	.8777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2984			
3		.3206			.9831		
6		.4904			1.2955		1.1934
7	.5636	.5658		.4475	1.6518		1.4586
8	.4641	.5658	.5018	.4641	1.749		
9			.5001			1.467	
10	.6299		1.094	.431			.3018
11	1.5546	1.5337		1.7166	.2	.2486	.2263
12	1.587			1.7814			.1886
13	1.4899		1.8399	1.749	.1667	.1823	.1886
14	1.6842			1.6194			.1132
15	1.5546	1.5389	1.6907	1.6194		.2155	.2263
16				1.7166			.2263
17	1.749		1.9227	1.7814			.2641
18	.2641						.3395
19	.4527	.2667		.4527	.4001		
20	.3772			.4904			.5281
22		.3668					.3772
23	.3018			.3018			
24	1.1022	.3018			.4694		
Max	1.749	1.5389	1.9227	1.7814	1.749	1.467	1.4586
Min	.2641	.2667	.5001	.2984	.1667	.1823	.1132
Avg	.9839	.6612	1.2582	1.0621	.8645	.5284	.4332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 203 / 11 KV GONDEGAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	1.5912	1.6078	
13			1.757
24	.9069		
Max	1.5912	1.6078	1.757
Min	.9069	1.6078	1.757
Avg	1.2491	1.6078	1.757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 201 / 11 KV JAWALA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
24	1.1022	.0648
Max	1.1022	.0648
Min	1.1022	.0648
Avg	1.1022	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 202 / 11 KV BODKA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
24	1.1022	1.1022
Max	1.1022	1.1022
Min	1.1022	1.1022
Avg	1.1022	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 203 / 11 KV DHOKI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	02-MAR-18
HR	Load (MW)	Load (MW)
24	1.1022	.0678
Max	1.1022	.0678
Min	1.1022	.0678
Avg	1.1022	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 201 / 11KV Bhisewagholi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 202 / 11kv Wadiwagholi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.9389
Max	.9389
Min	.9389
Avg	.9389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 203 / 11kv Khuntephal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 157013 / 132/33 kv Niwali Sstn

Feeder No / Name : 402 / 33 KV NIWALI FEEDER

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	4.4765
Max	4.4765
Min	4.4765
Avg	4.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 157013 / 132/33 kv Niwali Sstn

Feeder No / Name : 403 / 33 KV SHIRALA FEEDER
Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	3.4591
Max	3.4591
Min	3.4591
Avg	3.4591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 158006 / 220/33 kv Murud EHV

Feeder No / Name : 401 / 33kv Murud Feeder
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	01-MAR-18
HR	Load (MW)
24	4.4765
Max	4.4765
Min	4.4765
Avg	4.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 201 / 11 Kv Renapur-I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
8	.6859	.6001
24	.3429	
Max	.6859	.6001
Min	.3429	.6001
Avg	.5144	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 202 / 11 Kv Mahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
8	.8573	.6001
16	1.5432	
24	.3429	
Max	1.5432	.6001
Min	.3429	.6001
Avg	.9145	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 203 / 11 KV HANMANTWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
8		.2572
16	.0857	
24	.0857	
Max	.0857	.2572
Min	.0857	.2572
Avg	.0857	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 205 / 11 Kv Phata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
8	.2572	.4287
16	.3429	
24	.3429	
Max	.3429	.4287
Min	.2572	.4287
Avg	.3143	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 206 / 11 Kv Renapur-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)
8	.5144	.5144
16	.3429	
24	.2572	
Max	.5144	.5144
Min	.2572	.5144
Avg	.3715	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.3923	1.0159	.5735	.1848	.1294	.1663
4		1.5524	1.3108	1.065	.3292	.2195	.2561
6		1.6766	1.6712	1.4746	.4344	.362	.3982
8	1.2003	1.768	1.8679	1.491	.3292	.4344	.3801
10		.1638	.1802	.1638	.4344	.5243	
12	.12	.0819	.0983	.0819	1.3108	.9831	
14	.1294		.0655		1.1437	1.0814	
16		.0983	.0983	.0857	1.2407	1.6876	1.9204
18	.2195			.2195		.1478	
20	.2743			.3292	.3258	.3292	
22	.1829			.2195	.2294	.2561	
23							.2058
24	.5487	1.166	.3277	.2949	.1663	.1848	.1829
Max	1.2003	1.768	1.8679	1.491	1.3108	1.6876	1.9204
Min	.12	.0819	.0655	.0819	.1663	.1294	.1663
Avg	.3822	.9874	.7373	.5453	.5572	.5283	.5014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1848	.1638	.1638	.6379	.631	.7011
4		.2378	.1966	.1966	.7362	.8573	.8322
6		.2743	.2294	.2622	.8063	1.0395	.9602
8	.3277	.2926	.3113	.2294	1.1145	1.21	1.0631
10		.8192	.852	.2458	.2195	.1147	
12	.852	1.0159	.9503	.7373	.112	.0983	
14	.9709	.9503	.5571		.0934	.0819	
16	1.1022	.9831	.852	.8848	.0934	.0819	
18	.3258			.1848		.1663	
20	.3258			.2926	.2561	.2926	
22	.1829			.1829	.1829	.2195	
23							.1311
24	.1311	.1478	.1311	.1311	.5014	.2715	.3982
Max	1.1022	1.0159	.9503	.8848	1.1145	1.21	1.0631
Min	.1311	.1478	.1311	.1311	.0934	.0819	.1311
Avg	.5273	.5451	.4715	.3192	.4321	.4220	.6810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 203 / 11 Kv Bhokaramba SS SINGLE PHASING

Poharegaon Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4							.0191
6					.0191		.0191
8		.0191			.0191		
10						.0164	
12				.0164			
14	.0191	.0164	.0164		.0191		
16	.0191	.0328	.0164	.0179	.0191	.0328	
18	.0191			.0191		.0191	
Max	.0191	.0328	.0164	.0191	.0191	.0328	.0191
Min	.0191	.0164	.0164	.0164	.0191	.0164	.0191
Avg	.0191	.0228	.0164	.0178	.0191	.0228	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7888	.6001		.6001	.1715		.1715
8	.9945	1.1145	1.2003		.3429	.3429	.4287
12	.1715	.1715	.1543	.1886		1.1145	.9088
16	.1715	.1372	.1543	.1372			.9945
17					1.0974		
20		.3944	.3258	.3429			.3944
24	.4801	.1715	.1715	.3601	.1543	.1715	.1372
Max	.9945	1.1145	1.2003	.6001	1.0974	1.1145	.9945
Min	.1715	.1372	.1543	.1372	.1543	.1715	.1372
Avg	.5213	.4315	.4012	.3258	.4415	.5430	.5059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1715	.1372		.1715	.3772		.4287
8	.3601	.3429	.3086	.3601	.7545	.8573	.6516
12	.823	.8573	.7716	.583		.1372	.1372
16	.8573	.823	.8573	.7202	.1543	.1372	.1543
20		.3086	.2915	.2743			.3086
24	.12	.1372	.1372	.1543	.2915	.2915	.2572
Max	.8573	.8573	.8573	.7202	.7545	.8573	.6516
Min	.12	.1372	.1372	.1543	.1543	.1372	.1372
Avg	.4664	.4344	.4732	.3772	.3944	.3558	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 203 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.0343	.0343	.0343	.0686			.0171
16	.0514		.0514	.0514	.0514	.0343	.0343
Max	.0514	.0343	.0514	.0686	.0514	.0343	.0343
Min	.0343	.0343	.0343	.0514	.0514	.0343	.0171
Avg	.0429	.0343	.0429	.06	.0514	.0343	.0257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 204 / 11 kV Andalgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0514	.0343		.0686	.0857		.1372
8	.0857	.0857	.1029	.1029	.1715	.1715	.2229
12	.2058	.2572	.2058	.1886			.0171
16	.1372	.1715	.1886	.2229	.0343	.0171	.0171
20			.0686	.0686			.0857
24		.0171	.0343	.0343	.0514	.0514	.0514
Max	.2058	.2572	.2058	.2229	.1715	.1715	.2229
Min	.0514	.0171	.0343	.0343	.0343	.0171	.0171
Avg	.1200	.1132	.1200	.1143	.0857	.08	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 205 / 11 kV Sangvi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7888	.5144		.6173	.12		.1715
8	.9088	.8916	.8745	.8745	.3944	.3601	.3772
12	.0686	.0857	.0686	.0514		1.0288	.8402
16	.1372	.0343	.0514	.0343	1.0117	.9431	.9088
20		.2915	.2915	.2401			.2743
24	.3772	.1715	.4287	.4458	.1029	.0857	.0857
Max	.9088	.8916	.8745	.8745	1.0117	1.0288	.9088
Min	.0686	.0343	.0514	.0343	.1029	.0857	.0857
Avg	.4561	.3315	.3429	.3772	.4073	.6044	.4430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 206 / 11 kV Kolgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2401	.1372		.2743	.7202		.7716
8	.3944	.3772	.4115	.3429	1.1831	1.3717	1.406
12	1.7147	1.749	1.4403	1.3546		.0857	.12
16	1.6289	1.5775	1.406	1.4232	.12	.12	
20		.3772	.3086	.3258			.3429
24	.1715	.1715	.1715	.1715	.583	.6001	.6001
Max	1.7147	1.749	1.4403	1.4232	1.1831	1.3717	1.406
Min	.1715	.1372	.1715	.1715	.12	.0857	.12
Avg	.8299	.7316	.7476	.6487	.6516	.5444	.6481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0669	.4755		.6173		1.1431
16	1.448		1.2041		.3963	
24	.4877	.2452				.6097
Max	1.448	.4755	1.2041	.6173	.3963	1.1431
Min	.4877	.2452	1.2041	.6173	.3963	.6097
Avg	1.0009	.3604	1.2041	.6173	.3963	.8764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4115	.4904		.3506		
16	.8688		.9602		.0934	
24	.1219	.1715		.1524		.4409
Max	.8688	.4904	.9602	.3506	.0934	.4409
Min	.1219	.1715	.9602	.1524	.0934	.4409
Avg	.4674	.3310	.9602	.2515	.0934	.4409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu (J) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.4175	1.2955		1.2346		.6653
16	.2263		.1981		1.21	
24	.4877	.4752		.381		.3696
Max	1.4175	1.2955	.1981	1.2346	1.21	.6653
Min	.2263	.4752	.1981	.381	1.21	.3696
Avg	.7105	.8854	.1981	.8078	1.21	.5175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 201 / 11 Kv Bittergaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.463	.4115	.3761	.3353	.394	.3429	
9							.3086
12		.1267		.1267			.362
16		.0905	.0848	.1075	.285		.362
17						.3086	
18	.1715						
20		.2896		.3439			.3258
23						.1715	
24	.12	.12	.1086	.1029	.1629	.1543	
Max	.463	.4115	.3761	.3439	.394	.3429	.362
Min	.12	.0905	.0848	.1029	.1629	.1543	.3086
Avg	.2515	.2077	.1898	.2033	.2806	.2443	.3396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 202 / Kamkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573	.823	.9412	.9156	1.6655	1.6907	
9							1.7147
12		1.7909		.5014			.1448
16		1.576	1.2929	1.2894	.2915		.2534
17						.2058	
18	.463						
20		.7964		.6878			.724
24	.2743	.463	.3439		.9412	.6203	.6001
Max	.8573	1.7909	1.2929	1.2894	1.6655	1.6907	1.7147
Min	.2743	.463	.3439	.5014	.2915	.2058	.1448
Avg	.5315	1.0899	.8593	.8486	.9661	.8389	.6874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 203 / 11 Kv W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0343	.0343	.0543	.0343	.0537	.0343	
9							.0514
12		.1267		.0543			.0543
16		.0543	.0514		.0526		.0543
17						.0686	
18	.0514						
Max	.0514	.1267	.0543	.0543	.0537	.0686	.0543
Min	.0343	.0343	.0514	.0343	.0526	.0343	.0514
Avg	.0429	.0718	.0529	.0443	.0532	.0515	.0533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 204 / Wanjarwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8861		1.97	1.757	.2328	.2401	
9							.1543
12		.1086		.1086			1.773
16		.0905	.12	.0905	1.9725		1.7372
17						1.6804	
18	.1543						
20		.2534		.2353			.2896
24	.7202	.7716	.8688	.5868	.1463	.1029	.0857
Max	1.8861	.7716	1.97	1.757	1.9725	1.6804	1.773
Min	.1543	.0905	.12	.0905	.1463	.1029	.0857
Avg	.9202	.3060	.9863	.5556	.7839	.6745	.8080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 205 / Faradpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2915		.3258	.3601	.4835	.4359	
9							.3944
12		.543		.4119			.0543
16		.4119	.4359	.4656	.0857		.1086
17						.0857	
18	.2572						
20		.2534		.3077			.1646
24	.1029	.1029	.1086	.1372	.2353	.2035	.2572
Max	.2915	.543	.4359	.4656	.4835	.4359	.3944
Min	.1029	.1029	.1086	.1372	.0857	.0857	.0543
Avg	.2172	.3278	.2901	.3365	.2682	.2417	.1958

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 206 / Wala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.703	.6859	.7059	.703	2.2624	1.9498	
9							1.7147
12		2.1312		2.1312			.2172
16			1.8351	1.8983	.2229		.2172
17						.2229	
18	.5144						
20		.4706		.6154			.543
24	.3086	.2743	.2896	.3086	1.1765	.7127	1.0288
Max	.703	2.1312	1.8351	2.1312	2.2624	1.9498	1.7147
Min	.3086	.2743	.2896	.3086	.2229	.2229	.2172
Avg	.5087	.8905	.9435	1.1313	1.2206	.9618	.7442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494		.112	.1029	.1966	.2058	.2543
2	.1509		.1494	.1029	.1943	.2401	.2515
3	.1886		.1494	.1029	.1943	.2401	.4973
4	.1886		.1848	.1715	.2429	.3772	.2818
5	.2801		.2957	.2572	.2721		.2818
6	.3772		.4108	.3429	.3201	.463	.3277
7	.4481		.4481	.4115	.3521	.5144	.3605
8	.4108	.3429	.3429	.3772	.4161	.5144	.3978
9			.2058	.3734	.4115	.3277	
10			.3772	.2683	.1715	.2195	
11			.3772	.3647	.1029	.1867	
12			.3772	.4144		.0747	
13			.3772	.4096	.1029	.0747	
14			.3772	.3563	.1029	.0747	
15			.3772	.3239	.0857	.0747	
16	.4458	.4801	.4801	.2949	.0857	.0747	.0747
17		.4915	.4801	.2721	.1029	.0934	.0747
18		.112	.1029	.0747	.1029	.2801	.112
19		.2561	.2401	.2241	.2572	.2801	.2987
20		.2987	.2743		.3086	.2801	.2614
21		.2614	.2401	.2427	.2058	.2241	.2241
22		.1867				.2241	.1867
23		.1494				.2614	.1867
24	.1494	.1372	.1372	.1372	.1943	.2058	.2401
Max	.4481	.4915	.4801	.4144	.4161	.5144	.4973
Min	.1494	.112	.1029	.0747	.0857	.0747	.0747
Avg	.2789	.2716	.2962	.2679	.2106	.2396	.2536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 202 / 11 KV BHRAMWADI -Ghavan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		.112	.1543	.3441	.3601	.3688
2	.1886		.112	.1543	.3605	.463	.373
3	.1886		.112	.1543	.3521	.6001	.3688
4	.2263		.1698	.2058	.4001	.7716	.4144
5	.3206		.2801	.2572	.5668	.9431	.5735
6	.3772		.4481	.3601	.9282	1.0288	.8192
7	.3961		.4435	.4115	.9922	1.3375	1.3927
8	.3961		.3601	.3086	1.166	1.4403	1.4746
9			.2572	.2241	1.1317	1.2289	
10			1.0288	.823	.1029	.2241	
11			1.3375	1.1869	.1029	.1886	
12			1.3889	1.2574	.0514	.0754	
13			1.3375	1.1797	.1029	.0747	
14			1.1317	1.1469	.1029	.0747	
15			1.2346	1.1523	.1029	.0747	
16	1.4403	1.3375	1.286	1.166	.1029		.0566
17		1.278	1.286	1.065	.1029		.056
18		.112	.1029	.0754	.1543	.168	.056
19		.2801	.2572	.2241	.3086	.2614	.2801
20		.2829	.2572	.2801	.3086	.2614	.2801
21		.2832	.2058	.2801	.2572	.2801	.2801
22		.1698		.2241		.1867	.2241
23		.1698		.1867		.2915	.2241
24	.1698		.1543	.1543	.3441	.3086	.2883
Max	1.4403	1.3375	1.3889	1.2574	1.166	1.4403	1.4746
Min	.1698	.112	.1029	.0754	.0514	.0747	.056
Avg	.3892	.4892	.6047	.5263	.3812	.4838	.4430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4578		.373	.4287	.2801	.2229	.3174
2	.5868		.4239	.4287	.2801	.2058	.3206
3	.7042		.5935	.5144	.3174	.2058	.3174
4	.788		.5735	.6001	.3772	.2572	.3734
5	.8383		.7042	.6859	.5041	.3429	.415
6	.8288		.7127	.7716	.5601	.463	.5228
7	.852		.8453	.8059	.5658	.5658	.5975
8	.9175	.8059	.9945	.8573	.4527	.5658	.6535
9			.8573	.7956	.3258	.5415	
10			.2058	.2801	.2572	.5765	
11			.2058	.2614	.7202	.6962	
12			.1886	.2241	.8059	.7773	
13			.1715	.2054	.9259	.8097	
14			.1715	.1494	.8916	.7682	
15			.1715	.168	.7545	.8002	
16	.2743	.1715		.1867	.7716	.6478	.8478
17		.2075	.1715	.1867	.7716	.6554	.8648
18		.2801	.2058	.2801	.1715	.2987	.2641
19		.4854	.4801	.4668	.463	.4108	.3547
20		.4854	.5144	.5041	.5144	.4668	.3734
21		.3734	.3772	.4338	.4458	.4668	.4668
22		.3361				.3734	.3734
23		.2987				.3361	.034
24	.3944	.3772	.2401	.3944			.3361
Max	.9175	.8059	.9945	.8573	.9259	.8097	.8648
Min	.2743	.1715	.1715	.1494	.1715	.2058	.034
Avg	.6642	.3821	.4372	.4377	.5313	.4980	.4372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 201 / 11 KV Dighol SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.8861	1.8861	1.8004	.7716	.8573	.9431
16	.5144	.3429	.2572	.2572	1.6289	1.8861	1.8861
24	.9431	.6001	.6001	.9431	.3429	.3429	.3429
Max	.9431	1.8861	1.8861	1.8004	1.6289	1.8861	1.8861
Min	.5144	.3429	.2572	.2572	.3429	.3429	.3429
Avg	.7288	.9430	.9145	1.0002	.9145	1.0288	1.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 202 / 11 KV Motegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6859	.6001	.5144	.6859	1.3717	1.5432	1.5432
16	1.3717	1.5432	1.2003	1.2003	.1715	.0857	.0857
24	.2572	.1715	.1715	.2572		.5144	.3429
Max	1.3717	1.5432	1.2003	1.2003	1.3717	1.5432	1.5432
Min	.2572	.1715	.1715	.2572	.1715	.0857	.0857
Avg	.7716	.7716	.6287	.7145	.7716	.7144	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 203 / 11 KV Bhokaramba SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288	.9431	1.0288	1.0288	.1715	.1715	.2572
16	.0857	.0857	.0857	.0857	1.0288	1.0288	1.0288
24	.5144	.3429	.3429	.4287	.0857	.1715	.1715
Max	1.0288	.9431	1.0288	1.0288	1.0288	1.0288	1.0288
Min	.0857	.0857	.0857	.0857	.0857	.1715	.1715
Avg	.5430	.4572	.4858	.5144	.4287	.4573	.4858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 203 / 11KV Khanapur(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1494
2				1.3817			
3					.2241		.1494
4	1.6057			1.7177		.2218	
5							.1867
6		2.3525			.2241		
7	2.3285	2.3525		2.2779			.2241
8	2.7721	2.9874			.2614	.2218	.2241
9		2.838		2.6427	.1867		.1867
10	.2033		.168		1.6057		1.4003
11		.1867			2.2405		
12			.168				1.9231
13	.1663	.1867			2.6139		
14					2.0538		
15		.1494					
16		.1494	.1867	.2033	2.5019		2.6326
17	.1494		.1867			2.5766	2.6513
18	.1494			.1867		.1494	.1494
19			.2241				.2054
20	.2054			.2614		.1867	.2427
21			.1867				.2241
22				.1867		.1867	.2054
23			.1867				.1867
24	1.7147			1.1576		.1867	
Max	2.7721	2.9874	.2241	2.6427	2.6139	2.5766	2.6513
Min	.1494	.1494	.168	.1867	.1867	.1494	.1494
Avg	1.0328	1.4003	.1867	1.1129	1.3236	.5328	.6838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.961
2				.037			
3					1.4937		1.2567
4	.0373			.037		1.46	
5							1.5893
6		.0373			2.0538		
7	.0373	.0373		.037			2.0513
8	.0373	.0373			2.3339	2.6612	2.0911
9		.037		.037	2.2177		1.5123
10	1.7926				.037		.0373
11		2.1068	1.885		.037		
12			1.9605				.0373
13	1.9774	1.9774			.037		
14					.037		
15		2.1622					
16		2.3101	2.1098	1.885	.037		.037
17	2.2405		1.7002			.037	
18				.0373		.037	1.2197
19			.037				1.5524
20	.0373			.0373		.037	.037
21			.037				.037
22				.0373		.037	.037
23			.037				.037
24	1.7147			.037		.7207	
Max	2.2405	2.3101	2.1098	1.885	2.3339	2.6612	2.0911
Min	.0373	.037	.037	.037	.037	.037	.037
Avg	.9843	1.0882	1.1095	.2424	.9205	.7128	.8329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 205 / 11kv Utti w/w express
feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 206 / 11kv Old midc of 33KV AUSA SHEDDABLE FEEDER HAVING WEEKLY
sub Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.112
2			.168			
3						.0934
4			.1494		.0924	
5						.112
7			.1307			.112
8					.0739	.0747
9	.112		.1294	.112		
10				.168		
11	.2054			.4108		
13	.168			.4108		
14				.3361		
15	.168					
16	.2241		.2587	.2987		.5228
17		.2241			.2054	.3361
18					.2241	.1867
19		.0747				.0747
20					.0747	.0747
21		.0747				.0747
22					.0747	.112
23		.168				.1494
24			.168		.1109	
Max	.2241	.2241	.2587	.4108	.2241	.5228
Min	.112	.0747	.1294	.112	.0739	.0747
Avg	.1755	.1354	.1674	.2894	.1223	.1566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Karajgaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV Ausa

Feeder No / Name : 208 / 11 KV Almala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.2587
2				.2218			
3							.2402
4	.2801			.2957		.2402	
5							.2957
7	.5601			.5175			.5914
8	.5041					.4805	.4435
9		.3881			.3326		
10					.2957		
11		.2801			.2772		
13		.2957			.2957		
14					.2402		
15		.2587					
16		.2957		.2402	.2587		.2772
17			.3142			.2772	.2772
18						.3326	.3326
19			.462				.4805
20						.3696	.4805
21			.3881				.4251
22						.3326	.3696
23			.2772				.3326
24	1.7147			.2587		.2587	
Max	1.7147	.3881	.462	.5175	.3326	.4805	.5914
Min	.2801	.2587	.2772	.2218	.2402	.2402	.2402
Avg	.7648	.3037	.3604	.3068	.2834	.3273	.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 201 / 11KV Bhada Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 202 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1288	.1299	.1299		.1296	.2273	.1127
2	.1288		.1299		.1296	.2273	.0966
3	.1449	.1299	.1299		.1296	.2273	.1127
4	.161	.1627	.1623		.1619	.2597	.1288
5	.1932	.1948	.1948		.1943	.2597	.161
6	.2254	.2278	.2273		.2267	.2597	.1932
7	.2898	.2603	.2922		.2591	.2922	.2898
8	1.2986	.2597	.2922		.2915	.2597	.2737
9	1.3635	1.2986				.2512	.2515
10	1.396	1.2366				.2198	.1909
11	1.3667					.1925	.1591
12	1.3667					.1604	.0955
13	1.3635					.1283	.0955
14	1.331					.0963	.0955
15	1.331					.0802	.0795
16	.0651					.0963	.0795
17	.0974		.0642			1.6363	1.4636
18	.1305					1.524	1.4636
19	.1627		.2283			1.6042	1.2409
20	.2281			.1966		1.5721	1.0818
21	.2278			.2294		1.4758	1.0831
22	.1952			.1966		1.3475	1.0512
23	.1627	.1623		.1638		1.1871	1.0194
24	1.7147	.1299	.1299	.0956	.1311	1.1064	1.1269
Max	1.7147	1.2986	.2922	.2294	.2915	1.6363	1.4636
Min	.0651	.1299	.0642	.0956	.1296	.0802	.0795
Avg	.6280	.3811	.1801	.1764	.1837	.6121	.4978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 203 / 11KV Baranpur Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0764	.7792	1.0064		.0676	.2273	.1957
2	1.1742	1.0064	1.2986		.0676	.2273	.1957
3	1.2394	1.2012	1.331		.1014	.2597	.2283
4	1.3373	1.2012	1.4318		.1014	.2922	.2936
5	1.3699	1.3016	1.6232		.1352	.3246	.3262
6	1.4678	1.4934	1.6921		.169	.422	.3588
7	1.5656	1.6232	1.6921		.2028	.422	.4729
8	1.6309	1.6557	1.6557		.2028	.7467	.4403
9	.3254	.3896				1.1617	.8817
10	.2929	.2597				1.2873	1.0776
11						1.4167	1.1429
12	.2603					1.3201	1.2409
13	.2283					1.2557	1.045
14	.1952					1.2074	1.2409
15	.1952					1.2396	.8817
16	.2597					1.2879	1.1756
17	.2922		.1306			.1127	.098
18	.3254					.161	
19	.3579					.2898	.2612
20	.3896			.1014		.3059	.1633
21	.3571			.1352		.2576	.3269
22	.3254			.1014		.2254	.2615
23	.2597	.2273		.1014		.2254	.1962
24	1.7147	.1948	.1948	.1959	.0676	.2273	.212
Max	1.7147	1.6557	1.6921	.1959	.2028	1.4167	1.2409
Min	.1952	.1948	.1306	.1014	.0676	.1127	.098
Avg	.7235	.9444	1.2056	.1271	.1239	.6210	.5529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 204 / 11KV Korangala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0981	.0979	.1296		.7868	.7535	.9459
2	.0981	.0974	.1302		.7554	.9739	.9785
3	.1144	.1299	.1627		.7868	.9762	1.0474
4	.1308	.1302	.1948		.8498	1.2559	1.109
5	.1635	.1627	.2273		.8813	1.2559	1.1742
6	.2289	.1948	.2603		.8498	1.3187	1.3047
7	.2615	.2597	.3246		.8813	1.4129	1.4351
8	.1635	.3091	.2597		.8813	.157	1.3699
9	.1948	.211				.157	.0925
10	.1948	.1623				.1952	.1541
11	.1623					.1638	.0925
12	.1299					.1147	.0617
13	.0974					.0819	.0617
14	.0976					.0819	.0617
15	.0972					.0819	.0308
16	.7484					.0819	.0308
17	1.2337		1.0973			.0819	.0617
18	1.2661					.0819	.0925
19	1.3342					.1305	.185
20	1.3635			1.1331		.1957	.185
21	1.331			1.0072		.1631	.185
22	1.2986			.9757		.1305	.1541
23	1.2012	1.3001		.8341		.0979	.1233
24	1.7147	.0976	1.2986	.8685	.8183	.2512	.0979
Max	1.7147	1.3001	1.2986	1.1331	.8813	1.4129	1.4351
Min	.0972	.0974	.1296	.8341	.7554	.0819	.0308
Avg	.5718	.2627	.4085	.9637	.8323	.4248	.4598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 205 / 11KV utti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2098	.2597	.2441		.2267	.2826	.2267
2	.2259	.2273	.2441		.2915	.2355	.2267
3	.2259	.2278	.2922		.2853	.2355	.2915
4	.2582	.2597	.3571		.3077	.2922	.3077
5	.2905	.2922	.4545		.3563	.3567	.3563
6	.4196	.3579	.487		.3887	.4582	.3887
7	.5002	.4881	.5194		.4534	.471	.4858
8	.4196	.4545	.4545		.4696	.4082	.4696
9	1.4301	1.4643				.314	.3254
10	1.5674	1.6232				.2826	.2603
11	1.6232					.2615	.1952
12	1.6596					.2286	.1627
13	1.5908					.1959	.1464
14	1.5908					.1959	.1139
15	1.5583					.1959	.1302
16	.2435					.2123	.1464
17	.2441		.1642			1.9593	1.3667
18						1.8613	1.8223
19	.2929					1.9803	1.7084
20	.3571			.3563		1.8829	1.7084
21	.422			.3887		1.6557	1.6309
22	.4881			.3239		1.5583	1.5656
23	.3254	.3246		.2753		1.4609	1.5004
24	1.7147	.2597	.2441	.2619	.2267	.2918	1.4089
Max	1.7147	1.6232	.5194	.3887	.4696	1.9803	1.8223
Min	.2098	.2273	.1642	.2619	.2267	.1959	.1139
Avg	.7677	.5199	.3461	.3212	.3340	.7199	.7060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 206 / 11KV kalmatha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4609	1.0064	.8786		.1268	.1623	.1623
2	1.6232	.8413	1.3667		.1585	.1623	.1948
3	1.7531	1.3635	1.5945		.1902	.1952	.1948
4	1.818	1.4284	1.627		.2219	.2278	.2273
5	2.1427	1.6232	2.0826		.2219	.2597	.2273
6	2.2725	2.0777	2.2779		.2853	.2597	.2922
7	2.5322	2.4998	2.2725		.2853	.2603	.3896
8	2.1427	2.4348	2.2779			.487	.3246
9	.2273	.3239				2.2779	1.5089
10	.1623					1.8874	2.2005
11	.1299					2.4177	2.452
12	.1299					2.5789	2.5149
13	.0974					2.4822	2.2005
14	.0974					2.5789	2.1691
15	.0976					2.4177	2.2319
16	.1299					2.2888	2.2319
17	.1299		.0664			.0645	.0629
18	.1627					.0967	.0943
19	.2278					.2915	.2201
20	.2603			.1585		.322	.2201
21	.2922			.2219		.2591	
22	.2603			.1902		.2267	.1957
23	.2273	.2273		.1585		.1943	.1957
24	1.7147	.3571	.3254	.1285	.1268	.1623	.1623
Max	2.5322	2.4998	2.2779	.2219	.2853	2.5789	2.5149
Min	.0974	.2273	.0664	.1285	.1268	.0645	.0629
Avg	.8372	1.2894	1.4770	.1715	.2021	.9400	.8989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.2572
8		.8745	.7926	.823		.1981	
11		.0914					
16			.0686		.6249	.6859	
24	1.7147	.3086		.2572			.1372
Max	1.7147	.8745	.7926	.823	.6249	.6859	.2572
Min	1.7147	.0914	.0686	.2572	.6249	.1981	.1372
Avg	1.7147	.4248	.4306	.5401	.6249	.442	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.7202
8		.2229	.2743	.1543		1.2803	
11		1.1431					
16			1.3889		.061	.0514	
24	1.7147	.12		.0857			.4115
Max	1.7147	1.1431	1.3889	.1543	.061	1.2803	.7202
Min	1.7147	.12	.2743	.0857	.061	.0514	.4115
Avg	1.7147	.4953	.8316	.12	.061	.6659	.5659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 203 / 11KV HASEGAONWADI
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 201 / 11KV Matola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.7147	1.989
16			.3086	.2743
18				.2743
19		.6001		
24	1.7147		1.286	1.2346
Max	1.7147	.6001	1.7147	1.989
Min	1.7147	.6001	.3086	.2743
Avg	1.7147	.6001	1.1031	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 202 / 11kv water works express NON SHEDDABLE WATER SUPPLY AND
feede Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0667	.0857	.0857	.0857	.0171
16	.0857	.0857	.0857	.0857	
24	1.7147	.0857	.0857	.0857	.0857
Max	1.7147	.0857	.0857	.0857	.0857
Min	.0667	.0857	.0857	.0857	.0171
Avg	.6224	.0857	.0857	.0857	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 204 / Devtala Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5335	.5144	.583	.6859	1.5432
16	1.3032	1.4575		1.286	
24	3.4294	.1715	.2058	.2572	.8573
Max	3.4294	1.4575	.583	1.286	1.5432
Min	.5335	.1715	.2058	.2572	.8573
Avg	1.7554	.7145	.3944	.7430	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 205 / Kavli Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6004	2.2291	.823	2.0576	.2572	.4115	.2058
16	2.2291	2.2977	1.8347	.0857	1.2346	1.2346	1.2003
24	1.7147	1.2003	1.2689	1.2517	.1715	.1715	.1372
Max	2.2291	2.2977	1.8347	2.0576	1.2346	1.2346	1.2003
Min	1.6004	1.2003	.823	.0857	.1715	.1715	.1372
Avg	1.8481	1.9090	1.3089	1.1317	.5544	.6059	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 201 / 11kv Belkund

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.6706	
10	.6706		1.0059
24	1.7147		
Max	1.7147	.6706	1.0059
Min	.6706	.6706	1.0059
Avg	1.1927	.6706	1.0059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 202 / 11kv Tawshi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.2515	
10	.2801		.2515
24	1.7147		
Max	1.7147	.2515	.2515
Min	.2801	.2515	.2515
Avg	.9974	.2515	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 203 / 11 kv Karkhana Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)
10		.0187
24	1.7147	
Max	1.7147	.0187
Min	1.7147	.0187
Avg	1.7147	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 204 / Gukheda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.2372	
10	.2429		.2372
24	1.7147		
Max	1.7147	.2372	.2372
Min	.2429	.2372	.2372
Avg	.9788	.2372	.2372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 205 / Malumbra Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.6478	
10	.6325		.9717
24	1.7147		
Max	1.7147	.6478	.9717
Min	.6325	.6478	.9717
Avg	1.1736	.6478	.9717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 206 / Davakhana Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.0934	
10	.0934		.0934
24	1.7147		
Max	1.7147	.0934	.0934
Min	.0934	.0934	.0934
Avg	.9041	.0934	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.1336	1.3443	1.4937	.3018	.3395	.3239
2	1.587	1.2631	1.3817	1.8671	.3018	.3395	.2915
3	1.8298	1.3279	1.6804	2.0538	.3395	.415	.2915
4	1.8671	1.4575	2.0538	2.8006	.3772	.5281	.3563
5	2.0538	1.7284	2.8006	2.894	.4904	.6036	.4858
6	2.7633	2.3403	2.894	2.9874	.7545	.679	.6802
7	2.8006		2.9127	3.0247	.7545	.7545	.3239
8	2.8753	2.4036	2.95	2.8006	.7545	.679	.6478
9	2.9127	2.9687	2.7633	2.8006	.5658	.5182	.5182
10	.3978	.415	.3772	.3772	2.0538	1.7814	1.6194
11	.2984	.3018	.3018	.3018	2.4646	2.3482	2.0805
12	.2652	.2263		.2263	2.5766	2.4615	2.3365
13	.2486	.2263	.1886	.1886	2.4272		2.3525
14	.1989	.2263	.1886	.1886	2.6139		2.3685
15	.1658	.2263	.2263	.2263	2.6513	2.332	2.3685
16	.1658	.2263	.2641	.3018	2.726	.8097	2.3685
17	.1989	.2263	.3772	.3018	2.6513	2.4291	2.3685
18	.4144	.415	.4527	.415	.4715	.2915	.2321
19	.6554	.7545	.7545	.7545	.7545	.6478	.7373
20	.5898	.7167	.7545	.7545	.5658	.6154	.5735
21	.5243	.5658	.679	.6036	.6036	.583	.4973
22	.4641	.3772	.5658	.5658		.4858	.4161
23	1.7147	.415	.4904	.415	.415	.3563	.3315
24	.7842	1.004	1.1203	1.1203	.3772	.3772	.3239
Max	2.9127	2.9687	2.95	3.0247	2.726	2.4615	2.3685
Min	.1658	.2263	.1886	.1886	.3018	.2915	.2321
Avg	1.1269	.9107	1.1966	1.2277	1.2171	.9262	1.0372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1478	.1509	.1509	.5658	.5975	.5658
2	.1886	.1478	.1509	.1509	.6036	.5975	.6036
3	.2641	.2218	.1886	.1509	.7545	.6722	.6036
4	.3395	.3326	.3772	.2263	.9335	.7095	.6413
5	.5281	.4572	.4715	.3772	1.1949	.8215	.7545
6	.5658	.6401	.6036	.5658	1.307	1.0456	1.3203
7	.7167	.695	.679	.7545	1.307	1.1949	1.4335
8	.7545	.7421	.7545	.6036	1.307	1.1576	1.3756
9	.5281	.5658	.5281	.4527	1.3443	1.2826	1.2449
10	.5853	.6161	.8215	.8962	.3772	.3772	.3326
11	.8507	.8215	1.1203	1.1317	.2263	.1886	.1294
12	.9774	1.0456	1.1203	1.0829	.1509	.1509	.1109
13	1.0498	1.1203	1.0456	1.0456	.1132	.1132	.0924
14	1.1104	1.0829	1.0456		.1132	.1132	
15	1.0745	1.1203	1.0829	1.0829	.1132	.1132	
16	1.0387	1.1203	1.1203	1.1203	.1132	.1132	.1478
17	.9671	1.1203	1.1203	1.1203	.1132	.1132	.1478
18	.3326	.3584	.3018	.2641	.1886	.1886	.1848
19	.5487	.5281	.415	.3772		.5281	.3326
20	.439	.4715	.3772	.415	.415	.4904	.462
21	.3696	.3584	.3395	.3018	.3772	.4527	
22	.2865	.2829	.2263	.2641	.3395	.3395	.3326
23	.2218	.2263	.1886	.1886	.1886	.1886	.1848
24	1.7147	.1848	.1886	.1886	.415	.4481	.415
Max	1.7147	1.1203	1.1203	1.1317	1.3443	1.2826	1.4335
Min	.1509	.1478	.1509	.1509	.1132	.1132	.0924
Avg	.6501	.6003	.6008	.5614	.5462	.4999	.5436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 201 / 11 KV Pethe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 202 / 11kv Selu

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 203 / 11kv ALMALA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 204 / 11KV Khuntegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
23	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 205 / 11KV Budhoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 206 / 11KV Hasala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 201 / 11KV Tungi Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	2.2779
Max	2.2779
Min	2.2779
Avg	2.2779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 202 / 11 KV Nagarsoga Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 203 / 11KV Gadavewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.335	.3326	.3423	.3416	.3419	1.6604	1.7315
2	.3344	.3326	.3419	.3416	.3799	.3381	.2716
3	.3734	.3533	.4179	.417	.4175	.3765	.3056
4	.4116	.4108	.4929	.5118	.455	.4158	.3735
5	.4715	.6023	.6818	.6054	.5687	.5693	.5093
6	.7938	.8694	.7567	.9261	.7371	.8135	.7469
7	1.0384	1.094	.9828	1.0384	.9818	.9619	.9528
8	.9828	1.0552	1.094	1.0384	1.0185	.9068	.8857
9	.8307	.9044	.7204	.6804	.8358	.811	.7494
10	1.1092	1.396	1.3748	1.483	.4934	.4448	.417
11	1.8667	2.1201	1.9662	2.086	.2598	.2053	.2824
12	2.1136	2.2262	2.1779	2.0477	.2415	.2053	.2243
13	2.275	2.2181	2.1498	2.0837	.1821	.2053	.2037
14	2.2926	2.2181	2.1399	2.0524	.2012	.2053	.184
15	2.3285	2.2206	2.1136	2.021	.2014	.1711	.1829
16	2.135	2.1944	2.13	2.0454	.2029	.2395	.1818
17	2.4367	2.1845	1.8023	2.1509	.2037	.2395	.2435
18	.4909	.417	.3961	.3799	1.8918	1.9846	2.1002
19	.6735	.6811	.7182	.759	2.3807	2.3138	2.445
20	.6011	.6426	.7189	.7204	2.216	2.1097	2.1904
21	.4711	.4909	.5847	.5303	1.9618		1.9498
22	.3929	.4175	.412	.4554	1.9135	1.8333	1.7604
23	.3529	.4183	.3795	.4179	1.8382	1.8333	1.7814
24	.3164	.332	.3803	.3602	.3799	1.752	1.7714
Max	2.4367	2.2262	2.1779	2.1509	2.3807	2.3138	2.445
Min	.3164	.332	.3419	.3416	.1821	.1711	.1818
Avg	1.0595	1.0888	1.0531	1.0622	.8460	.8955	.9352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 202 / 11 KV Bheta Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2259	.2096	.2286	.2282	.2286	.2467	.2716
2	.5953	.5999	.6738	.7133	.1905	.2462	.2728
3	1.0069	.8939	1.5583	.9297	.2286	.2852	.2028
4	1.1145	1.1139	1.5982	1.0802	.2667	.3419	.2366
5	1.3496	1.4335	1.6556	1.2186	.3423	.417	.3747
6	1.6004	1.6921	1.6946	1.4368	.4939	.6465	.478
7	1.904	1.9304	1.7901	1.702	.6072	.7218	.6458
8	1.8785	1.5553	1.9091	1.646	.6452	.6648	.6584
9	1.7903	1.7382	1.6576	1.6023	.4183	.5698	.4758
10	.2279	.3784	.1901	.3021	.1124	1.2955	1.1797
11	.1898	.2659	.1715	.2282	1.3735	1.5617	1.4914
12	.1328	.1901	.1334	.1141	1.6364	1.8333	1.6701
13		.1143	.1143	.0953	1.7405	1.5617	1.6404
14	.133	.0953	.1518	.0953	1.7185		1.6228
15	.1898	.0953	.1509	.1143	1.6655	1.6296	1.6089
16	.2079	.1143	.1501	.1143	1.6384	1.6975	
17	.2337	.1143	.1125	.1518	1.6975	1.7315	1.5993
18	.3977	.2275	.1494	.1898	.1896	.1698	.1331
19	.5271	.5313	.4158	.5676	.5123	.4092	.4522
20	.4545	.4919	.5297	.4934	.4725	.5785	.5297
21	.3419	.4179	.3969	.4559	.4338		.4744
22	.3042	.3423	.3402	.3423	.3423	.3418	.3409
23	.2477	.2659	.3232	.3042	.2477	.2734	.2858
24	1.7147	.2286	.2662	.2852	.2659	.2286	.2393
Max	1.904	1.9304	1.9091	1.702	1.7405	1.8333	1.6701
Min	.1328	.0953	.1125	.0953	.1124	.1698	.1331
Avg	.7290	.6267	.6817	.6005	.7278	.7933	.7341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 203 / 11Kv Borgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 201 / 11KV Shivali Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8023	1.9204	2.0805	1.9662	.3239	.3201	.3201
2	2.13	2.0805	2.0805	2.13	.3239	.3201	.3201
3	2.13	2.3205	2.2405	2.3758	.4049	.3201	.3201
4	2.2119	2.4006	2.4006	2.6216	.4049		.3201
5	2.2939	2.4806	2.6406	2.7854	.4858	.4001	.4001
6	2.3758	2.5606	2.7206	2.6216	.4858	.4801	.4858
7	1.9662	2.7206	2.7206	3.0312	.5668	.5601	.5668
8	1.8023	2.7206	2.8006	3.0312	.4858	.5601	.5668
9	.4001	.4801	.5601	.4858	2.5606	2.2405	2.6216
10	.4858	.4001		.4049	2.7206	2.4577	2.2405
11	.4049			.3239	2.7206	2.4577	2.4806
12	.3239	.3201		.3239	2.7206	2.7854	2.6406
13	.3239	.3201	.3201	.3239	2.5606	2.8673	2.4006
14	.3239	.3201	.3201	.3239		2.7035	
15		.3201	.3201	.3239	2.8006	2.7035	2.3205
16	.3239	.3201	.3201	.2429	2.8006	2.7035	2.5758
17	.3239	.3201	.2401	.3239	.3201	.2401	.2429
18	.3239	.3201	.2401	.3239	.3201	.3201	
19	.4858	.4001	.4001	.4049	.4001	.4001	.4858
20	.4858	.4801	.4801	.4858	.4801	.4858	.4858
21	.4049	.4801	.4001	.4858	.4801	.4858	.4858
22	.4858	.4001	.3201	.4049	.4001	.4001	.4049
23	.4049	.4001	.3201	.4049	.4001	.4001	.4049
24	1.7147	.3239	.4001	.3201	.3239	.4001	.3201
Max	2.3758	2.7206	2.8006	3.0312	2.8006	2.8673	2.6406
Min	.3239	.3201	.2401	.2429	.3201	.2401	.2429
Avg	1.0404	1.0787	1.1584	1.1029	1.1083	1.1744	1.0641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.2429	.3201	.3201	.2429	.3239	.3201
2	.3201	.2429	.3201	.3201	.2429	.3239	.3201
3	.3201	.2429	.3201	.3201	.2429	.3239	.3201
4	.3201	.3239	.3201	.3201	.3239	.3239	
5	.3201	.4049	.4001	.3201	.4049	.3239	.3201
6	.3201	.4049	.4001	.4001	.4049	.4049	.4001
7	.3201	.4049	.4001	.3201	.4858	.4049	.4001
8	.3201	.4858	.4049		.4049	.4049	.4001
9	2.0481	1.1336	2.1052	1.8023	.3239	.3239	.3201
10	2.0805	.6478	2.13	2.0124	.3258	.3201	
11	2.1605	2.2672	2.13	1.7604	.3239	.3201	
12	2.2405	2.4291	2.2939	1.9204	.3239	.16	.1619
13	2.3205	2.2672	2.13	1.6804	.2429	.16	.1619
14	2.3205	2.4291	2.13	1.8404		.16	.1619
15	2.2405		2.2119	2.0005	.2429	.16	.1619
16	2.2405		2.2939	2.1605	.2429	.16	.1619
17		1.4575	.16	.16	2.2672	2.5396	2.2672
18	.2415	1.4575	.16	.2401	2.4291	2.2939	2.1176
19	.3239	.3239	.2401	.3201	2.2672	2.0481	
20	.4049	.4049	.3201	.4049	2.1052	1.9662	1.8733
21	.3239	.4049	.3201	.4049	2.1052	1.9662	1.7918
22	.3239	.3239	.3201	.3239	2.0243	1.9662	1.7918
23	.3239	.3239	.3201	.3239	1.8623	1.8842	1.7104
24	1.7147	.2429	.3201	.3201	.2429	1.7814	1.8023
Max	2.3205	2.4291	2.2939	2.1605	2.4291	2.5396	2.2672
Min	.2415	.2429	.16	.16	.2429	.16	.1619
Avg	1.0378	.8576	.9363	.8694	.8732	.8768	.8482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 203 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 201 / 11KV Gondri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.4022	1.6804	1.5947	.8488	.6706	.6535
2	1.4754	1.5242	1.8671	1.8004	.811	.7011	.5601
3	1.6263	1.7985	2.2405	1.9547	.7922	.6554	.5601
4	1.8107	1.829	2.4272	2.0919	.8488	.7316	.6535
5	1.9113	2.0424	2.6139	2.2977	.9242	.7621	.7468
6	2.2131	2.1338	2.8006	2.5206	.9997	.6554	.9335
7	2.4143	2.3777	2.9874	2.6749	1.094	.5944	1.0269
8	2.6322	2.4082	3.1741	2.7949	1.0562	.4877	1.0269
9	2.3137	2.4387	2.4272	2.5549	.9808	.6097	.8402
10	.7167		.7842	.9619	1.643	1.829	2.2405
11	.4572	.6535	.4973	.5658	1.829	2.6139	2.5377
12	.4268		.4287	.4527	2.1338	2.7073	2.6235
13				.415	2.1033	2.8006	2.692
14	.4572	.5601		.3395	2.1643	2.894	2.572
15	.5182	.4668		.3961	1.5394	2.9874	2.4691
16	.5335	.4668		.3584	1.829		2.7435
17	.5487	.4108	.4458	.415	2.1491		2.6406
18	.5182	.4481	.5144	.4715	.7316	.6535	.6516
19	.4572	.7468	.9088	1.0751	.7011	.8402	.9431
20	.4268	1.0269	.9945	1.1128	.7621	1.0269	.9945
21	.3963	.9335	.9945	1.094	.6706	.9335	.9945
22	.4115	.7468	.9431	1.0185	.6097	.8402	.8573
23	.4877	.7095	.8573	.9054	.6401	.7468	.7545
24	1.7147	1.0669	1.307	1.3203	.8676	.6097	.6535
Max	2.6322	2.4387	3.1741	2.7949	2.1643	2.9874	2.7435
Min	.3963	.4108	.4287	.3395	.6097	.4877	.5601
Avg	1.1229	1.2472	1.5447	1.2994	1.1971	1.2432	1.3904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 202 / 11KV Dhanora SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4268	.4854	.3429	.8939	.8993	1.4937
2	.415	.442	.4854	.4287	1.0288	1.1888	1.4937
3	.4527	.4572	.5228	.5144	1.2071	1.4327	1.6804
4	.5847	.5182	.5228	.583	1.4586	1.6766	1.8671
5	.6979	.5487	.5601	.6516	1.6095	1.8595	2.0538
6	.7922	.5792	.6535	.7202	1.8442	2.0729	2.4272
7	.8676	.6097	.8962	.7716	2.1628	2.1795	2.7073
8	.7733	.6401	.7468	.6859	2.3807	2.3167	3.0807
9	.679	.5487	.5975	.5658	2.4813	1.2955	2.9874
10	1.6095		2.2405	1.7939	.3961	.3048	.3734
11	1.5242		2.3491	2.1963	.2743	.3361	.2915
12	1.89		2.4348	2.431	.1829	.2801	.2401
13	1.9509	2.8006	2.6578	2.4813	.1677	.2987	.1886
14		3.1741	2.5892	2.5484	.1981	.3361	.2229
15		3.0807	2.5377	2.4478	.1981	.3734	.2743
16	1.4937	3.1741	2.6749	2.5316	.1829		.2229
17	1.5242	3.2674	2.7949	2.4478	.1829		.2572
18	.2743	.2614	.3772	.2641	.2743	.3734	.4287
19	.3048	.5601	.5144	.6036	.3353	.7468	.6516
20	.3506	.8402	.7202	.679	.3963	.6535	.7202
21	.3963	.7468	.6173	.6413	.442	.6535	.6001
22	.3353	.5601	.5144	.5658	.4572	.5601	.5144
23	.4268	.4668	.4458	.4904	.4877	.5228	.4458
24	1.7147	.4115	.4481	.3944	.6878	.6554	1.307
Max	1.9509	3.2674	2.7949	2.5484	2.4813	2.3167	3.0807
Min	.2743	.2614	.3772	.2641	.1677	.2801	.1886
Avg	.8843	1.1483	1.2245	1.1575	.8304	.9553	1.1054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154092 / 33KV Wanwada S/S

Feeder No / Name : 203 / 11 KV Wanwada feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3206	.3206	.3206	.2378	.3206	.2829
2	.3395	.3206	.3206	.3206	.2452	.3206	.2641
3	.3395	.3206	.3395	.3395	.2641	.3206	.2641
4	.3395	.3206	.3395	.3395	.2641	.3206	.2829
5	.3206	.3206	.3395	.3395	.2641	.3206	.2829
6		.3395	.3206	.3206	.2641	.3206	.2829
7	.3018	.3584	.3584	.3395	.2829	.3206	.2829
8	.3206	.3584	.3584	.3395	.3206	.3395	.3395
9	.3961	.3772	.415	.2829	.415	.3206	.3584
10	.8676	.6413	.6413	.3772	.6224	.3018	.4338
11	.679	.6224	.7545	.3772	.6224	.3395	.4338
12	.7545	.679	.6413	.3206	.6036	.3206	.3961
13	.679	.6036	.5658	.3018	.6036	.2829	.4338
14	.7922	.4715	.5658	.3206	.5847	.3018	.6602
15	.6413	.6036	.5847	.3395	.5658	.3206	.547
16	.5847	.415	.5847	.3772	.6224	.3206	.6602
17	.679	.4715	.5847	.3395	.6224	.3206	.6979
18	.7356	.4715	.6036	.3395	.7545	.3206	.6036
19	.6602	.547	.6413	.3018	.6224	.3206	.547
20	.679	.5093	.5658	.3206	.4904	.2829	.5847
21	.3584	.3584	.5093	.3021	.3018	.2452	.3584
22	.3395	.3206	.3395	.2641	.2641	.2641	.3206
23	.3395	.3206	.3206	.2641	.2829	.2641	.3395
24	1.7147		.3395		.2641	.3206	.3018
Max	1.7147	.679	.7545	.3772	.7545	.3395	.6979
Min	.3018	.3206	.3206	.2641	.2378	.2452	.2641
Avg	.5740	.4379	.4731	.3256	.4327	.3096	.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201	.6556	.6626	.6556	.6984	.7087	.6984
2	.5847	.6379	.6268	.6201	.6805	.691	.6626
3	.567	.6379	.6268	.6379	.6984	.691	.6984
4	.567	.6379	.6447	.6379	.7164	.691	.7164
5	.6379	.6733	.6447	.7442	.7164	.7619	.7164
6	.7087	.815	.788	.7973	.8954	.8682	.8417
7	.7973	.8859	.8775	.9036	.9134	.9391	.9671
8	.9922	.9922	.985	.9745	.9568	.9922	.985
9	.8682	.9214	.8596	.9391	.8859	.9036	.8775
10	.815	.9313	.7796	.8859	.9391	.9134	.8859
11	.7973	.985	.8328	.815	.8682	.7701	.8328
12	.7973	.788	.815	.815	.815	.9134	.8505
13	.8505	.8954	.7973	.7973	.8682	.9134	.8505
14	.7973	.8059	.7619	.8859		.8596	.9214
15	.7265	.8059	.7442		.9391	.8417	.8238
16	.7973	.8059	.7796	.7973	.9391	.8417	.7796
17	.8328	.8059	.7973	.8059	.9036	.8059	.8775
18	.9036	.8775	.8505	.9313	1.0099	.8417	1.0745
19	1.0277	1.0208	1.0099	1.0566	1.134	.9671	1.1104
20	1.0099	.9492	.9568	.9745	1.0454	.9671	1.0208
21	.8859	.9492	.9214	.985	.9568	.9313	.985
22	.8328	.9134	.8859	.9134	.9214	.9134	.985
23	.7796	.8059	.7796	.8238	.815	.8059	.8954
24	1.7147	.691	.7265		.7701	.7265	.7343
Max	1.7147	1.0208	1.0099	1.0566	1.134	.9922	1.1104
Min	.567	.6379	.6268	.6201	.6805	.691	.6626
Avg	.8296	.8286	.7981	.8362	.8733	.8441	.8663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.7964	.695	.6878	.7682	.7964	.7865
2	.6697	.7783	.6767	.6697	.7499	.7783	.8048
3	.6697	.7602	.695	.6878	.7682	.7783	.823
4	.6878	.7783	.7133	.724	.8048	.7783	.823
5	.724	.8326	.7499	.7421	.823	.8507	.8413
6	.8145	.9231	.8962	.8688		.9593	.9694
7	.905	1.0679	1.134	.9231	1.0974	1.0317	1.0974
8	1.0317	1.0498	1.0059	.9955	1.1403	1.1584	.9877
9	1.086	1.086	.8779	1.0679		.9231	1.0242
10	.9955	1.0059	.8326		.8869	.8413	.905
11	.8869	.9694	.7602	.8507	.8145	.8779	.8145
12	.8326	.8962	.7783	.8145	.8326	.7682	.6878
13	.8507	.8779	.7602	.8145	.8688	.7865	.8326
14	.8145	.8048	.724	.8688	.8688	.7865	.8688
15	.7964	.8048	.724	.8145	.7964	.8413	.8413
16	.8145	.823	.7602	.8326	.8507	.8779	.8688
17	.8326	.8413	.7783	.7682	.8688	.8413	.8962
18	.8688	.9145	.905	.8779	.905	.8779	1.0974
19	1.1403	1.2071	1.1041	1.134	1.2308	1.1157	1.2071
20	1.1041	1.1888	1.1584	1.1403	1.1765	1.1523	1.2254
21	1.0136	1.0791	1.0136	1.0608	1.086	1.0791	1.1523
22	.9231	.9511	.9231	.9877	.9955	1.0059	1.0425
23	.8688	.7865	.7783	.8596	.9231	.9145	.9145
24	1.7147	.8145	.724		.8048	.8326	.8596
Max	1.7147	1.2071	1.1584	1.1403	1.2308	1.1584	1.2254
Min	.6697	.7602	.6767	.6697	.7499	.7682	.6878
Avg	.9063	.9182	.8403	.8723	.9119	.9022	.9321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 201 / 11KV Ashiv Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 202 / 11 KV Taka feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 204 / 11 kv Ujani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 206 / 11 kv Ekambi Feeder

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 404 / 33KV Matola

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(NON CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157002 / 132 kv Ujani

Feeder No / Name : 406 / Ausa Belkund

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(NON CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 206 / 33KV Budhoda

Feeder KV- 33 / INCOMING

PURELY LIS FEEDERS

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 401 / 33KV AUSA

Feeder KV- 33 / INCOMING

SHEDDABLE RURAL

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 402 / Yerandi (Old Budhoda)
Feeder KV- 33 / INCOMINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(NON CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 403 / 33 KV MIDC

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 404 / 33KV Jawala

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 157009 / 132 KV AUSA S/S

Feeder No / Name : 406 / 33KV Bhada

Feeder KV- 33 / INCOMING

DATE	01-MAR-18
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 201 / 11 kv Killari Gaothan
feeder Feeder KV- 11 /
OUTGOING

GAOTHAN FEEDER

DATE	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)
1		.7888
2		.823
3		.8916
4		.9602
5		1.0288
10		1.0288
12		.7545
13		.6516
14		.6173
15		.6173
16		.6344
17	2.1384	.6516
18		.9259
19		1.046
20		1.1145
21		1.0802
22		.9602
23		.7545
24		.823
Max	2.1384	1.1145
Min	2.1384	.6173
Avg	2.1384	.8501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 202 / 11 kv Yelawat AG feeder
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-18
HR	Load (MW)
24	1.5261
Max	1.5261
Min	1.5261
Avg	1.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.463		.2058	.3086	.3258
2	.7716	.7716	.583	.6516	.2743	.2743	.2915
3	.823	.9431	.6687	.7716	.3429	.3772	.4115
4	1.0288	1.166	.823	.9945	.0171	.0171	.0171
5	1.286	1.3375	.9259	1.1145	.0171	.0171	.0171
6	1.406	1.5089	1.0288	1.286	.0171	.0171	.0171
7	1.5261	1.5775	1.3032	1.406	.0171	.0171	.0171
8	1.5089	1.5261	1.5089	1.3889	.0171	.0171	.0171
9	.5144	.6859	.583	.7373	1.2174	1.286	1.3717
10	.6516	.7545	.6687	.7888	1.2003	1.3717	1.3546
11	.7202	.823	.7888	.823	1.286	1.4403	1.3375
12	.6859	.7716	.8402	.9088	1.3717	1.4575	1.3717
13		.9259	.8916	.9431	1.4575	1.4746	1.3546
14		.8402	.9259	.8573	1.406	1.4403	1.3032
15	.6859	.9602	1.0288	.9602	1.3717	1.4575	1.3546
16	.7545	1.046	1.0631	1.0288	1.3546	1.4403	.7888
17	.1372	.0857	.1029	.1372	.8573	.823	.8573
18	.1715	.1029	.1372	.1715	1.0288	.9602	1.0631
19	.2743	.1715	.1715	.2572	1.166	1.1145	1.2003
20	.3086	.4115	.3086	.3601	1.166	1.0802	1.2346
21	.3429	.3601	.2743	.3772	1.0288	1.0288	1.1317
22	.2572	.3429	.2572	.3429	.9431	.9602	1.0631
23	.2058	.2743	.2401	.3086	.8573	.8573	.9945
24	.2572	.2401	.2229	.2401	.2572	.9259	.7716
Max	1.5261	1.5775	1.5089	1.406	1.4575	1.4746	1.3717
Min	.1372	.0857	.1029	.1372	.0171	.0171	.0171
Avg	.6820	.7559	.6587	.7328	.7866	.8402	.8195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 206 / 11 KV FACTORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	07-MAR-18
HR	Load (MW)
1	.0343
2	.0171
3	.0171
4	.0343
5	.0343
6	.0343
7	.0343
8	.0343
9	.0343
10	.0343
11	.0343
12	.0171
13	.0171
14	.0171
15	.0171
16	.0171
17	.0171
18	.0171
19	.0171
20	.0171
21	.0171
22	.0171
23	.0171
24	.0171
Max	.0343
Min	.0171
Avg	.0236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 201 / 11 KV Jawali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2801	.362
2	.362	.2801	.3506
3	.4382	.3734	.4382
10	.6001	.663	.7011
11	1.4251	1.4575	1.2146
12	1.4918	1.5927	1.2955
13	1.5746	1.5927	1.2803
14	1.5746	1.6108	1.2498
15	1.6575	1.6385	
16	1.5746		1.4918
17	1.5746	1.5927	
18	.2801	.2629	
19	.4668	.4382	
20	.5601	.6135	
21	.4668	.5258	
22	.3734	.362	
23	.2801	.362	
24	.2715	.2801	.362
Max	1.6575	1.6385	1.4918
Min	.2572	.2629	.3506
Avg	.8461	.8192	.8746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 203 / 11 KV Kharosa Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1867	.181	.1677	.3315	.4572	.3506
2	.2715	.1867	.2715	.1677	.4144	.4572	.4382
3	.3506	.2801	.362	.2515	.4973	.5335	.4287
4					.4973	.4572	.5144
5					.5801	.6859	.7545
6					.5801	.7621	1.0059
7					.8288	.9145	1.3413
8					1.0059	1.0669	1.4251
9					.9221	1.2003	1.2574
10	.4382	.9945	.4382	.503			
11	1.0059	.9945	.9221	.8383			
12	.9945	1.0898	.9221	.9116			
13	.9945	1.0898	.9221	.9945			
14	.9945	1.1022	.9221	1.0774			
15	1.0774	1.1022	1.0059	1.0774			
16	.9945	1.0898	1.0898	.9945	.0762	.0905	
17	.9945	1.0059	1.0898	.9945	.0848	.0905	
18	.0934	.0876	.0838	.0934	.081	.181	.3353
19	.2801	.3506	.3353	.3734	.3048	.3506	.503
20	.3734	.5258	.4191	.4668	.381	.4382	.5868
21	.3734	.4382	.3353	.3734		.3506	.5868
22	.2801	.362	.2515	.1867	.2286	.2715	.503
23	.1867	.181	.1677	.1867	.1524	.181	.4191
24	.181	.1867	.181	.1677	.2486	.1524	.2715
Max	1.0774	1.1022	1.0898	1.0774	1.0059	1.2003	1.4251
Min	.0934	.0876	.0838	.0934	.0762	.0905	.2715
Avg	.5592	.6252	.5500	.5459	.4244	.4801	.6701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 204 / 11 KV Lamjana II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4144	.4525
2	.5258	.4973	.543
3	.6135	.4973	.7011
4	.7011	.5801	.7888
5	.8573	.7459	1.0288
6	1.1022	.9945	1.2717
7	1.3413	1.2431	1.4251
8	1.5089	1.326	1.5089
9	1.4251	1.4089	1.3413
16	.2801	.3506	.4668
17	.3734	.4382	
18	.4668	.4382	
19	.8402	.7888	
20	.7468	.8764	
21	.6535	.724	
22	.5601	.543	
23	.4668	.4525	
24	.362	.3315	.4525
Max	1.5089	1.4089	1.5089
Min	.2801	.3315	.4525
Avg	.7376	.7028	.9073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 201 / 11 KV Tambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.7853	.7716	.8573	.4763	.4363	.4763
2	.8573	.8726	.9431	.8573	.4763	.4363	.4763
3	1.0288	.8726	1.0288	1.0288	.4763	.5235	.5716
4	1.0288	.9598	1.1145	1.1145			
5	1.3717	1.0471	1.2003	1.5432			
6	1.5432	1.2216	1.3717	1.7147			
7	1.8861	2.1815	1.5432	1.7147			
8	2.0576	2.4432		2.0576			
9	2.0576	2.0942	2.0069	2.2291			
10					.381	.349	.4363
11					.5716	1.3961	1.2216
12					1.7147	1.8324	1.6579
13					1.7147	1.9197	1.9427
14					1.9052		1.9427
15	.1715	.3429			1.9052	1.8324	1.7604
16	.3429	.3429	.349	.3429		1.9197	1.8324
17	.4363	.3429	.3429	.3429	1.9197	2.0005	1.8004
18	.4363	.4287	.4287	.3429	1.7452	1.5242	1.7147
19	.4363	.4287	.3429	.4287	.4363	.4763	.3429
20	.5235	.4287	.3429	.4763	.5235	.6668	.4287
21	.4363	.4287	.4287	.4763	.4363	.6668	.5144
22	.349	.4287	.4287	.4763	1.8324	.5716	.5144
23	.349	.4287	.4287	.4763	.4363	.4763	.5144
24	.4287	.6981	.6859	.6001	.4763	.349	.4763
Max	2.0576	2.4432	2.0069	2.2291	1.9197	2.0005	1.9427
Min	.1715	.3429	.3429	.3429	.381	.349	.3429
Avg	.8736	.8830	.8093	.9489	1.0251	1.0222	1.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1564	.1524	.0857	.381	.3151	.381
2	.1734	.1564	.1524	.0857	.381	.3151	.381
3	.1715	.1564	.1715	.0857	.4763	.3151	.381
4	.1715	.1564	.1715		.4763	.3151	.5716
5	.2915	.1564			.4763	.3151	.5716
6		.2346			.5716	.4727	.6668
7					.8573	.7878	.9526
8	.1715				.9526	.7878	.9526
9					.9526	.7878	.709
10				.0857			
11	.3429	.1715	.3128	.3429			
12	.6097	.8573	.4693	.6859			
13	.6097	.8573	.5475	.7716			
14	.7621	.8573	.5475	.7621			
15	.8573	.9145	.5475	.7716			
16	.7621	.9145	.6257	.8573	.0788	.0788	.0788
17	.7039	.7621	.6859	.7621	.0788	.0953	.0857
18	.6257		.6859	.7716	.0788	.0953	.0857
19	.1564	.2286	.0857	.1715	.1576	.1905	.1715
20	.1564	.2286	.0857	.2858	.2363	.1905	.1715
21	.1564	.1524	.0857	.1905	.1576	.2858	.1715
22	.1564	.1524	.1715	.1905	.1576	.2858	.1715
23	.1564	.1524	.1715	.1905	.1576	.1905	.1715
24	.0857	.1564	.1524	.0857	.381	.2363	.2858
Max	.8573	.9145	.6859	.8573	.9526	.7878	.9526
Min	.0857	.1524	.0857	.0857	.0788	.0788	.0788
Avg	.3603	.3906	.3235	.3990	.3894	.3367	.3867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7519	.6859	.5144	.7621	.5047	.5716
2	.6859	.7519	.7716	.6001	.7621	.5047	.5716
3	.6859	.8354	.7716	.6859	.8573	.5047	.6668
4					.8573	.5047	.8573
5					.9526	.5888	.9526
6					.9526	.757	1.1431
7					1.6194	1.1776	1.6194
8					1.7147	1.1776	1.9052
9					1.7147	1.0935	1.5141
10	.8573	.4287	.7519	.4287			
11	1.0288	.4287	.8354	.6001			
12	1.3717	1.3717	1.1696	1.0288			
13	1.4575	.6859	1.1696	1.3717			
14	1.4575	1.3717	1.1696	1.3717			
15	1.5432	1.2955	1.1696	1.3717			1.5141
16	1.4575	1.2193	1.1696	1.286	.3365	.4206	.3365
17	1.4202		1.3717	1.3717	.4206	.5716	.3429
18	1.4202	1.2193	1.286	1.3717	.5047		.4287
19	.7527	.6859	.4287	.8573	.8411	.5716	.6001
20	.8354	.7621	.5144	.9526	.757	.9526	.6859
21	.8354	.7621	.6859	.9526	.757	.9526	.6859
22	.8354	.8573	.7716	.8573		.0762	.6859
23	.7519	.7716	.6859	.7621	.6729	.7621	.6001
24	.5144	.6683	.6859	.6001	.7621	.4206	.4763
Max	1.5432	1.3717	1.3717	1.3717	1.7147	1.1776	1.9052
Min	.5144	.4287	.4287	.4287	.3365	.0762	.3365
Avg	1.0536	.8745	.8941	.9436	.8967	.6789	.8504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 204 / express feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0937	.0857	.0857	.0953	.0937	.0953
2	.0857	.0937	.0857	.0857	.0953	.0937	.0953
3	.0857	.0937	.0857	.0857	.0953	.0937	.0953
4	.0857	.0937	.0857	.0857	.0953	.0937	.0953
5	.0857	.0937	.0857	.0857	.0953	.0937	.0953
6	.3429	.0937	.0857	.0857	.0953	.0937	.0953
7	.3429	.0937	.0857	.3429	.381	.1875	.1905
8	.3429	.0937			.381	.1875	.381
9	.3429	.0937	.4687	.4287	.381	.0937	.4687
10	.3429	.0857	.4687	.3429	.2858	.1875	.1875
11	.3429	.0857	.4687	.3429	.2858	.2812	.5624
12	.3429	.0857	.4687	.3429	.381	.2812	.4687
13	.4287	.0857	.4687	.4287	.2858	.2812	.4687
14	.3429	.0857	.4673	.4287	.2858	.2812	.4687
15	.4287	.0857	.4687	.4287	.2858	.1875	.4687
16	.4287	.0857	.4687	.4287	.2812	.1875	.4687
17	.2812	.0857	.4287	.4287	.2812	.1905	.4287
18	.2618	.0857	.0857	.4287	.1875	.0953	.4287
19	.1875	.0857	.0857	.0857	.0937	.0953	.4287
20	.2812	.0857	.0857	.0953	.0937	.1905	.1715
21	.2812	.0857	.0857	.0953	.0937	.1905	.0857
22	.1875	.0857	.0857	.0953	.0937	.1905	.2572
23	.0937	.0857	.0857	.0953	.0937	.1905	.2572
24	.0857	.0937	.0857	.0857	.0953	.0937	.0953
Max	.4287	.0937	.4687	.4287	.381	.2812	.5624
Min	.0857	.0857	.0857	.0857	.0937	.0937	.0857
Avg	.2549	.0890	.2338	.2365	.2016	.1648	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3321	1.3016	1.3946	1.2489	.9669	.7438	.7502
2	1.432	1.3946	1.3016	1.3654	1.0413	.8368	.7837
3	1.3161	1.6735	1.6735	1.4653	1.0413	1.0227	.898
4	1.3477	1.8595	1.8595	1.5985			
5	1.9649	2.2314	2.0454	1.7897			
6	2.1647	2.6033	2.2314	2.0124			
7	2.2979	2.8264	2.6033	2.3339			
8	2.531	2.9752	2.7892	2.6642			
9	2.3312	2.8822	2.9752	2.4977	.4649		
10						.1332	.6008
11						1.796	1.1157
12					2.0454	2.1647	2.2314
13					2.2314	1.9143	2.2314
14					2.9752	1.9319	2.2314
15					2.6033	1.9316	2.0454
16	.2975	.2231		.2975	2.8822		2.1384
17	.6694		.333	.4091	2.1384	1.9982	2.1384
18	.7438	.6694	.5459	.4649	2.0454	1.5319	2.0454
19	.9669		.9335	.8925		.8669	.8182
20	1.0413		.8659	1.1157		1.0002	1.1157
21	.9297		.8326	1.0413		.9658	1.0413
22	.8182		.7993	.9669		.9335	.9669
23	.7438	.6694	.6661	.9297		.7837	.9669
24	.9669		1.1269	.8925		.7493	.9297
Max	2.531	2.9752	2.9752	2.6642	2.9752	2.1647	2.2314
Min	.2975	.2231	.333	.2975	.4649	.1332	.6008
Avg	1.3275	1.7758	1.4692	1.3326	1.8578	1.2532	1.3916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 202 / 11 KV Kinnithot

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2664	.3347	.2975	.2582	.4649	.4649	.267
2	.2664	.3719	.3719	.2929	.4649	.4649	.3304
3	.2997	.3347	.3347	.3001	.5207	.5578	.4187
4					.5578	.6508	.4785
5					.595	.7438	.5861
6					.595	.9297	.6335
7					.8925	1.1157	.8345
8					.9297	.9297	.9208
9						1.0227	.9211
10	.1488	.1488		.1952			
11	.6508	.6508	.5828	.4649			
12	.7438		.7493	.7438			
13	.3719	.7438	.7993	.8182			
14	.4649		.8326	.8182			
15	.8182	.5207	.8659	.8925			
16	.5207	.8182	.766	.9297	.2231	.0644	.1116
17	.8925		.7327	.9297	.1488	.1332	.1488
18	.8182		.7327	1.0413	.1859	.1667	.1488
19	.2975		.333	.2975		.3001	
20	.3719		.3542	.3719		.333	.2975
21	.4091		.333	.4091		.333	.3347
22	.3719		.2997	.3719		.3001	.3347
23	.3347		.2664	.3347		.2667	.2975
24	.3347		.2664	.4649		.2	.3719
Max	.8925	.8182	.8659	1.0413	.9297	1.1157	.9211
Min	.1488	.1488	.2664	.1952	.1488	.0644	.1116
Avg	.4657	.4905	.5246	.5519	.5071	.4987	.4374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2664	.2975	.3347	.1952	.595	.5578	.7503
2	.2664	.2603	.3719	.322	.6694	.5578	.769
3	.2997	.2975	.3719	.3254	.8182	.6508	.9026
4					.8925	.7438	.9901
5					.9669	.9297	1.4103
6					1.1157	1.1157	1.6531
7					1.4876	1.3016	1.5346
8					1.4876	.7438	1.5687
9						1.3016	1.4494
10	.1488	.1488	.0299	.161			
11	1.3388	1.1157	1.2988	.9297			
12	1.5806	1.3388	1.4653				
13	1.1157		1.346	1.4876			
14	.1859		1.4986	1.4876			
15	.1859		1.5652	1.5806			
16	.2603	1.6735	1.5985	1.6735	.3719	.0814	.093
17	1.6735		1.5837	1.7107	.1488	.1	.1116
18	1.6735		1.5837	1.7107	.1674	.1665	
19	.2231		.2331	.2231		.2334	
20	.2975		.2664	.2975		.3001	.2231
21	.2603		.2997	.3347		.2997	.2975
22	.2603		.2667	.3347		.1998	.2603
23	.2231		.2254	.2975		.1998	.2603
24	.2231		.1795	.5207		.6661	.4649
Max	1.6735	1.6735	1.5985	1.7107	1.4876	1.3016	1.6531
Min	.1488	.1488	.0299	.161	.1488	.0814	.093
Avg	.5824	.7332	.8066	.7995	.7928	.5639	.7962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.1524	.1524	.1966	.6097	.6097	.6097
2	.1966	.1524	.1524	.1966	.6097	.6097	.7621
3	.1966	.2286	.2286	.1966	.7621	.7621	.7621
4	.1966	.2286	.2286	.2294	.7621	.7621	.8383
5	.2458	.2286	.3048	.2458	.8383	.9145	.8383
6	.2622	.3048	.3048	.2622	.8535	.9145	.9145
7	.3277	.3048	.2286	.2949	.7621	.8383	.9145
8	.3277	.3048	.1524	.3277	.9145	.7621	.9145
9	.3277	.3048	.1524	.2949			
10	.2949	.3048	.2286	.2458			
15					.0762	.1524	.1311
16					.1524	.2286	.1311
17	.9145	.7621	1.1469	.6097	.1524	.2286	.1638
18	1.0669	.8383	1.2125	.6097	.2286	.3048	.1966
19	1.0669	.9145	1.0486	.7621	.2286	.3048	.2622
20	1.0669	.9145	.9831	.9145	.3048	.3048	.2949
21	.9145	.9907	.9175	1.0669	.3048	.2286	.2622
22	.7621	1.0669	.852	1.0669	.2286	.2286	.2458
23	.7621	.7621	.8192	.8383	.1524	.2286	.2458
24	.6882	.7621	.7621	.7865	.7621	.1524	.1524
Max	1.0669	1.0669	1.2125	1.0669	.9145	.9145	.9145
Min	.1966	.1524	.1524	.1966	.0762	.1524	.1311
Avg	.5453	.5292	.5486	.5081	.4835	.4742	.4800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.5335		.3239	.1524	.1524	.1524
2	.4858	.6097	.381	.3563	.2286	.2286	.2286
3	.583	.6097	.4572	.3887	.2286	.2286	.2286
4	.6478	.6859	.4572	.3932			
5	.9069	.6859	.6097	.4858			
6	.9717	.7621	.6097	.6478			
7	1.0688	.7621	.6859	1.0364			
8	1.085	.7621	.6859	.9831			
9					.6097	.4572	.3048
10					.6097	.5335	.5335
11					.6097	.7621	.6478
12					.6859	.7621	.6802
13					.6859	.7621	.6802
14					.7621	.7621	.6802
15	.0762	.0762	.1029		.5335	.9145	.7287
16	.0762	.0762	.1029		.6097	.7621	.7287
17	.1524	.1524	.0995	.0762			
18	.1524	.2286	.1658	.0762	.0762	.0762	.1638
19	.2286	.2286	.1966	.1524	.1524	.2286	.2591
20	.2286	.3048	.2652	.1524	.2286	.3048	.2591
21	.1524	.381	.1658	.2286	.3048	.1524	.1943
22	.0762	.4572	.1658	.2286	.1524	.1524	.1619
23	.0762	.2286	.1658	.1524	.0762	.0762	.1619
24	.1638	.0762	.2286	.1326	.1524	.0762	.0762
Max	1.085	.7621	.6859	1.0364	.7621	.9145	.7287
Min	.0762	.0762	.0995	.0762	.0762	.0762	.0762
Avg	.4196	.4234	.3262	.3634	.3810	.4107	.3817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1524	.2286	.1966	.1524	.1524	.1524
2	.1638	.2286	.2286	.1966	.1524		.1524
3	.1638	.2286	.3048	.2294	.2286	.3048	.1524
4				.2622	.2286	.381	.2286
5				.3277	.3048	.381	.2286
6					.3048	.4572	.3048
7					.3048	.4572	.3048
8					.381	.4572	.3048
9	1.0814	.7621	.7621	1.0159	.1524	.1524	.2286
10	1.0486	.7621	.6859	.9175	.1067	.1524	.1524
11	.9145	.7621	.852	.7621			
12	.9145	.7621	.8848	.8383			
13	.9145	.8383	.9175	.884			
14	.7621	.8383	.9175	.884			
15	.7621	.7621	.9175	.6097			
16	.7621	.7621		.5335			
17					.381	.6859	
18	.1524	.2286	.2294	.0762	.4572	.7621	1.0159
19	.3048	.3048	.4588	.1524	.6097	.9145	.9831
20	.3048	.381	.4588	.2286	.6859	.9145	.9175
21	.2286	.381	.426	.3048	.7621	.6097	.9175
22	.1524	.3048	.2949	.3048	.6097	.6097	.8848
23		.2286	.0183	.2286	.6097	.5335	.852
24	.1966	.0762	.3048	.2294	.2286	.5335	.4572
Max	1.0814	.8383	.9175	1.0159	.7621	.9145	1.0159
Min	.1524	.0762	.0183	.0762	.1067	.1524	.1524
Avg	.5289	.4869	.5230	.4591	.3700	.4976	.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.5258	
3		.3125	.503		.5935	.3906
5		.2315	.663	.5668	.6706	.3906
12	.703					.5468
13		.8288		.6554		
14	.8592				.703	.6249
15		.9831		.6554		
16	.8592			.7373	.6249	.7811
17				.7373	.6249	
18	.703	.9326				
19		.6783		.7011		
20	.6249	.6068			.5468	.6249
21		.5935				
23				.5258		
24	.3906		.5087		.4687	.4687
Max	.8592	.9831	.663	.7373	.703	.7811
Min	.3906	.2315	.503	.5258	.4687	.3906
Avg	.6900	.6459	.5582	.6542	.5948	.5468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.5087	
3		1.2498	1.1736	.5801	.6783	.5735
5		1.7185	1.4089			
6			1.6385			
7		2.1872	2.2377			
9		2.1091	2.13			
10				1.3765	1.5623	1.3279
11				1.8842		
12					2.0309	1.8747
13				1.989		
14					1.9528	1.6404
15				1.8623		
16	.2458			2.13	1.9528	1.8747
17				1.989	2.0309	1.8747
18	.3277	.2629				
19		.5087		.5316		
20	.4915	.5935			.5735	.3277
21		.5087				
23				.5258		
24	.7459		1.1022		.4915	.5735
Max	.7459	2.1872	2.2377	2.13	2.0309	1.8747
Min	.2458	.2629	1.1022	.5258	.4915	.3277
Avg	.4527	1.1423	1.6152	1.4298	1.3091	1.2584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 206 / 11 KV DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					1.1869	
3		.8192	.7545		1.1603	1.4842
5					1.4251	1.5623
6					1.6575	
7						2.3434
8					2.7349	
9				2.2672	2.6825	2.3434
10	1.4842					
11		2.1795				
12	1.9528					
13		2.2119				
14	2.1872					
15		2.2119				
16	2.1091			.2515	.1638	.1638
17				.2543	.3277	.4096
18	.5735	.4239				
19		.8383		.8764		
20	.5735	.9326			.7373	.5735
21		.7545				
23				.6135		
24	.6554		.6783		.8192	1.0155
Max	2.1872	2.2119	.7545	2.2672	2.7349	2.3434
Min	.5735	.4239	.6783	.2515	.1638	.1638
Avg	1.3622	1.2965	.7164	.8526	1.2895	1.2370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.5601				
2	.5611	.5601					
3		.6535	.5975				
4	.724	.7095	.5975	.6001	.5144		
5		.7842	.6535				
6	.905	.9522	.8215				
7	.9602	.8962	.7842		.823		
8	.7373	.8589	.8402	.9259		.7202	.8745
9		2.1845	2.5206				.6722
10	1.9719	2.1658	2.2405	2.0576	.3944		
11	2.1098	1.8111	2.0576		.12		
12	2.1472	2.1845	2.0576	1.9719	.1543		
13	2.2779	1.8671	1.8861		.1543		.1494
14	2.0538	2.2032	2.0576	1.8861	.12		.1867
15	2.2032	2.2405			.12		.2427
16	2.1845	1.7924		1.8004			
17		.1867					2.1845
18		.2614					2.1658
19	.6535	.7468					1.5497
20	.6908	.8962	.7716	.5658			1.6804
21		.7468					1.4937
22		.6535					1.4377
23		.5975	.6859	.5144			
24	.5611	.5601	.5601	.6001	.4801	.8145	.9593
Max	2.2779	2.2405	2.5206	2.0576	.823	.8145	2.1845
Min	.5611	.1867	.5601	.5144	.12	.7202	.1494
Avg	1.3828	1.1280	1.2308	1.2136	.3201	.7674	1.1331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 201 / 11 KV TAGARKHEDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.3429			.3429		.4287	.3429
16		.1715	.0857		.0857	.2572	
24	.0857			.0857		.0857	.0857
Max	.3429	.1715	.0857	.3429	.0857	.4287	.3429
Min	.0857	.1715	.0857	.0857	.0857	.0857	.0857
Avg	.2143	.1715	.0857	.2143	.0857	.2572	.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 202 / 11 KV HALGARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.7716		.8573		.8573	.8573
16		.3429		.2572	.3429	
24	.3429		.3429		.3429	.3429
Max	.7716	.3429	.8573	.2572	.8573	.8573
Min	.3429	.3429	.3429	.2572	.3429	.3429
Avg	.5573	.3429	.6001	.2572	.5144	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 203 / 11 KV SAWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.5144			.5144		.6001	.5144
16		.2572	.1715		.1715	.2572	
24	.2572			.2572		.1715	.1715
Max	.5144	.2572	.1715	.5144	.1715	.6001	.5144
Min	.2572	.2572	.1715	.2572	.1715	.1715	.1715
Avg	.3858	.2572	.1715	.3858	.1715	.3429	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 204 / 11 KV SHIRSHI HANGARGA
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.6859			.6859		.6001	.6001
16		.1715	.1715		.1715	.2572	
24	.3429			.3429		.2572	.2572
Max	.6859	.1715	.1715	.6859	.1715	.6001	.6001
Min	.3429	.1715	.1715	.3429	.1715	.2572	.2572
Avg	.5144	.1715	.1715	.5144	.1715	.3715	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 201 / 11 KV PANCHINCHOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	07-MAR-18
HR	Load (MW)
12	1.9909
Max	1.9909
Min	1.9909
Avg	1.9909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 202 / 11 KV TUPADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1736				.0914	.0686
3			1.5384			
4	1.6766	1.6804		1.6632	.128	
5			1.7193			
6			2.0452		.128	.1214
7	2.304		2.6968		.1448	.12
8		2.1795	2.7435	2.5339	.128	
9			.1267		1.7604	
10		.1097		.1097		2.1548
11	2.3205				2.0885	
12			.0091			2.2634
13		.1097		.1097		
14	.0671				2.1136	
16	.0838	.1097	.0914	.1097	2.1548	
17					.052	
19		.1267		.1097		
21		.1086		.128		
22			.112			
23		.128		.128		
24	.1029	.1029	.128	.0943	.1097	.104
Max	2.3205	2.1795	2.7435	2.5339	2.1548	2.2634
Min	.0671	.1029	.0091	.0943	.052	.0686
Avg	1.1041	.5172	1.1210	.5540	.8090	.8054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2947		.3982		.4207	.3988
3			.4024			
4	.3988	.4458		.4024	.5487	
5			.5853			
6			.7783		.6767	.9665
7	.6762		.6584		.7682	.9602
8		.5868	.7316	.724	.6584	
9			1.2254		.5316	
10		.9774		1.1888		.4801
11	.8951				.3258	
12			1.0105			.2347
13		1.0059		1.1706		
14	.9556				.2601	.3018
15		1.0679				
16	.9389	1.0608	1.5051	.9694	.2774	
17					.8718	
18		.3475				
19				.439		
20		.6219				
21				.3109		
22		.4755	.3326			
23		.4024		.4024		
24	.3258	.3258	.362	.3395	.3658	1.2574
Max	.9556	1.0679	1.5051	1.1888	.8718	1.2574
Min	.2947	.3258	.3326	.3109	.2601	.2347
Avg	.6407	.6652	.7263	.6608	.5187	.6571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FDR Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.163				.0329	
3			.0238			
4	.0789	.0789		.0112	.0329	
5			.0128			
6					.0329	
7	.0329		.011		.0311	
8		.0187	.011	.0128	.0439	
9			.011		.0555	
10		.0457		.0127		.0243
11	.0892				.0485	
12			.0094			.0326
13		.0439		.0127		
14	.0789				.0537	.012
16	.039	.0348	.0095	.0238	.0638	
17					.072	
18						.0103
19		.0165		.0366		
21		.0274		.0311		
22			.0113			.0086
23		.0219		.0311		
24	.0676	.2778	.0235	.0114	.0329	.0225
Max	.163	.2778	.0238	.0366	.072	.0326
Min	.0329	.0165	.0094	.0112	.0311	.0086
Avg	.0785	.0628	.0137	.0204	.0455	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8		2.1742	2.3363
24	.3243		
Max	.3243	2.1742	2.3363
Min	.3243	2.1742	2.3363
Avg	.3243	2.1742	2.3363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8		1.5348	1.6213
24	1.008		
Max	1.008	1.5348	1.6213
Min	1.008	1.5348	1.6213
Avg	1.008	1.5348	1.6213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 201 / 11 KV AURAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7716	.6535	.9335	.8764			
16	.0943	.0934	.0934	.0943	.6859	.6535	.924
17	.0943						
24	2.5339	.2629	.2801	.2801	.0943	.0924	.0934
Max	2.5339	.6535	.9335	.8764	.6859	.6535	.924
Min	.0943	.0934	.0934	.0943	.0943	.0924	.0934
Avg	.8735	.3366	.4357	.4169	.3901	.3730	.5087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 202 / 11 KV SHELGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						.2572	2.4863
16		2.3491	2.4177	2.4539		.0857	.0343
17	2.4926				.037		
24	2.8006	.0566		.0686	.7716	.6068	.7716
Max	2.8006	2.3491	2.4177	2.4539	.7716	.6068	2.4863
Min	2.4926	.0566	2.4177	.0686	.037	.0857	.0343
Avg	2.6466	1.2029	2.4177	1.2613	.4043	.3166	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.3681	.3361	.2614	.1791	.1663	.1867	.2054
24	.4108	.3681	.3734	.4108	.3439	.3174	.3734
Max	.4108	.3681	.3734	.4108	.3439	.3174	.3734
Min	.3681	.3361	.2614	.1791	.1663	.1867	.2054
Avg	.3895	.3521	.3174	.2950	.2551	.2521	.2894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 204 / 11 KV AURAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			.5601	.6135	.5544	.5544	.7392
17	.6516						
24	.4668	.5258	.462	.462	.5258	.4668	.462
Max	.6516	.5258	.5601	.6135	.5544	.5544	.7392
Min	.4668	.5258	.462	.462	.5258	.4668	.462
Avg	.5592	.5258	.5111	.5378	.5401	.5106	.6006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4382					
16	.5201	.4572	.462	.362	.3696	.2715	.4525
23						.2715	
24	.2801	.4382	.2715	.3696	.3658	.3734	.3658
Max	.5201	.4572	.462	.3696	.3696	.3734	.4525
Min	.2801	.4382	.2715	.362	.3658	.2715	.3658
Avg	.4001	.4445	.3668	.3658	.3677	.3055	.4092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 201 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.6554	.6859		.6554	.1715		.1638
4			.663			.1619	
5	.7373						
6	.8192	.8573		.8192	.2572		.2458
7	.9012	.8573	.9831	.8192	.2572	.2458	.2458
8	1.1469		.4858		.2572	.2429	.2949
9		1.2003			.2572		
10	.1715		.1638			.7373	.6859
11		.1638		.1715			
12	.1715		.1638	.1715	.7373	.9012	.9431
13			.1638				
14	.1715	.1638	.1638	.1715		.9012	1.0288
16	.1715		.1638	.1715			1.0288
17		.1638	.1638		.8192		
18						.1638	
19	.2572		.2458	.1715	.2429		.2572
20	.2572					.2458	
21			.2458	.2572	.2458		
22		.1619				.2458	.2572
23	.1715						
24	.3277	.5144	.4915	.5735	.1715	.1619	.1638
Max	1.1469	1.2003	.9831	.8192	.8192	.9012	1.0288
Min	.1715	.1619	.1638	.1715	.1715	.1619	.1638
Avg	.4584	.5298	.3415	.3982	.3417	.4008	.4832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 203 / 11 KV MASALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.7545	.8573		.8488	.1905		.1886
4			.7468			.1867	
5	.8488						
6	.9431	.9526		1.1317	.2858		.2829
7	.9431	1.1431	1.0374	1.1317	.2858	.2801	.2829
8	1.3203		.5601		.2858	.2829	.2829
9		1.2384			.2858		
10	.1905		.1886			1.0374	1.1431
12	.1905			.1715	1.0374	1.1317	1.3336
13			.1886				
14	.1905		.1886	.1905		1.1317	1.3336
16	.1905		.1886	.1905			1.1431
17			.1886		1.1317		
18						.1886	
19	.2858		.2829	.2858	.2801		.2858
20	.2858					.2829	
21			.2829	.2858	.2801		
22		.1867				.1886	.2858
23	.2858						
24	.3772	.7621	.7545	.7545	.1905	.1867	.1886
Max	1.3203	1.2384	1.0374	1.1317	1.1317	1.1317	1.3336
Min	.1905	.1867	.1886	.1715	.1905	.1867	.1886
Avg	.5236	.8567	.4189	.5545	.4254	.4897	.6137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	02-MAR-18	04-MAR-18
HR	Load (MW)	Load (MW)
14	.1467	.1715
Max	.1467	.1715
Min	.1467	.1715
Avg	.1467	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 205 / 11 KV Aambegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.6478	.7716			.1715		.1619
4			.6706				
5	.8097						
6	.9717	.8573			.1715		.1619
7	.9717	.8573	1.0774	1.1145	.1715	.1658	.2429
8	1.2955		.6554		.1715	.1638	.1638
9		1.2003			.1715		
10	.1715		.1619			.8907	.8573
11		.1658		.1715			
12	.1715		.1619	.1715	.9945	1.1336	1.0288
13			.1619				
14	.1715	.1658	.1619	.1715		1.0526	1.0288
16	.1715		.1619	.1715			1.0288
17		.1658	.1619		.9945		
18						.1619	
19	.1715		.1619	.1715	.1638		.1715
20	.1715						
21			.1619	.1715	.1658		
22		.1638					.1715
23	.1715						
24	.3239	.6859	.663		.1715	.1638	.1619
Max	1.2955	1.2003	1.0774	1.1145	.9945	1.1336	1.0288
Min	.1715	.1638	.1619	.1715	.1638	.1619	.1619
Avg	.4785	.5593	.3635	.3062	.3348	.5332	.4708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 201 / 11 KV NITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.4748
5		.5967		.7282
7		1.1317		1.1789
8				.9945
11	.4359			
12			.6401	
14	.2267		.5487	
16			.7274	
18			.5335	
20			1.1431	
22			.6859	
24		.8745		.3887
Max	.4359	1.1317	1.1431	1.1789
Min	.2267	.5967	.5335	.3887
Avg	.3313	.8676	.7131	.7530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 202 / 11 KV SHEND FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.2035	
4	.7811	.6722					.3125
5			.7459	.9069		.4508	
7			1.406			.5316	
8	1.166	1.2209	1.2071	1.2308	.5548	.4508	.5365
11		.2683					
12				.16	.2743	1.166	1.0623
14		.1296			1.0669	1.1523	1.0494
16	.2683	.1638		.1296	1.2651		1.1873
17			.1406				
18					.1905	.3048	
19	.5335	.4572					
20				.4191	.6097		.4572
21		.4954					
22					.3048	.381	
23		.1905					.2241
24	.3688	.4915	.5506	.6104	.1783	.1943	.1783
Max	1.166	1.2209	1.406	1.2308	1.2651	1.166	1.1873
Min	.2683	.1296	.1406	.1296	.1783	.1943	.1783
Avg	.6235	.4544	.8100	.5761	.5556	.5372	.6260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 203 / 11 KV BASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						.9835	
4	.5312	.3841			1.0364		.9998
5			.7293	.7125		1.1789	
7			1.0288			1.8427	
8		.8139	.8718	.8421	2.0111	2.0458	1.6766
11		1.2742					
12	1.6248			1.5364			.2343
14		1.4251			.1524	.192	.1852
16	1.8778	1.8023		1.5546	.1581		.1562
17			1.5623				
18					.2667	.381	
19	.8002	.8383					
20				.6859	.7621		.6097
21		.6478					
22					.381	.4572	
23		.381					.2987
24	.2683	.2294	.2915	.3052	.6836	.7907	.6539
Max	1.8778	1.8023	1.5623	1.5546	2.0111	2.0458	1.6766
Min	.2683	.2294	.2915	.3052	.1524	.192	.1562
Avg	1.0205	.8662	.8967	.9395	.6814	.9840	.6018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 204 / 11 KV BUJRUGWADI FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	03-MAR-18
HR	Load (MW)
17	.1875
Max	.1875
Min	.1875
Avg	.1875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 201 / 11 KV NANAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.2949	.3429	.3315	1.0288	1.004	1.0608
2	.3647	.3605	.3772	.3647	1.0288	1.1336	1.1271
3	.431	.4588	.5144	.5304	1.3717	1.1336	1.1203
4	.5304	.5243	.5487	.7293	1.5432	1.2631	1.326
5	.663	.6554	.7202	.8288	1.8861	1.3443	1.5249
6	.8619	.8192	.8573	.9614	2.0576	1.4403	1.6575
7	.9945	.9717	.9945		2.0576	1.9319	2.3205
8	.9945	.9717	.6859		2.4006	2.3537	2.5194
9	.7293	.8848	.6516		2.4006	2.4531	2.4863
10	1.094	1.3717	1.7147	1.7238			
11	1.6004	2.0576	1.8233	2.2291			
12	1.9685	2.2291	1.989				
13	1.9814	2.332	1.8233	2.2634			
14	1.9509	2.332	1.989	2.2634			
15	1.9204	2.3663	2.3205	2.2634			
16	1.9814	2.4006	2.3205	2.4006	.3277	.2321	.2401
17	2.0729	2.4006	2.3205	2.4691	.3277	.3315	.3086
18	.3277	.4115	.3978	.4115	.3932	.3647	.4115
19	.4915	.5144	.6299	.6516	.6554	.4641	.5144
20	.6554	.6859	.663	.6859	.6554	.6154	.5144
21	.4915	.5144	.4973	.5144	.5243	.663	.4801
22	.426	.4458	.4641	.3086	.4588	.5636	.3429
23	.3605	.3772	.3481	.2743	.3605	.3315	.3086
24	.2652	.2949	.3429	.3315	.823	.9393	.8619
Max	2.0729	2.4006	2.3205	2.4691	2.4006	2.4531	2.5194
Min	.2652	.2949	.3429	.2743	.3277	.2321	.2401
Avg	.9773	1.1115	1.0557	1.1268	1.1278	1.0313	1.0625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 202 / 11 KV JEWRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3978	.4915	.5144	.5304	.3086	.2949	.2984
2	.431	.4915	.5487	.5967	.3429	.3605	.3647
3	.5304	.5898	.6859	.663	.4115	.4915	.4641
4	.7293	.6882	.6859	.8288	.5144	.6554	.5636
5	.9614	.8192	.8573	.9614	.7202	.8192	.6962
6	1.1603	.9717	1.0288	1.094	.9945		.9282
7	1.326	1.1336	1.2003	1.1603	.9259		
8	1.1934	1.4403	1.2689	1.326	.6516		
9	.9945	1.3927	1.2003	1.1603	.5144		
10					.6554	.6299	.6962
11					.6882	.7293	.823
12					.8192	.7956	.7545
13					.8192	.8619	.7545
14					.7865	.9614	.7545
15					.3277	.8951	.7888
16	.1966	.2743		.2743	.7537	.9282	.7545
17	.2949	.3429	.2321	.3086	.7865	.8951	.7545
18	.3932	.5144	.4641	.3429		.3315	.3429
19	.7537	.8916	.8097	.6859	.6554	.663	.823
20	.5898	.6859	.6962	.7545	.6554	.7625	.7202
21	.5898	.5487	.5304	.4801	.4915	.5304	.5144
22	.3277	.4801	.431	.3772	.3605	.3978	.4458
23	.2949	.3429	.2984	.3429	.2949	.3239	.3429
24	.3647	.426	.5144	.4641	.3086	.2949	.2652
Max	1.326	1.4403	1.2689	1.326	.9945	.9614	.9282
Min	.1966	.2743	.2321	.2743	.2949	.2949	.2652
Avg	.6405	.6959	.7039	.6862	.5994	.6311	.6119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 203 / 11 KV MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4588	.5144	.4973	.2743	.2622	.2321
2	.5304	.5243	.6859	.6962	.3086	.2949	.2652
3	.6299	.6226	.6859	.6722	.3429	.3605	.3315
4	.6962	.7537	.8573	.8619	.5144	.4915	.3315
5	.8951	.9069	1.0288	.9945	.7545	.7209	.3647
6	1.1603	1.166	1.0288	.9945	.9945	.9393	.3978
7	1.3923	1.3763	1.3717	1.3592	.6516	.852	
8	1.4918	1.4083	1.3717	1.4586	.5144	.7956	
9	1.2597	1.3443	1.3717	.9945	.4115	.7293	
10					.8192	.7293	.663
11					.9717	.8619	.8573
12					1.1336	.9282	.8573
13					1.1012	.9614	.8916
14					1.0688	.9945	.8916
15					1.0688	.9945	
16	.2294	.2743	.1658	.2401	1.1012	1.0277	
17	.2622	.2743	.1989	.2401	1.166	1.094	
18	.2622	.3086	.2984	.3086	.2949	.2984	
19	.5898	.583	.6299	.6516	.5243	.5636	.6859
20	.6226	.6516	.663	.6859	.5898	.6299	.6173
21	.5243	.5144	.5304	.583	.4588	.4973	.4801
22	.3277	.4458	.4641	.4115	.3277	.3315	.4115
23	.2622	.3086	.2652	.2401	.2622	.2652	.3086
24	.4641	.3932	.4801	.3978	.2743	.2622	
Max	1.4918	1.4083	1.3717	1.4586	1.166	1.094	.8916
Min	.2294	.2743	.1658	.2401	.2622	.2622	.2321
Avg	.6721	.6842	.7007	.6826	.6637	.6619	.5367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 201 / 11 KV SARWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.1905	.3048	.3401		
2	.2096	.381		.2858	.5344	.5506	
3		.4763	.2096	.381	.639	.6316	
4	.3048	.5335	.2477	.4763	.6964	.6718	
5		.5716	.3239	.5335	.7935	.7377	
6	.5906	.6097	.4001	.5716	.9448	.788	
7		.6668	.5525	.6097		.9389	
8	.7049	.6859	.6668	.6668	.9892	.9892	
9		.4001	.5716	.5144	.9717	.8356	
10		.2858	.381	.4001	.4191	.1905	.1905
11		.4372	.6401	.4001	.3429	.1905	
12		1.0202	.6706	.7611	.1524	.1715	.1905
13		1.0526	.6859	.8421	.1334	.1334	
14		.9878	.7621	.9231	.1524	.1334	
15		1.1012	.7926	.9393	.1334	.1524	
16		.9717	.8078	.9831	.1334	.1715	.1334
17		.9878	.8993	.8907	.1905	.1905	
18		.4696	.8078	.8421	.2096	.3048	
19		.5144	.4763	.3239	.3239	.4001	
20		.4763	.4191	.4572	.4572	.4954	
21		.4001	.381	.381	.2858		
22		.2286	.3429	.2858	.2477		
23		.2286		.2096	.2096		
24	.1905	.2858	.2096	.2667	.1619	.1829	.1943
Max	.7049	1.1012	.8993	.9831	.9892	.9892	.1943
Min	.1905	.2286	.1905	.2096	.1334	.1334	.1334
Avg	.4001	.5881	.5199	.5521	.4114	.4430	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 202 / 11 KV MUDGAD EKOJI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2753	.25	
2				.4696	.2968	
3				.4696	.3725	
4				.502	.4049	
5				.6316	.502	
6				.7127	.583	
7					.7287	
8				.8048	.7773	
9				.7186	.6802	
11	.3401	.4572	.2753			
12	.7125	.5335				
13	.7701	.6097	.7287			
14	.7611	.6859	.6964			
15	.8421	.7621	.7611			
16	.8259	.7926	.7773			
17	.8097	.7621	.7287			
18	.4534	.6859	.7287			
24					.1562	.16
Max	.8421	.7926	.7773	.8048	.7773	.16
Min	.3401	.4572	.2753	.2753	.1562	.16
Avg	.6894	.6611	.6709	.5730	.4752	.16

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 203 / 11 KV KOKALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4372	.3048		.2477	
2	.4961	.3239	.4696	.381		.2858	
3		.4049	.6154	.4572		.3429	
4	.6478	.4858	.7045	.5335		.4001	
5		.7287	.7701	.6097		.4763	
6	.9231	.9116	.8453	.6859		.6287	
7		1.1401	.9556	.7621		.724	
8	1.0364	1.0227	1.0898	.884		.8002	
9		.9503	1.0364		.5906		
10		.5144	.4763				
11		.1524	.2667			.1829	
12			.2286		.506	.8583	
13		.1143	.2096		.9555	1.1633	
14		.1143	.1905		.9717	1.2452	
15					.8907	1.2289	
16		.1143			.8322	1.0688	
17		.1715	.1143		.8259	.9217	
18		.2667	.2096		.7611	.7968	
19		.5906	.2858		.4954	.7049	
20		.5525	.4763		.6097	.6668	
21		.5144	.4191		.3429		
22		.2858	.4001		.2858		
23		.2477			.2477		
24	.2187	.2429	.2591	.2439		.2286	.2477
Max	1.0364	1.1401	1.0898	.884	.9717	1.2452	.2477
Min	.2187	.1143	.1143	.2439	.2477	.1829	.2477
Avg	.6644	.4690	.4981	.5402	.6396	.6827	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.9145		.0692		
2	.743		1.1622		.0796		
3	.9717		1.2193		.1014	.181	.181
4	1.1431		1.5623	.5083	.144		.181
5	1.6956		1.829		.184		.181
6	1.9052		1.9052		.2561		.362
7	2.0957		2.0005		.3048		.4525
8	1.9624		1.5242		.208	.5068	.362
9	1.6004			1.8671	.181	.362	.3544
10	.0943	.0907		.0714	.0381	.3582	
11		.0914		.0566	.905	1.0517	
12	.0366	.0762		.056	1.448	1.2269	.6219
13		.0503		.029	1.448	1.387	
14		.0503		.0366	1.448	1.387	
15		.0434		.048	1.4022	1.4737	
16		.0503		.0434	1.4022	1.4899	.8669
17		.0572		.0514		1.4899	
18	.0533	.0429		.0703	1.4022	1.4022	
19	.096	.0953		.1158		.362	
20	.135	.1646		.132	.4525	.3258	.1067
21	.1219	.0838		.1195		.3077	
22		.081		.08		.2715	
23		.0619		.064	.3258	.1991	.0857
24	.5335	.4191	.6097	.1524	.0476	.2715	.181
Max	2.0957	.4191	2.0005	1.8671	1.448	1.4899	.8669
Min	.0366	.0429	.6097	.029	.0381	.181	.0857
Avg	.8671	.0972	1.4141	.2060	.5924	.7808	.3280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 202 / 11 KV BHOOTMUGLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.2096		.1894		.5373
2	.2096		.2096		.257		.5373
3	.2096		.2667		.3567	.543	
4	.2477		.362		.4572		.7164
5	.3429		.4191		.5573		.7164
6	.4382		.6097		.8429		1.1641
7	.6478		.6859		.9259		1.2536
8	.5906		.5525	.4572	.9282	1.1641	1.3432
9	.5335			.381	.6944	1.1641	1.3432
10	.4572	.3429		.3048	.362	.1791	
11		.4321		.4214	.181		
12	1.2696	.6661		.6472	.181	.181	.1524
13		.7727		.6923	.0953	.181	
14	1.2308	.7727		.6859	.181	.181	
15		.8619		.6923	.181	.181	.1143
16	1.0631	.8535		.6287	.181	.1867	.1143
17		.8535		.7002		.181	
18	1.086	.8128		.7093	.181	.181	.1905
19	.2858	.4001		.3185		.2715	
20	.381	.5525		.4161	.362	.2715	.3361
21	.362	.3601		.381		.2353	
22		.3429		.3048			
23		.2667		.2858	.181	.181	.2801
24	.2667	.2667	.2477	.2858	.1787	.394	.3582
Max	1.2696	.8619	.6859	.7093	.9282	1.1641	1.3432
Min	.2096	.2667	.2096	.2858	.0953	.1791	.1143
Avg	.5483	.5705	.3959	.4890	.3737	.3548	.6105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154108 / 33/11 KV AMBULAGA

Feeder No / Name : 201 / 11KV AMBULGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.3603
2					1.7695
3					1.8564
4					1.989
5					2.0885
6					1.4091
7					1.4419
16		1.7368	1.8351	1.7368	
17		1.8023	1.8896	1.8023	
18		1.8896	.5401		
19			.6481	.6481	
20		.5864	.7186	.6173	
21		.6249	.7811	.6481	
22		.6562		.6874	
23		.6874		.6874	
24	1.2003				.9922
Max	1.2003	1.8896	1.8896	1.8023	2.0885
Min	1.2003	.5864	.5401	.6173	.9922
Avg	1.2003	1.1405	1.0688	.9753	1.6134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 201 / NEW BANK COLONY

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8238	.8589	.7343	.8238	.8063	.8059
2	.8238	.7888	.8589	.7522	.8063	.7888	.788
3	.7888	.8063	.8501	.8238	.7888	.7888	.8238
4	.8589	.8238	.9149	.9313	.8413	.8589	.8954
5	.9465	.8764	1.0608	1.0029	.9465	.9465	1.0029
6	1.0517	.9816	1.1706	1.0924	1.0517	.9991	1.0924
7	1.1919	1.0517	1.2178	1.182	1.1393	1.0867	1.2178
8	1.262	1.1744	1.2403	1.1641	1.2094	1.1393	1.2178
9	1.1919	1.1919	1.0631	1.182	1.2269	1.0517	1.1462
10	1.1043	1.1517	.9922	1.0517	1.0867	.985	1.0692
11	1.0867	1.0517	.9922	.9991	1.0166	1.0029	1.0517
12	1.0517	1.0631	.9568	.964	.8764	.8954	1.0166
13	1.0166	.9214	1.0029	.9465	.929	.9492	.964
14	.9816	.9816	.8954	.8939	.8764	.8596	.9114
15	.929	.8859	.8775	.8764	.8413	.8059	.9465
16	.8939	.8859	.9134	.9114	.8764	.8954	.9465
17	.8764	.9214	.9313	.9465		.8775	.929
18	.929	1.0631	1.0099	1.0341	1.0867	.9313	1.0517
19	1.0517	1.2403	1.3073	1.262	1.262	1.0924	1.2445
20			1.2403	1.2445		1.2178	1.1568
21	1.0166		1.182	1.1218	1.0517	1.1283	1.0341
22	.9816	.9709	.985	.964	.9991	1.0387	.9816
23		.9335	.8775	.9114		.9313	.8939
24	.8413	.8589	.8962	.7701	.8238	.8413	.8238
Max	1.262	1.2403	1.3073	1.262	1.262	1.2178	1.2445
Min	.7888	.7888	.8501	.7343	.7888	.7888	.788
Avg	.9871	.9749	1.0123	.9901	.9791	.9549	1.0005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 202 / ASHOK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1663	.1886	.1433	.1848	.1848	.1433
2	.1478	.1663	.1886	.1433	.1663	.1848	.1612
3	.1478	.2033	.1886	.1612	.1848	.2218	.1772
4	.2218	.2218	.2263	.2481	.2957	.2772	.2865
5	.2957	.3511	.4481	.4656	.4066	.3696	.4656
6		.5544	.5601	.6089	.5914	.5914	.5731
7	.7392		.7468	.6626	.7023	.7947	.6984
8	.6283	.7023	.8402	.6984	.6838	.7392	.7164
9	.5729	.6283	.6348	.5552	.5359	.6468	.591
10	.4075	.3734	.394	.3696	.3881	.4835	.3881
11	.2772	.2743	.2865	.2587	.2772	.4298	.3142
12			.2658	.2033	.2218	.3761	.2402
13	.3696	.2987	.197	.1663	.1663	.3045	.1848
14	.462	.2561	.1791	.1663	.1848	.2507	.1478
15	.3881	.2561	.1595	.1848	.1578	.2686	.1478
16	.3696	.2561	.197	.1663	.2218	.2507	.1478
17	.3511	.2743	.2686	.1848		.2865	.1663
18	.3881	.3734	.2658	.2587	.3696	.3582	.2772
19	.4251	.4854	.4607	.5359	.462	.5493	.4435
20			.5194	.5175		.5014	.4805
21	.3696		.4298	.4435	.4251	.3761	.3696
22	.2587	.2481	.3224	.2772	.3326	.3045	.2957
23		.2263	.197	.2033		.197	.2033
24	.1848	.1848	.1886	.1595	.1848	.2033	.1612
Max	.7392	.7023	.8402	.6984	.7023	.7947	.7164
Min	.1478	.1663	.1595	.1433	.1578	.1848	.1433
Avg	.3586	.3250	.3481	.3243	.3402	.3813	.3242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 201 / 11 KV ANASARWADA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6859	.8059	.703	.7373	.6859
9		.7373			
16	.3772		.2058	.2572	.1543
24		.3086	.3429		.2743
Max	.6859	.8059	.703	.7373	.6859
Min	.3772	.3086	.2058	.2572	.1543
Avg	.5316	.6173	.4172	.4973	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 202 / 11 KV ANASARWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.3491	2.1776	2.1434	2.0576	
16					2.4006
24		.3086	.5316		
Max	2.3491	2.1776	2.1434	2.0576	2.4006
Min	2.3491	.3086	.5316	2.0576	2.4006
Avg	2.3491	1.2431	1.3375	2.0576	2.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 203 / 11 KV TALIKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7373	.823	.8059	.6859	.583
9		.7373			
16	.6344		.7202	.6173	.6859
24		.3429	.6344		.3429
Max	.7373	.823	.8059	.6859	.6859
Min	.6344	.3429	.6344	.6173	.3429
Avg	.6859	.6344	.7202	.6516	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 201 / 11KV SYED ANKULGA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506				
2					.2012
3	.3506	.5258			
4			.3506		.2012
5	.5609	.7362			
7	.6661	.9114			.503
8	.929		.964		
9					.3018
11					.7362
12					.7888
13				.8764	.7888
15					.8764
16				.8764	.9114
17	.2012			.964	
20			.2347		
23	1.5432		.2683		
24	1.3717	.2629	.2629		.2515
Max	1.5432	.9114	.964	.964	.9114
Min	.2012	.2629	.2347	.8764	.2012
Avg	.7467	.6091	.4161	.9056	.5560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 202 / 11 KV BIBRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269	1.0517			
2					.7042
3	1.4899	1.5775	1.4022		
4				.6371	.7042
5	1.6651	2.0157			
6			1.7528	.9389	
7	1.8229	2.5941			1.0059
8	2.9447				
9					.8383
10			.503		
11				2.191	2.489
12					2.4188
13				2.4539	2.5415
14			.218		
15					2.4539
16				2.191	2.3663
17	.5365			2.6642	
18			.3353		
20			.6036		
23	1.5432		.6036		
24	1.1393	.9114	.8764		.8048
Max	2.9447	2.5941	1.7528	2.6642	2.5415
Min	.5365	.9114	.218	.6371	.7042
Avg	1.5461	1.6301	.7869	1.8460	1.6327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 203 / 11 KV Ujed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353					
2				.3155	.2629	.2629
3	.503	.3353	.3018			
4				.3155	.3155	.3155
5	.7545					
6						.3506
7	1.0395		.6706		.3506	
8	.9724			.4908		.3506
9					.3155	
10						.3353
11					.4694	.0343
12					.3353	.0343
13			.2454	.3018	.3018	.0286
14						.0286
15					.2515	.0286
16			.2804	.2515	.2515	.0343
17	.2515			.2012		.0343
18					.3353	.0381
19						.0381
20			.3688		.5868	
21						.0476
22					.503	.0476
23	.3688					.0476
24	1.0288	.3353	.3506		.2629	.2629
Max	1.0395	.3353	.6706	.4908	.5868	.3506
Min	.2515	.3353	.2454	.2012	.2515	.0286
Avg	.6567	.3353	.3696	.3127	.3494	.1289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 204 / 11kv Halki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4191				
2						.8764
3	.3018	.3688		.5609	.7011	
4			.503			1.0166
5		.4191		.6661	.9114	
6						1.0517
7	.5365	.4359			1.4022	
8			.503	1.5775		1.4373
9					1.5424	
10						.3353
11					.2515	.0381
12					.2012	
13				.2012	.2515	
14			1.5424			
15					.2515	.0191
16				.2012	.1677	.0286
17	1.6651			.2012		.0286
18			.4024		.4191	.0572
19						.0667
20					.503	.0667
21						.0667
22			.503		.4694	.0572
23	1.7147					.0476
24	.3353	.4191	.4191		.6135	.7888
Max	1.7147	.4359	1.5424	1.5775	1.5424	1.4373
Min	.3018	.3688	.4024	.2012	.1677	.0191
Avg	.8148	.4124	.6455	.5680	.5912	.3739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8402	.7468	.8589	1.6194	1.6278	2.0243
9	.8962	.8962		2.1052	1.7635	1.6194
12	1.7004		1.5384			
15	1.7004		1.5384			.2241
18	.4668		.362			.3734
21	.5601		.6535			.7468
24	.4887	.5601	.4854	.8097	.6443	1.1336
Max	1.7004	.8962	1.5384	2.1052	1.7635	2.0243
Min	.4668	.5601	.362	.8097	.6443	.2241
Avg	.9504	.7344	.9061	1.5114	1.3452	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9717	.8097	.7461	.5658	.6722	.4904
9	1.004	1.0526	.9496		.5228	.5228
12	.2987		.1867			.7287
15	.2241		.1867			.7287
18	.2801		.1867			.2801
21			.4668			.4668
24	1.5432	.4858	.407	.3734	.2987	.3395
Max	1.5432	1.0526	.9496	.5658	.6722	.7287
Min	.2241	.4858	.1867	.3734	.2987	.2801
Avg	.7203	.7827	.4471	.4696	.4979	.5081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 203 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.724	.7468	1.2146	1.2887	1.9433
9	.8688		.6908	1.7004	1.7635	1.6194
12	2.1862		1.3765			.2896
15	2.1862		1.3765			.2172
18	.362		.362			.2715
21	.543		.6335			.543
24	1.8861	.4525	.4854	.6478	.6783	.7773
Max	2.1862	.724	1.3765	1.7004	1.7635	1.9433
Min	.362	.4525	.362	.6478	.6783	.2172
Avg	1.3387	.5883	.8102	1.1876	1.2435	.8088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 204 / 11 KV DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.753	2.915	2.2721	.3772	.3734	.3018
9	2.8826	2.753	2.6113	.2641	.2987	.2641
12	.0754		.1867			2.5911
15	.0754		.0754			2.4291
18	.1132		.1886			.1886
21	.2641		.2641			.3018
24	1.933	1.2955	2.0348	.2641	.2241	.1886
Max	2.8826	2.915	2.6113	.3772	.3734	2.5911
Min	.0754	1.2955	.0754	.2641	.2241	.1886
Avg	1.1567	2.3212	1.0904	.3018	.2987	.8950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	01-MAR-18	02-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.9431			.9145	.8573
8				.823	
9	.7716				.6859
11			.5487		
12	.6401				
15	.4572				
16	.4572				
24	.3429	.3658		.3658	.4287
Max	.9431	.3658	.5487	.9145	.8573
Min	.3429	.3658	.5487	.3658	.4287
Avg	.6020	.3658	.5487	.7011	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.7716		.4915	.5144
8			.4096	
9	.8573			.4287
12	.1638			
15	.1638			
16	.1638			
24	1.3717	.2458	.2458	.2572
Max	1.3717	.2458	.4915	.5144
Min	.1638	.2458	.2458	.2572
Avg	.582	.2458	.3823	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 203 / 11KV ARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.7716		1.7814	1.7147
8			1.9433	
9	.6001			2.1434
12	1.9433			
15	1.8623			
16	1.9433			
24	.4287	.4049	.8907	.8573
Max	1.9433	.4049	1.9433	2.1434
Min	.4287	.4049	.8907	.8573
Avg	1.2582	.4049	1.5385	1.5718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 204 / 11KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
7	.0343	.0229	.0857
8		.1715	
9	.0343		.0857
15	.0229		
16	.0229		
24	.0343	.0229	.0343
Max	.0343	.1715	.0857
Min	.0229	.0229	.0343
Avg	.0297	.0724	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
7	.0343	1.2012	1.286
8		1.2936	
9	.0343		1.3717
15	1.2936		
24	.0343	.5544	.5144
Max	1.2936	1.2936	1.3717
Min	.0343	.5544	.5144
Avg	.3491	1.0164	1.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
7	2.1434	.7468	.6001
8		.6535	
9	2.4006		.4287
15	.2801		
24	.7716	.2801	.2572
Max	2.4006	.7468	.6001
Min	.2801	.2801	.2572
Avg	1.3989	.5601	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 201 / 11 KV TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2218		.2915			.5144
2	.3258	.2218		.2915			.5144
3	.362	.2218		.3086			.5144
4	.3856	.2587		.3429			.5487
5	.4382	.2587		.3772		1.6126	.583
6	.4973	.3142		.4458			.7095
7	.4287	.3326		.4801			.7202
8	.5228	.2957	.3353	.4115		2.0458	.6173
9	.3856		.3772	.3601	2.0805	2.0805	.6173
10	1.4922		1.4022			.2012	
11	1.8564	2.0111	1.5546	1.7177	.2652		
12	1.8564		1.6461				.2347
13	1.9006						
14	1.9662	2.1033		2.1033			.3018
15	1.9662				.2347		
16	1.9006		1.7071				
17	2.0553	2.1498	1.8595		.2012		.2683
18	.2561		.1543			.1829	.3018
19	.3658		.3429			.2743	
20	.439		.3601			.439	
21	.439		.2915			.3658	
22	.4024		.2915			.3475	
23	1.7147		.2915			.3109	
24	.3258	.2957	.2347	.2915	1.1919	1.262	.463
Max	2.0553	2.1498	1.8595	2.1033	2.0805	2.0805	.7202
Min	.2561	.2218	.1543	.2915	.2012	.1829	.2347
Avg	.9420	.7238	.7749	.6185	.7947	.8293	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 202 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.4755
2							.5121
3							.5121
4							.5487
5						.5548	.5853
6							.6584
7			.2683				.7499
8			.3018			.5895	.8048
9					.6588	.6241	.6584
10	.439		.421				
11	.5731	.4854	.4588	.4557	.2984		
12	.5373		.4588				.3018
13	.5014		.4096				
14	.4961	.6588	.3932	.6661			.2683
15	.5373		.3605		.2347		
16	.5014		.5243				
17	.6089	.6241	.4915		.2515		.2515
18							.2515
24	1.5432		.2347		.4161	.4508	.439
Max	1.5432	.6588	.5243	.6661	.6588	.6241	.8048
Min	.439	.4854	.2347	.4557	.2347	.4508	.2515
Avg	.6375	.5894	.3930	.5609	.3719	.5548	.5012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 203 / 11 KV GHUGI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.0739		.7377			
2	.6516	.0739		.7712			
3	.6859	.0739		.8048			
4	.7373	.0924	.7011	.8383			
5	.823	.1109		.9054		.1677	
6	.9389	.1463		1.0395			
7	1.1065	.1463		1.2071			
8	1.0688	.1097	.9816	1.2742		.2683	
9	1.1401		1.004	1.1568	.2012	.2012	
10	.2195					.8573	
11		.1006		.1677	.5895	.6173	
12	.1463					1.0802	.9362
13	.1097					1.166	
14	.1097	.1006		.1402		1.2003	1.0749
15	.128				1.0517	1.2003	
16	.1829					1.2346	
17	.1829	.1341			1.0056	.8402	1.0402
18	.1829						.1341
19	.2561						
20	.3475						
21	.2195						
22	.1463						
23	.1463						
24	1.8861	.6878	.631	.6539	.1341	.1341	
Max	1.8861	.6878	1.004	1.2742	1.0517	1.2346	1.0749
Min	.1097	.0739	.631	.1402	.1341	.1341	.1341
Avg	.5247	.1542	.8294	.8081	.5964	.7473	.7964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 204 / 11 KV NEW TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 201 / 11 KV SHIVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.4572	.6859	.7716	1.0288
2	.381	.381	.381	.4572	.7716	.7716	1.4575
3	.381	.381	.381	.4572	1.0288	.8573	1.5432
4	.4572	.381	.381	.5121	1.0974	1.0288	1.5432
5	.4572	.381	.381	.5144	1.1145	1.0288	1.6975
6	.4572	.381	.381	.5487	1.4575	1.0288	1.6975
7	.4572	.381	.381	.5144	1.7147	1.7147	1.7147
8	.4572	.381	.4572	.5144	1.7147	1.7147	
9	.4572	.381	.4572	.5487	1.7147	1.7833	1.3717
10	1.1431	1.105	1.0288	1.4575	.4572	.439	1.3717
11	1.7147	1.6004	1.7147	1.5432	.4572	.4755	.3048
12	1.7147	1.7147	1.7147	1.7147	.4572	.4755	.3048
13	1.5242	2.0957	1.7147	1.7833	.4572	.4755	.381
14	1.5242	2.1719	1.3717	1.8004		.4755	.381
15	1.5242	2.1338	1.3717	1.7147		.4755	.381
16	1.5242	2.1719	1.3717	1.8176	.4572	.5121	.381
17	1.5242	2.1719	1.3717	1.8861	.4572	.5121	.381
18	.381	.381	.4572	1.8861	.4572	.4801	.4858
19	.381	.381	.4572	.4755	.4572	.5121	.4858
20	.381	.381	.5487	.5487	.4572	.5373	.4572
21	.381	.381	.5144	.5487	.4572	.5487	.381
22	.381	.381	.5144	.4755	.4572	.5487	.381
23	.381	.381	.5144	.4755	.4572	.5487	.4572
24	1.5432	.381		.4572	.5487	.7716	.7716
Max	1.7147	2.1719	1.7147	1.8861	1.7147	1.7833	1.7147
Min	.381	.381	.381	.4572	.4572	.439	.3048
Avg	.8295	.8859	.7934	.9629	.7880	.7703	.8417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 202 / 11 KV HIPPALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4572	.5335	.5144	.3658	.3658	.3658
2	.5335	.5335	.6097	.5144	.3658	.3658	.3582
3	.6097	.5335	.6097	.5144	.3658	.3658	.3658
4	.6097	.6097	.6859	.6859	.3658	.3658	.439
5	.6859	.6859	.6859	.6859	.3658	.4572	.439
6	.7621	.6859	.7621	.6859	.4024	.4572	.439
7	.8383	.7621	.8383	.7716	.439	.3658	.4755
8	.8383	.8383	.8383	.7716	.439	.4024	.381
9	.7621	.9145	.9145	.3658	.439	.4024	.4572
10	.381	.2858	.3658	.4024	.5144	.6173	.6097
11	.381	.2858	.3658		.6859	.6859	.6097
12	.381	.2858	.3658	.3658	.6859	.7716	.6097
13	.381	.2858	.3658	.3658	.6859	.7716	.6097
14	.381	.2858	.3658	.3658	.6859	.8573	.6859
15	.381	.2858	.3658	.3658	.6859	.8573	.703
16	.381	.2858	.3658	.4024	.6859	.9431	.6859
17	.381	.2858	.3658	.439	.7716	.9431	.6859
18	.381	.2858	.4572	.439	.4572	.439	.381
19	.381	.3429	.4572	.439	.4572	.4298	.4572
20	.381		.4572	.439	.4572	.4656	
21	.381	.3429	.4572	.439	.3658	.4656	.3048
22	.381	.3429	.4572	.3658	.3658	.4755	
23	.2667	.3429	.4572	.3658	.3658	.4298	.3048
24	1.3717	.4572		.5144	.3658	.3658	.4024
Max	1.3717	.9145	.9145	.7716	.7716	.9431	.703
Min	.2667	.2858	.3658	.3658	.3658	.3658	.3048
Avg	.5319	.4531	.5282	.4878	.4910	.5444	.4896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 203 / 11 KV GANESHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0914	.1372	.2572	.2058
2	.0953	.0953	.0953	.0914	.1372	.2572	.2058
3	.0953	.0953	.0953	.0914	.1543	.3429	.2058
4	.0953	.0953	.0953	.0914	.1543	.3429	.2401
5	.1143	.0953	.1143	.0914	.1543	.4287	.2401
6	.1143	.1143	.1143	.0914	.2058	.4287	.2401
7	.1143	.1143	.1143	.0914	.2743	.4115	.2572
8	.1143	.1143	.1143	.0914	.2743	.4458	.2286
9	.1143	.1143	.1143	.0914	.2743	.4458	.2286
10	.1905	.1905	.2572	.12	.0914	.1097	.1219
11	.381	.2667	.3429	.1372	.0914	.1097	.1219
12	.381	.3429	.3429	.1543	.0914	.1097	
13	.4763	.3429	.3429	.1715	.0914	.1097	.1219
14	.4763	.3429		.1715	.0914	.1097	.1219
15	.4763	.3048	.4287	.1886	.0914	.1097	.1219
16	.4763	.3048	.4287	.2229	.0914	.1097	.1219
17	.4763	.3048	.4287	.2401	.0914	.1097	.1219
18	.0953	.0953	.0914	.0914	.0914	.1097	.1219
19	.0953	.0953	.0914	.1097	.1715	.1097	.1219
20	.0953	.0953	.0914	.1097		.128	.1219
21	.0953	.0953	.0914	.1097	.1791	.128	.1219
22	.0953	.0953	.0914	.1097	.1715	.1254	.1219
23	.5144	.0953	.0914	.0914	.1715	.128	.1296
24	.0953	.0953		.0914	.1463	.1715	.1463
Max	.5144	.3429	.4287	.2401	.2743	.4458	.2572
Min	.0953	.0953	.0914	.0914	.0914	.1097	.1219
Avg	.2239	.1667	.1851	.1226	.1491	.2141	.1648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 201 / 11 KV Waki Dam AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.2291	2.4577		1.8023		
12				.1715		
16				.1715		2.0576
18	.1677					
20			.1696			
24	1.5089	1.3413		1.5261	.1886	
Max	2.2291	2.4577	.1696	1.8023	.1886	2.0576
Min	.1677	1.3413	.1696	.1715	.1886	2.0576
Avg	1.3019	1.8995	.1696	.9179	.1886	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 202 / 11 KV Nandura AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.2579	3.3979	3.1131	
16				1.3717
24	.583	1.9281	2.0348	
Max	3.2579	3.3979	3.1131	1.3717
Min	.583	1.9281	2.0348	1.3717
Avg	1.9205	2.663	2.5740	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 203 / 11 KV THODAGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0857	.0829		.0838		
12				1.2003		
16				1.2003		.0943
20			.0848			
24	.0943	.0838		.0848	.7545	
Max	.0943	.0838	.0848	1.2003	.7545	.0943
Min	.0857	.0829	.0848	.0838	.7545	.0943
Avg	.09	.0834	.0848	.6423	.7545	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 204 / 11 KV NANDURA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144	.4144		.4144		
12				.1715		
16				.1715		.1715
18	.2401					
20			.3391			
24	.2829	.1677		.1696	.2829	
Max	.5144	.4144	.3391	.4144	.2829	.1715
Min	.2401	.1677	.3391	.1696	.2829	.1715
Avg	.3458	.2911	.3391	.2318	.2829	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 201 / 11 KV KINGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6001		.9431	
2	1.0288		.6001	.9431	.8573
3		.6859		1.0288	
4	1.2003	.7716	.8573	1.2003	1.2003
5		.9431		1.2003	
6	1.2003	1.0288	1.2003	1.3717	
7		1.286		1.2003	
8		1.3717	1.1145		
9		1.3717			
10				1.0288	
11		1.0288		.8573	
12				.8573	.8573
13		1.1145		.8573	
14					.7716
15				.8573	
16					.7716
18				.6859	.6001
20				.6859	.7716
22				1.0288	.8573
24	.4801	.6001	.6001	1.0288	.8573
Max	1.2003	1.3717	1.2003	1.3717	1.2003
Min	.4801	.6001	.6001	.6859	.6001
Avg	.9774	.9820	.8745	.9859	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 202 / 11 KV GUNJOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 203 / 11 KV KOPARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.7147	
2			.6001	2.0576	2.0576
3				2.2291	
4			.7716	2.3148	2.4006
5				2.4006	
6			1.286	2.572	2.7435
7				3.4294	
8			1.286	3.4294	2.915
9				1.1145	
10				.8573	.6001
11				.6859	
12				.5144	
13		2.572		.5144	
16					.5144
18				.6001	.6001
20				.8573	.9431
22				.6859	.7716
24	.3429		.6859	1.7147	1.7147
Max	.3429	2.572	1.286	3.4294	2.915
Min	.3429	2.572	.6001	.5144	.5144
Avg	.3429	2.572	.9259	1.6289	1.5261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 204 / 11 KV KINGAON EXPRESS

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0034	
2			.0857	.0086	.0857
3				.0086	
4			.0857	.0051	.0857
5				.0086	
6			.0857	.0086	.0857
7				.0086	
8			.0857	.0086	.0857
9				.0086	
10					.0857
11				.0086	
12				.0086	.0857
13		.0086			
14					.0857
15				.0034	
16					.0857
18				.0857	.0857
20				.0857	.0857
22				.0857	.0857
24	.0857		.0857	.0034	.0857
Max	.0857	.0086	.0857	.0857	.0857
Min	.0857	.0086	.0857	.0034	.0857
Avg	.0857	.0086	.0857	.0219	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 201 / 11 KV UJANA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
23	.4973
24	1.0974
Max	1.0974
Min	.4973
Avg	.7974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 202 / 11 KV SANGHAVI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 203 / 11 KV GANGA HIPPARGA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 204 / 11 KV UJANA EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 205 / 11KV BALGHAT KARKHANA NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18
HR	Load (MW)
24	.0724
Max	.0724
Min	.0724
Avg	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 201 / 11 KV DHALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3717	.5144	.5087	.6859	1.286	1.3717	1.1869
16	1.2003	1.0174		1.3717			
24	.5144	.3429	.3391		1.0288	1.0288	1.0174
Max	1.3717	1.0174	.5087	1.3717	1.286	1.3717	1.1869
Min	.5144	.3429	.3391	.6859	1.0288	1.0288	1.0174
Avg	1.0288	.6249	.4239	1.0288	1.1574	1.2003	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 202 / 11 KV ANDHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8004	1.6289	1.6956	1.6289	1.3717	1.3717	1.3565
16		.4239		.5144			
24	.6344	.7716	.5087		.8573	.5144	.5935
Max	1.8004	1.6289	1.6956	1.6289	1.3717	1.3717	1.3565
Min	.6344	.4239	.5087	.5144	.8573	.5144	.5935
Avg	1.2174	.9415	1.1022	1.0717	1.1145	.9431	.975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 203 / 11 KV KENDREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.286		1.1869	1.4575	1.8861		1.6956
16	.6859	.763		1.0288			
24	.6001		1.4413		2.0576	.5144	.5087
Max	1.286	.763	1.4413	1.4575	2.0576	.5144	1.6956
Min	.6001	.763	1.1869	1.0288	1.8861	.5144	.5087
Avg	.8573	.763	1.3141	1.2432	1.9719	.5144	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5658	1.6289	1.5432	1.6289		.4287	.4287
16		.2572	.2058		1.8861	2.0576	
24	.4115	1.0288	1.0288	.5144		.1715	.2572
Max	.5658	1.6289	1.5432	1.6289	1.8861	2.0576	.4287
Min	.4115	.2572	.2058	.5144	1.8861	.1715	.2572
Avg	.4887	.9716	.9259	1.0717	1.8861	.8859	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 202 / 11 KV TAKALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-MAR-18	05-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.3429
14	.1715		
16		.9431	
24			.2572
Max	.1715	.9431	.3429
Min	.1715	.9431	.2572
Avg	.1715	.9431	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 203 / 11 KV KAJAL HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8						2.2291	2.332
16		2.3148	2.4348		.9431	.3086	
24	.6173	.5144	.5144	.5144		.6859	.6859
Max	.6173	2.3148	2.4348	.5144	.9431	2.2291	2.332
Min	.6173	.5144	.5144	.5144	.9431	.3086	.6859
Avg	.6173	1.4146	1.4746	.5144	.9431	1.0745	1.5090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.427		.3795	.4251	.4111	.499
2	.5175	.4111		.3163	.3696	.3321	.4805
3	.5544	.3321	.5914	.2846	.3881	.3005	.4435
4	.5914	.2846		.3321	.4805	.3321	.5175
5	.8871	.506		.5376	.6653	.5376	.7023
6	1.0534	.7432	.8501	.759	.9795	.759	.9055
7	1.1827	.8065		.9962	1.2012	.9804	1.1827
8	1.0719	.7432	.9425	.8855	1.0349	.8697	1.0349
9			.7023	.8223	.924		.8871
10	.6325		.5914	.5218	.6325	.6009	.7392
11	.5693		.3163				
12	.4744		.2846	.4066		.4251	.4805
13	.4111	.7023		.462	.3637	.3511	.3696
14				.499	.3005	.3326	.3511
15	.5218		.3321	.462	.3321	.3142	.3326
16	.4111		.3163	.4435	.3163	.3696	
17		.4805	.3163	.4251	.3005	.3881	
18			.4428	.4805	.506	.499	
19			.759	.7392	.7116	.8871	
20			.7116	.7762	.4902	.7392	.7392
21	.6642		.5535	.6653	.4744	.7023	.6838
22	.6009		.506	.5914	.4428	.6283	.6468
23	.506	.499	.4586	.5544	.4586	.5544	.5544
24	.583	.4428	.462	.4428	.499	.4428	.5359
Max	1.1827	.8065	.9425	.9962	1.2012	.9804	1.1827
Min	.4111	.2846	.2846	.2846	.3005	.3005	.3326
Avg	.6518	.5315	.5375	.5558	.5589	.5344	.6361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3123	1.182		1.6834			
2	1.3763	1.3969		1.7551			
3	1.4083	1.4327	1.3717	1.6834			
4	1.4403	1.4327		1.7551			
5	1.5203	1.4685		1.7551			
6	1.5684	1.5043	1.4937	1.8267			
7	1.6004	1.6118		1.8983			
8	1.7604	1.576	1.5546	2.0416			
10					2.0058	2.0774	2.0557
11					2.6863	2.1125	2.2138
12	2.758				2.758	2.3045	2.372
13					2.364	2.4006	2.4669
14					2.2455	2.4006	2.372
15					2.5789	2.3045	2.3087
16					2.6147	2.1765	
17					2.6863	2.2405	
23		1.3108	1.5402				
24	.8573	1.2536	1.3413	1.6476			
Max	2.758	1.6118	1.5546	2.0416	2.758	2.4006	2.4669
Min	.8573	1.182	1.3413	1.6476	2.0058	2.0774	2.0557
Avg	1.5602	1.4169	1.4603	1.7829	2.4924	2.2521	2.2982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.3916	.0655	
2					1.4403	.0655	
3					1.4548	.0655	
4					1.5181	.0655	
5					1.5497	.0655	
6					1.5813	.0655	
7					1.7394	.0655	
8					1.8976	.0655	
9							.192
10	2.3282		1.829	2.2207			
11	2.7221		2.5072	2.2771			
12	2.758		2.5431	2.3087			
13	2.7938	2.2253		2.3045			
14	2.8296			2.2455			
15	2.2565		2.7221	2.3087			
16	2.758			2.3403			
17	2.7938	2.3472	2.758	2.372			
23				1.2651	.0716	.064	.5693
24	.6859				1.3283	.1075	.064
Max	2.8296	2.3472	2.758	2.372	1.8976	.1075	.5693
Min	.6859	2.2253	1.829	1.2651	.0716	.064	.064
Avg	2.4362	2.2863	2.4719	2.1825	1.3973	.0696	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
ST

Feeder No / Name : 201 / 11KV BUSTAND FEEDER.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
ST

Feeder No / Name : 202 / 11KV TELEPHONE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
STFeeder No / Name : 203 / 11KV EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1677	.2058
2					.1715	.1677	.2058
3						.1677	.2743
4					.1715	.1677	.2743
5						.1677	.3391
6					.1677	.1677	.4359
7						.1677	.5967
8					.1677	.1677	.57
9					.1715	.1677	.5487
10	.2743	.2515	.1715	.2743			
12		.3353					
14		.3353					
16		.3353					
17		.3353					
24		1.0217			.1372	.1715	.2058
Max	.2743	1.0217	.1715	.2743	.1715	.1715	.5967
Min	.2743	.2515	.1715	.2743	.1372	.1677	.2058
Avg	.2743	.4357	.1715	.2743	.1645	.1681	.3656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029		.1029	.1029		1.3413	1.3375
2	.1029	.1029	.1029	.1029	1.4083	1.3413	1.3717
3	.1029		.1029	.1029		1.5089	
4	.1029	.1029	.1029	.1029	1.4083	1.5089	1.4746
5	.1029		.1029	.1029		1.6766	1.6804
6	.1029	.1029	.1029	.1029	1.6766	1.8442	1.9334
7	.1029		.1029	.1029		2.2131	2.0317
8	.1029	.1029	.1341	.1029	2.1795	2.1795	2.3594
9	.1029			.1029		1.8442	2.0317
10	1.8442	2.0119	1.8442	1.7695	.1029	.1006	.1029
11			1.8351			.1029	.1029
12		2.4143			.1029	.1029	.1029
13			1.9006			.1029	.1029
14		2.3807	1.9989		.1029	.1029	.1029
15			1.9662			.1029	
16		2.3472	2.0972		.1006	.1029	.1029
17		2.2801	2.1956			.1029	.1006
18		.1029	.1029		.1029	.1029	.1029
19		.1029	.1029			.1029	.1029
20		.1029	.1029		.1029	.1029	.1029
21		.1029	.1029			.1029	.1029
22		.1029	.1029		.1029	.1029	.1029
23		.1029	.1029			.1029	.1029
24	.1029	.1029	.1029	.1029	1.3413	1.3717	1.3375
Max	1.8442	2.4143	2.1956	1.7695	2.1795	2.2131	2.3594
Min	.1029	.1029	.1029	.1029	.1006	.1006	.1006
Avg	.2612	.7854	.7006	.2544	.7277	.7612	.7679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.3429	.2058		1.0059	.9259
2	.2058	.2058	.3353	.2058	.8048	1.0059	.9259
3	.2058		.4694	.2743		1.1736	.9602
4	.2401	.2058	.4359	.3086	.8718	1.1736	1.0288
5	.2401		.4024	.3086		1.3413	1.1191
6	.2743	.2683	.6036	.3429	1.0059	1.3413	1.2407
7	.2743		.6371	.3429		1.3748	1.5074
8	.3086	.3353	.6036	.3086	1.2955	1.4083	1.4746
9	.2058			.2401		1.3413	1.1797
10	1.1065	1.1065	1.1065	1.0608	.2743	.3429	.1029
11			1.1603			.2743	.1029
12		1.3413	1.2125		.2012	.2058	
13			1.2452			.1715	.1677
14		1.3413	1.1469		.2012	.1715	.2012
15			1.1797			.1372	
16		1.3413	1.278		.2012	.1372	.2012
17		1.3413	1.3592			.1372	.2012
18		.2743	.1372		.2401	.1715	.2401
19		.583	.1715			.2058	.4801
20		.5144	.2401		.4115	.2743	.5487
21		.5144	.2058			.2401	.5144
22		.5144	.1715		.3429	.2058	.3429
23		.3429	.1715			.1715	.3429
24	.2058	.1715	.3429	.2058	.8048	.8573	.9259
Max	1.1065	1.3413	1.3592	1.0608	1.2955	1.4083	1.5074
Min	.2058	.1715	.1372	.2058	.2012	.1372	.1029
Avg	.3157	.6501	.6504	.3458	.5546	.6196	.6697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259		1.073	.823		.1006	.1029
2	.9259	1.0059	1.1401	.8573	.1029	.1006	.1029
3	.9945		1.2071	.8573		.1006	.1029
4	1.0288	1.0059	1.3077	.9259	.1029	.1006	.1029
5	1.2407		1.4083	.9945		.1006	.1029
6	1.3748	1.2071	1.5089	1.0486	.1029	.1006	.1029
7	1.5729		1.6095	1.3435		.1006	.1029
8	1.4746	1.4083	1.7101	1.5074	.1029	.1006	.1029
9	1.3108			1.3763		.1029	.1029
10	.1029	.1029	.1029	.1029	1.1736	1.1736	1.0059
11			.1029			1.1934	1.1736
12		.1029	.1029		1.3413	1.3108	1.3413
13			.1029			1.3923	1.5089
14		.1006	.1029		1.5089	1.4419	1.576
15			.1029			1.3763	
16		.1006	.1029		1.576	1.4091	1.4754
17		.1029	.1029			1.3923	1.4083
18		.1029	.1029		.1029	.1029	.1029
19		.1029	.1029			.1029	.1086
20		.1029	.1029		.1029	.1029	.1029
21		.1029	.1029			.1029	.1029
22		.1029	.1029		.1029	.1029	.1029
23		.1029	.1029			.1029	.1029
24	.8573	.9389	.8383	.823	.1029	.1029	.1029
Max	1.5729	1.4083	1.7101	1.5074	1.576	1.4419	1.576
Min	.1029	.1006	.1029	.1029	.1029	.1006	.1029
Avg	1.0736	.4183	.5758	.9691	.5353	.5132	.4844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801		.503	.5144		.503	.5144
2	.4801	.4694	.57	.5144	.4801	.4694	.4801
3	.5144		.6371	.4801		.4694	.5144
4	.5487	.5365	.6371	.5487	.4801	.4694	.5144
5	.5487		.5365	.6173		.503	.5765
6	.6104	.6706	.6706	.6036	.6706	.583	.6036
7	.6371		.7712	.6706		.6706	.7042
8	.7377	.6706	.7712	.7042	.6706	.6706	.6706
9	.663			.6173		.503	.6173
10	.5426	.6036	.6036	.5087	.4694	.503	.6036
11			.5487			.4801	.5365
12		.5365	.4973		.503	.4458	.4694
13			.4694			.4801	.4534
14		.5365	.5087		.503	.5144	.4024
15			.5087			.4801	
16		.5365	.4694		.503	.5487	.5365
17						.5487	.503
18		.6706	.6173		.5144	.583	.6371
19		.7377	.6859			.6173	.7042
20		.8048	.6516		.6706	.7545	.8573
21		.6706	.6173			.7202	.6859
22		.6371	.583		.6036	.6173	.6371
23		.5365	.5487			.583	.6036
24	.4801	.4694	.503	.5144	.4801	.503	.5144
Max	.7377	.8048	.7712	.7042	.6706	.7545	.8573
Min	.4801	.4694	.4694	.4801	.4694	.4458	.4024
Avg	.5675	.6058	.5868	.5722	.5457	.5509	.5800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 206 / 11KV Atola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743		.3772	.3086		.1006	.1029
2	.3086	.3772	.4024	.3429	.1029	.1006	.1029
3	.3086		.4694	.3429		.1006	.1029
4	.3086	.4458	.503	.3772	.1029	.1006	.1029
5	.3429		.6036	.4115		.1006	.1029
6	.4024	.5487	.6706	.503	.1006	.1341	.1372
7	.4694		.7377	.57		.2012	.1715
8	.7293	.7377	.6802	.7377	.1006	.2012	.1372
9	.5304			.5365		.2012	.1029
10	.1029	.1029	.1006	.1029	.4694	.4024	.4024
11			.1029			.3688	.3887
12		.0671	.1029		.503	.4359	.4359
13			.1029			.4694	.503
14		.0671	.1029		.503	.4641	.4694
15			.1029			.4359	
16		.0671	.1029		.57	.4641	.57
17		.0686	.1029			.4641	.503
18		.0514	.1029		.1029	.1029	.1029
19		.1372	.1029			.1029	.1715
20		.1677	.1029		.1029	.1029	.1372
21		.1677				.1029	.1372
22		.1341	.1029		.1029	.1029	.1006
23		.1029	.1029			.1029	.1006
24	.3086	.3353	.3353	.3086	.1029	.1029	.1029
Max	.7293	.7377	.7377	.7377	.57	.4694	.57
Min	.1029	.0514	.1006	.1029	.1006	.1006	.1006
Avg	.3715	.2237	.2779	.4129	.2387	.2277	.2256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0343	.0343		.0335	.0343
2	.0343	.0343	.0343	.0343	.0343	.0335	.0343
3	.0343		.0343	.0343		.0335	.0343
4		.0343	.0343	.0343	.0343	.0335	.0343
5	.0343		.0343	.0343		.0335	.0343
6	.0343	.0343	.0335	.0343	.0343	.0335	.0343
7	.0343		.0335	.0343			.0343
8	.0343	.0343	.0335	.0343	.0335		.0343
9	.0343			.0343			.0343
10	.0343	.0343	.0335	.0343	.0343		.0335
11			.0343				.0324
12		.0343	.0343		.0343		.0335
13			.0343				.0335
14		.0335	.0343		.0343		.0335
15			.0343				
16		.0343	.0343		.0343		.0335
17		.0343	.0343				.0335
18		.0343	.0343		.0343		.0343
19		.0343	.0343		.0343		.0343
20		.0343	.0343		.0343		.0343
21		.0343	.0343				.0343
22		.0343	.0343		.0343		.0343
23		.0343	.0343			.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0335	.0335	.0343	.0335	.0335	.0324
Avg	.0343	.0343	.0342	.0343	.0342	.0337	.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3717	1.7147	1.3717	.6001	.5335
16		.2286		1.2193	1.3717
24	.8573		.8573		.5144
Max	1.3717	1.7147	1.3717	1.2193	1.3717
Min	.8573	.2286	.8573	.6001	.5144
Avg	1.1145	.9717	1.1145	.9097	.8065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9907	2.0576	1.6004	2.7435	1.5242
16		2.2862		1.0669	1.286
24	.7716		.8573		1.1145
Max	.9907	2.2862	1.6004	2.7435	1.5242
Min	.7716	2.0576	.8573	1.0669	1.1145
Avg	.8812	2.1719	1.2289	1.9052	1.3082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 203 / 11 KV MAHALANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0576	2.2291	2.0576	2.4006	1.9052
16		1.7528		2.5911	2.2291
24	.4287		.4287		.4287
Max	2.0576	2.2291	2.0576	2.5911	2.2291
Min	.4287	1.7528	.4287	2.4006	.4287
Avg	1.2432	1.9910	1.2432	2.4959	1.521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 204 / 11KV Tivghal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4734		.1894
9		2.8407		2.2725
12			3.5035	
16	2.746		.6628	
24		.4734		
Max	2.746	2.8407	3.5035	2.2725
Min	2.746	.4734	.6628	.1894
Avg	2.746	1.2625	2.0832	1.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 205 / 11KV Bothi Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	03-MAR-18	04-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0947		.0947
9		.0947		.0947
12			.0947	
16	.0947		.0947	
24		.0947		
Max	.0947	.0947	.0947	.0947
Min	.0947	.0947	.0947	.0947
Avg	.0947	.0947	.0947	.0947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 202 / 11KV Janwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.4644		
6		1.6161					
7		2.2105	2.6192		.9474	1.0807	
8	.8173	.9288	.9102	.9288	1.5975		1.5652
9			.7988				1.5279
15					1.9319		
16	.3901	.3158		.3529		.3727	.1863
19			.6873				
22						.5776	
24	1.2074	1.0217	1.1888	1.1331	.4644	.4845	
Max	1.2074	2.2105	2.6192	1.1331	1.9319	1.0807	1.5652
Min	.3901	.3158	.6873	.3529	.4644	.3727	.1863
Avg	.8049	1.2186	1.2409	.8049	1.0811	.6289	1.0931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-MAR-18
HR	Load (MW)
16	.0953
Max	.0953
Min	.0953
Avg	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.964	.8669	.8764	.8764	.7287	1.6651	1.0517
16	1.0936	1.2269	1.3146	1.3146	.4382	.4382	.4382
24	.4382		.5258	.5258		.8764	.964
Max	1.0936	1.2269	1.3146	1.3146	.7287	1.6651	1.0517
Min	.4382	.8669	.5258	.5258	.4382	.4382	.4382
Avg	.8319	1.0469	.9056	.9056	.5835	.9932	.8180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 202 / 11KV Ajansonda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					2.2291	2.0957	2.1195
16	2.0576	2.0957	2.0348	2.0576			
24	.4144		.503	.5087		1.0059	1.0174
Max	2.0576	2.0957	2.0348	2.0576	2.2291	2.0957	2.1195
Min	.4144	2.0957	.503	.5087	2.2291	1.0059	1.0174
Avg	1.236	2.0957	1.2689	1.2832	2.2291	1.5508	1.5685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 203 / 11KV Naigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6575	.9831	1.9281	1.8233			
16					1.8442	1.6575	2.0119
24	.7287		1.0059	1.0774		.503	.4973
Max	1.6575	.9831	1.9281	1.8233	1.8442	1.6575	2.0119
Min	.7287	.9831	1.0059	1.0774	1.8442	.503	.4973
Avg	1.1931	.9831	1.467	1.4504	1.8442	1.0803	1.2546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 204 / 11KV BSF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0572	.04	.0381	.0438	.0429	.0381	.0419
16	.04	.0333	.0429	.04	.0381	.0419	.04
24	.0572		.0381	.0419		.0362	.041
Max	.0572	.04	.0429	.0438	.0429	.0419	.0419
Min	.04	.0333	.0381	.04	.0381	.0362	.04
Avg	.0515	.0367	.0397	.0419	.0405	.0387	.0410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 201 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.905	1.0288	.8573	.1715	.1886	.181
2	.905	1.086	1.1145	.8573	.1715	.1886	.181
3	1.086	1.086	1.2003	.9431	.1715	.1886	.181
4	1.1765	1.1765	1.286	1.0288	.1715	.1886	.2715
5	1.267	1.3575	1.3717	1.286	.2572	.2829	.2715
6	1.3575	1.448	1.3717	1.3717	.3429	.3772	.362
7	1.448	1.5384	1.3717	1.5432	.5144	.4715	.362
8	1.6289	1.6289	1.5432	1.5432	.4287	.3772	.362
9	.2829	.1886	.181	.3429		.2829	.2715
10	.1886	.1886	.1715	.2572		1.0288	.9431
11	.1886	.181	.1715	.1715		1.0288	1.448
12	.1886	.181	.1715	.1715	.8573	1.1145	1.448
13	.1886	.181	.1715	.1715		1.286	1.448
14	.1886	.0905	.1715	.0857	1.0288	1.3717	
15	.1886	.0905		.0857	1.3717	1.3717	1.6289
16	.1886	.0905	.0857	.0857	1.5432	1.4575	1.6289
17	.1886	.0905	.0857	.0857	1.5432	1.3717	1.6289
18	.181	.181	.0857	.1715	.1886	.181	.1886
19	.2829	.181	.2572	.2572	.2829	.181	.1886
20	.2829	.2715	.2572	.3429	.3772	.2715	.2829
21	.2829	.181	.2572	.3429	.3772	.2715	.2829
22	.2829	.181	.1715	.2572	.2829	.2715	.2829
23	.543	.6335	.6859	.2572	.2829	.181	.2829
24	.9431	.724	.8573	.7716	.1715	.1886	.181
Max	1.6289	1.6289	1.5432	1.5432	1.5432	1.4575	1.6289
Min	.181	.0905	.0857	.0857	.1715	.181	.181
Avg	.5985	.5776	.6117	.5537	.5268	.5885	.6220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 202 / 11KV Shivankhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.905	1.0288	.8573	.2572		.2715
2	.9955	1.086	1.0288	.8573	.2572	.3772	.362
3	1.086	1.086	1.1145	.8573	.3429	.3772	.362
4	1.267	1.267	1.286	1.0288	.4715	.4715	.362
5	1.3575	1.3575	1.286	1.2003	.5144	.5658	.4525
6	1.448	1.448	1.3717	1.3717	.6859	.7545	.6335
7	1.6289	1.5384	1.5432	1.4575	.9431	.8488	.8145
8	1.8099	1.8099	1.8004	1.4575	.6859	.8488	.905
9	.7545	.2829	.362	.5144		.5658	.724
10	.2829	.2829	.4287	.3429		.8573	.8573
11	.1886	.2715				1.1145	1.1765
12		.2715		.2572	.6001	1.2003	1.1765
13		.181	.2572	.2572		1.286	1.1765
14		.181	.2572	.2572	.8573	1.4575	1.1765
15		.181	.2572	.2572	1.2003	1.4575	1.1765
16		.2715	.2572	.2572	1.286	1.4575	1.1765
17	.2829	.362	.2572	.2572	1.286	1.3717	1.086
18	.3772	.4525	.2572	.2572	.2829	.362	.2829
19	.5658	.4525	.5144	.4287	.5658	.4525	.4715
20	.5658	.6335	.6001	.6001	.6602	.6335	.4715
21	.5658	.543	.6001	.5144	.5658	.6335	.5658
22	.4715	.543	.5144	.4287	.4715	.4525	.4715
23	.6335	.8145	.6859	.3429	.3772	.4525	.3772
24	.9431	.8145	.9431	.8573	.3429	.3772	.362
Max	1.8099	1.8099	1.8004	1.4575	1.286	1.4575	1.1765
Min	.1886	.181	.2572	.2572	.2572	.362	.2715
Avg	.8489	.7099	.7569	.6486	.6327	.7989	.7038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 203 / 11KV Dhaveli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.181	.1715	1.0288	1.2003	1.286
2	.1886	.1886	.181	.1715	1.1145	1.2003	1.286
3	.1886	.1886	.181	.1715	1.2003	1.286	1.3717
4	.1886	.1886	.181	.1715	1.3717	1.3717	1.3717
5	.2829	.2829	.181	.2572	1.5432	1.7147	1.3717
6	.4715	.3772	.2715	.2572	1.7147	1.8861	1.8004
7	.3772	.3772	.2715	.3429	1.8861	1.9719	2.1434
8	.2829	.4715	.362	.2572	1.8861	1.9719	2.1434
9	.2829	.2829	.181	.2572		.2572	.181
10	2.0814	1.9909	1.4575	1.5432		.1886	.181
11	2.1719	1.9909	1.3717	1.8004		.181	.1886
12	2.1719	2.0576	1.8861	1.8004		.181	.1886
13	2.1719	2.2291	1.8004	1.7147		.0905	.1886
14	2.3529	2.2291	1.8004	1.6289	.0943	.0905	.1886
15	2.3529	2.2291	1.8004	1.5432	.0943	.0905	.1886
16	2.3529	2.1434	1.8004	1.4575	.0943	.181	.1886
17	2.1719	2.1434	1.8004	1.8004	.0943	.181	.1886
18	.1886	.181	1.8861	.0857	.1886	.181	.1886
19	.1886	.181	.1715	.1715	.1886	.181	.1886
20	.1886	.2715	.2572	.2572	.1886	.181	.1886
21	.1886	.181	.2572	.1715	.1886	.2715	.1886
22	.1886	.181	.1715	.1715	.1886	.181	.1886
23	.1886	.181	.1715	1.0288	1.086	1.1145	1.1765
24	.1886	.1886	.181	.1715	1.0288	1.226	1.2003
Max	2.3529	2.2291	1.8861	1.8004	1.8861	1.9719	2.1434
Min	.1886	.181	.1715	.0857	.0943	.0905	.181
Avg	.9000	.8719	.7835	.7252	.7990	.7242	.7407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4428			
2			.4111	.4428			.8223
3		.4428		.4428		.8539	
4				.5693			.9172
5			.6009	.5693			
6		.6958		.6325		1.012	1.0753
7				.8539			
8		.6958	.759		1.4232	1.2018	1.1069
9		.6009	.6325			1.1385	1.1069
10		.6642	.6325			.3479	
11		.8223	.8223				
12	.8539	.9172	.9488			.2214	.253
13		.8855	1.012			.2214	
14		.8539	1.012			.2214	.2214
15			.9488			.2214	
16	.9488		.9488		.1898	.2214	
17			.9488				.253
18	.3163		.2846			.4428	
19		.4428	.3795				
20			.6325			.6642	.6325
21		.5693	.5376			.6009	
22		.5376	.506				
23		.4744	.506			.4744	
24		.4428		.4428	.6325	.506	.6642
Max	.9488	.9172	1.012	.8539	1.4232	1.2018	1.1069
Min	.3163	.4428	.2846	.4428	.1898	.2214	.2214
Avg	.7063	.6461	.6958	.5495	.7485	.5566	.7053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0633			
2			.0949	.0949			.0158
3		.0791		.0949			
4				.0949		.0158	.0158
5			.1581	.0949			
6		.1265		.1265			.0158
7				.1265			
8		.1581	.1581		.0158	.0158	.0158
9		.1581	.1898			.0158	.0158
10	.0158	.0158	.0158			.0791	
11		.0158	.0158				
12		.0158	.0158			.1265	.0949
13		.0158	.0158			.1265	
14		.0158	.0158			.1107	.0949
15			.0158			.1265	
16	.0158		.0158		.1265	.1265	
17			.0158				.0633
18			.0158			.0158	
19		.0158	.0158				
20			.0158			.0158	.0158
21		.0158	.0158			.0158	
22		.0158	.0158				
23		.0158	.0158			.0158	.0158
24		.0474		.0633	.0158	.0158	.0158
Max	.0158	.1581	.1898	.1265	.1265	.1265	.0949
Min	.0158	.0158	.0158	.0633	.0158	.0158	.0158
Avg	.0158	.0508	.0457	.0949	.0527	.0587	.0345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1581			
2			.2214	.253			.0158
3		.0633		.253			
4							.0158
5			.3163	.3163			
6		.0949		.3795			.0158
7				.4428			
8		.1581	.5376			.0158	.0158
9		.1581	.506			.0158	.0158
10	.0158	.0158	.0158		.1898	.2214	
11		.0158	.0158			.3163	
12		.0158	.0158			.4111	.506
13		.0158	.0158			.4111	
14		.0158	.0158			.4111	.506
15			.0158			.4428	
16	.0158		.0158		.506	.4744	
17			.0158				
18			.0158			.0158	
19		.0158	.0158				
20			.0158			.0158	.0158
21		.0158	.0158			.0158	
22		.0158	.0158				
23		.0158	.0158			.0158	.0158
24		.0158		.1581	.0158	.0158	.0158
Max	.0158	.1581	.5376	.4428	.506	.4744	.506
Min	.0158	.0158	.0158	.1581	.0158	.0158	.0158
Avg	.0158	.0452	.1001	.2801	.2372	.1999	.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 201 / 11KV Mahalangra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3311	.5716	.5127	.6097		.3048	.1829
2	.3996	.8002	.5328	.7621	.1829	.3429	
3	.4774	.8573	.6262	.8764		.3429	.1524
4	.5328	1.0098	.6849	.9907	.2743	.3429	
5	.7792	1.0669	.8203	1.0669	.3048	.381	.1543
6	.8807	1.1431	.8693	1.1431	.381	.381	.1829
7	.9127	1.1812	.9676	1.2765		.362	.1829
8	1.2107	1.1503	1.2193	1.2384	.2743	.3429	.1524
9	1.2193	1.0231	1.105		.2591		.1524
10	.1905	.2246		.1829	.6668		.4334
11	.1905			.1219	.8192	.6859	
12	.2096	.1971	.1905		.8764	.7245	.7694
13	.2096	.1547	.1905		.9526	.6706	.716
14	.1905	.1665		.1219	.8764	.6401	.7162
15	.1905	.1461	.1524	.1524	.7049	.6401	.7826
16	.1715	.1332	.1524		.8764	.5792	.894
17	.1715		.1524	.1219	.9717		.9719
18	.1715	.2046	.2286	.1524	.2667	.1067	.1998
19	.2096	.2331	.381	.2134	.3429		.2728
20	.2858	.2597	.4001		.4001	.3445	.3751
21	.3429	.3069	.381	.2439	.3429		.3258
22	.3048	.2483	.3429		.3048	.2743	.2997
23	.2667	.2275	.2858	.1829	.3048	.2439	.2649
24	.2922	.5335	.4077	.4954	.1829	.3048	.2439
Max	1.2193	1.1812	1.2193	1.2765	.9717	.7245	.9719
Min	.1715	.1332	.1524	.1219	.1829	.1067	.1524
Avg	.4226	.5382	.5049	.5529	.5031	.4218	.4012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 202 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7801	.9526	.8148	.8764		.2667	.3096
2	.8889	1.0288	.8262	1.0288	.1219	.3048	.2551
3	.9797	1.1431	.9394	1.0288	.1219	.3048	.272
4	1.1064	1.2384	1.0913		.1524	.3429	.1332
5	1.2562	1.3908	1.2337	1.2955	.1524	.3429	.2932
6	1.2646	1.5432	1.3742	1.3717	.1829	.3048	.3829
7	1.392	1.6004	1.3976	1.4861	.1829	.3048	.2282
8	1.467	1.5096	1.829	1.6004	.1524	.1905	.3784
9	1.7147	1.2748	1.7528		.1524		.3884
10	.1524	.1957		.1524	1.3336	.945	1.056
11	.1524		.1524	.1219		1.2955	1.3033
12	.1524	.1625	.1143	.1219	1.4861	1.3717	1.331
13	.1524	.1705	.1143		1.448	1.3413	1.3245
14	.1143	.1593	.1143		1.4098	1.3413	1.3196
15	.1143	.1705	.1524	.0914	1.3717	2.6215	1.2337
16	.1524	.1254	.1524		1.5242	2.422	1.3982
17	.1143	.1238	.1524	.0914	1.6194	2.5218	1.4238
18	.1905	.1625	.1905	.1219	.1905	.2551	.1631
19	.2286	.1911	.2286		.2286	.1665	.1998
20	.2667	.223	.2667	.1524	.2667	.3786	.2331
21	.2667	.2558	.2667	.1524	.2667	.4081	.2283
22	.2286	.2167	.2286		.2667	.4407	.2046
23	.1905	.2046	.2286	.1341	.2667	.4081	.2051
24	.7162	.8764	.6874	.8002	.1219	.2667	.38
Max	1.7147	1.6004	1.829	1.6004	1.6194	2.6215	1.4238
Min	.1143	.1238	.1143	.0914	.1219	.1665	.1332
Avg	.5851	.6487	.6221	.6252	.5918	.8064	.6102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 203 / 11KV Ashta

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2046	.3429	.3418	.3429	.7316	.9526	.8421
2	.1975	.381	.3808	.3429	.823	1.0479	.8745
3	.2498	.4191	.4186	.381		1.2574	.9755
4	.3414	.4954	.4967	.4572	.945	1.3717	
5	.4556	.724	.5097	.4954	1.0059	1.6194	1.1888
6	.6111	.6859	.5892	.5335	1.0669	1.7909	1.2346
7	.6661	.724	.5842	.6097	1.4022	1.8671	1.3413
8	.6291	.5002	.6097	.2667	1.5546	1.6766	1.4937
9	.5335	.4141	.4954		1.4632		1.4937
10	1.6385	1.3626	1.5242	1.0974	.2667	.2439	.2932
11	1.848		1.9052	1.2651	.2477		.1998
12	1.7909	1.5319	1.9052		.2286	.1543	.2252
13	1.6004	1.6711	1.7147		.1905	.1219	.1878
14	1.6385	1.5232	1.6385	1.0669	.1905	.1341	.1629
15		1.4167	1.5623	1.1279	.1905		
16	1.6194	1.4729	1.5623	1.1584	.1905		.1842
17	1.6004	1.5722	1.6385	1.1888	.2286		.2
18	.2858		.3429	.1829	.3429		.2498
19	.381	.3418	.4572		.4572	.3963	.4058
20	.4572	.4258	.4954	.3963	.5335	.4268	.4636
21		.4215	.4572		.4954	.3963	.3996
22	.4572	.3751	.381	.3353	.4382		.3946
23	.4001	.341	.3429	.6859	.4001	.2743	.3716
24	.2853	.3429	.2936	.3429	.6859	.8764	.7316
Max	1.848	1.6711	1.9052	1.2651	1.5546	1.8671	1.4937
Min	.1975	.341	.2936	.1829	.1905	.1219	.1629
Avg	.8132	.7948	.8603	.6462	.6121	.8593	.6325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 201 / 11 KV LIMBALWADI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
7	.7938	.2079
24	1.1271	
Max	1.1271	.2079
Min	.7938	.2079
Avg	.9605	.2079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 202 / 11 KV DEVANGARA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
7	.8488	.4527
24	.563	
Max	.8488	.4527
Min	.563	.4527
Avg	.7059	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 203 / 11 KV AMBULGA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-18	06-MAR-18
HR	Load (MW)	Load (MW)
7	.3765	1.1811
24	.2249	
Max	.3765	1.1811
Min	.2249	1.1811
Avg	.3007	1.1811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 201 / 11KV TOGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5087	.5087	.4409	.4409	.5087	
2	.4458	.5426	.5426	.4409	.4239	.5426	.4801
3	.4801	.5765	.6104	.4748	.407	.5765	
4	.5144	.6104	.6104	.4748	.4239	.6104	.5487
5	.6001	.6443	.6783	.4748	.4578	.6443	
6	.6173	.6783	.7122	.4409	.5426	.6443	.6173
7	.8573	.6783	.7291	.4409	.6443	.763	
8	.8916	.8648	1.0004	.407	.5935	.6783	.5487
9	.5144	.5087			.5596	.6104	.463
10	.463	.4748			.5426	.5426	.4115
11				.4287	.6952		.4458
12				.4458	.6783		.4801
13				.4287			.4458
14				.4115	.6783		.4458
15				.4115	.6783		.4801
16				.4115	.6783		.5144
17				.4287	.5935		.4801
18					.5426		.5144
19					.7969		
20					.763		.4801
21					.6783		
22					.6443		.4458
23					.5426		.4115
24	.4458	.4409	.407	.407	.4578	.4748	.4801
Max	.8916	.8648	1.0004	.4748	.7969	.763	.6173
Min	.4458	.4409	.407	.407	.407	.4748	.4115
Avg	.5705	.5935	.6443	.4355	.5854	.5996	.4830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 202 / 11KV LASONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5935	.5426	.3391	.0848	.1017	
2	.6001	.6443	.5765	.5087	.0848	.1017	.1029
3	.6001	.7122	.6104	.5935	.0848	.1017	
4	.823	.7461	.6783	.6783	.0848	.1017	.1372
5	.8573	.8139	.7122	.763	.1187	.1187	
6	.8745	.8478	.7461	.8139	.1696	.1357	.1715
7	1.2003	.9326	.763	1.0513	.2204	.2035	
8	1.3032	.9156	.9835	1.1191	.1526	.2035	.1543
9	.1372	.0678			.1526	.2035	.12
10		.1526			.8478	.8478	.8916
11				.0686	.9665		.9259
12				.0686	1.0174		1.0802
13				.0514	1.0174		1.0974
14				.0514	1.0174		1.0631
15				.0514	1.0174		1.0631
16				.0514	1.0174		1.0288
17				.0514	1.0513		
18					.0678		.0857
19					.1187		
20					.1187		.0686
21					.1187		
22					.1017		.0857
23					.0848		.0857
24	.6001	.5596	.407	.407	.0848	.0848	.1029
Max	1.3032	.9326	.9835	1.1191	1.0513	.8478	1.0974
Min	.1372	.0678	.407	.0514	.0678	.0848	.0686
Avg	.7596	.6351	.6688	.4168	.4084	.2004	.4862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 203 / 11KV WALANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4409	.6104	.4239	.5087	.6104	.5487
2	.6516	.5426	.6783	.5087	.5087	.6783	.6173
3	.7716	.6104	.7461	.5935	.5087	.7461	.6859
4	.7716	.7122	.8139	.5935	.8478	.78	
5	.7888	.8478	.9496	.6783	.9835	.8478	
6	.823	.8817	1.0852	.6783	.5087	.9496	
7	1.2003	1.0513	1.2887	.763	.6783	.7461	
8	1.2003		1.2548	.763	.6783	.5087	.6516
9	.6173				.5765		.5144
10	.6516	.7461			.8478	.78	.7888
11					1.0513		.7545
12				.3086	.9835		.7545
13				.3086	1.0174		.6859
14				.3086	1.0174		.6859
15				.3086	1.0174		.823
16				.3086	1.0174		.8916
17				.3086	1.0174		
18							.3429
19					.8139		
20					.78		.5144
21					.7461		
22					.6783		.5144
23					.5426		.5144
24	.5144	.373	.5426	.3391	.5087	.5426	.5487
Max	1.2003	1.0513	1.2887	.763	1.0513	.9496	.8916
Min	.5144	.373	.5426	.3086	.5087	.5087	.3429
Avg	.7810	.6896	.8855	.4795	.7756	.7190	.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 205 / 11KV BORUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4409	.3391	.4239	.8478	.9496	.2058
2	.4287	.5426	.407	.4239	.8478	1.0513	.2401
3	.4801	.6783	.4748	.5087	1.0174	1.1191	.2743
4	.7716	.78	.6783	.5087	1.1869	1.2209	.3086
5	.8573	.8817	.8139	.5426	1.1869	1.3565	.3429
6		1.0174	.8817	.5935	1.3904	1.3565	.3772
7		.9496	.9835	.5935	1.4243	1.6956	.3772
8			.78	.6783	1.3904	1.6956	1.2346
9	.3429	.78			.6783		1.3032
10	.6722	1.0852			.407	.3391	1.2689
11	1.3032			1.1145	.373		
12	1.3032			1.2003	.3052		
13	1.3032			1.2003	.2713		.6859
14	1.3032			1.2003	.2713		
15	1.286			1.286	.2374		.6859
16	1.286			1.3375	.2374		.6859
17	1.286			1.3717	.2035		
18	.3429				.6104		.4458
19	.4801				.5087		
20	.4973				.5087		.4801
21	.5144				.5087		
22	.4801				.4748		.5144
23	.4115				.8139		.5144
24	.4287	.373	.373	.3391	.8478	.8478	.2058
Max	1.3032	1.0852	.9835	1.3717	1.4243	1.6956	1.3032
Min	.3429	.373	.3391	.3391	.2035	.3391	.2058
Avg	.7718	.7529	.6368	.8327	.6896	1.1632	.5639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 206 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4409	.373	.3391	.8478	.9326	
2	.3772	.5087	.407	.373	.8478	.9326	1.0288
3	.3772	.5765	.4748	.4239	.8817	.9326	
4	.4801	.6104	.5426	.4096	.9326	1.0174	1.3717
5	.6173	.6783	.6783	.407	.9665	1.0174	
6	.7545	.7291	.7461	.407	1.0174	1.1022	1.5089
7	.7202	.7969	.8817	.4409	1.4582	1.56	
8	.7545	.7461	.8139	.4409	1.3904	1.6956	1.5775
9	.6859	.6274			.6104	1.6956	.6859
10	1.0802	1.1869			.3561	.4239	.4801
11				1.3717	.3391		.4458
12				1.4575	.3391		.4115
13				1.3717	.2713		.4115
14				1.3375	.3052		.3772
15				1.3375	.3052		.4115
16				1.3717	.3222		.3086
17				1.4918	.2883		.3429
18					.3391		.3601
19					.6104		
20					.5765		.3429
21					.5426		
22					.5087		.463
23					.8139		.4458
24	.3772	.39	.3391	.3391	.8478	.9326	.823
Max	1.0802	1.1869	.8817	1.4918	1.4582	1.6956	1.5775
Min	.3772	.39	.3391	.3391	.2713	.4239	.3086
Avg	.6001	.6628	.5841	.8325	.6549	1.1130	.6554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154098 / 33 KV SUB STATION TOGRI

Feeder No / Name : 203 / 11 KV WAGDRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281				.8676	
2	.4527	.6413			1.226	.9054	
3		.679				1.0562	
4	.6036	.7842	.4904	.7356	1.2449	1.358	
5		.8962				1.6057	
6	1.1694	.9709			1.3203	1.643	
7		1.0456				1.6804	
8	1.0562	1.0829	1.0185	.9808	1.7353	2.0165	1.8107
9	.8299	.9709			.679	.3734	.6661
10	1.1694	1.1203			.5658	.4481	.5609
11	.5975						
12	1.1203		1.0562	1.5089	.2241		.5658
13	1.3817	1.5089			.2241		
14	1.4937				.2614		
15	1.5684				.2614		
16	1.531		1.6032	1.5278	.3361		.4715
17	1.6057	1.5089			.3734		
18	.6348				.3772	.2804	
19	.7842				.6413		
20	.7545		.7356	.7545	.679		.9054
21	.679				.6413		
22	.6036			.6413	.7545		
23	.5281	.4557		.8676	.8676		.679
24	.4527	.5281	.4904	.4904	.9054	.6036	.2804
Max	1.6057	1.5089	1.6032	1.5278	1.7353	2.0165	1.8107
Min	.4527	.4557	.4904	.4904	.2241	.2804	.2804
Avg	.9508	.9086	.8991	.9384	.7010	1.0699	.7425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 201 / JAWALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.381		.5716	1.2003	.8097	.7362
2	.6859	.381		.6097	1.3032	1.1022	.8859
3	.7621	.5335		.6859	1.4403	1.3108	1.134
4	.9145	.5716		.7621	1.6095	1.5565	1.3611
5	.9526	.6478		.9907	1.7436	1.7204	1.5043
6	.9907	.724	.9907	.8764	1.8785	1.9433	1.7909
7	.7621	.8002	.8002	.9145	1.9524	2.1538	2.2207
8	.8383	.6859	.7621	.9907	1.6933	2.1862	2.1491
9	.724	.6097	.6478	.8002	1.0098	.9145	.8764
10	1.6876		.57	1.4746		.6859	.724
11	1.7814	1.8138		1.7532	.5716	.4954	.4954
12	1.9271	1.9757	1.7147	1.3927	.2667	.4191	.3429
13	1.5546	1.9757	1.858	1.3927	.2667	.3429	.3048
14	1.8404	2.1376	2.1491	1.8679	.2667	.2667	.2667
15	1.8122	1.6956	1.4373	2.3434	.3048	.2667	.2286
16	2.0405	2.0348		1.9757	.2667	.3048	.2667
17	1.9919			2.1214			.2667
18	.4191		.4572				
19	.7049	.7621	.823				.8383
20	.8573	.8954	.8764				.9907
21	.724		.8383				.8383
22	.6097		.724				.6859
23	.5716	.5716	.6097	.9945			
24	.4954	.4954	.5144	.5716	1.1145	.6478	.5144
Max	2.0405	2.1376	2.1491	2.3434	1.9524	2.1862	2.2207
Min	.4191	.381	.4572	.5716	.2667	.2667	.2286
Avg	1.0925	1.0364	.9858	1.2152	1.0555	1.0075	.8828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 202 / 11 KV KAUTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6821	.1524		.5571	.2667	.2477	.3048
2	.8526	.1143		.6706	.3048	.3048	.3429
3	1.0231	.1143		.7545	.3429	.381	.381
4	1.0972	.1524		.8573	.381	.5144	.4954
5	1.1608	.1905		.9214	.4572	.5716	.5716
6	1.1816	.2286		.2743	.5335	.6287	.6097
7	1.3211	.2667		1.134	.5716	.5906	.6859
8	1.1742	.2286		1.134	.5335	.5906	.6097
9	1.1491	.4572		.5335	.4954		.5335
10	.5335			.4191	.6478	.5792	.6097
11	.4572	.6154		.3048	.4534	.6097	.9819
12	.381	.8817		.1905	.2012	.8573	1.0584
13	.381	.2286		.1905		.9602	.9739
14	.2667	.2286		.1905	.2667	.7712	.9464
15	.2477	.2286	.8048	.2286	.8097	.8764	.8469
16	.2286	.2667		.1905	.9878	1.1393	.8775
17	.2286			.2286			1.067
18	.2477		.5487				
19	.3429	.4763	.381				.5335
20	.4572	.6859	.6097				.5906
21	.4763		.5335				.4191
22	.381		.381				.381
23	.3429		.3658	.3048			
24	.5056	.4694		.4572	.2667	.2667	.2286
Max	1.3211	.8817	.8048	1.134	.9878	1.1393	1.067
Min	.2286	.1143	.3658	.1905	.2012	.2477	.2286
Avg	.6300	.3326	.5178	.5022	.4700	.6181	.6386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 203 / 11 KV MATEGADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.0572		.4801	.0953	.0953	.0953
2	.6487	.0381		.5898	.1143	.1143	.1143
3	.6828	.0572		.6706	.1524	.1334	.1143
4	.7682	.0762		.7202	.1905	.1905	.1524
5	.8194	.0953		.7712	.2286	.2286	.1905
6	.857	.1143	.8421	.2804	.2667	.2858	.3048
7	.8867	.1524	1.004	.823	.3429	.3429	.381
8	.9549	.0762	.9717	.6516	.3048	.2858	.3048
9	.9389	.1524	.2286	.1905	.2286	.2286	.2667
10	.1905		.1905	.1143	.5182	.5944	.6487
11	.1905	.1524	.1905	.1143	.2591	.7316	.9146
12	.1524	.1143		.0762	.8097	.8916	.9453
13	.1143	.407		.0762	.8097	.9709	1.0489
14	.1334	.6478		.0762	.8097	.6859	1.0548
15	.1334	.1143	.0572	.0572	.8097	.7545	1.0128
16	.1524	.1334		.0572	.9069	.9602	1.0332
17	.1524			.0762			1.0501
18	.1143		.0953				
19	.2286	.1905	.1524				.1905
20	.1715	.3048	.2286				.2858
21	.1524		.1905				.1715
22	.1334		.1524				.1524
23	.3856	.407	.2972	.0953			
24	.4742	.5144		.3963	.0762	.1334	.1143
Max	.9549	.6478	1.004	.823	.9069	.9709	1.0548
Min	.1143	.0381	.0572	.0572	.0762	.0953	.0953
Avg	.4186	.2003	.3539	.3325	.4073	.4487	.4794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 204 / Morge Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	05-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
12	.0093		.0459
13	.0093		
14			.0524
15		.0186	.037
16	.028		
17	.0467		
18	.056		
19	.0093		
Max	.056	.0186	.0524
Min	.0093	.0186	.037
Avg	.0264	.0186	.0451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 201 / mortalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.4287			
5				1.0288			
6	1.1145			.6859			
10	1.1145						
11							.1715
12		.6859	.6859	.6859		.3429	
15			.5144				
16			.5144				.1715
17			.4287				
18			.4287				
20			1.0288				
22			.6859				.5144
23					.4287		
24	.2572		.3429	.4287			.5144
Max	1.1145	.6859	1.0288	1.0288	.4287	.3429	.5144
Min	.2572	.6859	.3429	.4287	.4287	.3429	.1715
Avg	.8287	.6859	.5787	.6516	.4287	.3429	.3430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 202 / khandsari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.0288			
5			1.0288			
6	1.286		1.2003			
8			1.8004			
10	1.6289					
11						1.286
12		.0857	.0857	1.5432	1.5432	
15		.0857				
16		.0857				1.4575
17		.0857				
18		.0857				
20		.0857				
22		.0857				.0857
24	1.0288	1.0288	1.0288			.0857
Max	1.6289	1.0288	1.8004	1.5432	1.5432	1.4575
Min	1.0288	.0857	.0857	1.5432	1.5432	.0857
Avg	1.3146	.2036	1.0288	1.5432	1.5432	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 203 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.2572			
5			.8573			
6	.8573		.8573			
9			.9431			
11						.3429
12		.5144	.8573	.2572	.3429	
15		.5144				
16		.6859				.1715
17		.8573				
18		.2572				
20		.4287				
22		.3429				.2572
24	.1715	.1715	.2572			.3429
Max	.8573	.8573	.9431	.2572	.3429	.3429
Min	.1715	.1715	.2572	.2572	.3429	.1715
Avg	.5144	.4715	.6716	.2572	.3429	.2786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 204 / shelgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			1.2003			
5			1.5432			
6	1.5432		1.8004			
8			2.3148			
10	2.4863					
11						1.6289
12		.1715	.1715	2.2291	2.0576	
15		.1715				
16		.1715				1.8861
17		.1715				
18		.1715				
20		.1715				
22		.1715				.1715
24	1.2003	1.2003	1.2003			.1715
Max	2.4863	1.2003	2.3148	2.2291	2.0576	1.8861
Min	1.2003	.1715	.1715	2.2291	2.0576	.1715
Avg	1.7433	.3001	1.3718	2.2291	2.0576	.9645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 201 / telgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0429	.0532	.0496	.0497	.0207	.0177	.0177
2	.048	.0549	.0514	.0532	.0243	.023	.0195
3	.0497	.0567	.0549	.0549	.0302	.0248	.0195
4	.0566	.0602	.0567	.0583	.0317	.028	.0195
5	.0617	.0691	.0602	.0634	.0355	.0283	.0301
6	.0806	.0709	.0744	.0703	.0411	.0301	.0319
7	.0806	.0744	.085	.0274	.0299	.0266	.0283
8	.0789	.077	.085	.0737	.0321	.0177	.0213
9	.0248	.0274	.0248	.0223	.0195	.0154	.023
10	.0159	.0171	.0159	.0228	.0602	.0549	.0656
11	.0195	.0223	.0181	.0159	.0833	.0806	.0815
12	.0159	.0171	.0109	.0106		.0737	.0851
13		.012	.0127	.0106			.085
14	.0142	.012	.0127	.0106		.0754	.0815
15	.0177	.0103	.0127	.0106		.0789	.076
16	.0177	.012	.012	.0106		.0823	.0815
17	.0158	.0106	.0103	.0131		.0744	.0737
18	.0123	.0142	.012	.0151	.0425	.0159	.0137
19	.0266	.0266	.0257	.0224	.0638	.0266	.024
20	.0266	.0283	.0257	.0321	.0709	.0301	.0291
21	.023	.023	.0206	.0245	.0248	.023	.0223
22	.0195	.0195	.0206	.0205	.023	.0213	.0206
23	.0425	.0425	.0394	.0189	.0195	.0195	.0171
24	.0412	.0532	.0478	.048	.0207	.0177	.0177
Max	.0806	.077	.085	.0737	.0833	.0823	.0851
Min	.0123	.0103	.0103	.0106	.0195	.0154	.0137
Avg	.0362	.0360	.0350	.0316	.0374	.0385	.0411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 202 / shirur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0197	.0195	.0189	.0243	.0228	.0213
2	.0206	.0213	.0213	.0206	.0243	.0248	.0213
3	.0206	.0213	.0213	.0206	.0261	.0266	.0213
4	.0223	.023	.0213	.0223	.0224	.0283	.023
5	.0274	.0271	.023	.0223	.028	.0301	.0266
6	.0309	.0287	.0266	.024	.0317	.0301	.0283
7	.0343	.0326	.0354	.0343	.0299	.0319	.0319
8	.0377	.0525	.0337	.036	.0317	.0283	.0283
9	.0266	.024	.0266	.0257	.0248	.0223	.0266
10	.0266	.0257	.0248	.0243	.0266	.0274	.0248
11	.023	.0274	.0235	.0189	.0319	.0343	.0301
12	.0248	.0274	.0235	.023		.0326	.034
13	.0248	.0257	.0223	.0213			.0337
14	.0213	.024	.0181	.0213		.0309	.0304
15	.0248	.0223	.0235	.0213		.0291	.0304
16	.0248	.0223	.012	.0213		.0309	.0287
17	.0228	.023	.024	.0264		.0354	.0291
18	.0195	.023	.024	.0245	.0293	.0248	.0206
19	.0248	.0301	.0291	.0245	.0287	.0337	.0274
20	.0283	.0283	.0309	.0245	.0298	.0319	.0291
21	.0263	.0266	.0274	.0261	.0309	.0301	.0291
22	.0248	.0248	.0206	.0283	.0283	.0283	.0274
23	.0177	.0177	.0171	.0264	.0269	.0248	.024
24	.0189	.0213	.0177	.0189		.023	.0213
Max	.0377	.0525	.0354	.036	.0319	.0354	.034
Min	.0177	.0177	.012	.0189	.0224	.0223	.0206
Avg	.0247	.0258	.0236	.0240	.0280	.0288	.0270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 203 / belur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0069	.0072	.0089	.0086	.0275	.0372	.0354
2	.0086	.009	.0071	.0086	.0291	.0372	.0372
3	.0086	.0107	.0089	.0086	.0308	.0372	.0372
4	.0103	.0125	.0089	.0103	.0328	.0372	.039
5	.0137	.0143	.0124	.0137	.0344	.039	.0425
6	.0171	.0161	.0195	.0171	.0377	.0386	.0443
7	.0189	.0195	.0195	.0189	.0389	.0478	.0461
8	.0154	.034	.0159	.0171	.0377	.0456	.0496
9	.0159	.0171	.0142	.0154	.0142	.0154	.0159
10	.0372	.0377	.0425	.0408	.0089	.0103	.0124
11	.0443	.0429	.0376	.0443	.0089	.0103	.0088
12	.0443	.0463	.0429	.0456		.0086	.0053
13	.0425	.048	.0362	.0456		.0051	
14	.0443	.0429	.0429	.0443		.0069	.0073
15	.0443	.0446	.0367	.0461			.0072
16	.0443	.0463	.0367	.0461		.0069	.0071
17	.0438	.0478	.0343	.0421		.0071	.0086
18	.0088		.0069	.0093	.0072	.0089	.0086
19	.0124	.0159	.0137	.0113	.0159	.0159	.0137
20	.0142	.0159	.0137	.0149	.0142	.0142	.0137
21	.0124	.0142	.012	.0132	.014	.0124	.012
22	.0105	.0106	.0103	.0131	.0124	.0124	.0103
23	.0089	.0089	.0086	.0279	.034	.0337	.0343
24	.0086	.0088	.0089	.0086	.0262	.0372	.0354
Max	.0443	.048	.0429	.0461	.0389	.0478	.0496
Min	.0069	.0072	.0069	.0086	.0072	.0051	.0053
Avg	.0223	.0248	.0208	.0238	.0236	.0228	.0231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 204 / shirur Exp.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0175	.0177	.0179	.0164	.0177	.0177
2	.0179	.0175	.0177	.0179	.0162	.0175	.0177
3	.0179	.0177	.0177	.0179	.0164	.0177	.0177
4	.0179	.0175	.0177	.0179	.0164	.0177	.0177
5	.0179	.0175	.0177	.0179	.0164	.0175	.0177
6	.0179	.0175	.0177	.0179	.0164	.0175	.0177
7	.0179	.0179	.0177	.0179	.0162	.0175	.0177
8	.0179	.0181	.0177	.0179	.0162	.0171	.0177
9	.0177	.0179	.0177	.0179	.0177	.0179	.0177
10	.0177	.0179	.0177	.0171	.0177	.0179	.0177
11	.0177	.0179	.0189	.0175	.0177	.0179	.0177
12	.0177	.0179	.0189	.0171		.0179	.0181
13	.0177	.0179		.0171	.0177	.0179	.0175
14	.0177	.0179	.0189	.0175		.0179	.0177
15	.0177	.0179	.0189	.0173		.0179	.0177
16	.0177	.0179	.0179	.0175		.0179	.0177
17	.0175	.0177	.0179	.0162		.0177	.0179
18	.0175	.0177	.0179	.0164	.0175	.0177	.0179
19	.0177	.0177	.0179	.0164	.0177	.0177	.0179
20	.0175	.0177	.0179	.0164	.0177	.0177	.0179
21	.0173	.0177	.0179	.0164	.0177	.0177	.0179
22	.0175	.0177	.0179	.0162	.0175	.0177	.0179
23	.0175	.0177	.0179	.0164	.0171	.0177	.0179
24	.0181	.0173	.0177	.0179	.0162	.0173	.0177
Max	.0181	.0181	.0189	.0179	.0177	.0179	.0181
Min	.0173	.0173	.0177	.0162	.0162	.0171	.0175
Avg	.0177	.0177	.0180	.0173	.0170	.0177	.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 201 / kolnoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 202 / sonwala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.663
Max	.663
Min	.663
Avg	.663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 203 / mali hipparga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	1.448
Max	1.448
Min	1.448
Avg	1.448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 201 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 202 / ekurka

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 203 / gudsur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 204 / wadhona w/w exp.feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154044 / wadhona bk.

Feeder No / Name : 205 / 11 KV SUKNI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 201 / kumtha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0176	.0208	.0166	.0057	.0075	.0075
2		.0203	.0203		.0057	.0094	.0075
3		.019	.03	.0166	.0075	.0094	.0093
4		.0144	.0288	.018	.0075	.0112	.0094
5		.0141	.0197	.0182	.0094	.0112	.0112
6		.0176	.0206	.0199	.0093	.0132	.0112
7			.0174	.0213	.0148	.0131	.0151
8			.0203	.0229	.0129	.0131	.0131
9			1.4918	1.2883	.0129	.0075	.9995
10			1.1576	.8215	.0178	.0097	
11			.9054	.0074	.018		1.326
12			.6979	.0074	.0178	.0113	1.3435
13			.6348	.0055	.0194	.013	1.3108
14			.5658	.0037	.0197	.0147	1.21
15			.4904	.0055	.0194	.018	1.3272
16			.5228	.0055	.0213	.0162	1.278
17			.5601	.0057	.018	.0115	1.1469
18			.6348	.0057	.0037	.0057	.6535
19			1.0642	.0094	.0093	.0093	1.1949
20		.011	1.1317	.0113	.0075	.0113	1.1883
21		.0093	1.1203	.0094	.0093	.0094	1.0269
22		.0092	.8402	.0075	.0075	.0075	.8676
23		.0056	.0166	.0075	.0056	.0075	.7922
24	.7621	.0142	.0372	.0166	.0057	.0075	.0056
Max	.7621	.0203	1.4918	1.2883	.0213	.018	1.3435
Min	.7621	.0056	.0166	.0037	.0037	.0057	.0056
Avg	.7621	.0138	.5021	.1022	.0119	.0108	.6850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 202 / chimachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0056	.0093	.9896	.032	.041	.041
2		.0168	.0091		.0331	.0426	.0421
3		.0146	.0111	1.2637	.0331	.0453	.0442
4		.0148	.0129	1.307	.0342	.047	.0459
5		.0165	.0131	1.419	.0342	.0508	.047
6		.0165	.0165	.0205	.0352	.0534	.047
7			.0205	.0189	.042	.0573	.0557
8			.0256	.0207	.0449	.0551	.0518
9			1.6804	.0205	.0185	.0187	1.7737
10			.0497	.0492	.0113	.0131	1.4901
11			.0492	.0507	.0093	.0112	.9619
12			.0524	.0472		.0057	.7545
13			.0492	.0457	.0019	.0075	.6908
14			.0475	.0381	.0037	.0075	.6348
15			.0464	.042	.0038	.0056	.5975
16			.0492	.0443	.0056	.0056	.5601
17			.0492	.0405	.0038	.0056	.5415
18			.5975	.0055	.0057	.0075	.6908
19			1.3957	.0131		.0132	1.5497
20		.0146	1.5123	.0168	.0131	.0151	1.5089
21		.0111	1.2696	.0113	.0131		1.2136
22		.0089	1.0456	.0113	.0112		1.0829
23		.0073	.9335	.032	.0377	.0372	.0381
24	.6859	.0055	.009	.8775	.032	.0393	.0389
Max	.6859	.0168	1.6804	1.419	.0449	.0573	1.7737
Min	.6859	.0055	.009	.0055	.0019	.0056	.0381
Avg	.6859	.0120	.3731	.2776	.0209	.0266	.6043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 203 / shivankhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.034	.0246	.0057	.0075	.0075
2	.0359	.0484		.0057	.0094	.0093
3	.038	.0632	.0262	.0057	.0093	.0113
4	.0389	.0534	.0279	.0075	.0112	.0112
5	.0496	.0624	.0295	.0094	.0131	.0132
6		.0617	.0315	.0149	.0131	.0149
7		.0348	.041	.0148	.0151	.0151
8		.0364	.0377	.0148	.0168	1.6579
9		.0344	1.4937	.0129	.0131	1.3256
10		.7282	1.1763	.0311	.0372	.0377
11		.6535		.0344	.036	.0442
12		.5415		.036	.0324	.0426
13		.4904		.036	.036	.0414
14		.5228		.036	.0377	.0381
15		.4481	.0037	.0372	.0389	.0398
16		.3921	.0037	.0389	.0377	.041
17		.3584	.0038	.0344	.0372	.0365
18		.7095	.0075	.0056	.0057	.6535
19		.9335	.0094	.0113	.0093	.9709
20	.0093	1.0642	.0113	.0094	.0094	1.0374
21	.0056	.8865	.0075	.0075	.0075	.9431
22	.0055	.8029	.0075	.0093	.0075	.8402
23	.0073	.0246	.0057	.0056	.0056	.6908
24	.0308	.0328	.0527	.0057	.0075	.0057
Max	.0496	1.0642	1.4937	.0389	.0389	1.6579
Min	.0055	.0246	.0037	.0056	.0056	.0057
Avg	.0254	.3757	.1580	.0179	.0189	.3554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 201 / hadolti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.6135	.5087	.5087	.6068	.6068	.6201
2	.5258	.6135	.5087	.5087	.6935	.6068	.6135
3	.5258	.6135	.5087	.5935	.7802	.6935	.6135
4	.5258	.6935	.5087	.5935	.7802	.7802	.7011
5	.6135	.7802	.763	.6783	.8669	.8669	.7802
6	.8573	.9431	.6783	.763	.9536	.8669	.8669
7	.8573	1.1145	.8478	.8478	1.0402	1.0402	1.1145
8	.6783	1.0288	.8478	.8478	1.2136	1.1269	1.3003
9		.9745	.5935	.6783	.5935	.6783	.8764
10	.6783	1.2136	.8669	.8669	.5087	.5201	.5258
11	1.2003	1.2136	1.0402	.8669	.4239	.5144	.5201
12	1.3717	1.1269	1.1096	1.0402	.4239	.5144	.5144
13	1.4575	1.1269	1.1269	1.1269		.5144	.5144
14	1.4575	1.1269	1.1269	1.1269		.6001	.5144
15	1.4575	1.1269	1.1269	1.1269		.5144	.6001
16	1.4575	1.0402	1.0402	1.0402		.5144	.6001
17	1.4575	1.0402	1.0402	1.0402		.5144	.5144
18	.6201	.5087	.4239	.4239		.6201	.6201
19	.8859	.5935	.6783	.6783	.6783	.7973	.7973
20	.8954	.8478	.763	.6783	.8478	.9745	.8859
21	.8059	.8478	.763	.763	.8478	.8859	.8954
22	.7164	.6783	.6783	.6783	.6783	.8059	.8059
23	.6201	.5087	.5935	.5201	.5201	.5373	.5373
24	.5258	.6201	.5087	.5087	.6068	.6068	.6201
Max	1.4575	1.2136	1.1269	1.1269	1.2136	1.1269	1.3003
Min	.5258	.5087	.4239	.4239	.4239	.5144	.5144
Avg	.9007	.8748	.7772	.7711	.7258	.6959	.7063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 202 / jagalpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3506	.3391	.3391	.4334	.4334	.5316
2	.3506	.3506	.3391	.3391	.4477	.4334	.5258
3	.3506	.3506	.3391	.3391	.4334	.4334	.5258
4	.3506	.4334	.3391	.3391	.5201	.5201	.5258
5	.4382	.6068	.3391	.4239	.6068	.6935	.5201
6	.4382	.6859	.4239	.5087	.6935	.7802	.6068
7	.5144	.7716	.5087	.5087	.6935	.7802	.6859
8	.5087	.7716	.5087	.5087	.6935	.8669	.6935
9	.4239	.7087	.4239	.4239	.5087	.4239	.5258
10	.3467	.8669	.6935	.6935	.4239	.4334	.4382
11	.6001	.8669	.7802	.7802			.4334
12	.6859	.7802	.7802	.7802	.3391		.4287
13	.6859	.7802	.7802	.7802			.4287
14	.6859	.7802	.7802	.7802		.3429	.5144
15	.6859	.7802	.7802	.7802		.3429	.5144
16	.6859	.6935	.6935	.6935		.3429	.4287
17	.6859	.6935	.6783	.6068		.3429	.4287
18	.443	.3391	.3391	.3391		.443	.3544
19	.6201	.4239	.4239	.4239	.4239	.5316	.5316
20	.7164	.4239	.4239	.4239	.5087	.6201	.5316
21	.6268	.4239	.4239	.4239	.5087	.6201	.6268
22	.5373	.3391	.3391	.3391	.4239	.5373	.5373
23	.443	.3391	.3391	.3467	.3467	.4477	.4477
24	.3506	.443	.3391	.3391	.4334	.4334	.5316
Max	.7164	.8669	.7802	.7802	.6935	.8669	.6935
Min	.3467	.3391	.3391	.3391	.3391	.3429	.3544
Avg	.5219	.5835	.5065	.5109	.4964	.5144	.5132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 203 / walsangi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.6201	.6068	.6068	.2543	.2543	.3544
2	.7011	.6201	.6068	.6068	.2543	.2543	.3544
3	.7011	.6135	.6068	.6935	.2543	.2543	.3544
4	.6859	.7011	.6068	.6935	.3391	.2543	.3506
5	.8573	1.1269	.8669	.7802	.3391	.3391	.4382
6	1.0174	1.286	1.0402	.8669	.3391	.4239	.5201
7	1.1869	1.5432	1.3003	1.1269	.3391	.5087	.6859
8	1.1869	1.6289	1.3003	1.2136	.4239	.4239	.5201
9	1.1869	.6201	.3391	.4239	.6068	.3391	.4382
10	.3467	.3391	.381	.3391	.6935	.6935	.8764
11	.3429	.3391	.2543	.3391	1.0402	1.1145	1.1269
12	.2572	.3391	.2543	.3391	1.2136	1.4575	1.2003
13	.2572	.3391	.2543	.3391		1.3717	1.2003
14	.1715	.3391	.2543	.4239		1.286	1.2003
15	.1715	.3391	.2543	.4239		1.286	1.286
16	.1715	.3391	.2543	.3391		1.3717	1.286
17	.1715	.2543	.2543	.2543		1.4575	1.286
18	.3544	.3391	.2543	.2543		.3544	.3544
19	.5316	.4239	.4239	.4239	.4239	.443	.443
20	.4477	.5087	.5087	.5087	.6783	.5316	.5316
21	.3582	.5087	.4239	.4239	.5087	.5316	.5373
22	.3582	.4239	.4239	.4239	.4239	.4477	.4477
23	.5316	.3391	.3467	.3391	.3391	.3582	.3582
24	.7011	.6201	.5935	.5201	.2543	.2543	.3544
Max	1.1869	1.6289	1.3003	1.2136	1.2136	1.4575	1.286
Min	.1715	.2543	.2543	.2543	.2543	.2543	.3506
Avg	.5582	.6063	.5171	.5293	.4848	.6671	.6877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 201 / jalkot

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.8488	.7468			.7468	.7468	.7545
8		.6535		.6535	.7468	.7468	.7545
12	.7468	.6535		.6535	.7468	.7468	.6535
16	.7468	.6535		.6535		.7468	.6535
20	.7468	.7468		.7468	.7468		.7468
24	.6097	.7468	.7468		.7468	.7468	.7545
Max	.8488	.7468	.7468	.7468	.7468	.7468	.7545
Min	.6097	.6535	.7468	.6535	.7468	.7468	.6535
Avg	.7398	.7002	.7468	.6768	.7468	.7468	.7196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 202 / kunki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1677	.2801			.5868	.503	.6706
8		.1867		.1867	.6706	.7545	.7545
12	.503	.6706		.503	.1867		.1867
16	.503			.503		.1867	.1867
20	.2801	.2801		.2801	.1867		.2801
24	.8573	.2801	.2801		.3734	.3353	.3353
Max	.8573	.6706	.2801	.503	.6706	.7545	.7545
Min	.1677	.1867	.2801	.1867	.1867	.1867	.1867
Avg	.4622	.3395	.2801	.3682	.4008	.4449	.4023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 203 / ravankola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.2936	1.0059			.3734	.3734	.3696
8		1.3413		1.6766	.2801	.2801	.3696
12		.2801		.2801	1.3413	1.4251	1.3413
13	.1867						
16	.1867	.2801		.2801			
20	.3734	.3734		.3734	.3734		1.1736
23							1.1736
24	.8573	.503	.5601		.3734	.3734	.2772
Max	1.2936	1.3413	.5601	1.6766	1.3413	1.4251	1.3413
Min	.1867	.2801	.5601	.2801	.2801	.2801	.2772
Avg	.5795	.6306	.5601	.6526	.5483	.613	.7842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 202 / sandol

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.9814					
7		.1524				
8			.1524	1.5699	.1524	.1524
15			.1524			1.7528
16					1.768	
23		.1524				
24	.7716	.1524				
Max	1.9814	.1524	.1524	1.5699	1.768	1.7528
Min	.7716	.1524	.1524	1.5699	.1524	.1524
Avg	1.3765	.1524	.1524	1.5699	.9602	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 203 / jaybhachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3429					
7		.3429				
8			.3429	2.6578	2.6578	2.5034
15			2.452	.3429		.3429
16					.3429	
23		.3429			2.6578	
24	.3429	.3429				
Max	.3429	.3429	2.452	2.6578	2.6578	2.5034
Min	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.3429	.3429	1.3975	1.5004	1.8862	1.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9496	.8478	.8817	.9835	.9835
2	.9496	.8478	.8817	.9835	.9496
3	.9496	.8478	.8817	.9496	.9496
4	.9496	1.0513	.9496	.9665	.9835
5	.9835	1.0513	1.0174	.9665	1.0343
6	1.0513	1.0852	1.0852	1.17	1.1191
7	1.17	1.153	1.17	1.2717	1.2887
8	1.1869	1.2717	1.2887	1.3565	1.3395
9	1.1869	1.3904	1.1869		
10	1.153	1.4413	1.0852		
11	1.1191	1.4922	1.0513		
12	1.0513	1.4582	1.0343		
13	.9835	1.4243	1.0174		
14	.9835	1.2039	.9835		
15	.9496	.9835	.9665		
16	.9496	.9835		.9156	
17		.9835		1.0174	
18		1.0513	1.0202	1.1191	
19		1.3056		1.3735	
20		1.3565	1.1174	1.3735	
21		1.2887	1.085	1.2887	
22		1.2039	1.1012	1.2378	
23		1.0682	1.0526		
24	.9835	.9156	.9496	1.0004	1.0174
Max	1.1869	1.4922	1.2887	1.3735	1.3395
Min	.9496	.8478	.8817	.9156	.9496
Avg	1.0324	1.1544	1.0384	1.1234	1.0739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2204	.1696	.2035	.2543	.2374
2	.2035	.1696	.2035	.2374	.2374
3	.2035	.1696	.1696	.2374	.2374
4	.2035	.2035	.1696	.2543	.2374
5	.2374	.2035	.2035	.2543	.2543
6	.2713	.2374	.2374	.3052	.2883
7	.2883	.3052	.2543	.3391	.3052
8	.3052	.3052	.3391	.373	.3561
9	.3391	.3391	.3391		
10	.3391	.3391	.3391		
11	.373	.3391	.373		
12	.39	.373	.39		
13	.407	.373	.407		
14	.407	.3052	.4239		
15	.39	.2543	.373		
16		.2543		.407	
17		.2713	.4287	.407	
18		.3052	.4801	.4578	
19		.373	.5316	.5256	
20		.373	.4801	.4748	
21		.3391	.4287	.4409	
22		.3052	.3437	.373	
23		.2713	.2743		
24	.2543	.2374	.2374	.2543	.2713
Max	.407	.373	.5316	.5256	.3561
Min	.2035	.1696	.1696	.2374	.2374
Avg	.3020	.2840	.3317	.3497	.2694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 203 / 11 KV TELEPHONE Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0678	.0678	.0678	.0678
2	.0678	.0678	.0678	.0678	.0678
3	.0678	.0678	.0678	.0678	.0678
4	.0678	.0678	.0678	.0678	.0678
5	.0678	.0678	.0678	.0678	.0678
6	.0678	.0678	.0678	.0678	.0678
7	.0678	.0678	.0678	.0678	.0678
8	.0678	.0678	.0678	.0678	.0678
9	.0678	.0678	.0678		
10	.0848	.0848	.1187		
11	.1187	.1017	.1357		
12	.1187	.0678	.1526		
13	.1357	.0678	.1526		
14	.1357	.0678	.1526		
15	.1526	.0678	.1357		
16		.0848		.1526	
17		.0678	.1448	.1357	
18		.0678	.1086	.0678	
19		.1187	.0724	.0678	
20		.1187	.0724	.0678	
21		.1187	.0724	.0678	
22		.1187	.0724	.0678	
23		.0678	.0724		
24	.0678	.0678	.0678	.0678	.0678
Max	.1526	.1187	.1526	.1526	.0678
Min	.0678	.0678	.0678	.0678	.0678
Avg	.0890	.0791	.0931	.0773	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6783	.6783	.6952	.6783
2	.6443	.6783	.6783	.6783	.6783
3	.6443	.6783	.6783	.6783	.6783
4	.6783	.7461	.7122	.6952	.7122
5	.763	.8139	.78	.6952	.78
6	.8987	.8478	.8478	1.0174	.9156
7	1.1022	.9156	1.0513	1.1022	1.1869
8	1.1191	.9665	1.0852	1.1869	1.1869
9	1.1191	1.0174	1.0513		
10	1.1191	1.0513	.9835		
11	1.1191	1.0852	1.0174		
12	1.0852	1.0174	1.0513		
13	1.0852	.9835	1.0513		
14	1.0852	.8817	.9835		
15	1.0852	.763	.9496		
16		.7291		.8987	
17		.7461	.9831	.9496	
18		.8139	1.1336	1.0852	
19		1.0343	1.3765	1.4074	
20		1.0174	1.2146	1.2887	
21		.8987	1.065	1.1022	
22		.8139	.8907	.9326	
23		.7461	.7373		
24	.6952	.7122	.7122	.6952	.7122
Max	1.1191	1.0852	1.3765	1.4074	1.1869
Min	.6443	.6783	.6783	.6783	.6783
Avg	.9326	.8598	.9440	.9443	.8365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516	.5487		.5487		.6219
2		.6001	.5121		.6859		.5544
3		.724	.5068		.6516		.5487
4		.6859	.5487		.6001		.5792
5		.7716	.6154		.6859		.7023
6		.8573	.8688				.7602
7		.9431	1.0136		.9431		.9774
8		1.086			1.0898		
9	1.2437		1.2346		1.086		
10	.9412		1.0288		.8779		1.1145
11	.8688		.8573		.8326		.6859
12	.8413		.6859		.7602		.8573
13	.7964		.6859		.7316		.6859
14	.7602		.6859		.6878		.7716
15	.7316				.6516		
16	.7602		.6859		.6878		.6859
17	.6859	.724		.6859		.724	
18	.6859	.8131		.7716		.7682	
19	.6859	.8326		.9335		.905	
20	.9431	.9145		.9431		.905	
21	.6859	.9145		.8573		.9145	
22		.7964		.7716		.8688	
23	.6859	.6653		.6859		.7682	
24		.7468	.5792		.6001		.6516
Max	1.2437	1.086	1.2346	.9431	1.0898	.9145	1.1145
Min	.6859	.6001	.5068	.6859	.5487	.724	.5487
Avg	.8083	.7954	.7372	.8070	.7575	.8362	.7283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535	.3734		.7468		.5658
2		.7095	.3772		.7095		.5658
3		.6722	.3772		.6535		.5658
4		.5975	.3772		.7468		.5658
5			.4527		.9335		.6036
6		.8029	.5658		.9774		.9054
7		.9335	.9808		1.3937		1.094
8		1.0456	1.0562		1.3443		1.0185
9	1.1506		.905		1.3957		
10	1.5466		1.1041		1.5089		
11	1.4335		1.286		1.2826		1.4118
12	1.5089		1.307		1.3203		1.3575
13	1.2826		1.3443		1.2826		
14	1.2449		1.267		1.2071		1.1576
15	1.2071		1.2136		1.2071		1.2136
16	1.2071		1.1763		1.1694		1.1831
17	.8589	.5658		1.4003		1.0562	
18	.8962	.5658				1.1317	
19	.8145	.5658		1.307		1.2826	
20	.8962	.5658		1.251		1.0185	
21	.7716	.5281		.9335		.9054	
22	.7468	.4904		.8402		.8299	
23	.6878	.4527		.7468		.7468	
24		.6722	.415		.7095		.679
Max	1.5466	1.0456	1.3443	1.4003	1.5089	1.2826	1.4118
Min	.6878	.4527	.3734	.7468	.6535	.7468	.5658
Avg	1.0836	.6548	.8576	1.0798	1.0935	.9959	.9205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 208 / VAISHALI AGRO EXPRESS

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2896	.0739		.0362		.3734
2		.2715	.0747		.0373		.3326
3		.2915	.0747		.0373		.3292
4		.2896	.0924		.0362		.3326
5		.2572	.0934		.0362		.3475
6		.3086	.0914		.0373		.2926
7		.12	.0934		.0373		.3292
8		.0543	.0934		.0373		.2957
9	.3292		.0905		.0366		
10	.3326		.0724		.0373		.3429
11	.3475		.0373		.0373		.3734
12	.2957		.0373		.0373		.2896
13	.2926				.0373		.3361
14	.2957		.0362		.0373		.3174
15	.2926				.037		.2572
16	.3326		.0373		.0377		.2896
17	.3258	.0934		.0747		.3326	
18	.2715	.1097		.0362		.3292	
19	.3258	.0732		.0362		.3326	
20	.3361	.0934		.0362		.3475	
21	.3361	.0934		.0362		.3326	
22	.3361	.0732		.0373		.3292	
23	.2915	.0747		.0373		.3326	
24		.2896	.0934		.0373		.3292
Max	.3475	.3086	.0934	.0747	.0377	.3475	.3734
Min	.2715	.0543	.0362	.0362	.0362	.3292	.2572
Avg	.3161	.1739	.0728	.0420	.0371	.3338	.3230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 201 / 11KV BODHAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.3155	.2743	.2915	.2915	.3086	.3086
2	.2804	.298	.2743	.2743	.2743	.3086	.3086
3	.3155		.2572	.2743	.2743	.2743	.2915
4	.3506	.298	.2743	.3086	.3086	.3086	.2743
5	.3506	.3155	.2915	.3429	.3429	.3429	.3086
6	.3506	.3155	.3772	.3772	.4115	.4287	.4115
7	.4382	.3856	.4801	.4458	.5144	.5144	.5144
8	.4908	.4207	.4359	.4733	.4801	.463	.4458
9	.463	.4191	.4191	.4207	.4557	.4207	.5258
10		.4191	.4024	.4207	.4207	.4207	.4908
11	.4458	.4024	.3688	.3856	.3856	.3856	.4207
12	.3772	.3688	.3688	.3856	.3856	.3856	.3856
13	.3429	.3688	.3353	.3506	.3856	.3155	.4207
14	.3429	.3353	.3018	.3856	.3856	.3506	.3856
15	.3772	.3353	.3018	.3856	.3856	.3155	.4207
16	.4115	.3601	.3353	.3856	.3506	.3506	.333
17	.3944	.3944		.4115	.4115	.3772	.3772
18	.3944	.3772		.4458	.4458	.4115	.4287
19	.3944	.3429		.4801	.4458	.4458	.4973
20	.3772	.4115		.4458	.4024	.4801	.4801
21	.3429	.3772			.4024	.4458	.4287
22	.333						.4115
23	.3155						.3944
24	.298	.3155	.3086	.3086	.3086	.3258	.3258
Max	.4908	.4207	.4801	.4801	.5144	.5144	.5258
Min	.2804	.298	.2572	.2743	.2743	.2743	.2743
Avg	.3681	.3608	.3416	.3809	.3850	.3809	.3996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.0503	.0335	.1006	.1006	.1174	.0838
2	.0838	.0503	.0335	.1174	.0838	.1006	.0671
3	.0838	.0671	.0335	.1006	.1006	.1006	.0671
4	.0838	.0671	.0335	.1006	.1006	.1174	.0838
5	.1006	.0671	.0503	.1174	.1174	.1341	.0838
6	.1174	.0671	.0503	.0838	.1174	.1341	.0671
7	.1174	.0671	.0671	.0503	.1006	.1341	.0671
8	.1341	.0838	.0819	.1174	.0838	.0838	.1174
9	.1174	.0655	.0983	.0838	.1174	.1174	.0838
10	.1006	.1006	.0983	.1006		.0838	.0838
11	.0838	.1509	.0983	.1006	.0838	.1006	.0671
12	.1006	.1475	.0983	.1006	.0838	.0838	.1006
13	.1006	.1475	.1147	.1006	.1174	.1174	.1006
14	.1006	.1475	.1311	.1174	.1174	.1174	.1341
15		.1311	.1311	.1174	.1174	.1174	.1006
16	.1006	.1341	.1311	.1341	.1174	.1174	.1174
17	.1006	.1509	.1174	.1341	.1006	.0838	.0838
18	.1006	.1509		.1174	.1174	.1006	.0671
19	.1006	.1341		.1341	.1341	.1006	.1341
20	.0838	.1006		.1174	.1341	.0838	.1174
21	.0838	.0838			.1341	.0671	.1006
22	.0838						.0983
23	.0838						.0983
24	.1006	.0671	.0503	.1006	.1006	.1174	.1174
Max	.1341	.1509	.1311	.1341	.1341	.1341	.1341
Min	.0838	.0503	.0335	.0503	.0838	.0671	.0671
Avg	.0984	.1015	.0807	.1070	.1086	.1059	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3696	.3142	.3696	.3696	.4066	.3696
2	.3326	.3511	.2957	.3696	.3696	.3881	.3696
3	.3142	.3511	.2957	.3696	.3696	.3696	.3511
4	.3511	.3696	.3326	.4066	.4066	.4066	.3696
5	.4435	.3511	.3511	.4066	.4435	.4435	.4066
6	.5175	.3696	.4435	.4435	.462	.462	.4435
7	.6283	.4805	.5175	.5729	.5914	.6283	.5729
8	.6838	.5914	.5365	.5729	.5544	.6653	.7023
9	.5914	.5533	.5365	.6283	.6283	.8316	.8316
10	.5544	.5365	.5365	.7762	.6468	.6838	.7207
11	.499	.503	.6036	.7207	.6468	.7392	.7023
12	.3696	.4694	.6371	.7577	.6653	.7023	.7762
13	.7286	.4359	.6371	.7023	.5729	.6468	.6653
14	.5544	.3856	.5868	.7023	.5359	.6283	.6653
15	.5729	.3688	.6706	.7207	.7023	.7947	.6283
16	.5544	.4435	.6706	.5914	.6838	.7392	
17	.5175	.462	.7207	.6283	.6653	.0914	.7023
18	.5175	.4805		.6653	.7392	.0914	.5914
19	.5544	.4435		.6838	.7762	.6653	.6653
20	.5175	.462		.7577	.7392	.6283	.6468
21	.499	.4805			.7023	.5914	.6468
22	.462						.5487
23	.4251						.4458
24	.3511	.3881	.3326	.4066	.4066	.4251	.4251
Max	.7286	.5914	.7207	.7762	.7762	.8316	.8316
Min	.3142	.3511	.2957	.3696	.3696	.0914	.3511
Avg	.4947	.4385	.5011	.5835	.5763	.5468	.5760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.439	.439	.5121	.5121	.5121	.5487
2	.4572	.439	.439	.4755	.4755	.4755	.5121
3	.439	.4024	.4207	.4755	.4755	.4755	.4755
4	.439	.4024	.439	.4938	.4755	.4938	.4755
5	.4755	.439	.4572	.5121	.5121	.5121	.5121
6	.5304	.4572	.5304	.5304	.5487	.5487	.5487
7	.6401	.4755	.5853	.5853	.6401	.6767	.5853
8	.6401	.5853	.5533	.695	.6036	.5853	.5853
9	.6219	.503	.5533	.6584	.5853	.5853	.6401
10	.6767	.503	.57	.6401	.6219	.6767	.695
11	.6584	.4862	.6371	.6767	.6036	.695	.6767
12	.6767	.4694	.6706	.695	.6219	.7316	.7133
13	.7133	.4359	.6706	.6767	.6767	.7499	.823
14	.695	.4359	.6539	.6584	.6036	.7316	.7865
15	.7133	.4191	.6539	.6584	.6219	.823	.7682
16	.6767	.4755	.6874	.6584	.695	.7499	.7499
17	.6767	.5487	.7133	.7316	.6219	.6767	.8048
18	.7133	.5121		.8413	.7316	.7207	.8779
19	.8048	.5487		.9145	.8413	.7499	1.0425
20	.7133	.5853		.8962	.7865	.8048	.9145
21	.6584	.6219			.7316	.8413	.8413
22	.5853						.7042
23	.5304						.57
24	.4938	.4755	.4755	.5304	.5304	.5487	.567
Max	.8048	.6219	.7133	.9145	.8413	.8413	1.0425
Min	.439	.4024	.4207	.4755	.4755	.4755	.4755
Avg	.6127	.4845	.5639	.6436	.6144	.6529	.6841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI
HEALTHCAR Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0709		.0886	.124	.1063	.124
2	.0709	.0709		.0886	.1063	.0886	.1063
3	.0709	.0709	.1063	.0886	.1063	.0886	.1063
4	.0886	.0709	.1063	.0886	.0886	.1063	.1063
5	.0886	.0886	.0886	.1063	.1063	.1063	.1063
6	.0709	.0709	.0886	.1063	.1063	.1063	.0886
7	.0886	.0709	.1063	.0886	.0886	.0886	.0886
8	.0886	.0886	.1006	.0886	.1417	.0886	.1063
9	.1052	.0838	.1006	.0709	.0709	.0709	.0709
10	.1052	.0671	.0838	.0886	.0709	.0886	.0886
11	.0876	.0671	.0671	.0886	.0886	.0886	.0886
12	.0876	.0671	.0671	.1063	.0886	.0709	.0886
13	.1052	.0671	.0671	.0886	.1063	.1063	.1063
14	.1052	.0671	.0671	.1063	.124	.0886	.124
15	.1063	.0671	.0671	.1063	.124	.1063	.124
16	.124	.0876	.1006	.1063	.1417	.1063	.124
17	.124	.1052	.1052	.1052	.1402	.1227	.1417
18	.1063	.1052		.1227	.1227	.1052	.1595
19	.1063	.1052		.1052	.1052	.1052	.1595
20	.124	.0876		.1052	.0876	.0876	.1595
21	.124	.0876			.0905	.0876	.1595
22	.1063						.1509
23	.0886						.1509
24	.0709	.0709	.0886	.0886	.1417	.1063	.124
Max	.124	.1052	.1063	.1227	.1417	.1227	.1595
Min	.0709	.0671	.0671	.0709	.0709	.0709	.0709
Avg	.0964	.0790	.0882	.0968	.1078	.0964	.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 404 / 33KV O/G Nalgir

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.861	2.0576	2.0576	1.6461	2.0576	1.9547
2	1.3077	1.9113	1.9547	2.1605	1.749	2.1605	2.1605
3	1.3077	1.9113	2.1605	2.3663	1.8004	2.1605	2.0576
4	1.8107	2.1125	2.2634	2.4691	1.749	2.1091	2.2634
5	2.3137	2.3137	2.3663	2.6749	1.9547	2.2634	2.4691
6	2.9172	2.7161	2.6749	3.035	2.0576	2.3663	2.9321
7	3.8226	3.3196	3.7551	3.858	2.572	3.0864	3.0864
8	3.8226	3.5711	3.3196	3.722	2.7263	3.7551	3.0864
9	3.0178	1.2574	3.3196	.9556	.9556	1.0562	1.0059
10	2.5149	3.1184	2.8166	2.7664	1.6095	2.3137	1.9616
11		3.2693	2.7161	2.8166	2.6155	2.3137	2.6155
12	2.2634	3.1184	2.7664	2.364	2.8166	2.5149	2.6658
13	2.3137	3.0178	2.7664	2.3137	2.8669	2.7161	2.7161
14	2.2131	2.9172	2.6658	2.5652	2.8669	2.7161	2.6155
15	2.1605	3.0681	2.6155	2.5149	2.9675	2.6155	2.5652
16	2.0576	2.5652	2.6658	2.5149	2.9675	2.6155	2.6155
17	1.5947	1.9113	2.6749	1.9113	2.6658	2.4691	2.7778
18	1.1831	.6036			2.364	2.6749	.4115
19	1.2346	.8048		1.0059	1.5089	2.5149	.6173
20	1.3375	1.0059		1.1065	1.1317	1.5089	.9259
21	1.2346	1.0562			1.0059	1.2071	.823
22	1.4083						.7716
23	1.861						2.0062
24	1.0562	1.8107	1.8519	2.1091	1.6975	1.6975	1.749
Max	3.8226	3.5711	3.7551	3.858	2.9675	3.7551	3.0864
Min	1.0562	.6036	1.8519	.9556	.9556	1.0562	.4115
Avg	2.0048	2.2382	2.6340	2.3644	2.1043	2.3133	2.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7778	3.3951	3.6283	3.786	4.2593	4.8903	4.5222
2	2.8807	3.4979	3.4705	3.8386	4.3644	4.9429	4.7325
3	2.8807	3.4979	3.6808	3.9963	4.4696	4.9429	4.6273
4	3.3951	3.7037	3.786	4.2067	4.4696	5.048	4.8903
5	3.9095	3.9095	4.0489	4.6273	4.8903	5.3109	5.3109
6	4.8354	4.4239	4.6799	4.8354	5.5213	5.7842	5.8894
7	6.07	5.144	5.7842	5.8894	6.3626	7.1514	6.5204
8	6.07	5.607	5.1303	5.8128		7.0462	6.941
9	5.7613	3.0681	5.3315	3.3951	3.3951	3.7551	3.0864
10	5.6584	5.6333	5.4321	5.7613	3.5494	3.2922	4.2181
11	5.5041	5.8345	6.086	6.3786	4.784	4.1667	4.7325
12	5.5556	6.4381	5.9351	6.07	4.7325	4.5782	4.8868
13	5.6584	6.1866	6.0357	5.9671	4.7325	4.5268	4.8354
14	5.607	5.6333	5.08	6.0185	4.6811	4.2696	4.7325
15	5.2584	5.7339	5.9351	6.07	4.7325	4.4239	4.5268
16	5.3635	3.9095	5.8345	5.9671	5.0926	4.5268	4.784
17	5.2058	3.5494	5.4527	5.4527	4.9383	4.321	5.1532
18	3.2602	2.5206		4.1152	4.6296	3.0864	2.8395
19	3.9438	2.8807		3.8066	3.7551	3.2922	3.2076
20	3.786	3.0864		4.0124	3.6008	3.3951	3.9438
21	3.5231	3.1893			3.7037	3.4979	3.6808
22	3.2407						3.0864
23	3.4979						4.3724
24	2.6749	3.3951	3.3653	3.8912	4.5222	4.5748	4.417
Max	6.07	6.4381	6.086	6.3786	6.3626	7.1514	6.941
Min	2.6749	2.5206	3.3653	3.3951	3.3951	3.0864	2.8395
Avg	4.4299	4.2835	4.9276	4.9475	4.5327	4.5829	4.5807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.6935	.6859	.2572	.3429	.2601
2	.5144	.6859	.6935	.6859	.2572	.3429	.2601
3	.6001	.6859	.7802	.7716	.2572	.3429	.3467
4	.6859	.7716	.7802	.8573	.3429	.3429	.3467
5	.7716	.8573	.8669	.9431	.4287	.4287	.4334
6	.8573	1.0288	1.0402	1.0288	.5144	.5144	.5201
7	.5144	.9431	.8669	1.2003	.5144	.4287	.5201
8	1.2003	1.286	1.3003	1.2003	.4287	.4334	.4334
9	.4287	.4287	.3467	.5144	.4287	.5201	.5201
10	.2572	.4334	.3429	.3429	.6859	.6935	1.5432
11	.2572	.3467		.2572	1.1145	1.2136	1.0288
12	.2572	.2601	.1715	.2572	1.2003	1.2136	
13	.2572	.2601	.1715	.2572	1.2003	1.2136	
14	.2572	.2601	.1715	.2572	.9431	1.2136	.8573
15	.2572	.2601	.1715	.2572	1.286	1.3003	1.2003
16	.2601	.2601	.1715	.2572	1.2003	1.2136	1.2003
17	.2572	.2601	.1715	.1715	1.1145	1.2136	1.2003
18	.3429	.3467	.3429	.1715	.2572	.2601	.2572
19	.4287	.4334	.4287	.4287	.4287	.3467	.3429
20	.4287	.4334	.4287	.5144	.4287	.4334	.2572
21	.4287	.4334	.4287	.4287	.4287	.3467	.4287
22	.3429	.3467	.4287	.3429	.3429	.3467	.3429
23	.4287	.3467	.4287	.2572	.3429	.3467	.3429
24	.1715	.6001	.6068	.6001	.2572	.3429	.2601
Max	1.2003	1.286	1.3003	1.2003	1.286	1.3003	1.5432
Min	.1715	.2601	.1715	.1715	.2572	.2601	.2572
Avg	.4467	.5273	.5145	.5287	.6109	.6415	.5865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.8669	.8764	.8764	.2601	.3467	.2629
2		.8669	.8764	.964	.2601	.3467	.2629
3		.8669	.964	.964	.3467	.3467	.3506
4	.8573	.9536	1.0517	1.1393	.4334	.4334	.4382
5	.8573	1.1269	1.2269	1.4022	.4334	.4334	.4334
6	.7716	1.387	1.4022	1.4022	.5201	.5201	.5258
7	.6859	.7802	.7888	1.1393	.6068	.6068	.5258
8	1.0402	.9536	1.0517	1.2269	.5201	.5258	.5258
9	.5201	.5201	.4382	.5258	.5201	.5258	.5201
10	.3467	.4382	.2629	.2601	.8669	.7011	.6935
11	.2601	.3506		.2601	1.1269	.7888	.7802
12	.2601	.2629	.3506	.2601	.8669	.8764	
13	.2601	.2629	.2629	.2601	.9536	.964	.4334
14	.2601	.2629	.1753	.2601	.8669	.8764	.7802
15	.2601	.2629	.1753	.2601	.9536	.964	1.0402
16	.2601	.2629	.2629	.2601		1.0517	1.0402
17	.3467	.2629	.1753	.2601	1.0402	1.0517	1.0402
18	.3467	.3506	.2601	.2601	.2601	.2629	.2601
19	.4334	.3506	.4334	.4334	.4334	.3506	.3467
20	.4334	.4382	.443	.4334	.4334	.4382	.4334
21	.3467	.4382	.4382	.4334	.4334	.4382	.4334
22	.3467	.3506	.3429	.3467	.3467	.3506	.3467
23	.6935	.3506	.6935	.2601	.3467	.3506	.3467
24	.2601	.7802	.7888	.7802	.2601	.3467	.2629
Max	1.0402	1.387	1.4022	1.4022	1.1269	1.0517	1.0402
Min	.2601	.2629	.1753	.2601	.2601	.2629	.2601
Avg	.4791	.5728	.5975	.6112	.5691	.5791	.5254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 203 / 11 KV DIGRESS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9745	.8859	.8669
2					1.0631	.8859	.8669
3					1.1517	1.0631	.9536
4					1.2403	1.0631	1.0402
5					.8402	1.1517	1.2136
6					1.3289	1.4175	1.4737
7					1.5947	1.7718	1.647
8					1.6832	1.8861	1.7147
10	.8859	.8573	.8669	.443			
11	1.4175	1.0288		1.2403			
12	1.5947	1.2136	1.5947	1.2403			
13	1.4175	1.2003	1.5947	1.3289			
14	1.5947		1.5061	1.3289			
15	1.5947	1.0288	.9745	1.3289			
16	1.5947	1.6289	1.4175	1.4175			
17		1.7337	.7087	1.4175			
23					.7087	.6935	.5316
24		.1417			.5316	.8859	.8573
Max	1.5947	1.7337	1.5947	1.4175	1.6832	1.8861	1.7147
Min	.8859	.1417	.7087	.443	.5316	.6935	.5316
Avg	1.4428	1.1041	1.2376	1.2182	1.1117	1.1705	1.1166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 201 / 11 KV DEVARJAN (AG)

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	06-MAR-18
HR	Load (MW)
8	1.8004
24	1.1145
Max	1.8004
Min	1.1145
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 204 / 11 KV SHEKAPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	06-MAR-18
HR	Load (MW)
8	.4801
9	.4458
10	.3429
24	.1543
Max	.4801
Min	.1543
Avg	.3558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 205 / 11 KV DEVARJAN GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	06-MAR-18
HR	Load (MW)
8	.4287
9	.3429
24	.1372
Max	.4287
Min	.1372
Avg	.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 201 / 11 KV LOHARA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3361	.2743	.3361	.5487	.5415	.5487
2	.3734	.3174	.2401	.3174	.5792	.5975	.5792
3	.3547	.2987	.2572	.3174	.6097	.6535	.6097
4	.3547	.2801	.2743	.3547	.6706	.7468	.6706
5	.4108	.2987	.3086	.4108	.7011	.9335	.7011
6	.4294	.3174	.3429	.4668	.7316	1.0269	.7316
7	.4668	.3361	.3772	.4854	.7926	1.2136	.7926
8	.5041	.3734	.3429	.4294	1.1584	1.307	1.1584
9	.4854	.4108	.3772	.4481	.3353	.1981	.3353
10	.5228	.463	.4854	.5228	.2427	.2134	.3174
11	.5975	1.2346	.7095	1.0974	.2614	.2134	.3361
12	.7468	1.5432	.8589	1.3717	.2801	.2134	.4108
13	.8402	1.7147	1.0269	1.5242	.2987	.2134	.3734
14	.9335	1.7147	1.4563	1.5242	.3174	.2439	.3921
15	1.0269	1.7833	1.7364	1.5546	.3174	.2439	.4294
16	1.1203	1.7833	2.0351	1.5851	.3361	.2439	.4108
17	1.307		2.2218	1.5242	.3547	.2743	.4481
18	.2427		.2241	.2134	.3734	.2439	.4294
19	.2801	.2743	.2614	.2439	.4108	.2439	.4294
20		.3429	.2801	.3048	.4294	.3048	.4481
21		.4115	.2987	.3658	.4481	.3658	.3734
22		.3772	.3547	.3353	.4668	.3353	.3734
23		.3429	.3734	.4572		.4572	.4668
24	.4108	.3547	.2743	.3547	.4877	.5041	.4877
Max	1.307	1.7833	2.2218	1.5851	1.1584	1.307	1.1584
Min	.2427	.2743	.2241	.2134	.2427	.1981	.3174
Avg	.5891	.6959	.6413	.6894	.4849	.4805	.5106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 202 / 11 KV BHAKASKHEDA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5415	.583	.5415	.2134	.3547	.2134
2	.5601	.5601	.583	.6535	.2134	.3361	.2134
3	.6722		.6173	.7095	.2286	.3174	.2286
4	.7468	.6908	.6859	.8775	.2439	.2987	.2439
5	.8215	.7468	.7202	.9335	.2743	.2987	.2743
6	.9149	.9335	.7545	1.0082	.3048		.3048
7	1.0456	1.1203	.823	1.1016	.3658	.2915	.3658
8	1.2883	1.2136	.8573	1.2323	.3658	.3547	.3658
9	.2801	.2427	.2743	1.4003	.2439	.3048	.2439
10	.2801	.2401	.3361	.2987	.4481	.381	.4854
11	.2801	.2572	.3174	.2286		.4877	.5415
12	.2987	.2572	.3547	.2286	.5601	.7011	.6908
13	.3174	.2743	.3921	.2439	.6535	.7926	.8215
14	.3174	.2743	.3734	.2439	.7468	.884	.8962
15	.3361	.2743	.4108	.2439	.9335	.9145	1.0456
16	.3361	.2743	.4294	.2439	1.1203	.9755	1.1203
17	.3547	.2915	.4481	.2591	1.2136	1.0669	1.2323
18	.3734		.3921	.2743	.2614	.2743	.2614
19	.4108	.3429	.4108	.3048	.2987	.3048	.2987
20		.3429	.4294	.3048	.3174	.3048	.3361
21		.3772	.4108	.3353	.3361	.3353	.3547
22		.3429	.3734	.3048	.3547	.3048	.4108
23		.5487	.3361	.3048		.3048	.3361
24	.4668	.5041	.5144	.4668	.2439	.3547	.2439
Max	1.2883	1.2136	.8573	1.4003	1.2136	1.0669	1.2323
Min	.2801	.2401	.2743	.2286	.2134	.2743	.2134
Avg	.5331	.4841	.4928	.5310	.4519	.4758	.4804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 203 / 11 KV KUMTHA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.5601	.6516	.4854	.2439	.3361	.2439
2	.6535	.5975	.6859	.5415	.2439	.3174	.2439
3	.7842	.6535	.7545	.6535	.2439	.2987	.2439
4	.8962	.7468	.7888	.8029	.2743	.2801	.2743
5	1.0269	.9335	.823	.9335	.3048	.2987	.3048
6	1.1203	1.0269	.8573	1.0829	.3353	.3174	.3353
7	1.2323	1.2136	.9602	1.251	.3963	.3361	.3963
8	1.4377	1.307	1.0288	1.419	.3963	.3734	.3963
9	.2801	.2614	.3086	1.6244	.2743	.3353	.2743
10	.2801	.2572	.3547	.2614	.4668	.3963	.3921
11	.2987	.2743	.4108	.2439		.6097	.5228
12	.3174	.2743	.3547	.2439	.6348	.7926	.6908
13	.3361	.2915	.4294	.2591	.7095	.8535	.8402
14	.3361	.3086	.4481	.2743	.9335	.945	.9709
15	.3547	.3429	.3734	.3048	1.0269	.9755	1.0642
16	.3547	.3429	.3361	.3048	1.2136	1.0364	1.1763
17	.3734	.3429	.3547	.3048	1.307	1.1584	1.2696
18	.4108		.3174	.3048	.2801	.3048	.2427
19	.4294	.3772	.3361	.3353	.3174	.3353	.2614
20		.4115	.3547	.3658	.3361	.3658	.3174
21		.3772	.3734	.3353	.3547	.3353	.3361
22		.3429	.3547	.3048	.3547	.3048	.3547
23		.5487	.3361	.3658		.3658	.3547
24	.3921	.5228	.6173	.4108	.3048	.3547	.3048
Max	1.4377	1.307	1.0288	1.6244	1.307	1.1584	1.2696
Min	.2801	.2572	.3086	.2439	.2439	.2801	.2427
Avg	.5928	.5354	.5254	.5589	.4979	.5011	.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 204 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1715	.1867	.1524	.3174	.1524
2	.168	.168	.1715	.1867	.1524	.1867	.1524
3	.1494	.1494	.1372	.1867	.1219		.1219
4	.168	.1494	.1372	.1867	.1219	.1494	.1219
5	.168	.1494	.1372	.168	.1219	.1494	.1219
6	.168	.1494	.1372	.2241	.1219	.1494	.1219
7	.1867	.1494	.1715	.2054	.1524	.1494	.1524
8	.2054	.168	.2058	.2427	.1829	.1372	.1829
9	.2241	.1867	.2401	.2241	.2591	.1372	.2591
10	.2427	.1886	.2241	.2614	.3174	.1524	.2614
11	.2427	.2743	.2427	.3353	.3174	.3201	.2614
12	.2614	.3086	.2241	.3201	.3361	.3201	.2427
13		.3086	.2241	.3506	.3547	.3353	.2614
14	.2987	.3086	.2054	.3506	.3547	.3353	.2241
15	.3174	.3086	.1867	.3506	.2987	.3353	.1867
16	.3361	.3086	.1867	.3506	.2987	.3353	.2054
17	.3361	.3086	.1867	.3048	.2801	.3201	.2054
18	.3547		.2614	.2743	.2987	.2896	.2054
19	.3547	.2743	.2241	.2439	.2987	.2591	.2614
20		.2401	.2427	.2134	.3174	.2439	.2801
21		.2401	.2241	.2134	.3361	.2439	.2987
22		.2058	.2614	.1829	.3361	.1829	.2987
23		.1715	.2427	.1524		.1524	.2427
24	.2241	.3734	.1715	.2241	.1524	.3547	.1524
Max	.3547	.3734	.2614	.3506	.3547	.3547	.2987
Min	.1494	.1494	.1372	.1524	.1219	.1372	.1219
Avg	.2417	.2294	.2007	.2475	.2471	.2416	.2073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.6722	.6535	.4115	1.1203	1.3413	1.0288
2	.4801	.6722	.6535	.4801	1.1203	1.3413	1.2209
3	.4748	.6722	.7468	.4801	1.1576	1.3413	1.326
4	.5426	.7316	.8402	.6104	1.2437	1.3748	1.4586
5	.7293	.8048	1.0269	.663	1.2696	1.4754	1.6575
6	.9945	1.0288	1.1203	.8619	1.1584	1.9433	1.6194
7	1.1271	1.153	1.2136	.9945	2.0576	2.2939	2.0081
8	1.2452	1.1401	1.3443	.9945	2.332	2.3266	2.3967
9	.2103	.4527	.6173	.5258	.5243	.3772	
10	.6859	1.8313	1.5775	.6859	.6859	.6706	
11	1.6385	2.0317	1.7804	1.9662	.9831	.5487	
12	1.7394	2.0317	1.8564	1.9433	.852	.4409	.3429
13	1.749	2.3339	1.989	1.9448	.6554	.3978	.4641
14	1.704	2.2779	2.0553	1.9448	.5898	.3978	.4641
15	.0943	2.2032	2.0081	1.9113	.57	.4641	.5304
16	1.9662	2.1658	1.9433	1.0288	.5243	.4641	.5182
17	1.9433	2.4272	1.8785	1.7147	.5365	.4748	.4641
18	.2263	.2801	.1867	.1886	.2263	.2218	.2172
19	.415	.4668	.2987	.415	.3772	.3734	.3734
20	.4904	.5228	.3734	.4527	.415	.4854	.4854
21	.415	.4668	.4481	.4527	.415	.4481	.4481
22	.3395	.4108	.3361	.415	.3018	.3734	.3734
23	.5281	.5975	.3506	.3772	1.2018	.6859	.8413
24	.4115	.5975	.5975	.4115	.9431	1.3375	.8916
Max	1.9662	2.4272	2.0553	1.9662	2.332	2.3266	2.3967
Min	.0943	.2801	.1867	.1886	.2263	.2218	.2172
Avg	.8567	1.1655	1.079	.9114	.8859	.9000	.9110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.7095	.5087	.5144	.2263	.1132	.2241
2	.407	.695	.5935	.5487	.2263	.1132	.2241
3	.407	.695	.6783	.6173	.1886	.1132	.2987
4	.4641	.6859	.8139	.6783	.1886	.1509	.2957
5	.4973	.6859	.8478	.7956	.2263	.1886	.3696
6	.5967	.6859	.8478	.9945	.4527	.2641	.5792
7	.663	1.0486	1.1022	1.166	.5658	.3772	.5792
8	.9393	1.0159		1.2308	.3206	.1886	.5068
9	.2172		.2572	.3506	.3018	.1886	.3982
10	.1448		.181	.181	.1867	.6516	.3429
11	.1311		.1267	.1509	.9503	.9945	.9282
12	.1341	.1886	.1086	.1509	.9503	1.0277	
13	.0509	.1357	.1086	.0943	.852	1.0364	
14	.1052	.1187	.0724	.0943	.8421	.9069	.9717
15	.1372	.1017	.0724	.0943	.8097	.8288	.9069
16	.1402	.1187	.0724	.0943		.6104	.9069
17	.1829	.1357	.1109	.0943		.3391	.8745
18	.1886	.1526	.112	.1509	.0566	.1478	.1848
19	.3395	.2543	.2614	.415	.3395	.2987	.3361
20	.3772	.2543	.3734	.415	.3772	.4108	.4108
21	.3395	.2543	.3734	.3772	.3772	.3734	.3734
22	.2641	.2543	.2987	.3772	.1886	.2987	.2987
23	.5658	.4748	.3506	.3018	.132	.2241	.2987
24	.3429	.5658	.4748	.4458	.2641	.1132	.2241
Max	.9393	1.0486	1.1022	1.2308	.9503	1.0364	.9717
Min	.0509	.1017	.0724	.0943	.0566	.1132	.1848
Avg	.3324	.4396	.3803	.4306	.4102	.4150	.4788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 201 / 11 KV GUTTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3048	.2667	.2477	.4954	.2572	.2572
2	.2858	.3048	.2667	.2477	.5335	.3086	.3086
3	.381	.3239	.2858	.2858	.6097	.3052	.3258
4	.5716	.3429		.3429	.6478	.3018	.3658
5	.6478	.3429	.3429	.4001	.6859	.3353	.439
6	.6478	.4191	.4763	.4572	.8192	.4191	.6219
7	.8192	.6859	.8002	.8192	.9335	.6706	.7316
8	.8002	.7621	.8002	.7811	.9145	.6962	.7682
9	.724	.6767	.7621	.6859	.8002	.724	.6767
10	.567	.6584	.6859	.6859		.5716	
11	.5375	.6584		.6516	.4954	.4191	.4191
12	.5365	.5304	.724	.6767	.3429	.2858	.4191
13	.5182		.7049	.7133	.2667	.1905	.2667
14	.4973	.5853	.7621	.695	.2477	.1905	.2286
15	.5668	.6584	.8192	.7499	.2477	.1905	.1905
16	.4801	.7316	.7811	.7316	.2286		.2286
17	.5182	.6173	.743	.7682	.2286	.2286	.2286
18	.4001	.3429	.3239	.3429	.2667	.2667	.2667
19	.4763	.6668	.6097	.5525	.4954	.5906	.5906
20	.5144	.6287	.5144	.6859	.5335	.6097	.6668
21	.4572	.5525	.4382	.5525	.4763	.4954	.4954
22	.381	.381	.362	.4382	.4382	.4572	.4572
23	.3429	.3429	.3239	.3429	.1772	.1905	.2096
24	.3048	.3048	.3048	.2667	.4001	.2601	.2572
Max	.8192	.7621	.8192	.8192	.9335	.724	.7682
Min	.2858	.3048	.2667	.2477	.1772	.1905	.1905
Avg	.5109	.5140	.5499	.5467	.4906	.3898	.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 202 / 11 kv CHINCHOLI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2012	.2058	.3048	.3429	.4191	.4191
2	.3506	.2267	.2229	.3429	.3048	.381	.4191
3	.3506	.2267	.2572	.4001	.3048	.4191	.4001
4	.3814	.2591	.2743	.4382	.4382	.4572	.4572
5	.4115	.2915	.3258	.4954	.5335	.5716	.5716
6	.4458	.2949	.3601	.5144	.6859	.724	.6859
7	.503	.3932	.5853	.5906	.7621	.8002	.8002
8	.6036	.5801	.7316	.6287	.7811	.7621	.7621
9	.431	.724	.7621	.4954	.743	.6478	.6687
10	.5335	.6287	.5716	.362			.3429
11	.4954	.5906	.4763	.3429	.3353	.4191	.3772
12	.381	.4954	.4382	.381	.431	.4287	.4024
13	.4763	.4191	.4382	.362	.4191	.4115	.4024
14	.381	.381	.4001	.3429	.3018	.4115	.3658
15	.4572	.381	.362	.3239	.3315	.4115	.3658
16	.4191	.381	.3429	.3239	.4096	.3944	.3658
17	.362	.3429	.362	.3048	.4694	.3429	.3841
18	.4382	.4763	.4382	.4954	.4763	.4763	.4763
19	.6859	.7811	.7811	.743	.6859	.724	.724
20	.724	.6668	.6859	.6859	.6478	.7049	.7049
21	.6097	.5716	.6097	.6668	.6097	.6097	.6097
22	.5335	.5335	.5335		.5716	.6287	.6287
23	.2035	.2572	.2477	.4382	.5335	.5335	.5525
24	.3258	.2012	.2058	.2667	.3239	.4191	.4191
Max	.724	.7811	.7811	.743	.7811	.8002	.8002
Min	.2035	.2012	.2058	.2667	.3018	.3429	.3429
Avg	.4519	.4294	.4424	.4456	.4975	.5260	.5127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-18 and 07-MAR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 203 / 11 KV SULLALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-18	02-MAR-18	03-MAR-18	04-MAR-18	05-MAR-18	06-MAR-18	07-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2591	.2926	.3429	.2096	.1715	.1715
2	.2035	.2591	.2926	.4001	.1905	.1715	.1715
3	.2347	.2591	.3109	.4954	.2286	.2286	.2286
4	.2486	.2915	.3292	.5335	.2477	.2286	.2286
5	.3315	.2881	.3658	.4382	.3048	.2286	.2286
6	.426	.4001	.4024	.5716	.3429	.2667	.2667
7	.5243	.3521	.5121	.6478	.4001	.4191	.4191
8	.4588	.421	.6401	.6859	.4191	.381	.362
9	.4534	.2477	.381	.2477		.3429	
10	.1524	.1905	.2858	.1905		.4458	.4024
11	.1334	.1524	.2286	.1905	.421	.4458	.4755
12	.0762	.1334	.2096		.4744	.5487	.439
13	.1143	.1715	.1715	.1524	.5468	.5304	.6036
14	.0953	.1334	.1334	.1715	.5401	.5304	.6401
15	.1143	.1143	.1334	.1905	.5851	.5304	.6401
16	.1143	.1143	.1143	.2286	.5535	.5487	.5853
17	.1334	.1334	.1143	.1905	.5851	.5853	.6036
18	.2286	.2667	.2477		.2096	.1905	.1905
19	.2286	.3429	.3239	.3048	.362	.2096	.2477
20	.3048	.3048	.3239	.3429	.381	.381	.3048
21	.2858	.2667	.3048	.3239	.3048	.3048	.2858
22	.2667	.2667	.3048	.3048	.2667	.2667	.2667
23	.2622	.2572	.2667	.2286	.2286	.2286	.2286
24	.1715	.2591	.2926	.3239	.2096	.1905	.1905
Max	.5243	.421	.6401	.6859	.5851	.5853	.6401
Min	.0762	.1143	.1143	.1524	.1905	.1715	.1715
Avg	.2404	.2452	.2909	.3412	.3642	.3490	.3557