

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.8764	.8002	.5335	.9145	.724
2		.5335	.8573	.7621	.5716	.8764	.7621
3	.5144	.6097	.8383	.6859	.6478	.8383	.8002
4	.5335	.5716	.8383	.6859	.6859	.8002	.9145
5	.4954	.5335	.7621	.6478	.7621	.8002	.9526
6		.5716	.8383	.6478	.8002	.8002	.9526
7	.5335	.5335	.9145	.6287	.8192	.8002	1.0288
8	.5716	.6478	.9907	.8764	.8383	.8002	1.105
9		.9145	1.0669	1.1431	.9145		1.105
10		1.0669	1.1812	1.1431	1.0669		1.1431
11		1.2193	1.2955	1.1812	1.1431		1.105
12		1.2955	1.3527	1.1812	1.2574		1.1241
13		1.3336	1.3717	1.2193	1.2193		1.1431
14		1.4098	1.4098	1.2193	1.1431		.8764
15		1.3908	1.448	1.2003	1.1812		1.2193
16		1.3717	1.467	1.2193	1.2003		1.2003
17		1.3717		1.0669	1.2193		1.2193
18		1.2955	1.2193	.9145	1.3908		1.2003
19		1.2193	.9907	.8383	1.1812		.9907
20		1.1431	.8954		1.1431		.9145
21		1.105	.9526	.7621	1.086		.9526
22		1.0479	1.0098	.6097	1.086		.9907
23		.9526	.9526	.5716	1.086		.9717
24		.6097	.9145	.8764	.5335	1.0288	.5716
Max	.5716	1.4098	1.467	1.2193	1.3908	1.0288	1.2193
Min	.4954	.5335	.7621	.5716	.5335	.8002	.5716
Avg	.5297	.9717	1.0628	.9079	.9796	.851	.9986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV N. DATTA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4954	.6097	.3429	.4191	.4191	.4572
2	.362	.4572	.5716	.3429	.381	.4191	.4954
3	.381	.4191	.5335	.3429	.381	.381	.5716
4	.362	.381	.5335	.3429	.381	.381	.5335
5	.3048	.4191	.4572	.3429	.3429	.4572	.5335
6	.3239	.3429	.381	.381	.3429	.4191	.5716
7	.3048	.4572	.381	.381	.3429	.4572	.5335
8	.3239	.5335	.4572	.381	.4572	.4572	.5716
9		.6097	.4572	.381	.6859		.6097
10		.6859	.6097	.4572	.8002		.724
11		.7621	.8002	.5335	.7621		.743
12		.8383	.8383	.6097			.7621
13		.9145	.8002	.6859	.8383		.724
14		.8764	.7621	.7621	.8002		.7621
15		.9145	.7621	.8383	.8383		.743
16		.9145	.7621	.9145	.8383		.7621
17		.9145	.6859	.8383	.7621		.724
18		1.0669	.6097	.7621	.6859		.6478
19		1.0669	.5716	.6859	.6478		.6668
20		.9145	.5335	.6097	.5716		.4763
21		.8383	.4954	.5716	.4954		.4572
22		.7621	.4572	.5335	.4572		.4763
23		.6859	.381	.5335	.4572		.4001
24	.4191	.5716	.6859	.3429	.4572	.4572	.4572
Max	.4191	1.0669	.8383	.9145	.8383	.4572	.7621
Min	.3048	.3429	.381	.3429	.3429	.381	.4001
Avg	.3514	.7018	.5890	.5382	.5716	.4276	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4191	.6097	.4191	.5335	.381	.4572
2	.3429	.4572	.5716	.4191	.4572	.381	.4572
3	.3429	.4191	.5716	.381	.4572	.4191	.4572
4	.3429	.381	.6859	.381	.4191	.4572	.5335
5	.362	.381	.7621	.381	.4191	.4572	.5335
6	.381	.4191	.9145	.4572	.381	.4954	.5716
7	.3429	.4572	1.0669	.5335	.381	.5335	.5335
8	.362	.4191	1.1431	.9145	.5335	.5335	.5716
9		.5335	1.1431	.9907	.6097		.8383
10		.6859	1.2193	1.0669	.9145		.9526
11		.7621	1.2955	1.0669	1.0669		.9145
12		.8383	1.2955	1.1431	1.1431		.8764
13		.9145	1.3336	1.2193	1.105		.9145
14		.9526	1.3717	1.2193	1.0288		.9526
15		.9907	1.3717	1.1431	.9907		1.105
16		.9907	1.3717	1.2193	.9907		1.3146
17		1.0669	1.2955	1.1431	.9145		1.105
18		1.0669	1.1812	1.0669	.7621		.9907
19		.9907	1.0288	.9145	.6859		.6668
20		.9145	.7621	.8383	.6478		.4572
21		.8383	.6478	.7621	.5716		.4572
22		.7621	.5335	.6859	.5335		.4382
23		.6859	.4954	.6097	.4572		.4382
24	.381	.4572	.6097	.4572	.5716	.4191	.5335
Max	.381	1.0669	1.3717	1.2193	1.1431	.5335	1.3146
Min	.3429	.381	.4954	.381	.381	.381	.4382
Avg	.3577	.7002	.9701	.8097	.6906	.453	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3429	.3048	.1715	.2667	.2667	.2667
2	.2286	.2286	.3048	.1715	.2858	.2667	.2477
3	.2477	.2667	.2858	.1715	.3048	.2096	.2286
4	.2477	.3048	.3048	.1715	.3048	.2286	.3429
5	.2667	.3048	.3239	.1905	.3239	.2667	.3048
6	.2858	.2477	.3239	.2286	.3429	.3048	.3048
7	.381	.3048	.3429	.2477	.3429	.3429	.2477
8	.4382	.3429	.3429		.362	.362	.2667
9		.3429	.3429	.1715	.362		.2667
10		.362	.381	.2286	.362		.3048
11		.381	.4382	.3048	.362		.2858
12		.381	.4382	.3429	.362		.2858
13		.4001	.4191	.362	.3048		.3239
14		.4001	.381	.381	.3429		.3048
15		.381	.381	.381	.3048		.3239
16		.381	.381	.381	.2667		.3048
17		.381	.3429	.381	.3048		.2858
18		.4001	.3239	.6858	.3239		.2858
19		.4001		.3239	.3429		.3048
20		.381	.3239		.362		.3048
21		.381	.3048		.362		.3048
22		.3429	.2858	.3048	.3048		.3048
23		.3239	.2286	.2667	.2667		.2858
24	.2477	.3429	.3239	.1905	.2477	.2477	.3048
Max	.4382	.4001	.4382	.6858	.362	.362	.3429
Min	.2286	.2286	.2286	.1715	.2477	.2096	.2286
Avg	.2858	.3469	.3404	.2885	.3215	.2773	.2913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4572	.6097	.4572	.5335	.5335	.4572
2	.362	.4572	.6097	.4572	.4572	.4954	.5335
3	.3429	.4191	.5716	.4572	.4572	.4954	.5716
4	.3048	.4954	.5335	.4572	.4191	.4954	.5335
5	.3429	.4954	.5335	.4572	.381	.4572	.4572
6	.362	.4572	.4572	.4572	.381	.4954	.4191
7	.4001	.4191	.4572	.4572	.381	.5335	.4191
8	.381	.4572	.5335	.4572	.4572	.6097	.4954
9		.6097	.5335	.4572	.724		.9907
10		.6859	.6859	.6097	.7621		1.105
11		.7621	1.0669	.6859	1.0288		1.1431
12		.9145	1.2193	.9145	1.2193		1.1812
13		1.0669	1.1431	1.0669	1.1812		1.2193
14		1.1431	1.1812	1.1431	1.2193		1.1431
15		1.2193	1.105	1.2193			1.1812
16		1.2193	1.0669	1.2955	.6097		1.3146
17		1.2193	.9526	1.2193	.8002		1.1812
18		1.3717	.724	1.1431	1.0669		.9717
19		1.3717	.6859	1.0669	.9526		.7621
20		1.2193	.6097	.9145	.9145		.5335
21		1.0669	.6097	.8383	.8002		.5716
22		.9145	.6097	.7621	.6097		.5906
23		.7621	.5716	.6859	.6097		.6478
24	.4001	.4191	.6859	.5335	.5335	.5716	.4191
Max	.4001	1.3717	1.2193	1.2955	1.2193	.6097	1.3146
Min	.3048	.4191	.4572	.4572	.381	.4572	.4191
Avg	.3599	.8176	.7399	.7589	.7173	.5208	.7851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0386		2.2862	2.0386	2.191	2.21	2.5149
2	2.0005	2.1338	2.2862	1.9052	2.1338	2.21	2.6673
3	2.0005	2.0957	2.2481	1.829	2.0957	2.0957	2.4768
4	1.9814	2.3243	***	1.829	2.0957	2.0005	2.4387
5	2.0005	2.4768	2.21	1.829	2.0195	2.0005	2.3243
6	2.0386	2.4387	2.1338	1.829	2.0957	2.0957	2.3624
7	2.0957	2.2481	2.0957	1.9433	2.1338	2.21	2.3243
8	.7811	2.0576	2.1338	2.1338	2.1719	2.2291	2.1338
9		2.4006	2.191	2.0005	2.4387		2.1719
10		2.553	2.5911	2.2862	2.553		2.4006
11		2.7054	2.7816	2.6292	2.6673		
12		2.8959	2.915	2.7054	2.7816		2.8197
13		3.0864	2.8578	2.9531	2.7054		2.9531
14		3.2007	2.8197	2.9721	2.7054		2.934
15		3.2388	2.8578	2.9912	2.7435		2.8959
16		3.0293	2.9531	3.0102	2.7244		2.8387
17		3.0483	3.1245	3.0483	2.8197		2.7625
18		3.1436	3.2388	3.0864	2.8959		2.7054
19		3.2007	3.2388	2.8197	3.0864		
20		2.9531	3.2579	2.7054	3.3532		3.296
21		2.8578	3.1245	2.5911	3.0483		2.934
22		2.6673	2.7435	2.4768	2.7054		2.8006
23		2.4768	2.5911	2.4387	2.6101		3.2388
24	2.1148	2.1338	2.3815	2.21	2.2862	2.3815	2.4387
Max	2.1148	3.2388	22.1194	3.0864	3.3532	2.3815	3.296
Min	.7811	2.0576	2.0957	1.829	2.0195	2.0005	2.1338
Avg	1.8946	2.6681	3.4659	2.4276	2.5442	2.1592	2.6560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0302			.0302			2.8006
2	.0283			.0283			2.7726
3	.0264			.0283			2.4897
4	.0264			.0283			2.3388
5	.0243			.0283			2.4832
6	.0261			.0283			2.4646
7	.0299			.0299			2.5953
8	.0277		2.2916	.0296	.0238	2.4579	2.5873
9		2.2131			.0274		.0296
10	2.0119	.0235			1.9185		.0274
11	2.0271	.0238			1.7924	.0274	.0293
12	2.0271	.0256			1.957	.0274	.0293
13	2.0814	.0256			1.9753	.0274	.0314
14	2.1399	.0238				.0274	.0333
15		.024	.0293			.0274	.0314
16	2.0144	.0256	.0293	2.0698	1.922	.0274	.0277
17			.0274				
18			.0215				
19		2.846	.0256				
20			.0317				
21			.0317				
22						3.0247	
23		2.6139	.0317	.0311			
24	.0299			.0321	.0311		2.8567
Max	2.1399	2.846	2.2916	2.0698	1.9753	3.0247	2.8567
Min	.0243	.0235	.0215	.0283	.0238	.0274	.0274
Avg	.8367	.7845	.2800	.2149	1.2059	.7059	1.3899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0299			.0302			2.5503
2	.028			.0302			2.4646
3	.0261			.0283			2.2592
4	.0243			.0264			2.1285
5	.0243			.0261			2.1658
6	.0243			.0243			2.1845
7	.0243			.0261			2.2177
8	.024		2.1437	.0259	.0256	2.1948	2.2916
9		2.0814			.0256		.0274
10	2.0452	.0235			1.957	.0274	.0256
11	2.0814	.0256			2.0302	.0274	.0274
12	2.0633	.0256			2.2497	.0274	.0296
13	2.0995	.0256			2.0851	.0293	.0296
14	2.2081	.0274				.0293	.0314
15		.0277	.0293			.0293	.0296
16	2.2177	.0296	.0293	2.4508	2.2497	.0274	.0296
17			.0329				
18			.0308				
19		2.809	.0329				
20			.0329				
21			.0333				
22						2.7351	
23		2.5503	.0314	.0311			
24	.0311			.0317	.0293		2.6242
Max	2.2177	2.809	2.1437	2.4508	2.2497	2.7351	2.6242
Min	.024	.0235	.0293	.0243	.0256	.0274	.0256
Avg	.8634	.7626	.2663	.2483	1.3315	.5697	1.2422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0054			.0055			.3761
2	.0054			.0055			.362
3	.0054			.0055			.3658
4	.0054			.0055			.3582
5	.0054			.0054			.3582
6	.0054			.0054			.4031
7	.0071			.0072			.4382
8	.0069		.5144	.0071		.4287	.4681
9		.431			.007		.012
10	.463	.0085			.3481	.0105	.0134
11	.4191				.4359	.0123	.0103
12	.4024	.0116	.0123			.0123	.0104
13	.4409	.0119				.0123	.0123
14	.4239	.0117				.0123	.0124
15		.0119				.0105	.0104
16	.4409	.0099	.0123	.503	.3222	.0105	.0121
17			.0153				
18			.013				
19		.4748	.0103				
20			.0053				
21			.0072				
22						.4207	
23		.3439	.0072	.007			
24	.0054			.0055	.007		.3761
Max	.463	.4748	.5144	.503	.4359	.4287	.4681
Min	.0054	.0085	.0053	.0054	.007	.0105	.0103
Avg	.1761	.1461	.0664	.0511	.2240	.1033	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 201 / 11 KV Vivekanand Chowk
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288						
2	1.0288						
3	1.0288						
4	.9945						
5	.9945						
6	.9945						
7	.9945						
8	.9945						
9	.9945	.9259	.9945	.9945			
10	.9602	.8573	.8402	.9602			
11	.9259	.8916	.8059	.8916			
12	.9259	.8916	.823	.8916			
13	.9259	.8916	.823	.9088			
14	.9259	.8916	.8059	.9259			
15	.9259	.8916	.9431	.8745			
16	.8916	.8573		.8059	.7888	.7087	
17			.8573				1.0288
18			1.0631				1.0631
19							1.166
20							1.2003
21							1.166
22							1.2689
23				.9431	1.0631		1.2003
24	1.0288						1.0631
Max	1.0288	.9259	1.0631	.9945	1.0631	.7087	1.2689
Min	.8916	.8573	.8059	.8059	.7888	.7087	1.0288
Avg	.9743	.8873	.884	.9107	.9260	.7087	1.1446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 203 / 11 KV Gandhi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974						
2	1.0631						
3	1.0288						
4	1.0288						
5	.9945						
6	.9945						
7	.9945						
8	.9945						
9	.9945	1.1317	1.1145	1.3375			
10		1.2003	1.166	1.6118			
11	1.1317	1.6804	1.6975	1.6975			
12	1.3375	1.9547	1.9204				
13	1.3717	2.0576	2.0405				
14	1.6461	2.0919	2.0233	1.5432			
15	1.5432	2.0919	1.9719	1.8519			
16	1.4403	2.0233	1.8861	2.1948	1.9547	1.8004	
17			1.8861				1.749
18			2.0233				1.7833
19							2.1262
20							1.8861
21							1.8519
22							1.3717
23				.8573	1.4403		1.2003
24	1.1317						1.1145
Max	1.6461	2.0919	2.0405	2.1948	1.9547	1.8004	2.1262
Min	.9945	1.1317	1.1145	.8573	1.4403	1.8004	1.1145
Avg	1.1746	1.7790	1.7730	1.5849	1.6975	1.8004	1.6354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115						
2	.4115						
3	.4115						
4	.4115						
5	.3772						
6	.3772						
7	.3772						
8	.4458						
9	.5144	.5487	.5144	.5144			
10	.6173	.583	.5144	.6516			
11	.7888	.8573	.9088	.8402			
12	.9259	1.0974	1.0631	1.0288			
13	1.0288	1.0974	1.1831	1.1145			
14	1.0974	1.1317	1.2346	1.1145			
15	1.0288	1.1317	1.2517	1.2346			
16	.9259	1.2003	1.2517	1.3203	1.1488	1.4575	
17			1.286				1.3032
18			1.3717				1.406
19							1.6118
20							1.4746
21							1.4746
22							.6859
23				.5144	.583		.6001
24	.4458						.5144
Max	1.0974	1.2003	1.3717	1.3203	1.1488	1.4575	1.6118
Min	.3772	.5487	.5144	.5144	.583	1.4575	.5144
Avg	.6233	.9559	1.0580	.9259	.8659	1.4575	1.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 205 / 11 KV Hattenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545						
2	.7545						
3	.7545						
4	.7202						
5	.7202						
6	.7202						
7	.7202						
8	.7202						
9	.6859	.7202	.7716	.6344			
10	.6516	.6859	.6859	.6001			
11	.6859	.3772	.6687	.6001			
12	.7202	.4115	.7202	.6516			
13	.7545	.4458	.7202	.6687			
14	.7545	.4801	.6173	.6687			
15	.7545	.4801	.463	.7888			
16	.7202	.7202	.4973	.7888	.7202	.703	
17			.6859				.8916
18			.9259				.8916
19							.8916
20							.8916
21							.8916
22							1.2689
23				.6859	.7888		1.2003
24	.7545						.8573
Max	.7545	.7202	.9259	.7888	.7888	.703	1.2689
Min	.6516	.3772	.463	.6001	.7202	.703	.8573
Avg	.7263	.5401	.6756	.6763	.7545	.703	.9731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516						
2	.6516						
3	.6173						
4	.6173						
5	.6173						
6	.6859						
7	.7545						
8	.7545						
9	.7888	.6859	.7716	.6859			
10	.7888	.583	.7716	.6859			
11	.7888	.6859	.7202	.6687			
12	.7202	.7545	.6859				
13	.7202	.7202	.7202				
14	.7202	.6516	.6859	.7202			
15	.7545	.6516	.6859	.6859			
16	.6859	.6516	.6344	.7202	.6516	.7373	
17			.6001				.6859
18			.6001				.6859
19							.6859
20							.823
21							.823
22							.8916
23				.6859	.6859		.8573
24	.6516						.7888
Max	.7888	.7545	.7716	.7202	.6859	.7373	.8916
Min	.6173	.583	.6001	.6687	.6516	.7373	.6859
Avg	.7041	.6730	.6876	.6932	.6688	.7373	.7802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.3155	.3294	.3429	.2713	.4161	.4334
2	.6602	.3467	.3772	.3429	.2713	.4854	.4973
3	.7167	.4161	.4287	.3944	.2883	.583	.6173
4	.7922	.4458	.4917	.4287	.3086	.6859	.6274
5	.9054	.5144	.6613	.4748	.463	.7122	.6952
6	.9808	.5426	.788	.5596	.5487	.7461	.7377
7	1.094	.5935	.8785	.5256	.6443	.7712	.8215
8	.9054	.8139	.852	.6371	.7209	.8383	.8951
9	.7922	.6874	.7045	.5596	.6371	.3772	.8619
10	.4161	.5847	.5658	.6036	.6036	.6224	.811
11		.547	.5281	.5281	.5658	.5658	.6413
12	.2401	.547	.547	.4904	.547	.5658	.5847
13	.6613	.5658	.5093	.4904	.4904	.5281	.1886
14	.6371	.5281	.5093	.4715	.5658	.5281	.5658
15	.6203	.4338	.5281	.4338	.4904	.5093	.6036
16	.6539	.5847	.5093	.4527	.4715	.5658	.5281
17	.6874	.5847	.5658	.4338	.5093	.4904	.5658
18	.7167	.5281	.5847	.5658	.5658	.5658	.5658
19		.679		.9054	.7922	.7545	.7922
20	.7733	.8676		.8299		.8676	.8488
21	.679	.8299	.8488	.7545	.7922	.8488	.8865
22	.6097	.8192	.8299	.6602	.7621	.8488	.7733
23	.5716	.6287	.7356	.6287	.724		.7356
24	.5847	.2804	.2947	.3429	.2743	.3121	.3641
Max	1.094	.8676	.8785	.9054	.7922	.8676	.8951
Min	.2401	.2804	.2947	.3429	.2713	.3121	.1886
Avg	.6955	.5702	.5940	.5357	.5351	.6169	.6518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 203 / 11KV NANDGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2667	.2858	.2641	.2858	.3048	.3048
2	.3772	.2858	.2667	.2641	.2858	.3048	.3239
3	.4715	.3048	.3048	.2829	.2858	.3429	.3429
4	.5765	.3772	.3584	.3206	.2858	.3772	.3772
5	.6783	.4904	.4338	.3772	.3772	.4527	.4338
6	.7545	.5281	.4715	.4904	.4715	.4904	.547
7	.9431	.5658	.547	.5093	.6036	.5281	.5847
8	.9389	.4715	.3206	.4904	.2829	.4527	.5093
9	.9389	.3772	.2829	.415	.3772	.3206	.3772
10	.3395	.5426		.3121	.6001	.4917	.6706
11	.3018	.763	.1402		.7461	.6274	.7956
12	.1886	.788	.1402		.7969	.6036	.8288
13	.2452	.8288	.763	.3772	.8215	.4973	.4527
14	.2829	.7459	.8619	.4801	.7545	.57	.7377
15	.2641	.7625	.8288	.5426		.5426	.8215
16	.2452	.7459	.1372	.5868		.5426	.9116
17	.2829	.8122	.8453	.6706	.6203	.503	.9614
18	.3206	.2641	.2641	.2829	.2829	.2452	.2829
19		.3206		.4527	.4527	.3772	.3584
20	.3961	.3772	.4338	.415	.4904	.4338	.4527
21	.3772	.3584	.4527		.4527	.415	.4338
22	.3429	.4001	.3961	.3206	.4191	.4001	.415
23	.3048	.362	.3395	.3239	.381	.381	.3584
24	.3772	.2667	.3239	.3206	.2858	.3429	.3239
Max	.9431	.8288	.8619	.6706	.8215	.6274	.9614
Min	.1886	.2641	.1372	.2641	.2829	.2452	.2829
Avg	.4474	.5002	.4181	.4047	.4709	.4395	.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 204 / 11KV NAGZARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.7628	.7545	.8139	.6371	.8916	1.046
2	.2263	.823	.8309	.8383	.6371	.9156	1.1145
3	.2452	.9602	1.0395	.8718	.6443	.9156	1.17
4	.2829	1.0852	1.1568	.8718	.6443	.9389	1.2239
5	.3018	1.1869	1.2239		.7202	1.0059	1.3077
6	.3018	1.2071	1.442		.7716	1.073	1.3748
7	.3206	1.2574	1.4918	.8383	1.0898	1.094	1.3923
8	.2829	1.3245	1.5238	1.1603	1.1568	1.3426	1.4091
9	.2263	1.3592	1.2431	1.1736	1.1401	1.3757	1.3599
10	.8573	.2263	.2075	.2263	.2263	.2075	.3395
11	1.2378		.2075	.2263	.1698	.2452	.1886
12	1.3413	.3018		.1886	.1886	.1886	.2075
13	1.2071	.2641		.1886	.1886	.2263	.2452
14	1.3923	.2452		.1886	.1886	.2075	.2075
15	1.442	.2452		.1886	.1698	.2075	.2263
16	1.4255	.2452	.2829	.1886	.2263	.2075	.2263
17	1.4918	.2263	.2641	.2075	.1886	.2263	.1886
18	.2452	.132	.2452	.2452	.2263	.1886	.2075
19		.2829	.3584	.3584	.2829	.2263	.3018
20	.415	.3584	.3772	.3772	.3206	.3206	.3206
21	.3961	.3584	.3584		.3395	.3584	.3395
22	.381	.3239	.3395	.3206	.3239	.3429	.3772
23	.3429	.3048	.3206	.3048	.3239		.3395
24	.2452	.6762	.7282	.8139	.6371		.9602
Max	1.4918	1.3592	1.5238	1.1736	1.1568	1.3757	1.4091
Min	.2263	.132	.2075	.1886	.1698	.1886	.1886
Avg	.6450	.6155	.7198	.5043	.4768	.5776	.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 205 / Rajeshwari Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018		.0018	.0018
2	.0018	.0018	.0018	.0018		.0018	.0018
3	.0018	.0018	.0018	.0018		.0018	.0018
4	.0018	.0018	.0018	.0018		.0018	.0018
5	.0018	.0018	.0018	.0018		.0018	.0018
6	.0018	.0018	.0018	.0018		.0018	.0018
7	.0018	.0018	.0018	.0018		.0018	.0018
8	.0018	.0018	.0018	.0018		.0018	.0018
9	.0018	.0018	.0018	.0018		.0018	.0018
10	.0018	.0018	.0018	.0018		.0018	.0018
11	.0018	.0018	.0018	.0018		.0018	.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13	.0018	.0018	.0018	.0018	.0018	.0018	.0018
14	.0018	.0018	.0018	.0018	.0018	.0018	.0018
15	.0018	.0018	.0018	.0018	.0018	.0018	.0018
16	.0018	.0018	.0177	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	.0018
18	.0018	.0018	.0018	.0018	.0018	.0018	.0018
19	.0018	.0018	.0018	.0018	.0018	.0018	.0018
20	.0018	.0018	.0018		.0018	.0018	.0018
21	.0018	.0018	.0018		.0018	.0018	.0018
22	.0018	.0018	.0018		.0018	.0018	.0018
23	.0018	.0018	.0018		.0018	.0018	.0018
24	.0018	.0018	.0018	.0018		.0018	.0018
Max	.0018	.0018	.0177	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0018	.0018	.0025	.0018	.0018	.0018	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 206 / harangul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144		.4534		.7282
2			.6344		.4915		.8573
3			.7122		.5407		1.046
4			.9835		.5898		1.153
5			1.1568		.7042		1.291
6			1.2574		.8573		1.358
7			1.3094		1.1317		1.326
8			1.3599		1.1401		1.3599
9	.9526		1.3927		1.21		.9831
10	.823		.5281		.6287		.4904
11	.9496		.415		.5716		.4527
12	1.0395		.3772		.4763		.415
13	1.1568		.3772		.5335		.3772
14	1.2431		.3395		.381		.415
15	1.21		.3395		.362		.3961
16	1.3435		.3772		.4001		.415
17				.3772			
18		.4763		.4527		.4954	
19		.6097		.7545		.724	
20		.743		.6413		.8192	
21		.8002		.5658		.7621	
22		.7049		.4904		.5906	
23		.5716		.415		.5525	
24			.4334		.421		.6068
Max	1.3435	.8002	1.3927	.7545	1.21	.8192	1.3599
Min	.823	.4763	.3395	.3772	.362	.4954	.3772
Avg	1.0898	.6510	.7358	.5281	.6408	.6573	.8042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2572	.2229	.2401	.2058	
9	.1989	.2218			
12				.1823	
14			.2321		
15	.3978		.2321		
16	.3978		.1658		.3086
24			.0686		
Max	.3978	.2229	.2401	.2058	.3086
Min	.1989	.2218	.0686	.1823	.3086
Avg	.3129	.2224	.1877	.1941	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3944	.3601	.3601		
9	.3326	.3174			
12				.1006	
14			.1326		
15	.1341		.1006		
16	.1341		.0995		.1543
24			.2401		
Max	.3944	.3601	.3601	.1006	.1543
Min	.1341	.3174	.0995	.1006	.1543
Avg	.2488	.3388	.1866	.1006	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 203 / 11KV BHADGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5487	.9431		.8402	
9	.5636	1.0442			
13				.2402	
14			.2033		
15	.2587		.2957		
16	.2402		.2957		.2229
24			.3772		
Max	.5636	1.0442	.3772	.8402	.2229
Min	.2402	.9431	.2033	.2402	.2229
Avg	.4028	.9937	.2930	.5402	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772			.6562	.5658	.8048	.8592
2	.3772			.6562	.583	.9054	.9998
3	.3772			.6718	.6001	.9389	1.0936
4	.4287			.6718	.6516	1.0059	1.1561
5	.4801			.6718	.6401	1.0486	1.2186
6	.6173		1.1203	.5937	.8078	1.1142	1.2498
7	.583		1.5684	.5155	1.1431	1.4746	1.4575
8	.463		1.531	.6405	1.1431	1.5203	1.0155
9	.5281	.3601	1.3435	1.0456	1.1873	1.3717	1.4746
10	.9069	.8078	.415		.3772	.2743	.4715
11	1.2186	.3086			.3018	.3086	.415
12	1.1561	.3086			.2263	.2915	.3772
13	1.0623	.2572	.3772		.2641	.2401	.3398
14	1.1561	.2743	.2829		.2829	.2229	.3042
15	1.2498	.2743	.3395	.2614	.2829	.3258	.2829
16	1.2574	.3086	.3395	.3547	.2641	.2743	.2829
17	.415	.3734	.2641		.7209	.3772	
18	.415	.3921	.2641		.3395	.415	.3086
19			.415	.5487	.5281	.6036	.6173
20				.5487	.6036	.679	.6344
21	.5281		.6224	.5316	.6224	.7167	.583
22	.4715		.5658	.4458	.5281	.6413	.5487
23		.4854	.4527	.3601	.4904	.4527	.463
24	.3772			.6562	.5487	.7545	.7499
Max	1.2574	.8078	1.5684	1.0456	1.1873	1.5203	1.4746
Min	.3772	.2572	.2641	.2614	.2263	.2229	.2829
Avg	.6879	.3773	.6601	.5783	.5710	.6984	.7349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / PTS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0377		.0377	.0343	.0377	.0377
2	.0343	.0377		.0377	.0343	.0377	.0377
3	.0343	.0377		.0377	.0343	.0377	.0377
4	.0343	.0377		.0377	.0343	.0377	.0377
5	.0343	.0377		.0377	.0343	.0377	.0377
6	.0343	.0377	.0373	.0377	.0343	.0377	.0377
7	.0343	.0373	.0373	.0377	.0343	.0377	.0377
8	.0343	.0373	.0373	.0377	.0343	.0377	.0377
9	.0377	.0343	.0377	.0373	.0377	.0343	.0377
10	.0377	.0343	.0377		.0377	.0343	.0377
11	.0377	.0343	.0377		.0377	.0343	.0377
12	.0377	.0343	.0377		.0377	.0343	.0377
13	.0377	.0343	.0377		.0377	.0343	.0377
14	.0377	.0343	.0377		.0377	.0343	.0377
15	.0377	.0343	.0377	.0373	.0377	.0343	.0377
16	.0377	.0343	.0377	.0373	.0377	.0343	.0377
17	.0377	.0373	.0377	.0343	.0373	.0377	.0343
18	.0377	.0373	.0377	.0343	.0377	.0377	.0343
19				.0343	.0377	.0377	.0343
20				.0343	.0377	.0377	.0343
21	.0377		.0377	.0343	.0377	.0377	.0343
22	.0377		.0377		.0377	.0377	.0343
23		.0373	.0377	.0343	.0377	.0377	.0343
24	.0343	.0377		.0377	.0343	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0343	.0343	.0373	.0343	.0343	.0343	.0343
Avg	.0362	.0362	.0376	.0365	.0364	.0366	.0367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.4694		.421	.3429	.4287	.4534
2	.7545	.503		.421	.3429	.5144	.4858
3	.7545	.503		.421	.3429	.5144	.5182
4	.7888	.503		.421	.3772	.5144	.5182
5	.8573	.5304		.421	.4287	.5365	.5506
6	.9945	.5304	.6535		.5316	.5533	.6154
7	1.2174	.6371	1.0269	.6478	.823	.7045	.828
8	1.166	.6802	.9896	.6874	.6859	.7865	.8749
9	1.0642	.7202	.8322	.8402	.7449	.7545	.7373
10	.5344	.5316	.9054		.8775	.823	1.0374
11	.6478	.6859	.6979		.7842	.7373	.9054
12	.6478		.6979		.7282	.703	.8488
13	.5506	.6516	.6602		.6722	.6859	.7922
14	.5344	.6516	.7167		.6348	.6859	.7545
15	.5182	.6173	.7167	.6722	.6348	.6173	.7545
16	.6154	.6516	.6413	.6722	.6348		.7545
17	.8299	.6722	.6348	.6859	.6602	.679	.7373
18	.9431	.7468	.7095	.7545	.811	.6979	.823
19				1.0288	1.1317		1.0288
20				1.0974	1.2071	1.0829	1.1145
21			1.1576	.823	1.1694	1.1576	1.0117
22	.9054		1.0082	.823	1.0562	1.0082	.9945
23		1.0082	.8962	.7716	.9808	.8589	.9431
24	.7545	.4694		.421	.3429	.4287	.4049
Max	1.2174	1.0082	1.1576	1.0974	1.2071	1.1576	1.1145
Min	.5182	.4694	.6348	.421	.3429	.4287	.4049
Avg	.7917	.6191	.8090	.6683	.7061	.7033	.7703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.9175		.6874	.6706	1.073	1.1248
2	.5658	.8192		.6874	.6859	1.1401	1.2029
3	.5658	.8192		.7186	.6859	1.1469	1.2498
4	.6001	.8855		.7186	.7316	1.2125	1.2003
5	.6687	.9172		.7499	.8383	1.2452	1.286
6	.9945	.9488	1.587	.8436	1.1126	1.2955	1.3289
7	1.0974	1.2146	2.1285	.9374	1.4937	1.4083	1.5289
8	.9088	1.4706	2.2965	1.1561	1.6461	1.8976	1.5432
9	.9619	.6859	1.8623	1.4377	1.5432	1.1126	1.7394
10	1.2717	.6173	.6224		.6224	.6001	.4527
11	1.6004	.3086	.4715		.5658	.4801	.415
12	1.6404	.4287	.4527		.5093	.4287	.5658
13	1.6137	.4458	.4715		.4527	.3772	.4904
14	1.6861	.4287	.4715		.4715	.4115	.4338
15	1.6147	.463	.5658	.5228	.4715	.3944	.5658
16	1.8719	.4115		.9335	.4715	.3601	.5658
17	2.0481	.112	.4904	.3944	.4527	.3206	.3258
18	.5658	.5975	.5658	.4458	.4715	.5281	.583
19				.7545	.8299	.8215	.7716
20				1.0117	.9997	.9242	.8402
21	.8299		.8589	.6516	1.0374	1.0269	.8573
22	.7545		1.0456	.6344	.9054	.8215	.7716
23		.7842	.9709		.7922	.7167	.7373
24	.6001	.9175		.6562	.7373	.9724	.9686
Max	2.0481	1.4706	2.2965	1.4377	1.6461	1.8976	1.7394
Min	.5658	.112	.4527	.3944	.4527	.3206	.3258
Avg	1.0965	.7097	.9908	.7745	.7999	.8632	.8979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 207 / 11KV SHELU SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.1143		.0754	.0343	.1905	.1886
2	.7373	.1143		.0566	.0343	.1905	.2263
3	.7716	.1143		.0566	.0514	.1905	.2641
4	.6859	.1905		.0566	.0343	.2286	.2641
5	.7011	.2667		.0566	.0343	.2286	.3018
6	.8573	.3048	.1867	.0754	.0343	.2477	.3395
7		.2667	.2801	.0754	.0514	.1143	.2641
8	1.3108	.2286	.2054	.0377	.0514	.1524	.2641
9	1.4003	.1543	.2667	.056	.1886	.1543	.1905
10	.1509	.6859	1.065		.7655	.9297	1.0883
11	.132	.9297	1.2018		.9998	1.0669	1.2483
12	.1509	.9907	1.2967		1.2029	1.1431	1.4232
13	.132	1.0669	1.2334		1.1431	1.0364	1.4232
14	.132	.9145	1.1069		1.1248	1.1126	1.3916
15	.1698	1.0059	1.0494	1.2136	1.0467	1.1126	1.2967
16	.1509	.9297	1.0936	.9896	1.1873	.2572	1.3916
17	.1143	1.1016	1.1873	1.0212	1.186	.5344	1.2041
18	.1905	.1307	.1698	.1372	.1905	.2075	.1372
19				.2058	.2286	.2263	.2229
20				.2401	.2286	.2263	.2572
21	.1524		.0754	.2229	.2477	.2829	.2401
22	.1524		.0754	.1715	.2286	.2641	.2401
23			.0754	.0343	.1905	.2263	.2058
24	.6859	.1143		.0754	.0343	.2286	.1886
Max	1.4003	1.1016	1.2967	1.2136	1.2029	1.1431	1.4232
Min	.1143	.1143	.0754	.0343	.0343	.1143	.1372
Avg	.4758	.5065	.6606	.2557	.4383	.4397	.5943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 208 / 11 KV SAI DAIRY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0377		.0754	.0514	.0377	.0566
2	.0514	.0377		.0754	.0514	.0377	.0566
3	.0343	.0566		.0754	.0343	.0377	.0566
4	.0343	.0572		.0754	.0343	.0377	.0566
5	.0343	.0572		.0566	.0343	.0381	.0566
6	.0343	.0572	.4294	.0566	.0343	.0572	.0566
7	.0343	.0566	.0373	.0566	.0343	.1132	.0566
8	.0343	.0566	.0373	.0566	.0343	.0569	.0377
9	.0377	.0343	.0566	.056	.0377	.0343	.0566
10	.0566	.0514	.0754		.0754	.0343	.0566
11	.0754	.0686	.0566		.0754	.0514	.0754
12	.0754	.0686	.0566		.0754	.0514	.0754
13	.0754	.0857	.0754		.0754	.0514	.0754
14	.0754	.0686	.0566		.0754	.0343	.0754
15	.0754	.0686	.0754	.056	.0754	.0686	.0566
16	.0754	.0514	.0566	.056	.0566	.0343	.0566
17	.0754	.056	.0754	.0343	.0566	.0377	.0343
18	.0754	.056	.0377	.0343	.0566	.0377	.0343
19			.0377	.0343	.0572	.0377	.0343
20				.0343	.0377	.0377	.0343
21	.0377		.0377	.0343	.0377	.0377	.0343
22	.0381		.0377	.0343	.0377	.0377	.0514
23		.0747	.0377	.0686	.0377	.0377	.0343
24	.0514	.0377		.0377	.0514	.0381	.0566
Max	.0754	.0857	.4294	.0754	.0754	.1132	.0754
Min	.0343	.0343	.0373	.0343	.0343	.0343	.0343
Avg	.0540	.0569	.0751	.0531	.0512	.0449	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.4973		.4115	.4801	
2		.2743	.4973		.4115	.4801	
3		.2058	.5144			.4801	
4		.3429	.5487		.4801	.6173	
5		.4801	.6173		.6173	.7202	
6		.6173	1.0288		.8573	.9945	.9602
7		.6859					.823
8	1.7147	.6173		.4801	.9259	.9945	.7545
9	1.6461		.6859	.6859	.6859	.7888	.4801
10	.6859		1.2346		.823	1.166	1.0631
11	.5487		1.3717	1.2003			1.2689
12	.4801		1.4746	1.3375		1.5775	1.406
13	.4115		1.5775	1.2689		1.5775	1.3717
14	.4115		1.5089	1.3032		1.0288	1.406
15	.3429		1.6461	1.3032		1.3032	1.4403
16	.3429		1.5089	1.3375		1.5089	1.4403
17	.4115	1.3375		1.5089	1.2689	1.5775	
18		.5144		.4115	.4458	.4801	
19	.7545	.7202		.6173	.6173	.5487	
20		.7202		.8916	.7545	.6859	.7202
21		.6859		.6173	.7202	.823	
22	.4801	.6173		.5144	.6173	.7545	
23	.4801	.583		.4801	.583	.6173	
24		.4115	.4973		.4458	.4973	.4801
Max	1.7147	1.3375	1.6461	1.5089	1.2689	1.5775	1.4403
Min	.3429	.2058	.4973	.4115	.4115	.4801	.4801
Avg	.6700	.5723	1.0140	.9305	.6666	.8955	1.0473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.2058		.1372	.1715	
2		.0686	.2058		.1372	.1715	
3		.1372	.2058			.2401	
4		.2058	.2401		.2058	.2401	
5		.3429	.2743		.3429	.3772	
6		.4801	.6173		.4115	.583	.6173
7							.5487
8				.2058		.5487	.4801
9	.7202		.3429			.4801	.2743
10	.2058		.3429		.5487	.4115	.5144
11			.4801	.4458			.4801
12			.4115	.5144		.6173	.583
13	.1372		.5487	.5487		.6173	.583
14	.1372		.4801	.583		.5487	.583
15	.1372		.5487	.5487		.6173	.6173
16	.1372			.583		.6173	.6173
17	.2058	.4801		.5487	.7202	.6859	
18	.2058	.2058		.1372	.2743	.1372	
19	.2743	.3429		.2743	.3429	.2058	
20		.3772		.4115	.3772	.1372	.4115
21		.3086		.3429	.3429	.2058	
22	.2058	.2401		.2743	.2743	.1372	
23	.1372	.2058		.2058	.2401	.1372	
24		.1372	.2058		.1715	.2058	.1372
Max	.7202	.4801	.6173	.583	.7202	.6859	.6173
Min	.1372	.0686	.2058	.1372	.1372	.1372	.1372
Avg	.2276	.2597	.3650	.4017	.3233	.3679	.4959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.4115		.3429	.5144	
2		.1029	.4458		.4115	.5487	
3		.1029	.4801			.583	
4		.1372	.4801		.5487	.583	
5		.1372	.4973		.6173	.7545	
6		.2058	.7545		.6859	1.0288	1.166
7		.1372	.9945		1.0974	1.2346	1.3032
8		.1372	1.0974	.4115	.8916	1.2346	1.3717
9			1.1317	.583	.823	1.2003	1.3032
10	.823		.1372		.1372	.1372	.12
11	1.166		.1029	.0686		.1029	.1029
12	1.2346			.0686		.0686	.0686
13	1.3032			.0686			.0686
14	1.3032			.0514			.0686
15	1.3717		.0686			.0686	.0686
16	1.3032		.0686	.0514		.0686	.0514
17	1.2346	.0686		.0686	.0343		
18	.1029	.7202		.1029	.0686	.0686	
19	.2058	.1715		.1372	.1372	.1029	
20		.1372		.2058	.1372	.1372	.1372
21		.1029		.1372	.1029	.2058	
22	.1372	.0686		.1029	.0686	.1372	
23	.1029	.0686		.0686	.0686	.0686	
24		.0514	.3772	.3429		.4801	.4801
Max	1.3717	.7202	1.1317	.583	1.0974	1.2346	1.3717
Min	.1029	.0514	.0686	.0514	.0343	.0686	.0514
Avg	.8574	.1511	.5034	.1646	.3858	.4442	.4854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 204 / 11 KV SALGARA II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5432		1.2346	1.406	
2			1.5432		1.3032	1.3375	
3			1.6461			1.4403	
4			1.8861		1.4403	1.4746	
5			2.0233		1.5775	1.5432	
6			2.1262		2.0576	2.2291	2.4006
7			2.6406		2.4006	2.5377	2.6749
8			2.7435	2.3663	2.0576	2.6406	2.5377
9	.8916		2.6406	1.6975	2.0576	2.4691	2.4006
10	1.9204		.4801	.7888	.6173	.4801	.6173
11	2.0576		.3429				.5144
12	2.1948			.4115		.2743	.4801
13	2.332			.3429			.4115
14	2.4006			.3429			.4458
15	2.4006		.2743	.3772		.2743	.4458
16	2.2634		.3429	.4458		.2743	.4458
17	4.5268	.5144		.4115	.4115		
18	.823	1.9547		.4115	.5144	.4801	
19	.6173	1.0288		.6173	.823	.5487	
20		1.0631		1.0288	.9945		1.0974
21		1.0974		.8916	1.0288	.8916	
22	.9602	.9259		.7545	.8916	.823	
23	.823	.7545		.5487	.823	.6859	
24		.3429	1.4403		1.166	1.3717	1.4403
Max	4.5268	1.9547	2.7435	2.3663	2.4006	2.6406	2.6749
Min	.6173	.3429	.2743	.3429	.4115	.2743	.4115
Avg	1.8624	.9602	1.5481	.7625	1.2588	1.2201	1.2240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 201 / 11KV KAWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4515	.2033	.1867	.2427	.1867	.2054	.2054
2	.503	.2033	.1867	.2427	.1867	.2054	.2054
3	.5401	.2033	.1867	.2614	.2241	.2241	.2241
4	.6009	.2218	.2241	.2801	.2641	.2241	.2241
5	.664	.2772	.2829	.2801	.3018	.2614	.2614
6	.6964	.3142	.3395		.3395	.3174	.2614
7	.7125	.3511			.2829	.2987	.2987
8	.7537	.3018	.2801		.2829	.2987	
9	.4938	.2641	.2427		.2614	.2452	.3174
10	.2054	.6093			.4321	.4321	.6401
11	.1494	.68	.8259	.4218	.6562	.6964	.7042
12	.1494	.8223	.8259	.6154	.6401		.7362
13	.1307	.8381	.8745	.6478	.6241	.7116	.6882
14	.1494	.828	.8162	.6249	.5921	.759	.6401
15	.1307	.7907	.8907	.7468	.6401	.759	.7042
16	.1307	.7432	.8745	.68	.7522	.7682	.8162
17	.1132	.6722	.8482	.6958	.7202	.4961	.8097
18		.1494	.1307	.168	.1494	.1698	.1867
19		.1867	.2801	.2614	.2054	.2263	.2614
20	.2743	.2427	.3174	.2801	.2987	.3206	.2987
21	.3475	.2241	.2987	.2614	.2801	.2641	.2801
22	.3292	.2427	.2987	.2241		.2263	.2427
23	.2561		.2614	.2054		.2452	.2427
24	.4515	.2641	.1867	.2427	.1867	.2054	.0205
Max	.7537	.8381	.8907	.7468	.7522	.7682	.8162
Min	.1132	.1494	.1307	.168	.1494	.1698	.0205
Avg	.3742	.4189	.4390	.3886	.3867	.3722	.4030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.0914	.2812	.2656	.1619	.16	.176
2	.1867	.0914	.2812	.2812	.1619	.16	.192
3	.1867	.0914	.2812	.2881	.1802	.16	.2241
4	.1867	.0914	.3239	.3201	.1802	.192	.2241
5	.2054	.1067	.3563	.3201	.2429	.2429	.2881
6	.2241	.1372	.3887	.3201	.2429	.2915	.3361
7	.2241	.2286			.3077	.3239	.3521
8	.2427	.216	.5182		.3401	.3401	.3681
9	.2054	.1898	.4858		.2915	.3725	.3201
10	.3041	.1307	.0934		.1494	.1307	.1494
11	.4641	.112	.0934	.1867	.112	.1307	.1307
12	.4161	.0934	.112	.1943	.112	.112	.1307
13	.4321	.0934	.0934	.1494	.112	.1307	.1307
14	.4481	.112	.0934	.0373	.112	.1494	.112
15	.4161	.112	.112	.1494	.096	.1494	.1307
16	.4641	.112	.112	.1307	.112	.112	.112
17	.4961	.0187	.1307	.1307	.0934	.112	.1307
18	.112	.168	.1494	.168	.1307	.1494	.1494
19		.2054	.2241	.2427	.1867	.2241	.1867
20		.2987	.2427	.2427	.2614	.2614	.2614
21	.2801	.2614	.2427	.2427	.2801	.2614	.2801
22	.2427	.2614	.2614	.2241		.2614	.2427
23	.2241		.2241	.2054		.2427	.2427
24	.2054	.0914	.2812	.2656	.1619	.16	.176
Max	.4961	.2987	.5182	.3201	.3401	.3725	.3681
Min	.112	.0187	.0934	.0373	.0934	.112	.112
Avg	.2897	.1441	.2340	.2182	.1831	.2013	.2103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572		.3048	.2721	.1457	.192	.3201
2	.0572		.3048	.2721	.1475	.192	.3201
3	.0762		.3048	.2881	.1802	.192	.3681
4	.0953		.3201	.2881	.1619	.2267	.4001
5	.1334		.3841	.2881	.213	.2429	.4321
6	.1143		.421	.3201	.2267	.2753	.4801
7	.1334				.2622	.4049	.4961
8	.1143	.4111	.5506		.3563	.4752	.4961
9	.0762	.4161	.5668		.4049	.3277	.5121
10	.4161	.4049	.0572		.0381	.0381	.0381
11	.4961	.3725	.0191	.0381	.0381	.0381	.0381
12	.4641	.0381	.0191	.2429	.0381	.0191	.0191
13	.4961	.0191	.0191	.0373	.0381	.0572	
14	.5761	.0381	.0381	.0191	.0381	.0191	
15	.6081	.0381		.0381	.0191	.0191	
16	.5761	.0191	.0381	.0381	.0381	.0191	
17	.5601	.0381	.0191	.0191	.0381	.0191	.0381
18		.0381	.0191		.0572	.0381	.0572
19		.0572	.0953		.0762	.0762	.0953
20	.0953	.1143	.0953	.0762	.0953	.1334	.1524
21	.0953	.1143	.0762	.0572	.1143	.1143	.1143
22	.0762	.0953	.0953	.0381		.0953	.0953
23			.0953	.0381		.0953	.0953
24	.0762		.3048	.2721	.1457	.192	.3041
Max	.6081	.4161	.5668	.3201	.4049	.4752	.5121
Min	.0572	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2568	.1476	.1886	.1468	.1306	.1459	.2436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1635	.6173	.639	.7716		.6241	.6895
2	.0191	.5864	.639	.7888		.0191	.7133
3	.0191	.5864	.6687	.823		.0191	.7133
4	.0191	.6173	.6836	.823		.743	.7133
5	.1635	.6327	.7133	.823		.8173	.7133
6	.1783	.6327	.1337		.4938	.9214	.7133
7	.1783	.9568	1.0105		.6944	.9808	.9511
8	.1635	1.034	1.1294		.7253	1.0848	.9511
9	.0191	.8322	1.2346	.2572	.6481	1.07	.9214
10	.8179	.1189	.1543	.1852	.1189	.0892	.1715
11		.0743	.1543	.1235	.0892	.104	.1372
12	1.0031	.1189	.12	.108	.0892	.104	.1715
13	1.034	.104	.1372	.1235	.104	.104	.1543
14	.4938	.0892		.1389	.104	.104	.1543
15	.9877	.1337		.1235	.0892	.104	.1543
16	.9877	.104	.1372	.108	.104	.104	.1372
17	1.1728	.1189	.1372	.1235		.104	.1372
18	.1235	.1189	.1372	.1235	.1189	.104	.1372
19		.1783	.2229	.1543	.1635	.1635	.1886
20	.2006	.1932	.2401	.1852	.208	.1783	.2401
21	.0191	.208	.2401		.2378	.1932	.2572
22	.1852	.1932	.2401	.2006	.2378	.2378	.2572
23	.1698	.1932	.2401	.2006	.5944	.2378	.2743
24	.1635	.6173	.6241	.7202	.6173	.5944	.6984
Max	1.1728	1.034	1.2346	.823	.7253	1.0848	.9511
Min	.0191	.0743	.12	.108	.0892	.0191	.1372
Avg	.3765	.3775	.4380	.3453	.3021	.3669	.4313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11KV GANGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.7282	.7975	.7888	1.3794	.823	.8149
2	.9945	.7628	.7802	.7716	1.3104	.7202	.8149
3	1.0631	.9015	.7802		1.3794	.7202	.9015
4	1.166	1.0749	.9015		1.5863	.8059	1.0749
5	1.2003	1.3176	1.0923		2.069	.9945	1.2483
6	1.286	1.4217	1.2309		2.2414	1.5089	1.387
7	1.9547	.9709	1.1269		1.8621	1.0117	.9015
8	1.9204	1.0056	.7802		1.6552	1.0631	.9882
9	1.7833	.8322	.7202		.9311	.8745	.9015
10		1.283	1.3546	1.0229		1.4217	1.4918
11	.5548	1.4861	1.7833	1.1789	1.4575	1.595	1.7147
12	.5375	1.5901	1.7833	1.3003	1.4575	1.6991	2.0233
13	.5375	1.5604		1.2483		1.7511	1.3203
14	.5375	1.8031	1.5947	1.2136		1.7684	1.7661
15	.4681	1.8378	1.6632	.9995	1.5604	1.8378	1.8347
16	.4854	1.9938	1.9033	1.543	1.7661	1.8724	1.4918
17	.5375	1.9071	1.9719	1.595	.5487	1.9418	1.9547
18	.7282	.5721	.5487	.6588	.6344	.4854	.5316
19		.8322	1.0802	.8669	.7373	.9882	1.0288
20	1.0402	1.0923	1.0288	.9709	1.0802	1.1789	1.1831
21	1.0749	1.0576	.9945		1.1145	1.1443	1.0802
22	.9709	.9882	.9945	.8149	1.0631	1.0576	.9945
23	.8669	.9015	.9259	.7628	.9088	.9709	.9259
24	.8402	.7628	.8322	.823	1.4484	.8573	.8669
Max	1.9547	1.9938	1.9719	1.595	2.2414	1.9418	2.0233
Min	.4681	.5721	.5487	.6588	.5487	.4854	.5316
Avg	.9769	1.1951	1.1595	1.0350	1.3424	1.2122	1.2184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.426	.6299	.6001	.3605	.4534	.5304
2	.3563	.4588	.6962	.6001	.3932	.4696	.5304
3	.3563	.5243	.6962	.6173	.4588	.4534	.5967
4	.4534	.5898	.7293	.6859	.4915	.5182	.6962
5	.4858	.6226	.7956	.6859	.4915	.6154	.7625
6	.6964	.6554			.5243	1.004	.9614
7	.7611	.9175	1.0442		.8192	1.004	1.094
8	.6316	.9667	1.1603		.852	1.0202	1.0722
9	.5182	.8453	1.2003		.3605	1.0364	1.0111
10	.6718	.3978	.3944	.5201	.3401	.3978	.4458
11	.9175		.3601	.3932	.2753	.3647	.3772
12	.9503		.3086	.3768	.2267	.3315	.3258
13	.852	.2652	.2915	.3277	.2743	.3315	.3429
14	.8192	.2984	.3086	.3113		.3315	.3258
15	.9175	.2818	.2572	.2949		.3149	.2915
16	.9339	.3647	.3258	.2785	.2915	.3647	.2915
17	1.0159	.3647	.2915	.2949	.3887	.3315	.3258
18	.3768	.3647	.3601	.3277	.3887	.4144	.4115
19		.5138	.6001	.3932	.502	.5304	.583
20	.4915	.5636	.6173	.4915	.6316	.6133	.6001
21	.5571	.5138	.6001		.5344	.5801	.6001
22	.4915	.5304	.5487	.4752	.5182	.5801	.5658
23	.426	.4641	.5144	.3605	.4696	.5304	.5487
24	.3887	.3932	.5967	.5658	.3277	.3563	.5138
Max	1.0159	.9667	1.2003	.6859	.852	1.0364	1.094
Min	.3563	.2652	.2572	.2785	.2267	.3149	.2915
Avg	.6286	.5147	.5794	.4527	.4509	.5395	.5752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / K R REFINARY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0171		.0191	.0191
2	.0191	.0191	.0191	.0171		.0191	.0191
3	.0191	.0191	.0191	.0171		.0191	.0191
4	.0191	.0191	.0191	.0171		.0191	.0191
5	.0191	.0191	.0191	.0171		.0191	.0191
6	.0191	.0191	.0191			.0191	.0191
7	.0191	.0191	.0191			.0191	.0191
8	.0191	.0191	.0191			.0191	.0191
9	.0191	.0191	.0171			.0191	.0191
10		.0191	.0171			.0191	.0171
11	.0191	.0191	.0171		.0191	.0191	.0171
12	.0191	.0191	.0171	.0191	.0191	.0191	.0171
13	.0191	.0191	.0171	.0191	.0191	.0191	.0171
14	.0191	.0191	.0171	.0191	.0191	.0191	.0171
15	.0191	.0191	.0171	.0191	.0191	.0191	.0171
16	.0191	.0191	.0171	.0191	.0191	.0191	.0171
17	.0191	.0191	.0171	.0191	.0191	.0191	.0171
18	.0191	.0191	.0171	.0191	.0191	.0191	.0171
19		.0191	.0171	.0191	.0191	.0191	.0171
20		.0191	.0171	.0191	.0191	.0191	.0171
21	.0191	.0191	.0171		.0191	.0191	.0171
22	.0191	.0191	.0171		.0191	.0191	.0171
23	.0191	.0191	.0171		.0191	.0191	.0171
24	.0191	.0191	.0191	.0171		.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0171	.0171	.0191	.0191	.0171
Avg	.0191	.0191	.0179	.0183	.0191	.0191	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5093	.4458	.4578	.5144	.5847	.4801
2	.703	.4715	.4287	.4748	.5316	.6224	.4801
3	.8059	.5975	.6001	.4801	.5658	.7167	.5487
4	.9602	.9054	.7716	.6859	.703	.8488	.7716
5	1.0802	1.0829	.9945	.8916	.9945	.9242	.9431
6	1.2003	1.1458	1.1145		1.1488	1.0374	1.1488
7	1.6461	1.1827	1.2003	1.2003	1.2003	1.0185	1.2346
8	1.6118	.9896	1.0117		1.0802	1.0185	1.0802
9	1.6975	.7545	.8573	1.094	.9259	.7716	1.0374
10	.6344	1.2548	.4801	1.0974	1.286	1.2517	1.065
11	.5144	1.4922	1.2003	1.1283	1.406	1.3203	1.2146
12	.4115	1.543	1.3889	1.1111	1.3203	1.3717	1.1544
13	.3944	.5596	1.5432	1.0936	1.4746	1.3375	1.3535
14	.3772	1.3546	1.3889	1.1227	1.3889	1.3203	1.3121
15	.3772	1.5775	1.2517	1.0467	1.3203	1.3032	1.1683
16	.3601	1.6118	.3772	1.1728	1.4403	1.2346	1.5364
17		.1372	.78	1.2517	1.4255	1.2003	1.3203
18	.7468	.4973		.583	.5304	.5487	.5316
19	.7356			.5658	.6413	.6859	.7202
20	.7655	.7716	1.0117		.7356	.8745	.8745
21	.7095	.6859	.8478	.5487	.7167	.7545	.7545
22	.6224	.6001	.7202	.5316	.6979	.6516	.6516
23	.6036	.4973	.5658	.4973	.6602	.5487	.5316
24	.5316	.4854	.463	.5144	.5144	.5658	.4973
Max	1.6975	1.6118	1.5432	1.2517	1.4746	1.3717	1.5364
Min	.3601	.1372	.3772	.4578	.5144	.5487	.4801
Avg	.7865	.9003	.8838	.8357	.9676	.9380	.9338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.2136	1.0117	1.3717	1.3717	1.6827	1.5261
2	1.6118	1.5154	1.0288	1.4403	1.4232	1.7194	1.5432
3	1.6461	2.1033	1.1145	1.2003	1.4575		1.6289
4	1.6975	2.4434	1.2346	1.4746	1.5432	2.4188	2.1434
5	1.7147	2.8172	1.6289	1.5775	2.0233	2.8172	2.4863
6	1.749	2.8395	1.869		2.3834	2.8607	2.7435
7	1.9204	2.9767	2.0576	1.8861	2.7778	2.93	2.915
8	1.6804	2.8833	2.0233	2.2977	2.8292	2.9647	2.9492
9	1.4918	2.8527	1.989	2.3579	2.692	2.8807	2.6006
10	1.5089	1.0974	.9774	1.2696	1.2346	1.286	1.2567
11	2.2291	1.0288		1.1273	1.166	1.0802	1.2254
12	2.3491	.9945	.7373	1.1088	1.0288	.8402	1.2197
13	2.2634	1.0341	1.046	1.1389	.9774	.9431	1.2012
14	2.2291	.9816	1.0288	1.0903	.9945	.9774	1.1706
15	2.2119	.9945	1.0117	1.0829	1.0117	1.0117	1.134
16	2.5377	1.0288	.9945	1.134	.9945		1.2254
17		.9774	1.1393	.9774	1.0679		1.166
18	1.5402	1.2346	1.3146	1.2174	1.2254		1.2346
19	1.7002	1.5089	1.3717	1.3375	1.5154	1.6289	1.8004
20	1.7375	1.5775	1.5775	1.3203	1.7556	1.8004	1.8004
21	1.5565	1.5432	1.5089	1.3375	1.7002	1.7147	1.7147
22	1.4661	1.4746	1.4403	1.3546	1.6461	1.5947	1.5261
23	1.46	1.3889	1.406	1.3032	1.6078	1.5261	1.4403
24	1.5947	1.0056	.9774	1.406	1.3032	1.5565	1.4918
Max	2.5377	2.9767	2.0576	2.3579	2.8292	2.9647	2.9492
Min	1.46	.9774	.7373	.9774	.9774	.8402	1.134
Avg	1.8047	1.6465	1.3256	1.3831	1.5721	1.8117	1.7143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 203 / 11KV AGRAWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1715	.1886	.1753	.1372	.2206	.1543
2	.12	.1543	.1886	.1578	.1372	.18	.1543
3	.1372	.1543	.1715	.1543	.12	.2008	.1543
4	.1372	.1715	.1715	.1753	.12	.1821	.1372
5	.1372	.1715	.1543		.1372		.1372
6	.1372	.1886	.1543		.1372	.2066	.1543
7	.1543	.1886	.1715	.1928	.1372	.2004	.1543
8	.1715	.1886	.1886		.0857	.2004	.1543
9	.1372	.1715	.1886	.2186	.1886	.1886	.1821
10	.1372	.2054	.2229	.1983	.1886	.2058	.1886
11	.0857	.2427	.2572	.1821	.1886	.2229	.1821
12	.1372	.3206	.2915	.3461	.1715	.2401	.2206
13	.1372	.2641	.2743	.3096	.2229	.2572	.1983
14	.1372	.2743	.2743	.3241	.2572	.2572	.239
15	.1372	.3361	.2572	.2951	.2743	.2572	.2206
16	.1372	.3841	.1886	.255	.3601	.2401	.2915
17		.2572	.3361	.2401	.3461	.2229	.2401
18	.1821	.2229	.2614	.1715	.3086	.2229	.2229
19	.166	.2401	.2279	.1715	.2914	.2058	.2058
20	.2043	.2058	.1848	.1715	.2521	.1886	.2058
21	.1825	.2058	.1715	.1543	.239	.1886	.1886
22	.1879	.1886	.1753	.1372	.2373	.1715	.1886
23	.1543	.1886	.1772	.12	.2186	.1886	.1886
24	.12	.2004	.1886	.1715	.12	.255	.1543
Max	.2043	.3841	.3361	.3461	.3601	.2572	.2915
Min	.0857	.1543	.1543	.12	.0857	.1715	.1372
Avg	.1460	.2207	.2111	.2058	.2032	.2132	.1882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 204 / PANAN MAHASANGH

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0876	.0857	.0857	.0857
2	.0857	.0857	.0857	.0867	.0857	.0857	.0857
3	.0857	.0857	.0857	.0867	.0857	.0857	.0857
4	.0857	.0857	.0857	.0867	.0857	.0857	.0857
5	.0857	.0857	.0857	.0876	.0857	.0857	.0857
6	.0857	.0857	.0857		.0857	.0857	.0857
7	.0857	.0857	.0857	.0857	.0857	.0857	.0857
8	.0857	.0857	.0857	.0857	.0857	.0857	.0857
9	.0857	.0857	.0857	.0857	.0857	.0857	.0857
10	.0857	.0857	.0857	.0857	.0857	.0857	.0857
11	.0857	.0876	.0857	.0857	.0857	.0857	.0857
12	.0857	.0876	.0857	.0857	.0857	.0857	.0857
13	.0857	.0886	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857		.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857		.0857
17		.0857	.0876	.0857	.0857	.0857	.0857
18	.0857	.0857		.0857	.0857	.0857	.0857
19	.0857	.0857		.0857	.0857	.0857	.0857
20	.0857	.0857	.0876	.0857	.0857	.0857	.0857
21	.0857	.0857		.0857	.0857	.0857	.0857
22	.0857	.0857		.0857	.0857	.0857	.0857
23	.0857	.0857		.0857	.0857	.0857	.0857
24	.0857	.0857	.0857	.0876	.0857	.0857	.0857
Max	.0857	.0886	.0876	.0876	.0857	.0857	.0857
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.0860	.0859	.0861	.0857	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 201 / 11KV MALVATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.5144
8			.5068		.3982	.5144
9						.4115
10						1.5203
11						1.5927
12	2.0576					
13	2.0576	2.4977				
14	2.0576					
17						2.2805
18				.362		
Max	2.0576	2.4977	.5068	.362	.3982	2.2805
Min	2.0576	2.4977	.5068	.362	.3982	.4115
Avg	2.0576	2.4977	.5068	.362	.3982	1.1390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 202 / 11KV KOLPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.6859
8			.4163		.8326	.6859
9						.6859
10						.362
11	.2058					.2534
12	.2743					
13	.2743	.2715				
14	.2743					
17						.2715
18				.3982		
Max	.2743	.2715	.4163	.3982	.8326	.6859
Min	.2058	.2715	.4163	.3982	.8326	.2534
Avg	.2572	.2715	.4163	.3982	.8326	.4908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 203 / 11KV BHATKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						1.0288
8			.2534		.8326	1.0288
9						.823
10						.2896
11	.1715					.2534
12	.2058					
13	.2058	.1448				
14	.2058					
17						.2172
18				.362		
Max	.2058	.1448	.2534	.362	.8326	1.0288
Min	.1715	.1448	.2534	.362	.8326	.2172
Avg	.1972	.1448	.2534	.362	.8326	.6068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 201 / 11KV water supply feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2572				.3258		
6			.3366			.3658	
7	.0171	.3658	.3658		.2401		
8	.3772	.3658	.3658		.2915	.3121	
10		.4755				.4572	.5658
12	.3475	.5121		.6344	.6097		.6859
14	.3292			.583	.6036		.6516
15		.7621					
16		.8002	.6401	.6001	.743		.6516
18		.7049			.6478		
19			.4207				
20	.3292			.4973			
22	.2743	.3467			.2947		
24	.2572			.2743	.2572	.2481	
Max	.3772	.8002	.6401	.6344	.743	.4572	.6859
Min	.0171	.3467	.3366	.2743	.2401	.2481	.5658
Avg	.2736	.5416	.4258	.5178	.4459	.3458	.6387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 202 / 11KV AIRPORT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.7545				.6516		
6			1.0099			1.2003	
7	1.1831	1.0387	1.1157		.9088		
8	.9774	.985	.7442		.9774	1.2955	
10		1.1431	1.086			1.2536	.9602
12	.8059	1.0059		1.5089	1.2193		1.3375
14	.7164			1.046	.8669		.8745
15		.9922					
16		1.3336	1.0679	1.2003	1.1431		1.0974
18		1.3717			1.2574		
19			.9694				
20	.9492			.7545			
22	.7701	.8478			.7865		
24	.703			.5973	.4287	.5721	
Max	1.1831	1.3717	1.1157	1.5089	1.2574	1.2955	1.3375
Min	.703	.8478	.7442	.5973	.4287	.5721	.8745
Avg	.8575	1.0898	.9989	1.0214	.9155	1.0804	1.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 203 / 11KV Goodwill feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.1372				.2401		
6			.1696			.4024	
7	.1372	.1905	.1341		.2743		
8	.1372	.1905	.1357		.2058	.3292	
10		.4954				.4763	.3429
11			.5281				
12	.1524	.4572		.4115	.7621		.4115
14	.1524			.4458	.6097		.3086
15		.6097					
16		.4755	.547	.583	.6478		.4115
18		.6097			.724		
19			.3734				
20	.1905			.5144			
22	.1524	.3292			.5335		
24	.2058			.3018	.1715	.5335	
Max	.2058	.6097	.547	.583	.7621	.5335	.4115
Min	.1372	.1905	.1341	.3018	.1715	.3292	.3086
Avg	.1581	.4197	.3147	.4513	.4632	.4354	.3686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0171				.0171		
6			.0503			.2743	
7		.0164	.0335		.0171		
8	.0171	.0164	.0503		.0171	.2601	
10			.0171			.0819	.1029
11		.0709					
12	.0164	.0503		.0171	.0335		.0171
14	.0164			.0171	.0168		.0171
15		.0503					
16		.0335	.0171	.0171	.0678		.0171
18		.0503			.0509		
19			.0171				
20	.0164			.0171			
22	.0164	.0354			.2126		
24	.0171			.0171		.2195	
Max	.0171	.0709	.0503	.0171	.2126	.2743	.1029
Min	.0164	.0164	.0171	.0171	.0168	.0819	.0171
Avg	.0167	.0404	.0309	.0171	.0541	.2090	.0386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 205 / KANHAIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2229				.2058		
6			.2835			.2254	
7	.2058	.2195	.3109		.2401		
8	.1715	.1829	.2254		.2058	.1907	
10		.5906	.4904			.2743	.4115
12	.2012	.5906		.463	.3544		.5144
14	.1829			.2401	.3174		.3772
15		.3012					
16		.4024	.439	.3429	.5906		.5487
18		.3561			.5121		
19			.4024				
20	.1829			.1886			
22	.1646	.2303			.2204		
24	.2058			.2195	.2229	.2427	
Max	.2229	.5906	.4904	.463	.5906	.2743	.5487
Min	.1646	.1829	.2254	.1886	.2058	.1907	.3772
Avg	.1922	.3592	.3586	.2908	.3188	.2333	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.8059				.7545		
6			.8779			.8149	
7	.7716	.8589	.8779		.823		
8	.823	.8215	.9145		.7716	.7455	
10		.8505	.8775			.8215	.8059
12	.8029	.9526		.2743	.6952		.9088
14	.7842			.3086	.6935		.7373
15		.7969					
16		.9145	.8775	.7545	.6935		.7716
18		.7802			.6952		
19			.3361				
20	.8402			.6859			
22	.8589	.9145			.815		
24	.823			.4108	.7888	.8596	
Max	.8589	.9526	.9145	.7545	.823	.8596	.9088
Min	.7716	.7802	.3361	.2743	.6935	.7455	.7373
Avg	.8137	.8612	.7936	.4868	.7478	.8104	.8059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 207 / 11 KV Dhoot feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2572				.1886		
6			.2601			.2683	
7	.2572	.1357	.2683		.2058		
8	.2058	.1696	.2374		.1715	.218	
10		.218	.2058			.2374	.2058
12	.1357	.1509		.2401	.218		.2229
14	.1357			.2401	.218		.2058
15		.1677					
16		.3222	.2915	.2401	.2515		.2915
18		.3391			.2347		
19			.2743				
20	.1696			.2401			
22		.2347			.2515		
24	.3258			.2572	.2229	.2374	
Max	.3258	.3391	.2915	.2572	.2515	.2683	.2915
Min	.1357	.1357	.2058	.2401	.1715	.218	.2058
Avg	.2124	.2172	.2562	.2435	.2181	.2403	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 208 / 11 KV Kalantri feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	1.3717				.8916		
6			1.4861			1.2574	
7	1.3889	1.3717	1.5432		.9431	1.2574	
8	1.1317	1.3336	1.4861		.9602	1.1706	
10		1.3717	1.5466			1.3336	1.3375
12	.9526	1.7718		1.7147	1.7718		1.4746
14	.9526			1.6118	1.448		1.406
15		1.2803					
16		1.4861	1.4937	1.5432	1.5813		1.4575
18		1.4861			1.3717		
19			1.1883				
20	1.0479			1.4575			
22	1.1431	1.0631			.8842		
24	1.3375			1.1694	.9602	1.262	
Max	1.3889	1.7718	1.5466	1.7147	1.7718	1.3336	1.4746
Min	.9526	1.0631	1.1883	1.1694	.8842	1.1706	1.3375
Avg	1.1658	1.3956	1.4573	1.4993	1.2013	1.2562	1.4189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 201 / 11KV Nagazari SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.4572	.5316	.6001	.3048	.4115	.5487
2	.1372	.4572	.6001	.4287	.3048	.4801	.5487
3	.1543	.4877	.6687	.4458	.3353	.5487	.583
4	.1715	.5182	.7716	.4458	.3506	.6173	.6516
5	.1886	.5487	.8916	.4458	.3658	.6859	.6859
6	.2401	.6097	.9945	.6001	.3963	.7545	.7716
7	.2229	.8535	1.1317	.7373	.5944	.8402	1.046
8	.2229	.8993	1.2003	.9431	.6097	1.0288	.9602
9	.1543	.823	1.1145	.884	.6554	.9602	.7888
10	.5487	.1372	.12	.1372	.12	.1372	.12
11	.7468	.12	.1029	.1029	.1372	.1029	
12	.7468	.1029	.1029	.0686	.12		.1029
13	.7164	.12	.1029	.0857		.1029	.12
14	.8688	.1029	.1029	.0686	.1029	.1029	.12
15	.7926	.1029	.1029	.1029	.12	.1029	.12
16	.7926	.1029	.12	.1029	.1372	.1029	.0857
17	.9297	.12	.1029	.0857	.12	.12	.12
18	.1372	.1372	.1372	.1372	.1029	.12	.1372
19	.1543	.1886	.1886	.2058	.1886	.1543	.2058
20	.2058		.2058	.1715	.2572	.2401	.2401
21	.1715	.2058	.2058		.2401	.2229	.2229
22	.1543	.1886	.2401	.12	.2229	.1886	.2058
23	.1372	.1715	.1715	.12	.2058	.1543	.1715
24	.1372	.381	.463	.5144	.2743	.3429	.5144
Max	.9297	.8993	1.2003	.9431	.6554	1.0288	1.046
Min	.1372	.1029	.1029	.0686	.1029	.1029	.0857
Avg	.3695	.3407	.4323	.3284	.2724	.3705	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 202 / 11 KV SAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.1543	.1886	.1715	.1372	.1715	.1886
2	.4458	.1543	.2229	.1886	.1372	.2058	.1886
3	.4458	.1715	.2572	.1886	.1715	.2229	.2058
4	.4458	.2401	.2915	.2401	.1715	.2401	.2401
5	.5144	.3086	.3086	.2743	.2058	.2572	.2743
6	.5487	.3429	.3429	.2915	.2572	.2915	.3258
7	.7316	.3429	.3772	.3086	.2058	.3086	.3086
8	.8383	.2915	.3429	.2743	.0857	.2743	.2743
9	.8688	.2229	.2229	.2058	.12	.1886	.2401
10	.1715	.6097	.9945	.8059	.6859	.7621	.823
11	.0686	.8993	1.3032	1.0117	.6706	.9602	.9145
12	.0686	.4115	.2572	1.0059	.9602	1.1145	1.0517
13	.12	.5144		1.1431	.9945	.9907	1.0517
14	.1372		1.1317	1.2041	1.0288	.9907	1.0669
15	.1372	1.1145	1.2689	1.2955	1.1145	1.0364	1.0974
16	.1372	1.3375	1.2498	1.2955	1.1488	1.0669	1.1126
17	.12	1.3375	1.2498	1.2803	1.2346	1.0059	1.0974
18	.1372	.12	.12	.1029		.1372	.12
19	.1372	.2401	.2058	.2058	.2229	.1886	.2058
20	.2229	.2743	.2401	.1715	.2572	.2572	.2401
21	.2401	.2572	.2743		.2401	.2743	.2572
22	.1886	.2401	.2229	.1372	.2058	.2401	.2401
23	.1715	.2058	.1886	.1372	.2058	.2058	.2229
24	.4287	.1543	.2058	.1715	.1372	.1886	.2058
Max	.8688	1.3375	1.3032	1.2955	1.2346	1.1145	1.1126
Min	.0686	.12	.12	.1029	.0857	.1372	.12
Avg	.3231	.4324	.4986	.5266	.4608	.4825	.4981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 203 / 11 KV RAIWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429	.3944	.4458	.3429	.4287	.4287
2	.4287	.3429	.3772	.4458	.3429	.3944	.4287
3	.4801	.3772	.3601	.463	.3772	.4287	.463
4	.4268	.4801	.3944	.463	.4801	.4801	.463
5	.4877	.5144	.463	.4801	.5144	.5487	.463
6	.5639	.583	.5316	.5487	.583	.583	.6001
7	.7164	.583	.6001	.6001	.6001	.6173	.583
8	.7773	.4801	.5658	.5316	.5487	.583	.5658
9	.7926	.463	.4458	.463	.3944	.4973	.5144
10	.3944	.4572	.6516	.5487	.5792	.5639	.6516
11	.2915	.6401	.7716	.6344	.703	.7202	.7621
12	.2915	.823	.8402		.7888	.8402	.8078
13	.3086	.6687	.8573	.6249	.823	.7888	.7621
14	.2915	.7716	.8573	.6554	.8059		.7926
15	.2743	.7202	.8916	.6859	.7716	.7888	.7926
16	.3086	.9088	.8916	.7926	.823	.8916	.8383
17	.2743	.9259	.8078	.8078	.8402	.8402	.823
18	.2401	.2915	.2915	.3086	.2743	.2915	.3258
19	.4115	.4287	.4801	.5144	.5144	.4458	.4973
20	.5487	.5144	.5658	.5144	.6001	.5658	.583
21	.5144	.4801	.5144		.5658	.5658	.6001
22	.4458	.463	.4801	.3429	.5316	.5144	.5144
23	.4115	.4287	.4458	.3429	.5144	.463	.463
24	.3944	.3601	.4115	.4458	.3429	.463	.4287
Max	.7926	.9259	.8916	.8078	.8402	.8916	.8383
Min	.2401	.2915	.2915	.3086	.2743	.2915	.3258
Avg	.4376	.5437	.5788	.5300	.5692	.5784	.5897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 201 / 11KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1463	.1698	.1663	.1663	.1886	.1886
2	.1478	.1294	.1478	.1646	.1478	.1698	.1886
3	.1478	.1267	.1478	.1448	.1448	.132	.1698
4		.1448	.1463	.1448	.124	.132	.1698
5	.1509	.1463	.1494	.1433	.128	.132	.1698
6	.1494	.1433	.1663	.1629	.1294	.1132	.1698
7	.1494	.1448	.1663	.1417	.1478	.132	.1886
8	.1848	.1478	.1646	.1848	.1829	.1698	.1698
9	.1524	.1698	.2096	.2075	.2263	.1698	.1663
10	.1698	.2452	.2452	.2263	.2641	.2263	.2012
11	.1698	.2454	.2829	.2641	.2452	.2075	.1663
12	.1698	.2641	.2858	.2452	.2263	.2263	.1646
13	.1698	.2263	.2667	.2075	.2452	.2452	.168
14	.1509	.1698	.1886	.1886	.1886	.2263	.1494
15	.1509	.1698	.2263	.2075	.1905	.2075	.1848
16	.1509	.2075	.2452	.2075	.1886		.1867
17	.1509	.2075	.2263	.2075	.1886	.2286	.168
18	.1698	.1886	.1886	.2075	.1886	.1886	.1905
19	.1698	.1886	.1886	.1886	.2075	.2054	.1886
20	.168	.1886		.2075	.2075	.2075	.2054
21	.1867	.2075	.2075	.1698	.2075	.2075	.2075
22	.1698	.2075	.1886	.1715	.2075	.1886	.1867
23	.1494	.168	.1886	.1905	.1886	.1886	.2054
24	.1698		.1698	.1698	.168	.2075	.1886
Max	.1867	.2641	.2858	.2641	.2641	.2452	.2075
Min	.1478	.1267	.1463	.1417	.124	.1132	.1494
Avg	.1608	.1819	.1985	.1883	.1879	.1870	.1810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 202 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3306	1.4415	1.307	1.2567	1.5123	1.531
2	1.2567	1.2071	1.4415	1.2752	1.1888	1.4003	1.4563
3	1.2197	1.086	1.3032	1.2752	1.1765	1.3443	1.4003
4	1.0498	1.1041	1.2803	1.1403	1.1389	1.3443	1.363
5	1.1157	1.1827	1.2071	1.2012	1.0719	1.363	1.3817
6	1.2696	1.3169	1.2567	1.1389	1.1763	1.4563	1.5524
7	1.267	1.363	1.2936	1.1523	1.2696	1.4969	1.6263
8	1.2803	1.2308	1.1949	1.2567	1.1888	1.4815	1.5746
9	1.1462	1.0985	1.134	1.2894	1.1584	1.3169	1.386
10	1.1462	1.1517	1.2048	1.2715	1.0277	1.3394	1.4969
11	1.182	1.2357	1.3253	1.258	1.2445	1.3672	1.4661
12	1.2048	1.2715	1.39	1.3289	1.262	1.4175	1.7375
13	1.258	1.3169	1.4083	1.3643	1.2757	1.4506	1.7556
14	1.2048	1.3535	1.4815	1.3998	1.3112	1.4842	1.7187
15	1.134	1.3756	1.4266	1.382	1.3169	1.4661	1.6095
16	1.1946	1.4118	1.3032	1.4175	1.2437		1.6095
17	1.1744	1.4327	1.4661	1.5565	1.3937	1.5238	1.7013
18	1.3466	1.56	1.5939	1.5592	1.3643		1.5592
19		1.8823	2.0237	1.8983	1.8461	1.7556	1.8823
20	1.182	1.9022		1.829	1.9204	1.4998	1.8642
21	1.1403	1.7556	1.7558	1.4784	1.848	1.4045	1.829
22	1.0719	1.6078	1.6817	1.4003	1.7556	1.7556	1.8473
23	1.0719	1.6057	1.7187	1.3817	1.7177	1.587	1.9035
24	1.3817		1.587	1.6244	1.3256	1.5893	1.6448
Max	1.3817	1.9022	2.0237	1.8983	1.9204	1.7556	1.9035
Min	1.0498	1.086	1.134	1.1389	1.0277	1.3169	1.363
Avg	1.1954	1.3819	1.4313	1.3828	1.3533	1.4707	1.6207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 203 / 11KV KANHERI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.6908	.8215	.7468	.6722	.8299	.8676
2	.7468	.6335	.8131	.7356	.6584	.7922	.8299
3	.679	.6283	.7762	.6602	.6335	.7733	.7922
4	.679	.6283	.8048	.6219	.6099	.7733	.7733
5	.695	.6908	.7733	.7095	.6722	.7545	.7545
6	.7655	.7545	.8029	.7316	.7947	.8488	.8488
7	.8488	.8215	.823	.7964	.8871	.8775	.8676
8	.7733	.7655	.6908	.7095	.7545	.8402	.8402
9	.7095	.7762	.7316	.7023	.6908	.7133	.7922
10	.6653	.7316	.7133	.7316	.7762	.7499	.7947
11	.6401	.7783	.7392	.7783	.7421	.3439	.8779
12	.6468	.7619	.7023	.7316	.8238		.8962
13	.6535	.924	.7577	.7499	.3012	.9795	.9242
14	.6535	.9425	.7577	.7947	.8775	.9328	.8871
15	.6653	.961	.7682	.8488	.9055	.9593	.9619
16	.6908	.961	.823	.9619			.9149
17		.8048	.8779	.9145		1.1041	.8686
18	.8048	.9036	.9231	.9231	1.0099	1.0029	.9313
19		1.0974	1.0974	1.1706	1.2254	1.1523	1.0974
20	.8488	1.0534		1.0534	1.0164	1.1643	1.0534
21	.8299	.9896	.9808	.8589	1.1203	1.0642	.9522
22	.8299	.9149	.9808	.8488	1.0562	1.0185	1.0082
23	.7356	.9242	.9431	.7922	1.0185	.9808	1.0082
24	.8215		.8488	.8488	.7356	.8865	.9054
Max	.8488	1.0974	1.0974	1.1706	1.2254	1.1643	1.0974
Min	.6401	.6283	.6908	.6219	.3012	.3439	.7545
Avg	.7320	.8321	.8239	.8092	.8174	.8883	.8937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
7		2.1285
8		1.8671
17	1.3817	
24		1.251
Max	1.3817	2.1285
Min	1.3817	1.251
Avg	1.3817	1.7489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
7		.128
8		.128
17	.4908	
24		.1753
Max	.4908	.1753
Min	.4908	.128
Avg	.4908	.1438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 206 / 11 KV KARKATTA

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
7		.2353
8		.2033
17	.128	
24		.0572
Max	.128	.2353
Min	.128	.0572
Avg	.128	.1653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	09-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
7		1.9959
8		2.0911
17	.0739	
24		1.2012
Max	.0739	2.0911
Min	.0739	1.2012
Avg	.0739	1.7627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.2346				
10			1.0288		.8059
18		.0754			
19				.2829	
Max	1.2346	.0754	1.0288	.2829	.8059
Min	1.2346	.0754	1.0288	.2829	.8059
Avg	1.2346	.0754	1.0288	.2829	.8059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.823				
10			.4973		.823
18		.1886			
19				.7733	
Max	.823	.1886	.4973	.7733	.823
Min	.823	.1886	.4973	.7733	.823
Avg	.823	.1886	.4973	.7733	.823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 201 / 11 KV BOPLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	1.0688		1.1717
9	1.0688		1.057
10	.1143		.1524
11	.0953		.0381
12	.0191		.0381
13	.0191		
14	.0191		
15	.0191		.0572
16		.0572	.0572
17	.0191	.0572	
18		.1143	
19		.2286	
20		.3048	
21		.2858	
22		.2477	
23		.2286	
Max	1.0688	.3048	1.1717
Min	.0191	.0572	.0381
Avg	.2714	.1905	.3674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 202 / 11 KC CHATA FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	09-APR-18	10-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.0953		.1905
9	.0381		.1715
10	.4001		.362
11	.4784		
12	.4218		.3506
13	.4111		.3506
14	.4374		.3772
15	.4481		.4287
16	.5014	.5441	.4115
17	.5335	.5556	
18	.0381	.0381	
19		.0762	
20		.1334	
21		.1524	
22		.1143	
23		.0762	
Max	.5335	.5556	.4287
Min	.0381	.0381	.1715
Avg	.3458	.2113	.3303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 203 / 11 KV Takli FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	09-APR-18	10-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8			.7888
9	.6718		.8059
10	.9762		.1334
11	.0572		.0953
12	.0762		.0381
13	.0381		.0381
14	.0381		.0381
15	.0381		.0381
16	.0381	.0381	.0381
17	.0381	.0381	
18	.0381	.0381	
19		.1143	
20		.1715	
21		.1905	
22		.1524	
23		.1334	
Max	.9762	.1905	.8059
Min	.0381	.0381	.0381
Avg	.201	.1096	.2238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 206 / 11 kV Ekurga new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.4382		.7049
9	.5906		.6478
10	.8539		
11	1.3283		
12			1.692
13	1.5623		1.7236
14	1.7604		1.97
15	1.866		1.7394
16	1.8785	1.9925	1.7553
17	1.8185	1.9925	
18	.4001	.2477	
19		.4572	
20		.5716	
21		.6478	
22		.6097	
23		.5335	
Max	1.8785	1.9925	1.97
Min	.4001	.2477	.6478
Avg	1.2497	.8816	1.4619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 207 / 11 KV MBF New
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	09-APR-18	10-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.0381		.0381
9	.0572		.0381
10	.0572		.0381
11	.1143		.0953
12	.0953		.0762
13	.0953		.0762
14	.0953		.0762
15	.0953		.0762
16	.0762	.0762	.0762
17	.0762	.0381	
18	.0381	.0381	
19		.0381	
20		.0381	
21		.0381	
22		.0381	
23		.0381	
Max	.1143	.0762	.0953
Min	.0381	.0381	.0381
Avg	.0762	.0429	.0656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4454	.6299		.7131	.6096	.5944	.6299
2	1.4503	.6645			.77	.5944	.7459
3	1.4609	.6645			.791	.6249	.7459
4	1.5337	.8639			.8639	.7468	.8785
5	1.648	1.1962			.9502	.884	.9614
6	1.9171	1.246			1.1711	1.1126	1.1934
7	2.4172	1.2958			1.2836	1.1431	1.2266
8	2.4339	1.0965	1.1603		1.1336	1.1105	1.1105
9	2.2076	1.03	1.0117				.9116
10	.7335	1.6907	1.9281		1.0974		1.3108
11	.5335	2.0388	1.9662	1.467	1.0822	1.326	1.3927
12	.4501	2.0388	2.0481	1.2879		1.442	1.4746
13	.4001	2.0388		1.2513	1.1279	1.3592	1.4737
14	.3834	1.989	1.9109	1.3003	1.0974	1.326	1.5074
15	.3834		1.8785	1.2031	1.1126	1.3592	1.5232
16	.3834	1.989	1.8623	1.2814	1.1431	1.326	1.4746
17	.4001	2.0222	1.9109	1.2748	1.0059	1.4586	1.4746
18	.7002	.4973	.6859		.5182		.6859
19		.7956	.8573	1.3136	.945	.8288	1.1145
20	.9968	1.0277	1.1145		1.0822	1.094	1.0059
21	.9137	.9614	.9259		.8078	.8619	.9431
22	.6978	.7293	.7545	.898	.6401	.7459	.8573
23	.6313	.6299	.6859	.6668	.6249	.663	.6859
24	1.3636	.6313	.6299	.6487	.6168	.5944	.6299
Max	2.4339	2.0388	2.0481	1.467	1.2836	1.4586	1.5232
Min	.3834	.4973	.6299	.6487	.5182	.5944	.6299
Avg	1.1080	1.2073	1.3332	1.1088	.9307	1.0093	1.0816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.038	.1562		.1877	.1871	.1524	.1562
2	.038	.1994			.1871	.1524	.1562
3	.038	.1875			.1667	.1524	.1718
4	.038	.2187			.1604	.1829	.1886
5	.0376	.2187			.1771	.2134	.2193
6	.038	.2343			.2152	.2591	.3132
7	.0376	.4687			.3529	.3963	.3915
8	.0376	.5312	.5312		.3821	.4062	.4698
9	.038	.5155	.5658		.3381	.4374	.3445
10	.3929	.0314	.0362		.0305	.0314	.0362
11	.4715	.0314	.0362	.038	.0305	.0314	.0362
12	.503	.0314	.0362	.0375	.0305	.0314	.0362
13	.4733	.0314	.0362	.038	.0305	.0314	.0362
14	.4259	.0314	.0362	.038	.0305	.0314	.0362
15	.3144	.0316	.0362	.0375	.0305	.0316	.0362
16	.3458	.0314	.0362	.0376	.0305	.0314	.0362
17	.3929	.0314	.0362	.0374	.0305	.0314	.0362
18	.0314	.0314	.0362		.0305		.0362
19	.0314	.0314	.0362	.0374	.0305	.0314	.0362
20	.0314	.0314	.0362		.0305	.0314	.0362
21	.0314	.0314	.0362		.0305	.0314	.0362
22	.0314	.0314	.0362	.0375	.0305	.0314	.0362
23	.0314	.0314	.0362	.038	.0305	.0314	.0362
24	.0379	.1572	.1572	.1877	.1497	.1524	.1562
Max	.503	.5312	.5658	.1877	.3821	.4374	.4698
Min	.0314	.0314	.0362	.0374	.0305	.0314	.0362
Avg	.1620	.1386	.1036	.0627	.1143	.1267	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.149	1.0111			.8669	1.0517	.848
2	.1536	1.0437			.9415	1.0517	.9492
3	.1814	1.0601			.9669	1.0822	.9492
4	.2252	1.1416			1.0002	1.1584	1.0147
5	.3378	1.1742			.9739	1.2803	1.0474
6	.4058	1.2721			1.1669	1.3565	1.5056
7	.495	1.6309			1.2065	1.6461	1.6529
8	.4268	1.7939	1.6635		1.2065	1.6615	1.7184
9	.3296	1.7939	1.668		1.1355	1.5964	1.3093
10	1.5819	.1957	.1886		.1372	.1466	.206
11	1.5004	.1146	.1629		.1372	.0814	.1715
12	1.4351		.1448			.0814	
13	1.4188		.1086			.0814	.1029
14			.1086	.1154		.0814	.1036
15	1.3862		.1086	.0919	.1067	.0814	.1029
16	1.5656	.1142	.1448	.0938	.1372	.0814	.1029
17	1.6309	.1142	.1267	.1871		.0814	.1029
18	.212	.1305	.1715		.1219	.0814	.1715
19	.2772	.1886	.3086	.2922	.2439	.2281	.2058
20	.2446	.2283	.2401		.2591	.2443	.2534
21	.1957	.1794	.2401		.1829	.2281	.2172
22	.1631	.1468	.2058	.1451	.1219	.1629	.181
23	.1468	.1468	.1715	.1497	.1372	.1303	.1629
24	.1536	.9774	.9431	1.0836	.7792	1.0212	.8145
Max	1.6309	1.7939	1.668	1.0836	1.2065	1.6615	1.7184
Min	.1468	.1142	.1086	.0919	.1067	.0814	.1029
Avg	.6355	.7229	.3945	.2699	.5915	.6124	.6041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0903	.0932		.0722		.1219	.092
2	.09	.0751				.1067	.0736
3	.0938	.0751				.1067	.0736
4	.09	.0747				.1067	.0736
5	.09	.0751				.1067	.092
6	.09	.0747				.1067	.092
7	.0824	.0938				.1126	.092
8	.0903	.1501	.1126			.1314	.092
9	.1264	.1501	.1086			.1501	.092
10	.1677	.1315	.1267			.1501	.1086
11	.1677	.1314	.1267	.1626		.1501	.1276
12	.1677	.1501	.1448	.1806		.1501	.1448
13	.1677	.1501	.1448	.1974		.1501	.1629
14	.1677	.1501	.1448	.1974		.1501	.1629
15	.1863	.1314	.1629	.18		.1501	.1629
16	.1677	.1314	.1629	.1806		.1877	.1448
17	.1491	.1501	.1629	.162		.2064	.1448
18	.1491	.1314	.1448		.1524	.1656	.1267
19	.0932	.1126	.1086		.1524	.1472	.1267
20	.0939	.1126	.1086		.1372	.1288	.1267
21	.0939	.1126	.0905		.1219	.1288	.1267
22	.0939	.0938	.0905		.1219	.092	.1086
23	.0939	.0938	.0905		.1219	.092	.0905
24	.0903	.0932	.0938	.09		.1219	.092
Max	.1863	.1501	.1629	.1974	.1524	.2064	.1629
Min	.0824	.0747	.0905	.0722	.1219	.092	.0736
Avg	.1205	.1141	.125	.1581	.1346	.1342	.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.4694	.3932		.4096	.3768
9		.4694			.3277		
16	.6371						
23		.2347					
24		.2347	.2683	.2401	.2622	.2622	.2622
Max	.6371	.4694	.4694	.3932	.3277	.4096	.3768
Min	.6371	.2347	.2683	.2401	.2622	.2622	.2622
Avg	.6371	.3129	.3689	.3167	.2950	.3359	.3195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.3768		
8	1.7101	.4191	.4359	.4096		.3932	.3277
16	.1174	1.2742	1.2346	1.2616		1.1469	1.278
17					.3768		
24	1.0059	.1677	.2012	.1966	.1966	.2458	.2294
Max	1.7101	1.2742	1.2346	1.2616	.3768	1.1469	1.278
Min	.1174	.1677	.2012	.1966	.1966	.2458	.2294
Avg	.9445	.6203	.6239	.6226	.3167	.5953	.6117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3521	.3185	.2949	.1638	.1638	.1311
16	.3856						.3277
24		.2012	.218	.1966	.1638	.0983	.1311
Max	.3856	.3521	.3185	.2949	.1638	.1638	.3277
Min	.3856	.2012	.218	.1966	.1638	.0983	.1311
Avg	.3856	.2767	.2683	.2458	.1638	.1311	.1966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 204 / 11 KV Kanadi Borgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.0655		
8		.9724	1.1233		.5735	.6226
10					1.0395	
16	1.0227					.1802
17				.3605		
24	.0838	.57	.7209	.0655	.1311	.1147
Max	1.0227	.9724	1.1233	.3605	1.0395	.6226
Min	.0838	.57	.7209	.0655	.1311	.1147
Avg	.5533	.7712	.9221	.1638	.5814	.3058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 205 / 11 KV Tandulja Gao SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.7545				
10	.4862	.503		.5197	.426	.4588	.4424
16	.3521	.3185	.285	.285		.3277	
17					.2458		
24	.3353	.3353	.3353	.3353	.3277	.3277	.3605
Max	.4862	.503	.7545	.5197	.426	.4588	.4424
Min	.3353	.3185	.285	.285	.2458	.3277	.3605
Avg	.3912	.3856	.4583	.38	.3332	.3714	.4015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 206 / 11KV Tandulja AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5197	.0335	.0168		
10				.4694	
16		.4287	.6371	.57	.4915
24	.3353				
Max	.5197	.4287	.6371	.57	.4915
Min	.3353	.0335	.0168	.4694	.4915
Avg	.4275	.2311	.3270	.5197	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	.8684	.6554	.9724	.6859	.8848	.7373
2	.1457	.8848	.7373	1.0277	.7373	.9175	.7716
3	.1619	.9496	.7373	1.1317	.7716	.9831	.8192
4	.1658	1.0174	.7373	1.1831	.8192	1.0814	.9339
5	.1989	1.0814	.7537	1.2003	.9831	1.1305	.9831
6	.2591	1.1869	.7701		.9831	1.1469	1.2289
7	.2591	1.4074	1.0288	1.2346	1.1469	1.3763	1.326
8	.2429	1.3435	1.065	1.2689	1.2616	1.3435	1.4255
9	.1943	1.3108	1.0288	1.1469	1.3108	1.3226	1.4091
10	.9945	.1715	.1147	.181	.12	.1311	.1311
11	1.56	.1715	.1372	.1372	.0509	.1372	.0983
12	1.5939	.1341	.1052		.0509	.12	.0819
13	1.56	.1254	.1372	.1132	.1017	.1029	.0819
14	1.4419	.1267	.12	.1029	.1017	.1029	.0848
15	1.4746	.1132	.0857	.1029	.1017	.1029	
16	1.5043	.0943	.0857	.1029	.1017	.0857	.0819
17	1.4723	.0857	.1029	.1372	.1187	.0857	.1311
18	.1638		.2229	.2572	.1357	.12	.1311
19	.2622	.2058	.2401	.2743	.2035	.12	.1638
20	.2374	.2058	.2058	.2401	.2785	.1372	.2458
21	.2543	.1677	.2058	.2058	.2458	.1715	.2294
22	.2035	.1715	.1715	.1715	.1966	.2058	.213
23	.1638	.1372	.1543	.1715	.1802	.6706	.1966
24	.1638	.8817	.6706	.7545	.6859	.9156	
Max	1.5939	1.4074	1.065	1.2689	1.3108	1.3763	1.4255
Min	.1457	.0857	.0857	.1029	.0509	.0857	.0819
Avg	.6177	.5584	.4281	.5508	.4739	.5582	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 204 / 11 KV Natural FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0191	.0183	.0189		.0191	.0189
2	.0177	.0191	.0189		.0189	.0191	.0189
3	.0177	.0191	.0183		.0189	.0191	.0189
4	.0179	.0191	.0189		.0189	.0191	.0189
5	.0177	.0191	.0189		.0189	.0191	.0189
6	.0175	.0191	.0377		.0189	.0191	.0189
7	.0177	.0191	.0377		.0189	.0381	.0377
8	.0171	.0191	.0377		.0189	.0191	.0377
9	.0177	.0191	.0189	.0189	.0189	.0191	.0191
10	.0175	.0189	.0189	.0189	.0189	.0191	.0191
11		.0189	.0189	.0189	.0381	.0183	.0191
12		.0189	.0189	.0189	.0191	.0189	.0191
13		.0189	.0189	.0189	.0191	.0189	.0191
14		.0189	.0189	.0189	.0191	.0189	.0191
15		.0189	.0189	.0189	.0191	.0189	.0191
16		.0189	.0189	.0189	.0191	.0189	.0381
17		.0189	.0189	.0189	.0381	.0189	.0381
18		.0189	.0189	.0189	.0381	.0189	.0381
19		.0189	.0189	.0189	.0381	.0189	.0381
20		.0189	.0189	.0189	.0191	.0189	.0381
21		.0189	.0189	.0189	.0381	.0189	.0381
22		.0189	.0189		.0191	.0189	.0191
23	.0191	.0189	.0189	.0189	.0191	.0189	.0191
24	.0351	.0191	.0189	.0189		.0191	.0189
Max	.0354	.0191	.0377	.0189	.0381	.0381	.0381
Min	.0171	.0189	.0183	.0189	.0189	.0183	.0189
Avg	.0207	.0190	.0212	.0189	.0233	.0198	.0253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.4527	
6			.503		.503	
8	1.56		.3688		.3521	.373
10				.9054		
11		1.7101				
12					2.0687	1.8652
13				1.8778		
14		2.364				
15				1.7436		
16		2.364				
17						2.0348
18				.1677		
20		.3688		.4024	.3561	
22		.3018		.3185		
23						.3052
24	.6443		.3018		.3018	
Max	1.56	2.364	.503	1.8778	2.0687	2.0348
Min	.6443	.3018	.3018	.1677	.3018	.3052
Avg	1.1022	1.4217	.3912	.9026	.6724	1.1446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.8383	
6			1.2407		1.0227	
8	.3222		1.4419		1.2407	1.3226
10		.1341				
12		.0671			.0678	.1017
14		.0838		.1677		
16		.0838				
17				.1006		.1526
20		.2683		.3018		
22		.2012		.1844		
23						.2543
24	.2543		.8048		.57	
Max	.3222	.2683	1.4419	.3018	1.2407	1.3226
Min	.2543	.0671	.8048	.1006	.0678	.1017
Avg	.2883	.1397	1.1625	.1886	.7479	.4578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 204 / 11 KV WATER WORKS EXP
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
8		.0678
12	.0678	
20	.017	
Max	.0678	.0678
Min	.017	.0678
Avg	.0424	.0678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 205 / 11 KV Bhoyra New SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.2683	
6			.3185		.3185	
8	.9326		.3018		.2515	.2713
10		.5365		.5365		
12		.6203			.6613	
14		.6371				
15				.4694		
16		.6371				
17				.5868		.6443
20		.2683		.3185	.2883	
22		.218		.2012		
23						.1696
24	.3391		.1677		.1677	
Max	.9326	.6371	.3185	.5868	.6613	.6443
Min	.3391	.218	.1677	.2012	.1677	.1696
Avg	.6359	.4862	.2627	.4225	.3259	.3617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 206 / 11 KV Ankoli new SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.5868		.6173	
7			.57			
8	.9156				.5365	.5596
10		.788		.8383		
12		1.0059			.8817	.8987
13				.9054		
14		.9724				
15				.788		
16		.9724				
17				.8551		.9835
20		.4862		.503	.5426	
22		.3856		.4024		
23						.373
24	.5087		.3688			
Max	.9156	1.0059	.5868	.9054	.8817	.9835
Min	.5087	.3856	.3688	.4024	.5365	.373
Avg	.7122	.7684	.5085	.7154	.6445	.7037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 207 / 11 KV Dhanori SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.6371	
6			1.0227		.6952	
8	.1187		1.073		.8309	.8139
10				.0335		
12		.0168			.0339	.0339
13				.0168		
14		.0335				
16		.0335				
17						.0339
20		.1174		.1341	.1187	
22		.0671		.0061		
23				.0671		.0848
24	.0848		.4191		.4024	
Max	.1187	.1174	1.073	.1341	.8309	.8139
Min	.0848	.0168	.4191	.0061	.0339	.0339
Avg	.1018	.0537	.8383	.0515	.4530	.2416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4382	.3563		.3563	.4207	.4525
2	1.6872	.5228	.3401	.3982	.3401	.3681	.4344
3	1.8564	.4706	.3887	.4024	.3725	.4755	.4755
4	1.8747	.5895	.5182	.4706	.421	.5359	.4938
5	2.0885	.6762	.664		.5182	.6219	.5973
6	2.1714	.8063	.7611	.7602	.7125	.6687	.8775
7	2.4234	.8954	.7287	.8775	.7449	.6219	.8145
8	2.1795	.7602	.7287		.664	.5144	.7682
9	.7207	1.8747	1.7394	1.5061	1.1174	1.0669	1.3441
10	.5611	2.0881	2.2405	1.5565	1.247	1.1126	1.3765
11	.463	2.1643	2.4006	1.5708	1.0822	1.3603	1.4899
12	.3696	2.2672	2.2672	1.6032		1.4575	
13	.298	2.2348	2.2455	1.6518	1.2193	1.4403	
14	.3224	2.2672	2.2613	1.587	1.2651	1.4899	1.6032
15	.2439	2.2834	2.2996	1.5546	1.2193	1.4723	1.5708
16	.2774	2.332	2.4006	1.5223	1.326	1.439	1.6032
17	.3696	.3563	.3258	.2915		.3292	
18		.421	.5228	.3401	.463	.3361	
19	.6878	.5992	.6161	.5668	.6805	.6908	
20	.7762	.664	.7842	.6154	.7716	.7468	
21	.6241	.583	.6908	.3077	.6838	.6908	
22	.5544	.5344	.5853	.3401		.6161	
23	.4334	.4858	.5121	.3563		.5487	
24	.4334	.4334	.421	.5121	.3563	.4382	.5041
Max	2.4234	2.332	2.4006	1.6518	1.326	1.4899	1.6032
Min	.2439	.3563	.3258	.2915	.3401	.3292	.4344
Avg	.9502	1.1145	1.1166	.8948	.7781	.8109	.9604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3403	.3467	.3077	.3658	.2753	.4572	.3734
2	.3258	.362	.3239	.3258	.2915	.3601	.4066
3	.3881	.3814	.3725	.3582	.3239	.4458	.4024
4	.4887	.5601	.4696	.5068	.3887	.5601	.4435
5	.6283	.6805	.6478		.4696	.6516	.6535
6	.7343	.7802	.8259	.9313	.6154	.7373	.8775
7	.6836	.788	.7287		.5992	.5487	.8507
8	.7207	.6722	.6478	.8417	.4372	.6173	.695
9		.6468	.6516	.6335	.3563	.4287	.4858
10	1.448	.462	.3801	.4572	.2753	.3475	.3887
11	1.6244	.3086	.2686	.2915	.208	.2534	.2753
12	1.7284	.2429		.2105		.2195	
13	1.768	.2105		.2105		.2149	.2429
14	1.6766	.1943	.2195	.2105	.2058	.2303	.2105
15	1.8435	.1781	.2328	.1943	.2058	.2534	.2105
16	1.8595	.1781	.2353	.1619	.2743	.2561	
17		1.9433	2.1862	2.2024	1.4327	1.9109	
18		1.8785	2.0005	2.2186	1.7071	2.0243	
19	.5959	1.8623	1.8623	1.8623	1.8435	1.9433	
20	.6878	1.7814	1.7004	1.1336	1.768	1.8404	
21	.4508	1.7652	1.5565		1.6766	2.0119	
22	.4066	1.6518	1.5384			1.8023	
23	.3506	1.6518	1.5565	.2753		1.6385	
24	.3224	.3294	1.5708	1.4746	.2753	1.6964	1.8671
Max	1.8595	1.9433	2.1862	2.2186	1.8435	2.0243	1.8671
Min	.3224	.1781	.2195	.1619	.2058	.2149	.2105
Avg	.9082	.8273	.9220	.7433	.6815	.8937	.5589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.4115	.4049	.5304	.4858	.4572	.5407
2	.0747	.4696	.4858	.5571	.5182	.4877	.5365
3	.0724	.4268	.6154	.5668	.583	.5506	.5735
4	.1214	.4877	.7449	.6226	.6316	.5944	.6154
5	.1928	.5624	.8907		.6964	.6562	.7373
6	.2865	.6249	.9878	.7611	.8097	.8951	1.0526
7	.3077	.7164	1.0526	1.0402	1.0526	1.2631	1.3283
8	.2835	.7621	.2105	1.1203	1.0202	.945	1.1336
9	.2218	.2614	.2353	.2353	.2267	.12	.2105
10	.12	.1294	.1097	.181	.1457	.112	.081
11			.1254	.0648	.0857	.0905	.0486
12			.0709	.0486		.0732	
13	.0739		.0716	.0486	.0457	.0543	.0486
14	.0537	.0648		.0486	.0514	.0537	
15	.0554	.0648		.0486	.0514	.0732	.0486
16	.0724	.0648	.0709	.0486	.0514	.0543	.0486
17	1.0059	.0648	.0537	.0648	.0554	.0739	
18		.0972	.168	.081			
19	.4999	.1457	.2829	.2267	.2254	.2452	
20	.503	.1943	.2263	.1781	.2987	.2641	
21	.5138	.1457	.132	.1134	.1848	.1698	
22	.4725	.1134	.1132	.081		.12	
23		.081	.1132	.081		.0943	
24	.4725	.4321	.081	.0566	.0648	.1029	.0943
Max	1.0059	.7621	1.0526	1.1203	1.0526	1.2631	1.3283
Min	.0537	.0648	.0537	.0486	.0457	.0537	.0486
Avg	.2748	.3010	.3294	.2959	.3642	.3283	.4732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 201 / 11 KV RAMEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4444	.7773			.8423	
2		.5902				.865	
3		.8081				.8936	
4		1.0586	.9069			.9239	
5						1.0242	
6		1.251				1.1254	
7		1.2491	1.2308	.6062		1.0913	
8	.3812				.6081		
9					.6571	.8956	
10		.2641		.2263	.1711		.2641
11		.1494	.116	.0754			.1509
12		.1509					
13		.1132		.0754	.1331		
14		.1132			.1331		.1132
15		.1132		.0754	.1141		.1132
16					.1141		.1886
17		.1132			.1331		.1509
18				.1509	.2282		
19		.2263			.3803		.3395
20		.3395			.4183		
21	.2662				.3423		.3018
22	.2282				.3042		
23	.2092	.1886			.2662		
24		.3354				.5281	
Max	.3812	1.251	1.2308	.6062	.6571	1.1254	.3395
Min	.2092	.1132	.116	.0754	.1141	.5281	.1132
Avg	.2712	.4417	.7578	.2016	.2860	.9099	.2028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0189	
8	.2486			
10		.1372		
11		.125	.0663	
12		.16		
13		.1619		
14		.1619		.0171
15		.0164		.0343
16				.0312
17		.0655		.0324
20		.0189		
Max	.2486	.1619	.0663	.0343
Min	.2486	.0164	.0189	.0171
Avg	.2486	.1059	.0426	.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4588	.852		.5194	.9709	
4		.5898	1.3108		.7975	1.1488	
6			1.6385		.8573	1.2039	
8			1.7204	1.3375	1.1233	1.2944	
10					.0373		.0655
12	.7373				.0373		
14	.5898	.0328		.0171	.0191		
16	.8848	.0164	.0171	.0187	.0187		.0164
17						.0343	
18				.0191	.056		
20					.0924		
22				.0373	.0739		
24		.3277	.3605	1.3032		.7888	
Max	.8848	.5898	1.7204	1.3375	1.1233	1.2944	.0655
Min	.5898	.0164	.0171	.0171	.0187	.0343	.0164
Avg	.7373	.2851	.9832	.4555	.3302	.9069	.0410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1638	.1966		.1478	.1478	
4		.2294	.2458		.2561	.1829	
6		.2949	.3441		.3982	.3258	
7			.3441				
8		.2785	.3441	.2845	.3982	.362	
9	.9284						
10	.1966	.6062			.2743		.852
11					.2743		
12	.1475	1.0486			.5258		.9503
14	.1311	.8848		.7487	.5609		.7865
16	.1147	.9995	.9584	.9536	.8764		.9339
18				.1646	.1646		
20				.2195	.2561		
22				.1646	.2378		
24	.2845	.1311	.1638	.1348	.1478	.1646	
Max	.9284	1.0486	.9584	.9536	.8764	.362	.9503
Min	.1147	.1311	.1638	.1348	.1478	.1478	.7865
Avg	.3005	.5152	.3710	.3815	.3476	.2366	.8807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 203 / 11 Kv Bhokaramba SS SINGLE PHASING

Poharegaon Feeder KV- 11 /
OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.0191	.0191	
8		.0164	.0328	.0179			
9	.0179						
10	.0164						
12	.0164				.0191		
14	.0164				.0191		
16	.0158		.3582	.0191			.0164
18				.0191			
20					.0191		
23					.0191		
Max	.0179	.0164	.3582	.0191	.0191	.0191	.0164
Min	.0158	.0164	.0328	.0179	.0191	.0191	.0164
Avg	.0166	.0164	.1955	.0187	.0191	.0191	.0164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5144	.7202	.6516			.5316
8		1.046	1.166	.7202		.9088	.9945
12	.9774		.1372	.1372		.1715	
16	.9431		.1543	.1029	.12	.12	
20	.2743	.3429				.3429	
24	.1715	.4801	.5487	.5144	.3601		.4973
Max	.9774	1.046	1.166	.7202	.3601	.9088	.9945
Min	.1715	.3429	.1372	.1029	.12	.12	.4973
Avg	.5916	.5959	.5453	.4253	.2401	.3858	.6745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.1715	.2401	.1372			.2058
8		.3258	.3429	.3429		.2915	.2743
12	.1372		.6001	.5658		.4973	
16	.1543		.6001	.583	.5487	.5316	
20	.1715	.3086				.3086	
24	.2229	.1372	.1715	.2572	.2058		.2058
Max	.2229	.3258	.6001	.583	.5487	.5316	.2743
Min	.1372	.1372	.1715	.1372	.2058	.2915	.2058
Avg	.1715	.2358	.3909	.3772	.3773	.4073	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 203 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-18	10-APR-18
HR	Load (MW)	Load (MW)
12	.0857	.0171
16	.0514	.0686
Max	.0857	.0686
Min	.0514	.0171
Avg	.0686	.0429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 204 / 11 kV Andalgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0343	.0514	.0343			.0514
8		.0686	.0514	.0857		.0857	.0514
12	.0343		.3086	.2401		.2058	
16	.0171		.3086	.2572	.1715	.2229	
20	.0686	.0686				.0686	
24	.0171	.0343	.0343	.0343	.0171		.0343
Max	.0686	.0686	.3086	.2572	.1715	.2229	.0514
Min	.0171	.0343	.0343	.0343	.0171	.0686	.0343
Avg	.0343	.0515	.1509	.1303	.0943	.1458	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 205 / 11 kV Sangvi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5487	.8059	.6516			.4287
8		.9088	1.0631	.7716		.6001	.6687
12	.9259		.0686	.0514		.0686	
16	.9602		.0514	.0686	.0343	.0514	
20	.2058	.2572				.2572	
24	.0857	.4458	.6344	.6001	.2743		.3772
Max	.9602	.9088	1.0631	.7716	.2743	.6001	.6687
Min	.0857	.2572	.0514	.0514	.0343	.0514	.3772
Avg	.5444	.5401	.5247	.4287	.1543	.2443	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 206 / 11 kV Kolgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2058	.2401	.1715			.2401
8		.3086	.2401	.3772		.3086	.2915
12	.1372		1.1145	.7888		.8573	
16	.12		1.3375	1.0974	.8402	.8573	
20	.2401	.2915				.3258	
24	.3772	.1543	.1543	.1543	.12		.1886
Max	.3772	.3086	1.3375	1.0974	.8402	.8573	.2915
Min	.12	.1543	.1543	.1543	.12	.3086	.1886
Avg	.2186	.2401	.6173	.5178	.4801	.5873	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.7468			.8383
16	.5944		.3201	.5792	
24	.7316				
Max	.7316	.7468	.3201	.5792	.8383
Min	.5944	.7468	.3201	.5792	.8383
Avg	.663	.7468	.3201	.5792	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4973	.2286			.061
16	.381		.5792	.4858	
24	.2374				
Max	.4973	.2286	.5792	.4858	.061
Min	.2374	.2286	.5792	.4858	.061
Avg	.3719	.2286	.5792	.4858	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu (J)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.462	.7621	.8535
16	.8535		
24	.2772		
Max	.8535	.7621	.8535
Min	.2772	.7621	.8535
Avg	.5309	.7621	.8535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 201 / 11 Kv Bittergaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18
HR	Load (MW)	Load (MW)
7	.3258	.3086
8	.3086	
Max	.3258	.3086
Min	.3086	.3086
Avg	.3172	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 202 / Kamkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18
HR	Load (MW)
8	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 203 / 11 Kv W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-18	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0171				
8	.0171		.1086		
12				.0543	
16			.0514	.0543	.0514
21		.0724			
Max	.0171	.0724	.1086	.0543	.0514
Min	.0171	.0724	.0514	.0543	.0514
Avg	.0171	.0724	.08	.0543	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 204 / Wanjarwadi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3258	1.406				
8	.2743		1.647	.9556		1.5223
12					.1086	
16			.12		.1086	.12
20					.2715	
21		.2896				
24			.7602	.5256	.7716	.6516
Max	.3258	1.406	1.647	.9556	.7716	1.5223
Min	.2743	.2896	.12	.5256	.1086	.12
Avg	.3001	.8478	.8424	.7406	.3151	.7646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 205 / Faradpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0686	.2572				
8	.0514		.2715	.3258		.2896
12					.5249	
16			.4527		.5068	.5365
20					.2715	
21		.1991				
24			.1448	.1543	.12	.1448
Max	.0686	.2572	.4527	.3258	.5249	.5365
Min	.0514	.1991	.1448	.1543	.12	.1448
Avg	.06	.2282	.2897	.2401	.3558	.3236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 206 / Wala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.8059				
8	1.5775		.724	.7373		.6516
12					1.9004	
16			1.5912		1.7372	1.9281
20					.5792	
21		.4887				
24			.3439	.3258	.3086	.3439
Max	1.5775	.8059	1.5912	.7373	1.9004	1.9281
Min	1.5775	.4887	.3439	.3258	.3086	.3439
Avg	1.5775	.6473	.8864	.5316	1.1314	.9745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1715	.1372	.1715	.1029	.1372	.1715
2	.1943	.1715	.1715	.1715	.1029	.1372	.1715
3	.2267	.1715	.2058	.1715	.1029	.1715	.1715
4	.2267	.2058	.2401	.2058	.1372	.2058	.2058
5	.2915	.2572	.2743	.2572	.2058	.2743	.2401
6	.3239	.3429	.3086	.3429	.3086	.3086	.3086
7	.3239	.3772	.3772	.4115	.3772	.3772	.3601
8	.3239	.2743	.3086	.3772		.2743	.2915
9	.2743		.2401	.2241		.2401	
10	.1372	.2915	.2743	.285	.2591	.2439	.2622
11	.1029	.3239	.3048	.285	.2915	.2439	.2949
12	.1029	.3077	.2286	.2984	.2591	.2439	.2785
13	.1029	.3239	.2743	.2818	.2915	.2439	.2949
14	.1029	.3239	.2743	.2818	.2915	.1677	.2785
15		.2915	.3048	.2785	.2915	.1829	.2294
16	.1029	.3239	.3658	.2949	.2591	.2134	.2881
17	.1029	.3563		.2785	.2915	.2439	.2458
18	.1029	.1372		.112	.1715	.1543	.1478
19	.2743	.2401		.112	.2401	.2743	.1867
20	.2058	.2058			.2058	.2401	.2241
21		.1715		.1494	.2058	.2572	.2241
22		.1715		.1867	.1715		.2427
23		.1715			.1715		.2427
24	.1619	.1715	.1372	.1715	.1132	.1372	.1715
Max	.3239	.3772	.3772	.4115	.3772	.3772	.3601
Min	.1029	.1372	.1372	.112	.1029	.1372	.1478
Avg	.1940	.2515	.2604	.2431	.2205	.2260	.2405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 202 / 11 KV BHRAMWADI -Ghavan SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.1543	.1543	.1543	.1543	.1543	.1543
2	.2915	.1543	.1543	.1543	.1372	.1543	.1543
3	.2915	.1543		.1543	.1543	.2058	.1543
4	.3401	.1543	.2058	.1543	.1715	.2058	.2058
5	.4534		.2572	.2058	.1715	.2572	.2572
6	.583	.2572	.3086	.3086	.1715	.3086	.3429
7	.9069	.3086	.3601	.3601	.2058	.3601	.4115
8	1.3117	.3601	.2572	.3086	.2058	.2058	.3601
9	1.2803	.2572	.1543	.1867	.2572	.2058	.2801
10	.1543	.9069	.9145	.6464	.583	.7316	.7459
11	.1029	1.166	1.1431	.9614	.6802	.4572	.7956
12	.1029	1.166	1.1888	.9831	.7287		.6882
13	.1029	1.166	1.0669	1.0159	.7773	.4572	.7209
14	.1029	1.1174	.9145	1.1469	.6316		.7865
15		1.166	.9602	1.1469	.6802	.7316	.7373
16	.1029	1.166	1.0974	1.2289	.7287	.7773	.9717
17	.1029	1.2146		1.1603	.7773	.8688	.9339
18	.1029	.1029		.112	.2058	.1029	.112
19	.2572	.2058		.112	.2572	.2572	.2263
20	.2058	.2058			.2058	.2572	.2829
21		.1543		.2241	.2058	.2572	.3206
22		.1543		.1867	.2058		.2829
23		.1543			.1543		.2263
24	.1943	.1543	.1029	.1543	.1715	.1543	.1543
Max	1.3117	1.2146	1.1888	1.2289	.7773	.8688	.9717
Min	.1029	.1029	.1029	.112	.1372	.1029	.112
Avg	.3617	.5218	.5775	.5030	.3593	.3555	.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3353	.3563	.4725	.3239	.3563	.3658
2	.3086	.381	.421	.4725	.3239	.3887	.381
3	.3429	.381	.5506	.4725	.3563	.421	.4572
4	.3772	.4572	.583	.4877	.4534	.421	.4572
5	.4801	.5335	.6802	.5335	.4858	.4534	.5335
6	.6001	.5792	.7449	.6001	.5668	.5668	.6401
7	.5144	.6097	.7773	.6173	.5668	.6316	.6859
8	.3944	.6706	.7449	.5487	.4049	.6173	.6706
9		.6802	.1981	.6535	.421	.1715	.7865
10	.4268	.3086	.2229	.3361	.2743	.2401	.2987
11	.4877	.1715	.1886	.2241	.1715	.2401	.2241
12	.5487	.1715	.1372	.2241	.1715	.2058	.2263
13	.5487	.1886	.1715	.2241	.1781	.2058	.2241
14	.6097	.2058	.1715	.1867	.1715	.1715	.1867
15		.1715	.2058	.1867	.1715	.1715	.1867
16	.5335	.2058	.1715	.1867	.1715	.2058	.1867
17	.5792	.2058		.2241	.1715	.1886	.1867
18	.3086	.3086		.3018	.2743	.2058	.2427
19		.3944		.2614	.3429	.4458	.4668
20	.3944	.4801			.4458	.4458	.5601
21		.4115		.2801	.3429		.5228
22		.3772		.2241	.3772		.4066
23		.3429			.3086		.3174
24	.3086	.3353	.2915	.4725	.2818	.3239	.3658
Max	.6097	.6802	.7773	.6535	.5668	.6316	.7865
Min	.3086	.1715	.1372	.1867	.1715	.1715	.1867
Avg	.4485	.3711	.3892	.3723	.3232	.3371	.3992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 201 / 11 KV Dighol SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6859	.5144		1.6289	1.7147	1.5432	2.0576
16	1.7147	.3429	.3429		.3429	.3429	
24	.3429	.2572	1.2003	1.0288	.9431	.8573	1.2003
Max	1.7147	.5144	1.2003	1.6289	1.7147	1.5432	2.0576
Min	.3429	.2572	.3429	1.0288	.3429	.3429	1.2003
Avg	.9145	.3715	.7716	1.3289	1.0002	.9145	1.6290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 202 / 11 KV Motegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.286	.3429	.5144		.5144	.5144	.5144
16	.1715	1.2003	1.2003	.9431	.5144	1.0288	
24	1.0288	.2572	.2572	.1715	.1715	.3429	.3429
Max	1.286	1.2003	1.2003	.9431	.5144	1.0288	.5144
Min	.1715	.2572	.2572	.1715	.1715	.3429	.3429
Avg	.8288	.6001	.6573	.5573	.4001	.6287	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154124 / 33/11 KV Bhokaramba S/S

Feeder No / Name : 203 / 11 KV Bhokaramba SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2572	.1715	.7716	.6001	.6001	.6859	.9431
16	.9431	.1715	.1715	.1715	.1715	.0857	.1715
24	.1715	.0857	.4287	.3429	.4287	.4287	.6859
Max	.9431	.1715	.7716	.6001	.6001	.6859	.9431
Min	.1715	.0857	.1715	.1715	.1715	.0857	.1715
Avg	.4573	.1429	.4573	.3715	.4001	.4001	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 203 / 11KV Khanapur(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1576		
2			.6468		.7577	.9425
4			.7023	1.1576	.8316	.9425
6		1.1203	.6838		.8871	1.5154
7		1.8111				
8		2.0538	.499		1.2567	2.0883
9					.112	
10						.168
11		.1867			.112	
12	.2241	.1867				.1494
13	1.9044	.1494	.1867		.1867	
14		.1494				.1494
15	2.0351					
16					.1867	.168
17			.1867			
18			.1867			
19			.2241			
21			.2241			
23			1.0456			
24			.5359		.8871	.8686
Max	2.0351	2.0538	1.0456	1.1576	1.2567	2.0883
Min	.2241	.1494	.1867	1.1576	.112	.1494
Avg	1.3879	.8082	.4656	1.1576	.5797	.7769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.037		
2			.037		.037	
4			.037	.037	.037	.037
6			.037		.037	.037
8			.037		.037	.037
9				.037	.037	
10	.037					.9795
11	.037				1.2197	
12	.037	.6099				1.848
13	.037	.6283	1.4937		1.8111	
14		1.3676				1.9035
15	.037					
16					1.2936	1.8665
17			1.9035			
19			.037			
23			.037			
24			.037		.037	
Max	.037	1.3676	1.9035	.037	1.8111	1.9035
Min	.037	.6099	.037	.037	.037	.037
Avg	.037	.8686	.4062	.037	.5052	.9584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 205 / 11kv Utti w/w express
feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1478
4				.1478
6		.0373		
9				.037
10	.1478			
11	.1848			
12	.1848	.0739		
13	.1848	.1478		
14		.1848		
15	.1848			
17			.2218	
18			.2218	
19			.1478	
21			.1478	
23			.1478	
Max	.1848	.1848	.2218	.1478
Min	.1478	.0373	.1478	.037
Avg	.1774	.1110	.1774	.1109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Karajgaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0739
4				.1109
9				.2033
10	.037			
11	.037			
12	.037	.037		
13	.037	.0739		
14		.037		
15	.037			
17			.037	
18			.0739	
19			.1294	
21			.0924	
23			.1109	
Max	.037	.0739	.1294	.2033
Min	.037	.037	.037	.0739
Avg	.037	.0493	.0887	.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 202 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5274		.4566
2				.7251		.5219
3				.857		.5871
4				.9229		
5						.6523
6						1.109
7			1.6194	.8075	1.331	1.4351
8				.791	1.3635	1.3536
10		.1299			.1623	
11		.1481	.1305			
12		.1317				
13		.1317				
14		.1152				
15		.0823	.0815			
16		.0823				
17		.0991	.0979			
18		.0988	.1142			
23	.1623					
24		.6493	.2915	.2966	.487	.2609
Max	.1623	.6493	1.6194	.9229	1.3635	1.4351
Min	.1623	.0823	.0815	.2966	.1623	.2609
Avg	.1623	.1668	.3892	.7039	.8360	.7971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 203 / 11KV Baranpur Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4625		.2643
2				.4955		.2973
3				.5947		.3304
4				.7268		
5						.3304
6						.6607
7			1.0139	.4295	.6818	.7598
8			1.0218	.5286		.6607
9			.8259	.4625		
10		.2273			.0974	
11		.1648				
13		.1648				
14		.1318				
15		.1318				
16		.1483				
17		.1648	.1669			
18			.2337			
23	.3246					
24		.4545	.338	.3304	.2278	.2313
Max	.3246	.4545	1.0218	.7268	.6818	.7598
Min	.3246	.1318	.1669	.3304	.0974	.2313
Avg	.3246	.1985	.6000	.5038	.3357	.4419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 204 / 11KV Korangala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3941		.296
2				.4927		.3288
3				.5255		.3453
4				.5584		.3617
5						.3946
6						.7234
7			.7868		.7305	.8879
8			.8899			.7728
9			.9229			
10		.1623	.1318		.1907	
11		.1305	.0989			
12		.1142	.0824			
13		.1142	.0659			
14		.0979	.0659			
15		.0979	.0659			
16		.0815	.0659			
17		.1142	.0824			
18		.1305	.0824			
23	.1948					
24		.1623	.3147	.3285	.1299	.2631
Max	.1948	.1623	.9229	.5584	.7305	.8879
Min	.1948	.0815	.0659	.3285	.1299	.2631
Avg	.1948	.1206	.2812	.4598	.3504	.4860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 205 / 11KV utti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6183		.5796
2				.9111		.6762
3				1.0413		.7727
4				1.0738		.8371
5						.8854
6						1.0947
7			1.8623	.423	1.1863	1.4489
8			1.8266	.5207		1.3523
9			1.7613	.4556		
10		.2759	.2609		.2727	
11		.2093	.2446			
12		.161	.2283			
13		.161	.1957			
14		.161	.1794			
15		.161	.1957			
16		.1771	.2283			
17		.1932	.2446			
18		.2254	.2609			
23	.3246					
24		.2597	.4049	.423	.3575	.3542
Max	.3246	.2759	1.8623	1.0738	1.1863	1.4489
Min	.3246	.161	.1794	.423	.2727	.3542
Avg	.3246	.1985	.6072	.6834	.6055	.8890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 206 / 11KV kalmatha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1957		.1623
2			.1957		.1948
3			.2291		.2273
4			.1957		.2597
5					.2922
6					.3246
7		.2833		.1948	.2922
8		.2278			.2597
9		.1952			
10		.6508		.2597	
11		2.0501			
12		1.9524			
13		1.985			
14	1.6442	1.9524			
15	2.0717	1.9524			
16	2.1046	1.985			
17	2.0388	2.0501			
18	1.973	.1302			
24		.1585	.1957	.1627	.1623
Max	2.1046	2.0501	.2291	.2597	.3246
Min	1.6442	.1302	.1957	.1627	.1623
Avg	1.9665	1.1979	.2024	.2057	.2417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4801				.3963	
8						.6097	.6097
9					.1715		
15					.1029		
17	.5487			.1067			
18		.12					
21			.1715				
24		.2401					
Max	.5487	.4801	.1715	.1067	.1715	.6097	.6097
Min	.5487	.12	.1715	.1067	.1029	.3963	.6097
Avg	.5487	.2801	.1715	.1067	.1372	.503	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.2229				.2743	
8						.1372	.2134
9					.1715		
15					.6859		
17	.061			.6706			
18		.0857					
21			.2401				
24		.12					
Max	.061	.2229	.2401	.6706	.6859	.2743	.2134
Min	.061	.0857	.2401	.6706	.1715	.1372	.2134
Avg	.061	.1429	.2401	.6706	.4287	.2058	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 203 / 11KV HASEGAONWADI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.3658	
8					.3201	.3201
17	.6706			.6706		
18		.1543				
21			.2572			
Max	.6706	.1543	.2572	.6706	.3658	.3201
Min	.6706	.1543	.2572	.6706	.3201	.3201
Avg	.6706	.1543	.2572	.6706	.3430	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 201 / 11KV Matola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5089		.7888	.8916	1.0288	1.0288
16		2.1434	2.0919		1.8861	1.3375
24			.3429		.2743	.3429
Max	1.5089	2.1434	2.0919	.8916	1.8861	1.3375
Min	1.5089	2.1434	.3429	.8916	.2743	.3429
Avg	1.5089	2.1434	1.0745	.8916	1.0631	.9031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 205 / Kavli Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1372	.7202	1.1317	.3086	.9259	.9431	.8916
16	.7373	.1372	.1029		.1372	.1372	.0686
24		.6001	.6859			.6859	.5144
Max	.7373	.7202	1.1317	.3086	.9259	.9431	.8916
Min	.1372	.1372	.1029	.3086	.1372	.1372	.0686
Avg	.4373	.4858	.6402	.3086	.5316	.5887	.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 203 / 11 kv Karkhana Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	12-APR-18
HR	Load (MW)
8	.0019
Max	.0019
Min	.0019
Avg	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 205 / Malumbra Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	12-APR-18
HR	Load (MW)
8	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 206 / Davakhana Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-APR-18
HR	Load (MW)
8	.0914
Max	.0914
Min	.0914
Avg	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	1.1203	1.0829	.8589	.9335	1.1203	.8421
2	.2915	1.1203	1.0082	.8962	1.0082	1.1576	.9717
3		1.2136	1.2696	.8962	1.1203	1.1949	1.1012
4	.3239	1.419	1.3443	.7842	1.307	1.419	1.1843
5	.4534	1.8671	1.4003	.8589	1.4937	1.8671	1.2803
6	.5182	2.0538	1.9044	.9709	1.6057	2.1658	1.4723
7	.6154	2.3152	2.0538	1.0456	1.6804	2.3525	1.9044
8	.583	2.3899	2.3899	1.1576	1.8671	2.3899	2.0165
9	.3563	.5281	.4527	.3734	.5601	.5601	.3978
10	1.1336	.3734	.415	.4481	.4481	.3647	.3647
11	1.7924		.3772	.3734	.3361	.2652	.3315
12	2.0538		.2641	.2987	.2241	.2652	.2818
13	2.1658		.3018	.2241	.1867	.2652	.2818
14	2.0538			.1867	.1867		.2652
15	1.9605		.3395	.1867	.1867		.2652
16	2.1472			.2241	.2241	.2652	.2652
17	2.2405	.3772		.2614	.2987	.2984	.2652
18	.3018	.3772	.3018	.2987	.3361	.2984	.3978
19	.6036	.4904	.6036	.4108	.5228	.3315	.6226
20	.679	.5281	.7922	.7095	.6722	.5571	.5304
21		.6036		.5601	.5975	.4752	.4973
22	.4904	.5281		.3734	.4108	.3978	.4144
23	.8299	.8215	.8402	.5601	.7468	.5735	.4973
24	.3239	.9335	.9335	.7842	.7468	.9335	.7373
Max	2.2405	2.3899	2.3899	1.1576	1.8671	2.3899	2.0165
Min	.2915	.3734	.2641	.1867	.1867	.2652	.2652
Avg	1.0095	1.0589	.9513	.5726	.7375	.8872	.7162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.1509	.1509	.1132	.0747	.0754	.0924
2	.3772	.1509	.1509	.1132	.0747	.0754	.0924
3		.1509	.1886	.1132	.112	.0754	.1478
4	.415	.2263	.2263	.1886	.2241	.0754	.2772
5	.5658	.3772	.2641	.2641	.3734	.1886	.3696
6	.9054	.4527	.2641	.3395	.4108	.3018	.499
7	1.0185	.4904	.4904		.3734	.3395	.4066
8	1.0185	.4527	.415		.2987	.3018	.3326
9	.4527	.3018	.3772		.112	.2641	.1663
10	.2641	.415	.4481		.2241	.2957	.2772
11	.1886	.9335	.6722	.2614	.5975	.7499	.7316
12	.1132	.9709	.8962	.8589	.8962	.6516	.823
13	.0754	.8962	.5975	.9335	.8589	.6335	.8048
14	.0754	.7842		.9335	.8589	.6335	.7865
15	.0754	.9335		.8962	.8962	.724	.7499
16	.1132	.8962		.8589	.9709	.6878	.7499
17	.1132	.7842	.6722	.8962	.9335	.6697	.7499
18	.2263	.3395	.1509	.2987	.0934	.1848	.8048
19	.3772	.415	.3772	.3734	.2987	.3326	.3326
20	.415	.415	.4527	.4108	.3734	.3696	.2772
21	.3395	.3584		.2987	.2987	.2772	.2402
22	.2263	.1886	.1509	.1867	.1867	.2218	.1663
23	.1886	.1886	.1509	.112	.0934	.1478	.1294
24	.3395	.1509	.1509	.1509	.1086	.0943	.0924
Max	1.0185	.9709	.8962	.9335	.9709	.7499	.823
Min	.0754	.1509	.1509	.112	.0747	.0754	.0924
Avg	.3592	.4760	.3624	.4301	.4060	.3488	.4208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.399	.3704	.3605	.4518	.365	.3889
2		.4024	.3727	.3521	.4334	.3519	.3889
3		.4399	.412	.3441	.4715	.3522	.4087
4		.5914	.4508	.5243	.5647	.3734	.5975
5		.7468	.5647	.6401	.6387	.5255	.7476
6		.9798	.7175	.7682	.8488	.9035	.9749
7		.8266	.8703	.8322	.9778	1.0007	.9081
8	1.9156	.7218	.8307	.7682	.8282	1.0562	.9063
9	2.263	.5578	.6218	.6882	.6763	.5239	.7514
10	.5981	.7161	1.7664	1.5527	1.5661	.8471	1.5013
11	.3624	1.6964	2.2206	2.1176	2.1424	2.2262	2.4506
12	.2939	2.5115	2.2879	2.0826	2.193	2.2926	2.3371
13	.3015	2.5878	2.2231	2.0765	2.2465	2.2848	2.4089
14	.2643	2.5034	2.4225	2.1474	2.3205	2.2516	2.3179
15	.3009	2.4395	2.6244	2.1879	2.3425	2.2058	2.3371
16	.2829	2.5426	2.7926	2.2325	2.3005	1.9289	2.2716
17	.245	2.5702	1.0883	2.3429	2.3618	2.1678	
18		.4082	.3201	.3982	.3889	.4284	.5688
19	.7407	.6335	.5898	.6413	.6387	.5731	.7453
20	.7008	.5578	.6081		.7153	.6393	.6922
21	.5731	.5196	.5121	.4909	.5975	.5228	.5938
22	.5014	.4057	.426	.5103	.5185	.4399	.4938
23	.4444	.3869		.4706	.4057	.4041	.4185
24		.4298		.3521	.4527	.4045	.3881
Max	2.263	2.5878	2.7926	2.3429	2.3618	2.2926	2.4506
Min	.245	.3869	.3201	.3441	.3889	.3519	.3881
Avg	.6525	1.1073	1.1406	1.0818	1.1284	1.0446	1.1129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 202 / 11 KV Bheta Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8257	.5633	.3226	.3772	.2824	.3423	.3232
2	.3206	.5868	.4298	.3772	.6429	.659	.7115
3	.3018	.631	1.0727	1.2826	.9217	1.0947	1.0254
4	.378	.7145	1.259	1.5972	1.0002	1.2498	1.1888
5	.4531	.7926	1.415	1.369	1.2643	1.5294	1.3748
6	.6432	1.0169	1.5565	1.8253	1.5337	1.704	1.5097
7	.7772	1.3714	1.7449	2.0535	1.7828	1.8415	1.9105
8	.6811	1.2803	1.6118	1.9774	1.714	1.7449	1.8548
9	.4536		1.4932	1.9014	1.5797	1.5916	1.2607
10	.3	.2978	1.8063	.2033	.2824	.2804	.2902
11	.2204		.2472	.1882	.1687	.1513	.1896
12	.1863	.1689	.1521	.1494	.185	.1689	.1875
13	.1492	.1691	.1521	.1884	.1515	.152	.1694
14	.1706	.1506	.1521	.1886	.1701	.1509	.1886
15	.1711	.1504	.1521	.2071	.1699	.1518	.1884
16	.1708	.1497	.1521	.1879	.1684	.1886	.1886
17	.152	.1648		.2259	.1672	.184	
18		.2328	.2263		.1776	.2478	.2254
19	.7468	.4499	.4527	.5653	.526	.4993	.5658
20	.815	.5271	.5281		.5093	.5281	.5292
21	.768	.4321	.4527		.4531	.4706	.4545
22	.7276	.3402	.3772	.3551	.3788	.3953	.378
23	.6687	.3223		.3012	.3416	.3412	.3398
24	.9048	.6382		.3395	.2821	.3419	.3416
Max	.9048	1.3714	1.8063	2.0535	1.7828	1.8415	1.9105
Min	.1492	.1497	.1521	.1494	.1515	.1509	.1694
Avg	.4776	.5069	.7503	.7553	.6189	.6671	.6694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 201 / 11KV Shivali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.1349	1.2803		1.2289	1.4575	1.6004
2	.4001	1.1349	1.2803		1.3108	1.6194	1.6004
3	.4001	1.1349	1.2803		1.3927	1.6289	1.7604
4	.4001	1.3032	1.3603		1.3927	1.7918	1.7604
5	.4801	1.3846	1.6004			1.7918	1.9204
6	.4801	1.7104	1.9204		1.5565	1.9547	2.0805
7	.4801	1.9547	1.9204		2.13	2.2805	2.2405
8	.4801	1.9547	1.9204		2.13	2.1176	2.2405
9	.4001	.4887	.4801		.4801	.4801	.5601
10	.4049	.4801	.4801	.3201	.4025	.4801	.4801
11	.4049			.2401	.4025	.4001	.4858
12	.3239	.3201		.2401	.4025	.4001	.4858
13	.3239	.3201		.2401	.322	.3201	.3239
14	.3239	.3201		.2401	.322	.3201	.3239
15	.3239	.3201		.2401	.322	.3201	.3239
16	.3239			.2401	.322	.3201	.3239
17	1.9433					.3201	.4049
18	2.0362		.3258		.322	.3201	.4049
19	.4858		.4072	.3201	.483	.4001	.4049
20	1.5384	.4801	.4887		.5701	.4801	.4049
21		.4801	.4887		.5701	.4801	.4049
22		.4049	.4072	.3201	.4887	.4001	.3239
23	1.0588	.4001	.4072	.3201	.4072	.4001	.3239
24	1.4746	1.1403	.3201	.3258	.3201	.4049	.4001
Max	2.0362	1.9547	1.9204	.3258	2.13	2.2805	2.2405
Min	.3239	.3201	.3201	.2401	.3201	.3201	.3239
Avg	.7218	.8877	.9628	.2770	.7854	.8704	.8993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6478	.7287		.3201	.3239	.3239
2	.6478	.6478	.6478		.3201	.3239	.3239
3	2.6216	.6478	.6478		.3201	.3239	.3239
4	2.7035	.7287	.6478		.3201	.4049	.4049
5	2.6216	.7287	.8097		.4001	.4049	.4049
6	2.7035	.8097	.9717		.4001	.4858	
7	1.4746	.9717	.9717		.4001	.4858	.4858
8	2.7035	.8907	.8097		.4001	.4049	.4049
9	.3201	2.834	2.915	1.8023	2.0481	2.3482	2.1862
10	.5701	2.834	2.915	1.9662	2.0243	2.4291	2.4291
11	.4887			2.0481	2.4291	2.5911	2.4577
12	.4887	2.4291		2.0481	2.5911	2.672	2.4577
13	.4072	2.4291		2.2939	2.5101	2.672	2.4577
14	.4072	2.4291		2.6216	2.5911	2.672	2.4577
15	.4072	2.5911		2.6216	2.753	2.753	2.4577
16	.4887	2.5911		2.6216	2.753	2.753	2.4577
17	.4887	.5668	.6516	.3201		.2429	.3258
18	.4887		.5701	.2401	.3239	.2429	.3258
19	.4887	.5668	.6516	.2401	.3258	.3239	.3258
20	.733	.8097	.733		.4072	.4049	.3258
21		.8097	.733		.4887	.4049	.3258
22		.8097	.733	.3201	.4072	.3239	.3258
23	.5701	.7287	.6516	.3201	.4072	.3239	.3258
24	.7287	.6478	.7287	.733	.3201	.3258	.3239
Max	2.7035	2.834	2.915	2.6216	2.753	2.753	2.4577
Min	.3201	.5668	.5701	.2401	.3201	.2429	.3239
Avg	1.0545	1.3250	.9732	1.4426	1.0983	1.1101	1.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 203 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.1619	.16		.2401	.1619	.16
2	.16	.1619	.16		.2401	.1619	.16
3	.2401	.1619	.16		.3201	.1619	.16
4	.3201	.2429	.16		.3201	.2429	.2401
5	.3201	.3239	.2401		.4001	.3239	.2401
6	.4001	.3239	.3201		.4801	.3239	.3201
7	.4001	.4049	.3201		.4801	.4049	.3201
8	.4001	.3258	.3201		.4801	.3239	.3201
9	1.8023	.2429	.3201		.2401	.3201	.3201
10	1.6289	.2401	.2401		.2429	.2401	.2401
11	1.8733			.16	.1619	.2401	.2443
12	1.9547	.16			.1619	.2401	.2443
13	1.9547	.16		.16	.081	.16	.2443
14	1.9547	.16		.08	.081	.16	.2443
15	1.9547	.16	.3239	.08	.081	.16	.2443
16	1.9547	.16		.08	.1619	.16	.2443
17	.1619	1.9204	1.9433	1.6385	1.7814	1.7604	1.4661
18	.1619		1.9433	1.9662	2.0362	1.9204	
19	.2429	1.9204	1.9433	1.9662	1.9547	1.9204	
20	.3239	1.7604	1.8623		1.9433	1.7604	
21		1.7604	1.8623		1.8623	1.7604	.2443
22		1.7604	1.7814	1.065	1.7814	1.7604	.2443
23	.1619	1.7604	1.7814	.9831	1.7814	1.7604	.2443
24	.08	.1619	1.7604	1.7918	.9831	1.7814	1.7604
Max	1.9547	1.9204	1.9433	1.9662	2.0362	1.9204	1.7604
Min	.08	.16	.16	.08	.081	.16	.16
Avg	.8423	.6561	.9264	.9064	.7623	.7587	.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 201 / 11KV Gondri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202		1.5851	1.3413		1.5089	1.5394
2	.7716		1.7071			1.576	1.6766
3	.8059		1.829	1.4937		1.7101	1.8595
4	.8573		1.9509	1.5242		1.9784	2.1033
5	.9088		2.0424	1.6766		2.2466	2.1491
6	.9945		2.1033	1.7223		2.5484	2.2862
7	.9602		2.1948	1.8595		2.9508	2.3472
8	.9945		2.1338	1.5242	2.4177	2.7496	2.1338
9	.7922		.2896	.9145	2.6578	.8299	.6706
10	1.4842	.9389	.6097	.6706	2.4006	.6413	.2439
11	2.0119		.4877	.583	.547	.5335	.2401
12	2.3137		.4572	.5316	.4904	.5182	.1886
13	2.1963	1.3413	.4268	.463	.4715	.4572	.3429
14	2.0119	.4877	.5182	.4287	.4904		.4115
15		.5487	.6097	.4801	.4715		.5316
16	1.7772	.6097	.5792	.3429	.4715	.5335	.583
17	2.2801	.6706	.5487	.4115	.4338	.5182	.5144
18	.6036	.7316	.6097	.5487	.547	.4877	.6173
19	.9808	.4268	.6706	.8745	.8865	.5487	.7716
20		.5487		.9945	1.1128	.5792	.9945
21		.7316		.9431	1.094	.6097	.9431
22		.8688	.6401	.8573	1.0374	.5335	.823
23		.9145	1.0517	1.0802	1.4373	1.2803	1.0802
24	.6859		1.4022	1.2193		1.4754	1.5242
Max	2.3137	1.3413	2.1948	1.8595	2.6578	2.9508	2.3472
Min	.6036	.4268	.2896	.3429	.4338	.4572	.1886
Avg	1.2711	.7349	1.1113	.9776	1.0605	1.2189	1.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 202 / 11KV Dhanora SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	.4715	.4877			.5658	.4268
2		.4527	.5182			.5658	.3963
3		.5093	.5487			.6224	.4572
4		.5658	.5792			.6602	.4877
5		.679				.7356	.5182
6		.7545	.4877			.7733	.5487
7		.6979	.4572			.811	.5792
8		.6224	.3963			.7167	.5487
9		.5093	.3658			.5093	.4268
10	.8299	1.1218	.7316		1.0802		1.5242
11	.3395	1.0974	2.1338		1.2742	1.2803	2.332
12	.3206	1.2651	2.1033	.2058	1.358	1.5242	2.4691
13	.3018	1.3717	2.21	1.286		1.7985	2.3491
14	.2829	1.6766	2.2558	1.5089	.8718	1.829	2.1091
15		1.7985	2.1643	1.6118	.9221	1.9052	2.0062
16	.2829	1.9814	1.9662	1.8347		1.9509	2.452
17	.3018	2.0424	1.9966	1.9033	1.6263	2.0271	2.5892
18	.3206	.3658	.2439	.3086	.3395	.2439	.4287
19		.4877	.2591	.463	.4904	.2743	.5487
20	.7545	.5182			.8299	.3353	.6687
21	.7733	.5487	.2896		.811	.3963	.5487
22	.6224	.5182	.2743	.6516	.679	.4268	.4801
23	.547	.4877			.6036	.4877	.4287
24	1.2346	.5093	.5182			.5847	.5182
Max	1.4232	2.0424	2.2558	1.9033	1.6263	2.0271	2.5892
Min	.2829	.3658	.2439	.2058	.3395	.2439	.3963
Avg	.5954	.8772	.9994	1.0860	.9072	.9141	1.0768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1886	.2075		.2452	.2075	.2641
2	.2829	.1886	.2075	.2829	.2641	.2075	.2641
3	.2829	.1886	.2075	.2641	.2263	.2263	.2641
4	.2641	.2075	.1886	.2641	.2452	.2263	.2641
5	.2641	.2075	.1886	.1886	.2452	.2263	.2829
6	.2829	.2452	.1886	.2263	.2263	.2452	.2829
7	.2829	.2452	.2075	.2641	.2263	.2263	.2829
8	.2829	.2263	.2075	.2641	.2263	.2452	.2641
9	.2075	.2075	.2263	.2641	.2829	.2452	.2452
10	.3584	.3395	.3395	.2641	.3772	.3395	.3772
11	.3772	.3961	.3395	.3584	.4338	.4338	.415
12	.3395	.3206	.415		.415	.415	.4338
13	.3584	.3018	.3018	.2829	.415	.3772	.3395
14	.3206	.3395	.3584	.3395	.3772	.3961	.3584
15		.3772	.3772	.3772	.4338	.415	.3961
16	.3772	.3772	.3772	.4527	.415	.415	.3961
17	.3772		.3772	.4527	.415	.415	.415
18	.3772	.3961	.3772	.3395	.4338	.415	.3584
19	.2829	.3961	.3584	.3584	.3772	.3584	.3584
20	.2263	.3395	.3395	.3206	.3772	.3584	.3018
21	.1886	.2829	.3018	.2452	.3018	.3395	.2641
22		.2452	.2641	.2452	.2263	.3206	.2452
23	.2641	.2263	.2829	.2452	.2263	.3206	.2452
24	.2641	.2075	.2263	.2829	.2452	.2263	.2829
Max	.3772	.3961	.415	.4527	.4338	.4338	.4338
Min	.1886	.1886	.1886	.1886	.2263	.2075	.2452
Avg	.2975	.2805	.2861	.2992	.3191	.3167	.3167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.6805	.6733	.7619	.6984	.788	.7973
2	.7164	.7164	.6733	.7442	.7164	.788	.7796
3	.7522	.7343	.7087	.7442	.7164	.8059	.7973
4	.7522	.7343	.7265	.7619	.7343	.8059	.7973
5	.788	.7522	.7442	.7619	.7164	.8059	.8859
6	.8417	.8417	.8328	.7619	.8059	.9313	.9214
7	.8596	.9671	.9745	.8505	.8954	1.0745	.9745
8	.7701	.9134	1.0631	.9036	.9313	1.0745	.9745
9	.9391	.8682	.9036	.8505	.8596	.9745	.9745
10	.9134	.8505	.8859	.9134	.7265	.9391	.8859
11	.9492	.815	.815	.788	.7973	.9214	.9036
12		.8505	.9391	.9313	.815	.9214	.9391
13	.9922	.8859	.9568	.9492	.8596	.9391	.9568
14	1.0099	.8505	.9745	.8775	.7522	.9036	.9036
15		.8328	.9745	.8775	.9134	.8859	.9214
16	.8505	.9214	.9214	.8596	.9671	.9036	1.0374
17	.8328	.9568	.9568	.8417	.9671	.9214	.8859
18	.8954	.9745	.9568	.9671	.9214	.9391	1.0277
19	.8596	.9922	1.1517	1.0029	1.1694	1.0631	1.0277
20		1.0277	1.0985	1.0745	1.134	1.0985	1.0277
21	.9922	1.0099	1.0099	.9134	1.0808	1.0985	1.0454
22	.9412	.8859	.9391	.8596	.9922	.9922	1.0631
23	.815	.8505	.8859	.788	.9134	.9214	.9745
24	.7701	.691	.7619	.7973	.7343	.8417	.8505
Max	1.0099	1.0277	1.1517	1.0745	1.1694	1.0985	1.0631
Min	.7164	.6805	.6733	.7442	.6984	.788	.7796
Avg	.8551	.8585	.8970	.8576	.8674	.9308	.9314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.8048	.7964	.8869	.8048	.9328	.9231
2	.823	.7865	.7783	.8688	.8048	.9145	.905
3	.8413	.8048	.7783	.8507	.8413	.9145	.905
4	.823	.823	.7964	.8688	.8048	.9328	.9231
5	1.0242	.8596	.8145	.8688	.823	.9511	.9412
6	1.0242	1.0425	.905	.9412	.9877	1.1157	.9955
7	1.0608	1.1706	.9412	.9774	1.0974	1.2071	1.1403
8	1.0974	1.0425	.9955	1.0166	1.0242	1.1157	1.086
9	1.0242	.9231	.9231	.8869	1.0059	1.0498	1.0317
10	.8596	.8507	.905	.9328	.9412	.9774	1.0136
11	1.0059	.8688	.8688	.9145	.905	.9774	1.0136
12		.905	.9774	1.0425	.8688	.9593	1.1222
13	1.0317	.9593	1.0317	1.0974	.9877	.9231	1.0317
14	.9955	.9231	1.0498	1.0059	.9877	.9231	1.0498
15		.9231	1.0317	1.0974	1.0608	.9231	.9955
16	.9955	.9412	1.0136	1.0791	.9511	.9231	1.0317
17	.9412	.9412	.9774	1.0242	.9877	.9412	1.0136
18	1.0791	.9955	1.086	1.0425	.8869	.9412	1.0317
19		1.1222	1.3213	1.262	1.2851	1.1222	1.1403
20		1.1765	1.267	1.2254	1.2489	1.2489	1.1765
21	1.1584	1.1222	1.1584	1.0791	1.2127	1.2489	1.1946
22	1.0498	.9955	1.0679	1.0059	1.1403	1.1403	1.1222
23	.9412	.9412	.9955	.9145	1.0974	1.086	1.086
24	.7499	.8688	.8326	.9231	.8596	1.0059	.9955
Max	1.1584	1.1765	1.3213	1.262	1.2851	1.2489	1.1946
Min	.7499	.7865	.7783	.8507	.8048	.9145	.905
Avg	.9647	.9497	.9714	.9922	.9840	1.0198	1.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 201 / 11 kv Killari Gaothan

GAOTHAN FEEDER

feeder Feeder KV- 11 /
OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6173	.8573	.7202	.6344	.7716	.6516
2	.823	.6516	.9431	.823	.6173	.823	.7202
3	.9945	.823	.9945	.8916	.6859	.8573	.7888
4	1.0974	1.1488	1.1145	1.0288	.9259	.9431	.9774
5	1.286	1.2174	1.166	1.0974	1.0802	1.0802	1.0974
8			1.648				
10	1.2174	1.046	.7716		1.1145	.8573	1.166
11	1.1488	.9088	.7373		.9431	.9602	1.0974
12	.9259	.8573	.7202	1.0631	.8916	.8745	.8573
13	.7545	.823	.703	.8745	.823	.7545	.823
14	.6516	.7716	.6687	.8059	.7716	.703	.8573
15	.6516	.823	.6516	.7545	.7888	.6687	.8916
16	.6344	.8916	1.2936	.7373	.823	.6516	.9431
17	.6859	.9431	.9661	.6859	.7888	.6344	.8916
18	.7202	.9088	1.5956		.8573	.7202	.8573
19	.9774	.9945	.9602	.9259	.9945	.9945	.9431
20	1.0974	1.0288	1.3375	1.0974	1.0288	1.0974	1.0288
21	.9431	.9431	1.0974	1.046	.9431	1.0288	1.0631
22	.6859	.8573	.9259	.8745	.8573	.9088	.9431
23	.6859	.8916	.8059	.6859	.823	.7545	.8573
24	.6859	.6687	.823	.6859	.6687	.7545	.6687
Max	1.286	1.2174	1.648	1.0974	1.1145	1.0974	1.166
Min	.6344	.6173	.6516	.6859	.6173	.6344	.6516
Avg	.8711	.8908	.9896	.8705	.8530	.8419	.9062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.4973	.6859	.4287	.3258	.6001	.6001
2	.823	.4801	.823	.5144	.4458	.6859	.6344
3	.8573	.4973	.8573	.583	.5144	.7716	.6687
4	.9259	.4973	1.1145	.6687	.583	1.1145	.703
5	.9431	.5316	1.166	.7888	.6173	1.166	.7373
6	.663	.583	1.406	.8573	.6687	1.1145	.7716
7	1.0974	.823	1.286		.8059	1.286	1.0117
8	1.1488	.9431	1.2689		.9602	1.2003	1.0974
9	.4287	.3944	.4458		.3601	.583	.9602
10	.12	.4973	.583		.4458	.6516	.463
11		.5144	.6173		.6516	.703	.6001
12		.6001	.6344		.6859	.7545	.7545
13		.6859			.6001	.823	.6859
14		.7202			.6516		.5658
15	.0171	.9945	1.0974	.2229	.8573	.823	.6859
16	.0171	.9088	.9945	.2572	.9945	.8573	.9602
17	1.2689	.1715	.1715	.2401	.1715		
18	1.1488	.2572	.2229	.5487	.2058	.0171	.2572
19	1.0974	.3772	.3258	.6516	.3086	.3601	.3429
20		.4287	.5144	.7888	.3429	.3772	.4287
21		.4801	.4115	.7545	.3601	.4115	.5144
22	.5658	.4115		.3258	.3429	.3429	.3429
23	.5487	.3429	.2401	.2743	.3086	.2915	.3086
24	.9431	.5144	.2572	.2572	.2572	.2743	.2401
Max	1.2689	.9945	1.406	.8573	.9945	1.286	1.0974
Min	.0171	.1715	.1715	.2229	.1715	.0171	.2401
Avg	.7446	.5480	.7202	.5101	.5194	.6913	.6232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 206 / 11 KV FACTORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0171	.0171	.0171	.0171
2	.0171	.0343	.0343	.0171	.0171	.0171	.0171
3	.0171	.0343	.0343	.0171	.0171	.0171	.0171
4	.0171	.0343	.0343	.0171	.0171	.0171	.0171
5	.0171	.0343	.0343	.0171	.0171	.0171	.0171
6	.0343	.0343	.0343	.0171	.0171	.0171	.0171
7	.0343	.0343	.0343	.0171	.0171	.0171	.0343
8	.0343	.0343	.0343		.0171	.0171	.0171
9	.0343	.0343	.0343		.0171	.0171	.0171
10	.0343	.0343	.0343		.0171	.0171	.0171
11	.0343	.0343	.0343		.0171	.0171	.0171
12	.0343	.0343	.0343	.0171	.0171	.0171	.0171
13	.0343	.0343	.0343	.0171	.0171	.0171	.0171
14	.0343	.0343	.0343	.0171		.0171	.0171
15	.0343	.0343	.0343	.0343	.0171	.0171	.0171
16	.0343	.0343	.0343	.0343	.0171	.0171	.0171
17	.0343	.0343	.0343	.0171	.0171	.0171	.0171
18	.0343	.0343	.0343	.0171	.0171	.0171	.0171
19	.0343	.0343	.0343	.0171	.0171	.0171	.0171
20		.0343	.0171	.0171	.0171	.0171	.0171
21		.0343	.0171	.0171	.0171	.0171	.0171
22	.0343	.0343	.0171	.0171	.0171	.0171	.0171
23	.0343	.0343	.0171	.0171	.0171	.0171	.0171
24	.0343	.0343	.0343	.0171	.0171	.0171	.0171
Max	.0343	.0343	.0343	.0343	.0171	.0171	.0343
Min	.0171	.0343	.0171	.0171	.0171	.0171	.0171
Avg	.0304	.0343	.0314	.0188	.0171	.0171	.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 201 / 11 KV Jawali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	13-APR-18
HR	Load (MW)
10	.3391
Max	.3391
Min	.3391
Avg	.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 206 / 11 KV Chalburga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-18
HR	Load (MW)
8	.7122
9	.6554
Max	.7122
Min	.6554
Avg	.6838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 201 / 11 KV Tambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.2858	.5293	.4411	.6668	.5293	
2	.4763	.2858	.5293	.4411	.6668	.5293	
3	.4763	.2858	.5293	.4411	.7621	.5293	
4		.2858	.5293	.5293	.9526	.5293	
5		.2858	.6175	.5293	.9526	.6175	
6	.4763	.2858	.8821	.5293	1.1431	.8821	
7			1.235		1.1431	1.3232	
8			.8821		1.1431	1.4114	
9			1.0585		1.2384	1.3336	
10	.381	.8716		.7057			
11	.6668	.8716		.5293			
12	1.1431	.8716		.6175			
13	1.2384						
14	1.3336						.7057
15	1.5242						.7057
16	1.5242		.3429	.381		.381	.7057
17	1.3336	.3487	.3429	.381	.3528	.4763	
18	1.2384		.381	.4763	.4411		
19	.4763	.4411	.4287	.4763	.3528		.5293
20	.4763	.4411	.4763	.4763	.4411		.5293
21	.4763		.4763	.5716	.4411		.5716
22	.2858	.4411	.4763	.5716	.4411		.5716
23	.2858	.4411	.4411	.4763	.4411		.4763
24	.4763		.5293	.3528	.5716	.5293	
Max	1.5242	.8716	1.235	.7057	1.2384	1.4114	.7057
Min	.2858	.2858	.3429	.3528	.3528	.381	.4763
Avg	.7771	.4602	.5937	.4959	.7148	.7560	.5994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.1905	.1562	.1562	.1905	.1562	
2	.381	.1905	.1562	.1562	.1905	.1562	
3	.381	.1905	.1562	.1562	.1905	.1562	
4	.381						
5	.4763						
6	.5716						
7	.6668						
8	.7621						
9	.7621						
10		.0788	.0781	.0781	.0953	.0953	.0781
11		.0788	.3906	.1562	.1905	.1905	.0781
12		.6302	.4687	.2343	.5716	.5716	.0781
13		.6302	.4687	.3125	.5716	.5716	.1562
14		.5515	.5144	.3125	.5716	.5716	.1562
15		.5515	.5144	.3125	.5716	.5716	.1562
16	.0953	.6302	.4287	.381	.5716	.6668	.1562
17	.0953	.6302	.6859	.381	.4687	.6668	.1562
18	.0953	.5515	.6859	.4763	.4687		.1562
19	.1905	.1562	.1905	.0953	.1764		.1562
20	.1905	.1562	.1905	.0953	.1562		.1562
21	.1905		.1905	.1905	.1562		.1905
22	.1905	.1562	.1905	.1905	.1562		.1905
23	.1905	.1562	.1562	.1905	.1562		.0953
24	.381	.1905	.1562	.1562	.1905	.1562	
Max	.7621	.6302	.6859	.4763	.5716	.6668	.1905
Min	.0953	.0788	.0781	.0781	.0953	.0953	.0781
Avg	.3546	.3365	.3210	.2240	.3136	.3776	.1400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.6744	.5901	.6668	.6744	.5716
2	.5716	.6668	.7587	.5901	.7621	.6744	.5716
3	.5716	.7621	.8431	.5901	.7621	.7587	.6668
4	.6668						
5	.6668						
6	.9526						
7	.9526						
8	.9526						
9	.9526						
10		.3372		.7587	.4763	.381	.3372
11		.5058		.4215	.4763	.5716	.3372
12		.8431	.8431	.4215	.6668	1.1431	.4215
13		.5058	.8431	.5058	.7621	1.1431	.6744
14		1.096	.7716	.5058	.5716	.9526	.6744
15		1.1403	.7716	.5901	.6668	.9526	.3372
16	.381	1.1403	.7716	.6668	.6668	.8573	.4215
17	.4763	.733	.7716	.7621	.5901	.8573	.6744
18	.5716	.7587	.7716	.7621	.6744		.5901
19	.6668	.7587	.6668	.4763	.7587		.8431
20	.7621	.8431	.9526	.7621	.9274		1.0117
21	.7621		.9526	.7621	.8431		.9526
22	.7621	.7587	.8573	.7621			.7621
23	.5716	.7587	.6744	.6668	.6744		.6668
24	.5716		.6744	.5058	.6668	.6744	
Max	.9526	1.1403	.9526	.7621	.9274	1.1431	1.0117
Min	.381	.3372	.6668	.4215	.4763	.381	.3372
Avg	.688	.7612	.7874	.6167	.6831	.8034	.6185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 204 / express feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0937	.0938	.0953	.0938	.0953
2	.0953	.0953	.0938	.0938	.0953	.0938	.0953
3	.0953	.0953	.0938	.0938	.0953	.0938	.0953
4	.0953	.0953	.0938	.0938	.0953	.0938	.0953
5	.0953	.0953	.0938	.0938	.9717	.0938	.0953
6	.1905	.1875	.0938	.0938	.0953	.0938	.0953
7	.381	.4687	.2815	.1877	.4763	.4692	.2815
8	.381	.4687	.1877	.3753	.4763	.4692	.2815
9	.381	.5624	.2815	.4692	.4763	.4763	.563
10	.381	.5624	.2815	.4692	.4763	.4763	.563
11	.381	.5624	.4692	.4692	.381	.4763	.0938
12	.5716	.5624	.4692	.3753	.4763	.5716	.0938
13	.5716	.5624	.4692	.4692	.4763	.5716	.4692
14	.5716	.5624	.4287	.4692	.4763	.5716	.4692
15	.4763	.5624	.4287	.4692	.4763	.5716	.4692
16	.4763	.5624	.4287	.4763	.4763	.5716	.4692
17	.381	.3749	.4287	.4763	.4692	.5716	.4692
18	.1905	.0937	.3429	.4763	.1877		.0938
19	.0953	.0937	.0953	.0953	.0938		.0938
20	.0953	.0937	.9717	.0953	.0938		.0938
21	.0953		.0953	.0953	.0938		.0953
22	.0953	.0938	.0953	.0953	.0938		.0953
23	.0953	.0938	.0938	.0953	.0938		.0953
24	.0953	.0953	.0938	.0938	.0953	.0938	
Max	.5716	.5624	.9717	.4763	.9717	.5716	.563
Min	.0953	.0937	.0937	.0938	.0938	.0938	.0938
Avg	.2659	.3061	.2711	.2631	.3057	.3585	.2331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7506	.6592	.7416	1.1157	1.126
2			.9008	.8075	.8526	1.3016	1.126
3			1.0321	.9064	.9179	1.562	1.3136
4			1.126	.9888	1.0231	1.562	1.689
5			1.201	1.0712	1.1563	1.8595	.9383
6			1.3512		1.3352	2.0454	2.0643
7			1.6514		1.6337	2.0826	2.2519
8			1.5951		1.5857	2.0454	2.2519
9				1.1206	1.5491	1.8595	2.2519
10	.4649						
11	.7438						
12	1.562						
13	1.4876						
14	1.4876						
15	1.4876						
16	1.3946			.2966	.2975	.3753	.4433
17	1.4132		.6592	.4944	.3719	.4692	.4944
18	1.4876	.9758	.2966	.648	.5578	.6756	.6592
19			.857	1.1206	1.0413	.9008	.9335
20	.9297	1.2198		.9558	1.1157	1.126	.9064
21			.791	.9064	1.0413	1.0321	.9383
22		.9008	.7416	.824	.9669	.9383	.7285
23		.8445	.6592	.751	.9297	.8257	.6922
24		.7506	.7251	.6828	1.0413	.9383	.9888
Max	1.562	1.2198	1.6514	1.1206	1.6337	2.0826	2.2519
Min	.4649	.7506	.2966	.2966	.2975	.3753	.4433
Avg	1.2459	.9383	.9559	.8156	1.0088	1.2619	1.2110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 202 / 11 KV Kinnithot SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2627			.3719	.3003
2			.2627			.4091	.3378
3			.3003			.3719	.3753
6	.3719						
7	.5207						
9	.5207						
10		.1126	.341			.1859	.1877
11			.563		.2975	.4504	.4614
12		.5255	.6381		.6694	.6756	.5933
13			.6821		.6508	.7506	.6262
14		.6756	.7162	.0989	.6508	.6568	.6592
15			.6821	.4285	.6528	.4692	.7268
16		.7882	.7506	.4614	.6508	.5255	.648
17	.1488		.4944	.6821	.7438	.6005	.6821
18	.1859	.6756	.5933	.6592	.7438	.4504	.7162
19			.2637	.3296	.3347	.2252	.2339
20	.2231	.4129	.3626	.3626	.3719	.3753	.2966
21	.2975		.3296		.4091	.4129	.3418
22		.3378			.3719	.3753	.3266
23		.3003			.3347	.3753	.3296
24		.3003			.3347	.3378	.2728
Max	.5207	.7882	.7506	.6821	.7438	.7506	.7268
Min	.1488	.1126	.2627	.0989	.2975	.1859	.1877
Avg	.3241	.4588	.4828	.4318	.5155	.4455	.4509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0744	.0375	.0494	.033	.0558	.0375
2		.0744	.0375	.033	.0334	.0744	.0375
3		.0744	.0751	.0659	.0496	.0558	.0751
9	.1859						
10		.0375	.0989		.0372	.0372	.0375
11			.1318		.093	.0938	.0989
12		.1501	.1648		.1859	.1126	.0989
13			.1705	.1318	.2231	.1501	.1318
14		.1877	.1978	.1705	.2231	.1501	.1648
15			.2046	.1648	.1859	.1126	.2252
16	.093	.2252	.1978	.1648	.1859	.1501	.2252
17			.1648	.1648	.2231	.1689	.1629
18		.1501	.1648	.1978	.2603	.1126	.1705
19			.1501	.1318	.0372	.0375	.0938
20		.0751	.1705	.0989		.0375	.091
21	.0744		.1978	.0659		.0375	.0682
22		.0751	.1648	.0494	.0744	.0375	.0563
23	.056	.0375	.1631	.0494		.0375	.033
24	.0558	.0375	.1648	.033	.1116	.0375	.0341
Max	.1859	.2252	.2046	.1978	.2603	.1689	.2252
Min	.0558	.0375	.0375	.033	.033	.0372	.033
Avg	.0930	.0999	.1476	.1047	.1304	.0833	.1023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1658	.2286	.1524
2	.1524	.2286	.1524	.2286	.1638	.2286	.1524
3	.1524	.2286	.2286	.2286	.1658	.2286	.2286
4		.3048	.2286	.3048	.1658	.3048	.2286
5		.3048	.3048	.3048	.1989	.3048	.3048
6		.2286	.3048	.3048	.1989	.3048	.3048
7		.2286	.3048		.1989		.1524
8		.1524	.3048		.1966		.1524
9	.6097	.1524	.2286		.1638		.1524
10	.7621	.1524	.2286		.1638	.0762	.1524
11	.7621						
12	.9145						
13	.9145						
14	.8383						
15	.7621						
16	.7621						
17		.9145	.3048	.5487	.8383	.6097	.6097
18	.2286	.9145	.4572	.5487	.9145	.6859	.7621
19	.1524	.9145	.5335	.5487	.9145	.6859	.7621
20		.9145	.6859	.4877	.9145	.7621	.7621
21		.7621	.7621	.4877	.7621	.8383	.7621
22		.7621	.8383	.4572	.7621	.6097	.5335
23	.1524	.6859	.7621	.4268	.6859	.4572	.4572
24	.1524	.0762	.6859	.7621	.4268	.6097	.4572
Max	.9145	.9145	.8383	.7621	.9145	.8383	.7621
Min	.1524	.0762	.1524	.1524	.1638	.0762	.1524
Avg	.4979	.4488	.4149	.4137	.4445	.4623	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.4572		.2591	.3048	.2286
2	.1524		.4572		.2591	.3048	.3048
3	.1524		.5335		.2915	.3048	.3048
4	.1219		.5335		.3239	.381	.381
5	.1219		.6097		.3563	.381	.381
6	.1524		.6097		.4534	.4572	.4572
7	.1524		.6097		.4858	.4572	.2286
8	.0762		.6097		.4534	.381	.2286
9	.0762						
10	.0762						
15		.0762			.0762	.0762	.0762
16		.0762				.0762	.0762
17	.4572	.1524		.3048	.0762	.1524	.0762
18	.5335	.1524		.1311	.1524	.1524	.1524
19	.5335	.3048		.2294	.2286	.2286	.2286
20		.3048		.1966	.2286	.2286	.3048
21		.2286		.2195	.2286	.1524	.3048
22		.1524		.1966	.1524	.0762	.1524
23		.1524		.1638	.0762	.0762	.0762
24	.381		.0762		.1638	.0762	.0762
Max	.5335	.3048	.6097	.3048	.4858	.4572	.4572
Min	.0762	.0762	.0762	.1311	.0762	.0762	.0762
Avg	.2188	.1778	.4996	.2060	.2509	.2371	.2244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1524	.1524	.0762	.1715	.1524	.1524
2	.3048	.1524	.1524	.1524	.1715	.1524	.1524
3	.381	.2286	.2286	.1524	.1715	.2286	.2286
4	.381						
5	.4572						
6	.4572						
7	.4572						
8	.5335						
9		.5335	.4572		.4572	.4572	.1524
10		.6097	.4572		.5182	.4572	.1524
11		.6859	.5335		.381	.5335	.2286
12		.6859	.5335		.2286	.5335	.2286
13		.6097	.6097		.2286	.4572	.2286
14		.6097	.6097			.4572	.2286
15	.0762	.6859	.6859	.3048	.381	.6097	.2286
16	.1524	.6859	.6859	.381	.381	.6097	.2286
17	.1524						
18	.2286	.0762	.0762	.3277	.0762	.0762	.1524
19	.3048	.3048	.0762	.3605	.3048	.1524	.3048
20		.3048	.1524	.3277	.3048	.1524	.3048
21		.2286	.2286	.2949	.2286	.2286	.3048
22		.1524	.3048	.2622	.1524	.2286	.1524
23	.1524	.0762	.1067	.1966	.0762	.0762	.0762
24	.0762	.0762	.0762	.0914	.1966	.0762	.0762
Max	.5335	.6859	.6859	.381	.5182	.6097	.3048
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.2946	.3810	.3404	.2440	.2606	.3133	.1990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629						
2	.2629			.2543			
3	.2543					.2343	
4	.2515						
5	.3353		.3315	.3353	.3239	.3125	
12	.1943				.3125	.3906	
13			.4191				
14			.4144			.5468	.3978
15		.192			.3906		
16	.3887		.4973	.3239			
17				.3887		.6249	
18					.5468		
20			.3391			.3125	
21					.3125		
22			.2543				
23		.2652					
24	.3506			.2543	.1562		
Max	.3887	.2652	.4973	.3887	.5468	.6249	.3978
Min	.1943	.192	.2543	.2543	.1562	.2343	.3978
Avg	.2876	.2286	.3760	.3113	.3404	.4036	.3978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144						
2	.5087			.503			
3	.503					.4687	.7811
5				.503			
7		.8097	1.2146		1.2803	1.5623	1.1717
8				.663		1.406	
12	1.0402						
14							.2515
15		.1619			.2343	.2458	
16	.9488		.2543	.5801			
17				.3315		.2458	
18			.3353		.3277		
19			.503				
20			.4973				
21					.4096		
22			.5087			.3277	
23	.4858	.2486					
24	.5087	.4144		.503	.3906	.5468	
Max	1.0402	.8097	1.2146	.663	1.2803	1.5623	1.1717
Min	.4858	.1619	.2543	.3315	.2343	.2458	.2515
Avg	.6442	.4087	.5522	.5139	.5285	.6862	.7348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 206 / 11 KV DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9326						
2	.9221			.6783			.7373
3	.9326		.8383	.6783	.8383	.7373	
5	1.4251						
7	2.5149	.8288					
8	2.652						
10					.6249	.5468	
11			.9945				
12			1.0898				
13			1.1603			1.0155	
14			1.1603		.8592		1.2146
15		.9116				1.0936	
16	.3315		1.1603	.7287			
17				.7459	.9374	.9374	
18			.503				
19			.8192				
20			.9116		.4096		
22			.6783			.6554	
23		.6706					
24	.8288			.6783	.6554	.6554	
Max	2.652	.9116	1.1603	.7459	.9374	1.0936	1.2146
Min	.3315	.6706	.503	.6783	.4096	.5468	.7373
Avg	1.3175	.8037	.9316	.7019	.7208	.8059	.9760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6908				
2	1.086		.6535	.7468		.6335	
3			.7095	.8215			
4	1.6651		.8215	.823	.6859	.724	.7545
5			.9709	.9335			
6			.9709	1.0829	.8916	1.1403	
7			.9709				
8	2.0576					.7716	
9	.5144		1.6804			1.2174	
10	1.8099	.9709	1.7924		.7888	1.286	1.1488
11			1.9044			1.0974	
12	.2915		1.307				1.4746
13		1.307	1.587			1.0288	
14	.2572	1.531	1.587			1.0288	
15		1.4937	1.643			1.0117	
16	.2229	1.587	1.6057	.9259		1.0631	1.4403
17		.2241					
18			.2614	.9431			
19			.6161				.6173
20			1.0082	.8916		.7545	
21			.8402				
22			.9335				
23	.3429		.7842	.6859		.6859	.5487
24	.362		.6722	.7468	.6173	.5792	
Max	2.0576	1.587	1.9044	1.0829	.8916	1.286	1.4746
Min	.2229	.2241	.2614	.6859	.6173	.5792	.5487
Avg	.8610	1.1856	1.0914	.8601	.7459	.9302	.9974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 201 / 11 KV PANCHINCHOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
1		.3258
6		.7186
9	.5658	
10		.5487
12	.3429	
16	.2743	.2683
18	1.2136	
20	1.0059	1.2346
23	.9448	
Max	1.2136	1.2346
Min	.2743	.2683
Avg	.7246	.6192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 202 / 11 KV TUPADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
1	1.1022	1.2431
3	1.4918	
6	2.5149	2.8673
8	2.4863	
10	.0857	.0848
11	.1029	
14	.0867	
16	.0857	.1006
20	.1214	.12
23	.1214	
Max	2.5149	2.8673
Min	.0857	.0848
Avg	.8199	.8832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
1	.3429	
3	.3772	.3429
6	.6415	.3641
8	.4973	
10	1.0802	1.0923
11	1.0898	.3121
14	1.0395	
16	1.0802	1.073
18	.3429	
20	.3988	.583
23	.3988	1.073
Max	1.0898	1.0923
Min	.3429	.3121
Avg	.6626	.6915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FDR Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0103			.0137	.012
2	.011				.011		
3						.0171	
4	.011		.0121	.0117	.0128	.0165	
6	.011				.011	.0154	.0121
7	.0127	.0127	.0121		.0128	.0163	
8				.0117			
9	.2027						
10		.2795				.0156	.2011
11	.2158			.2268		.1179	
12		.2255			.197		
13				.0476			
14		.0137				.0139	
15					.1875		
16		.2401	.2263	.0398			.1835
18		.012			.0217	.0086	
19				.0128			
20							.0343
21				.0128	.0183		
22		.012					
23		.0121		.0128		.0104	
24	.0128	.0111		.0123	.0128	.017	
Max	.2158	.2795	.2263	.2268	.197	.1179	.2011
Min	.011	.0111	.0103	.0117	.011	.0086	.012
Avg	.0681	.0910	.0652	.0431	.0539	.0239	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	1.5421	1.2146	1.1323	1.291
Max	1.5421	1.2146	1.1323	1.291
Min	1.5421	1.2146	1.1323	1.291
Avg	1.5421	1.2146	1.1323	1.291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			2.0359	1.0789	1.9938	1.9028
16	1.3649	1.1029				
Max	1.3649	1.1029	2.0359	1.0789	1.9938	1.9028
Min	1.3649	1.1029	2.0359	1.0789	1.9938	1.9028
Avg	1.3649	1.1029	2.0359	1.0789	1.9938	1.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 201 / 11 KV AURAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.543			.7468	
16		.0943	.4525	.0924		.0943
24	.0754			.3734	.3696	.3696
Max	.0754	.543	.4525	.3734	.7468	.3696
Min	.0754	.0943	.4525	.0924	.3696	.0943
Avg	.0754	.3187	.4525	.2329	.5582	.2320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 202 / 11 KV SHELGI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	2.5072		1.8004	1.7318	1.7194
24		.037	.0343	.0857	.0343
Max	2.5072	.037	1.8004	1.7318	1.7194
Min	2.5072	.037	.0343	.0857	.0343
Avg	2.5072	.037	.9174	.9088	.8769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.3326	.3174	.4668	.2801	.3142
24		.4108	.4668	.5544	.5175
Max	.3326	.4108	.4668	.5544	.5175
Min	.3326	.3174	.4668	.2801	.3142
Avg	.3326	.3641	.4668	.4173	.4159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 204 / 11 KV AURAD GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		.8316	.924	.7392		.8316
24	.4668		.4668	.5544	.5544	.5544
Max	.4668	.8316	.924	.7392	.5544	.8316
Min	.4668	.8316	.4668	.5544	.5544	.5544
Avg	.4668	.8316	.6954	.6468	.5544	.693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		.3696	.2743	.462	.3696	.3696
24	.3734		.3734	.3696	.4572	.462
Max	.3734	.3696	.3734	.462	.4572	.462
Min	.3734	.3696	.2743	.3696	.3696	.3696
Avg	.3734	.3696	.3239	.4158	.4134	.4158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 201 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.5144		.5735		.6001
5			.6001		.6554		
6				.4915	.6554	.6478	.6001
7	.2429				.7373		
8			.6859	.4858		.7287	.7716
9					.2458		
10	.4915			.2458		.1715	
11	.6554						
12				.2458			
13	.6554	.1715		.2458		.1715	
14			.1638				.1638
15	.6554	.1715		.1638	.1619		
16						.1715	
17	.6554			.1638	.1619		.1619
18			.1619	.1638			
19					.1619	.2572	
20		.2572					
21			.2458	.2458	.2429		.2429
22						.2572	
23					.3239		
24			.5144	.4096	.4915		.4287
Max	.6554	.2572	.6859	.4915	.7373	.7287	.7716
Min	.2429	.1715	.1619	.1638	.1619	.1715	.1619
Avg	.5593	.2001	.4123	.2862	.4010	.3436	.4242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 203 / 11 KV MASALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.7621		.7545		.7621
5			.8573		.8488		
6				.5658	.9431	.8192	.8573
7	.2458				.9431		
8			.9526	.5658		.8192	1.1431
9	.2458	.9431			.2829		
10	.5658					.1905	
11	.9431	.1905					
12			.1867				
13	.9431						
14							.1867
15	.9431	.1905			.1638		
16						.1905	
17	.9431			.1886	.1638		
18			.1867	.1886			
19						.2858	
20		.2858					
21			.2801	.2829	.2458		.2801
22						.2858	
23					.3277		
24		.5658	.7621	.5601	.5658		.7621
Max	.9431	.9431	.9526	.5658	.9431	.8192	1.1431
Min	.2458	.1905	.1867	.1886	.1638	.1905	.1867
Avg	.6900	.4351	.5697	.3920	.5239	.4318	.6652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 201 / 11 KV NITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3704		
5			.4915		.4915
6	.8421				.7712
7			.8817		
8			.8718		.8002
11		.4877			
14				.4588	
16		.3841			
18		.6097			
20		1.1431		1.1431	
23				.3658	
24	.3563	.4268	.3887		.3395
Max	.8421	1.1431	.8817	1.1431	.8002
Min	.3563	.3841	.3704	.3658	.3395
Avg	.5992	.6103	.6008	.6559	.6006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 202 / 11 KV SHEND FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.5556				
4				.5937	.5441	.7499	
5	.3898		.6554				.9831
6	.5506						1.073
7			1.153				
8			1.2574		1.0608	1.4083	1.4083
11		.5182				.1966	
14						.1311	
16			.1658	.1326			
18			.2667				
19					.3429		.4191
20		.4572		.362		.4572	
23		.3932	.5487			.2743	.4344
24	.1943		.583	.4877	.3437	.5761	.6481
Max	.5506	.5182	1.2574	.5937	1.0608	1.4083	1.4083
Min	.1943	.3932	.1658	.1326	.3429	.1311	.4191
Avg	.3782	.4562	.6482	.394	.5729	.5419	.8277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 203 / 11 KV BASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.3395				
4				.3125	.4481	.3749	
5	.5609		.6554				
6	.9393						
7	1.7814		.9326				
8	1.6872		.8048		.7956	.8048	
11		.9145				1.4419	
12			1.5364	.4687	1.3923		
14		1.4327				1.5074	
16		1.3443		1.0608	1.5813	1.5242	
18		.5716	.3429				
19					.5335		1.5424
20		.6859	.6283	.7621			
23		.3605	.3048				.3982
24	.6154		.3239	.2743	.3125	.3201	
Max	1.7814	1.4327	1.5364	1.0608	1.5813	1.5242	1.5424
Min	.5609	.3605	.3048	.2743	.3125	.3201	.3982
Avg	1.1168	.8849	.6521	.5757	.8439	.9956	.9703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 201 / 11 KV NANAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956		.3605	.1658	.3647	.3605	.3315
2	.8619		.3932	.1989	.3978	.3932	.3978
3			.4588	.2652	.4641	.4588	.4641
4			.5243	.3315	.5304	.5243	.5304
5			.6226	.3647	.663	.6226	.663
6		.5636	.8848	.3647	.8951	.8848	.8951
7		.5967	.9069		.9945	.852	.8619
8		.8951	.6882		.663	.7865	.5636
9	1.1603	.663	.4588		.4641	.5967	.4973
10			1.5249		.8619	1.1603	.9945
11			1.989	.9282	1.2631	1.4918	.9945
12		1.5684	2.0553	.9945	1.3763	1.6244	.9945
13		1.6964	2.0222	.8951	1.4403	1.6244	1.1603
14		1.7284	1.8564	.8619	1.4403	1.6244	1.3592
15		1.7394	1.989	1.094	1.5043	1.6244	1.3592
16	.2321	1.4083	1.989	.4973	1.4723	1.6244	1.4255
17	.4641	1.5364	1.8233	.8288	1.4083	1.6244	1.4586
18	.4973	.3277	.3315	.431	.3932		.3647
19	.6299	.5898	.5967	.5636	.5243		.6299
20		.6554	.4973	.6299	.6226		.5967
21		.5243	.3647	.663	.5898		.4641
22		.4915	.2984	.431	.5243		.3978
23		.426		.3647	.3932		.3315
24	.7956		.3605	.1658	.2915	.3277	
Max	1.1603	1.7394	2.0553	1.094	1.5043	1.6244	1.4586
Min	.2321	.3277	.2984	.1658	.2915	.3277	.3315
Avg	.6796	.9632	.9998	.5520	.8143	1.0114	.7711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 202 / 11 KV JEWRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315		.4915	.5304	.3978	.3932	.3978
2	.431		.4915	.663	.431	.426	.4973
3	.4973		.5571	.663	.4973	.4915	.4973
4	.6962			.8288	.5967	.5571	.5967
5	.7956		.6554	.9945	.7293	.6554	.663
6		.5967	.9717		.8951	.8192	.8288
7		.9945	1.1984		.9945	.9393	.9945
8		.663	1.166		.8288	.9393	.9945
9		.7293	.9717	.8288	.7293	.7865	.8288
10	.8288			.663			.3315
11	.7625						.1989
12	.8288						.2321
13	.8288	.1677	.1989	.1989	.2294	.1989	.1989
14	.7956	.1677	.1989	.1989	.2294	.2321	.1989
15	.8288	.1677	.1989	.2321	.2294	.2321	.2267
16	.8288	.2622	.2321	.2984	.2294	.2321	.2321
17	.8288	.2949	.2652	.3647	.2294	.2652	.2652
18	.3978	.3932	.3647	.4641	.3277		.3647
19	.663		.6299	.5304	.6882		.663
20		.6554	.6962	.7625	.6554		.6299
21		.4915	.663		.4915		.5304
22	.3978	.3932	.4641		.426		.3315
23	.3315	.2949	.2652	.2652	.2949		.2652
24	.2984		.426	.3315	.3315	.3605	
Max	.8288	.9945	1.1984	.9945	.9945	.9393	.9945
Min	.2984	.1677	.1989	.1989	.2294	.1989	.1989
Avg	.6317	.4480	.5553	.5187	.4982	.5019	.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 203 / 11 KV MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2984	.4973	.6554	.663	.663	.5571	.5967
2	.3315	.5304	.6554	.663	.663	.2294	.663
3	.3647	.5304	.8192	.8288	.8288	.6226	.663
4	.431	.5304	.8192	.8288	.8951	.6882	.6962
5	.7956	.663	.9717	.9945	.9282	.8192	.8288
6	.9945	.7293	1.4403	1.1934	.9945	1.1336	.8288
7	.9945	1.1603	1.6964	1.1603	1.1271	1.3443	.9945
8	.9614	1.1271	1.4723		1.094	1.3123	.9945
9	.5967	1.1603	1.2955	1.1603	.9945	1.1336	.9945
10	.8619						.2321
11	1.0277						.1989
12	1.1271						.1658
13	1.0608						.1989
14	1.094						.1989
15	1.094						.2321
16	1.2266	.2622	.2984	.3647	.2294	.2321	
17	1.1603	.2949	.3315	.2984	.2622	.2652	.2321
18	.3647	.2949	.3315	.4641	.3277		.3315
19	.6299	.7537	.4973	.4973	.6226		.6154
20		.5898	.6962	.7293	.5898		.5967
21		.426	.5636	.5636	.5571		.4973
22	.431	.3277	.3647	.3647	.426		.3978
23	.2652	.2622	.2652	.2321	.2622		.2984
24	.2652	.4973	.5898	.4641	.4973	.4915	
Max	1.2266	1.1603	1.6964	1.1934	1.1271	1.3443	.9945
Min	.2652	.2622	.2652	.2321	.2294	.2294	.1658
Avg	.7444	.5910	.7646	.6747	.6646	.7358	.5207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.543			.4887
4							.724
7				.985			
8							1.1393
12				.181			
14							.181
16				.2172			.181
19				.3801			
23		.3018		.2715			.2715
24	.2075		.5658	.3658	.543	.4525	.3801
Max	.2075	.3018	.5658	.985	.543	.4525	1.1393
Min	.2075	.3018	.5658	.181	.543	.4525	.181
Avg	.2075	.3018	.5658	.4205	.543	.4525	.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 202 / 11 KV BHOOTMUGLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4				.3258
8				.4887
12				.724
14	.543			
15	.543			
16	.543			.7888
17	.5373			
18	.5373			
19	.2715			
24		.2715	.2534	.2715
Max	.543	.2715	.2534	.7888
Min	.2715	.2715	.2534	.2715
Avg	.4959	.2715	.2534	.5198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 203 / 11 KV USTURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181			
5				.3681
7	.543			
8				.7059
14	.2715			
15	.362			
16				.6935
19	.2378			
24	.1886	.2715	.2534	.3258
Max	.543	.2715	.2534	.7059
Min	.181	.2715	.2534	.3258
Avg	.2973	.2715	.2534	.5233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 201 / NEW BANK COLONY

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	1.0029	1.0166	1.1203	.985	.9816	1.0208
2	1.0562	.9671	.9991	1.094	.985	.964	.9671
3	1.0269	1.0029	.964	1.094	1.0029	.964	.9492
4	1.0374	1.0387	1.0341	.9997	1.0566	1.0166	1.0029
5	1.094	1.1104	1.1218	1.1016	1.1283	1.0867	1.0924
6	1.1203	1.1641	1.2445	1.226	1.182	1.2094	1.2536
7	1.134	1.3073	1.2971	1.1949	1.2894	1.262	1.2894
8	1.2803	1.3253	1.2795	1.2071	1.2894	1.2269	1.2536
9	1.307	1.2269	1.1744	1.1203	1.182	1.1919	1.2357
10	1.1462	1.1043	1.0608	.8954	1.1568	1.1919	1.1999
11	1.0745	1.0692	1.1706	1.0387	1.1393	1.1744	1.1999
12	1.0029	1.0341	1.1706	1.0387	1.1393	1.2094	1.182
13	1.0387	1.0517	1.0808		1.0867	1.2094	1.3073
14	.985	1.0517	1.2136	1.2178	1.0517	1.1393	1.2178
15	1.0029	1.0692	1.2071	1.182	1.0166	1.1104	1.1641
16	1.0208	1.1393	1.134	1.1462	1.0341	1.1462	1.1283
17	1.0566	1.1393	1.2071	1.182	1.0517	1.1218	1.2178
18	1.0924	1.1568	1.307	1.2178	1.1218	1.1999	1.2536
19	1.4506	1.4373	1.3817	1.4327	1.262	1.2715	1.3969
20		1.4022	1.419	1.3611	1.4022	1.3253	1.3432
21		1.1744	1.3443	1.2715	1.3321	1.3253	1.2178
22		1.1393	1.2826	1.1641	1.2269	1.2894	1.2536
23	1.2178			1.0566		1.182	1.182
24	1.1694	1.0387	1.0517	1.1694	1.0029	1.0166	1.0745
Max	1.4506	1.4373	1.419	1.4327	1.4022	1.3253	1.3969
Min	.985	.9671	.964	.8954	.985	.964	.9492
Avg	1.1141	1.1371	1.1810	1.1536	1.1359	1.1590	1.1835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 202 / ASHOK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1791	.2033	.2263	.197	.1848	.1791
2	.2075	.1612	.1848	.2263	.2507	.2033	.1791
3	.2075	.1612	.1663	.2075	.3224	.2033	.197
4	.2263	.2149	.2033	.2641	.4298	.2587	.2507
5	.3018	.4656	.3326	.4481	.4835	.3696	.3761
6	.5975	.6268	.5544	.5658	.6626	.5914	.5731
7	.7167	.7701	.7023	.5658	.5731	.7392	.6089
8	.8589	.7343	.6653	.5788	.591	.7023	.5373
9	.679	.7392	.4066	.7545	.6089	.4435	.5194
10	.4656	.3696	.3361	.5731	.5544	.4805	.6089
11	.4298	.3326	.3361	.394	.3696	.3511	.5014
12	.3761	.2772	.2402	.3761	.2957	.2772	.4477
13	.3045	.2402	.2241	.3582	.2218	.2218	.4119
14	.2686	.2218	.2241	.197	.1848	.2402	.3403
15		.1663	.2241		.2033	.2149	.2865
16	.2507	.2218	.2241	.2686	.2033	.197	.2507
17	.2865	.2218	.2263	.3403	.2218	.2033	.2686
18	.3582	.2957	.3772	.394	.3696	.3761	.3045
19	.5373	.4435	.5093	.5552	.4908	.4477	.3224
20		.499	.5281	.5014	.5544	.394	.3403
21		.4251	.4527	.3761	.4435	.4119	
22		.3142	.3395	.3045	.3696	.3224	.2865
23	.2507	.2957		.2149		.2686	.2865
24	.2263	.197	.2402	.2829	.1791	.2218	.2149
Max	.8589	.7701	.7023	.7545	.6626	.7392	.6089
Min	.2054	.1612	.1663	.197	.1791	.1848	.1791
Avg	.3877	.3572	.3435	.3902	.3818	.3469	.3605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 201 / 11 KV ANASARWADA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.583		.7373
16	.2743	.2743	
24	.2915		
Max	.583	.2743	.7373
Min	.2743	.2743	.7373
Avg	.3829	.2743	.7373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 202 / 11 KV ANASARWADA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	10-APR-18	14-APR-18
HR	Load (MW)	Load (MW)
8	.6859	.9602
24	.3258	
Max	.6859	.9602
Min	.3258	.9602
Avg	.5059	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 203 / 11 KV TALIKHED GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.4115		.4973
16	.5144	.4115	
24	.2058		
Max	.5144	.4115	.4973
Min	.2058	.4115	.4973
Avg	.3772	.4115	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 201 / 11KV SYED ANKULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353			
2	.3353	.4382		
3	.4191			
4	.4191	.6661		
5	.4191	.7888		
6	.4694			
7	.503	.9114		
8	.6371	.964		
9	.0286			
10	.0191			
13			.1341	
23	.2629			
24	.3353	.3856		.4359
Max	.6371	.964	.1341	.4359
Min	.0191	.3856	.1341	.4359
Avg	.3486	.6924	.1341	.4359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 202 / 11 KV BIBRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383			
2	.8383	1.3146		
3	1.0059			
4	1.0059	1.6651		
5	1.3413			
6	1.3413	2.1033		
7	1.5089			
8	1.5089	2.5941		
9	.0857			
13			.3353	
23	1.1393			
24	.6706	1.4022		1.4899
Max	1.5089	2.5941	.3353	1.4899
Min	.0857	1.3146	.3353	1.4899
Avg	1.0259	1.8159	.3353	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 203 / 11 KV Ujed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381			
2	.0343	.3018		
3	.0343			
4	.0381			
5	.0476	.4694		
6	.061			
7	.061	.5868		
8	.0629	.6371		
13			.2629	
23	.3353			
24	.0381	.3018		.2683
Max	.3353	.6371	.2629	.2683
Min	.0343	.3018	.2629	.2683
Avg	.0751	.4594	.2629	.2683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 204 / 11kv Halki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2515		
4		.2515		
6		.3353		
8		.4191		
13			1.3672	
23	.4191			
24		.3353		.3018
Max	.4191	.4191	1.3672	.3018
Min	.4191	.2515	1.3672	.3018
Avg	.4191	.3185	1.3672	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.7635		.7468	.8402		.7468
9	.8029		.5601	.8402		.4481
12			2.1862		2.1862	
15			1.8623		2.1052	
18		.4481	.5601		.4481	
21		.7468	.7468		.7468	
24	.3391		.5601	.5601		.5601
Max	1.7635	.7468	2.1862	.8402	2.1862	.7468
Min	.3391	.4481	.5601	.5601	.4481	.4481
Avg	.9685	.5975	1.0318	.7468	1.3716	.585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5601		.9335	.5144		.8097
9	.4854		.4668	.4481		.4481
12					.2801	
15			.2801		.2172	
18		.4481	.2987		.2241	
21		.4668	.3734		.4668	
24	.3361		.5601	.4481		.4858
Max	.5601	.4668	.9335	.5144	.4668	.8097
Min	.3361	.4481	.2801	.4481	.2172	.4481
Avg	.4605	.4575	.4854	.4702	.2971	.5812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 203 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0852		.724	.724		.543
9	.5601		.3734			.543
12			1.3765		1.9433	
15			1.5384		1.6194	
18		.112	.362			
21		.543			.6335	
24	.407		.4525	.4344		.543
Max	1.0852	.543	1.5384	.724	1.9433	.543
Min	.407	.112	.362	.4344	.6335	.543
Avg	.6841	.3275	.8045	.5792	1.3987	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 204 / 11 KV DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.1052	1.7814		2.4291
9	.1494	.1867		.1867
12			.0747	
15			.0747	
18			.1867	
21	.1867		.1867	
24	1.6194	1.6194		1.6194
Max	2.1052	1.7814	.1867	2.4291
Min	.1494	.1867	.0747	.1867
Avg	1.0152	1.1958	.1307	1.4117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			1.0059	.8573
9	.6859			
24	.4572	.4287	.4572	.4287
Max	.6859	.4287	1.0059	.8573
Min	.4572	.4287	.4572	.4287
Avg	.5716	.4287	.7316	.643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.7373	.9431
9	.6859			
24	.3277	.3429	.3277	.4287
Max	.6859	.3429	.7373	.9431
Min	.3277	.3429	.3277	.4287
Avg	.5068	.3429	.5325	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 203 / 11KV ARI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.4858	.6001
9	.2572			
24		.3429	.4049	.4287
Max	.2572	.3429	.4858	.6001
Min	.2572	.3429	.4049	.4287
Avg	.2572	.3429	.4454	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 204 / 11KV WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0229	.0343
9	.3429			
24		.0343	.0229	.0343
Max	.3429	.0343	.0229	.0343
Min	.3429	.0343	.0229	.0343
Avg	.3429	.0343	.0229	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0554	.0343
11	.0343			
24		.0343	.037	.0343
Max	.0343	.0343	.0554	.0343
Min	.0343	.0343	.037	.0343
Avg	.0343	.0343	.0462	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			2.2405	1.8861
9	1.8861			
24		.7716	1.307	.6859
Max	1.8861	.7716	2.2405	1.8861
Min	1.8861	.7716	1.307	.6859
Avg	1.8861	.7716	1.7738	1.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 201 / 11 KV TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2172	.3109			.2957	.3109
2		.2172	.3292			.2957	
3			.3292			.2957	.3258
4		.2172	.3658			.3326	
5		.2534	.4024			.4066	.3982
6		.4163	.5487				.4887
7		.3982	.439		.2347	.5914	.5249
8		.362	.4252		.2683	.4481	.4706
9	.2012	.2926	.3292		.2347	.3361	.3982
10	.181	.8619			.8413	.9393	
11	.1448	1.1797			1.2071	1.2631	
12	.0905				1.1401		
13		1.4899			1.2742		
14	.1086	1.4419	1.9631		1.2742	1.2631	
15		1.3108	1.5257		1.0059		
16	.1086	1.5729			1.2742		
17	.0905	1.704			1.3923	1.587	
18	.1086	.1646			.1463	.1448	
19	.2896	.3658			.2561	.2534	
20		.439		.3018	.5228	.4163	
21		.439			.4066	.3801	
22		.3658			.3142	.3439	
23		.2926			.3174	.3077	
24			.3109			.2957	.3109
Max	.2896	1.704	1.9631	.3018	1.3923	1.587	.5249
Min	.0905	.1646	.3109	.3018	.1463	.1448	.3109
Avg	.1470	.6668	.6066	.3018	.7124	.5366	.4035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 202 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.2347	
9	.2012				.2347	
10		.5201			.439	.4115
11		.5609			.4298	.6173
12		.5895				
13		.4801			.5014	
14		.4854	.6935		.4961	.463
15		.4508	.7362		.4607	
16		.5548			.4607	.4801
17		.5201			.4607	
20				.2347		
Max	.2012	.5895	.7362	.2347	.5014	.6173
Min	.2012	.4508	.6935	.2347	.2347	.4115
Avg	.2012	.5202	.7149	.2347	.4131	.4930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 203 / 11 KV GHUGI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3856	.7625			.7011	.5243
2		.4024	.7625			.6935	
3		.4024	.7956			.7545	.5571
4			.7956			.7888	
5		.4024	.8288			.8139	.7209
6		.6706	.852			.9389	.9667
7		.9221	1.1142	.8413		1.0059	1.065
8	.1677	.8848	1.0486	.8669	.9362	.9389	.9717
9			.2561		.2204	.2561	
10		.1097			.0914		
11	.8421	.128			.0732		
12	1.085	.0914			.0732		
13	1.1012	.0732					
14		.0732	.1357		.0732		
15	1.1336	.0732	.1006		.0732		
16	1.1336	.0732					
17	1.0688	.1463					
18		.2561					
19		.2926					
20		.2561			.3326		
21		.2195			.2587		
22		.1829			.1848	.1991	
23		.6554			.6089	.3688	
24			.7293			.7011	.4915
Max	1.1336	.9221	1.1142	.8669	.9362	1.0059	1.065
Min	.1677	.0732	.1006	.8413	.0732	.1991	.4915
Avg	.9331	.3191	.6818	.8541	.2660	.6801	.7567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 204 / 11 KV NEW TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3887	.8048			1.643	
2			.8048			1.643	1.5729
3		.3887	.8383			1.6575	
4		.3887	.8718			1.6575	1.6385
5		.4049	.9282			1.704	1.6842
6		.6478	.9831			1.9006	1.8947
7		.8097	1.3435			2.0972	2.2024
8		.8356	1.5223		1.858	2.2283	2.2283
9	.2012	.2172	.2172		.2374	.3326	.3982
10	.3772	.1829			.2587	.2715	
11	.8383	.1097			.1829	.2353	
12	.9069	.1097			.1109		
13		.1097			.1478		
14	.8907	.1097	.1341		.1478	.181	
15		.1478	.1696		.1463		
16	.9717	.2587			.1478		
17	.9393	.1109			.1848	.181	
18	.1629	.1478			.2218	.2012	
19	.3982	.2587			.3734	.3658	
20		.3326		.2683	.4755	.4525	
21	.5068	.2926			.4435	.4024	
22		.2561			.4066		
23		.57			1.2548	1.576	
24			.7712			1.6095	1.6095
Max	.9717	.8356	1.5223	.2683	1.858	2.2283	2.2283
Min	.1629	.1097	.1341	.2683	.1109	.181	.3982
Avg	.6193	.3217	.7824	.2683	.4124	1.0705	1.6536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 201 / 11 KV SHIVPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286		.3658		.381	.381	.4572
2	1.286		.3658		.381	.4191	.4572
3	1.286		.3658		.381	.381	.4572
4	1.5432		.3658		.4191	.381	.4572
5	1.5432		.4755		.4191	.4191	.4572
6	1.5432		.4755		.4191	.4191	.4572
7	1.6289		.4904		.4191	.4572	.4572
8	1.6289		.4954		.4191	.4191	.5144
9	.4572		.4954	.7621	1.3336	.4191	.5144
10	.4572		.9145	1.4289	1.4289	1.105	1.2955
11	.4572	.6859	1.2955	1.4289	1.5242	1.2955	1.2003
12	.4572	.8573	1.6766	1.7147	1.4289	1.6766	1.2003
13	.439	.9602	1.7909	1.7147	1.1431	1.8671	1.2003
14	.439	1.0288	1.9052	1.7147	1.3336	2.0957	1.2003
15	.439	1.0288	1.9814	1.7147	1.1431	2.0957	1.2003
16	.439	1.0288	1.9814	1.8099	1.1431	2.1719	1.4746
17	.439	1.0288	1.829	1.8099	1.1431	2.1719	1.5432
18	.4024	.3429	.381	.381	.381	.381	.4755
19	.4024	.4755		.381	.4954	.4572	.5121
20	.4024	.4755		.381	.4954		.5121
21		.4755		.381	.4954	.4572	.4572
22		.439	.4572	.381	.4954	.4572	.4572
23		.439		.381	.4572	.4572	.4572
24	1.166		.4024	.381	.4191	.4572	
Max	1.6289	1.0288	1.9814	1.8099	1.5242	2.1719	1.5432
Min	.4024	.3429	.3658	.381	.381	.381	.4572
Avg	.8639	.7128	.9255	1.0478	.7541	.9062	.7572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 202 / 11 KV HIPPALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439		.6859	.5335	.6668	.6668	
2	.3658		.6859	.6097	.6668	.6668	
3	.3658		.6859	.6097	.6668	.7621	
4	.3658		.6859	.6097	.7621	.7621	
5	.3658		.7202	.6859	.8573	.7621	
6	.3658	.4458	.7202	.6859	.8573	.8573	
7	.3658	.4458	.7202	.6859	.8573	.8573	
8	.3658	.4115	.8383	.6859	.8573	.7621	
9	.3658	.4458	.8383	.381	.381	.381	
10	.6401	.4458	.381	.381	.381	.381	.381
11	.7716	.4755	.381	.381	.4954	.381	.3658
12	.7716	.4755	.381	.381	.4954	.381	.4024
13	.7716	.4755	.381	.381	.381	.4572	.4024
14	.7716	.4755	.381	.381	.381	.4572	.4024
15	.8573	.4755	.381	.381	.4954	.4572	.4024
16	.8573	.4755	.381	.381	.4954	.4572	.439
17	.8573	.5121	.381	.381	.4763	.4572	.439
18	.4024	.5121	.381	.381	.4763	.4572	.439
19	.4024	.439	.381	.381	.4572	.4572	.439
20	.4024	.4024	.381	.381	.4572		.439
21		.4024	.5335	.381	.4191		.439
22		.4024	.381	.381	.4191	.4572	.439
23		.5144	.4572	.381	.5716	.4572	.4024
24	.439		.5335	.381	.6668	.4572	
Max	.8573	.5144	.8383	.6859	.8573	.8573	.439
Min	.3658	.4024	.381	.381	.381	.381	.3658
Avg	.5386	.4574	.5282	.4668	.5684	.5542	.4166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 203 / 11 KV GANESHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.0914	.0914	.1143	.0953	.1143	.1143
2	.2572	.0914	.1097	.1143	.0953	.1143	.1143
3	.2572	.0914	.0914	.1143	.0953	.1143	.1143
4	.2572	.0914	.0914	.1143	.0953	.1143	.1143
5	.2572	.0914	.0914	.1143	.0953	.1143	.1143
6	.2572	.0914	.0914	.1143	.1143	.1143	.1143
7	.2572	.0914	.0914	.1143	.1143	.1143	.1143
8	.2572	.0914	.0953	.1143	.1143	.1143	.1143
9	.0914	.0914	.0953	.1143	.1143	.1143	.1143
10	.0914	.1097	.1905	.1905	.1143	.1905	.1905
11	.0914	.1715	.2667	.2858	.1905	.2286	.2058
12	.0914	.1715	.3429	.2858	.1905	.2667	.2058
13	.0914	.1715	.3429	.2858	.2286	.3048	.2058
14	.0914	.2058	.381		.2286	.3048	.2058
15	.0914	.2058	.381	.2858	.2286	.3429	.2058
16	.0914	.2058	.381	.2858	.2286	.381	.2058
17	.0914	.2401		.2858	.1905	.381	.1715
18	.0914	.1097	.0953	.0953	.1143	.1143	.1715
19	.0914	.1097	.0953	.0953	.1143	.1143	.1097
20	.0914	.1097	.0953	.0953	.1143	.1143	.1097
21	.0914	.1097	.1143	.0953	.1143	.1143	.1097
22	.0914	.1097	.1143	.0953	.1143	.1143	.0914
23	.0914	.1097	.1143	.0953	.1143	.1143	.0914
24	.2401	.0914	.1143	.0953	.1143	.1143	
Max	.2572	.2401	.381	.2858	.2286	.381	.2058
Min	.0914	.0914	.0914	.0953	.0953	.1143	.0914
Avg	.1522	.1272	.1686	.1566	.1389	.1762	.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 201 / 11 KV KINGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-18	12-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.7716		
2	.7716		
3	.8573		
4	.8573		
5	.9431		
6	1.0288		
7	1.0288		
8	.9431		.9431
9	.8573		
10	.6859		.9431
11	.6859		.9431
12	.6859	.9431	.8573
13		1.0288	.8573
14		.8573	.9431
15		.9431	.9431
16			.8573
18		.8573	
20		1.1145	
21		.9431	
22		.9431	
23		.8573	
24	.6859		
Max	1.0288	1.1145	.9431
Min	.6859	.8573	.8573
Avg	.8310	.9431	.9109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 203 / 11 KV KOPARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431			
2	.9431			
3	1.0288			
4	1.1145			
5	1.2003			
6	1.2003			
7	1.286			
8	1.286			.8573
9	1.3717			.9431
10	2.7435			.7716
11	3.0864			3.2579
12	3.0864	.6001		3.1722
13		.5144		3.0864
14		3.4294		3.0007
15		3.4294		2.7435
16		3.2579		2.7435
17		3.4294		
18		2.915		
19		.7716		
20		1.286		
21		1.1145		
22		.8573		
23		.6859	.7716	
24	.9431			
Max	3.0864	3.4294	.7716	3.2579
Min	.9431	.5144	.7716	.7716
Avg	1.5564	1.8576	.7716	2.2862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 204 / 11 KV KINGAON EXPRESS

NON SHEDDABLE WATER SUPPLY AND
UTILITYFEEDER Feeder KV- 11 /
OUTGOING

DATE	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0086			
2	.0086			
3	.0086			
4	.0086			
5	.0086			
7	.0086			
8	.0086		.0086	.0086
9	.0086			.0137
10	.0086			.0086
11	.0086			.0086
12	.0086	.0086		
13		.0086		.0086
15		.0034		
16		.0034	.0086	.0086
18		.0034	.0086	
19		.0086		
20		.0086		
23		.0086	.0086	
24	.0086		.0086	
Max	.0086	.0086	.0086	.0137
Min	.0086	.0034	.0086	.0086
Avg	.0086	.0067	.0086	.0095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 201 / 11 KV DHALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6783	.6859	.9431	1.1022
16	.4239	1.0288		.6783	
24		.763	.6001	.6001	.6783
Max	.4239	1.0288	.6859	.9431	1.1022
Min	.4239	.6783	.6001	.6001	.6783
Avg	.4239	.8234	.643	.7405	.8903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 202 / 11 KV ANDHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.0174	1.3717	1.3717	1.0174
16	.6783	.5144		.6783	
24		1.0174	.6001	.6859	1.1022
Max	.6783	1.0174	1.3717	1.3717	1.1022
Min	.6783	.5144	.6001	.6783	1.0174
Avg	.6783	.8497	.9859	.9120	1.0598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 203 / 11 KV KENDREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.8478	1.3717	1.286	1.0174
16	1.6956	.6001		.6783	
24		.5935	1.6289	1.8004	1.0174
Max	1.6956	.8478	1.6289	1.8004	1.0174
Min	1.6956	.5935	1.3717	.6783	1.0174
Avg	1.6956	.6805	1.5003	1.2549	1.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.2003		1.5223	.3429		
10							1.6118
16	.1715	.4287	.4477		.2572		
17						.2458	
20			.5373				
24		.3429	.3429	.4477	.2572		.3582
Max	.1715	1.2003	.5373	1.5223	.3429	.2458	1.6118
Min	.1715	.3429	.3429	.4477	.2572	.2458	.3582
Avg	.1715	.6573	.4426	.985	.2858	.2458	.985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 203 / 11 KV KAJAL HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.6268		
16	.3429	2.4863	2.4177		2.2291	
17						2.4177
20			.6268			
24		.5144	.7716			
Max	.3429	2.4863	2.4177	.6268	2.2291	2.4177
Min	.3429	.5144	.6268	.6268	2.2291	2.4177
Avg	.3429	1.5004	1.2720	.6268	2.2291	2.4177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3326	.3479	.4805	.2218	.5175	.4805
2		.3511	.3479	.5175	.2587	.5175	.5175
3		.3696	.3163	.5359	.3326	.5175	.5175
4		.4066	.3795	.6283	.3696	.6283	.5544
5		.4435	.5693	.8501	.4066	.7762	.6283
6		.5175	.7274	1.0164	.4435	.9425	.7207
7	1.0164	.5544	.6325	.961	.3881	.9795	.7023
8	.961		.5693	.924	.3696	.7762	.6838
9	.8871	.5914	.5376	.7207	.6653	.5544	.5182
10			.4435	.499	.5544	.4805	.4805
11	.5914			.4435		.4435	.3511
12	.462	.3479			.5544		.2846
13	.4435	.3005		.3326	.5359		.3163
14	.4251	.2688	.4066		.499	.3696	.3321
15	.4251	.3321	.4435	.4066	.462	.3881	.3321
16	.4435		.462	.5175	.4066	.4066	.3163
17	.4251	.3163	.4805	.5544	.4251	.4119	.3479
18	.5175		.499	.5175	.462	.4066	.4428
19	.6653	.4428	.7392	.9979	.7577	.6653	.5535
20	.7392	.4744	.6653	.924	.7392	.7392	.6642
21	.7023	.4428	.6468		.7023	.7023	.6325
22	.6653	.4111			.6468	.5914	.5693
23	.2218	.3795			.5914	.462	.4902
24		.2772	.3795	.5359	.1848	.5359	.4435
Max	1.0164	.5914	.7392	1.0164	.7577	.9795	.7207
Min	.2218	.2688	.3163	.3326	.1848	.3696	.2846
Avg	.5995	.3979	.5049	.6507	.4773	.5824	.4950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7551	1.5684	1.4232	1.6324	
2	1.97	1.6004	1.5181	1.7284	
3	2.0058	1.7604	1.6446		
4	1.8343	1.8404	1.6762	1.8564	
5	1.866	2.0005	1.7394	1.9204	
6	2.1491	2.0805	1.8027		
7	2.4356	2.1445	1.9925	2.0485	
8	2.5789	2.2085	2.0873	1.9204	1.3443
9	2.364	2.2725	2.0557	1.9204	1.2803
10	2.2348	2.1765	1.9292	1.8564	1.5364
Max	2.5789	2.2725	2.0873	2.0485	1.5364
Min	1.7551	1.5684	1.4232	1.6324	1.2803
Avg	2.1194	1.9653	1.7869	1.8604	1.387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.9488						
11		1.97	1.8564	2.0557	2.1125	2.6566	.3201
12		2.2923	2.2405	2.2138	2.5606	2.4966	2.1132
13		2.9012	2.6566	2.3403	2.4326	2.4966	2.5072
14		2.1491	2.5606			2.5286	2.8654
15		2.2207	2.5926	2.4352	2.2725	2.4966	2.9012
16		2.1132	2.5606	2.4985	2.4326	2.5606	2.6505
17		2.1491	2.4006	2.5617	2.6246	2.5926	2.8654
18		2.1132	2.0805	2.2138	2.3045	.3841	2.6147
Max	.9488	2.9012	2.6566	2.5617	2.6246	2.6566	2.9012
Min	.9488	1.97	1.8564	2.0557	2.1125	.3841	.3201
Avg	.9488	2.2386	2.3686	2.3313	2.3914	2.2765	2.3547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			
2	.1886			
3	.2058			
4	.2058			
5	.2401			
6	.2572			
7	.3086			
8	.3086			
9	.3429			
10		.1677	.1715	.2401
12		.1677	.2515	
14		.1677	.1677	
16		.2515	.1677	
17		.2515	.1677	
24	.1715			
Max	.3429	.2515	.2515	.2401
Min	.1715	.1677	.1677	.2401
Avg	.2401	.2012	.1852	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288					.1029
2	1.0631		.1029	.1029	.1029	.1029
3	1.0974					.1029
4	1.1317		.1029	.1029	.1029	.1029
5	1.2548					.1029
6	1.4419		.1029	.1029	.1006	.1372
7	1.7901					.1029
8	1.8861			.1029	.1029	.1029
9	.6173				.1029	.1029
10	.1029	.5144		1.6766	1.6766	1.8519
11	.1029				2.332	
12	.1029	1.0059		2.1795	2.5263	
13	.1029				2.2939	
14	.1029	1.0059		2.2801	2.2211	
15	.1029				1.9989	
16	.1029	1.3413		2.3472	2.2283	
17	.1029			2.1795	2.4291	
18		.1086		.1029	.1029	
19					.1029	
20		.1086			.1372	
21					.1029	
22		.1029		.1029	.1029	
23				.1029	.1029	
24	1.0288		.1029	.1029	.1029	.1029
Max	1.8861	1.3413	.1029	2.3472	2.5263	1.8519
Min	.1029	.1029	.1029	.1029	.1006	.1029
Avg	.7313	.5982	.1029	.8835	.9487	.2650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583					.3086
2	.631	.4024	.4115	.1715	.3429	.2743
3	.6173					.2743
4	.6859	.4694	.4694	.1715	.3772	.2401
5	.9259					.3086
6	1.1317	.6036	.5365	.1677	.3772	.3086
7	1.2407					.3429
8	1.2346	.503		.2347	.3688	.3086
9	1.2003				.3688	.2743
10	.1715	.6097		.7712	.5765	.9602
11	.1372				.8718	
12	.1029	1.0395		1.0059	.9945	
13	.1029				.9175	
14	.1029	.9054		1.073	.8951	
15	.1006				.8288	
16	.1357	1.0059		1.073	.9282	
17	.2058			1.0059	1.1797	
18		.3086		.0686	.1372	
19					.3429	
20		.5487			.4508	
21					.4908	
22		.4801		.3429	.3772	
23				.4115	.3429	
24	.583	.3429	.3772	.1715	.4115	.3086
Max	1.2407	1.0395	.5365	1.073	1.1797	.9602
Min	.1006	.3086	.3772	.0686	.1372	.2401
Avg	.5496	.6016	.4487	.5130	.5790	.3554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029					.823
2	.1029	.7042	.9724	.7377	1.0059	.8573
3	.1029					.8573
4	.1029	.8383	1.1736	.503	1.1736	.9602
5	.1029					1.0288
6	.1029	1.0059	1.3748	.6706	1.4083	1.2407
7	.1029					1.4746
8	.1029	1.073			1.3413	1.4419
9	.1029				1.2742	
10	.8573	.1029		.1029	.1029	
11	1.1065				.1029	
12	.9614	.1029		.1006	.1029	
13	1.0277				.1029	
14	1.1469	.1006			.1029	
15	1.2452			.57	.1029	
16	1.3108	.1006				
17	1.3763			.1029		
18				.1029	.1029	
19					.1029	
20		.1086			.1052	
21					.1052	
22		.1029		.1029	.1029	
23				.1029	.1029	
24	.1029	.4115	.8048	.583	.7202	.823
Max	1.3763	1.073	1.3748	.7377	1.4083	1.4746
Min	.1029	.1006	.8048	.1006	.1029	.823
Avg	.5590	.4229	1.0814	.3345	.4535	1.0563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487					.5487
2	.583	.6371	.5365	.503	.5365	.5144
3	.583					.5487
4	.6173	.6036	.503	.503	.6036	.583
5	.6173					.6173
6	.6443	.6401	.7042	.6036	.7377	.6783
7	.6783					.7377
8	.6173	.6036				.6706
9	.583				.6783	.6173
10	.5765	.5365		.503	.6173	
11	.6036				.583	
12	.5365	.6036		.5365	.5087	
13	.5765				.583	
14	.6104	.5365		.6371	.5487	
15	.5571				.6173	
16	.5304	.503		.6371	.583	
17	.57			.57	.6036	
18		.57		.6516	.6859	
19					.7545	
20		.823			.7888	
21					.7545	
22		.6173		.6706	.7202	
23				.5487	.6516	
24	.5487	.6706	.5487	.5144	.5144	.5487
Max	.6783	.823	.7042	.6706	.7888	.7377
Min	.5304	.503	.503	.503	.5087	.5144
Avg	.5879	.6121	.5731	.5732	.6353	.6065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 206 / 11KV Atola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4359	1.073		.7545
4	.6371	1.1736		1.0059
6	.8383	1.3413	1.1736	1.1736
8	.8383			1.2574
9				1.2574
10	.503		.1715	
12	.3353		.218	
14	.3018		.2012	
16	.2683		.2012	
17			.2347	
18	.3086		.2347	
20	.503			
22	.3772			
24	.3688	.5487		.5658
Max	.8383	1.3413	1.1736	1.2574
Min	.2683	.5487	.1715	.5658
Avg	.4763	1.0342	.3478	1.0024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343					.0343
2	.0343	.0343	.0343		.0343	.0343
3	.0343					
4	.0343	.0343	.0343	.0335	.0335	
5	.0343					.0343
6	.0343	.0335	.0335		.0335	.0343
7	.0343					.0343
8	.0343	.0335	.0335	.0335	.0335	
9	.0343				.0343	.0343
10	.0343	.0335		.0343	.0343	.0343
11	.0343				.0343	
12	.0343	.0335		.0335	.0343	
13	.0343				.0343	
14	.0343	.0335		.0343	.0343	
15	.0343				.0343	
16	.0343	.0335		.0335	.0343	
17	.0343			.0335	.0343	
18		.0343		.0343	.0343	
20		.0343			.0343	
22		.0343		.0343	.0343	
23				.0343	.0343	
24	.0343	.0343	.0343		.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0335	.0335	.0335	.0335	.0343
Avg	.0343	.0339	.0340	.0339	.0342	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.3717		1.8004	1.2193
16	1.2193		.6859		.3048
17		.3048			
Max	1.2193	1.3717	.6859	1.8004	1.2193
Min	1.2193	.3048	.6859	1.8004	.3048
Avg	1.2193	.8383	.6859	1.8004	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.2003		1.6289	1.1431
16	.9145		2.4863		
17		2.3624			
Max	.9145	2.3624	2.4863	1.6289	1.1431
Min	.9145	1.2003	2.4863	1.6289	1.1431
Avg	.9145	1.7814	2.4863	1.6289	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 203 / 11 KV MAHALANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.7147		1.5432	1.3717
16	1.2193		1.286		1.448
17		1.5242			
Max	1.2193	1.7147	1.286	1.5432	1.448
Min	1.2193	1.5242	1.286	1.5432	1.3717
Avg	1.2193	1.6195	1.286	1.5432	1.4099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 202 / 11KV Janwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.7311			.8061
15				.4687		
16		.4312	.4124	.4124	.4499	
23	.5624			.6749		
24		.7124	.7124			.5437
Max	.5624	.7124	.7311	.6749	.4499	.8061
Min	.5624	.4312	.4124	.4124	.4499	.5437
Avg	.5624	.5718	.6186	.5187	.4499	.6749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.3048			.1905
15				.1334		
16		1.105	.4382	.724	.7621	
23	.1905					
24			.1524		.1905	.1524
Max	.1905	1.105	.4382	.724	.7621	.1905
Min	.1905	1.105	.1524	.1334	.1905	.1524
Avg	.1905	1.105	.2985	.4287	.4763	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2136		.7459		.6935		.7459
16		1.1603	1.2269	1.2136		1.0774	1.4022
24	.4334		.4973		.5201		.5801
Max	1.2136	1.1603	1.2269	1.2136	.6935	1.0774	1.4022
Min	.4334	1.1603	.4973	1.2136	.5201	1.0774	.5801
Avg	.8235	1.1603	.8234	1.2136	.6068	1.0774	.9094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 202 / 11KV Ajansonda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.5089		.4287		.503		.4287
16		1.7147	1.5927	1.6766		1.1145	1.6766
24	.4239		.4287	.4191	.4191		.2572
Max	1.5089	1.7147	1.5927	1.6766	.503	1.1145	1.6766
Min	.4239	1.7147	.4287	.4191	.4191	1.1145	.2572
Avg	.9664	1.7147	.8167	1.0479	.4611	1.1145	.7875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 203 / 11KV Naigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.0059		.9945		1.5089
16	.3353	.3353	.3353		.2515	.3353
24		.4191	.4191	.3353		.503
Max	.3353	1.0059	.4191	.9945	.2515	1.5089
Min	.3353	.3353	.3353	.3353	.2515	.3353
Avg	.3353	.5868	.3772	.6649	.2515	.7824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 204 / 11KV BSF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0362		.04		.0352		.04
16		.04	.0381	.0352		.04	.0381
24	.0352		.04	.0333	.0352		.04
Max	.0362	.04	.04	.0352	.0352	.04	.04
Min	.0352	.04	.0381	.0333	.0352	.04	.0381
Avg	.0357	.04	.0394	.0343	.0352	.04	.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 201 / 11KV Ganjur SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.5144	.7545	.3772	.4287	.6859	.7545
2	.181	.5144	.9431	.3772	.4287	.7164	.8488
3	.181	.5144	.9431	.362	.5144	.6859	.9431
4	.181	.6001	1.0288	.362	.5144	.6859	.8573
5	.2715	.6859	1.1145	.362	.6001	.7716	.8573
6	.2715	.8573	1.2003	.543	.6859	.8573	.8573
7	.362	.9431	1.4575	.724	.8573	1.0288	1.2003
8	.2715	1.0288	1.3717	.724	.8573	1.0288	1.2003
9	.2715	.6001	1.286	.8145	.8573	.7716	1.2003
10	.181	.6859	1.267	.7716	.6859	.724	1.1145
11	.8573	.1886	.1886	.1715		.1886	.2572
12		.1886	.1886	.1715		.1886	.1715
13	1.286	.1886	.1886	.1715		.1886	.1715
14	1.286	.1886	.1886	.1715		.1886	.1715
15	1.3717	.1886	.1886	.1715		.1886	.1715
16	1.5432	.1886	.1886	.1715		.1886	.1715
17	1.2003	.1886	.1886	.1715		.1886	.1715
18	1.1145	.1886		.1715	.181	.1886	.1715
19		.2829		.2572	.181	.1886	.2572
20	.2572	.2829		.2572	.2715	.2829	.4287
21	.3429	.2829	.2829	.3429	.181	.2829	.4287
22	.2572	.1886		.2572	.2715	.2829	.3429
23	.2572	.2829	.1886	.2572	.2715	.2829	.2572
24	.181	.2572	.1886	.1886	.2572	.2715	.2829
Max	1.5432	1.0288	1.4575	.8145	.8573	1.0288	1.2003
Min	.181	.1886	.1886	.1715	.181	.1886	.1715
Avg	.5594	.4179	.6673	.3479	.4732	.4607	.5537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 202 / 11KV Shivankhed SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.4287	.5658	.362		.5144	.5658
2	.2715	.4287	.6602	.362		.6001	
3		.5144	.6602	.362		.6235	.6859
4		.6001	.6859	.362		.6859	.7716
5		.6859	.8573	.362		.6859	.8573
6		.8573	1.1145	.543		.6001	.8573
7		1.0288	1.286	.724		.9431	1.0288
8		1.0288	1.2003	.905	.4287		1.0288
9		1.0288	1.1145	.905	.6859	.724	1.1145
10	.362	.6859	1.086	.8573	.6001	.6335	.9431
11	.6859	.3772	.3772	.3429	.2715	.3772	.3429
12		.2829	.2829	.3429	.2715	.2829	.2572
13	1.1145	.1886	.2829	.2572	.2715	.2829	.2572
14	1.0288	.1886	.2829	.2572		.2829	.2572
15	1.0288	.2829	.2829	.2572	.2715	.2829	.2572
16	1.1145	.2829	.2829	.2572	.362	.2829	
17	1.2136	.2829	.2829	.2572	.362	.2829	.2572
18	1.0288	.2829		.2572	.4525	.2829	.2572
19		.5658		.5144	.6335	.4715	.5144
20	.4287	.5658		.5144	.6335	.6602	.6001
21	.5144	.4715	.3772		.6335	.5658	.6001
22	.4287	.3772			.6335	.4715	.5144
23	.3429	.3772	.2829		.543	.4715	.4287
24	.2715	.3429	.3772	.2829		.4525	.4715
Max	1.2136	1.0288	1.286	.905	.6859	.9431	1.1145
Min	.2715	.1886	.2829	.2572	.2715	.2829	.2572
Avg	.6737	.5065	.6171	.4421	.4703	.4983	.5849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 203 / 11KV Dhaveli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1886	.1886	.1715	.181	.1886
2	.181	.1715	.1886	.1886	.1715	.181	.1886
3	.181	.1715	.1886	.1886	.1715	.181	.1886
4	.181	.1715	.1886	.1886	.1715	.181	.1886
5	.181	.1715	.1886	.1886	.1715	.1715	.2829
6	.181	.2572	.2829	.2829	.2572	.181	.3772
7	.2715	.3429	.3772	.2829	.2572	.362	.3772
8	.2715	.3429	.3772	.2829	.2572	.362	.3772
9	.724	.1715	.2829	.2829	.1715	.2715	.2829
10	1.0288	.1886	.1886	.1715	.1715	.181	.1886
11		1.2003	1.267	.9431	1.1145	1.1145	1.1145
12		1.286	1.448	1.286	1.1145	1.286	1.286
13	.0857	1.286	1.448	1.2003	1.1145	1.286	1.286
14	.0857	1.1145	1.448	1.1145	1.2003	1.2003	1.3717
15	.0857	1.2003	1.6289	1.2003	1.2003	1.286	1.1145
16	.0857	1.1145	1.6289	1.2003	1.2003	1.2003	1.286
17	.0857	1.2003	1.448	1.2003	1.2003	1.3717	1.3717
18	.0857	1.2003	1.267	1.286	1.267	1.4575	1.286
19		.1886		.1715	.181	.1886	.1715
20	.1715	.1886		.2572	.181	.1886	.2572
21	.2572	.1886	.1886		.181	.1886	.2572
22	.1715	.1886		.1715	.181	.1886	.1715
23		.1886	.1886	.1715	.181	.1886	.1715
24	.181	.1715	.1886	.1886	.1715	.181	.1886
Max	1.0288	1.286	1.6289	1.286	1.267	1.4575	1.3717
Min	.0857	.1715	.1886	.1715	.1715	.1715	.1715
Avg	.2339	.5366	.6953	.5494	.5192	.5658	.5823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.4374		
3	.8124				.6249	
4				.4687		.5468
6	.9998			.7186	.8124	
8	.9998			.7811	.5937	.7186
9	.9374			.7907		
12	.3125		.4999	.3906		.9374
14			.6562			
15				.6249		
16	.3125		.6874			.8749
17			.7186			
18	.3749	.4374		.3749		.4374
19			.4999			
20				.6249		
21			.5624			
23			.4999	.5624		
24	.3749			.4687	.4999	.3906
Max	.9998	.4374	.7186	.7907	.8124	.9374
Min	.3125	.4374	.4999	.3749	.4999	.3906
Avg	.6405	.4374	.5892	.5675	.6327	.6510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.0625	
4						.0625
5	.0156					
6					.0937	
8	.0156				.125	.125
9	.0156					
12	.0937		.0156	.0156		
14			.0156			.0156
15				.0625		
16	.0937		.0156			
17			.0156			
18	.0156	.0156		.0156		.0152
19			.0156			
20				.0156		
23				.0156		
24	.0156				.0312	.0312
Max	.0937	.0156	.0156	.0625	.125	.125
Min	.0156	.0156	.0156	.0156	.0312	.0152
Avg	.0379	.0156	.0156	.0250	.0781	.0499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.25	
4						.2187
6					.3125	
8					.3125	.3125
9	.0156					
12	.3437		.0156			
14			.0156			
15				.1875		
16	.3749		.0156			.0156
17			.0156			
18	.0156	.0156		.0156		
19			.0156			
20				.0156		
23				.0156		
24					.0937	.125
Max	.3749	.0156	.0156	.1875	.3125	.3125
Min	.0156	.0156	.0156	.0156	.0937	.0156
Avg	.1875	.0156	.0156	.0586	.2422	.1680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 201 / 11KV Mahalangra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.2997	.2286		.381	.3246
2		.3048	.341	.2667		.4572	.3663
3		.2858	.4097	.3048		.5716	.4136
4		.2477	.445	.3429		.6097	.4761
5		.2477	.5298	.3429		.6859	.5347
6		.2286	.6262	.381		.7621	.596
7		.1905	.6906	.362		.8192	.619
8		.2286	.7162			.7796	.6671
9		.1332	.3048	.2134		.5844	.8002
10	.381	.0666	.1524	.1524	.4763	.1932	.1905
11	.4954	.0682	.2286	.1067	.6097	.1656	.1905
12	.4954	.0494	.1905	.1067		.1648	.1905
13	.4954	.0563	.2096	.1067		.1665	
14	.5335		.1905	.061		.1367	.2096
15	.5335			.1067	.2667	.1302	.2286
16	.6097	.05		.1341	.3048	.1332	.1905
17	.6478	.0497	.2096		.1905		
18	.2096	.0487		.1524	.2667	.2728	
19		.0651		.2439	.3239	.3418	.3239
20		.0812		.2743	.4191	.3461	.381
21		.0993	.2858		.381	.2853	.3429
22		.0795	.2667		.3429	.2548	.2667
23	.2667	.0828	.2477		.3048	.2483	.3048
24		.3429	.2728	.2286		.3429	.333
Max	.6478	.3429	.7162	.381	.6097	.8192	.8002
Min	.2096	.0487	.1524	.061	.1905	.1302	.1905
Avg	.4668	.1505	.3483	.2166	.3533	.3840	.3786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 202 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.5716	.4285			.2286	.4058
2	.1905	.6097	.5603			.2286	.4967
3	.1905	.6859	.6118				.5823
4	.1905	.724	.7563			.2667	.648
5	.2286	.724	.9901			.3429	.7494
6	.2667	.9526	1.1766			.4191	.8949
7	.2667	1.0288	1.2291			.4954	.9415
8	.2286	1.0479	1.2618			.9145	1.049
9	.2667	.8278	.724			.957	1.2955
10		.161	.1905			.1665	.2286
11		.1987	.1524	.442		.1952	.2286
12		.1673	.1524	.4877		.1911	.2286
13		.1705	.1524	.6097	.8764	.1978	
14	1.3527	.1332	.1524		.8764	.1705	.1905
15	1.5242	.1274	.1524	.4877	.9526	.1656	.1524
16	1.5242	.1283		.2743	.2286	.1623	.1524
17	1.4861	.1627	.1905	.1524	.2667	.1665	
18	.1905	.1705		.1524	.2667	.1948	
19		.2051			.3429	.298	.2286
20		.2278		.2134	.3429	.446	.2667
21		.2222			.2667	.2734	.3429
22		.2051			.2286	.2469	.2667
23	.2286	.2252			.2286	.2291	.2286
24	.2286	.381	.3571			.2286	.4019
Max	1.5242	1.0479	1.2618	.6097	.9526	.957	1.2955
Min	.1905	.1274	.1524	.1524	.2286	.1623	.1524
Avg	.5346	.4191	.5434	.3525	.4434	.3124	.4752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 203 / 11KV Ashta

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3429	.2734	.3429	.2743	.3429	.3083
2	.2667	.381	.2438	.381		.3429	.3342
3	.2667	.4572	.2867	.4572	.3048	.381	.401
4	.3048	.5335	.4305	.4954		.4572	.4017
5	.381	.5716	.4613	.5716	.4268	.4954	.4785
6	.5144	.6097	.5335	.6097	.5487	.5716	.5469
7	1.2955	.5906	.5995	.6478	.4877	.6478	.5768
8	1.4861	.4763	.487	.4725	.4572	.4191	.4383
9	1.7147	.4189	.381	.381	.4954	.3311	.4572
10	1.5242	.8992	1.2765	.884	1.1431		1.3908
11	1.4098	1.1371	1.5432	.9145	1.1812		1.5242
12		1.2583	1.5051	.9907	1.1431	1.2675	1.6575
13		1.1946	1.467	.9145	1.3336	1.2252	
14		1.2223	1.5051		1.3336	1.2817	1.3908
15		1.1454	1.448	.9145	1.3336	1.2583	1.5623
16	.2477	.9741		1.0364	1.5242	1.2846	1.448
17	.2858	1.2817	1.5242	1.0974	1.5242	1.432	
18	.3429	.2302		.1829	.2667		
19		.3414		.3125	.381		.381
20		.3946			.4572	.3864	.4191
21		.4428	.4572		.4954	.4091	.4572
22		.3782	.4191	.3353	.4572	.3996	.4572
23	.3429	.4137	.381	.4268	.4191	.3996	.4191
24	.2667	.3048	.298	.3429	.2743	.3429	.2925
Max	1.7147	1.2817	1.5432	1.0974	1.5242	1.432	1.6575
Min	.2477	.2302	.2438	.1829	.2667	.3311	.2925
Avg	.6823	.6667	.7761	.6053	.7392	.6838	.7306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 201 / 11 KV LIMBALWADI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)
8		.7167
16	.0377	
Max	.0377	.7167
Min	.0377	.7167
Avg	.0377	.7167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 202 / 11 KV DEVANGARA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)
8		.7655
16	.1506	
Max	.1506	.7655
Min	.1506	.7655
Avg	.1506	.7655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 203 / 11 KV AMBULGA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)
8		.2729
16	.8944	
Max	.8944	.2729
Min	.8944	.2729
Avg	.8944	.2729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154098 / 33 KV SUB STATION TOGRI

Feeder No / Name : 203 / 11 KV WAGDRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5658			
2			.6036	.7922			
3				.9054			
4		1.1128	.679	1.0456			
5				1.1203			
6			1.2826	1.1949			
7				1.1576		1.1317	.6036
8	.7922	1.094	1.094	1.0829		.9465	.4904
9			.4527				1.0185
10			.4108		.8871	.5959	.7545
11			1.4937			1.6221	1.1949
12		1.358	1.531			1.7353	1.307
13			1.4937		1.2631		1.3443
14			1.419			1.6975	1.3443
15		1.4335	1.3443				1.3817
16	.4338		1.2696	1.3413		1.8107	1.3817
17			1.1576				1.419
18		1.3203	1.358		1.3123		1.4335
19		.679	.8676				.7167
20		.7167	.7922			.7167	.8676
21			.679				.7922
22			.6413			.6413	.679
23	.7356	.6036	.5658		.6516	.6036	.6413
24	.5281	.5847	.5658	.5658		.5258	.6036
Max	.7922	1.4335	1.531	1.3413	1.3123	1.8107	1.4335
Min	.4338	.5847	.4108	.5658	.6516	.5258	.4904
Avg	.6224	.9892	.9851	.9772	1.0285	1.0934	.9985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 201 / JAWALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.6287	.6287	.6097	.6097	.6668
2	1.0159		.6668	.7621	.6478	.6478	.8573
3	1.3032		.7621	.9526	.6859	.7621	.9526
4	1.3717		.8573	1.0669	.8002	.9145	1.0479
5	1.4403		.9526	1.0479	1.0669	1.0479	
6	1.1393		1.0669				
7	1.97						
8	2.3282						.4954
9	2.1491				.8764		.6097
10	.9221			.6859	.7811		.7621
11	.6097		1.6046		1.1065	1.3904	1.2193
12	.4954		1.9439	.5243	1.3603	1.6842	1.7147
13	.4382		1.9265		1.3283	1.7004	1.8176
14	.4001		1.9139	.6401	1.4575	1.6194	1.8781
15	.4001		1.8778	.7377	1.4419	1.4899	1.8625
16	.4382	1.3927	1.4259	.7712	1.4575	1.6194	
17	.4001	1.3927	1.0162	.7888	1.4899	1.3279	1.7909
18	.4191	1.166	1.1949	.7545	1.5708	1.4899	1.7909
19	.8002	.8002	.9907	.6859	.6287	.6859	.724
20	.8764	.9526	.8383	1.0288	1.0479	1.0288	1.0288
21	.8764	.8573	.7621	.9526	.9717	.8573	.8764
22		.7621	.6859	.6859	.8192	.7621	.8002
23		.6668	.6859	.6097	.724	.724	.724
24	.6097		.6287	.6097	.5716	.6478	.6478
Max	2.3282	1.3927	1.9439	1.0669	1.5708	1.7004	1.8781
Min	.4001	.6668	.6287	.5243	.5716	.6097	.4954
Avg	.9621	.9988	1.1215	.7741	1.0211	1.1058	1.1134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 202 / 11 KV KAUTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.5144	.4858	.5627	.3048	.5765	.4096
2	.381	.583	.5668	.5798	.3658	.6783	.5087
3	.4954	.6371	.5992	.5804	.3658	.7377	.6104
4	.5716	.7042	.6478	.5941	.4374	.8048	.6882
5	.6097	.7537	.763	.6487	.4687	.852	.8097
6	.7621	.8029	.8097	.6084	.4999	.9231	.9069
7	.4572	1.0688	.9995	.8355	1.0288	1.1498	1.247
8	.5716	1.1012	1.0526	.844	1.0974	1.1498	.9878
9	.4572	.9221			1.0288	.8745	.9393
10	.4191			.2458	.7935	.4858	.8573
11	.503		.2286		.2667	.2858	.3048
12	.8029		.2286	.2286	.2096	.2096	.2667
13	.8642		.2477	.2286	.2286	.1905	.2667
14	.8421		.2286	.2667	.2477	.2286	.2667
15	.8802		.2477	.2667	.2667	.2286	.2286
16	.8684		.2286	.2667	.2477	.2286	.2286
17	.7343	.2477	.2096	.2667	.1905		.2286
18	.8907	.2858	.2477	.2286	.2096	.2286	.3429
19	.4001	.4382	.5144	.4191	.362	.4001	.4191
20	.5144	.5335	.5716	.5716	.6097	.5906	.5716
21	.4763	.4763	.4382	.5335	.4763	.4954	.4954
22	.4191	.381	.362	.381	.4001	.381	.381
23		.3048	.3048	.3048	.3429	.3048	.3048
24	.2667	.3048	.2858	.3048	.2286	.3048	.2667
Max	.8907	1.1012	1.0526	.844	1.0974	1.1498	1.247
Min	.2667	.2477	.2096	.2286	.1905	.1905	.2286
Avg	.5866	.5917	.4667	.4439	.4449	.5352	.5224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 203 / 11 KV MATEGADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.4801	.4049	.5064	.3475	.5144	.3239
2	.1143	.503	.4858		.4458	.583	.3239
3	.1334	.5365	.5735	.5908	.4572	.6371	.4049
4	.1905	.5571	.6274	.5915	.5243	.6554	.4858
5	.2286	.583	.6478	.6097	.6036	.7209	.6783
6	.381	.6401	.7773	.6436	.6706	.7773	.7773
7	.2667	.7499	.9014	.6991	.823	.9175	.9717
8		.8124	.9717	.7327	.8916	.8421	.8097
9		.8421		.3559	.8916	.8745	.8478
10				.2622	.7499	.5087	.8048
11			.1524		.0953	.1334	.1524
12	.7373		.1143	.1143	.0762	.0762	.1143
13	.8097		.0953	.1143	.0572	.0762	.1143
14	.8421		.0953	.1143	.0572	.0953	.0953
15	.8097		.1143	.0953	.0572	.0762	.0953
16	.8718	.0762	.1143	.0953	.0572	.0953	.0762
17		.0762	.0953	.0953	.0762	.0762	.0953
18	.5868	.0953	.1334	.1143	.0762	.0762	.0953
19	.1905	.2286		.1905	.1524	.1524	.1524
20	.2286	.2858	.2286	.1905	.2286	.2286	.1905
21	.1524	.2477	.1905	.1524	.1905	.1905	.1905
22	.1524	.1905	.1143	.1524	.1524	.1524	.1524
23	.0762	.1524	.1334	.1143	.1143	.1334	.1334
24	.1143	.0686	.1334	.1143	.1143	.0953	.1334
Max	.8718	.8421	.9717	.7327	.8916	.9175	.9717
Min	.0762	.0686	.0953	.0953	.0572	.0762	.0762
Avg	.3685	.3959	.3383	.3022	.3296	.3620	.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 204 / Morge Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.0373		
9					.056		.0211
10				.0373	.0734	.0634	.0747
11	.0524				.0838	.0634	.056
12				.0653	.0524		.056
13				.0653			.0655
15	.0629		.0559				.0373
16	.0524	.0634	.0558		.0524		.0469
17		.0634	.037	.056	.0524	.0634	.0187
18		.0846	.0643	.056	.0838	.0529	
19					.0105		
20					.0105		
21					.0105		
22					.0105		
Max	.0629	.0846	.0643	.0653	.0838	.0634	.0747
Min	.0524	.0634	.037	.0373	.0105	.0529	.0187
Avg	.0559	.0705	.0533	.0560	.0445	.0608	.0470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 201 / mortalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		1.2003				
12	.6173		.6859	.4287	.8573	.4287
16	.3429			.3429		
20	.8573					
24		.5144				.3429
Max	.8573	1.2003	.6859	.4287	.8573	.4287
Min	.3429	.5144	.6859	.3429	.8573	.3429
Avg	.6058	.8574	.6859	.3858	.8573	.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 202 / khandsari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		1.2003				
12	1.2003		.0762		.0857	.0857
16	1.7147			.0857		
20	.0857					
24		.0857				1.0288
Max	1.7147	1.2003	.0762	.0857	.0857	1.0288
Min	.0857	.0857	.0762	.0857	.0857	.0857
Avg	1.0002	.643	.0762	.0857	.0857	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 203 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		.9431				
12	.3429		1.0669	.9431	1.0288	.8573
16	.2572			1.0288		
20	.8573					
24		.2572				.2572
Max	.8573	.9431	1.0669	1.0288	1.0288	.8573
Min	.2572	.2572	1.0669	.9431	1.0288	.2572
Avg	.4858	.6002	1.0669	.9860	1.0288	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 204 / shelgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5		1.3717				
12	1.7147		.1715	.1715	.1715	.1715
16	1.7147			.1715		
20	.1715					
24		.1715		.6859		1.0288
Max	1.7147	1.3717	.1715	.6859	.1715	1.0288
Min	.1715	.1715	.1715	.1715	.1715	.1715
Avg	1.2003	.7716	.1715	.3430	.1715	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 205 / mortalwadi-ww
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-18	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	.2229	.2058	.2058	
16	.2229			
24				.2058
Max	.2229	.2058	.2058	.2058
Min	.2229	.2058	.2058	.2058
Avg	.2229	.2058	.2058	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 201 / telgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0446	.0443	.0343	.036	.0425
2			.0463	.0461	.0343	.0446	.0443
3			.048	.0461	.036	.0463	.0461
4			.0497	.0478	.0377	.048	.0496
5			.0566	.0478	.0429	.0583	.0532
6			.0686	.0549	.048	.0652	.0673
7			.084	.0797	.0669	.0669	.0726
8			.0747	.0744	.0583		.0762
9			.06	.0669		.0532	
10	.0171		.0583	.0634		.0532	
11	.0429		.0137		.0142		
12	.0377		.012	.012			
13	.0394		.012	.012	.0142	.0137	
14	.06		.012	.0103	.0142	.0137	
15			.0103	.012	.0142	.0137	
16			.012			.0137	
17		.0103	.0106	.012	.012	.0142	.0137
18			.0124	.0137	.0137	.0159	.0137
19			.0248			.0266	.024
20			.0248	.0223	.0291	.0319	.0274
21			.0213	.0189	.024	.0248	.0257
22		.0189	.0177	.0189	.0206	.023	.0223
23		.0173	.0177		.0189	.0195	.024
24			.0154	.0159	.0154	.0189	.0195
Max	.06	.0189	.084	.0797	.0669	.0669	.0762
Min	.0171	.0103	.0103	.0103	.012	.0137	.0137
Avg	.0394	.0155	.0336	.0360	.0289	.0334	.0389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 202 / shirur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0103		.0206	.023	.0137	.0171	.0213
2	.0086		.0206	.023	.0154	.0171	.0213
3	.0086		.0206	.023	.0154	.0189	.0213
4	.0103		.0223	.0248	.0154	.0189	.023
5	.0103		.024	.0248	.0206	.0223	.0248
6	.0206		.0291	.0337	.024	.0291	.0301
7	.0257		.036	.0354	.024	.0309	.0337
8	.024		.0392	.0372	.0326	.0343	.039
9			.0291	.0326		.024	
10	.0309		.024	.0291		.024	
11	.0257		.0223	.0223	.023		
12	.0291			.0223	.0248	.024	
13	.0257		.0274	.0223	.0213	.024	
14	.024		.0257	.0206	.0248	.0223	
15			.024	.0223	.0248	.0206	
16			.024	.0257	.0248	.024	
17		.024	.023		.024	.023	.0257
18			.0266	.0274	.0257	.023	.0274
19			.0319		.0274	.0301	.0309
20			.0301		.0326	.0319	.0326
21			.0301	.0309	.0309	.0301	.0309
22		.0326	.0301	.0274	.0291	.0301	.0309
23		.0277	.0266		.0274	.0266	.0274
24	.0103		.0257	.0248	.0206	.0257	.0266
Max	.0309	.0326	.0392	.0372	.0326	.0343	.039
Min	.0086	.024	.0206	.0206	.0137	.0171	.0213
Avg	.0189	.0281	.0267	.0266	.0237	.0249	.0279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 203 / belur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0223		.0086	.0089	.0069	.0086	.0089
2	.024		.0086	.0089	.0086	.0086	.0089
3	.024		.0086	.0089	.0086	.0086	.0089
4	.024		.0086	.0124	.0086	.0086	.0106
5	.024		.012	.0124	.0171	.0154	.0124
6	.0257		.0171	.0177	.0171	.0189	.0177
7	.0343		.0154	.0177	.0154	.012	.0177
8	.0343		.0149	.0159	.0154	.0137	.0142
9	.0326		.012	.0137		.0137	.0177
10	.0343		.0103	.0086		.0103	
11	.0086		.0429	.0394	.0319	.0412	
12	.0069		.0467	.036	.0372	.0446	
13	.0069		.0429	.0429	.0372	.0412	
14	.0086		.0446	.0171	.0372	.0429	
15			.0446	.0394	.0372	.0394	
16			.0429	.0429		.0412	
17		.0446	.0408	.0412	.0394	.0425	.0412
18			.0372	.0412	.0412	.0425	.0394
19					.0137	.0142	.0137
20			.0142	.012	.0137	.0159	.0154
21			.0124	.0103	.012	.0106	.012
22		.0103	.0106	.0103	.0103	.0106	.012
23		.0104	.0106		.0103	.0089	.0103
24	.0069		.0086	.0089	.0069	.0086	.0089
Max	.0343	.0446	.0467	.0429	.0412	.0446	.0412
Min	.0069	.0103	.0086	.0086	.0069	.0086	.0089
Avg	.0212	.0218	.0224	.0212	.0203	.0218	.0159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 204 / shirur Exp.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181		.0171	.0177	.0181	.0171	.0177
2	.0181		.0171	.0177	.0181	.0171	.0177
3	.0181		.0171	.0177	.0181	.0171	.0177
4	.0181		.0171	.0177	.0181	.0171	.0177
5	.0181		.0171	.0177	.0181	.0171	.0177
6	.0181		.0171	.0177	.0181	.0171	.0177
7	.0181		.0171	.0177	.0181	.0171	.0177
8	.0181		.0187	.0177	.0181	.0171	.0177
9	.0181		.0181	.0171	.0181	.0181	
10	.0171		.0181	.0171		.0171	
11	.0171		.0181	.0171	.0177	.0181	
12	.0171		.0181	.0171	.0177	.0181	
13	.0171		.0181	.0171	.0177	.0181	
14	.0171		.0181	.0171	.0177	.0181	
15			.0181	.0171	.0177	.0181	
16			.0181	.0171	.0177	.0181	
17		.0171	.0177	.0181	.0171	.0177	.0181
18			.0177	.0181	.0171	.0177	.0181
19			.0177		.0171	.0177	.0181
20			.0177	.0181	.0171	.0177	.0181
21			.0177	.0181	.0171	.0177	.0181
22		.0171	.0177	.0181	.0171	.0177	.0181
23		.0173	.0177		.0171	.0177	.0181
24	.0181		.0171	.0177	.0181	.0171	.0177
Max	.0181	.0173	.0187	.0181	.0181	.0181	.0181
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0177
Avg	.0178	.0172	.0177	.0176	.0177	.0176	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 201 / kolnoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5144	.5658	.4715	.3772	.4715	.4715
2		.5144	.5658	.4715	.3772	.4715	.4715
3	.5658	.5487	.6413	.5281	.3772	.5658	.5281
4	.7545	.6344	.7167	.5658	.3772	.5658	.5658
5	.7545	.6516	.7545	.6602	.3772	.6413	.5658
6	.1715	.6859	.7922	.6602	.3772	.6979	.6602
7	.1715	.7716	.8488	.7545	.4715	.7167	.7545
8	.1715	.6859	.8488	.8488	.5144	.6602	.7545
9	.2572	.6001	1.0374	.8488	.6859	.6602	.6602
10	.4287	.5144	.8488		.6859	.5658	.6602
11	.4287		.5658		.4287	.6602	.5658
12	.4801		.5658		.3429	.5658	.5658
13	.4801	.2829	.5281		.3429	.5658	.4715
14	.5144	.2829	.4715		.3429	.4715	.4715
15	.5144	.3772	.4715		.3772	.4715	.3772
16	.5144	.3772	.3772		.3772	.3772	.3772
17	.5144	.3772	.3772		.3944	.3772	.2829
18	.5144		.4715		.4287	.7167	.4715
19	.4287	.4715	.4715		.6001	.8488	.6602
20	.7716	.6602	.6602		.6859	.8488	.6602
21	.8573	.6602	.7545		.6859	.6602	.5658
22	.823	.6602	.6602		.6001	.5658	.5658
23	.7716	.5658	.6602			.5658	.5658
24	.5658	.6859	.5658	.4715	.3772	.5658	.5658
Max	.8573	.7716	1.0374	.8488	.6859	.8488	.7545
Min	.1715	.2829	.3772	.4715	.3429	.3772	.2829
Avg	.5226	.5487	.6342	.6281	.4611	.5949	.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 202 / sonwala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.4715	.7545	.7545	.6602	.6602
2		.5144	.4715	.7545	.7545	.6602	.6602
3		.6001	.5281	.8488	.7545	.7545	.7545
4		.6344	.5658	.8488	.9431	.9054	.8488
5		.823	.5658	.9054	.9431	1.3203	.8488
6			.7167	1.1317	1.1317	1.4146	1.1317
7			.8488	1.226	1.2449		1.2826
8				1.2826	.4287	.9431	1.226
9				.9808	.4287	.9431	1.1317
10		.9602	.5658		.3429	.8488	.9431
11	.3772	.7545	.6602		.5487	.7167	.5658
12	.5144	.7545	.7545		.6001	.7167	.5658
13	.6001	.7545	.7545		.6001	.7545	.6602
14	.6173	.7922	.8488		.6001	.7545	.679
15	.6001	.7922	.8488		.6001	.7922	.7545
16	.6001	.7922	.8865		.5658	.8488	.7545
17	.6001	.8488	.8865			.8488	
18	.6859		.8488		.5658	.7545	.7545
19	.7202	.7545	.9431		.7716	.9431	1.1317
20		.8488	1.094		.8573	1.1694	1.094
21	.6001	.8488	1.0562		1.0288	1.094	.8488
22	.6001	.5658	.7545		.9431	.7922	.7545
23	.5144	.5658	.7545		.0686	.7545	.6602
24		.5144	.4715	.7545	.3772	.6602	.6602
Max	.7202	.9602	1.094	1.2826	1.2449	1.4146	1.2826
Min	.3772	.5144	.4715	.7545	.0686	.6602	.5658
Avg	.5858	.7176	.7407	.9488	.6893	.8718	.8422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 203 / mali hipparga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.5658		.5658	.5144
2		.3772	.5658		.5658	.5658
3		.5658	.6602		.6036	.5658
4		.5658	.6602		.6602	.6602
5		.6602	.7167		.6602	.6602
6		.6602	.7545		.7167	.7545
7		.7167	.9054		.7545	.8488
8		.7167	1.0185		.7545	.8488
9		.7545	.7545		.7545	.7545
10		.7545				.7545
11	.4715			.1715		.6602
12	.415			.2572		.5658
13	.3772	.7545		.4287	.6602	.547
14	.3772	.6602		.4287	.6602	.547
15	.3772	.6602		.4458	.4715	.4715
16	.3395	.5658		.4801	.5281	.4715
17	.415	.4715		.4801	.5658	.4715
18		.6979		.4801	.8488	.7545
19	.7545	.7545		.5144	1.1317	1.1317
20		.8488		.823	1.1317	1.0562
21	.9242	.8488		.8573	.9808	.8488
22	.3772	.8488		***	.7922	.7545
23	.3772	.5658		.6344	.6602	.7545
24		.3772	.5658		.6602	.6602
Max	.9242	.8488	1.0185	27.4177	1.1317	1.1317
Min	.3395	.3772	.5658	.1715	.4715	.4715
Avg	.4732	.6456	.7167	2.5707	.7203	.6926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 201 / kumtha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075	.0081	.8785	.0146	.0016	1.0277	
2	.0057	.0081	.9945	.0211	.0016	1.1904	
3	.0056	.0097	1.0608	.0224	.0016	1.3748	
4	.0056	.0098	1.2929	.0243	.0016	1.5257	
5	.0075	.0115	1.358	.0256	.0016	.0168	
6	.0094	.0131	1.4251	.025	.0016	.0184	
7	.0131	.0115	.0199	.0243	.0046	.0187	
8	.0112	1.0111	.0201	.0221	.003	.0218	.0122
9	.0093	.7127	.0218	.0237	.003	.0199	.009
10	.0075	.6706	.0184	.0205	.003	.0187	
11	.0081	.6722		.0056	.5041		
12	.0098	.6979		.0056	.5847		
13	.0115	.6535		.0055	.5658		
14	.0097	.5788		.0055	.5228		
15	.0081	.5041		.0037	.679		
16	.0097	.4854		.0055	.5975	.0055	
17	.0082	.5415			.5228		
18	.0065	.7468			.7095		
19	.0098	1.094			1.2136		
20	.0094	1.0562		.0131	1.2826		
21	.0093	.9896		.0055	1.0751		
22	.0094	.9335		.0056	1.0269		
23	.0075	.8589		.0037	.9149		
24		.0075	.8215	.0037	.0038	.8589	.0075
Max	.0131	1.094	1.4251	.0256	1.2826	1.5257	.0122
Min	.0056	.0075	.0184	.0037	.0016	.0055	.0075
Avg	.0087	.5119	.7192	.0136	.4261	.5081	.0096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 202 / chimachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0291	.0093	.9335	.0054	.0057	.9896	
2	.0295	.0112	.8962	.0165	.0075	.8865	
3	.0279	.0132	.9896	.017	.0094	.9335	
4	.0275	.0132	1.1949	.0168	.0094	1.1203	
5	.0308	.0149	1.3435	.0165	.0113	1.531	
6	.036	.017	.0182	.0183	.0151	.0207	
7	.0442	.0189	1.3923	.0131	.0168	.0205	
8	.0421	.017	1.2597	.0148	.0149	1.8298	.0166
9	.0459			.017		1.643	
10	.0459	1.2136		.0092		1.3443	
11	.0093	.0547		.0396	.0298		
12		.0564		.0396	.0315		
13	.0094	.053		.0411	.0332		
14	.0075	.0464		.0396	.0373		
15	.0093	.0469		.0396	.0381		
16	.0075	.0448		.0411	.0369	.0381	
17	.0056	.0453			.0332		
18	.0057	.0365			.0381		
19	.0151	1.2883			.8402		
20	.0151	1.4937		.0146	1.4377		
21	.0131	1.4377		.0055	1.363		
22	.0131	1.1694		.0072	1.2637		
23	.0112	1.0456		.0037	1.0642		
24		.0112	.9896	.0074	.0075	1.0456	.0094
Max	.0459	1.4937	1.3923	.0411	1.4377	1.8298	.0166
Min	.0056	.0093	.0182	.0037	.0057	.0205	.0094
Avg	.0219	.3547	1.0019	.0202	.2884	.9502	.013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 203 / shivankhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0057	.0259	.7127	.034		.0235	
2		.0295	.6796	.0364		.0201	
3		.0308	.779	.0475		.0168	
4		.034	.8288	.1139		.0184	
5			1.2431	.0348		.0215	
6			1.326	.0496		.0302	
7	.0149		.0431	.0496		.039	
8	.0131		.0464	.0432		.0373	.0352
9	.0112	.0688	.041	.0437		.0369	.0323
10	.0093	.0381	.0431	.0357		.0335	
11	.0372	.7095					
12	.0393						
13	.0405	.547		.0019			
14	.0389	.679		.0037	.6161		
15	.0405	.5788		.0037	.5601		
16	.0389	1.083		.0037	.0298	.0037	
17	.0389	1.1202			.0282		
18	.0372	.679			.5601		
19	.0113	.8402			.9997		
20	.0093			.0093	1.1763		
21	.0093	.9149		.0054	.9335		
22	.0094	.8865		.0056	.8962		
23	.0075	.8029		.0055	.7922		
24		.0075	.7468	.009		.7282	.0057
Max	.0405	1.1202	1.326	.1139	1.1763	.7282	.0352
Min	.0057	.0075	.041	.0019	.0282	.0037	.0057
Avg	.0229	.5042	.5900	.0282	.6592	.0841	.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 201 / hadolti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6001	.5087	.6335		.6001	.5087
2		.6001	.5935	.6335		.6001	.5087
3	.6001	.6001	.5935	.6268		.6001	.5087
4	.6001	.6859	.6783	.8059		.6859	.5935
5	.6001	.7716	.8478	1.0631		.8573	.6783
6	.8573	1.0288	1.0174	1.1269		1.1145	.8478
7	.8573	1.2003	1.0288	1.1145		1.1145	1.0174
8	.9431	.9431	1.0288	1.0288		.9431	1.0402
9	.6859	.8573		.9431		.7716	.8669
10	.5144			.8573		.7716	.6859
11		.8669	.8573	1.1145	1.1145	.8669	.9536
12	.6001	1.0402	1.0288	1.0288	1.3717	.8669	1.286
13	.5144	1.0402	1.1145	1.286		1.2136	1.2003
14	.5144		1.1145	1.286	1.286	1.2136	1.2003
15	.5144		1.1145	1.1145	1.2003	1.2136	1.2003
16	.5144	1.1269	1.1145	1.1145	1.286	1.2136	1.1145
17	.4287	1.0402	1.1145	1.1145	1.3717	1.2136	1.1145
18	.4287		1.1145	1.1145	1.286	1.2136	1.1269
19	.9431		.724	.6859	.9431	.6783	.724
20	.8573		.9955	.9431	.9431	.763	.9955
21	.8573		.9145	.8573	.9431	.8478	.9145
22	.6859	.6783	.823	.6859	.8573	.8478	.9145
23	.6859	.5935	.823		.6859	.6783	.823
24		.6001	.5087	.7316		.6859	.5935
Max	.9431	1.2003	1.1145	1.286	1.3717	1.2136	1.286
Min	.4287	.5935	.5087	.6268	.6859	.6001	.5087
Avg	.6601	.8396	.8936	.9526	1.1074	.8990	.8924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 202 / jagalpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.3391	.4525		.4287	.3391
2		.5144	.3391	.4477		.4287	.3391
3	.5144	.5144	.3391	.443		.4287	.3391
4	.5144	.6001	.3391	.5316		.5144	.3391
5	.5144	.6859	.4239	.6135		.6001	.4239
6	.6001	.7716	.5087	.6935		.6859	.5087
7	.6859	.7716	.5144	.6859		.6859	.5087
8	.6001	.6859	.4287	.6001		.6001	.5087
9	.6859	.5144		.5144			.4239
10	.5144		.4287	.4287		.4287	.3429
11	.4287	.6935	.5144	.4287	.4287	.6935	.5201
12	.4287	.6935	.5144	.8573	.3429	.6935	.6001
13	.3429	.6935	.5144	.5144	.3429	.6935	.5144
14	.3429		.5144	.8573	.3429	.6935	.5144
15	.3429		.5144	.6001	.3429	.6935	.5144
16	.3429	.6935	.5144	.6001	.3429	.6068	.5144
17	.3429	.6935	.5144	.6001	.3429	.6068	.5144
18	.3429		.5201	.5144	.4287	.6068	.5201
19	.6859		.6335	.6001	.6001	.4239	.4525
20	.6001		.724		.6001	.4239	.6335
21	.6001		.6401		.6001	.4239	.6335
22	.5144	.5087	.5487		.6001	.3391	.5487
23	.5144		.5487		.5144	.3391	.5487
24		.5144	.3391	.4572		.5144	.3391
Max	.6859	.7716	.724	.8573	.6001	.6935	.6335
Min	.3429	.5087	.3391	.4287	.3429	.3391	.3391
Avg	.4981	.6290	.4876	.5720	.4484	.5458	.4767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 203 / walsangi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4334	.543		.1715	.4334
2		.4287	.5201	.6268		.1715	.5201
3	.3429	.4287	.5201	.6268		.1715	.6068
4	.4287	.6001	.6068	.7087		.1715	.6935
5	.4287	.6859	.6935	.7888		.1715	.6935
6	.6001	.7716	.8669	.8669		.1715	.8669
7	.5144	1.1145	1.1145	1.1145		.1715	1.0402
8	.4287	1.0288	1.0288	1.0288		.1715	1.0402
9	.3429	.8573		.8573			.9536
10		.4287		.6859			.8573
11	.6859	.3391		.2572			.2601
12	1.1145	.2543		.2572		.6935	.1715
13	.9431	.2543		.2572		.9536	.1715
14	1.0288		.2572	.2572	.0857	.9536	.1715
15	.9431		.2572	.2572	.0857	.8669	.1715
16	1.0288		.2572	.2572	.2572	.5201	.1715
17	1.0288		.2572	.3429	.2572	.2543	.1715
18	.9431		.3506	.3429	.2572	.2543	.2601
19	.6001		.4525	.4287	.4287	.4239	.4525
20	.5144		.543	.3429	.5144	.4239	.6335
21	.4287		.5487	.3429	.4287	.4239	.5487
22	.4287	.4239	.4572	.3429	.4287	.3391	.4572
23	.4287	.3391	.4572		.3429	.3391	.4572
24		.4287	.3391	.4572		.3429	
Max	1.1145	1.1145	1.1145	1.1145	.5144	.9536	1.0402
Min	.3429	.2543	.2572	.2572	.0857	.1715	.1715
Avg	.6602	.5508	.5243	.5214	.3086	.3886	.5132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 201 / jalkot

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7545		.7468	.7468	.7468	.7468
8		.7545	.7468	.7468	.7468	.7468	.7468
12	.7545		.7468	.7468	.7468	.7468	.7468
16	.7545		.7468	.7468	.7468	.7468	.7468
20	.7545		.7468	.7468	.7468	.7468	.7468
24	.7545	.7545		.7468	.7468	.7468	.7468
Max	.7545	.7545	.7468	.7468	.7468	.7468	.7468
Min	.7545	.7545	.7468	.7468	.7468	.7468	.7468
Avg	.7545	.7545	.7468	.7468	.7468	.7468	.7468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 202 / kunki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2543		.1867	.2801	.2801	.2801
8		.2829	.1867	.1867	.1867	.1867	.2801
12	.1696		.5601	.5601	.503	.6706	.4191
16	.1696		.7468	.503	.503	.6706	.503
20	.2543		.1867	.2801	.2801	.2801	.2801
24	.3353	.2543		.1867	.2801	.2801	.2801
Max	.3353	.2829	.7468	.5601	.503	.6706	.503
Min	.1696	.2543	.1867	.1867	.1867	.1867	.2801
Avg	.2322	.2638	.4201	.3172	.3388	.3947	.3404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 203 / ravankola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.1022		1.1736		1.0898	1.0898
8			1.1736	1.3413	.6706	1.1736	1.0898
9		.3391					
12	1.3203		.2801	.2801	.2801	.2801	.2801
16	1.307			.2801	1.1736	.1867	.2801
20	.3734		.2801	.2801	.3734	.3734	.3734
24		.3772		.9335		.6706	.6706
Max	1.3203	1.1022	1.1736	1.3413	1.1736	1.1736	1.0898
Min	.3734	.3391	.2801	.2801	.2801	.1867	.2801
Avg	1.0002	.6062	.5779	.7148	.6244	.6290	.6306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 202 / sandol

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.1524	1.9814	1.7528	1.6004	1.7528
8	.1524					
24	.1524	.1524	1.5242	1.9357	.1524	1.2955
Max	.1524	.1524	1.9814	1.9357	1.6004	1.7528
Min	.1524	.1524	1.5242	1.7528	.1524	1.2955
Avg	.1524	.1524	1.7528	1.8443	.8764	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 203 / jaybhachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.3429	.3429	.3429		.3429
8	1.6289					
24	.3429	.3429	.3429	.3429	.3429	.3429
Max	1.6289	.3429	.3429	.3429	.3429	.3429
Min	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.9859	.3429	.3429	.3429	.3429	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.153	1.0526	1.1191	1.153	.8907	1.0526	1.1336
2	1.153	1.065	1.0852	1.153	.8907	1.004	1.1012
3	1.1191	1.004	1.0852	1.1191	.8583	1.004	1.0526
4	1.1191	.9717	1.0852	1.1191	.8421	1.004	1.0526
5	1.153	1.0526	1.1191	1.1191	.8907	1.0526	1.1012
6	1.17	1.1336	1.17	1.1869	.9555	1.1822	1.1984
7	1.2378	1.2955	1.3565	1.3565	1.0513	1.3279	1.247
8	1.2887	1.3765	1.3565	1.4243	1.0526	1.4089	1.2955
16	1.1012					.5596	
17	1.0927	1.0852		1.0526		.5426	
18	1.0764	1.1869	1.2289	1.166		.5426	
19	1.2955	1.4243	1.3108	1.3927			
20	1.4575	1.4922	1.4251	1.2955			
21	1.3765						
22	1.2955	1.4243					
23	1.2146	1.2548		.9717			
24	1.2039	1.085	1.1869	1.1869	.9231	1.1336	1.5546
Max	1.4575	1.4922	1.4251	1.4243	1.0526	1.4089	1.5546
Min	1.0764	.9717	1.0852	.9717	.8421	.5426	1.0526
Avg	1.2063	1.1936	1.2107	1.1926	.9283	.9846	1.1930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.2915	.3052	.3052	.2401	.2915	.2915
2	.2374	.2743	.2713	.2713	.2229	.2572	.2572
3	.2374	.2743	.2713	.2713	.2229	.2572	.2572
4	.2374	.2743	.2713	.2713	.2401	.2572	.2572
5	.2543	.2915	.2713	.2713	.2572	.2915	.2915
6	.2883	.3086	.3052	.3052	.3086	.3429	.3086
7	.3052	.3429	.3391	.3391	.3429	.4115	.3258
8	.373	.3772	.1865	.3561	.3944	.4287	.4115
16	.4287					.39	
17	.463	.407		.4801		.4748	
18	1.5432		.5316	.5144		.5087	
19	.5487	.6104	.5487	.583			
20	.6001	.5935	.5487	.6001			
21	.5144	.5087					
22	.3772	.39		.3601			
23	.3429	.3391		.3086			
24	.2543	.3258	.3052	.3222	.2572	.3429	.3258
Max	1.5432	.6104	.5487	.6001	.3944	.5087	.4115
Min	.2374	.2743	.1865	.2713	.2229	.2572	.2572
Avg	.4270	.3739	.3463	.3706	.2763	.3545	.3029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 203 / 11 KV TELEPHONE Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0724	.0678	.0678	.0724	.0724	.0724
2	.0678	.0724	.0678	.0678	.0724	.0724	.0724
3	.0678	.0724	.0678	.0678	.0724	.0724	.0727
4	.0678	.0724	.0678	.0678	.0724	.0724	.0724
5	.0678	.0724	.0678	.0678	.0724	.0724	.0724
6	.0678	.0724	.0678	.0678	.0724	.0724	.0724
7	.0678	.0724	.0678	.0678	.1086	.0724	.0724
8	.0678	.0724	.0678	.0678	.0724	.0724	.0724
16	.1543					.1865	
17	.1372	.1696		.1448		.1865	
18	.12	.1357	.1629	.1086		.0678	
19	.1029	.1187	.1086	.0724			
20	.0724	.1526	.0724	.0724			
21	.0724	.0678					
22	.0724	.0678		.0724			
23	.0724	.0678		.0724			
24	.0678	.0724	.0678	.0678	.0724	.0724	.0724
Max	.1543	.1696	.1629	.1448	.1086	.1865	.0727
Min	.0678	.0678	.0678	.0678	.0724	.0678	.0724
Avg	.0832	.0895	.0795	.0769	.0764	.0910	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.78	.7125	.7122	.8478	.6478	.7773	.7773
2	.7461	.6802	.7122	.8139	.6478	.7287	.7287
3	.7461	.6554	.7122	.8139	.6154	.7287	.7287
4	.7461	.7537	.7461	.8139	.6154		.7287
5	.8139	.8097	.78	.8817	.6478	.8097	.8192
6	.9156	.9393	.8817	.9496	.8907	.9717	.9717
7	1.0343	1.0526	1.1191	1.1869	.9717	1.2146	1.0526
8	1.1361	1.1336	.9496	1.153	1.0526	1.2289	1.1012
16	1.0526					1.2378	
17	1.1336			1.1336		1.153	
18	1.1336	1.0513	1.3108	1.2955		1.2378	
19	1.3765	1.3056	1.3765	1.5061			
20	1.4251	1.0852	1.4746	1.5384			
21	1.1336	1.0174					
22	.9717	.8987		.8097			
23	.8097	.8139		.7773			
24	.78	.7287	.7461	.8987	.7287	.8097	.8097
Max	1.4251	1.3056	1.4746	1.5384	1.0526	1.2378	1.1012
Min	.7461	.6554	.7122	.7773	.6154	.7287	.7287
Avg	.9844	.9092	.9601	1.028	.7575	.9907	.8575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859			.7716	
2		.7202			.6859	
3		.6859			.8573	
4		.823			.8573	
5		.8573			.8916	
6		.8573			.8573	
7		1.1145			.9945	
8		1.0288			1.1145	
9			1.0288			.9431
10			.8573			.9431
11			.7716			.8573
12			.8916			
13			.9335			
14			.8573			
15			.8688			
16			.7716			
17	.8573					
18	.8573					
19	.8573					
20	.9431			1.0288		
21	.8573			1.0288		
22	.8573			1.0631		
23	.8573			.9431		
24		.8145			.6859	
Max	.9431	1.1145	1.0288	1.0631	1.1145	.9431
Min	.8573	.6859	.7716	.9431	.6859	.8573
Avg	.8696	.8430	.8726	1.0160	.8573	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6335			.7842	
2		.6535			.6001	
3		.6722			.7095	
4		.6535			.7468	
5		.724			.9335	
6		.905			.9709	
7		.9335			.9335	
8		.9896			1.0456	
9			1.2136			1.587
10			1.307			1.7194
11			1.4003			1.9605
12			1.5497			
13			1.363			
14			1.4003			
15			1.267			
16			1.6057			
17	1.7177			1.4937		
18	1.587			1.2883		
19	1.4937			1.307		
20	1.4003			1.4003		
21	1.086			.9335		
22	.8402			.724		
23	.7468			.7468		
24		.6535			.7468	
Max	1.7177	.9896	1.6057	1.4937	1.0456	1.9605
Min	.7468	.6335	1.2136	.724	.6001	1.587
Avg	1.2674	.7576	1.3883	1.1277	.8301	1.7556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 208 / VAISHALI AGRO EXPRESS

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373			.0934	
2		.0373			.0747	
3		.0373			.12	
4		.0373			.0934	
5		.0373			.0373	
6		.0373			.0373	
7		.0373			.0373	
8		.0373			.0373	
9			.0373			.0362
10			.0343			.0362
11			.0373			.0373
12			.0373			
13			.0934			
14			.168			
16			.1867			
17	.0373			.168		
18	.0373			.1494		
19	.0373			.168		
20	.0362			.1267		
21	.0373			.0747		
22	.0373			.0747		
23	.0362			.0724		
24		.0362			.0747	
Max	.0373	.0373	.1867	.168	.12	.0373
Min	.0362	.0362	.0343	.0724	.0373	.0362
Avg	.0370	.0372	.0849	.1191	.0673	.0366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 201 / 11KV BODHAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3155	.3155	.3506	.298	.3155	.3429
2	.3155	.298	.3155	.3155	.2804	.3155	.3429
3	.298	.298	.3155	.3155	.2804	.333	.3429
4	.298	.3155	.3506	.333	.298	.3506	.3429
5	.333	.3856	.4207	.3856	.3155	.4207	.3429
6	.3506	.4207	.4557	.4207	.3506	.4557	.3772
7	.4557	.5083	.5083	.5083	.4557	.4908	.4458
8	.4557	.5083	.4733	.5083	.4382		.4458
9	.4694	.4115	.4191	.3856	.4115	.4694	.4359
10	.4862	.4115	.4024	.3856	.4287	.4694	.4024
11	.4359	.3944	.3688	.3856	.4458	.4694	.4527
12	.4024		.3521	.4024	.4458	.4527	.4359
13	.4191		.3688	.4191	.4115	.4359	.4527
14	.4191		.3856	.4191	.4458	.4191	.4359
15	.4024		.4024	.4191	.4115	.4024	.4024
16	.4191	.6036	.3521	.3856	.3772	.4191	.4024
17	.4694	.57	.3601	.4287	.4031		.4115
18	.4694	.57	.3772	.4458	.4207		.4458
19	.5197	.57	.4801	.3772	.5258		.4801
20	.5197	.5197	.4458		.5609		.5144
21	.4862	.503	.4801		.4908		.5144
22	.4557	.4557	.4557	.3506	.4908		
23	.4207	.4207	.4207	.3506	.4207		
24	.3506	.3506	.3506	.3856	.298	.3506	.3772
Max	.5197	.6036	.5083	.5083	.5609	.4908	.5144
Min	.298	.298	.3155	.3155	.2804	.3155	.3429
Avg	.4153	.4415	.3990	.3945	.4044	.4106	.4158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006		.0838	.1174	.0503	.0838	.0671
2	.1006		.0838	.1174	.0503	.0838	.0503
3	.1006		.0838	.1006	.0503	.0838	.0671
4	.1006		.1006	.1006	.0671	.1006	.1006
5	.1006		.1006	.1174	.0671	.1006	.1006
6	.1174		.1006	.1006	.1006	.1006	.1174
7	.1006		.1006	.1509	.0503	.1006	.1341
8	.1341		.0838		.0503		.1341
9	.1311		.0983		.0503	.1147	.1311
10	.1311	.0671	.1311	.0492	.0671	.1147	.1341
11	.1475	.1677	.0983	.0983	.0671	.0655	.1006
12	.1475		.0983	.1475	.0503	.0983	.1006
13	.1311		.1311	.1311	.0503	.1147	.1006
14	.1147		.1638	.1311	.0671	.0983	.0983
15	.1311		.1475	.1638	.0838	.0983	.0819
16	.1638	.1475	.1475	.1638	.0838	.0838	.1147
17	.1638		.1677	.1677	.1006		.1174
18	.1802		.1677	.1844	.1174		.1341
19	.1311	.1311	.1341	.1677	.1006		.1174
20	.1311	.1147	.1341		.0838		.1174
21	.1147	.0983	.1341		.0838		.1174
22	.0671	.1006	.1341	.0503	.1006		
23	.0503	.1006	.1341	.0503	.1006		
24	.1006		.0838	.1341	.0503	.1006	.0671
Max	.1802	.1677	.1677	.1844	.1174	.1147	.1341
Min	.0503	.0671	.0838	.0492	.0503	.0655	.0503
Avg	.1205	.1160	.1185	.1222	.0727	.0964	.1047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.4066	.4066	.462	.3696	.4066	.4435
2	.3326	.3696	.3696	.4066	.3326	.3696	.4251
3	.3326	.3511	.3696	.3696	.3326	.3696	.4066
4	.3511	.3511	.3881	.3881	.3696	.3881	.4435
5	.3696	.4066	.4435	.4435	.4435	.4066	.4251
6	.3881	.462	.5175	.499	.5175	.4435	.4435
7	.499	.7023	.6468	.5729		.5914	.5544
8	.5175	.7577	.6653	.5175	.5359		.6653
9	.5365	.7023	.6371	.5365	.6099	.6706	.7042
10	.57	.6653	.7042	.5868	.5544	.6706	.7042
11	.57	.6653	.6706	.6371	.5175	.6371	.6371
12	.4862		.6371	.7042	.4805	.6706	.6706
13	.5365		.6036	.7377	.4435	.7042	.6706
14	.57		.5868	.7545	.5175	.6539	.6371
15	.5868		.7545	.5868	.6283	.6371	.503
16	.6036	.7712	.6203	.7545	.7023	.7042	.6036
17	.6036	.6874	.7023	.8686	.7023		.6283
18	.6203	.7712	.7392	.9055	.6838		.6653
19	.7209	.8383	.7947	.961	.7392		.6838
20	.6706	.7545	.7577		.7762		.7207
21	.57	.6874	.7577		.7577		.5914
22	.5729	.5544	.6653	.4805	.6653		
23	.5175	.4805	.5359	.4251	.5359		
24	.4435	.4435	.462	.499	.4066	.462	.4805
Max	.7209	.8383	.7947	.961	.7762	.7042	.7207
Min	.3326	.3511	.3696	.3696	.3326	.3696	.4066
Avg	.5149	.5914	.6015	.5953	.5488	.5491	.5776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.5853	.5853	.5853	.5121	.5853	.5853
2	.5487	.567	.5487	.5487	.5121	.567	.5853
3	.5121	.5487	.5304	.5304	.5121	.567	.5853
4	.5121	.5487	.5304	.5304	.5304	.5487	.567
5	.5304	.567	.5853	.567	.5304	.5853	.5853
6	.5487	.6219	.6036	.6036	.5487	.6036	.6219
7	.6401	.6036	.695	.6401	.6219	.6584	.6401
8	.6401	.6767	.7133	.7316	.6036		.695
9	.6203	.7133	.6706	.6036	.6767	.6203	.6203
10	.6706	.7316	.7042	.6203	.7316	.7042	.6371
11	.6706	.7316	.8383	.788	.8048		.7545
12	.6706		.9054	.8215	.8413	.7712	.7712
13	.7042		.9054	.788	.8596		.8048
14	.7209		.8718	.7712	.8048	.8215	.7712
15	.7377		.8383	.8215	.7682		.7545
16	.7712	1.0059	.8215	.788	.7682	.788	.7716
17	.7712	.9389	.9145	.8779	.8413		.8413
18	.7712	.9389	.9145	.8596	.8962		.9145
19	.9054	.9724	1.0242	.8779	.9877		.9511
20	.8718	.9054	1.0059		1.0974		.9694
21	.8048	.8048	.9328		.9328		.8962
22	.7499	.8048	.8048	.7316	.8048		
23	.7133	.695	.695	.6219	.7316		
24	.6584	.6219	.6219	.6401	.5487	.6401	.6767
Max	.9054	1.0059	1.0242	.8779	1.0974	.8215	.9694
Min	.5121	.5487	.5304	.5304	.5121	.5487	.567
Avg	.6819	.7292	.7609	.6976	.7278	.6508	.7273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI
HEALTHCAR Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886		.0886	.1063	.0886	.0709	.1417
2	.0886	.0709	.0886	.1063	.0886	.0886	.1417
3	.0886	.0886	.0886	.0886	.0886	.0886	.1595
4	.1063	.0886	.124	.0886	.1063	.1063	.1417
5	.124	.0886	.124	.1063	.124	.1063	.1417
6	.1063	.0886	.1063	.1063	.0886	.1063	.1417
7	.124	.0709	.1063	.124	.0709	.1063	.1417
8	.0886	.0886	.0886	.0886	.0709		.1063
9	.0838	.0886	.0838	.1341	.0701		.1006
10	.0838	.1063	.0838	.1174	.0876	.0838	.0838
11	.0838	.1063	.0838	.0838	.1052		.0838
12	.0838		.0838	.0838	.1052	.0838	.1006
13	.0838		.0838	.0838	.1227		.1677
14	.0838		.0838	.0838	.1227	.0838	.1341
15	.0838		.0838	.0838	.1052		.0838
16	.0838	.1006	.1006	.0838	.1052	.0838	.1509
17	.1006	.1006	.1417	.1052	.1063		.1402
18	.1341	.1006	.1595	.1227	.124		.1227
19	.1341	.1677	.1595	.1227	.1063		.1063
20	.1341	.1677	.1063		.1063		.0886
21	.1341	.1677	.1772		.0709		.1063
22	.124	.124	.1417	.0709	.0709		
23	.0886	.0886	.124	.0709	.0886		
24	.1063	.0709	.0886	.1063	.0709	.0709	.1417
Max	.1341	.1677	.1772	.1341	.124	.1063	.1677
Min	.0838	.0709	.0838	.0709	.0701	.0709	.0838
Avg	.1017	.1039	.1084	.0985	.0956	.0900	.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 404 / 33KV O/G Nalgir

Feeder KV- 33 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6539	1.0059	3.9735	4.0238	1.7101	4.3256	3.4979
2	.7545	1.5592	4.3256	3.9232	1.7101	4.225	3.7037
3	.8048	1.6095	4.3256	3.9232	1.8107	4.1244	3.858
4	1.358	1.7101	4.4262	4.0741	2.1125	4.4262	4.0124
5	1.861	1.9616	5.5327	4.225	2.7161	4.9291	4.9383
6	2.3137	2.364	6.1363	5.3818	3.3196	6.1363	5.4527
7	2.7664	2.9675	7.3937	6.2369	4.9291	6.941	6.1214
8	2.6155	2.5652	5.8345	5.9351	4.6273		5.8128
9	1.5592	2.4177	5.7339	5.7339	5.1303	5.1806	5.1806
10	2.6155	.6173	4.225	4.4765	4.6273	5.0297	4.3759
11	2.4143	1.5432	4.3256	4.0741	3.9735	2.8669	3.6717
12	2.3137		3.8729	4.5771	4.0238	3.8226	4.1244
13	2.2131		4.1244	4.4765	4.1244	3.8729	4.225
14	2.1628		4.3759	4.3759	4.5268	3.7723	4.1244
15	2.2131		4.225	4.0741	4.8285	3.722	3.6717
16	2.4646	2.0119	3.8729	4.0741	5.2309	3.5711	3.8729
17	2.364	2.8669	4.2181	4.0238	4.8285		
18	2.2131	2.8166	4.2696	3.9735	4.2753		3.0681
19	.8551	2.9172	2.8807	4.0238	3.219		3.0864
20	1.0059	3.5208	3.0864		4.0238		2.9835
21	1.0059	3.3196	2.572		3.1184		2.5206
22	.9556	2.9675	2.5149	1.5089	3.1184		
23	.7545	3.219	2.0622	1.4083	2.8166		
24	.6036	.7042	3.219	3.1184	1.6095	3.3196	2.9321
Max	2.7664	3.5208	7.3937	6.2369	5.2309	6.941	6.1214
Min	.6036	.6173	2.0622	1.4083	1.6095	2.8669	2.5206
Avg	1.7017	2.2332	4.2303	4.1655	3.6004	4.3916	4.0588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9835	2.8807	5.9671	6.07	3.0864	5.7613	5.5213
2	3.035	3.035	6.0185	5.9671	3.0864	5.7613	5.679
3	3.0864	3.0864	6.07	5.9671	3.1379	5.6584	5.7842
4	3.1893	3.2922	6.1728	6.1728	3.2407	6.1728	5.8368
5	4.0124	3.5494	7.2017	6.3786	3.6523	6.3786	7.1514
6	4.5268	3.9095	8.3333	7.0473	4.2181	7.9218	7.6772
7	5.5556	4.8868	9.8251	8.7449	5.9671	8.8477	8.4659
8	5.5041	4.784	8.2305	7.9218	6.6873		8.0979
9	4.3759	4.5222	6.9913	7.7458	6.1728	7.7458	7.2428
10	5.2309	3.5757	6.2369	6.5889	6.4815	7.8464	6.6895
11	3.7723	4.9429	7.3434	7.2428	6.6358	4.6273	7.0416
12	4.3256		7.4943	8.2991	6.6873	5.6836	7.9973
13	4.3256		7.9973	8.1985	6.893	5.583	7.947
14	4.3256		8.0476	8.1482	7.7161	6.4381	7.9973
15	4.7279		7.6452	7.7458	8.3333	6.4381	6.8404
16	4.8788	6.3878	7.0416	8.1482	8.4362	6.9913	7.2931
17	4.3256	6.4883	8.3082	8.2305	8.0247		6.5844
18	4.1747	6.941	8.4134	8.0247	7.7161		6.6873
19	3.9232	5.8848	6.0997	7.7161	6.2243		6.2049
20	3.9735	6.1363	6.2049		7.0473		5.7842
21	3.2693	6.0357	5.7316		6.07		5.3635
22	3.2922	5.3498	5.0412	2.7778	5.5041		
23	2.9835	5.1955	4.6296	2.572	5.0926		
24	2.5206	2.6235	5.144	5.0926	2.9321	5.2469	4.6799
Max	5.5556	6.941	9.8251	8.7449	8.4362	8.8477	8.4659
Min	2.5206	2.6235	4.6296	2.572	2.9321	4.6273	4.6799
Avg	4.0133	4.6754	6.9246	6.8546	5.7935	6.4439	6.7530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.4287	.5087	.5144	.5201	.5144	.6783
2	.3467	.5144	.763	.6859	.6935	.6859	.8478
3	.3467	.6859	.763	.6859	.6935	.7716	.9156
4	.4334	.6859	.8478	.6859	.6935	.8573	1.0174
5	.4334	.8573	.8478	.8573	.8669	.8573	1.1022
6		.9431	1.0174	.9431	.9536	.9431	1.153
7	.5201	1.0288	1.0174	.8573	.8669	1.286	1.2887
8	.5201	.7716	1.1022	1.0288	1.1269	1.3717	1.2887
9		.7716	1.0288	.8573	1.1269	1.286	1.1317
10		.9431	.9431	.8573	1.0288	1.2003	1.0288
11		.2572	.2572	.3467	.2572	.3429	.2743
12				.3467	.2572	.3429	.2743
13	.4287	.2572		.2601		.3429	.2743
14	.2572	.2572		.2601	.2572	.3429	.2743
15		.2572	.1715	.2601	.2572	.3429	.2743
16		.2572	.2572	.2601	.2572	.2572	.2058
17		.2572	.2572	.2601	.2572	.2572	.2058
18		.2572	.2572	.3467	.2572	.3429	.2058
19		.4287	.2572	.4334	.3429	.4287	.3429
20	.4287	.5144	.4287	.4334	.4287	.5144	.4801
21	.4287	.4287	.4287			.4287	.4287
22	.3429	.4287	.4287	.3467	.3429	.4239	.3772
23	.3429	.3429	.3429	.3467	.3429	.3391	.2572
24	.3467		.3429	.3429		.3429	.3391
Max	.5201	1.0288	1.1022	1.0288	1.1269	1.3717	1.2887
Min	.2572	.2572	.1715	.2601	.2572	.2572	.2058
Avg	.3945	.5261	.5842	.5312	.5633	.6176	.6111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.6935	.8573	.8669	.8764	.7802	.823
2	.3506	.7802	1.0288	.8669	.8669	.8573	.9602
3	.3506	.8669	1.0288	.8669	.8669	.9536	1.1145
4	.3506	1.0631	1.2003	.8669	1.0517	1.0288	1.1869
5	.4334	1.2136	1.286	1.0402	1.2269	1.0288	1.3375
6	.5258	1.5061	1.3717	1.2136	1.4022	1.0288	1.3717
7	.5258	1.5604	1.1145	.9536	1.0517	1.0402	1.166
8	.5258	1.2136	1.1145	1.0402	1.2269	1.0402	1.0974
9	.5201	1.3003	1.0517	1.0402	1.2136	1.1269	1.0402
10		.1753	.8669	1.0402	1.1269	.9536	.9362
11	.7802	.3506	.3467		.2601	.3467	.2774
12		.2629	.2601		.2601	.3506	.2835
13	.7802	.2629	.2601	.2629		.3506	.2774
14	.9536	.2629	.2601	.2629	.2601	.2601	.2774
15		.2629	.2601	.2629	.2601	.2601	.2774
16		.2629	.2601	.2629	.2601	.2601	.2774
17		.2629	.2601	.2629	.2601	.2601	.2774
18		.2629	.3467	.3506	.2601	.3467	.2774
19		.4382	.5201	.4382	.3467	.3467	.4334
20	.3467	.4382	.5201	.5258	.5201	.5258	.4854
21	.5201	.4382	.4334			.4382	.4334
22	.4334	.4382	.4334	.4382	.4334	.4287	.4334
23	.3467	.3506	.3467	.3506	.3467	.3429	.2601
24	.3506	.2601	.3506	.3467		.3467	.3429
Max	.9536	1.5604	1.3717	1.2136	1.4022	1.1269	1.3717
Min	.3467	.1753	.2601	.2629	.2601	.2601	.2601
Avg	.4968	.6220	.6575	.6457	.6847	.6126	.6520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 203 / 11 KV DIGRESS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935						
2	.6935						
3	.7802						
4	.7802	.0159					
5	.8669						
6	1.0402						
7	1.286						
8	1.3717						
9	1.0288						
10	1.4175						
11		1.2403	1.1517	.8669	1.1517	1.1393	1.1517
12		1.4175	1.3289	.9536	1.4175	1.4022	1.2048
13		1.2403	1.2403	.9536	1.2403	1.3289	1.1517
14		1.2269	1.1517	1.1269	1.1517	.8764	1.2403
15		1.1517	.8859	1.1269	1.1517	1.1517	1.2403
16		1.1517	1.3289	1.1269	1.1517	1.2403	1.2403
17		1.1517	1.3289	1.0402	1.4632	1.4022	1.2757
18		1.0631	1.2403	1.0402	1.3289	1.3289	1.2403
Max	1.4175	1.4175	1.3289	1.1269	1.4632	1.4022	1.2757
Min	.6935	.0159	.8859	.8669	1.1517	.8764	1.1517
Avg	.9959	1.0732	1.2071	1.0294	1.2571	1.2337	1.2181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 204 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1829	.1867	.1867		.2126	
2	.168	.1829	.1494	.168		.1753	
3	.1867	.1448	.1494	.1494		.1772	
4	.1494	.1463	.1494	.1494		.181	
5	.168	.1433	.112	.1494		.1463	
6	.1867	.1753	.168	.1494		.1463	
7	.2054	.1715	.1867	.1494		.1753	
8	.2241	.2401	.2614	.1867		.2058	
9		.2743		.1867		.2439	.2987
10	.3429	.3734			.2439	.2743	.2987
11	.3429	.1867				.3048	.2241
12	.3772	.2054			.3429	.3048	.1867
13	.3814	.2241				.3353	.1867
14	.3353	.2241			.3429	.3048	.168
15		.2241			.3429	.3048	.168
16		.2241				.3048	.1867
17		.1867			.3506		.2241
18		.1867					.2614
19		.2054			.2743		.2054
20	.2715	.2427			.2743		.2614
21	.2534	.2614					.2801
22	.2561	.2614			.2629		.2427
23	.2195	.2801			.2427		.2241
24	.2801	.2195	.2427	.2614		.2401	
Max	.3814	.3734	.2614	.2614	.3506	.3353	.2987
Min	.1494	.1433	.112	.1494	.2427	.1463	.168
Avg	.2520	.2153	.1784	.1737	.2975	.2375	.2278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 201 / 11 KV DEVTALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.3174	.2241	.3361	.3547	.2241	.2987
2	.8402	.2987	.2241	.3361	.3361	.2241	.3361
3	1.0269	.3174	.2987	.4108	.3734	.1867	.2987
4	1.1203	.3174	.2987	.4854	.4108	.1848	.2241
5	1.307		.4481	.4854	.4854	.2957	.6722
6	1.587		.5792	.6722	.5601	.4344	.7468
7	1.6804		.4344	.5228	.543	.5068	.6348
8	2.2405		.362	.4668	.4344	.362	.5601
9	2.4272		.362	.4108	.5068	.2896	.4668
10			.3734	.3361	.3856		.3361
11			1.4003		1.0288		1.1203
12		.3429	1.4937		1.1603	1.587	1.2136
13			1.4937		1.3603	1.5684	
14		.3429	1.4937		1.4251	1.531	
15		.8951	1.4003		1.4899	1.4937	1.4003
16		.9945	1.4937		1.4899	1.7177	1.4937
17	.3506	1.1271				1.8671	1.587
18		1.1934				1.7737	
19		.2172				.1867	
20		.3734			.2987	.2241	
21		.3734	.3734		.3734	.2801	
22		.2987	.3361		.3734	.2987	
23	.3547	.2987	.3361		.2987	.3361	
24	.6535	.3547	.2987	.3361	.3547	.2987	.2987
Max	2.4272	1.1934	1.4937	.6722	1.4899	1.8671	1.587
Min	.3506	.2172	.2241	.3361	.2987	.1848	.2241
Avg	1.1946	.5039	.6862	.4362	.6687	.7214	.7305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.3361	.2454		.2241	.2804	.2987
2	.2427	.3174	.2454	.2614	.2614	.2743	.3361
3	.2427	.3174	.2454	.2987	.2801	.2743	.4108
4	.2614	.3361	.2743	.3361	.2987	.3429	.4668
5	.2614	.3547	.2743	.3361	.3361	.3429	.4668
6	.2241	.181	.2743	.4108	.4481	.4641	.4668
7	.2801	.181	.3429	.5601	.5601	.5304	.5975
8	.3174	.181		.5228	.5304	.5304	.5228
9	.3174	.181		.4668	.4973	.4641	.5975
10		.181	.4668	.3734	.4144	.5228	.4668
11		.181	.1307		.4973	.2241	.2241
12		.1448	.1494		.2058	.1494	.2427
13					.1052	.1494	.1867
14			.1867		.1086	.1494	.1494
15			.1494		.1086	.1494	.1307
16		.1086	.1307		.1448	.1494	
17	.7459	.1086			.1448	.1494	.168
18		.1448			.2218	.1867	
19		.1848			.2241	.2801	
20		.2987			.2987	.2614	
21		.2987	.3361		.2987	.2241	
22		.2241	.2241		.2241	.2241	
23	.2987	.2241	.1867		.2241	.1867	
24	.2241	.3361	.2241	.1867	.2054	.1867	.1867
Max	.7459	.3547	.4668	.5601	.5601	.5304	.5975
Min	.2241	.1086	.1307	.1867	.1052	.1494	.1307
Avg	.3033	.2296	.2404	.3753	.2859	.2790	.3482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-18	09-APR-18	10-APR-18	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.5601	.4801	.2543	.2427	.4801	.4409
2	.3174	.9335	.4801	.3052	.2401	.5487	.5426
3	.2987	1.1203	.5487	.3391	.2401	.5487	.5935
4	.3361	1.2136	.5967	.3052	.2801	.6104	.763
5	.3361	1.307	.5967	.3052	.2987	.5967	.9326
6	.3547	1.4003	.663	.5426	.3734	.6962	.9496
7	.362	1.4563	.663		.4108	.8745	.1102
8	.4668	1.1934	.6962			.9717	1.1022
9	.4382	1.1271	.7293			.4973	.9496
10	.4557	.9945	.763	.2035	.3086	.5426	.8817
11	.7716	.1753	.1357		.8288	.1696	.1867
12	.9945	.1086	.1696		.2229	.1187	.2241
13	.9945		.1357		.1753	.1187	.2427
14	1.0608	.1086	.1187		.181	.1357	.1494
15	1.0608	.1086			.1448	.1357	.1307
16	1.1271	.1448			.1448	.1526	.168
17	1.1271	.1448			.1448	.1526	.168
18		.181			.2587	.2543	
19		.2587			.3361	.3052	
20		.4108			.4108	.3391	
21		.3734	.2713		.3734	.373	
22		.2987	.2543		.2987	.373	
23	.2614	.2987	.2035		.2987	.3052	
24	.2801	.4668	.2241	.2035	.2427	.2241	.2204
Max	1.1271	1.4563	.763	.5426	.8288	.9717	1.1022
Min	.2614	.1086	.1187	.2035	.1448	.1187	.1102
Avg	.5970	.6254	.4294	.3073	.2935	.3969	.4864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 201 / 11 KV GUTTI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.381		
2	.362		
3	.362		
4	.4191		.4191
5	.4954		
6	.6097		
7	.724		
8	.724	.724	.724
9	.743		
10	.6668		
11	.4001		
12	.4954	.381	.4572
13	.5525		
14	.5335		
15	.5716		
16	.5716	.4572	.4954
17	.5906		
18	.5906		
19	.6287		
20		.7049	
23		.4191	
24	.4001	.3429	.381
Max	.743	.724	.724
Min	.362	.3429	.381
Avg	.5411	.5049	.4953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 202 / 11 kv CHINCHOLI FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	11-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.2096		
2	.3048		
3	.3429		
4	.3429	.4572	.362
5	.3429		
6	.362		
7	.2667		
8	.4191	.6097	.5335
9	.4382		
10	.4382		
11	.4001		
12	.4191	.4954	.4191
13	.4572		
14	.4572		
15	.4763		
16	.4954	.381	.362
17	.5144		
18	.5525		
19	.7049		
20		.6668	.743
23		.5525	.5335
24	.5525	.4954	.5335
Max	.7049	.6668	.743
Min	.2096	.381	.362
Avg	.4248	.5226	.4981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-18 and 14-APR-18

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 203 / 11 KV SULLALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-18	12-APR-18	13-APR-18	14-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362			
2	.362			
3	.381			
4	.4191		.3429	.3048
5	.4572			
6	.4954			
7	.4763			
8	.4763		.4382	.4954
9	.4763	.362		
10	.4191	.362		
11	.1524	.3048		
12	.1524	.2477	.1905	.2286
13	.1524	.2286		
14	.1524	.2477		
15	.1334	.2286		
16	.1334	.2477	.1524	.2286
17	.1524	.3048		
18	.1715	.3429		
19	.3048	.381		
20	.3048	.0191	.362	.362
21		.0191		
22		.0191		
23		.0191	.2667	.2667
24	.2477		.3048	.2477
Max	.4954	.381	.4382	.4954
Min	.1334	.0191	.1524	.2286
Avg	.3039	.2223	.2939	.3048