

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 201 / BHOKAR TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6001			
2			.5144				.5144
3				.6001			
4			.5144				.5144
5			.6001	.6001			
6			.6001	.6859			.6001
7		.6001	.6859	.6859		.6859	.6001
8	.6001		.6859				
9	.6001		.6001	.6859		.6001	.6001
10						.6001	
11	.6001	.6001	.6001			.5144	
12	.6001					.6001	
13					.6001		
14	.6001		.6001				
15	.6001		.6001			.5144	
16	.5144				.5144		
17			.6001			.6001	
18		.6001					
19		.6001	.6859			.6001	
20		.6001					
21		.6001					
22		.6001	.6001				
23					.6001	.6001	
24			.5144	.6001			.5144
Max	.6001	.6001	.6859	.6859	.6001	.6859	.6001
Min	.5144	.6001	.5144	.6001	.5144	.5144	.5144
Avg	.5879	.6001	.6001	.6369	.5715	.5906	.5573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 202 / BHOKAR TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3717			
2			1.3717				1.3717
3				1.3717			
4			1.3717				1.3717
5			1.4575	1.4575			
6			1.5432	1.5432			1.3717
7		1.5432	1.5432	1.5432		1.6289	1.4575
8	1.5432		1.4575				
9	1.3717		1.3717	1.5432		1.4575	1.4575
10	1.5432					1.4575	
11	1.5432	1.6289	1.3717			1.3717	
12	1.5432					1.3717	
13					1.5432		
14	1.4575		1.3717				
15	1.3717					1.3717	
16	1.3717				1.4575		
17						1.4575	
18		1.5432					
19		1.7147	1.6289			1.7147	
20		1.5432					
21		1.5432					
22		1.4575	1.5432				
23					1.5432	1.4575	
24			1.3717	1.3717			1.4575
Max	1.5432	1.7147	1.6289	1.5432	1.5432	1.7147	1.4575
Min	1.3717	1.4575	1.3717	1.3717	1.4575	1.3717	1.3717
Avg	1.4682	1.5677	1.4503	1.4575	1.5146	1.4765	1.4146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 203 / BATALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4572			
2			.4572				1.3717
3				.4572			
4			.4572				1.4575
5			.5335	.4572			
6			.6097	.5335			1.5432
7		.5335		.5335		1.5242	1.7147
8	.9145		.9145				
9	1.5242		1.6289	1.7147		.381	.3429
10	1.6766					.381	
11	1.5242	1.6004	1.6766			.3048	
12	.9145					.3048	
13					.3048		
14	1.5432		1.3717				
15	1.3717					.3048	
16	.3048				.3048		
17			.3048			.3048	
18		.4572					
19		.5335	.4572			.5335	
20		.5335					
21		.5335					
22		.5335	.5335				
23					.9145	1.3717	
24			.4572	.4572			1.2193
Max	1.6766	1.6004	1.6766	1.7147	.9145	1.5242	1.7147
Min	.3048	.4572	.3048	.4572	.3048	.3048	.3429
Avg	1.2217	.6750	.7835	.6586	.5080	.6012	1.2749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 204 / NARWAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3717			
2			1.5432				.6097
3				1.2193			
4			1.8861				.6097
5			2.0805	1.3717			
6			2.2291	2.2291			.6859
7		2.2862		2.1338		.5335	.6097
8	.5335		.5144				
9	.4572		.4572	.4572		1.6004	1.7147
10	.381					1.829	
11	.3429		.3048			2.3148	
12	.3048					2.0576	
13					1.2955		
14	.3048		.3048				
15	.3048		.3429			1.8861	
16	.3048		.3429		.3048		
17			.3429			.381	
18		.4572					
19		.6859	.6097			.6097	
20		.6859					
21		.6859					
22		1.4575	1.0669				
23					.6859	.7716	
24			1.5432	1.3717			.6097
Max	.5335	2.2862	2.2291	2.2291	1.2955	2.3148	1.7147
Min	.3048	.4572	.3048	.4572	.3048	.381	.6097
Avg	.3667	1.0431	.9692	1.4506	.7621	1.3315	.8066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 205 / MANJIT COTTON EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5144			
2			.5144				.5144
3				.5144			
4			.5144				.5144
5			.5144	.5144			
6			.5144	.5144			.5144
7		.3429		.5144		.5144	.4287
8	.2572		.3429				
9	.2572		.1715	.1715		.1715	.0857
10	.3429					.0857	
11		.0857	.0857			.0857	
12	.3429					.0857	
13					.1715		
14	.5144		.0857				
15	.3429		.0857			.0857	
16	.3429		.1715		.2572		
17			.3429			.3429	
18		.4287					
19		.5144	.5144			.5144	
20		.5144					
21		.5144					
22		.5144	.5144				
23					.5144	.5144	
24			.5144	.5144			.5144
Max	.5144	.5144	.5144	.5144	.5144	.5144	.5144
Min	.2572	.0857	.0857	.1715	.1715	.0857	.0857
Avg	.3429	.4164	.3491	.4654	.3144	.2667	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 206 / EXP. FEEDER W/S BKR(SUDHA) NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0857			
2			.0857				.0857
3				.0857			
4			.0857				.0857
5			.1715	.0857			
6			.1715	.1715			.1715
7		.1715		.1715		.1715	.1715
8	.1715		.1715				
9	.1715		.1715	.1715		.1715	.1715
10	.1715					.1715	
11	.1715	.1715	.1715			.1715	
12	.1715					.1715	
13					.1715		
14	.1715		.1715				
15	.0857		.1715			.1715	
16	.0857		.0857		.1715		
17			.0857			.0857	
18		.0857					
19		.0857	.0857			.0857	
20		.0857					
21		.0857					
22		.0857	.0857				
23					.0857	.0857	
24			.0857	.0857			.0857
Max	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1501	.1102	.1286	.1225	.1429	.1429	.1286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 201 / MATUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	.5426	.4572	.5487	.5967	.5487	.5487
2	.4024	.5365	.4572	.543	.5898	.5487	.5487
3	.3688	.5426	.4572	.5121	.6554	.6097	.6097
4	.3647	.5426	.4877	.5068	.6554	.7316	.7926
5	.3978	.5426	.4877	.543	.9282	.8383	.8535
6	.3978	.6104	.5182	.5853	.9831	.9755	.9145
7	.3978	.5967	.5487	.6219	.9717	1.0059	.9755
8	.7042	.78	.6401	.6219	.4858	.2743	.4268
9	.9831	.9503	.7621	1.0498	.3563	.3048	.2439
10	.9614	1.0608	.823	.9175	.3353	.3353	.4252
11	.9945	1.1271	.9877	.8619	.2743	.3353	.4211
12	.9724	.9755	.9877	.8383	.2743	.3353	.3506
13		.9145	.9412	.8619	.3086	.3048	.3856
14	.8951	.8535	.905	.8619	.3048	.3048	.3506
15	.9831	.7926	.7964	.7042	.3048	.3048	.3856
16	.3932	.3048	.4344	.3521	.3048	.3048	.3856
17	.407	.3658	.3982	.3605	.3658	.3658	.4207
18	.4359	.4572	.543	.4641	.0396	.3963	.5201
19	.663	.5487	.6516	.5967	.4877	.4572	.6588
20	.663	.5335	.6878	.6036	.5182	.5182	.6241
21	.6036	.5487	.6878	.57	.5182	.5487	.5895
22	.5365	.5182	.6516	.4858	.4572	.4877	.6068
23	.5365	.4877	.6089	.583	.5182	.5487	.6068
24	.4409	.5365	.4572	.5792	.6036	.5182	.5487
Max	.9945	1.1271	.9877	1.0498	.9831	1.0059	.9755
Min	.3647	.3048	.3982	.3521	.0396	.2743	.2439
Avg	.6048	.6529	.6407	.6322	.4932	.4960	.5497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 202 / BENDRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.1006	.1372	.2534	.2347	.2058	.2439
2	.2321	.0995	.1029	.181	.2321	.1829	.2439
3	.2294	.1017	.1029	.181	.2294	.2286	.2439
4	.1989	.1006	.1029	.181	.2321	.2439	.3048
5	.1357	.0995	.1372	.181	.2321	.3048	.3048
6	.1341	.0995	.1372	.181	.2321	.3048	.3353
7	.1311	.0983	.1219	.181	.2321	.1372	.3353
8	.2321	.1677	.3048	.2896	.2294	.1715	.1715
9	.5365	.5304	.4877	.5487	.1677	.1715	.1715
10	.5967	.5571	.5487	.5304	.1715	.1524	.1734
11	.6371	.5967	.5792	.431	.1372	.1524	
12	.6299	.5487	.5121	.4973	.1219	.2058	.2048
13		.3086	.5792	.4973	.1219	.1715	.2427
14	.4024	.5182	.543	.4641	.1524	.1715	.208
15	.5304	.5182	.6154	.3887	.1524	.1524	.208
16	.1658	.1715	.2172	.1638	.1715	.1524	.208
17	.1989	.2572	.2172	.1677	.2401	.1829	.2462
18	.2294	.2743	.2896	.1989	.2439	.2572	.2122
19	.3353	.3086	.362	.2321	.2743	.3086	.2117
20	.3018	.3086	.362	.2321	.2743	.3429	.2829
21	.2652	.3086	.3258	.2012	.2401	.2743	.321
22	.2012	.1524	.2896	.1966	.1715	.2058	.2042
23	.0995	.1715	.2561	.1966	.2058	.2401	.2219
24	.2683	.0995	.1372	.2534	.2347	.2058	.2401
Max	.6371	.5967	.6154	.5487	.2743	.3429	.3353
Min	.0995	.0983	.1029	.1638	.1219	.1372	.1715
Avg	.3012	.2707	.3112	.2845	.2056	.2136	.2409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 203 / SONARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2597	.9907	1.1462	.7956	.7316	.823
2	1.1934	1.2597	1.0974	1.2308	.7956	.7316	.7888
3	1.1934	1.326	1.2193	1.3032	.8048	.7011	.7888
4	1.2742	1.326	1.3413	1.3756	.7625	.7011	.7621
5	1.3413	1.4918	1.448	1.448	.7537	.7621	.7621
6	1.5912	1.5912	1.448	1.5203	.7865	.823	.7926
7	1.7695	1.6766	.9755	1.7013	.852	.8383	.7926
8	.7293	.7956		.727	.7293	.5335	.8535
9	.6036	.7293		.6154	1.1271	.5792	.884
10	.5967	.6036	.724	.5898	1.2193	.8573	1.2136
11	.5365	.4641	.6516	.4641	1.2193	1.0364	1.4737
12		.5487	.5853	.4973	1.0974	1.0669	1.387
13		.5487	.543	.6036	1.0974	1.1279	1.3176
14	.5304	.5487	.5792	.5967	.9907	1.0974	1.3523
15	.6036	.583	.6154	.5243	1.0364	1.286	1.3523
16	.6036	.583	.6516	.5967	1.0364	1.2003	1.4737
17	.5967	.5792	.724	.6036	.4877	.6001	.5201
18	.6783	.8573	.724	.8048	.5487	.6401	.8495
19	1.0059	.884	.724	.8951	.6859	.823	.9923
20	1.0059	.884	1.0136	.9389	.8535	.9602	1.0157
21	.8817	.823	1.086	.9389	.7926	.9602	.9672
22	1.2071	.884	1.0136	.7956	.7621	.7926	.9496
23	1.2597	.9907	1.1222	.7865	.7316	.7621	.8487
24	1.1934	1.2597	.9907	1.1584	.8048	.7316	.823
Max	1.7695	1.6766	1.448	1.7013	1.2193	1.286	1.4737
Min	.5304	.4641	.543	.4641	.4877	.5335	.5201
Avg	.9819	.9374	.9213	.9109	.8655	.8477	.9910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 201 / MASALGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6859	
2				.6859	
4				.8573	.5365
5				.8573	
6				.8573	
7				.8573	.8048
10		.8718			
11	.9774		.7621		
12	.8718				
16	.9724				
17	.8718		.6687		
22				.57	.5365
24				.6859	.6036
Max	.9774	.8718	.7621	.8573	.8048
Min	.8718	.8718	.6687	.57	.5365
Avg	.9234	.8718	.7154	.7571	.6204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 202 / PALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2193			
2			1.2193			
3			1.2193			
4		1.7772	1.5242			
5			1.5242			
6			1.5242			
7	1.4632	1.8778	1.5242			
10					1.1736	1.8107
11				1.5699		
12					2.079	1.9448
15					1.2407	
16					1.3413	1.8107
17					1.4754	1.8107
22	1.3077					
24		1.6766	1.0669			
Max	1.4632	1.8778	1.5242	1.5699	2.079	1.9448
Min	1.3077	1.6766	1.0669	1.5699	1.1736	1.8107
Avg	1.3855	1.7772	1.3527	1.5699	1.462	1.8442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 203 / KINI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1772			.1772	
2			.1772			.1772	
3			.2126			.2126	
4		.2926	.2126			.2126	.2926
5			.2481			.2481	
6			.2481			.2835	
7	.3189		.2835				
8		.2561					.2195
10		.1829				.2195	.1829
11	.1595			.1829	.1772		
12	.1829					.2195	.1829
15						.2195	
16	.1463					.2195	.2195
17	.1829			.2126			
18				.3189		.2561	
19							.3292
22	.3292						
24		.2926	.1772			.1772	.2926
Max	.3292	.2926	.2835	.3189	.1772	.2835	.3292
Min	.1463	.1829	.1772	.1829	.1772	.1772	.1829
Avg	.2200	.2561	.2171	.2381	.1772	.2185	.2456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 204 / PALAJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2561			.2926	
2			.2561			.2926	
3			.2926			.2926	
4		.3658	.2926			.3292	.3658
5			.3292			.3292	
6			.3292			.3658	
7	.4024		.3658			.3658	
8		.4755					.2926
10		.4024				.2926	.3292
11	.3475			.2401	.2561		
12	.3658					.2561	.3658
15						.2926	
16	.3292					.2926	.3658
17	.3658			.3475			
18				.4024		.4024	
19							.4755
22	.3658						
24		.3292	.2561			.2926	.2926
Max	.4024	.4755	.3658	.4024	.2561	.4024	.4755
Min	.3292	.3292	.2561	.2401	.2561	.2561	.2926
Avg	.3628	.3932	.2972	.33	.2561	.3151	.3553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 201 / SINGARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2515	.3018	.3018	.431	.431	.4144
2	.3018	.2515	.3018	.3018	.4144	.431	.4144
3	.3018	.2515	.3018	.3018	.431	.431	.4144
4	.3521	.2515	.3018	.3018	.431	.431	.3978
5	.3521	.2743	.3018	.3353	.431	.4641	.3978
6	.3521	.3018	.3521	.3353	.4973	.5304	.4973
7	.2515	.2347	.2515	.2683	.4641	.5304	.5138
8	.4024	.2515	.4024	.2321	.0995	.1492	.1989
9	.503	.4359	.503	.4641	.0995	.0995	.1989
10	.5365	.4359	.2515	.5304	.0995	.1492	.1989
11	.5533	.4694	.4694	.5636	.0995	.1492	.1658
12	.57	.4694	.5365	.5304	.0995	.1492	.1658
13	.3688		.5365	.4973	.1492	.1492	.1658
14	.4024		.5365	.4973	.1492	.1492	.1658
15	.3856	.4694	.4694	.4641	.1492	.1989	.1658
16	.1509	.4694	.1341	.4641	.1492	.1989	.1658
17	.1509	.2012	.1677	.2321	.1989	.1989	.1658
18	.2515	.2012	.2012	.1989	.1989	.1492	.1989
19	.3018	.3018	.3018	.2984	.2984	.3481	.2984
20	.3018	.3521	.3353	.3481	.3481	.3481	.3647
21	.3018	.3521	.3688	.2984	.3481	.3978	.3647
22	.2515	.3521	.3353	.4144	.431	.3978	.3978
23	.2515	.3521	.3353	.4144	.4641	.3978	.3978
24	.3018	.2515	.3018	.3353	.4144	.4641	.431
Max	.57	.4694	.5365	.5636	.4973	.5304	.5138
Min	.1509	.2012	.1341	.1989	.0995	.0995	.1658
Avg	.3416	.3264	.3458	.3721	.2873	.3060	.3025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 202 / SAWARGAON MAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.1843	1.1336	1.2308	.0648	.0486	.0648
2	1.2003	1.2003	1.1336	1.2308	.0648	.0486	.0648
3	1.2163	1.2003	1.1336	1.2631	.0648	.0486	.0648
4	1.2323	1.2483	1.1336	1.2631	.0648	.0486	.0648
5	1.2483	1.2483	1.166	1.2955	.0648	.0972	.0648
6	1.2483	1.3443	1.2631	1.3279	.0648	.0972	.0648
7	1.3123	1.3413	1.2955	1.3603	.0486	.0972	.0648
8	.048	.048	.0486	.0648	.0324	.0486	.0324
9	.048	.048	.0324	.0324	.1619	.1943	.1943
10	.048	.048	.0324	.0324	.2591	.2591	.2591
11	.048	.048	.0324	.0324	.2915	.2915	.2915
12	.048	.048	.0324	.0324	.2915	.3239	.2591
13	.048		.0324	.0324	.2915	.2915	.2591
14	.048	.048	.0324	.0324	.2429	.1943	.2591
15	.048	.048	.0648	.0648	.1619	.2267	.2267
16		.048	.0648	.0648	.1296	.2267	.2267
17	.048	.048	.0648	.0648	.0486	.0324	.0324
18	.048	.0486	.0648	.0648	.0486	.0486	.0324
19	.048	.0486	.0648	.0648	.0486	.0648	.0648
20	.048	.0972	.0972	.0648	.0972	.0648	.0972
21	.048	.0972	.0648	.0648	.0972	.0648	.0972
22	1.1523	1.1336	1.1984	.0648	.0972	.0648	.0648
23	1.1683	1.1336	1.1984	.0648	.0972	.0648	.0648
24	1.1683	1.1843	1.1336	1.2308	.0648	.0486	.0648
Max	1.3123	1.3443	1.2955	1.3603	.2915	.3239	.2915
Min	.048	.048	.0324	.0324	.0324	.0324	.0324
Avg	.5553	.5627	.5216	.4602	.1208	.1248	.1242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 203 / DEWTHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.208	.208	.208	.208	.208
2	.2427	.2427	.208	.208	.208	.208	.208
3	.2427	.2427	.208	.208	.208	.208	.208
4	.2427	.2601	.208	.208	.208	.208	.208
5	.2427	.2601	.2254	.2427	.208	.208	.208
6	.2427	.2774	.2774	.2774	.208	.208	.208
7	.3121	.2774	.3467	.3467	.208	.2601	.208
8	.104	.208	.156	.208	.208	.208	.208
9	.104	.156	.1387	.156	.1387	.2427	.208
10	.104	.156	.1387	.156	.2427	.208	.208
11	.104	.104	.1387	.104	.2774	.208	.208
12	.104	.104	.104	.104	.2774	.208	.208
13	.104	.104	.104	.156	.208	.208	.208
14	.104	.104	.104	.156	.208	.1734	
15	.104	.104	.104	.156	.2427	.1734	.2427
16	.104	.156	.1387	.104	.2427	.1734	.2427
17	.104	.156	.1734	.104	.156	.156	.1734
18	.208	.156	.208	.156	.156	.156	.1734
19	.208	.156	.2427	.156	.2601	.2601	.208
20	.208	.2601	.2774	.2601	.2601	.2601	.2427
21	.208	.208	.2427	.2601	.208	.2601	.2427
22	.208	.208	.208	.2601	.2601	.2601	.2427
23	.208	.208	.208	.2601	.2601	.2601	.2427
24	.2427	.2427	.208	.208	.208	.208	.208
Max	.3121	.2774	.3467	.3467	.2774	.2601	.2427
Min	.104	.104	.104	.104	.1387	.156	.1734
Avg	.1791	.1914	.1907	.1943	.2196	.2138	.2140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 201 / BHOSI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.5089	1.6598	1.643			
4					.5093	.5601
5	1.7147					
6		1.8298	1.9791			
7	1.7318			1.749		
8					.5601	
9	.4458	.5415		.2743		
11		.4108				
12			.1943		2.0538	1.9719
14		.362				
16					2.1285	2.0062
17		.4382				
18			.2058			
20					.6161	.4458
21		.5228	.3201			
24	1.4403	1.5278	1.5089	1.3765	.4527	.4904
Max	1.7318	1.8298	1.9791	1.749	2.1285	2.0062
Min	.4458	.362	.1943	.2743	.4527	.4458
Avg	1.3683	.9116	.9752	1.1333	1.0534	1.0949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 202 / WAKAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.9602	1.1506	1.0456		.1715		
4						.1886	.1886
5	1.0288						
6		1.3392	1.3817				
7	1.2003			1.3603	.1715		
8						.1867	
9	.1372	.1307		.0914			
11		.1307					
12			.0914			1.531	1.3889
14		.1494					
16						1.5684	1.2689
17		.1227					
18			.1029				
20						.2614	.2572
21		.2054	.1143				
24	.8745	1.0185	1.0185	.8907	.1372	.2075	.2263
Max	1.2003	1.3392	1.3817	1.3603	.1715	1.5684	1.3889
Min	.1372	.1227	.0914	.0914	.1372	.1867	.1886
Avg	.8402	.5309	.6257	.7808	.1601	.6573	.6660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 203 / CHITGIRI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					2.6063		
3	.3429	.3961	.4481				
4					2.6749	3.2253	3.0247
5	.3086						
6		.4108	.5788				
7	.4115			.2972	2.8978		
8	.3601					.3361	
9	2.4006	2.2218		2.4615			
11		2.5393					
12			2.0081			.2614	.3086
14		2.2786					
16						.3174	.3429
17		.3506					
18			.1943				
20						.4481	.4287
21		.4854	.2515				
24	.3601	.3961	.4338	.2515	2.572	2.8669	3.1121
Max	2.4006	2.5393	2.0081	2.4615	2.8978	3.2253	3.1121
Min	.3086	.3506	.1943	.2515	2.572	.2614	.3086
Avg	.6973	1.1348	.6524	1.0034	2.6878	1.2425	1.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 201 / AMBALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.502	.5487	.5304	.5182	.9145	.8259	.9717
2	.4858	.5144	.5304	.5182	.9145	.8097	.9393
3	.4858	.5144	.547	.5182	.9145	.8259	.9393
4	.4858	.5144	.5636	.5182	.9145	.8097	.9717
5	.5182	.583	.5967	.5344	.945	.9069	.9878
6	.5182	.6001	.5967	.6316	.945	1.2308	1.3441
7	.5668	.6001	.502	.583	1.3108	1.4575	1.4575
8	.8745	.9145	.9878	.5506	.5316	.502	.3887
9	1.2631	1.1888	1.2955	1.2146	.4287	.3725	.3887
10	1.2803	1.2517	1.3117	.5182	.3563	.3725	.3772
11	1.2346	1.2955	1.1822	1.2498	.1905	.3239	.3258
12	1.2346	1.2631	1.247	1.1736	.3077	.3239	.3601
13	1.0822	1.1822	1.1336	1.1279	.3077	.3887	.3086
14	.8078	1.085		1.0212	.3077	.3401	.3429
15	.9297	1.0526	.9069	1.1145	.3077	.3401	.4115
16	.2915	.2915	.2429	1.1279	.3725	.3239	.3944
17	.3086	.3239	.2267	.3944	.3725	.3239	.3429
18	.3772	.3401	.3077	.4115		.2915	.4801
19	.5144	.5636	.5182	.5487	.5992	.5344	.5487
20	.6516	.6299	.6478	.5144	.6802	.6154	.6516
21	.583	.7167	.6316	.5144	.6154	.6478	.6344
22	.6173	.5967	.583	.8535	.9069	.9717	.8993
23	.5487	.5636	.5668	.8535	.8745	.9878	.823
24	.502	.5487	.5182	.5182	.8535	.8421	.9717
Max	1.2803	1.2955	1.3117	1.2498	1.3108	1.4575	1.4575
Min	.2915	.2915	.2267	.3944	.1905	.2915	.3086
Avg	.6943	.7368	.7032	.7304	.6466	.6404	.6775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 202 / HADGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5524	1.4575	1.587	1.6632	1.6461	1.6804	1.7741
2	1.5154	1.4575	1.587	1.6263	1.5089	1.6617	1.7741
3	1.4784	1.4575	1.5684	1.5893	1.5089	1.643	1.7556
4	1.4784	1.5432	1.5497	1.5893	1.5432	1.643	1.7372
5	1.5893	1.5432	1.6617	1.6632	1.7147	1.8858	1.7372
6	1.7926	1.6975	1.9791	1.9589	1.8004	2.0351	3.3819
7	1.922	1.7147	1.9978	2.0328	1.9547	2.1098	1.9959
8	1.7556	1.8861	1.8111	1.848	1.8176	2.0165	1.9035
9		1.6975	1.5123	1.8296	1.5261	1.6991	1.7741
10		1.5775	1.5684	1.6118	1.531	1.7177	1.406
11	.8916	1.6244	1.5339	1.7318	1.5684	1.6632	1.4746
12	.823	1.6244	1.5154	1.4403	1.4937	1.6078	1.4022
13	1.7833	1.587	1.4969	1.4575	1.6057	1.6632	1.2498
14	1.6118	1.4563	1.4969	1.4403	1.587	1.5893	1.4403
15	1.5261	1.4563	1.4415	1.4232	1.5684	1.5524	1.4232
16	1.5604	1.6057	1.5524	1.4232	1.5684	1.6263	1.5261
17	1.6118	1.6991	1.5893	1.5089	1.5684	1.6632	1.6804
18	1.6461	1.7177	1.6632	1.5775	1.7924	1.7187	1.7147
19	1.8004	1.9044	2.0328	1.8176	2.0725	2.0883	1.869
20	1.8519	1.9978	1.9959	1.4575	2.0538	1.9959	1.8004
21	1.7318	1.8858	1.9035		1.9418	1.922	1.7318
22	1.7318	1.8858	1.9035	1.9719	1.9791	1.9035	1.8519
23	1.5432	1.7737	1.8111	1.7147	1.8298	1.8665	1.7147
24	1.5893	1.5089	1.6804	1.7002	1.6461	1.7737	1.7926
Max	1.922	1.9978	2.0328	2.0328	2.0725	2.1098	3.3819
Min	.823	1.4563	1.4415	1.4232	1.4937	1.5524	1.2498
Avg	1.5812	1.6566	1.6850	1.6555	1.7011	1.7803	1.7463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 203 / BELMANDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2193	1.1431	1.1149	.7202	.7655	.7842
2	1.1888	1.2041	1.1279	1.0856	.7545	.7468	.7842
3	1.1736	1.2041	1.1431	1.0856	.823	.7468	.7842
4	1.1736	1.2955	1.1279	1.0856	.823	.7468	.8215
5	1.1888	1.326	1.2041	1.1294	.823	.8215	.8775
6	1.387	1.3565	1.4022	1.0669	.8573	.8589	.9335
7	1.4937	1.3717	1.448	1.4632	.7202	.7282	.7922
8	.6687	.6173	.7282	.7545	.6516	.5415	.679
9	.5487	.3944	.547	.5975	1.3413	1.3413	1.3108
10	.4287	.4458	.4338	.463	1.2955	1.4327	1.2955
11	.3772	.3921	.4338	.4801	1.4022	1.3717	1.2498
12	.3601	.3921	.4854	.4801	.5639	1.2643	1.2193
13	.4115	.4854	.4854	.4801	1.1126	1.247	1.2041
14	.4801	.4668		.4973	1.2955	1.1883	1.2193
15	.4458	.4481		.463	1.2955	1.2631	1.2346
16	.4115	.4481		.3944	1.3413	1.3077	1.326
17	.5144	.4854		.4801	.5601	.5544	.4287
18	.5487	.5788	.6653	.4973	.6535	.6283	.4572
19	.7373	.8962	.8131	.7202	.8215	.8215	.7202
20	.7373	.7468		.823	.7842	.8402	.8059
21	.7545	.8029	.8589	.7716	.8589	.8775	.8402
22	1.326	1.2955	1.2803	.7716	.8215	.8589	.7716
23	1.2803	1.2651	1.2651	.7202	.7842	.811	.7202
24	1.1888	1.2193	1.2041	1.1591	.7202	.7842	.7842
Max	1.4937	1.3717	1.448	1.4632	1.4022	1.4327	1.326
Min	.3601	.3921	.4338	.3944	.5601	.5415	.4287
Avg	.8339	.8482	.9367	.7743	.9094	.9395	.9185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 204 / WATEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9061	.884	.8078	.8322	.4115	.4481	
2	.9061	.823	.7926	.8173	.4115	.4481	.4527
3	.9061	.823	.7926	.7876	.4115	.4668	.4715
4	.9061	.823	.7926	.7876	.6516	.4854	.4904
5	.9374	.9145	.9145	.8429	.6516	.5601	.679
6	1.1405	.9907	1.1584	1.142	.8059	.7095	.5788
7	1.2186	1.2193	1.0974	1.2186	.6001	.6161	.6348
8	.679	.6173	.6348	.6413	.463	.6722	.6348
9	.4715	.5144	.4338	.5093	1.0364	1.2041	1.0822
10	.3944	.4115	.3206	.3429	1.1126	1.3413	1.0974
11	.3258	.3361	.3772	.2401	1.0364	1.2041	1.1888
12	.2572	.3547	.3395	.3429	1.1431	1.189	1.0974
13	.3086	.3547	.3395	.3258	1.1431	1.1443	1.0822
14	.2743	.3361	.3206	.3086	1.1431	1.0997	1.0974
15	.3258	.3547	.3584	.4115	1.1736	1.0997	1.1279
16	.2743	.3361	.3584	.3944	1.2346	1.1145	1.1584
17	.3429	.3772	.4294	.4287	.3734	.4481	.3086
18	.4287		.4854	.4287	.5415	.4854	.463
19	.5487	.6908	.6036	.583	.6722	.6535	.5658
20	.5316	.6908	.5658	.3506	.5975	.6036	.5487
21	.4973	.4904	.547	.3944	.5415	.5281	.5487
22	.9297	.884	.8951	.4458	.3174	.4904	.4801
23	.9145	.8535	.945	.4115	.4668	.4527	.4287
24	.9061	.884	.8535	.884	.4115	.4481	.4527
Max	1.2186	1.2193	1.1584	1.2186	1.2346	1.3413	1.1888
Min	.2572	.3361	.3206	.2401	.3174	.4481	.3086
Avg	.6388	.6506	.6318	.5780	.7230	.7464	.7248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 205 / KOTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.5487	.567	.5853	1.0669	1.2041	1.247
2	.6099	.5487	.567	.5853	1.0669	1.2041	1.247
3	.6099	.583	.567	.5853	1.0669	1.1888	1.247
4	.5914	.583	.6036	.6036	1.1279	1.1888	1.2955
5	.6283	.6001	.6767	.6099	1.1888	1.2955	1.3441
6	.7392	.6344	.6767	.6468	1.2346	1.448	1.5384
7	.6838	.6001	.6036	.6283	1.4327	1.5089	1.5708
8	1.247	1.1126	1.0974	.5304	.5487	.4755	.567
9	1.5223	1.4784	1.448	1.4899	.5144	.4755	.5487
10	1.5242	1.4937	1.4632	1.0974	.3475	.3658	.4458
11	1.3565	1.2955	1.4864	1.4937	.4024	.4049	.3772
12	1.4022	1.448	1.4529	1.4327	.3658	.4298	.3429
13	1.387	1.4175	1.4373	1.4327	.4024	.3544	.3258
14	1.326	1.3717	1.3748	1.387	.3658	.3506	.3258
15	1.387	1.3717	1.3748	1.3717	.3475	.333	.3258
16	.463	.3292	.3544	1.4022	.3841	.3761	.4115
17	.4115	.3841	.3544	.3944	.439	.333	.3772
18	.463	.439	.4344	.4458	.4572	.3544	.4801
19	.583	.6401	.5973	.583	.6036	.6468	.6001
20	.6001	.6584		.5487	.6401	.6468	.6516
21	.6173	.6219	.6767	.5487	.6036	.6099	.6173
22	.5658	.6036	.6401	1.3565	1.2498	1.278	1.1126
23	.5487	.5853	.6036	1.2955	1.2498	1.3108	1.1126
24	.6099	.5487	.567	.5853	1.0974	1.2498	1.2323
Max	1.5242	1.4937	1.4864	1.4937	1.4327	1.5089	1.5708
Min	.4115	.3292	.3544	.3944	.3475	.333	.3258
Avg	.8536	.8291	.8532	.9017	.7585	.7931	.8060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 206 / KOTHALA WW EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.008	.0079	.0073
2					.008	.0079	.0073
3	.0587	.0467		.0394	.0533	.0079	.0594
4	.044	.0467	.0695		.0533	.0079	.0594
5	.044	.0467	.0417	.0394	.061	.0714	.061
6	.044	.0467	.0423	.0394	.0533	.0714	.061
7	.0446	.0467	.0429	.0423	.0533	.0714	.061
8	.0412	.0427	.0429	.0389		.0714	.0587
9	.0429		.0417	.0259	.008	.0714	.0743
10	.04		.0417	.0387	.0079	.0714	
11				.04	.0079	.0073	
12					.815		
13				.0387	.0079		
14				.04	.0079		
15	.0453				.0079		
16	.0453			.0387	.0079	.0074	
17				.04	.0705	.0071	
18		.061	.0389	.04	.0705	.0602	
19		.0417	.04	.0373	.0714	.0095	.056
20		.0417	.0383	.0093	.0714	.0072	
21		.0429	.0366	.0093	.0714	.007	
22		.0429		.008	.0079	.0075	
23				.008	.0079	.0074	.0533
24					.008	.0079	.0073
Max	.0587	.061	.0695	.0423	.815	.0714	.0743
Min	.04	.0417	.0366	.008	.0079	.007	.0073
Avg	.045	.0460	.0433	.0319	.0669	.0294	.0472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 201 / WAIPANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.448	1.1523	.8962	1.475	1.0364	1.1869
2	1.3443	1.1869	1.1523	.8775	1.475	.9998	1.1869
3	1.3443	1.1869	1.0974	.8775	1.475	.9755	1.1869
4	1.4003	1.1869	1.0974	.8775	1.3256	1.0242	1.1869
5	1.4563	1.1869	1.2193	1.0082	1.307	1.1248	1.1869
6	1.0829	1.1022	.9054	1.0456	1.307	.9755	1.1022
7	1.251	1.1022	.9808	1.2323	1.0364	.9755	1.1022
8	.7842	1.1022	.9808	1.0082	1.0456	1.0829	1.0174
9	.6535	.763		.7282	.8215	.8215	.8478
10	.181	.7167	.6348	.7468	.6036	.6783	.6783
11	.181	.6036	.6535	.7095	.5281	.5935	.5935
12	.181	.5975	.6535	.6535	.4481	.5935	.5935
13	.181	.5975	.6535	.6722	.4481	.5935	.5935
14	.5087	.5975	.6722	.6722	.4481	.5087	.5935
15	.5087	.5975	.7468	.6348	.5228	.5087	.5935
16	.5935	.5975	.8029	.7095	.5975	.5935	.5935
17	.5935	.5975	.8402	.7282		.5868	.6783
18	.6783	.5975	.8589	1.8111	.7468	.763	.763
19	1.2574	.7773	1.3817	2.0911	.8539	1.1022	
20	1.4413	1.6644	1.4937	2.3712	1.4548	1.3565	1.1869
21	1.5261	1.3413	1.4937		1.4251	1.3565	1.1736
22	1.5261	1.2193	1.531	1.6057	1.358	1.3565	1.1869
23	1.5261	1.0974	1.3256	1.5684	1.166	1.2717	1.1022
24	1.3817	1.3565	1.1523	.8962	1.4937	.9755	1.2717
Max	1.5261	1.6644	1.531	2.3712	1.4937	1.3565	1.2717
Min	.181	.5975	.6348	.6348	.4481	.5087	.5935
Avg	.9553	.9677	1.0209	1.0618	1.0158	.9106	.9394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 202 / TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.1022	1.0364	.8962		.7545	.6783
2	1.2323	1.1022	1.0364	.8962		.7545	.6783
3	1.2323	1.1022	1.0364	1.0829		.7545	.6783
4	1.3817	1.1022	1.1584	1.1016		.7545	.6783
5	1.8298	1.1869	1.2498	1.5684		.8299	.763
6	1.9978	1.2717	1.5813	1.7364		.8383	.8478
7	2.0911	1.3565	1.6194	1.9978		.8299	.763
8	.5415	.6783	.679	.6535		.7167	.6783
9	.5601			.6348		.9488	1.0174
10	.5087	.6036	.5601	.5601	1.0364	1.2717	.9326
11	.4239	.5281	.5228	.5041	.6859	1.2717	1.0174
12	.4239	.5281	.4854	.407	1.0242	1.2717	1.0174
13	.4239	.5281	.4481	.4239	1.012	1.1869	1.0174
14	.4239	.5281	.4108	.4668	1.0242	1.2717	1.0174
15	.4239	.5281	.4108	.4668	1.0883	1.2717	1.1022
16	.4239	.4527	.4108	.4854	1.3443	1.2717	1.1022
17	.4239	.4904	.4108	.4854	.5281	.5087	.5087
18	.5087	.5281	.4294	.6348	.6036	.5087	.5087
19	.6783	.8299	.5415	.8215	.7922	.6783	.6783
20	.763	.8299	.6535	.8402	.7922	.763	.763
21	.6783	.7922	.6348	.8215	.7922	.763	.763
22	1.0174	1.2071	.7655		.7922	.763	.763
23	1.1022	1.1012	.8589		.7922	.763	.6783
24	1.1949	1.1022	1.0364	.9335		.7545	.6783
Max	2.0911	1.3565	1.6194	1.9978	1.3443	1.2717	1.1022
Min	.4239	.4527	.4108	.407	.5281	.5087	.5087
Avg	.8966	.8470	.7816	.8372	.8791	.8959	.8054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 203 / TAMSA TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.543	.6348	.5601	.5975	.6219	.6335
2	.5601	.543	.6348	.5601	.5975	.6219	.6335
3	.5601	.543	.6348	.5601	.5975	.6219	.6335
4	.5601	.543	.5975	.5601	.5975	.6219	.6335
5	.5601	.543	.6722	.6348		.6584	.724
6	.6535	.6335	.7468	.7095	.6535	.6584	.8145
7	.7095	.8145	.8215	.7655	.7655	.8215	.8145
8	.7095	.8145	.8215	.7842	.7468	.695	.8145
9	.6908	.724		.8029	.7095	.6219	.8145
10	.6335	.8131	1.486	.8215	.6584	.6335	.724
11	.6335	.8131	.7095	.7655	.6219	.724	.6335
12	.6335	.5914	.6443	.7282	.6584	.8145	.6335
13	.6335	.7023	.6443	.7282	.6584	.8145	.6335
14	.6335	.5792	.6908	.7842	.6584	.8145	.6335
15	.6335	.5792	.7095	.8029	.6584	.724	.6335
16	.6335	.6154	.7468	.7842	.6584	.8145	.6335
17	.6335	.6722	.7842	.7468	.7164	.8145	.6335
18	.6335	.7842	.8029	.8402	.788	.8145	.6335
19	.8145	.8215	.7842	.8775	.8048	.8145	.724
20	.8145	.8215	.7468	.8775	.8048	.8145	.8145
21	.8145	.7468	.7468	.8402	.8131	.8145	.8145
22	.724	.7095	.7282	.7468	.8215	.8145	.8145
23	.6335	.6722	.6535	.6535	.7316	.724	.8145
24	.5601	.543	.6348	.6348	.6535	.6219	.6335
Max	.8145	.8215	1.486	.8775	.8215	.8215	.8145
Min	.5601	.543	.5975	.5601	.5975	.6219	.6335
Avg	.6511	.6736	.7425	.7321	.6944	.7298	.7051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 204 / JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4239	.3772	.4294	1.4937	1.0402	1.0898
2	.4668	.4191	.3772	.4294	1.4937	1.0402	1.0898
3	.4668	.4239	.3772	.4294	1.4937	1.0031	1.0898
4	.4668	.4239	.3772	.4294	1.6617	1.1523	1.1736
5	.4854	.4239	.4904	.4668	1.6991	1.3443	1.1736
6	.4854	.503	.5658	.4668	1.8671	1.5813	1.6766
7	.5228	.503	.5281	.4854	2.0351	1.9292	2.0119
8	.5415	1.0059	.5693	.5228	.2987	.3961	.4191
9	1.9418	1.6956		1.5497	.3174	.3018	.3353
10	1.6766	1.5242	1.6804	1.5769	.2641	.2515	.2515
11	1.6766	1.5089	1.6804	1.8671	.1886	.2515	.2515
12	1.6766	1.4022	1.6617	1.8858	.2075	.2515	.2515
13	1.5927	1.3717	1.6244	2.3152	.4527	.2515	.2515
14	1.5927	1.2763	1.5123	2.2592	.1886	.2515	.2515
15	1.6766	1.6975	1.5684	2.2218	.1886	.2515	.2515
16	.2515	.6036	.3921	2.2592	.1698	.2515	.2515
17	.3353	.2641	.3734	.2614	.2614	.2515	.2515
18	.3353	.4904	.3547	.4108	.3174	.3353	.3353
19	.5087	.4904	.4108	.4294	.5658	.503	.4191
20	.4191	.5093	.5228	.5228	.5281	.503	.503
21	.4239	.4715	.5228	.5228	.5281	.503	.503
22	.4239	.4715	.4854	.9522	.6958	.8383	.503
23	.4191	.4715	.4481	1.2696	1.0031	1.0898	1.0898
24	.4668	.4191	.415	.4294	1.307	.9907	1.0898
Max	1.9418	1.6975	1.6804	2.3152	2.0351	1.9292	2.0119
Min	.2515	.2641	.3547	.2614	.1698	.2515	.2515
Avg	.8050	.7831	.7528	1.0164	.8011	.6902	.6881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 206 / Natraj Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0724	.0076	.0747	.0747	.0107	.0905
2	.0747	.0724	.0076	.0747	.0747	.0076	.0905
3	.0678	.0724	.0076	.0747	.0747	.0091	.091
4	.0747	.0724	.0069	.0747	.0747	.0091	.0905
5	.0747	.0724	.0076	.0747	.0747	.0076	.0905
6	.0747	.0905	.0145	.0747	.0747	.0076	.0905
7	.0747	.0905	.0076	.1307	.0747	.0076	.0905
8	.1017		.0137	.0747	.0747	.0061	.0905
9	.112	.0905		.0747	.0747	.0061	.0905
10		.0107	.0747	.1494		.0905	.0905
11		.0107	.0747	.168		.0905	.0905
12		.0076	.0747	.1867	.1433	.0905	.0905
13		.0069	.0747	.1867	.1417	.0905	.0905
14		.0076	.0747	.1867	.1387	.0905	.0905
15	.181	.0076	.0747	.1867	.1387	.0905	.0905
16	.181	.0076	.0747	.1867	.1387	.0905	.0905
17	.181	.0076	.0747	.1867	.1387	.0905	.0905
18	.181	.0069	.0747	.1867	.1387	.0848	.0905
19	.0905	.0137	.0747	.1867	.1387	.0905	.0905
20	.0905	.0076	.0934	.1017	.1387	.0848	.0905
21	.0905	.0076	.0934	.112	.0076	.0905	.0905
22	.0905	.0076	.0934		.0076	.0905	.0905
23	.0724	.0076	.0934	.0747	.0076	.0905	.0905
24	.0747	.0724	.0076	.0934	.0747	.0076	.0905
Max	.181	.0905	.0934	.1867	.1433	.0905	.091
Min	.0678	.0069	.0069	.0747	.0076	.0061	.0905
Avg	.1033	.0358	.0522	.1270	.0921	.0556	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 201 / RUI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5487	.5658	.583	.5144	.5144	.583
2	.6224	.5487	.5658	.583	.5144	.5144	.5487
3	.6602	.5487	.5658	.583	.5144	.5144	.5487
4	.7356	.583	.6859	.6173	.583	.583	.6173
5	.8299	.7202	.8745	.7202	.8596	.6859	.7202
6	1.1506	.9431	.9945	.9602	1.1403	1.0631	.9259
7	1.1763	1.0288	.9774	1.0288	1.1203	.9945	.8573
8	1.0751	.9259	.9431	.9602	1.0456	.9259	.9259
9	.7545	.7716	.7202	.7545	.7716	.4801	.7202
10	.6722	.6173	.3772	.5144	.6173	.4801	
11	.5601	.5144	.4115	.5601	.5487	.4801	.5316
12	.5544	.4801	.4458	.5175	.4801	.4801	.5316
13	.4755	.4973	.4458	.5544	.4801	.5144	
14	.4207	.5144	.4115	.5487	.4801	.5144	.5144
15	.4755	.5316	.4801	.5121	.5144	.5487	.5487
16	.5487	.5144	.4801	.5121	.583	.583	.5658
17	.5914	.583	.583	.5487		.6859	.6344
18	.7842	.703	.6516	.695	.8573	.8573	.8059
19	1.1317	.9602	.7888	1.0374	.9259	.7888	.7716
20	.9335	.823	.823	.9335		.7202	.8402
21	.823	.7202	.7202	.7316	.7545	.6516	.7373
22	.7164	.6516	.6516	.6219	.6859	.6173	.6173
23	.631	.583	.6173	.5731	.6173	.6687	
24	.6413	.583	.5658	.583	.5144	.583	.6344
Max	1.1763	1.0288	.9945	1.0374	1.1403	1.0631	.9259
Min	.4207	.4801	.3772	.5121	.4801	.4801	.5144
Avg	.7328	.6623	.6394	.6764	.6874	.6437	.6753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 202 / DHANORA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.5089	1.5242	1.5775	1.3717			
10		1.4632	1.5242	1.3108			
11	1.4632	1.5242	1.4937	1.2498			
12	1.4175	1.3108	1.4632	1.247			
13	1.387	1.3413	1.3108	1.166			
14	1.3717	1.3717	1.3108	1.1336			
15	1.448	1.387	1.3413	1.2146			
16	1.5242	1.4022	1.3413	1.4413		1.5242	
17					1.5851	1.5851	1.4784
18					1.5546	1.5242	1.5089
19					1.3717	1.4327	1.2803
20					1.1888	.7316	.9145
21					1.1584	1.1584	.8993
22					1.1279	1.1431	.945
23					1.0974	1.1279	.945
24							1.0974
Max	1.5242	1.5242	1.5775	1.4413	1.5851	1.5851	1.5089
Min	1.3717	1.3108	1.3108	1.1336	1.0974	.7316	.8993
Avg	1.4458	1.4156	1.4204	1.2669	1.2977	1.2784	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 203 / VARULA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1888	1.2193	1.0974
2					1.1584	1.2193	1.2193
3					1.1584	1.2803	
4					1.1584	1.2803	1.3108
5					1.1873	1.3717	1.3413
6					1.3108	1.6461	1.3717
7					1.3717	1.3375	1.5546
8					1.4175	1.4632	1.3108
17		1.5851	1.6461	1.6356			
18	2.7435	1.7528	1.6461	1.7004			
19	1.6613	1.6156	1.5242	1.6842			1.4784
20	1.5242	1.5699	1.5242	1.4575			1.2651
21	1.4937	1.5394	1.4937	1.4575			1.2651
22		1.5546	1.4937	1.3748			1.3413
23	1.448	1.5242	1.4632	1.3108			1.2803
24	1.4937		1.6632	1.4327	1.2803		
Max	2.7435	1.7528	1.6632	1.7004	1.4175	1.6461	1.5546
Min	1.448	1.5242	1.4632	1.3108	1.1584	1.2193	1.0974
Avg	1.7274	1.5917	1.5568	1.5067	1.2480	1.3522	1.3197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 204 / Yelamb AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.6401			
2	.6859	.6859	.7545	.6706			
3	.7164	.7316	.7716	.6706			
4	.7621	.7621	.823	.7316			
5	.7926	.7926	.8745	.8535			
6	.8383	.8535	.9431	.9145			
7	1.0822	.9145	1.2346	1.0669			
8	1.0669	1.0517	1.286	1.0669			
9					2.1338	.3048	1.0364
10					2.2252	.2743	1.0669
11					2.1948	.2439	1.0669
12					2.1948	.2439	1.0517
13					2.1338	.2439	1.0212
14					2.1338	.1524	.9907
15					2.1948	.3048	.9145
16					2.1948	.3353	.8383
Max	1.0822	1.0517	1.286	1.0669	2.2252	.3353	1.0669
Min	.6859	.6859	.6859	.6401	2.1338	.1524	.8383
Avg	.8288	.8097	.9217	.8268	2.1757	.2629	.9983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 205 / NIWGHA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3429	.3772	.3772	.3772	.3429	.3772
2	.3734	.3429	.3772	.3772	.3772	.3429	.3772
3	.3921	.3429	.3772	.3772	.3772	.3429	.3772
4	.4294	.4287	.4115	.4115	.4298	.3772	.4115
5	.4854	.4801	.4287	.4458	.5487	.4801	.4801
6	.5788	.5487	.5487	.5487	.6348	.583	.583
7	.6535	.6173	.6344	.6173	.6722	.6516	.583
8		.5487	.583	.5487	.5975	.6173	.5487
9	.5281	.5144	.4973	.5144	.5144	.4801	.5144
10	.4481	.2743	.4115	.5144	.4801	.4458	.4458
11	.4108	.3086	.3772	.5228	.4115	.4115	.3429
12	.4108	.3086	.3772	.4854	.3429	.4458	.3944
13	.4066	.3601	.3429	.439	.3429	.4458	.4115
14	.4024	.3772	.3429	.4024	.3429	.4458	.3944
15	.3841	.4115	.3772	.439	.3772	.4458	.3944
16	.4024	.3258	.4115	.4572	.4115	.4458	.3944
17	.4207	.3944	.4801	.4755	.4458	.4458	.4458
18	.5121	.4973	.5144	.5487	.4801	.4458	.5316
19	.5975	.6516	.583	.5788	.583	.5487	.6344
20	.5601	.5316	.5487	.6348	.5487	.5144	.5316
21	.4755	.4801	.4801	.5487	.5144	.4801	.463
22	.4298	.4115	.4115	.4656	.4458	.4115	.4458
23	.4031	.3772	.4115	.4298	.3772	.3772	.4115
24	.3772	.3601	.3772	.3772	.3772	.3429	.3772
Max	.6535	.6516	.6344	.6348	.6722	.6516	.6344
Min	.3734	.2743	.3429	.3772	.3429	.3429	.3429
Avg	.4546	.4265	.4451	.4807	.4588	.4529	.4530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 206 / PEWA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4458	.4458	.4458	.4458	.4115	.4801
2	.4904	.4458	.4458	.4458	.4458	.4115	.4458
3	.5093	.4458	.4458	.4458	.4458	.4115	.4458
4	.5658	.4801	.5487	.5144	.4801	.4801	.5487
5	.679	.6001	.6516	.6859	.6516	.5144	.6859
6	.8676	.8573	.823	.7888	.9709	.823	.8402
7	.9431	.8916	.8573	.8573	.8962	.8573	.7888
8	.8488	.7545	.8573	.7888	.8589	.6859	.7202
9	.7356	.6859	.5658	.6516	.6516	.6173	.6173
10	.6348	.5487	.5487	.5144	.4458	.4801	.5144
11	.5041	.3944	.4801	.4854	.3772	.4115	.3601
12	.4108	.3772	.3772	.3921	.3429	.3772	.3944
13	.3772	.3772	.3772	.3734	.3429	.3772	.4115
14	.3772	.3944	.3772	.4108	.3429	.3772	.4115
15	.4115	.3944	.4115	.4024	.3772	.4115	.4115
16	.4115	.4115	.4115	.439	.4115	.4458	.4115
17	.5144	.4458	.4801	.4854	.5487	.5144	.4973
18	.6516	.6344	.5144	.6535	.6516	.6516	.6859
19	.7545	.7888	.6859	.8589	.7716	.7545	.7888
20	.6859	.6859	.7545	.7468	.6859	.6859	.6859
21	.6001	.5316	.5487	.6722	.6516	.6516	.583
22	.5144	.4801	.4801	.5487	.4801	.583	.5487
23	.4801	.4458	.4801	.6661	.4801	.5144	.5144
24	.4904	.463	.4458	.4458	.4458	.4458	.4801
Max	.9431	.8916	.8573	.8589	.9709	.8573	.8402
Min	.3772	.3772	.3772	.3734	.3429	.3772	.3601
Avg	.5812	.5408	.5423	.5716	.5501	.5373	.5530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 201 / LINGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.1193
Max	1.1193
Min	1.1193
Avg	1.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 202 / ASHTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.2929
Max	1.2929
Min	1.2929
Avg	1.2929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 203 / SHARADA EXP
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.1886
Max	.1886
Min	.1886
Avg	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 204 / YEOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5182
Max	.5182
Min	.5182
Avg	.5182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 201 / BARADSHEWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4089	1.1568	1.4918		2.1214	2.1434	2.4863
2	1.4089	1.1568	1.4918		2.1214	1.2431	2.4863
3	1.4089	1.2071	1.4918		2.2024	1.2431	2.4863
4	1.6244	1.3957	1.5746		2.2672	1.286	2.7349
5	1.9062		1.8233		2.3482	1.4384	2.9007
6					2.7368		2.9835
7					2.8988	1.5861	1.4089
8	2.652	1.7901	2.4863		1.2323	.8573	1.4089
9	3.0664	1.9439	2.9835		.9682		.9945
10		1.8787	3.0664		.8619	1.0608	.8049
11	2.652	2.6235		2.672	.8288	.8288	.7545
12	2.652	2.4478		2.4939	.8785	.9945	.7306
13	2.3205	1.8947		2.5101	.7876	.8288	.7419
14	2.2377	2.2672		2.2377	.9065	.9945	.7922
15	2.3205	2.0405		2.0719	.9214		.8802
16	1.1603	.7796		2.6397	1.0254	1.1603	.9682
17	.9717	1.1437		1.0084	.9659	1.326	.9682
18	.9976	1.1271		1.085	1.326		
19	1.3733	1.6575		1.3957	1.5009	1.7404	1.3832
20	1.3474	1.7404		1.3455	1.5604	1.9062	1.4586
21	1.3214	1.7404		1.2637	1.4563	1.6575	1.4209
22	1.2308	1.5746		2.2186	2.4074	2.652	
23	1.1443	1.4918		2.1862	2.3331	2.652	2.4129
24	1.4918	1.1191	1.4918		2.1214	1.3432	2.4863
Max	3.0664	2.6235	3.0664	2.672	2.8988	2.652	2.9835
Min	.9717	.7796	1.4918	1.0084	.7876	.8288	.7306
Avg	1.7475	1.6275	1.9890	1.9330	1.6158	1.4471	1.6224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 202 / PALSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	.8817	1.0059	.8718	.6104	.57	.5868
2	.9221	.8817	1.0059	.8718	.6104	.57	.5868
3	.9221	.9156	1.0059	.9054	.6104	.57	.5868
4	.9221	.9496	1.0059	1.1401	.6104	.5868	.5868
5	.9221	.8309	1.0395	1.2574	.6104	.6173	.5868
6	1.1736	.8139	1.0059	1.3413	.6783	.6516	.6036
7	1.3413	1.2887	1.3748	.5365	.5596	.583	.503
8	.503	.4409	.4191	.5365	.4409	.463	.4527
9	.4191	.39	.3315	.4359	1.1022	.463	.8383
10	.3353	.373	.3353		1.3245	1.0898	1.1869
11	.3353	.3391	.503	.3391	1.2574	1.1736	1.1191
12	.1677	.3052	.3018	.3222	.6874	1.1736	1.2548
13	.3353	.3052	.3018	.39	1.1568	.9221	1.1361
14	.3353	.3222	.3688	.39	.9892	.8383	1.1361
15	.3353	.3391	.3353	.407	1.1065	.8048	1.0513
16	.3353	.39	.3353	.39	1.0395	1.0898	1.0513
17	.373	.3353	.3521	.3391	.4024	.4191	.4239
18	.3391	.3315	.3688	.39	.3688	.4191	.4748
19	.5426	.503	.6203	.5935	.5365	.5868	.5935
20	.6952	.7042	.7042	.7122	.7042	.7042	.6882
21	.7122	.6706	.7011	.6104	.7377	.7042	.7122
22	1.0174	1.0059	.6706	.6443	.6539	.5365	.6783
23	1.0004	1.0059	.8383	.5426	.6036	.5868	.6443
24	.9221	.9156	1.0059	.8383	.6104	.5868	.5868
Max	1.3413	1.2887	1.3748	1.3413	1.3245	1.1736	1.2548
Min	.1677	.3052	.3018	.3222	.3688	.4191	.4239
Avg	.6595	.6350	.6640	.6437	.7505	.6963	.7529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 203 / SIBDARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6068	.5426	.6068	.3155	.5426	.5487	.5201
2	.6068	.5426	.6068	.3155	.5426	.5609	.5201
3	.6068	.5426	.6068	.3155	.5426	.567	.5201
4	.6068	.5426	.6068	.3506	.5426	.6447	.5201
5	.6935	.5426	.6935	.5609	.6104	.7164	.6935
6	1.0402	.8139	.6935	.7712	.763	.7164	.7802
7	1.0402	.8817	.6935	1.3321	.7461	.7164	.7802
8	.6935	.6104	.5201	1.3321	.6104	.7164	.6935
9	.5201	.5426	.5201	.6661	.78	.5792	.6935
10	.3467	.5087	.3467		.7712	.6588	.78
11	.1677	.3391	.1753	.3391	.7011	.6935	.407
12	.1734	.2035	.1753	.2035	.4207	.6935	.8139
13	.1734	.2035		.2374	.7011	.7282	.8139
14	.1734	.2035	.1753	.2035	.7011	.6935	.6783
15	.1734	.2035	.333	.3391	.6661	.7802	.6783
16	.1734	.1696	.2103	.2713		.8669	.6783
17	.1696	.1734	.2103	.2713	.3506	.4334	.4748
18	.3391		.2103	.3391	.4908	.5868	.5426
19	.6104	.6935	.6661	.6783	.7011	.6706	.7461
20	.6783	.6935	.6661	.6783	.3856	.6706	.6783
21	.6783	.6935	.7011	.6104	.7011	.6935	.6783
22	.6104	.6935	.2629	.6104	.7011	.6935	.5243
23	.5426	.6935	.3506	.5426	.5609	.6068	
24	.6068	.5426	.6068	.3155	.5426	.1802	.5201
Max	1.0402	.8817	.7011	1.3321	.78	.8669	.8139
Min	.1677	.1696	.1753	.2035	.3506	.1802	.407
Avg	.5013	.5033	.4625	.5043	.6120	.6423	.6407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 201 / TALNI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.6836	.7819
8	.4458	.4458	.3864		.3864	1.0997
11					.5944	
12		.5428				
16	.5053	.8949				
23				.2972	.7133	.5944
24				.4752	.5944	.8025
Max	.5053	.8949	.3864	.4752	.7133	1.0997
Min	.4458	.4458	.3864	.2972	.3864	.5944
Avg	.4756	.6278	.3864	.3862	.5944	.8196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 202 / SHIVVOOR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.9214	1.3077
8	1.1888	1.1736	.9831		1.0997	
12		1.1736				
16	.6687	1.0416				
23				.7727	1.1584	1.0402
24				.9831	.8916	.9214
Max	1.1888	1.1736	.9831	.9831	1.1584	1.3077
Min	.6687	1.0416	.9831	.7727	.8916	.9214
Avg	.9288	1.1296	.9831	.8779	1.0178	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 203 / TALNI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.7682				1.3306	1.3443
8	1.1294	1.3306		1.3256	1.4563	.6535	1.3717
12		.924			.9511		
16	.6584	1.307		.8402	1.4632	.8025	.7316
23	.9877	.6584			1.3717	1.1706	.7316
24	.5053	.6219	.6584	.7842	.9149	1.3535	.9511
Max	1.1294	1.3306	.6584	1.3256	1.4632	1.3535	1.3717
Min	.5053	.6219	.6584	.7842	.9149	.6535	.7316
Avg	.8202	.9350	.6584	.9833	1.2314	1.0621	1.0261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 204 / MATALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		1.0105	1.0715			
11					.6241	
16					1.2163	1.3611
23	.8688	1.0997				
24	.5944	.8916	1.07	.5647		
Max	.8688	1.0997	1.0715	.5647	1.2163	1.3611
Min	.5944	.8916	1.07	.5647	.6241	1.3611
Avg	.7316	1.0006	1.0708	.5647	.9202	1.3611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 201 / Lyhari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4904	.4715	.4715	.8745	1.0911	1.0279
2	.415	.4904	.4715	.4527	.8745	1.0883	1.0437
3	.4904	.5093	.4715	.4527	.9069	1.1203	1.0242
4	.4904	.5281	.5281	.4904	.9393	1.1336	1.0082
5	.679	.547	.5658	.5658	.9602	1.1523	1.1174
6	.5658	.6224	.6413	.6602	1.2163	1.4548	1.5402
7	.5281	.6036	.5658	.547	1.2955	1.4529	1.6324
8	1.0486	1.0883	1.3108	.547	.3772	.4904	.5281
9	1.4575	1.4548	1.5497	1.2803	.3395	.4715	.415
10	1.5546	1.4403	1.4548	1.2334	.3018	.415	.3772
11	1.5546	1.4575	1.4575	.9393	.3018	.2263	.3361
12	1.4403	1.4723	1.3927	1.2651	.2829	.3772	.3361
13	1.2483	1.4413	1.3763	1.2651	.2075	.415	.3395
14	1.3283	1.3603	1.4251	1.2018	.3018	.3772	.3395
15	1.4243	1.4419	1.4251	1.3916	.3961	.3584	.3361
16	.3584	.3395	.3772	1.1248	.3961	.3772	.3547
17	.3961	.3584	.415	.3547	.3961	.415	.415
18	.4338	.4338	.415	.4294	.4338	.4338	.4527
19	.4715	.5281	.5281	.4904	.5281	.5658	.5228
20	.5658	.5975	.547	.6036	.547	.5658	.5975
21	.5658	.5658	.5847	.5658	.5658	.547	.5975
22	.547	.5281	.5281	.8848	1.1961	1.1203	1.3108
23	.5093	.4904	.5093	.8642	1.1336	1.0753	1.2631
24	.4338	.4904	.4715	.4904	.8539	1.1203	1.0311
Max	1.5546	1.4723	1.5497	1.3916	1.2955	1.4548	1.6324
Min	.3584	.3395	.3772	.3547	.2075	.2263	.3361
Avg	.7892	.8033	.8118	.7738	.6511	.7435	.7478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 202 / HARDAP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0688	1.3916	1.1961	1.4083	.4481	.4715	.4904
2	.9922	1.3923	1.1768	1.3763	.4527	.4715	.4715
3	.9922	1.3765	1.1305	1.3283	.4481	.4904	.4715
4	1.0242	1.3283	1.1961	1.3125	.5228	.5281	.5093
5	1.0883	1.2811	1.2631	1.3927	.6722	.6036	.5847
6	1.2018	1.5181	1.5684	1.6324	.679	.679	.7167
7	1.5497	1.7284	1.6288	1.7976	.6413	.6036	.5847
8	.4111	.547	.6036	.5093	.5281	.5093	.5093
9	.4527	.4527	.4338	.3584	1.6712	1.4251	1.4575
10	.3772	.3961	.3772	.4338	1.7166	1.7394	1.5181
11	.3018	.3395	.3395	.3018	1.5524	1.5813	1.5497
12	.3018	.3206	.3395	.3206	1.5708	1.4548	1.5154
13	.3395	.3395	.3206	.3395	1.4255	1.406	1.4998
14	.3395	.3395	.3206	.3584	1.4403	1.3904	1.5546
15	.3395	.3395	1.0774	.3395	1.3603	1.3889	1.4575
16	.3395	.3772	.3018	.3361	1.5364	1.3599	1.5364
17	.3772	.415	.2641	.3547	.4527	.3018	.3395
18	.4338	.4904	.3395	.5601	.4715	.4338	.4904
19	.5847	.547	.4904	.5658	.5281	.6036	.5658
20	.5281	.5281	.5093	.5041	.547	.5658	.5281
21	.5281	.5281	.5281	.4854	.547	.5658	.5658
22	1.4563	1.3108	1.3927	.4854	.5281	.5281	.5281
23	1.4723	1.2616	1.4083	.4668	.4904	.5093	.5281
24	1.0526	1.3599	1.2289	1.4083	.4668	.4904	.4904
Max	1.5497	1.7284	1.6288	1.7976	1.7166	1.7394	1.5546
Min	.3018	.3206	.2641	.3018	.4481	.3018	.3395
Avg	.7314	.8295	.8098	.7657	.8624	.8376	.8526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 203 / PINGALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.4372	.4534	.4534	.7432	.7682	.8421
2	.4534	.421	.4534	.426	.7274	.8002	.8097
3	.4534	.4372	.4534	.431	.7274	.8002	.7773
4	.4534	.4372	.4858	.463	.7274	.8322	.7773
5	.4858	.4534	.502	.5847	.7432	.8642	.8002
6	.4858	.5344	.5344	.6413	.8697	1.0722	1.1203
7	.4534	.4372	.4534	.5281	1.0753	1.2018	1.2163
8	.6802	.664	.6478	.415	.3953	.4481	.3521
9	1.0526	.9393	1.0364	1.134	.3321	.3361	.2881
10	1.1336	1.0364	1.1012	1.2656	.3005	.2881	.2401
11	1.166	1.1336	1.166	1.2407	.2372	.2401	.2267
12	1.1012	1.1174	1.0526	1.094	.2214	.2881	.2267
13	.8421	1.1012	1.0202	1.0562	.253	.2881	.2591
14	.8745	.9878	.9555	1.0364	.2688	.2721	.2915
15	.9393	1.0526	.9231	1.0082	.2846	.2721	.2915
16	.2429	.2591	.2753	1.0082	.3361	.2915	.3077
17	.2753	.2753	.2753	.2591	.3201	.3077	.3077
18	.3401	.3401	.3077	.3077	.3163	.3239	.3077
19	.4534	.4858	.4534	.5344	.4481	.4858	.4534
20	.502	.4534	.502	.5344	.5601	.5344	.4858
21	.502	.5182	.5182	.5344	.5281	.5344	.5344
22	.4858	.4858	.4858	.68	.7682	.8097	.8907
23	.4696	.4696	.4696	.759	.8162	.8259	.8907
24	.4534	.4534	.4534	.4696	.7432	.8162	.8583
Max	1.166	1.1336	1.166	1.2656	1.0753	1.2018	1.2163
Min	.2429	.2591	.2753	.2591	.2214	.2401	.2267
Avg	.6147	.6221	.6241	.7027	.5310	.5709	.5648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 201 / JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4481	.3772	.3429	.2614	.2241	.2058
2	.4481	.4481	.3772	.3086	.2614	.2241	.2058
3	.4481	.4527	.4458	.3086	.2801	.2241	.2401
4	.4854	.5658	.5144	.3772	.3174	.2427	.2401
5	.5415	.5975	.5487	.4458	.3734	.3174	.2743
6	.6722	.6722	.583	.5144	.4668	.3734	.3086
7	.5601	.7095	.6173	.6001	.4108	.4668	.3429
8	.2987	.2035	.2058	.6173	.5788	.6348	
9	.2656	.2883	.2401	.2058	.5228	.4668	.4801
10	.2753	.3086	.2743	.2743	.3734	.3429	.4287
11	.2688	.2572	.2572	.2987	.3361	.3429	.3772
12	.2347	.2401	.2572	.2801	.3361	.3086	.3429
13	.1865	.2401	.2401	.2801	.3174	.3086	.3086
14	.1844	.2058	.2401	.2801	.3174	.2743	.2743
15	.2543	.2058	.2572	.3361	.3361	.2743	.3086
16	.2713	.3429	.3086	.3734	.3361	.3086	.3086
17	.3391	.3772	.3429	.4108	.3734	.3772	.3429
18	.4854	.4287	.4287	.5601	.5041	.4458	.4458
19	.6535	.5487	.6001	.7095	.6908		.6001
20	.7095	.5487	.5144	.6161	.3361		.5144
21	.5601	.5144	.4458	.5144	.4854	.4801	.4458
22	.5228	.4801	.4115	.2614	.2241	.2401	.4458
23	.5228	.4458	.3772	.2614	.2427	.2058	.2401
24		.4854	.4115	.2614	.2427		.2058
Max	.7095	.7095	.6173	.7095	.6908	.6348	.6001
Min	.1844	.2035	.2058	.2058	.2241	.2058	.2058
Avg	.4206	.4173	.3865	.3933	.3719	.3373	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 202 / VIRSANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2427	.2058	.2058	.3734	.3734	.3772
2	.2427	.2427	.2058	.2058	.3921	.3734	.4115
3	.2427	.2427	.2743	.2401	.3921	.3921	.4115
4	.2614	.2641	.3086	.2401	.4108	.3944	.4115
5	.2987	.3361	.3086	.2743	.4294	.4854	.4458
6	.3361	.3361	.3429	.3086	.5415	.5601	.4801
7	.2743	.3734	.3086	.3086	.5975	.6348	.5144
8	.4854	.4534	.4458		.3361	.3361	.3429
9	.4696	.5182	.5144		.2614	.2743	.3086
10	.5182	.583	.5487		.2427	.2401	.2058
11	.6348	.5487	.5144	.5601	.2241	.2058	.2058
12	.4999	.5144	.5144	.5228	.1867	.2058	.2058
13	.502	.5144	.2401	.4854	.1867	.2058	.1715
14	.4999	.5144	.4801	.4481	.1867	.1715	.1715
15	.4744	.5487	.5144	.4481	.2241	.1886	.2058
16	.0162	.2058	.2401	.4854	.2241	.2058	.2058
17	.2267	.2401	.2743		.2801	.2743	.2401
18	.2987	.2572	.2743	.2987	.2987		.3086
19	.3361	.3086	.3429	.3734	.3734	.3429	.3086
20	.3361	.2743	.3429	.3361	.3361	.3086	.2743
21	.2987	.2572	.3086	.3361	.3361	.2401	.2058
22	.3018	.2401	.2743	.2614	.4481	.3429	.3086
23	.2614	.2401	.2401	.3547	.3921	.3429	.3429
24		.2614	.2058	.3734	.3734		.3772
Max	.6348	.583	.5487	.5601	.5975	.6348	.5144
Min	.0162	.2058	.2058	.2058	.1867	.1715	.1715
Avg	.3512	.3549	.3429	.3534	.3353	.3227	.3101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 203 / KAMARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.2987	1.0631	1.2003	.7468	.7655	.6516
2	.9335	.2987	1.0974	1.2346	.7095	.7655	.6173
3	1.0456	.3361	1.2003	1.2689	.7095	.7842	.6173
4	1.1576	.3361	1.2346	1.3717	.7468	.8215	.6516
5	1.1576	.3734	1.3717	1.4403	.8775	.8589	.7202
6	1.531	.4481	1.4403	1.5432	.9896	.9522	.8573
7	1.8298	1.307	1.5432	1.5775	.7842	.9522	.8916
8	.7655	.7468	.7202	.7716	.7468	.8215	
9	.6722		.583	.6859	.9709	1.4937	1.4575
10	.5601	.5144	.5144	.4458	1.4937	1.4403	1.6289
11	.5281	.4458	.4801	.5041	1.643	1.5432	1.4403
12	.5281	.4115	.4458	.5041	1.4937	1.4746	1.3717
13	.547		.4115	.5228	1.4937	1.2003	1.3032
14	.5228	.4458	.4287	.5228	1.4937	1.2346	1.2003
15	.5228	.4801	.4458	.5228	1.4937	1.2689	1.2689
16	.5281	.5144	.4801	.5415	1.4937	1.3032	1.5775
17	.5975	.6173	.6173	.4854	.6348	.4801	.6173
18	.7282	.6859	.6859	.5601	.6722	.6173	.7202
19	.9149	.8573	.8573	.8962	.9335	.8916	.7716
20	.8865	.823	.8573	.8589	.8962	.8573	.7202
21	.9335	.7888	.7545	.8589	.8962	.7888	.6859
22	.9709	.9259	1.1145	.8402	.8589	.6859	.6516
23	.9069	1.0288	1.2003	.8215	.8215	.6516	.6173
24		.2915	1.0631	.8215	.7842		.6516
Max	1.8298	1.307	1.5432	1.5775	1.643	1.5432	1.6289
Min	.5228	.2915	.4115	.4458	.6348	.4801	.6173
Avg	.8566	.5898	.8588	.8667	1.0160	.9849	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 201 / MANATHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.1317	1.1431	1.1128	.6104	.7011	.7202
2	.9709	1.1694	1.1431	1.1317	.6443	.7282	.763
3	1.0269	1.2071	1.1431	1.1506	.6783	.7282	.7969
4	1.0164	1.2071	1.1431	1.1317	.763	.7802	.8215
5	1.1088	1.2826	1.3336	1.226	.8478	.8573	.8987
6	1.2197		1.5242	1.358	.9054	.9665	.9892
7	.7762			1.4523	1.0513	1.0343	1.1869
8	.5087	.5426	.503	1.1506	1.1883	1.1622	1.1317
9	.6203	.7291	.9907	.7888	.9808	.9907	.9431
10	.6706	.8309	.8383	.8309	.7545	.8029	.8865
11	.7122	.639	.7291	.9054	.724	.7733	.7167
12	.6154	.639	.7373	.5426	.6097	.7356	.7356
13	.6316	.6478	.7127	.7209	.6668	.679	.7167
14	.6274	.6478	.6796	.7122	.724	.6979	.6413
15	.5992	.7449	.663	.6952	.724	.7356	.6413
16	.6036	.6668	.679	.7122	.7621	.7545	.7468
17	.8402	.7621	.7545	.8215	.8002	.9242	.8488
18	1.0374	.9526	.8299	.8215	.8764	1.0374	.9808
19	1.2449	1.3717	1.0751	.9335	1.0479	1.358	.9709
20	1.3014	1.2955	1.2637	1.0374	1.1431	1.3014	1.0185
21	1.226	1.2384	1.2449	1.226	1.2384	1.2637	1.226
22	1.1128	1.1431	1.1506	.5847	.7011	.6626	.6485
23	1.1203	1.1431	1.1317	.5487	.7011	.7265	.6068
24	.9709	1.1317	1.1431	1.1317	.6344	.7011	.703
Max	1.3014	1.3717	1.5242	1.4523	1.2384	1.358	1.226
Min	.5087	.5426	.503	.5426	.6097	.6626	.6068
Avg	.8972	.9602	.9807	.9470	.8241	.8793	.8475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 202 / KEDARGUDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409	.4801	.5258	.4973	.4191	.4954	.4954
2	.4458	.5201	.5258	.5304	.5144	.4954	.5144
3	.4409	.5548	.5258	.5571	.415	.4954	.5144
4	.5144	.5609	.5258	.5967	.3772	.4954	.5335
5	.6001	.583	.6135	.6464	.381	.5144	.5335
6	.6173	.6859	.7202	.6962	.4382	.5335	.547
7	.6859	.6613	.7042	.7291	.4572	.4763	.4763
8	.3772	.2858	.3048	.3772	.381	.362	.3429
9	.2829	.2641	.3048	.2858	.407	.3978	.4696
10	.2452	.2096	.2286	.2829	.5533	.5304	.5344
11	.2286	.1905	.2096	.2286	.4858	.5138	.5312
12	.2096	.2096	.1905	.2829	.4534	.4915	.4687
13	.1509	.1715	.2096	.3395	.4534	.421	.4321
14	.1905		.2096	.2858	.421	.4372	.4012
15	.1905	.1905	.2286	.2096	.4858	.4374	
16	.2096	.2096	.2096	.2096	.5506	.4752	.3749
17	.2096	.2477	.1905	.2477	.2286	.2477	.2286
18	.2477	.2477	.2477	.2667	.2858	.2858	.2286
19	.5335	.4763	.4954	.2858	.5144	.5144	.3429
20	.5281	.5335	.5144	.381	.5335	.5716	.381
21	.5144	.5335	.4862	.547	.5525	.5906	.5525
22	.4578	.4961	.4359	.5335	.5335	.547	.5144
23	.4801	.5316	.4475	.5335	.5144	.5335	.4715
24	.4748	.4801	.5316	.4641		.4954	.5144
Max	.6859	.6859	.7202	.7291	.5533	.5906	.5525
Min	.1509	.1715	.1905	.2096	.2286	.2477	.2286
Avg	.3865	.4054	.3994	.4173	.4503	.4733	.4523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 203 / MALZARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5426	.7202	.7442	.6859	.7922	.7922	.7468
2	.5487	.7202	.7442	.7455	.8299	.7922	.7468
3	.5365	.7628	.7442	.7802	.8488	.7922	.7842
4	.5365	.823	.7973	.7975	.8488	.7922	.8402
5	.5365	.823	.8859	.8149	.8676	.8488	.8962
6	.5087	.9945	1.0867	.8764	.9054	.9808	.9896
7	.6371	1.0631	.9602	.8589	.9242	.9431	.9709
8	.7377	.7545	.7545	.811	.7922	.7545	.7922
9	.7167	.679	.6224	.6979	.6344	.5935	.5609
10	.5658	.5658	.5093	.5847	.503	.6001	.5596
11	.4904	.4108	.415	.5093	.4973	.5533	.4999
12	.415	.3772	.4338	.4527	.4973	.5138	.4531
13	.4527	.415	.415	.4715	.4973	.4752	.427
14	.4527	.415	.4338	.4715	.4973	.5197	.4687
15		.4108	.4715	.4527	.5243	.547	.4843
16	.4527	.415	.4715	.4904	.5801	.5138	.506
17	.5281	.4854	.5041	.5281	.5658	.5658	.6413
18	.4481	.5601	.5658	.6224	.6478	.6224	.679
19	.8676	.8676	.7545	.6602	.7545		.7167
20	.8865	.8676	.811	.8676	.8676	.8589	.7545
21	.8299	.811	.7455	.8865	.8299	.8402	.8676
22	.6661	.7164	.6001	.8299	.8299	.7842	.7922
23	.6935	.7522	.6516	.7922	.7922	.7655	.7545
24	.6001	.6935	.7442	.703	.7922	.7922	.7655
Max	.8865	1.0631	1.0867	.8865	.9242	.9808	.9896
Min	.415	.3772	.415	.4527	.4973	.4752	.427
Avg	.5935	.6710	.6611	.6830	.7133	.7062	.6957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 201 / LOHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2789	.2829	.2829	.3734		.4858
2	.2829	.2789	.2801	.2829			.4858
3	.2829	.2789	.2801	.2829			.4858
4	.2829	.2795	.2801	.2829			.5668
5	.2829	.2721	.3734	.2829			.6478
6	.3772	.3704	.3734	.3772			.7287
7	.3772	.3727	.2801	.3772			.6478
8	.4287	.7438	.4108	.2829	.1867		.2829
9	.6478	.7346	.2858	.4858			.1886
10	.7461	.5792	.5668	.6478	.1867	.1886	.1867
11	.7453		.6478		.1867	.2829	.1867
12	.7423	.5792	.6478			.1886	.1867
13	.7438		.6478			.1886	.1867
14	.7453	.4344	.5668			.1886	.1867
15	.6521		.6478			.1886	
16	.184	.1867	.1886	.5135		.1886	.1867
17			.1886			.2829	.1867
18	.1877	.1867	.1886			.2829	.1867
19	.2795		.2829			.3772	.2801
20	.3799	.2801	.3772	.3734		.3772	.2801
21	.3727	.3734	.3772			.3772	.3734
22	.3727	.2801	.3772			.503	.4287
23	.2792	.2829	.2829	.4344		.4858	.3715
24	.2829	.2789	.2829	.2829	.381		.4858
Max	.7461	.7438	.6478	.6478	.381	.503	.7287
Min	.184	.1867	.1886	.2829	.1867	.1886	.1867
Avg	.4330	.3722	.3799	.3707	.2629	.2929	.3580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 202 / CHIKALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.4906	1.3717	1.6194	.8402		.9431
2	1.2955	1.4845	1.4251	1.6194			.9431
3	1.2955	1.677	1.6289	1.6194			.9431
4	1.2955	1.6547	1.6766	1.7004			.9431
5	1.3765	1.9564	2.0119	1.7814			1.0374
6	1.5384	2.2108	2.2634	1.9433			1.1317
7	1.9433	2.5899	2.4006	2.1862			.8488
8	.6602	.559	.5601	.7545	.5601		.6602
9	.5658	.4482	.5601	.5658	1.6766		1.3717
10	.4658		.4715	.6859		2.1052	2.0576
11	.3727	.4668	.3772		1.6766	2.1052	
12	.3727		.4715	.4668		1.9433	1.829
13	.3727	.4715	.5658			1.6194	
14	.3727		.4715			1.5384	1.4746
15	.3727	.4668	.4715			1.4575	
16	.4658	.4668	.5658	.4668		1.7004	1.9662
17			.5658			.4715	.4668
18	.559	.6535	.6602			.5658	.5601
19	.9316		.8488			.9431	.9335
20	1.0353	.9335	.9431			1.0374	1.0269
21	1.0248	.9335	.9431			1.0374	1.0269
22	1.3043		1.7814			1.0374	.9335
23	1.3043		1.7004			.9431	.9335
24	1.3765	1.3975	1.1869	1.6194	.8402		.9431
Max	1.9433	2.5899	2.4006	2.1862	1.6766	2.1052	2.0576
Min	.3727	.4482	.3772	.4668	.5601	.4715	.4668
Avg	.9390	1.1683	1.0801	1.3099	1.1187	1.3218	1.0940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 203 / WANWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6568	.6535	.6602	.9221		1.1736
2	.7545	.6521	.6535	.6602			1.1736
3	.7545	.6642	.6535	.6602			1.1736
4	.7545	.6408	.6535	.6602	1.0059		1.2574
5	.7545	.6421	.6535	.6602			1.3413
6	.7545	.7171	.6535	.7545			1.5927
7	.6602	.6301	.5601	.6602			1.6766
8	1.0288	1.3875	.8954	.4715	.4668		.4715
9	1.6766	1.7176	1.4575	1.3413			.3772
10	1.3946	1.5261	1.5089	1.5089	.2801	.2829	.3734
11	1.4906		1.5089		.3734	.2829	.3734
12	1.5181	1.4251	1.6032	1.4251		.2829	.2801
13	1.3975		1.3413			.2829	.2801
14	1.3043	1.0059	.8383			.3772	
15	1.118		1.1736			.3772	
16	.9316	.2801	.2829	1.0898		.2829	.2801
17			.3772			.3772	.3734
18	.4658	.4668	.4715			.3772	.3734
19	.6521		.6602			.6602	
20	.7453		.5658			.7545	.6535
21	.7453	.6535	.5658			.7545	.7468
22	.7438		.6602			1.0288	1.153
23	.7453	.6535	.6602	1.0059		1.226	1.1393
24	.7545	.6521	.6535	.6602	1.0059		1.1736
Max	1.6766	1.7176	1.6032	1.5089	1.0059	1.226	1.6766
Min	.4658	.2801	.2829	.4715	.2801	.2829	.2801
Avg	.9521	.8454	.8211	.8727	.6757	.5248	.8304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 201 / KOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4435	.3696	.3961	.4294	.4251	.4066
2	.4435	.4435	.3696	.3961	.4108	.4066	.4066
3	.462	.4805	.4066	.415	.4108	.4066	.4435
4	.4805	.4805	.4066	.415	.5228	.4435	.4435
5	.5914	.6283	.6099	.811	.6348	.5544	.5175
6	.9425	.7947	.8501	.811	.8775	.7577	.6838
7	.8316	.8131	.8686	.6413	.8402	.7947	.7577
8	.7577	.6838	.7023	.6036	.8029	.7207	.499
9	.499	.6099	.5914	.4904	.5729	.5914	.462
10	.4435	.5359	.4251	.4338	.4251	.499	.3696
11	.4066	.4435	.3961	.4108	.3511	.4251	.3734
12	.3326	.3881	.3584	.3734	.3326	.4066	.3921
13	.3881	.4066	.4527	.4294	.3326	.4251	.3921
14	.3511	.4066	.415	.4294	.4066	.4805	
15	.3696	.3881	.3961	.4294	.4066	.4435	
16	.4251	.462	.4527	.4668	.462	.499	.2241
17	.5359	.5914	.5658	.5788	.6099	.6468	.5601
18	.5914	.6653	.6413	.6348	.7023	.7392	.6535
19	.7947	.8316	.7733	.7095	.7947	.8131	.7282
20	.6283	.5729	.5847	.6161	.6468	.6653	.5975
21	.5359	.499	.5093	.4854	.5359	.5359	.4668
22	.4805		.4338	.4481	.462	.462	.4668
23	.462	.4251	.4338	.4294	.4435	.4251	.4294
24	.4435	.462	.3881	.415	.4294	.4251	.4066
Max	.9425	.8316	.8686	.811	.8775	.8131	.7577
Min	.3326	.3881	.3584	.3734	.3326	.4066	.2241
Avg	.5267	.5416	.5167	.5112	.5351	.5413	.4855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 202 / KOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2641	.3353	.3048
2					.2641	.3353	.3048
3					.2641	.3353	.3048
4					.2934	.3658	.3658
5					.3227	.4115	.3963
6					.4401	.5639	.5792
7					.4694	.5792	.5944
8	.3048	.3201					
9	.4268	.4572		.2824			
10	.5182	.5487		.4904			
11	.5182	.5944		.5135			
12	.3658	.5487	.4607	.5575			
13	.3963	.503	.4607	.5281			
14	.3963	.4725	.4458	.535			
15	.4268	.4115	.431	.4988			
16				.4841			
22				.2934	.3506	.3506	.2972
23				.2934	.3506	.3353	.3121
24					.2675	.3353	.3201
Max	.5182	.5944	.4607	.5575	.4694	.5792	.5944
Min	.3048	.3201	.431	.2824	.2641	.3353	.2972
Avg	.4192	.4820	.4496	.4477	.3287	.3948	.3780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 203 / BHATEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3353	.2896	.2641			
2	.2743	.3353	.2743	.2641			
3	.2743	.3658	.2743	.2494			
4	.3048	.3658	.3048	.2494			
5	.3201	.3658	.3048	.2641			
6	.4268	.381	.3201	.3374			
7	.442	.442	.3658	.4254			
9					.3658	.2896	.3201
10					.499	.381	.4268
11					.4251	.3506	.3814
12					.3658	.3963	.3814
13					.3658	.3201	.3668
14					.3658	.3353	.3814
15					.4115	.3353	.3814
16					.381	.3506	.3961
22	.3506	.3506	.2934				
23	.3353	.3201	.3081				
24	.2743	.3353	.2896	.2751			
Max	.442	.442	.3658	.4254	.499	.3963	.4268
Min	.2743	.3201	.2743	.2494	.3658	.2896	.3201
Avg	.3277	.3597	.3025	.2911	.3975	.3449	.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 201 / HIMAYATNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	1.0985	1.2071	1.1888	1.1222		1.1317
2	1.0974	1.0974	1.1888	1.134		1.1888	1.1317
3	1.0517	1.0608	1.1222	1.134	1.1765	1.0974	1.1317
4	1.0745	1.0517	1.086	1.134	1.2437	1.0974	1.1317
5	1.1218	1.1888	1.267	1.134	1.2803	1.1888	1.1317
6	1.2178	1.134	1.2445	1.1888	1.3289	1.1888	1.166
7	1.1888	1.1888	1.134	1.1888	1.2795	1.1888	1.2003
8	1.1393	1.1694	1.0974		1.2437	1.1888	1.2346
9	1.0631	1.1218	1.134	1.134	1.134	1.1765	1.3032
10	1.134	1.262	1.0059	1.1568	1.0059	1.2071	1.166
11	1.1041	1.2127	1.0242	1.1694	.9511	1.1919	1.0974
12	1.1218	1.2437	1.0608	1.1393	.9145	1.1765	1.0974
13	1.0631	1.1568	1.0974	1.2308	1.0974	1.1888	1.2003
14	1.0867	1.1393	1.134	1.1871	1.1706	1.0867	1.2003
15	1.1043	1.1043	1.134	1.1403	1.1888	1.0867	1.166
16	1.1517	1.1744	1.134	1.134	1.1888	1.0867	1.0974
17	1.1222	1.1517	1.134	1.1694	1.1888	1.2308	1.166
18	1.1517	1.1694	1.3717	1.1706	1.1888	1.0911	1.3717
19	1.3466	1.3146	1.4266	1.1765	1.2803	1.1873	1.3375
20	1.2757	1.3112	1.3717	1.2071	1.4266	1.2631	1.3375
21	1.382	1.262	1.3169	1.3535	1.3169	1.2929	1.3717
22	1.258	1.2094	1.2803	1.3169	1.3169	1.2334	1.3717
23	1.2403	1.2437	1.1888	1.2803	1.3169	1.3394	1.3375
24	1.086	1.2048	1.1568	1.1888	1.0631	1.2803	1.2803
Max	1.382	1.3146	1.4266	1.3535	1.4266	1.3394	1.3717
Min	1.0517	1.0517	1.0059	1.134	.9145	1.0867	1.0974
Avg	1.1514	1.1780	1.1799	1.1851	1.1924	1.1851	1.2151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 204 / KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.2683	.2572	.6401	.5853	.6401	.5487
2	.5898	.2785	.2804	.5853	.6219	.6401	.5487
3	.5898	.2641	.3086	.5853	.6516	.6401	.5487
4	.5967	.2881	.2804	.5853	.6878	.6401	.5487
5	.583	.3121	.3418	.6401	.724	.7316	.5792
6	.5937	.3041	.3681	.7316	.7602	.7682	.6097
7	.5247	.3201	.3041	.6584	.7888		.6859
8	.4534		.4572		.6219	.5853	.381
9	.5316	.4557	.5487	.7888	.4572	.3681	.3353
10	.7059	.6878	.7316	.6584	.3658	.3401	.3353
11	.6379	.691	.7316	.6401	.3658	.3239	.3772
12	.6878	.7087	.6401	.6036	.3658	.3563	.3772
13	.6379	.6661	.6401	.6516	.4024	.3521	.3944
14	.6556	.6836	.6401	.6335	.4024	.3479	.3506
15	.691	.7087	.7316	.6697	.4572	.3605	.3353
16	.724	.7362	.7316	.724	.3658	.3281	.3772
17	.144	.1715	.7316	.176	.3658	.3725	.4115
18		.2401	.8779	.2058	.5121	.3725	
19	.3258	.3258	.9511	.3258		.5898	.6516
20	.3429	.7888	.9145	.3858	.5853	.6154	.6401
21	.3601	.3506	.7316	.3201	.6584	.6464	.6859
22	.3258	.3243	.6401	.6154	.6401	.5693	.6097
23	.2881	.2801	.6401	.5792	.6401	.5792	.5487
24	.583	.2915	.2743	.6401	.5487	.6401	.5792
Max	.724	.7888	.9511	.7888	.7888	.7682	.6859
Min	.144	.1715	.2572	.176	.3658	.3239	.3353
Avg	.5288	.4411	.5731	.5671	.5467	.5134	.4983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 201 / KOSMETH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3						1.3154	
6	1.2193	1.323	1.3077				1.1431
8						1.6442	
9					1.3077	1.448	1.3811
10	1.85	1.5656		1.5162			
11		1.6289		1.3843			
12	1.3214	1.5493	1.5242	1.3184			
15					1.5021	1.5242	
16		1.3001					
17	1.5857			1.648			
18			1.5242				
19	1.3214			1.648	1.6328		1.6442
20	1.3875	1.4951	1.448	1.4832	1.3895	1.2955	1.4798
21		1.3001			1.3077		
22	1.3214	1.2189		1.3184	1.3093		1.236
23							1.4798
24				1.1431			
Max	1.85	1.6289	1.5242	1.648	1.6328	1.6442	1.6442
Min	1.2193	1.2189	1.3077	1.1431	1.3077	1.2955	1.1431
Avg	1.4295	1.4226	1.4510	1.4325	1.4082	1.4455	1.394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 201 / JALDHARA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3384	
2					.1429	.3572	
5						.3572	
6	.0347	.2591					
7		.3628	.4999		.3292	.3948	.4999
11	.4001						
15	.3894						
16				.0347			
17					.0549		
18				.0339	.0532		
19					.0732		
20				.0732	.0732		
21	.0514			.0732	.0732	.0953	
22			.3086	.2286	.3243		.2968
23	.2841			.2	.3572		
24		.2229		.4054	.1286	.3521	
Max	.4001	.3628	.4999	.4054	.3572	.3948	.4999
Min	.0347	.2229	.3086	.0339	.0532	.0953	.2968
Avg	.2319	.2816	.4043	.1499	.1610	.3158	.3984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 202 / NANDGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3547	
2					.2829	.3361	
5		.3734				.3734	
6	.3467	.4481					
7	.3696	.3547	.298	.3326	.2801	.3142	.298
11				.2686			
12				.2686			
13				.2715	.3109		
14				.2534	.2835		
15				.2481			
16				.2481	.2481		
17	.2804			.2835	.2865		
18	.3109			.2926	.3403		
19	.4066				.4066		
20	.4251			.2957	.4066		
21	.4251			.3658	.4108	.3856	
22			.333	.3696	.4108		.3544
23	.3921			.2957	.3921		
24		.3881		.3361	.2829	.3547	
Max	.4251	.4481	.333	.3696	.4108	.3856	.3544
Min	.2804	.3547	.298	.2481	.2481	.3142	.298
Avg	.3696	.3911	.3155	.2950	.3340	.3531	.3262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2058			.1029
2		.1886	.2229	.0886		.1029
3		.2058	.1715			.1029
4		.2229	.1715	.0886		.1029
5		.2401	.1715			.12
6		.3258	.1886	.124		.12
7		.3601	.1886	.1063		.0857
8		.0857	.1029	.0543		.0514
9					.0686	
10	.0514		.0532	.1949	.3429	
11	.0857		.0709		.3601	
12	.0686		.0532	.1949	.3429	
13	.0514		.0886		.2229	
14	.0514		.0886		.2229	
15	.0686		.1063		.2229	
16	.0686		.0709		.2915	
17	.0686		.0724		.2915	
18	.0686		.0724		.0857	
19	.1029				.12	
20	.1372	.12	.1267		.12	
21	.1543	.1372	.1267		.1372	
22			.124		.12	
23	.1543	.2572	.1063		.1372	
24		.1715	.2572	.1063		.12
Max	.1543	.3601	.2572	.1949	.3601	.12
Min	.0514	.0857	.0532	.0543	.0686	.0514
Avg	.0870	.2072	.1291	.1197	.2058	.1010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 203 / TAKARALA (OLD POTA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.8573			1.166
2		.9088	.8573	.9745		1.1488
3		.9259	.8573			1.1488
4		.9774	.9259	1.0631		1.2003
5		1.166	.9945			1.3203
6		1.2003	1.3032	1.5947		2.0062
7		1.1317	1.0802	.7087		1.7661
8		.8402	.8573	.8505		.8916
9					.6687	
10	1.5261		.3898	.3772	.5144	
11	1.5604		.9214		.4801	
12	1.4232		1.4175	.4115	.4973	
13	1.1488		1.0631		.4973	
14	1.0802		1.1517		.4973	
15	1.286		1.2048		.4973	
16	1.5432		1.5061		.5658	
17	1.4918		1.6289		.583	
18			.8145		.6859	
19	1.1488				1.046	
20	1.0631	.9774	1.086		1.0802	
21	1.046	1.046	1.0498		1.0802	
22			1.0099		1.2517	
23	1.0288	.9602	.9214		1.2346	
24		.9774	.9088	.8859		1.2003
Max	1.5604	1.2003	1.6289	1.5947	1.2517	2.0062
Min	1.0288	.8402	.3898	.3772	.4801	.8916
Avg	1.2789	1.0045	1.0367	.8583	.7453	1.3165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 204 / POTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8916	.8573			.6859
2		.8573	.823			.6859
3		.8916	.823			.6859
4		.9259	.823	.8505		.7545
5		.9774	.8573			.8573
6		1.3032	1.1317	.9568		.9945
7		1.2689	1.286	.8859		.9088
8		.7888	.7373	.7964		.7545
9					.583	
10	.5316		.567	1.2934	1.2517	
11	.4801		.567		1.3375	
12	.4973			1.0985	.7202	
13	.5144				.9259	
14	.4973				.9774	
15	.583		.7087		.9945	
16	.5487		.7087		1.0288	
17	.5144		.6154		1.0631	
18	.6173		.724		.6516	
19	.8402				.8059	
20	.7888	.7888	.905		.8916	
21	.8059	.8059	.9412		.8745	
22			.8859		.8402	
23	.9945	.9602	.8505		.7716	
24		.9431	.9391	.815		.7373
Max	.9945	1.3032	1.286	1.2934	1.3375	.9945
Min	.4801	.7888	.567	.7964	.583	.6859
Avg	.6318	.9502	.8290	.9566	.9145	.7850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 201 / KANCHALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4287	.4572	.476
2					.4287	.4572	.476
3					.4287	.4572	.5289
4					.4287	.4572	.5289
5					.5001	.3429	.5289
6					.5144	.4572	.5818
7					.6287	.6859	.6347
8	.5716	.6001	.5024				
9	.8002	.7859	.6875	.7331			
10	.8573	.7933	.7331	.6203			
11	.8779	.714	.7331	.743			
12	.9145	.6875	.7331	.6859			
13	.8859		.7331	.5716			
14	.743	.6082	.6767	.5144			
15	.6859	.6347	.6767	.5716			
16		.6875					
17		.7404					
18		.714					
22				.3572	.4572	.4231	.4512
23				.3572	.4572	.4496	.4512
24					.3572	.4572	.476
Max	.9145	.7933	.7331	.743	.6287	.6859	.6347
Min	.5716	.6001	.5024	.3572	.3572	.3429	.4512
Avg	.7920	.6966	.6845	.5727	.4630	.4645	.5134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 202 / SHIWANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3572	.3858	.3384	.282	.3572	.3429	.3102
2	.3572	.3858	.3384	.282	.3572	.3429	.3102
3		.3858	.3384	.2961	.3572	.3429	.3102
4	.3572	.3858	.3666	.3243	.3572	.3429	.3102
5	.3858	.4287	.3666	.3243	.3572	.3001	.3384
6	.4144	.443	.4512	.3948	.4001		.3666
7			.4512				
8			.5075				
9			.4793				
10	.6001	.7613	.5498	.5357		.3948	
11	.7145	.7895	.578	.6062	.6001	.6203	.6485
12	.6859	.6082	.5498	.6287	.6716	.7049	.6908
13	.6859		.5075	.6144	.6716	.6485	.6062
14	.4287	.423	.4793	.3001	.6001	.5639	.6062
15		.4793		.3572	.6144		.6062
16		.5639		.3572	.5287		.578
17		.5921		.4858	.6287	.5639	.6203
18	.6573	.6485		.5858	.6144		.423
19	.4858	.6203	.5357	.5144	.5573	.5639	.4934
20	.4858		.4793	.5001	.3429	.5639	.3948
21	.4858	.3948	.4652	.5001	.4144	.5357	.4089
22	.4287	.3948	.4512	.5001	.3858	.5075	.3948
23	.4287	.3666	.2256	.5001	.3715	.3102	.3948
24	.3858	.4287	.3666	.282	.4287	.3429	.3102
Max	.7145	.7895	.578	.6287	.6716	.7049	.6908
Min	.3572	.3666	.2256	.282	.3429	.3001	.3102
Avg	.4909	.4993	.4413	.4367	.4808	.4701	.4561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 201 / Andegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2683	.2543		.3018			1.0059
2	.2683			.3086	1.1561		1.2193
3	.2683	.2321		.3086	1.142		1.2193
4	.2713			.3086	1.1728		1.2811
5	.2713	.2652		.3429			1.3123
6	.2543	.3353		.3391	1.2346	1.2342	1.3599
7		.3018		.3018	1.2963	1.3123	1.0031
8	.2241	.2402	.2686	.2075	1.5524	.2587	.168
9	1.4083		.8688		.2374	.2012	
10	1.4586		1.2955	1.1431	.2187	.1619	
11	1.4091		1.3413			.1423	
12	1.2651		1.07	1.1728		.144	
13	1.1069		1.1149			.16	
14	1.2811		1.1888	1.1873		.1739	
15	1.2963		1.2037			.1739	
16	1.2346		1.2037	1.142		.1581	
17	1.2654		1.278	1.1873		.16	
18	.2241		.3361			.3292	
19	.2614		.4108	.2587		.3841	
20	.3326		.4108			.4024	.3584
21	.3326		.4108	.3734	.4294	.4024	.373
22			.3772			.7202	1.0174
23	.2743		.3429	.8436	.9374	.9282	.9374
24	.2683	.3018		.3018	.9374	.9374	.9145
Max	1.4586	.3353	1.3413	1.1873	1.5524	1.3123	1.3599
Min	.2241	.2321	.2686	.2075	.2187	.1423	.168
Avg	.6929	.2758	.8201	.5899	.9377	.4413	.9361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2374		.2683			
2	.2347	.2347		.2743			
3	.2347	.2374		.3086			
4	.2543			.3086			
5	.2713	.2984		.3086			
6	.2713	.3149		.3391			
7	.3018	.2949	.3018	.2683			
9						.2012	
10						.3077	.2543
11						.2846	
12					.2035	.2561	
13						.2881	
14						.2846	
15						.2846	
16						.2846	
17					.2656	.2881	.2968
22	.2012	.2035	.2058				
23	.2374	.2543	.2401				
24	.2347	.2572	.2713	.2347			
Max	.3018	.3149	.3018	.3391	.2656	.3077	.2968
Min	.2012	.2035	.2058	.2347	.2035	.2012	.2543
Avg	.2476	.2592	.2548	.2888	.2346	.2755	.2756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 203 / PARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4862		.4191			.1829
2	.4694	.5087		.4287	.1739		.1829
3	.4694			.4801	.1581		.1677
4	.5087	.5144		.4801	.1423		.1718
5	.5426	.5138		.5144			.1718
6	.5935	.5304		.5087	.1423	.1898	.1739
7		.503		.6036	.1389	.1562	.1698
8	.2263	.1638	.1254	.1357	.1463	.112	.1132
9			.1067		.3658	.3018	.1865
10	.1235		.1219	.1406		.4696	
11			.1219			.5535	
12	.125		.1189	.125		.5921	
13			.1174			.5921	
14	.125		.0892	.1357		.5535	
15			.104			.4902	
16	.1423		.0892	.1235		.4744	
17	.1389		.1189	.125	.4999	.4801	.3749
18	.1867		.1867			.1646	
19	.2218		.2241	.2218		.2195	
20	.2614		.2241			.2195	
21	.2829		.2241	.2587		.2195	
22	.3353		.3772			.192	
23	.4409		.4115	.1875	.2035	.192	.2543
24	.4694	.3353		.4191	.1875	.2035	.1829
Max	.5935	.5304	.4115	.6036	.4999	.5921	.3749
Min	.1235	.1638	.0892	.1235	.1389	.112	.1132
Avg	.3228	.4445	.1726	.3122	.2159	.3356	.1944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174123 / PALASPUR

Feeder No / Name : 201 / PALASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1433	.1402		.1417	.0716	.1433	.1448
7	.0358	.1052		.0354	.1075	.1433	
8	.0358	.0701	.0701	.0354	.0716		.0716
9			.0709	.0354	.0716	.1075	.0716
10	.1075	.1052	.0709	.0709	.0724	.0716	
11	.0972	.1052	.1063	.1086	.0709	.0716	.0716
12	.096	.1052	.0709	.0724	.0709	.1075	.0716
13	.096	.0701	.0709	.1086	.1075	.1075	
14	.0972	.0701	.0709	.1086	.1075	.1086	
15	.0972	.0701	.0709	.0724	.1075	.1075	
16	.1296	.0701	.0709	.1448	.1075	.0716	.0716
17	.1296	.0709	.0709	.1086	.0716		.0716
18	.0648	.0701	.0354	.0724	.0716	.0716	.0716
19	.1296	.1052		.1448	.1433	.1075	
20	.1658	.1402		.1448	.1791		
21	.1658			.181	.1791	.1791	.1791
22	.1658				.1433	.1075	
24		.1052		.1417		.1433	
Max	.1658	.1402	.1063	.181	.1791	.1791	.1791
Min	.0358	.0701	.0354	.0354	.0709	.0716	.0716
Avg	.1098	.0935	.0708	.1016	.1032	.1099	.0917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174123 / PALASPUR

Feeder No / Name : 202 / SIRPALLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.1265	.1235		.125	.3086	.4062	.4428
7	.1265	.0926		.0937	.2778	.4062	
8	.0949	.0926	.0625	.0937	.0926	.0937	.0633
9	.0633	.0937	.0625	.0937	.0617	.0937	.0949
10	.2846	.3125	.3125	.3125	.0617	.0625	
11	.3048	.6173	.3437	.3647	.0937	.0625	.0633
12	.3048	.3125	.3749	.3647	.0937	.0625	.0633
13	.3311	.3437	.3749	.3647	.0937	.0937	
14	.3311	.3125	.3437	.3978	.0937	.0937	
15	.3269	.3437	.3437	.3978	.0937	.0937	
16	.3269	.3437	.3749	.3647	.0625	.0625	.0633
17	.3567	.3437	.3437	.3647	.0937		.0633
18	.0892	.0625	.0625	.0663	.0937	.0937	.0633
19	.1189	.125		.1326	.125	.125	
20	.1505	.1562		.1326	.1562		
21	.1505			.1326	.1562	.125	.1581
22	.1505				.3125	.3437	
23						.3749	
24		.1235		.125		.3125	
Max	.3567	.6173	.3749	.3978	.3125	.4062	.4428
Min	.0633	.0625	.0625	.0663	.0617	.0625	.0633
Avg	.2140	.2375	.2727	.2310	.1336	.1709	.1195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174123 / PALASPUR

Feeder No / Name : 203 / DOLHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.16	.1875		.1387	.3163	.3201	.3841
7	.128	.1562		.1387	.3479	.3521	
8	.128	.1265	.0949	.1387	.1265	.16	.128
9	.096	.1265	.0949	.104	.0949	.128	.096
10	.2241	.2214	.2957	.2774	.0949	.096	
11	.2107	.3163	.2774	.3277	.096	.064	.096
12	.1783	.1898	.2427	.3277	.096	.064	.096
13	.2054	.1898	.2427	.3277	.096	.096	
14	.2054	.1581	.208	.2949	.096	.096	
15	.2027	.1898	.3121	.2949	.096	.0937	
16	.2027	.2214	.2774	.2949	.096	.064	.064
17	.1715	.2214	.2774	.3605	.096		.064
18	.1143	.0949	.0693	.0983	.064	.096	.096
19	.1158	.1265		.1638	.16	.128	
20	.1467	.1265		.1311	.16		
21	.1486			.1638	.16	.16	.16
22	.1486				.2881	.2561	
23						.2881	
24		.125		.1387		.2561	
Max	.2241	.3163	.3121	.3605	.3479	.3521	.3841
Min	.096	.0949	.0693	.0983	.064	.064	.064
Avg	.1639	.1736	.2175	.2189	.1462	.1599	.1316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 201 / 11 KV MANDVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.7122				
9				.5548	.5609
10		.0029			
11			.5895		
12					.5898
14				.5548	
16		.0034			.2058
19					.2374
20			.2715	.2715	
24		.5144			
Max	.7122	.5144	.5895	.5548	.5898
Min	.7122	.0029	.2715	.2715	.2058
Avg	.7122	.1736	.4305	.4604	.3985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 203 / 11 KV UMRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.5426	.5765
10	.0011			
11		.5144		
12				.6478
14			.5765	
16	.0015			.1357
19				.1753
20		.1772	.1772	
24	1.0288			
Max	1.0288	.5144	.5765	.6478
Min	.0011	.1772	.1772	.1357
Avg	.3438	.3458	.4321	.3838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 204 / 11KV MANDAVI RH FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 201 / 11KV WAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2686	.3258		.3696	.2743	.3361
2				.3361			
4	.3361	.3155	.362		.5914	.2743	.3734
5				.439			
6						.4024	
7	.4908	.4557	.5258	.4409	.4066		.5544
8						.3658	
10	.2801	.3544	.2801	.3292	.373		.3506
11						.4115	
13	.2686	.3982	.2172	.0934	.3772		.3506
14						.373	
16	.2195	.362	.3326	.3224	.3429		.394
17						.3429	
19	.0934	.5373	.4805	.4435		.5228	.543
20					.4287		
22	.5914	.4525	.5601	.5914	.3856	.5228	.543
24				.3361			
Max	.5914	.5373	.5601	.5914	.5914	.5228	.5544
Min	.0934	.2686	.2172	.0934	.3429	.2743	.3361
Avg	.32	.3930	.3855	.3702	.4094	.3878	.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 202 / 11KV SINDAKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1088	1.086		.5853	.5853	.5914
2				1.1203			
4	1.1576	1.1576	1.0867		.6219	.5853	.6447
5				1.2012			
6						.823	
7	1.2437	1.1949	1.1393	1.2071	.6219		.78
8						.7202	
10	.5895	.5609		.5548	.6722		.7362
11						.8048	
13	.5487	.5973	.5487	.5487	.7888		.7362
14						.7682	
16	.5487	.5792	.5487	.583	.7362		.7522
17						.8131	
19	1.3306	1.3032	1.2178	1.3817		1.2936	1.267
20					1.3575		
22	1.3443	1.3032	1.2936	1.5154	1.3032	1.2567	1.3032
24				1.2136			
Max	1.3443	1.3032	1.2936	1.5154	1.3575	1.2936	1.3032
Min	.5487	.5609	.5487	.5487	.5853	.5853	.5914
Avg	.9854	.9756	.9887	1.0362	.8359	.8500	.8514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 203 / 11KV DAHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.7362	.6335		.9335	.9145	.9979
2				.5914			
4	.6584	.7522	.6661		.9896	.9145	1.0242
5				.6516			
6						.9492	
7	.7716	.8417	.7362	.6443	.8775		1.0608
8						.631	
10	1.0349	.8764	1.0242	.9511	.5935		.5609
11						.5487	
13	.9877	1.086	1.1888	.7059	.5316		.6089
14						.6783	
16	.8145	.5792	1.1706	.6516	.6001		.7164
17						.6443	
19	1.587	.9955	1.2197	.9425		1.2567	.9955
20					1.0867		
22	.8779	.905	1.0349	1.0903	1.0498	1.2936	.9955
24				.5144			
Max	1.587	1.086	1.2197	1.0903	1.0867	1.2936	1.0608
Min	.5914	.5792	.6335	.5144	.5316	.5487	.5609
Avg	.9154	.8465	.9593	.7492	.8328	.8701	.8700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / 33Kv Bodhdi Substation

Feeder No / Name : 201 / 11 KV BODHADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9568		1.0029	
2		.8505	.9391	.9313	.9745	.985	.9745
3				.8859		1.0029	
4		.9036	1.0208	.964	1.0277	1.0029	1.0208
5				1.2403		1.0745	
6		1.1517	1.3847	1.3289	1.3289	1.2403	1.2403
7			1.4685	1.4506	1.3643	1.2894	1.4864
8		1.2403	1.258	1.2894			1.3432
9		1.2403	1.1999	1.258	1.1694		1.1871
10	.9745	1.0099	1.0745		1.0208	.9922	1.0277
11		.8413	.9568	.1524	.8939		
12	.7712	.8859	.8954		.8682	.9313	.7973
13		.8859	.8505	.9391	.8859	.9036	
14	.7265	.8589			.8859	.9671	.9036
15		.8238	.8589	.9745	.6733	.9922	
16	.9114	.9492		.9922	.9134	1.0387	1.0631
17		1.0387	1.0277		1.0517	1.1163	
18	1.1218	1.2803	1.1641	1.1517	1.258	1.2357	1.2403
19	1.2757	1.4632	1.2715	1.2757	1.5223	1.4685	
20		1.2894				1.3432	1.2536
21	.9922	1.0985	1.1641	1.2934	1.0985	1.1871	1.2226
22	1.0099	1.0208	1.0808		1.1283	1.1163	1.0867
23	.9214	1.0099	1.0387	1.0808	.9745	1.0745	1.1999
24		.8859	.985	1.4994	1.0099	.9745	1.0387
Max	1.2757	1.4632	1.4685	1.4994	1.5223	1.4685	1.4864
Min	.7265	.8238	.8505	.1524	.6733	.9036	.7973
Avg	.9672	1.0364	1.0911	1.0925	1.0552	1.0923	1.1304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / 33Kv Bodhdi Substation

Feeder No / Name : 202 / 11 KV SAWRI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9568			.8859			
2	.9671	.8859	.6024	.8505	.8859	.8238	.8505
3				.8063			
4	.9214	.9745	.6836	.8505	.9568	.8417	.9313
5				.985			
6	.9391	1.0808	.815	1.0631	1.1871	1.0387	.9134
7				1.1283	1.1517	1.134	.7442
8	1.0277	1.0985	.7701	.7701			.6984
9		.7265	.6556	.6733	.6379	.7522	.5493
10	.6201	.5784		.6556	.5316	.6556	.5138
11		.6268			.5194		
12	.631	.3856	.5316	.691	.4961	.6089	.5493
13		.4031	.5731		.5138	.5847	
14	.5434	.3506		.5847	.5373	.5083	.5847
15		.4784	.5784		.5138	.567	
16	.567	.9391		.5847	.591	.6089	.6379
17		.6836	.6733		.567	.691	
18	.7362	.7796	.7164	.7796	.7796	.9134	.6733
19	1.1517	.8238	.9134	.8682	1.1641	.985	
20		.7796			.9036	1.0631	.9214
21	1.1163		1.0029	1.0631	.8954	1.0745	.985
22	1.0985	.7522	.9568		1.0029	1.0208	.8939
23	1.0277	.691	.9492	1.0099	.9492	.9671	.9134
24	.985	.9745	.6805	.5144	.9391	.9671	.9313
Max	1.1517	1.0985	1.0029	1.1283	1.1871	1.134	.985
Min	.5434	.3506	.5316	.5144	.4961	.5083	.5138
Avg	.8859	.7375	.7402	.8202	.7862	.8319	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / 33Kv Bodhdi Substation

Feeder No / Name : 204 / 11 KV BODHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14	2.6755	2.268		2.2148	2.561	2.392	2.4806
15		2.7401	2.5415		1.8427		
16	2.9058	2.8475		2.5692	1.8427	2.7221	2.6932
17		2.955	2.7938		2.8117	2.5789	
18	2.8349	2.6932	2.6578	2.4806	2.7463	2.4629	2.64
19	2.7463	2.3838	2.3137	2.392	2.3565	2.2436	
20		2.3743			1.5249	2.1735	2.2923
21	2.392	2.3388	2.2085	2.1971	1.5947	2.1439	2.0553
24				.5144			
Max	2.9058	2.955	2.7938	2.5692	2.8117	2.7221	2.6932
Min	2.392	2.268	2.2085	.5144	1.5249	2.1439	2.0553
Avg	2.7109	2.5751	2.5031	2.0614	2.1601	2.3881	2.4323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / 33Kv Bodhdi Substation

Feeder No / Name : 205 / 11 KV SAWRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			1.9136	1.5074	1.5061	1.7703	1.8229
6			2.0157	1.7364	1.8604		2.3388
7	2.2085		2.5072	2.516	2.516	2.5431	2.6326
8		1.4373	2.4983	2.758			3.2594
9	2.3312	2.7286	2.8117		3.0121	2.0376	3.1007
10		2.4274		2.8704	3.0266	3.0445	3.0121
11		2.8654	1.8073		2.7109	3.0445	
12	2.0908	2.5072	2.1971	2.6578	2.64	2.7463	2.6578
13		2.3034					
Max	2.3312	2.8654	2.8117	2.8704	3.0266	3.0445	3.2594
Min	2.0908	1.4373	1.8073	1.5074	1.5061	1.7703	1.8229
Avg	2.2102	2.3782	2.2501	2.341	2.4674	2.5311	2.6892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / 33Kv Gokunda

Feeder No / Name : 202 / Town Feeder II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / 33Kv Gokunda

Feeder No / Name : 203 / CHIKHALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / 33Kv Gokunda

Feeder No / Name : 204 / CHIKHLI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center Substation

Feeder No / Name : 201 / 11 KV BELLORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
1	.7202	.6859
4	.6762	.7455
6		.7545
8	.7545	.6173
9	.6859	
12	.5487	.567
14		.5304
16	.4694	.5373
18	.5487	.5138
20	.6173	.6796
22	.7282	
Max	.7545	.7545
Min	.4694	.5138
Avg	.6388	.6257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center Substation

Feeder No / Name : 202 / 11 KV TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
23	.5144
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center Substation

Feeder No / Name : 203 / 11 KV GHOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center Substation

Feeder No / Name : 205 / 11KV SIRMITI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
1	.9709	.9015
4	1.0117	.9259
6		.9602
8	.9259	.8718
9	.8573	
10		.8583
12	.7888	.3932
14		.8259
16	.8817	1.0608
18	1.0631	1.1934
20	1.046	1.1271
22	.9882	
Max	1.0631	1.1934
Min	.7888	.3932
Avg	.9482	.9118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center Substation

Feeder No / Name : 207 / 11KV SIRMITI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
1	.052	.052
4	.052	.052
6		.0514
8	.0343	.0335
9	.0343	
10		.0324
12	.0343	.0324
14		.0324
16	.0339	.0324
18	.0343	.0324
20	.052	.0492
22	.0514	
Max	.052	.052
Min	.0339	.0324
Avg	.0421	.0400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / 33 Kv Umri Bazar

Feeder No / Name : 202 / 11KV Umri

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / 33 Kv Umri Bazar

Feeder No / Name : 203 / 11KV Wazara

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174134 / 33 Kv Tinganwadi Substation

Feeder No / Name : 201 / 11Kv Andbori Gaothan SEPARATED GAOTHAN FEEDERS
Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
23	.5144
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174134 / 33 Kv Tinganwadi Substation

Feeder No / Name : 202 / 11Kv Malakwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 202 / 11KV SHIKHAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631		.8764	.8573	1.0745		1.2003
2	1.0631		.8764	.8916	1.0745		1.2003
3	1.0631		.8764	.8916	1.0745		1.2384
4	1.0985		.964	.9259	1.0566		1.2384
5	1.2048		.964	.9088	1.0387		1.2384
6	1.258		.9465	1.1145	1.0208		1.2955
7	1.3643		.8764	1.1488	1.182		1.3336
8	.9391		.7537	.8573	.4477		1.2765
9	.9335		.7796	.8764	.9671	.9313	1.0517
10	.8573		.9568	.964	1.2934	1.0924	.964
11	1.086		1.0631	.964	1.1744	1.0985	1.0166
12	1.1622		1.0099	1.0166	1.1568	.9745	1.0341
13	1.1431		1.0099	1.0341	1.1568	1.258	1.0517
14	1.1431		1.0277	1.0341	1.0341	1.2226	1.0517
15	1.1241		1.0454	.8939	.8939	.9745	1.1218
16	1.1812		1.1163	.9114	1.0692	1.1871	1.1393
17		1.1744	1.4289	1.2178		1.3336	1.1568
18		1.262	1.448	.6984		1.4098	1.1919
19		1.2795	1.5432	1.0277		1.448	1.2094
20		1.2269	1.5242	1.1999		1.3908	1.2094
21		1.2094	1.5623	1.2178		1.3717	1.1919
22		.8764	.8573	1.1641		1.2955	1.1568
23		.8764	.9088	1.1283		1.2384	1.0867
24	1.0454		.9114	.9088	1.0745		1.2384
Max	1.3643	1.2795	1.5623	1.2178	1.2934	1.448	1.3336
Min	.8573	.8764	.7537	.6984	.4477	.9313	.964
Avg	1.1018	1.1293	1.0553	.9939	1.0464	1.2151	1.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 203 / 11KV HADSANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5316	.5083	.6097	.5493		.6173
2	.5316	.5316	.5083	.5716	.567		.6173
3	.5316	.5316	.5083	.5716	.567		.583
4	.567	.5316	.5083	.5716	.567		.6344
5	.6201	.5434	.6135	.6097	.5847		.703
6	.6556	.5959	.631	.724	.7265		.7545
7	.6201	1.4148	.6661	.7049	.6201		.8916
8	.3721	.631	.6485	.6097	.5316		.5525
9	.6859		.7087	.6135	.4477	.4252	.4908
10	.6001		.6661	.6661	.3403	.3045	.4382
11	.6173		.6135	.6661	.3224	.3403	.4207
12	.6173		.5959	.631	.3403	.3761	.4031
13	.6001		.4908	.5959	.3403	.3582	.3681
14	.6001		.4908	.5258	.3045	.3582	.3856
15	.5658		.4733	.5609	.3582	.3582	.3856
16	.3429		.2865	.5258	.3045	.3403	.3856
17	.4252	.3681	.4382	.3898	.5258	.4382	.4382
18	.5373	.4207	.5144	.443	.631	.4763	.4557
19	.7522	.631	.724	.691		.724	.5083
20	.6447	.7362	.7049	.6556	.6485	.724	.6135
21	.6447	.7362	.6668	.6201	.631	.6859	.6661
22	.6447	.7011	.6287	.6379	.6135	.703	.7362
23	.5847	.6135	.6097	.5847	.6661	.6859	.7362
24	.5316	.5493	.5609	.5906	.5493	.6135	.6516
Max	.7522	1.4148	.724	.724	.7265	.724	.8916
Min	.3429	.3681	.2865	.3898	.3045	.3045	.3681
Avg	.5760	.6292	.5736	.5988	.5103	.4945	.5599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 204 / 11KV ASTHA(SARKHANI) SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4075	.4075	.3681	.3944	.4557		.4287
2	.4075	.4031	.3681	.3944	.4382		.4287
3	.4075	.4031	.3681	.3944	.4382		.4115
4	.4252	.4031	.3856	.4115	.4382		.4115
5	.443	.4031	.4207	.4115	.4557		.4115
6	.4607	.4207	.4557	.4458	.4908		.4458
7	.5316	.4607	.4908	.4973	.5609		.4801
8	.5138	.4557	.4908	.5316	.5609		.5144
9	.4801		.4733	.5784	.4908	.4908	.5258
10	.5144		.4681	.5609	.4908	.5083	.5083
11	.5144		.4508		.4908	.4908	.4908
12	.4801		.3988		.4908	.4908	.4733
13	.4287		.4075		.5083	.4382	.4382
14	.4287		.4075		.4733	.4733	.4382
15	.3772		.3856		.4382	.4908	.4207
16	.3944		.4382	.6135	.4207	.5434	.4207
17	.5138	.4382	.4287	.6135		.4801	.4733
18	.5138	.5083	.5316	.6836		.5144	.5258
19	.6201	.5609	.4801	.631		.5487	.5609
20	.5493	.5609	.463	.6135		.5316	.5784
21	.5493	.5959	.4287	.5434		.5144	.5609
22	.4784	.5609	.4287	.5434		.4801	.5609
23	.4252	.5258	.4287	.5083		.463	.5258
24	.4075	.4031	.4733	.3944	.4733		.4287
Max	.6201	.5959	.5316	.6836	.5609	.5487	.5784
Min	.3772	.4031	.3681	.3944	.4207	.4382	.4115
Avg	.4697	.4694	.4350	.5139	.4774	.4972	.4776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 205 / 11KV MAHUR FEEDER NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.9877		.8745
2		.823	.9694		.8573
3		.7888	.8779		.823
4		.7888	.8779		.7888
5		.7716	.8596		.7888
6		.7888	.823		.823
7		.703	.7499		.7373
8		.6516	.6767		.703
9	.6401	.7011	.6219	.6767	.7011
10	.6219	.7011	.6767	.6584	.6836
11	.6584		.6584	.6401	.6661
12	.6219			.6219	.6836
13	.7499		.7682	.7316	.6836
14	.7499		.7316	.7682	.7011
15	.7316		.8048	.8048	.7362
16	.7316	.5959	.8048	.823	.7712
17	.7202	.9694		.7716	.8238
18	.7373	.8596		.8059	.9114
19	.7545	.9877		.8745	.964
20	.823	.9511		.8916	.964
21	.9088	.9877		.8916	.9465
22	.9602	1.0242		.9431	.9114
23	.9774	1.0242		.9259	.8764
24		.8916	1.0242		.8745
Max	.9774	1.0242	1.0242	.9431	.964
Min	.6219	.5959	.6219	.6219	.6661
Avg	.7591	.8351	.8070	.7886	.8039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 206 / 11KV RENUKADEVI PHC NON SHEDDABLE WATER SUPPLY AND
EXPRESS FE Feeder KV- 11 / UTILITY
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0354	.0351	.0514	.0354		.0514
2	.0362	.0354	.0351	.0343	.0354		.0343
3	.0362	.0354	.0351	.0343	.0354		.0686
4	.0362	.0354	.0351	.0343	.0354		.0686
5	.0362	.0354	.0351	.0343	.0354		.0686
6	.0362	.0354	.0351	.0343	.0354		.0343
7	.0362	.0354	.0351	.0343	.0532		.0343
8	.0362	.0354	.0351	.0343	.0532		.0343
9	.0343		.0358	.0351	.0532	.0532	.0351
10	.0514		.0537	.0351	.0532	.0532	.0351
11	.0343		.0537	.0526	.0532	.0532	.0351
12	.0514		.0358	.0526	.0532	.0532	.0351
13	.0343		.0537	.0526	.0532	.0532	.0351
14	.0514		.0537	.0526	.0532	.0532	.0351
15	.0514		.0537	.0526	.0709	.0532	.0526
16	.0514		.0537	.0526	.0532	.0532	.0526
17	.0354	.0526	.0514	.0354		.0343	.0526
18	.0354	.0526	.0514	.0532		.0343	.0526
19	.0709	.0526	.0686	.0709		.0514	.0526
20	.0532	.0526	.0686	.0532		.0514	.0526
21	.0532	.0526	.0514	.0532		.0514	.0526
22	.0354	.0351	.0343	.0532		.0343	.0526
23	.0354	.0351	.0343	.0532		.0343	.0526
24	.0362	.0354	.0351	.0343	.0354		.0343
Max	.0709	.0526	.0686	.0709	.0709	.0532	.0686
Min	.0343	.0351	.0343	.0343	.0354	.0343	.0343
Avg	.0419	.0407	.0446	.0452	.0469	.0478	.0464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 201 / 11 KV WAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.5847		.6161
2	.5847	.5788		.6161
3	.5847	.5729		.6161
4	.5729	.5847		.6161
5	.5788	.6161		.6161
6	.6535	.6099		.6468
7	.6224	.6224		.6468
8	.7628	.7628		.6468
9	1.0056	1.0056		.8322
10	.9709	1.0288		
11	.9945	.9709		
12	1.0402	.9362		
13	1.0402	.8573		.9015
14	.8322	.8139		
15	.8669	.823		
16	.3961			
17			.5788	
18	.6602			
19	.7207		.6838	
20	.6979		.6838	
21	.6602		.6838	
22	.6161		.6838	
23	.5729		.6468	
24	.6224			.6468
Max	1.0402	1.0288	.6838	.9015
Min	.3961	.5729	.5788	.6161
Avg	.7233	.7579	.6601	.6729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 202 / 11 KV HIWALANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4338		.4338
2	.4294	.4294		.4338
3	.4251	.4294		.4338
4	.4294	.4251		.4338
5	.4207	.4338		.4338
6	.4668	.4715		.4668
7	.4668	.4668		.4338
8	.4854	.3814		.3584
9	.7628	.7628		.4409
10	.6241	.7545		
11	.5895	.7628		
12	.5548	.6588		
13	.5144	.5201		.407
14	.5201	.5087		
15	.5201	.5258		
16	.2452			
17	.3174		.2829	
18	.3961			
19	.5729		.4668	
20	.5415		.5041	
21	.5093		.5041	
22	.5093			
23	.4715		.5041	
24	.4338			.4715
Max	.7628	.7628	.5041	.4715
Min	.2452	.3814	.2829	.3584
Avg	.4850	.5310	.4524	.4316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 203 / 11 KV ANJANKHED FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5548	.5548		.567
2	.5487	.5487		.567
3	.5548	.5548		.567
4	.5487	.5426		.6024
5	.6104	.6588		.6661
6	.6036	.7628		.7888
7	.6104	.9362		.9259
8	.4715	.547		.5415
9	.4294	.5041		.5415
10	.4338	.4668		
11	.3921	.4572		
12	.3584	.4668		
13	.3547	.4338		.4715
14	.3921	.3206		
15	.4207	.3921		
16	.4715			
17	.5093		.5415	
18	.5093			
19	.6161		.6161	
20			.6468	
21			.6838	
23			.6733	
24	.5895			.567
Max	.6161	.9362	.6838	.9259
Min	.3547	.3206	.5415	.4715
Avg	.4990	.5431	.6323	.6187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 204 / JAY YOGESWAR EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0347		
2	.0347			
3	.0347	.0347		
5	.0347	.0347		
7		.0343		
8	.0343			
9	.1357	.104		
10	.1387	.104		
11	.1387	.1017		
12	.1387	.1387		
13	.0693	.0693		.0594
14	.0343	.0347		
15	.1357	.1189		
16	.1734			
17	.1867		.0892	
18	.1372			
19	.0848			
20	.1387		.0297	
21			.0149	
22			.0297	
23			.0297	
24	.0347			.0297
Max	.1867	.1387	.0892	.0594
Min	.0343	.0343	.0149	.0297
Avg	.0991	.0736	.0386	.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 201 / 11 KV Ashta

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3121	.2774	.3429	.3467	.3429	.3772	.3086
2	.2774	.2774	.3429	.3121	.3429	.3772	.3086
3	.2774	.2774	.3086	.3121	.3429	.3772	.3086
4	.2774	.2774	.3086		.3772	.3772	.3086
5	.2774	.2774	.3429	.3467	.4115	.4115	.3429
6	.3121	.2774	.3856	.3467	.4458	.4115	.4115
7	.3467	.2774	.3506	.3467	.4115	.5144	.5144
8	.4854	.4161	.5258	.3121	.2743	.2743	.3086
9	.5548	.5895	.5895	.5895	.3429	.2743	.3429
10	.2774	.5548		.6241	.3086	.3429	.2401
11	.4854	.5316	.6241	.6516	.2743	.3086	.2743
12	.4508	.5258	.5548	.6516	.2743	.2743	.3086
13	.3121	.4557	.5487	.4801	.2401	.2743	.3086
14	.3814	.4801	.4801	.4801	.2401	.2743	.2743
15	.3814	.5144	.4801	.4801	.2743	.2401	.2743
16	.208	.2713	.1696	.5144		.2743	.2743
17	.2774	.3086	.2713	.2743	.2743	.3429	.3086
18	.3467	.3772	.3052	.3429	.3772	.3429	.3429
19	.4161	.4115	.3391	.4115	.4458	.4458	.4458
20	.4161	.4115	.407	.2743	.3772	.4115	.4458
21	.3467	.3772	.373	.3429	.3772		.3772
22	.3467	.3429	.3391	.3429	.3772	.3429	.3429
23	.3121	.3429	.3391	.3429	.3772	.3429	.3429
24	.3121	.2774	.3429	.3429	.3429	.3772	.3086
Max	.5548	.5895	.6241	.6516	.4458	.5144	.5144
Min	.208	.2713	.1696	.2743	.2401	.2401	.2401
Avg	.3496	.3804	.3944	.4117	.3414	.3474	.3343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 202 / 11 KV Takali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.57	.5365	.5365	.3353	.3018	.3018
2	.5365	.5365	.5365	.5365	.3353	.3018	.3018
3	.503	.5365	.5365	.503	.3353	.3018	.3018
4		.5365	.503	.503	.3353	.3018	.3018
5	.57	.6036	.57	.57	.4024	.3353	.3391
6	.6706	.7377	.8383	.8048	.4359	.4607	.407
7	.8048	.8048	.8048	.8383	.4024	.4607	.407
8	.3353	.4359	.4024	.4024	.3688	.3688	.3391
9	.3353	.3353	.3353	.2683	.7712	.6706	.6443
10	.2683		.2683	.2347	.7712	.7377	.6783
11	.2683	.2652	.2347	.2347	.7712	.6706	.6783
12	.2347	.2321	.2683	.2347	.6706	.6036	.6443
13	.2347	.2321	.2347	.2012	.6036	.6036	.6104
14	.2347	.2321	.2683	.2012	.6036	.6036	.5426
15	.2012	.2321	.2347	.2347	.57	.5365	.5426
16	.2012	.1989	.2347	.2012	.57	.57	.5765
17	.2347	.2683	.2012	.2012	.2012	.2347	.2035
18	.2347	.2347	.3018	.2683	.3018	.3018	.2374
19	.3688	.4359	.3688	.4359	.4694	.4359	.407
20	.3688	.4024	.3688	.4024	.3688	.4024	.4409
21	.3353	.3688	.3688	.3688	.3688	.3353	.373
22	.6706	.7042	.6706	.3353	.3353	.3353	.373
23	.6371	.6371	.6371	.3353	.3353	.3353	.373
24	.6036	.57	.57	.57	.3353	.3018	.3018
Max	.8048	.8048	.8383	.8383	.7712	.7377	.6783
Min	.2012	.1989	.2012	.2012	.2012	.2347	.2035
Avg	.4097	.4396	.4289	.3926	.4583	.4380	.4303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 203 / 11 KV Gokul

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.567	.5731	.6089	.3189	.3189	.3544
2	.5316	.567	.5731	.5731	.3189	.3189	.3189
3	.5316	.567	.5731	.5731	.3544	.3189	.3189
4	.5316	.567	.5731	.6089	.4252	.3544	.3189
5	.567	.567	.5731	.6089	.4607	.4252	.3898
6	.6024	.6024	.6516	.7164	.4961	.4607	.4607
7	.6024	.6024	.6878	.6447	.4607	.4961	.567
8	.4252	.4961	.3982	.5731	.567	.567	.6379
9	.4961	.4607	.4706	.5014	.4961	.4607	.4607
10	.4252	.4252	.362	.5014	.4252	.4607	.4252
11	.3544	.362	.3582	.4298	.3544	.3544	.3544
12	.3898	.362	.3224	.3582	.3544	.3189	.3189
13	.2835	.2896	.3582	.3582	.3898	.3544	.3544
14	.3189	.3224	.394	.3544	.3898	.3898	.3898
15	.3544	.3582	.4607	.3898	.3544	.3544	.3898
16	.3898	.3898	.3544	.3544	.3544	.3898	.4252
17	.4607	.4252	.4607	.4252	.4607	.4607	.4607
18	.5316	.567	.4252	.5316	.5316	.5316	.567
19	.7796	.8238	.7796	.7796	.8505	.7442	.7442
20	.7442	.788	.7442	.7087	.7087	.7442	.7442
21	.6733	.6805	.6733	.6379	.6733	.6379	.7442
22	.6379	.6447	.6379	.3544	.3898	.4252	.4252
23	.6024	.6089	.6379	.3544	.3544	.3898	.3898
24	.567	.6024	.5731	.6089	.3189	.3189	.3189
Max	.7796	.8238	.7796	.7796	.8505	.7442	.7442
Min	.2835	.2896	.3224	.3544	.3189	.3189	.3189
Avg	.5153	.5269	.5256	.5231	.4503	.4415	.4533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 201 / UMRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
1	.3658
2	.362
3	.3582
4	.362
24	.3658
Max	.3658
Min	.3582
Avg	.3628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 201 / SHINDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2572	.3429	.2572	.2572	.2572
2		.2572	.2572	.3429	.2572	.2572	.2572
3		.2572	.2572	.3429	.2572	.2572	.2572
4		.2572	.2572	.3429	.2572	.2572	.2572
5		.2572	.2572	.3429	.2572	.2572	.2572
6		.2572	.2572	.3429	.2572	.2572	.2572
7		.2572	.2572	.3429	.2572	.2572	.2572
8		.2572		.1715	.2572	.2572	.2572
9	.2572	.1715	.1715	.1715	.2572	.2572	.2572
10	.2572	.1715	.2715	.1715	.3429	.3429	.4525
11	.1715	.1715	.1829	.1715	.2572	.3429	
12	.1715	.1715	.1829	.1715	.2572	.3429	
13	.1715	.1715	.181	.1715	.2572	.3429	
14	.1715	.1715	.181	.1715	.2572	.3429	
15	.1715	.1715	.1829	.1715	.2572	.4287	
16	.1715	.1715	.1829	.1715	.2572	.5144	
17	.1715	.1715	.2743	.2572	.2572	.5144	
18	.2572	.1715	.2715	.2572	.2572	.2572	
19	.2572	.2572	.2686	.2572	.2572	.2572	
20	.2572	.2572	.2686	.2572	.2572	.2572	
21	.2572	.2572	.2715	.2572	.2572	.2572	
22	.2572	.2572	.2715	.2572	.2572		
23	.2572	.2572	.3658	.2572	.2572	.2572	
24		.2572	.2572	.362		.2572	.2572
Max	.2572	.2572	.3658	.362	.3429	.5144	.4525
Min	.1715	.1715	.1715	.1715	.2572	.2572	.2572
Avg	.2172	.2215	.2429	.2544	.2609	.3057	.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 202 / HUNDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4239	.3429	1.5432	1.6956	1.5432
2		.4287	.4239	.3429	1.5432	1.6956	1.5432
3		.4287	.4239	.3429	1.7147	1.6956	1.5432
4		.4287	.4239	.3429	1.7147	1.3565	1.7147
5		.4287	.3391	.3429	1.8861	1.4413	2.0576
6		.4287	.4239	.4287	2.0576	1.6956	2.0576
7		.4287	.4239	.4287	2.0576	1.7804	2.0576
8		.3429	.3391	.3429	.5144	.4287	.3429
9	.2572	.2572	.2543	.2572	.3429	.2572	.3429
10	1.3717	1.6289	1.7804	1.7147	.2572	.1696	
11	1.7147	1.8652	1.8442	1.8861	.1696	.1696	
12	1.7147	1.6956	1.8652	1.8861	.1715	.1715	
13	1.7147	1.6956	1.8652	1.8861	.1715	.1715	
14	1.7147	1.6956	1.8442	1.8861	.1715	.1715	
15	1.7147	1.6956	1.8652	2.2291	.2572	.1715	
16	1.7147	1.6956	1.8652	2.2291	.2572	.1715	
17	1.7147	1.7804	1.8652	2.3148	.2543	.1715	
18	.4287	.3429	.2543	.3429	.3391	.2572	
19	.4287	.5144	.3429	.3429	.4239	.2572	
20	.4287	.5144	.4287	.4287	.4287	.3429	
21	.4287	.5087	.4287	.4287	.4287	.4287	
22	.4287	.4458	.4287	1.3717	1.2717	1.2003	
23	.4287	.4287	.4287	1.5432	1.6956	1.3717	
24		.4287	.4287	.4239	1.5432	1.6956	1.5432
Max	1.7147	1.8652	1.8652	2.3148	2.0576	1.7804	2.0576
Min	.2572	.2572	.2543	.2572	.1696	.1696	.3429
Avg	1.0803	.8557	.8755	1.0036	.8840	.7903	1.4746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 203 / SHIVANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1006	.3429	.0857	.0838	.0857
2		.1715	.1006	.3429	.0857	.0838	.0857
3		.1715	.1006	.3429	.0857	.0838	.0857
4		.1715	.1341	.3429	.0857	.0838	.0857
5		.1715	.1677	.3429	.0857	.0843	.0857
6		.1715	.1677	.3429	.0857	.0838	.0857
7			.1677	.3429	.0857	.0838	.0857
8		.0857	.0838	.0857	.0857	.0838	.0857
9	.0857	.0857	.0838	.0857	.0857	.0838	.0857
10	.0857	.0857	.0724	.0857	.3429	.4191	
11	.0857	.0838	.0714	.0857	.4191	.503	
12	.0857	.0838	.0714	.0857	.4191	.6001	
13	.0857	.0848	.0724	.0857	.4191	.6859	
14	.0857	.0838	.0724	.0857	.503	.6859	
15	.0857	.0838	.0724	.0857	.503	.8573	
16	.0857	.0848	.0724		.503	.8573	
17	.0857	.0848	.0714	.0857	.503	.8573	
18	.0857	.0838	.0714	.0857	.0838	.0857	
19	.0857	.0838	.0857	.0857	.0848	.0857	
20	.0857	.0848	.0857	.0857	.0838	.0857	
21	.0857	.0838	.0857	.0857	.0838	.0857	
22	.1715	.0838	.2572	.0857	.0848		.0857
23	.1715	.0838	.3429	.0857	.0838		.0857
24		.1715	.0838	.3429	.0857	.0838	.0857
Max	.1715	.1715	.3429	.3429	.503	.8573	.0857
Min	.0857	.0838	.0714	.0857	.0838	.0838	.0857
Avg	.0971	.1109	.1123	.1752	.2073	.3021	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 204 / 11 kv Dairy feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.0857	.0857	.0857
2			.1715	.0857	.0857	.0857
3				.0857	.0857	.0857
4		.1715		.0857	.0857	.0857
5		.1715		.0857	.0857	.1715
6				.0857	.0857	.1715
7				.0857	.1715	.3429
8				.0857	.1715	.3429
9		.1715		.0857	.1715	.2572
10		.181			.1715	
11	.1715	.1829			.1715	
12	.1715	.1829			.1715	
13	.1715	.1829	.0857	.1715	.2572	
14	.1715	.1829	.0857	.1715		
15	.1715	.1829	.0857	.1715	.3429	
16	.2572	.1829	.0857	.1715	.3429	
17	.2572	.181	.0857		.3429	
18		.181	.0857		.2572	
19		.1715	.0857		.1715	
20		.1715	.0857		.0857	
21		.1715	.0857	.0857	.0857	
22		.1715	.0857	.0857	.0857	
23		.1715	.0857	.0857	.0857	
24			.1715	.0857	.0857	.0857
Max	.2572	.1829	.1715	.1715	.3429	.3429
Min	.1715	.1715	.0857	.0857	.0857	.0857
Avg	.1960	.1772	.1041	.1059	.1603	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 205 / PALASGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0576	1.8861	1.8861	.6859	1.0288	.8573
2		2.0576	1.8861	2.0576	.6859	1.0288	.8573
3		2.0576	1.8861	2.0576	.6859	1.0288	.8573
4		2.0576	1.8861	2.2291	.6859	1.0288	.8573
5		2.2291	2.0576	2.2291	.8573	1.0288	1.0288
6		2.4006	2.2291	2.4006	.8573	1.0288	1.2003
7		2.572	2.572	2.4863	1.1145	1.0288	1.1145
8		1.0288	1.0288	1.0288	1.0288	.8573	1.0288
9		.8573	.8573	.8573	.9431	.7716	.9431
10		.6859	.6859	.7716	2.7435	2.8292	
11	.8573	.6001	.6001	.6859	2.7978	3.4294	
12	.6859	.6001	.6859	.6859	3.0521	3.2579	
13	.6859	.6001	.6001	.6001	2.7978	3.0864	
14	.6859	.6001	.6001	.6001	2.7978	2.915	
15	.6859	.6001	.6001	.6001	2.7978	2.7435	
16	.6859	.6001	.6001	.6001	3.0521	2.4006	
17	.6859	.6859	.6859	.7716	3.0521	2.2291	
18	1.2003	1.0288	.7716	.8573	1.0288	.8573	
19	1.2003	1.2003	1.2003	.9431	1.2003	1.0288	
20	1.2003	1.2003	1.2003	1.2003	1.2003	1.2003	
21	1.2003	1.2003	1.2003	1.2003	1.2003	1.286	
22	1.8861	1.8004	1.7147	1.0288	1.1145	1.0288	
23	2.0576	1.8004	1.8861	.8573	1.0288	.8573	
24		2.0576	1.8861	1.8861	.6859	1.0288	.8573
Max	2.0576	2.572	2.572	2.4863	3.0521	3.4294	1.2003
Min	.6859	.6001	.6001	.6001	.6859	.7716	.8573
Avg	1.0552	1.3574	1.3003	1.2717	1.5873	1.6254	.9602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 206 / SHELGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.1696	.1715	.9431	1.0059	.8573
2		.2572	.1696	.1715	.9431	1.0059	.8573
3		.2572	.1696	.1715	.9431	1.0059	.8573
4		.2572	.1696	.1715	.9431	.8383	1.0288
5		.2572	.1696	.1715	.9431	1.0059	1.0288
6		.3429	.2543	.2572	1.0288	1.0898	1.2003
7		.3429	.2543	.2572	1.0288	1.0898	1.2003
8		.2572	.1696	.2572	.2572	.2543	.1715
9	.1715	.1715	.1696	.1715	.1715	.2543	.1715
10	.8573	.9431	1.1145	.8573	.1715	.1696	
11	.8573	1.1022	1.1145	.8573	.1696	.1698	
12	.8573	1.0174	1.1145	.9431	.1696	.1715	
13	.9431	1.0174	1.0288	.9431	.1696	.1715	
14	.9431	1.0059	1.0288	.9431	.1696	.1715	
15	.9431	1.0174	.9431	.9431	.1696	.1715	
16	.9431	1.0288	.9431	.9431	.1696	.1715	
17	.9431	1.0174	.9431	.9431	.1715	.1715	
18	.2572	.2035	.1715	.1715	.2543	.1715	
19	.2572	.2572	.2572	.1715	.2543	.1715	
20	.2572	.2572	.2572	.2572	.2543	.2572	
21	.2572	.2572	.2572	.2572	.2543	.2572	
22	.2572	.2515	.1715	.8573	.9326	.6859	.6859
23	.2572	.2543	.1715	.8573	1.0059	.8573	.8573
24		.2572	.2543	.1715	.9431	1.0059	.8573
Max	.9431	1.1022	1.1145	.9431	1.0288	1.0898	1.2003
Min	.1715	.1715	.1696	.1715	.1696	.1696	.1715
Avg	.6001	.5120	.4778	.4966	.5192	.5135	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 207 / 11 KV MANOOR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6001	.5144	.9431	1.0288	.9431
2		.5144	.6001	.5144	.9431	1.0288	.9431
3		.5144	.6001	.5144	.9431		.9431
4		.5144	.6001	.6001		1.0288	1.0288
5		.5144	.6001	.6859	1.0288	1.0288	1.0288
6		.6001	.6859	.6859	.12	1.1145	1.0288
7		.6001	.6859	.6001	1.2003	1.286	1.0288
8		.5144	.5144	.5144	.5144	.5144	.4287
9	.4287	.4287	.4287	.3429	.4287	.4287	.3429
10	1.1145	1.2003	1.2003	1.0288	.2572	.3429	
11		1.3717	1.286	1.1145	.2572	.2572	
12	1.2003	1.3717	1.286	1.1145	.2572	.2572	
13	1.2003	1.3717	1.2003	1.2003	.2572	.2572	
14	1.286	1.3717	1.1145	1.2003	.2572	.2572	
15	1.286	1.3717	1.1145	1.2003	.2572	.2572	
16	1.286	1.3717	1.2003	1.286	.2572	.3429	
17	1.286	1.286	1.2003	1.286	.3086	.3429	
18	.5144	.3429	.3429	.3429	.4287	.4287	
19	.5144	.6859	.6001	.4287	.6001	.5144	
20	.5144	.6859	.6859	.6001	.6001	.6859	
21	.5144	.6859	.6859	.6001	.6001	.6859	
22	.5144	.6001	.6859	.8573	1.0288	.8573	
23	.5144	.6001	.6859	.9431	1.0288	.9431	
24		.5144	.6001	.6001	.9431		.9431
Max	1.286	1.3717	1.286	1.286	1.2003	1.286	1.0288
Min	.4287	.3429	.3429	.3429	.12	.2572	.3429
Avg	.8696	.8145	.8002	.7823	.5852	.6313	.8659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 201 / 11 kv waghawada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)
1		.2058
2		.2058
3		.2058
4		.2058
5		.2058
6		.2229
7		.2229
8		.2229
9		.1715
10		.1715
11		.1715
12		.1886
13		.1886
16	.1715	.1715
17	.1715	
19	.2743	
20	.2743	
21	.2572	
22	.2401	
23	.2401	.2229
24		.2058
Max	.2743	.2229
Min	.1715	.1715
Avg	.2327	.1994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 202 / 11kv Hassa feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)
1		.1372
2		.1372
3		.1372
4		.1543
5		.1543
6		.1543
7		.1372
8		.12
9		.1029
10		.1715
11		.2572
12		.2915
13		.3086
14		.3086
15		.3086
16	.3086	.2915
17	.3086	
18	.1715	
19	.1715	
20	.1715	
21	.1715	
22	.1715	
23	.1372	
24		.1372
Max	.3086	.3086
Min	.1372	.1029
Avg	.2015	.1947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 203 / 11 kv Hatni Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)
1		.1029
2		.1029
3		.1029
4		.12
5		.1372
7		.1372
8		.1372
9		.1372
10		.1715
11		.2058
12		.2229
13		.2229
14		.2229
15		.2229
16		.2229
17	.1543	
18	.1543	
19	.1543	
20	.1543	
21	.1372	
22	.12	
23	.1029	
24		.1029
Max	.1543	.2229
Min	.1029	.1029
Avg	.1396	.1608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 201 / 11 KV LOHGAON FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-APR-18
HR	Load (MW)
8	1.1812
24	1.4901
Max	1.4901
Min	1.1812
Avg	1.3357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 202 / 11 KV RAHER FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-APR-18
HR	Load (MW)
8	.3584
24	.3544
Max	.3584
Min	.3544
Avg	.3564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 203 / 11 KV HARNAL FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	02-APR-18
HR	Load (MW)
8	.8131
24	.5493
Max	.8131
Min	.5493
Avg	.6812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 201 / 11 KV DAULATAPUR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7545	.4115	.3772	.3944	.3258	.3429	.3429
16	.1715	.1715	.2058	.1886	1.0288	.9945	.9602
24	.9259	.8573	.8573	.9088	.2572	.2572	.2572
Max	.9259	.8573	.8573	.9088	1.0288	.9945	.9602
Min	.1715	.1715	.2058	.1886	.2572	.2572	.2572
Avg	.6173	.4801	.4801	.4973	.5373	.5315	.5201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 202 / 11 KV SAGROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.3086	.4115	.3429	.3772	.4115		.4801
24	.3772	.3429	.3772	.3772	.3772	.3772	.3772
Max	.3772	.4115	.3772	.3772	.4115	.3772	.4801
Min	.3086	.3429	.3429	.3772	.3772	.3772	.3772
Avg	.3429	.3772	.3601	.3772	.3944	.3772	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 203 / 11 KV BOLEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4458	.5144	.4458	.4973	1.1831	1.2517	1.2174
16	1.5089	1.4403	1.3546	1.4746	.2743	.2572	.2743
24	.3772	.3772	.4115	.3601	1.2346	1.166	1.1831
Max	1.5089	1.4403	1.3546	1.4746	1.2346	1.2517	1.2174
Min	.3772	.3772	.4115	.3601	.2743	.2572	.2743
Avg	.7773	.7773	.7373	.7773	.8973	.8916	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 201 / 11 kv BAMNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.5426	.4458	.1772	.3772	.4075
2	.4115	.5895	.5426	.4458	.1595	.3429	.4075
3	.4115		.5765	.4801	.1595	.3429	.4075
4	.4458	.5895	.5935	.3429	.1595	.3772	.4075
5	.4458		.6104	.5144	.1772	.3772	.4075
6	.4458	.6068	.6104	.5144	.1949	.3429	.3898
7	.4801	.4681	.5935	.5487	.1772	.3429	.443
8	.2058	.3772	.39	.4115	.1791	.2804	.4784
9	.2058	.3944	.39	.4115	.1075	.3506	.4801
10	.1715	.3772	.3944	.3391	.1029	.4031	.5487
11	.1595	.4115	.4115	.373		.4382	
12		.4115	.4115	.3856	.3086	.4784	
13	.1543	.3772	.4115	.3681	.3772	.4607	.1715
14	.3429	.4115	.4115	.3721	.3772	.4784	.2743
15	.3429	.3429	.3772	.3544	.3772	.4784	.3086
16	.3814	.3429	.3772	.3366	.4115	.4784	
17		.443	.4115		.2743	.3189	
18	.5201	.5316	.4115	.443	.4458	.3898	.3086
19		.5847	.4458		.4458	.443	.4458
20	.5784	.5765	.4458	.5316	.3772	.5138	.3429
21		.567	.4458		.4115	.3544	.4287
22	.5083	.4961	.4115	.1417	.3772	.443	.4115
23		.5138	.3772		.4115	.443	.3601
24	.3772	.5609	.5087	.4115	.1772	.4115	.4075
Max	.5784	.6068	.6104	.5487	.4458	.5138	.5487
Min	.1543	.3429	.3772	.1417	.1029	.2804	.1715
Avg	.3666	.4749	.4626	.4086	.2768	.4028	.3919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 202 / 11 KV HINGNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.407	.4115	.4024	.583	.4458
2	.5487	.4359	.407	.4115	.4694	.6173	.4458
3	.5487		.407	.4115	.4694	.6516	.4458
4	.5487	.4409	.407	.4458	.4694	.6516	.463
5	.583		.4239	.4458	.503	.6859	.5144
6	.6173	.4578	.4409	.4458	.503	.6859	.583
7	.2229	.4287	.4578	.4115	.5365	.7202	.6859
8	.1715	.4458	.39	.3772	.5365	.3052	.7545
9	.5144	.583	.5256	.5144	.3222	.3391	.4973
10	.7545	.7373	.6344	.6783	.3601	.407	.4801
11	.7628	.7545	.6859	.6783	.3429	.4409	.4801
12	.763	.7545	.7202	.703		.4748	.4458
13	.78	.7545	.7202	.6859		.4239	.4801
14	.7712	.4287	.7202	.6859	.2058	.4191	.4115
15	.7377	.5144	.6859	.6516	.2743	.4239	.3429
16	.7127	.6859	.6859	.5967		.4409	.2058
17		.3391				.4801	
18	.3315	.4239	.3772	.4641	.3772	.5487	
19		.6274	.4115		.6173	.6001	.4458
20	.4807	.5087	.4458	.503	.583	.5658	.4801
21		.4748	.4115		.6173	.5658	.4458
22	.4694	.4578	.4115	.3018	.6173	.5144	.4115
23		.4239	.3772		.583	.3944	.4458
24	.5144	.4359	.4239	.3772	.4024	.5487	.4287
Max	.78	.7545	.7202	.703	.6173	.7202	.7545
Min	.1715	.3391	.3772	.3018	.2058	.3052	.2058
Avg	.5674	.5292	.5034	.5100	.4596	.5203	.4700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 203 / 11 KV BADOOR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487		.5197	.5144	.5487	.3429	.8059
2	.583	.7042	.5079	.5144	.5487	.3429	.8059
3	.583		.5079	.5487	.5487	.3772	.8059
4	.6173	.7042	.5079	.5487	.5487	.3772	.8059
5	.6173		.5079	.5144	.583	.3429	.8059
6	.6173	.7209	.5668	.5144	.5487	.3772	.7888
7	.6859	.7461	.6154	.5487	.5487	.3429	.7373
8	.4801	.4458	.4588	.3772	.5144		.6859
9	.4115	.4801	.4752	.3429	.5658		.5658
10	.4115	.4287	.4973	.3353	.6173		.6173
11		.4287	.5144	.3353	.7545		.6516
12			.5487	.4359	.7888	.6706	.583
13	.3315		.5487	.4527	.7545	.7461	.6173
14	.3521	.463	.583	.4527	.7202	.7545	.583
15	.3521	.4801	.5487	.4527	.3772	.7122	.4801
16	.3856	.4801	.5144	.4359	.3086	.6783	.463
17		1.5261			.3086	.5087	
18	.4527		.4115	.503	.2743	.6783	.583
19			.4458			.4239	.8573
20	.7122	.6443	.4458	.7461	.3772	.8817	.7202
21		.6783	.4115		.4115	.8648	.6859
22	.5765	.4578	.4458	.5426	.4115	.8478	.7202
23		.503	.4115		.3772	.8309	.6859
24	.5487	.6783	.5197	.4115	.5596	.3772	.7969
Max	.7122	1.5261	.6154	.7461	.7888	.8817	.8573
Min	.3315	.4287	.4115	.3353	.2743	.3429	.463
Avg	.5148	.6217	.5006	.4764	.5216	.5739	.6892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 201 / 11 KV TOWN 1 DEGLOOR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.8501		
4		.695	.823	.8779	.9335		
6	.8871						
8		1.0242	.9694	1.0608	1.0349	1.0242	
10	.9511						
12	1.0608	.9511	1.0425	1.134	1.134	.8316	.7682
16	1.2071	1.1523	1.0608	1.0608	1.0608	.7682	1.262
18			1.0608	1.0059			
20	1.3717	1.4083					1.4815
24	.9145	.9328				.8413	.7499
Max	1.3717	1.4083	1.0608	1.134	1.134	1.0242	1.4815
Min	.8871	.695	.823	.8779	.8501	.7682	.7499
Avg	1.0654	1.0273	.9913	1.0279	1.0027	.8663	1.0654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 202 / 11 KV TOWN 2 DEGLOOR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.7316	.7023	.6283		
6	.7023						
8		1.0242	1.0059	.7392	.5914	.7499	
10	.5853						.7023
11				.7316			
12	.6584	.7682	.7316	.5487	.5487	.5914	.7316
13		.5853					
16	.695	.7316	.5121	.6401	.6468	.5853	.6584
18			.5853	.6584			
20	.8048	.9511					.9145
24	.6219					.5487	.7316
Max	.8048	1.0242	1.0059	.7392	.6468	.7499	.9145
Min	.5853	.5853	.5121	.5487	.5487	.5487	.6584
Avg	.6780	.8121	.7133	.6701	.6038	.6188	.7477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 203 / 11 KV TOWN 3 DEGLOOR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.6219	.695	.7023	.6468		
6	.7762						
8		.7682	.8048	.7316	.7095	.6036	
10	.6584						.5175
12	.6584	.7316	.6584	.6401	.6219	.5914	.5853
16		.6219	.5853	.6401	.6468	.6468	.7133
18			.5853	.6584			
20	1.0059	.8048					.8779
24	.6584	.6584				.5853	.6219
Max	1.0059	.8048	.8048	.7316	.7095	.6468	.8779
Min	.6584	.6219	.5853	.6401	.6219	.5853	.5175
Avg	.7515	.7011	.6658	.6745	.6563	.6068	.6632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL DEGLOOR SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0366	.0366	.0366	.037		
6	.0566						
8		.0914	.0732	.0554		.0739	
10	.112						.0373
12	.1463	.2195	.1463	.2561	.2195	.1494	.0549
16	.5853	.2378	.0549	.1829	.2241		.2378
17						.1294	
18			.0732	.1829			
20	.1097	.1097					.128
24	.0549	.0554				.037	.0549
Max	.5853	.2378	.1463	.2561	.2241	.1494	.2378
Min	.0549	.0366	.0366	.0366	.037	.037	.0373
Avg	.1775	.1251	.0768	.1428	.1602	.0974	.1026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 205 / 11 KV TOWN 4 DEGLOOR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.5853	.567	.6584	.6283		
6	.7392						
8		.7499	.6584	.695	.6335	.7762	
10	.6401						.5914
12	.5487	.5853	.5121	.6401	.5853	.6468	.5487
16	.5853	.6219	.5853	.6036	.6219	.6401	.6584
18			.6036	.6219			
20	.7133	.7316					.7865
24	.6219	.6584				.5487	.6401
Max	.7392	.7499	.6584	.695	.6335	.7762	.7865
Min	.5487	.5853	.5121	.6036	.5853	.5487	.5487
Avg	.6414	.6554	.5853	.6438	.6173	.6530	.6450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 206 / 11 KV BHAKTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.4572	.4435		
6	.2263					
8			.4572	.1848	.1848	
10	.5175					.3696
12			.1829	.1848	.4024	
16		.1463	.1829	.1867	.5121	.128
18		.2195	.2195			
20						.2378
24	.1494				.4755	.5487
Max	.5175	.2195	.4572	.4435	.5121	.5487
Min	.1494	.1463	.1829	.1848	.1848	.128
Avg	.2977	.1829	.2999	.2500	.3937	.3210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 207 / GOVT. HOSPITAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.0183	.0185		
6	.0189					
8			.0183	.0185	.0189	
10	.0189					.0189
12			.0183	.0189	.0189	
16		.0183	.0183	.0189	.0189	.0183
18		.0183	.0187			
20						.0183
24	.0189				.0189	.0183
Max	.0189	.0183	.0187	.0189	.0189	.0189
Min	.0189	.0183	.0183	.0185	.0189	.0183
Avg	.0189	.0183	.0184	.0187	.0189	.0185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 201 / 11 KV MUKRAMABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3326	.2614	.3361	.3734	.3734	.3734
2	.2987	.2987	.2987	.3395	.3361	.3361	.3361
3	.2987	.3361	.3361	.3772	.3361	.3734	.3361
4		.3361	.3734	.415	.3361	.3361	.4024
5	.3734	.3734	.4108	.4527	.3696	.3761	.4755
6	.4108	.4755	.4481	.4854	.4755	.4755	.5121
7		.5487	.4854	.4854	.5487	.5121	.5068
8	.5068	.5601		.5601	.4805	.4755	.5792
9	.5068	.362	.4066	.4805	.4435		.5601
10	.5068	.5014	.439	.5175	.4024	.5544	.5228
11	.4656	.4656	.3982	.4435	.4024	.4801	.4854
12	.4298	.5014	.3658	.4024	.4024	.4805	.4854
13	.439	.4706	.362	.3982	.3982	.4706	.4854
14	.4024	.4344	.3982	.439	.3982	.4344	.4481
15	.4024	.362	.3658	.3982	.3982	.4024	.4854
16	.3658		.3658	.4344	.3982	.439	.5228
17	.362	.3734	.3982	.4024	.3658		.4481
18	.4344	.4108	.439	.4344	.3292	.3696	.4481
19	.439	.4481	.4755	.439	.5121	.5175	.4854
20	.4435	.4854	.4805	.5121	.5121	.5175	.5228
21	.4024	.4481		.439	.5175	.4805	.4854
22	.4066		.4435	.439	.4435	.4435	.4481
23	.3734	.3734	.4066	.4066	.4108	.4481	.4481
24	.3734	.3734	.3361	.3734	.3696	.4108	.4108
Max	.5068	.5601	.4854	.5601	.5487	.5544	.5792
Min	.2987	.2987	.2614	.3361	.3292	.3361	.3361
Avg	.4081	.4214	.3952	.4338	.4150	.4412	.4672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 202 / 11 KV GOJEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7545	.8589	.7468	.823	.823	1.0829
2	.7095	.6859	.8589	.7922	.7545	.7888	.8962
3	.7095	.6516	.8962	.7545	.7888	.7888	.8962
4	.7468	.7202	.9335	.9431	.7888	.823	1.0242
5	.9335	.7888	.9709	1.0185	.8573	.8916	1.2437
6	.9709	.9945	1.0082	1.0829	1.0288	1.0288	1.2803
7		1.1317	1.1203	1.2323	1.166	1.2346	1.3937
8	1.1946			1.307	1.2346	1.2346	1.5203
9	1.2308		.7888	1.1827	1.2567	.8916	1.4563
10	1.1946	.9671	.8573	1.1088	1.1706		1.3817
11	1.1462	.8238	.9259	1.0719			1.3443
12	1.0745	.8238	.8916	1.0242			1.307
13	1.0974	.8688	.8916	1.0498	.9412	.9602	1.2323
14	1.0608	.8326	.8573	1.0242		.9602	1.1949
15	.9877	.8326	.823	.9774	.5792	.9945	1.1576
16	.8048	.8215	.823	1.0136	1.0136	1.0974	1.1203
17	.9602	.8962	1.0608	.9259	1.0288		1.2323
18	1.0631	.9335		.9945	.823	.6653	1.1949
19	1.0288	.9709		.9945	.9945	1.1458	1.1576
20	.9602	1.0082	1.0974	1.0288	1.0288	1.1827	1.1203
21	.9259	1.0829	1.0349	.9602	.9602	1.1088	1.0456
22	.8573	1.1203	.961	.8573	.9259	1.0719	.9709
23	.823	.9335	.924	.823	.8573	1.0082	.9335
24	1.0082	.7888	.8962	.7468	.7888	.8573	.9709
Max	1.2308	1.1317	1.1203	1.307	1.2567	1.2346	1.5203
Min	.7095	.6516	.7888	.7468	.5792	.6653	.8962
Avg	.9667	.8833	.9276	.9859	.9434	.9779	1.1732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 203 / 11 KV RAVANKOLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6173	.7468	.6722	.6516	.6516	.7468
2	.6722	.583	.7842	.7167	.6173	.6173	.7095
3	.6348	.583	.8215	.7545	.6173	.6173	.7095
4	.5975	.583	.8589	.9054	.6516	.583	.7842
5	.6348	.583	.8962	.9808	.6859	.6687	.8413
6	.6722	.8573	.9335	1.0562	.8916	.8573	.8779
7		.9945	1.1203	1.1576	.9602	.8916	1.086
8	.7964	.9945		.9335	.8916	.8916	1.1584
9	.6878	1.0136	.6859	1.1458	1.0719	.9259	1.1203
10	.7164	.9671	.7545	1.0719	.8779		1.0082
11	.6805	.9313	.6859	1.1088			.9335
12	.6805	.8238	.583	.8779		.7202	.8589
13	.6447	.724	.6173	.7602	.6516	.7202	.7468
14	.5853	.6878	.6516	.6584	.724	.6516	.7095
15	.5487		.6173	.724	.6878	.6859	.6348
16	.3658		.6516	.724	.6516	.7682	.7468
17	.6173		1.0136	.8916	.7545		.8962
18	.7202	.5601	.9511	.8916	.823	.6283	.8589
19	.583		.9511	.8573	.7888	.8501	.8962
20	.5487	.5975	.9145	.823	.7888	.8871	.8589
21	.7202	.5601	.8501	.7545	.7202	.7762	.7842
22	.7202		.7392	.7202	.6859	.7392	.7468
23	.6859	.5975	.7392	.6859	.6859	.7468	.7468
24	.7468	.6516	.7468	.7095	.6859	.6859	.7842
Max	.7964	1.0136	1.1203	1.1576	1.0719	.9259	1.1584
Min	.3658	.5601	.583	.6584	.6173	.583	.6348
Avg	.6508	.7321	.7963	.8576	.7530	.7411	.8435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 201 / 11 KV TAMLOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2507	.6805	.6249
16		.2427	.2254	.2149
24	.5959	.3121	.3224	.3605
Max	.5959	.3121	.6805	.6249
Min	.5959	.2427	.2254	.2149
Avg	.5959	.2685	.4094	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 202 / 11KV NARANGAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2534	.2686	.2865
16		.3224	.2865	.2686
24	.1402	.208	.2149	.1865
Max	.1402	.3224	.2865	.2865
Min	.1402	.208	.2149	.1865
Avg	.1402	.2613	.2567	.2472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 203 / 11 KV SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.1791	.1734	.208
16		1.3611	1.1694	.9362
24	.2126	.168	.1612	.1612
Max	.2126	1.3611	1.1694	.9362
Min	.2126	.168	.1612	.1612
Avg	.2126	.5694	.5013	.4351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 204 / 11KV MANDAGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0914	.0732	.0895
16		.0554	.0514	.0537
24	.0716	.0549	.0554	.0486
Max	.0716	.0914	.0732	.0895
Min	.0716	.0549	.0514	.0486
Avg	.0716	.0672	.06	.0639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 205 / 11KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3155	.4588	.5544
16		.2033	.2195	.176
24	.5175	.3142	.3189	.4298
Max	.5175	.3155	.4588	.5544
Min	.5175	.2033	.2195	.176
Avg	.5175	.2777	.3324	.3867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174037 / 33 KV S/S HANEGAON

Feeder No / Name : 201 / 11 KV HANEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.543			
3					.3906
7					.442
8	.4656	.7522	.5175	.3658	
11				.442	
12					.4321
14				.4268	
15	.4755		.4481		.3963
17				.3858	
18			.4877	.4167	.4877
21					.5639
22			.4161	.4572	
24	.6219				.4268
Max	.6219	.7522	.5175	.4572	.5639
Min	.4656	.543	.4161	.3658	.3906
Avg	.521	.6476	.4674	.4157	.4485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174037 / 33 KV S/S HANEGAON

Feeder No / Name : 202 / 11 KV WAZAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2378			
3					.2774
7					.2427
8		.2507	.2865	.2804	
11				.5895	
12					.5375
14				.5895	
15			.4458		.4161
17				.3506	
18			.1734	.3142	.2254
21					.2774
22			.2629	.2774	
24	.5853				.298
Max	.5853	.2507	.4458	.5895	.5375
Min	.5853	.2378	.1734	.2774	.2254
Avg	.5853	.2443	.2922	.4003	.3249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174037 / 33 KV S/S HANEGAON

Feeder No / Name : 203 / 11 KV LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)
3		.3506
7		.3403
12		.7087
14	.5373	
15		.6379
17	.5847	
18		.2481
21		.4607
22	.4298	
24		.4207
Max	.5847	.7087
Min	.4298	.2481
Avg	.5173	.4524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 201 / 11 KV KARADKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.829				
2			1.7375				
3			1.3565				
4			1.2887				
5			1.701				
6			2.0851				
7			2.1098				
8	1.1641	.9979	2.1216	2.1293	1.9281	2.1559	2.0287
9		1.8343					.4338
10		2.2138					.415
11		2.0083					.3772
12		2.0178					.3584
13		1.9839					.3206
14		1.8842	.7282				.3018
15		1.8351					.2829
16	2.2805	1.6956	.6535	.3174	.2987	.3921	.3395
17		1.6956					.3584
18		.3018					.3772
19		.7922					.9808
20		.9054					1.0374
21		1.1869					1.1317
22		1.6476					
23		1.7187					1.0631
24	.8779	.8775	1.8839	1.7002	1.0923	1.0867	1.5777
Max	2.2805	2.2138	2.1216	2.1293	1.9281	2.1559	2.0287
Min	.8779	.3018	.6535	.3174	.2987	.3921	.2829
Avg	1.4408	1.5057	1.5904	1.3823	1.1064	1.2116	.7115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 202 / 11 KV MARKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0808				
2			1.0974				
3			1.0208				
4			.9745				
5			1.0136				
6			1.1643				
7			1.0056				
8	.3658	.3734	.8764	.9602	1.1393	1.2094	1.2378
9		.9896					.3772
10		1.0852					
11		1.1022					
12		1.1191					.3206
13		1.0682					.2641
14		1.0343	.2801				.2263
15		.9831					.1886
16	1.0402	1.0004	.2402	.2241	.2241	.2241	.1886
17		.2054					.2452
18		.2195					.2452
19		.2715					.3206
20		.3174					.3584
21		.3292					.3961
22		.3547					.3961
23		.9326					.9431
24	.3292	.7186	1.0608	.7796	.7888	.7712	.8063
Max	1.0402	1.1191	1.1643	.9602	1.1393	1.2094	1.2378
Min	.3292	.2054	.2402	.2241	.2241	.2241	.1886
Avg	.5784	.7120	.8922	.6546	.7174	.7349	.4343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 203 / 11 KV KINI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9568				
2			.9231				
3			.8779				
4			.7888				
5			.8596				
6			.8859				
7			.9568				
8	.2801	.2614	.905	1.166	.8063	.9465	.8718
9		.8309					.2452
10		.9496					.1886
11		.9665					.1886
12		.9835					.1886
13		1.086					.2263
14		1.0208	.168				.2641
15		.852					.2075
16	.8939	.7461	.168	.168	.1494	.168	.1509
17		.1267					.132
18							.1886
19		.1829					.2263
20		.2452					.2829
21		.2543					.3206
22		.2926					.3018
23		.815					.8676
24	.2614	.2241	.8478	.7011	.6935	.7108	
Max	.8939	1.086	.9568	1.166	.8063	.9465	.8718
Min	.2614	.1267	.168	.168	.1494	.168	.132
Avg	.4785	.6149	.7580	.6784	.5497	.6084	.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 204 / 11 KV DEGLOOR WATER SUPPLY NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0701				
5			.0886				
6			.1097				
7			.0181				
8	.1097	.0739	.1595	.0739	.1214	.1227	.0914
9		.0678					.0943
10							.132
11		.0701					.1509
12		.1595					.132
13		.1357					.132
14		.1017	.128				.0943
15		.1097					.0754
16	.1109	.0924	.0732	.112	.112	.0739	.0754
17		.1132					.0566
18		.1448					.1132
19		.1448					.1132
20		.1267					.132
21		.1448					.1509
22		.1698					.1509
23		.1417					.1132
24	.1097	.1307	.1227	.0747	.1227	.0701	.1294
Max	.1109	.1698	.1595	.112	.1227	.1227	.1509
Min	.1097	.0678	.0181	.0739	.112	.0701	.0566
Avg	.1101	.1205	.0962	.0869	.1187	.0889	.1139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 205 / 11 KV CHAKUR EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINUOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0709				
2			.0709				
3			.0526				
4			.0886				
5			.0886				
6			.0886				
7			.0876				
8	.0895	.0739	.0914	.056	.052	.0701	.0934
9		.0848					.0566
10		.0867					.0943
11		.0886					.0943
12		.0754					.0754
13		.0701					.0754
14		.0732	.1109				.132
15		.1017					.132
16	.0934	.128	.1294	.0934	.112	.0934	.0943
17		.1132					.1132
18		.1307					.0754
19		.0848					.0754
20		.0934					.0754
21		.0914					.0754
22		.0886					.0566
23		.0886					.0532
24	.0732	.0747	.0709	.0747	.0701	.0701	.0747
Max	.0934	.1307	.1294	.0934	.112	.0934	.132
Min	.0732	.0701	.0526	.056	.052	.0701	.0532
Avg	.0854	.0910	.0864	.0747	.0780	.0779	.0851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 201 / 11 KV KUNDALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
8		.5906
16	.5144	
23		.5906
Max	.5144	.5906
Min	.5144	.5906
Avg	.5144	.5906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 203 / 11 KV GUJARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
8		.2286
16	.2477	
23		.2667
Max	.2477	.2667
Min	.2477	.2286
Avg	.2477	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 205 / 11 KV GUJARI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)
8		.6668
16	1.1622	
23		1.0479
Max	1.1622	1.0479
Min	1.1622	.6668
Avg	1.1622	.8574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 201 / 11 KV RAO DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3772		.3658	.415		.5658	.5144
4	.4527		.4024	.4527		.6001	.5487
5					.6118		
6	.4904		.4755	.4904		.6859	.6036
7		.4079			.6798		
8	.4527	.3399	.4024	.4527	.6628	.7202	.5365
9		.5438					
10	.6154	.7478	.6859	.583	.2719	.2926	
12	.6798		.6478	.5608	.2743	.2195	.3772
14	.5098	.6554	.6478		.3086	.2926	
16		.6882	.7287	.6798	.2743	.3292	.3772
18	.3059	.4024	.415	.3739	.3086	.3292	.415
19				.4758			
20	.4419	.439	.4527	.4928	.5144	.5121	.4904
21	.4758						
22		.4024	.4904		.5144	.5121	.4904
23				.4079			
24	.3772	.3739	.4024	.4527	.5098	.5144	.5144
Max	.6798	.7478	.7287	.6798	.6798	.7202	.6036
Min	.3059	.3399	.3658	.3739	.2719	.2195	.3772
Avg	.4708	.5001	.5097	.4865	.4482	.4645	.4868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 202 / 11 KV YETALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.4575		1.5242	1.5384		1.0288	1.182
4	1.5384		1.5242	1.6194		1.0288	1.182
5					.972		
6	1.6194		1.6766	1.6194		1.2003	1.2894
7		2.1725			.9025		
8	1.3203	.8322	1.2071	1.3203	.8678	1.0288	1.2071
9		.7993					
10	1.226	.8669	1.0745	1.1317	1.7936	1.6766	
12	.8966	.9114	.9431		1.8861	1.6766	1.9433
14	.9656	.9114	.8488		1.8861	1.6766	1.9433
16		.9114	.8488	.973	1.8861	1.5242	1.8623
18	1.1108	1.0517	1.1317		.9431	.9602	1.3203
19				1.2497			
20	1.1132		1.3203	1.1976	1.2003	1.2894	1.3203
21	1.1294						
22		1.2193	1.2955		1.2003	1.262	1.3203
23				1.0078			
24	1.3765	1.4595	1.2193	1.3765	.9372	1.0288	1.182
Max	1.6194	2.1725	1.6766	1.6194	1.8861	1.6766	1.9433
Min	.8966	.7993	.8488	.973	.8678	.9602	1.182
Avg	1.2503	1.1136	1.2178	1.3034	1.3159	1.2818	1.4320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 203 / 11 KV ELEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.9054		.8059	.7922		1.1145	1.0898
4	.9431		.8596	.8488			1.1469
5					1.0537		
6	.9431		1.0029	.9431		1.286	1.3108
7		.8941			1.2134	1.166	
8	1.0374	.8302	.9313	.8488	1.2293	1.286	
9		1.0697					
10	1.2955	1.2772	1.2498	1.2955	.6546	.7164	
12	1.3411	1.2193	1.3765		.6859	.6447	.5658
14	1.3092	1.1584	1.2955		.6859	.6584	.4904
16		1.2193	1.2955	1.1815	.6859	.6584	.5281
18	.7025	1.0242	.7545	.5269	.7202	.7522	.7167
19				.8302			
20	.8302	1.0517	.9431	.8302	.8573	.9671	.9054
21	.8302						
22		.9313	.8488		.8573	.9313	.9431
23				.9899			
24	.8488	.7025	.8059	.7545	1.0378	1.1145	1.0898
Max	1.3411	1.2772	1.3765	1.2955	1.2293	1.286	1.3108
Min	.7025	.7025	.7545	.5269	.6546	.6447	.4904
Avg	.9988	1.0344	1.0141	.8947	.8801	.9413	.8787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 204 / Karkheli Gaothan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5658		.5121	.4527		.2743	.1791
4	.6036		.5487	.6036		.3086	.1791
5					.3591		
6	.679		.6584	.6036		.3086	.2149
7		.4725			.3213		
8	.6413	.4725	.6219	.5281	.3591	.3086	.2149
9		.4914					
10	.2267	.378	.2804	.2591	.4914	.5121	
12	.2457	.2804	.2429	.2646	.4287	.439	.5281
14	.2646	.2804	.2591		.4801	.439	.4904
16		.2804	.2267	.2457	.5144	.4755	.4527
18	.5292	.5121	.5281	.378	.5144	.5121	.5281
19				.4158			
20	.378	.6584	.6036	.4914	.6001	.6584	.6036
21	.4158						
22		.6219	.6036		.5144		.6413
23				.2646			
24	.4904	.3591	.5121	.4527	.2646	.2401	.2149
Max	.679	.6584	.6584	.6036	.6001	.6584	.6413
Min	.2267	.2804	.2267	.2457	.2646	.2401	.1791
Avg	.4582	.4370	.4665	.4133	.4407	.4069	.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 201 / 11 KV MUKHED TOWN I
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-APR-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 202 / 11 KV CHANDOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3944
Max	.3944
Min	.3944
Avg	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 203 / 11 KV PFC

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 205 / 11 KV BELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 206 / 11 MUKHED TOWN II
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-APR-18
HR	Load (MW)
24	.3944
Max	.3944
Min	.3944
Avg	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 207 / Govt.Hospital Express

Feeder Feeder KV- 11 /

OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 201 / 11 KV RAJURA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 203 / 11 KV JAHOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 201 / 11 KV BARHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.9156
Max	.9156
Min	.9156
Avg	.9156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 202 / 11 KV DORNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.7152
Max	.7152
Min	.7152
Avg	.7152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 203 / 11 KV PAISMAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 204 / Public Water Work Sugaon NON SHEDDABLE EXPRESS HV FEEDERS
Camp Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 201 / 11 KV YEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2572		.2572	.2915			
4	.2401		.2743	.3086			
6	.3772		.3601	.3601			
8	.4287		.4115	.463			.7011
10		.5487	.5144				.3761
12	.5316	.5144	.463				.2896
14	.4287	.4287	.4458				.2865
16	.583	.4973	.5144	.4973			.3045
18	.2743	.2572	.2401				.3189
20	.4115	.4115	.3772				.4382
22		.3429	.3601				.3721
24	.3258		.3086	.3429	.2743	.4801	.3506
Max	.583	.5487	.5144	.4973	.2743	.4801	.7011
Min	.2401	.2572	.2401	.2915	.2743	.4801	.2865
Avg	.3858	.4287	.3772	.3772	.2743	.4801	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 202 / 11 KV HONWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.8322		.7802	.7628			
4	.7975		.7975	.7975			
6	.9189		.9189	.9189			
8	.9882		.9709				1.3146
9				1.0923			
10	.8573	.9088	.8573				.8059
12	.6516	.823	.7545				.724
14	.583	.6001	.7202				.6268
16	.8402	.703	.7716	.463			.6805
18	.6935	.6415	.6241				.7442
20	.9709	1.1096	1.0749				1.1919
22		.9189	.8669				.9391
24	.9015		.8669	.8322	.5487	.9602	.964
Max	.9882	1.1096	1.0749	1.0923	.5487	.9602	1.3146
Min	.583	.6001	.6241	.463	.5487	.9602	.6268
Avg	.8213	.8150	.8337	.8111	.5487	.9602	.8879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 201 / 11 KV JAMB

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-APR-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 202 / 11 KV SAWARGAON

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-APR-18
HR	Load (MW)
23	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 203 / 11 KV KAMJALGA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-APR-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 201 / 11kv BETMOGRA SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
23	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 202 / 11KV KHATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 203 / 11KV EKLARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 201 / 11 KV BOMNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 202 / 11 KV SHIRUR D

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3086
Max	.3086
Min	.3086
Avg	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 203 / 11 KV JUNNA

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-APR-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174121 / 33kV JAHOR

Feeder No / Name : 201 / 11KV PALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
23	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174121 / 33kV JAHOR

Feeder No / Name : 202 / 11KV CHONDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174121 / 33kV JAHOR

Feeder No / Name : 203 / 11 KV JAHOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2229
Max	.2229
Min	.2229
Avg	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 201 / 11 KV NARSI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583		.5601	.6859	.6348	.7095	.6348
2	.5487		.5601	.6859	.6348	.7095	.6348
3	.5487		.6348	.6859	.6722	.7095	.6348
4	.583		.6348	.6859	.6722	.7095	.6722
5	.6516		.6722	.7202	.7095	.7468	.6722
6	.7202		.7468	.7545	.7468	.7842	.7468
7	.823		.7545	.7888	.7545	.8589	.7468
8	.7545	.8282	.8215	.7888		.8589	.7842
9	.6516	.8266	.7468	.8573		.7842	.6722
10	.6173	.6735	.7468	.823		.8215	.8215
11	.6783	.6348	.7202	.7468	.7202	.7468	.7888
12		.5601	.823	.6722	.6859	.7468	
13	.6023	.5601	.823	.6348	.5144	.7468	.823
14	.5618	.5975	.7888	.5975		.6722	.823
15	.5556	.5975	.6859	.5975	.583	.6348	.7888
16		.5975	.583	.6348	.6516	.6722	.7202
17		.6348	.6516	.5601	.6516	.6722	.7202
18	.6011	.6722	.6859	.5975	.6516	.7468	.6859
19	.8106	.7468	.7545	.7468	.7888	.8215	.823
20	.6605	.6722	.7888	.6722	.823	.7468	.823
21		.6722	.823	.7468	.7888	.6722	.823
22		.6348	.823	.6722	.7888	.6722	.7888
23		.5975	.7545	.6722	.7842	.6348	.7545
24	.6173		.5601	.6859	.6348	.7468	.6348
Max	.823	.8282	.823	.8573	.823	.8589	.823
Min	.5487	.5601	.5601	.5601	.5144	.6348	.6348
Avg	.6427	.6566	.7143	.6964	.6946	.7344	.7399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 202 / 11 KV NAIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403		1.5684	1.5089	1.6057	1.6975	1.6804
2	1.4403		1.6057	1.4746	1.6057	1.6804	1.7177
3	1.4746		1.6057	1.4746	1.643	1.6804	1.7177
4	1.5089		1.643	1.4746	1.7177	1.7177	1.7924
5	1.5775		1.7924	1.5775	1.7551	1.7551	1.8671
6	1.7147		1.8671	1.7147	1.7924	1.7924	1.9044
7	1.989		2.0911	1.9547	1.9418	2.1658	2.0538
8	1.8519	1.869	1.7924	1.989	1.8671	2.0165	2.0165
9	1.749	1.9556	1.6804	1.749	1.7177	1.9418	1.8671
10	1.5775	1.8034	1.7924	1.8176	1.643	1.7924	2.0165
11	1.723	1.6804	1.7147	1.6804	3.2952	1.6804	1.8519
12	1.6548	1.643	1.5432	1.4784	3.2952	1.6804	
13	1.6172	1.5684	1.5432	1.6057	3.2952	1.7924	1.7147
14	1.5357	1.5684	1.5432	1.5684	3.4385	1.7551	1.7147
15	1.4967	1.6057	1.5775	1.6057	3.4385	1.6804	1.7147
16	1.4262	1.8671	1.5775	1.6057	3.4385	1.7177	1.7147
17		1.6804	1.5775	1.643	3.5102	1.7177	1.7147
18	1.6481	1.7924	1.6118	1.7177	3.6534	1.7924	1.7833
19	1.9832	2.2032	2.0576	2.0165	3.9399	2.0911	2.0576
20	1.7942	2.0911	2.0233	1.9044	4.0115	2.0165	2.0576
21		1.6804	1.6804	1.6804	3.8684	1.8671	1.989
22		1.643	1.5775	1.643	3.7251	1.7924	1.8519
23		1.6057	1.6118	1.6057	1.8298	1.7551	1.6804
24	1.5089		1.5684	1.5089	1.6057	1.7177	1.6804
Max	1.989	2.2032	2.0911	2.0165	4.0115	2.1658	2.0576
Min	1.4262	1.5684	1.5432	1.4746	1.6057	1.6804	1.6804
Avg	1.6356	1.7661	1.6936	1.6666	2.6514	1.8040	1.8330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 203 / 11 KV CANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029		.1132	.0686	.1886	.1494	.1886
2	.1029		.1132	.0686	.1886	.1867	.2241
3	.1029		.1132	.0686	.2263	.2241	.2641
4	.1029		.1132	.0686	.2641	.2241	.2641
5	.1372		.1132	.0686	.3018	.3361	.3395
6	.1372		.1509	.1029	.3395	.4108	.3772
7	.1715		.1509	.1029	.3772	.4481	.3772
8	.1715	.0974	.1886	.1372	.3696	.4481	.3018
9	.2401	.1604	.2263	.1715			
10	.3429	.2295	.2263	.2401			
11	.3288	.415	.3086	.3395			
12	.2597	.415	.3086	.3772			
13	.2567	.3772	.3086	.3772			
14	.2295	.3772	.3086	.3395			
15	.2246	.3772	.2743	.3361	.1509	.1494	.1372
16	.299	.415	.2401	.3772	.1886	.1494	.1372
17					.1886	.1494	.1372
18					.1715	.1494	.1029
19					.1715	.1886	.1715
20					.1715	.1886	.1715
21					.1715	.1867	.1372
22					.1867	.1509	.1715
23		.1132	.0686	.1509	.1509	.1886	.2058
24	.1029		.1132	.0686	.1886	.1494	.1886
Max	.3429	.415	.3086	.3772	.3772	.4481	.3772
Min	.1029	.0974	.0686	.0686	.1509	.1494	.1029
Avg	.1949	.2977	.1911	.1924	.222	.2265	.2165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 201 / 11 KV RUI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1088	1.1203	1.1203			2.2786
2	1.1317	1.1088	1.2012	1.1203			2.4539
3	1.1317		1.2012	1.1203			2.4539
4	1.1203		1.307	1.1203			2.5415
5	1.4937		1.4937	1.3203			2.6292
6	1.6804		1.8671	1.6975			2.6292
7	1.6461		1.6461	1.5089			.5068
8	1.5223		1.6461	1.4937			.4668
9	1.9938		2.0348	2.3034			1.1203
10	2.4539		2.8349	2.8045			1.1203
11	2.5415		2.6006	2.9797	1.0745		
12	2.6292	2.6863	2.0576	.1791	1.1765	1.1203	
13	2.7168	2.6863	2.2786	2.3663	1.0974	2.2405	.9335
14	2.6292		2.6578	2.6863	.9955	1.1203	.9335
15	2.2786		2.572	2.4177	.9145	1.1203	.9335
16	2.4539		2.572	2.4539	.9145	1.1203	.9431
17	.9335		.9335	.9145	1.0059		
18	1.1203		1.1203	1.0974	1.267	2.2405	
19	1.6804	2.1195	1.4937	1.4784	1.6461	1.7718	
20	1.6632	2.2377	1.5089	1.4937	1.448	1.6804	1.6118
21	1.4937	2.2119	1.4784	1.4003	.6401	1.4937	1.4632
22	1.4003		1.307	2.2405	.7392	1.4784	1.3717
23	1.307	1.2803	1.1203	2.1491		1.307	.5373
24	1.1203	1.1088	1.1203	1.1203			2.2786
Max	2.7168	2.6863	2.8349	2.9797	1.6461	2.2405	2.6292
Min	.9335	1.1088	.9335	.1791	.6401	1.1203	.4668
Avg	1.7193	1.8387	1.7156	1.6911	1.0766	1.5176	1.5372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 202 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8839	.1829	.1829	.1829	.7468	.823	.6535
2	.1829	.1829	.181	.1829		.8145	.6602
3	.1772	.1829	.1791	.1829		.9145	.6602
4	.2686	.181	.2686	.181		.823	.6602
5	.2686	.2686	.3582	.3658		.9145	.6602
6	.4477	.362	.4477	.4572		.9145	.7545
7	.5316	.4525	.5316	.5487		.9145	.9431
8	.8764	.9431	.7888	.5373		.9145	.9431
9	1.0059	.7545	.6401	.8402		.724	.3582
10	.823	.7545	.5487	.5601		.3582	.3582
11	.8145	.7545	.5658	.6535		.3582	.4477
12	.6535	.5658	.5658	.5601		.3582	
13	.6535	.6535	.6602	.5487		.3582	.3582
14	.6535	.5487	.5601	.5487		.3467	.4572
15	.6535	.5544	.5601	.6468		.3467	.4572
16	.1867	.6535	.4715	.6401		.3467	.4477
17	.7468	.5601	.5658	.6401		.6535	.5487
18	.7468	.5601	.7545			.7468	.6401
19	.9431	.8402	.8402	.9145		.8402	.9145
20	.9431	.7545	.9431	.9145		.9335	.9335
21	.8402	.8488	.9335	.9335		.9335	
22	.181	.1791	.8402	.8402		.8402	.8402
23	.181	.181	.1829	.7545	.7468	.6535	.7468
24	.1829	.1829	.1829	.1829	.7545		.6535
Max	1.8839	.9431	.9431	.9335	.7545	.9335	.9431
Min	.1772	.1791	.1791	.181	.7468	.3467	.3582
Avg	.6186	.5043	.5314	.5573	.7494	.6883	.6408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 204 / 11 KV KAHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.6135	.6268	.5258	1.3575	.7011
2	.6068	.6068	.6201	.5258	1.4632	.7011
3	.6068	.6068	.7087	.5258	1.3717	.7011
4	.6335	.6068	.7164	.5258	1.3575	.7011
5	.8059	.6935	.7973	.7087	1.3575	.8764
6	.9745	.8764	.8764	.8859	1.3575	.964
7	1.1517	.9745	.8954	1.0745	1.2803	1.0517
8	1.1517	1.2403	1.1641	.8859	1.2803	1.0517
9	1.086	1.1641	1.0059	1.0517	.8669	.7973
10	.924	1.0631	1.0059	.8859	.8669	.964
11	.8059	.8059	.7087	.8954	.8573	.8859
12	.7087	.823	.7087	.823	.7011	
13	.6201	.823	.6201	.7316	.7011	.7011
14	.6201	.7316	.7087	.7316	.7011	.7011
15	.6201	.7468	.6201	.6535	.7802	.7888
16	.7087	.7545	.6135		.8573	.9745
17	.8859	.9431	.7164	1.0269	.8145	.823
18	.905	.9335	.8954	1.1203	1.086	
19	1.0745	1.1317	1.0745	1.226	1.2403	1.1203
20	1.1641	1.1317	1.1203	1.226	1.1641	1.1203
21	.985	1.1317	1.1203	1.1317	1.0269	1.1317
22	.6201	.6335	1.0269	1.0374	.905	.9431
23	.7011	.6268	.5258	.9431	.905	.9431
24	.6135	.6135	.6268	.5258		.7888
Max	1.1641	1.2403	1.1641	1.226	1.4632	1.1317
Min	.6068	.6068	.5258	.5258	.7011	.7011
Avg	.8161	.8448	.8126	.8551	1.0565	.8832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 205 / TATA Chemicals
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.013	.0135	.0057	.0042	.0044	.0183	.0034
2	.013	.0135	.0055	.0053	.005	.0181	.0034
3	.0124	.0135	.0053	.0051	.005	.0179	.0034
4	.0122	.0133	.0059	.0051	.0057	.0183	.0034
5	.0114	.0072	.0059	.0051	.0061	.0183	.0032
6	.0183	.0072	.0038	.0042	.0095	.0183	.0027
7	.0183	.0044	.0048	.0044	.0027	.0183	.0025
8	.0175	.0044	.0051	.0051	.0189	.0183	.0025
9	.0175	.0046	.0034	.0137	.0189	.0181	.0023
10	.0103	.004		.0036		.0181	.0025
11	.0025	.005	.0034	.0034	.0185	.0029	.0057
12	.0021	.0042	.0034	.0038	.0181	.0032	
13	.0027	.0044	.004	.0036	.0183	.0034	.004
14	.0027	.0046	.0023	.0032	.0183	.0034	.0044
15	.003	.005	.004	.0067	.0177	.0034	.005
16	.0034	.005	.0042	.0034	.0181	.0034	.0044
17	.0042	.0046	.0044	.0038	.0183	.0059	.0175
18	.0187	.0046	.0137	.0065	.0181	.0055	.0177
19	.0177	.005	.0175		.0181	.0055	.0183
20	.0177	.0046	.0057		.0181	.0051	.0183
21	.0175	.0053	.0067		.0181	.0061	.0175
22	.0143	.0065	.0044		.0181	.0061	.0189
23	.0135	.0067	.0053		.0181	.0032	.0189
24	.0137	.0149	.0057			.0183	.0032
Max	.0187	.0149	.0175	.0137	.0189	.0183	.0189
Min	.0021	.004	.0023	.0032	.0027	.0029	.0023
Avg	.0116	.0069	.0057	.0050	.0142	.0107	.0080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 201 / 11 KV GADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.7202	.7716	.7545	.7202	.7202	1.2346
2	.3429	.7202	.7716	.7545	.7202	.7202	1.2346
3	.3429	.7202	.7716	.7545	.7202	.7545	1.2346
4	.3429	.7888	.8573	.7545	.7545	.7716	1.286
5	.3772	.8573	.9945	.8916	.823	.9431	1.3717
6	.4801	.9602	1.2003	1.0631	.9259	1.1145	1.6118
7	.5658	1.2517	1.3375	1.3717	1.166	1.2689	1.5775
8	.5487	.5144	.6344	.4973	1.0974	1.1317	1.6632
9	.8916	.4801	.4458	.4973	.4287	.3086	
10	.9602	.2915	.3601	.4287	.3429	.2572	
11		.4115	.2915	.3429	.3258	.2229	
12			.2743	.3429	.3086	.2572	
13	.7202	.2401	.2401	.3086	.3086	.3258	
14	.9259	.2401	.2229	.2058	.3086	.3601	.3944
15	.7888	.2572	.3258	.3086	.2915		.7202
16	.7888	.2743	.3258	.3086	.3086		.4801
17	.2058	.2401	.3258	.3772	.3086	.7373	.4801
18		.3601	.3429	.3772	.3601	.6859	.7888
19	.5144		.4801	.4458	.463	.7716	1.0288
20	.4458	.4115	.4458	.3772	.4458	1.286	1.046
21	.4115	.3772	.3772	.4458	.3772	1.2174	.9945
22	.6687	.7545	.7545	.3944	.3601	1.1831	.9259
23	.6859	.7716	.7545	.7888	.7716	1.2003	1.0974
24	.3429	.6859	.7716	.7545	.7888	.7716	1.2003
Max	.9602	1.2517	1.3375	1.3717	1.166	1.286	1.6632
Min	.2058	.2401	.2229	.2058	.2915	.2229	.3944
Avg	.5569	.5604	.5866	.5644	.5594	.7732	1.0721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 202 / 11 KV KOLAMBI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.1029	.12	.1543	.1372	.1372	.1543
2	.6001	.1029	.1029	.1543	.1372	.1372	.1543
3	.5144	.1029	.1029	.1543	.1372	.1372	.1543
4	.5144	.1029	.12	.1543	.1372	.1372	.1543
5	.6516	.1372	.1372	.1543	.1715	.1715	.1543
6	.8573	.1886	.1886	.1715	.1886	.1886	.1886
7	1.3032	.2058	.2058	.2058	.2229	.1886	.2058
8	.1715	.2058	.2058	.1886	.2058	.1886	.2058
9	.1372	.8059	.6344	.6687	.7545	.823	.9602
10	.12	.9602	.8402	.7202	.8916	.9945	.9602
11	.12	.8916	.7373	.8573	.8745	.6173	.9259
12	.1029	.8916	.7202	.823	.7373	.7545	.8916
13	.1029	.8916	.7373	.7888	.703	.7545	.8573
14	.1029	.7373	.7373	.583	.6516	.7373	.7545
15	.1029	.7545	.6687	.6859	.7545		.6173
16	.1029	.8573	.823	.7202	.823		.7545
17	.1029	.1029	.1029	.1372	.1029	.6859	.1029
18	.12	.1029	.1029		.0857	.12	.12
19	.2743	.2058	.2058	.1886	.1886	.2229	.2058
20	.2058	.1886	.1886	.2229	.2229	.2229	.2058
21	.1886	.1886	.1715	.1886	.1886	.1886	.1886
22	.1543	.1543	.1543	.1715	.1715	.1543	.1715
23	.12	.12	.1543	.1543	.1543	.1543	.1543
24	.6001	.1029	.12	.1543	.1372	.1543	.1543
Max	1.3032	.9602	.8402	.8573	.8916	.9945	.9602
Min	.1029	.1029	.1029	.1372	.0857	.12	.1029
Avg	.3244	.3794	.3451	.3653	.3658	.3577	.3915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 203 / 11 KV MANJRAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.8916	.8573	.823	.823	.8573	.823
2	.4287	.8916	.8573	.823	.823	.8573	.823
3	.4287	.8916	.8573	.823	.823	.8573	.823
4	.4287	.9945	.9431	.823	1.0288	.9431	.8573
5	.5144	1.0631	1.0288	.9431		1.0288	1.0288
6	.583	1.2346	1.2003	1.0288		1.2003	1.1145
7	.6516	1.5432	1.2003	1.3889	1.0288	1.3717	1.3717
8	.6173	.6516	.6001	.6859	.8916	1.0631	1.2003
9	1.1145	.6001	.5144	.6001	.4458	.6344	.5144
10	1.1145	.5144	.4458	.4973	.3429	.3601	.4287
11	.9602	.4115	.4115	.4458	.3772	.4287	
12		.4115		.3429	.3601	.4287	
13	.8573	.4115	.3429	.3429	.3429	.3944	.5144
14	.9259	.2401	.3086	.3429	.3429	.3601	.4801
15	.6001	.3429	.3944	.3429	.3601		.583
16	.6859	.3429	.3944	.3429	.3944		.6516
17		.3944	.4115	.3772	.4287	.3601	.6859
18		.4458	.4458	.4287	.4287	.4973	.7202
19	.583	.583	.6001	.6001	.6001	.7202	1.0288
20	.6516	.6001	.6001	.6001	.6173	.6859	1.046
21	.5316	.5144	.5316	.5144	.5144	.6001	.8573
22	.8573	.7202	.8916	.4801	.5144	.8573	.823
23	.8573	.8573	.8916	.8573	.8573	.823	.8573
24	.4287	.8573	.8573	.8916	.8573	.8573	.823
Max	1.1145	1.5432	1.2003	1.3889	1.0288	1.3717	1.3717
Min	.4287	.2401	.3086	.3429	.3429	.3601	.4287
Avg	.6785	.6837	.6777	.6394	.6001	.7358	.8207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 204 / 11 KV POULTRY FARM
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171		.0171	.0171	.0171
2	.0171	.0171			.0171		.0171
3	.0171	.0171			.0171		.0171
4	.0171	.0171			.0171		.0171
5	.0171	.0171	.0171	.0171	.0171	.0171	.0171
6	.0171	.0171	.0171	.0343	.0343	.0343	.0171
7	.0171	.0171	.0171	.0514	.0343	.0343	.0343
8	.0171			.0514	.0343	.0171	.0514
9					.0171	.0171	.0171
10	.0343	.0343	.0343	.0343	.0686	.0343	.0171
11	.0343	.2229	.2058	.2401	.1715	.1886	
12	.2401	.2572	.2229	.2572	.2229	.2572	
13	.2401	.2401	.2743	.2401	.2572	.2572	.2229
14	.2572	.2572	.2743	.2401	.2743	.2572	.1029
15	.2401	.2401	.2572	.2572	.2572		.2229
16	.2401	.2401	.2572	.2572	.2572		.2401
17	.2401	.2572	.2572	.2572	.2572	.2401	.2572
18	.2401	.2743	.2743	.2572	.2743	.2743	.2572
19	.0514	.1715	.2743	.2572	.2915	.2572	.2743
20	.0343	.12	.1029	.2743	.2229	.2229	.2401
21	.0343	.0686	.0514	.0514	.0514	.0343	.0343
22	.0171	.0514	.0343	.0514	.0514	.0343	.0343
23	.0171	.0343	.0343	.0343	.0343	.0343	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.2572	.2743	.2743	.2743	.2915	.2743	.2743
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0902	.1185	.1390	.1516	.1214	.1182	.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 201 / 11 KV KUNTOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.823			.6401	
2			.9145			.6401	
3			1.0059		.6097	.6401	
4			1.0974			.6401	
5			1.1888			.695	
6			1.2803			1.0059	
7		.9297	1.2803		.9755	1.0608	
8		.8383	1.1706			.9145	
9		.9145	.9145		.823		
10				.7011	.6401		.5944
11		.7682			.6584		
12		.7316		.6097	.5487		
13		.7316			.6401		.5792
14		.6584			.6401		
15		.5487		.5792	.6401		.6401
16	.503	.695			.6036		
17				.5944	.7316		
18					.695		
19		.5487			.823		
20		1.0059			.8596		
21		.9511			.8779		
22	.6249	.9145			.7682		
23		.8596			.7316		
24		.5792	.7682		.5487	.6401	
Max	.6249	1.0059	1.2803	.7011	.9755	1.0608	.6401
Min	.503	.5487	.7682	.5792	.5487	.6401	.5792
Avg	.5640	.7783	1.0444	.6211	.7119	.7641	.6046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 202 / 11 KV KUNTUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.823		
2			.823		
3			.9145		
4			.9145		
5			1.0059		
6			1.0974		
7		.8535	1.0974		
9				.503	
10				.823	.9297
11				1.0974	
12				1.0974	
13				1.1888	.6706
14				1.1706	
15				1.1888	.7621
16				.823	
22	.6097	.7316			
23		.823			
24		.6401	.823		
Max	.6097	.8535	1.0974	1.1888	.9297
Min	.6097	.6401	.823	.503	.6706
Avg	.6097	.7621	.9373	.9865	.7875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 203 / Koklegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.7316
2						.7316
3					.4725	.7316
4						.5487
5						.7316
6						1.0059
7					.7468	.8048
8						1.0059
9		.7316	.823			
10		1.3717		.9297		
11		1.2803				
12		1.2803		.6706		
13		1.1888				
14		1.0974				
15		1.0974		.7164		
16	.945	1.0974				
23					.7316	
24					.381	.7316
Max	.945	1.3717	.823	.9297	.7468	1.0059
Min	.945	.7316	.823	.6706	.381	.5487
Avg	.945	1.1431	.823	.7722	.5830	.7804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 204 / 11 kv New Ambika EX
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.128			.128	
2			.128			.128	
3			.1463		.0457	.1463	
4			.128			.128	
5			.1463			.128	
6			.128			.0366	
7		.0914	.128		.1067	.128	
8		.0914	.1829			.0914	
9		.0549	.0366		.1646		
10		.0366		.0457	.1829		.0305
11		.1646			.1383		
12		.1646		.0457	.1829		
13		.1829			.2378		.0457
14		.3292			.2378		
15		.1646		.0457	.2195		.0305
16	.0457	.1829			.2378		
17		.2012		.0457	.2012		
18		.1509			.2012		
19		.2195			.2743		
20		.3109			.5121		
21		.128			.5487		
22	.1067	.1829			.1646		
23		.128			.128		
24		.1067	.128		.0457	.128	
Max	.1067	.3292	.1829	.0457	.5487	.1463	.0457
Min	.0457	.0366	.0366	.0457	.0457	.0366	.0305
Avg	.0762	.1606	.1280	.0457	.2128	.1158	.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 205 / 11 KV KOKLEGAON GAOUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3658		.3658
2			.3658		.3658
3			.3658		.3658
4			.3658		.3658
5			.3658		.439
6			.3658		.5121
7		.442	.3475		.3841
8		.3658	.3658		.439
9		.3658	.3475	.3658	
10		.3658		.3292	
11		.128		.2926	
12		.1829		.2743	
13		.1829		.2926	
14		.1646		.2743	
15		.2743		.2743	
16	.2134	.1829		.2378	
17		.1646		.2561	
18		.3658		.2195	
19		.4572		.3658	
20		.3658		.4572	
21		.3841		.4024	
22	.3048	.3841		.3841	
23		.3841		.3658	
24		.2743	.3658		.3658
Max	.3048	.4572	.3658	.4572	.5121
Min	.2134	.128	.3475	.2195	.3658
Avg	.2591	.3019	.3621	.3195	.4004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 201 / 11 KV VAZIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.362	.415		1.5432	1.3203
2		.362	.415		1.5432	1.3203
3		.362	.415		1.6289	1.3203
4		.362	.415		1.6289	1.3203
5		.4525	.4527		1.7147	1.3957
6		.4525	.5281		1.7147	1.5089
7		.4525	.4904		1.7147	1.6221
8	.5601	.362	.4527	1.9418	1.5432	1.6598
9		1.3717	1.6598		.4525	.5281
10		1.7833	1.8861		.4344	.2829
11		1.7833	1.9805		.362	.2829
12		1.7147	1.9805		.3258	.2829
13		1.7147	1.9805		.3258	.2829
14		1.6461	1.8861		.2896	.2829
15		1.6461	1.8861		.2896	.2829
16	1.8671	1.5775	1.8861	.2987	.3258	.3772
17		.362	.4715		.362	.3772
18		.4344	.3772		.4344	.4715
19		.5792	.4715		.543	.5658
20		.543	.5658			.4715
21		.4706	.4715			.4715
22		.4344	.4715			.3772
23	.3734		.4715	1.4937		1.4146
24	.4668	.362	.415	1.4937	1.5432	1.3203
Max	1.8671	1.7833	1.9805	1.9418	1.7147	1.6598
Min	.3734	.362	.3772	.2987	.2896	.2829
Avg	.8169	.8518	.9352	1.3070	.9360	.8142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 202 / 11 KV ANTERGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8442			.8764	.9808
2		2.0119	2.0748		.8764	.9808
3		2.0119	2.0748		.8764	.9808
4		2.1795	2.0748		.964	1.0562
5		2.1795	2.2634		1.0517	1.0562
6		2.3472	2.452		1.0517	1.1317
7		2.3472	2.5652		1.0517	1.1694
8	1.4937	1.0517	1.2071	1.2696	.8764	1.2071
9		1.0517	1.1317		.964	2.2634
10		1.0517	.8488		1.3717	2.6406
11		.9816	.7545		1.5089	2.7349
12		.9816	.7545		1.6095	2.7349
13		.9465	.7545		1.6766	2.7349
14		.9465	.6602		2.0119	2.8292
15		.9114	.7545		2.1795	2.8292
16		.9114	.7545	.7468	2.2131	2.9235
17		.9816	.7545		2.3472	.9431
18		1.0517			1.0059	1.1317
19		1.1919	.8488		1.1919	1.226
20		1.1218	1.0374			1.5089
21		1.0517	1.0374			1.4146
22		1.6095	1.0374			1.3203
23	1.8671		1.6975	1.1203		1.226
24	2.0538	1.8442	1.8861	1.1203	.8764	.9808
Max	2.0538	2.3472	2.5652	1.2696	2.3472	2.9235
Min	1.4937	.9114	.6602	.7468	.8764	.9431
Avg	1.8049	1.4177	1.3375	1.0643	1.3291	1.6669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 203 / 11 KV BARBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.905	.9431		.6001	.7545
2		.905	.9431		.6001	.7545
3		.905	.9431		.6001	.7545
4		1.086	1.0562		.6859	.7545
5		1.267	1.3203		.6859	.7922
6		1.448	1.5089		.6859	.8299
7		1.5384	1.5844		.6859	.9054
8		1.448	1.5089	1.1203	.7716	.9431
9		.9955	.8299		1.086	1.2071
10		.8573	.9431		1.0136	1.0374
11			.8488		.905	.8488
12			.8488		.724	.8488
13		.7888	.8488		.724	.8488
14		.7888	.8488		.724	
15		.7545	.7545		.7964	.8488
16	.7468	.7545	.7545	.7468	.905	.8488
17		.905	1.0374		1.086	1.1317
18		1.086	1.0374		1.267	1.4146
19		1.5203	1.226		1.448	1.5089
20		1.267	1.4146			1.3203
21		1.086	1.226			1.1317
22		.9412	1.0374			1.0374
23	1.1203		.9431	.6535		.7545
24	.9335	.905	.9431	.6722	.6001	.7545
Max	1.1203	1.5384	1.5844	1.1203	1.448	1.5089
Min	.7468	.7545	.7545	.6535	.6001	.7545
Avg	.9335	1.0549	1.0563	.7982	.8297	.9579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 201 / 11 kv kirti
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5927	1.7147	1.6095	1.701	1.7924	1.8461	1.6832
2	1.5565	1.6766	1.5546	1.7193	1.7177	1.8461	1.7013
3	1.5384	1.6766	1.4998	1.7193	1.8298	1.828	1.6832
4	1.5203	1.6575	1.4632	1.7558	1.8298	1.8099	1.6651
5	1.4842	1.6575	1.4118	1.7924	1.9791	1.7556	1.6651
6	1.4661	1.6385	1.4118	1.7918	1.9791	1.7194	1.647
7	1.5927	1.7337	1.2489	1.701	2.0538	1.6832	1.6651
8	.9145	1.3336	1.5729	1.6095	1.9044	1.5384	1.7375
9	1.5565	1.0479	1.6461	1.6804	1.8673	1.6651	1.6289
10	1.7147	1.8642		1.6804	1.7737	1.7194	1.9243
11	1.8099	1.8823	1.9022	1.8839	1.9185	1.7194	1.9624
12	1.7337	1.7737	1.7558	1.9418	2.0452	1.7375	2.0767
13	1.6956	1.829	1.7375	1.8298	1.9004	1.7556	1.9052
14	1.7337	1.7924	1.7193	1.8298	1.828	1.7375	.8764
15	1.7147	1.7558	1.701	1.8484	1.8099	1.6651	1.3336
16	1.7147	1.7375	1.6644	1.7924	1.6832	1.6108	1.7147
17	1.6004	1.6644	1.4632	1.8671	1.7194	1.6289	1.7147
18	1.6956	1.6827	1.5364	1.3014	1.7375	1.6651	1.7528
19	1.7147	1.5912	1.6644	1.8107	1.7556	1.7194	1.7528
20	1.7337	1.5912	1.6827	1.6804	1.7556	1.7556	1.7909
21	1.7337	1.701	1.7193	1.7353	1.7737	1.7375	1.8099
22	1.7528	1.6278	1.701	1.643	1.7737	1.7194	1.9052
23	1.7528	1.6278	1.6827	1.7177	1.7918	1.7194	1.9624
24	1.6289	1.7337	1.6644	1.6827	1.7177	1.8099	1.7013
Max	1.8099	1.8823	1.9022	1.9418	2.0538	1.8461	2.0767
Min	.9145	1.0479	1.2489	1.3014	1.6832	1.5384	.8764
Avg	1.6230	1.6663	1.6093	1.7381	1.8307	1.7247	1.7192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 202 / 11 kv flemingo
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1905	.4755	.4755	.2241	.3361	.2801
2	.2614	.1905	.4755	.439	.2829	.3361	.2241
3	.2241	.1334	.4344	.439	.2241	.3547	.1867
4	.2241	.1334	.439	.4755	.1867	.3547	.1494
5	.2054	.1334	.362	.439	.1867	.3361	.1494
6	.2054	.1143	.3439	.439	.2427	.3174	.1307
7	.1494	.1524	.1448	.3292	.3547	.3174	.3174
8	.0934	.1334	.1097	.128	.3361	.0762	.0381
9	.4805	.0953	.1097	.1494	.5601	.3696	.0572
10	.4001	.3801		.1494	.6468	.4435	.381
11	.362	.362	.3982	.2926	.7023	.5175	.5525
12	.381	.3982	.3292	.2987	.7762	.5729	.5525
13		.4024	.3439	.2987	.5175	.4805	.5716
14	.0572	.2561	.3475	.2987	.2054	.2614	.7049
15	.0572	.4024	.4024	.2801	.2614	.3696	.6668
16	.0572	.6036	.4755	.2427	.3361	.4805	.6859
17	.1715	.6219	.3658	.2987	.3361	.4435	.6859
18	.1715	.7499	.3475	.1886	.3547	.3511	.5716
19	.1905	.7865	.3475	.2452	.3547	.3696	.381
20	.1905	.4024	.4024	.2241	.3696	.3881	.2858
21	.1905	.4938	.5304	.2241	.3696	.3696	.2858
22	.1905	.5304	.439	.3734	.3361	.3511	.3048
23	.2286	.5121	.439	.2801	.3174	.3361	.4001
24	.2987	.2286	.4938	.4755	.2427	.3174	.2987
Max	.4805	.7865	.5304	.4755	.7762	.5729	.7049
Min	.0572	.0953	.1097	.128	.1867	.0762	.0381
Avg	.2205	.3503	.3720	.3118	.3635	.3688	.3693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 203 / 11 kv advance steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.0953	.1463	.1097	.1494	.1307	.0934
2	.1494	.0953	.1463	.1097	.112	.112	.112
3	.1494	.0953	.1097	.1463	.1509	.112	.112
4	.1307	.0953	.1097		.112	.0934	.112
5	.1307	.0953	.1086	.1463	.112	.0934	.1307
6	.1307	.0953	.1086	.1463	.1494	.0934	.1307
7	.1307	.0953	.0905	.1463	.1463	.112	.1307
8	.0762	.0953	.1097	.0732	.1494	.112	.1307
9	.112	.0953	.1097	.1494	.2075	.1867	.3361
10	.0953	.1267		.1494	.462	.2987	.2858
11	.0953	.1448	.362	.3547	.5544	.3174	.2667
12	.0953	.2534	.4024	.3547	.6653	.3174	.2667
13	.1143	.2561	.181	.168	.3696	.2987	.2667
14	.1143	.2195	.1646	.168	.1494	.2801	.2096
15	.0953	.2561	.2926	.168	.2801	.2987	.381
16	.0762	.2926	.3841	.1494	.4805	.2801	.4763
17	.0953	.3475	.2561	.3547	.4066	.2614	.4763
18	.0572	.3109	.1646	.2075	.3361	.2427	.381
19	.0762	.4024	.2561	.2263	.2614	.2241	.381
20	.0762	.2012	.0732	.168	.2241	.2054	.1905
21	.0762	.128	.1097	.1698	.1867	.1867	.1715
22	.0762	.1829	.1097	.168	.1494	.112	.1334
23	.0762	.1463	.1097	.1494	.1307	.112	.1524
24	.1307	.0762	.1463	.1097	.1494	.1307	.0934
Max	.1494	.4024	.4024	.3547	.6653	.3174	.4763
Min	.0572	.0762	.0732	.0732	.112	.0934	.0934
Avg	.1046	.1751	.1761	.1779	.2539	.1922	.2259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 205 / 33 KV Venkys Express
Feeder Feeder KV- 33 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2862	1.6461	1.8656			
2		2.2862	1.7558	1.8656			
3		2.2862	1.7558	1.7558			
4	1.6632	2.1719	1.6461	1.7558			
5	1.7741	2.1719	1.6461	1.7558			
6	2.2177	2.0576					
7	4.3347						
8	4.2798						
9	4.1701	1.829					
10	4.5725						
11	5.0297	4.5068					
12	5.0869	2.8235					
13	4.3439	2.0851					
14	4.6868	1.9753	1.7558				
15	4.8583	1.8656	1.8656				
16	4.8583	1.7558	1.9204				
17	4.401	1.8656	2.0302				
18	4.3439	2.0302	2.1948				
19	4.401	1.9753	2.1399			1.9404	
20	4.4582	1.9204	2.0851		1.9404	1.9404	
21	4.4582	1.9204	2.0851		1.885	1.885	
22	4.4582	1.8107	1.9753			1.8296	
23	2.8006	1.8107	1.9753			1.7741	
24		2.8578	1.6461	1.9753			1.6632
Max	5.0869	4.5068	2.1948	1.9753	1.9404	1.9404	1.6632
Min	1.6632	1.7558	1.6461	1.7558	1.885	1.7741	1.6632
Avg	4.0599	2.2044	1.8827	1.8290	1.9127	1.8739	1.6632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 207 / 11 KV India Mega Agro
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.4001	.4024	.439	.439	.4251	.4066
2	.2241	.381	.4024	.439	.4207	.4435	.3881
3	.2054	.381	.3841	.4207	.3921	.462	.3696
4	.2241	.381	.3841	.4207	.4294	.4066	.3361
5	.2427	.381	.3982	.4207	.4207	.3881	.3361
6	.2614	.4001	.3982	.4207	.4024	.3696	.3547
7	.2614	.4001	.3801	.4207	.3292	.3511	.3696
8	.2801	.5716	.4207	.4024	.4572	.3403	.2987
9	.2987	.6668	.439	.4481	.4572	.4805	.3361
10	.381	.724		.4207	.5175	.5544	.4763
11	.4001	.7059	.543	.6584	.5914	.5729	.381
12	.4572	.6516	.5853	.6401	.6283	.5914	.5335
13	.362	.6584	.6219	.5487	.5914	.5914	.5144
14	.381	.6584	.6584	.5487	.5729	.5914	.5525
15	.4763	.6219	.6584	.567	.5544	.6283	.4954
16	.5906	.5853	.6584	.5853	.5729	.6468	.4763
17	.6859	.567	.5853	.5853	.5175	.5544	.4763
18	.6287	.4938	.5121	.4755	.4805	.5175	.4763
19	.5716	.5121	.5121	.5601	.4435	.462	.4763
20	.4763	.4024	.439	.4481	.4066	.3881	.2667
21	.4191	.4207	.439	.4294	.3881	.3696	.4763
22	.381	.3658	.4207	.439	.3696	.3881	.4954
23	.381	.3841	.4207	.439	.3696	.3881	.4572
24	.2427	.381	.3841	.439	.4481	.4066	.3696
Max	.6859	.724	.6584	.6584	.6283	.6468	.5525
Min	.2054	.3658	.3801	.4024	.3292	.3403	.2667
Avg	.3774	.5040	.4803	.4840	.4667	.4716	.4216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174111 / 33 KV NAIGAON

Feeder No / Name : 101 / Lalwandi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5658	.4904	.4904	.5658	.5658	.6602
2	.4527	.5658	.4904	.4904	.5658	.5658	.679
3	.4904	.6036	.4904	.4904	.4904	.5658	.7167
4	.5281	.6413	.5281	.5281	.4904	.4904	.7545
5	.5658	.679	.5658	.5658	.4904	.4904	.8488
6	.6602	.7167	.6224	.6036	.9808	1.0751	.9054
7	.7545	.7167	.6602	.7167	.9808	1.0751	.9808
8	.7545	.7167	.7167	.8488	.8488	.9808	1.0185
9	.6602	.7356	.6602	.8676		.7167	.4715
10	.6602	.8299	.7356	.8676	.7545	.6224	.4904
11	.6602	.8676	.7733	.8299	.5658		.4338
12	.5658	.8488	.7545	.8299	.415	.3772	
13	.5658	.7922	.7356	.7545	.3772	.3772	
14	.6602	.7356	.7545	.6602	.3772	.3772	.415
15	.6602	.7167	.7922	.7545	.3772		.3961
16	.6602		.8299	.7545	.4338	.3961	.415
17	.3772	.4338	.415	.3772	.4338	.415	.4338
18	.5658	.4527	.4338	.3772	.5658	.5093	.4904
19	.5658	.5281	.4338	.5658	.6036	.5658	.5658
20	.6602	.6602	.6413	.5658	.679	.6224	.5658
21	.6602	.7167	.6036	.5658	.679	.5658	.5281
22	.5658	.6224	.5658	.5658	.4904	.5281	.4904
23	.5658	.5658	.5281	.5658	.6036	.5658	.5281
24	.5658	.5658	.4904	.4904	.5658	.6036	.6224
Max	.7545	.8676	.8299	.8676	.9808	1.0751	1.0185
Min	.3772	.4338	.415	.3772	.3772	.3772	.3961
Avg	.5949	.6642	.613	.6303	.5798	.5933	.6096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174111 / 33 KV NAIGAON

Feeder No / Name : 103 / 11 kv Degaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2263	.1886	.2641	.2641
2	.2641	.2263	.2263	.1886	.2641	.2263
3	.2641	.2641	.2641	.1886	.2641	.2263
4	.3018	.2641	.3018	.2263	.3395	.2263
5	.3018	.3018	.3395	.2641	.3395	.3395
6	.3018	.3018	.3772	.3018	.415	.415
7	.3018	.3018	.415	.3772	.415	.415
8	.3018	.3018	.415	.4338	.3772	.3395
9	.3772	.3395	.2263	.3772	.3018	.2641
10	.3395	.3772	.2641	.3772	.3018	.2263
11	.3395	.415	.2641	.415		.2075
12	.3395	.4338	.3018	.415	.1886	.1886
13	.3395	.3772	.2829	.3772	.1886	.2075
14	.3772	.3584	.3018	.2641	.1886	.1886
15	.3772	.3395	.3395	.3018	.2263	.1886
16	.3772	.3395	.3772	.3018	.2263	.1886
17	.1886	.1886	.1886	.1886	.2263	.1886
18	.1886	.2641	.2075	.1886	.3395	.2075
19	.2263	.3018	.2075	.3395	.3772	.2452
20	.2263	.3395	.2829	.3395	.3772	.3206
21	.2263	.3018	.2641	.3395	.3772	.3018
22	.2641	.2641	.2263	.3018	.3018	.2829
23	.2641	.2263	.2263	.2641	.2641	.2641
24	.3018	.2641	.2263	.1886	.2641	.2641
Max	.3772	.4338	.415	.4338	.415	.415
Min	.1886	.1886	.1886	.1886	.1886	.1886
Avg	.2939	.3049	.2814	.2979	.2969	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 201 / 11 KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	03-APR-18
HR	Load (MW)	Load (MW)
13		.3429
24	.1715	
Max	.1715	.3429
Min	.1715	.3429
Avg	.1715	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 202 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-APR-18
HR	Load (MW)
23	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 203 / 11 KV JAWAHAR NAVODAY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	03-APR-18
HR	Load (MW)
13	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 204 / 11 KV SHANKARNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 201 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.4344		.9145	.5068		.5487
2	.9145	.4481	.5601	.9145	.5068	.5373	.5487
3	.9145	.4344		.9145	.5121		.5487
4	.9145	.4344	.5601	.9145	.5121	.5373	.7316
5	.9145	.5068		.9145	.5121		.7316
6	.9145	.5068	.5601	.9145	.5121	.5373	.7316
7	.9145	.5068	.5601	.9145	.6516	.5373	.7316
8	.9145	.5068	.5601	.9145	.6516	.5373	.7316
9	.8376	.5487	.6516	.7602	.3734	.5487	.7602
10	.9307	.5487	.6516	.7602	.543	.5487	.7602
11		.5487	.5792	.9412	.5373	.5487	.7602
12	.7446	.5487		.9412	.5373	.5487	.7602
13	.5584	.5487	.5792	.7602	.5373	.5487	.7602
14	.8376	.5487	.7602	.7442	.543	.5487	.5792
15	.7446		.905	.6516	.543	.9145	.6516
16	.8376	.5487	.9412	.6584	.543	.9145	.9145
17	.8376	.5601	.9145	.7602	.5373	.9145	.7164
18	.8376	.5601	.9145	.7682	.5373	.9145	.7164
19	.8376	.5601	.9145	.7602	.5373	.9145	.724
20	.724	.7468	.9145	.5792	.7164	.9145	.543
21	.5068	.5601	.9145	.5792	.543	.7316	.543
22	.4344		.9145	.5853	.543	.5487	.543
23	.4344		.9145	.543	.543	.5487	
24	.9145	.4344	.5601	.9145	.543	.5373	.5487
Max	.9307	.7468	.9412	.9412	.7164	.9145	.9145
Min	.4344	.4344	.5601	.543	.3734	.5373	.543
Avg	.7971	.5258	.7415	.7926	.5426	.6587	.6776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 202 / 11 KV GURUDWARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.5853		.7316	.5853		.7316
2	.7316	.5853	.5544	.7316	.5853	.7316	.7316
3	.7316	.5853		.7316	.5853		.7316
4	.7316	.5853	.5544	.7316	.5853	.7316	.7316
5	.7316	.5792		.7316	.6401		.7316
6	.7316	.695	.7392	.7316	.6584	.7316	.7316
7	.9145	.695	.8316	.7316	.695	.7316	.7316
8	.9145	.7316	.6468	.7316	.7316	.6401	.7316
9	.765	.7316	.6401	.5487	.7392	.7316	.7316
10	.7285	.7316	.6584	.6401	.7392	.7316	.7682
11		.823	.7316	.6584	.7392	.9145	.7682
12	.8378	.9145		.6401	.7392	.7316	.8779
13	.765	.823	.695	.6219	.7392	.7316	.695
14	.7285	.7316	.7316	.6584	.8316	.9145	.823
15	.8743		.7682	.6401	.8316	.823	.7682
16	.8378	.7316	.7682	.6401	.8316	.7316	.8413
17	.8378	.8316	.7316	.695	.7392	.7316	.9145
18	.8378	.8316	.823	.7316	.8316	.7316	1.0059
19	.9835	.924	.9145	.7964	1.0059	1.0974	1.1888
20	.9412	.924	.9145	.8779	.9145	1.0974	1.0974
21	.8779	.924	.9145	.8413	.924	.9145	1.0059
22	.8779		.823	.7316	.9145	.823	.9145
23	.8145		.7316	.7316	.9145	.7316	
24	.7316	.823	.5544	.7316	.5487	.823	.7316
Max	.9835	.924	.9145	.8779	1.0059	1.0974	1.1888
Min	.7285	.5792	.5544	.5487	.5487	.6401	.695
Avg	.8112	.7518	.7363	.7099	.7521	.8013	.8254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 203 / 11 KV SOMESH COLONEY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.7375		1.829	1.6289		1.829
2	1.6461	1.7194	1.6632	1.6461	1.6461	1.7556	1.6461
3	1.6461	1.7375		1.6461	1.6289		1.6461
4	1.6461	1.7375	1.6632	1.6461	1.6461	1.7556	1.829
5	2.0119	1.6289		2.0119	1.7375		2.1948
6	2.3777	1.5546	1.6632	2.3777	1.7194	1.848	2.5606
7	2.1948	1.8099	1.9404	2.1948	1.9204	2.0328	2.3777
8	2.1948	2.0119	2.0328	2.0119	2.0376	2.0328	2.3777
9	2.134	2.0119	1.9004	1.9909	2.1253	2.3777	2.0814
10	2.134	2.3777	2.1719	1.9909	2.4025	2.7435	1.8099
11		2.9264	2.4434	2.0814	2.5873	3.1093	1.9909
12	2.6686	2.9264		1.9909	2.5873	3.2922	2.1948
13	2.4846	2.9264	2.5339	1.9909	2.4949	3.4751	2.1719
14	2.3926	2.9264	2.4434	1.8099	2.6797	3.2922	2.1719
15	2.4846		2.4434	1.9004	2.6797	3.4751	2.1719
16	2.3926	2.7435	2.4434	1.8099	2.6797	3.658	2.0814
17	2.3926	2.4025	2.7435	2.0119	2.7721	3.2922	2.4025
18	2.5766	2.4949	3.2922	1.9909	2.6797	3.1093	2.5873
19	2.7606	2.5873	3.8409	2.2862	2.9569	3.8409	2.6797
20	2.5339	2.4949	3.658	2.1719	2.5873	3.2922	2.5873
21	2.3167	2.2177	3.1093	2.0119	2.3101	2.9264	2.2177
22	1.9909		2.3777	1.9605	2.2177	2.1948	1.848
23	1.9404		2.0119	1.7375	2.0328	1.829	
24	2.0119	1.9204	1.6632	1.829	1.6289	1.7556	1.829
Max	2.7606	2.9264	3.8409	2.3777	2.9569	3.8409	2.6797
Min	1.6461	1.5546	1.6632	1.6461	1.6289	1.7556	1.6461
Avg	2.2070	2.2330	2.4020	1.9554	2.2245	2.7185	2.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 204 / 11 KV VAZIRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.8859		1.2803	.9145		1.0974
2	1.0974	.905	1.0269	1.0974	.9145	1.0059	1.0059
3	1.0974	.9145		1.0974	.9145		.9145
4	1.0974	.905	1.0269	1.0974	.9145	1.0059	.9145
5	1.1888	.9145		1.2437	.9145		1.0974
6	1.2803	.905	1.0269	1.2803	1.0136	1.0974	1.2803
7	1.4632	1.0242	1.1203	1.2803	1.0498	1.1888	1.2803
8	1.2803	1.134	1.2136	1.2803	1.086	1.2803	1.2803
9	1.2463	1.2803	1.0974	1.2308	1.307	1.4632	1.2308
10	1.4662	1.4632	1.1222	1.3756	1.307	1.4632	1.2437
11		1.4632	1.448	1.3756	1.4937	1.4632	1.1765
12	1.8328	1.6461		1.3289	1.7737	1.6461	1.6461
13	1.004	1.6461	1.5927	1.5238	1.7737	1.6461	1.6461
14	1.5579	1.829	1.5927	1.5364	1.8671	1.6461	1.6651
15	1.5762		1.8099	1.5546	1.8671	1.829	1.7193
16	1.5396	1.7375	1.829	1.448	1.8671	1.829	1.8099
17	1.6495	1.7737	1.829	1.6461	1.9605	1.829	1.9204
18	1.7595	1.7737	1.829	1.6651	2.1472	1.6461	2.0119
19	1.9712	2.0538	2.0119	1.8461	2.1033	2.1948	2.1033
20	1.7737	1.9605	2.0119	1.8099	1.9204	1.829	2.0119
21	1.5384	1.6804	1.829	1.6095	1.7556	1.6461	1.7375
22	1.267		1.6461	1.3535	1.4632	1.4632	1.4632
23	1.267		1.4632	1.3535	1.2803	1.2803	
24	1.4632	1.086	1.1203	1.4632	1.267	1.1888	1.0974
Max	1.9712	2.0538	2.0119	1.8461	2.1472	2.1948	2.1033
Min	1.004	.8859	1.0269	1.0974	.9145	1.0059	.9145
Avg	1.4216	1.3801	1.4823	1.4074	1.4532	1.5067	1.4502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 205 / 11 KV Khadakpura

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.267		1.0974	1.2803		1.0974
2	1.0974	1.2803	1.1203	1.0974	1.2803	1.1203	1.0974
3	1.0974	1.267		1.0974	1.267		1.0974
4	1.2803	1.267	1.307	1.0974	1.267	1.2136	1.2803
5	1.4632	1.267		1.2803	1.3575		1.4632
6	1.6461	1.5565	1.4937	1.6461	1.5746	1.6804	1.829
7	1.829	2.0851	1.8671	1.829	1.8461	1.9605	2.0119
8	2.1948	2.3167	2.1472	2.0119	2.1357	2.2405	2.1948
9	2.2405	2.1948	1.9185	2.1357	2.1472	2.1948	2.3167
10	1.8671	2.3777	1.7013	1.9004		1.6461	2.0851
11		2.1948		1.9547		1.6461	1.7737
12	1.8671	1.829	1.5203	1.9909		1.6461	1.7737
13	1.5684	1.829	1.3756	1.7177	1.587	1.4632	1.5203
14	1.4563	1.4632	1.267	1.448	1.6804	1.4632	1.4563
15	1.307		1.1765	1.3032	1.4003	1.4632	1.3756
16	1.307	1.2803	1.2136	1.267	1.4937	1.4632	1.3032
17	1.531	1.587	1.6461	1.6095	1.6804	1.2803	1.587
18	1.9044	1.7737	2.0119	1.8823	2.1472	2.0119	2.1472
19	2.1472	2.2405	2.1948	2.0633	2.3339	2.1948	2.3339
20	1.7551	1.7737	1.829	1.7013	1.8671	1.829	1.9605
21	1.5203	1.4937	1.6461	1.5364	1.6804	1.6461	1.6804
22	1.448		1.4632	1.5203	1.587	1.4632	1.587
23	1.3575		1.4632	1.267	1.4937	1.2803	
24	1.2803	1.267	1.1203	1.2803	1.267	.5601	1.0974
Max	2.2405	2.3777	2.1948	2.1357	2.3339	2.2405	2.3339
Min	1.0974	1.267	1.1203	1.0974	1.267	.5601	1.0974
Avg	1.5806	1.6958	1.5741	1.5723	1.6368	1.5937	1.6552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 201 / 11 KV COLLECTOR OFFICE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2534			
3			.1753			.181
6			.1372			
7						.1029
8			.1052		.8688	.0876
9	.1402			.1086		
10				.1402		
11	.1753					.1052
12				.1372		
13	.1715					.1402
16	.2103			.2103		.1402
17	.2126	.2172			.1753	.1372
19	.104	.1052		.1402	.1372	
20		.1086			.1063	
21	.1417					
22		.2103			.2172	
23		.2835				
24				.3658		.2401
Max	.2126	.2835	.2534	.3658	.8688	.2401
Min	.104	.1052	.1052	.1086	.1063	.0876
Avg	.1651	.1850	.1678	.1837	.3010	.1418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 202 / 11 KV CHIKHALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0498			
3			.9816			1.0517
6			.9259			
7						.8916
8			.8413		.8688	.8764
9	.8764			.9412		
10				.9465		
11	1.1218					1.1317
12				1.0631		
13	1.166					1.3321
16	1.3321			1.1919		1.4723
17	1.2757	1.267			1.4022	
19	1.5604	1.4723		1.2269	1.5432	
20		1.6289			1.5947	
21	1.382					
22		1.262			1.3756	
23		1.134				
24				1.2803		1.1145
Max	1.5604	1.6289	1.0498	1.2803	1.5947	1.4723
Min	.8764	1.134	.8413	.9412	.8688	.8764
Avg	1.2449	1.3528	.9497	1.1083	1.3569	1.1243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 203 / 11 KV GRANTH BHAVAN

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1086			
3			.1052			.0876
6			.1029			
7						.0514
8			.0701		.0543	.0526
9	.0701			.0543		
10				.0701		
11	.0526					.0514
12				.0514		
13	.0514					.0351
16	.0701			.0701		.0701
17	.0532	.0724			.0526	
19	.0693	.0876		.0701	.0686	
20		.0905			.0709	
21	.0886					
22		.1227			.0905	
23		.124				
24				.1097		.0857
Max	.0886	.124	.1086	.1097	.0905	.0876
Min	.0514	.0724	.0701	.0514	.0526	.0351
Avg	.0650	.0994	.0967	.0710	.0674	.0620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 204 / 11 KV BAFNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7737			
3			1.5775			1.7528
6			1.5432			
7						1.5089
8			1.5424		1.7013	1.6476
9	1.6827			1.7375		
10				1.7878		
11	1.7353					1.6118
12				1.8519		
13	1.9719					1.7177
16	1.9281			1.9631		1.9631
17		1.9185			1.893	
19		2.1735		2.0332		
20		2.1357			2.1262	
22		1.7878			2.0633	
23		1.8604				
24				1.9753		1.8861
Max	1.9719	2.1735	1.7737	2.0332	2.1262	1.9631
Min	1.6827	1.7878	1.5424	1.7375	1.7013	1.5089
Avg	1.8295	1.9752	1.6092	1.8915	1.9460	1.7269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 205 / 11 KV OLD MONDHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7737			
3			1.6476			1.7177
6			1.3717			
7						1.3032
8			1.262		1.267	
9	1.1919					
10				1.5775		
11	1.1919					1.2003
12				1.3717		
13	1.2003					1.262
16	1.2971			1.4022		1.5424
17	1.2757	1.3394			1.3321	
19	1.5257	1.4899		1.4723	1.5432	
20		1.6651			1.7364	
21	1.6301					
22		1.6827			1.9909	
23		1.8427				
24				1.9204		1.8176
Max	1.6301	1.8427	1.7737	1.9204	1.9909	1.8176
Min	1.1919	1.3394	1.262	1.3717	1.267	1.2003
Avg	1.3304	1.6040	1.5138	1.5488	1.5739	1.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 206 / 11 KV SACHKHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6154			
3			.5258			.5609
6			.3429			
7						.3086
8			.2804		.2896	
9	.2804			.4344		
10				.3506		
11	.2743					.2743
12				.4115		
13	.2743					.2804
16	.2103			.4207		.3506
17	.3544	.362			.4207	
19	.3467	.3506		.4908	.4115	
20		.362			.3544	
21	.3544					
22		.5609			.5792	
23		.6379				
24				.7316		.5487
Max	.3544	.6379	.6154	.7316	.5792	.5609
Min	.2103	.3506	.2804	.3506	.2896	.2743
Avg	.2993	.4547	.4411	.4733	.4111	.3873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 207 / 11 KV RAILWAY HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1086			
3			.1063			.1052
6			.1029			
7						.1029
8			.1052		.0905	.1029
9	.0701			.1086		
10				.1052		
11						.0686
12				.1029		
13	.1029					.1052
16	.0701			.1052		.1052
17		.1086			.1052	
19		.1052		.1227	.1029	
20		.1267			.1063	
22		.1227			.1267	
23		.124				
24				.128		.1029
Max	.1029	.1267	.1086	.128	.1267	.1052
Min	.0701	.1052	.1029	.1029	.0905	.0686
Avg	.0810	.1174	.1058	.1121	.1063	.0990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 201 / 11 KV BILAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2936	1.2012	1.2936	1.2936	1.2936	1.2936
2	1.2936	1.2936	1.1088	1.2936	1.2936	1.2936	1.2936
3	1.1088	1.2936	1.1088	1.2936	1.2936	1.2936	1.2936
4	1.2936	1.2936	1.1088	1.2936	1.2936	1.2936	1.2936
5	1.2936	1.2936	1.1088	1.2936	1.2936	1.386	1.2936
6	1.2936	1.2936	1.2136	1.4784	1.2936	1.587	1.386
7	1.4937	1.2936	1.587	1.4784	1.4784	1.6804	1.4784
8	1.587	1.6632	1.6632		1.6632	1.8671	1.6632
9	1.6632	1.7556	1.6804	2.0538	1.4003	1.6804	1.587
10	1.6632		1.7737	1.6804	1.307	1.587	1.6804
11		1.9404	1.4937	1.8671	1.4784	1.6804	1.6632
12	1.4784	1.9404	1.4784	1.6632	1.5708	1.587	1.4784
13	1.2936	1.6632	1.386	1.5708	1.4784	1.4937	1.4784
14	1.4784	1.4784	1.386	1.4784		1.4784	2.0328
15	1.386	1.2936	1.4784	1.2803	1.0974	1.4632	1.2936
16		1.2012	1.4784	1.2136	1.4632	1.3717	
17	1.4784	1.2936	1.4784	1.2936	1.6632	1.4784	1.386
18	1.7556	1.2936	1.848	1.2936	1.6632	1.848	1.6632
19	1.6632	1.4937	2.1253	1.4784	1.6632	1.9404	1.9404
20	1.4784	1.587	1.7556	1.4784	1.5708	1.6632	1.6632
21	1.2936		1.5708	1.2936	1.4784	1.6632	1.4784
22	1.2936	1.386	1.4784	1.2936	1.386	1.2936	1.4784
23	1.2936	1.386		1.2936	1.2936	1.2936	1.2936
24	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936	1.2936
Max	1.7556	1.9404	2.1253	2.0538	1.6632	1.9404	2.0328
Min	1.1088	1.2012	1.1088	1.2136	1.0974	1.2936	1.2936
Avg	1.4168	1.4420	1.4698	1.4326	1.4222	1.5213	1.4959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 202 / 11 KV RLY TRACK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	1.848	1.848	1.848	2.0328	1.9404	2.2177
2	1.848	1.848	1.6632	1.848	2.0328	1.848	2.2177
3	1.848	1.848	1.6632	1.848	2.0328	1.848	2.0328
4	1.848	1.848	1.6632	1.848	1.848	1.848	1.848
5	1.848	1.848	1.6632	1.848	1.848	1.848	1.848
6	1.848	1.848	1.8671	1.848	1.848		1.9404
7	1.8671	2.0328	1.8671	1.9404	2.2177	2.0538	1.9404
8	2.0538	2.2177	1.9605	2.0328	2.2177	2.0538	2.0328
9	2.0328	2.2177	2.0538	2.2405	2.2405	2.2405	2.1472
10	2.0328		2.0538	2.2405	2.0538	2.0538	2.1472
11		2.4025	1.8671	2.2405	1.9404	2.0538	1.9404
12	1.848	2.4025	1.848	2.1253	1.848	2.0538	1.848
13	1.848	2.4025	1.848	2.0328	1.9404	1.9605	2.2177
14	1.848	2.0328	1.6632	1.9404	1.8671	1.848	2.0328
15	1.6632	1.6632	1.7556	1.829	1.7375	1.829	1.848
16	1.6632	1.6632	1.7556	1.7737	1.7375	1.7375	
17	1.848	1.6632	1.7556	1.848	1.848	1.848	
18	1.848	1.307	2.0328	2.0328	1.9404	2.0328	2.4025
19	2.5873	2.4272	2.4025	2.3282	2.0328	2.4025	2.5873
20	2.4949	2.2405	2.2177	2.4025	2.4025	2.3101	2.6797
21	2.2177		2.2177	2.2177	2.2177	2.0328	2.5873
22	2.2177	2.0328	2.0538	2.2177	2.2177	2.2177	2.5873
23	2.0328	2.0328		2.2177	2.2177	2.2177	2.4025
24	2.0328	2.0328	1.9404	2.0328	2.0328	2.2177	2.2177
Max	2.5873	2.4272	2.4025	2.4025	2.4025	2.4025	2.6797
Min	1.6632	1.307	1.6632	1.7737	1.7375	1.7375	1.848
Avg	1.9743	1.9936	1.8983	2.0326	2.0147	2.0216	2.1692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 203 / 11 KV DEGLOOR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4025	2.5873	2.5873	2.7721	2.9569	2.5873	2.9569
2	2.4025	2.5873	2.2177	2.5873	2.9569	2.5873	2.9569
3	2.2177	2.4025	2.2177	2.5873	2.7721	2.5873	2.9569
4	2.4025	2.4025	2.2177	2.5873	2.7721	2.5873	2.5873
5	2.5873	2.4025	2.2177	2.5873	2.5873	2.5873	2.5873
6	2.5873	2.4025	2.2177	2.5873	2.5873	2.6139	2.5873
7	2.6139	2.7721	2.6139	2.5873	2.5873	2.6139	2.5873
8	2.6139	2.9569	2.6139	2.5873	2.7721	2.6139	2.5873
9	2.9569	3.3265	2.6139	2.9874	2.8006	2.6139	2.9874
10	2.9569		2.8006	2.9874	2.9874	2.9874	2.9569
11		3.5113	2.6139	2.9874	2.9569	2.9874	2.7721
12	2.5873	3.3265	2.5873	2.9569	2.7721	2.8006	2.7721
13	2.5873	3.3265	2.4025	2.6797		2.9874	2.5873
14	2.4025	2.7721	2.4025	2.5873	2.6139	2.6139	2.5873
15	2.4025	2.4025	2.4025	2.5606	2.3777	2.5606	2.4025
16	2.2177	2.5873	2.4025	2.6139	2.3777	2.5606	
17	2.4025	2.5873	2.4025	2.7721	2.5873	2.5873	2.5873
18		2.5873	2.5873	2.9569	2.5873	2.7721	2.9569
19	2.9569	3.3608	3.3265	3.3265	2.9569	3.3265	3.3265
20	2.7721	3.1741	3.1417	3.3265	3.3265	3.1417	3.3265
21	2.9569		2.7721	3.1417	3.1417	2.9569	2.9569
22	2.7721	2.9569	2.5873	2.9569	2.9569	2.9569	2.9569
23	2.7721	2.9569		2.9569	2.9569	2.9569	2.9569
24	2.4025	2.5873	2.7721	2.9569	2.9569	2.9569	2.9569
Max	2.9569	3.5113	3.3265	3.3265	3.3265	3.3265	3.3265
Min	2.2177	2.4025	2.2177	2.5606	2.3777	2.5606	2.4025
Avg	2.5897	2.8171	2.5530	2.8183	2.7978	2.7727	2.8216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 204 / 11 KV KHUDWAI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.848	1.848	1.5708	1.848	1.848	1.7556	1.848
2	1.848	1.848	1.4784	1.848	1.848	1.7556	1.848
3	1.6632	1.848	1.4784	1.848	1.848	1.7556	1.848
4	1.6632	1.848	1.4784	1.848	1.7909	1.7556	1.6632
5	1.7556	1.848	1.5708	1.848	1.848	1.7556	1.6632
6	1.848	2.0328	1.6804	1.848	1.848	1.8671	1.848
7	1.9605	2.0328	1.9605	1.848	2.0328	2.0538	2.0328
8	2.0538	2.4025	2.0538	2.0328	2.2177	2.2405	2.2177
9	2.0328	2.4025	1.8671	2.0538	2.0538	2.0538	2.1472
10	1.848		1.8671	2.0538	2.0538	1.8671	2.0538
11		2.4025	1.8671	2.0538	1.9404	1.9605	1.848
12	1.6632	2.2177	1.6632	1.848	1.8671	1.8671	1.848
13	1.4784	2.0328	1.4784	1.6632	1.6632	1.8671	1.5708
14	1.6632	2.2405	1.4784	1.4784		1.6632	1.4784
15	1.5708	2.4025	1.6632	1.5546	1.4632	1.6461	1.2936
16	1.4784	2.4025		1.587	1.5546	1.5546	
17	1.6632	1.6632	1.848	1.6632	1.7556	1.848	
18	1.848	1.848		1.848	1.9404	2.0328	1.848
19	1.848	2.3339	2.2177	2.0328		2.4025	3.3265
20	1.848	1.8671	2.0328	2.0328		2.0328	2.2177
21	1.848		1.848	1.848	1.848	2.0328	1.9404
22	1.848	1.6632	1.848	1.848	1.848	1.848	1.848
23	1.848	1.6632	1.848	1.848	1.848	1.848	1.848
24	1.848	1.848	1.848	1.848	1.848	1.848	1.848
Max	2.0538	2.4025	2.2177	2.0538	2.2177	2.4025	3.3265
Min	1.4784	1.6632	1.4784	1.4784	1.4632	1.5546	1.2936
Avg	1.7815	2.0316	1.7567	1.8429	1.8555	1.8880	1.9130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 202 / 11 KV WAJEGAON (OLD
TUPPA) Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	31-MAR-18	03-APR-18
HR	Load (MW)	Load (MW)
4	1.2323	
6	1.419	
8	1.419	1.4415
24	1.2323	1.2323
Max	1.419	1.4415
Min	1.2323	1.2323
Avg	1.3257	1.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 203 / 11 KV BHAGYLAXMI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0373			.0373		.0377
4	.0373	.0373		.0373		.0377
6	.0373	.0373		.0373		.0373
8	.0373	.0373		.0373	.037	.0373
9						.0373
10		.0373	.0373		.0373	
11			.0373			.0373
12		.0373				.0373
13			.0373			
14					.056	.0373
15			.0747			
16		.0373	.0747			.0373
17			.0747			
18		.0373			.0377	.0373
19			.0373			.0373
20		.0377	.0373		.0377	
21						.0373
22					.0377	
23		.0377	.0373			.0373
24	.0373	.0377		.0373	.0373	.0377
Max	.0373	.0377	.0747	.0373	.056	.0377
Min	.0373	.0373	.0373	.0373	.037	.0373
Avg	.0373	.0374	.0498	.0373	.0401	.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 204 / 11 KV CHOUPHALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1203	1.1317			1.1203		1.1317
4	1.1203		1.1827		1.307	1.1949	1.1317
6	1.4937		1.7741		1.8671	1.4937	.9335
7		1.8671					
8	1.587	1.8671	1.922		1.8671	1.922	1.2323
9	1.4937			1.9418			1.5684
10	1.307		1.307			1.419	
11				1.1203			1.1203
12			1.1203				.9709
13				1.1203			
14	.9335					1.0456	.9709
15				1.1203			
16			1.0082	1.1203			1.0269
17	1.0082			1.0269			
18						1.358	1.4003
19				1.4003			1.587
20	1.6221		1.5844	1.587		1.6975	
21							1.4937
22						1.358	
23	1.1317		1.1317	1.1203			1.2136
24	2.4272	1.1317	1.1949		1.1203	1.3443	1.1317
Max	2.4272	1.8671	1.922	1.9418	1.8671	1.922	1.587
Min	.9335	1.1317	1.0082	1.0269	1.1203	1.0456	.9335
Avg	1.3859	1.4994	1.3584	1.2842	1.4564	1.4259	1.2081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 207 / 11 Kv Water works
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	31-MAR-18	03-APR-18
HR	Load (MW)	Load (MW)
4	.4527	
6	.5228	
8	.8215	1.0456
24	.5281	.8962
Max	.8215	1.0456
Min	.4527	.8962
Avg	.5813	.9709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 201 / 11 KV NANAKSAR GAUTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2804	.3361		.3506		.3982
10				.3772			
16	.1402		.7011				.1402
17				.2534		.2534	
24		.1402	.2241	.2241	.1402		
Max	.1402	.2804	.7011	.3772	.3506	.2534	.3982
Min	.1402	.1402	.2241	.2241	.1402	.2534	.1402
Avg	.1402	.2103	.4204	.2849	.2454	.2534	.2692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 202 / 11 KV VIDYAPEETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4207			.4207		.4163
9				.4527			
16	.4908		.7011				.5609
17				.5249		.3982	
24		.3155		.415	.3506		
Max	.4908	.4207	.7011	.5249	.4207	.3982	.5609
Min	.4908	.3155	.7011	.415	.3506	.3982	.4163
Avg	.4908	.3681	.7011	.4642	.3857	.3982	.4886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 203 / 11 KV GANGABET

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4557			.5434		.6516
16	.3681		.3856				.2804
17				.3582		.5487	
24		.3506		.415	.3506		
Max	.3681	.4557	.3856	.415	.5434	.5487	.6516
Min	.3681	.3506	.3856	.3582	.3506	.5487	.2804
Avg	.3681	.4032	.3856	.3866	.447	.5487	.466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 204 / 11 KV PIMPALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				1.1919	1.9728
16	1.6651	1.6651			
17			1.9547		
24				.9114	
Max	1.6651	1.6651	1.9547	1.1919	1.9728
Min	1.6651	1.6651	1.9547	.9114	1.9728
Avg	1.6651	1.6651	1.9547	1.0517	1.9728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 205 / 11 KV KALESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.2629	.4706
16	.5258	.4908			
17			.5249		
24				.2103	
Max	.5258	.4908	.5249	.2629	.4706
Min	.5258	.4908	.5249	.2103	.4706
Avg	.5258	.4908	.5249	.2366	.4706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 206 / 11 KV PANGRA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	30-MAR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
8	.4207		
16			.4908
17		.5973	
24	.3155		
Max	.4207	.5973	.4908
Min	.3155	.5973	.4908
Avg	.3681	.5973	.4908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 208 / 11 KV GODAWARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.5434	.4344
16	.3506	.4908			
17			.4887		
24				.1753	
Max	.3506	.4908	.4887	.5434	.4344
Min	.3506	.4908	.4887	.1753	.4344
Avg	.3506	.4908	.4887	.3594	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 209 / 11 KV VISHNUPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.964			.7186		.9145
16	.5609		.5609				.5609
17				.6335		.5973	
24		.6135			.5609		
Max	.5609	.964	.5609	.6335	.7186	.5973	.9145
Min	.5609	.6135	.5609	.6335	.5609	.5973	.5609
Avg	.5609	.7888	.5609	.6335	.6398	.5973	.7377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 201 / 11 kV NAGAPUR G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7377				.6206	
2		.7377				.6571	
3		.7762			.6653	.6571	
4		.8916				.7316	
5		.9689				1.0041	
6		1.0082				1.1576	
7		1.1203				1.1576	
8		1.16	1.1925		1.1317	.9259	
9			1.0829	1.126		.8962	1.1203
10			1.1949	1.0851			.9297
11				.9729			.7762
12				.9335			.6639
13				.781			.5476
14				.6687			.5476
15				.6639			.6571
16	.924			.6639		.7095	.6979
17	1.0062						.7095
18	.9669				1.1203		
19	1.0082				1.1974		
20	.8148				.7278		
21	.6639				.7301		
22	.7377				.7301		
23	.7377				.6571		
24		.7377	.6264	.5544	.6219	.653	.479
Max	1.0082	1.16	1.1949	1.126	1.1974	1.1576	1.1203
Min	.6639	.7377	.6264	.5544	.6219	.6206	.479
Avg	.8574	.9043	1.0242	.8277	.8424	.8337	.7129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 202 / 11 kV PUNEGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.4952	
2					1.5509	
3				1.9113	1.7004	
4					1.84	
5					1.907	
6					2.1509	
7					2.532	
8				2.4539	1.7456	
9		2.2436	2.3552		2.2801	2.0073
10		2.5789				
16	2.3312					
17	1.8244					
18	2.3152					
19	2.3259					
24			1.5089	1.1469	1.331	1.4402
Max	2.3312	2.5789	2.3552	2.4539	2.532	2.0073
Min	1.8244	2.2436	1.5089	1.1469	1.331	1.4402
Avg	2.1992	2.4113	1.9321	1.8374	1.8533	1.7238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 203 / 11 kV TUPPA AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3777					
2		.3777					
3		.3777					
4		.4102					
5		.4102					
6		.4102					
7		.5389					
8		.5734	.4694				
11				.5706			.6371
12				.5409			.6371
13				.506			.673
14				.4744			.6409
15				.4744			.6409
16				.6052	.5302	.6516	.6386
17					.5415		
18					.5415		
23	.3132						
24		.3768	.3521				
Max	.3132	.5734	.4694	.6052	.5415	.6516	.673
Min	.3132	.3768	.3521	.4744	.5302	.6516	.6371
Avg	.3132	.4281	.4108	.5286	.5377	.6516	.6446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 204 / 11 kv New Wajegaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9669				1.0424	
2		.9649				1.0021	
3		.963			.9335	1.0021	
4		1.0062				1.0785	
5		1.0434				1.2323	
6		1.1949				1.3096	
7		1.3512				1.3887	
8		1.6221	1.4146		1.3169	1.6188	
9			1.358	1.4089		1.4937	1.3498
10			1.4335	1.5059			1.3123
11				1.4277			1.1974
12				1.3123			1.1203
13				1.1949			1.0807
14				1.1203			1.0807
15				1.1203			1.0807
16	1.1541			1.1203	1.0424	1.1949	1.0807
17	1.1576				1.2748		1.2449
18	1.315				1.4682		
19	1.5028				1.6975		
20	1.2348				1.3901		
21	1.1949				1.2373		
22	1.0062				1.1203		
23	1.0062				1.0807		
24		.9669	.9679	.8589	.8871	1.0807	.9679
Max	1.5028	1.6221	1.4335	1.5059	1.6975	1.6188	1.3498
Min	1.0062	.963	.9679	.8589	.8871	1.0021	.9679
Avg	1.1965	1.1199	1.2935	1.2299	1.2226	1.2222	1.1515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 205 / 11 kv Injegaon AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.2373	
2					1.3123	
3				1.773	1.4262	
4					1.5812	
5					1.6941	
6					1.8107	
7					2.1924	
8				1.9239	2.1546	
9		1.9616			1.5844	1.4998
10		2.1502				
16	2.3057					
17	2.0165					
18	2.1285					
19	1.7551					
20	1.8671					
21	1.7142					
22	1.7551					
24			1.4937	1.3306	1.0829	1.2567
Max	2.3057	2.1502	1.4937	1.9239	2.1924	1.4998
Min	1.7142	1.9616	1.4937	1.3306	1.0829	1.2567
Avg	1.9346	2.0559	1.4937	1.6758	1.6076	1.3783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 206 / 11Kv MARATHWADA EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4567				.4567	
2		.4567				.4567	
3		.4207			.4557	.4567	
4		.3848				.4918	
5		.3848				.4929	
6		.4577				.5281	
7		.494				.6011	
8		.494	.481		.5121	.5316	
9			.4755	.495		.5853	.6037
10			.5853	.6024			.5316
11				.6024			.7133
12				.5304			.6392
13				.5304			.5304
14				.5316			.5304
15				.494			.5304
16	.444			.495	.5902	.6584	.5304
17	.5682				.6037		.6219
18	.642				.5316		
19	.642				.5316		
20	.6063				.6037		
21	.5682				.5316		
22	.5304				.5304		
23	.494				.4577		
24		.494	.4435	.4435	.4115	.4577	.4422
Max	.642	.494	.5853	.6024	.6037	.6584	.7133
Min	.444	.3848	.4435	.4435	.4115	.4567	.4422
Avg	.5619	.4493	.4963	.5250	.5236	.5197	.5674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 201 / 11 KV R.T.O.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.6097	.6097	.6097	.4954	.6478	.4572
2	.7621	.6097	.5335	.6097	.4954	.6478	.4572
3	.7621	.6097	.5335	.6097	.4954	.6478	.4572
4	.724	.6097	.5335	.6097	.4954	.6478	.4572
5	.724	.6097	.5335	.6097	.4954	.6478	.4572
6	.6859	.6097	.5335	.6097	.6097	.6478	.6097
7	.5335	.6097	.5335	.6097	.6097	.6478	.6097
8	.4954	.5716	.6859	.5716	.5716	.6097	.6097
9	.4954	.724	.7621	.6097	.7621	.6478	.6097
10	.5716	.9907	1.0288	.8383	1.086	1.1241	1.0669
11	.6478	1.1431	1.1241	.8383	1.2574	1.3336	1.3717
12	.6478	1.1812	1.105	.9907	1.3527	1.3717	1.3717
13	.6859		1.0288	.8383	1.0669	1.0669	1.2955
14	.6097		1.0669	.8383	1.0669	1.2765	1.0669
15	.6478		1.0669	.9907	1.105	1.2384	1.2955
16	.6478		1.1812	.8383	1.0669	1.3336	1.448
17	.5716	.8383	1.0669	.9526	1.0479		1.3336
18	.4572		.9907	.8383	1.0479	.9907	1.1812
19	.5716	.7621	.8383	.6859	.9145	.9145	1.0479
20	.6097	.6859	.6097	.6097	.6859	.7621	.8002
21	.6668	.6859	.6097	.4954	.6097	.6097	.6859
22	.6859	.6097	.5716	.4954	.6478	.6859	.6859
23	.6859	.6097	.5335	.4954	.6478	.6859	.6859
24	.724	.6859	.6097	.6097	.4954	.6478	.6097
Max	.8002	1.1812	1.1812	.9907	1.3527	1.3717	1.448
Min	.4572	.5716	.5335	.4954	.4954	.6097	.4572
Avg	.6422	.724	.7788	.7002	.7970	.8623	.8613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 202 / 11 KV NANDED FLOOR MILL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.7621	.3048	.381	.4001	.381	.3048
2	.724	.7621	.3048	.381	.4001	.381	.3048
3	.724	.7621	.3048	.381	.4001	.381	.3048
4	.724	.7621	.3048	.381	.4763	.381	.3048
5	.724	.7621	.3048	.381	.4763	.381	.3048
6	.7049	.8002	.5716	.4001	.7049	.5144	.8383
7	.7621	1.0479	.6097	.6478	.724	.5144	.7621
8	.6668	.9526	.5716	.6097	.6097	.6287	.7621
9	.724	.9907	.7049	.5335	.5716	.5335	.7621
10	.5906	1.1431	.8002	.7621	.8383	.4382	.6097
11	.5906	1.5051	.9335	.7621	.7621	.3239	.9145
12	.5144		.9717	.7621	.7621	.3239	.7621
13	.5335		.9526	.7621	.724	.3239	.6097
14	.6668		1.0669	.7621	.8954	.4191	.5335
15	.6478		1.105	.8383	.9526	.5716	.6859
16	.6668		1.1622	.6859	.7049	.6668	.4572
17	.6668	.8383	1.0098	.7621	.7621		.381
18	.6668		.6097	.6478	.5525	.5335	.3239
19	.724	.3048	.4001	.4001	.3429	.3048	.3239
20	.724	.3048	.362	.4001	.362	.3048	.3429
21	.7621	.3048	.743	.4001	.3429	.3048	.3429
22	.7621	.3048	.381	.4001	.3429	.3048	.3429
23	.7621	.3048	.381	.4001	.381	.3048	.3429
24	.7049	.7621	.3048	.381	.4001	.381	.3048
Max	.7621	1.5051	1.1622	.8383	.9526	.6668	.9145
Min	.5144	.3048	.3048	.381	.3429	.3048	.3048
Avg	.6851	.7430	.6319	.5509	.5787	.4175	.4969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 203 / 11 KV GODAWARI DRUG
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.7167	.5281	.5304	.5121	.7922	.5975
2	.8299	.7167	.5228	.5601	.5121	.7922	.5975
3	.8299	.7167	.5228	.5975	.5175	.7922	.5975
4	.8299	.7095	.5228	.5975	.5175	.7922	.5975
5	.8299	.7095	.5228	.5975	.5175	.7842	.5975
6	.7922	.5175	.5228	.5544	.5487	.7922	.679
7	.811	.462	.5228	.4733	.5068	.811	.679
8	.7922	.547	.439	.5121	.5068	.811	.679
9	.811	.4854	.5121	.439	.547	.8299	.679
10	.7922	.5228	.5544	.5121	.6224	.7842	.679
11	.7733	.4805	.5544	.5121	.5975	.7468	.6722
12	.8383		.5975	.5121	.679	.7545	.7468
13	.8573		.5544	.5175	.5544	.7545	.6722
14	.8299		.5175	.5175	.5544	.7545	.7545
15	.7202		.5228	.5175	.2469	.7545	.679
16	.8299		.4908	.5175	.3163	.7545	.679
17	.8383	.2591	.5601	.5914	.5359		.7167
18	.8383		.6224	.5121	.5304	.679	.7545
19	.8299	.5281	.5975	.5121	.6602	.679	.7468
20	.7922	.5281	.5975	.5175	.4706	.679	.7468
21	.7922	.5281	.6413	.5121	.4344	.679	.7468
22	.7545	.5281	.5788	.5175	.5249	.6722	.7545
23	.7545	.5281	.5194	.5175	.7468	.6722	.7468
24	.811	.7545	.5281		.5175	.7468	.6653
Max	.8573	.7545	.6413	.5975	.7468	.8299	.7545
Min	.7202	.2591	.439	.439	.2469	.6722	.5975
Avg	.8087	.5688	.5439	.5282	.5282	.7525	.6860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 201 / 11 KV ASARJAN GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2926			.3109		
6				.4024		
7					.4557	
8			.3898	.4207	.4382	.4031
9				.3544		
10		.3292	.3109		.3292	
11					.2561	
12		.2279	.2629			
14		.2103	.2658		.2378	
15		.2481			.2561	
16	.2658	.2629	.3012	.2835		
18			.3189			.3658
19						.3658
20			.3721			.3658
21						.3475
22			.3292			.3475
23			.3109			.3292
24	.2743		.3012	.2926	.3224	.3045
Max	.2926	.3292	.3898	.4207	.4557	.4031
Min	.2658	.2103	.2629	.2835	.2378	.3045
Avg	.2776	.2557	.3163	.3441	.3279	.3537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 202 / 11 KV KOUTHA GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	1.2071			1.2437		
6				1.3535		
7					1.5424	
8			1.5592	1.5729	1.7177	1.4373
9				1.382		
10		1.39	1.4529		1.3169	
11					1.2437	
12		1.0985	1.39			
14		1.1694	1.1694		1.2071	
15		1.1218			1.134	
16	1.134	1.2048	1.2757	1.2048		
18			1.3466			1.2803
19						1.4632
20			1.5238			1.5364
21						1.5364
22			1.5364			1.5364
23			1.4998			1.5364
24	1.2437		1.3112	1.3535	1.4685	1.4327
Max	1.2437	1.39	1.5592	1.5729	1.7177	1.5364
Min	1.134	1.0985	1.1694	1.2048	1.134	1.2803
Avg	1.1949	1.1969	1.4065	1.3517	1.3758	1.4699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 203 / 11 KV AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.2012			.0732		
6				.0732		
7					.4382	
8			.2629	.2378	.4557	.4252
9				.3155		
15		.0532				
16	.0709	.0709	.0351	.0701		
18			.0354			.0732
19						.0732
20			.0549			.0732
21						.0732
22			.0549			.0732
23			.0366			.128
24	.2195		.2149	.0732	.1791	.1433
Max	.2195	.0709	.2629	.3155	.4557	.4252
Min	.0709	.0532	.0351	.0701	.1791	.0732
Avg	.1639	.0621	.0992	.1405	.3577	.1328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 204 / Sahayog G.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.3292			.4755		
6				.5121		
7					.5609	
8			.4207	.2561	.5784	.5258
9				.2149		
10		.5487	.3898		.2926	
11					.2835	
12		.4961	.4607			
14		.2103	.5121		.2926	
15		.2804			.6219	
16	.4207	.2481	.5316	.2804		
18			.3544			.5487
19						.5121
20			.3224			.3658
21						.3292
22			.2561			.3292
23			.2561			.3292
24	.3292		.3224	.2561	.5373	.3898
Max	.4207	.5487	.5316	.5121	.6219	.5487
Min	.3292	.2103	.2561	.2149	.2835	.3292
Avg	.3597	.3567	.3826	.3325	.4525	.4162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174131 / 33kv kakandi s/s

Feeder No / Name : 201 / 11 KV JAMRUN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2561	.2439				
2	.2229	.2561	.2439				
3	.2229	.2241	.2439				
4	.2229	.2241	.2743				
5	.2229	.2241	.2743				
6	.2401	.2241	.2743				
7	.2915	.2561	.3048				
8	.2915	.2881	.3048				
11				.2743	.3258	.2134	.2743
12				.2743	.2229	.2439	.2743
13				.3048	.2743	.2743	.2743
14				.2743	.3086	.2743	.2439
15				.2743	.3258	.2743	.2439
16				.3048	.3258	.2743	.2439
17				.3048	.3258	.2743	.2896
18				.3048	.2743	.2743	
23	.2241	.2439					
24	.2229	.2561	.2439				
Max	.2915	.2881	.3048	.3048	.3258	.2743	.2896
Min	.2229	.2241	.2439	.2743	.2229	.2134	.2439
Avg	.2385	.2453	.2676	.2896	.2979	.2629	.2635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174131 / 33kv kakandi s/s

Feeder No / Name : 202 / 11 KV KAKANDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	1.4251	1.2193				
2	1.3565	1.3927	1.2193				
3	1.3565	1.4091	1.2193				
4	1.4074	1.4575	1.3108				
5	1.4255	1.4251	1.3108				
6	1.5083	1.4737	1.3108				
7	1.7368	1.5223	1.5242				
8	1.6549	1.5546	1.4632				
11				1.7375	1.7804	1.587	1.6461
12				1.768	1.8896	1.8138	1.7375
13				1.768	1.8679	1.8138	1.7985
14				1.7375	1.8351	1.8299	.2743
15				1.7071	1.8023	1.8299	
16				1.7071	1.7532	1.8138	1.5242
17				1.6461	1.8023	1.749	
18				1.5242	1.8023	1.749	
20							.1219
23	1.2597	1.1584					
24	1.3565	1.4251	1.2193				
Max	1.7368	1.5546	1.5242	1.768	1.8896	1.8299	1.7985
Min	1.2597	1.1584	1.2193	1.5242	1.7532	1.587	.1219
Avg	1.4419	1.4244	1.3108	1.6994	1.8166	1.7733	1.1838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV REST HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.8671	1.8671	1.8671	1.8671	1.8671	1.6804
2	1.6804	1.6804	1.7737	1.8671	1.8671	1.6804	1.6804
3	1.6804	1.6804	1.7737	1.6804	1.6804	1.6804	1.587
4	1.4937	1.3717	1.6804	1.6804	1.6804	1.6804	1.587
5	1.4937	1.4937	1.6804	1.6804	1.6804	1.6804	1.587
6	1.4937	1.4937	1.8671	1.587	1.6804	1.6804	1.587
7	1.587	1.7737	1.8671	1.6804	1.7737	1.6804	1.587
8	1.4937	1.8671	1.7737	1.6804	1.8671	1.6804	1.6804
9	1.4937	1.6804	1.587	1.6804	1.6804	1.587	1.6804
10	1.4937	1.587	1.4937	1.6804	1.587	1.4937	1.6804
11	1.4937	1.587	1.6804	1.6804	1.6804	1.4937	1.6804
12	1.4937	1.6804	1.6804	1.587	1.6804	1.4937	1.6804
13	1.4937	1.6804	1.6804	1.587	1.6804	1.4784	1.6804
14	1.587	1.587	1.6804	1.6804	1.6804	1.4784	1.6804
15	1.6804	1.587	1.6804	1.6804	1.6804	1.5708	1.7737
16	1.6804	1.6804	1.7737	1.6804	1.6804	1.5708	1.587
17	1.6804	1.6804	1.8671		1.8671	1.8671	1.8671
18	1.7737	1.8671	1.7737		2.0538	1.8671	1.8671
19	1.8671	1.8671	2.2405		2.1472	2.1472	2.2405
20	1.8671	1.8671	2.2405	2.2405	2.1472	2.1472	2.0538
21	1.8671	1.8861	2.0538	2.0538	2.1691	1.9605	2.0538
22	1.8671	1.8671	2.0538	2.1472	2.1472	1.9605	2.2405
23	1.8671	2.1472	2.0538	2.0538	2.0538	2.0538	2.2405
24	1.8671	1.8671	1.8671	2.0538	1.8671	1.9605	1.8671
Max	1.8671	2.1472	2.2405	2.2405	2.1691	2.1472	2.2405
Min	1.4937	1.3717	1.4937	1.587	1.587	1.4784	1.587
Avg	1.6609	1.7228	1.8204	1.7871	1.8291	1.7400	1.7854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.9335	1.0269	1.0269	1.0269	1.0269	1.0269
2	1.0269	.9335	1.0269	.9335	.9335	1.0269	1.0269
3	1.0269	.9335	.9335	.9335	.9335	.9335	.9335
4	.9335	.9335	.9335	.9335	.9335	.9335	.9335
5	.9335	.9335	.9335	.9335	.9335	.9335	.9335
6	.9335	.9335	.9335	.9335	1.0269	.9335	.9431
7	.9335	.9335	.9335	.8573	1.0269	.9335	1.0164
8	.9335	1.1203	.9335	.9335	1.307	.9335	1.1203
9	.9335	1.1203	.9335	1.0269	1.1203	.9335	1.0269
10	.9335	1.0269	.9335	1.0269	.9335	.8402	1.0269
11	.9335	.9335	.9335	1.0269	.9335	.8402	1.0269
12	.9335	.9335	.9335	1.0269	.9335	1.0269	1.0269
13	.9335	.9335	.9335	.9335	.9335	1.0164	1.0269
14	.9335	.9335	.9335	.9335	1.1203	1.0164	1.0269
15	1.1203	.9335	.9335	.9335	1.1203	1.1088	1.0269
16	1.1203	.9335	1.0269	.9335	1.1203	1.1088	1.1203
17	.9335	1.0269	1.0269		1.0269	1.0269	1.1203
18	1.0269	1.1203	1.1203		1.1203	1.1203	1.2136
19	1.1203	1.307	1.307		1.2136	1.307	1.307
20	1.307	1.307	1.307	1.4937	1.2136	1.2136	1.307
21	1.1203	1.2136	1.1203	1.307	1.2136	1.2012	1.307
22	1.1203	1.2136	1.1203	1.2136	1.1203	1.1203	1.307
23	1.1203	1.2136	1.1203	1.307	1.1203	1.1088	1.307
24	1.1203	1.0269	1.1203	1.1203	1.1203	1.1203	1.1203
Max	1.307	1.307	1.307	1.4937	1.307	1.307	1.307
Min	.9335	.9335	.9335	.8573	.9335	.8402	.9335
Avg	1.0230	1.0347	1.0191	1.0366	1.0619	1.0319	1.0930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 203 / 11 KV MGM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605	1.8671	2.0538		2.0538	2.0538	1.8671
2	1.8671	1.8671	1.8671	2.0538	1.8671	1.8671	1.8671
3	1.8671	1.8671	1.8671	1.8671	1.8671	1.6804	1.8671
4	1.8671	1.8671	1.7737	1.8671	1.8671	2.0538	1.8671
5	1.8671	1.8861	1.9605	1.8671	2.0538	2.2405	1.8671
6	1.8671	2.0538	2.0538	2.0538	2.2405	2.3339	1.9605
7	1.8671	2.1472	2.1472	2.1472	2.2405	2.0538	2.0538
8	1.8671	2.0538	2.1472	2.0538	2.0538	1.7737	1.9605
9	1.8671	2.0538	1.8671	1.9605	1.8671	1.6804	1.8671
10	1.8671		2.0538	1.8671	1.8671	1.587	1.8671
11	1.7737	1.8671	2.0538	1.7737	2.0538	1.6804	1.8671
12	1.7737	1.8861	2.0538	1.7737	2.0538	1.8671	1.7737
13	1.8671	2.0538	2.0538	1.7737	2.0538	1.848	1.7737
14	1.8671	2.0538	2.0538	1.8671	2.0538	1.7556	1.8671
15	2.0538	2.0538	2.0538	1.8671	2.0538	1.848	1.8671
16	2.0538	2.0538	2.1472	1.8671	2.2405	1.848	2.1472
17	2.0538	2.0538	1.9605		2.4272	1.8671	2.2405
18	2.0538	2.2405	2.0538		2.4272	1.8671	2.2405
19	2.2405	2.3339	2.4272		2.3339	2.2405	2.4272
20	2.2405	2.2405	2.4272	2.7073	2.3339	2.2405	2.6139
21	2.2405	2.2405	2.4272	2.4272	2.3339	2.2177	2.4272
22	2.2405	2.2405	2.4272	2.2405	2.2405	2.3339	2.6139
23	2.2405	2.2405	2.4272	2.4272	2.2405	2.3101	2.4272
24	1.9605	2.0538	2.1472	2.2405	2.2405	2.2405	2.2405
Max	2.2405	2.3339	2.4272	2.7073	2.4272	2.3339	2.6139
Min	1.7737	1.8671	1.7737	1.7737	1.8671	1.587	1.7737
Avg	1.9760	2.0555	2.1044	2.0351	2.1277	1.9787	2.0655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 204 / 11 KV DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7468	.7468	.7468	.7468	.8402	.8402
2	.6535	.6535	.6535	.6535	.6535	.7468	.7468
3	.6535	.6535	.6535	.6535	.6535	.7468	.7468
4	.6535	.6535	.5601	.5601	.5601	.7468	.7468
5	.6535	.6535	.5601	.5601	.5601	.7468	.7468
6	.6535	.6535	.6535	.6535	.7468	.7468	.7392
7	.6535	.7468	.6535	.5601	.6535	.6535	.6535
8	.6535	.6535	.6535	.5601	.6535	.6535	.6535
9	.5601	.6535	.5601	.4668	.6535	.5601	.5601
10	.5544	.6535	.5601	.4668	.6535	.5601	.5601
11	.5601	.5601	.4668	.5601	.5601	.5601	.6535
12	.5601	.5601	.4668	.6535	.5601	.5601	.6535
13	.5601	.5601	.5601	.6535	.5601	.6468	.6535
14	.5601	.5601	.6535	.6535	.5601	.6468	.6535
15	.5601	.3734	.6535	.6535	.5601	.6468	.6535
16	.5601	.5601	.6535	.6535	.6535	.6468	.6535
17	.5601	.5601	.6535		.8402	.6535	.6535
18	.5601	.6535	.6535		.8402	.6535	.6535
19	.7468	.7468	.7468		.8402	.7468	.7468
20		.7468	.7468	1.0269	.8402	.8402	.8402
21	.7468	.8402	.7468	.9335	.8402	.8402	.8402
22	.7468	.8402	.8402	.9335	.8402	.8402	.9335
23	.7468	.8402	.7468	.9335	.8402	.9335	.9335
24	.7468	.7468	.7468	.7468	.8402	.8402	.9335
Max	.7468	.8402	.8402	1.0269	.8402	.9335	.9335
Min	.5544	.3734	.4668	.4668	.5601	.5601	.5601
Avg	.6370	.6613	.6496	.6801	.6963	.7107	.7271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 205 / 11KV NAGARJUNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.6804	1.6804	1.6804	1.6804	1.6804	1.7737
2	1.6804	1.6804	1.587	1.5432	1.6804	1.6804	1.6804
3	1.6804	1.6804	1.587	1.4937	1.4937		1.6804
4	1.6804	1.6804	1.4937	1.4937	1.4937	1.8671	1.6804
5	1.7737	1.8671	1.6804	1.6804	1.6804	1.8671	1.8671
6	1.8671	1.8671	1.7737	1.8671	2.0538	2.0538	2.0328
7	1.9605	2.0538	1.9605	2.0538	2.1472	1.9605	2.1253
8	2.1472	2.2405	1.9605	2.0538	2.0538	1.9605	2.0538
9	1.8671	1.9605	1.7737	1.8671	1.8671	1.8671	1.8671
10	1.7556	1.7737	1.4937	1.7737	1.6804	1.587	1.8671
11	1.4937	1.4937	1.4003	1.6804	1.4003	1.4937	1.6804
12	1.307	1.587	1.4003	1.4937	1.307	1.307	1.4937
13	1.307	1.4937	1.4003	1.4937	1.2003	1.2936	1.4003
14	1.307	1.307	1.307	1.4003	1.307	1.2936	1.4003
15	1.2136	1.307	1.307	1.4003	1.307	1.2936	1.4003
16	1.2136	1.1203	1.307	1.4937	1.4003	1.2936	1.4003
17	1.307	1.4937	1.307		1.6804	1.4937	1.4937
18	1.4937	2.0538	1.4937		1.8671	1.6804	1.6804
19	1.8671	2.2405	1.8671		2.1472	1.9605	1.9605
20	1.8671	2.0538	1.8671	2.2405	2.0538	1.9605	1.9605
21	1.8671	1.8671	1.8671	2.0538	1.9605	1.9605	1.9605
22	1.8671	1.8861	1.8671	1.9605	1.8671	1.9605	1.8671
23	1.8671	1.7737	1.8671	1.8671	1.7737	1.8671	1.8671
24	1.6804	1.6804	1.6804	1.6804	1.8671	1.7737	1.8671
Max	2.1472	2.2405	1.9605	2.2405	2.1472	2.0538	2.1253
Min	1.2136	1.1203	1.307	1.4003	1.2003	1.2936	1.4003
Avg	1.6563	1.7434	1.6220	1.7272	1.7071	1.7024	1.7525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 201 / 11 KV RLY DIVISION
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.112	.132	.1132	.0914	.112
2	.1132		.0934	.132	.1132	.0914	.0934
3	.1132		.0934	.1132	.1132	.0914	.0934
4	.0943		.0747	.0943	.0943	.0914	.0934
5			.0747	.0943	.0943	.0914	.0934
6	.0943		.0747	.0943	.0754		.0934
7	.1132		.112	.1132	.0754		.0747
8	.1132		.0934	.0943	.1132		.0934
9	.0566		.056	.0943	.1132		.0934
10	.0934		.0566	.056	.0943	.1509	.0943
11	.0934		.0566	.056	.0943	.0943	.0943
12	.1494		.0566		.0943	.0943	.0943
13	.0747		.0566		.0943	.0943	.0943
14	.112		.0566	.1307	.1132	.0943	.1132
15	.112		.0943	.1307	.132	.132	.1509
16	.1867		.0943	.1307	.1509	.1509	.1509
17	.1509	.112	.1132		.1463	.1307	.1698
18	.1509	.112	.1132		.1463	.1494	.1698
19	.1509	.1307	.1132			.168	.1698
20	.1509	.1494	.132	.132		.1494	.1698
21	.1509	.1307	.132	.1509		.1494	.132
22	.132	.112	.1509	.1509	.1097	.1307	.1509
23	.132	.112	.1509	.1509	.1097	.1494	.1509
24	.132	.1132	.1307	.1509	.132	.0914	.1307
Max	.1867	.1494	.1509	.1509	.1509	.168	.1698
Min	.0566	.112	.056	.056	.0754	.0914	.0747
Avg	.1210	.1215	.0955	.1159	.1106	.1193	.1199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 202 / 11 KV CHAITNYA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8564	1.9109	1.9433	2.1948	1.9757
2	1.6194		1.7652	1.7814	1.8623	2.1948	1.8404
3	1.5384		1.749	1.749	1.7814	2.0119	
4	1.5384		1.7284	1.749	1.9433	2.0119	1.7604
5	1.5384		1.7166	1.7814	2.1862	1.829	1.7284
6	1.7004		1.8461	1.7814	2.3482		1.7604
7	1.9433		1.9204	1.9433	2.4291		1.9524
8	2.0243		2.0243	2.0405	2.2996		1.9364
9	2.0243			1.9433	1.9109		1.8244
10	1.8244		1.7004	2.0081	1.8138	1.8461	1.8138
11	1.6842		1.6194	1.8404	1.7166	1.587	1.749
12	1.6356		1.6032	1.7284	1.6194	1.5384	1.6842
13	1.7166		1.3765	1.6324	1.6194	1.4575	1.6842
14	1.6194		1.2955	1.7604	1.6518	1.5384	1.7166
15	1.6518		1.6194	1.8084	1.6842	1.749	1.6518
16	1.6518		1.6194	1.6964	1.7166	1.7004	1.6518
17	1.7004	1.6518	1.6842		1.829	1.7124	1.6518
18	1.7166	1.6842	1.749		1.829	1.8138	1.749
19	2.0081	2.0405	2.0243			2.1538	2.0729
20	2.1052	2.0645	2.0729	2.3967		2.17	2.4291
21	2.0729	2.0165	2.0729	2.332		2.2024	2.3967
22	2.1052	2.0805	2.1052	2.3644	2.4691	2.2085	2.3967
23	2.0405	2.0645	2.1376	2.3967	2.4691	2.2405	2.332
24	1.9433	1.9757	1.9845	2.0405	2.1052	2.1948	2.1376
Max	2.1052	2.0805	2.1376	2.3967	2.4691	2.2405	2.4291
Min	1.5384	1.6518	1.2955	1.6324	1.6194	1.4575	1.6518
Avg	1.8001	1.9473	1.7944	1.9374	1.9632	1.9178	1.9085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 203 / 11 KV MAHALAJ - SANGVI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145		1.0059	1.0242	1.0974	1.1888	.9955
2	.9145		.9694	1.0242	1.0059	1.1888	.9511
3	.9145		.9145	.9511	1.0059	1.1888	.9511
4	.9145		.9145	.9511	.9145	1.1888	1.0059
5	1.0974		1.2071	1.0608	.9145	1.1888	1.134
6	1.3717		1.6827	1.3169	1.3717		1.3535
7	1.4266		1.7375	1.6827	1.4632		1.5729
8	1.4266		1.39	1.4632	1.3169		1.6278
9	1.1888			1.39			1.5364
10	1.0791		1.3169	1.3032		1.2071	1.2254
11	.9328		1.1888	1.1706	1.2437	1.0974	1.134
12	1.0791		1.0608	1.0974	1.1706	1.0608	.8413
13	1.0425		1.0059	.9511	.9877	1.134	.8779
14	.8779		.9145		1.1888	1.0974	.9511
15	.6219		.8413			1.0242	1.0242
16	1.0608		.9145	1.1706		1.134	1.0242
17	1.1706	1.0242	1.134			1.2254	1.0242
18	1.1706	1.1888	1.2437			1.2803	1.3169
19	1.3535	1.4449	1.4632		1.4632	1.3169	1.5729
20	1.3169	1.39	1.4632	1.2071	1.4632	1.4266	1.5364
21	1.2803	1.39	1.39	1.2437		1.4266	1.4815
22	1.2803	1.134	1.2071	1.3203	1.2803	1.3352	1.2803
23	1.2449	1.1946	1.0974	1.3169	1.2803	1.0974	1.1706
24	1.0059	1.1706	1.0136	1.0608	1.134	1.1888	1.0974
Max	1.4266	1.4449	1.7375	1.6827	1.4632	1.4266	1.6278
Min	.6219	1.0242	.8413	.9511	.9145	1.0242	.8413
Avg	1.1119	1.2421	1.1772	1.1950	1.1942	1.1998	1.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 205 / 11 KV AIRPORT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305		.0366	.0343	.0305	.0366	.0366
2	.0305		.0366	.0343	.0305	.0366	.0366
3	.0305		.0366	.0343	.0305	.0366	.0366
4	.0305		.0366	.0343	.0305	.0366	.0366
5	.0305		.0366	.0343	.0305	.0366	.0366
6	.0305		.0366	.0343	.0305		.0366
7	.0305		.0366	.0343	.0305		.0366
8	.0305		.0366	.0343	.0305		.0366
9				.0343	.0457		.0549
10	.0914		.0457	.0732	.0686	.0457	.0686
11	.0366		.061	.0732	.0686	.0457	.0686
12	.0366		.061	.0732	.0514	.0457	.0686
13	.0366		.061	.0732	.0686	.0305	.0686
14	.0549		.061	.0914	.0686	.0457	.0514
15	.0366		1.5242	.0549	.0343	.0305	.0514
16	.0366		.0305	.0366	.0343	.0305	.0343
17	.0343	.0366	.0343		.0293	.0366	.0343
18	.0343	.1097	.0343		.0293	.0366	.0343
19	.0343	.0366	.0514			.0366	.0343
20	.0366	.037	.0514	.0305		.0366	.0343
21	.0343	.0366	.0857	.0305		.0366	.0343
22	.0343	.037	.1029	.0305	.0366	.0366	.0343
23	.0377	.037	.1029	.0305	.0366	.0366	.0362
24	.0305	.0343	.0366	.0343	.0305	.0293	.0366
Max	.0914	.1097	1.5242	.0914	.0686	.0457	.0686
Min	.0305	.0343	.0305	.0305	.0293	.0293	.0343
Avg	.0369	.0456	.1146	.0448	.0403	.0371	.0432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 206 / 11KV GADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.132	.1829	.0892
2					.1829	.0892
3				.132	.1829	.104
4				.1698	.1829	.104
5				.1698	.1829	.1189
6				.1698		.1486
7				.1886		.1783
8				.1886		.1932
9	.2452			.1886		.1783
10	.2315	.2641				
11	.3549	.2829	.208			
12	.3567	.2829	.2378			
13	.3418	.2829	.2378			
14	.2229	.2829	.1932			
15	.208	.2641	.1932			
16	.1932	.2452	.1932			
24				.132	.1829	.0892
Max	.3567	.2829	.2378	.1886	.1829	.1932
Min	.1932	.2452	.1932	.132	.1829	.0892
Avg	.2693	.2721	.2105	.1635	.1829	.1293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 207 / 11Kv Asana River Express
Feeder Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	04-APR-18
HR	Load (MW)
15	.1372
20	.1402
Max	.1402
Min	.1372
Avg	.1387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 201 / 11 KV MAHAVEER SOCIETY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3696	.3734	.3696	.3696	.3734
2	.3734	.3734	.3696	.3734	.3696	.3696	.3734
3	.3734	.3734	.3696	.3734	.3696	.3696	
4	.3734	.3734	.3696	.3734	.3696	.3696	.3734
5	.3734	.3734	.3696	.3734	.3696	.462	.3734
6	.3734	.3734	.4668	.3734	.3696	.5601	.3734
7	.5658	.6535	.5658	.4668	.5601	.5658	.4668
8	.5658	.6535	.5658	.5601	.5601	.5658	.5658
9	.5658	.6535	.6602	.5601	.5601	.6602	.5658
10	.5601	.6602	.5658	.6468	.5658	.5658	.5601
11	.4668	.6602	.4668	.5601	.5658	.4668	.5601
12	.5601	.6602	.4668	.5601	.4668	.3734	.4668
13	.5601	.5658	.3734	.4668	.4668	.3734	.3734
14	.3734	.4715	.3734	.4668	.3734	.3734	.3734
15	.3734	.3734	.3734	.4668	.3734	.3734	.3734
16	.3734	.3734	.3734	.4668	.3734	.3734	.3734
17	.5601	.4668	.4668	.4668	.4668	.4668	.4668
18	.5601	.5658	.5601	.5601	.5601	.5658	.6535
19	.5601	.5658	.6602	.5601	.6535	.6602	.6535
20	.5601	.5601	.5658	.5601	.5601	.5658	.6535
21	.5601	.4668	.4668	.5601	.4668	.4668	.5601
22	.5228	.4668	.3734	.4668	.4668	.3734	.4668
23	.3734	.3734	.3734	.4668	.3696	.3734	.3734
24	.3734	.3734	.3696	.3734	.3696	.3696	.3734
Max	.5658	.6602	.6602	.6468	.6535	.6602	.6535
Min	.3734	.3734	.3696	.3734	.3696	.3696	.3734
Avg	.4698	.4919	.4557	.4782	.4582	.4597	.4673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 202 / 11 KV SHIVAJI NAGAR ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.9431	1.0374	1.0374	.9431	1.226	1.226
2	.9431	.9431	1.0374	.9431	.9431	1.226	1.1317
3	.9431	.9431	1.0374	.9431	.9431	1.1317	1.0374
4	.9431	.9431	1.0374	.9431	.9431	1.1317	1.0374
5	.9431	.9431	1.0374	.9431	.9431	1.1317	1.0374
6	1.0374	.9431	1.1317	.9431	1.0374	1.226	1.0374
7	1.0374	1.0374	1.3203	1.0374	1.1317	1.3203	1.0374
8	1.0374	1.0374	1.226	1.1317	1.1317	1.3203	1.1317
9	1.0374	1.0374	1.0374	1.0374	1.0374	1.1317	1.1317
10	.9431	1.1317	1.0374	1.1317	1.1317	1.0269	1.3203
11	1.1317	1.1317	1.0374	1.1317	1.1317	1.1203	1.3203
12	1.226	1.226	1.0374	1.1317	1.226	1.1203	1.3203
13	1.226	1.226	1.1317	1.226	1.226	1.2136	1.3203
14	1.226	1.1317	1.1317	1.226	1.226	1.2136	1.3203
15	1.226	1.1317	1.1317	1.226	1.226	1.2136	1.3203
16	1.226	1.1317	1.1317	1.226	1.226	1.2136	1.3203
17	1.226	1.226	1.1317	1.226	1.3203	1.2136	1.3203
18	1.226	1.307	1.226	1.3203	1.3203	1.3203	1.5089
19	1.4146	1.4937	1.4146	1.3203	1.5089	1.5089	1.6032
20	1.4146	1.4146	1.4146	1.4146	1.5089	1.3203	1.6032
21	1.4003	1.4146	1.4146	1.4146	1.4146	1.3203	1.5089
22	1.3203	1.3203	1.4146	1.4146	1.4146	1.3203	1.5089
23	1.3203	1.3203	1.3203	1.3203	1.3203	1.3203	1.5089
24	1.1317	1.1317	1.226	1.226	1.1317	1.3203	1.3203
Max	1.4146	1.4937	1.4146	1.4146	1.5089	1.5089	1.6032
Min	.9431	.9431	1.0374	.9431	.9431	1.0269	1.0374
Avg	1.1508	1.1462	1.1710	1.1631	1.1828	1.2338	1.2889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 203 / 11 KV INDUSTRIAL AREA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3239	.4382	.5201	.4287	.4382	.443
2	.4191	.3239	.4287	.4287	.4287	.4287	.4334
3	.4191	.3239	.4287	.4287	.4239	.4287	.4287
4	.4191	.3353	.4334	.4287	.4239	.4239	.4287
5	.4191	.3353	.4334	.4287	.4239	.4287	.4287
6	.4191	.3353	.4334	.4287	.4239	.4334	.4287
7	.4191	.4382	.4287	.5201	.4525	.443	.4334
8	.4287	.4382	.4477	.5316	.462	.5487	.443
9	.4382	.5258	.4572	.5373	.5487	.5487	.5487
10	.5601	.6602	.6602		.7545	.6602	.9431
11	.5601	.8488	.8488	.6602	.8488	.9431	.9431
12	.6602	.9431	.8488	.6602	.9431	.9431	.9431
13	.6602	.9431	.8488	.6602	.9431	1.0374	.9431
14		.8488	.9431	.6602	.8488	1.0374	.9431
15	.9431	.8488	.9431	.6468	.9431	.9431	.9431
16	.9431	.9431	.9431	.7392	.9431	.9431	.9431
17	.9431	.9431	.9431	.7392	.9431	.9431	.9431
18	.9431	.8488	.9431	.7545	.9431	1.0374	.9431
19	.8488	.8488	.9431	.7545	.9431	.9431	.9431
20	.7468	.7545	.9431	.6468	.8488	.8488	.8488
21	.6535	.7545	.8488	.5544	.7545	.7468	.6602
22	.5487	.6535	.7468	.5544	.5544	.6401	.6602
23	.543	.5487	.7316	.5487	.5487	.543	
24	.4382	.3506	.4477	.6268		.543	.543
Max	.9431	.9431	.9431	.7545	.9431	1.0374	.9431
Min	.4191	.3239	.4287	.4287	.4239	.4239	.4287
Avg	.6001	.6299	.6880	.5852	.6859	.7031	.7026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 204 / I.T.M. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.5601	.5658	.5601	.5658	.6602
2	.5658	.5601	.5601	.5658	.5601	.5658	.5658
3	.5658	.5601	.5601	.5658	.5601	.5658	
4	.5658	.5601	.5601	.5658	.5601	.5658	.5658
5	.5658	.5601	.5601	.5658	.5658	.5658	.5658
6	.5658	.5601	.5601	.5658	.5658	.5658	.5658
7	.5658	.5601	.5601	.5658	.6602	.5658	.5658
8	.5658	.5601	.5601	.5658	.6602	.5658	.5658
9	.5658	.6535	.7545	.5658	.6535	.6602	.6602
10	.6602	.7468	.7545			.6602	.7545
11	.6602	.7468	.8488	.9335	.8402	.9431	.7545
12	.7545	.7468	.8488	.9431	.9335	.9431	.9431
13	.7545	.9431		.9431	.9335	.9431	.9431
14	.8488	.9431		.9431	.9335		.9431
15	.8488	.9431		.924	.9335	1.0374	.9431
16	.8488	.9431		.924	.9335	1.0374	.9431
17	.8488	1.0374		.924	.9335	1.0374	.9431
18	.8488	.924		.924	.9335	1.0374	.9431
19	.8402	.9335	.9431	.924	.9431	1.0374	.9431
20	.8488	.9335	1.0374	.9335	.9431	.9431	.9431
21	.8488	.8488	.9431	.8402	.9431	.8488	.7545
22	.6602	.7468	.7545	.8402	.8488	.7545	.7545
23	.6602	.7468	.7545	.7468	.7545	.7545	.7468
24	.5658	.5658	.6535	.6602	.5601	.7545	.7545
Max	.8488	1.0374	1.0374	.9431	.9431	1.0374	.9431
Min	.5658	.5601	.5601	.5658	.5601	.5658	.5658
Avg	.6912	.7454	.7096	.7607	.7701	.7791	.7705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 201 / 11 KV Yashwant Nagar
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.5373	.4481	.3887	.583	.4481	.5228
2	.3361	.5373	.4108	.5601	.5487	.4481	.5228
3	.3361	.5731	.4108	.4854	.463	.4481	.4481
4	.3361	.5731	.4481	.4854	.4973	.4481	.3734
5	.3361	.5731	.4854	.4854	.4973	.4854	.3734
6	.2987	.5731	.5228	.2614	.463	.5228	.4481
7	.2987	.5731	.5788	.3361	.6687	.5041	.5228
8	.2987	.5731	.4854	.3734	.6516	.4854	.5228
9	.2987	.6447	.5228	.4854	.4287	.5228	.5228
10	.543	.6348	.4481	.4854	.4115	.5228	.5228
11		.4854	.4481	.4578	.4854	.4854	
12		.4481	.3734	.463	.4481	.5601	
13		.4481	.5601	.4458	.4481	.6653	.4287
14	.1086	.4481	.4481	.4287	.4854	.3734	.6687
15	.1086	.4854	.3734	.4458	.4854	.3734	.6344
16	.1448	.4108	.1867	.5487	.4481	.2987	.5487
17	.1448	.4481	.1867	.2401	.4481	.1867	.2915
18	.1448	.4854	.5601	.3086	.4108	.7392	
19	.4656	.4481	.6653	.4115	.4108	.7023	.4409
20	.6447	.4854	.3361	.4115	.3734	.7023	.4115
21	.6447	.4108	.5601	.5658	.3734	.6283	.4578
22	.6447	.4481	.6653	.5658	.4481	.2987	.5426
23	.6089	.4854	.6283	.5765	.4481	.5601	.4748
24	.3018	.6089	.4854	.6283	.583	.4854	.6283
Max	.6447	.6447	.6653	.6283	.6687	.7392	.6687
Min	.1086	.4108	.1867	.2401	.3734	.1867	.2915
Avg	.3514	.5141	.4683	.4519	.4795	.4956	.4908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 202 / 11 KV NASARADPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5014	.4481	.4481	.439	.4481	.4108
2	.4481	.4298	.4481	.4108	.3982	.4481	.4108
3	.4481	.4298	.4481	.4108	.3982	.4481	.3734
4	.4481	.3982	.4481	.4108	.4344	.4481	.3734
5	.4481	.3982	.4481	.2614	.4525	.4854	.4481
6	.4854	.5373	.5228	.4481	.4887	.5228	.4854
7	.5228	.5373	.5601	.5228	.5249	.5788	.5228
8	.5601	.4656	.4854	.5601	.5792	.5601	.5601
9	.5228	.6805	.4854	.5914	.6335	.5975	.5914
10	.4706	.6348	.5228	.5601	.6154	.5228	.5975
11		.5975	.4854	.5068	.5975	.4108	
12		.5601	.4481	.4706	.5601	.4481	
13		.4854	.4481	.4887	.5228	.4108	.6584
14	.5373	.4481	.4854	.5068	.5228	.4108	.6154
15	.5373	.4481	.5228	.4887	.4854	.4481	.5611
16	.6089	.4854	.5228	.5068	.4854	.4854	.5792
17	.6447	.5228	.5601	.5068	.5228	.5914	.5249
18	.6447	.5975	.5975	.5611	.5975		.7059
19	.6805	.6348	.5914	.5792	.6348	.6653	.6516
20	.6805	.6348	.5601	.5973	.5975	.6283	.6335
21	.6089	.5601	.5228	.543	.5601	.5601	.5792
22	.6089	.5601		.5249	.5228	.5228	.5068
23	.5731	.5228	.4854	.4938	.4854	.4854	.4755
24	.4854	.5373	.4481	.4481	.4344	.4481	.4481
Max	.6805	.6805	.5975	.5973	.6348	.6653	.7059
Min	.4481	.3982	.4481	.2614	.3982	.4108	.3734
Avg	.5434	.5253	.4998	.4936	.5206	.5033	.5324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 203 / 11 KV Dnyaneshwar Wadi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.3432	1.307	1.5203	1.5203	1.531	1.5927
2	1.4937	1.2894	1.307	1.448	1.448	1.531	1.5203
3	1.4937	1.2894	1.307	1.448	1.3394	1.531	1.448
4	1.4937	1.7013	1.307	1.448	1.3756	1.531	1.448
5	1.4937	1.8267	1.307	1.5203	1.5203	1.531	1.5565
6	1.7924	1.8804	1.4563	1.5927	1.829	1.7924	1.6289
7	1.9418	1.9342	2.0165	1.7909	1.9547	2.0165	1.8625
8	2.0538	1.9342	1.7924	1.97	1.9909	1.8671	2.0416
9	1.9418	1.8267	1.6804	1.8625	1.7013	1.7177	1.8983
10	1.7909	1.8298	1.5565	1.7013	1.5565	1.448	1.6289
11		1.7924	1.448	1.5565	1.531	1.3394	
12		1.7177	1.3394	1.448	1.4937	1.4118	
13		1.6057	1.3394	1.448	1.4563	1.448	1.6108
14	1.3969	1.5684	1.3032	1.4842	1.419	1.5203	1.5927
15	1.3611	1.419	1.3394	1.4266	1.307	1.5927	1.5384
16	1.3969	1.3443	1.3756	1.3575	1.4563	1.6289	1.5565
17	1.576	1.7177	1.448	1.4118	1.531	1.5203	1.6289
18	1.7193	1.8298	1.5203	1.5927	1.6057	1.6289	1.6832
19	1.7551	1.9044	1.6289		1.7924	1.8625	1.8461
20	1.97	1.7924	1.6651		1.7177	1.8983	1.9185
21	2.0595	1.7177	1.6651	1.8461	1.6804	1.8267	1.8823
22	1.7909	1.6804	1.6289	1.7556	1.6057	1.7909	1.8461
23	1.6118	1.6057	1.5203	1.6651	1.6057	1.7375	1.8642
24	1.4937	1.4327	1.4937	1.5927	1.5746	1.5684	1.6651
Max	2.0595	1.9342	2.0165	1.97	1.9909	2.0165	2.0416
Min	1.3611	1.2894	1.3032	1.3575	1.307	1.3394	1.448
Avg	1.6724	1.6660	1.4897	1.5858	1.5839	1.6363	1.6936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 204 / 11 KV FARANDE NAGAR - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.5731	.7095		.8688	.7468	
2	.6535	.5731	.5601		.8326	.7468	
3	.6535	.5731	.5601		.7602	.7468	
4	.6535	.8059	.5601		.7602	.7468	
5	.6535	.8238	.5601		.7964	.7468	
6	.8962	.8238	.7842		.7783	.8589	
7	.9335	.8596	.8962		.8326	.8962	
8	.9709	.8596	.7842		.9593	.7842	
9	.8589	.8954	.7468		.8326	.7468	
10	.788	.8589			.6878		
11		.8215		.695	.6722		
12		.8215		.6697	.6348		
13		.7468		.6697	.5975		.6697
14	.6805	.7095		.6878	.7095		.7602
15	.6805	.6348		.7059	.5975		.8145
16	.7164	.6722		.7602	.6348		.8413
17	.7522	.7468		.7783	.6722		.7783
18	.7522	.8589		.7602	.7468		.7059
19	.7164	.8962		.9231	.8589		.8145
20	.6805	.8589		.905	.9709		.8869
21	.6805	.7095		2.9502	.9335		.9955
22	.6089	.6722		.9774	.8962		.9774
23	.5731	.5975		.9231	.8589		1.0136
24	.7095	.5731	.5601		.8688	.7842	
Max	.9709	.8962	.8962	2.9502	.9709	.8962	1.0136
Min	.5731	.5731	.5601	.6697	.5975	.7468	.6697
Avg	.7269	.7486	.6721	.9543	.7817	.7804	.8416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 205 / 11 KV Vijay Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1104	1.1203	1.086	1.1946	1.1203	1.1946
2	1.1203	1.1104	1.1203	1.086	1.0852	1.1203	1.1584
3	1.1203	1.1104	1.1203	1.0608	1.1222	1.1203	1.1584
4	1.1203	1.3032	1.1203	1.0242	1.1222	1.1203	1.086
5	1.1203	1.4327	1.1203	1.086	1.2489	1.1203	1.1946
6	1.307	1.4327	1.4563	1.1946	1.3032	1.4563	1.3394
7	1.419	1.4327	1.8671	1.448	1.4118	1.8671	1.4842
8	1.6057	1.4327	1.7177	1.6289	1.5546	1.8298	1.5203
9	1.5684	1.5402	1.6057	1.5565	1.4449	1.4377	1.448
10	1.448	1.4563	1.3394	1.448	1.3394	1.267	1.4118
11		1.4003	1.086	1.3213	1.307	1.1946	
12		1.307	1.0242	1.1584	1.2696	1.1946	
13		1.2696	1.0608	1.1584	1.1576	1.1584	1.1888
14	1.1641	1.2136	1.086	1.134	1.1203	1.1584	1.1584
15	1.0745	1.1576	1.086	1.1523	1.0829	1.1222	1.1041
16	1.0745	1.1203	1.1222	1.1222	1.1949	1.1222	1.086
17	1.2178	1.1576	1.1222	1.1584	1.2696	1.086	1.0679
18	1.2536	1.2696	1.3394		1.307	1.3032	1.0317
19	.4656	1.4563	1.6289	1.3575	1.643	1.6651	1.4118
20	1.3611	1.531	1.5565	1.4299	1.6221	1.6651	1.5384
21	1.3253	1.3443	1.3394	1.4118	1.531	1.5203	1.5364
22	1.3253	1.307	1.267	1.39	1.419	1.3756	1.4299
23	1.2536	1.2136	1.1946	1.3394	1.307	1.3032	
24	1.1576	1.1584	1.1203	1.1584	1.2308	1.2136	1.267
Max	1.6057	1.5402	1.8671	1.6289	1.643	1.8671	1.5384
Min	.4656	1.1104	1.0242	1.0242	1.0829	1.086	1.0317
Avg	1.2201	1.3028	1.2759	1.257	1.3037	1.3142	1.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 201 / 11 KV LIMBGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0373	.0373	.2896	.1315	.2229
2		.0373	.0373	.0373	.2896	.1334	.2229
3		.0373	.0373	.0373	.2896	.1353	.2972
4		.0373	.0373	.0373	.3715	.1372	.2972
5					.4344	.2972	.2896
6					.4801	.4572	.5201
7					.5792	.7621	.7716
8					.5792	.6687	.5068
9			.362		.4801	.4344	.3668
10		.6687	.4458	.5401			
11		.6773	.5335	.5201			
12		.6687	.602	.4344			
13		.7526	.5944	.4458			
14	.4458	.6173	.4458	.4515			
15		.6173	.4515	.4515			
16	.4401	.5411	.5944	.5268			
17				.4515			
18				.3715			
19	.0373	.0373	.037	.0373	.0373	.037	.037
20	.0373	.0373	.0373	.0373	.0373	.037	.037
21	.0373	.0373	.0373	.0373	.0377	.0373	.0373
22	.0373	.0373	.0373	.0373	.0377	.0373	.0373
23	.0373	.0373	.0373	.0373	.0377	.0373	.0373
24		.0373	.0373	.0373	.0373	.1315	.1505
Max	.4458	.7526	.602	.5401	.5792	.7621	.7716
Min	.0373	.0373	.037	.0373	.0373	.037	.037
Avg	.1532	.2892	.2446	.2403	.2679	.2316	.2554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 202 / 11 KV CHUDAWA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373		.1715	.2667	.4001
2	.0373	.0373	.0373		.1867	.2667	.4668
3	.0373	.0373	.0373		.1867		.4601
4	.0373		.0373		.2572	.3429	.4534
5					.4458	.3429	.4534
6					.5201	.4868	.7145
7					.7526	.8916	.9659
8					.7526		.8459
9	.8069		.724	.7145	.6763	.5411	.6859
10	.724	.743	.5792	.9259	.6763		
11	.8688	.7049		.8688	.6087		
12	.8688	.8688	.724	.7859	.6259		
13	.8688	.8688	.2858		.5335		
14	.6859	.6859	.5487	.7049			
15	.6878	.6859	.7649	.6954			
16	.7754	.7754	.8345	.7049			
17				.6173			
18				.5487			
19	.0373	.056	.0747	.0373	.0747	.0373	.056
20	.0373	.056	.0747	.0373		.0373	.056
21	.0373	.056	.0747	.0373	.056	.0373	.0373
22	.0373	.056	.0747	.0373	.056	.0373	.0373
23	.0373	.0373	.056	.056	.056	.0373	.0373
24		.0373	.0373	.056	.056	.1315	.4058
Max	.8688	.8688	.8345	.9259	.7526	.8916	.9659
Min	.0373	.0373	.0373	.0373	.056	.0373	.0373
Avg	.3895	.3590	.2943	.4552	.3718	.2659	.4050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 204 / 11 KV TALNI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3544	.3944	.4334	.056	.0566	.0373
2	.3944	.3544	.3829	.4334	.056	.0566	.0373
3	.3944	.4601	.3715	.4468	.056	.0566	.0373
4	.5335	.5258	.503	.4468	.056	.0566	.0373
5	.6573	.6001	.5744	.5258			
6	.7859	.6859	.7888	.8459			
7	.724	.6859	1.0717	1.0269			
8	.6173	.7754	.9736	.904			
10					.8802	.4058	.6259
11					1.0269	.8459	.7545
12					.8459	.6668	.6859
13						.5916	.6573
14						.5106	.6573
15						.5916	.6001
16						.6763	.6087
17					.6763	.6001	.6001
18					.8116		
19	.056	.0373	.0747	.056	.4058	.056	
20	.056	.0373	.0747	.056	.3601	.056	.0747
21	.056	.0373	.0747	.056	.0566	.056	.0747
22	.056	.0373	.0747	.056	.0566	.056	.0747
23	.3544	.3944	.3658	.056	.0566	.056	.0747
24	.3944	.3544	.3944	.4268	.056	.0566	.0554
Max	.7859	.7754	1.0717	1.0269	1.0269	.8459	.7545
Min	.056	.0373	.0747	.056	.056	.056	.0373
Avg	.391	.3814	.4371	.4121	.3638	.3029	.3349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 205 / 11 KV LIMBGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3734	.3734	.4572	.4668	.4668	.3734
2	.3696	.3734	.3734	.4572	.4668	.4668	.3734
3	.3696	.3696		.4572		.4668	.3734
4	.4668	.4668	.4668	.462	.5601	.4668	.3696
5	.5601	.5601	.5658	.5544	.7468	.5658	.5601
6	.8402	.7468	.7468	.6468	.7468	.7545	.7468
7	.9431	.9335	.9335	.7468	.8402	.9431	.9335
8	.9335	.9335	.8402		.7468	.8488	.8402
9	.6535	.6535	.5601	.7545	.6535	.6535	.7392
10	.5601	.5601	.5487		.3696	.4572	.5601
11	.1867	.3734	.362	.3658	.3772	.2772	.4668
12	.1867	.3734		.2743	.2743	.2801	.4668
13	.3734	.3734	.362	.2743	.3582	.2801	.3734
14	.3734	.3734	.362	.2772	.4525	.2743	.3734
15	.3734	.3734	.362	.2743	.4525	.2743	.3734
16		.3734	.3658	.2743	.4572	.3658	.3734
17	.5601	.362	.3658	.3658	.4668	.6468	.5601
18	.6535	.5487	.3658	.5487	.5601	.6401	.6535
19	.7468	.7468	.5487	.6401	.6535	.7392	.7468
20	.5601	.5544	.5487	.6535	.5601	.5544	.6535
21	.4668	.4668		.5601	.3734	.3734	.5601
22	.3734	.3734		.4668	.4668	.2801	.3734
23	.3734	.3734		.4668	.4668	.2801	.3734
24	.3696	.3734	.3734	.4572	.4668	.4668	.3734
Max	.9431	.9335	.9335	.7545	.8402	.9431	.9335
Min	.1867	.362	.362	.2743	.2743	.2743	.3696
Avg	.5071	.5004	.4960	.4743	.5210	.4926	.5246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 205 / 11KV PIMPALGAON GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823		.8573
2		.823		.8573
3		.9602		.9602
4		1.2003		1.2003
5		1.3717		1.3717
6		1.3717		
10	1.0288	.9945	.8573	
11	.9602	.823	.8573	
12	.8916	.7545	.7545	
13	.7202	.6516	.7888	
14	.6859	.583	.7888	
15	.6859	.6516	.8383	
16	.6859	.6173	.7202	
17	.7888		.7202	
18	.8916		.7545	
19	.9259		.9602	
20	1.0631		.9602	
21	1.0288		.9602	
22	.8916		.8916	
23	.8573		.8573	
24		.823		.8573
Max	1.0631	1.3717	.9602	1.3717
Min	.6859	.583	.7202	.8573
Avg	.8647	.8892	.8364	1.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 202 / 11 KV JAITAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373				.2801	.3734	
2	.0373		.0373	.037	.2801	.3734	.3696
3	.0373				.3361		
4	.0373	.0381	.0373	.037	.3361	.4668	.462
5					.3734	.5601	
6					.4108	.5601	.5544
7					.5601	.6535	
8							.7392
9			.5601				.6535
10	.6287	.5601					
11		.6535		.6535			
12		.6535		.7095			
13		.5601		.8402			
14		.5601		.8402			
15		.5601		.7468			
16	.6668	.5601		.7468			
17				.7095			.0373
18				.6535		.037	.0373
19		.0373		.0373	.0373		.0373
20		.0373		.0373	.0373	.037	.0373
21		.0373		.0373	.0373		
22		.0373		.0373	.0373	.037	.0373
23	.0381	.0373	.037	.0373	.0373	.037	.0373
24	.0373	.0381	.0373	.037	.2801	.2801	.2772
Max	.6668	.6535	.5601	.8402	.5601	.6535	.7392
Min	.0373	.0373	.037	.037	.0373	.037	.0373
Avg	.1900	.3122	.1418	.3873	.2341	.3105	.2733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 203 / 11 KV PIMPALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601		.5601		.0373	.0373	
2	.6535		.5601	.5544	.0373	.0373	.037
3	.7095				.0373	.0373	
4	.7095	.6668	.5601	.6468	.0373	.0373	.037
5	.7468		.6535				
6	.7468		.7468	.7392			
7	.7842		.7468				
8	.7621	.7621	.6535	.7392			
11					.5601	.6468	.7468
12					.7468	.7392	.8402
13							.8402
14					.7468	.7392	.7842
15					.7468		.7468
16						.7392	.7468
17	.0381	.0373		.0377	.6535		.7842
18		.0373		.0373	.6535	.7392	.7468
19		.0373		.0373	.0373		.0373
20		.0373		.0377	.0373	.037	.0373
21				.0373			.0373
22		.0373		.0373	.0373	.037	.0373
23	.5716	.4668	.462	.0373	.0373	.037	.0373
24	.4668	.6097	.5601	.5544	.0373	.0373	.037
Max	.7842	.7621	.7468	.7392	.7468	.7392	.8402
Min	.0381	.0373	.462	.0373	.0373	.037	.037
Avg	.6135	.2991	.6114	.2913	.2962	.3001	.4083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 204 / 11 KV SUGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0373		.6535		
2	.0373			.037	.7468	.7468	.8316
3	.0373		.0373		.7468	.9335	
4	.0373	.0381		.037	.8402		1.1088
5					.9335	1.1203	
6					1.4003	1.307	1.2936
7					1.531	1.4937	
8							1.4784
9			1.1203				1.4937
10	1.4289	1.4003					
11		1.4937		.9335			
12		1.4003		1.2136			
13		1.307		1.2696			
14		1.307		1.307			
15		1.2136		1.4003			
16	1.4289	1.2136		1.307			
17				1.2696			.0373
18				1.1203		.037	
19		.0373		.0373	.0373		.0373
20		.0373		.0373	.0373	.037	.0373
21				.0373	.0373		.0373
22		.0373		.0373	.0373	.037	.0373
23	.0381	.0373	.037	.0373	.0373	.037	.0373
24	.0373	.0381	.0373	.037	.3734	.4668	.5544
Max	1.4289	1.4937	1.1203	1.4003	1.531	1.4937	1.4937
Min	.0373	.0373	.037	.037	.0373	.037	.0373
Avg	.3853	.7355	.2538	.6324	.5702	.6216	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 205 / 11 KV NALESHWAR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468		.6348		.7468	.7842	
2	.7468		.7095	.7762	.8402	.7468	.7392
3	1.0269		.7468		.8962		
4	1.307	1.1241	.8215	1.0164	1.0269	1.0456	.924
5	1.4937		1.1203		1.2696	1.1576	
6	1.587		1.3443	1.4784	1.4937	1.2696	1.386
7	1.587		1.4937		1.4563	1.4003	
8	1.5623	1.5623	1.4003	1.6632			1.386
9			1.307	1.4784	1.4937		1.4937
10	1.105	1.251		1.4003		1.2197	1.3443
11		.8962		1.0269	1.0082	.924	.7468
12		.7468		.8402		.8131	.7468
13		.6348		.7468	.6722		.5975
14		.5975		.7095	.7095	.6283	.6535
15		.7095		1.0269	.7468		.7842
16	.8764	.8589		1.0269	1.0269	.8686	.8962
17	1.0288	.9335		1.1203	1.0829		.9335
18		.9709		1.2136	1.1576	1.2012	1.1576
19		1.3443		1.4563	1.4003		1.307
20		1.4563		1.307	1.3443	1.1088	1.307
21		1.1576		1.0269	1.0082		1.0269
22		.8215		.9335	.7842	.8686	.9335
23	.8002	.7842	.8316	.7468	.7468	.8316	.8402
24	.7468	.7621	.7468	.7392	.7468	.7095	.7392
Max	1.587	1.5623	1.4937	1.6632	1.4937	1.4003	1.4937
Min	.7468	.5975	.6348	.7095	.6722	.6283	.5975
Avg	1.1242	.9771	1.0142	1.0867	1.0313	.9736	.9972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 201 / 11KV MUGAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7762	.6859	.6859	.7468	.7392	.6859
2	.6859	.8131	.6859	.6859	.7468	.7023	.6859
3	.6859	.8501	.6859	.7545	.7468	.6653	.9602
4	.823	.961	.7545	.823	.9335	.7762	1.0288
5	1.0288	1.2197	.9602	1.0288	1.1576	.924	1.3717
6	1.4403	1.5524	1.4937	1.5089	1.643	1.1827	1.6461
7	1.6461	1.5524	1.4403	1.5089	1.7177	1.4045	1.7147
8	1.3717	1.4784	1.5684	1.5775	1.4937	1.3306	1.3717
9	1.4045	1.3443	1.3032	1.2346	1.1949	1.166	1.3306
10	1.3676	1.1949	1.0974	1.1949	1.0456	1.0288	1.1827
11	1.3306	.9709	.8916	.8962	.7392	.7545	.924
12		.7468	.6859	.5975	.6653	.6859	.8131
13	.6653	.7095	.5487	.5975	.6653	.6173	.7392
14	.6653	.6722		.6348	.6653	.6173	.6653
15	.6653	.7095	.6859	.6722	.7468	.6173	.6653
16	.8131	.8215	.7545	.7842	.8215	.6173	.7392
17		.9709	.823	1.0456	.961	1.0974	.8501
18	1.1088	1.0456	1.3032	1.1203	1.1088	1.2346	.961
19	1.1088	1.419	1.3717	1.2696	1.1088	1.3717	1.0349
20	1.1088	1.1949	1.166	1.2696	1.0349	1.0974	1.0719
21	.924	.9709	.823	1.0456	.961	1.0288	1.0349
22	.8131	.8215	.7545	.8215	.8871	.7545	.8131
23	.8131	.7842	.6859	.7842	.7392	.7545	.7392
24	.6859	.7762	.7468	.6859	.7468	.7392	.6859
Max	1.6461	1.5524	1.5684	1.5775	1.7177	1.4045	1.7147
Min	.6653	.6722	.5487	.5975	.6653	.6173	.6653
Avg	.9928	1.0148	.9529	.9678	.9699	.9128	.9881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 202 / 11 KV MATASAB AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5914	.6173	.583			
2	.6173	.5914	.6173	.583			
3	.6173	.5914	.6173	.6173			
4	.6173	.6283	.6173	.6173			
5	.6173	.6283	.6516	.6173			
6	.6173	.6283	.7392	.6859			
7	.6859	.7392	.6859	.6859			
8	.6859	.7392	.7392	.6859			
11					.6283	.7545	.7392
12					.7023	.7545	.8871
13					.6653	.7545	.8871
14					.6653	.7545	.8501
15					.6653	.7545	.8501
16					.7023	.7545	.8131
17					.6283	.6859	.8131
18					.5914	.6097	.7392
23	.5914	.5914	.583				
24	.6173	.5914	.6653	.583			
Max	.6859	.7392	.7392	.6859	.7023	.7545	.8871
Min	.5914	.5914	.583	.583	.5914	.6097	.7392
Avg	.6284	.6320	.6533	.6287	.6561	.7278	.8224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 203 / 11 KV AMDURA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1848		.2058	1.4937	1.3306	1.2346
2	.1715	.1848	.2058	.2058	1.7924		1.2346
3	.2058	.2218	.2058	.2401	1.7924	1.4045	1.3032
4	.2058	.2218	.2401	.2743	1.9605	1.848	1.3717
5	.2743	.2957	.2401	.2743	1.9605	1.848	1.7147
6	.2743	.2957	.2683	.2743	2.1125	2.0698	1.989
7					2.2405	2.1437	2.2634
8					2.3152	2.2177	2.4508
9	2.3655	2.4646	1.7147	2.3011	2.3152	2.0576	2.3899
10	2.4394	1.7177	1.7833	2.4143			
11	2.5133	2.4646	1.3717	2.452			
12	2.5133	2.4646	1.3032	2.452			
13	1.848	2.4272	1.5775	2.4897			
14	2.2916	2.3899	2.0576	2.4272			
15	2.2916	2.3899	2.1262	2.4646			
16	2.3655	2.3899	2.1948	2.2405			.1494
17				2.2405	.2241	.1829	.2241
18				2.2405	.2218	.2058	.2218
19					.2218		.2241
20					.2218		.2218
21	.1478	.1677	.1715	.1509	.2218		.2218
22	.1848	.2012	.1715	.1509	.2218		.2241
23	.1848	.2012	.1715	.1677	.2218		.2241
24	.1715	.1848	.2012	.2058	1.1203	1.1827	
Max	2.5133	2.4646	2.1948	2.4897	2.3152	2.2177	2.4508
Min	.1478	.1677	.1715	.1509	.2218	.1829	.1494
Avg	1.1456	1.1593	.9415	1.2936	1.2152	1.4992	1.0390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 201 / 11 KV TRIKUT AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1317	.9945	.9945
2					1.166	.9945	1.0631
3					1.2003	1.0288	1.0974
4						1.0974	1.166
5					1.2346	1.286	1.2003
6					1.2689	1.3717	1.3032
7					1.3717	1.406	1.406
8					1.3717	1.4403	1.5432
9	1.4403	1.3108	.9945	1.3717	1.4403	1.6461	1.4746
10	1.3108	1.3717	1.0974	1.5775			
11	1.3565	1.4327	1.286	1.6118			
12	1.3717	1.4784	1.3717	1.6461			
13	1.4022	1.5089	1.5775	1.5089			
14	1.4327	1.4327	1.5432	1.6461			
15	1.4175	1.4022	1.5432	1.6461			
16	1.4022	1.326	1.5432	1.6118			
24					1.0288	.9259	.9602
Max	1.4403	1.5089	1.5775	1.6461	1.4403	1.6461	1.5432
Min	1.3108	1.3108	.9945	1.3717	1.0288	.9259	.9602
Avg	1.3917	1.4079	1.3696	1.5775	1.246	1.2191	1.2209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 202 / 11 KV MATASAB GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2401	.2401	.2715	.2401	.2572	.2401
2	.2743	.2401	.2401	.2572	.2401	.2715	.2401
3	.2743	.2401	.3086	.3086	.2743	.2715	.2743
4	.3086	.3429	.4115	.4287	.3429	.4287	.3429
5	.4115	.463	.5487	.5487	.4124	.4287	.4115
6	.6173	.6687	.703	.6859	.6516	.6154	.6516
7	.6859	.6173	.6859	.6516	.6516	.6173	.6859
8	.6516	.6344	.6001	.5144	.5487	.5487	.6173
9	.5487	.5144	.5144	.4458	.4458	.4801	.4801
10	.3772	.3772	.4287	.3429	.4115	.3772	.3429
11	.2915	.3429	.3429	.2743	.3772	.2743	.3086
12	.2743	.2572	.2572	.2401	.3429	.2058	.2915
13	.2743	.2572	.2058	.2058	.3086	.2058	.3086
14	.2915	.2743	.2058	.2058	.2401	.2401	.2915
15	.3086	.2743	.2572	.2401	.2743	.2743	.3086
16	.3086	.2915	.3086	.2743	.3429	.3086	.3429
17	.3429	.3944	.415	.3772	.3772	.3772	.3772
18	.3772	.4115	.4344	.4115	.4287	.5144	.4458
19	.4115	.4458	.4115	.5144	.3772	.583	.4801
20	.4458	.4458	.4115	.4458	.3429	.5144	.4115
21	.3772	.3429	.3982	.3772	.3429	.4115	.3772
22	.3258	.3086	.3429	.3086	.362	.3429	.3429
23	.2401	.2915	.3086	.2743	.2572	.3086	.3258
24	.2743	.2401	.2743	.2572	.2572	.2058	.2743
Max	.6859	.6687	.703	.6859	.6516	.6173	.6859
Min	.2401	.2401	.2058	.2058	.2401	.2058	.2401
Avg	.3736	.3715	.3856	.3692	.3688	.3776	.3822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 203 / 11 KV MUGHAT RLY STN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0288	1.2003	1.1145	.2229	.2452	.2229
2	.9945	1.0288	1.2346	1.1145	.2229	.2229	.2229
3	.9945	1.0631	1.2689	1.2003	.2229	.2229	.2232
4	1.0288	1.0974	1.3375	1.286	.2229	.2229	.2229
5	1.0288	1.1317	1.3717	1.286	.2229	.2229	.2229
6	1.2346	.8573	1.3889	1.3032	.2229	.2229	.2229
7	1.5432	1.5432	1.3717	1.6461			
8	1.5775	1.5432	1.4918	1.4403			
11					1.2003	1.5089	1.4746
12					1.286	1.5775	1.4403
13					1.3717	1.5089	1.4575
14					1.4575	1.4746	1.4232
15	.2378	.2378	.2058		1.3717	1.3717	1.4403
16	.2378	.2378	.2229	.2229	1.4575	1.406	1.4232
17	.2378	.2378	.2229	.2229	1.5432	1.3717	1.406
18	.2378	.2229	.2229	.2229	1.3717	1.3717	1.3717
19	.2378	.2229	.2229	.2229			
20	.2378	.2229	.2229	.2229	.2229		
21	.2378	.2229	.2229	.2229	.2229	.2229	
22	.2378	.2229	.2229	.2229	.2229	.2229	.2378
23	1.0242	1.1488	.9259	.2229		.2229	.2378
24	.9602	.9945	1.166	1.0974	.2229	.2229	.2229
Max	1.5775	1.5432	1.4918	1.6461	1.5432	1.5775	1.4746
Min	.2378	.2229	.2058	.2229	.2229	.2229	.2229
Avg	.7361	.7369	.8069	.7807	.7383	.7690	.7925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 204 / 11 KV DHANAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.3032	1.1145	1.3032
2					1.3717	1.1145	1.3717
3					1.3717	1.0288	1.4746
4					1.4403	.9602	1.4746
5					1.4746	1.1145	1.4403
6					1.5089	1.3032	1.4403
7					1.6118	1.3717	1.749
8					1.6461	1.7147	1.749
9	1.8519	1.5851	1.3717	1.8519		1.3717	1.7147
10	1.6766	1.6156	1.6289	1.8004			
11	1.7833	1.6461	1.7147	1.7833			
12	1.7985	1.6156	1.8004	1.8176			
13	1.829	1.6461	1.7147	1.7833			
14	1.829	1.6461	1.7147	1.8347			
15	1.7985	1.6156	1.7147	1.749			
16	1.7985	1.5242	1.7147	1.749			
24					1.2346	1.1145	1.2346
Max	1.8519	1.6461	1.8004	1.8519	1.6461	1.7147	1.749
Min	1.6766	1.5242	1.3717	1.749	1.2346	.9602	1.2346
Avg	1.7957	1.6118	1.6718	1.7962	1.4403	1.2208	1.4952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 205 / 11 KV GURUDWARA GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0857	.1029	.1029	.1029	.0686
2	.0686	.0686	.0857	.1029	.1029	.1029	.0686
3	.0686	.0857	.0857	.1029	.1029	.1029	.0686
4	.0686	.0857	.0857	.1029	.1029	.1029	.0686
5	.0686	.0857	.0857	.1029	.1029	.1029	.0686
6	.0686	.0857	.0857	.1029	.1029	.1029	.0686
7	.1029	.1029	.0686	.1029	.1029	.1029	.0686
8	.12	.0857	.0686	.1029	.0857		.0686
9	.0857	.0857	.0857	.0857	.0857	.0857	.0686
10	.1029	.1029	.0857	.0857	.0857	.0857	.0857
11	.1029	.1029	.0857	.1029	.0857	.0686	.0857
12	.1029	.1029	.0857	.1029	.0857	.0686	.0857
13	.1029	.1029	.0857	.1029	.0857	.0686	.0857
14	.1029	.1029	.0857	.1029	.0857	.0686	.0857
15	.0857	.1029	.1029	.1029	.12	.0857	.0857
16	.0857	.1029	.1029	.1029	.1029	.1029	.1029
17	.0857	.1029	.1029	.1029	.1029	.1029	.1029
18	.0857	.1029	.1029	.1029	.0857	.0857	.1029
19	.0857	.1029	.1029	.1029	.1029	.0857	.1029
20	.0857	.1029	.1029	.1029	.1029	.0857	.0857
21	.0857	.0857	.1029	.1029	.1029	.0857	.0857
22	.0686	.0857	.1029	.1029	.1029	.0857	.0857
23	.0686	.0857	.1029		.1029	.0857	.0857
24	.0686	.0686	.0857	.1029	.1029	.1029	.0686
Max	.12	.1029	.1029	.1029	.12	.1029	.1029
Min	.0686	.0686	.0686	.0857	.0857	.0686	.0686
Avg	.0850	.0922	.0907	.1014	.0979	.0902	.0814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 201 / 11 KV NEELA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.1576	1.307	1.1949	1.1949	1.307	1.1949
2	1.307	1.1576	1.307	1.1949	1.2696	1.307	1.2323
3	1.307	1.3443	1.307	1.3443	1.3817	1.307	1.4563
4	1.4937	1.6804	1.419	1.531	1.6804	1.3817	1.6804
5	1.9605	2.0165	1.6804	1.8298	2.0165	1.7924	2.0538
10	1.4937	1.5684	1.1203	1.4937	1.4937	1.4937	1.4937
11	1.1949	1.307	.9335	1.2696	1.1203	1.2696	1.2136
12	1.0642	1.1203	.9896	1.0456	.8402	1.0456	1.1203
13	.9335	.7842	1.1016	1.1203	.8402	.9709	1.0829
14	.8589	.7468	1.0642	1.0456	.8402	.8962	1.1203
15	.8962	.7468	1.0829	1.1203	.9709	.9709	1.1576
16			1.1949	1.2696	1.1203	1.1203	1.1949
17	1.1203		1.419	1.3443	1.3443	1.4563	1.307
18	1.4563		1.419	1.4937	1.4937	1.6804	1.419
19	1.7551	2.3899	1.5655	1.6991	1.7924	1.8671	1.9791
20	1.531	1.9605	1.7177	1.643	1.6804	1.8111	1.7737
21	1.4003	1.6804	1.4937	1.4563	1.4937	1.5123	1.4937
22	1.307	1.4937	1.307	1.2696	1.4937	1.3443	1.4003
23	1.2323	1.4937	1.2696	1.2696	1.419	1.1949	1.307
24	1.307	1.1949	1.419	1.2323	1.1949	1.307	1.1949
Max	1.9605	2.3899	1.7177	1.8298	2.0165	1.8671	2.0538
Min	.8589	.7468	.9335	1.0456	.8402	.8962	1.0829
Avg	1.3119	1.4025	1.3059	1.3434	1.3341	1.3518	1.3938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 202 / 11 KV CHIKHALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1561		1.2967	.8802	.7049	.9755	.8977
2	1.1561		1.3123	.8802	.7049	1.0059	.8833
3	1.1873		1.3748	.9469	.743	1.0364	.8573
4	1.2498		1.406	1.0151	.7573	1.0974	.8716
5	1.2811		1.4529	1.0974	.7716	1.2193	.8716
6	1.4998		1.7185	1.1843	1.0402	1.2955	1.1443
7	1.9372		2.0622	1.8595	1.326	1.5089	1.4327
8	1.7966		1.9372	.8173	.8345	1.2803	.8573
9	1.3435	.6748	1.3748	1.3717	1.3032	1.4022	1.709
10	1.406	1.2041	1.4529	1.4022	1.3937	1.4632	1.7238
11	1.3717	1.4842	1.3592	1.358	1.6766	1.5844	1.6857
12	1.3245	1.5935	1.3108	1.4352	1.6766	1.5455	1.6556
13	1.2631	1.7185	1.2643	1.3426	1.6461	1.3032	1.2803
14	1.0551	1.406	1.2037	1.2334	1.6461	1.2689	1.3108
15	1.0856	1.3748	1.1294	1.3717	1.5546	1.3432	1.3748
16	1.0269	1.3279	1.1004	1.2498		1.386	1.406
22							1.406
23		1.2967	.9069	.6767	.823	.9242	.9288
24	1.1561		1.2967	.9069	.6767	.884	.9242
Max	1.9372	1.7185	2.0622	1.8595	1.6766	1.5844	1.7238
Min	1.0269	.6748	.9069	.6767	.6767	.884	.8573
Avg	1.3116	1.3423	1.3867	1.1683	1.1341	1.2513	1.2221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174128 / 33 KV RAHATI

Feeder No / Name : 201 / 11 KV RAHATI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.1867	.2641	.2614	.2614		.2829
2	.2614	.2241	.2641	.2614	.2614		.2829
3	.2614	.2241	.2829	.2614	.2614		.3018
4	.3361	.2614	.3772	.3174	.3174		.3772
5	.4108	.2987	.4715	.4481	.3734		.5281
6	.6722		.6413	.6722	.6219		.7167
7	.7095		.6413	.7468	.6219	.6329	.7356
8	.5975	.6722	.6602	.5975		.5956	.6413
9		.5601	.5658	.5228		.5584	.5658
10	.2614	.4338	.3018	.3734		.3772	.4338
11	.2241	.2263	.2241	.1867	.335	.2452	.2987
12	.2241	.1698	.1867	.2241	.2978	.2263	.2427
13	.1867	.1698	.1867	.1867		.1698	.2427
14	.1867	.1886		.1867		.2075	.2614
15	.1494	.1886	.1867	.2241		.2263	.2987
16	.2241	.2263	.2241	.2614	.3723	.3018	.3174
17	.2984	.3584	.2801	.2987	.3723	.4527	
18	.4108	.4338	.3174		.4467	.5281	.462
19	.5359	.5847	.3734	.5601	.4653	.6602	.5914
20	.4108	.4715	.4294	.5601		.5658	.4435
21	.3734	.3584	.3547	.3547		.4338	.3881
22	.2987	.3018	.2987	.2987		.3584	.3361
23	.2587	.2829	.2614	.2614		.3206	.2987
24	.2614	.2614	.2641	.381	.2561		.3018
Max	.7095	.6722	.6602	.7468	.6219	.6602	.7356
Min	.1494	.1698	.1867	.1867	.2561	.1698	.2427
Avg	.3398	.3220	.3503	.3673	.3760	.4036	.4065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174128 / 33 KV RAHATI

Feeder No / Name : 202 / 11 KV SOMESHWAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.112	.1509	.0747	1.6518		1.6766
2	.128	.112	.1509	.0747	1.6518		1.6918
3	.1463	.112	.1509	.0747	1.7004		1.7071
4	.1463	.1006	.1509	.0747	1.7814		1.7071
5					1.8623		1.7528
6					2.0729		1.9052
7					2.2611	2.1898	2.1643
8						2.1586	2.0119
9	1.9547	2.13	1.9509			2.0334	1.9509
10	2.2283	2.3167	2.2253				
11	2.2874	2.3167	2.0561	2.1956			
12	2.2672	2.21	1.8099	2.2611			
13	2.2939			2.3922			
14	2.2939	2.0576		2.3967			
15		2.2558		2.4291			
16	.6783	2.2253	1.2193	2.5263			
17	2.2043			2.3967		.0943	.0914
18				2.2996		.1132	.1463
19	.0747	.1509	.0934	.0972	.1215	.132	.1829
20	.112	.1509	.0747	.0972		.132	.1829
21	.112	.1509	.0747	.1357		.1509	.1463
22	.112	.1509	.2987	.1463		.1509	.1463
23	.112	.1509	.0747	.1463		.1509	.1463
24	.128	.112	.2641		1.4746		1.6766
Max	2.2939	2.3167	2.2253	2.5263	2.2611	2.1898	2.1643
Min	.0747	.1006	.0747	.0747	.1215	.0943	.0914
Avg	.9671	.9891	.7164	1.1658	1.6198	.7306	1.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174128 / 33 KV RAHATI

Feeder No / Name : 203 / 11 KV GODAWARI RAHATI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3969	1.3765	1.5089	1.4861			
2	1.3969	1.3927	1.5242	1.4861			
3	1.3969	1.6244	1.5089	1.4861			
4	1.3969	1.4413	1.5242	1.4861			
5	1.4266	1.4746	1.5242	1.448			
6	1.419		1.4327	1.5059			
7	1.419		1.4784	1.5203			
8	1.39	1.5074	1.5242	1.5158			
11					1.7202	1.7985	1.7375
12					1.6473	1.9509	1.7955
13						1.9662	1.8534
14						1.9509	1.8823
15						1.9814	1.9113
16					1.8829	2.0119	1.9113
17					1.9132	2.0119	1.8823
18					1.9132	1.9509	1.7833
23	1.1797	1.4937	1.2955				
24	1.4327	1.1797	1.5089				
Max	1.4327	1.6244	1.5242	1.5203	1.9132	2.0119	1.9113
Min	1.1797	1.1797	1.2955	1.448	1.6473	1.7985	1.7375
Avg	1.3855	1.4363	1.4830	1.4918	1.8154	1.9528	1.8446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174130 / 33 KV TALANI

Feeder No / Name : 201 / 11 KV TALANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2266	.2103	.2263	.2268	.2263	.208
2	.2172	.2643	.2427	.2263	.2646	.2641	.2401
3	.2896	.3398	.3467	.2829	.3402	.3206	.2743
4	.394	.4154	.4508	.3326	.4536	.4527	.4161
5	.4961	.5287	.5201	.4805	.4536	.6838	.5548
6	.5959	.6608	.6588	.7133	.756	.8413	.7011
7	.6762	.7175	.7282	.7865	.793	.7682	.6001
8	.6588	.7749	.7975	.7733	.8119	.8048	.7011
9	.567	.6042	.5028	.6224	.5853	.5359	.547
10	.3403		.3734	.4904	.4154	.415	.3734
11	.2268		.2987	.3021	.2987	.2743	.2987
12	.1892	.1734	.168	.3213	.2218	.1928	.2218
13	.189	.208	.1494	.3024	.1848	.1715	.2033
14	.1888	.2427	.2054	.3402	.1867	.2058	.2218
15	.2268	.2743	.2218	.3398	.2241	.2454	.2587
16	.2835	.2947	.2957	.378	.2957	.2774	.3511
17	.3776	.4161	.3772	.4343	.462	.3772	.3881
18	.5287	.4681	.4715	.4536	.5281	.4681	.5281
19	.6042	.6485	.5658	.5664	.6036	.5258	.547
20	.4154	.4733	.5093	.5292	.3961	.5028	.5093
21	.3402	.3544	.3584	.378	.2829	.3814	.3395
22	.3024	.2774	.3018	.3024	.2829	.3155	.3206
23	.2646	.2601	.2829	.2832	.2641	.2427	.2829
24	.2172	.1888	.2572	.2641	.2266	.2263	.2279
Max	.6762	.7749	.7975	.7865	.8119	.8413	.7011
Min	.1888	.1734	.1494	.2263	.1848	.1715	.2033
Avg	.3669	.4005	.3873	.4221	.3983	.4050	.3881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 201 / 11 KV KANDHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.6385		1.4146	1.7147		1.4937
2	1.3443	1.5242		1.4003	1.6385		1.4937
3	1.3203	1.5242		1.5089	1.6385		1.4937
4	1.4003	1.6766		1.4937	1.7147		1.6057
5	1.6804	1.6766		1.4937	1.829		1.6804
6	1.7737	1.7528		1.7918	1.9052		1.7924
7	1.8671	2.0195		1.9616	2.0957		2.1879
8	1.8671	2.2862	2.0538	1.7737	1.9814	1.8099	2.5274
9		1.829	1.9805		1.829	2.0748	2.3285
10		1.4146	1.9427		1.7147	1.8861	2.0328
11		1.2136	1.8296		1.829	1.7924	1.8671
12		1.7737	1.7918		1.829	1.6804	2.0538
13		2.0182	1.8671		1.829	1.6804	1.9605
14		1.9805	1.7924		1.829	1.8107	1.9605
15		1.9805	1.8107		1.9052	1.7924	2.0538
16		1.9427	1.7364	1.1203	2.0195	1.8484	2.0538
17			1.7177	1.9052		1.8671	2.0182
18			1.79	2.0957		2.0911	2.0748
19			1.9805	2.2862		2.2405	2.2257
20			1.8671	2.2862		2.4272	2.2634
21			1.7924	2.0957		2.2405	2.1691
22			1.7924	2.0195		2.0538	2.0559
23			1.6804	1.9052		1.8671	1.9239
24	1.4937	1.7147		1.6032	1.829		1.6804
Max	1.8671	2.2862	2.0538	2.2862	2.0957	2.4272	2.5274
Min	1.307	1.2136	1.6804	1.1203	1.6385	1.6804	1.4937
Avg	1.5615	1.7627	1.8391	1.7739	1.8312	1.9477	1.9582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4115		.2575	1.6461		1.8671
2	.3429	.4115		.3772	1.6461		1.8671
3	.2915	.4115		.3781	1.7558		2.0748
4	.3429	.4801		.3429			2.4272
5	.4287	.5144		.4287	2.0485		2.5873
6	.4287	.5144	.5601	.5144	2.1948	1.8671	2.9874
10			.3429				
11			.3429		.3429	.2743	.2572
12		.4287	.4287		.3429	.2743	.3429
13		.4287	.4287		.3429	.2743	.3429
14			1.8671		.3429	.2743	.2572
15		2.4272	2.2405		.1715	.2743	.2572
16		2.4272			.2401	.2743	.2575
17						.3086	.3429
18			2.0328			.3429	.4287
19			2.6139	2.8006		.4801	
20			2.4272	2.6139		.6173	.5144
21			2.5873	2.4025		.5144	.4287
22			2.1472	2.1948		.5144	.4287
23			.4287	1.829		1.8671	1.8671
24	.4287	.4801		.3429	1.829		2.2405
Max	.4287	2.4272	2.6139	2.8006	2.1948	1.8671	2.9874
Min	.2915	.4115	.3429	.2575	.1715	.2743	.2572
Avg	.3723	.8123	1.4191	1.2069	1.0753	.5827	1.1461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 203 / 11 KV PANBHOSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.386	1.0974		1.3163	.1715		.1715
2	1.4415	1.0974		1.4003	.1715		.1715
3	1.4784	1.2437		1.4003	.1715		.1715
4	1.4784	1.39		1.307	.2743		.2401
5	1.587	1.6095		1.6958	.3429		.2743
6	1.587	1.829		1.6804			.3429
7					1.829		1.4937
8		.2743	.3734		1.0288	1.6804	1.7924
9		.2743	.2572		1.829	1.8671	2.0538
10		.2572	.2572		1.829	1.8671	1.9404
11		.2572	.2572		1.829	1.8671	1.8298
12		.2572	.2572		1.7558	1.6263	1.7737
13		.2058			1.6461	1.5684	1.7737
14		.2058			1.4632	1.4937	1.4784
15			.1715		.2401	.1715	.2772
16			.2572	.3734	.2743	.1715	
17			.2229	.2401		.206	.2572
18			.2229	.2401		.2743	.2572
19			.3429	.3429		.3429	.3429
20			.3429	.4115		.4115	.4287
21			.2572	.4115		.4115	.3429
22			.2572	.3429		.3429	.3429
23			1.2936	.2401		.2743	.2572
24	1.587	1.0974		1.2936	.1715		.1715
Max	1.587	1.829	1.2936	1.6958	1.829	1.8671	2.0538
Min	1.386	.2058	.1715	.2401	.1715	.1715	.1715
Avg	1.5065	.7926	.3408	.8464	.9392	.9110	.7907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 204 / 11 KV KURULA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401		.2229	.1715		.1715
2	.2915	.1715		.2572	.1715		.1715
3	.2915	.1715		.2572	.1715		.1715
4	.3429	.2401		.2572	.1715		.2743
5	.3429	.3086		.2572	.2743		.3429
6	.3429	.3429		.3429	.2743		.4115
7	1.6804	1.4632		1.4937	.2743		.5144
8	1.8298	1.829	1.6804	1.587	.2743	.3734	.5144
9		1.7147	1.6632			.2743	.4115
10		1.7737	1.6804		.2743	.2743	.4115
11		1.6804	1.386			.8573	.2572
12		1.587	1.4003		.2743	.2743	.1715
13		1.386	1.307		.2743	.1715	.1715
14		1.307	.3658		.2743	.1717	.2058
15		.2572	.3429		1.39	1.6632	1.4575
16		.1715	.3429	.3734	1.5432	1.7924	1.587
17			.2572	.2401		1.8671	1.6804
18			.2229	.2401		1.8671	1.6804
19			.3429	.3429		2.0538	1.4937
20			.3429	.4115		2.0538	1.4146
21			.3429	.3429		1.8671	1.4146
22			.3429	.2743		1.6804	1.307
23			.2572	.2743		.2401	.2572
24	.2572	.2401		.2572	.1715		.1715
Max	1.8298	1.829	1.6804	1.587	1.5432	2.0538	1.6804
Min	.2572	.1715	.2229	.2229	.1715	.1715	.1715
Avg	.6263	.8756	.7674	.4372	.3990	1.0926	.6944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 205 / KANDHAR HOSPITAL
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191			.0191		
2	.0191	.0191			.0191		
3	.0191	.0191			.0191		
4	.0191	.0191			.0191		
5	.0191	.0191			.0191		
6	.0191	.0191			.0191		
7	.0191	.0191			.0191		
8	.0191	.0191		.0191	.0191	.0187	
9		.0191	.0191		.0191	.0191	
10		.0191	.0191		.0191	.0191	
11		.0191			.0191	.0191	
12		.0191			.0191	.0191	
13		.0191			.0191	.0191	
14		.0191	.0191		.0191	.0191	
15		.0191			.0191		
16		.0191			.0191	.0191	
17				.0191		.0191	.0191
18			.0191	.0191		.0191	.0191
19				.0191		.0191	.0191
20				.0191		.0191	.0191
21				.0191		.0191	.0191
22				.0191		.0191	.0191
23			.0191	.0191		.0191	.0191
24	.0191	.0191		.0191	.0191		.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0187	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 201 / 11 KV BARUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	2.3339	2.5019	2.5766
2	.9709	2.4272	2.5393	2.5766
3	.8962	2.4646	2.5766	2.6513
4	1.0829	2.7073	2.6886	2.7446
5	1.3817	2.9127	2.9313	2.8567
6	1.6617	3.2487	3.2674	3.1927
7	1.7177	3.3981	3.4728	3.4541
8	1.6804	3.3608	3.3981	3.4189
9	1.6244	1.4937	1.1949	1.4937
10	1.5684	1.251	1.2696	1.3817
11	3.2301	1.1203	1.1949	1.1389
12	3.1367	.9335	1.0269	1.0829
13	3.3048		.9709	1.0082
14	3.2861		.9335	.9709
15	3.3608	1.3256	.9709	.9709
16	2.8753	1.2323	1.0269	1.0642
17	3.3608	1.1949	1.0642	1.1576
18	1.2136	1.307	1.3256	1.2323
19	1.5123	1.531	1.6617	1.4377
20	1.8111	1.4563	1.6617	1.531
21	1.5684	1.3817	1.4563	1.4377
22	1.3443	1.251	1.3817	1.358
23	2.1285	1.531	2.1472	2.2634
24	1.1203	2.2779	2.0911	2.5206
Max	3.3608	3.3981	3.4728	3.4541
Min	.8962	.9335	.9335	.9709
Avg	1.9535	1.9155	1.8648	1.8967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 202 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.1494	.112	.8775	.7842	.8962
2	.112	.112	.1494	.0934	.9335	.8215	.9335
3	.0934	.0934	.168	.0934	.9709	.8589	.9709
4	.112	.1307	.1867	.1307	1.0642	.8775	1.0269
5	.1494	.1494	.1867	.168	1.1016	.8962	1.0642
6	.2614	.2241	.2241	.2427	1.1389	1.1203	1.4003
7	.2801	.2427	.2427	.2427	1.363	1.307	1.5893
8	.2427	.2614	.1867	.2241	1.251	1.3443	1.587
9	.2241	.2241	.168	.2241	.1867	.2241	.1867
10	.9709	.7095	.8215	.8962	.1307	.1307	.1307
11	1.307	1.2323	.8962	1.1763	.1307	.0934	.1307
12	1.4563	1.3443	.9335	1.3256	.0934	.0934	.112
13	1.3817	1.4377	1.251	1.3256	.0934	.0747	.112
14	1.363	1.4937	1.1949	1.307	.0747	.0747	.112
15	1.4003	1.4563	1.1576	1.2696	.0934	.0934	.1307
16	1.4563	1.4003	1.0082	1.251	.0747	.0934	.1494
17	1.4377	1.307	1.2323	1.1763	.0747	.056	.1867
18	.1307	.1307	.112	.1307	.0934	.1307	.2054
19	.2054	.1867	.168	.2054	.2054	.2054	.2241
20	.2241	.168	.2241	.2241	.1867	.2427	.2427
21	.168	.1867	.2054	.1867	.168	.1867	.1867
22	.1494	.1494	.168	.1494	.1494	.168	.168
23	.1494	.1307	.1494	.6908	.6722	.1494	.679
24	.1494	.1307	.1307	.1307	.8402	.7095	.8589
Max	1.4563	1.4937	1.251	1.3256	1.363	1.3443	1.5893
Min	.0934	.0934	.112	.0934	.0747	.056	.112
Avg	.5640	.5422	.4714	.5407	.4987	.4473	.5535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 203 / 11 KV KAWTHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.1203	.9896	.9709	.8589	1.0456	.9335
2	1.251	1.1949	1.0269	1.1203	.8402	1.0082	.8962
3	1.3443	1.3443	1.1203	1.0829	.8775	.9335	.9896
4	1.5684	1.4563	1.2136	1.1576	1.0269	.9896	1.0269
5	1.7177	1.4937	1.2696	1.3817	1.1576	1.0642	1.0642
6	1.9605	1.643	1.6617	1.531	1.307	1.3256	1.419
7	2.0538	2.1285	1.9231	1.7551	1.419	1.475	1.5497
8	1.7924	2.1658	1.9791	1.7924	1.1949	1.3443	1.386
9	1.6244	1.9978	1.5497	1.8671	1.2136	1.1203	1.2883
10		1.0269	.8215	.9709	1.4003	1.419	1.4937
11	.9335	.9709	.7655	.8775	1.5684	1.5684	1.587
12	.8589	.8589	.7468	.8962	1.6991	1.8111	1.7737
13	.7842	.7468	.7095	.8215	1.7924	1.7551	1.6804
14	.7282	.7282	.6908	.7282	1.7177	1.4937	1.5684
15	.7095	.7095	.7468	.7842	1.5497	1.5497	1.475
16	.7468	.7468	.7842	.7842	1.4937	1.643	1.4377
17	.8589	.8215	.8215	.8215	1.3817	1.6057	.8775
18	.9896	.9709	.8962	.9709		1.0269	1.0456
19	1.4377	1.2696	1.0082	1.3817	1.1763	1.4003	1.1949
20	1.307	1.419	1.251	1.2696	1.2883	1.4377	1.363
21	1.1389	1.1949	1.3443	1.1203	1.2696	1.2883	1.3256
22	1.0456	1.0269	1.1576	.9709	1.2136	1.1203	1.307
23	1.0082	.9709	1.0829	.8573	1.1576	1.0456	1.2637
24	.8962	.9335	.8962	.8589	.8962	1.0829	.9522
Max	2.0538	2.1658	1.9791	1.8671	1.7924	1.8111	1.7737
Min	.7095	.7095	.6908	.7282	.8402	.9335	.8775
Avg	1.2136	1.2058	1.1024	1.1155	1.2826	1.3148	1.2875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 201 / 11 KV KURULA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.1107	.141	.08			
2	.1296	.1107	.141	.08			
3		.1423	.141	.08			
4		.1423	.141	.08			
5		.2134	.1974	.1334			
6		.2439	.2538	.2256			
7		.2675	.3102	.2286			
8	.3286	.3227	.3374	.2572			
9	.2858	.2934	.2934	.2782			
10					.2462	.2143	.1947
11					.2606	.2256	.2086
12					.2572	.2286	.2086
13					.2572	.2429	.2256
14					.2225	.2462	.2256
15					.2225	.2462	.2256
16					.2225	.2429	.2195
17					.2256	.2429	.2195
24	.0972	.1107	.096	.08			
Max	.3286	.3227	.3374	.2782	.2606	.2462	.2256
Min	.0972	.1107	.096	.08	.2225	.2143	.1947
Avg	.1877	.1958	.2052	.1523	.2393	.2362	.2160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 203 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1486	.2429
2					.1486	.1486	.2429
3					.1783	.1486	.2429
4					.2378	.2229	.2915
5					.2606	.3048	.2915
6					.2606	.3437	.4049
7					.2675	.4001	.5243
8					.2378	.3906	.4744
9					.2526		
10		.1143	.1097	.1429			
11		.2286	.1372	.3048			
12		.2896	.2	.3749			
13		.3048	.2286	.3048			
14	.3281	.2675	.2572	.301			
15	.2688	.2229	.2824	.2675			
16	.2688	.1932	.2824	.2675			
17	.253	.1932	.2591	.2675			
23					.1486		
24					.1189	.1486	.2267
Max	.3281	.3048	.2824	.3749	.2675	.4001	.5243
Min	.253	.1143	.1097	.1429	.1189	.1486	.2267
Avg	.2797	.2268	.2196	.2789	.2111	.2507	.3269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 201 / 11 KV JANGAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1104	.8669	.8322	.6935	.1772	.1254	.1075
2	1.2178	.8669	.9015	.6935	.1753	.1254	.0886
3	1.2269	.8764	.8916	.7282	.1753	.1433	.0876
4	1.2894	.8764	.9259	.7362	.1928	.1772	.0724
5	1.3969	.9214	.9259	.7362	.1949	.1772	.0895
6	1.5074	.9745	.9431	.7619	.2126	.1949	.0876
7	1.576	.9745	.9602	.9745	.2507	.2303	.1254
8	1.5402		.9536	1.0402	.2279	.2454	.1097
9	1.4723	.8669	1.0576	.1886			.1029
10	.1063	.1433	.1734	.1578	.8589	.9671	.8669
11	.1387	.1402	.1187	.156	.8916	.9015	1.0227
12	.1029	.1372	.1174	.1543	.9835	.8764	1.0774
13	.0829	.1174	.1174		.9175	.8322	1.0774
14	.0829	.1006	.1006	.1387	.9175	.8063	1.0442
15	.0838	.1006	.1174	.1326	.8951	.8413	1.0442
16	.0838	.116	.1174	.116	.8619	.8764	1.0442
17	.0995	.1174	.1174	.1147	.8383	.9015	1.0277
18	.1294	.1494	.1663	.1463	.1494	.1417	.1478
19	.2241	.1867	.2054	.2218	.2054	.1578	.2263
20	.2241	.2241	.2241	.2801	.2614	.1791	.2427
21	.1867	.2054	.2241	.2614	.2241	.1791	.2427
22	.1494	.1867	.2241	.2241	.1867	.1629	.2241
23	.1307	.1867	.6859	.1772	.1417	.1433	.1928
24	.8954	.823	.7888	.6859	.1772	.1417	.1463
Max	1.576	.9745	1.0576	1.0402	.9835	.9671	1.0774
Min	.0829	.1006	.1006	.1147	.1417	.1254	.0724
Avg	.6274	.4417	.4954	.4139	.4399	.4142	.4374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 202 / 11 KV HARBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2401	.2427	.2427	.7619	.8596	1.0387
2	.2149	.208	.208	.2427	.7888	.9313	1.0136
3	.1791	.2103	.2058	.2427	.8413	.985	1.0985
4	.1791	.2103	.2401	.2629	.9465	1.0277	1.134
5	.2149	.3189	.2743	.2804	.9922	1.0985	1.2308
6	.2507	.3189	.3258	.3189	1.0808	1.2757	1.2715
7	.2865	.3721	.4458	.3544	1.2178	1.3289	1.2894
8	.1254	.3961	.3467	.0867	1.1393	1.2269	1.2403
9	.2629	.3467	.2947	.3018		.2774	.3772
10	.8859	.7164	.7282	.7888	.298	.2629	.2774
11	1.1269	1.0166	.9326	1.0576	.2401	.2454	.218
12	1.1145	1.0288	1.0395	1.0631	.2035	.208	.2155
13	1.0277	1.0059	1.0898		.1966	.1753	.2155
14	.9945	1.0395	1.0059	1.0056	.1966	.2103	.1989
15	1.0059	1.0395	1.0059	1.0111	.1823	.2454	.1989
16	1.0059	1.0277	.8383	.9945	.2155	.2454	.1823
17	.9116	1.0059	1.0898	.9831	.218	.2896	.1823
18	.2587	.3174	.2402	.2743	.3734	.3224	.2772
19	.4481	.2987	.4108	.3696	.4108	.3292	.4338
20	.4481	.4854	.4481	.4294	.4108	.3582	.4108
21	.4108	.3921	.4294	.4108	.3734	.3189	.3921
22	.3734	.3734	.3361	.3361	.3547	.2804	.3734
23	.3361	.3086	.3086	.5316	.6733	.7522	.631
24	.2454	.2572	.2804	.2572	.7087	.7973	.7265
Max	1.1269	1.0395	1.0898	1.0631	1.2178	1.3289	1.2894
Min	.1254	.208	.2058	.0867	.1823	.1753	.1823
Avg	.5217	.5389	.5320	.5150	.5576	.5855	.6095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 203 / 11 KV PANSHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.104	.0867	.0867	.3189	.3582	.3856
2	.0905	.0867	.0693	.0867	.3155	.394	.394
3	.1075	.0876	.0686	.104	.3506	.4298	.4477
4	.1086	.0876	.0857	.1052	.3856	.443	.4656
5	.1227	.1063	.12	.1227	.4075	.443	.4961
6	.1433	.1417	.1372	.1595	.4961	.4961	.4706
7	.1433	.1417	.1715	.1595	.591	.5316	.5014
8	.1267	.1698	.1387	.1387	.5434	.5258	.5068
9	.1227	.1387	.1387	.132		.1227	.1372
10	.3189	.3582	.3814	.3856	.1227	.1227	.104
11	.4334	.3856	.4239	.3814	.0857	.1075	.1006
12	.4287	.4287	.4191	.3944	.0678	.104	.0829
13	.4144	.4024	.4191		.0655	.1075	.0829
14	.4144	.4024	.3688	.3467	.0655	.0895	.0829
15	.3688	.4144	.3688	.3647	.0663	.0895	.0829
16	.3688	.4144	.3688	.3647	.0663	.1052	.0829
17	.4144	.3688	.4191	.3932	.0838	.1254	.0829
18	.0924	.112	.0924	.0914	.112	.1075	.0924
19	.1494	.1307	.1494	.1294	.1494	.128	.1698
20	.1494	.1494	.1494	.168	.168	.1433	.168
21	.168	.1307	.1494	.1494	.168	.1433	.1494
22	.1494	.112	.1307	.1307	.1307	.1254	.1494
23	.1307	.112	.1029	.3012	.2658	.3224	.3155
24	.0886	.12	.0876	.1029	.3012	.3012	.3506
Max	.4334	.4287	.4239	.3944	.591	.5316	.5068
Min	.0886	.0867	.0686	.0867	.0655	.0895	.0829
Avg	.2144	.2127	.2103	.2086	.2316	.2444	.2459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 201 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6068	.7011	.6401	.5258	.9431	.9431	1.0374
2	.6935	.7011	.7164	.5258	.8488	.9431	1.0374
3	.6935	.7802	.8059	.7011	.8488	.9431	1.0374
4	.7802	.7802	.7888	.7888	.9431	.9431	1.0374
5	.7802	.7802	.964	.8669	.9431	1.0374	1.1317
6	.8573	1.0517	1.1145	.9536	1.1317	1.226	1.1317
7	1.1022	1.3146	1.1145	1.1145	1.226	1.226	1.226
8	.9945	1.286		1.1105	1.226	1.226	1.1317
9	.9945	.8573	1.0288	.8573	1.1203	1.0374	1.0269
10	.8488	.7468	.7716	.9431	1.0288	.9945	.8954
11		.5658		.8488	1.1736	.9326	.8764
12	.7545	.5658	.8488	.9335	1.1145	1.1022	.964
13	.7468		.7545		1.0174	.9326	.964
14	.7468	.5658	.5658	.9335	1.0174	.9326	1.0517
15	.7468	.5658	.5658	.9335	.9221	.9326	1.0517
16	.8402	.5658	.5658	.9335	1.0059	1.0059	1.0517
17	.7468	.5658	.8402	1.0164	1.0059	1.0059	1.0517
18	.7468	.7545	.8402	.9335	.9335	.8488	.9431
19	1.2136	1.226	1.0374	1.226	1.2136	1.226	1.0374
20	1.1203	1.226	1.226	1.3203	1.3203	1.3203	1.0374
21	1.1317	1.1317	1.1317	1.2136	1.226	1.3203	1.226
22	1.0374	.9431	.9431	1.1203	1.1317	1.226	1.1317
23	.9431	.9431	.5258	.964	.964	1.1317	1.0374
24	.6135	.6201	.6401	.4382	.9431	1.0374	1.1317
Max	1.2136	1.3146	1.226	1.3203	1.3203	1.3203	1.226
Min	.6068	.5658	.5258	.4382	.8488	.8488	.8764
Avg	.8583	.8365	.8377	.9218	1.0520	1.0614	1.0520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 202 / 11 KV WARWANT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.7545	.9431	.8488	.6068	.6859	.6935
2	.8402	.6602	.8488	.8488	.6068	.6859	.6935
3	.8402	.6602	.8488	.8488	.6001	.7011	.8669
4	.8402	.7545	.8488	.9431	.6935	.7802	.9536
5	.9335	.8488	.9431	1.0374	.7011	.7802	1.0402
6	1.0374	1.1317	1.1317	1.1317	.964	1.0517	1.1269
7	1.1317	1.0374	1.1317	1.1317	1.1145	.9745	1.1145
8	1.1317	1.0374	1.1317	1.0374	1.1393	1.1269	.9431
9	.9431	.9431	.9431	.9431	.7545	.8402	.8488
10	.9326	.964	1.2136	.9431	.7545	.7545	.7545
11	.9431	1.1145	1.0174	1.1022	.7468	.6602	.7545
12	.9326	1.1145	1.0395	1.0174	.7468	.6602	.7545
13	1.0059	1.0288	1.0174		.6602	.6036	.7545
14	1.0059	1.0288	1.0174	.8573	.5658	.6036	.7545
15	.9116	1.0288	.9326	.9431	.5601	.6602	.7545
16	.9221	.964	.9326	.9431	.5601	.6602	.7545
17	1.0059	.964	.5487	1.0288	.7468	.7545	.7545
18	.6535	.5258	.5487	.7392	.7392	.8316	.7545
19	1.1203	1.1317	.9431	1.1203	1.1203		.7545
20	1.1203	1.1317	1.0374	1.2136	1.1317	1.2136	1.1317
21	1.0374	1.0374	1.0374	1.0269	1.0374	1.2136	1.1317
22	.9431	.9431	.9431	.9335	.9335	1.1317	1.0374
23	.8488	.9431	.9431	.7011	.7011	.5658	.7468
24	.9335	.7545	.9431	.8488	.7011	.6935	.6068
Max	1.1317	1.1317	1.2136	1.2136	1.1393	1.2136	1.1317
Min	.6535	.5258	.5487	.7011	.5601	.5658	.6068
Avg	.9562	.9376	.9536	.9647	.7869	.8101	.8534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 201 / 11 KV BACHOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5492	1.4098	1.4373	1.2136	1.1974	1.0855
2		1.6231	1.5912	1.5205	1.1763	1.16	1.0505
3		1.6584	1.5947	1.5844	1.1203	1.3096	1.1206
4		1.7289	1.768	1.6443	1.251	1.4219	1.3292
5		1.9074	1.8504	1.768	1.363	1.4967	1.4691
6		2.0134	1.868	1.8918	1.4175	1.5903	1.5391
7		2.2606	2.2558	1.9802			
8	1.1104	1.4498	1.2689	1.4998	1.6123	1.6464	1.0844
9	1.2178	1.1315	1.3041	1.3989	1.6088	1.7025	1.6405
10	1.2536	1.2023	1.2689	1.3056	2.0413	2.058	2.164
11	1.0879	1.1893		1.1751	2.0067	1.9631	2.0595
12	.9826	1.1242	1.251	1.0818	1.9894	1.9982	2.0416
13	.9124	1.054	1.0829	1.0072	2.1285	1.8889	1.9342
14	.9486	1.0517	.962	1.0259	1.9547	1.8539	1.9342
15	1.0188	1.054	.925	1.0445	2.0413	1.8889	1.97
16	1.0891	.9816	.888	1.0818	1.9375	1.9589	2.0058
17	1.2661	1.1594	.851	1.1191	1.1043	1.0155	
18	1.4771	1.335	1.1315	1.2804	1.1779	1.2606	
19	1.5826	1.4451	1.3716	1.4845	1.363	1.3687	
20	1.5139	1.4803	1.3189	1.4474	1.419	1.509	
21	1.3746	1.1418	1.2309	1.4103	1.3817	1.4388	
22	1.1984	.9869	1.0551	1.3443		1.3336	
23	1.4803	1.2336	1.2134	1.3056	1.2909	1.1919	1.2178
24	1.2894	1.5139	1.3217	1.4022	1.251	1.2161	1.1218
Max	1.5826	2.2606	2.2558	1.9802	2.1285	2.058	2.164
Min	.9124	.9816	.851	1.0072	1.1043	1.0155	1.0505
Avg	1.2237	1.3865	1.3384	1.3850	1.5386	1.5421	1.5746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 202 / 11 KV CHINCHOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5809	.6697	.6555	1.1751	1.1294	1.1218
2		.5985	.7072	.6368	1.2497	1.2235	1.1556
3		.6351	.7087	.6756	1.3056	1.2988	1.1556
4		.6704	.9194	.7311	1.3616	1.3176	1.1893
5		.8477	1.0926	.8061	1.4548	1.3741	1.2243
6		1.0597	1.1631	.9186	1.4861	1.3553	1.4342
7	1.1104	1.1656	1.1807	1.0123	1.5108	1.4118	1.3642
8		1.1492	1.1455	1.1811	1.2497	1.167	1.1019
9		1.3614	1.3394	1.2096	.9986	1.0541	.9947
10	1.3969	1.4498	1.4275	1.3133	.8856	.9223	.8202
11	1.4388	1.4532	1.3755	1.3824	.7537	.7011	.7164
12	1.4739	1.3701	1.315	1.3997	.6406	.5959	.6089
13	1.509	1.3701	1.2774	1.3824	.603	.5247	.5373
14	1.5458	1.3672	1.311	1.3651	.6972	.4897	.5014
15	1.4404	1.3701	1.2395	1.3306	.6595	.5247	.5373
16	1.3877	1.3321	1.3297	1.3479	.6406	.5597	.5731
17	.5803	1.2823	.4307	.5239	.6653	.6653	
18	.7737	.5972	.7131	.6951	.7023	.7354	
19	.9848	.8812	.9008	.7514	.9699	.9651	
20	.8802	.9516	.9848	.9017	.8393	.9124	
21	.7578	.8783	.8265	.8078	.7274	.8598	
22	.6697	.6697	.7131	1.0072	1.0259	.9826	
23	.6168	.6521	.6908	1.0807	1.0918	1.0867	1.1104
24	.6805	.5809	.6697	.6562	1.0831	1.1294	1.1218
Max	1.5458	1.4532	1.4275	1.3997	1.5108	1.4118	1.4342
Min	.5803	.5809	.4307	.5239	.603	.4897	.5014
Avg	1.0779	1.0114	1.0055	.9905	.9907	.9578	.9594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 203 / 11 KV BAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7042	.6697	.7072	.8988	.9114	.9816
2		.7042	.6895	.6873	.9869	.9598	.9805
3		.741	.7087	.7049	1.0398	.9976	1.0155
4		.8115	.884	.7402	1.0926	.9773	1.0494
5		.9184	1.0574	.8107	1.1455	1.0122	1.0844
6		1.0243	1.0926	.8459	1.1984	1.0471	1.1543
7	1.0387	1.095	1.0221	.8812	1.1807	1.082	1.2243
8	1.0745	1.0431	1.0045	.9516	1.0045	.8377	1.0144
9	1.2536	.9901	1.0574	1.1044	.8019	.6981	.2443
10	1.2536	1.3614	1.3217	1.2139	.6624	.6108	.1745
11	1.2283	1.0155	1.2363	1.284	.523	.5609	.5731
12	1.2283	1.1769	1.148	1.3196	.4537	.5258	.5373
13	1.2634	1.1769	1.0773	1.2363	.4881	.5072	.5373
14	1.2999	1.0867	1.1127	1.148	.523	.5072	.5373
15	1.335	.7553	1.148	1.0962	.523	.5247	.6089
16	1.2999	1.0341	1.1795	1.1455	.5404	.5947	.7164
17	.6506	.4918	.4415	.6011	.6303	.7004	
18	.8089	.6148	.6521	.7026	.7004		
19	1.0023	.8812	.7754	.8256	.9816	.9826	
20	.8802	.9693	.934	.9134	.8764	.9475	
21	.8283	.9134	.8459	.8607	.7888	.9124	
22	.793	.8283	.793	.808	.8589	.8773	
23	.7578	.7049	.7754	.8459	.8764	.9465	.9671
24	.7164	.7042	.7049	.7402	.8812	.928	.9816
Max	1.335	1.3614	1.3217	1.3196	1.1984	1.082	1.2243
Min	.6506	.4918	.4415	.6011	.4537	.5072	.1745
Avg	1.0396	.9061	.9305	.9239	.8190	.8108	.7990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 201 / 11 KV DIGRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3395	.3395	.3361	.3361	.3395	.3395
2	.3361	.3395	.3584	.3361	.3361	.3584	.3206
3	.3361	.3772	.3961	.3734	.2987	.3961	.3584
4	.4108	.4527	.4527	.4108	.2987	.4527	.3961
5	.5228	.5093	.5658	.5228	.4481	.5093	.4715
6	.5975	.5658	.6224	.5975	.5975	.5658	.5658
7	.6348	.6036	.6224	.6348	.6348	.6413	.6036
8	.5601	.6224	.5847	.5975	.5975	.6036	.5975
9	.5228	.5601	.4854	.5228	.5975	.6036	.5415
10	.4854	.4481	.3734	.4108	.5041	.4108	.4668
11	.3361	.3881	.3326	.3734	.3734	.2987	.4024
12	.2801	.3142	.2957	.2987	.3326	.3547	.3658
13	.2987	.3326	.2957		.3326	.3174	.3292
14	.3142	.2926	.2957		.3142	.2957	.2926
15	.2957	.2957	.2926		.2957	.3142	.2926
16	.2772	.2772	.2926		.3142	.3326	.2743
17	.2957	.2772	.3292		.2743	.3326	.2743
18	.3658	.3142	.3658	.3734	.3881	.3696	.3292
19	.5228	.5601	.5601	.5601	.5788	.6348	.5544
20	.5975	.5975	.5601	.5601	.6348	.6535	.5914
21	.5041	.5041	.4481	.5228	.5228	.5601	.5544
22	.4338	.4481	.4108	.4481	.4668	.4481	.4435
23	.3961	.3961	.3361	.3734	.3961	.3961	.3658
24	.3361	.3584	.3772	.3361	.3361	.3395	.3584
Max	.6348	.6224	.6224	.6348	.6348	.6535	.6036
Min	.2772	.2772	.2926	.2987	.2743	.2957	.2743
Avg	.4165	.4239	.4164	.4520	.4254	.4387	.4204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 202 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4999	.5624	.5468
2					.5312	.571	.5556
3					.5937	.6093	.571
4					.6562	.6405	.6093
5					.6562	.679	.6562
6					.7811	.7186	.5218
7					.8436	.8855	.8124
8					.8124	.9442	.7811
10	.6642	.7042	.5937	.7116			
11	.8223	.7748	.7811	.8223			
12	.8223	.8539	.7811	.7907			
13	.7811	.8065	.7186				
14	.7499	.8642	.7186				
15	.7811	.7907	.6874				
16	.8539	.8002	.6874				
17	.828	.8539	.7499				
23				.3749	.6093	.578	.4001
24					.4687	.6093	.5624
Max	.8539	.8642	.7811	.8223	.8436	.9442	.8124
Min	.6642	.7042	.5937	.3749	.4687	.5624	.4001
Avg	.7879	.8061	.7147	.6749	.6452	.6798	.6017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 201 / DEULGAON (OLD SAWARGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	.9831	1.0288	.6554	.7373	.6554
2	1.0288	1.0288	1.0174	1.0288	.6554	.7373	.6554
3	1.0288	1.0288	1.0174	1.0288	.6554	.7373	
4	1.0288	1.2003	1.0288	1.2003	.8192	.8192	.8192
5	1.0288	1.2003	1.0288	1.2003	.8192	.8192	.9831
6	1.0288	1.3717	1.2003	1.3717	.9831	.9831	
7	1.2003	1.3717	1.2003	1.3717	.9831	1.1469	.8192
8	1.2003	1.3717	1.3717	1.3717	.8192	1.1469	.8192
9	1.0288	1.3717	1.0288	1.3717	.3174	.3734	
10	.2614	.9831	.7373	1.3717	1.0288	1.0288	.9831
11	.2801	.8192	.6554	1.2003	1.0288	1.0288	
12	.2801	.8192	.6554	1.2003	1.2003	1.2003	1.0288
13	.3174	.8192	.6554	1.2003	1.2003	1.2003	
14	.3174		.6554	1.2003	1.2003		1.0288
15	.3174	.8192	.6554	1.0288	1.2003	1.2003	
16	.8192	.8192	.6554	1.0288		1.2003	1.0288
17	.8192	.8192	.8192	1.0288	1.2003	1.0288	
18	.8478	.8192	.8192	.8192		.9831	.8192
19	.9831	.9831	.9831	.9831	.9831	1.1469	
20	.9831	.9831	.9831	.9831	.9831	1.1469	1.1469
21	.9831	.7373	.9831	.8192	.8192	1.1469	
22	1.0174	.7373	.8192	.7373	.8192	.9831	.9831
23	.8192	.7373	.6554	.6554	.8192	.8192	.8192
24	1.0288	.8573	.9831	1.7147	.6554	.7537	.6554
Max	1.2003	1.3717	1.3717	1.7147	1.2003	1.2003	1.1469
Min	.2614	.7373	.6554	.6554	.3174	.3734	.6554
Avg	.8199	.9881	.8997	1.1227	.9021	.9725	.8830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 202 / SAWARGAON (OLD SUNEGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.6554	.4915	.6554	.8573	.8573	1.0288
2	.7373	.6554	.4915	.6554	.8573	.8573	1.0288
3	.8192	.6554	.4915	.6554	.8573	.8573	
4	.8192	.6554	.4915	.8192	1.0288	.8573	1.2003
5	.8192	.8192	.7373		1.2003	1.0288	
6	.9831	1.0174	.9831	1.065	1.2003	1.0288	1.3717
7	1.0174	.9831	1.0174		1.2003	1.2003	
8	.9831	.9175	1.0174	.9831	1.2003	1.2003	1.2003
9	.3174	.8192	.7373		.3174	.3174	
10	1.0288	.8573	.4287	.8192	.3734	.2614	.8192
11	1.0288	.8573	.8573		.2801	.2614	
12	.8573	1.0288	.8573	.6554	.1867	.2241	.6554
13	.8573	1.0288	.8573		.1867	.2241	
14	.8573	1.0288	.8573		.1867		.6554
15	.6859	1.0288	.6859		.1867		
16	.6859	1.0288	.6859	.6554		.5735	.6554
17	.8573	1.0288	.6859		.6554		
18	.6783	.6783	.6554	.8192		.7373	.8192
19	.9831	.8192	.8192	.8192	1.0174	.8192	
20	.8192	.763	.8192	.7373	.9831		.9831
21	.8192	.7865	.8192	.6554	.8192	.9831	
22	.6554	.4915	.6554	.6554	.8192	.8192	.8192
23	.6554	.5087	.6554	.6859	.6859	1.0288	.8573
24	.763	.6554	.4915	.2614	.8573	.8573	1.0288
Max	1.0288	1.0288	1.0174	1.065	1.2003	1.2003	1.3717
Min	.3174	.4915	.4287	.2614	.1867	.2241	.6554
Avg	.8111	.8237	.7204	.7248	.7253	.7497	.9374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 203 / RAIWADI (OLD KAREGAON) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.763	.8192	.7373		1.0288	.8573	1.0288
2	.763	.8192	.7373	.8192	1.0288	1.0288	1.0288
3	.7373	.8478	.763	.8192	1.0288	1.0288	
4	.7373	.8192	.7373	.9831	1.0288	1.0288	1.2003
5	.8192	1.0174	.7373	1.0174	1.2003	1.2003	
6	.8478	1.1869	1.0174	.9831	1.3717	1.2003	1.3717
7	.8192	1.1469	1.2289	.9831	1.3717	1.3717	
8	.8192	1.1469	.9831	.9831	1.3717	1.3717	1.3717
9	.2614	.9831	.9831	.9831	.3174	.3734	
10	.8573	1.0288	.6859	.9831	.3734	.3174	.8192
11	1.2003	.9831	.8573	.9831	.3734	.3174	
12	1.3717	1.2003	1.0288	.8192	.3174	.3174	.6554
13	1.5432	1.2003	1.0288		.3174	.3174	
14	1.5432	1.3717	1.0288	.8192	.2801		.6554
15		1.3717			.2801	.7373	
16	1.3717	1.3717	.8573	.8478			.8192
17	1.3717	1.3717	.8573		.8192	.8478	
18	.7373	.8192	.6554	.9831		.9831	1.0174
19	1.0174	.9831	.8192		.9831	1.1469	
20	.9831	.9831	.8478	.9831	.9831	1.1469	1.1469
21	.9831	.7373	.8478	.9831	.8192		
22	.8192	.7373	.8192	.8478	.8192	.9831	.8192
23	.8478	.7373	.7373	.8573	.8573	1.0288	.8573
24	.7373	.8192		.8192	1.0288	.8573	1.0288
Max	1.5432	1.3717	1.2289	1.0174	1.3717	1.3717	1.3717
Min	.2614	.7373	.6554	.8192	.2801	.3174	.6554
Avg	.9544	1.0209	.8634	.9209	.8182	.8791	.9872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 204 / LOHA URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5432	1.5432	1.7147	1.7147	1.8861	1.7147
2	1.7147	1.5432	1.5432	1.7147	1.7147	1.8861	1.7147
3	2.4006	1.5432	1.5432	1.7147	1.7147	1.8861	
4		1.7147	1.5432	2.0576	2.572	2.0576	2.4006
5	2.7435	2.0576	1.8861	2.2291	3.0521	2.4006	
6	2.915	2.572	2.572	2.572	3.0864	2.7435	3.0864
7	2.915	2.915	2.7435	2.7435	3.0864	3.0864	
8	2.7435	2.572	2.572	2.7435	2.572	3.0864	2.7435
9	2.572	2.572	2.572	2.572	2.4006		
10	2.572	2.572	2.4006	2.572	2.4006		2.7435
11	2.4006	2.4006	2.4006	2.4006	2.4006		
12	2.2291	2.4006	2.4006	2.3663	2.4863	2.572	2.4006
13	2.1434	2.4006	2.2291	2.3148	2.572		
14	2.1434	2.3148	2.0576	2.3148	2.4006	2.572	2.4006
15	2.0576	2.2291	2.2291	2.4006	2.4006		
16	2.0576	2.2291	2.2291	2.4006		2.5139	2.572
17	2.2291	2.4006	2.4006	2.572	2.4006		
18	2.4006	2.572	2.572	2.572		2.7435	2.7435
19	2.572	2.572	2.7435	2.915	3.0864		
20	2.572	2.2291	2.7435	2.915	2.7435	2.915	2.915
21	2.4006	2.0576	2.7435	2.572	2.4006		
22	2.2291	1.7147	2.572	2.2291	2.0576	2.4863	2.0576
23	1.8861	1.5432	2.0576	2.0576	2.0576	2.0576	2.0576
24	1.7147	1.5432	1.5432		1.7147	1.8861	1.7147
Max	2.915	2.915	2.7435	2.915	3.0864	3.0864	3.0864
Min	1.7147	1.5432	1.5432	1.7147	1.7147	1.8861	1.7147
Avg	2.3186	2.1755	2.2434	2.3767	2.4107	2.4237	2.3761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 206 / Karegaon New

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.6554	.7373	.5735	1.3717	1.0288	1.3717
2	.8192	.6554	.7373	.5935	1.3717		1.3717
3	.8478	.6554	.7373	.5935	1.3717	1.2003	
4	.8192	.6554	.7373		1.5432	1.2003	1.8861
5	.9831	.8192	.763	1.0174	1.8861	1.2003	
6	1.1469	.9831	.9831	1.0174	1.8861	1.5432	2.3663
7	1.065	.9831	.9831		1.8861	1.8861	
8	.9831	.9831	.9831	.8478	1.7147	1.8861	2.0576
9	.3734	.8192	.7373		.2614		
10	1.0288	1.0288	1.0288	.6783	.1867	.5898	.6783
11	1.3717	1.5432	1.2003		.1715		
12	1.5432		1.2003	.4915	.1867	.6226	.426
13	1.7147	1.2003	1.2003		.1867		
14	1.5432	1.2003	1.2003	.4915	.1867	.4915	.426
15	1.5432	1.0288	1.2003		.1867		
16		1.0288	1.2003	.4915		.4915	.426
17	1.5432	1.0288	1.2003		.4915		
18	.6783	.6554	.6554	.6783		.7373	.6554
19	.9496	.9831	.8478		.8478		
20	.9175	1.1469	.8478	.8192	.8192	1.0174	.8192
21	.8192	.9831	.8478		.8192		
22	.7461	.7373	.8192	.6554	.7209	.6554	.7373
23	.7209	.7373	.6554	.8573	.8573	.8573	.8573
24	.8192	.6554	.763	.2241	1.3717	1.0288	1.3717
Max	1.7147	1.5432	1.2003	1.0174	1.8861	1.8861	2.3663
Min	.3734	.6554	.6554	.2241	.1715	.4915	.426
Avg	1.0346	.9203	.9278	.6687	.9239	1.0273	1.1036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 207 / SUNEGAON NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.5432	1.7147	1.5432	1.1469	.9831	1.1469
2	2.0576	1.8861	1.7147	1.8861	.9831	.9831	1.1469
3	2.4006	1.8861	1.7147	1.8861			
4	2.4006	2.0576	1.7147	2.0576	1.3108	.9831	1.3108
5	2.572	2.4006	1.7147		1.8023		
6	2.7435	2.572	2.0576	2.572	1.8023	1.3108	1.6385
7	2.7435	2.7435	2.0576		1.8023		
8		2.4006	2.0576	2.572	1.8023	1.4746	1.3108
9	2.2291	2.2291	1.8861		.6348		
10	.3734	.9831	.763	2.0576	1.5432	1.5432	1.7147
11	.3734	.8192	.8478		1.5432		
12	.3174	.8192	.8478		1.7147	1.7147	1.8861
13	.3174	.8192	.8192		1.7147		
14	.2801	.8192	.8192	1.2689	1.5432	1.8004	1.7147
15	.2801	.8192	.7537	1.286	1.5432		
16	.7716	.8192	.78	1.286	1.5432	1.8004	1.7147
17	.9175	.8192	.8478	1.3717	1.7147		
18	.9831	.9012	.9012	.9831		.9831	.9831
19	1.4746	1.3927	1.1869	1.1469	1.5261		
20	1.4746	1.1469	1.3108	1.1469	1.4746	1.1469	1.5261
21	1.3108	1.2289	1.3565	1.3108	1.3108		
22	1.1469	1.2289	1.1469	1.2289	1.1469	1.3108	1.3108
23	1.1469	.9831	1.1469	1.2289	1.1469	1.1869	1.1469
24	1.7147	1.5432	1.7147	1.3717	.9831	.9831	1.1469
Max	2.7435	2.7435	2.0576	2.572	1.8023	1.8004	1.8861
Min	.2801	.8192	.7537	.9831	.6348	.9831	.9831
Avg	1.3951	1.4526	1.3281	1.5669	1.4424	1.3003	1.4070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 201 / KALAMBAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3605	.4287	.443	.5087	.6036	.5658	.5658
2	.4144	.4287	.443	.5087	.6036	.5658	.5658
3	.4144	.4287	.443	.503	.6036	.6602	.5658
4	.4973	.4287	.443	.5304	.6036	.6602	.6602
5	.5801	.503	.5316	.5735	.679	.8488	.7545
6	.6882	.8383	.7186	.7373	.8488	.9619	.8488
7	.9393	.9724	.9259	.8583	.9431	.9619	.9431
8	.9175	.5868	.9602	.8745	.8488	.8865	.811
9		.8097	.8916	.9069	.8299	.7167	.7733
10		.6602	.5847	.7167	.6859	.6952	.6882
11		.5281	.4904	.5658	.7373	.7373	.8383
12		.5093	.4338	.4904	.7545	.7865	.8383
13	.3429	.4904	.3961	.4527	.8718	.6882	.7712
14	.4801	.4527	.415	.4527	.8288	.6554	.7545
15	.3086	.4527	.415	.4527	.8288	.7209	.7042
16	.5281	.4527	.5281	.5658	.7459	.7865	.7042
17	.679	.4338	.6224	.5658	.7377	.779	.7125
18			.6979	.6602	.679	.7167	.6602
19	.7545	.9242	.9054	.8299	.7733	.8488	.9054
20	.7922	.7922	.7922	.8488	.7733	.8488	.9054
21	.7167	.7545	.7356	.7167	.6602		.7545
22	.6036	.6602	.6602	.6036	.679	.6602	.7167
23	.5658	.6036	.6036	.6036	.6224	.6224	.6602
24	.3647	.362	.3544	.5087	.6036	.5658	.5658
Max	.9393	.9724	.9602	.9069	.9431	.9619	.9431
Min	.3086	.362	.3544	.4527	.6036	.5658	.5658
Avg	.5762	.5870	.6014	.6265	.7311	.7365	.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 202 / PANGRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.724	.5668	.6299	.5281	.4715	.4715
2	.8192	.724	.5668	.6371	.5281	.4715	.4715
3	.8192	.7716	.5668	.663	.5281	.4715	.4715
4	.8097	.7716	.6478	.7459	.5658	.5658	
5	.8907	.9259	.8097	.8192	.5658	.6602	.5658
6	.8962	1.0288	.9555	.8583	.679	.7356	.6036
7	1.085	1.1012	1.1822	1.1174	.7545	.6224	.6413
8		.6478	1.166	1.004	.6602	.6036	.6036
9	1.1142	.9717	.9717	1.004	.5658	.4527	.4424
10		.4527	.3961	.4527	.9878	.8259	.9012
11		.4527	.3395	.3772	1.1012	.9012	.9717
12			.3018	.3395	1.0526	.9448	
13	.3429	.3395	.3018	.3772	.9555	.8848	1.0364
14	.6706	.3395	.3018	.3772	.9717	.8322	1.0364
15	.7377	.3395	.3018	.3772	.9717	.8421	1.1012
16	.2829		.3206	.3772		.8583	1.1012
17	.2829	.415	.3206	.3772	.9231	.9054	1.1469
18	.3395	.5281	.3395	.415	.4904	.415	.415
19	.4715	.6413	.5847	.679	.6413	.6602	.7167
20	.679	.6413	.6036	.679	.5847	.6224	.679
21	.6413	.6036	.5847	.5658	.5847		.6036
22	.5658	.5658	.5658	.5658	.5658	.5281	.5281
23	.5281	.5658	.5281	.5281	.5093	.5093	.724
24	.663	.5068	.5182	.6443	.5281	.4715	.4715
Max	1.1142	1.1012	1.1822	1.1174	1.1012	.9448	1.1469
Min	.2829	.3395	.3018	.3395	.4904	.415	.415
Avg	.6651	.6390	.5726	.6088	.7062	.6633	.7138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 203 / TELKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6413	.6602	.6413	.724	.6554	.5801
2	.6224	.6413	.6602	.6413	.724	.6554	.5801
3	.679	.6413	.6602	.6413	.724	.6554	.5801
4	.7545	.679	.7545	.6602	.724	.8288	.6554
5	.9431	.7545	.9431	.7922	1.1145	1.0059	.9717
6	1.0562	.8488	1.1694	1.094	1.0898	1.3056	1.1203
7	.9619	.9808	.9808	.9431	1.4754	1.5947	1.4723
8	.9054	.8488	.811	.9808	1.5223	1.7295	1.5524
9		.7167	.9054	.9808	.8299		.8589
10		.7545	.7459	.6001	.5281	.7922	.6224
11		1.1603	1.1305	1.0059	.4715		.5281
12		1.1603	1.1469	1.1336	.3961	.4668	.5281
13	.8383	1.1603	1.1469	.8573	.3772	.415	.4715
14	1.1984	1.1603	1.1469	1.073	.3772	.3772	.4715
15	1.2146	1.1271	1.1633	1.0364	.415	.4527	.5281
16	1.2146	1.1797	1.1797	1.1336	.5281	.5658	.5658
17	1.2146	1.3763	1.2289	1.3957	.6413	.6602	.7167
18	1.2631	.679	.4715	.6036	.8865	.8488	.8488
19	.8488	1.0374	.7733	.8488	1.0374	1.0751	.9431
20	.9431	1.0185	.9054	.9054	.9808	1.0185	.9431
21	.8299	.8488	.8488	.7545	.9054		.8488
22	.7167	.811	.7167	.679	.8676	.7922	.7167
23	.6602	.7545	.6602	.4525	.6226	.5935	.4706
24	.6224	.6602	.6602	.6413	.6878	.6554	.5801
Max	1.2631	1.3763	1.2289	1.3957	1.5223	1.7295	1.5524
Min	.6224	.6413	.4715	.4525	.3772	.3772	.4706
Avg	.9055	.9017	.8946	.8540	.7771	.8164	.7564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 204 / ALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	.6335	.4801	.503	.5281	.4715	.4715
2	.663	.6001	.4801	.503	.5281	.4715	.4715
3	.7373	.6001	.4801	.4973	.5281	.4715	.5281
4	.8192	.823	.6401	.663	.5658	.5658	.5658
5	.8907	.823	.8002	.8288	.5658	.6602	.6602
6	1.0688	1.0526	.9922	.9012	.7545	.8299	.7545
7	1.085	1.2146	1.1363	1.166	.9808	.8299	.8676
8	1.1012	.7287	1.2266	1.166	.9054	.7356	.7356
9		1.0526	1.1105	1.1822	.7545	.6413	.6224
10		.5847	.5041	.6036	1.0277	.8097	.9448
11		.4904	.3961	.5281	1.0898	.9503	1.0526
12		.3395	.3772	.3772	1.1065	.9995	
13		.415	.3584	.3772	1.0111	.8962	1.004
14	.8097	.415	.3772	.3772	.9945	.8259	.9717
15	.9069	.415	.3772	.3772	.9945	.9717	1.004
16	.4527	.4338	.3772	.4527	1.0159	1.0364	1.004
17	.5658	.4904	.3772	.4527	.9614	1.085	1.0526
18	.5658	.5281	.5093		.5658	.6036	.5281
19	.7167	.7545	.8299	.8676	.811	.7922	.7922
20	.7167	.7167	.7545	.7922	.6413	.7545	.7545
21	.679	.6413	.679	.7545	.5093		.6602
22	.5658	.5847	.6036	.5658	.5658	.6036	.5658
23	.5281	.5658	.5658	.5658	.4904	.5601	.4904
24	.5304	.5068	.4481	.503	.3772	.4715	.4715
Max	1.1012	1.2146	1.2266	1.1822	1.1065	1.085	1.0526
Min	.4527	.3395	.3584	.3772	.3772	.4715	.4715
Avg	.7359	.6421	.6200	.6524	.7614	.7408	.7380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 205 / Pokharbhosi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3584	.3772	.4344	.4049	.3315
2	.3772	.3772	.3584	.3772	.4344	.4049	.4144
3	.3772	.3772	.3584	.3772	.543	.4049	.4096
4	.415	.3772	.3772	.3772	.5258	.4858	.4096
5	.4715	.5281	.4715	.4715	.6706	.5668	.4915
6	.5281	.5658	.5847	.5658	.8048	.7287	.5898
7	.5281	.5658	.5847	.5281	.8097	.9069	.7865
8	.4858	.5281	.4904	.4527	.8745	.9878	.9503
9		.4527	.415	.3772	.2263	.415	.4904
10			.5304	.6859	.1698	.2753	.3018
11		.8745	.9175	.9602	.2075	.2641	.2829
12		.8745	.8848	.9259	.2263	.2263	
13	.4287	.9555	.8848	.8383	.2075	.2263	
14	.8383	.9393	.852	.8383	.2075	.2263	
15	.8745	.9231	.8192	.8383	.2263	.1886	
16	.8745	.8097	.8848	.8383	.2452	.1509	
17		.9393	.9175	.9054	.2452	.2263	
18	.6706	.2452	.1509	.2263	.2641	.3772	
19	.3772	.3961	.3772	.4715	.4338	.5658	
20	.5658	.4527	.415	.4715	.2452	.5281	
21	.4527	.415	.415	.3772	.415	.415	
22	.415	.3772	.415	.3772	.3961	.3772	
23	.3772	.3772	.3772	.3292	.3401		
24	.3772	.3772	.3584	.3772	.4344	.4049	
Max	.8745	.9555	.9175	.9602	.8745	.9878	.9503
Min	.3772	.2452	.1509	.2263	.1698	.1509	.2829
Avg	.5164	.5698	.5499	.5569	.3995	.4243	.4962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 201 / KAPSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7907	.6325	.7529	.7468	.9488	.9488	.9145
2	.7907	.6325	.7529	.6535	1.1069	.9488	.9145
3	.7907	.6325	.8471	.6535	1.1069	.9488	1.0059
4	.8697	.7907	.9412	.6535	1.2651	.9488	1.086
5	.9488	.9488	1.0458	.6535	1.2651	1.1069	1.0745
6	1.1069	.9488	1.1294	.7468	1.4232	1.2651	1.2003
7	1.1069	.7907	1.3176	.8402	1.4232	1.4232	1.5432
8	.9488	.9488	1.1294	1.1203	1.4232	1.5813	1.3717
9	.7907	.7907	.9412	1.1203	.7907	.9488	.5601
10	1.2651	1.1294	1.2003	1.2651	.6325	.9335	.6325
11		1.4937	1.2003		.6325	.9335	.6325
12	1.2651	1.8823	1.286	1.4232	.4744	.9335	.6325
13	1.4232	1.6941	1.2717		.4744	.7468	
14	1.4232	1.3535	1.3565		.4744	.7468	.7907
15	1.4232	1.4937	1.286		.4744	.7468	
16	1.5813	1.4118	1.1869	1.4232	.4744	.7468	.7907
17	1.5813	1.331	1.2003		.4744	.8402	
18	.7907	.9335	.7468	.7907	.7907	.9335	
19	.9488	1.2136	.8402		.9488	1.2136	
20	1.1069	1.5059	.8402	.9488	.9488	1.2136	.9488
21	.9488	1.2359	.9335		.9488	1.2136	
22	.7907	1.0269	.9335		.7907	1.1203	.7907
23	.6325	.9507	.8402		.9488	.6535	
24	.6325		.7468	1.0269	.9488		.9145
Max	1.5813	1.8823	1.3565	1.4232	1.4232	1.5813	1.5432
Min	.6325	.6325	.7468	.6535	.4744	.6535	.5601
Avg	1.0416	1.1205	1.0303	.9378	.8829	1.0042	.9296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 202 / MARTALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405			2.1948	1.1203	1.1203	
2	2.4272		2.3529	2.1719	1.1203	1.1203	1.2136
3	2.4272		2.447	2.3529	1.2136	1.1203	1.2136
4	2.6139		2.7294	2.4434	1.4003	1.1203	1.2136
5	2.6139		3.0117	2.3663	1.4937	1.4003	1.2136
6	2.9874		3.3882	2.7435	1.6804	1.4937	1.307
7	2.9874		3.3882	2.8826	1.6804	1.6804	1.6804
8	3.0807			3.0007	1.4937	1.6804	1.6804
9	2.9874		3.3882	2.9797	1.307	1.4937	1.4937
10	1.4937	.9412	1.587	1.307	2.6139	2.8045	2.9874
11	1.307	.9412	1.6804		2.8006	2.8921	3.0807
12	1.1203	.8471	1.4937		2.8006	2.8292	2.9874
13	1.1203	.8471	1.307		2.9874	2.4006	
14	1.1203	.7606	1.307		3.1741	2.7435	2.9874
15	1.1203	.7606	1.307		3.1741	2.8292	
16	1.1203	.9412	1.307	1.307	3.1741	2.8826	1.1203
17		.9412	1.307	1.1203	3.1741	3.2674	
18		.9412	1.307	1.1203		1.0269	
19		1.5059	1.307		1.4937	1.2136	
20		1.6941	1.4003	1.6804	1.6804	1.4937	1.6804
21		1.5059	1.4003		1.6804	1.587	
22		1.3176	1.4003		1.4937	1.307	1.307
23			1.2136		1.307	1.307	
24				1.4784	1.1203		1.2136
Max	3.0807	1.6941	3.3882	3.0007	3.1741	3.2674	3.0807
Min	1.1203	.7606	1.2136	1.1203	1.1203	1.0269	1.1203
Avg	2.0480	1.0727	1.9062	2.0766	1.9645	1.8615	1.7738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 203 / Sai Stone Crusher (Express NON SHEDDABLE EXPRESS HV FEEDERS
 Fee Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0366	.0376	.0373	.0914	.0914	.0373
2	.0914	.0366	.0376	.0373	.0914	.0914	.0373
3	.0914	.0366	.0373	.0373	.0914	.0914	.0373
4	.0914		.0376	.0373	.0914	.0914	.0373
5	.0914	.0366	.0376	.0373	.0914	.0914	.0373
6	.0914	.0366	.0376	.0373	.0914	.0914	.0373
7	.1829	.0366	.0373	.0373	.0914	.0914	.0373
8	.1829	.0366	.0941	.0373	.0914	.0914	.0373
9	.3658	.1829	.0951	.3658	.3658	.0914	.3429
10	.3658	.2824	.0934	.9145	.3658	.0934	.9145
11	.3658	.1901	.4287		.5487	.0934	.9145
12	.3658	.1882	.4287		.7316	.0934	.9145
13	.3658	.2824	.4287		.7316	.0934	
14	.3658	.2824	.0857		.3658	.0934	.7316
15	.3658	.2824	.3429		.3658	.0934	
16	.5487	.1882	.0857	.9145	.5487	.0934	.7316
17	.7316	.1882	.3353	.9145	.7316	.0934	
18	.5487	.2801	.4287	.9145	.7316	.0934	
19	.5487	.1882	.4191		.7316	.0934	
20	.5487	.1882	.0857	.1829	.1829	.0934	.1829
21	.0366	.0941	.0335		.0914	.0934	
22	.0366	.0941	.0373		.0914	.0934	.0914
23	.0366	.0941	.0373		.0914	.0373	
24	.0366		.0941	.0373	.0914		.0373
Max	.7316	.2824	.4287	.9145	.7316	.0934	.9145
Min	.0366	.0366	.0335	.0373	.0914	.0373	.0373
Avg	.2728	.1483	.1590	.3028	.3124	.0902	.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 204 / Golegaon New

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.5487	.7606	.4668	1.1317	.9431	.823
2	.8488	.5658	.7529	.4668	1.226	.9431	.9145
3	.8488	.5658	.8471	.4668	1.3203	.9431	.9145
4	.9431	.7545	.9335	.5601	1.3203	1.1317	.9145
5	.9431	.9431	1.1294	.5601	1.4146	1.3203	1.0974
6	1.5089	1.1317	1.3176	.5601	1.7918	1.5089	1.4022
7	1.6975	1.3203	1.5059	.8402	2.0748	1.8861	1.5432
8	1.6975	1.5089	1.307	.8402	1.8861	1.6975	1.6804
9	1.5089	1.3203	1.848	1.3137	1.1317	1.1317	1.3137
10	1.5089	.9412	.9145	1.6975	.9431	.5601	.9431
11	1.5089	1.2235	.905		.7545	.5601	1.1317
12	1.6975	1.5059	.905	1.5089	.5658	.6535	.9431
13	1.6975	1.6941	1.0517		.5658	.4668	
14	1.6975	1.6	1.0517		.5658		1.1317
15	1.6975	1.5059	1.0288		.5658		
16	1.6975	1.3176	1.1203	1.5089	.5658	.5601	1.1317
17	1.6975	1.2235	1.3146	1.5089	.5658	.5601	
18	1.3203	.7529	.4668	1.1317	.7545	.6535	
19	1.5089	1.2235	.4668		1.1317	.7468	
20	1.6975	1.4118	.4668	1.5089	1.3203	.8402	1.5089
21	1.1317	1.307	.5601		1.3203	.8402	
22	.9431	1.1294	.5601		1.1317	.7468	1.1317
23	.7545	.9412	.5601		1.1317	.6535	
24	.7545		.7529	.5601	.9431		.8316
Max	1.6975	1.6941	1.848	1.6975	2.0748	1.8861	1.6804
Min	.7545	.5487	.4668	.4668	.5658	.4668	.823
Avg	1.3439	1.1494	.9386	.9687	1.0885	.9213	1.1386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 201 / GOLEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0983		
2	.3429	.3086	.2055		.0983	.1199	.137
3					.0983		
4	.4287	.4287	.3426	.4115	.1147	.137	.1199
5					.1311		
6	.5144	.4801	.4111		.1638	.1884	.1713
7					.1802		
8	.5658	.5658	.5823	.583	.1638	.1713	.1713
9	.5144			.1966			.1372
10	.12	.137		.1475	.4796	.4796	.3429
11				.1147			.5487
12	.0857	.0856	.1029	.0983	.4111	.5138	.5144
13				.0983			.4458
14	.0857	.0856		.0983	.4111	.4453	.463
15				.0983			.4458
16	.0857	.1028	.0857	.0972	.5138	.5823	.4458
17				.0972			.4973
18	.1029	.137		.1296	.137	.2227	.1372
19				.1457			
20	.1543	.137	.1543	.1619	.1541	.1713	.1886
21				.1457			
22				.1296	.137	.137	.1372
23				.1296			
24	.2743	.2572	.1713	.2572	.1147	.1199	.137
Max	.5658	.5658	.5823	.583	.5138	.5823	.5487
Min	.0857	.0856	.0857	.0972	.0983	.1199	.1199
Avg	.2729	.2478	.2570	.1745	.2129	.2740	.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 202 / SHIRADHON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0492		
2	.2058	.1543	.3426		.0492	.0343	.0343
3					.0492		
4	.2572	.1543	.3768	.3429	.0492	.0343	.0343
5					.0648		
6	.3429	.3086	.3426		.0648	.0343	.0343
7					.0648		
8	.5144	.5487	.2282	.6344	.0819	.0343	.0343
9	.4973			.1134			.0343
10	.0686	.0856		.0972	.3083	.4453	.2915
11				.081			.3429
12	.0514	.0685	.0857	.0648	.4453	.5138	.3944
13				.0486			.4115
14	.0514	.0685		.0486	.4453	.5138	.4287
15				.0486			.4287
16	.0686	.0514	.0686	.0486	.4453	.5138	.463
17				.0486			.4801
18	.0686	.0685		.0486	.0685	.0856	.0686
19				.0648			
20	.0857	.0856	.0857	.081	.0514	.0343	.0686
21				.0972			
22				.0972	.0343	.0343	.0857
23				.081			
24		.1543	.3426	.2401	.0819	.0343	.0343
Max	.5144	.5487	.3768	.6344	.4453	.5138	.4801
Min	.0514	.0514	.0686	.0486	.0343	.0343	.0343
Avg	.2011	.1589	.2341	.1270	.1471	.1927	.2159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 203 / JOSHI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3605		
2	.2058	.1715	.1713		.3605	.6166	.6166
3					.3605		
4	.1715	.2572	.137	.2229	.3932	.9592	.8906
5					.4915		
6	.2058	.2743	.1713		.639	1.0619	1.0962
7					.8848		
8	.2058	.2572	.2912	.3086	.9503	1.336	1.4045
9	.2229			.2591			.3086
10	.4287	.7194		.3887	.274	.1713	.2401
11				.6154			.1886
12	.8916	1.0277	.7202	.7537	.2398	.2055	.1715
13				.7956			.1886
14	.7373	1.0559		.8192	.2055	.2055	.1715
15				.8192			.1715
16	.8745	1.1989	.6859	.852	.1713	.2398	.1543
17				.8192			.1886
18	.9602	.2227		.2267	.2055	.3083	.2572
19				.2915			
20	.2572	.274	.2058	.3239	.2227	.3083	.2572
21				.2915			
22				.2591	.3083	.3083	.2743
23				.3605			
24		.1715	.274	.1543	.3563	.4796	.5481
Max	.9602	1.1989	.7202	.852	.9503	1.336	1.4045
Min	.1715	.1715	.137	.1543	.1713	.1713	.1543
Avg	.4692	.5118	.3321	.4756	.4015	.5167	.4193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 205 / Osmanagar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4915		
2	.0857	.0686	.0856		.4915	.6166	.5481
3					.4915		
4	.0857	.0686	.0856	.0857	.5243	.7194	.8221
5					.6554		
6	.0857	.0686	.137		.852	.8221	1.0277
7					1.1142		
8	.1372	.0857	.1541	.1372	1.2289	1.4045	1.4387
9	.1029			.1134			.1372
10	.4458	.8564		.4372	.1199	.3083	.1029
11				.852			.0514
12	1.0974	1.1647	1.1145	1.065	.0856	.2398	.0514
13				1.0814			.0686
14	.7202	.9934		1.094	.0856	.2227	.0686
15				1.0814			.0686
16	.703	1.0962	1.166	1.1142	.1028	.2398	.0686
17				1.1603			.0686
18	.0857	.1028		.1311	.1028	.3254	.1029
19				.1296			
20	.0857	.1028	.0857	.1134	.1199	.1028	.1029
21				.0972			
22				.081	.1028	.1028	.1029
23				.4588			
24		.0686	.0856	.0686	.4752	.5481	.4796
Max	1.0974	1.1647	1.166	1.1603	1.2289	1.4045	1.4387
Min	.0857	.0686	.0856	.0686	.0856	.1028	.0514
Avg	.3305	.4251	.3643	.5168	.4402	.4710	.3124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 206 / 11 KV GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

SEPARATED GAOTHAN FEEDERS

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3277
2		.6516			.2949
3					.2622
4		.6859		.4458	.2622
5					.3932
6		.6859			.5898
7					.5898
8		.583		.5487	.5243
9	.5144			.4915	
10	.4801			.4641	
11				.431	
12	.3772		.3772	.3647	
13				.3315	
14	.2743			.2984	
15				.2949	
16	.3429		.2401	.2949	
17				.3605	
18	.3772			.4588	
19				.5243	
20	.5487		.5487	.4915	
21				.4588	
22				.426	
23				.3932	
24		.6001		.4115	.3605
Max	.5487	.6859	.5487	.5487	.5898
Min	.2743	.583	.2401	.2949	.2622
Avg	.4164	.6413	.3887	.4161	.4005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 201 / SONKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696		.3658	.3696		.3658	.3696
2	.3326		.3658	.3511		.3658	.3696
3	.3881		.3658	.3881		.5487	.3696
4	.4435		.4572	.4805		.4572	.462
5	.5175		.5487	.5544		.5487	.5544
6	.6283		.6401	.7023		.7316	.6468
7	.7577		.7316	.7762		.823	.7392
8	.7392	.7343	.7316	.7023	.6908	.7316	.7392
9		.6653	.6468	.6653	.6535	.5487	.6468
10		.5853	.5487		.4668	.4572	.6099
11		.5487	.3881	.543	.4668	.5487	.5544
12		.5487	.5544	.4024	.3734	.439	.4435
13	.5544	.5487	.6283		.3734	.6036	.4435
14	.5544	.4755	.4435	.4938	.3734	.5487	.4435
15	.462	.4024	.4066		.3734	.4938	.4435
16	.462	.4024	.4435	.439	.3734	.4207	.4435
17	.4755	.4572	.4805		.4668	.4755	.4805
18	.5281	.5487	.5729		.5601	.5544	.5175
19	.6602	.6401	.6468	.7356	.6535	.6468	.7023
20		.5487	.5544		.5601	.6468	.6468
21		.4572	.499		.4668	.4382	.5544
22	.4481	.4572	.4435	.415	.3734	.462	.499
23	.3772	.3658	.4251	.3961	.3696	.462	.462
24	.3881	.3696	.3658	.4066	.3395	.3696	.462
Max	.7577	.7343	.7316	.7762	.6908	.823	.7392
Min	.3326	.3658	.3658	.3511	.3395	.3658	.3696
Avg	.5048	.5150	.5106	.5189	.4667	.5287	.5251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 202 / SHEVADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269		1.1888	1.3321		.7316	.7316
2	1.2971		1.1888	1.3717		.7316	.7316
3	1.3717		1.2803	1.406		.7316	.7316
4	1.4746		1.2803	1.4582		.823	.823
5	1.5939		1.3717	1.4918		.823	.823
6	1.7635		1.4632	1.6575		.9145	1.0059
7	1.8564		1.7375	1.7166		1.0974	.9145
8	1.8896	1.8947	1.829	1.749	1.0242	.9145	1.0974
9		1.9845	1.7375		.7023	.9877	.7316
10		.8215	.6401		1.386	1.4022	1.7177
11			.679	.9055	1.386	1.6278	1.8313
12		.9335	.7545		1.6632	1.56	1.7901
13	.823	.9335	.811		1.6632	1.6108	1.8896
14	.9145	.8962	.7922	.7655	1.5708	1.6278	1.8564
15	.9145	.8589	.7922		1.5708	1.6617	1.8233
16	.823	.8589	.8299	.8596	1.7556	1.6956	1.8233
17	.9328	1.0269	.8676		1.4784	1.6956	1.8233
18	.7842	.7468	.9431		.8316	.7316	.7167
19	1.1016	1.0269	1.0829	1.0642	1.0164	1.0974	1.094
20		.9335	1.1203		.924	1.0974	1.1203
21		.8402	1.0562		.924	.9145	1.0456
22	.8962	.8402	.9054	.8299	.8316	.823	.9431
23	.8215	.8402	.7545	.7922	.7392	.6401	.7545
24	1.2094	1.086	1.1203	1.2403	.7545	.7392	.6401
Max	1.8896	1.9845	1.829	1.749	1.7556	1.6956	1.8896
Min	.7842	.7468	.6401	.7655	.7023	.6401	.6401
Avg	1.2052	1.0327	1.0928	1.2427	1.1895	1.1117	1.1858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 203 / Dagadgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949		.3277	.2294		.4096	.3277
2	.2949		.3277	.2622		.4096	.3277
3	.3277		.3277	.3277		.4915	.3277
4	.3277		.3277	.3932		.4915	.4096
5	.3605		.3277	.426		.5735	.4915
6	.3768		.4096	.4915		.6554	.6554
7	.3932		.4915	.5407		.9831	1.065
8	.4915	.3277	.5735	.5571	1.1797	1.1469	1.065
9		.5079	.4915	.5735	.213	1.1469	.1638
10		.5898	.5735		.4096	.1638	.5571
11		1.1142	.7537	1.1633	.4915	.426	.4096
12		1.0814	1.1961	1.3272	.2458	.6062	
13	1.1469	1.2125	1.0159		.2458	.6062	.4915
14	1.3108	1.1469	1.0486	1.1797	.3277	.6226	.5571
15	1.3108	1.0814	1.1142	1.2125	.4096	.6226	.6226
16	1.4746	1.2452	1.278	1.2452	.4096	.639	.639
17	1.5074	1.3927	1.4419	1.3763	.3277	.5243	.7537
18	.3932	.3277	1.278	.852	.5735	.5735	.8192
19	.4424	.4915	.4096	.4096	.4915	.3277	
20		.4096	.3932	.3605	.4915	.3277	.4915
21		.4096	.3605	.3277	.2458	.1638	.4915
22	.3277	.4096	.3277	.3113	.2458	.2458	.4588
23	.3113	.3277	.3113	.2713	.3277	.3277	.3932
24	.3277	.2949	.3277	.2785	.3391	.3277	.3277
Max	1.5074	1.3927	1.4419	1.3763	1.1797	1.1469	1.065
Min	.2949	.2949	.3113	.2294	.213	.1638	.1638
Avg	.6344	.7277	.6431	.6417	.4103	.5339	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 204 / Dapshed Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.4715	.415		.4715	.4715
2	.4338		.4715	.3772		.4715	.4715
3	.4527		.4715	.4527		.4715	.4715
4	.5281		.4715	.5281		.4715	.4715
5	.5658		.6602	.6036		.4715	.4715
6	.679		.8488	.7167		.5658	.5658
7	.7545		.8488	.7922		.8488	.7545
8	.7167	.7783	.7545	.7545	.6838	.7545	.7545
9		.6036	.5658	.7167	.6036	.4527	.7545
10		.5121	.5658		.4715	.3772	.5281
11		.5853	.4715	.5975	.3772	.3206	.415
12		.5121	.547	.5975	.3772	.3772	.3395
13	.5658	.4755	.547		.3772	.3772	.3206
14	.6602	.4755	.5281	.5041	.2829	.415	.3395
15	.5658	.4755	.5093		.2829	.4527	.3961
16	.6602	.5853	.5658	.5041	.3772	.4715	.3961
17	.6908	.6602	.6036		.3772	.5281	.4904
18	.547	.4715	.5658		.5658	.5658	.5281
19	.7167	.7545	.6224	.679	.7545	.7545	.7922
20		.6602	.4904		.6602	.6602	.6224
21		.5658	.4715		.5658	.5658	.547
22	.415	.4715	.4527	.4527	.4715	.4715	.5093
23	.3772	.4715	.4338	.415	.4715	.4715	.4527
24	.415	.3734	.4715	.4527	.415	.4715	.4715
Max	.7545	.7783	.8488	.7922	.7545	.8488	.7922
Min	.3772	.3734	.4338	.3772	.2829	.3206	.3206
Avg	.5623	.5548	.5588	.5623	.4774	.5108	.5140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 201 / MALAKOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.6401	.6468	.5516	.2926		.8316
2	.7392	.6767	.6873	.5538	.2926		.7762
3	.7762	.7762	.7282	.5556	.2743		.8871
4	.7762	.8402	.7978	.5636	.3109		.9316
5	.8215	.9335	.8548	.6635	.3696		1.0248
6		.9709	.9118	.6648	.4066		1.118
7	.9335	.8402	.9497	.8548	.4251		1.1643
8	.8402	.9335	.8548	.759	.4066	.3316	1.2197
9	.8962	.8548	.6648	.2012	.3361	.9795	.4108
10	.2195	.8916	.2213	.3109	.5653	.7326	.7842
11	.2378	.823	.2373	.3292	.5687	.7545	.7468
12	.2743	.823	.2718	.2743	.5693	.7583	.7095
13	.2378	.823	.2353	.2561	.5698	.7225	.6535
14	.2772	.8779	.235	.2195	.5693	.6655	.5975
15		.8688	.2715	.2378	.5693	.6845	.5601
16	.2378	.8145	.2703	.2743	.5681		.5601
17	.2561	.724	.2692	.2561	.6628	.6845	.6535
18	.2957	.6495	.3057	.2926	.2692	.8642	.2772
19	.4066	1.0425	.3244	.4108	.3673	.9955	.3696
20	.3658	1.1145	.3612	.3841	.3669	1.1888	.3696
21	.3658	1.0774	.362	.3696	.3326	1.1031	.3696
22		1.0402	.3083	.3696	.296	1.0349	.3696
23	.3326	.9979	.4549	.3292	.2972	.961	.3292
24	.6468	.6535	.6401	.5481	.3109		.9055
Max	.9335	1.1145	.9497	.8548	.6628	1.1888	1.2197
Min	.2195	.6401	.2213	.2012	.2692	.3316	.2772
Avg	.5066	.8620	.4943	.4263	.4165	.8307	.6925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 202 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	1.0269	.9055	1.0663	.2561		.5544
2	1.0269	1.2136	1.0217	1.2	.2378		.6099
3	1.1576		1.1203	1.3333	.2561		.6099
4	1.4003	1.4146	1.2347	1.5028	.2743		.8385
5	1.6617	1.5466	1.4816	1.5734	.2957		.8944
6	1.9239	1.6975	1.7475	1.6146	.3142		.9689
7	2.1691	2.2634	2.2034	2.2034	.3696		
8	2.2634	2.3577	1.9565	2.1632	.3511	.3316	1.0534
9	2.1125	2.1654	1.8805	.3142	.3142	.961	.3174
10	.2772	.7802	.1475	.2561	1.319	1.3525	1.4003
11	.2561	.6036		.2195	1.8578	2.0748	1.9239
12	.1829	.5487		.1829	1.8596	2.1232	2.0748
13	.1829	.439		.1829	1.8235	2.0915	1.9805
14	.1848	.4938	.1085	.1463	1.8976	1.9014	1.9239
15	.1848	.4887	.1448	.1463	1.9355	1.9965	1.8861
16	.1463		.1622	.1848	1.9695	1.9394	1.7353
17	.1829		.1615	.1829	1.5529	1.8634	1.6032
18	.1463	.5954	.1799	.2012	.1795	.5941	.2587
19	.2743	.823		.3174	.2755	.8145	.3142
20	.3475	.9474	.1806	.2926	.3119	.9145	.2957
21	.3109	.8359	.2172	.2926	.2772	.9009	.3142
22	.2743	.7802	.1814	.2743	.259	.7392	.2957
23		.7207	.6368	.2561	.2415	.6468	.2743
24		.9709	.7865	.8039	.2378		.6099
Max	2.2634	2.3577	2.2034	2.2034	1.9695	2.1232	2.0748
Min	.1463	.439	.1085	.1463	.1795	.3316	.2587
Avg	.8000	1.0816	.8229	.7046	.7778	1.3278	.9886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 203 / ASHTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2743	.7392	.2574	.8962		.8316
2	.2378	.2561	.743	.2585	.8589		.9055
3	.2561	.2743	.7282	.2593	.9149		.961
4	.2772	.3142	.9307	.3006	.9709		1.0248
5	.3511	.4066	1.1017	.3412	1.0829		1.0807
6	.462	.4668	1.3676	.3609	1.1694		1.1552
7	.462	.4854	1.4436	.4559	1.6032		1.386
8	.4108	.4668	1.3296	.4364	1.4146	1.1975	1.4784
9	.3921	1.2157	.3419	.3734	.2957	.924	.3361
10	.7842	.7802	.3504	1.0269	.2826	.8453	.3142
11	.6535	1.1523	.5476	1.0829	.2464	.7545	.2957
12	1.1576	1.0974	.5979	1.0456	.2277	.6256	.2772
13	1.0269	.5487	.5792	.9709	.1899	.6845	.2587
14	1.0829		.452	.9335		.6845	.7392
15	1.0456		.543	.924		.7415	.2218
16	1.0642	.8688	.5767	1.1317		.7415	.462
17	1.0269	.905	.5923	1.1576	.2462	.7986	.2587
18	.2195	.5413	.2338	.1052	.2872	.8102	.2772
19	.8402	.9877	.2703	.4108		.905	.4066
20	1.1203	1.1331	.307		.3669	1.0059	.3881
21	.3292	.9659	.3258		.3511	.956	.3696
22		.9288	.2902		.3145	.924	.2926
23	.2743	.8686	.2729	.8402	.3715	.6468	.8402
24	.2743	.2561	.7682	.2741	.9335		.7207
Max	1.1576	1.2157	1.4436	1.1576	1.6032	1.1975	1.4784
Min	.2195	.2561	.2338	.1052	.1899	.6256	.2218
Avg	.6089	.6906	.6430	.6165	.6512	.8278	.6367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 204 / Limboti Dam Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
5	.019		
6			.0373
7			.037
8	.019		.037
9			.0486
10	.0312		.0312
11	.0156	.0377	.0324
12		.0379	.0324
13	.0154	.019	.0324
14		.019	.0324
15		.019	.0324
16		.019	.0328
17			.0328
18		.018	.0328
19		.0362	.0332
20		.0366	.0328
21		.0184	.0328
22			.0324
23			.0156
Max	.0312	.0379	.0486
Min	.0154	.018	.0156
Avg	.0200	.0261	.0332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 201 / PENUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3944	.381	.3561	.407	.4694	.442
2	.4115	.4287	.4572	.3391	.4578	.4917	.4115
3	.442	.4287	.4572	.39	.5087	.4862	.6097
4	.4572	.3601	.4572	.407	.5426	.5087	.5639
5	.5487	.4287	.4572	.407	.5765	.5365	.6249
6	.5487	.5316	.4572	.5426	.5935	.5935	.6554
7	.5792	.6516	.5335	.5765	.6104	.6274	.6401
8	.5944	.5487	.5335	.6613		.4862	.5792
9	.5487	.583	.6001	.39	.503	.4287	.442
10	.3048	.4973	.381	.4409	.4694	.4287	.381
11	.3506	.3658	.4287	.4239	.4191	.4458	.381
12	.3353	.3048	.3429	.4024	.4024	.4115	.381
13	.3048	.3048	.3429	.285	.3353		.381
14	.2743	.3048	.3258	.2683	.3018	.4115	.381
15	.2743	.3048	.3185	.2515	.3353	.4973	.381
16	.3048	.3048	.3018	.3353	.4191	.4458	.381
17	.3353	.3353	.3353	.4359	.3688	.4458	.381
18	.3658	.381	.3688	.4694	.503	.463	.381
19	.6001	.4572	.503	.6203	.6203	.4115	.4572
20	.6344	.4572	.5533	.5868	.5868	.503	.5335
21	.5487	.4572	.5197	.5365	.5533	.4725	.5335
22	.5316	.4572	.503	.4862	.5197	.4572	.5335
23	.5144	.4572	.3688	.3521	.4024	.2896	.5335
24	.381	.4115	.381	.39	.4239	.4527	.381
Max	.6344	.6516	.6001	.6613	.6203	.6274	.6554
Min	.2743	.3048	.3018	.2515	.3018	.2896	.381
Avg	.4405	.4232	.4295	.4314	.4722	.4680	.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 202 / ANTESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.1715	.4572	.1715	.1509	.1543	.1524
2	.5335	.1715	.6097	.1715	.1509	.1715	.1524
3	.6097	.1715	.6097	.1715	.1677	.2058	.1524
4	.6706	.1715	.6097	.1715	.2543	.2572	.3048
5	.7011	.2286	.6097	.4287	.4862	.4287	.381
6	.7926	.5144	.6097	.5144	.8718	.7716	.3201
7	.8383	.8573	.4572	.5144	.9054	.8916	.3048
8	.8383	.5144	.4572	.8573	.4694	.8573	.1524
9	.6401	.4115	.4572	.7716	.4024	.8916	.2286
10	.8383	.4287	.7621	.9326	.8383	1.046	.7621
11	1.2193	.8078	.9431	1.17	1.17	1.0802	.7621
12	1.2193	1.1584	.9431	1.1869	1.2717	1.0974	.7621
13	1.1888	1.1431	1.0288		1.2378	1.0288	
14	1.1888	1.0669	1.0288	1.0174	1.1869	1.0802	.9145
15	1.1888	.9145	.9431	1.0682	1.1568	1.1488	.9145
16	1.1736	.7621	1.0288	1.0852	1.0682	1.0974	.9145
17	1.1584	.7621	1.0288	1.2717	1.1869	1.0631	.9145
18	.3048	.3048	.2572	.2515	.3353	.2915	.3048
19	.8402	.4572	.3429	.503	.7545	.5335	.381
20	.7716	.4572	.5144	.3353	.5868	.6097	.381
21	.6859	.4572	.5144	.1677	.3353	.5182	.381
22	.5144	.4572	.2572	.1509	.1677	.2286	.381
23	.2229	.4572	.2572	.1677	.1509	.1524	.381
24	.1524	.1715	.4572	.1715	.1677	.1543	.1524
Max	1.2193	1.1584	1.0288	1.2717	1.2717	1.1488	.9145
Min	.1524	.1715	.2572	.1509	.1509	.1524	.1524
Avg	.7780	.5424	.6327	.5762	.6447	.6567	.4546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 203 / Godawari Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1509	
2						.1677	
3						.2012	
4						.2515	
5						.4191	
6						.7545	
7						.8718	
8						.8383	
9					1.6108		
10	1.3717	.6097	1.829	1.6108	1.6108	1.5242	1.829
11	1.6004	1.829	2.0576	1.8652	1.95	1.9547	1.829
12	1.7071	1.8442	1.8861	1.8652	2.0517	1.8861	1.829
13	1.7071	1.829	1.7528	2.0348	2.0687	2.0576	1.829
14	1.7528	1.829	2.0576	2.0348	2.1195	1.9547	1.829
15	1.7528	1.829	1.7071	2.0348	2.0348	1.9547	1.829
16	1.7985	1.829	1.5242	2.0348	2.0348	1.869	1.829
17	1.829	1.829	1.7071	2.1195	2.1195	1.8861	1.829
24						.1509	
Max	1.829	1.8442	2.0576	2.1195	2.1195	2.0576	1.829
Min	1.3717	.6097	1.5242	1.6108	1.6108	.1509	1.829
Avg	1.6899	1.6785	1.8152	1.9500	1.9556	1.1114	1.829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 201 / Mohanpura Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4527	.4458	.5464	.4527	.4668	.4287
2	.3734	.4527	.4115	.547	.4527	.5601	.4287
3	.5601	.4108	.4115	.547	.4854	.5601	.4287
4	.7468	.4854	.5144	.5481	.4854	.7468	.5144
5	.7468	.6036	.6859	.6054	.679	.9335	.6001
6	.9335	.679	.7716	.7393	.8299	.9335	.7202
7	.9335	.8596	.8059	.945	.9431	.9335	.7202
8	.9335	.9054	.7888	.8573	.9619	.9335	.7545
9		.8127	.7468	.8573	.7749	.7545	.5601
10		.7167	.5601	.5487	.5228	.6161	.5601
11		.5653	.3734	.3772	.4854	.5228	.5601
12		.3742	.3734	.3772	.4682	.4904	.5601
13	.4115	.3003	.3734	.3772	.4682	.4527	.3734
14	.4287	.2245	.3734	.3772	.4504	.4527	.3734
15	.4287	.3715	.3734	.3944	.4879		.3734
16	.463	.4884	.3734	.4287	.5276	.415	.3734
17	.547	.4973	.4287	.5093	.5601	.5144	.4522
18	.6413	.5487	.4973	.5975	.5601	.583	.547
19	.7167	.7716	.6516	.7545	.7468	.6516	.6811
20	.7468	.6859	.6859	.679	.7468	.6687	.6054
21	.6722	.6173	.5658	.6413	.6535	.6001	.5658
22	.6036	.5658	.5487	.5658	.5601	.5144	.5653
23	.5658	.5144	.5316	.5228	.5601	.4458	.5082
24	.4668	.4904	.4801	.5636	.4904	.4668	.4287
Max	.9335	.9054	.8059	.945	.9619	.9335	.7545
Min	.3734	.2245	.3734	.3772	.4504	.415	.3734
Avg	.6147	.5581	.5322	.5795	.5981	.6181	.5285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 203 / Betsangavi Agri
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	1.8138	1.829	1.8338	.1132	.0934	.1029
2	2.0119	1.989	1.829	1.936	.1132	.0934	.1029
3	2.0119	2.2801	1.829	2.0096	.1132	.0934	.1029
4	2.3472	2.3472	1.9509	2.1101	.1494	.0934	.1029
5	2.5149	2.3868	2.0119	2.182	.1509	.0934	.1715
6	2.4577	2.4478	2.1338	2.3112	.1886	.1867	.2058
7	2.2939	2.4143	2.2558	2.3739	.2263	.1867	.2572
8	2.5149	2.2801	2.2558	2.1338	.2263	.1867	.1715
9		2.3445	2.5149	.1543	.1191	.1886	.1867
10		.1248	.1867	.1372	1.7298	1.9109	2.2405
11		.0719	.0934	.1029	2.3948	2.3868	2.4577
12		.0711	.0934	.1029	2.4842	2.3472	2.5149
13	.0857	.0591	.0934	.1029	2.5745	2.3594	2.4577
14	.1029	.0583	.0934	.1029	2.5914	2.3644	2.4577
15	.1029	.0581	.0934	.0857	2.6341	2.4813	2.6216
16	.1029	.0581	.0934	.0857	2.6541	2.42	2.6825
17	.1132	.1029	.0857	.1132	2.5149	2.3167	2.6795
18	.0943	.1029	.0857	.1132	.1867	.1029	.0743
19	.112	.1715	.1372	.112	.1867	.1715	.1185
20	.1867	.2058	.1372	.1509	.1867	.1715	.0959
21	.1509	.1372	.1372	.1509	.1867	.1715	.0711
22	.1509	.1372	.12	.1132	.1867	.1372	.0711
23	.1509	.1372	.9602	.1132	.0934	.1372	.0708
24	1.4403	1.6095	1.829	1.7444	.1132	.0934	.1372
Max	2.5149	2.4478	2.5149	2.3739	2.6541	2.4813	2.6825
Min	.0857	.0581	.0857	.0857	.0934	.0934	.0708
Avg	1.0395	.9754	.9521	.8490	.9216	.8662	.9231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 204 / Jawala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2353	.4024	.503	.3658
2		.2353	.407	.6535	.4572
3		.2365	.4359	.7468	.4572
4		.252	.5365	.7468	.5792
5		.2968	.5967	.8402	.6097
6		.3562	.663	.9335	.6401
7		.4118	.7865	.9335	.7011
8		.3944	.7045	.9335	.6859
9		.3429	.1471	.1886	.1867
10		.5335	.088	.1132	.0934
11		.7011	.1177	.132	.0934
12		.7011	.132	.1494	.0934
13		.7316	.1319	.1509	.1867
14		.7316	.132	.2263	.1867
15		.7011	.1471	.3018	.1867
16		.7011	.1767	.2641	.1867
17		.7449	.1867	.2229	.2365
18		.2218	.2801	.2229	.282
19		.3018	.3734	.3429	.2942
20	.2743	.3395	.3734	.3944	.282
21	.3258	.3511	.3734	.3429	.2671
22	.2915	.2641	.3734	.3086	.2375
23	.3086	.3688	.3201	.3353	.3353
24		.25	.407	.3277	.3658
Max	.3258	.7449	.7865	.9335	.7011
Min	.2743	.2218	.088	.1132	.0934
Avg	.3001	.4335	.3455	.4298	.3338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 201 / Janapuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.2454	.2713	.2229	.2263	.2263	.2641
2	.3121	.2804	.3052	.2543	.2263	.2263	.3018
3	.4115	.3429	.3391	.2883	.2452	.2263	.3395
4	.5426	.4024	.4458	.3353	.2452	.2452	.3584
5	.6036	.4915	.5548	.4024	.2641	.2829	.3772
6	.6718	.6226	.6859	.4973	.3772	.4338	.415
7	.9393	.8619	.9496		.4904	.4527	.4527
8	1.0486	.7537	1.073	.7373	.415	.3921	.3961
9		.8583	1.073	.3772	.3772	.3921	.3584
10		.3206	.2641	.3584	.5487	.6478	.3201
11		.2452	.2075	.2054	.9878	.8848	
12		.2075	.2452	.2054	1.004	.7865	.3086
13	.2075	.2241	.1886	.1307	1.0202	.852	.4321
14	.2263	.2452	.1886	.1886	1.004	.7865	
15	.2075	.1867	.2263	.2054	.9717	.7865	.7499
16	.1698	.1867		.2241	.9878	.8192	.9831
17	.2641	.2263		.2263	.9231	.852	
18	.2641	.2641		.1886	.1886	.2452	.1886
19	.3584	.3206		.3018	.2641	.3018	.2829
20	.3584	.3772	.2987	.1698	.3206	.3018	.3395
21	.2829	.3018	.3361	.3018	.2829	.3018	.3018
22	.2641	.2829	.3206	.3018	.2829	.2829	.3018
23	.2452	.2641	.3018	.2452	.2829	.2641	.3018
24	.2454	.1772	.2103	.1886	.2452	.2452	.2641
Max	1.0486	.8619	1.073	.7373	1.0202	.8848	.9831
Min	.1698	.1772	.1886	.1307	.1886	.2263	.1886
Avg	.3950	.3621	.4243	.2851	.5076	.4682	.3827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 202 / Wadepuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.4715	.5281	.2629	.2865	.3391
2	.4527	.4527	.4715	.5658	.2629	.2865	.3391
3	.4904	.4527	.4904	.6036	.2629	.3012	.373
4	.5281	.5281	.5093	.6413	.2804	.3189	.4024
5	.6036	.6036	.6602	.7167	.3721	.3155	.4191
6	.7167	.7356	.8488	.8488	.5434	.4207	.431
7	.8488	.9431	.9242	.9619	.6935	.6588	.5735
8	.8865	.8676	.8676	.9054	.7716	.6001	.5898
9		.7922	.7167	.811	.6602	.6224	.6413
10		.3258	.3856	.3353	.5847	.5658	.5658
11		.3647	.4854	.3688	.4715	.3584	.415
12		.4111	.4862	.3361	.4338	.3584	.3395
13	.431	.2949	.4359	.3563	.3961	.3206	.3395
14	.4475	.3113	.4359	.4062	.3772	.3584	.3772
15	.4144	.3201	.4641	.3321	.3584	.3395	.415
16	.4915	.3953	.5243	.3906	.3772	.3772	.4527
17	.5441	.4858	.4588	.4801	.5093	.5093	
18	.5281	.5658	.4527	.5093	.5093	.5281	.5658
19	.7922	.7922	.7167	.7167	.7545	.9431	.7545
20	.679	.7167	.6602	.7922	.679	.7922	.7167
21	.6036	.6224	.6224	.6413	.5658	.6224	.6602
22	.5658	.5281	.5658	.547	.5281	.5658	.5658
23	.5281	.4904	.5093	.2629	.2172	.2629	.4527
24	.4715	.5093	.4715	.5281	.2629	.2507	.3258
Max	.8865	.9431	.9242	.9619	.7716	.9431	.7545
Min	.4144	.2949	.3856	.2629	.2172	.2507	.3258
Avg	.5738	.5417	.5681	.5661	.4640	.4568	.4806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446]

BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 203 / Ratneshwari Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0179	.0179	.0179	.0179	.0179	.0179
2	.0179	.0179	.0179	.0179	.0179	.0179	.0179
3	.0179	.0179	.0179	.0179	.0179	.0179	.0179
4	.0177	.0179	.0179	.0177	.0179	.0173	.0179
5	.0177	.0179	.0179	.0177	.0179	.0173	.0179
6	.0175	.0179	.0179	.0175	.0179	.0173	.0179
7	.0175	.0354	.0175	.0175	.0351	.0358	.0177
8	.0175	.0177	.0173	.0175	.0343	.0358	.0175
9		.0177	.0343	.0171	.0171	.0351	.0175
10		.0175	.0343	.0171	.0171	.0351	.0175
11		.0166	.0343	.0171	.0351	.0351	.0173
12		.0166	.0343	.0181	.0351	.0351	.0168
13	.0177	.0166	.0171	.0168	.0351	.0343	.0168
14	.0177	.0156	.0171	.0168	.0351	.0343	.0168
15	.0177	.016	.0171	.0168	.0351	.0343	.0168
16	.0177	.0183	.0171	.0168	.0351	.0343	.0168
17	.0351	.0171	.0175	.0171	.0351	.0175	
18	.0347	.0173	.0175	.0171	.0335	.0175	.0171
19	.0347	.0173	.0175	.0171	.0335	.0175	.0171
20	.0175	.0175	.0175	.0351	.017	.0175	.0175
21	.0177	.0179	.0175	.0358	.017	.0175	.0358
22	.0179	.0179	.0179	.0179	.0179	.0175	.0179
23	.0179	.0179	.0179	.0179	.0187	.0175	.0179
24	.0179	.0179	.0179	.0179	.0179	.0187	.0179
Max	.0351	.0354	.0343	.0358	.0351	.0358	.0358
Min	.0175	.0156	.0171	.0168	.017	.0173	.0168
Avg	.0203	.0182	.0204	.0189	.0255	.0248	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174129 / 33 KV MALEGAON YATRA

Feeder No / Name : 201 / 11KV Nehru Nagar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1029	.1715	.6859	.5144
2		.1715	.1715	.1029	.1715	.7545	.6859
3					.2058	.823	.7888
4	.2058	.1715	.2058	.1715	.2058	.8916	.7545
5					.2058	.9259	.823
6		.2401	.2401	.2401	.2058	1.0288	.8573
7					.2401	1.0288	.9945
8	.2401	.2743	.3086	.3086	.2401	1.0288	1.0288
9					.1715		.2743
10	.3429	.6859	.7545	.6859	.1372	.1715	
11					.1372	.0686	
12	.8916	.7202	.9259	.8573	.1029	.0686	
13				.9259	.1029	.0686	
14	.9259	1.0288	.823	1.0288	.1029	.0686	
15				1.0288	.1029	.0686	
16	1.0288	.9945	.9259	.9945	.1372	.0686	
17				.9259	.1715	.1029	
18	.1029	.2058	.1372	.1715	.1715	.1372	
19				.1715	.2058	.1715	
20	.2058	.1029	.2058	.2058	.1715	.1715	
21				.1715	.1715	.1372	
22		.2058	.2058	.1715	.1715	.1372	
23	.2058		.1715	.1715	.4458	.4115	
24	.1715	.1715	.1372	.1029	.1715	.5144	.5144
Max	1.0288	1.0288	.9259	1.0288	.4458	1.0288	1.0288
Min	.1029	.1029	.1372	.1029	.1029	.0686	.2743
Avg	.4321	.4144	.4010	.4494	.1801	.4145	.7236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174129 / 33 KV MALEGAON YATRA

Feeder No / Name : 202 / 11 KV Malegaon(Yatra) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3772	.3429	.6859	.6859
2		.4115	.3429	.3772	.3429	.8573	.8573
3					.3429	1.0288	1.0288
4	.4458	.4458	.4115	.4115	.4115	1.2346	1.1317
5					.4458	1.3717	1.2003
6		.6173	.6173	.5144	.4458	1.5432	1.3032
7					.4801	1.6461	1.3717
8	.5144	.5144	.4801	.583	.4801	1.7147	1.3032
9					.4458		.2743
10	.5144	1.1317	1.2003	1.1317	.3429	.3086	
11					.3086	.2743	
12	1.4746	1.406	1.4746	1.5089	.2743	.3086	
13				1.4746	.2401	.2743	
14	1.5089	1.5432	1.5089	1.406	.2401	.2743	
15				1.3717	.2401	.2401	
16	.823	1.5432	1.4746	1.3717	.2743	.2743	
17				1.3717	.3086	.3086	
18	.3429	.3086	.3086	.3429	.3086	.3086	
19			.3429	.3429	.4115	.3772	
20	.4801	.4801	.4458	.3772	.4458	.4801	
21			.4801	.4115	.4458	.4458	
22	.4458	.4458	.4458	.4458	.4115	.4115	
23			.4115	.4115	.5144	.4458	
24	.4458	.3772	.3429	.3772	.3429	.6173	.5144
Max	1.5089	1.5432	1.5089	1.5089	.5144	1.7147	1.3717
Min	.3429	.3086	.3086	.3429	.2401	.2401	.2743
Avg	.6996	.7687	.6859	.7689	.3686	.6709	.9671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174129 / 33 KV MALEGAON YATRA

Feeder No / Name : 203 / 11KV Gaoundgaon SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.6461	1.4746	.2058	.1715
2		1.2346	1.2346	1.6461	1.5089	.2401	.2058
3					1.5432	.2743	.2401
4	1.3717	1.5775	1.7147	1.7147	1.5432	.3086	.2743
5					1.6118	.3086	.3086
6		1.6461	1.8519	1.7833	1.7147	.3429	.3429
7					1.7147	.3429	.3772
8	1.8861	1.7147	1.7147	1.9204	1.7833	.3429	.3429
9					.2058		.3086
10	.3429	.2058	.1372	.2058	1.7147	1.5432	
11					1.7147	1.6461	
12	.1029	.1715	.1029	.1029	1.749	1.7147	
13				.1029	1.8176	1.8176	
14	.1029	.1029	.1029	.1029	1.7833	1.8861	
15				.1029	1.7833	1.8861	
16	.1372	.0686	.1029	.1372	1.7147	1.8176	
17				.1372	1.7147	1.7147	
18	.2058	.1715	.2058	.1715	.2058	.1715	
19				.2058	.2401	.2058	
20	.2401	.2058	.2401	.2058	.2058	.2058	
21				.2058	.2058	.2058	
22	.2401	.2058	.2058	.2058	.1715	.2058	
23			.2058	1.0288	.1715	.2058	
24	.6859	.6859	.7545	1.4403	1.4403	.1715	.1715
Max	1.8861	1.7147	1.8519	1.9204	1.8176	1.8861	.3772
Min	.1029	.0686	.1029	.1029	.1715	.1715	.1715
Avg	.5316	.6659	.6595	.6877	1.2389	.7724	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174133 / 33/11 KV KIWALA STN

Feeder No / Name : 201 / 11 KV KIWLA GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2452	.3772	.2896	.3018	.3395	.3395
2	.415	.3395	.5281	.3258	.3395	.3395	.3395
3	.4527	.3772	.5658	.3982	.3395	.3772	.3772
4	.4904	.5658	.6036	.4706	.3772	.5281	.415
5	.5658	.679	.679	.5853	.4527	.6413	.4527
6	.6602	.7545	.7167	.6516	.5093	.7167	.5658
7	.7167	.7167	.7545	.6878	.7167	.7545	.7167
8	.7545	.6036	.7167	.7316	.679	.7167	.679
9		.6413	.4706	.7545	.5658	.6036	.6036
10		.5281	.4024	.7167	.4904	.4527	.5281
11		.4527	.362	.3772	.415		.415
12	.6036	.3772	.3982	.3395	.3395	.415	.3395
13	.3395	.3395	.3258	.3018	.3395	.415	.3018
14	.415	.3018	.3258	.3018	.3772	.3772	.3772
15	.3772	.3395	.3582	.3772	.3772	.3772	.415
16	.415	.3772	.394	.415	.415	.415	.4527
17	.4527	.4527	.4298	.4904	.5281	.4904	.3772
18	.5658	.4904	.4755	.4904	.5281	.5658	.5658
19	.6036	.5658	.3982	.4527	.5658	.6036	.6036
20	.5281	.5281		.4527	.6036	.6413	.679
21	.5658	.4527	.394	.3772	.5281	.6413	.4527
22	.6036	.415	.3658	.3395	.415	.4904	.3772
23	.4904	.3772	.2926	.3018	.3395	.3772	.3395
24	.3395	.4527	.2641	.2534	.3018	.3018	.3395
Max	.7545	.7545	.7545	.7545	.7167	.7545	.7167
Min	.3395	.2452	.2641	.2534	.3018	.3018	.3018
Avg	.5111	.4739	.4608	.4534	.4519	.5035	.4605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174133 / 33/11 KV KIWALA STN

Feeder No / Name : 202 / 11 KV BORGAON AGP FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.2641	.679	.543			
2	.8865	.2641	.7167	.5792			
3	.9431	.3772	.7545	.6878			
4	.9431	.5281	.7545	.7602			
5	1.0185	.7545	.7922	.8238			
6	1.0562	.9054	.7922	.9231			
7	1.094	.9619	.9431	1.0745			
8	1.1317	.9431	1.0751	1.134			
9					1.1694		
10					1.2071	.9997	.9054
11					1.2449	1.2449	1.1317
12					1.2071	1.2826	1.2637
13					1.1694	1.1694	1.2637
14					1.1317	1.1317	1.226
15					1.1694	1.0562	1.2826
16					1.2071	1.094	1.358
17					.9997	1.1317	.8865
23	.6036	.679	.5121				
24	.7545	.7167	.5658	.5373			
Max	1.1317	.9619	1.0751	1.134	1.2449	1.2826	1.358
Min	.6036	.2641	.5121	.5373	.9997	.9997	.8865
Avg	.9223	.6394	.7585	.7848	1.1673	1.1388	1.1647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174133 / 33/11 KV KIWALA STN

Feeder No / Name : 203 / 11 KV DHAKANI AGP FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.1886	.1886	.2896			
2	.3395	.1886	.7545	.3258			
3	.3772	.3395	.2263	.3582			
4	.4527	.415	.3018	.394			
5	.5093	.3772	.3772	.4344			
6	.6036	.4527	.547	.4887			
7	.7167	.5281		.5014			
8		.5658		.181			
10					.5847	.4338	.415
11					.5658		.4715
12					.547	.679	.547
13					.5281	.6413	.5658
14					.4715	.6413	.6036
15					.5658	.6036	.6224
16					.6036	.5658	.7167
17					.6036	.5658	.3395
23	.2829	.2452	.2195				
24	.2829	.3206	.2641	.2534			
Max	.7167	.5658	.7545	.5014	.6036	.679	.7167
Min	.2829	.1886	.1886	.181	.4715	.4338	.3395
Avg	.4338	.3621	.3599	.3585	.5588	.5901	.5352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 201 / 11KV MUDKHED (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2003	1.2003	1.1145	1.2269	1.2003	
2	1.0517	1.2003	1.2003	1.1145	1.1393	1.2003	
3		1.2003	1.2003	1.1145	1.1393	1.2003	
4	1.0517	1.2003	1.2003	1.1145	1.1393	1.2003	
5		1.2003	1.2003	1.1145	1.2269	1.2003	
6	1.2269	1.3717	1.286	1.2003	1.4022	1.286	
7		1.4575		1.286	1.5775	1.3717	1.4899
8	1.2269	1.286		1.286	1.4022	1.3717	
9	1.0669		1.2003	1.3146	1.3717		1.286
10	1.2003		1.1145		1.286		1.286
11	1.2003	1.3717	1.2003	1.1393	1.286		1.3717
12	1.1145	1.3717	1.2003			1.1393	
13	1.0288	1.3717	1.1145	1.2269	1.286		1.2003
14	1.0288	1.2003	1.1145		1.2003		1.2003
15	1.0288	1.1145	1.1145	1.1393	1.2003		1.2003
16	1.0288	1.2003	1.2003	1.1393	1.2003		1.2003
17	1.0288	1.2003	1.2003	1.2269	1.286		1.2003
18	1.2003	1.2003	1.2003	1.2269	1.286	1.3146	1.4937
19	1.3717	1.286	1.3717	1.5775	1.3717		1.4575
20	1.4575	1.286	1.3717	1.4899		1.4899	1.5432
21	1.286	1.286	1.5261	1.4899	1.4575		1.4575
22	1.286	1.286	1.286	1.4022	1.4575		1.3717
23	1.2003	1.2003	1.2003	1.3146	1.286		1.286
24	1.1393	1.2003	1.2003	1.2003	1.2269	1.307	1.2269
Max	1.4575	1.4575	1.5261	1.5775	1.5775	1.4899	1.5432
Min	1.0288	1.1145	1.1145	1.1145	1.1393	1.1393	1.2003
Avg	1.1612	1.2587	1.2229	1.2492	1.2934	1.2735	1.3295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 202 / 11KV MENDAKA

SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335	.6097	.5335	1.1717	1.3717	
2	.5468	.5335	.6097	.4572	1.1717	1.3717	
3		.5335	.6097	.4572	1.2498	1.5242	
4	.5468	.5335	.6097	.4572	1.2498	1.5242	
5		.5335	.6097	.4572	1.4842	1.6766	
6	.703	.6097	.7621	.6001	1.5623	1.829	
7		.6859		.6859	1.9528	1.9814	2.6292
8	.3906	.6097		.6097	1.8747	2.1338	
9	.4572	.6097	.381	.5468	1.7528		1.829
10	1.1431	.9145	1.6766		.381		.381
11	1.6766	.9145	2.0576	1.8747	.381		.381
12	1.5242	1.448	1.7528		.3048	.4382	.381
13	1.5242	1.448	1.6004	1.7185	.381		.381
14	1.3717		1.5242		.381		.381
15	1.3717	1.2193	1.3717	1.406	.381		.381
16	1.3717	.5335	1.5242	1.5623	.381		.381
17	1.448		1.6766	1.6404	.4572		.381
18	.4572		.5792		.6097	.6135	.4572
19	.5335	.4572	.6097	.6249	.6859		.5335
20	.6097	.5335	.6859	.7888		.8764	.6859
21	.6859	.5335	.6859	.703	.6859		.6859
22	.6097	.6097	.6097	.6249	.6859		.6097
23	.5335	.6097	.5335	.6249	.6859		.9907
24	.5468	.5335	.6097	.5335	.9374	1.2193	1.3146
Max	1.6766	1.448	2.0576	1.8747	1.9528	2.1338	2.6292
Min	.3906	.4572	.381	.4572	.3048	.4382	.381
Avg	.9026	.7113	.9859	.8453	.9047	1.38	.7520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 203 / 11KV IZALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	1.2193	.9145	.4687	.381	
2	1.0155	1.1431	1.2955	.9145	.4687	.381	
3		1.2193	1.3717	.9145	.4687	.381	
4	1.0936	1.2193	1.3717	1.0669	.4687	.381	
5		1.3717	1.448	1.2193	.5468	.381	
6	1.3279	1.448	1.5242	1.3717	.703	.4572	
7		1.6004		1.6766	.6249	.6097	.6135
8	1.8747	1.5242		1.7528	.5468	.4572	
9	1.6766	1.448	1.6766	1.6404	.4572		.381
10	.381	.381	.3048		1.448		1.0669
11	.381			.3125	1.6766		1.2193
12			.2286		1.7528	1.7528	1.2955
13			.3048	.2343	1.6004		1.3717
14			.3048		1.448		1.448
15			.3048	.3125	1.5089		1.5242
16	.2286	.3048	.3048	.3125	1.3717		1.6004
17			.3048	.3125	1.448		1.5242
18			.3353	.4687	.6859	.5258	.4572
19			.4572	.5468	.7621		.5335
20			.5335	.5468		.7011	
21	.5335		.5335	.5468	.5335		
22			.5335	.4687	.4572		
23	.6097		.4572	.4687	.4572		.4572
24	.7811	.6859	.6859	.7621	.4687	.381	1.3146
Max	1.8747	1.6004	1.6766	1.7528	1.7528	1.7528	1.6004
Min	.2286	.3048	.2286	.2343	.4572	.381	.381
Avg	.9003	1.1050	.7381	.7983	.8858	.5658	1.0577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 204 / 11KV DONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.6097	.5335	.703	1.0669	
2	.6249	.6097	.6097	.5335	.8592	1.0669	
3		.6097	.6097	.5335	1.0155	1.0669	
4	.6249	.6097	.6097	.5335	1.0936	1.2193	
5		.6859	.6097	.5335	1.3279	1.3717	
6	.7811	.6859	.6097	.6097	1.406	1.7147	
7		.6859		.6097	1.5623	1.6004	2.0157
8	.5468	.6097		.5335	1.5623	1.6004	
9	.381	.6097	.381	.4687	1.6004		1.6004
10	1.2955	.7621	1.1431		.381		.381
11	1.6004	1.6004	1.6004	1.5623	.381		.381
12	1.5242	1.5242	1.5242		.3048	.3506	.381
13	1.3717	1.2955	.7621	1.4842	.3048		.3048
14	1.2193	1.2955	.7621		.3048		.3048
15	1.2955	1.2955	1.2193	1.3279			.3048
16	1.2955	1.2193	1.3717	1.4842			.381
17	1.3717	1.3717	1.3717	1.4842			.381
18	.4572	.381	.381			.5258	.4572
19	.6097	.5335	.5335	.703	.6859		.6097
20	.6097	.6097	.6097	.703		.7011	.6859
21	.6097	.6097	.6097	.6249	.6859		.6859
22	.6097	.6097	.6097	.6249	.6859		.6859
23	.6097	.6097	.6097	.6249	.6097		.8383
24	.6249	.6097	.6097	.6097	.703	1.0059	.7888
Max	1.6004	1.6004	1.6004	1.5623	1.6004	1.7147	2.0157
Min	.381	.381	.381	.4687	.3048	.3506	.3048
Avg	.9032	.8351	.8071	.8061	.8514	1.1076	.6581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 205 / 11KV CRPF EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0905	.1086	.1029		.1029	
2		.0905	.1086	.0857		.0857	
3		.0905	.0905	.0857		.0857	
4		.0762	.0905	.0857		.0857	
5		.0905	.0905	.0857		.0857	
6		.1086	.0905	.1029		.1029	
7		.1267		.1372		.1494	.1052
8		.1267		.1372		.1029	
9	.1494	.1267	.0857		.1372		.1267
10	.1448	.1267	.1543		.1372		.1307
11	.1267	.1267	.0857		.1372		.1267
12	.1086	.1267	.0857		.1372	.0876	.1267
13	.0905	.1267	.0857		.12		.1494
14	.0905	.1448	.0857		.1029		.1629
15	.0905	.1448	.0686		.0857		.1448
16	.1086	.1448	.12		.1029		.1267
17	.1267	.181	.12		.1372		.1448
18	.181	.1629	.12		.1372	.1578	.1448
19	.181	.1448	.1372		.1867		.1629
20	.1629	.1267	.1543			.1753	.1629
21	.1267	.1267	.1543		.1372		.1629
22	.1086	.1086	.1372		.12		.1448
23	.0905	.1086	.1029		.1307		.1267
24		.0905	.1086	.1029		.1029	.1227
Max	.181	.181	.1543	.1372	.1867	.1753	.1629
Min	.0905	.0762	.0686	.0857	.0857	.0857	.1052
Avg	.1258	.1216	.1084	.1029	.1292	.1104	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 201 / NAGELI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.9145	.9145	.9145	.1372	.1524	.1372
2	.884	.9145	.9145	.9755	.1372	.1524	.1372
3	.9145	.9145	1.0364	1.0059	.1372	.1524	.1372
4	.945	1.0669	1.0364	1.0364	.1524	.1524	.1524
5	.9602	1.2193	1.1279	1.0669	.1677	.1677	.1677
6	.9907	1.2193	1.1888	1.0974	.1829	.1829	
7	1.2041	1.2955	1.1584	1.1584	.1829	.1829	
8	1.2193	1.2193	1.2193	1.1888	.1219	.1372	
9	1.1888	1.1431	1.3413	.0762	.0914	.0914	
10	.0914	.0762	.0762	.0914	1.1888	1.2955	
11	.0914	.0762	.0762	.0762	1.3413	1.2498	1.2955
12	.0762	.0762	.061	.0762	1.4022	1.4022	1.5242
13	.0762	.0762	.0762	.0762	1.3717	1.3413	1.4784
14	.0762	.0762	.0762	.0914	1.2803	1.2955	1.4327
15	.0762	.0762	.0762	.0914	1.2346	1.2346	1.4632
16	.0762	.0914	.0762	.0914	1.3717	1.3413	1.5089
17	.0762	.0914	.0762	.0914	1.2803	1.4327	1.5242
18	.0914	.1219	.1067	.0914	.0914	.1372	.0914
19	.1219	.1524	.1372	.1219	.1372	.1829	.1219
20	.1524	.1524	.1829	.1524	.1524	.2134	.1524
21	.1524	.1677	.1677	.1524	.1677	.1829	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.7316	.1372	.1524	.1524	.1372
24	.823	.884	.884	.1372	.1372		.1524
Max	1.2193	1.2955	1.3413	1.1888	1.4022	1.4327	1.5242
Min	.0762	.0762	.061	.0762	.0914	.0914	.0914
Avg	.4769	.5138	.5373	.4229	.5322	.5646	.6273

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 202 / 11KV BARASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097		.5487	.5487	1.3717	1.3717	1.3108
2	.6401		.5487	.5487	1.3717	1.3717	1.3413
3	.7011		.5487	.5792	1.3717	1.3717	1.3413
4	.7011		.6401	.6097	1.3717	1.3717	1.4022
5	.7316		.7316	.6706	1.5242	1.5242	1.4632
6	.7773		.7468	.7468	1.5242	1.5851	1.5546
7	.7011		.6859	.7316	1.6004	1.6156	1.7375
8	.6401		.6401	.6401	1.5242	1.5851	1.6766
9			.6097	.5487	.4572	.4572	.5944
10		1.6766	1.6004	1.6004	.4268	.4115	.4268
11	1.6766	1.7985	1.7375	1.829	.3048	.3048	.4268
12	1.6766	1.6766	1.6461	1.829	.3353	.3963	.3963
13	1.6766	1.5546	1.5851	1.6766	.3658	.381	.3658
14	1.5242	1.5546	1.5242	1.5242	.3353	.3658	.3353
15	1.5242	1.448	1.4327	1.3717	.3353	.3506	.3963
16		1.448	1.448	1.3717	.3963	.4268	.4268
17	1.5242	1.5546	1.5546	1.3717	.4572	.4877	.4572
18	.4877	.4268	.4572	.7316	.5182	.5487	.4877
19	.5487	.6401	.5639	.7621	.7316	.6401	.6401
20	.6401	.7316	.6554	.7621	.7011	.7011	.7621
21	.7316	.6706	.6859	.7011	.7011	.6706	.7316
22	.6401	.6097	.5792	.6859	.6706	.6554	.6706
23	.6097	.5792	.5639		1.3108	1.2041	1.326
24	.5792	.5487	.5487	1.2193	1.3717		1.2803
Max	1.6766	1.7985	1.7375	1.829	1.6004	1.6156	1.7375
Min	.4877	.4268	.4572	.5487	.3048	.3048	.3353
Avg	.9210	1.1279	.9285	1.0026	.8783	.8608	.8980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 203 / BARAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4458	.3658	.4572	.4572	.4268	.442
2	.4268	.4458	.3658	.4572	.4268	.3963	.442
3	.4268	.4458	.3963	.4268	.3963	.4115	.4268
4	.442	.4458	.3963	.4268	.3963	.3963	.4268
5	.442	.4801	.4877	.4877	.4268	.4268	.4268
6	.4572	.4973	.4877	.5182	.4572	.4572	.442
7	.503	.5144	.4725	.4877	.4877	.4572	.4725
8	.4115	.4458	.3963	.4572	.4115	.4115	.4115
9	.4268	.3506	.3963	.4572	.4115	.3963	.381
10	.4115	.4115	.3658	.4458	.3353	.3658	.3658
11	.4115	.4115	.3658	.3944	.3506	.3658	.3658
12	.4115	.4115	.3506	.4287	.3353	.3658	.3506
13	.3658	.4115	.381	.4287	.381	.3658	.3658
14	.3772	.3429	.4115	.4287	.381	.3963	.381
15	.3353	.4287	.4268	.4801	.4268	.4115	.3963
16	.3772	.3944	.3963	.4801	.3963	.4268	.4115
17		.4287	.381	.4973	.381	.4572	.4115
18	.5658	.463	.442	.5144	.3963	.4877	.4268
19	.583	.5316	.5182	.5487	.503	.4877	.4572
20	.5658	.5658	.5182	.583	.5182	.5182	.4877
21	.5658	.583	.503	.6001	.5335	.5487	.5182
22	.5487	.5316	.503	.583	.5182	.5182	.503
23	.5144	.5144	.4725	.5487	.4877	.4877	.4725
24	.4115	.4458	.3963	.5144	.4572		.4572
Max	.583	.583	.5182	.6001	.5335	.5487	.5182
Min	.3353	.3429	.3506	.3944	.3353	.3658	.3506
Avg	.4525	.4561	.4249	.4855	.4280	.4340	.4268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 204 / SHEMBOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.6004	1.4937	.4877	.4572	.5182
2	1.4327	1.3717	1.6766	1.4937	.4877	.4572	.5487
3	1.4632	1.3717	1.6766	1.5242	.4877	.5182	.5487
4	1.5089	1.5242	1.7985	1.5851	.5182	.5487	.5792
5	1.5699	1.829	2.2558	1.6156	.5792	.6097	.5792
6	1.6156	1.9814	2.1948	1.6766	.6401	.5792	.6097
7	2.0576	2.1338	2.1643	1.829	.6097	.5792	.6554
8	2.1338	1.9814	2.0271	2.0119	.5182	.5182	.5487
9	1.9204	1.829	2.0424	.4572	.4877	.4572	.4572
10	.4268	.4268	.3353	.4572	1.7985	1.829	1.829
11	.4268		.3658	.3353	2.1033	2.2253	2.0729
12	.4115		.3506	.3353	1.9052	2.1948	2.271
13	.3963	.3353	.3658	.3658	1.9814	1.9814	2.1338
14	.3963	.3353	.3658	.3963	1.829	1.9357	2.0119
15	.3963	.3658	.3963	.3963	1.7985	1.8595	2.0119
16	.3963	.3353	.3353	.4268	1.9052	2.0119	1.9814
17	.4572	.3963	.3353	.4268	2.0729	2.1491	2.0119
18	.4572	.3963	.4268	.4572	.4572	.4877	.4572
19	.4877	.5182	.503	.4877	.5182	.5182	.5182
20	.5182	.5182	.6097	.5182	.5487	.5487	.5792
21	.5792	.5182	.5792	.5792	.5792	.5792	.5792
22	.5792	.4877	.5639	.5487	.5792	.5487	.5487
23	.5487	.4572	1.2193	.5182	.5182	.5182	.5182
24	1.326	1.2803	1.2803	.5182	.4877	.4877	.5182
Max	2.1338	2.1338	2.2558	2.0119	2.1033	2.2253	2.271
Min	.3963	.3353	.3353	.3353	.4572	.4572	.4572
Avg	.9532	.9893	1.0612	.8523	.9958	1.0250	1.0453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 205 / Barad AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6097	.7621	.7316
2					.6859	.7621	.7926
3					.6859	.7621	.8535
4					.6859	.7621	.945
5					.7621	.823	1.0059
6					.7621	.9145	1.0364
7					.8383	.9907	1.0669
8					.9145	.9907	.9297
10	.8383	.8383	.823	.8383			
11	.9145	.9145	.945	.9907			
12	.9145	.8688	1.0669	.9145			
13	.9145	.8383	1.0974	.9145			
14	.8383	.7621	1.0669	.8383			
15	.8383	.6706	1.0364	.7621			
16	.9145	.7316	.7316	.8383			
17	.9145	.7926	.7621	.8383			
23					.6097	.6249	.7011
24					.6097		.6859
Max	.9145	.9145	1.0974	.9907	.9145	.9907	1.0669
Min	.8383	.6706	.7316	.7621	.6097	.6249	.6859
Avg	.8859	.8021	.9412	.8669	.7164	.8214	.8749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 206 / AMBEGAON AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.6859	.9145	.8688	.3353	.3048	.3048
2	.7011	.7621	.9145	.884	.3353	.3048	.3048
3	.7316	.7621	.9755	.9145	.3353	.2743	.3048
4	.7621		1.0669	.945	.3353	.3658	.3353
5	.8078	1.0669	1.1888	.9907	.3658	.4268	.3353
6	.8535	1.2193	1.2193	1.0212	.3658	.4268	.3506
7	1.0517	1.2193	1.1888	1.0974	.3963	.3963	.3506
8	1.0364	1.2193	1.0669	1.1584	.3658	.3048	.2896
9	.9907	1.0669	1.1279	.2743	.3048	.2439	.2743
10	.2134	.2134	.2134	.2286	1.3413	1.7985	1.6461
11	.2134		.1829	.2134	1.5242	1.7375	1.7528
12	.2134		.1829	.2134	1.6004	1.8595	1.8595
13	.2134	.1981	.1829	.2134	1.4327	1.7375	1.6766
14	.2134	.1829	.1981	.2134	1.4022	1.6918	1.7071
15	.2439	.2134	.1981	.2134	1.3717	1.6613	1.7375
16	.2439	.2134	.1829	.1829	1.4937	1.6766	1.768
17	.2743	.2439	.2591	.1524	1.6156	1.7071	1.7985
18	.3353	.2743	.3201	.1524	.2439	.2743	.2439
19	.3506	.3963	.381	.1524	.3963	.3353	.3353
20	.381	.4268	.3963	.1524	.3963	.3353	.4115
21	.381	.3963	.381	.4268	.4268	.3658	.4115
22		.381	.381	.3963	.3963	.3506	.3963
23		.3658	.6859	.3658	.3658	.3353	.381
24	.6401	.6706	.6706	.3658	.3353	.3353	.3353
Max	1.0517	1.2193	1.2193	1.1584	1.6156	1.8595	1.8595
Min	.2134	.1829	.1829	.1524	.2439	.2439	.2439
Avg	.5238	.5799	.6033	.4915	.7284	.8021	.8046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 207 / DONGARGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1219	.0914	.0914	.7621	.7621	1.0059
2	.0762	.1219	.0914	.0914	.7621	.7621	1.0364
3	.0762	.1219	.0914	.1067	.7621	.823	1.0974
4	.0762	.1219	.0914	.1067	.9145	1.0364	1.1279
5	.0914	.1219	.1219	.1219	1.0669	1.0669	1.1584
6	.0914	.1219	.1219	.1219	1.0669	1.1279	1.1888
7					1.1431	1.1888	1.2193
8					1.0669	1.2498	1.1279
10	.9907	.9145	1.1279	1.1279			
11	1.0669	1.3413	1.4632	1.2955			
12	1.2193	1.0974	1.2193	1.2955			
13	1.2193	.945	1.1584	1.2193			
14	1.2193	.9907	1.0974	1.2193			
15	.7621	.9907	1.0974				
16	1.2193	1.0059	1.0517	.9145			
17	1.2193	1.0974	1.0974	.6097			
19	.1219	.1219	.0914	.1219	.1219	.1067	.1219
20	.1219	.1219	.1067	.1219	.1219	.1219	.1524
21	.1219	.0914	.1219	.1219	.0914	.1219	.1524
22	.1219	.0914	.1219	.1219	.0914	.1524	.1372
23	.1219	.0914	.1067	.6859	.7011	.9145	.9145
24	.0762	.0914	.0914	.7621	.7621	.7621	.9907
Max	1.2193	1.3413	1.4632	1.2955	1.1431	1.2498	1.2193
Min	.0762	.0914	.0914	.0914	.0914	.1067	.1219
Avg	.5045	.4862	.5281	.5399	.6739	.7283	.8165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 201 / 11 Kv Niwgha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7773	.7611	.8421	1.0688	.8421	.8421
2		.7773	.7935	.8421	1.0688	.8583	.8421
3		.8421	.8421	.8421	1.1012	.9393	.8421
4		.9717	.9717	.8745	1.1336	1.0364	.9717
5		1.0688	1.1012	1.166	1.166	1.2308	1.166
6		1.3117	1.2146	1.2955	1.1984		1.3603
7					.9717		
8	1.166	1.1174	1.1822	1.166	1.1336		1.1012
9	1.2955	1.3927	1.2955	1.2955	1.0688	.9069	.7773
10	1.2308	1.2146	1.166	1.1984	.8097	.7125	.6802
11	1.1012	1.0364	1.1012	1.0688	.5506	.6478	.5344
12	1.085	.8097	.9717	.9393	.5182	.5182	.502
13	.8421	.8421		.9717	.4858	.4534	.4858
14	.9069	.8745	.9717	1.004	.4858	.4534	.4858
15	.9393	.9231	1.4251	1.0688	.4858	.4534	.4858
16	1.0688	1.004	.9717	1.0688	.5668	.6154	.5506
17	.7125	.5992	.6478	.7449	1.3279	1.2955	1.4899
18	.7125	.6478	.9717	.8097	1.3765	1.2955	1.4575
19	.8421	.8097	.8421	1.004	1.2146	1.166	1.3927
20	.9393	.9069	.8421	.9717	1.0688	1.166	1.2308
21	.8421	.7773	.9145	.8745	1.004	1.166	1.2146
22	.7935	.7449	.7773	.9069	.9717	1.0364	1.1822
23	.7611	.7287	.7773	.8745	.9555	1.0364	1.2146
24		.7611	.7287	.7773	.8745	.9393	.9717
Max	1.2955	1.3927	1.4251	1.2955	1.3765	1.2955	1.4899
Min	.7125	.5992	.6478	.7449	.4858	.4534	.4858
Avg	.9524	.9104	.9669	.9829	.9420	.8938	.9470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 202 / 11 kv Pardi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3077	.2915	.2591	1.4575	1.3603	1.4251
2	.3239	.3077	.2915	.2591	1.4899	1.4413	1.4251
3	.3239	.3239	.2915	.2591	1.5546	1.4575	1.4899
4	.3887	.3401	.3077	.3239	1.587	1.4575	1.4899
5	.3887	.3563	.3563	.3239	1.6194	1.4899	1.4899
6	.3887	.3725	.4049	.3887	1.6194	1.4899	1.6194
7	.3887	.3887	.3887	.3887	1.6194	1.6842	1.8785
8	.3887	.3401	.3401	.3239	1.587		1.8138
9	.3239	.3563	.3239	.3563	.2429	.2591	.3887
10	.3239	.3239	.3239	.3239		.2915	.2915
11	.2591	.3077	.2591	.2915		.2591	.2267
12	.2267	.2591	.2591	.2267	.2267	.2591	.2267
13	.2267	.2591		.2267	.2591	.2591	.2591
14	.2267	.2591	.2591	.2267	.2591	.2591	.2267
15	.2267	.2429	.2267	.2267	.2267	.1943	
16	.2267	.2429	.2267	.2267	.2105	.2591	.2105
17	2.1052	2.0405	2.1376	2.0405	.2267	.1943	.2591
18	1.9433	1.8785	1.8785	1.9433	.2591	.2591	.3239
19	1.8461	1.749	1.749	1.6518	.2915	.2591	.3563
20	1.7328	1.6194	1.6194	1.6518	.3239	.3887	.3725
21	1.7004	1.587	1.6194	1.6518	.3239	.3887	.3563
22	1.5384	1.5708	1.6194	1.6194	.3239	.3239	.3239
23	1.587	1.587	1.6194	1.6194	.3239	.3239	.3077
24	1.4575	1.5546	1.5223	1.6194	1.4575	.3239	.3239
Max	2.1052	2.0405	2.1376	2.0405	1.6194	1.6842	1.8785
Min	.2267	.2429	.2267	.2267	.2105	.1943	.2105
Avg	.7861	.7740	.7963	.7679	.7950	.6471	.7428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 203 / 11 KV Khambal feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6194	1.6842	1.749	.0648	.0648	.0972
2	1.6194	1.6842	1.7166	1.749	.081	.0648	.0972
3	1.749	1.7004		1.749	.081	.0648	.0972
4	1.749	1.749	1.7814	1.8785	.0972	.0648	.0972
5	1.8785	1.8461	1.8623	2.0081	.0972	.0648	.0972
6	2.0729	2.0243	2.0729	2.0081	.0972	.1134	.0972
7	2.5911	2.5911	2.4291	3.0769	.1134	.1134	.0972
8	2.1376	2.2996	2.1052	2.2348	.1134		.0972
9	.0972	.0648	.0972	.1134	1.6194	2.5263	2.4291
10	.0162	.0648	.0972	.0648	1.6518	2.2672	2.3644
11	.0162	.0648	.0648	.0648	1.9757	2.2672	2.2348
12	.0324	.0648	.0648	.0648	2.0081	1.749	2.0567
13	.0324	.0648		.0648	2.0081		2.0243
14	.0324	.0648	.0648	.0648	2.0729	1.8138	1.9757
15	.0324	.0486	.0648	.0648	2.0729	1.9433	2.0405
16	.0324	.0486	.0648	.0648	2.1052	2.0081	2.1052
17	.0486	.0486	.0972	.0648	.081	.0972	.081
18	.0648	.0648	.0972	.081	.081	.0972	.0648
19	.0486	.081	.0972	.0972	.081	.0972	.0972
20	.081	.0648	.0972	.0972	.081	.0972	.0972
21	.0648	.0648	.0972	.081	.0648	.0972	.0648
22	.0648	.0648	.0972		.0648	.0972	.0648
23	.0648	.0648	.0972	.0648	.0648	.0972	.0648
24	.0972	.0648	.0648	.0972	.0648	.0648	.081
Max	2.5911	2.5911	2.4291	3.0769	2.1052	2.5263	2.4291
Min	.0162	.0486	.0648	.0648	.0648	.0648	.0648
Avg	.6768	.6883	.6780	.7654	.7018	.7214	.7760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 201 / 11 KV Mahati

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.3108	1.3336	1.0526	.3487	.381	.3361
2	1.2955	1.3108	1.3923	1.0526	.3487	.3841	.3361
3	1.3927	1.3108	1.5003	1.1336	.3487	.4049	.3361
4	1.4899	1.3435	1.5912	1.2308	.3719	.4321	.5041
5	1.6518	1.4091	1.6337	1.3603	.43	.4355	.5521
6	1.7166	1.5813	1.6518	1.5546	.5346	.553	.5761
7	1.8947	1.821	.821	1.749	.567	.5761	.5761
8	1.9433	1.866	1.2477	1.8138	.5197	.4985	.567
9	1.9109	1.8128	1.2146	1.7438	.4915	.4321	.5335
10	.43	.3993	.4001	.3887	1.5601	1.4723	1.6194
11	.3951	.3494	.3734	.2873	1.6289	1.9845	2.0243
12	.3429	.3064	.3467		1.7267	1.9204	1.8595
13	.2743	.2703	.3201	.2431	1.7918	1.9204	1.9757
14	.2789		.3201	.2321	1.7593		2.0081
15	.2905		.3201	.2673	1.7593		2.1052
16	.3071		.3201	.3138	1.7918		2.17
17	.3601		.3201	.3601	1.9109		2.1052
18	.4441		.3467	.4401	.4992		.5068
19	.5365	.5816	.4534	.5697	.5591		.5601
20	.5041	.5521	.5335	.5573	.5281	.6036	.6135
21	.4489	.5281	.4801	.4954	.5041	.5533	.5335
22	.3898	.4839	.4268	.439	.4525	.4527	.4534
23	.378	.4633	.4001	.3841	.4016	.3521	.3201
24	1.2631	1.2452	1.2597	1.0364	.3603	.381	.3361
Max	1.9433	1.866	1.6518	1.8138	1.9109	1.9845	2.17
Min	.2743	.2703	.3201	.2321	.3487	.3521	.3201
Avg	.8848	.9971	.7920	.8133	.8831	.7632	.9795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 202 / 11 KV Malkautha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.6737	.6636	.6935	1.9925	1.9338	.4588
2	.6935	.6737	.7259	.6668	1.9925	2.0348	.5243
3	.6935	.6737	.7682	.6668	1.866	2.0553	.5243
4	.7735	.7514	.8162	.8269	1.9925	2.0885	.6554
5	.9069	.8551		.9069		2.1168	.7209
6				.9602	2.3015	2.6543	.7209
7					2.4387	2.7199	.6554
8	.6401	.8173	.8425		2.3562	2.5839	1.9662
9	.6851	.6935	.7468		.5658	.4801	.5868
10	1.8976	2.3731	2.2348		.5106	.4801	.5601
11	2.2497	2.5412	2.5263	2.2222		.3841	.5068
12	1.9372	2.652		2.372	.4595	.3361	.4534
13	1.9608	2.6189	2.0729	2.4669	.434	.4321	.2134
14	2.3482	2.3339	2.3967	2.4996	.421	.3841	.2
15		2.0005	2.4615	2.4371	.4301	.4321	.2
16	2.4577	2.3672	2.5911	2.4371	.4458	.4321	.4934
17	2.4577	2.2542	2.5263	2.4996	.4458	.5281	.5335
18		.5952	.6401		.7819	.6241	
19	.8928	.873	.7468	.9069	.8688	.9587	.8002
20	.8792	.7373	.8002	.8802	.7625	.9069	.8535
21	.8402	.7404	.8535	.8269	.7099	.9069	.8002
22	.8002	.7148	.8002	.7468	.715	.7468	.7202
23	.7255	.6893	.7735	1.8027	1.8896	2.0972	2.0729
24	.6935	.6737	.6893	.7202	1.9608	1.9227	.4588
Max	2.4577	2.652	2.5911	2.4996	2.4387	2.7199	2.0729
Min	.6401	.5952	.6401	.6668	.421	.3361	.2
Avg	1.2613	1.3320	1.3338	1.4494	1.1973	1.2600	.6817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 203 / 11 KV Rohipimpalgaon
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.166	1.1401	.9717	.2195	.2229	.2195
2	.9717	1.166	1.2266	.9717	.2195	.2229	.2195
3	1.0688	1.166	1.3003	.9717	.2439	.2458	.2195
4	1.166	1.166	1.3336	.9717	.2439	.2477	.2743
5	1.2631	1.166	1.326	1.004	.2761	.2703	.2439
6	1.3279	1.2071	1.3592	1.1012	.3086	.2721	.2926
7	1.3279	1.3077	1.367	1.166	.281	.2721	.2926
8	1.3603	1.3466	1.3108	1.2631	.2717	.2683	
9	1.3413	1.0751	1.2146	1.2334	.2324	.192	1.2631
10	.144	.0995	.16	.168	1.3982	1.1934	1.4575
11	.0335	.1115	.16	.1536	1.4243	1.326	1.4899
12	.0335	.1326	.16	.0335	1.4413	1.326	1.4899
13	.1334	.1395	.16	.0335	1.4494	1.2597	1.4575
14	.1446	.1627	.16	.1509	1.4163	1.1271	1.4251
15	.1555	.1587	.1334	.16	1.3904	1.0608	1.4251
16	.1947	.1395	.1334	.1734	1.3641	1.1271	1.3603
17	.2086	.1395	.1334	.1951	1.3565	1.1934	1.2955
18	.2	.2058	.1734	.2408	.2782	.2225	.2401
19	.3111	.2808	.2401	.3292	.3361	.3338	.2667
20	.2934	.2724	.2801	.3292	.2892	.2782	.2934
21	.2591	.2477	.2667	.2976	.261	.2782	.2667
22	.2462	.2477	.2401	.2667	.2591	.2782	.2401
23	.2332	.216	.2134	.2195	.2332	.2225	.2134
24	.9717	1.1488	1.153	.9717	.2195	.2229	.2195
Max	1.3603	1.3466	1.367	1.2631	1.4494	1.326	1.4899
Min	.0335	.0995	.1334	.0335	.2195	.192	.2134
Avg	.5984	.6029	.6394	.5574	.6422	.5693	.7029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 204 / DAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5243	.5304		.8962	.9337	.9831
2	.4858	.5243	.5668		.8962	.9981	.9831
3	.4858	.5243	.6262		.8962	1.0303	1.0814
4	.6154	.5735	.6592		.8962	1.0947	1.1469
5	.6478	.639	.6962		.8962	1.1336	1.2125
6	.664	.6718	.7293		1.1203	1.3603	1.2125
7	.583	.6062		.421	1.3123	1.4251	1.3435
8	.4858	.5079	.5243	.5182	1.3123	1.3603	1.3108
9	.4096	.3449	.3239	.4372	.322	.2622	.3239
10	.9503	1.0814	1.0364		.2254	.2622	.2753
11	1.3108	1.1536	1.0364	1.0364	.2254	.2294	.2591
12	1.3108	1.1797	1.0364	1.2239	.2576	.1966	.2429
13	1.2452	1.1536	1.0364	1.1336	.2254		.2429
14	1.2125	1.1206	1.004	1.0688	.2622		.2429
15	1.1469	1.0511	.9393	1.0526	.2606	.1311	.2267
16	1.2289	.9831	.8583	1.004	.2898	.2622	.2267
17	1.2125	1.0547	.8097	1.0883	.2949	.3277	.2915
18	.3441	.3626	.3239	.3681	.5182	.3932	.3563
19	.639	.6592	.5182	.6081	.619	.6554	.5182
20	.6226	.6554	.6154	.6081		.6226	.5506
21	.6062	.4706	.583	.5761	.5441	.5898	.5182
22	.5735	.4698	.5506	.5601	.483	.5571	.4534
23	.5571	.5636	.5182	.8642	.8745	1.0486	.9393
24	.4858	.5243	.5304		.8802	.9015	1.0159
Max	1.3108	1.1797	1.0364	1.2239	1.3123	1.4251	1.3435
Min	.3441	.3449	.3239	.3681	.2254	.1311	.2267
Avg	.7629	.7250	.6980	.7855	.6308	.7171	.6649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 205 / Chikala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7773	.9717	.7537	.7773	.3887	.3887	.3239
2	.7773	.9717	.8335	.7773	.3887	.4534	.3239
3	.8745	.9717	.9054	.8421	.421	.5001	.421
4	.9717	.9717	.9669	.8745	.4534	.5243	.4858
5	1.0364	.9717	.9945	.9717	.5182	.5152	.583
6	1.085	1.0688	1.1536	1.1012	.664	.6882	.583
7	1.166	1.1498	1.1934	1.166	.664	.7176	.7125
8	1.2631	1.247	1.278	1.2955	.6154	.6922	.6802
9	1.278	1.1206	1.1984	1.2631	.5219	.5182	.5182
10	.421	.4588	.3725	.4111	1.1797	1.2631	1.2955
11	.3725	.3932	.3239	.3321	1.2125	1.2631	1.3279
12	.3239	.2966	.2915	.3163	1.1728	1.2955	1.3765
13	.2267	.2966	.2591	.3163	1.1797	1.3279	1.2955
14	.2591	.3277	.2591	.2846	1.1469	1.2955	1.2308
15	.2915	.3605	.2591	.3005	1.2054	1.2631	1.2308
16	.3563	.3296	.2915	.3163	1.1797	1.2955	1.2308
17	.421	.431	.3563	.3841	1.2631	1.3927	1.166
18	.5182	.431	.421	.4801	.4534	.421	.4372
19	.6154	.6299	.4858	.5761	.5182	.583	.5506
20	.5668	.5933	.4858	.5761		.583	.5992
21	.4858	.5636	.4696	.5121	.4858	.4858	.5506
22	.3887	.5636	.4534	.4321	.4534	.421	.4534
23	.3563	.4973	.421	.3681	.421	.3563	.3563
24	.7125	.8124	.7377	.7449		.3887	.3239
Max	1.278	1.247	1.278	1.2955	1.2631	1.3927	1.3765
Min	.2267	.2966	.2591	.2846	.3887	.3563	.3239
Avg	.6477	.6846	.6319	.6425	.7503	.7764	.7524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 201 / ARDHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.4746	1.6221	1.6575	1.5432	1.5775	1.6575
2	1.4232	1.4575	1.6032	1.6575	1.5432	1.5775	1.6575
3	1.4232	1.5432	1.6461	1.6004	1.5089	1.5432	1.6194
4	1.5604	1.5432	1.6975	1.6004	1.5432	1.6289	1.6194
5	1.5947	1.5947	1.6461	1.6766	1.5775	1.6289	1.6766
6	1.6804	1.6289	1.6975	1.7909	1.6804	1.7147	1.7909
7	1.6804	1.6289	1.6975	2.0195	1.8519	1.7147	2.0005
8	1.6289	1.7147	1.6598	1.9052	1.6804	1.7147	2.0005
9		1.5432		1.8861	1.5947	1.5432	1.8861
10	1.6598	1.6598	1.4575	1.5947	1.6194	1.5432	1.6289
11	1.5089	1.5089	1.406	1.4232	1.6194	1.5432	
12	1.5089	1.4146	1.406	1.4232	1.5623	1.3717	1.4575
13	1.4712	1.4146	1.406	1.3717	1.5623	1.3717	1.406
14		1.5089	1.406	1.3375	1.5623	1.3717	1.406
15	1.5089		1.406	1.3375	1.5432	1.3717	1.406
16	1.5089	1.5089	1.3717	1.3375	1.5051	1.3717	1.4575
17	1.5432	1.6975	1.7147	1.3717	1.5432	1.7147	1.5089
18	1.6289	1.6975	1.9433	1.6632	1.7147	1.8861	1.6461
19	2.0576		2.0767	1.8861	1.749	2.0576	1.8861
20	1.6289	1.7353	2.0767	1.8004	1.8004	2.0576	1.8519
21	1.6289		2.0195	1.7147	1.749	2.0005	1.8004
22	1.5947	1.6461	1.8861	1.6289	1.7147	1.8861	1.8004
23	1.5432	1.6461	1.6598	1.6289	1.6289	1.848	1.6804
24	1.5604	1.5089		1.7337	1.5775	1.6289	1.7337
Max	2.0576	1.7353	2.0767	2.0195	1.8519	2.0576	2.0005
Min	1.4232	1.4146	1.3717	1.3375	1.5051	1.3717	1.406
Avg	1.5803	1.5750	1.6594	1.6270	1.6240	1.6528	1.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 202 / DABHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4115		.4763	.3772	1.166	1.1145
2	.3601	.4115		.4572	.3772	1.2346	1.1145
3	.3944	.4115		.4382	.3601	1.3032	1.0802
4	.4287	.4458		.4382	.3944	1.3375	1.1831
5	.4287	.4801		.4191	.4115	1.406	1.3717
6	.463	.4801		.4001	.4801	1.4746	1.5775
7	.3944	.3944		.4191	.4287	1.6461	1.7833
8	.3601	.3772		.381		1.6289	1.9033
9		.5658		.3429	.2915	.3429	.3239
10	1.773	1.4523	1.3032	1.2689	1.3546	.3258	.3258
11	1.7193	1.773	1.3889	1.6118	1.5261	.3429	.3086
12		1.773	1.4746	1.6804	1.6461	.2743	.2743
13	1.8484	1.773	1.5089	1.5775	1.6118	.3772	.2743
14	1.773	1.773	1.5261	1.4232	1.406	.3772	.2743
15	1.6409	1.6095	1.406	1.4403	1.406	.3601	.3086
16	1.6598	1.5089	1.3032	1.4575	1.4575	.3086	.2743
17	1.4746	1.5278	1.3203	1.5947	1.5947	.4382	
18	.3601	.4755	.3048	.3772	.3601	.4382	.4458
19	.463	.4024	.5716	.4115	.5144	.5335	.4973
20	.463	.4527	.5144	.4801	.5487	.6668	.5487
21	.463	.4527		.5144	.5487	.6097	.5144
22	.4458	.4904	.5525	.4801	.5316	.6478	.463
23	.4458	.4755	.4954	.463	.0343	1.1812	1.1488
24	.3944	.4458	.439	.4763	.4287	1.0974	1.0802
Max	1.8484	1.773	1.5261	1.6804	1.6461	1.6461	1.9033
Min	.3601	.3772	.3048	.3429	.0343	.2743	.2743
Avg	.8233	.8485	1.0078	.7929	.7865	.8133	.7909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 203 / Dabhad-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.7545	.8413	.7621	.6859	1.4403	1.406
2	.6859	.8059		.7621	.6859	1.4746	1.4232
3	.7716	.8573	.9808	.724	.7202	1.6289	1.4232
4	.823	.9431		.6668	.7716	1.6461	1.5089
5	.8916	1.0288		.703	.8573	1.7318	1.6289
6	1.0974	1.0631		.8745	1.046	1.7661	1.749
7	.9602	.9431		.9602	.9774	1.7833	2.0576
8	.7373	.7545	2.5086	.8059	.7888	1.9204	2.1262
9		.703		.6859	.4973	.583	.5525
10	1.7353	1.9239	1.4746	1.4746	1.7661	.4458	.4801
11	1.9239	1.9239	2.0233	1.9204	1.9204	.4287	.4458
12	2.0748	1.9805	1.6804	2.0233	1.9719	.4115	.4287
13	2.0748	2.0748	1.6118		1.9719	.3944	.3429
14	1.9993	1.8861	1.5947		1.5604	.463	.3601
15	1.9427	1.8861	1.6632	1.6804	1.7147	.4458	.3772
16		1.9239	1.5261	1.8347	1.869	.4801	.4458
17	1.2517	1.8656	1.7318	2.0233	1.9204	.6173	.5487
18	1.2003	.9431	.6668	.6344	.703	.7049	.6687
19	.8573	.9431	.9907	.8059	.7888	.9335	.8745
20	.8916	.9431	1.0479	.8745	.8059	.9526	.8916
21	.8916	.9431	.9145	.8573	.823	.9335	.823
22	.8745	.9431	.8764	.7716	.8059	.8764	.7888
23	.7888	.9431	.8383	.7373	1.3375	1.5623	1.4403
24	.7373	.7545	.8676	.8002	.7202	1.3717	1.406
Max	2.0748	2.0748	2.5086	2.0233	1.9719	1.9204	2.1262
Min	.6859	.703	.6668	.6344	.4973	.3944	.3429
Avg	1.1779	1.2388	1.3244	1.0628	1.1546	1.0415	1.0082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 204 / MENDHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0631	1.1694	1.2574	1.0631	.5487	.5144
2	1.0288	1.1317	1.2449	1.2574	1.0631	.6516	.6001
3	1.0631	1.2689	1.2449	1.3527	1.166	.7716	.7888
4	1.1145	1.406	1.2449	1.2174	1.2003	.8573	.823
5	1.3375	1.4746	1.6221	1.286	1.2346		
6	1.5432	1.5604	1.7164	1.6461	1.2346		
7	1.9033	1.7833	2.1313	2.0748	1.8861		
8	2.0576	1.9376	2.1313	2.0062	1.9547		
9		1.6461		.7049			
10	.4904	.4904	.6859	.4973	.4115	1.749	1.7661
11	.4527	.4904	.3258	.3429	.3944	1.8861	1.7147
12	.4572	.4715	.3086		.3772	1.9204	1.6632
13	.4715	.4715	.2572		.3772	1.6632	1.6632
14	.3018	.4715	.3086		.4191	1.6461	1.6461
15	.3018	.4527	.2572		.4572	1.6118	1.6461
16	.3206	.3206	.3429		.5335	1.7833	1.7661
17	.6001	.9431	.5335	.6001	.6859	1.9033	1.7833
18	.7716	.9431	.6668	.6516	.6516	.9145	
19	.8745	.9431	.8383	.8059	.6859	.9526	.9259
20	.8573	.9431	.7811	.6344	.7202	.8383	.7373
21	.5144	.9431	.6097	.4458	.5487	.724	.6859
22	.5144	.9431	.5525	.463	.5144	.6097	.5487
23	.4801	.9431	.4954	1.0802	.4801	.5335	.4801
24	.9431	.9602	1.0562	1.2003	1.1145	.4973	.4458
Max	2.0576	1.9376	2.1313	2.0748	1.9547	1.9204	1.7833
Min	.3018	.3206	.2572	.3429	.3772	.4973	.4458
Avg	.8447	1.0001	.8924	1.0276	.8336	1.1612	1.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 205 / NIRML COTTON & GINNING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0566	.0381	.0514	.0343	.0572
2	.0514	.0514	.0566	.0381	.0343	.0343	.0343
3	.0514	.0514	.0566	.0381	.0343	.0343	.0343
4	.0514	.0514	.0566	.0381	.0343	.0343	.0343
5	.0514	.0514	.0566	.0381	.0514	.0343	.0343
6	.0686	.0514	.0566	.0572	.0514	.0343	.0343
7	.0514	.0514	.0566		.0514	.0343	.0343
8	.0514	.0514	.0566	.0572	.0514	.0343	.0514
9		.0514		.0572	.0514	.0343	.0572
10	.0566	.0566	.0514	.0343	.0514	.0343	.0514
11	.0566	.0566	.0514	.0514	.0514	.0514	.0514
12	.0566	.0566	.0514	.0514	.0514	.0514	.0514
13	.0566	.0566	.0514	.0514	.0514	.0514	.0514
14	.0566	.0566	.0514	.0514	.0514	.0514	.0514
15	.0377	.0566	.0514	.0343	.0514	.0514	.0514
16	.0566	.0566	.0514	.0514	.0514	.0514	.0514
17	.0514	.0549	.0514	.0514	.0514	.0572	.0514
18	.0514	.0566	.0572	.0514	.0514	.0572	.0514
19	.0514	.0566	.0572	.0514	.0514	.0572	.0514
20	.0514		.0381	.0514	.0514	.0572	.0514
21		.0549	.0381	.0514	.0514	.0572	.0514
22	.0514	.0566	.0381	.0514	.0343	.0572	.0343
23	.0514	.0566	.0381	.0514	.0343	.0572	.0343
24	.0514	.0514	.0566	.0381	.0514	.0343	.0514
Max	.0686	.0566	.0572	.0572	.0514	.0572	.0572
Min	.0377	.0514	.0381	.0343	.0343	.0343	.0343
Avg	.0530	.0542	.0516	.0472	.0478	.0453	.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 201 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8402	.9282	.703	1.0829	1.0498	1.1203
2	.852	.9054	.9282	.788	1.0829	1.0903	1.1203
3	.9116	.9995	.9556	.852	1.0829	1.1584	1.1949
4	.9448	1.1012	.9724	1.1012	1.1949	1.2226	1.3443
5	.9724	1.1702	.9892	1.2597	1.5684	1.4998	1.5684
6	1.0174	1.4419	1.0174	1.4922	1.8671	1.7375	1.7924
7	1.1934	1.5424	1.5089	1.5424	2.0165	1.8427	1.9044
8	1.5384	1.5729	1.5203	1.5074	1.643	1.6827	1.7177
9	1.4403	1.3916	1.3279	1.531	1.419	1.419	1.6057
10	1.0974	1.4003	1.0288	1.2696	1.1218	1.1065	.9717
11	1.0498	1.363	1.0317	1.0269	1.2003	1.2071	.9783
12	.9214	1.307	1.0185	1.0082	1.2742	1.1904	.9907
13	.929	1.2883	.9808	1.0082	1.1012	1.1401	.9602
14	.9313	1.251	1.0374	1.0082	.9374	1.0898	.945
15	1.0317	.9934	1.0185	1.0456	.9755	1.073	.9145
16	1.0517	1.2136	1.0562	1.1576	1.0494	1.073	1.0802
17	.9945	1.307	1.0974	1.1949	1.0669	1.1736	1.0822
18	1.0059	1.386	1.2071	1.363	.9282	1.4003	1.4003
19	1.3672	1.7737	1.286	1.7364	1.2048	1.7924	1.643
20	1.6032	1.6804	1.4118	1.643	1.4901	1.4563	1.6804
21	1.6975	1.587	1.5089	1.3443	1.358	1.419	1.6804
22	1.5278	.5601	1.4712	1.2696	1.2071	1.2696	1.587
23	1.3957	1.4003	.6413	1.1949	1.1317	1.1763	1.4937
24	.8383	.7964	.9116	.6516	1.1203	1.0719	1.1203
Max	1.6975	1.7737	1.5203	1.7364	2.0165	1.8427	1.9044
Min	.8192	.5601	.6413	.6516	.9282	1.0498	.9145
Avg	1.1305	1.2614	1.1190	1.1958	1.2552	1.3059	1.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 202 / UMRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9339	.8745	.8288		.3921	.362	.3921
2	.9831	.9389	.8785	.9724	.3921	.3582	.4108
3	1.0277	1.0322	.9221	1.0322	.3921	.4481	.4481
4	1.0442	1.1012	.9724	1.1174	.4481	.5249	.5975
5	1.1065	1.2018	1.0395	1.2266	.5601	.6379	.7095
6	1.2378	1.3435	1.1361	1.2887	.8215	.7865	.7716
7	1.2431	1.4251	1.3245	1.3077	.8775	.8596	.8962
8	1.247	1.2452	1.4083	1.278	.7095	.7888	.4668
9	1.2483	1.291	1.1873	.4294	.4481	.4294	.3734
10	.298	.3361	.2572	.2241	1.262	1.2574	1.1142
11	.2534	.2801	.2715	.2241	1.2003	1.0059	1.174
12	.2172	.2427	.2829	.2054	1.1904	.7712	1.0822
13	.2303	.2427	.2452	.2054	1.1174	1.1233	1.0517
14	.2353	.2614	.2452	.2241	1.0467	1.1065	.9907
15	.2658	.2801	.2641	.2241	1.1126	1.0898	1.0212
16	.3155	.2987	.2896	.2801	1.2037	1.1736	1.1265
17	.3601	.2896	.3258	.3921	1.1736	1.3077	1.0669
18	.3856	.4251	.3856	.4294	.4144	.4108	.4294
19	.4382	.5228	.4458	.5041	.4607	.4668	.4294
20	.4904	.5041	.4525	.4481	.4527	.4668	.4294
21	.4527	.4668	.4715	.4294	.4527	.4668	.4294
22	.4715	.4294	.4338	.4294	.415	.4294	.4294
23	.4527	.4294	.7545	.4108	.3961	.4108	.4108
24	.8551	.8145	.7956	.8688	.3921	.3696	.3921
Max	1.2483	1.4251	1.4083	1.3077	1.262	1.3077	1.174
Min	.2172	.2427	.2452	.2054	.3921	.3582	.3734
Avg	.6581	.6782	.6508	.6153	.7221	.7105	.6935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 203 / DEGAON (KD.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6154	.6535	.6099	.57	.7202	.6706
2	.7282	.6024	.6535	.6154	.6371	.788	.7545
3	.7655	.6447	.7095	.6626	.8048	.8356	.8718
4	.8029	.695	.7842	.7442	.9054	.9172	.9389
5	.8402	.7164	.9335	.8688	.9724	1.0526	1.0059
6	.8775	.7421	1.0642	.9145	1.073	1.1568	1.0059
7	.8402	.7442	.9896	.9313	1.0898	1.2125	1.073
8	.7282	.6379	.8775	.8326	1.0562	1.1768	1.2071
9		.5228	.6093	.7095	.6722	.6722	.7468
10	.7625	.9172	.7611	.8383	.4706	.4668	.5228
11	.7935	.9217	.8065	1.0395		.4108	.4668
12	.8697	.9259	.8436	.9556	.3353	.3921	.4481
13	.8333	.9105	.8078	.9221	.3544	.3921	.4668
14	.7926	.8535	.8333	.9221	.4207	.4108	.4668
15	.9217	.7977	.7926	.9054	.5068	.4854	.4668
16	.9646	.7676	.7499	1.0059	.5853	.5975	.5415
17	.9717	.0934	.7621	1.0562	.583	.7468	.5975
18	.6036	.7282	.3185	.7282	.5967	.8029	.6722
19	.631	.8962	.4115	.8589	.7087	.7468	.5601
20	.6413	.8402	.5068	.8589	.7356	.7468	.4668
21	.6602	.7842	.5658	.6722	.6413	.7468	.5415
22	.679	.7282	.6413	.5228	.5658	.6722	.6908
23	.679	.6908	.6979	.4359	.6413	.5365	.5571
24	.6722	.6535	.6535	.6602	.5365	.6878	
Max	.9717	.9259	1.0642	1.0562	1.0898	1.2125	1.2071
Min	.6036	.0934	.3185	.4359	.3353	.3921	.4481
Avg	.7717	.7262	.7261	.8030	.6723	.7239	.6844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 204 / KASARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4163	.4294	.4251	.6036	.6687	.7042
2	.4668	.443	.4294	.3982	.6706	.6874	.8383
3	.5041	.5121	.4668	.4075	.7545	.7537	.9054
4	.5788	.5373	.5601	.5121	.8718	.8065	.9389
5	.6722	.5784	.6722	.5792	1.0059	.9555	1.0059
6	.7842	.6516	.8402	.6201	1.1065	1.1233	1.0059
7	.663	.6733	.7468	.6733	1.1401	1.1633	1.2574
8	.6154	.691	.5601	.5784	1.0562	1.21	1.1401
9	.5083	.5601	.3856	.5601	.5601	.5041	.5975
10	.6796	.7432	.7125	.7545	.362	.4481	.5415
11	.8745	.8124	.7907	.9724	.3511	.4294	.286
12	.9488	.8796	.8124	1.0898	.3292		.3174
13	.8951	.8796	.7621	1.073	.3361	.3921	.3361
14	.8383	.8535	.8179	.9221	.3292	.3921	.3361
15	.8124	.8278	.945	.9221	.3582	.3921	.3361
16	.7907	.7977	1.0467	1.0562	.3721	.4108	.3547
17	.9393	.8383	.9907	1.0395	.463	.4294	.4108
18	.4862	.4435	.3856	.5228	.4973	.5415	.5228
19	.5609	.6348	.5487	.6535	.5316	.6535	.5601
20	.5658	.5975	.543	.5601	.5281	.6535	.5601
21	.5281	.5601	.5281	.5228	.5281	.5415	.5601
22	.4904	.5041	.5093	.4854	.4904	.5415	.5228
23	.4527	.4668	.4715	.503	.5847	.5868	.5407
24	.4294	.4294	.4294	.4338	.5197	.6516	.6371
Max	.9488	.8796	1.0467	1.0898	1.1401	1.21	1.2574
Min	.4294	.4163	.3856	.3982	.3292	.3921	.286
Avg	.6464	.6388	.6410	.6777	.5979	.6494	.634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 201 / LAHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.7545		.8745		.4801	
2	.9526	.9259		1.0288		.4801	
3	1.1431	.9602		1.0288		.4801	
4	1.2193	1.0288		1.1145		.5144	
5	1.2193	1.0974		1.1488		.5144	
6	1.3336	1.166	1.0974	1.2003		.5487	
7	1.448	1.3717	1.3032	1.2346		.5487	
8	1.448	1.3032		1.3717	1.5242	.4115	.4801
9	1.3717		1.3032			.4115	
10	.3429				.3429		
11	.3429				.3429		
12	.3429	.3429			.2743		
13	.4115				.2743		
14	.3429				.2743		
15	.3429				.2743		
16	.3429	.3429		.381	.3429		
17	.4115				.3429		
18	.4115	.3429			.3429		
19	.5144				.3429		
20	.5144			.6097	.4115		
21	.4801				.4801		
22	.4801				.4801		
23	.4801	.4801		.381	.4801	.4801	
24	.9526	.6859	.7545	.6516	.7621	.4458	.4801
Max	1.448	1.3717	1.3032	1.3717	1.5242	.5487	.4801
Min	.3429	.3429	.7545	.381	.2743	.4115	.4801
Avg	.7417	.8310	1.1146	.9188	.4558	.4832	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 202 / CHABHARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115		.4458		1.3717	
2	.4801		.4801		1.7147	
3	.583		.4801		1.7833	
4	.6173		.5144		1.8519	
5	.6516		.5487		1.8861	
6	.6859		.6516		1.8861	
7	.6859	.6859	.6859		2.332	
8	.5144		.6001	.6097	2.0233	2.2291
9	.5144	.3429	.4954		.4115	
10	1.2003		1.829	1.5775		
11	1.5432		1.9052	1.8519		
12	1.8004			1.5775		
13	1.6289			1.5775		
14	1.6289			1.5775		
15				1.5775		
16	1.4575		1.9052	1.6461		
17	1.7147			1.8176		
18	.3429			.4458		
19				.583		
20				.5487		
21				.5487		
22				.4801		
23	.4287		.4763		1.0288	
24	.4115		.4115	.4763	1.1317	1.0288
Max	1.8004	.6859	1.9052	1.8519	2.332	2.2291
Min	.3429	.3429	.4115	.4458	.4115	1.0288
Avg	.9106	.5144	.8164	1.1264	1.5837	1.6290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.1317		1.3203		.823	
2	1.3336	1.3032		1.4918		.823	
3	1.3717	1.3717		1.6632		.9259	
4	1.6385	1.5089		1.8861		1.1317	
5	1.7147	1.7147		2.0576		1.3717	
6	1.9052	1.8176	1.6289	2.3148		1.6461	
7	2.0195	2.2291	1.8861	2.4691		1.5432	
8	2.2862	2.2977		2.1262	1.7147	1.3032	1.5432
9	2.1262		1.7147			.8573	
10	.6859				.583		
11					.4458		
12					.4458		
13	.6859				.4115		
14	.6516				.4115		
15	.6173				.4458		
16	.583			.8764	.5144		
17	.8573	.1715			.6173		
18		1.0288			1.0974		
19	1.3717				1.3375		
20	1.2003			1.2574	1.2003		
21					1.1317		
22					.9259		
23	.8573	.8573		1.0669	.8573	.8573	
24	1.2193	1.0288	1.0288	.9431	1.0669	.823	.8573
Max	2.2862	2.2977	1.8861	2.4691	1.7147	1.6461	1.5432
Min	.583	.1715	1.0288	.8764	.4115	.823	.8573
Avg	1.2813	1.3718	1.5646	1.6227	.8254	1.1005	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 204 / 11KV SONALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.5487		.6001		.823	
2	.724	.5487		.6001		.8573	
3	.6859	.583		.6173		.9602	
4	.6859	.6859		.6001		1.0288	
5	.724	.823		.6516		1.2003	
6	.724	.9259		.823		1.4746	
7	.7621	.8573	.8573	.9602		1.749	
8	.8383	.6859		.7888	.8764	1.7147	1.5432
9	.7888		.5487			.583	
10	.8573				.0343		
11	1.2689				1.6804		
12	1.2003				1.6804		
13	1.0631				1.5432		
14	1.0974				1.5089		
15	1.1317				1.3717		
16	1.1317			1.4098	1.3375		
17	1.1317	1.0288			.823		
18	.4115	.5144			.5487		
19	.7202				.7202		
20	.6859			.7621	.7202		
21	.6516				.6859		
22	.6173				.6173		
23	.583	.6001		.6097	.583	.6859	
24	.6478	.5487	.6001		.6478	.6859	.6859
Max	1.2689	1.0288	.8573	1.4098	1.6804	1.749	1.5432
Min	.4115	.5144	.5487	.6001	.0343	.583	.6859
Avg	.8242	.6959	.6687	.7657	.9612	1.0693	1.1146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 201 / PARDI (M) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4999	.6554	.6325	.6554	.8192	.6413	.6413
2	.5693	.7459	.6325	.7209	.9116	.7167	.6413
3	.5556	.7459	.6958	.7537	.9012	.7545	.6413
4	.6009	.8192	.7907	.8192	.9012	.7962	.679
5	.6481	.8288	.8223	.8642	.9945	.8676	.9054
6	.7716	.9945	.9172	1.0279	1.065	.9808	.9054
7	.9568	1.1603	1.0669	1.1405	1.2289	.7922	.8676
8	1.0623	1.2431	.9907	1.0623	1.2431	.7167	.7545
9	1.0486	1.0669	.9755	.6036	.6036	.6413	.6036
10	.4904	.5281	.6036	.5281	.4527	.8322	.9448
11	.415	.4527	.5658		.415	.8619	.9282
12	.3772	.4338	.5281			.8916	.852
13	.3772	.4338	.4527	.4527	.415	.8322	.7956
14	.3772	.415	.415	.415	.4527	.8535	.8192
15		.415	.415	.415	.415	.8535	.7956
16	.4527	.415	.4527	.3772	.4527	.884	.8288
17	.5281	.5093	.547	.3772	.5658	.884	.8288
18	.6413	.4904	.6468	.6413	.679	.6413	.6036
19	.7545	.7545	.6722		.7204	.8299	.7167
20	.7167	.7545	.679	.679	.7583	.7545	.7545
21	.679	.7167	.679	.6413	.7167	.7545	.7167
22		.6413	.679	.6602	.7583	.7167	.6299
23	.5658	.5658	.5898	.6413	.6852	.7167	.7167
24	.4858	.4915	.5376	.6554	.663	.5658	.679
Max	1.0623	1.2431	1.0669	1.1405	1.2431	.9808	.9448
Min	.3772	.415	.415	.3772	.415	.5658	.6036
Avg	.617	.6782	.6661	.6729	.7312	.7825	.7604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 202 / CHORAMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6413	.6413	.679	.679	.9393	.9831
2	.679	.6413	.6036	.6413	.6413	.9717	1.0486
3	.679	.6413	.6036	.6036	.6413	1.0486	1.0814
4	.7167	.6602	.6413	.6036	.6413	1.0814	1.1843
5	.7613	.679	.7545	.679	.679	1.1336	1.4403
6	.7922	.7167	.9054	.8299	.7167	1.4251	1.6872
7	.7922	.7545	.7922	.7733	.7545	1.7924	1.9841
8	.679	.7545	.7167	.7167	.7545	1.0437	1.8747
9	.6602	.5658	.6036	.5658	.679	.415	.4904
10	1.2452	.7907	1.0753	.5243	1.406	.415	.3772
11	1.6575	1.7711	1.6766	1.9662	.9259	.1867	.3772
12	1.6575	1.7029	1.6613	1.989		.2987	.3395
13	1.6385	1.656	1.6156	1.9062	1.6049	.3734	.3395
14	1.5746	1.5623	1.5242	1.8233	1.6248	.3734	.3395
15	1.6385		1.4632	1.8233	1.5432	.415	.3395
16		1.0974	1.5242	1.8233	1.6129	.4527	.2641
17		1.6766	1.6461	.9831	1.6248	.4904	.4527
18	.4527	.4904	.415	.679	.4904	.5281	.5658
19	.7545	.811	.7733	.7545	.7545	.7545	.7167
20	.7545	.7922	.811	.7167	.7922	.7545	.7545
21	.7167	.7545	.7922	.7167	.7545	.7167	.7167
22	.679	.7167	.7733	.7167	.679	.6413	.679
23	.6413	.679	.7167	.7167	.7865	.9175	.8192
24	.679	.6413	.6413	.679	.679	.852	.9503
Max	1.6575	1.7711	1.6766	1.989	1.6248	1.7924	1.9841
Min	.4527	.4904	.415	.5243	.4904	.1867	.2641
Avg	.9331	.9216	.9738	.9963	.9333	.7509	.8252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 203 / Delub Bk SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282	.9831	.9488		1.0774	.6036	.6036
2	.9282	.9945	1.0437	1.0486	1.0774	.6036	.6036
3	.9393	1.0774	1.0437	1.0814	1.2431	.6413	.5658
4	.9488	1.1603	1.1069	1.1203	1.3108	.679	.5658
5	.9686	1.2431	1.1385	1.1843	1.3927	.7545	.679
6	1.0936	1.4089	1.1584	1.2809	1.5565	.8257	.8676
7	1.358	1.4918	1.448	1.5181	1.4746	.7545	.8299
8	1.3889	1.5565	1.4632	1.3123	1.4089	.6413	.7167
9	1.3763	1.448	1.2498	.5281	.5658	.415	.6036
10	.415		.4338	.5281	.4527	1.1111	1.1469
11	.3772		.415	.3772		1.2346	1.4918
12	.3772		.3772	.3772		1.3272	1.4089
13	.3018	.4527	.3772	.3772	.415	1.2037	1.326
14	.3395	.3395	.3395	.3395	.4527	1.2193	1.326
15	.3395	.3206	.3395		.3772	1.3413	1.326
16	.3395	.3584	.3584	.2641	.415	1.3717	1.1603
17	.5281	.3772	.3961	.2641	.5281	1.3108	1.326
18	.6036	.5281	.4904	.6036	.6413	.6224	.5281
19	.7167	.6602	.7167	.7167	.7545	.8676	.6413
20	.7167	.6413	.6413	.679	.7167	.7545	.7167
21	.679	.6224	.6036	.6413	.679	.6224	.679
22	.6413	.6224	.6036	.6413	.6036	.6224	.6413
23	.6036	.6036	.9503	1.0374	.6036	.6036	.6036
24	.9069	.9012	.8223	.9667	.9945	.6036	.6036
Max	1.3889	1.5565	1.4632	1.5181	1.5565	1.3717	1.4918
Min	.3018	.3206	.3395	.2641	.3772	.415	.5281
Avg	.7423	.8472	.7694	.7676	.8519	.8639	.8734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 201 / KAMTHA (BK.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5121	.4715	.5228	.1886	.1509	.1494
2	.4715	.4572	.5658	.5228	.1886	.1509	.1494
3	.5281	.5121	.5658	.5601	.1886	.1886	.168
4	.5658	.6401	.5658	.5601	.2075	.2263	.1698
5	.6036	.695	.2263	.5601	.2452	.2263	.2241
6	.6602	.7316	.6602	.7392	.2829	.2452	.2829
7	.7167	.695	.6979	.6535	.3018	.2829	.2829
8	.7167	.7468	.695	.7023	.2452	.2829	.2427
9	.6602	.695	.2263	.2241	.2263	.2452	.168
10	.1509	.1494	.1494	.1698	.6224	.6224	.6602
11	.1307	.1509	.1698	.1509	.7545	.7468	.6602
12	.1307	.1509	.1494	.1509	.6413	.6468	.6036
13	.1307	.132	.168	.1509	.6602	.5853	.5658
14	.112	.1509	.1494	.1509	.6602	.5487	.5658
15	.132	.1509	.1494	.1509	.6224	.5853	.5658
16	.1509	.1509	.1494	.1509	.6224	.5853	.6036
17	.1494	.1509	.1494	.1698	.6224	.6219	.6413
18	.1698	.1698	.1698	.1698	.1886	.1886	.2075
19	.2241	.2263	.1867	.2641	.2263	.2641	.2452
20	.2427	.2452	.2427	.2641	.2641	.2452	.2641
21	.2241	.2263	.2452	.2263	.2452	.2263	.2452
22	.2241	.2263	.2241	.2075	.2263	.1886	.2263
23	.2263	.1886	.462	.2075	.1886	.1509	.2075
24	.4527	.5121	.4715	.5228	.1886	.1886	.1509
Max	.7167	.7468	.6979	.7392	.7545	.7468	.6602
Min	.112	.132	.1494	.1509	.1886	.1509	.1494
Avg	.3436	.3611	.3296	.3397	.3670	.3498	.3438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 202 / GANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1307	.1509	.1307	.9431	.8488	.8962
2	.1698	.1494	.1509	.1307	.9431	.9431	.9145
3	.1886	.1494	.1509	.1494	1.0374	.9431	.9335
4	.2263	.1867	.2263	.1494	1.0374	1.094	1.0269
5	.2641	.2427	.2195	.2241	1.1317	1.1317	1.2437
6	.2829	.2987	.2452	.3018	1.4146	1.3203	1.4632
7	.3395	.3174	.3109	.2801	1.4146	1.5089	1.587
8	.2829	.2614	.2743	.2241	1.6221	1.6975	1.587
9	.2075	.1494	.2263	.2054	.1886	.1886	.1886
10	1.226	1.1203	1.1888	1.1506	.1509	.1509	.1698
11	1.2567	1.4712	1.4632	1.3392	.1132	.1509	.1132
12	1.2803	1.4146	1.3717	1.4146	.0943	.132	.1132
13	1.2437	1.4146	1.3717	1.3957	.0943	.112	.1132
14	1.1888	.8488	1.2803	1.358	.0943	.1132	.1132
15	1.3717	1.2803	1.2803	1.3392	.132	.1132	.132
16	1.3717	1.3203	1.1888	1.3769	.1509	.168	.1509
17	1.4266	1.5089	1.2803	1.4146		.1886	.1698
18	.1494	.2263	.1509	.1886	.2452	.2263	.2075
19	.2427	.2263	.2263	.2263	.2452	.2427	.2263
20	.2241	.2452	.2452	.2452	.2452	.2427	.2263
21	.1867	.2263	.1886	.2075	.2263	.2263	.1886
22	.1509	.1886	.1509	.1886	.2263	.1867	.1698
23	.1509	.1509	.1509	.8488	.2263	.7095	.7545
24	.132	.1307	.1509	.132	.9431	.7545	.8402
Max	1.4266	1.5089	1.4632	1.4146	1.6221	1.6975	1.587
Min	.132	.1307	.1509	.1307	.0943	.112	.1132
Avg	.5714	.5691	.5685	.6092	.5617	.5581	.5637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 203 / NANDUSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5544	.5658	.4572	.132	.1132	.132
2	.5658	.5487	.5658	.5121	.132	.1132	.1307
3	.6602	.6401	.5658	.6468	.1509	.1132	.132
4	.7545	.695	.6602	.6468	.1509	.132	.1509
5	.7545	.9145	.8488	.7392	.1509	.132	.1509
6	.8488	1.0059	.9431	.8871	.1509	.132	.1509
7	.9431	1.0534	1.1317	.8962	.1698	.132	.1494
8	1.0751	1.0719	1.0185	1.0059	.1509	.132	.1509
9	.9619	1.0829	.9431	.0943		.132	.1307
10	.0754	.0754	.0754	.0943	.811	.8299	.8488
11	.0754	.0566	.0754	.0754	.9054	.823	.9054
12	.0747	.0566	.0747	.0754	.8488	.9431	.8676
13	.0747	.0566	.0934	.0566	.8488	.8962	.8299
14	.0747	.0566	.0934	.0566	.8488	.8402	.811
15	.0747	.0566	.0754		.9431	.7468	.7922
16	.0747	.0754	.0754		.9619	1.0164	.7922
17	.0934	.0754	.0754		1.0185	1.0164	.8488
18	.0943	.0943	.0747		.0943		.0943
19	.112	.132	.112	.1509	.1132	.168	.132
20	.1494	.132	.1494	.1509	.132	.168	.1509
21	.1494	.132	.1509	.1509	.132	.1494	.1509
22	.1307	.1132	.1307	.132	.132	.132	.132
23	.1307	.1132	.462	.132	.132	.1307	.132
24	.5281	.5487	.4715	.462	.132	.1132	.132
Max	1.0751	1.0829	1.1317	1.0059	1.0185	1.0164	.9054
Min	.0747	.0566	.0747	.0566	.0943	.1132	.0943
Avg	.3768	.3892	.3930	.3711	.4018	.3959	.3708