

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 201 / 11 KV MIDC I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.0005 | 1.8671 | 2.4196 | 2.2862 | 2.0576 | 2.0005 | 2.0957 |
| 2 | 2.0957 | 1.9052 | 2.3243 | 2.0005 | 2.0005 | 1.9052 | 2.0005 |
| 3 | 1.9052 | 1.7147 | 2.191 | 2.0957 | 1.8099 | 1.8861 | 1.9433 |
| 4 | 1.9814 | 1.7147 | 2.0957 | 2.0576 | 1.7147 | 1.8861 | 2.0957 |
| 5 | 2.0005 | 1.6766 | 2.0957 | 1.9624 | 1.6194 | 1.848 | 1.9052 |
| 6 | 1.9052 | 1.6766 | 2.0005 | 2.0005 | 1.5242 | 1.8671 | 1.8099 |
| 7 | 1.9052 | 1.7147 | 1.9052 | 2.0005 | 1.448 | 1.8861 | 1.7147 |
| 8 | 2.0957 | 1.7528 | 1.7528 | 1.6194 | | 1.9814 | 1.7147 |
| 9 | 2.191 | 1.9052 | 2.0957 | 1.7147 | 2.0957 | 2.2862 | 1.7147 |
| 10 | 2.0957 | 2.0957 | 2.3815 | 1.9052 | 2.0957 | 2.3815 | 1.7147 |
| 11 | 1.9433 | 2.0005 | 2.2862 | 2.0957 | 2.0957 | 2.2862 | 1.3336 |
| 12 | 2.0195 | 1.9052 | 2.0957 | 2.0005 | 2.0957 | 2.2862 | 1.2384 |
| 13 | 1.6575 | | 1.7909 | 1.7147 | 1.7147 | 1.7147 | 1.3336 |
| 14 | 2.0195 | 1.9052 | 1.7147 | 2.0957 | 1.7147 | 2.4768 | 1.3336 |
| 15 | 2.0576 | 2.191 | 2.2862 | 2.191 | 1.9052 | 1.9052 | 1.3908 |
| 16 | 2.4768 | 2.0195 | 2.191 | 2.2862 | 2.3815 | 2.2862 | 1.3336 |
| 17 | 2.572 | 2.1719 | 2.2862 | 2.0957 | 2.4006 | 2.2862 | 1.5242 |
| 18 | 2.572 | 2.21 | 2.3434 | 1.848 | 2.3434 | | 1.9052 |
| 19 | 2.5911 | 2.2862 | 2.2862 | 1.9052 | 2.1338 | 2.191 | 1.8861 |
| 20 | 2.4577 | 2.21 | 2.0957 | 2.0005 | 2.2481 | 2.2481 | 1.829 |
| 21 | 2.4006 | 2.1338 | 2.0957 | 2.0005 | 2.3434 | 2.0957 | 1.8099 |
| 22 | 2.0957 | 2.2672 | 2.2481 | 2.0576 | 2.0957 | 2.0386 | 1.8099 |
| 23 | 2.0576 | 2.4006 | 2.1338 | 2.0576 | 2.0576 | 2.191 | 1.7528 |
| 24 | 2.0005 | 2.0195 | 2.5339 | 2.2862 | 2.1338 | 2.0386 | 2.0957 |
| Max | 2.5911 | 2.4006 | 2.5339 | 2.2862 | 2.4006 | 2.4768 | 2.0957 |
| Min | 1.6575 | 1.6766 | 1.7147 | 1.6194 | 1.448 | 1.7147 | 1.2384 |
| Avg | 2.1291 | 1.9889 | 2.1521 | 2.0116 | 2.0013 | 2.0858 | 1.7202 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 202 / 11 KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1715 | .3429 | .1905 | .381 | .3429 | .1905 |
| 2 | | .1715 | .2667 | .1905 | .381 | .2286 | .1905 |
| 3 | .1905 | .1524 | .2667 | .1905 | .2858 | .2286 | .1905 |
| 4 | .1905 | .1524 | .2286 | .1905 | .2858 | .1905 | .1905 |
| 5 | .1905 | .1905 | .2286 | .1905 | .1905 | .1715 | .1905 |
| 6 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 7 | .1905 | .1715 | .2286 | .1905 | .1905 | .1715 | .1905 |
| 8 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 9 | .1905 | .381 | .381 | .1905 | .381 | .381 | .1905 |
| 10 | .1905 | .381 | .381 | .381 | .381 | .381 | .0953 |
| 11 | .1715 | .381 | .381 | .381 | .5716 | .381 | .0953 |
| 12 | .1905 | .5716 | .5716 | .5716 | .5716 | .381 | .0953 |
| 13 | .1905 | | .381 | .381 | .381 | .381 | .0953 |
| 14 | .1905 | .2858 | .381 | .381 | .381 | .5716 | .0953 |
| 15 | .2286 | .5716 | .5716 | .381 | .5716 | .381 | .0953 |
| 16 | .2286 | .5716 | | .381 | .5716 | .381 | .0953 |
| 17 | .1905 | .381 | .381 | .2858 | .4954 | .381 | .0953 |
| 18 | .1715 | .381 | .381 | .1905 | .1905 | .381 | .0953 |
| 19 | .1905 | .1905 | | .2858 | .1905 | .381 | .0953 |
| 20 | .1715 | .2858 | .1905 | .4191 | .1905 | .381 | .1143 |
| 21 | .2667 | .381 | .1905 | .4954 | .1905 | .1905 | .1524 |
| 22 | .2286 | .381 | .1905 | .5716 | .3429 | .1905 | .1715 |
| 23 | .1905 | .381 | .1905 | .4763 | .2286 | .1905 | .1905 |
| 24 | | .2286 | .381 | .1905 | .381 | .3429 | .1905 |
| Max | .2667 | .5716 | .5716 | .5716 | .5716 | .5716 | .1905 |
| Min | .1715 | .1524 | .1905 | .1905 | .1905 | .1715 | .0953 |
| Avg | .1969 | .3106 | .3135 | .3120 | .3382 | .3080 | .1453 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 203 / 11 KV TAKALGHAT (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .381 | .381 | .381 | .381 | .5335 | .5716 |
| 2 | .381 | .362 | .381 | .381 | .381 | .5716 | .5716 |
| 3 | .381 | .362 | .381 | .381 | .5716 | .5716 | .5716 |
| 4 | .381 | .381 | .4763 | .381 | .5716 | .5906 | .5716 |
| 5 | .4763 | .4763 | .4763 | .4763 | .6668 | .5906 | .5716 |
| 6 | .5716 | .6097 | .5716 | .5716 | .6668 | .6097 | .5716 |
| 7 | .5716 | .7621 | .6668 | .5716 | .7621 | .6668 | .5716 |
| 8 | .5716 | .8192 | .7621 | .7621 | .6668 | .6668 | .5716 |
| 9 | .5716 | .7621 | .7621 | .7621 | .5716 | .6668 | .5716 |
| 10 | .6668 | .7621 | .5716 | .5716 | .5716 | .5716 | .5716 |
| 11 | .6859 | .5716 | .5716 | .5716 | .5716 | .5716 | .5716 |
| 12 | .6668 | .5716 | .5716 | .5716 | .5716 | .5716 | .5716 |
| 13 | .6668 | | .5716 | .5716 | .5716 | .5716 | .5716 |
| 14 | .6668 | .5716 | .5716 | .7621 | .5716 | .381 | .5716 |
| 15 | .6859 | .5716 | .5716 | .5716 | .5716 | .5716 | .5716 |
| 16 | .5716 | .5716 | .5716 | .5716 | .7621 | .381 | .5716 |
| 17 | | .6668 | .5716 | .5716 | .7621 | .381 | .6287 |
| 18 | | .6668 | .5716 | .5716 | .724 | .381 | .7049 |
| 19 | .8002 | .7621 | .6668 | .5716 | .8954 | .6668 | .8002 |
| 20 | .6859 | .7621 | .6668 | .5716 | .9145 | .7621 | .9145 |
| 21 | .6668 | .7621 | .7621 | .5716 | .7621 | .7621 | .9145 |
| 22 | .4191 | .6668 | .6668 | .5716 | .5906 | .7621 | .8954 |
| 23 | .381 | .4763 | .381 | .4763 | .5716 | .7049 | .7811 |
| 24 | .381 | .381 | .381 | .381 | .381 | .6478 | .5716 |
| Max | .8002 | .8192 | .7621 | .7621 | .9145 | .7621 | .9145 |
| Min | .381 | .362 | .381 | .381 | .381 | .381 | .5716 |
| Avg | .5560 | .5948 | .5636 | .5478 | .6263 | .5898 | .6399 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 204 / 11 KV MIDC III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6097 | 1.1431 | 1.5242 | 1.2384 | 1.0479 | 1.086 | 1.1431 |
| 2 | .6478 | 1.1431 | 1.4289 | 1.2003 | .9907 | 1.086 | 1.1431 |
| 3 | .6097 | 1.0669 | 1.4289 | 1.1431 | .9526 | 1.086 | 1.0479 |
| 4 | .6097 | 1.0669 | 1.3336 | 1.1241 | .9526 | 1.0669 | 1.0479 |
| 5 | .6478 | 1.086 | 1.2384 | 1.1622 | .9526 | 1.0479 | 1.0288 |
| 6 | .6097 | 1.086 | 1.1431 | 1.2003 | 1.0288 | 1.0288 | .9907 |
| 7 | .6287 | 1.0669 | 1.105 | 1.2003 | 1.0288 | .9907 | .9717 |
| 8 | .8002 | 1.1241 | 1.0288 | 1.105 | 1.1431 | .8192 | .9526 |
| 9 | .9145 | 1.3336 | 1.1431 | 1.1431 | 1.1431 | .9526 | .7811 |
| 10 | | 1.4289 | 1.2384 | 1.3336 | 1.2384 | 1.1431 | .8573 |
| 11 | 1.5242 | 1.5242 | 1.3336 | 1.4289 | 1.3336 | 1.1431 | .9526 |
| 12 | 1.5242 | 1.7147 | 1.4289 | 1.5242 | 1.3336 | 1.2384 | .8192 |
| 13 | 1.105 | | 1.1622 | 1.5242 | 1.105 | 1.0479 | .8764 |
| 14 | 1.1241 | 1.5242 | 1.2384 | 1.4289 | 1.3336 | 1.2384 | .9526 |
| 15 | 1.4098 | 1.6194 | 1.3336 | 1.5242 | 1.4289 | 1.1431 | 1.1431 |
| 16 | 1.4289 | 1.5623 | 1.3336 | 1.4289 | 1.4289 | 1.1431 | 1.1431 |
| 17 | 1.2384 | 1.467 | 1.2384 | 1.3527 | 1.3336 | 1.1431 | .9526 |
| 18 | 1.2384 | 1.3336 | 1.0479 | 1.2765 | 1.2765 | 1.1431 | .9145 |
| 19 | 1.3908 | 1.2765 | .9526 | 1.1812 | 1.2193 | 1.1431 | .9335 |
| 20 | 1.2384 | 1.3336 | .9907 | 1.105 | 1.0479 | 1.1431 | .9717 |
| 21 | 1.2003 | 1.3336 | 1.0098 | 1.0479 | 1.1622 | 1.086 | 1.0479 |
| 22 | 1.2955 | 1.4289 | 1.1431 | .9717 | 1.1431 | 1.1431 | 1.0669 |
| 23 | 1.4861 | 1.5242 | 1.086 | 1.0479 | 1.0479 | 1.1431 | 1.105 |
| 24 | .5906 | 1.2384 | 1.5813 | 1.2193 | 1.086 | 1.0288 | 1.1431 |
| Max | 1.5242 | 1.7147 | 1.5813 | 1.5242 | 1.4289 | 1.2384 | 1.1431 |
| Min | .5906 | 1.0669 | .9526 | .9717 | .9526 | .8192 | .7811 |
| Avg | 1.0379 | 1.3229 | 1.2289 | 1.2463 | 1.1566 | 1.0931 | .9994 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 205 / 11 KV MIDC IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5906 | .5716 | .6287 | .6668 | .6668 | .6287 | .4572 |
| 2 | .5716 | .5906 | .5716 | .6668 | .6668 | .6478 | .4954 |
| 3 | .6097 | .5906 | .5716 | .6097 | .5906 | .6287 | .4763 |
| 4 | .5525 | .5716 | .5335 | .5716 | .5906 | .6287 | .4763 |
| 5 | .5906 | .5716 | .5335 | .5906 | .6097 | .6097 | .4191 |
| 6 | .6097 | .5906 | .5906 | .5716 | .6097 | .6097 | .4382 |
| 7 | .6097 | .5906 | .5906 | .5716 | .6097 | .6287 | .381 |
| 8 | .5716 | .5716 | .5525 | .5716 | .5716 | .6097 | .4954 |
| 9 | .5716 | .5716 | .5716 | .5716 | .5716 | .6668 | .5525 |
| 10 | .5716 | .5716 | .5716 | .381 | .5716 | .6668 | .5716 |
| 11 | .5906 | .5716 | .5716 | .381 | .5716 | .6668 | .5716 |
| 12 | .5716 | .5716 | .5716 | .5716 | .5716 | .6668 | .5525 |
| 13 | .5716 | | .6097 | .5716 | .5906 | .6097 | .4954 |
| 14 | .5716 | .5716 | .5716 | .5716 | .5716 | .6668 | .4763 |
| 15 | .5335 | .4763 | .5716 | .5716 | .6097 | .381 | .5144 |
| 16 | .5716 | .5716 | .5716 | .5716 | .6668 | .381 | .5335 |
| 17 | .5716 | .5716 | .5716 | .6097 | .6668 | .381 | .4954 |
| 18 | .5525 | .5716 | .6097 | .6097 | .6478 | .381 | .4954 |
| 19 | .5906 | .6287 | .5716 | .5716 | .6478 | .381 | .5716 |
| 20 | .5716 | .5906 | .5716 | .5716 | .6097 | | .5716 |
| 21 | .5525 | .5906 | .5525 | .5335 | .6478 | .4001 | .5716 |
| 22 | .5716 | .6478 | .6097 | .5335 | .6668 | .4572 | .5906 |
| 23 | .5716 | .6478 | .6668 | .6478 | .6859 | .5144 | .6859 |
| 24 | .5144 | .5906 | .6668 | .6668 | .7049 | .6287 | .5144 |
| Max | .6097 | .6478 | .6668 | .6668 | .7049 | .6668 | .6859 |
| Min | .5144 | .4763 | .5335 | .381 | .5716 | .381 | .381 |
| Avg | .5732 | .5823 | .5835 | .5732 | .6216 | .5583 | .5168 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 206 / 11 KV MIDC VI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5716 | 1.3336 | 1.1431 | 1.0479 | 1.1431 | 1.3336 | 1.3336 |
| 2 | .5716 | 1.3336 | 1.1431 | 1.0479 | 1.1431 | 1.3336 | 1.3336 |
| 3 | .5716 | 1.3336 | 1.0479 | .9526 | 1.0479 | 1.3336 | 1.2193 |
| 4 | .5716 | 1.2384 | 1.0479 | .9526 | .8573 | 1.1812 | 1.1431 |
| 5 | .5716 | 1.1431 | .9907 | .9526 | .7621 | 1.1812 | 1.1431 |
| 6 | .5716 | 1.0479 | .9907 | .9526 | .724 | 1.1431 | 1.0479 |
| 7 | .5716 | .8002 | .8573 | .9526 | .6859 | .8002 | 1.0479 |
| 8 | .7621 | .7621 | .7621 | .5716 | .5716 | .7621 | .9145 |
| 9 | .9526 | .5716 | .5716 | .7621 | .4763 | .7621 | .7621 |
| 10 | .9907 | .4763 | .5716 | .8573 | .4763 | .7621 | .7621 |
| 11 | 1.0479 | .5716 | .7621 | .7621 | .4763 | .8573 | .5716 |
| 12 | 1.105 | .5716 | 1.1431 | .5716 | .4763 | 1.1431 | .5716 |
| 13 | .5716 | .7621 | .9526 | .8573 | .4763 | .9526 | .5716 |
| 14 | .9526 | .5716 | .9526 | | .6668 | 1.0479 | .5716 |
| 15 | .9907 | .8573 | .8573 | .9526 | .8573 | 1.1431 | .5716 |
| 16 | 1.1431 | .9526 | 1.1431 | 1.1431 | 1.0479 | 1.3336 | .5716 |
| 17 | 1.2384 | .9526 | 1.1431 | 1.1812 | .9907 | 1.2384 | .5525 |
| 18 | 1.1431 | .9907 | 1.0479 | 1.2193 | .9526 | 1.1431 | .8573 |
| 19 | 1.1431 | .9907 | 1.1431 | | .9526 | 1.2384 | .6859 |
| 20 | 1.1431 | 1.1431 | 1.1431 | 1.1812 | .9526 | 1.2384 | .6668 |
| 21 | 1.1431 | 1.2955 | 1.1431 | 1.1812 | 1.3336 | 1.2384 | .7621 |
| 22 | 1.0098 | | 1.1431 | 1.1431 | 1.3336 | 1.2955 | .8573 |
| 23 | .9907 | 1.2384 | 1.0479 | 1.2384 | 1.0098 | 1.4098 | .8573 |
| 24 | .5716 | 1.3336 | 1.2193 | 1.0479 | 1.2955 | 1.1431 | 1.4289 |
| Max | 1.2384 | 1.3336 | 1.2193 | 1.2384 | 1.3336 | 1.4098 | 1.4289 |
| Min | .5716 | .4763 | .5716 | .5716 | .4763 | .7621 | .5525 |
| Avg | .8709 | .9683 | .9986 | .9786 | .8629 | 1.1256 | .8669 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 207 / 11 KV MIDC VII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .5335 | .4954 | .5716 | .4191 | .6287 | .5335 |
| 2 | .3429 | .5335 | .4763 | .5716 | .381 | .6287 | .5144 |
| 3 | .3239 | .5335 | .4572 | .5716 | .381 | .6478 | .4763 |
| 4 | .3239 | .4954 | .4572 | .5335 | .4572 | .6478 | .4954 |
| 5 | .3239 | .5144 | .4763 | .5335 | .4572 | .6287 | .4763 |
| 6 | .3048 | .5144 | .5144 | .5335 | .4954 | .6668 | .4763 |
| 7 | .3239 | .5144 | .6668 | .5335 | .4954 | .6097 | .4954 |
| 8 | .5144 | .5525 | .743 | .6668 | .5716 | .5906 | .4954 |
| 9 | .7621 | .7621 | .7621 | .8573 | .7621 | .6668 | .5144 |
| 10 | .8192 | .9526 | .9526 | 1.0479 | 1.1431 | .8573 | .4763 |
| 11 | .8192 | .9526 | 1.0479 | 1.1431 | 1.1431 | .7621 | .5716 |
| 12 | .8192 | 1.0479 | .7621 | 1.1431 | 1.0479 | 1.0479 | .4763 |
| 13 | .7811 | | .8573 | 1.1431 | .8573 | .8573 | .4954 |
| 14 | .8002 | .7621 | .9526 | 1.1431 | .9526 | 1.1431 | .4763 |
| 15 | 1.105 | .8573 | 1.0479 | 1.2384 | .9526 | .9526 | .5716 |
| 16 | 1.0479 | 1.0669 | 1.1431 | .9526 | 1.1431 | 1.0479 | .5716 |
| 17 | .9717 | .8954 | 1.1431 | .9526 | .7621 | .9526 | .5716 |
| 18 | .6478 | .7621 | .9526 | .9907 | .6859 | .8002 | .5716 |
| 19 | .6097 | .6097 | | .8573 | .6859 | .7621 | .5716 |
| 20 | .6287 | .5716 | .8002 | .7621 | .7049 | .7621 | .5906 |
| 21 | .6287 | .6097 | .6859 | .6668 | .724 | .6478 | .5906 |
| 22 | .6097 | .5716 | .6097 | .5906 | .724 | .6097 | .5716 |
| 23 | .5906 | .5716 | .6287 | .5335 | .7621 | .5716 | .5716 |
| 24 | .3239 | .4954 | .5335 | .5716 | .4763 | .724 | .5144 |
| Max | 1.105 | 1.0669 | 1.1431 | 1.2384 | 1.1431 | 1.1431 | .5906 |
| Min | .3048 | .4954 | .4572 | .5335 | .381 | .5716 | .4763 |
| Avg | .6152 | .6817 | .7463 | .7962 | .7160 | .7589 | .5279 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 208 / 11KV MIDC No.VIII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1431 | 1.1431 | 1.2765 | 1.1431 | 1.2765 | 1.2384 | 1.1622 |
| 2 | 1.1431 | 1.1622 | 1.2193 | 1.105 | 1.2193 | 1.2384 | 1.086 |
| 3 | 1.1431 | 1.1622 | 1.2193 | 1.1431 | 1.2193 | 1.2574 | 1.0479 |
| 4 | 1.1431 | 1.1812 | 1.1431 | 1.1431 | 1.1812 | 1.1812 | .9907 |
| 5 | 1.1431 | 1.1812 | 1.1431 | 1.1431 | 1.1812 | 1.1812 | .9526 |
| 6 | 1.1431 | 1.2003 | 1.1431 | 1.1431 | 1.1431 | 1.2003 | .9907 |
| 7 | 1.1431 | 1.0098 | 1.2384 | 1.1431 | 1.1431 | 1.2574 | .9526 |
| 8 | 1.4289 | .9907 | 1.3336 | 1.3336 | 1.5242 | 1.3146 | .9526 |
| 9 | 1.7147 | 1.3336 | 1.4289 | 1.7147 | 1.5242 | 1.7147 | .9526 |
| 10 | 2.0005 | 1.5242 | 1.5242 | 2.0957 | 1.7147 | 1.9052 | .9526 |
| 11 | 2.191 | 1.9052 | 1.9052 | 2.2862 | 1.7147 | 1.9052 | .9526 |
| 12 | 1.5242 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.7147 | .9526 |
| 13 | 1.4289 | | 1.5242 | 2.0957 | 1.7147 | 1.5242 | .7621 |
| 14 | 1.9624 | 1.4289 | 1.5242 | 2.4768 | 1.9052 | 1.7147 | .8954 |
| 15 | 2.191 | 1.7147 | 1.7147 | 2.2862 | 2.0957 | 2.0957 | .9526 |
| 16 | 2.0005 | 1.7147 | 1.9052 | 1.7147 | 1.7147 | 2.0957 | .7621 |
| 17 | 1.9624 | 1.6194 | 2.0957 | 1.7147 | 1.7337 | 2.0957 | .8192 |
| 18 | 1.829 | 1.6194 | 2.2862 | 1.7147 | 1.7147 | 1.9052 | .8764 |
| 19 | 1.5242 | 1.5242 | 1.9052 | 1.5242 | 1.7718 | 1.7909 | .8764 |
| 20 | 1.2384 | 1.3336 | 1.7528 | 1.3146 | 1.0288 | 1.5623 | .8764 |
| 21 | 1.2003 | 1.1431 | 1.1431 | 1.105 | 1.1431 | 1.3336 | .8954 |
| 22 | 1.1431 | 1.2384 | 1.1431 | .9526 | 1.0288 | 1.3336 | .8573 |
| 23 | 1.0479 | 1.2384 | 1.1431 | 1.1431 | 1.0479 | 1.3336 | 1.2193 |
| 24 | 1.1431 | 1.1431 | 1.3336 | .9526 | 1.3336 | .9907 | |
| Max | 2.191 | 1.9052 | 2.2862 | 2.4768 | 2.0957 | 2.0957 | 1.2193 |
| Min | 1.0479 | .9907 | 1.1431 | .9526 | 1.0288 | .9907 | .7621 |
| Avg | 1.4805 | 1.3659 | 1.4980 | 1.5122 | 1.4575 | 1.5369 | .9451 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 209 / 11 KV MIDC IX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.105 | .9717 | 1.105 | 1.1431 | 1.0479 | 1.1241 | 1.1431 |
| 2 | 1.1431 | .9907 | 1.0288 | 1.1622 | 1.0479 | 1.105 | 1.1431 |
| 3 | 1.1431 | .9907 | .9526 | 1.086 | 1.105 | 1.105 | 1.1241 |
| 4 | 1.1431 | .9907 | .9526 | 1.1431 | 1.105 | 1.0669 | 1.0669 |
| 5 | 1.105 | 1.0288 | 1.0288 | 1.1431 | 1.1431 | 1.086 | 1.086 |
| 6 | 1.105 | 1.0479 | 1.0669 | 1.105 | 1.1431 | 1.086 | 1.086 |
| 7 | 1.105 | 1.0288 | 1.0479 | 1.1241 | 1.1812 | 1.1431 | 1.086 |
| 8 | 1.086 | 1.0098 | 1.0479 | 1.1431 | 1.3336 | 1.2003 | .9907 |
| 9 | 1.105 | 1.3336 | 1.1431 | 1.3336 | 1.5242 | 1.3336 | .8192 |
| 10 | 1.3336 | 1.4289 | 1.4289 | 1.6194 | 1.5242 | 1.4289 | .8573 |
| 11 | 1.4289 | 1.5242 | 1.3336 | 1.3336 | 1.3336 | 1.3336 | .9526 |
| 12 | 1.2574 | 1.6194 | 1.3336 | 1.2384 | 1.2384 | 1.2384 | 1.829 |
| 13 | 1.2384 | | 2.4768 | 1.3336 | 1.2384 | 1.2384 | 1.7908 |
| 14 | 1.3336 | 1.5242 | 1.4289 | 1.3336 | 1.3336 | 1.2384 | .9526 |
| 15 | 1.3527 | 1.3336 | 1.6194 | 1.2384 | 1.3336 | 1.1431 | .8573 |
| 16 | 1.3717 | 1.5051 | 1.3336 | 1.3336 | 1.4289 | 1.5242 | 2.0958 |
| 17 | 1.2003 | 1.4098 | 1.4289 | 1.2955 | 1.3908 | 1.4289 | 1.0479 |
| 18 | 1.1622 | 1.2384 | 1.5242 | 1.2384 | 1.1812 | 1.467 | 1.0288 |
| 19 | 1.1431 | 1.0288 | 1.4861 | 1.1812 | .9526 | 1.3336 | 1.0479 |
| 20 | 1.1812 | 1.0479 | 1.3336 | 1.1812 | 1.1812 | 1.3336 | 1.0669 |
| 21 | .9907 | 1.105 | 1.1431 | 1.1431 | 1.0479 | 1.1812 | 1.0479 |
| 22 | .9526 | 1.105 | 1.1431 | 1.1431 | .9907 | 1.1431 | 1.0669 |
| 23 | .9335 | 1.1431 | 1.2193 | 1.086 | .9526 | 1.1431 | 1.1241 |
| 24 | 1.0669 | 1.0479 | 1.1431 | 1.105 | 1.105 | 1.105 | 1.1431 |
| Max | 1.4289 | 1.6194 | 2.4768 | 1.6194 | 1.5242 | 1.5242 | 2.0958 |
| Min | .9335 | .9717 | .9526 | 1.086 | .9526 | 1.0669 | .8192 |
| Avg | 1.1661 | 1.1937 | 1.2812 | 1.2161 | 1.2027 | 1.2304 | 1.1439 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 210 / TAKALGHAT(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | | | | .1524 | |
| 9 | | .1524 | .1905 | .1905 | |
| 10 | | .1524 | .2286 | .2858 | .1905 |
| 11 | .1524 | .1524 | .1905 | .2858 | .2286 |
| 12 | .1524 | .1715 | .1905 | .2858 | .2286 |
| 13 | .1524 | .1905 | .2477 | .2858 | .2477 |
| 14 | .1524 | .2286 | .1524 | .2667 | .2286 |
| 15 | .1524 | .1905 | .1524 | .2667 | .2286 |
| Max | .1524 | .2286 | .2477 | .2858 | .2477 |
| Min | .1524 | .1524 | .1524 | .1524 | .1905 |
| Avg | .1524 | .1769 | .1932 | .2524 | .2254 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 201 / 11 KV MOHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | .6859 | .9088 | .8573 | .6859 | 1.0288 | 1.0288 |
| 2 | .6859 | .6516 | .8916 | | .6859 | .8573 | .8573 |
| 3 | .6859 | .6859 | .8573 | .6859 | .6859 | 1.0288 | .8573 |
| 4 | .6001 | .6859 | .7716 | .6859 | .6859 | 1.0288 | .8573 |
| 5 | .6859 | .6859 | .6859 | .6859 | .6859 | 1.0288 | .8573 |
| 6 | .6859 | .6859 | .7716 | .6859 | .6859 | .8573 | .8573 |
| 7 | .6859 | .8573 | .8573 | .8573 | .8573 | 1.0288 | .8573 |
| 8 | .8573 | 1.0288 | .8573 | .8573 | .8573 | 1.0288 | 1.0288 |
| 9 | .8573 | 1.0288 | .8573 | 1.0288 | 1.0288 | | 1.0288 |
| 10 | .8573 | .8573 | .8573 | 1.0288 | 1.0288 | 1.0288 | .8573 |
| 11 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 | .6859 |
| 12 | .8573 | .8573 | .8573 | .8573 | .8573 | .8573 | .6859 |
| 13 | .6859 | .6859 | .6859 | .8573 | .6859 | .8573 | .6859 |
| 14 | .6859 | .5144 | .5144 | .6859 | .6859 | .6859 | .6859 |
| 15 | .6859 | .6859 | .5144 | .6859 | .6859 | .6859 | .6859 |
| 16 | .6859 | .6859 | .5144 | .6859 | .8573 | .6859 | .6859 |
| 17 | .6859 | | .5144 | .8573 | .8573 | .6859 | .8573 |
| 18 | .8573 | .8573 | .6859 | .8573 | 1.0288 | 1.0288 | .8573 |
| 19 | 1.2003 | .8573 | | 1.2003 | 1.0288 | 1.2003 | .8573 |
| 20 | 1.0288 | 1.0288 | .6859 | 1.2003 | 1.2003 | 1.2003 | .8573 |
| 21 | 1.0288 | 1.0288 | 1.0288 | 1.3717 | .8573 | 1.2003 | .6859 |
| 22 | .6859 | .8573 | .8573 | .8573 | .6859 | 1.0288 | .6859 |
| 23 | .6859 | .8573 | .8573 | .8573 | .6859 | 1.0288 | .6859 |
| 24 | .6859 | .6859 | .8573 | .8573 | .6859 | .8573 | .8573 |
| Max | 1.2003 | 1.0288 | 1.0288 | 1.3717 | 1.2003 | 1.2003 | 1.0288 |
| Min | .6001 | .5144 | .5144 | .6859 | .6859 | .6859 | .6859 |
| Avg | .7752 | .7962 | .7716 | .8722 | .8145 | .9468 | .8145 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 202 / 11 KV BUTIBORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .5144 | .7373 | .6344 | .583 | .7716 | .6516 |
| 2 | .5144 | .5144 | .8402 | .6173 | .5658 | .6859 | .6516 |
| 3 | .4801 | .4801 | .8573 | .6344 | .5316 | .6859 | .6859 |
| 4 | .5144 | .4801 | .8573 | .6344 | .5487 | .6516 | .6687 |
| 5 | .6001 | .463 | .7716 | .6173 | .5144 | .5144 | .6859 |
| 6 | .5144 | .6001 | .8573 | .6173 | .583 | .7716 | .6859 |
| 7 | .6859 | .6859 | .8402 | .6859 | .7545 | .7373 | .7716 |
| 8 | .6859 | .7716 | .6859 | .7373 | | .7202 | .823 |
| 9 | .6859 | .7716 | .7716 | .7716 | .7716 | .7545 | .8573 |
| 10 | .6516 | .823 | .6859 | .7716 | .7716 | .7545 | .6516 |
| 11 | .6687 | .6859 | .7202 | .823 | .8573 | .6859 | .6687 |
| 12 | .6516 | | .7545 | .7716 | .6859 | .7202 | .6859 |
| 13 | .6516 | .5144 | .6859 | .703 | .6859 | .6859 | .6859 |
| 14 | .6001 | .3772 | .5144 | .583 | .6859 | .6001 | .6687 |
| 15 | .583 | .5144 | .5144 | .6859 | .6516 | .5144 | .7373 |
| 16 | .6001 | .6001 | .4801 | .7545 | .6859 | .6516 | |
| 17 | .6173 | | .5144 | .6859 | .6859 | .6173 | |
| 18 | .6859 | .6516 | .6687 | .5487 | .6859 | .7373 | .5316 |
| 19 | .9431 | .6001 | | .8745 | .7716 | .7716 | .7716 |
| 20 | .6859 | .6859 | .8573 | .6859 | .8059 | .8402 | .8745 |
| 21 | .7545 | .7716 | .8573 | .6859 | .6859 | .7716 | .8573 |
| 22 | .5487 | .6859 | .6344 | .463 | .7202 | .7545 | .7545 |
| 23 | .5144 | .6516 | .6516 | .5144 | .6859 | .6859 | .6859 |
| 24 | .6516 | .5316 | .6859 | .6344 | .5487 | .7716 | .6516 |
| Max | .9431 | .823 | .8573 | .8745 | .8573 | .8402 | .8745 |
| Min | .4801 | .3772 | .4801 | .463 | .5144 | .5144 | .5316 |
| Avg | .6252 | .6079 | .7149 | .6723 | .6725 | .7023 | .7139 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 203 / 11 KV BORKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5432 | 1.3717 | 1.7147 | 1.5432 | .3772 | 1.7147 | 1.5432 |
| 2 | 1.7147 | 1.5432 | 1.6289 | 1.7147 | 1.5432 | 1.7147 | 1.5432 |
| 3 | 1.5432 | 1.7147 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |
| 4 | 1.5432 | 1.7147 | 1.6289 | | 1.5432 | 1.5432 | 1.5432 |
| 5 | | 1.7147 | 1.7147 | 1.7147 | 1.5432 | 1.7147 | 1.5432 |
| 6 | | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.5432 |
| 7 | .3429 | 1.7147 | 1.7147 | 1.5432 | 1.7147 | 1.5432 | 1.5432 |
| 8 | 1.5432 | 1.7147 | 1.7147 | 1.5432 | 1.7147 | 1.5432 | 1.5432 |
| 9 | 1.5432 | 1.5432 | 1.7147 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |
| 10 | 1.7147 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.3717 |
| 11 | 1.7147 | 1.5432 | .4287 | 1.3717 | 1.5432 | 1.5432 | 1.3717 |
| 12 | 1.7147 | 1.3717 | 1.5432 | 1.3717 | 1.7147 | 1.5432 | 1.3717 |
| 13 | 1.5432 | 1.5432 | 1.7147 | 1.3717 | .8573 | 1.5432 | 1.3717 |
| 14 | 1.5432 | 1.5432 | 1.7147 | 1.5432 | 1.5432 | 1.5432 | 1.3717 |
| 15 | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.7147 | 1.5432 | 1.3717 |
| 16 | 1.7147 | 1.5432 | 1.5432 | 1.5432 | 1.7147 | 1.5432 | 1.5432 |
| 17 | 1.7147 | | 1.5432 | 1.3717 | 1.3717 | 1.5432 | 1.5432 |
| 18 | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.5432 | 1.5432 | 1.5432 |
| 19 | 1.8861 | 1.7147 | | 1.8861 | 1.5432 | | 1.5432 |
| 20 | 1.7147 | 1.8861 | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.5432 |
| 21 | 1.8861 | 1.8861 | 1.7147 | 1.7147 | 1.5432 | 1.7147 | 1.5432 |
| 22 | | 1.7147 | 1.7147 | 1.7147 | 1.5432 | 1.5432 | 1.5432 |
| 23 | 1.7147 | 1.7147 | 1.7147 | 1.7147 | 1.5432 | 1.5432 | 1.5432 |
| 24 | 1.5432 | 1.7147 | 1.7147 | 1.7147 | 1.5432 | 1.5432 | 1.5432 |
| Max | 1.8861 | 1.8861 | 1.7147 | 1.8861 | 1.7147 | 1.7147 | 1.5432 |
| Min | .3429 | 1.3717 | .4287 | 1.3717 | .3772 | 1.5432 | 1.3717 |
| Avg | 1.5922 | 1.6401 | 1.6066 | 1.5954 | 1.5089 | 1.5879 | 1.5003 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 205 / 11 KV AIR II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .5144 | .3429 | .5144 | .5144 | .5487 | .5144 |
| 2 | .5487 | .4115 | .3429 | .5144 | .5658 | .5144 | .5144 |
| 3 | .583 | .463 | .3429 | .5144 | .5487 | .5487 | .5487 |
| 4 | .5658 | .4801 | .2572 | .5316 | .6001 | .5144 | .5487 |
| 5 | .5487 | .0343 | .1715 | .5144 | | .6001 | .6001 |
| 6 | .4801 | .4115 | .1372 | .5316 | .5658 | .5144 | .6001 |
| 7 | .1372 | .1372 | .1372 | .1372 | .1372 | .1372 | .1543 |
| 8 | .1372 | .1372 | .1372 | .1372 | .1372 | .1372 | .1543 |
| 9 | .1372 | .1543 | .1372 | .1372 | .1372 | .1372 | .1543 |
| 10 | .1372 | .1543 | .1372 | .1543 | .1543 | .1543 | .1543 |
| 11 | .1372 | .1543 | .1372 | .1543 | .1543 | .1543 | .1543 |
| 12 | .1543 | .1543 | .1372 | .1543 | .1543 | .1543 | .2058 |
| 13 | .2229 | .2229 | .1372 | .1543 | .2401 | .2401 | .2058 |
| 14 | .2229 | .3601 | .1372 | .1543 | .2401 | .2058 | .2058 |
| 15 | .2229 | .2229 | .1372 | .2058 | .2401 | .2058 | .2229 |
| 16 | .2229 | .5144 | .12 | .2058 | .2401 | .2058 | .2229 |
| 17 | .2401 | | .1543 | .2058 | .6344 | .2058 | .3429 |
| 18 | .4287 | .2058 | .463 | .2058 | .5658 | .2058 | .4801 |
| 19 | .4458 | .5144 | | .583 | .6173 | .5144 | .5144 |
| 20 | .4287 | .5487 | .5144 | .4287 | .6001 | .5487 | .5487 |
| 21 | .4115 | .583 | .5144 | .3944 | .583 | .5144 | .5487 |
| 22 | .4287 | .5144 | .5316 | .3944 | .583 | .583 | .583 |
| 23 | .4458 | .5487 | .5144 | .3772 | .5658 | .5487 | .5658 |
| 24 | .5144 | .4287 | .3429 | .5144 | .5144 | .5144 | .5144 |
| Max | .583 | .583 | .5316 | .583 | .6344 | .6001 | .6001 |
| Min | .1372 | .0343 | .12 | .1372 | .1372 | .1372 | .1543 |
| Avg | .3465 | .3422 | .2602 | .3258 | .4041 | .3587 | .3858 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 206 / 11 KV W.T.PLANT FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .4115 | .3429 | .4287 | .5144 | .3258 | .4801 |
| 2 | .3086 | .4287 | .3258 | .4801 | .4287 | .3429 | .4801 |
| 3 | .3429 | .4458 | .3258 | .4801 | .4115 | .3086 | .5144 |
| 4 | .2915 | .4287 | .3258 | .5144 | .4287 | .3086 | .4801 |
| 5 | .3086 | .4115 | .3086 | .5144 | .463 | .3258 | .5144 |
| 6 | .2915 | .463 | .3429 | .5144 | .4973 | .3429 | .5144 |
| 7 | .2401 | .3429 | .2915 | .4287 | .4287 | .4287 | .4801 |
| 8 | .3429 | .3086 | .3429 | .3944 | .4973 | .5144 | .3944 |
| 9 | .3258 | .3429 | .3601 | .4115 | .5144 | .5487 | .3258 |
| 10 | .3429 | .4801 | .3944 | .4115 | .5487 | .5487 | .5316 |
| 11 | .3772 | .4801 | .3944 | .4115 | .5144 | .5144 | .6001 |
| 12 | .4458 | .4801 | .3772 | .4115 | .5316 | .5658 | .6687 |
| 13 | .4801 | .583 | .3429 | .3601 | .5144 | .5658 | .583 |
| 14 | .4801 | .5144 | .3429 | .3258 | .5144 | .5316 | |
| 15 | .4973 | .4287 | .3086 | .3258 | .5487 | .5144 | .3601 |
| 16 | .4287 | .4115 | .3086 | .3258 | .5144 | .3944 | .3944 |
| 17 | .3944 | | .2915 | .3258 | .4458 | .4287 | .4115 |
| 18 | .4115 | .3944 | .3944 | .3258 | .4458 | .4287 | .4458 |
| 19 | .4287 | .3944 | | .2229 | .5144 | .4458 | .4287 |
| 20 | .4115 | .4115 | .463 | .4115 | .5487 | .4458 | .4458 |
| 21 | .4115 | .4115 | 1.046 | .4115 | .5144 | .4458 | .4287 |
| 22 | .4287 | .3772 | .4801 | .4115 | .4801 | .4287 | .4287 |
| 23 | .4115 | .3944 | .463 | .3944 | .4801 | .4458 | .4115 |
| 24 | .5658 | .3772 | .3086 | .4287 | .5144 | .4973 | .4287 |
| Max | .5658 | .583 | 1.046 | .5144 | .5487 | .5658 | .6687 |
| Min | .2401 | .3086 | .2915 | .2229 | .4115 | .3086 | .3258 |
| Avg | .3879 | .4227 | .3862 | .4030 | .4923 | .4437 | .4674 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 208 / 11 KV RAMADAM

NON SHEDDABLE WATER SUPPLY AND
UTILITY

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .3429 | .3429 | .3429 | .3429 | .3429 | .2572 |
| 2 | .5144 | .3772 | .3772 | .3429 | .3429 | .3258 | .2572 |
| 3 | .4801 | .3944 | .3944 | .3086 | .3601 | .2058 | .3086 |
| 4 | .3429 | .3772 | .3429 | .3429 | .3258 | .3086 | .3086 |
| 5 | .3429 | .3429 | .3258 | .3429 | .3086 | .3258 | .3429 |
| 6 | .3258 | .3258 | | .3429 | .3258 | .3429 | .3429 |
| 7 | .2058 | .3547 | .3258 | .3429 | .3258 | .3429 | .3429 |
| 8 | .2058 | .3258 | .3429 | .3429 | .3258 | .3429 | .3258 |
| 9 | .2058 | .3429 | .3086 | .3429 | .3258 | .3429 | .3258 |
| 10 | .2229 | .3429 | .2058 | .3429 | .3429 | .3429 | .3429 |
| 11 | .2572 | .3601 | .2058 | .3429 | .3429 | .3429 | .3429 |
| 12 | .3086 | .3429 | .2229 | .3601 | .3601 | .3429 | .3258 |
| 13 | .3429 | .3601 | .2058 | .3601 | .3601 | .3429 | .3429 |
| 14 | .3429 | .3601 | .2229 | .3601 | .3601 | .3429 | .3601 |
| 15 | .3601 | .3429 | .2572 | .3601 | .3601 | .3429 | .3429 |
| 16 | .3601 | .2229 | .3258 | .3601 | .3601 | .3429 | .3258 |
| 17 | .3601 | | .3086 | .3429 | .3601 | .3601 | .3429 |
| 18 | | .3258 | .3258 | .2572 | .2058 | .3258 | .3429 |
| 19 | .2229 | .3429 | | .2229 | .2058 | .3429 | .3429 |
| 20 | .3429 | .3258 | .3429 | .2058 | .2229 | .3429 | .3429 |
| 21 | .3258 | .3258 | .3429 | .2058 | .2058 | .3086 | .3086 |
| 22 | .3258 | .3429 | .3429 | .2058 | .2058 | .2058 | .2058 |
| 23 | .3429 | .3086 | .3429 | .2229 | .2058 | .2229 | .2229 |
| 24 | .2401 | .3429 | .3429 | .3429 | .3429 | .2229 | .2401 |
| Max | .5144 | .3944 | .3944 | .3601 | .3601 | .3601 | .3601 |
| Min | .2058 | .2229 | .2058 | .2058 | .2058 | .2058 | .2058 |
| Avg | .3258 | .3405 | .3071 | .3143 | .3094 | .3172 | .3143 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 401 / 33 KV BELA

Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5432 | 1.5432 | 1.286 | 1.2346 | 1.8004 | 2.0576 | 1.4403 |
| 2 | 1.8004 | 1.6461 | 1.286 | 1.286 | 1.5432 | 1.8004 | 1.4403 |
| 3 | 1.5432 | 1.6975 | 1.4918 | 1.4403 | 1.6461 | 2.0576 | 1.286 |
| 4 | 1.6461 | 1.6461 | 1.5432 | 1.4403 | 1.6461 | 1.8004 | 1.286 |
| 5 | 1.749 | 1.5432 | 1.6461 | 1.6461 | 1.5432 | 1.9033 | 1.0802 |
| 6 | 1.8004 | 1.6975 | 1.6461 | 1.749 | 1.9547 | 1.9547 | 1.0802 |
| 7 | 1.8519 | 1.6975 | 1.6461 | 1.8004 | 2.2119 | 2.1091 | 2.1605 |
| 8 | 1.5432 | 1.5432 | 1.5432 | 1.8519 | 2.2119 | 2.572 | 2.1091 |
| 9 | 1.286 | 1.4403 | 1.8004 | 1.8004 | 2.3148 | 2.572 | 2.2634 |
| 10 | 1.4918 | 1.5947 | 2.0576 | 1.749 | 2.3663 | | 1.9033 |
| 11 | 2.0576 | 2.0576 | 2.1091 | 1.6461 | 2.3148 | 2.4691 | 1.8004 |
| 12 | 2.1605 | 2.1605 | 2.1091 | 2.0062 | 1.5432 | 2.0576 | 1.5432 |
| 13 | 2.2119 | 2.5206 | 2.3148 | 2.5206 | 1.6975 | 1.8004 | 1.749 |
| 14 | 2.572 | 3.035 | 2.6749 | 2.4691 | 1.6461 | 2.1091 | 1.4918 |
| 15 | 2.6749 | 2.9321 | 2.572 | 2.4691 | 1.749 | 2.0576 | 1.5947 |
| 16 | 2.8567 | 3.6523 | 2.4177 | 2.4691 | 1.6461 | 1.8519 | 1.6975 |
| 17 | 2.7778 | | 2.3148 | 2.4691 | 1.6975 | 1.286 | 1.0802 |
| 18 | 2.572 | 1.749 | 2.1091 | 2.0062 | 1.9547 | .823 | 1.1317 |
| 19 | 2.3663 | 1.166 | 1.5432 | 2.1605 | 1.5432 | 1.0288 | 1.0288 |
| 20 | 1.6975 | 1.5432 | 1.286 | 1.286 | 1.286 | 1.3375 | .8745 |
| 21 | 1.3889 | 1.1831 | | 1.3375 | 1.286 | 1.5432 | 1.0288 |
| 22 | 1.4403 | 1.2346 | 1.286 | 1.4918 | 1.286 | 1.5432 | 1.0802 |
| 23 | 1.286 | 1.286 | 1.1831 | 1.5432 | 1.2346 | 1.5432 | 1.0288 |
| 24 | 1.2346 | 1.2346 | 1.286 | 1.1831 | 1.5432 | 1.1831 | 1.5432 |
| Max | 2.8567 | 3.6523 | 2.6749 | 2.5206 | 2.3663 | 2.572 | 2.2634 |
| Min | 1.2346 | 1.166 | 1.1831 | 1.1831 | 1.2346 | .823 | .8745 |
| Avg | 1.8980 | 1.8176 | 1.7892 | 1.7940 | 1.7361 | 1.8026 | 1.4468 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 402 / 33 KV VARRON AUTO

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4115 | .4115 | .4115 | .4115 | .4115 | .3601 | .4115 |
| 2 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| 3 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| 4 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| 5 | .3601 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| 6 | .3601 | .3601 | .4115 | .4115 | .3601 | .4115 | .4115 |
| 7 | .3601 | .3601 | .4115 | .3601 | .4115 | .3601 | .3601 |
| 8 | .4115 | .3601 | .3601 | .3601 | .4115 | .4115 | |
| 9 | .4115 | .4115 | .3601 | .3601 | .4115 | .4115 | .3601 |
| 10 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 | .3601 |
| 11 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 | |
| 12 | .3601 | .4115 | .4115 | .4115 | .4115 | .4115 | |
| 13 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 | |
| 14 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 | |
| 15 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 | |
| 16 | .4115 | .4115 | .3601 | .4115 | .4115 | .3601 | |
| 17 | .4481 | | .3601 | .4115 | .4115 | .3601 | |
| 18 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| 19 | .4115 | .3601 | | .4115 | .4115 | .4115 | .4115 |
| 20 | .4115 | .3601 | .4115 | .4115 | .4115 | .4115 | .3601 |
| 21 | .4115 | .3601 | .4115 | .3601 | .4115 | .4115 | .4115 |
| 22 | .3601 | .3601 | .3601 | .3601 | .4115 | .4115 | .4115 |
| 23 | .3601 | .3601 | .3601 | .3601 | .4115 | .4115 | .4115 |
| 24 | .4115 | .3601 | .4115 | .3601 | .4115 | .3601 | .4115 |
| Max | .4481 | .4115 | .4115 | .4115 | .4115 | .4115 | .4115 |
| Min | .3601 | .3601 | .3601 | .3601 | .3601 | .3601 | .3601 |
| Avg | .3895 | .3914 | .3869 | .3965 | .4094 | .4008 | .3987 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0762 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 2 | .0953 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 3 | .0762 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 4 | .0762 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 5 | .0762 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 6 | .0762 | .0934 | .0762 | .0762 | .0934 | .0762 | .0762 |
| 7 | .0762 | .0934 | .0572 | .0572 | .0934 | .0762 | .0762 |
| 8 | .0762 | .0934 | .0572 | .0572 | .0747 | .0953 | .0762 |
| 9 | .0762 | .0747 | .0762 | .0572 | .056 | .0762 | .0762 |
| 10 | .0762 | .056 | .0762 | .0572 | .056 | .0762 | .0762 |
| 11 | .056 | .0572 | .0762 | .056 | .0572 | .0762 | .0747 |
| 12 | .056 | .0572 | .0762 | .056 | .0572 | .0762 | .056 |
| 13 | .056 | .0572 | .0762 | .056 | .0572 | .0572 | .056 |
| 14 | .056 | .0572 | .0762 | .056 | .0572 | .0762 | .056 |
| 15 | .056 | .0572 | .0762 | .056 | .0572 | .0762 | .056 |
| 16 | .056 | .0572 | .0762 | .056 | .0572 | .0762 | .056 |
| 17 | .056 | .0572 | .0762 | .0747 | .0572 | .0762 | .056 |
| 18 | .056 | .0572 | .0762 | .056 | .0572 | | .056 |
| 19 | .0747 | .0572 | .0762 | .0747 | .0572 | .0762 | .0934 |
| 20 | .0934 | .0953 | .0953 | .0934 | .0762 | .0762 | .0934 |
| 21 | .0934 | .0953 | .0953 | .0934 | .0762 | .0762 | .0934 |
| 22 | .0934 | .0953 | .0953 | .0934 | .0953 | .0762 | .0934 |
| 23 | .0934 | .0762 | .0572 | .0934 | .0762 | .0762 | .0934 |
| 24 | .0572 | .0934 | .0953 | .0572 | .0934 | .0762 | .0762 |
| Max | .0953 | .0953 | .0953 | .0934 | .0953 | .0953 | .0934 |
| Min | .056 | .056 | .0572 | .056 | .056 | .0572 | .056 |
| Avg | .0723 | .0770 | .0770 | .0691 | .0739 | .0762 | .0738 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 201 / 11 KV MOHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | .4294 | .381 | .381 | .5041 | .4572 | .4763 |
| 2 | .4572 | .4294 | .381 | .381 | .5041 | .4572 | .4763 |
| 3 | .4191 | .4108 | .381 | .381 | .4668 | .4763 | .4763 |
| 4 | .4191 | .4108 | .381 | .381 | .4668 | .4763 | .4572 |
| 5 | .381 | .4294 | .381 | .381 | .4481 | .4954 | .4191 |
| 6 | .4954 | .4668 | .4191 | .4191 | .4668 | .5144 | .4954 |
| 7 | .5335 | .4854 | .4572 | .4954 | .4668 | .5335 | .5335 |
| 8 | .5525 | .5601 | .5335 | .5144 | .5788 | .6478 | .5716 |
| 9 | .5335 | .5228 | .4954 | .5335 | .6348 | .6859 | .7049 |
| 10 | .4954 | .4481 | .5525 | .6478 | .6161 | .6478 | .7049 |
| 11 | .4854 | .5144 | .4954 | .5975 | .5335 | .6097 | .6348 |
| 12 | .4481 | .4763 | .5335 | .5975 | .5716 | .6097 | .6161 |
| 13 | .4481 | .4191 | .4954 | .5228 | .6097 | .6287 | .5601 |
| 14 | .4481 | .4191 | .4954 | .4481 | .5335 | .5716 | .5788 |
| 15 | .4294 | .4763 | .5335 | .4668 | .5144 | .5335 | .4854 |
| 16 | .3734 | .4572 | .5525 | .4854 | .5716 | .5335 | .5788 |
| 17 | .4108 | .4763 | .5716 | .5041 | .6097 | .6097 | .5788 |
| 18 | .4108 | .5144 | .5335 | .4668 | .5335 | .6097 | .5228 |
| 19 | .6161 | .7049 | .6859 | .6722 | .6478 | .7049 | .6535 |
| 20 | .6348 | .6287 | .6287 | .6535 | .6478 | .7049 | .6722 |
| 21 | .5975 | .5716 | .6287 | .5975 | .6478 | .6859 | .6161 |
| 22 | .5228 | .4954 | .5716 | .5788 | .6097 | .6097 | .5975 |
| 23 | .4481 | .4382 | .4954 | .5041 | .5335 | .5335 | .5601 |
| 24 | .4572 | .4294 | .381 | .4763 | .5041 | .4954 | .4954 |
| Max | .6348 | .7049 | .6859 | .6722 | .6478 | .7049 | .7049 |
| Min | .3734 | .4108 | .381 | .381 | .4481 | .4572 | .4191 |
| Avg | .4781 | .4839 | .4985 | .5036 | .5509 | .5763 | .5611 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 202 / 11 KV CICR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .056 | .0762 | .0762 | .056 | .0572 | .0572 |
| 2 | .0572 | .0747 | .0762 | .0762 | .056 | .0572 | .0572 |
| 3 | .0572 | .0747 | .0762 | .0762 | .056 | .0572 | .0572 |
| 4 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 5 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 6 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 7 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0953 |
| 8 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0953 |
| 9 | .0572 | .056 | .0572 | .0572 | .0747 | .0953 | .0953 |
| 10 | .0953 | .0934 | .1143 | .0572 | .112 | .1524 | .1334 |
| 11 | .112 | .1143 | .1143 | .056 | .1334 | .1524 | .0934 |
| 12 | .0934 | .0953 | .0953 | .056 | .1143 | .1715 | .168 |
| 13 | .0934 | .0953 | .0953 | .056 | .0953 | .1715 | .168 |
| 14 | .112 | .0953 | .1143 | .056 | .1143 | .1715 | .2427 |
| 15 | .112 | .1143 | .0953 | .056 | .1143 | .1524 | .1867 |
| 16 | .0934 | .0953 | .0953 | .056 | .0953 | .1524 | |
| 17 | .0747 | .0762 | .0572 | .056 | .0762 | .0762 | |
| 18 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .112 |
| 19 | .056 | .0762 | .0762 | .056 | .0572 | .0953 | .0934 |
| 20 | .056 | .0762 | .0572 | .056 | .0572 | .0953 | .0934 |
| 21 | .056 | .0572 | .0572 | .056 | .0572 | .0953 | .0747 |
| 22 | .0747 | .0572 | .0572 | .056 | .0572 | .0953 | .0747 |
| 23 | .056 | .0762 | .0572 | .056 | .0572 | .0953 | .0747 |
| 24 | .0572 | .056 | .0762 | .0572 | .056 | .0572 | .0953 |
| Max | .112 | .1143 | .1143 | .0762 | .1334 | .1715 | .2427 |
| Min | .056 | .056 | .0572 | .056 | .056 | .0572 | .0572 |
| Avg | .0714 | .0740 | .0746 | .0589 | .0740 | .0985 | .1018 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 203 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2667 | .2614 | .1715 | .1715 | .2614 | .1334 | .1905 |
| 2 | .2667 | .2427 | .1905 | .1905 | .2427 | .1334 | .1905 |
| 3 | .2286 | .2427 | .1524 | .1524 | .2054 | .1143 | .1524 |
| 4 | .2286 | .2241 | .1334 | .1334 | .1867 | .1143 | .1143 |
| 5 | .1905 | .168 | .1143 | .1143 | .168 | .1143 | .1143 |
| 6 | .1524 | .0934 | .0953 | .0953 | .0934 | .0953 | .0953 |
| 7 | .0953 | .0934 | .0953 | .0953 | .0747 | .0953 | .0953 |
| 8 | .0953 | .0934 | .0953 | .0953 | .0747 | .0762 | .0953 |
| 9 | .0953 | .112 | .0953 | .0953 | .0934 | .0953 | .0953 |
| 10 | .0953 | .112 | .0953 | .0953 | .1307 | .1334 | .1143 |
| 11 | .0934 | .1524 | .1524 | .112 | .1715 | .1143 | .1494 |
| 12 | .0747 | .1524 | .1334 | .112 | .1715 | .1143 | .1867 |
| 13 | .112 | .1143 | .1143 | .0747 | .1143 | .1143 | .1307 |
| 14 | .112 | .0953 | .0953 | .0747 | .1334 | .1334 | .112 |
| 15 | .112 | .1143 | .1524 | .0934 | .1334 | .1334 | .1307 |
| 16 | .0934 | .1334 | .1524 | .1307 | .1143 | .1334 | .1307 |
| 17 | .1307 | .1524 | .1524 | .0934 | .1143 | .1143 | .1307 |
| 18 | .0934 | .1334 | .1143 | .0934 | .0953 | .1143 | .112 |
| 19 | .112 | .1143 | .1524 | .112 | .1143 | .1143 | .112 |
| 20 | .112 | .1143 | .1334 | .112 | .1334 | .1143 | .112 |
| 21 | .1307 | .1524 | .1143 | .168 | .1334 | .0953 | .112 |
| 22 | .1867 | .1334 | .3239 | .2987 | .1905 | .1143 | .168 |
| 23 | .2614 | .1715 | .3239 | .2801 | .2667 | .1143 | .168 |
| 24 | .1905 | .2614 | .2858 | .1143 | .2614 | .1905 | .1143 |
| Max | .2667 | .2614 | .3239 | .2987 | .2667 | .1905 | .1905 |
| Min | .0747 | .0934 | .0953 | .0747 | .0747 | .0762 | .0953 |
| Avg | .1471 | .1516 | .1516 | .1295 | .1533 | .1175 | .1303 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 204 / 11 K V JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | .4108 | .4763 | .4763 | .4854 | .4763 | .4763 |
| 2 | .4572 | .4108 | .4572 | .4572 | .4668 | .4572 | .4572 |
| 3 | .4572 | .3921 | .4572 | .4572 | .4481 | .4572 | .4572 |
| 4 | .4191 | .3921 | .4572 | .4572 | .4294 | .4572 | .4382 |
| 5 | .4191 | .4108 | .4572 | .4572 | .4294 | .4382 | .4382 |
| 6 | .4191 | .4481 | .4382 | .4382 | .4668 | .4382 | .4382 |
| 7 | .381 | .4481 | .4191 | .4191 | .3734 | .4382 | .4572 |
| 8 | .381 | .3174 | .4001 | .381 | .3734 | .4572 | .4001 |
| 9 | .381 | .3361 | .5144 | .4191 | .3734 | .4001 | .3048 |
| 10 | .381 | .3361 | .5716 | .4763 | .4294 | .4191 | .3048 |
| 11 | .3361 | .3429 | .4572 | .4481 | .4382 | .6478 | .2987 |
| 12 | .3174 | .3048 | .4191 | .4481 | .4572 | .6859 | .2987 |
| 13 | .2987 | .3048 | .4954 | .4108 | .4763 | .5335 | .2614 |
| 14 | .2987 | .3429 | .4001 | .4481 | .4572 | .6097 | .2801 |
| 15 | .3361 | .4001 | .4572 | .4481 | .5716 | .6859 | |
| 16 | .3734 | .4954 | .5525 | .5041 | .6097 | .6859 | |
| 17 | .3921 | .5335 | .6097 | .4481 | .5906 | .7621 | |
| 18 | .4294 | .5335 | .6097 | .4481 | .5335 | .7621 | .4294 |
| 19 | .5601 | .5716 | .8002 | .6161 | .8002 | | .5228 |
| 20 | .5228 | .5906 | .7621 | .5975 | .6859 | .6859 | .5041 |
| 21 | .5041 | .5144 | .724 | .5601 | .5716 | .5335 | .5228 |
| 22 | .5041 | .5144 | .6859 | .5601 | .6097 | .6097 | .5228 |
| 23 | .4668 | .5144 | .6668 | .5415 | .5716 | .6097 | .5041 |
| 24 | .4572 | .4108 | .4954 | .5716 | .5041 | .5525 | .4572 |
| Max | .5601 | .5906 | .8002 | .6161 | .8002 | .7621 | .5228 |
| Min | .2987 | .3048 | .4001 | .381 | .3734 | .4001 | .2614 |
| Avg | .4146 | .4282 | .5327 | .4787 | .5064 | .5567 | .4178 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 205 / 11 Kv MJP W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 2 | .0572 | .056 | .0572 | .0572 | .056 | | .0572 |
| 3 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 4 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 5 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 6 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 7 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 8 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 9 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 10 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0572 |
| 11 | .056 | .0572 | .0572 | .056 | .0572 | .0572 | .056 |
| 12 | .0934 | .1143 | .0572 | .056 | .1143 | .0572 | .112 |
| 13 | .0934 | .2286 | .0572 | .056 | .1334 | .0572 | .0934 |
| 14 | .112 | .2286 | .0572 | .112 | .2286 | .0572 | .168 |
| 15 | .0934 | .1905 | .0572 | .056 | .2286 | .0762 | .0934 |
| 16 | .0934 | .0572 | .0572 | .056 | .1143 | .0762 | .056 |
| 17 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 18 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 19 | .056 | .0572 | .0572 | .056 | .0572 | | .056 |
| 20 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 21 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 22 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 23 | .056 | .0572 | .0572 | .056 | .0572 | .0762 | .056 |
| 24 | .0572 | .056 | .0572 | .0572 | .056 | .0572 | .0762 |
| Max | .112 | .2286 | .0572 | .112 | .2286 | .0762 | .168 |
| Min | .056 | .056 | .0572 | .056 | .056 | .0572 | .056 |
| Avg | .0651 | .0789 | .0572 | .0589 | .0789 | .0641 | .0675 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 401 / 33 KV INCOMMER

Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | | 1.1763 | 1.2003 | | 1.2323 | 1.4289 | |
| 16 | 1.0642 | 1.3146 | | 1.2883 | 1.6004 | | .8402 |
| 22 | 1.4563 | 1.3717 | | 1.6804 | 1.6004 | | 1.5123 |
| 24 | | 1.2883 | 1.3717 | | 1.5123 | 1.4289 | |
| Max | 1.4563 | 1.3717 | 1.3717 | 1.6804 | 1.6004 | 1.4289 | 1.5123 |
| Min | 1.0642 | 1.1763 | 1.2003 | 1.2883 | 1.2323 | 1.4289 | .8402 |
| Avg | 1.2603 | 1.2877 | 1.286 | 1.4844 | 1.4864 | 1.4289 | 1.1763 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 402 / 33 KV TRANSFORMER NO-I

Feeder KV- 33 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | | .7282 | .6859 | | .7282 | .8002 | |
| 9 | | .7282 | | | | | |
| 16 | .5601 | .6859 | | .6722 | .8002 | | .7282 |
| 22 | .7842 | .6859 | | .9522 | .8573 | | .8402 |
| 24 | | .7282 | .743 | | .8402 | .743 | |
| Max | .7842 | .7282 | .743 | .9522 | .8573 | .8002 | .8402 |
| Min | .5601 | .6859 | .6859 | .6722 | .7282 | .743 | .7282 |
| Avg | .6722 | .7113 | .7145 | .8122 | .8065 | .7716 | .7842 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 403 / 33 KV TRANSFORMER NO-II

Feeder KV- 33 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | | .4481 | .5144 | | .5041 | .6287 | |
| 16 | .5041 | .6287 | | .6161 | .8002 | | .112 |
| 22 | .6722 | .6859 | | .7282 | .743 | | .6722 |
| 24 | | .5601 | .6287 | | .6722 | .6859 | |
| Max | .6722 | .6859 | .6287 | .7282 | .8002 | .6859 | .6722 |
| Min | .5041 | .4481 | .5144 | .6161 | .5041 | .6287 | .112 |
| Avg | .5882 | .5807 | .5716 | .6722 | .6799 | .6573 | .3921 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 2 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 3 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 4 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 5 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 6 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 7 | .0381 | .0381 | .0381 | .0381 | .0191 | .0191 | .0381 |
| 8 | .0381 | .0381 | .0381 | .0381 | .0572 | .0381 | .0381 |
| 9 | .0381 | .0381 | .0381 | .0381 | .0572 | .0381 | .0381 |
| 10 | .0381 | .0381 | .0381 | .0572 | .0381 | .0381 | .0381 |
| 11 | .0191 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 12 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 13 | .0381 | .0381 | .0381 | .0191 | .0381 | .0381 | .0381 |
| 14 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 15 | .0381 | .0381 | .0381 | .0191 | .0381 | .0381 | .0381 |
| 16 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 17 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 18 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 19 | .0381 | .0381 | .0381 | .0381 | .0572 | | .0381 |
| 20 | .0381 | .0572 | .0572 | .0381 | .0572 | .0381 | .0572 |
| 21 | .0381 | .0381 | .0381 | | .0572 | .0381 | .0572 |
| 22 | .0381 | .0381 | .0381 | .0381 | .0572 | .0381 | .0381 |
| 23 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 24 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Max | .0381 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 |
| Min | .0191 | .0381 | .0381 | .0191 | .0191 | .0191 | .0381 |
| Avg | .0373 | .0389 | .0389 | .0373 | .0421 | .0373 | .0397 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 201 / CIDCO Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 2 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 3 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 4 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 5 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 6 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .2286 |
| 7 | .2858 | .1905 | .1905 | .1905 | .1905 | .2858 | .2858 |
| 8 | .2858 | .2858 | .1905 | .1905 | .1905 | .2858 | .2858 |
| 9 | .1905 | .2858 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 10 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 11 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 12 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 13 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 14 | .1905 | .1905 | .1905 | | .1905 | .1905 | .1905 |
| 15 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 16 | .0953 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 17 | .0953 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 18 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 19 | .1905 | .1905 | .2858 | .2858 | .1905 | .1905 | .1905 |
| 20 | .1905 | .1905 | .2858 | .2858 | .2858 | .1905 | .1905 |
| 21 | .1905 | .1905 | .1905 | .1905 | .2858 | .1905 | .1905 |
| 22 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 23 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 24 | .1905 | .1905 | .1905 | .1905 | .381 | .1905 | .1905 |
| Max | .2858 | .2858 | .2858 | .2858 | .381 | .2858 | .2858 |
| Min | .0953 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| Avg | .1905 | .1984 | .1984 | .1988 | .2064 | .1984 | .2000 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 202 / MIDC Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2858 | .2858 | .1905 | .2858 | .1905 | .1905 | .381 |
| 2 | .2858 | .2858 | .1905 | .2858 | .1905 | .1905 | .381 |
| 3 | .2858 | .1905 | .1905 | .2858 | .1905 | .1905 | .381 |
| 4 | .1905 | .1905 | .1905 | .2858 | .2858 | .1905 | .381 |
| 5 | .1905 | .2858 | .1905 | .2858 | .2858 | .1905 | .381 |
| 6 | .381 | .2858 | .2858 | .2858 | .2858 | .381 | .381 |
| 7 | .381 | .381 | .2858 | .2858 | .2858 | .381 | .381 |
| 8 | .381 | .381 | .381 | .381 | .2858 | .2858 | .381 |
| 9 | .2858 | .381 | .381 | .381 | .2858 | .1905 | .381 |
| 10 | .2858 | .1905 | .2858 | .2858 | .1905 | .2858 | .2858 |
| 11 | .1905 | .1905 | .2858 | .1905 | .1905 | .381 | .1905 |
| 12 | .2858 | .1905 | .1905 | .1905 | .1905 | .381 | .1905 |
| 13 | .1905 | .1905 | .1905 | .1905 | .1905 | .2858 | .1905 |
| 14 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 15 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .381 |
| 16 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .381 |
| 17 | .1905 | .1905 | | .1905 | .1905 | .1905 | .1905 |
| 18 | .2858 | .4001 | .1905 | .1905 | .2858 | .2858 | .381 |
| 19 | .381 | .381 | .381 | .381 | .2858 | .381 | .381 |
| 20 | .381 | .381 | .381 | .381 | .381 | .381 | .381 |
| 21 | .381 | .381 | .3429 | .381 | .381 | .4191 | .381 |
| 22 | .381 | .381 | .2858 | .381 | .381 | .381 | .381 |
| 23 | .2858 | .2858 | .2858 | .381 | .381 | .381 | .381 |
| 24 | .2858 | .2858 | .2858 | .2858 | .381 | .381 | .381 |
| Max | .381 | .4001 | .381 | .381 | .381 | .4191 | .381 |
| Min | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| Avg | .2818 | .2786 | .2593 | .2818 | .2620 | .2873 | .3373 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 203 / Satgaon Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2858 | .2858 | .3429 | .381 | .3429 | .4382 | .4763 |
| 2 | .2858 | .2477 | .3429 | .381 | .362 | .4191 | .4763 |
| 3 | .2667 | .2286 | .3239 | .381 | .381 | .4001 | .4763 |
| 4 | .2667 | .2286 | .3239 | .3429 | .381 | .381 | .4763 |
| 5 | .3048 | .381 | .362 | .381 | .4191 | .4001 | .4763 |
| 6 | .381 | .4763 | .4382 | .4001 | .4382 | .4572 | .4763 |
| 7 | .4382 | .4572 | .4954 | .4191 | .4572 | .4954 | .4763 |
| 8 | .4572 | .4954 | .4954 | .4763 | .4763 | .4954 | .4954 |
| 9 | .4001 | .4572 | .4191 | .4572 | .4572 | .4763 | .4954 |
| 10 | .4382 | .381 | .4382 | .4763 | .4763 | .4382 | .4191 |
| 11 | .381 | .3429 | .381 | .4382 | .4763 | .4382 | .4572 |
| 12 | .3429 | .2667 | .381 | .4001 | .381 | .3429 | .4763 |
| 13 | .2858 | .2667 | .3239 | .362 | .381 | .4382 | .4001 |
| 14 | .2477 | .2477 | .3048 | .3429 | .381 | .3429 | .381 |
| 15 | .2286 | .2286 | .3048 | .381 | .3429 | .3429 | .381 |
| 16 | .2858 | .2667 | .3429 | .4001 | .381 | .381 | .381 |
| 17 | .3048 | .2477 | .3429 | .3239 | .4191 | .381 | .4191 |
| 18 | .4001 | .4001 | .4191 | .381 | .4382 | .4763 | .4191 |
| 19 | .6097 | .5716 | .5906 | .5716 | .4763 | .6287 | .5716 |
| 20 | .5906 | .5335 | .5716 | .5525 | .6097 | .6287 | .5716 |
| 21 | .5525 | .5144 | .5335 | .5525 | .5716 | .6097 | .5906 |
| 22 | .4191 | .4572 | .4763 | .4954 | .5335 | .5716 | .5525 |
| 23 | .3239 | .362 | .381 | .4382 | .4572 | .5335 | .5716 |
| 24 | .2858 | .2858 | .3429 | .381 | .2667 | .4382 | .4763 |
| Max | .6097 | .5716 | .5906 | .5716 | .6097 | .6287 | .5906 |
| Min | .2286 | .2286 | .3048 | .3239 | .2667 | .3429 | .381 |
| Avg | .3660 | .3596 | .4033 | .4215 | .4294 | .4565 | .4747 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 201 / 11 KV Dongargaon feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2561 | .2402 | .2743 | .2401 | .2926 | .3439 | .2915 |
| 2 | .2195 | .2218 | .2743 | .2572 | .2926 | .3155 | .2915 |
| 3 | .2195 | .2012 | .2743 | .2572 | .2926 | .3155 | .2743 |
| 4 | .2743 | .2012 | .2743 | .2743 | .3292 | .298 | .2915 |
| 5 | .3292 | .2614 | .2926 | .2743 | .3109 | .298 | .3086 |
| 6 | .3292 | .2987 | .2926 | .2915 | .3292 | .3467 | .3086 |
| 7 | .3475 | .3292 | .3258 | .2915 | .3292 | .3681 | .3429 |
| 8 | .3658 | .3696 | .4024 | .3086 | .3658 | .3856 | .3258 |
| 9 | .3109 | .3547 | .4207 | .3086 | .3841 | .3856 | .3258 |
| 10 | .3109 | .3881 | .3258 | .2915 | .4755 | .4344 | .3601 |
| 11 | .3361 | .3658 | .3429 | .3841 | | .4287 | .3841 |
| 12 | .3982 | .3841 | .3601 | .4024 | .4668 | .4115 | .3658 |
| 13 | .3142 | .3258 | .3429 | .3658 | .4344 | .4115 | .439 |
| 14 | .2561 | .3258 | .2572 | .3292 | .4163 | .3772 | .4024 |
| 15 | .3142 | .3439 | .3429 | .4024 | .5041 | .3429 | .4024 |
| 16 | .3258 | .3439 | .3944 | .4572 | .5487 | .4287 | .439 |
| 17 | .3881 | .3292 | .3601 | | .5487 | .4801 | .5121 |
| 18 | .3841 | .3439 | .3429 | .4572 | .4066 | .4458 | |
| 19 | .4163 | .4024 | .3086 | .439 | .4668 | .4115 | .4572 |
| 20 | .3696 | .3658 | .3086 | .3841 | .439 | .3772 | .439 |
| 21 | .3511 | .3439 | .3429 | .3658 | .3881 | .3429 | .4024 |
| 22 | .2957 | .3292 | | .3292 | .362 | .3086 | .3475 |
| 23 | .1829 | .2561 | .2743 | .2926 | .3439 | .3086 | .3658 |
| 24 | | .2561 | .2715 | .2926 | | .333 | .3658 |
| Max | .4163 | .4024 | .4207 | .4572 | .5487 | .4801 | .5121 |
| Min | .1829 | .2012 | .2572 | .2401 | .2926 | .298 | .2743 |
| Avg | .3172 | .3159 | .3220 | .3346 | .3967 | .3708 | .3671 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 202 / 11 KV Dhuti feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .0934 | .128 | .1029 | .1463 | .1227 | .0857 |
| 2 | .128 | .0747 | .128 | .1029 | .1463 | .1052 | .0857 |
| 3 | .1097 | .056 | .1267 | .12 | .1646 | .0886 | .0686 |
| 4 | .1097 | .056 | .128 | .12 | .1646 | .0876 | .0686 |
| 5 | .1097 | .0747 | .1463 | .1372 | .1829 | .0701 | .0857 |
| 6 | .1097 | .056 | .1494 | .1372 | .1829 | .0701 | .0686 |
| 7 | .128 | .0747 | .128 | .1372 | .1829 | .1402 | .0857 |
| 8 | .128 | .0934 | .1829 | .1543 | .1829 | .1227 | .1029 |
| 9 | .1097 | .0934 | .1829 | .1543 | .1646 | .1448 | .12 |
| 10 | .1463 | .0934 | .1629 | .1372 | .1463 | .1494 | |
| 11 | .112 | .0914 | .1372 | .0732 | | .1372 | .1097 |
| 12 | .1097 | .0549 | | .1097 | .1132 | .1372 | .128 |
| 13 | .1109 | .0549 | .1029 | .0914 | .0905 | .12 | .0914 |
| 14 | .1307 | .0543 | .0857 | .0914 | .0914 | .1029 | .1097 |
| 15 | .112 | .0732 | .0857 | .0914 | .1109 | .1029 | .1097 |
| 16 | .112 | .0732 | .0857 | .0914 | .0914 | .0857 | .1097 |
| 17 | .0934 | .0732 | .1029 | .1097 | .1109 | .0857 | .1097 |
| 18 | .1097 | .1097 | .12 | .128 | .1086 | .12 | .0732 |
| 19 | .1294 | .1829 | .12 | .1463 | .1307 | .1715 | .0366 |
| 20 | .1509 | .2195 | .12 | .1829 | .0754 | .1715 | .0366 |
| 21 | .1646 | .1646 | .1029 | .1829 | .2054 | .1715 | .0366 |
| 22 | .1294 | .1646 | .12 | .1646 | 1.6991 | .1372 | .0183 |
| 23 | .0187 | .1097 | .1029 | .1646 | .1629 | .12 | .0366 |
| 24 | | .112 | .1267 | .1463 | | .1402 | .0549 |
| Max | .1646 | .2195 | .1829 | .1829 | 1.6991 | .1715 | .128 |
| Min | .0187 | .0543 | .0857 | .0732 | .0754 | .0701 | .0183 |
| Avg | .1178 | .0960 | .1250 | .1282 | .2116 | .1210 | .0797 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 203 / 11 kv Swapnil Agro

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5853 | .5201 | .0183 | .3429 | .6584 | .4908 | .3772 |
| 2 | .6219 | .5028 | .0181 | .4458 | .695 | .5083 | .4287 |
| 3 | .6219 | .5028 | .0181 | .4801 | .695 | .4973 | .5144 |
| 4 | .6584 | .4854 | .1267 | .5144 | .6584 | .4908 | .5487 |
| 5 | .6401 | .4854 | .2896 | .5144 | .6584 | .4908 | .5487 |
| 6 | .5853 | .5201 | .4207 | .5487 | .6401 | .5138 | .5144 |
| 7 | .6036 | .5784 | .543 | .5487 | .6401 | .3641 | .4801 |
| 8 | .3658 | .4854 | .4525 | .5487 | .6219 | .4854 | .4287 |
| 9 | .4572 | .5201 | .4706 | .583 | .5853 | .39 | .1372 |
| 10 | .3658 | .4961 | .5068 | .5144 | .567 | .3801 | .463 |
| 11 | .3121 | .5121 | .4801 | .0914 | | .4287 | .5121 |
| 12 | .3814 | .5792 | .463 | .5121 | .0701 | .463 | .4755 |
| 13 | .4207 | .5304 | .4801 | .439 | .0362 | .4801 | .4572 |
| 14 | .4207 | .3467 | .4801 | .4755 | .0362 | .5144 | .4755 |
| 15 | .4252 | .462 | .4458 | .5121 | .0876 | .5144 | .4024 |
| 16 | .4681 | .5304 | .3772 | .4755 | .0693 | .4801 | .3658 |
| 17 | .4748 | .5121 | | .4938 | .4508 | .4287 | .2743 |
| 18 | .499 | .0181 | .3601 | .4938 | .4854 | .4287 | .4024 |
| 19 | .5083 | .0181 | .3944 | .5853 | .5729 | .463 | .5487 |
| 20 | .3988 | .0181 | .4115 | .5487 | .4334 | .463 | .6036 |
| 21 | .5028 | .0181 | .0857 | | .3641 | .1372 | .6401 |
| 22 | .4908 | .0183 | | .6584 | .3155 | .1715 | .7499 |
| 23 | .0867 | .0183 | | .6219 | .4382 | .2572 | .695 |
| 24 | | .5201 | .0187 | .6219 | | .4508 | .695 |
| Max | .6584 | .5792 | .543 | .6584 | .695 | .5144 | .7499 |
| Min | .0867 | .0181 | .0181 | .0914 | .0362 | .1372 | .1372 |
| Avg | .4737 | .3833 | .3267 | .5031 | .4445 | .4288 | .4891 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 205 / Mohagaon (Gaothan)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .3018 | .1267 | .1372 | .1829 | .1463 | .1372 |
| 2 | .1829 | .2801 | .1267 | .1372 | .1829 | .1463 | .1543 |
| 3 | .1646 | .2402 | .1267 | .1715 | .1646 | .1294 | .1543 |
| 4 | .1463 | .2218 | .1267 | .2058 | .1646 | .1294 | .1372 |
| 5 | .1463 | .2075 | .1448 | .2058 | .1646 | .1494 | .1372 |
| 6 | .1463 | .2218 | .1463 | .2572 | .1829 | .1829 | .1372 |
| 7 | .1646 | .132 | .1448 | .2915 | .1829 | .1646 | .1715 |
| 8 | .1646 | .128 | .2012 | .3429 | .2378 | .2279 | .1715 |
| 9 | .2743 | .2641 | .2353 | .3601 | .2743 | .2458 | .2058 |
| 10 | .2378 | .2218 | .2715 | .3086 | .2378 | .3258 | .2401 |
| 11 | .3086 | .2353 | .2743 | .3292 | | .3429 | .2378 |
| 12 | .2033 | .2353 | .2572 | .3841 | .3326 | .3429 | .2195 |
| 13 | .2033 | .2534 | .2401 | .4024 | .3077 | .3772 | .2378 |
| 14 | .168 | .2534 | .2572 | .4207 | .2896 | .3429 | .2561 |
| 15 | .3018 | .2743 | .2401 | .4207 | .3109 | .3258 | .2378 |
| 16 | .1886 | .2378 | .2229 | .439 | .3326 | .2915 | .2561 |
| 17 | .2033 | .2378 | .2058 | .4207 | .2926 | .2572 | .2743 |
| 18 | .3658 | .2534 | .1886 | .3841 | .2629 | .2229 | .2561 |
| 19 | .3361 | .2353 | .1886 | .4024 | .2686 | .2058 | .2378 |
| 20 | .3547 | .2195 | .2058 | .3658 | .1991 | .2058 | .1829 |
| 21 | .3395 | .1991 | .2058 | .3109 | .2033 | .1886 | .1646 |
| 22 | .3361 | .1829 | .1372 | .2012 | .1753 | .1715 | .1646 |
| 23 | .1886 | .1463 | .1372 | .2012 | .1578 | .1715 | .1646 |
| 24 | | .3206 | .128 | .1829 | | .156 | .1646 |
| Max | .3658 | .3206 | .2743 | .439 | .3326 | .3772 | .2743 |
| Min | .1463 | .128 | .1267 | .1372 | .1578 | .1294 | .1372 |
| Avg | .2316 | .2293 | .1891 | .3035 | .2322 | .2271 | .1959 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 400 / 33 KV PANJARI(INCOMMER)

Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1523 | 1.1763 | .543 | .823 | 1.262 | 1.0402 | .9259 |
| 2 | 1.1523 | 1.1088 | .543 | .9259 | 1.3169 | 1.0517 | .9774 |
| 3 | 1.0974 | 1.0534 | .5373 | 1.0802 | 1.3169 | 1.0517 | 1.0288 |
| 4 | 1.1523 | .9979 | .7133 | 1.1317 | 1.3169 | .9991 | 1.0802 |
| 5 | 1.2071 | 1.0642 | .8688 | 1.1317 | 1.3169 | .9991 | 1.0802 |
| 6 | 1.1523 | 1.1203 | .9774 | 1.2346 | 1.3169 | 1.1403 | 1.0802 |
| 7 | 1.262 | 1.1643 | 1.1523 | 1.286 | 1.3169 | .9991 | 1.1317 |
| 8 | 1.1523 | 1.1203 | 1.262 | 1.3375 | 1.3717 | 1.1963 | 1.0802 |
| 9 | 1.1523 | 1.2752 | 1.3575 | 1.3889 | 1.4266 | 1.1568 | .8745 |
| 10 | 1.0974 | 1.2197 | 1.2489 | 1.286 | 1.4266 | 1.2094 | 1.2346 |
| 11 | 1.1088 | 1.262 | 1.1831 | .8779 | | 1.3889 | 1.2071 |
| 12 | 1.1088 | 1.3169 | 1.1831 | 1.4815 | 1.0425 | 1.3889 | 1.262 |
| 13 | 1.0425 | 1.1946 | 1.286 | 1.262 | .8688 | 1.4403 | 1.3717 |
| 14 | .9979 | 1.2071 | 1.1317 | 1.3717 | .8145 | 1.3889 | 1.3169 |
| 15 | 1.1643 | 1.1946 | 1.1831 | 1.4266 | .9979 | 1.3375 | 1.3169 |
| 16 | 1.1643 | 1.2489 | 1.1317 | 1.5364 | .9979 | 1.3375 | 1.0974 |
| 17 | 1.1763 | 1.2489 | 1.0802 | 1.4815 | 1.4563 | 1.286 | 1.1523 |
| 18 | 1.386 | | 1.0802 | 1.4266 | 1.3306 | 1.286 | .7133 |
| 19 | 1.4815 | .8779 | 1.0288 | 1.5364 | 1.4415 | 1.286 | 1.3169 |
| 20 | 1.2752 | .8779 | 1.0802 | 1.4266 | 1.1643 | 1.2346 | 1.0974 |
| 21 | 1.4003 | .7602 | .7716 | 1.4815 | 1.1883 | .8745 | 1.262 |
| 22 | 1.262 | .7133 | .6173 | 1.0974 | 1.0425 | .823 | 1.262 |
| 23 | .5041 | .5487 | .5658 | 1.262 | 1.1403 | .7202 | 1.262 |
| 24 | | 1.2449 | .5487 | 1.2071 | | 1.1403 | 1.262 |
| Max | 1.4815 | 1.3169 | 1.3575 | 1.5364 | 1.4563 | 1.4403 | 1.3717 |
| Min | .5041 | .5487 | .5373 | .823 | .8145 | .7202 | .7133 |
| Avg | 1.1587 | 1.0868 | .9615 | 1.2709 | 1.2215 | 1.1573 | 1.1414 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 402 / 33 KV Dongargaon-VRINDAVAN
i/c Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0549 | .0572 | .0543 | | .0549 | .0572 | |
| 2 | .0549 | .0572 | .0543 | | .0549 | .0572 | |
| 3 | .0549 | .0572 | .056 | | .0549 | .0572 | |
| 4 | .0549 | .0572 | .0537 | | .0549 | .0572 | |
| 5 | .0549 | .0572 | .0549 | | .0549 | .0572 | |
| 6 | .0549 | .0572 | .0549 | | .0549 | .0572 | |
| 7 | .0549 | .0572 | .0543 | | .0549 | .0572 | |
| 8 | .0549 | .0572 | .0549 | | .0549 | .0572 | 2.8292 |
| 9 | .0549 | .0572 | .0537 | | .0549 | .0572 | |
| 10 | .0549 | .0572 | .0543 | | .0549 | .0572 | |
| 11 | .0572 | .0543 | | .0549 | | | .0549 |
| 12 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 13 | .0572 | .0543 | | .0549 | .0572 | | .0549 |
| 14 | .0572 | .0543 | 1.1317 | .0549 | .0572 | | .0549 |
| 15 | .0572 | .0543 | | .0549 | .0572 | | .0549 |
| 16 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 17 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 18 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 19 | .0572 | .056 | | | .0572 | | .0549 |
| 20 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 21 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 22 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 23 | .0572 | .0549 | | .0549 | .0572 | | .0549 |
| 24 | | .0572 | .0549 | .0549 | | .0572 | .0549 |
| Max | .0572 | .0572 | 1.1317 | .0549 | .0572 | .0572 | 2.8292 |
| Min | .0549 | .0543 | .0537 | .0549 | .0549 | .0572 | .0549 |
| Avg | .0562 | .0559 | .1443 | .0549 | .0562 | .0572 | .2399 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 200 / MIHAN STATION T/F

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0183 | .0179 | .0179 | .0183 | .0183 | .0175 | .0171 |
| 2 | .0183 | .0179 | .0179 | .0171 | .0189 | .0175 | .0179 |
| 3 | .0183 | .0179 | .0179 | .0171 | .0189 | .0175 | .0179 |
| 4 | .0183 | .0179 | .0179 | .0171 | .0189 | .0171 | .0179 |
| 5 | .0183 | .0179 | .0179 | .0171 | .0183 | .0171 | .0179 |
| 6 | .0183 | .0179 | .0179 | .0171 | .0183 | .0171 | .0179 |
| 7 | .0183 | .0179 | .0179 | .0183 | .0183 | .0187 | .0179 |
| 8 | .0183 | .0179 | .0179 | .0171 | .0175 | .0175 | .0171 |
| 9 | .0183 | .0179 | .0179 | .017 | .0175 | .0183 | .0171 |
| 10 | .0179 | .0179 | .0179 | | .0175 | .0179 | .0171 |
| 11 | .0179 | .0179 | .0171 | .0175 | .0175 | .0179 | .0183 |
| 12 | .0179 | .0179 | .0171 | .0175 | .0175 | .0179 | .0183 |
| 13 | .0179 | .0179 | .0171 | .0175 | .0175 | .0171 | .0183 |
| 14 | .0179 | .0179 | .0171 | .0175 | .0171 | .0171 | .0187 |
| 15 | .0179 | .0179 | .0171 | .0183 | .0175 | .0171 | .0183 |
| 16 | .0179 | .0179 | .0171 | .0183 | .0175 | .0171 | .0187 |
| 17 | .0179 | .0179 | .0171 | .0183 | .0175 | .0183 | .0187 |
| 18 | .0179 | .0179 | .0171 | .0175 | .0175 | .0171 | .0187 |
| 19 | .0179 | .0179 | .0171 | .0175 | .0175 | .0179 | .0187 |
| 20 | .0179 | .0179 | .0171 | .0175 | .0175 | .0171 | .0187 |
| 21 | .0179 | .0179 | .0171 | .0175 | .0175 | .0179 | .0183 |
| 22 | .0179 | .0179 | .0171 | .0189 | .0175 | .0179 | .0189 |
| 23 | .0179 | .0179 | .0171 | .0175 | .0175 | .0171 | .0183 |
| 24 | .0187 | .0179 | .0179 | .0171 | .0177 | .0175 | .0171 |
| Max | .0187 | .0179 | .0179 | .0189 | .0189 | .0187 | .0189 |
| Min | .0179 | .0179 | .0171 | .017 | .0171 | .0171 | .0171 |
| Avg | .0181 | .0179 | .0175 | .0176 | .0178 | .0176 | .0181 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 201 / Mihan-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7316 | .9145 | 1.0059 | .7842 | .8081 | .8145 | .8962 |
| 2 | .6219 | .9145 | .9145 | .7316 | .8048 | .7602 | .8779 |
| 3 | .6401 | .823 | .823 | .7392 | .7682 | .724 | .8779 |
| 4 | .6401 | .823 | .823 | .7392 | .7316 | .7468 | .8779 |
| 5 | .6401 | .7316 | .7316 | .7392 | .7316 | .7468 | .8779 |
| 6 | .7682 | .7682 | .7682 | .7392 | .7316 | .7468 | .8779 |
| 7 | 1.0608 | 1.0608 | .9145 | .7392 | 1.0608 | .9709 | 1.0059 |
| 8 | 1.1888 | 1.0974 | 1.2437 | .9145 | 1.086 | 1.1222 | 1.1203 |
| 9 | 1.0059 | 1.0974 | 1.0974 | .9145 | 1.1222 | 1.1946 | 1.307 |
| 10 | 1.2803 | 1.3169 | 1.2803 | .905 | 1.2308 | 1.2071 | 1.2136 |
| 11 | 1.2437 | 1.2437 | 1.2803 | .9412 | 1.3575 | 1.2803 | 1.2803 |
| 12 | 1.134 | 1.0059 | .7316 | .8688 | 1.267 | 1.2803 | 1.2696 |
| 13 | .9511 | 1.0974 | 1.0974 | .8688 | 1.1765 | 1.1458 | 1.1888 |
| 14 | 1.0059 | 1.134 | 1.0608 | .8145 | 1.1584 | 1.0974 | 1.1576 |
| 15 | 1.0059 | 1.1888 | 1.0164 | .7545 | 1.1584 | 1.1888 | 1.0974 |
| 16 | 1.0608 | 1.2437 | 1.0059 | .7316 | 1.1946 | 1.134 | 1.1203 |
| 17 | .9145 | 1.134 | 1.0829 | .9145 | 1.134 | 1.1203 | 1.0269 |
| 18 | 1.0974 | 1.1888 | 1.1203 | .8326 | 1.134 | 1.2136 | 1.1888 |
| 19 | 1.4632 | 1.4266 | 1.3443 | 1.1765 | 1.448 | 1.5729 | 1.4632 |
| 20 | 1.3717 | 1.3169 | 1.4003 | 1.2803 | 1.4118 | 1.4937 | 1.4632 |
| 21 | 1.3717 | 1.3717 | 1.3443 | 1.1222 | 1.448 | 1.4632 | 1.4632 |
| 22 | 1.2803 | 1.0974 | 1.1576 | .9511 | 1.3032 | 1.4266 | 1.2936 |
| 23 | 1.0974 | 1.0974 | 1.1203 | .905 | 1.1584 | 1.1203 | 1.2136 |
| 24 | .8402 | .9145 | 1.0059 | .9335 | .7964 | .8869 | .9335 |
| Max | 1.4632 | 1.4266 | 1.4003 | 1.2803 | 1.448 | 1.5729 | 1.4632 |
| Min | .6219 | .7316 | .7316 | .7316 | .7316 | .724 | .8779 |
| Avg | 1.0173 | 1.0837 | 1.0571 | .8767 | 1.0926 | 1.1024 | 1.1289 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 202 / Mihan-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0366 | .0362 | .0362 | .0373 | .0366 | .0351 | .0373 |
| 2 | .0366 | .0362 | .0362 | .0366 | .0366 | .0351 | .0366 |
| 3 | .0366 | .0362 | .0362 | | .0366 | .0526 | .0366 |
| 4 | .0366 | .0362 | .0362 | .037 | .0366 | .0373 | .0366 |
| 5 | .0366 | .0362 | .0362 | .037 | .0366 | .0373 | .0366 |
| 6 | .0366 | .0362 | .0362 | .0373 | .0366 | .0373 | .0366 |
| 7 | .0366 | .0362 | .0362 | .0366 | .0366 | .0373 | .0366 |
| 8 | .0366 | .0366 | .0362 | .0366 | .0351 | .0351 | .0373 |
| 9 | .0366 | .0362 | .0362 | .0366 | .0351 | .0354 | .0366 |
| 10 | .0362 | .0362 | .0362 | .0351 | .0351 | .0366 | .0366 |
| 11 | .0362 | .0362 | .0366 | .0351 | .0358 | .0366 | .0366 |
| 12 | .0362 | .0362 | .0366 | .0351 | .0351 | .0366 | .0366 |
| 13 | .0362 | .0362 | .0366 | .0526 | .0351 | .0366 | .0366 |
| 14 | .0362 | .0362 | .0366 | .0351 | .0351 | .0366 | .0373 |
| 15 | .0362 | .0362 | .0366 | .0366 | .0358 | .037 | .0366 |
| 16 | .0362 | .0362 | .0373 | .0366 | .0351 | .0366 | .0366 |
| 17 | .0362 | .0362 | .0373 | .0366 | .0351 | .0373 | .0373 |
| 18 | .0362 | .0362 | .0366 | .0351 | .0358 | .0373 | .0366 |
| 19 | .0366 | .0362 | .0373 | .0351 | .0351 | .0366 | .0373 |
| 20 | .0362 | .0366 | .0373 | .0351 | .0351 | .0373 | .0373 |
| 21 | .0362 | .0362 | .0373 | .0354 | .0354 | .0366 | .0373 |
| 22 | .0362 | .0366 | .0373 | .0366 | .0351 | .0366 | .0373 |
| 23 | .0362 | .0362 | .0366 | .0351 | .0351 | .0373 | .0373 |
| 24 | .0373 | .0362 | .0362 | .0373 | .0354 | .0351 | .0373 |
| Max | .0373 | .0366 | .0373 | .0526 | .0366 | .0526 | .0373 |
| Min | .0362 | .0362 | .0362 | .0351 | .0351 | .0351 | .0366 |
| Avg | .0364 | .0363 | .0366 | .0368 | .0357 | .0372 | .0369 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 203 / Mihan-III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .695 | .7316 | .823 | .7316 | .823 | .8779 | .924 |
| 2 | .6401 | .7316 | .823 | .695 | .823 | .8048 | .9145 |
| 3 | .6401 | .6401 | .7316 | | .7714 | .7682 | .9145 |
| 4 | .6219 | .6401 | .6401 | .7023 | .7316 | .7922 | .8779 |
| 5 | .6219 | .6401 | .6401 | .7023 | .7316 | .7468 | .8779 |
| 6 | .7316 | .7316 | .7316 | .7392 | .7316 | .8402 | .8779 |
| 7 | .7316 | .9145 | .9145 | .8779 | .9145 | 1.1203 | 1.0608 |
| 8 | 1.0974 | 1.0059 | 1.0059 | .9145 | 1.0242 | 1.134 | 1.0974 |
| 9 | 1.1888 | 1.0974 | 1.0059 | 1.0059 | 1.134 | 1.2071 | 1.134 |
| 10 | 1.0059 | 1.134 | 1.0974 | 1.086 | 1.134 | .9877 | 1.134 |
| 11 | 1.0608 | 1.0059 | 1.0059 | 1.2071 | 1.0974 | 1.0608 | 1.0608 |
| 12 | .9511 | .9145 | .9145 | 1.2803 | 1.0242 | 1.0059 | 1.0059 |
| 13 | .823 | .823 | .7682 | .9877 | .9774 | .985 | .9145 |
| 14 | .9511 | .7682 | .7682 | .8779 | .9511 | 1.0059 | .9511 |
| 15 | .7682 | .7316 | .7316 | .7316 | .9231 | .9145 | .9145 |
| 16 | .7682 | .7682 | .823 | .7316 | .9511 | .9955 | .9145 |
| 17 | .823 | .823 | .9145 | .7682 | .9774 | 1.0059 | .8402 |
| 18 | .9145 | .9145 | .8779 | .823 | 1.0608 | 1.0974 | .9335 |
| 19 | 1.0974 | 1.134 | 1.134 | 1.2437 | 1.2803 | 1.3352 | 1.307 |
| 20 | 1.0974 | 1.0974 | 1.134 | 1.2803 | 1.2437 | 1.2803 | 1.307 |
| 21 | 1.0059 | 1.0059 | 1.0719 | 1.2071 | 1.2308 | 1.3169 | 1.1888 |
| 22 | .9145 | .9511 | 1.0164 | 1.0608 | 1.1706 | 1.1888 | 1.1576 |
| 23 | .823 | .9145 | .9145 | .9671 | 1.0608 | 1.0719 | 1.1203 |
| 24 | .7316 | .7316 | .823 | .7316 | .9145 | .9877 | 1.0164 |
| Max | 1.1888 | 1.134 | 1.134 | 1.2803 | 1.2803 | 1.3352 | 1.307 |
| Min | .6219 | .6401 | .6401 | .695 | .7316 | .7468 | .8402 |
| Avg | .8627 | .8688 | .8879 | .9284 | .9868 | 1.0221 | 1.0185 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 205 / Mahindra Boomdale

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0549 | .0532 | .0532 | .0549 | .0549 | .0532 | .0549 |
| 2 | .0549 | .0532 | .0532 | .0549 | .0549 | .0532 | .0549 |
| 3 | .0549 | .0532 | .0532 | | .0549 | .0526 | .0549 |
| 4 | .0549 | .0532 | .0532 | .0554 | .0549 | .056 | .0549 |
| 5 | .0549 | .0532 | .0532 | .056 | .0549 | .056 | .0549 |
| 6 | .0549 | .0532 | .0532 | .0554 | .0549 | .056 | .0549 |
| 7 | .0549 | .0532 | .0532 | .0549 | .0549 | .056 | .0549 |
| 8 | .0549 | .0532 | .0532 | .0549 | .0526 | | .0549 |
| 9 | .0549 | .0532 | .0532 | .0526 | .0526 | .0526 | .0549 |
| 10 | .0532 | .0532 | .0532 | .0526 | .0526 | .0549 | .0549 |
| 11 | .0532 | .0532 | .0549 | .0526 | .0532 | .0549 | .0549 |
| 12 | .0532 | .0532 | .0549 | .0526 | .0526 | .0549 | .0549 |
| 13 | .0532 | .0532 | .0549 | .0526 | .0526 | .0549 | .0549 |
| 14 | .0532 | .0532 | .0549 | .0526 | .0526 | .0549 | .056 |
| 15 | .0532 | .0532 | .0549 | .0549 | .0526 | .0549 | .056 |
| 16 | .0532 | .0532 | .0549 | .0549 | .0526 | .0549 | .056 |
| 17 | .0532 | .0532 | .0549 | .0549 | .0526 | .0549 | .0549 |
| 18 | .0532 | .0532 | .0549 | .0526 | .0532 | .0549 | .056 |
| 19 | .0532 | .0532 | .0549 | .0526 | .0537 | .0549 | .056 |
| 20 | .0532 | .0566 | .0549 | .0526 | .0532 | .0549 | .0549 |
| 21 | .0532 | .0532 | .0549 | .0526 | .0526 | .0549 | .056 |
| 22 | .0532 | .0549 | .0549 | .0566 | .0526 | .0549 | .0549 |
| 23 | .0532 | .0532 | .0549 | .0526 | .0526 | .0549 | .0549 |
| 24 | .0549 | .0532 | .0532 | .0549 | .0532 | .0526 | .0549 |
| Max | .0549 | .0566 | .0549 | .0566 | .0549 | .056 | .056 |
| Min | .0532 | .0532 | .0532 | .0526 | .0526 | .0526 | .0549 |
| Avg | .0539 | .0534 | .0541 | .0540 | .0534 | .0546 | .0552 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 200 / S/STN TRANSFORMER

Feeder KV- 33 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 2 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 3 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 4 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 5 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 6 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| 7 | .3292 | .3361 | .2801 | .3292 | .2801 | .2801 | .3292 |
| 8 | .2743 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 |
| 9 | .2743 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 |
| 10 | .2743 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 |
| 11 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 | .2743 |
| 12 | .2801 | .2801 | .2743 | .2743 | .2801 | .2743 | .2801 |
| 13 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 | .2801 |
| 14 | .2801 | .2801 | .2743 | .2743 | .2801 | .2743 | .2801 |
| 15 | .2801 | .2801 | .2743 | .2743 | .2801 | .2743 | .2801 |
| 16 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 | .2743 |
| 17 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 | .2743 |
| 18 | .2801 | .2801 | .2743 | .2801 | .2801 | .2743 | .2801 |
| 19 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 | .3921 |
| 20 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 | .3841 |
| 21 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 | .3921 |
| 22 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 | .3921 |
| 23 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 | .3921 |
| 24 | .3841 | .3921 | .3921 | .3841 | .3921 | .3921 | .3841 |
| Max | .3921 | .3921 | .3921 | .3921 | .3921 | .3921 | .3921 |
| Min | .2743 | .2801 | .2743 | .2743 | .2801 | .2743 | .2743 |
| Avg | .3351 | .3384 | .3325 | .3344 | .3361 | .3325 | .3340 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 201 / SANDESH CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0183 | .0373 | .0187 | .0183 | .0373 | .0187 | .0183 |
| 2 | .0183 | .0187 | .0187 | .0183 | .0373 | .0187 | .0183 |
| 3 | .0183 | .0187 | .0187 | .0183 | .0373 | .0187 | .0183 |
| 4 | .0183 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 |
| 5 | .0183 | .0187 | .0187 | .0183 | .0373 | .0187 | .0183 |
| 6 | .0183 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 |
| 7 | .0183 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 |
| 8 | .0183 | .0373 | .0187 | .0183 | .0187 | .0187 | .0183 |
| 9 | .0366 | .0187 | .0187 | .0366 | .0187 | .0187 | .0366 |
| 10 | .0183 | .0187 | .0187 | .0183 | .0187 | .0373 | .0366 |
| 11 | .0187 | .0187 | .0183 | .0187 | .0187 | .0366 | .0183 |
| 12 | .0373 | .0187 | .0183 | .0183 | .0187 | .0183 | .0187 |
| 13 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 | .0187 |
| 14 | .0187 | .0187 | .0183 | .0183 | .0187 | .0183 | .0187 |
| 15 | .0187 | .0187 | .0183 | .0183 | .0187 | .0183 | .0187 |
| 16 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 | .0183 |
| 17 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 | .0183 |
| 18 | .0187 | .0187 | .0183 | .0187 | .0187 | .0183 | .0187 |
| 19 | .0373 | .0373 | .0183 | .0373 | .0373 | .0366 | .0373 |
| 20 | .0373 | .0187 | .0366 | .0373 | .0373 | .0366 | .0366 |
| 21 | .0373 | .0373 | .0366 | .0373 | .0373 | .0366 | .0373 |
| 22 | .0373 | .0373 | .0366 | .0373 | .0373 | .0366 | .0373 |
| 23 | .0187 | .0373 | .0183 | .0187 | .0187 | .0366 | .0739 |
| 24 | .0183 | .0187 | .0187 | .0366 | .0187 | .0187 | .0366 |
| Max | .0373 | .0373 | .0366 | .0373 | .0373 | .0373 | .0739 |
| Min | .0183 | .0187 | .0183 | .0183 | .0187 | .0183 | .0183 |
| Avg | .0232 | .0234 | .0208 | .0231 | .0249 | .0238 | .0261 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 202 / JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2012 | .2054 | .2241 | .2195 | .2054 | .2241 | .2012 |
| 2 | .2012 | .2054 | .2241 | .2195 | .2054 | .2241 | .2012 |
| 3 | .2012 | .2054 | .2241 | .2012 | .2054 | .2241 | .2012 |
| 4 | .2195 | .2054 | .2241 | .2012 | .2054 | .2241 | .2012 |
| 5 | .2378 | .2054 | .2241 | .2012 | .2054 | .2241 | .2195 |
| 6 | .2378 | .2614 | .2427 | .2012 | .3361 | .2614 | .2012 |
| 7 | .2561 | .2054 | .2801 | .2195 | .2614 | .2801 | .2195 |
| 8 | .2926 | .3921 | .2987 | .2195 | .3361 | .3174 | .2195 |
| 9 | .2743 | .2427 | .2427 | .2743 | .2427 | .2614 | .2743 |
| 10 | .3475 | .2987 | .2614 | .2195 | .2987 | .2801 | .2561 |
| 11 | .2427 | .2614 | .2561 | .2241 | .3361 | .2561 | .2743 |
| 12 | .3174 | .2987 | .3109 | .2012 | .2801 | .2743 | .2614 |
| 13 | .2427 | .2427 | .2743 | .2054 | .2987 | .2926 | .3174 |
| 14 | .3361 | .2987 | .3109 | .2195 | .3361 | .3292 | .3174 |
| 15 | .2427 | .2614 | .2743 | .2195 | .2801 | .3292 | .4668 |
| 16 | .3361 | .2801 | .3109 | .2054 | .2801 | .3292 | .567 |
| 17 | .3174 | .2987 | .3109 | .2054 | .3174 | .3475 | .6584 |
| 18 | .3734 | .2801 | .2926 | .2614 | .2987 | .2743 | .2987 |
| 19 | .4108 | .3921 | .2926 | .3547 | .3734 | .3109 | .4108 |
| 20 | .2987 | .2801 | .2743 | .3174 | .4108 | .3292 | .4024 |
| 21 | .2614 | .2801 | .2378 | .2427 | .2801 | .2561 | .3921 |
| 22 | .2427 | .2614 | .2195 | .2241 | .2614 | .2378 | .2427 |
| 23 | .2801 | .2241 | .2743 | .2241 | .2427 | .2195 | .2801 |
| 24 | .2012 | .2054 | | .2012 | .2241 | .2427 | .2195 |
| Max | .4108 | .3921 | .3109 | .3547 | .4108 | .3475 | .6584 |
| Min | .2012 | .2054 | .2195 | .2012 | .2054 | .2195 | .2012 |
| Avg | .2739 | .2622 | .2646 | .2284 | .2801 | .2729 | .3043 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 204 / 11 KV INCOMMER-II

Feeder KV- 11 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2427 | | | | | |
| 3 | | | | | .2427 | | |
| 7 | | .2241 | | | | | |
| 8 | | .4294 | | | .3547 | | |
| 9 | .3109 | .2614 | .2614 | | .2614 | | .2378 |
| 10 | | | | | .3174 | .3174 | |
| 12 | .3547 | | | | | | .2801 |
| 13 | | | | .2241 | | | .3361 |
| 14 | | | | | | | .3361 |
| 15 | | | | | | | .4854 |
| 16 | | | | .2241 | | | |
| 17 | | | | .2241 | | | |
| 18 | .3921 | | | .2801 | | | .3174 |
| 19 | .4481 | | | .3921 | | | .4481 |
| 20 | .3361 | .2987 | | .3547 | .4481 | | |
| 21 | .2987 | | | .2801 | | | .3921 |
| 22 | | | .2561 | .2614 | | | .2801 |
| 24 | | .2241 | | | .2427 | | |
| Max | .4481 | .4294 | .2614 | .3921 | .4481 | .3174 | .4854 |
| Min | .2987 | .2241 | .2561 | .2241 | .2427 | .3174 | .2378 |
| Avg | .3568 | .2801 | .2588 | .2801 | .3112 | .3174 | .3459 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 401 / 33 KV Issasani -jamtha

Feeder KV- 33 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2241 | | | | | |
| 3 | | | | | .2241 | | |
| 7 | | .2241 | | | | | |
| 8 | | .4481 | | | .3361 | | |
| 9 | .3292 | .2801 | .2801 | | .2801 | | .3292 |
| 10 | | | | | .3361 | .3361 | |
| 12 | .3361 | | | | | | .2801 |
| 13 | | | | .2241 | | | .3361 |
| 14 | | | | | | | .3361 |
| 15 | | | | | | | .5041 |
| 16 | | | | .2241 | | | |
| 17 | | | | .2241 | | | |
| 18 | .3921 | | | .2801 | | | .3361 |
| 19 | .4481 | | | .3921 | | | .4481 |
| 20 | .3361 | .2801 | | .3361 | .4481 | | |
| 21 | .2801 | | | .2801 | | | .4481 |
| 22 | | | .2743 | .2801 | | | .2801 |
| 24 | | .2241 | | | .2241 | | |
| Max | .4481 | .4481 | .2801 | .3921 | .4481 | .3361 | .5041 |
| Min | .2801 | .2241 | .2743 | .2241 | .2241 | .3361 | .2801 |
| Avg | .3536 | .2801 | .2772 | .2801 | .3081 | .3361 | .3664 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 200 / SUB STATION T/F

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 18-FEB-18 | 19-FEB-18 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0154 | | .0154 |
| 2 | .0154 | | .0154 |
| 3 | .0154 | | .0154 |
| 4 | .0154 | | .0154 |
| 5 | .0154 | | .0154 |
| 6 | .0154 | | .0154 |
| 7 | .0154 | | .0154 |
| 8 | | | .0154 |
| 10 | .0154 | | .0154 |
| 11 | | .0103 | |
| 12 | | .0154 | |
| 13 | | .0154 | |
| 14 | | .0154 | |
| 15 | | .0154 | |
| 16 | | .0171 | |
| 17 | | .0154 | |
| 18 | | .0154 | |
| 22 | | .0154 | |
| 24 | .0154 | | |
| Max | .0154 | .0171 | .0154 |
| Min | .0154 | .0103 | .0154 |
| Avg | .0154 | .0150 | .0154 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 202 / 11 KV D ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9774 | | .9431 | .8954 | .7545 | .9526 | .9619 |
| 2 | .9774 | .743 | .9054 | .8573 | .7545 | .9526 | .9431 |
| 3 | 1.0288 | .7621 | .8676 | .9526 | .7545 | .9145 | .9242 |
| 4 | 1.0288 | .8002 | .8488 | 1.0479 | .7545 | .9335 | .9054 |
| 5 | 1.0631 | .7621 | | 1.105 | .7888 | .8383 | .9431 |
| 6 | 1.0974 | .6859 | .7922 | 1.1431 | .8059 | 1.0288 | .9808 |
| 7 | 1.0802 | 1.0098 | .9054 | 1.1431 | .8916 | 1.0669 | 1.0185 |
| 8 | | 1.3146 | 1.1694 | 1.467 | 1.5432 | 1.4289 | 1.0562 |
| 9 | 1.6575 | 1.9624 | 1.3392 | 1.5242 | 1.7918 | 1.5623 | 1.3014 |
| 10 | 1.6804 | 2.1719 | 1.4335 | 1.6766 | 1.6975 | 1.9052 | 1.3957 |
| 11 | 1.9624 | 2.3954 | 1.5278 | 1.6975 | 1.7147 | 1.9993 | 1.3717 |
| 12 | 2.2862 | 2.1313 | 1.5242 | 1.8004 | 1.6766 | 2.6217 | 1.4098 |
| 13 | 2.553 | 2.7915 | 1.7147 | 1.8176 | 3.0864 | 1.9427 | 1.2384 |
| 14 | 2.3434 | 2.2068 | 1.8099 | 1.6804 | 2.4006 | 2.1502 | 1.3336 |
| 15 | 1.5432 | 2.3765 | 1.9052 | 1.5775 | 1.7528 | 1.7541 | 1.6194 |
| 16 | 2.0195 | 2.1313 | 2.0005 | 1.5604 | 2.0386 | 1.9427 | 1.5051 |
| 17 | 2.3624 | 2.452 | 2.1719 | 2.0919 | 1.848 | 1.9616 | 1.5242 |
| 18 | 2.0576 | 1.4901 | 2.572 | 1.1831 | 1.6385 | 1.6787 | |
| 19 | 1.1622 | 1.3957 | 1.5813 | 1.2637 | 1.5813 | 1.3957 | 1.1431 |
| 20 | 1.5432 | 1.3014 | 1.5242 | 1.8296 | 1.467 | 1.3014 | 1.2384 |
| 21 | 1.7337 | | 1.1431 | 1.0185 | 1.7147 | 1.1317 | 1.0288 |
| 22 | .724 | 1.226 | .9526 | .8573 | 1.105 | 1.1506 | 1.105 |
| 23 | .8192 | .9431 | .9526 | .5093 | 1.086 | 1.0374 | 1.0669 |
| 24 | 1.0288 | .6859 | .9808 | .9526 | .7922 | .9717 | .9997 |
| Max | 2.553 | 2.7915 | 2.572 | 2.0919 | 3.0864 | 2.6217 | 1.6194 |
| Min | .724 | .6859 | .7922 | .5093 | .7545 | .8383 | .9054 |
| Avg | 1.5100 | 1.5336 | 1.3724 | 1.3188 | 1.4350 | 1.4426 | 1.1745 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 205 / 11 KV FOOD PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7545 | .8954 | .9054 | 1.1431 | .823 | .8573 | .9242 |
| 2 | .7202 | .8764 | .8865 | 1.1812 | .823 | .8764 | .9054 |
| 3 | .7202 | .8383 | .9054 | .9526 | .823 | .8954 | .9242 |
| 4 | .7202 | .8192 | .9054 | 1.0479 | .823 | .9145 | .9242 |
| 5 | .7202 | .8954 | .8865 | .9526 | .823 | .8573 | .8488 |
| 6 | .7202 | .9717 | .8865 | .9526 | .823 | .8573 | .7922 |
| 7 | .7545 | .8192 | .811 | .7621 | .8573 | .8192 | .7356 |
| 8 | 1.0374 | 1.1622 | 1.1694 | 1.3336 | 1.166 | 1.105 | .7733 |
| 9 | 1.1622 | 1.2384 | 1.3769 | 1.5242 | 1.3336 | 1.3336 | .811 |
| 10 | 1.3375 | 1.5432 | 1.4712 | 1.6194 | 1.3375 | 1.4289 | .9619 |
| 11 | 1.2574 | 1.358 | 1.4335 | 1.3889 | 1.2574 | 1.3769 | .9717 |
| 12 | 1.3336 | 1.4146 | 1.2765 | 1.3717 | 1.5242 | | .9526 |
| 13 | 1.1812 | 1.5089 | 1.467 | 1.4232 | 1.2955 | 1.3203 | .9717 |
| 14 | 1.467 | 1.2449 | 1.4861 | 1.406 | 1.3908 | 1.3392 | |
| 15 | 1.3717 | 1.3957 | 1.5242 | 1.3889 | 1.448 | 1.4901 | |
| 16 | 1.4289 | 1.5089 | 1.5242 | 1.3203 | 1.4289 | 1.4712 | |
| 17 | .8573 | 1.5655 | 1.3717 | 1.2689 | 1.3908 | | |
| 18 | 1.3336 | 1.3957 | 1.467 | 1.4232 | 1.4861 | 1.4901 | .8002 |
| 19 | 1.2955 | 1.4712 | 1.3908 | 1.3908 | 1.3336 | 1.358 | .8573 |
| 20 | 1.3146 | 1.4335 | 1.3336 | 1.448 | 1.0669 | 1.3014 | .7621 |
| 21 | 1.2955 | | 1.2955 | 1.2765 | 1.1622 | 1.1883 | .9145 |
| 22 | 1.1812 | 1.1694 | 1.2574 | 1.1317 | 1.2193 | 1.1694 | .9335 |
| 23 | 1.086 | 1.226 | 1.2193 | 1.2384 | 1.086 | 1.094 | .8383 |
| 24 | .7716 | .9145 | .9431 | 1.2384 | .9335 | .9907 | .9054 |
| Max | 1.467 | 1.5655 | 1.5242 | 1.6194 | 1.5242 | 1.4901 | .9717 |
| Min | .7202 | .8192 | .811 | .7621 | .823 | .8192 | .7356 |
| Avg | 1.0759 | 1.2029 | 1.2164 | 1.2577 | 1.1523 | 1.1607 | .8754 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 200 / S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0274 | .0274 | .1128 | .1128 | .1128 | .0274 | .0274 |
| 2 | .0274 | .0274 | .1128 | .1128 | .1128 | .0274 | .0274 |
| 3 | .0274 | .0274 | .1128 | .1128 | .1128 | .0274 | .0274 |
| 4 | .0274 | .0274 | .1128 | .1128 | .1128 | .0274 | .0274 |
| 5 | .0274 | .0274 | | .1128 | .1128 | .0274 | .0274 |
| 6 | .0274 | .0274 | | | | .0274 | .0274 |
| 19 | .1128 | .1219 | .1128 | .1158 | .1128 | .1128 | .1097 |
| 20 | .1128 | .1128 | .1128 | .1158 | .1128 | .1128 | .1128 |
| 21 | .1128 | .1128 | .1128 | .1158 | .1128 | .1128 | .1128 |
| 22 | .1128 | .1128 | .1128 | .1158 | .1128 | .1128 | .1128 |
| 23 | .1128 | .1128 | .1128 | .1158 | .1128 | .1128 | .1128 |
| 24 | | .1128 | .1128 | | .0274 | | .0274 |
| Max | .1128 | .1219 | .1128 | .1158 | .1128 | .1128 | .1128 |
| Min | .0274 | .0274 | .1128 | .1128 | .0274 | .0274 | .0274 |
| Avg | .0662 | .0709 | .1128 | .1143 | .1050 | .0662 | .0627 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 201 / VRINDAVAN FEEDER NO. I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0373 | .0392 | .0407 | .0388 | .037 | .0472 | .0396 |
| 2 | .0355 | .0373 | .037 | .037 | .0333 | .0453 | .0396 |
| 3 | .0392 | .0299 | .0333 | .0333 | .0314 | .0396 | .0377 |
| 4 | .0336 | .0317 | .0259 | .0277 | .0314 | .049 | .0377 |
| 5 | .0355 | .0355 | .0277 | .0277 | .0314 | .0453 | .0358 |
| 6 | .0373 | .0373 | .0314 | .0314 | .0296 | .0434 | .0358 |
| 7 | .0336 | .0261 | .0333 | .0277 | .0259 | .0415 | .0302 |
| 8 | | .028 | .0222 | .0277 | .0425 | .0453 | .0264 |
| 9 | .0392 | .0336 | .0296 | .0314 | .0425 | .0472 | .0302 |
| 10 | .0392 | .056 | .0296 | .0351 | .0388 | .049 | .0453 |
| 11 | .0485 | .0635 | .061 | .0314 | .0773 | .0528 | .0566 |
| 12 | .0504 | .1008 | .0702 | .0499 | .0811 | .1037 | .0472 |
| 13 | .0709 | .1064 | .0628 | .048 | .083 | .1188 | .0641 |
| 14 | .0653 | .1046 | .0684 | .0591 | .0886 | .0792 | .0604 |
| 15 | .056 | .1064 | .0961 | .0554 | .0905 | .1019 | .0585 |
| 16 | .0672 | .0934 | .0776 | .0536 | .1037 | .0849 | .0717 |
| 17 | .0822 | .0878 | .0758 | .0462 | .0754 | .0736 | .0622 |
| 18 | .0597 | .0407 | .0462 | .0333 | .0453 | .0453 | .0396 |
| 19 | .0784 | .0739 | .0665 | .0573 | .0672 | .066 | .0754 |
| 20 | .056 | .0721 | .0795 | .0536 | .0604 | .0641 | .0754 |
| 21 | .0579 | .0573 | .0758 | .0444 | .0641 | .0509 | .0604 |
| 22 | .0429 | .0462 | .0554 | .0425 | .0585 | .0434 | .0509 |
| 23 | .0448 | .0425 | .0444 | .0351 | .0547 | .0415 | .049 |
| 24 | | .0411 | .0444 | .0425 | .0509 | | .0415 |
| Max | .0822 | .1064 | .0961 | .0591 | .1037 | .1188 | .0754 |
| Min | .0336 | .0261 | .0222 | .0277 | .0259 | .0396 | .0264 |
| Avg | .0505 | .0580 | .0515 | .0404 | .0560 | .0600 | .0488 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 202 / VRINDAVAN FEEDER NO. II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 19-FEB-18 | 20-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5 | | | | .0248 | |
| 6 | | | | .0229 | |
| 7 | | .0267 | | .0229 | |
| 8 | .0229 | | | | |
| 9 | .0267 | | .0229 | .0229 | .0248 |
| 10 | | | | .0267 | |
| 11 | | .0248 | | | |
| 19 | | .0229 | | | |
| 22 | | .0229 | | | |
| Max | .0267 | .0267 | .0229 | .0267 | .0248 |
| Min | .0229 | .0229 | .0229 | .0229 | .0248 |
| Avg | .0248 | .0243 | .0229 | .0240 | .0248 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 203 / VRINDAVAN FEEDER NO. III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0448 | .0429 | .0348 | .0329 | .0235 | .0271 | .0416 |
| 2 | .0411 | .0429 | .0329 | .0348 | .0235 | .0308 | .0398 |
| 3 | .0467 | .0448 | .0311 | .0311 | .0235 | .0253 | .0398 |
| 4 | .0373 | .0467 | .0293 | .0311 | .0235 | .0344 | .038 |
| 5 | .0355 | .0523 | .0311 | .0293 | .0235 | .0326 | .0471 |
| 6 | .0467 | .0541 | .0329 | .0329 | .0416 | .029 | .0543 |
| 7 | .0485 | .0448 | .0348 | .0713 | .0398 | .0362 | .0579 |
| 8 | .0541 | .028 | .0402 | .0713 | .0344 | .0326 | .0434 |
| 9 | .0467 | .0467 | .0439 | .0878 | .0525 | .0344 | .0344 |
| 10 | .0485 | .0523 | .0274 | .0549 | | .0471 | .0398 |
| 11 | .0597 | .0299 | .0402 | .0604 | .0742 | .0778 | .0615 |
| 12 | .0672 | .056 | .0348 | .0549 | .0525 | .0452 | .067 |
| 13 | .0653 | .0691 | .0512 | .0402 | .0597 | .0452 | .0796 |
| 14 | .0504 | .0803 | .0421 | .0366 | .0615 | .0362 | .0579 |
| 15 | .0429 | .0485 | .0366 | .0494 | .067 | .067 | .0507 |
| 16 | .0448 | .0523 | .053 | .0512 | .0615 | .0724 | .0652 |
| 17 | .0467 | .0635 | .0658 | .0439 | .038 | .0706 | .0507 |
| 18 | .0541 | .0452 | .0457 | .0271 | .0398 | .0471 | .0416 |
| 19 | .0392 | .0416 | .0439 | .0326 | .0398 | .0452 | .0326 |
| 20 | .0467 | .0398 | .0476 | .0308 | .0434 | .0525 | .0305 |
| 21 | .0429 | .0348 | .0384 | .0326 | .038 | .0471 | |
| 22 | .0429 | .0366 | .0476 | .0326 | .0344 | .0452 | .0326 |
| 23 | .0411 | .0366 | .0144 | .0253 | .0308 | .0434 | .0326 |
| 24 | | .0448 | .0348 | .0366 | .0326 | | .0434 |
| Max | .0672 | .0803 | .0658 | .0878 | .0742 | .0778 | .0796 |
| Min | .0355 | .028 | .0144 | .0253 | .0235 | .0253 | .0305 |
| Avg | .0476 | .0473 | .0389 | .0430 | .0417 | .0445 | .0470 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 201 / 11KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5144 | .4801 | .5487 | .5487 | .5487 | .5658 | .6859 |
| 2 | .4801 | .4287 | .5487 | .5144 | .5144 | .5316 | .6687 |
| 3 | .463 | .4287 | .5316 | .463 | .4801 | .4801 | .6687 |
| 4 | .4287 | .4458 | .5316 | .4287 | .4801 | .4801 | .6516 |
| 5 | .4801 | .4801 | .5144 | .5028 | .5144 | .5144 | .6516 |
| 6 | .5144 | .5144 | .5487 | .5548 | .5487 | .5487 | .6173 |
| 7 | .5487 | .5316 | .6001 | .6001 | .583 | .6001 | .6173 |
| 8 | .3429 | .3258 | .4287 | .4801 | .5144 | .5658 | .5487 |
| 9 | .3772 | .4458 | .4801 | .6687 | .7716 | .823 | .823 |
| 10 | .3601 | .463 | .4973 | .8402 | .8916 | .8916 | .6859 |
| 11 | .3772 | .463 | .5487 | .7373 | .7373 | .9602 | .9602 |
| 12 | .3429 | .4458 | .583 | .7373 | .7545 | .9259 | .8745 |
| 13 | .3772 | .4801 | .6001 | .7202 | .7545 | .823 | .8745 |
| 14 | .3601 | .463 | .6415 | .6859 | .7545 | .8573 | .9015 |
| 15 | .4115 | .4287 | .6588 | .3601 | .6687 | .4801 | .8916 |
| 16 | .3258 | .3429 | .463 | .3772 | .3944 | .3772 | .583 |
| 17 | .2915 | .3772 | .4287 | .3429 | .4115 | .3601 | .5658 |
| 18 | .463 | .5144 | .3641 | .6687 | .5658 | .583 | .5375 |
| 19 | .8745 | .9945 | .5487 | .9259 | .9431 | .9431 | .9431 |
| 20 | .8916 | .9945 | .8322 | .9431 | .9602 | .9774 | .9602 |
| 21 | .8573 | .9088 | .8842 | .8916 | .8916 | .9431 | .9709 |
| 22 | .6859 | .7202 | .7888 | .7373 | .823 | .8573 | .9088 |
| 23 | .6344 | .6173 | .6859 | .6859 | .703 | .7373 | .8402 |
| 24 | .5144 | .5144 | .583 | .5721 | .6173 | .6001 | .6859 |
| Max | .8916 | .9945 | .8842 | .9431 | .9602 | .9774 | .9709 |
| Min | .2915 | .3258 | .3641 | .3429 | .3944 | .3601 | .5375 |
| Avg | .4965 | .5337 | .5767 | .6245 | .6594 | .6844 | .7549 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 202 / Kanholibara - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | .0983 | .1311 | .1638 | .2294 | .2458 | .2622 | .2622 |
| 9 | .0983 | .1147 | .1966 | .2785 | .2294 | .2949 | .3441 |
| 10 | .1147 | .1638 | .1802 | .3441 | .2785 | | .3605 |
| 11 | .1147 | .1802 | .213 | .3113 | .213 | .2949 | .3768 |
| 12 | .0983 | .1475 | .2458 | .3277 | .2949 | .2785 | .3605 |
| 13 | .0983 | .1802 | .1943 | .3277 | .2949 | .2949 | .3605 |
| 14 | .0983 | .213 | .1311 | .2949 | .3113 | .2785 | .3277 |
| 15 | .0983 | .1966 | .081 | .1966 | .2949 | .3113 | .3077 |
| 16 | | .1966 | | | | .1802 | |
| 21 | | | | .1966 | | | |
| Max | .1147 | .213 | .2458 | .3441 | .3113 | .3113 | .3768 |
| Min | .0983 | .1147 | .081 | .1966 | .213 | .1802 | .2622 |
| Avg | .1024 | .1693 | .1757 | .2785 | .2703 | .2744 | .3375 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 203 / 11 KV GUMGAON - SPARE- SINGLE PHASING
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4917 | .4748 | .5596 | .5596 | .6443 | .6443 | .7461 |
| 2 | .4578 | .4748 | .5426 | .5197 | .5935 | .6104 | .6783 |
| 3 | .4578 | .4239 | .5426 | .4748 | .5935 | .5596 | .6783 |
| 4 | .4239 | .4239 | .5256 | .4239 | .5596 | .5596 | .7461 |
| 5 | .4748 | .5087 | .5256 | .4917 | .5596 | .5765 | .7461 |
| 6 | .5426 | .5935 | .5935 | .5533 | .5765 | .6104 | .7291 |
| 7 | .6274 | .6783 | .6613 | .6274 | .6104 | .6443 | .7122 |
| 8 | .5935 | .6104 | .6443 | .6274 | .6287 | .8478 | .7291 |
| 9 | .5426 | .5765 | .6783 | .6443 | .6613 | .78 | .8139 |
| 10 | .5596 | .5765 | .6613 | .6613 | .7291 | .8478 | .8478 |
| 11 | .5426 | .5765 | .6952 | .6274 | .407 | .8478 | .8817 |
| 12 | .2883 | .5426 | .7122 | .6613 | .4409 | .8478 | .8048 |
| 13 | .407 | .4917 | .6706 | .6613 | .6952 | .8139 | .8383 |
| 14 | .4409 | .5426 | .6443 | .5426 | .78 | .8648 | .8478 |
| 15 | .407 | .5426 | .6274 | .2713 | .6783 | .8139 | .8215 |
| 16 | .4748 | .5426 | .5426 | .5765 | .6274 | .5426 | .7377 |
| 17 | .4409 | .4917 | .5935 | .5087 | .6443 | .6443 | .7122 |
| 18 | .5426 | .5935 | .6203 | .7122 | .7461 | .7291 | .6783 |
| 19 | .9326 | .9496 | .7042 | .9835 | 1.0174 | 1.0682 | 1.0682 |
| 20 | .9326 | .9496 | .8478 | 1.0004 | 1.0174 | 1.0852 | 1.0513 |
| 21 | .8648 | .8817 | .8916 | .9326 | .9496 | 1.0513 | 1.0174 |
| 22 | .7122 | .7291 | .7969 | .8139 | .8817 | .6274 | .9221 |
| 23 | .5935 | .6104 | .6539 | .763 | .7461 | .8648 | .8478 |
| 24 | .5256 | .5256 | .5596 | .5765 | .6783 | .6783 | .763 |
| Max | .9326 | .9496 | .8916 | 1.0004 | 1.0174 | 1.0852 | 1.0682 |
| Min | .2883 | .4239 | .5256 | .2713 | .407 | .5426 | .6783 |
| Avg | .5532 | .5963 | .6456 | .6339 | .6861 | .7567 | .8091 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 204 / 11 KV Kanholibara-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6908 | .6908 | .7468 | .7164 | .8029 | .8215 | .8402 |
| 2 | .6535 | .6535 | .7095 | .6697 | .7468 | .7842 | .8402 |
| 3 | .6535 | .6535 | .7095 | .6268 | .7095 | .7468 | .8215 |
| 4 | .6161 | .6722 | .7282 | .6154 | .6535 | .7468 | .8589 |
| 5 | .6722 | .7095 | .7282 | .6626 | .6535 | .8029 | .9149 |
| 6 | .7468 | .7842 | .8589 | .7164 | .7468 | .8402 | .8962 |
| 7 | .8775 | .8589 | .9149 | .7783 | .8215 | .7865 | .9149 |
| 8 | 1.251 | 1.0456 | .9335 | 1.1104 | 1.1949 | .9339 | 1.1949 |
| 9 | 1.2323 | 1.0642 | .9149 | 1.1203 | 1.307 | 1.5684 | 1.6057 |
| 10 | 1.0082 | .9896 | .8775 | 1.1016 | 1.4377 | 1.251 | 1.2323 |
| 11 | 1.1389 | .8589 | .8596 | 1.0829 | 1.0456 | 1.2323 | 1.2883 |
| 12 | 1.0456 | .9896 | .8954 | 1.2323 | 1.3817 | 1.4377 | 1.2536 |
| 13 | .9149 | .9709 | .905 | 1.251 | 1.3256 | 1.1389 | 1.1462 |
| 14 | .8962 | 1.0082 | .8417 | 1.1203 | 1.4003 | 1.4003 | 1.086 |
| 15 | .8215 | .8029 | .788 | .8215 | .9896 | 1.0269 | .9955 |
| 16 | .4481 | | .5731 | .5228 | .4668 | .8215 | |
| 17 | .4481 | | .6154 | .5228 | .5041 | .5228 | |
| 18 | .5788 | .4108 | .6697 | .7095 | .7468 | .8402 | |
| 19 | 1.251 | 1.307 | .8059 | 1.2883 | 1.3443 | 1.363 | 1.3611 |
| 20 | 1.2696 | 1.3256 | 1.086 | 1.3443 | 1.363 | 1.4003 | 1.267 |
| 21 | 1.1763 | 1.2136 | 1.1765 | 1.2883 | 1.251 | 1.3443 | 1.2308 |
| 22 | .9149 | .9335 | 1.0745 | 1.0456 | 1.1016 | 1.1576 | 1.1283 |
| 23 | .8402 | .7842 | .9593 | .9335 | .9335 | 1.0082 | .985 |
| 24 | .7095 | .7282 | .7468 | .7522 | .8589 | .8589 | .9335 |
| Max | 1.2696 | 1.3256 | 1.1765 | 1.3443 | 1.4377 | 1.5684 | 1.6057 |
| Min | .4481 | .4108 | .5731 | .5228 | .4668 | .5228 | .8215 |
| Avg | .8690 | .8843 | .8383 | .9181 | .9911 | 1.0348 | 1.0855 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 205 / 11 KV NARAYANA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9 | .0572 | | | | | | |
| 10 | .1334 | | | | | | |
| 11 | .1524 | .1524 | | .1524 | .1143 | | .1143 |
| 12 | .1143 | .1524 | .0381 | .1524 | | .1143 | .1143 |
| 13 | .1143 | .1143 | .0572 | .1334 | .1524 | .1143 | |
| 14 | .1143 | .1143 | .0762 | .1334 | | .1143 | |
| 15 | .1524 | .1143 | .1143 | | .0381 | .1143 | |
| 16 | .1143 | .1143 | .1524 | | | .1143 | |
| 17 | | .1143 | .1334 | | .1715 | .1143 | |
| 18 | | .1143 | .1143 | | .1715 | .1143 | |
| 19 | | | .1143 | | .1334 | .1143 | .1524 |
| 20 | | | | | .1524 | .1143 | .1524 |
| 21 | | | | | .1524 | | .1524 |
| 22 | | | | | | | .1524 |
| 23 | | | | | | | .1524 |
| Max | .1524 | .1524 | .1524 | .1524 | .1715 | .1143 | .1524 |
| Min | .0572 | .1143 | .0381 | .1334 | .0381 | .1143 | .1143 |
| Avg | .1191 | .1238 | .1000 | .1429 | .1358 | .1143 | .1415 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 206 / R.R.R Water works Boregaon NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 2 | .0381 | .0381 | .0381 | .0381 | .0381 | .038 |
| 3 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 4 | .0381 | .0381 | .0381 | .0381 | .0381 | .038 |
| 5 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 6 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 7 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 8 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 9 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 10 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 11 | | .0381 | | | | .0381 |
| 12 | | .0381 | | | | .0381 |
| 13 | | | | | | .0381 |
| 14 | | | | | | .0381 |
| 15 | | | | | .0381 | .0381 |
| 16 | | | .0381 | .0381 | | .0381 |
| 17 | .0381 | .0381 | .0381 | .0381 | | |
| 18 | .0381 | .0381 | .0381 | .0381 | | |
| 19 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 20 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 21 | .0381 | .0381 | .0381 | .0762 | .0381 | |
| 22 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 23 | .0381 | .0381 | .0381 | .0381 | .0381 | |
| 24 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Max | .0381 | .0381 | .0381 | .0762 | .0381 | .0381 |
| Min | .0381 | .0381 | .0381 | .0381 | .0381 | .038 |
| Avg | .0381 | .0381 | .0381 | .0401 | .0381 | .0381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 207 / 11 KV Industrial Sawangi SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .0572 | .0572 | .0953 | .0381 | .0572 | .0572 |
| 2 | .0572 | .0572 | .0572 | .0762 | .0381 | .0572 | .0572 |
| 3 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0572 |
| 4 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0572 |
| 5 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0572 |
| 6 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0572 |
| 7 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0572 |
| 8 | .0572 | .0762 | .0572 | .0572 | .0381 | .0762 | .0572 |
| 9 | .0953 | .1143 | .0572 | .0572 | .0572 | .1715 | .0762 |
| 10 | .1905 | .1524 | .0953 | .0572 | .1143 | 1.6385 | .0762 |
| 11 | .2286 | .2477 | .1905 | .1524 | .1143 | .1143 | .0572 |
| 12 | | .2286 | .1905 | .1524 | .1143 | .0762 | .1715 |
| 13 | .2286 | .2286 | .2286 | .0953 | .1143 | .0762 | .1715 |
| 14 | .1905 | .2286 | .2667 | | .1143 | .1143 | .1334 |
| 15 | .0953 | .2286 | .2858 | .0953 | .1143 | .0762 | .1334 |
| 16 | .2667 | .1143 | .2858 | .0572 | .1143 | .1143 | .1715 |
| 17 | .2667 | .1143 | .2477 | .0572 | .1905 | .0953 | .1905 |
| 18 | .4001 | .2286 | .2096 | .0572 | .2096 | .1905 | .2286 |
| 19 | .3429 | | .1905 | .0381 | .1715 | .1905 | .1715 |
| 20 | .1905 | .2477 | .1715 | .0381 | .1524 | .1524 | .1334 |
| 21 | .1524 | .1143 | .1524 | | .152 | .0953 | .0762 |
| 22 | .0762 | .0572 | .1524 | .0381 | .0762 | .0572 | .0572 |
| 23 | .0572 | .0572 | .1143 | .0381 | .0572 | .0572 | .0572 |
| 24 | .0572 | .0572 | .0572 | .0953 | .0381 | .0572 | .0572 |
| Max | .4001 | .2477 | .2858 | .1524 | .2096 | 1.6385 | .2286 |
| Min | .0572 | .0572 | .0572 | .0381 | .0381 | .0572 | .0572 |
| Avg | .1433 | .1259 | .1397 | .0702 | .0921 | .1564 | .1008 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 208 / 11 KV Jagruteshwar

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2614 | | | | |
| 2 | | .2427 | | | | |
| 3 | | .2427 | | | | |
| 4 | | .1867 | | | | |
| 5 | | .1867 | | | | |
| 6 | | .1494 | | | | |
| 9 | .3174 | .2054 | .4294 | | .3361 | |
| 10 | .3174 | | .4481 | | .2427 | .2614 |
| 11 | .3174 | .4481 | .3511 | | .2801 | |
| 12 | .4294 | | .2957 | | | .1663 |
| 13 | | | .3142 | | | .2033 |
| 14 | .3734 | | .3174 | | | .2241 |
| 15 | .3734 | | .3547 | | | .2772 |
| 16 | .4668 | | .2772 | | .5601 | .499 |
| 17 | .5228 | | .3174 | .2987 | .2614 | .4481 |
| 18 | .3174 | | .3511 | .2987 | .4108 | .4066 |
| 19 | | | .3511 | .1867 | .4854 | .5175 |
| 20 | | | .3361 | .2987 | .1524 | .4805 |
| 21 | .4668 | | .3547 | .3361 | .4481 | .4481 |
| 22 | .3174 | | .2587 | .3734 | .4108 | .3511 |
| 23 | .2801 | | .168 | .2614 | | .2427 |
| 24 | | .2614 | | | | |
| Max | .5228 | .4481 | .4481 | .3734 | .5601 | .5175 |
| Min | .2801 | .1494 | .168 | .1867 | .1524 | .1663 |
| Avg | .3750 | .2427 | .3283 | .2934 | .3588 | .3481 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 402 / 33 KV Abhijit MADC

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 2 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 3 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 4 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 5 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 6 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 7 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 8 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 9 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 10 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 11 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 12 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 13 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 14 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 15 | .1143 | .1143 | .1143 | | .1143 | .1143 | .1143 |
| 16 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 17 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 18 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 19 | .1143 | .1143 | .1143 | .1143 | | .1143 | .1143 |
| 20 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 21 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 22 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 23 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 24 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| Max | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| Min | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |
| Avg | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 | .1143 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 201 / 11 kV Mohagaon Ag Sep
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1372 | .0953 | .1715 | .0943 | .1141 | .1711 | .1521 |
| 2 | .1272 | .0953 | .1715 | .0943 | .1141 | .1711 | .1521 |
| 3 | .1357 | .0762 | .1715 | .0943 | .0951 | .1711 | .1521 |
| 4 | .1372 | .0762 | .1715 | .0943 | .0951 | .1711 | .1331 |
| 5 | .1406 | .0762 | .1524 | .0943 | .1141 | .1521 | .1331 |
| 6 | .12 | .0953 | .1524 | .0943 | .1141 | .1331 | .1521 |
| 7 | .1357 | .0953 | .0953 | .0943 | .1141 | .1128 | .1711 |
| 8 | .0911 | | .0953 | | .3993 | .3905 | .3803 |
| 9 | .1052 | .4382 | .3905 | .3961 | .4373 | .4277 | .5514 |
| 10 | .0867 | .4191 | | .4338 | .4944 | .5021 | .6275 |
| 11 | .4191 | .4191 | .3961 | .4373 | .4835 | .4563 | .5021 |
| 12 | .4382 | .4001 | .3772 | .4183 | .4649 | .4183 | .4649 |
| 13 | .4382 | .0953 | .3881 | .4373 | .4835 | .4183 | .4649 |
| 14 | .4191 | .1143 | .3961 | .4373 | .4091 | .3803 | .3719 |
| 15 | .4572 | .1143 | .3772 | .4183 | .4091 | .3993 | .3719 |
| 16 | .1143 | .1143 | .1132 | .1711 | .093 | .1331 | .093 |
| 17 | .0953 | .1143 | .0943 | .1521 | .0941 | .1331 | .093 |
| 18 | .0953 | .1334 | .1132 | .0951 | .0941 | .1331 | .093 |
| 19 | .0953 | .1524 | .1132 | .1141 | .1506 | .1711 | .1506 |
| 20 | .1143 | .1715 | .1132 | .1141 | .1674 | .1711 | .1694 |
| 21 | .0953 | .1715 | .1132 | .1141 | .1674 | .1521 | .1694 |
| 22 | .0953 | .1715 | .0943 | .1141 | .1674 | .1711 | .1694 |
| 23 | .0953 | .1715 | .0943 | .1141 | .1698 | .1711 | .1694 |
| 24 | .1235 | .0953 | .1715 | .0943 | .1141 | .1711 | .1521 |
| Max | .4572 | .4382 | .3961 | .4373 | .4944 | .5021 | .6275 |
| Min | .0867 | .0762 | .0943 | .0943 | .093 | .1128 | .093 |
| Avg | .1797 | .1698 | .1968 | .2053 | .2317 | .2451 | .2517 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 202 / 11 kV Hingna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8063 | .7888 | .781 | .823 | .8916 | 1.046 | 1.0288 |
| 2 | .7442 | .7716 | .729 | .7716 | .8573 | 1.0111 | .9945 |
| 3 | .7442 | .7716 | .729 | .763 | .823 | .9762 | .9602 |
| 4 | .7619 | .7202 | .8331 | .7888 | .7888 | .9762 | .9259 |
| 5 | .8505 | .823 | .9546 | .8322 | .8573 | 1.0414 | .9945 |
| 6 | .9671 | .9945 | 1.2242 | .9602 | .9431 | 1.1108 | 1.0802 |
| 7 | 1.2178 | 1.166 | 1.2889 | 1.046 | 1.046 | 1.267 | 1.2346 |
| 8 | 1.3611 | 1.3032 | 1.2373 | 1.2689 | 1.2689 | 1.3061 | 1.3203 |
| 9 | 1.3611 | 1.286 | 1.2889 | 1.3176 | 1.3889 | 1.3576 | 1.406 |
| 10 | 1.3253 | 1.2174 | 1.2029 | 1.3546 | 1.4403 | 1.3061 | 1.3203 |
| 11 | 1.1317 | 1.2428 | 1.2346 | 1.3375 | 1.3276 | 1.2689 | 1.3046 |
| 12 | 1.0288 | 1.122 | 1.1831 | 1.2346 | 1.2889 | 1.2174 | 1.2016 |
| 13 | .9945 | 1.0357 | .9774 | 1.1317 | 1.1342 | 1.0802 | 1.2874 |
| 14 | .9259 | .9148 | .9602 | 1.0974 | 1.0311 | 1.1488 | 1.2889 |
| 15 | .823 | .9148 | .9156 | 1.0288 | .8936 | 1.1488 | 1.2069 |
| 16 | .8745 | .9546 | .9431 | 1.0631 | .9656 | 1.1317 | 1.117 |
| 17 | .9259 | .9967 | 1.046 | 1.0288 | 1.0345 | 1.0631 | 1.1207 |
| 18 | 1.0288 | 1.0357 | 1.2003 | 1.1317 | 1.1035 | 1.2689 | 1.138 |
| 19 | 1.406 | 1.2889 | 1.4232 | 1.3717 | 1.4575 | 1.5775 | 1.4419 |
| 20 | 1.3203 | 1.2889 | 1.3546 | 1.3032 | 1.4263 | 1.4918 | 1.3904 |
| 21 | 1.2003 | 1.2029 | 1.2517 | 1.2346 | | 1.3717 | 1.3218 |
| 22 | 1.0288 | 1.0655 | 1.1096 | 1.166 | 1.2414 | 1.2346 | 1.2759 |
| 23 | .9335 | .8678 | .9945 | .9945 | 1.1629 | 1.1145 | 1.2069 |
| 24 | .8505 | .823 | .781 | .8573 | .9088 | 1.0587 | 1.046 |
| Max | 1.406 | 1.3032 | 1.4232 | 1.3717 | 1.4575 | 1.5775 | 1.4419 |
| Min | .7442 | .7202 | .729 | .763 | .7888 | .9762 | .9259 |
| Avg | 1.0255 | 1.0249 | 1.0685 | 1.0795 | 1.0992 | 1.1906 | 1.1922 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 203 / 11 KV Industrial
Wanadongari Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7621 | .724 | 1.1431 | .724 | .8573 | .6668 | .724 |
| 2 | .7049 | .6859 | 1.105 | .6859 | .8192 | .6668 | .7621 |
| 3 | .6478 | .6859 | 1.0479 | .6859 | .7621 | .724 | .6668 |
| 4 | .5525 | .6859 | 1.0479 | .6668 | .724 | .7621 | .6668 |
| 5 | .6097 | .724 | .9526 | .724 | .7811 | .8002 | .6287 |
| 6 | .6478 | .7621 | .8002 | .7621 | .8383 | .724 | |
| 7 | .6668 | .7621 | .8573 | .8192 | .7621 | .8383 | .7049 |
| 8 | .7621 | .8192 | .8383 | .8764 | .8002 | .8383 | .8002 |
| 9 | .7811 | .724 | .7621 | 1.2955 | .724 | .9145 | .7811 |
| 10 | 1.0288 | .7621 | .9526 | 1.3336 | .743 | 1.0288 | .4954 |
| 11 | .9907 | .8192 | .9526 | 1.4098 | .8573 | 1.1431 | .5335 |
| 12 | .8573 | .8002 | .8764 | 1.1431 | .7621 | 1.2765 | .5525 |
| 13 | 1.0669 | .7811 | .9526 | 1.3717 | 1.0669 | 1.3717 | .5525 |
| 14 | 1.1431 | .6859 | 1.1812 | 1.2003 | 1.0288 | .9717 | .4763 |
| 15 | 1.1812 | .7621 | 1.105 | 1.2574 | .8383 | 1.5813 | .4763 |
| 16 | .8573 | .8573 | 1.1241 | 1.1431 | .9145 | 1.105 | .4572 |
| 17 | .8573 | .8002 | 1.105 | 1.2384 | 1.0288 | 1.2003 | .381 |
| 18 | .8002 | .6668 | 1.0288 | 1.1431 | .9526 | 1.2574 | .381 |
| 19 | .8383 | .7621 | .9907 | .8192 | .7811 | 1.1622 | |
| 20 | .8192 | .8002 | .8573 | .7811 | .8383 | .8192 | .5525 |
| 21 | .7811 | .8002 | .7621 | .743 | .743 | .8002 | .5525 |
| 22 | .7621 | .7811 | .7811 | .7049 | .743 | .7621 | .5716 |
| 23 | .7621 | .8573 | .7621 | .8573 | .7049 | .7811 | .5716 |
| 24 | .7621 | .724 | 1.1431 | .724 | .8764 | .7049 | .724 |
| Max | 1.1812 | .8573 | 1.1812 | 1.4098 | 1.0669 | 1.5813 | .8002 |
| Min | .5525 | .6668 | .7621 | .6668 | .7049 | .6668 | .381 |
| Avg | .8184 | .7597 | .9637 | .9629 | .8311 | .9542 | .5915 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 204 / 11 kV Sangam Ag Sep

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0551 | .048 | .0487 | .064 | .048 | .0652 | .064 |
| 2 | .0502 | .048 | .0489 | .064 | .048 | .0652 | .064 |
| 3 | .0518 | .048 | .0489 | .064 | .048 | .0652 | .048 |
| 4 | .064 | .048 | .0489 | .064 | .048 | .0652 | .048 |
| 5 | .0648 | .048 | .0489 | .048 | .048 | .0652 | .048 |
| 6 | .0486 | .048 | .0489 | .048 | .048 | .0652 | .048 |
| 7 | .0648 | .048 | .0487 | .048 | .048 | .0649 | .048 |
| 8 | .0819 | .176 | .1618 | .2401 | .3201 | .3235 | .3521 |
| 9 | .1147 | .2241 | .274 | .2881 | .4961 | .4529 | .5601 |
| 10 | .1311 | .2561 | .2901 | .3681 | .4961 | .4955 | .5921 |
| 11 | .128 | .1786 | .3041 | .2561 | .3868 | .4001 | .5182 |
| 12 | .144 | .211 | .3361 | | .4191 | .3041 | .5182 |
| 13 | .16 | .2273 | .3361 | .3841 | .4191 | .4641 | .5661 |
| 14 | .176 | .2597 | .3841 | .3521 | .4997 | .5281 | .5661 |
| 15 | .192 | .2435 | .3521 | .176 | .1612 | .4801 | .5708 |
| 16 | .048 | .0812 | .048 | .08 | .0487 | .064 | .0652 |
| 17 | .048 | .0812 | .064 | .08 | .0487 | .048 | .0652 |
| 18 | .048 | .0812 | .064 | .08 | .0649 | .08 | .0652 |
| 19 | .08 | .0812 | .064 | .064 | .0649 | .064 | .0815 |
| 20 | .064 | .0649 | .08 | .064 | .0812 | .064 | .0815 |
| 21 | .064 | .0649 | .064 | .064 | .0812 | .064 | .0652 |
| 22 | .064 | .0649 | .064 | .048 | .0812 | .064 | .0652 |
| 23 | .048 | .0487 | .064 | .048 | .0652 | .064 | .0652 |
| 24 | .0486 | .048 | .0487 | .064 | .048 | .0652 | |
| Max | .192 | .2597 | .3841 | .3841 | .4997 | .5281 | .5921 |
| Min | .048 | .048 | .048 | .048 | .048 | .048 | .048 |
| Avg | .0850 | .1137 | .1392 | .1329 | .1716 | .1867 | .2246 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 205 / 11 kV Amar/Rajiv Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4435 | .4805 | .543 | .5544 | .5731 | .6516 | .7682 |
| 2 | .4024 | .4435 | .543 | .5914 | .5373 | .6154 | .7316 |
| 3 | .4024 | .4435 | .543 | .5914 | .5014 | .5792 | .695 |
| 4 | .4207 | .5175 | .543 | .7023 | .5138 | .5792 | .695 |
| 5 | .5121 | .6468 | .6335 | .7392 | .5792 | .6805 | .7499 |
| 6 | .7499 | .7762 | .788 | .7392 | .6219 | .7522 | .8131 |
| 7 | | .8686 | .7973 | .7577 | .7762 | .8859 | .961 |
| 8 | .8775 | .8871 | .7973 | .8316 | .8686 | .8859 | .9795 |
| 9 | .8316 | .9055 | .8505 | .8501 | .9425 | .8328 | .8686 |
| 10 | .8316 | .8686 | .7398 | .8871 | .8871 | .8328 | .8316 |
| 11 | .7783 | .6878 | .7499 | .8779 | .8413 | .8048 | .7087 |
| 12 | .6838 | .6154 | .695 | .8413 | .7796 | .7602 | .6878 |
| 13 | .6024 | .543 | .6653 | .7421 | .7087 | .6878 | .6335 |
| 14 | .4908 | .5068 | .6219 | .6154 | .6201 | .6089 | .5973 |
| 15 | .4961 | .543 | .5853 | .6089 | .567 | .6268 | .6335 |
| 16 | .3696 | .543 | .5914 | .5731 | .6201 | .6268 | .6516 |
| 17 | .5304 | .5792 | .5853 | .591 | .6154 | .6697 | .6447 |
| 18 | .6283 | .6268 | .6838 | .6516 | .6556 | .7059 | .543 |
| 19 | .8871 | .7973 | .9145 | .9145 | .8764 | 1.0425 | .9214 |
| 20 | .8871 | .7973 | .8596 | .8779 | .9214 | 1.0059 | .9745 |
| 21 | .8316 | .7796 | .823 | .7964 | .9036 | .9694 | .9745 |
| 22 | .7392 | .7087 | .7682 | .7421 | .8688 | .9511 | .9412 |
| 23 | .5914 | .6335 | .7023 | .6805 | .7602 | .8688 | .8507 |
| 24 | .4755 | .5544 | .5249 | .6283 | .6089 | .6878 | .7865 |
| Max | .8871 | .9055 | .9145 | .9145 | .9425 | 1.0425 | .9795 |
| Min | .3696 | .4435 | .5249 | .5544 | .5014 | .5792 | .543 |
| Avg | .6288 | .6564 | .6895 | .7244 | .7145 | .7630 | .7768 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 206 / 11 kV Mahajanwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3658 | .3734 | .4145 | .4294 | .695 | .603 | .6468 |
| 2 | .3292 | .3361 | .3768 | .3734 | .5121 | .5653 | .6099 |
| 3 | .3292 | .3361 | .3768 | .3734 | .4706 | .5276 | .5914 |
| 4 | .3109 | .3734 | .3757 | .3734 | .4706 | .5276 | .5487 |
| 5 | .4024 | .4481 | .4884 | .4481 | .5121 | .603 | .6283 |
| 6 | .5544 | .5975 | .6575 | .5228 | .5544 | .6763 | .6908 |
| 7 | .6283 | .7095 | .7138 | .5975 | .6348 | .7702 | .7842 |
| 8 | .7023 | .056 | .7491 | .6535 | .7095 | .7326 | .7842 |
| 9 | .6283 | .6908 | | .6722 | .6908 | .7304 | .6722 |
| 10 | .6099 | .6348 | .5993 | .7023 | .6535 | .6742 | .6348 |
| 11 | .5359 | .5431 | .5359 | .7207 | .6555 | .5788 | .5431 |
| 12 | .6838 | .4682 | .5544 | .5975 | .5431 | .499 | .5618 |
| 13 | .4251 | .4307 | .4481 | .5359 | .5244 | .5175 | .5244 |
| 14 | .4066 | .412 | .4435 | .499 | .4869 | .4938 | .4869 |
| 15 | .3696 | .412 | .4066 | .4755 | .412 | .4755 | .526 |
| 16 | .2241 | .412 | .4066 | .439 | .4499 | .4938 | .526 |
| 17 | .3696 | .4682 | .3881 | .439 | .4495 | .499 | .526 |
| 18 | .5601 | .5431 | .4938 | .5914 | .5618 | .5914 | .5636 |
| 19 | .7842 | .6555 | .7392 | .823 | .8615 | .8686 | .7679 |
| 20 | .7655 | .6575 | .7762 | .7762 | .8641 | .8871 | .7866 |
| 21 | .6722 | .6575 | .7023 | .7392 | .8078 | .8402 | .8078 |
| 22 | .5975 | .6199 | .6468 | .7023 | .7514 | .7842 | .7514 |
| 23 | .4481 | .5276 | .5601 | .6283 | .6951 | .7023 | .6951 |
| 24 | .3841 | .4108 | .4334 | .4854 | .5853 | .6199 | .6468 |
| Max | .7842 | .7095 | .7762 | .823 | .8641 | .8871 | .8078 |
| Min | .2241 | .056 | .3757 | .3734 | .412 | .4755 | .4869 |
| Avg | .5036 | .4906 | .5342 | .5666 | .6063 | .6359 | .6377 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 207 / 11 kV Mohagaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1254 | .1494 | .1503 | .1494 | .1494 | .1879 | .1867 |
| 2 | .1267 | .1494 | .1503 | .168 | .1494 | .1879 | .1867 |
| 3 | .1267 | .168 | .1503 | .168 | .1307 | .1879 | .168 |
| 4 | .1086 | .168 | .1503 | .168 | .1307 | .1879 | .168 |
| 5 | .1086 | .168 | .1687 | .168 | .1494 | .1691 | .1867 |
| 6 | .1267 | .168 | .1691 | .1867 | .168 | .1687 | .1867 |
| 7 | .128 | .168 | .1686 | .1867 | .168 | .1687 | .1867 |
| 8 | .1991 | .2427 | .1873 | .1867 | .1867 | .2062 | .2054 |
| 9 | .3326 | .2614 | .2247 | .3921 | .3734 | .2247 | .2241 |
| 10 | .2715 | .5041 | .2622 | .4294 | .3734 | .2247 | .2427 |
| 11 | .2054 | .3749 | .3921 | .5041 | .3371 | .2427 | .2996 |
| 12 | .4294 | .3749 | .2801 | .3921 | .4495 | .2241 | .3746 |
| 13 | .4481 | .2812 | .2614 | .3361 | .3746 | .2241 | .3 |
| 14 | .2987 | .225 | .2054 | .3174 | .2809 | .2054 | .225 |
| 15 | .2054 | .225 | .2054 | .2614 | .225 | .1867 | .3749 |
| 16 | .3734 | .225 | .2801 | | .2437 | .2054 | .3937 |
| 17 | .3734 | .2625 | .4294 | .2614 | .2062 | .2241 | .3374 |
| 18 | .1867 | .3 | .1867 | .2614 | .2437 | .2054 | .3 |
| 19 | .2804 | .3 | .2987 | .3174 | .2996 | .2987 | .2622 |
| 20 | .2801 | .2625 | .2801 | .2614 | .3 | .2801 | .2437 |
| 21 | .2054 | .225 | .2241 | .2241 | .2437 | .2614 | .2062 |
| 22 | .1494 | .1879 | .168 | .1867 | .225 | .2241 | .1875 |
| 23 | .1494 | .1503 | .168 | .1494 | .1875 | .2054 | .1687 |
| 24 | .1086 | .1494 | .1315 | .1494 | .1494 | .1875 | .1867 |
| Max | .4481 | .5041 | .4294 | .5041 | .4495 | .2987 | .3937 |
| Min | .1086 | .1494 | .1315 | .1494 | .1307 | .1687 | .168 |
| Avg | .2228 | .2371 | .2205 | .2533 | .2394 | .2120 | .2417 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 208 / 11 kV Sangam

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .1494 | .1507 | .1867 | .1848 | .2077 | .2241 |
| 2 | .1294 | .1494 | .1507 | .1646 | .1848 | .1888 | .2241 |
| 3 | .1294 | .1494 | .1507 | .1663 | .1663 | .1888 | .1867 |
| 4 | .128 | .168 | .1507 | .1848 | .168 | .1886 | .1867 |
| 5 | .1463 | .168 | .1696 | .2012 | .1663 | .1886 | .2054 |
| 6 | .1629 | .1867 | .1884 | .2033 | .1848 | .2073 | .2241 |
| 7 | .181 | .1867 | .1884 | .2054 | .1991 | .2442 | .2402 |
| 8 | .1991 | .2241 | .2231 | .2241 | .2534 | .2603 | .2743 |
| 9 | .1991 | .2427 | .216 | .2801 | .2494 | .2789 | .2865 |
| 10 | .3077 | .2427 | .2672 | .3174 | .3012 | .2914 | .2658 |
| 11 | .2279 | .2266 | .2126 | .2865 | .285 | .3045 | .2521 |
| 12 | .2454 | .2266 | .2303 | .2122 | .2494 | .3045 | .2521 |
| 13 | .2054 | .1569 | .1949 | .1949 | .2316 | .2686 | .255 |
| 14 | .2033 | .1743 | .1949 | .2303 | .2323 | .2835 | .255 |
| 15 | .1848 | .2092 | .2126 | .2328 | .18 | .3012 | .2914 |
| 16 | .2103 | .2092 | .1949 | .2507 | .2365 | .3012 | .3347 |
| 17 | .2103 | .2138 | .2126 | .2149 | .2417 | .3077 | .2824 |
| 18 | .1753 | .2138 | .2303 | .2328 | .2045 | .2561 | .2824 |
| 19 | .3361 | .2494 | .3012 | .3292 | .2975 | .3475 | .3385 |
| 20 | .2454 | .2502 | .2835 | .2957 | .2824 | .2926 | .32 |
| 21 | .2103 | .2231 | .2481 | .2614 | .2812 | .2926 | .2824 |
| 22 | .1772 | .2045 | .2241 | .2241 | .2659 | .2561 | .2633 |
| 23 | .1448 | .1859 | .1848 | .1867 | .2279 | .2241 | .2257 |
| 24 | .1433 | .1494 | .1488 | .1867 | .1867 | .2079 | .2241 |
| Max | .3361 | .2502 | .3012 | .3292 | .3012 | .3475 | .3385 |
| Min | .128 | .1494 | .1488 | .1646 | .1663 | .1886 | .1867 |
| Avg | .1937 | .1983 | .2054 | .2280 | .2275 | .2580 | .2574 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 202 / 11 KV Issasani

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4251 | .4108 | .4572 | .5093 | .5415 | .6099 | .5906 |
| 2 | .3881 | .415 | .4191 | .4904 | .5093 | .5729 | .5716 |
| 3 | .3734 | .4481 | .381 | .4904 | .5093 | .5544 | .5716 |
| 4 | .4066 | .5093 | .362 | .5093 | .5281 | .499 | .6287 |
| 5 | .499 | .5228 | .4572 | .5093 | .5658 | .5914 | .6668 |
| 6 | .5914 | .5658 | .5906 | .547 | .6602 | .6838 | .724 |
| 7 | .7023 | .679 | .6859 | .6224 | .6979 | .7577 | .743 |
| 8 | .6468 | .7167 | .7049 | .7468 | .7167 | .7762 | .7621 |
| 9 | .6838 | .6979 | .6478 | .7167 | .7356 | .7577 | .743 |
| 10 | .6287 | .7049 | .7049 | | .743 | .6468 | .743 |
| 11 | .5906 | .6287 | .6478 | .6668 | .7049 | .6478 | .6859 |
| 12 | .2096 | .4954 | .5525 | .3048 | .6668 | .6287 | .5144 |
| 13 | .4572 | .4763 | .5144 | .6097 | .5716 | .5716 | .4763 |
| 14 | .4001 | .4572 | .4763 | .5716 | .5716 | .5525 | .6287 |
| 15 | .4191 | .4763 | .4954 | .5335 | .5906 | .5906 | .6478 |
| 16 | .362 | .4572 | .3239 | .5335 | .5716 | .5525 | .6478 |
| 17 | .4338 | .4763 | .5906 | .547 | .5525 | .6097 | .5716 |
| 18 | .4904 | .5716 | .6224 | .5281 | .5906 | .5716 | .6413 |
| 19 | .8215 | .8002 | .811 | .811 | .8501 | .8573 | .8865 |
| 20 | .7922 | .8002 | .7922 | .811 | .8501 | .8573 | .9054 |
| 21 | .7545 | | .7922 | .8299 | .8316 | .8954 | .9054 |
| 22 | .5788 | .6668 | .6908 | .7356 | .7762 | .8383 | .8676 |
| 23 | .4904 | .5525 | .6036 | .6413 | .6838 | .724 | .811 |
| 24 | .4435 | .4527 | .4954 | .5281 | .6036 | .6468 | .6287 |
| Max | .8215 | .8002 | .811 | .8299 | .8501 | .8954 | .9054 |
| Min | .2096 | .4108 | .3239 | .3048 | .5093 | .499 | .4763 |
| Avg | .5245 | .5644 | .5758 | .5997 | .6510 | .6664 | .6901 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 203 / 11 KV Bhimnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5359 | .5788 | .6668 | .6722 | .7356 | .8215 | .8954 |
| 2 | .499 | .5658 | .6287 | .6348 | .7167 | .7842 | .8764 |
| 3 | .462 | .547 | .6097 | .6036 | .724 | .7655 | .8573 |
| 4 | .5544 | .7167 | .5716 | .6602 | .7733 | .7468 | .9335 |
| 5 | .7842 | .8299 | .743 | .7922 | .8865 | .7762 | 1.0669 |
| 6 | 1.0903 | 1.0642 | 1.105 | .9054 | 1.094 | .8501 | 1.2384 |
| 7 | 1.0903 | 1.1317 | 1.1431 | 1.0374 | 1.094 | 1.0719 | 1.1812 |
| 8 | 1.1273 | 1.1506 | 1.1622 | 1.1506 | 1.094 | 1.0903 | 1.2003 |
| 9 | 1.0349 | 1.0562 | 1.086 | 1.0562 | 1.0751 | 1.0719 | 1.0669 |
| 10 | 1.0098 | 1.105 | 1.0479 | | .9907 | 1.0719 | 1.2193 |
| 11 | 1.0098 | 1.0479 | 1.0288 | .9335 | .9335 | 1.086 | 1.0669 |
| 12 | .8764 | .8954 | .9717 | .8954 | .8383 | .9717 | .9526 |
| 13 | .8002 | .8192 | .9145 | .743 | .8192 | .9335 | .9526 |
| 14 | .7049 | .8573 | .8383 | | .8192 | .9526 | .9526 |
| 15 | .743 | .8002 | .8383 | .7049 | .743 | .9717 | .9145 |
| 16 | .8954 | .8764 | .8954 | .7621 | .7811 | 1.0098 | 1.0669 |
| 17 | .8764 | .9145 | .2286 | .7922 | .8954 | .9335 | 1.0479 |
| 18 | .9054 | .9717 | .6979 | .8865 | 1.0098 | 1.0288 | 1.0751 |
| 19 | 1.2637 | 1.2574 | 1.2071 | 1.1694 | 1.2382 | 1.2955 | 1.3392 |
| 20 | 1.1883 | 1.2003 | 1.1694 | 1.1694 | 1.2382 | 1.2765 | 1.3014 |
| 21 | 1.0751 | 1.1241 | 1.094 | 1.0751 | 1.2012 | 1.2574 | 1.226 |
| 22 | .8962 | .9335 | .9619 | .9619 | 1.0534 | 1.1431 | 1.1506 |
| 23 | .7167 | .7811 | .811 | .8299 | .9149 | 1.0098 | 1.0374 |
| 24 | .5544 | .5847 | .7049 | .6979 | .7733 | .8775 | .9145 |
| Max | 1.2637 | 1.2574 | 1.2071 | 1.1694 | 1.2382 | 1.2955 | 1.3392 |
| Min | .462 | .547 | .2286 | .6036 | .7167 | .7468 | .8573 |
| Avg | .8623 | .9087 | .8802 | .8697 | .9351 | .9916 | 1.0639 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 201 / Dainik Bhaskar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4954 | .8383 | .724 | .7621 | .8764 | .8573 | .7621 |
| 2 | .5335 | .8192 | .7621 | .724 | .8192 | .8954 | .8002 |
| 3 | .4763 | .8192 | .8002 | .7621 | .8002 | .9145 | .8383 |
| 4 | .4954 | .8002 | .7049 | .7811 | .724 | .8764 | .724 |
| 5 | .5144 | .7621 | .7621 | .743 | .7049 | .8383 | .8002 |
| 6 | .4763 | .724 | .743 | .724 | .6859 | .7621 | .7621 |
| 7 | .4763 | .724 | .7621 | .7049 | .7049 | .8002 | .6859 |
| 8 | .5525 | .7621 | .6859 | .724 | .724 | .7811 | .6478 |
| 9 | .6478 | .7621 | .7811 | .8573 | .8383 | .9145 | .5525 |
| 10 | .8192 | 1.086 | 1.105 | .9717 | 1.086 | 1.0288 | .5906 |
| 11 | 1.105 | 1.1812 | 1.4289 | 1.1812 | 1.3146 | 1.3336 | .8002 |
| 12 | 1.1622 | 1.1241 | 1.2193 | 1.1812 | 1.2955 | 1.3336 | .7621 |
| 13 | 1.0288 | 1.086 | 1.1431 | 1.0479 | 1.2003 | 1.1622 | .7621 |
| 14 | 1.1622 | 1.3336 | 1.1812 | 1.1241 | 1.3146 | 1.467 | .8383 |
| 15 | 1.0669 | 1.2574 | 1.2955 | 1.2193 | 1.2574 | 1.3717 | .8764 |
| 16 | 1.2765 | 1.467 | 1.5242 | 1.1622 | 1.3336 | 1.4861 | .9145 |
| 17 | 1.3336 | 1.3527 | 1.5242 | 1.1241 | 1.3146 | 1.3717 | .8192 |
| 18 | 1.1431 | 1.5051 | 1.3146 | 1.0479 | 1.1622 | | .8383 |
| 19 | 1.0669 | 1.105 | 1.2003 | .7811 | 1.0669 | 1.1812 | .7811 |
| 20 | .8383 | .8573 | .9907 | .743 | .9335 | 1.0288 | .6859 |
| 21 | .7811 | .7621 | .8954 | .743 | .8573 | .8573 | .6859 |
| 22 | .7049 | | .8002 | .7621 | .8764 | 1.0479 | .5716 |
| 23 | .724 | .7811 | .8192 | .8002 | 1.0288 | | .5525 |
| 24 | .4572 | .8002 | .6859 | .8002 | .8954 | .8573 | 1.0288 |
| Max | 1.3336 | 1.5051 | 1.5242 | 1.2193 | 1.3336 | 1.4861 | 1.0288 |
| Min | .4572 | .724 | .6859 | .7049 | .6859 | .7621 | .5525 |
| Avg | .8057 | .9874 | .9939 | .8947 | .9923 | 1.0530 | .7534 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 202 / 11 kV RC PLASTO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.0576 | 1.9433 | 2.1338 | 2.0957 | 2.0576 | 1.9052 | 2.3053 |
| 2 | 2.1338 | 1.9052 | | 2.1338 | 2.1338 | 1.9433 | 2.2862 |
| 3 | 2.21 | 2.0195 | 2.0576 | 2.21 | 2.0195 | 2.0195 | 2.2291 |
| 4 | 2.21 | 2.1338 | 2.0957 | 2.0957 | 2.0957 | 2.0576 | 2.1719 |
| 5 | 2.1338 | 2.1338 | 2.0005 | 2.0576 | 2.0576 | 1.8671 | 2.1338 |
| 6 | 1.9052 | 2.1719 | 1.9433 | 2.0576 | 1.9052 | 1.9052 | 2.0576 |
| 7 | 2.1338 | 2.21 | 1.9814 | 1.9814 | 1.9433 | 2.0576 | 2.0386 |
| 8 | 2.21 | 2.0576 | 2.0005 | 2.0576 | 2.0005 | 1.5242 | 2.2862 |
| 9 | 2.0576 | 2.2862 | 2.21 | 2.0957 | 2.1338 | 2.0005 | 1.9814 |
| 10 | 2.2862 | 2.2481 | 2.1338 | 2.0957 | 2.0576 | 2.21 | 2.21 |
| 11 | 2.3243 | 2.1338 | 2.1719 | 1.9814 | 2.0576 | 2.2862 | 1.9052 |
| 12 | 2.1338 | 2.3624 | 1.9814 | 2.0576 | 1.9814 | 2.21 | 2.21 |
| 13 | 2.21 | 2.21 | 1.6004 | 1.7528 | 2.21 | 1.6004 | 1.9052 |
| 14 | 2.191 | 2.21 | 2.0576 | 1.9814 | 2.2862 | 1.7528 | 2.0957 |
| 15 | 2.2291 | 2.0957 | 1.829 | 1.9433 | 1.6004 | 1.9814 | 2.2862 |
| 16 | 2.1338 | 2.2481 | 2.2862 | 1.9814 | 1.9814 | 2.21 | 2.0957 |
| 17 | 1.9052 | | 2.3624 | 2.1338 | 2.0576 | 2.21 | 2.2862 |
| 18 | 2.21 | 2.3434 | 2.21 | 2.0576 | 2.0195 | | 2.0957 |
| 19 | 2.191 | 2.0957 | 1.9814 | 2.2862 | 2.21 | 2.2291 | 2.1338 |
| 20 | 2.21 | 2.191 | 1.8671 | 2.0576 | 2.2481 | 2.0195 | 1.9814 |
| 21 | 1.9814 | 2.21 | 2.21 | 2.0957 | 2.0576 | 2.3243 | 2.2862 |
| 22 | 2.3243 | | 2.21 | 2.2481 | 2.0767 | 2.2862 | 2.21 |
| 23 | 2.2862 | 2.21 | 2.0576 | 2.0957 | 1.9052 | .6668 | 2.1719 |
| 24 | 1.829 | 2.0576 | 2.0767 | 2.1338 | 1.9052 | 1.9243 | 2.0767 |
| Max | 2.3243 | 2.3624 | 2.3624 | 2.2862 | 2.2862 | 2.3243 | 2.3053 |
| Min | 1.829 | 1.9052 | 1.6004 | 1.7528 | 1.6004 | .6668 | 1.9052 |
| Avg | 2.1457 | 2.1581 | 2.0634 | 2.0703 | 2.0417 | 1.9648 | 2.1433 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonagoan S/Stn

Feeder No / Name : 203 / 11KV Rukmini Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6097 | .7621 | .9526 | .8383 | .8383 | .6097 | .724 |
| 2 | .6287 | .8383 | .9145 | .9145 | .8573 | .6859 | .7621 |
| 3 | .6097 | .8573 | .9717 | .8573 | .8192 | .7621 | .6668 |
| 4 | .5716 | .8383 | .8954 | .8764 | .7621 | .8002 | .6859 |
| 5 | .5906 | .8002 | .8573 | .8002 | .6668 | .7621 | .6478 |
| 6 | .6478 | .8002 | .8383 | .724 | .6097 | .724 | .6287 |
| 7 | .6859 | .724 | .8573 | .6668 | .5335 | .7049 | .5335 |
| 8 | .724 | .8383 | .7621 | .743 | .5906 | .9335 | .5335 |
| 9 | .9335 | 1.3527 | 1.7337 | 1.086 | 1.5242 | 1.086 | .5144 |
| 10 | 1.1812 | 1.6956 | 1.3717 | 1.5623 | 1.8671 | 2.553 | .4763 |
| 11 | 2.0576 | 1.3717 | 2.4387 | 1.2955 | 1.2003 | 1.448 | .5335 |
| 12 | 1.3908 | 1.7147 | 1.2955 | 1.5623 | 1.2955 | 1.5242 | .5335 |
| 13 | 2.3243 | 1.829 | 1.7528 | 1.2193 | 1.2193 | 1.4098 | .5525 |
| 14 | 2.21 | 1.6194 | 1.9814 | 1.7337 | 1.5623 | 1.467 | .5144 |
| 15 | 1.4289 | 1.5432 | 2.191 | 1.6194 | 1.6575 | 1.5432 | .5525 |
| 16 | 1.3717 | 1.6385 | 1.829 | 2.2481 | 1.3717 | 2.0576 | .5906 |
| 17 | 1.7909 | 1.2765 | 2.2481 | 2.0195 | 1.2003 | 1.7147 | .5716 |
| 18 | 1.2574 | 2.0957 | 2.5339 | 2.3815 | 1.086 | | .5716 |
| 19 | .9145 | 1.1812 | 1.9624 | .8573 | .9907 | .9526 | .5716 |
| 20 | .8383 | .8192 | .6668 | .6097 | .6859 | .8383 | .5525 |
| 21 | .7621 | .6859 | .6287 | .5716 | .6859 | .6668 | .5335 |
| 22 | .8383 | | .743 | .743 | .6859 | .7621 | .6097 |
| 23 | .8002 | .8192 | .8764 | .8192 | .6668 | | .6668 |
| 24 | .5716 | .724 | .8954 | .8573 | .8573 | .5716 | .6668 |
| Max | 2.3243 | 2.0957 | 2.5339 | 2.3815 | 1.8671 | 2.553 | .7621 |
| Min | .5716 | .6859 | .6287 | .5716 | .5335 | .5716 | .4763 |
| Avg | 1.0725 | 1.1663 | 1.3416 | 1.1503 | 1.0098 | 1.1172 | .5914 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 200 / Station T/F

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | .1715 | .1715 | .1715 |
| 16 | .1715 | .1715 | | | |
| Max | .1715 | .1715 | .1715 | .1715 | .1715 |
| Min | .1715 | .1715 | .1715 | .1715 | .1715 |
| Avg | .1715 | .1715 | .1715 | .1715 | .1715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL-II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | 1.2003 | 1.2003 | 1.2003 |
| 16 | 1.2003 | 1.2003 | | | |
| Max | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| Min | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| Avg | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 209 / 11 KV MANKAPUR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | .8573 | .8573 | .8573 |
| 16 | .8573 | .8573 | | | |
| Max | .8573 | .8573 | .8573 | .8573 | .8573 |
| Min | .8573 | .8573 | .8573 | .8573 | .8573 |
| Avg | .8573 | .8573 | .8573 | .8573 | .8573 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 210 / 11 KV HINGNA-I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | 1.2003 | 1.2003 | 1.2003 |
| 16 | 1.2003 | 1.2003 | | | |
| Max | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| Min | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| Avg | 1.2003 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 211 / 11 KV HINGNA-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | 2.3148 | 2.3148 | 2.3148 |
| 16 | 2.3148 | 2.3148 | | | |
| Max | 2.3148 | 2.3148 | 2.3148 | 2.3148 | 2.3148 |
| Min | 2.3148 | 2.3148 | 2.3148 | 2.3148 | 2.3148 |
| Avg | 2.3148 | 2.3148 | 2.3148 | 2.3148 | 2.3148 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 214 / 11 kv Urban-II

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | .5144 | .5144 | .5144 |
| 16 | .5144 | .5144 | | | |
| Max | .5144 | .5144 | .5144 | .5144 | .5144 |
| Min | .5144 | .5144 | .5144 | .5144 | .5144 |
| Avg | .5144 | .5144 | .5144 | .5144 | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 216 / 11 KV INDUSTRIAL-I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | 1.5432 | 1.5432 | 1.5432 |
| 16 | 1.5432 | 1.5432 | | | |
| Max | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |
| Min | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |
| Avg | 1.5432 | 1.5432 | 1.5432 | 1.5432 | 1.5432 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 217 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | .5144 | .5144 | .5144 |
| 16 | .5144 | .5144 | | | |
| Max | .5144 | .5144 | .5144 | .5144 | .5144 |
| Min | .5144 | .5144 | .5144 | .5144 | .5144 |
| Avg | .5144 | .5144 | .5144 | .5144 | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 219 / 11 KV ABC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 15 | | | .6859 | .6859 | .6859 |
| 16 | .6859 | .6859 | | | |
| Max | .6859 | .6859 | .6859 | .6859 | .6859 |
| Min | .6859 | .6859 | .6859 | .6859 | .6859 |
| Avg | .6859 | .6859 | .6859 | .6859 | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 201 / Suvarna Laghu Udyog(SLU)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .724 | 1.6004 | 1.5432 | 1.6385 | 1.5242 | .1372 | 1.3527 |
| 2 | .7621 | 1.4861 | 1.5242 | 1.6766 | 1.4861 | .1334 | 1.2384 |
| 3 | .743 | 1.5432 | 1.5242 | 1.7147 | 1.4098 | .1296 | 1.2003 |
| 4 | .7811 | 1.4098 | 1.5051 | 1.6194 | 1.5242 | .1429 | 1.0479 |
| 5 | .7621 | 1.3527 | 1.5432 | 1.6575 | 1.4861 | .1524 | 1.0098 |
| 6 | .8573 | 1.3908 | 1.5432 | 1.5623 | 1.3336 | .1543 | .9717 |
| 7 | 1.086 | 1.4098 | 1.3717 | 1.6194 | 1.2384 | .1372 | .9526 |
| 8 | 1.4289 | 1.7337 | 1.8861 | 1.6956 | 1.5623 | .1372 | .7049 |
| 9 | 1.8861 | 1.8861 | 1.8861 | 1.7718 | 1.7718 | 2.0165 | .5716 |
| 10 | 1.448 | 1.587 | 2.0386 | 1.829 | 1.6194 | 2.0195 | .4954 |
| 11 | 1.7528 | 2.0576 | 2.0195 | 1.9243 | .2058 | 1.9624 | .4954 |
| 12 | 1.829 | 1.7147 | 1.9243 | 1.8671 | .1276 | 1.9243 | .0514 |
| 13 | 1.8671 | 1.8099 | 1.7909 | 1.7909 | .1334 | 1.8671 | .0514 |
| 14 | 1.829 | 1.7147 | 1.6956 | 1.6766 | .1543 | 1.7528 | .0514 |
| 15 | 1.6956 | 1.5432 | 1.848 | 1.5242 | .1543 | 1.8099 | .0495 |
| 16 | 1.848 | 1.8861 | 1.9624 | 1.9052 | .1867 | 1.8671 | .0495 |
| 17 | 1.8671 | 1.7909 | 2.0195 | 1.5813 | .1715 | 1.7718 | .0533 |
| 18 | 1.829 | 1.8861 | 1.9243 | 1.7337 | .1886 | 1.7718 | .0572 |
| 19 | 1.467 | 1.8099 | 1.7909 | 1.6766 | .1257 | 1.6194 | .0553 |
| 20 | 1.6194 | 1.7337 | 1.6956 | 1.5813 | .1372 | 1.9243 | .0572 |
| 21 | 1.3146 | 1.7147 | 1.5623 | 1.3717 | .1372 | 1.8671 | .0591 |
| 22 | 1.2765 | 1.6004 | 1.5432 | 1.3908 | .1315 | 1.8099 | .0762 |
| 23 | 1.3527 | 1.5432 | 1.6194 | 1.2955 | .1429 | 1.4098 | .1048 |
| 24 | .743 | 1.6575 | 1.5432 | 1.5623 | 1.3908 | .1486 | 1.3527 |
| Max | 1.8861 | 2.0576 | 2.0386 | 1.9243 | 1.7718 | 2.0195 | 1.3527 |
| Min | .724 | 1.3527 | 1.3717 | 1.2955 | .1257 | .1296 | .0495 |
| Avg | 1.3654 | 1.6609 | 1.7210 | 1.6528 | .7643 | 1.1944 | .5046 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 202 / Berar Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3239 | .3048 | .362 | .381 | 1.2003 | .0533 | 1.2955 |
| 2 | .3048 | .3239 | .3429 | .5716 | .9907 | .0743 | 1.1622 |
| 3 | .2858 | .2667 | .3429 | .7621 | .724 | .0781 | 1.2765 |
| 4 | .3048 | .2858 | .3429 | .8573 | .8573 | .0533 | 1.3146 |
| 5 | .3239 | .362 | .3429 | .6668 | | .0495 | 1.3336 |
| 6 | .3429 | .3429 | .3429 | .5716 | .6097 | .0343 | .381 |
| 7 | .3048 | .362 | .3429 | .6668 | .6859 | .0343 | .381 |
| 8 | .3429 | .3429 | 1.5432 | 1.2003 | 1.5432 | .1543 | .4382 |
| 9 | .2286 | .3429 | 1.5432 | 1.105 | 1.3146 | 1.3443 | .4382 |
| 10 | .4001 | .3921 | 1.6385 | 1.0098 | 1.1622 | 1.2955 | .4382 |
| 11 | .8002 | .9145 | 1.4289 | 1.3336 | .2058 | 1.1431 | .04 |
| 12 | .7621 | .8573 | .8573 | .9717 | .0686 | 1.086 | .0419 |
| 13 | .6859 | .7811 | .724 | .5525 | .0686 | .9526 | .0343 |
| 14 | .8954 | .6859 | .6287 | 1.9052 | .0629 | 1.1241 | .0343 |
| 15 | .362 | .4001 | .5335 | .724 | .0781 | .743 | .0362 |
| 16 | .2858 | .3429 | .4572 | .4001 | .0533 | .4572 | .0362 |
| 17 | .3429 | .3429 | .4382 | .5716 | .0419 | .4382 | .0419 |
| 18 | .3048 | .3429 | .4382 | .4191 | .0514 | .4382 | .0362 |
| 19 | .2477 | .3429 | .3239 | .4572 | .0457 | .4382 | .0343 |
| 20 | .3239 | .3429 | .2858 | .4382 | .0324 | .4001 | .0267 |
| 21 | .2667 | .3429 | .2477 | .4763 | .04 | .2858 | .0305 |
| 22 | .3048 | .3429 | .381 | .4001 | .0305 | .3048 | .0362 |
| 23 | .2667 | .362 | .4191 | .381 | .0286 | 1.448 | .0343 |
| 24 | .3048 | .3429 | .362 | .362 | .9145 | .0286 | 1.3336 |
| Max | .8954 | .9145 | 1.6385 | 1.9052 | 1.5432 | 1.448 | 1.3336 |
| Min | .2286 | .2667 | .2477 | .362 | .0286 | .0286 | .0267 |
| Avg | .3882 | .4196 | .6112 | .7160 | .4700 | .5191 | .4273 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 203 / Varsha feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6668 | .8573 | .7049 | .8002 | .8573 | .0781 | .8192 |
| 2 | .6859 | .8002 | .7049 | .7621 | .7621 | .0705 | .8192 |
| 3 | .6668 | .7621 | .7049 | .724 | .724 | .0743 | .8192 |
| 4 | .6859 | .7621 | .6859 | .6668 | .7621 | .0781 | .8002 |
| 5 | .7049 | .724 | .6859 | .724 | .7049 | .0705 | .7811 |
| 6 | .724 | .7621 | .6859 | .7621 | .7811 | .0762 | .7811 |
| 7 | .7621 | .8192 | .8573 | .8002 | .8383 | .0762 | .8002 |
| 8 | .743 | .8764 | .8573 | .8764 | .8002 | .0857 | .6287 |
| 9 | .7811 | .8573 | .8573 | 1.0479 | .8954 | .8402 | .5906 |
| 10 | 1.1431 | 1.1016 | 1.0479 | 1.2003 | 1.0669 | .8954 | .6097 |
| 11 | .9907 | 1.0288 | 1.0669 | 1.2193 | .12 | .9717 | .0572 |
| 12 | 1.0098 | | 1.0479 | 1.1812 | .1029 | 1.0288 | .061 |
| 13 | .9907 | | 1.086 | 1.1622 | .1029 | 1.0669 | .0629 |
| 14 | 1.0479 | | 1.105 | 1.086 | .12 | 1.2193 | .0629 |
| 15 | 1.086 | | 1.0669 | 1.1241 | .1029 | 1.1431 | .6097 |
| 16 | 1.0288 | | 1.086 | 1.1622 | .1029 | 1.0098 | .061 |
| 17 | 1.1431 | | 1.086 | 1.1431 | .1029 | .9907 | .0705 |
| 18 | .9335 | | .9526 | .9907 | .0857 | .9907 | .0686 |
| 19 | .9907 | .9526 | .9145 | .9335 | .0934 | .9335 | .0686 |
| 20 | .8573 | .8954 | .8383 | .8192 | .0857 | .8954 | .0648 |
| 21 | .8383 | .7621 | .8192 | .8573 | .0762 | .8383 | .0629 |
| 22 | .8573 | .7621 | .8764 | .7811 | .0781 | .8002 | .0648 |
| 23 | .8764 | .724 | .8573 | .743 | .0781 | .7811 | .0648 |
| 24 | .6478 | .7621 | .7049 | .8383 | .7811 | .0724 | .7811 |
| Max | 1.1431 | 1.1016 | 1.105 | 1.2193 | 1.0669 | 1.2193 | .8192 |
| Min | .6478 | .724 | .6859 | .6668 | .0762 | .0705 | .0572 |
| Avg | .8692 | .8358 | .8875 | .9336 | .4260 | .6286 | .4004 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 204 / SANVIJAY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .5716 | .5716 | .7621 | .5525 | .061 | .6287 |
| 2 | .381 | .5335 | .5716 | .724 | .5144 | .061 | .6287 |
| 3 | .362 | .5335 | .5525 | .743 | .4572 | .0572 | .6097 |
| 4 | .4191 | .5525 | .4763 | .6859 | .4382 | .0591 | .5906 |
| 5 | .4572 | .5144 | .4572 | .6668 | .4191 | .0553 | .5716 |
| 6 | .4954 | .5906 | .4382 | .6478 | .4954 | .0514 | .5525 |
| 7 | .5335 | .6859 | .5144 | .6097 | .5335 | .0514 | .5525 |
| 8 | .5335 | .7811 | .5144 | .5906 | .6287 | .0686 | .4572 |
| 9 | .6478 | .6859 | .6859 | .724 | .6668 | .7468 | .0438 |
| 10 | 1.086 | 1.0082 | .8954 | .8192 | .8954 | .7621 | .0438 |
| 11 | .8764 | .8573 | .7621 | .743 | .0762 | .7049 | .0457 |
| 12 | .8573 | .9335 | .7811 | .7049 | .0686 | .6668 | .0457 |
| 13 | .8192 | .6859 | .8002 | .6287 | .0743 | .6097 | .0438 |
| 14 | .9907 | 1.0288 | .8002 | .9145 | .08 | 1.0098 | .0457 |
| 15 | .7811 | .7811 | .8192 | .6668 | .0762 | .9526 | .0419 |
| 16 | .9907 | .9335 | .8573 | .8764 | .0686 | .8954 | .0438 |
| 17 | .9526 | .9335 | .8383 | .8002 | .0857 | .9335 | .0476 |
| 18 | .9907 | .8573 | .8192 | .9145 | .0857 | .9526 | .0457 |
| 19 | 1.0288 | .8002 | .8383 | .8002 | .0743 | .8764 | .0457 |
| 20 | .7811 | .724 | .7621 | .6859 | .0667 | .7621 | .04 |
| 21 | .6859 | .6097 | .6478 | .6668 | .0514 | .5906 | .0305 |
| 22 | .743 | .6097 | .8002 | .6859 | .0591 | .5716 | .0305 |
| 23 | .724 | .6097 | .7811 | .7049 | .0705 | .6859 | .0324 |
| 24 | .362 | .5906 | .6097 | .8002 | .5716 | .0667 | .6097 |
| Max | 1.086 | 1.0288 | .8954 | .9145 | .8954 | 1.0098 | .6287 |
| Min | .3429 | .5144 | .4382 | .5906 | .0514 | .0514 | .0305 |
| Avg | .7017 | .7255 | .6914 | .7319 | .2963 | .5105 | .2428 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 205 / CANDICO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0479 | 1.3717 | 1.6004 | 1.6194 | 1.5432 | .1372 | 1.448 |
| 2 | 1.0669 | 1.3336 | 1.6004 | 1.5623 | 1.4861 | .1372 | 1.3908 |
| 3 | .9907 | 1.3908 | 1.5813 | 1.6385 | 1.4289 | .1391 | 1.3336 |
| 4 | 1.0479 | 1.3717 | 1.5432 | 1.6766 | 1.5051 | .1372 | 1.2574 |
| 5 | 1.105 | 1.3908 | 1.5432 | 1.6004 | 1.3717 | .1353 | 1.2765 |
| 6 | 1.1431 | 1.3527 | 1.6004 | 1.6385 | 1.4098 | .1372 | 1.2574 |
| 7 | 1.2003 | | 1.5432 | 1.5623 | 1.4098 | .1372 | 1.2574 |
| 8 | 1.5623 | 1.5432 | 1.8861 | 1.7528 | 1.7337 | .1715 | 1.1812 |
| 9 | 1.9243 | 2.0576 | 2.4006 | 2.2862 | 2.1719 | 1.9418 | 1.2003 |
| 10 | 2.553 | 2.8193 | 2.9721 | 2.553 | 2.7244 | 2.0957 | 1.2003 |
| 11 | 2.8959 | 3.0864 | 2.9912 | 2.7054 | .3258 | 2.2672 | .0972 |
| 12 | 2.8197 | 3.5437 | 3.0674 | 2.4768 | .3715 | 2.7625 | .0857 |
| 13 | 2.1529 | 2.572 | 3.1055 | 2.2672 | .3315 | 2.934 | |
| 14 | 2.6673 | 3.0864 | 3.1245 | 2.7244 | .2972 | 3.296 | |
| 15 | 2.8959 | 3.1817 | 3.2769 | 2.553 | .3201 | 3.2579 | |
| 16 | 3.315 | 3.2579 | 3.2198 | 2.8197 | .3639 | 3.2388 | |
| 17 | 2.9912 | 3.2579 | 3.1436 | 2.9531 | .2915 | 3.1817 | .0857 |
| 18 | 2.9531 | 3.0864 | 3.0674 | 2.8769 | .2782 | 3.0674 | .0876 |
| 19 | 2.6673 | 3.0483 | 2.6292 | 2.3243 | .2229 | 2.4768 | .0991 |
| 20 | 2.1148 | 2.0957 | 2.1529 | 1.829 | .1924 | 2.0957 | .0991 |
| 21 | 1.8099 | 1.6575 | 1.6766 | 1.5623 | .1543 | 1.7337 | .1067 |
| 22 | 1.5623 | 1.6194 | 1.5623 | 1.5242 | .1467 | 1.7337 | .1029 |
| 23 | 1.4861 | 1.5242 | 1.6194 | 1.5623 | .1429 | 1.4861 | .1086 |
| 24 | 1.0288 | 1.3908 | 1.6385 | 1.6385 | 1.5051 | .1391 | 1.5242 |
| Max | 3.315 | 3.5437 | 3.2769 | 2.9531 | 2.7244 | 3.296 | 1.5242 |
| Min | .9907 | 1.3336 | 1.5432 | 1.5242 | .1429 | .1353 | .0857 |
| Avg | 1.9584 | 2.2191 | 2.2728 | 2.0711 | .9054 | 1.6183 | .7600 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 201 / 11 KV APEX

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4031 | .3077 | .5068 | .362 | .4557 | .6516 | .4887 |
| 2 | .4031 | .3077 | .543 | .362 | .4557 | .6584 | .4887 |
| 3 | .3856 | .3077 | .5792 | .362 | .4382 | .6878 | .4887 |
| 4 | .3856 | .3077 | .6219 | .3439 | .4207 | .6878 | .4706 |
| 5 | .3856 | .3077 | .5068 | .3439 | .4207 | .724 | .4706 |
| 6 | .3506 | .3361 | .4706 | .3439 | .3856 | .724 | .4706 |
| 7 | .4207 | .3439 | .5068 | | .3506 | .5068 | |
| 8 | .333 | .3439 | .5249 | .3801 | .3155 | .3801 | .3801 |
| 9 | .2804 | .4163 | .543 | .5068 | .3856 | .3801 | .3258 |
| 10 | .4908 | .4887 | .5792 | .5249 | .3155 | .4163 | .3292 |
| 11 | .5068 | .4887 | .5611 | 1.1218 | .362 | .4163 | .3292 |
| 12 | .4706 | .4887 | .543 | 1.0516 | .3801 | .4344 | .3292 |
| 13 | .5249 | .5249 | .543 | .5258 | .3801 | .4344 | .3582 |
| 14 | .5249 | .543 | .5249 | .4908 | .3801 | .4525 | .3582 |
| 15 | .5611 | | .5249 | .4557 | .362 | .4525 | .4024 |
| 16 | .543 | .5973 | .5249 | | .362 | .3982 | .3658 |
| 17 | .5249 | .567 | .5249 | .3856 | .3982 | .3982 | .3292 |
| 18 | .5249 | .5487 | .5068 | .3506 | .3982 | .362 | .3292 |
| 19 | .4706 | .5249 | .4525 | .4207 | .362 | .4706 | .3658 |
| 20 | .3077 | .4887 | .3077 | .4557 | .362 | .4887 | .439 |
| 21 | .3077 | .4887 | .3801 | .4557 | .4706 | .4887 | .4024 |
| 22 | .3077 | .4887 | .3801 | .4557 | .543 | .4887 | .4024 |
| 23 | .3077 | .4706 | .3801 | .4382 | .5792 | .4887 | .4024 |
| 24 | .4207 | .3077 | .5121 | .362 | .4557 | .6154 | .4887 |
| Max | .5611 | .5973 | .6219 | 1.1218 | .5792 | .724 | .4887 |
| Min | .2804 | .3077 | .3077 | .3439 | .3155 | .362 | .3258 |
| Avg | .4226 | .4346 | .5020 | .4772 | .4058 | .5086 | .4007 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 202 / 11 KV BAZARGAON PAPER MILL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9602 | .9214 | 1.0136 | .4784 | .9945 | .9877 | 1.0277 |
| 2 | .9259 | .9391 | 1.0136 | .4784 | 1.0288 | 1.0136 | 1.0277 |
| 3 | .9602 | .9391 | 1.0498 | .4607 | 1.0631 | 1.0136 | 1.0454 |
| 4 | .9259 | .9568 | 1.0974 | .4607 | 1.0288 | 1.0498 | 1.0454 |
| 5 | .8573 | .9568 | 1.0136 | .8859 | .9945 | 1.086 | 1.0631 |
| 6 | .823 | .9745 | .9231 | 1.0454 | 1.0288 | 1.1222 | 1.0631 |
| 7 | | .7442 | .905 | | 1.0288 | .6516 | |
| 8 | .9259 | .6733 | .8688 | .8505 | .9945 | 1.0317 | .8328 |
| 9 | .9602 | .8859 | 1.0608 | .8505 | .8573 | .9774 | .8328 |
| 10 | .823 | 1.0099 | 1.1222 | .8505 | 1.0974 | .905 | .815 |
| 11 | .8328 | .9511 | 1.0631 | .8573 | 1.0498 | .8859 | .924 |
| 12 | .7973 | .8779 | 1.0277 | .823 | .9328 | .8505 | .8871 |
| 13 | .8505 | .905 | .9214 | .8573 | .9231 | .815 | .8501 |
| 14 | 1.0099 | .9231 | .8505 | .9259 | .905 | .815 | .8871 |
| 15 | .9922 | 1.0498 | .7087 | .9602 | 1.1222 | .9391 | .8871 |
| 16 | .9745 | 1.086 | | 1.0288 | 1.1946 | 1.0985 | .924 |
| 17 | .8859 | .9412 | .2658 | 1.0288 | 1.1706 | 1.0808 | .8871 |
| 18 | .8682 | .8869 | .2481 | .9945 | 1.0791 | 1.0631 | .8501 |
| 19 | .8328 | .9412 | .2658 | .8916 | 1.0679 | 1.0631 | .924 |
| 20 | .8328 | .9955 | .3012 | .7888 | 1.0425 | 1.0631 | 1.1458 |
| 21 | .815 | 1.0059 | .2658 | .7888 | .9511 | 1.0277 | 1.1088 |
| 22 | .7973 | .9774 | .2481 | .7545 | .8145 | 1.0277 | 1.0719 |
| 23 | .815 | .9774 | .2835 | 1.0631 | .7964 | .9922 | 1.0349 |
| 24 | | .8328 | 1.0242 | .2835 | 1.0288 | .9412 | 1.0099 |
| Max | 1.0099 | 1.086 | 1.1222 | 1.0631 | 1.1946 | 1.1222 | 1.1458 |
| Min | .7973 | .6733 | .2481 | .2835 | .7964 | .6516 | .815 |
| Avg | .8848 | .9313 | .7627 | .8003 | 1.0081 | .9792 | .9628 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 203 / 11 KV UMBARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | | | .2534 | | | | |
| 7 | | .3467 | .5068 | | | | |
| 8 | | .3467 | .5792 | .5201 | | | |
| 9 | | .3814 | .6219 | .4161 | | | |
| 10 | | .4161 | .5792 | .4854 | | | |
| 11 | | .439 | .5895 | .5487 | | | |
| 12 | | .4344 | .6068 | .5487 | | | |
| 13 | | .5068 | .5548 | .5144 | | | |
| 14 | | .4887 | .5375 | .5487 | .3292 | | |
| 15 | .3988 | | | | .6516 | .6241 | .7522 |
| 16 | .4334 | | | | .724 | .6935 | .8954 |
| 17 | .4161 | | | | .6516 | .6241 | .8413 |
| 18 | .3988 | | | | .5792 | .6068 | .6584 |
| 19 | .3988 | | | | .5068 | .5721 | .6447 |
| 20 | .3988 | | | | .4525 | .5721 | .6089 |
| 21 | .3467 | | | | .4163 | .5721 | .6089 |
| 22 | .3121 | | | | .3801 | .5028 | .5731 |
| Max | .4334 | .5068 | .6219 | .5487 | .724 | .6935 | .8954 |
| Min | .3121 | .3467 | .2534 | .4161 | .3292 | .5028 | .5731 |
| Avg | .3879 | .4200 | .5366 | .5117 | .5213 | .5960 | .6979 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 204 / 11KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | | | .2378 | | | | |
| 7 | | .2427 | .2743 | | | | |
| 8 | | .2947 | .3292 | .4161 | | | |
| 9 | | .3467 | .5304 | .5201 | | | |
| 10 | | .3814 | .6219 | .6241 | | | |
| 11 | | .4024 | .5895 | .583 | | | |
| 12 | | .3658 | .5895 | .6173 | | | |
| 13 | | .3292 | .4854 | .6173 | | | |
| 14 | | .2926 | .2254 | .6516 | .2378 | | |
| 15 | .3121 | .2926 | | | .8048 | .6241 | .5487 |
| 16 | .3294 | | | | .7682 | .7282 | .6401 |
| 17 | .3294 | | | | .695 | .6935 | .6859 |
| 18 | .3294 | | | | .5853 | .4508 | .583 |
| 19 | .3294 | | | | .5121 | .3467 | .5144 |
| 20 | .3467 | | | | .4207 | .3294 | .4115 |
| 21 | .2947 | | | | .3841 | .2947 | .4115 |
| 22 | .2774 | | | | .3841 | .2774 | .3772 |
| Max | .3467 | .4024 | .6219 | .6516 | .8048 | .7282 | .6859 |
| Min | .2774 | .2427 | .2254 | .4161 | .2378 | .2774 | .3772 |
| Avg | .3186 | .3276 | .4315 | .5756 | .5325 | .4681 | .5215 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 205 / 11KV KONDALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2804 | .2801 | .2534 | .2801 | .2454 | .3077 | .2987 |
| 2 | .2629 | .2801 | .2561 | .2801 | .2454 | .2743 | .2987 |
| 3 | .2629 | .2614 | .2561 | .2801 | .2454 | .2534 | .2801 |
| 4 | .2454 | .2614 | .2172 | .2614 | .2103 | .2534 | .2801 |
| 5 | .2454 | .2801 | .2172 | .3174 | .2103 | .2172 | .2801 |
| 6 | .2454 | .2987 | .2561 | .2614 | .2103 | .2172 | .2801 |
| 7 | .2454 | .2614 | .2896 | | .2804 | .1991 | |
| 8 | .2454 | .2614 | .3258 | .3734 | .3856 | .2172 | .2801 |
| 9 | .2454 | .2987 | .362 | .3734 | .3155 | .2172 | .2801 |
| 10 | .2804 | .3361 | .4344 | .3921 | .2804 | .2172 | .2987 |
| 11 | .1494 | .3292 | .4668 | .3772 | .3658 | .2054 | .2454 |
| 12 | .0934 | .3292 | .4854 | .4458 | .439 | .2054 | .2103 |
| 13 | .112 | .3258 | .3734 | .4458 | .439 | .1867 | .2103 |
| 14 | .0747 | .3258 | .2427 | .4115 | .439 | .168 | .2103 |
| 15 | .2987 | .2926 | .1867 | .1753 | .5121 | .4481 | .2743 |
| 16 | .3734 | .3258 | .168 | .1753 | .4755 | .6161 | .3429 |
| 17 | .3734 | .2896 | .1867 | .2454 | .4344 | .5601 | .5014 |
| 18 | .3547 | .181 | .2054 | .2804 | .4163 | .5415 | .5373 |
| 19 | .3174 | .2896 | .3734 | .3155 | .3658 | .4854 | .4908 |
| 20 | .3174 | .362 | .3921 | .3506 | .3109 | .4668 | .4207 |
| 21 | .2987 | .3258 | .3174 | .3506 | .3439 | .4294 | .4298 |
| 22 | .2987 | .2926 | .3174 | .3155 | .3475 | .4108 | .394 |
| 23 | .2801 | .2896 | .2987 | .2804 | .3077 | .3734 | .3155 |
| 24 | .2804 | .2614 | .2561 | .2987 | .2454 | .3109 | .3547 |
| Max | .3734 | .362 | .4854 | .4458 | .5121 | .6161 | .5373 |
| Min | .0747 | .181 | .168 | .1753 | .2103 | .168 | .2103 |
| Avg | .2576 | .2933 | .2974 | .3168 | .3363 | .3242 | .3267 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 206 / 11KV POLO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0701 | .0747 | .0549 | .0934 | .0701 | .0732 | .0747 |
| 2 | .0701 | .0747 | .0549 | .0934 | .0701 | .0724 | .0747 |
| 3 | .0701 | .0747 | .0549 | .0934 | .0701 | .0724 | .0747 |
| 4 | .0701 | .056 | .0366 | .0747 | .0526 | .0732 | .0747 |
| 5 | .0701 | .056 | .0366 | .0747 | .0526 | .0549 | .0747 |
| 6 | .0701 | .056 | .0366 | .0747 | .0526 | .0549 | .0747 |
| 7 | .0701 | .056 | .0724 | | .0526 | .0549 | |
| 8 | .0701 | .056 | .0543 | .0747 | .0701 | .0549 | .0747 |
| 9 | .0701 | .056 | .0549 | .0747 | .0701 | .0549 | .0747 |
| 10 | .0701 | .056 | .0549 | .0747 | .0701 | .0732 | .0747 |
| 11 | .1867 | .1097 | .1867 | .1052 | .1097 | .1867 | .1433 |
| 12 | .2054 | .1829 | .2054 | .1753 | .1646 | .2054 | .2149 |
| 13 | .2054 | .2534 | .2054 | .2103 | .2561 | .1867 | .2103 |
| 14 | .1867 | .1463 | .2054 | .2103 | .1829 | .1867 | .1753 |
| 15 | .112 | .1086 | .2054 | .2103 | .1463 | | .1829 |
| 16 | .0934 | .1086 | .1307 | .1753 | .1097 | .112 | .2561 |
| 17 | .0934 | .1086 | .1307 | .1402 | .1097 | .112 | .1075 |
| 18 | .0934 | .1086 | .1307 | .1402 | .0914 | .0934 | .0716 |
| 19 | .0934 | .0914 | .112 | .1052 | .0914 | .0747 | .0716 |
| 20 | .0934 | .0724 | .0934 | .0876 | .0732 | .0747 | .0716 |
| 21 | .0747 | .0724 | .0747 | .1052 | .0732 | .0747 | .0716 |
| 22 | .0747 | .0543 | .056 | .0701 | .0732 | .0747 | .0716 |
| 23 | .0747 | .0543 | .056 | .0701 | .0732 | .0747 | .0716 |
| 24 | .0701 | .0747 | .0549 | .056 | .0701 | .0732 | .0747 |
| Max | .2054 | .2534 | .2054 | .2103 | .2561 | .2054 | .2561 |
| Min | .0701 | .0543 | .0366 | .056 | .0526 | .0549 | .0716 |
| Avg | .0983 | .0901 | .0983 | .1126 | .0940 | .0943 | .1073 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 207 / 11 kV Dhamna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5609 | .4862 | .6219 | .5533 | .5609 | .6516 | .5533 |
| 2 | .5609 | .4862 | .6219 | .5533 | .5609 | .6219 | .57 |
| 3 | .5258 | .4694 | .6036 | .5365 | .5258 | .6219 | .57 |
| 4 | .5258 | .4694 | .5973 | .5365 | .5258 | .5792 | .5868 |
| 5 | .5258 | .4694 | .6401 | .5197 | .5258 | .5487 | .5868 |
| 6 | .4908 | .4694 | .6767 | .5197 | .5258 | .5068 | .5868 |
| 7 | .5087 | .6036 | .6767 | | .6104 | .6878 | |
| 8 | .5426 | .6371 | .6584 | .57 | .7122 | .8145 | .8215 |
| 9 | .6104 | .6036 | .6878 | .57 | .9496 | .9877 | .8718 |
| 10 | .6443 | .57 | .6219 | .6203 | 1.0174 | 1.2254 | 1.0898 |
| 11 | .6203 | .5487 | .503 | .5959 | .9877 | 1.0562 | 1.0852 |
| 12 | .6203 | .4024 | .4527 | .5258 | .8596 | 1.0227 | 1.0174 |
| 13 | .6036 | .4024 | .4024 | .4908 | .8962 | .9724 | .9835 |
| 14 | .5533 | .4024 | .3353 | .4557 | .8962 | .9556 | .9496 |
| 15 | .3018 | .7682 | .5365 | .8817 | .5121 | .6706 | .4207 |
| 16 | .3521 | 1.0317 | .8048 | 1.0174 | .4755 | .7042 | .4908 |
| 17 | .3521 | .9145 | .8383 | .9156 | .5121 | .6036 | .4908 |
| 18 | .3856 | .823 | .9389 | .8478 | .5487 | .4862 | .5258 |
| 19 | .7377 | .7602 | | .8478 | .8779 | .7377 | .8413 |
| 20 | .8886 | .724 | .7712 | .8139 | 1.0425 | .9724 | 1.0517 |
| 21 | .7042 | .695 | .7377 | .7461 | .9511 | .8718 | .9816 |
| 22 | .6203 | .6219 | .6706 | .6783 | .823 | .8215 | .9114 |
| 23 | .503 | .6219 | .6036 | .5959 | .7682 | .7377 | .7362 |
| 24 | .5609 | .4862 | .6219 | .503 | .5609 | .695 | .7042 |
| Max | .8886 | 1.0317 | .9389 | 1.0174 | 1.0425 | 1.2254 | 1.0898 |
| Min | .3018 | .4024 | .3353 | .4557 | .4755 | .4862 | .4207 |
| Avg | .5542 | .6028 | .6358 | .6476 | .7178 | .7730 | .7577 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 208 / Adegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .2454 | .2534 | .2454 | .2058 | .2534 | .2103 |
| 2 | .2229 | .2454 | .2534 | .2454 | .2058 | .2534 | .2427 |
| 3 | .2229 | .2279 | .2172 | .2454 | .2058 | .2534 | .2279 |
| 4 | .2058 | .2279 | .2172 | .2279 | .2058 | .2172 | .2103 |
| 5 | .2058 | .2279 | .2012 | .2279 | .2058 | .2172 | .2103 |
| 6 | .2058 | .2103 | .1991 | .2103 | .2058 | .2172 | .1928 |
| 7 | .2058 | .1753 | .1829 | | .2401 | .2896 | |
| 8 | .1715 | .1578 | .1629 | .1753 | .2401 | .3258 | .3856 |
| 9 | .2572 | .1753 | .2172 | .1753 | .5144 | .5249 | .4207 |
| 10 | .3429 | .1753 | .1629 | .1753 | .4801 | .5792 | .4908 |
| 11 | .3506 | .181 | .1753 | .1715 | .3982 | .5784 | .503 |
| 12 | .3506 | .1646 | .1753 | .1715 | .362 | .631 | .503 |
| 13 | .2804 | .1629 | .1753 | .1715 | .3258 | .5258 | .4359 |
| 14 | .2629 | .1448 | .1578 | .1715 | .2896 | .4733 | .4694 |
| 15 | .1753 | .3982 | .3856 | .5144 | .2534 | .1402 | .1715 |
| 16 | 1.6834 | .5973 | .4382 | .583 | .2012 | .1402 | .1715 |
| 17 | .1402 | .543 | .4382 | .5144 | .2896 | .1753 | .2058 |
| 18 | .1402 | .4887 | .4557 | .3772 | .2172 | .2279 | .2401 |
| 19 | .4031 | .3982 | .3506 | .3429 | .3801 | .2804 | .3772 |
| 20 | .4031 | .3439 | .2804 | .3086 | .4163 | .4031 | .4458 |
| 21 | .3506 | .3258 | .2804 | .3086 | .3439 | .3506 | .3429 |
| 22 | .2804 | .2926 | .2629 | .2743 | .2896 | .298 | .3086 |
| 23 | .2804 | .2926 | .2454 | .2401 | .2896 | .2804 | .2743 |
| 24 | .2401 | .2629 | .2534 | .2279 | .2058 | .2534 | .2629 |
| Max | 1.6834 | .5973 | .4557 | .583 | .5144 | .631 | .503 |
| Min | .1402 | .1448 | .1578 | .1715 | .2012 | .1402 | .1715 |
| Avg | .3176 | .2777 | .2559 | .2742 | .2905 | .3287 | .3175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 209 / 11 KV ECONOMIC EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .1494 | .1086 | .1494 | .1097 | .1448 | .1494 |
| 2 | .1463 | .1494 | .1086 | .1494 | .1097 | .1448 | .1494 |
| 3 | .1463 | .1494 | .0724 | .1494 | .1097 | .1086 | .1494 |
| 4 | .128 | .1494 | .0724 | .1494 | .1097 | .1086 | .1494 |
| 5 | .128 | .1494 | .0724 | .1494 | .1097 | .0724 | .1494 |
| 6 | .128 | .1494 | .0724 | .1494 | .1097 | .0724 | .1494 |
| 7 | .1829 | .1867 | .1086 | | .1463 | .1448 | |
| 8 | .1829 | .1867 | .1448 | .1494 | .2195 | .181 | .1867 |
| 9 | .1463 | .1494 | .181 | .1494 | .2195 | .2172 | .2241 |
| 10 | .2195 | .1494 | .2172 | .1494 | .2195 | .2534 | .2241 |
| 11 | .2427 | .181 | .2987 | .128 | .2534 | .2427 | .2743 |
| 12 | .2427 | .2172 | .2987 | .128 | .2896 | .2427 | .2743 |
| 13 | .2801 | .2534 | .2987 | .0914 | .3258 | .2427 | .2561 |
| 14 | .2801 | .2896 | .2987 | .0732 | .362 | .2427 | .2561 |
| 15 | .2801 | .3258 | .2427 | .0732 | .3801 | .2241 | .2378 |
| 16 | .2801 | .362 | .2427 | .0732 | .4024 | .2241 | .2378 |
| 17 | .2427 | .2896 | .2427 | .0914 | .3258 | .2801 | .2378 |
| 18 | .2427 | .2561 | .2427 | .1463 | .2534 | .2801 | .2195 |
| 19 | .2241 | .2534 | .2241 | .1463 | .2195 | .1867 | .2195 |
| 20 | .2241 | .2172 | .2241 | .0914 | .2172 | .1867 | .2195 |
| 21 | .2054 | .181 | .2241 | .1463 | .181 | .2614 | .2195 |
| 22 | .1867 | .1448 | .2241 | .1097 | .181 | .2614 | .2012 |
| 23 | .1494 | .1086 | .1494 | .1097 | .1448 | .1494 | .1829 |
| 24 | .1463 | .1494 | .1086 | .1494 | .1097 | .1448 | .1494 |
| Max | .2801 | .362 | .2987 | .1494 | .4024 | .2801 | .2743 |
| Min | .128 | .1086 | .0724 | .0732 | .1097 | .0724 | .1494 |
| Avg | .1992 | .1999 | .1866 | .1262 | .2129 | .1924 | .2051 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 211 / 11 KV ORIENT EXPLOSIVE NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0351 | .056 | .1086 | .056 | .0351 | .1086 | .0747 |
| 2 | .0351 | .056 | .1086 | .056 | .0351 | .1086 | .0747 |
| 3 | .0351 | .056 | .0724 | .056 | .0351 | .0724 | .0747 |
| 4 | .0351 | .056 | .0732 | .056 | .0351 | .0724 | .0747 |
| 5 | .0351 | .056 | .0366 | .056 | .0351 | .0724 | .0747 |
| 6 | .0351 | .056 | .0366 | .056 | .0351 | .0724 | .0747 |
| 7 | .0351 | .056 | .0724 | | .0351 | .1086 | |
| 8 | .0351 | .0747 | .1086 | .056 | .0351 | .1463 | .0747 |
| 9 | .0351 | .0747 | .1463 | .0747 | .0351 | .181 | .056 |
| 10 | .1052 | .112 | .181 | .112 | .1753 | .2172 | .056 |
| 11 | .2241 | .1463 | .2987 | .2103 | .2172 | .2241 | .0358 |
| 12 | .2241 | .181 | .2987 | .2454 | .2534 | .2241 | .0358 |
| 13 | .1494 | .2172 | .2241 | .1753 | .2896 | .1867 | .0366 |
| 14 | .1494 | .2534 | .1867 | .1052 | .3258 | .1867 | .0366 |
| 15 | .1867 | .2896 | .1867 | .1753 | .362 | .1867 | .0358 |
| 16 | .1867 | .3258 | .1494 | .2103 | .3982 | .2241 | .0358 |
| 17 | .0747 | .2896 | .0747 | .0701 | .2896 | .1494 | .0358 |
| 18 | .0747 | .2534 | .0747 | .0701 | .2534 | .1494 | .0716 |
| 19 | .0747 | .2534 | .0747 | .0351 | .2172 | .0747 | .0716 |
| 20 | .0747 | .2172 | .0747 | .0351 | .181 | .0747 | .0716 |
| 21 | .0747 | .181 | .0747 | .0351 | .181 | .0747 | .0358 |
| 22 | .0747 | .1448 | .0747 | .0351 | .1448 | .0747 | .0358 |
| 23 | .056 | .1086 | .056 | .0351 | .1448 | .0747 | .0358 |
| 24 | .0351 | .056 | .1086 | .056 | .0351 | .1086 | .0747 |
| Max | .2241 | .3258 | .2987 | .2454 | .3982 | .2241 | .0747 |
| Min | .0351 | .056 | .0366 | .0351 | .0351 | .0724 | .0358 |
| Avg | .0867 | .1488 | .1209 | .0901 | .1577 | .1322 | .0558 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 401 / 33 kv kalmeshwar to baz
income Feeder KV- 33 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.4179 | 3.2487 | 3.5082 | 2.9687 | 2.9447 | 3.8477 | 3.5848 |
| 2 | 3.3653 | 3.2487 | 3.6214 | 2.9687 | 2.9447 | 3.8477 | 3.5848 |
| 3 | 3.2076 | 3.2487 | 3.5648 | 2.9687 | 2.9447 | 3.7912 | 3.5848 |
| 4 | 3.155 | 3.2487 | 3.678 | 2.8567 | 2.8395 | 3.8477 | 3.5848 |
| 5 | 3.155 | 3.2487 | 3.5648 | 3.3048 | 2.7869 | 3.8477 | 3.5848 |
| 6 | 2.9447 | 3.2487 | 3.678 | 3.4728 | 2.7869 | 3.7346 | 3.5848 |
| 7 | 3.2602 | 3.9209 | 4.3004 | | 3.1024 | 3.3385 | |
| 8 | 3.786 | 2.9687 | 4.6399 | 3.5288 | 3.9963 | 3.7912 | 4.145 |
| 9 | 3.6283 | 4.5931 | 5.4321 | 4.425 | 4.5748 | 4.357 | 3.9209 |
| 10 | 4.1015 | 4.9851 | 5.8848 | 4.7611 | 5.1532 | 4.8663 | 4.257 |
| 11 | 4.369 | 4.8663 | 6.2174 | 4.6273 | 5.2624 | 5.2092 | 4.2067 |
| 12 | 4.257 | 4.5833 | 6.1614 | 4.7325 | 4.9228 | 5.2092 | 4.2067 |
| 13 | 4.201 | 4.9794 | 5.6013 | 4.9429 | 5.2058 | 4.6491 | 3.9963 |
| 14 | 4.201 | 5.036 | 4.8731 | 4.8903 | 5.5453 | 4.537 | 3.8912 |
| 15 | 4.8171 | 4.6965 | 4.0889 | 4.3118 | 6.394 | 5.7693 | 4.6273 |
| 16 | 4.9291 | 5.4321 | 3.8649 | 4.5222 | 6.2809 | 6.2734 | 5.2058 |
| 17 | 4.6491 | 4.8097 | 3.9769 | 4.2067 | 6.0545 | 6.2174 | 4.7851 |
| 18 | 4.5931 | 4.4702 | 4.0889 | 3.9963 | 5.5453 | 5.7693 | 4.7325 |
| 19 | 5.2092 | 4.4702 | 3.9209 | 3.8912 | 5.7716 | 5.5453 | 5.1006 |
| 20 | 5.2092 | 4.1872 | 3.6969 | 3.7334 | 5.4887 | 5.9374 | 5.3109 |
| 21 | 4.7051 | 4.0175 | 3.5288 | 3.4705 | 5.2058 | 5.8253 | 5.647 |
| 22 | 4.369 | 3.6214 | 3.4168 | 3.155 | 4.8663 | 5.6013 | 5.1532 |
| 23 | 3.2487 | 3.5082 | 2.8567 | 3.0498 | 3.7912 | 3.9769 | 3.5757 |
| 24 | 3.4705 | 3.1367 | 3.3385 | 2.6886 | 2.9447 | 3.7912 | 3.8649 |
| Max | 5.2092 | 5.4321 | 6.2174 | 4.9429 | 6.394 | 6.2734 | 5.647 |
| Min | 2.9447 | 2.9687 | 2.8567 | 2.6886 | 2.7869 | 3.3385 | 3.5757 |
| Avg | 4.0104 | 4.0739 | 4.2293 | 3.8032 | 4.4731 | 4.7325 | 4.2668 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 405 / 33 KV PIX

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .631 | .5041 | .3258 | .5601 | .1052 | .3292 | .4481 |
| 2 | .631 | .5041 | .4344 | .5601 | .1052 | .439 | .4481 |
| 3 | .5258 | .5041 | .4344 | .5601 | .1052 | .439 | .4481 |
| 4 | .5258 | .5041 | .5487 | .5601 | .1052 | .5487 | .4481 |
| 5 | .5258 | .5041 | .6584 | .5601 | .1052 | .6584 | .4481 |
| 6 | .5258 | .5041 | .3292 | .5601 | .1052 | .5487 | .4481 |
| 7 | .5258 | .4481 | .439 | | .2103 | .4344 | |
| 8 | .5258 | .4481 | .543 | .2801 | .4207 | .3292 | .5041 |
| 9 | .631 | .6161 | .6584 | .112 | .6836 | .439 | .5601 |
| 10 | .7362 | .6722 | .8779 | .112 | .6836 | .5487 | .6161 |
| 11 | .6722 | .5487 | .7842 | .1052 | .5487 | .6722 | .6984 |
| 12 | .6722 | .3292 | .7842 | .1578 | .439 | .6722 | .7522 |
| 13 | .6722 | .439 | .7282 | .1578 | .5487 | .6722 | .6447 |
| 14 | .6161 | .5487 | .7282 | .1052 | .439 | .6161 | .6447 |
| 15 | .6161 | .543 | .5601 | .1052 | .439 | .6161 | .6447 |
| 16 | 4.9291 | .5487 | .5601 | .1052 | .3292 | .6161 | .591 |
| 17 | .6722 | .4344 | .6722 | .1052 | .439 | .7842 | .6447 |
| 18 | .6722 | .543 | .7282 | .1052 | .439 | .7842 | .6984 |
| 19 | .6722 | .543 | .6722 | .1052 | .5487 | .5601 | .5373 |
| 20 | .6722 | .4344 | .6722 | .1052 | .4344 | .5601 | .5373 |
| 21 | .6722 | .439 | .7282 | .1052 | .439 | .8402 | .8596 |
| 22 | .6161 | .3258 | .7282 | .1052 | .439 | .8402 | .8059 |
| 23 | .5601 | .3258 | .5601 | .1052 | .3292 | .5601 | .5373 |
| 24 | .631 | | .3292 | .5601 | .1052 | .3292 | .5041 |
| Max | 4.9291 | .6722 | .8779 | .5601 | .6836 | .8402 | .8596 |
| Min | .5258 | .3258 | .3258 | .1052 | .1052 | .3292 | .4481 |
| Avg | .7971 | .4875 | .6035 | .2564 | .3561 | .5766 | .5856 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 201 / CHIKNA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1033 | .1207 | .1207 | .1379 | .1381 | .1552 | .1554 |
| 2 | .1033 | .1207 | .1035 | .1379 | .1381 | .1379 | .1381 |
| 3 | .1033 | .1035 | .1035 | .1379 | .1381 | .1379 | .1381 |
| 4 | .1033 | .1035 | .1035 | .1379 | .1381 | .1379 | .1381 |
| 5 | .1206 | .1207 | .1207 | .1552 | .1381 | .1552 | .1381 |
| 6 | .155 | .1379 | .1379 | .1552 | .1554 | .1897 | .1554 |
| 7 | .155 | .1724 | .1552 | .1724 | .1899 | .1897 | .2244 |
| 8 | .1722 | .1717 | .1552 | .2069 | .2417 | .2069 | .397 |
| 9 | .2411 | .1552 | .2759 | .2241 | .2244 | .2414 | .2915 |
| 10 | .31 | .2067 | .2586 | .2244 | .2411 | .4287 | .2762 |
| 11 | .2586 | .2756 | .3104 | .2417 | .2414 | .2572 | .328 |
| 12 | .2931 | .2759 | .2759 | .1726 | .3445 | .3429 | .3797 |
| 13 | .1207 | .1724 | .1379 | .2244 | .2583 | .3452 | .5178 |
| 14 | .2241 | .2586 | .1379 | | .2411 | .2915 | .4661 |
| 15 | .2586 | .2414 | .1724 | .1899 | .328 | .397 | .4488 |
| 16 | .1207 | .2759 | .2586 | .2589 | .4138 | .3625 | .4661 |
| 17 | .1207 | .2759 | .3276 | .2244 | .2934 | .3625 | .5524 |
| 18 | .1207 | .1552 | .1724 | .1381 | .2589 | .3625 | .4833 |
| 19 | .2069 | .1724 | .1897 | .2244 | .2071 | .3107 | .2762 |
| 20 | .2069 | .1897 | .1897 | .1899 | .2071 | .2417 | .2417 |
| 21 | .1724 | .1552 | .1724 | .1726 | .2071 | .1899 | .2417 |
| 22 | .1379 | .1379 | .1552 | .1554 | .1899 | .1899 | .2071 |
| 23 | .1379 | .1207 | .1379 | .1554 | .1554 | .1554 | .1899 |
| 24 | .1033 | .1207 | .1207 | .1379 | .1381 | .1554 | .1554 |
| Max | .31 | .2759 | .3276 | .2589 | .4138 | .4287 | .5524 |
| Min | .1033 | .1035 | .1035 | .1379 | .1381 | .1379 | .1381 |
| Avg | .1687 | .1767 | .1789 | .1815 | .2178 | .2477 | .2919 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 202 / Kirnapur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | .0343 | .0515 | .0515 | .0515 | .0514 | .0515 |
| 2 | .0343 | .0343 | .0515 | .0515 | .0515 | .0514 | .0515 |
| 3 | .0343 | .0343 | .0515 | .0343 | .0515 | .0514 | .0515 |
| 4 | .0343 | .0343 | .0515 | .0343 | .0343 | .0514 | .0515 |
| 5 | .0343 | .0343 | .0515 | .0343 | .0343 | .0514 | .0687 |
| 6 | .0343 | .0343 | .0515 | .0343 | .0343 | .0514 | .0343 |
| 7 | .0514 | .0515 | .0343 | .0343 | .0515 | .0514 | .0343 |
| 8 | .0514 | .0515 | .0687 | .0858 | .0687 | .0686 | .0858 |
| 9 | .0858 | .0858 | .0858 | .0687 | .0515 | .0857 | .0857 |
| 10 | .0858 | .1029 | .0687 | .0687 | .0514 | .0686 | .0687 |
| 11 | .0515 | .0857 | .0687 | .0687 | .0514 | .0686 | .0687 |
| 12 | .0343 | .0514 | .0515 | .0687 | .0343 | .0857 | .0687 |
| 13 | .0343 | .0514 | .0343 | .0515 | .0514 | | .0687 |
| 14 | .0343 | .0514 | .0343 | .0515 | .0514 | .0686 | .0687 |
| 15 | .0343 | .0514 | .0515 | .0515 | .0514 | .0687 | .0515 |
| 16 | .0343 | .0343 | .0515 | .0687 | .0687 | .0515 | .0687 |
| 17 | .0343 | .0514 | .0687 | .0687 | .0687 | .0687 | .0687 |
| 18 | .0343 | .0687 | .0687 | .0687 | .0687 | .0687 | .0515 |
| 19 | .0515 | .0858 | .103 | .0858 | .0857 | .0687 | .0858 |
| 20 | .0515 | .0686 | .0858 | .0687 | .0686 | .0687 | .0687 |
| 21 | .0515 | .0686 | .0687 | .0687 | .0514 | .0515 | .0687 |
| 22 | .0515 | | .0515 | .0515 | .0515 | .0515 | .0515 |
| 23 | .0343 | .0515 | .0515 | .0515 | .0515 | .0515 | .0515 |
| 24 | .0343 | .0343 | .0515 | .0515 | .0515 | .0515 | .0515 |
| Max | .0858 | .1029 | .103 | .0858 | .0857 | .0857 | .0858 |
| Min | .0343 | .0343 | .0343 | .0343 | .0343 | .0514 | .0343 |
| Avg | .0436 | .0544 | .0587 | .0572 | .0536 | .0612 | .0615 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 203 / Adyali

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3586 | .3048 | .3227 | | .3406 | .3406 | .4487 |
| 2 | .3227 | | .3227 | .3406 | .3406 | .3406 | .4128 |
| 3 | .3227 | .3048 | .3227 | .3227 | .3227 | .3406 | .4128 |
| 4 | .3227 | .2868 | .3227 | .3227 | .3227 | .3406 | .4128 |
| 5 | .3048 | .3048 | .3406 | .3227 | .3227 | .3765 | .4307 |
| 6 | .3406 | .3406 | .3586 | .3227 | .3406 | .3586 | .4487 |
| 7 | .3761 | .3765 | .3586 | .3765 | .3765 | .3586 | .4487 |
| 8 | .394 | .3586 | .4123 | .4123 | .3765 | .3765 | .4307 |
| 9 | .4298 | .3765 | .4123 | .4482 | .4661 | .4482 | .5025 |
| 10 | .3586 | .3403 | .3765 | .3586 | .4477 | .4487 | .5025 |
| 11 | .2689 | .394 | .3586 | .3586 | .4303 | .4487 | .5205 |
| 12 | .3048 | .3944 | .4123 | .3406 | .4661 | .4487 | .5384 |
| 13 | .3048 | .3586 | .3944 | .4482 | .4123 | .4487 | .4846 |
| 14 | .3276 | .3227 | .3586 | | .3944 | .5564 | .5384 |
| 15 | .3227 | .3406 | .3586 | .3406 | .3765 | .5564 | .5564 |
| 16 | .3944 | .3586 | .3586 | .3765 | .3944 | .5564 | .5865 |
| 17 | .3586 | .3944 | .3227 | .3586 | .3944 | .5564 | .5025 |
| 18 | .3406 | .3406 | .3944 | .3586 | .502 | .5384 | .4666 |
| 19 | .502 | .5199 | .4841 | .5199 | .5199 | .5564 | .5025 |
| 20 | .4482 | .4482 | .4482 | .4841 | .4661 | .5923 | .4307 |
| 21 | .4303 | .4482 | .4303 | .4482 | .4661 | .5205 | .4307 |
| 22 | .3944 | .4123 | .3944 | .4123 | .4123 | .5205 | .4128 |
| 23 | .3586 | .3944 | .3586 | .3944 | .3944 | .4846 | .3589 |
| 24 | .3761 | .3048 | .3586 | .3406 | .3586 | .3586 | .4666 |
| Max | .502 | .5199 | .4841 | .5199 | .5199 | .5923 | .5865 |
| Min | .2689 | .2868 | .3227 | .3227 | .3227 | .3406 | .3589 |
| Avg | .3609 | .3663 | .3743 | .3822 | .4019 | .4530 | .4686 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 204 / Pipla

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2749 | .2932 | .3116 | .3666 | .3662 | .3666 | .3849 |
| 2 | .2749 | .2932 | .2932 | .3666 | .3662 | .3666 | .3666 |
| 3 | .2566 | .2749 | .2932 | .3666 | .3662 | .3482 | .3666 |
| 4 | .2566 | .2566 | .2932 | .3666 | .3662 | .3482 | .3666 |
| 5 | .2566 | .2749 | .3125 | .3666 | .3479 | .3849 | .3666 |
| 6 | .3299 | .3482 | .3479 | .3666 | .3662 | .4215 | .4399 |
| 7 | .4582 | .4032 | .4028 | .3849 | .4028 | .4765 | .4399 |
| 8 | .4399 | .5315 | .5127 | .4399 | .4394 | .4765 | .4949 |
| 9 | .4399 | .4582 | .4765 | .4215 | .4394 | .4582 | .477 |
| 10 | .4765 | .4399 | .5315 | .4577 | .4949 | .4949 | .4949 |
| 11 | .4765 | .4399 | .4765 | .4943 | .4582 | .4587 | .4949 |
| 12 | .3666 | .4765 | .4765 | .476 | .4215 | .4403 | .4399 |
| 13 | .3482 | .3849 | .4399 | .4577 | .4032 | .4399 | .4215 |
| 14 | .3666 | .4032 | .3666 | .3845 | .3666 | .4215 | .4032 |
| 15 | .3116 | .2932 | .3299 | .3479 | .3849 | .4215 | .4032 |
| 16 | .3482 | .4032 | | .4211 | .4032 | .4215 | .4215 |
| 17 | .3666 | .4032 | .3482 | .3662 | .3299 | .4215 | .3849 |
| 18 | .3849 | .4215 | .4032 | .4394 | .4399 | .5498 | .3666 |
| 19 | .5315 | .5498 | .5682 | .6225 | .5498 | .5682 | .5315 |
| 20 | .5132 | .4949 | .5315 | .5493 | .5682 | .5865 | .5498 |
| 21 | .4765 | .4765 | .5132 | .531 | .5132 | .5315 | .5132 |
| 22 | .4399 | .4582 | .4582 | .5127 | .4949 | .5132 | .4949 |
| 23 | .3849 | .3849 | .4032 | .4577 | .4399 | .4765 | .4765 |
| 24 | .2749 | .2932 | .3299 | .3482 | .3662 | .4032 | .4215 |
| Max | .5315 | .5498 | .5682 | .6225 | .5682 | .5865 | .5498 |
| Min | .2566 | .2566 | .2932 | .3479 | .3299 | .3482 | .3666 |
| Avg | .3773 | .3940 | .4096 | .4297 | .4206 | .4498 | .4384 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 201 / Saibaba nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1494 | .168 | .1494 | .2033 | .2054 | .2241 | .2241 |
| 2 | .1494 | .168 | .168 | .1848 | .2054 | .2054 | .2241 |
| 3 | .1494 | .168 | .1867 | .1848 | .1867 | .2054 | .2054 |
| 4 | .1494 | .1494 | .168 | .1848 | .1867 | .2054 | .2241 |
| 5 | .168 | .1494 | .1867 | .1848 | .2054 | .2054 | .2427 |
| 6 | .1867 | .1867 | .2054 | .1848 | .1867 | .2054 | .2614 |
| 7 | .2241 | .2054 | .2241 | .1848 | .2241 | .2241 | .2801 |
| 8 | .2241 | .2987 | .2801 | .2772 | .2427 | .2614 | .2987 |
| 9 | .2987 | .2614 | .2241 | .2427 | .2801 | .2427 | .2801 |
| 10 | .2241 | .2427 | .2241 | .2427 | .2614 | .2427 | .2427 |
| 11 | .2241 | .2241 | .2427 | .2614 | .2614 | .2241 | .2033 |
| 12 | .2241 | .2241 | .1848 | .2241 | .2427 | .2054 | .2218 |
| 13 | .168 | .1867 | .1663 | .2241 | .1307 | .2241 | .1848 |
| 14 | .1494 | .168 | .1663 | .2054 | .2054 | .2054 | .1663 |
| 15 | .1494 | .168 | .1478 | .1867 | .1867 | .1867 | .1663 |
| 16 | .168 | .1867 | .1848 | .168 | .1867 | .2054 | .1663 |
| 17 | .1494 | .2054 | .2033 | .1867 | .2054 | .2241 | .1663 |
| 18 | .2054 | .2054 | .2218 | .2427 | .2614 | .2614 | |
| 19 | .2801 | .3174 | .2957 | .2614 | .3174 | .2801 | .2957 |
| 20 | .2987 | .2987 | .3326 | .2801 | .3174 | .2987 | .2772 |
| 21 | .2614 | .2614 | .2772 | .2614 | .2987 | .2801 | .2957 |
| 22 | .2241 | .2241 | .2402 | .2427 | .2801 | .2987 | .2772 |
| 23 | .1867 | .2054 | .2218 | .2427 | .2427 | .2614 | .2587 |
| 24 | .1494 | .168 | .1867 | .2033 | .2054 | .2241 | .2427 |
| Max | .2987 | .3174 | .3326 | .2801 | .3174 | .2987 | .2987 |
| Min | .1494 | .1494 | .1478 | .168 | .1307 | .1867 | .1663 |
| Avg | .1984 | .2100 | .2120 | .2194 | .2303 | .2334 | .2350 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 202 / NAVNATH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2772 | .3174 | .3174 | .3696 | .3734 | .3734 | .4108 |
| 2 | .2772 | .3174 | .3361 | .3326 | .3547 | .3361 | .3734 |
| 3 | .2772 | .3174 | .3174 | .3326 | .3547 | .3361 | .3361 |
| 4 | .2772 | .2987 | .3361 | .3326 | .3547 | .3361 | .3547 |
| 5 | .3142 | .2987 | .3547 | .3326 | .3547 | .3734 | .3361 |
| 6 | .3326 | .3174 | .3547 | .3142 | .3547 | .3921 | .3547 |
| 7 | .3734 | .3734 | .3734 | .3881 | .3921 | .4108 | .3734 |
| 8 | .4066 | .4294 | .3921 | .4066 | .4108 | .4294 | .4108 |
| 9 | .3734 | .4108 | .3921 | .4108 | .4294 | .4108 | .4108 |
| 10 | .3734 | .3921 | .3547 | .4108 | .3696 | .3547 | .3361 |
| 11 | .2987 | .3734 | .3547 | .3921 | .3326 | .2987 | .3696 |
| 12 | .3174 | .3361 | .2957 | .3361 | .3142 | .2427 | .2957 |
| 13 | .2614 | .3174 | .2772 | .3174 | .2987 | .2614 | .2772 |
| 14 | .2614 | .2427 | .2587 | .2987 | .2801 | .2801 | .2772 |
| 15 | .2241 | .2614 | .2402 | .2801 | .2957 | .2987 | .2772 |
| 16 | .2241 | .2801 | .2402 | .2801 | .2957 | .2987 | .2772 |
| 17 | .2241 | .2614 | .2402 | .2614 | .2957 | .3174 | .2587 |
| 18 | .2987 | .2801 | .2957 | .3174 | .3174 | .3734 | |
| 19 | .4294 | .4294 | .4066 | .3921 | .4854 | .4481 | .462 |
| 20 | .4108 | .4108 | .4435 | .4294 | .5041 | .5228 | .4805 |
| 21 | .3921 | .3734 | .4066 | .4294 | .4481 | .4854 | .462 |
| 22 | .3734 | .3921 | .3881 | .4108 | .2801 | .5041 | .462 |
| 23 | .3361 | .3547 | .3696 | .3921 | .4294 | .4668 | .4435 |
| 24 | .2772 | .3174 | .3361 | .3696 | .3734 | .3921 | .4481 |
| Max | .4294 | .4294 | .4435 | .4294 | .5041 | .5228 | .4805 |
| Min | .2241 | .2427 | .2402 | .2614 | .2801 | .2427 | .2587 |
| Avg | .3171 | .3376 | .3367 | .3557 | .3625 | .3726 | .3690 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 203 / 11 KV BAHADURA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .128 | .1494 | .1307 | .1294 | .1494 | .1478 | .1494 |
| 2 | .128 | .1307 | .1307 | .1294 | .1494 | .1294 | .1494 |
| 3 | .128 | .1307 | .1307 | .1294 | .1307 | .1294 | .1307 |
| 4 | .128 | .1307 | .1307 | .1294 | .1307 | .1294 | .1307 |
| 5 | .128 | .1307 | .1307 | .1294 | .1494 | .1478 | .1494 |
| 6 | .128 | .1494 | .1307 | .1294 | .1494 | .1663 | .168 |
| 7 | .128 | .168 | .1494 | .1478 | .1494 | .1663 | .1867 |
| 8 | .2012 | .2241 | .2241 | .2241 | .2054 | .1848 | .2241 |
| 9 | .2054 | .2241 | .1867 | .2054 | .2054 | .1848 | .2054 |
| 10 | .168 | .168 | .1307 | .1867 | .1478 | .1663 | .168 |
| 11 | .1494 | .1867 | .1867 | .1867 | .1848 | .1494 | .1848 |
| 12 | .1494 | .168 | .1294 | .168 | .1478 | .1494 | .1663 |
| 13 | .1494 | .168 | .1294 | .1494 | .1294 | .1307 | .1294 |
| 14 | .1494 | .1307 | .1294 | .1494 | .1294 | .1307 | .1294 |
| 15 | .1494 | .1307 | .1294 | .1494 | .1294 | .1307 | .1294 |
| 16 | .1307 | .1307 | .1294 | .1494 | .1294 | .1307 | .1294 |
| 17 | .1307 | .1307 | .1294 | .1307 | .1294 | .1494 | .1294 |
| 18 | .1494 | .1307 | .1294 | .1494 | .1663 | .168 | |
| 19 | .2054 | .2241 | .2218 | .2054 | .2218 | .1867 | .2218 |
| 20 | .1867 | .1867 | .2218 | .1867 | .2218 | .2241 | .2033 |
| 21 | .168 | .1494 | .2033 | .1867 | .1848 | .2054 | .2033 |
| 22 | .168 | .1307 | .1848 | .168 | .1848 | .2241 | .2033 |
| 23 | .1494 | .1307 | | .168 | .1663 | .2054 | .1663 |
| 24 | .128 | .1494 | .1307 | .1663 | .1494 | .1478 | .1867 |
| Max | .2054 | .2241 | .2241 | .2241 | .2218 | .2241 | .2241 |
| Min | .128 | .1307 | .1294 | .1294 | .1294 | .1294 | .1294 |
| Avg | .1514 | .1564 | .1535 | .1606 | .1601 | .1619 | .1672 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164077 / 33 kv kharabi sub station

Feeder No / Name : 204 / Dhangawali SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3548 | .3921 | .3734 | .4095 | .4108 | .4294 | .1307 |
| 2 | .3548 | .3734 | .3921 | .3908 | .4108 | .3921 | .1307 |
| 3 | .3548 | .3734 | .3921 | .3908 | .3921 | .3921 | .1307 |
| 4 | .3548 | .3734 | .3921 | .3908 | .3921 | .3921 | .1307 |
| 5 | .3734 | .3734 | .3921 | .3908 | .4108 | .4108 | .1307 |
| 6 | .3921 | .4108 | .4108 | .3908 | .4108 | .4481 | .1307 |
| 7 | .4108 | .4481 | .4481 | .4465 | .4294 | .4668 | .1494 |
| 8 | .4855 | .5414 | .5227 | .4854 | .4855 | .5227 | .1494 |
| 9 | .4855 | .5041 | .4854 | .4668 | .5041 | .5041 | .1307 |
| 10 | .4481 | .4668 | .4295 | .4855 | .4294 | .4854 | .1307 |
| 11 | .5974 | .4294 | .4294 | .4855 | .4294 | .2987 | .1294 |
| 12 | .5975 | .4108 | .3721 | .4481 | .4108 | .1307 | .1294 |
| 13 | .5041 | .3921 | .3721 | .4295 | .3548 | .168 | .1294 |
| 14 | .4482 | .3548 | .3535 | .4108 | .3734 | .168 | .1294 |
| 15 | .4482 | .3548 | .3535 | .4108 | .3734 | .1494 | .1294 |
| 16 | .4482 | .3734 | .3535 | .3921 | .3734 | .1307 | .1294 |
| 17 | .4295 | .3734 | .3721 | .3734 | .3921 | .1307 | .1294 |
| 18 | .5601 | .3734 | .3908 | .4108 | .4294 | .1494 | |
| 19 | .7841 | .5414 | .5025 | .5041 | .5975 | .168 | .1848 |
| 20 | .7655 | .5041 | .5584 | .5227 | .5975 | .1867 | .1663 |
| 21 | .7282 | .4668 | .521 | .5227 | .5601 | .168 | .1478 |
| 22 | .6908 | .4294 | .4652 | .4668 | .5227 | .1867 | .1663 |
| 23 | .6162 | .4108 | .4294 | .4668 | .4855 | .1494 | .1478 |
| 24 | .3548 | .5788 | .3921 | .4281 | .4108 | .4481 | .1307 |
| Max | .7841 | .5788 | .5584 | .5227 | .5975 | .5227 | .1848 |
| Min | .3548 | .3548 | .3535 | .3734 | .3548 | .1307 | .1294 |
| Avg | .4995 | .4271 | .4210 | .4383 | .4411 | .2948 | .1389 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 201 / 11 kv NIT industrial 1

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2096 | .1715 | .1543 | .1905 | .1905 | .0171 |
| 2 | .1543 | .2096 | .1715 | .1543 | .1905 | .1905 | .0171 |
| 3 | .1543 | .2096 | .1715 | .1543 | .1905 | .1905 | .1543 |
| 4 | .1543 | .2096 | .1715 | .1372 | .1905 | .1905 | .1543 |
| 5 | .1543 | .2096 | .1905 | .1715 | .1905 | .1905 | .1543 |
| 6 | .1543 | .2096 | .1905 | .1715 | .1905 | .1905 | .1543 |
| 7 | .1543 | .1905 | .1905 | .1715 | .1905 | .1905 | .1715 |
| 8 | .1543 | .1905 | .1905 | .1715 | .1905 | .1905 | .2058 |
| 9 | .1543 | .1905 | .1715 | .1715 | .1905 | .1905 | .0857 |
| 10 | .1715 | .1715 | .1715 | .1905 | .1543 | .1715 | .0857 |
| 11 | .1715 | .1715 | .1886 | .1905 | .1543 | .1543 | .12 |
| 12 | .1543 | .1543 | .1886 | .1905 | .1543 | .1543 | .1372 |
| 13 | .1715 | .1715 | .1715 | .1905 | .1543 | .1715 | .1372 |
| 14 | .1543 | .1715 | .1886 | | .1543 | .1715 | .12 |
| 15 | .1715 | .1715 | .1715 | .1905 | .1543 | .1715 | .12 |
| 16 | .1715 | .1715 | .1715 | .1905 | .1543 | .1715 | .1372 |
| 17 | .1543 | .1543 | .1543 | .1905 | .1543 | .1543 | .1372 |
| 18 | .1905 | .1905 | .1543 | .1905 | .1543 | .1543 | .1524 |
| 19 | .1905 | .1905 | .1715 | .1905 | .1905 | .1715 | .1524 |
| 20 | .2096 | .1905 | .1715 | .1905 | .1905 | .1715 | .1524 |
| 21 | .2096 | .1905 | .1543 | .1905 | .1905 | .1715 | .1524 |
| 22 | .2096 | .1905 | .1543 | .1905 | .1905 | .1543 | .1524 |
| 23 | .2096 | .1905 | .1543 | .1905 | .1905 | .1543 | .1524 |
| 24 | | .2096 | .1715 | .1543 | .1905 | .1905 | .1543 |
| Max | .2096 | .2096 | .1905 | .1905 | .1905 | .1905 | .2058 |
| Min | .1543 | .1543 | .1543 | .1372 | .1543 | .1543 | .0171 |
| Avg | .1708 | .1883 | .1732 | .1778 | .1769 | .1751 | .1324 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 202 / 11 KV MAHURZARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0857 | | .2286 | .1886 | .2667 | .2286 | .2915 |
| 2 | .0857 | | .2286 | .1886 | .2477 | .2286 | .2401 |
| 3 | .0857 | | .2096 | .1715 | .2477 | .2286 | .2401 |
| 4 | .0857 | | .2286 | .1715 | .2477 | .2286 | .2401 |
| 5 | .0857 | | .2667 | .2058 | .2477 | .2286 | .2401 |
| 6 | .0857 | | .2667 | .1886 | .2477 | .2477 | .2401 |
| 7 | .1886 | | .3048 | .2058 | .2477 | .2477 | .2229 |
| 8 | .2058 | .0572 | .2858 | .2229 | .2667 | .2667 | .2572 |
| 9 | .2229 | .0572 | .2915 | .2401 | .381 | .3048 | .2915 |
| 10 | .2915 | .0514 | .2915 | .381 | .3258 | .3258 | .2915 |
| 11 | .2058 | .0514 | .3429 | .381 | .3944 | .3772 | .3086 |
| 12 | .2572 | .1372 | .3429 | .381 | .4287 | .3772 | .3258 |
| 13 | .2229 | .1886 | .3601 | .3429 | .3429 | .3772 | .3258 |
| 14 | .2572 | .2058 | .2401 | .2667 | .2743 | .2401 | .2743 |
| 15 | .2572 | .1543 | .3086 | .3048 | .2743 | .2401 | .3086 |
| 16 | .2401 | .2229 | .3601 | .2667 | .3429 | .2743 | .3086 |
| 17 | .2915 | .2743 | .3429 | .2286 | .2743 | .3601 | .3429 |
| 18 | .3048 | .4001 | .2743 | .2477 | .2401 | .2743 | .3239 |
| 19 | .3429 | .381 | .2743 | .2667 | .2858 | .2743 | .3239 |
| 20 | .2477 | .3239 | .2572 | .2667 | .2858 | .2572 | .3239 |
| 21 | .2477 | .3429 | .2401 | .2667 | .3048 | .2229 | .2667 |
| 22 | .2667 | .2667 | .2229 | .2477 | .2858 | .2743 | .2667 |
| 23 | .2667 | .2858 | .2058 | .2667 | .2667 | .2229 | .2477 |
| 24 | | .2667 | .2286 | .2058 | .2667 | .2667 | .2229 |
| Max | .3429 | .4001 | .3601 | .381 | .4287 | .3772 | .3429 |
| Min | .0857 | .0514 | .2058 | .1715 | .2401 | .2229 | .2229 |
| Avg | .2101 | .2157 | .2751 | .2543 | .2914 | .2739 | .2802 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 203 / 11 kv Bodhala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2401 | .2915 | .362 | .2915 | .381 | .4001 | .3944 |
| 2 | .2401 | .2915 | .362 | .2915 | .381 | .4001 | .3601 |
| 3 | .2229 | .2915 | .3429 | .2572 | .3429 | .4001 | .3601 |
| 4 | .2229 | .3086 | .3429 | .2572 | .3429 | .4001 | .3601 |
| 5 | .2401 | .3258 | .4191 | .2743 | .3429 | .4572 | .3601 |
| 6 | .2401 | .3258 | .4954 | .3086 | .3086 | .4954 | .3601 |
| 7 | .2743 | .4458 | .5335 | .3772 | .463 | .5144 | .463 |
| 8 | .3944 | .463 | .5906 | .4973 | .5658 | .6859 | .6344 |
| 9 | .4287 | .6173 | .583 | .583 | .8383 | .8002 | .7888 |
| 10 | .3944 | .4973 | .2743 | .583 | .6859 | .6859 | .7888 |
| 11 | .3944 | .463 | .4287 | .6001 | .6859 | .6173 | .6859 |
| 12 | .3944 | .4458 | .5316 | .6516 | .3429 | .8059 | .7888 |
| 13 | .3944 | .463 | .6001 | .6001 | .2915 | .7373 | .823 |
| 14 | .4115 | .463 | .583 | .6516 | .5487 | .6859 | .7888 |
| 15 | .4287 | .4287 | .5316 | .5144 | .7888 | .7373 | .7716 |
| 16 | .4287 | .5144 | .583 | .5658 | .8059 | .7545 | .8745 |
| 17 | .463 | .463 | .5487 | .583 | .823 | .8573 | .2058 |
| 18 | .5487 | .4954 | .4973 | .5144 | .6516 | .703 | .743 |
| 19 | .4973 | .5335 | .4458 | .463 | .6097 | .5658 | .6668 |
| 20 | .4801 | .5335 | .4287 | .4458 | .5335 | .5316 | .6097 |
| 21 | .3944 | .4954 | .4115 | .4458 | .5144 | .4801 | .5716 |
| 22 | .3429 | .4191 | .3601 | .4115 | .4763 | .4115 | .5144 |
| 23 | .3429 | .381 | .3258 | .4572 | .4382 | .9945 | .4954 |
| 24 | | .3429 | .362 | .2915 | .4191 | .4001 | .3944 |
| Max | .5487 | .6173 | .6001 | .6516 | .8383 | .9945 | .8745 |
| Min | .2229 | .2915 | .2743 | .2572 | .2915 | .4001 | .2058 |
| Avg | .3661 | .4292 | .4560 | .4549 | .5242 | .6051 | .5752 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 204 / 11 kv fetari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | .2328 | .1524 | .1543 | .2328 | .1715 | .2058 |
| 2 | .1543 | .1791 | .1524 | .1372 | .2328 | .1715 | .2058 |
| 3 | .1543 | .1791 | .1905 | .12 | .2328 | .1715 | .2058 |
| 4 | .1543 | .1791 | .1905 | .1372 | .1791 | .1715 | .2058 |
| 5 | .1543 | .1791 | .2286 | .1372 | .1791 | .1905 | .2058 |
| 6 | .1543 | .1791 | .2286 | .1372 | .1791 | .2286 | .2229 |
| 7 | .1543 | .2686 | .2667 | .1715 | .2507 | .2477 | .2401 |
| 8 | .1543 | .2865 | .3239 | .2743 | .3403 | .3429 | .3772 |
| 9 | .1543 | .3403 | .3429 | .3601 | .394 | .381 | .4801 |
| 10 | .2743 | .2743 | .3772 | .394 | .4287 | .3772 | .4801 |
| 11 | .3258 | .2058 | .3429 | .3761 | .4115 | .2915 | .4801 |
| 12 | .2229 | .2058 | .3258 | .3761 | .3086 | .2743 | .4115 |
| 13 | | .1886 | .2915 | .3403 | .3086 | .3086 | .4115 |
| 14 | .2229 | .2401 | .3086 | .3224 | .2915 | .2743 | .3601 |
| 15 | .2058 | .2743 | .2915 | .3582 | .3258 | .3258 | .3944 |
| 16 | .2058 | .2915 | .3086 | .3582 | .3601 | .4287 | .4458 |
| 17 | .2401 | .2915 | .2915 | .3045 | .3258 | .3772 | .4115 |
| 18 | .2686 | .3429 | .3429 | .2686 | .2743 | .3258 | .4001 |
| 19 | .3045 | .3429 | .3086 | .2686 | .3048 | .2401 | .362 |
| 20 | .2686 | .3048 | .2401 | .2686 | .2667 | .2572 | .3239 |
| 21 | .2667 | .2477 | .2229 | .2507 | .2667 | .2229 | .3239 |
| 22 | .2328 | .2096 | .2058 | .2328 | .2477 | .2058 | .2858 |
| 23 | .2328 | .1715 | .1886 | .2507 | .2286 | .2058 | .2667 |
| 24 | | .2328 | .1524 | .1543 | .2507 | .1905 | .2058 |
| Max | .3258 | .3429 | .3772 | .394 | .4287 | .4287 | .4801 |
| Min | .1543 | .1715 | .1524 | .12 | .1791 | .1715 | .2058 |
| Avg | .2118 | .2437 | .2615 | .2564 | .2842 | .2659 | .3297 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 205 / 11 kv industrial 2 jain

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 2 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 3 | .0171 | | .0191 | .0171 | .0191 | .0191 | .0171 |
| 4 | .0171 | | .0191 | .0171 | .0191 | .0191 | .0171 |
| 5 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 6 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 7 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 8 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 9 | .0171 | .0191 | .0171 | .0171 | .0191 | .0191 | .0171 |
| 10 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 11 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 12 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 13 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 14 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 15 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 16 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 17 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 18 | .0191 | .0191 | .0171 | .0191 | .0171 | | .0191 |
| 19 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 20 | .0191 | .0191 | .0171 | | .0191 | .0171 | .0191 |
| 21 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 22 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 23 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 24 | | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| Max | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Min | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| Avg | .0176 | .0184 | .0179 | .0182 | .0184 | .0180 | .0176 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 164079 / 33 kv Fetari sub station

Feeder No / Name : 207 / 11 kv station transformer

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 2 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 3 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 4 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 5 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 6 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 7 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 8 | .0171 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| 9 | .0171 | .0191 | .0171 | .0171 | .0191 | .0191 | .0171 |
| 10 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | |
| 11 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 12 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 13 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 14 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 15 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 16 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 17 | .0171 | .0171 | .0171 | .0191 | .0171 | .0171 | .0171 |
| 18 | .0191 | .0191 | .0171 | .0191 | .0171 | .0171 | .0191 |
| 19 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 20 | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 21 | | .0191 | .0171 | .0191 | .0191 | .0171 | .0191 |
| 22 | .0191 | .0191 | .0171 | .0191 | .0191 | | .0191 |
| 23 | .0191 | .0191 | .0171 | .0191 | .0191 | | .0191 |
| 24 | | .0191 | .0191 | .0171 | .0191 | .0191 | .0171 |
| Max | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 | .0191 |
| Min | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 | .0171 |
| Avg | .0176 | .0184 | .0179 | .0183 | .0184 | .0180 | .0176 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 201 / 11 KV VIHIRGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9 | 1.3717 | 1.3717 | | 1.3717 | 1.3717 | 1.4575 | 1.286 |
| 10 | | | 1.1145 | | | | |
| Max | 1.3717 | 1.3717 | 1.1145 | 1.3717 | 1.3717 | 1.4575 | 1.286 |
| Min | 1.3717 | 1.3717 | 1.1145 | 1.3717 | 1.3717 | 1.4575 | 1.286 |
| Avg | 1.3717 | 1.3717 | 1.1145 | 1.3717 | 1.3717 | 1.4575 | 1.286 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 213 / 11 kV Hudkeshwar Urban 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9 | 1.9052 | 1.9052 | 1.9052 | 1.8099 | 2.0005 | 2.0005 | .1905 |
| Max | 1.9052 | 1.9052 | 1.9052 | 1.8099 | 2.0005 | 2.0005 | .1905 |
| Min | 1.9052 | 1.9052 | 1.9052 | 1.8099 | 2.0005 | 2.0005 | .1905 |
| Avg | 1.9052 | 1.9052 | 1.9052 | 1.8099 | 2.0005 | 2.0005 | .1905 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

HUDKESHWAR SDN.[367] BU 3905

Substation No/ Name :- 167017 / 132 KV BESA

Feeder No / Name : 401 / 33 KV BESA LUXORA KHAPARI

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9 | .1543 | .1029 | .1029 | .1029 | .1029 | .1029 | .1029 |
| 23 | | .1029 | | | | | |
| Max | .1543 | .1029 | .1029 | .1029 | .1029 | .1029 | .1029 |
| Min | .1543 | .1029 | .1029 | .1029 | .1029 | .1029 | .1029 |
| Avg | .1543 | .1029 | .1029 | .1029 | .1029 | .1029 | .1029 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 201 / Temple Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1829 | .1886 | .1886 | .1886 | .2075 | .1886 | .2263 |
| 2 | .1829 | .1886 | .1886 | .1886 | .2075 | .1886 | .2263 |
| 3 | .1829 | .1886 | .1886 | .1886 | .2075 | .1886 | .2263 |
| 4 | .1848 | .1886 | .1886 | .1886 | .2075 | .1886 | .2263 |
| 5 | .1848 | .1886 | .1886 | .1905 | .1905 | .1886 | .2263 |
| 6 | .1867 | .1886 | .1886 | .1905 | .1905 | .1886 | .2263 |
| 7 | .2075 | .2075 | .2263 | .2096 | .2096 | .2075 | .2641 |
| 8 | .2263 | .2263 | .2075 | .2286 | .2263 | .2452 | |
| 9 | .2241 | .2075 | .1905 | .1715 | .2286 | .2286 | |
| 10 | .2054 | .2263 | .2667 | .2286 | .2263 | .2667 | .2452 |
| 11 | .3772 | .3018 | .3429 | .2667 | .3018 | .3395 | .5228 |
| 12 | .2896 | .4904 | .4191 | .381 | .415 | .4904 | .3742 |
| 13 | .4207 | .4715 | .4527 | .3772 | .4904 | .5281 | .5228 |
| 14 | .4338 | .4715 | .4715 | .3772 | .4904 | .5281 | .5093 |
| 15 | .4527 | .4338 | .5093 | .4191 | .5093 | .547 | .4904 |
| 16 | .4527 | .4527 | .4715 | .4382 | .5281 | .5093 | .4904 |
| 17 | .4715 | .5281 | .4715 | .4338 | .5281 | .547 | .5847 |
| 18 | .5415 | .5975 | .6099 | .5093 | .6348 | .6535 | .6535 |
| 19 | .6348 | .6161 | .6908 | .5658 | .6908 | .7023 | .7468 |
| 20 | .6161 | .6161 | .6535 | .5093 | .6722 | .6908 | .7282 |
| 21 | .4108 | .5228 | .4668 | .4481 | .4904 | .5281 | .5093 |
| 22 | .2427 | .2427 | .2801 | .2614 | .2801 | .3961 | .3018 |
| 23 | .2054 | .2263 | .2427 | .2241 | .2427 | .2263 | .2263 |
| 24 | .1867 | .1886 | .1886 | .1886 | .2075 | .2241 | .2263 |
| Max | .6348 | .6161 | .6908 | .5658 | .6908 | .7023 | .7468 |
| Min | .1829 | .1886 | .1886 | .1715 | .1905 | .1886 | .2263 |
| Avg | .3210 | .3400 | .3456 | .3072 | .3576 | .3746 | .3979 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 202 / Station Transformer No I SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0126 | .0133 | .0139 | .0141 | .0141 | .0137 | .0139 |
| 2 | .0126 | .0133 | .0139 | .0141 | .0141 | .0137 | .0139 |
| 3 | .0126 | .0133 | .0139 | .0141 | .0141 | .0137 | .0139 |
| 4 | .0126 | .0124 | .0139 | .0143 | .0137 | .0137 | .0139 |
| 5 | .0124 | .0124 | .0139 | .0143 | .0137 | .0133 | .0133 |
| 6 | .0124 | .0114 | .0139 | .0143 | .0133 | .0133 | .0133 |
| 7 | .012 | .0114 | .0139 | .0143 | .0133 | .0133 | .013 |
| 8 | .0118 | .0111 | .0137 | .0122 | .013 | .0133 | |
| 9 | .0137 | .013 | .0124 | .0141 | .0114 | .0124 | |
| 10 | .016 | .0152 | .0171 | .0171 | .0171 | .0171 | .0171 |
| 11 | .0373 | .0187 | .0179 | .0171 | .0171 | .0343 | |
| 12 | .056 | .0373 | .0183 | .0343 | .0377 | .0373 | .0373 |
| 13 | .0566 | .0566 | .0377 | .0343 | .0566 | .0566 | .0373 |
| 14 | .0566 | .056 | .0377 | .0343 | .0554 | .0566 | .0373 |
| 15 | .0566 | .056 | .0566 | | .0554 | .0572 | .056 |
| 16 | .056 | .0572 | .0566 | .0514 | .0739 | .056 | .056 |
| 17 | .0566 | .0566 | .0566 | .0514 | .0747 | .0566 | .056 |
| 18 | .0566 | .0554 | .0724 | .0492 | .0739 | .0747 | .056 |
| 19 | .0732 | .0895 | .0886 | .081 | .1075 | .0895 | .0724 |
| 20 | .0732 | .0716 | .0895 | .0663 | .0886 | .0895 | .0716 |
| 21 | .0724 | .0716 | .0514 | .0497 | .0554 | .0747 | .0716 |
| 22 | .0312 | .0154 | .0154 | .0305 | .0154 | .0324 | .0343 |
| 23 | .0141 | .0147 | .0145 | .0145 | .0151 | .0151 | .0343 |
| 24 | .0133 | .0133 | .0139 | .0141 | .1551 | .0139 | .0139 |
| Max | .0732 | .0895 | .0895 | .081 | .1551 | .0895 | .0724 |
| Min | .0118 | .0111 | .0124 | .0122 | .0114 | .0124 | .013 |
| Avg | .0349 | .0332 | .0320 | .0292 | .0425 | .0367 | .0355 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 203 / Station Transformer No II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0179 | .0191 | .0183 | .0185 | .0185 | .0185 | .0185 |
| 2 | .0179 | .0191 | .0183 | .0185 | .0187 | .0185 | .0185 |
| 3 | .0179 | .0191 | .0183 | .0185 | .0187 | .0185 | .0185 |
| 4 | .0181 | .0191 | .0183 | .0185 | .0187 | .0185 | .0185 |
| 5 | .0181 | .0191 | .0183 | .0185 | .0187 | .0185 | .0189 |
| 6 | .0181 | .0191 | .0187 | .0189 | .0187 | .0185 | .0189 |
| 7 | .0185 | .0189 | .0381 | .0191 | .0187 | .0185 | .0381 |
| 8 | .0373 | .037 | .0362 | .0381 | .0187 | .037 | |
| 9 | .0373 | .0185 | .0185 | | .037 | .0373 | .0381 |
| 10 | .037 | .0381 | .0381 | .0191 | .0373 | .0381 | .0566 |
| 11 | .1109 | .0924 | .1097 | .0185 | .0934 | .1109 | .0754 |
| 12 | .128 | .1294 | .1097 | .0747 | .112 | .1478 | .132 |
| 13 | .128 | .1097 | .128 | .0914 | .1109 | .1478 | .132 |
| 14 | .1097 | .128 | .128 | .0914 | .1109 | .1294 | |
| 15 | .1097 | .128 | .1294 | .1097 | .1294 | .128 | .128 |
| 16 | .1097 | .1109 | .1109 | .1097 | .128 | .1463 | .128 |
| 17 | .128 | .1097 | .1109 | .0914 | .1267 | .1294 | .1448 |
| 18 | .1227 | .1227 | .1402 | .1187 | .1402 | .124 | .1433 |
| 19 | .1433 | .1402 | .1417 | .1433 | .1595 | .1433 | .1612 |
| 20 | .1417 | .1417 | .1595 | .124 | .1402 | .1595 | .1612 |
| 21 | .1433 | .1612 | .1075 | .1214 | .1402 | .1629 | .1612 |
| 22 | .0724 | .0739 | .0905 | .0739 | .0537 | .0943 | .0732 |
| 23 | .0373 | .0358 | .0366 | .0366 | .0362 | .0381 | .0377 |
| 24 | .0179 | .0191 | .0189 | .0185 | .0185 | .0191 | .0185 |
| Max | .1433 | .1612 | .1595 | .1433 | .1595 | .1629 | .1612 |
| Min | .0179 | .0185 | .0183 | .0185 | .0185 | .0185 | .0185 |
| Avg | .0725 | .0721 | .0734 | .0613 | .0718 | .0801 | .0791 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 207 / Zero Mile

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5041 | .5083 | .5658 | .5658 | .5596 | .571 | .6838 |
| 2 | .5041 | .5083 | .5658 | .5658 | .5596 | .571 | .6838 |
| 3 | .5041 | .5083 | .5658 | .5658 | .5596 | .571 | .6344 |
| 4 | .5041 | .5083 | .5658 | .5658 | .5596 | .571 | .6344 |
| 5 | .4887 | .5138 | .5487 | .5487 | .5426 | .5639 | .6344 |
| 6 | .4887 | .5138 | .5487 | .5487 | .5426 | .5639 | .6173 |
| 7 | .5138 | .5493 | .5487 | .5487 | .5426 | .5639 | .5535 |
| 8 | .5258 | .5601 | .5365 | .5596 | .5468 | .5639 | |
| 9 | .5256 | .5556 | .547 | .5596 | .5535 | .5937 | .6344 |
| 10 | .6173 | .6062 | .6001 | .5658 | .6516 | .6687 | .6516 |
| 11 | .6859 | .6687 | .7011 | .583 | .6859 | .7545 | .6687 |
| 12 | .6687 | .6706 | .6687 | .6516 | .6859 | .6935 | .6859 |
| 13 | .6687 | .6539 | .6687 | .6516 | .6687 | .6859 | |
| 14 | .6859 | .6706 | .6173 | .6344 | .6859 | .6859 | .6859 |
| 15 | .6722 | .6796 | .6859 | .6344 | .6859 | .6859 | .6859 |
| 16 | .6687 | .7108 | .6859 | .6516 | .6859 | .6859 | .6859 |
| 17 | .6859 | .6464 | .6859 | .6344 | .6859 | .6859 | .6859 |
| 18 | .6062 | | .6316 | .5864 | .639 | .6554 | .6859 |
| 19 | .5851 | .639 | .6241 | .6009 | .6554 | .6554 | .6687 |
| 20 | .5851 | .6241 | .6009 | .5792 | .6241 | .6401 | .6687 |
| 21 | .5556 | .5937 | .5921 | .6009 | .6081 | .5864 | .6173 |
| 22 | .5487 | .5895 | .5992 | .583 | .6009 | .6001 | .6344 |
| 23 | .5493 | .5895 | .5765 | .5658 | .6009 | .5853 | .6173 |
| 24 | .5014 | .5083 | .5658 | .5658 | .5596 | .6081 | .5729 |
| Max | .6859 | .7108 | .7011 | .6516 | .6859 | .7545 | .6859 |
| Min | .4887 | .5083 | .5365 | .5487 | .5426 | .5639 | .5535 |
| Avg | .5768 | .5903 | .6040 | .5882 | .6121 | .6254 | .6496 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 209 / 11 KV Mure Memorial

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0293 | .029 | .0354 | .037 | .0373 | .0354 | .037 |
| 2 | .0293 | .029 | .0354 | .037 | .0373 | | .037 |
| 3 | .0293 | .029 | .0354 | .037 | .0373 | .0354 | .037 |
| 4 | .0305 | .0305 | .0354 | .0373 | .0362 | .0354 | .037 |
| 5 | .0305 | .0305 | .0358 | .0373 | .0362 | .0354 | .0366 |
| 6 | .0324 | .0305 | .0358 | .0373 | .0343 | .0343 | .0366 |
| 7 | .0324 | .0309 | .0358 | .0373 | .0339 | .0343 | .0366 |
| 8 | .0857 | .0309 | .032 | .0324 | .032 | .0328 | |
| 9 | .0324 | .0328 | .032 | .0354 | .0332 | .0332 | .0351 |
| 10 | .0381 | .0377 | .0381 | .056 | .0373 | .0572 | .037 |
| 11 | .0377 | .0373 | .0566 | .037 | .0373 | .0566 | .0377 |
| 12 | .0373 | .037 | .0566 | .0358 | .056 | .0566 | .0377 |
| 13 | .0373 | .0354 | .0754 | .0377 | .0747 | .0566 | .0377 |
| 14 | .056 | .0377 | | .056 | .0554 | .0566 | .0566 |
| 15 | .0377 | .0377 | .0572 | .0549 | .0754 | .0572 | .056 |
| 16 | .0572 | .0377 | .0566 | .0362 | .0762 | .0572 | .056 |
| 17 | .0566 | .0381 | .0566 | .0347 | .0754 | .0572 | .0566 |
| 18 | .0566 | .0572 | .0566 | .056 | .0572 | .0572 | .037 |
| 19 | .0554 | .0762 | .0762 | .0762 | .0566 | .0762 | .0572 |
| 20 | .0572 | .0572 | .0754 | .0762 | .0572 | .0754 | .0572 |
| 21 | .0354 | .0381 | .0566 | .0566 | .0381 | .056 | .0566 |
| 22 | .0366 | .0366 | .0572 | .0377 | .0377 | .0373 | .0377 |
| 23 | .0328 | .0362 | .0377 | .0373 | .037 | .0373 | .037 |
| 24 | .0305 | .029 | .0354 | .037 | .0373 | .0362 | .037 |
| Max | .0857 | .0762 | .0762 | .0762 | .0762 | .0762 | .0572 |
| Min | .0293 | .029 | .032 | .0324 | .032 | .0328 | .0351 |
| Avg | .0414 | .0376 | .0481 | .0439 | .0469 | .0481 | .0430 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 211 / 11KV Variety Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0187 | .0185 | .0377 | .0373 | .0377 | .0377 | .0381 |
| 2 | .0187 | .0185 | .0377 | .0373 | .0377 | .0377 | .0381 |
| 3 | .0187 | .0185 | .0377 | .0373 | .0377 | .0377 | .0381 |
| 4 | .0187 | .0185 | .0381 | .0373 | .0373 | .0377 | .0381 |
| 5 | .0187 | .0187 | .0381 | .0187 | .0187 | .0377 | .0377 |
| 6 | .0187 | .0187 | .0381 | .0187 | .0185 | .0373 | .0377 |
| 7 | .0187 | .0187 | .0381 | .0187 | .0185 | .0373 | .0373 |
| 8 | .0187 | .0373 | .0373 | .0381 | .0191 | .0373 | |
| 9 | .0381 | .0373 | .037 | .0187 | .0373 | .0381 | .0377 |
| 10 | .0377 | .0373 | .056 | .0373 | .0373 | .0373 | .0377 |
| 11 | .0381 | .0377 | .056 | .0373 | .0373 | .0381 | .0566 |
| 12 | .056 | .0381 | .0566 | .0381 | .0373 | .0572 | .0566 |
| 13 | .0381 | .0566 | .0566 | .0381 | .0373 | .0572 | .0566 |
| 14 | .0381 | .0381 | .0566 | .0566 | .0381 | .056 | .0572 |
| 15 | .0381 | .0566 | .0377 | .0566 | .0572 | .056 | .0572 |
| 16 | .0373 | .0566 | .037 | .0566 | .0566 | .0566 | .0572 |
| 17 | .0381 | .0566 | .037 | .0377 | .056 | .0566 | .056 |
| 18 | .0373 | .0377 | .056 | .0373 | .0566 | .0747 | .0754 |
| 19 | .0572 | .0566 | .0566 | .0566 | .0747 | .056 | .0754 |
| 20 | .0572 | .0566 | .0754 | .0377 | .0754 | .056 | .0754 |
| 21 | .0572 | .0566 | .0566 | .0373 | .056 | .0566 | .0754 |
| 22 | .0373 | .0381 | .0377 | .0377 | .0566 | .0377 | .0572 |
| 23 | .0381 | .0377 | .0381 | .0377 | .0377 | .0377 | .0572 |
| 24 | .0191 | .0185 | .0377 | .0373 | .0377 | .0373 | .0381 |
| Max | .0572 | .0566 | .0754 | .0566 | .0754 | .0747 | .0754 |
| Min | .0187 | .0185 | .037 | .0187 | .0185 | .0373 | .0373 |
| Avg | .0339 | .0368 | .0455 | .0376 | .0423 | .0462 | .0518 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 201 / 11 KV YASHWANT STEDIUM SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2801 | .2829 | .2829 | .2801 | .2829 | .3206 | .3395 |
| 2 | .2801 | .2829 | .2829 | .2801 | .2829 | .3206 | .2829 |
| 3 | .2801 | .2829 | .2829 | .2801 | .2641 | .3206 | .2829 |
| 4 | .2801 | .2829 | .2829 | .2801 | .2641 | .3018 | .2829 |
| 5 | .2801 | .2829 | .2829 | .2801 | .2263 | .3018 | .2829 |
| 6 | .2801 | .2829 | .2829 | .2801 | .2263 | .3018 | .2829 |
| 7 | .2801 | .3018 | .3395 | .2801 | .2829 | .3772 | .3772 |
| 8 | .3734 | .3206 | .3395 | .2801 | .3206 | .3772 | .3772 |
| 9 | .3734 | .3772 | .3772 | .2801 | .3206 | .3772 | .3772 |
| 10 | .3772 | .3734 | .3772 | .3772 | .3772 | .4715 | .3772 |
| 11 | .3772 | .3734 | .3772 | .3584 | .3772 | .3772 | .4527 |
| 12 | .4715 | .3734 | .415 | .3395 | .4527 | .415 | .4527 |
| 13 | .3772 | .3734 | .415 | .415 | .4715 | .4715 | .4715 |
| 14 | .4715 | .3734 | .415 | .3772 | | .4715 | .4715 |
| 15 | .4715 | .3734 | .415 | .3772 | .4715 | .4715 | .4527 |
| 16 | .3772 | .3734 | .415 | .3772 | .4715 | .4715 | .4715 |
| 17 | .415 | .415 | .4668 | .3206 | .4715 | .4715 | .4668 |
| 18 | .3772 | .4715 | .4668 | .3772 | .4715 | .4715 | .4668 |
| 19 | .4715 | .4715 | .4668 | .3961 | .4715 | .5281 | .4668 |
| 20 | .4338 | .4715 | .4668 | .3961 | .4715 | .4715 | .4668 |
| 21 | .3772 | .3772 | .3734 | .3772 | .4715 | .4715 | .4668 |
| 22 | .3206 | .3772 | .3734 | .3395 | .3961 | .415 | .3734 |
| 23 | .2829 | .3395 | .2801 | .3395 | .415 | .3772 | .3734 |
| 24 | .2801 | .2829 | .2829 | .2801 | .2829 | .3206 | .3772 |
| Max | .4715 | .4715 | .4668 | .415 | .4715 | .5281 | .4715 |
| Min | .2801 | .2829 | .2801 | .2801 | .2263 | .3018 | .2829 |
| Avg | .3579 | .3549 | .365 | .3320 | .3715 | .4031 | .3956 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 202 / 11 KV PUSHPAKUNJ FDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8402 | .8488 | .9431 | 1.0269 | .9431 | 1.0374 | .9431 |
| 2 | .8402 | .8488 | .9431 | 1.0269 | .8488 | .9808 | .9431 |
| 3 | .8402 | .8488 | .9431 | .9335 | .8488 | .9808 | .9431 |
| 4 | .7468 | .9431 | .9431 | .8402 | .7922 | .9431 | .9431 |
| 5 | .9335 | .9431 | .9431 | .8402 | .7922 | .9431 | .9431 |
| 6 | 1.1203 | .9431 | .9431 | .8402 | .7545 | .9431 | .9431 |
| 7 | 1.1203 | 1.1317 | 1.0374 | .8402 | .8573 | 1.1317 | 1.1317 |
| 8 | 1.2136 | 1.226 | 1.1317 | 1.0269 | 1.226 | 1.226 | 1.226 |
| 9 | .9335 | 1.226 | 1.226 | 1.0269 | 1.226 | 1.3203 | 1.226 |
| 10 | 1.226 | 1.307 | 1.3203 | 1.1317 | 1.4146 | 1.3203 | 1.4146 |
| 11 | 1.3203 | 1.1736 | 1.4146 | 1.1694 | 1.4146 | 1.5089 | 1.5089 |
| 12 | 1.226 | 1.307 | 1.3203 | 1.1145 | 1.5089 | 1.4146 | 1.5089 |
| 13 | 1.226 | 1.307 | 1.4146 | 1.226 | 1.5089 | 1.4146 | 1.5089 |
| 14 | 1.226 | 1.2136 | 1.5089 | 1.1317 | 1.6032 | 1.6032 | 1.5089 |
| 15 | 1.226 | 1.2136 | 1.5089 | 1.1317 | 1.5089 | 1.4146 | 1.5089 |
| 16 | 1.226 | 1.1203 | 1.3203 | 1.1317 | 1.4146 | 1.3203 | 1.5089 |
| 17 | 1.1317 | 1.226 | 1.2136 | .9431 | 1.4146 | 1.3203 | 1.4937 |
| 18 | 1.226 | 1.4146 | 1.2136 | 1.1317 | 1.4146 | 1.3203 | 1.307 |
| 19 | 1.226 | 1.4146 | 1.307 | 1.1317 | 1.358 | 1.5089 | 1.4003 |
| 20 | 1.1694 | 1.4146 | | 1.1694 | 1.3203 | 1.5089 | 1.307 |
| 21 | 1.226 | 1.226 | 1.2136 | 1.226 | 1.3203 | 1.5089 | 1.307 |
| 22 | 1.0374 | 1.226 | | 1.1317 | 1.1317 | 1.4146 | 1.1203 |
| 23 | .8488 | 1.1317 | 1.0269 | 1.1317 | 1.1317 | 1.226 | 1.1203 |
| 24 | .9335 | 7.7143 | 1.0374 | 1.0269 | .9431 | 1.0374 | 1.0374 |
| Max | 1.3203 | 7.7143 | 1.5089 | 1.226 | 1.6032 | 1.6032 | 1.5089 |
| Min | .7468 | .8488 | .9431 | .8402 | .7545 | .9431 | .9431 |
| Avg | 1.0860 | 1.4321 | 1.1761 | 1.0555 | 1.1957 | 1.2645 | 1.2418 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 203 / 11 KV PRESS FDR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1867 | .1886 | .1886 | .1867 | .1886 | .1886 | |
| 2 | .1867 | .1886 | .1886 | .1867 | .1886 | .1886 | .1886 |
| 3 | .1494 | .1509 | .1886 | .1494 | .1886 | .1886 | |
| 4 | .1494 | .1509 | .1886 | .1494 | .1886 | .1886 | |
| 5 | .1867 | .1509 | .1886 | .1867 | .1886 | .1886 | |
| 6 | .1867 | .1509 | .1886 | | .1886 | .1886 | |
| 7 | .1867 | .1886 | .1886 | .1867 | .1886 | .1509 | .1886 |
| 8 | .1867 | .1886 | .1886 | .1867 | .1886 | .1698 | .1886 |
| 9 | .1867 | .1886 | .1886 | .1867 | .1886 | .1886 | .1886 |
| 10 | .1886 | .1867 | .2263 | .1886 | .2263 | .2263 | .2263 |
| 11 | .2263 | .2801 | .2829 | .1886 | .2829 | .2829 | .2829 |
| 12 | .2829 | .2801 | .2829 | .1886 | .2829 | .2829 | .2829 |
| 13 | .2829 | .2801 | .2829 | .1886 | .2829 | | .2829 |
| 14 | .2829 | .3361 | .2829 | .1886 | .2829 | | .2829 |
| 15 | .2829 | .2801 | .2829 | .1886 | .2572 | .2829 | .1509 |
| 16 | .2829 | .3361 | | .1886 | .2829 | .2829 | .2829 |
| 17 | .3018 | .132 | .2801 | .1886 | .2829 | .2829 | .2801 |
| 18 | .2829 | .2829 | .2801 | .1886 | .2829 | | .2801 |
| 19 | .2829 | .2829 | .2801 | .1886 | .2829 | | .2801 |
| 20 | .2829 | .2829 | .1867 | .1886 | .2641 | | .2801 |
| 21 | .2263 | .2263 | .1867 | .1886 | .2263 | | .1867 |
| 22 | .1886 | .1886 | .1867 | .1886 | .1886 | | .1867 |
| 23 | .1886 | .1886 | .0934 | .1886 | .1886 | | .1867 |
| 24 | .1867 | .1886 | .1886 | .1867 | .1886 | .1886 | |
| Max | .3018 | .3361 | .2829 | .1886 | .2829 | .2829 | .2829 |
| Min | .1494 | .132 | .0934 | .1494 | .1886 | .1509 | .1509 |
| Avg | .2240 | .2208 | .2183 | .1846 | .2292 | .2169 | .2348 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 204 / 11 KV VIJAYANAND FDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4108 | .3772 | .3772 | .3734 | .4715 | .4715 | |
| 2 | .4108 | .3772 | .3772 | .3734 | .415 | .4287 | |
| 3 | .3734 | .3772 | .3772 | .3734 | .415 | .4715 | |
| 4 | .3734 | .3772 | .3772 | .3734 | .415 | .4715 | |
| 5 | .4668 | .3772 | .3772 | .3734 | .3772 | .4715 | |
| 6 | .4668 | .3772 | .3772 | .3734 | .3772 | .4715 | |
| 7 | .4668 | .4715 | .4715 | .3734 | .3772 | | .4715 |
| 8 | .4668 | .5658 | .415 | .4668 | .4715 | .4715 | .4715 |
| 9 | .5601 | .5658 | .5658 | .5601 | .6602 | .5658 | .5658 |
| 10 | .6602 | .5601 | .5658 | .5658 | .6602 | .6602 | .6602 |
| 11 | .6602 | .6535 | .6602 | .5658 | .6602 | .7545 | .7545 |
| 12 | .6602 | .6535 | .6602 | .5658 | .6602 | .7545 | .7922 |
| 13 | .6602 | .6535 | .6602 | .5658 | .6602 | .7545 | .7922 |
| 14 | .5658 | .6535 | .6602 | .5658 | .6602 | .7545 | .7545 |
| 15 | .5658 | .6535 | .6602 | .4715 | .6602 | .6602 | .7545 |
| 16 | .6602 | .6535 | .6602 | | .7545 | .7545 | .7545 |
| 17 | .6602 | .6602 | .6535 | .4715 | .7545 | .7545 | .7468 |
| 18 | .6602 | .7545 | .6535 | .5658 | .7922 | | 1.0269 |
| 19 | .7545 | .7545 | .7468 | .5658 | .7545 | | .8402 |
| 20 | .7545 | .7545 | .6535 | .5658 | .7545 | | .9335 |
| 21 | .5658 | .6602 | .5601 | .5658 | .6602 | | .6535 |
| 22 | .5658 | .5658 | .4668 | .4715 | .5658 | | .5601 |
| 23 | .4715 | .4715 | .4668 | .4715 | .5093 | | .4668 |
| 24 | .4668 | .3772 | .3772 | .4668 | .4715 | .4715 | |
| Max | .7545 | .7545 | .7468 | .5658 | .7922 | .7545 | 1.0269 |
| Min | .3734 | .3772 | .3772 | .3734 | .3772 | .4287 | .4668 |
| Avg | .5553 | .5561 | .5342 | .4820 | .5816 | .5966 | .7058 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 205 / 11KV CHHOTI DHANTOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0747 | .0943 | .0943 | .0747 | .0943 | .0943 | |
| 2 | .0747 | .0943 | .0943 | .0747 | .0943 | .0943 | |
| 3 | .0747 | .0754 | .0943 | .0747 | .0943 | .0943 | |
| 4 | .0747 | .0754 | .0943 | .0747 | .0943 | .0943 | |
| 5 | .0747 | .0754 | .0943 | .0747 | .0943 | .0943 | |
| 6 | .0747 | .0754 | .0943 | .0747 | .0943 | .0943 | |
| 7 | .0747 | .0943 | .0943 | .0747 | .0943 | .0754 | .0943 |
| 8 | .0747 | .0943 | .0943 | .0747 | .0943 | .0943 | .0943 |
| 9 | .0934 | .132 | .0943 | .0747 | .132 | .1132 | .0943 |
| 10 | .0943 | .1307 | .1509 | .0943 | .1509 | .1509 | .132 |
| 11 | .0943 | .112 | .1886 | .1132 | .1886 | .1886 | .132 |
| 12 | .0943 | .0934 | .1509 | .132 | .1886 | | .1509 |
| 13 | .132 | .0934 | .132 | .0943 | .1509 | .132 | .132 |
| 14 | .132 | .1307 | .132 | .0943 | .1509 | .132 | .1886 |
| 15 | .132 | .1307 | .132 | .0943 | .132 | .1509 | .1509 |
| 16 | .132 | .0934 | | .0943 | .132 | .1509 | .1509 |
| 17 | .1132 | .132 | .0934 | .0857 | .132 | .0943 | .1494 |
| 18 | .132 | .1509 | .112 | .0943 | .1886 | | .1307 |
| 19 | .1886 | .1886 | .1307 | .132 | .1886 | | .1307 |
| 20 | .1886 | .1886 | .0934 | .0943 | .132 | .1886 | .0934 |
| 21 | .132 | .1509 | .0934 | .0943 | .132 | | .0934 |
| 22 | .0943 | .0943 | .0934 | .0943 | .0943 | | .0934 |
| 23 | .0943 | .0943 | .0934 | .0943 | .0943 | | .0747 |
| 24 | .0934 | .0943 | .0943 | .0934 | .0943 | .0943 | |
| Max | .1886 | .1886 | .1886 | .132 | .1886 | .1886 | .1886 |
| Min | .0747 | .0754 | .0934 | .0747 | .0943 | .0754 | .0747 |
| Avg | .1058 | .1120 | .1104 | .0905 | .1265 | .1184 | .1227 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 201 / 11 KV DEO NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2801 | | .2801 | .2987 | .2401 | .3174 | .3734 |
| 2 | .2801 | .2401 | .2801 | .2987 | .2401 | | .3734 |
| 3 | .2801 | .2401 | .2801 | .2801 | .2401 | .2987 | .3547 |
| 4 | .2801 | .2401 | .2614 | .2801 | .2401 | .2987 | .3547 |
| 5 | .3361 | .2401 | .2614 | .2801 | .2401 | .3361 | .3547 |
| 6 | .3361 | .3258 | .2987 | .2801 | .2572 | .3361 | .3547 |
| 7 | .3734 | .3258 | .3361 | .2801 | .2572 | .3734 | .3734 |
| 8 | .3734 | .3429 | .3734 | .3361 | .2915 | .3734 | .3734 |
| 9 | .4108 | .2915 | .3734 | .3734 | .3429 | .3734 | .4108 |
| 10 | .3734 | .3429 | .3734 | .3361 | .3086 | .3734 | .3734 |
| 11 | .3734 | | .4119 | .3189 | .3734 | .394 | .3582 |
| 12 | .3734 | .3086 | .3761 | .3189 | .3734 | .3582 | .3582 |
| 13 | .3361 | .2572 | .3582 | .3189 | .3361 | .3403 | .3582 |
| 14 | .2801 | .2572 | .3224 | .2896 | .3174 | .3224 | .3582 |
| 15 | .2801 | .2572 | .3045 | .2804 | .3174 | .3224 | .3403 |
| 16 | .3174 | .2572 | .333 | .2658 | .3734 | .3403 | .3761 |
| 17 | .3361 | .3361 | .3601 | .2658 | .3734 | .3582 | .362 |
| 18 | .3429 | .4108 | .3734 | .3258 | .4294 | .4481 | .4481 |
| 19 | .3944 | .4668 | .4668 | .3429 | .4668 | .4668 | .4668 |
| 20 | .3601 | .4108 | .4481 | .3429 | .4668 | .4668 | .4668 |
| 21 | .3601 | .4481 | .4294 | .3429 | .4294 | .4481 | .4481 |
| 22 | .3258 | .3734 | .4108 | .1715 | .3921 | .4108 | .4108 |
| 23 | .2572 | .3174 | .3734 | .2915 | .3734 | .3734 | .3734 |
| 24 | .2614 | .2572 | .2801 | .2987 | .2572 | .3174 | .3174 |
| Max | .4108 | .4668 | .4668 | .3734 | .4668 | .4668 | .4668 |
| Min | .2572 | .2401 | .2614 | .1715 | .2401 | .2987 | .3174 |
| Avg | .3301 | .3158 | .3486 | .3008 | .3307 | .3673 | .3808 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 202 / 11 KV NERI NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1867 | .1715 | .1848 | .1867 | .1543 | .1848 | .1867 |
| 2 | .1867 | .1715 | .1848 | .1867 | .1543 | .1848 | .1867 |
| 3 | .1867 | .1715 | .1848 | .1867 | .1543 | .1848 | .1867 |
| 4 | .1867 | .1715 | .1478 | .1867 | .1543 | .1848 | .1867 |
| 5 | .1867 | .1715 | .1478 | .1867 | .1543 | .1848 | .1867 |
| 6 | .1867 | .1715 | .1478 | .1867 | .1715 | .1478 | .1867 |
| 7 | .1867 | .1715 | .1848 | .1867 | .1715 | .1478 | .1867 |
| 8 | .2241 | .1715 | .2033 | .1867 | .1715 | .1848 | .1867 |
| 9 | .2427 | .2058 | .2218 | .1867 | .1886 | .2218 | .2614 |
| 10 | .2241 | .2058 | .2218 | .2241 | .2058 | .2772 | .2801 |
| 11 | .2402 | | .2429 | .2035 | .2614 | .3109 | .2743 |
| 12 | .2772 | .2401 | .1619 | .2058 | .2801 | .2896 | .2743 |
| 13 | .2772 | .2572 | .1698 | .1886 | .2801 | .2926 | .3174 |
| 14 | .2402 | .1715 | .2012 | .1524 | .2801 | .2743 | .3174 |
| 15 | .2427 | .2229 | .1619 | .1524 | .2614 | .3174 | .2987 |
| 16 | .2241 | .1715 | .1886 | .1524 | .2614 | .2801 | .2926 |
| 17 | .2614 | .2218 | .1886 | .1524 | .2614 | .2772 | .2743 |
| 18 | .2058 | .2402 | .1867 | .1715 | .2402 | .2801 | .2801 |
| 19 | .2058 | .2587 | .2614 | .1715 | .2402 | .2614 | .2614 |
| 20 | .1715 | .2218 | .2614 | .1715 | .2033 | .2241 | .2241 |
| 21 | .1715 | .1848 | .2241 | .1715 | .1848 | .1867 | .2241 |
| 22 | .1715 | .1848 | .1867 | .1715 | .1848 | .1867 | .1867 |
| 23 | .1543 | .1848 | .1867 | .1715 | .1867 | .1867 | .1867 |
| 24 | .1867 | .1715 | .1848 | .1867 | .1543 | .1848 | .1867 |
| Max | .2772 | .2587 | .2614 | .2241 | .2801 | .3174 | .3174 |
| Min | .1543 | .1715 | .1478 | .1524 | .1543 | .1478 | .1867 |
| Avg | .2095 | .1963 | .1932 | .1803 | .2067 | .2273 | .2347 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 203 / 11KV ORANGE CITY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2801 | .2572 | .3174 | .2987 | .2915 | .3734 | .4668 |
| 2 | .2801 | .2572 | .3174 | .2987 | .2915 | .3734 | .4668 |
| 3 | .2801 | .2572 | .2987 | | .2915 | .3361 | .4668 |
| 4 | .2987 | .2572 | .2987 | .2987 | .2915 | .3361 | .4481 |
| 5 | .3734 | .2572 | .3361 | .2987 | | .3361 | .4481 |
| 6 | .3734 | .3429 | .3547 | .3174 | .3086 | .3734 | .4668 |
| 7 | .4108 | .3772 | .3734 | .3174 | .3429 | .4294 | .4668 |
| 8 | .4668 | .463 | .4108 | .3361 | .3429 | .4294 | .4668 |
| 9 | .4108 | .4287 | .4481 | .4294 | .3772 | .4294 | .4668 |
| 10 | .4108 | .3944 | .4481 | .4481 | .4115 | .4668 | .4668 |
| 11 | .4668 | | .4527 | .4668 | .4481 | .4338 | .4481 |
| 12 | .3734 | .3429 | .4338 | .3772 | .4481 | .4481 | .4108 |
| 13 | .3734 | .2915 | .3772 | .4108 | .4108 | .3361 | .4668 |
| 14 | .3361 | .2743 | .3772 | .3772 | .3734 | .3174 | .4668 |
| 15 | .3361 | .2572 | .3395 | .3584 | .3734 | .3921 | .3921 |
| 16 | .2987 | .3258 | .3206 | .3584 | .4108 | .4668 | .4668 |
| 17 | .3734 | .3734 | .3772 | .3734 | .4108 | .4668 | .4668 |
| 18 | .4287 | .4108 | .4108 | .3601 | .4854 | .5041 | .4668 |
| 19 | .4458 | .4668 | .5228 | .4287 | .5041 | .5601 | .5041 |
| 20 | .4287 | .4668 | .5041 | .4287 | .4854 | .5041 | .5228 |
| 21 | .4115 | .4668 | .4668 | .4287 | .4854 | .5041 | .5228 |
| 22 | .3429 | .4668 | .4481 | .3772 | .4668 | .4668 | .4668 |
| 23 | .2915 | .3734 | .3734 | .3429 | .4108 | .3734 | .4108 |
| 24 | .2801 | .2572 | .3174 | .2987 | .3086 | .3734 | .3734 |
| Max | .4668 | .4668 | .5228 | .4668 | .5041 | .5601 | .5228 |
| Min | .2801 | .2572 | .2987 | .2987 | .2915 | .3174 | .3734 |
| Avg | .3655 | .3507 | .3885 | .3665 | .3900 | .4179 | .4590 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 204 / 11KV JAIL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .056 | .0343 | .056 | .056 | .0343 | .0747 | .0747 |
| 2 | .056 | .0343 | .056 | .056 | .0343 | .0747 | .0747 |
| 3 | .056 | .0343 | .056 | .056 | .0343 | .0747 | .0747 |
| 4 | .0373 | .0171 | .056 | .056 | .0171 | .0747 | .0747 |
| 5 | .0373 | .0171 | .0373 | .0373 | .0171 | .056 | .0747 |
| 6 | .0373 | .0171 | .0373 | .0373 | .0171 | .056 | .0373 |
| 7 | .0373 | .0171 | .0373 | .0373 | .0171 | .0373 | .0187 |
| 8 | .0187 | .0171 | .056 | .0373 | .0171 | .056 | .0187 |
| 9 | .056 | .0686 | .056 | .0747 | .0514 | .056 | .056 |
| 10 | .0747 | .0514 | .056 | .056 | .0514 | .0934 | .0747 |
| 11 | .056 | | .0732 | .0762 | .0747 | .0754 | .0716 |
| 12 | .056 | .0343 | .0549 | .0572 | .0747 | .0732 | .0724 |
| 13 | .0373 | .0343 | .0732 | .0381 | .0747 | .0732 | .0716 |
| 14 | .0373 | .0343 | .0549 | .0572 | .056 | .0549 | |
| 15 | .0373 | .0171 | .0549 | .0572 | .0747 | .0914 | .0739 |
| 16 | .0373 | .0343 | .0543 | .0572 | .0373 | .0732 | .0549 |
| 17 | .056 | .0373 | .0732 | .0377 | .0747 | .0754 | .0732 |
| 18 | .0343 | .0373 | .056 | .0343 | .0747 | .0747 | .0747 |
| 19 | .0514 | .056 | .0747 | .0514 | .0747 | .0747 | .0747 |
| 20 | .0514 | .056 | .0747 | .0514 | .0747 | .0747 | .0747 |
| 21 | .0514 | .056 | .0747 | .0514 | .0747 | .0747 | .0934 |
| 22 | .0514 | .056 | .056 | .0514 | .0747 | .0747 | .0747 |
| 23 | .0343 | .056 | .056 | .0514 | .0747 | .0747 | .0747 |
| 24 | .056 | .0343 | .056 | .056 | .0514 | .0747 | .0747 |
| Max | .0747 | .0686 | .0747 | .0762 | .0747 | .0934 | .0934 |
| Min | .0187 | .0171 | .0373 | .0343 | .0171 | .0373 | .0187 |
| Avg | .0464 | .0370 | .0579 | .0513 | .0524 | .0705 | .0669 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 205 / 11KV KANCHPURA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4481 | .3429 | .462 | .5041 | .4287 | .462 | .5601 |
| 2 | .4481 | .3429 | .462 | .5041 | .3944 | .462 | .5228 |
| 3 | .4481 | .3429 | .4435 | .4854 | .3944 | .462 | .5228 |
| 4 | .4481 | .3429 | .4435 | .4854 | .3944 | .462 | .5228 |
| 5 | .4481 | .3429 | .4805 | .4854 | .3944 | .499 | .5601 |
| 6 | .5228 | .3429 | .499 | .5228 | .3772 | .5544 | .5601 |
| 7 | .5601 | .5144 | .5175 | .5601 | .5144 | .5914 | .5601 |
| 8 | .5601 | .583 | .5544 | .5601 | .5144 | .6099 | .6348 |
| 9 | .5975 | | .6283 | .5601 | .5316 | .6099 | .6535 |
| 10 | .6348 | .5144 | .7023 | .6348 | .5658 | .6653 | .6348 |
| 11 | .6283 | | .6602 | .6478 | .6348 | .6413 | .6413 |
| 12 | .5914 | .5144 | .6602 | .6668 | .6535 | .6224 | .6224 |
| 13 | .5544 | .5144 | .679 | .6478 | .6348 | .6036 | .6036 |
| 14 | .5175 | .4287 | .5658 | .5716 | .5601 | .5658 | .6036 |
| 15 | .499 | .4287 | .5658 | .5658 | .5601 | | .5658 |
| 16 | .5175 | .463 | .547 | .5658 | .5975 | .6036 | .5847 |
| 17 | .499 | .5175 | .5658 | .5281 | .5601 | .6602 | .5658 |
| 18 | .5144 | .5544 | .5601 | .5144 | .6468 | .6535 | .5975 |
| 19 | .583 | .6468 | .6535 | .6001 | | .7095 | .6348 |
| 20 | .583 | .6468 | .6535 | .6001 | .6468 | .7095 | .6535 |
| 21 | .5144 | .6468 | .6161 | .6001 | .6468 | .7095 | .6535 |
| 22 | .4801 | .5914 | .5601 | .5658 | .6099 | .6535 | .6535 |
| 23 | .4287 | .5544 | .5601 | .5144 | .5544 | .5601 | .5975 |
| 24 | .4481 | .3944 | .462 | .5041 | .463 | .499 | .5041 |
| Max | .6348 | .6468 | .7023 | .6668 | .6535 | .7095 | .6535 |
| Min | .4287 | .3429 | .4435 | .4854 | .3772 | .462 | .5041 |
| Avg | .5198 | .4805 | .5626 | .5581 | .5338 | .5900 | .5922 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 206 / 11 KV SAI MANDIR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4668 | .4287 | .4668 | .4854 | .463 | .5041 | .5601 |
| 2 | .4668 | .4287 | .4668 | .4854 | .4287 | .5041 | .5601 |
| 3 | .4668 | .4287 | .4668 | .4854 | .4287 | .4854 | .5601 |
| 4 | .4668 | .4287 | .4668 | .4668 | .4287 | | .5601 |
| 5 | .4854 | .4287 | .4854 | .5041 | .4287 | .4668 | .5601 |
| 6 | .4854 | .4287 | .5041 | .5041 | .463 | .4854 | .5601 |
| 7 | .5228 | .4973 | .5228 | .5415 | .463 | .5228 | .5601 |
| 8 | .5228 | .5144 | .5601 | .5228 | .4973 | .5601 | .5601 |
| 9 | .5601 | .5144 | .6161 | .5601 | .5144 | .5601 | .5975 |
| 10 | .5601 | .5316 | .5975 | .5601 | .5144 | .6535 | .5601 |
| 11 | .6348 | | .5847 | .5847 | .5975 | .6602 | .6224 |
| 12 | .5601 | .5144 | .5847 | .5658 | .6348 | .6413 | .4715 |
| 13 | .5601 | .5144 | .5847 | .547 | .6348 | .6224 | .6602 |
| 14 | .5228 | .5144 | .5847 | .5658 | .5601 | .6413 | .6602 |
| 15 | .5228 | .4458 | .5658 | .5658 | .5601 | | .6224 |
| 16 | .4854 | .5144 | .5281 | .5658 | .6161 | .4715 | .6413 |
| 17 | .5601 | .6161 | .5658 | .5658 | .6348 | .6413 | .6413 |
| 18 | .6001 | .6535 | .6535 | .5316 | .6722 | .6535 | .6908 |
| 19 | .6344 | .7095 | .6535 | .6001 | .6908 | .7468 | .7468 |
| 20 | .6001 | .6535 | .6535 | .6001 | .7095 | .7468 | .7095 |
| 21 | .6001 | .6535 | .6535 | .583 | .6535 | .6908 | .6535 |
| 22 | .5144 | .5975 | .5975 | .5144 | .6161 | .6535 | .6535 |
| 23 | .4801 | .5601 | .5601 | .5144 | .5601 | .5601 | .5975 |
| 24 | .4668 | .4287 | .4668 | .4854 | .463 | .5228 | .5228 |
| Max | .6348 | .7095 | .6535 | .6001 | .7095 | .7468 | .7468 |
| Min | .4668 | .4287 | .4668 | .4668 | .4287 | .4668 | .4715 |
| Avg | .5311 | .5220 | .5579 | .5377 | .5514 | .5907 | .6055 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 201 / 11 KV HAMP YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4066 | .4066 | .4572 | .4755 | .4805 | .499 | .4938 |
| 2 | .4066 | .4066 | .439 | .4572 | .462 | .5175 | .4755 |
| 3 | .4066 | .4066 | .439 | .439 | .462 | .499 | .4755 |
| 4 | .3921 | .4066 | .439 | .4207 | .4481 | .4854 | .4572 |
| 5 | .4108 | .4435 | .439 | .4024 | .4481 | .4668 | .4572 |
| 6 | .3961 | .462 | .439 | .3841 | .4481 | .5041 | .4572 |
| 7 | .4854 | .499 | .4755 | .4207 | .4294 | .5729 | .5121 |
| 8 | .5729 | .6838 | .5487 | .5304 | .5359 | .6283 | .6219 |
| 9 | .6908 | .6722 | .6348 | .6036 | .6602 | .679 | .6979 |
| 10 | .6908 | .6908 | .6722 | .6348 | .6908 | .7095 | .6348 |
| 11 | .6535 | .6908 | .6348 | .7356 | .7356 | .5658 | .6979 |
| 12 | .6161 | .6908 | .6161 | .6413 | .679 | .7545 | |
| 13 | .6161 | .5601 | .5788 | .547 | .6348 | .6602 | .6224 |
| 14 | .5415 | .5601 | .5601 | .547 | .6413 | .6036 | .6036 |
| 15 | .4854 | .5788 | .5788 | .4527 | .5658 | .6224 | .679 |
| 16 | .5041 | .5415 | .5415 | .4715 | .6036 | .6602 | .6979 |
| 17 | .5175 | .5487 | .5847 | .4938 | .5914 | .6584 | .6283 |
| 18 | .6653 | .6219 | .679 | .6036 | .7023 | .7133 | .7207 |
| 19 | .8501 | .8048 | .8299 | .8048 | .8501 | .8413 | .8871 |
| 20 | .7947 | .8048 | .7922 | .8048 | .8316 | .8048 | .8316 |
| 21 | .7207 | .7095 | .7167 | .7316 | .7577 | .7499 | .7577 |
| 22 | .6838 | .6767 | .695 | .695 | .7023 | .6767 | .7207 |
| 23 | .5729 | .5487 | .5304 | .5729 | .6468 | .567 | .6468 |
| 24 | .4805 | .4805 | .4572 | .4938 | .499 | .5544 | .4938 |
| Max | .8501 | .8048 | .8299 | .8048 | .8501 | .8413 | .8871 |
| Min | .3921 | .4066 | .439 | .3841 | .4294 | .4668 | .4572 |
| Avg | .5650 | .5790 | .5741 | .5568 | .6044 | .6248 | .6205 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 202 / 11KV Chichabhawan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4588 | .4424 | .5304 | .5304 | .4588 | .4588 | .567 |
| 2 | .4424 | .426 | .5304 | .5121 | .4588 | .4588 | .5487 |
| 3 | .4424 | .4424 | .5121 | .5121 | .4424 | .4588 | .5487 |
| 4 | .463 | .4424 | .5121 | .5121 | .4801 | .4801 | .5304 |
| 5 | .463 | .5175 | .5121 | .5121 | .4801 | .5144 | .5304 |
| 6 | .463 | .5359 | .5487 | .5121 | .463 | .5144 | .567 |
| 7 | .5316 | .5571 | .6036 | .5487 | .4973 | .5407 | .6584 |
| 8 | .5571 | .6718 | .6401 | .6219 | .5243 | .5407 | .695 |
| 9 | .6478 | .6154 | .5668 | .6173 | .6516 | .6173 | .6687 |
| 10 | .6154 | .6001 | .6001 | .6316 | .6154 | .5506 | .583 |
| 11 | .5344 | .5668 | .6154 | .6687 | .6516 | .6001 | .6173 |
| 12 | .4534 | .4858 | .502 | .6173 | .6001 | .4973 | |
| 13 | .4696 | .4534 | .502 | .5144 | .502 | .4801 | .4801 |
| 14 | .421 | | .4372 | .4973 | .5144 | .463 | .463 |
| 15 | .3887 | .4115 | .421 | .463 | .5144 | .4287 | .4458 |
| 16 | .421 | .4049 | .4049 | .4458 | .4973 | .4458 | .463 |
| 17 | .3932 | .4755 | .463 | .4755 | .4588 | .4938 | .4752 |
| 18 | .5079 | .6219 | .5144 | .567 | .5571 | .6401 | .5407 |
| 19 | .7373 | .823 | .7545 | .8048 | .7373 | .8596 | .7373 |
| 20 | .7209 | .823 | .7202 | .7682 | .7373 | .7865 | .7373 |
| 21 | .6226 | .6154 | .6516 | .695 | .6718 | .7865 | .6882 |
| 22 | .6062 | .6584 | .6401 | .6584 | .6062 | .695 | .6226 |
| 23 | .5079 | .5853 | .6219 | .5243 | .5571 | .6584 | .5735 |
| 24 | .4752 | .4752 | .5487 | .5304 | .4915 | .4915 | .567 |
| Max | .7373 | .823 | .7545 | .8048 | .7373 | .8596 | .7373 |
| Min | .3887 | .4049 | .4049 | .4458 | .4424 | .4287 | .4458 |
| Avg | .5143 | .5500 | .5564 | .5725 | .5487 | .5609 | .5786 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 204 / 11KV AJNI O/G
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3014 | 1.2826 | 1.4335 | 1.4335 | 1.4146 | 1.4712 | 1.5655 |
| 2 | 1.2449 | 1.2449 | 1.3957 | 1.4146 | 1.3769 | 1.4523 | 1.5089 |
| 3 | 1.2071 | 1.2071 | 1.358 | 1.3957 | 1.3392 | 1.4146 | 1.4712 |
| 4 | 1.2071 | 1.2071 | 1.3203 | 1.358 | 1.3392 | 1.4146 | 1.4523 |
| 5 | | 1.1694 | 1.2826 | 1.3392 | 1.3392 | 1.4335 | 1.4335 |
| 6 | 1.3769 | 1.358 | 1.358 | 1.3392 | 1.3769 | 1.5089 | 1.5089 |
| 7 | 1.6221 | 1.6598 | 1.6032 | 1.4712 | 1.4335 | 1.6975 | 1.7164 |
| 8 | 1.7918 | 1.9805 | 1.8107 | 1.5655 | 1.6409 | 1.8484 | 1.8484 |
| 9 | 1.8673 | | 1.9427 | 1.7918 | 1.8861 | 1.9239 | 1.9805 |
| 10 | 1.8673 | 1.9427 | 1.9427 | 1.773 | 1.9239 | 2.1125 | 1.9616 |
| 11 | 1.9427 | 2.037 | 2.037 | 1.8107 | 2.037 | 2.037 | 2.0748 |
| 12 | 1.8484 | 1.8484 | 1.7918 | 1.773 | 1.9805 | 2.0182 | 1.7353 |
| 13 | 1.6975 | 1.8673 | 1.7353 | 1.6221 | 1.9427 | 1.9239 | 1.6975 |
| 14 | 1.6221 | | 1.6787 | 1.4712 | 1.7541 | 1.7353 | 1.5466 |
| 15 | 1.6221 | 1.6032 | 1.6032 | 1.4523 | 1.7541 | 1.7541 | 1.8296 |
| 16 | 1.5278 | 1.6221 | 1.6598 | 1.4523 | 1.8484 | 1.8107 | 1.9616 |
| 17 | 1.6975 | 1.7541 | 1.6598 | 1.5466 | 1.905 | 2.037 | 2.0182 |
| 18 | 2.0182 | 1.9805 | 2.0182 | 1.6644 | 2.0936 | 2.2445 | 2.2068 |
| 19 | 2.3011 | 2.3388 | 2.3011 | 2.1691 | 2.3765 | 2.5274 | 2.3577 |
| 20 | 2.2068 | 2.2634 | 2.2068 | 2.1125 | 2.2634 | 2.4143 | 2.32 |
| 21 | 2.0182 | 2.1313 | 2.0936 | 2.037 | 2.1313 | 2.3577 | 2.2257 |
| 22 | 1.773 | 1.9427 | 1.8484 | 1.8861 | 2.0182 | 2.0748 | 2.0748 |
| 23 | 1.6032 | 1.7353 | 1.6409 | 1.7353 | 1.7353 | 1.7918 | 1.8861 |
| 24 | 1.358 | 1.3769 | 1.4523 | 1.4901 | 1.5278 | 1.5655 | 1.6032 |
| Max | 2.3011 | 2.3388 | 2.3011 | 2.1691 | 2.3765 | 2.5274 | 2.3577 |
| Min | 1.2071 | 1.1694 | 1.2826 | 1.3392 | 1.3392 | 1.4146 | 1.4335 |
| Avg | 1.6836 | 1.7070 | 1.7156 | 1.6294 | 1.7683 | 1.8571 | 1.8327 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 205 / 11 KV NAVJEEVAN COLONY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3142 | .2957 | .3475 | .3292 | .3881 | .4066 | .3841 |
| 2 | .3326 | .2957 | .3292 | .3109 | .3696 | .3881 | .3658 |
| 3 | .2957 | .2957 | .3292 | .2926 | .3696 | .3696 | .4572 |
| 4 | .2427 | .3142 | .3109 | .2743 | .3547 | .3734 | .3475 |
| 5 | .2614 | .3142 | .3109 | .2561 | .3361 | .3734 | .3292 |
| 6 | .2987 | .3326 | .3109 | .2561 | .3174 | .3361 | .3292 |
| 7 | .3696 | .3881 | .3292 | .3658 | .3547 | .4435 | .4024 |
| 8 | .462 | .4805 | .4024 | .4024 | .4435 | .462 | .4755 |
| 9 | .4481 | .4854 | .4854 | .4481 | .4854 | .5415 | .5601 |
| 10 | .4668 | .4668 | .4668 | .4294 | .5041 | .5228 | .4854 |
| 11 | .4668 | .4294 | .4108 | .4481 | .5041 | .5228 | .4854 |
| 12 | .3547 | .3734 | .4294 | .4294 | .4294 | .4108 | .4294 |
| 13 | .3547 | .3547 | .3734 | .4108 | .3921 | .4668 | .4481 |
| 14 | .3547 | | .3361 | .3547 | .3734 | | .4108 |
| 15 | .3174 | .3361 | .3174 | .3361 | .3734 | .3921 | .3961 |
| 16 | .2987 | .3361 | .3361 | .3547 | .3547 | .4294 | .4527 |
| 17 | .3326 | .2926 | .3584 | .3658 | .3881 | .4024 | .3881 |
| 18 | .4066 | .4024 | .3921 | .439 | .4435 | .439 | .4251 |
| 19 | .462 | .5121 | .5788 | .5487 | .5544 | .5487 | .5914 |
| 20 | .5359 | .4755 | .5975 | .5487 | .5544 | .567 | .6099 |
| 21 | .462 | .5041 | .5601 | .5121 | .499 | .5304 | .6099 |
| 22 | .499 | .4024 | .439 | .4755 | .499 | .5121 | .5729 |
| 23 | .3881 | .3658 | .3841 | .462 | .4805 | .439 | .5175 |
| 24 | .3511 | .3511 | .3475 | .3475 | .4435 | .4435 | .3841 |
| Max | .5359 | .5121 | .5975 | .5487 | .5544 | .567 | .6099 |
| Min | .2427 | .2926 | .3109 | .2561 | .3174 | .3361 | .3292 |
| Avg | .3782 | .3828 | .3951 | .3916 | .4255 | .4487 | .4524 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 206 / 11 KV PANDEY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3511 | .3326 | .3841 | .439 | .4066 | .4435 | .4938 |
| 2 | .3511 | .3326 | .3841 | .4207 | .3696 | .4066 | .4572 |
| 3 | .3326 | .3326 | .3658 | .4207 | .3696 | .3881 | .4572 |
| 4 | .3361 | .3326 | .3658 | .4024 | .3921 | .3921 | .439 |
| 5 | .3584 | .3326 | .3658 | .3841 | .3921 | .4108 | .4207 |
| 6 | .3734 | .3511 | .3475 | .3658 | .3547 | .4481 | .4207 |
| 7 | .4854 | .4251 | .439 | .4024 | .4108 | .499 | .4938 |
| 8 | .5175 | .6099 | .5121 | .4938 | .4805 | .5175 | .6219 |
| 9 | .5788 | .6535 | .5975 | .5415 | .5601 | .5228 | .6722 |
| 10 | .6348 | .6535 | .5788 | .6535 | .6722 | .6722 | .6348 |
| 11 | .6161 | .6722 | .6348 | .5601 | .6535 | .6161 | .6908 |
| 12 | .5975 | .5975 | .6161 | .6348 | .6722 | .6535 | .6722 |
| 13 | .5228 | .5041 | .5415 | .5601 | .5788 | .6348 | .6348 |
| 14 | .4294 | | .4668 | .4854 | .5228 | .5415 | .5788 |
| 15 | .4108 | .4108 | .4668 | .4108 | .5228 | .5415 | .5847 |
| 16 | .4294 | .4668 | .5041 | .4108 | .5228 | .5975 | .5847 |
| 17 | .462 | .4755 | .4854 | .4207 | .5175 | .5853 | .5544 |
| 18 | .5544 | .5853 | .5228 | .4572 | .5914 | .6219 | .6283 |
| 19 | .7577 | .7133 | .7282 | .6584 | .7577 | .7499 | .7947 |
| 20 | .7207 | .6584 | .7095 | .6584 | .7392 | .7682 | .7577 |
| 21 | .6653 | .6348 | .6348 | .6401 | .6653 | .695 | .6838 |
| 22 | .5729 | .5487 | .567 | .567 | .6099 | .6219 | .6283 |
| 23 | .4435 | .439 | .4572 | .499 | .5175 | .5487 | .5544 |
| 24 | .3696 | .3881 | .3841 | .439 | .4435 | .4435 | .4938 |
| Max | .7577 | .7133 | .7282 | .6584 | .7577 | .7682 | .7947 |
| Min | .3326 | .3326 | .3475 | .3658 | .3547 | .3881 | .4207 |
| Avg | .4946 | .4979 | .5025 | .4969 | .5301 | .555 | .5814 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 207 / 11 KV Wireless

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2218 | .2218 | | .2378 | .2402 | .2587 | |
| 2 | .2218 | .2033 | | .2378 | .2218 | .2587 | .2743 |
| 3 | .2218 | .2033 | | .2195 | .2218 | .2402 | .2561 |
| 4 | .1296 | .2218 | | .2195 | .2241 | .2427 | .2561 |
| 5 | .2012 | .2402 | .2195 | .2195 | .9709 | .2614 | .2561 |
| 6 | .2241 | .2772 | .2378 | .2195 | .2241 | .2801 | .2926 |
| 7 | .2587 | .2957 | .2743 | .2378 | .2614 | .3142 | .3292 |
| 8 | .3696 | .3511 | .3109 | .2378 | .3142 | .3142 | .3292 |
| 9 | .3361 | .3174 | .3174 | .3361 | .3174 | .2801 | |
| 10 | .3361 | .3547 | .3547 | .3174 | .3361 | .3734 | .3361 |
| 11 | .2801 | .2801 | .3174 | .2987 | .3174 | .3174 | .3547 |
| 12 | .2801 | .3174 | .3361 | .3395 | .3174 | .3174 | .2987 |
| 13 | .2801 | .2743 | .3174 | .3174 | .3174 | .3547 | .2987 |
| 14 | .2427 | | .2614 | .2801 | .2987 | .3174 | .2801 |
| 15 | .2241 | .2561 | .2427 | .2427 | .2801 | .2801 | .2801 |
| 16 | .2427 | .2427 | .2614 | .2241 | .2801 | .2801 | .2987 |
| 17 | .2402 | .2561 | .2801 | .2195 | .2587 | .3109 | .2957 |
| 18 | .3142 | .3109 | .3361 | .2561 | .3511 | .3841 | .3511 |
| 19 | .3881 | .4024 | .4108 | .3841 | .4066 | .3841 | .4435 |
| 20 | .3696 | .4207 | .3921 | .3658 | .3881 | .4024 | .4251 |
| 21 | .3881 | .3921 | .3921 | .3841 | .3881 | | .4251 |
| 22 | .3511 | .3475 | .3658 | .3841 | .3881 | .3658 | .6653 |
| 23 | .2957 | .3109 | .2926 | .3326 | .3142 | .3292 | .3696 |
| 24 | .2402 | .2402 | .2561 | .2378 | .2587 | .2772 | .2743 |
| Max | .3881 | .4207 | .4108 | .3841 | .9709 | .4024 | .6653 |
| Min | .1296 | .2033 | .2195 | .2195 | .2218 | .2402 | .2561 |
| Avg | .2774 | .2930 | .3088 | .2812 | .3290 | .3106 | .3359 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 211 / 11KV Congressnagar-I
outgoing Feeder KV- 11 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0185 | 1.0562 | 1.1317 | 1.2449 | 1.1883 | 1.1317 | 1.2449 |
| 2 | .9431 | .9242 | 1.094 | 1.2071 | 1.1317 | 1.1317 | 1.1694 |
| 3 | .8865 | .9242 | 1.0562 | 1.1694 | 1.0751 | 1.0185 | 1.1317 |
| 4 | .8299 | .9431 | 1.0185 | 1.1317 | 1.0374 | 1.0374 | 1.094 |
| 5 | | .9054 | .9808 | 1.0059 | .9997 | 1.0562 | 1.0751 |
| 6 | .9619 | 1.1128 | 1.0751 | .9328 | 1.0751 | 1.0562 | 1.2071 |
| 7 | 1.3392 | 1.2826 | 1.1317 | 1.1694 | 1.1883 | 1.3957 | 1.358 |
| 8 | 1.5089 | 1.5278 | 1.5655 | 1.3392 | 1.4523 | 1.5089 | 1.6409 |
| 9 | 1.5466 | 1.5844 | 1.5466 | 1.3203 | 1.6409 | 1.6221 | 1.6221 |
| 10 | 1.5655 | 1.6598 | 1.7353 | 1.4335 | 1.7541 | 1.8296 | 1.7353 |
| 11 | 1.6598 | 1.7164 | 1.8107 | 1.5466 | 1.9239 | 1.9616 | 1.9427 |
| 12 | 1.6032 | 1.6975 | 1.7164 | 1.5466 | 1.9993 | 1.9239 | 2.037 |
| 13 | 1.6598 | 1.6975 | 1.9239 | 1.6032 | 1.8107 | 1.8861 | 1.9427 |
| 14 | 1.6221 | | 1.9993 | 1.4146 | 1.9616 | 1.9239 | 1.8673 |
| 15 | 1.6032 | 1.5844 | 1.7353 | 1.3957 | 1.905 | 1.8484 | 1.8484 |
| 16 | 1.6032 | 1.5466 | 1.7353 | 1.3203 | 1.8861 | 1.8296 | 2.0748 |
| 17 | 1.5844 | 1.7353 | 1.6221 | 1.2826 | 1.8296 | 1.773 | 1.9616 |
| 18 | 1.6221 | 1.8861 | 1.6975 | 1.3392 | 1.9239 | 1.8673 | 1.8861 |
| 19 | 1.8484 | 1.8861 | 1.7924 | 1.5278 | 2.0182 | 2.1125 | 1.9239 |
| 20 | 1.7541 | 1.773 | 1.8296 | 1.6221 | 1.905 | 2.0182 | 1.9239 |
| 21 | 1.5655 | 1.7353 | 1.7353 | 1.4901 | 1.7353 | 1.7918 | 1.9239 |
| 22 | 1.3203 | 1.6032 | 1.5089 | 1.6032 | 1.5466 | 1.6221 | 1.6409 |
| 23 | 1.2449 | 1.4523 | 1.3203 | 1.4335 | 1.4901 | 1.5655 | 1.4523 |
| 24 | 1.094 | 1.1694 | 1.4523 | 1.2254 | 1.2637 | 1.2826 | 1.3203 |
| Max | 1.8484 | 1.8861 | 1.9993 | 1.6221 | 2.0182 | 2.1125 | 2.0748 |
| Min | .8299 | .9054 | .9808 | .9328 | .9997 | 1.0185 | 1.0751 |
| Avg | 1.4080 | 1.4523 | 1.5089 | 1.3460 | 1.5726 | 1.5914 | 1.6260 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 212 / 11KV chatrapati-
Congressnagar Feeder KV- 11 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5281 | .5281 | .6036 | .5658 | .5658 | .6036 | |
| 2 | .5093 | .5281 | .5847 | .547 | .5281 | .5658 | |
| 3 | .5093 | .4904 | .5658 | .5281 | .5093 | .5281 | |
| 4 | .5093 | .5093 | .547 | .5281 | .5093 | .5281 | |
| 5 | .5281 | .4904 | .5093 | .5093 | .5093 | .547 | |
| 6 | .6036 | .5847 | .5847 | .5093 | .5658 | | |
| 7 | .7167 | .6036 | .6413 | .547 | .5847 | .7167 | .6602 |
| 8 | .6979 | .7545 | .679 | .6602 | .6602 | .7545 | .7316 |
| 9 | .7545 | .811 | .7356 | .7167 | .7922 | .7545 | .7733 |
| 10 | .8488 | .8865 | .8488 | .7356 | .8865 | .9619 | .8676 |
| 11 | .9431 | .9431 | .8676 | .7356 | 1.094 | 1.0374 | 1.094 |
| 12 | .9997 | .9808 | .9808 | .811 | 1.0562 | 1.1694 | 1.1317 |
| 13 | .9808 | .9808 | .9808 | .7167 | 1.0562 | | 1.0374 |
| 14 | .9431 | | .9054 | .7167 | 1.0562 | | 1.094 |
| 15 | .8676 | .9619 | .9619 | .679 | 1.0562 | | 1.1317 |
| 16 | .9997 | .9242 | 1.0185 | .6602 | 1.0751 | | 1.1883 |
| 17 | .9808 | .9808 | .9997 | .6979 | 1.0562 | | 1.2449 |
| 18 | .9997 | 1.0562 | .9997 | .695 | 1.1128 | | 1.1883 |
| 19 | 1.094 | 1.094 | 1.094 | .8299 | 1.1694 | | 1.226 |
| 20 | .9431 | .9808 | .9808 | .8488 | .9997 | | 1.0751 |
| 21 | .8299 | .9054 | .8676 | .7733 | .8676 | | .9619 |
| 22 | .811 | .7922 | .7316 | .7545 | .7922 | | .8488 |
| 23 | .6413 | .7545 | .7167 | .6602 | .7167 | | .7922 |
| 24 | .5658 | .547 | .6224 | .5847 | .6036 | .6224 | |
| Max | 1.094 | 1.094 | 1.094 | .8488 | 1.1694 | 1.1694 | 1.2449 |
| Min | .5093 | .4904 | .5093 | .5093 | .5093 | .5281 | .6602 |
| Avg | .7836 | .7864 | .7928 | .6671 | .8260 | .7325 | 1.0028 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 405 / 33kv Congress Nagar O/G SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.358 | 1.358 | 1.358 | 1.358 | 1.5844 | 1.5844 | 2.037 |
| 2 | 1.1317 | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 2.037 |
| 3 | 1.1317 | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 2.037 |
| 4 | 1.1317 | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 2.037 |
| 5 | | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 2.037 |
| 6 | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 1.5844 | 2.2634 |
| 7 | 1.5844 | 1.5844 | 1.5844 | | 1.5844 | 1.8107 | 1.8107 |
| 8 | 1.8107 | 2.037 | 1.7558 | 1.5844 | 1.8107 | 1.8107 | 2.037 |
| 9 | 2.037 | 2.037 | 2.037 | 1.8107 | 2.037 | 2.037 | 2.037 |
| 10 | 2.2634 | 2.2634 | 2.2634 | 1.8107 | 2.2634 | 2.4897 | 2.2634 |
| 11 | 2.2634 | 2.037 | 2.2634 | 2.037 | 2.4897 | 2.4897 | 2.2634 |
| 12 | 2.2634 | 2.2634 | 2.4897 | 1.8107 | 2.4897 | 2.7161 | 2.7161 |
| 13 | 2.2634 | 2.037 | 2.4897 | 2.037 | 2.4897 | 3.6214 | 2.4897 |
| 14 | 2.037 | 2.037 | 2.2634 | 1.5844 | 2.2634 | 3.6214 | 2.2634 |
| 15 | 2.037 | 2.037 | 2.037 | 1.8107 | 2.4897 | 3.6214 | 2.2634 |
| 16 | 2.037 | 2.037 | 2.2634 | 1.5844 | 2.2634 | 3.6214 | 2.2634 |
| 17 | 2.037 | 1.9753 | 2.2634 | 1.5844 | 2.4897 | 3.6214 | 2.7161 |
| 18 | 2.4897 | 2.2634 | 2.2634 | 1.8107 | 2.7161 | | 2.7161 |
| 19 | 2.4897 | 2.4897 | 2.7161 | 2.2634 | 2.2634 | 3.8477 | 2.9424 |
| 20 | 2.4897 | 2.4897 | 2.4897 | 2.1948 | 2.7161 | 2.9424 | 2.7161 |
| 21 | 2.2634 | 2.2634 | 2.2634 | 2.037 | 2.4897 | 3.3951 | 2.4897 |
| 22 | 1.8107 | 2.037 | 2.037 | 1.9753 | 2.2634 | | 2.2634 |
| 23 | | 2.037 | 1.7558 | 1.8107 | 2.037 | 2.4897 | 2.037 |
| 24 | 1.358 | 1.5844 | 2.037 | 1.5844 | 1.5844 | 1.8107 | 2.2634 |
| Max | 2.4897 | 2.4897 | 2.7161 | 2.2634 | 2.7161 | 3.8477 | 2.9424 |
| Min | 1.1317 | 1.358 | 1.358 | 1.358 | 1.358 | 1.358 | 1.8107 |
| Avg | 1.893 | 1.9024 | 1.9759 | 1.7165 | 2.0465 | 2.4794 | 2.2917 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 201 / 11KV A.I.R.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5415 | | .5658 | .6036 | .6602 | .6979 | .6979 |
| 2 | .5415 | | .5847 | .5975 | .6001 | .6979 | .6979 |
| 3 | .4668 | .5658 | .5658 | .5601 | .6602 | .6979 | .6602 |
| 4 | .5601 | .5658 | .5658 | .5601 | .6413 | .679 | .679 |
| 5 | .6535 | .5847 | .6036 | .6535 | .6413 | .679 | .6979 |
| 6 | .7095 | .5847 | .6602 | .6535 | .6413 | .679 | .7167 |
| 7 | .7095 | .7545 | .7356 | .6535 | .6413 | .7356 | .8488 |
| 8 | .7655 | .8488 | .7733 | .7282 | .7733 | .7922 | .8676 |
| 9 | .7655 | .7922 | .8299 | .7468 | .8676 | .8676 | .9431 |
| 10 | .8488 | .8402 | .9054 | .7733 | .8865 | .9242 | .9242 |
| 11 | .8488 | .8775 | .8676 | .7545 | .9242 | .9431 | .9619 |
| 12 | .7733 | .8215 | .8865 | .7356 | .9242 | .9431 | .9431 |
| 13 | .7733 | .8402 | .811 | .6413 | | .8488 | .8865 |
| 14 | .7356 | .7095 | .8488 | .6413 | .8488 | .9242 | .8488 |
| 15 | .7356 | .7282 | .7922 | .6224 | .7922 | .9242 | .7922 |
| 16 | .7733 | .7282 | .7922 | .6036 | .8299 | .9054 | .8299 |
| 17 | .7922 | .8299 | .8029 | .6413 | .9431 | .9054 | .8962 |
| 18 | .8676 | .9808 | .8589 | .7545 | 1.0374 | .9619 | .8775 |
| 19 | .9619 | .9242 | .9149 | .8676 | 1.0185 | 1.094 | .9896 |
| 20 | .9431 | .9431 | .8962 | .8488 | .9808 | 1.0374 | .9522 |
| 21 | .8676 | .8488 | .8029 | .811 | .9054 | .9619 | .8775 |
| 22 | .7545 | .7545 | .7468 | .7545 | .8299 | .8865 | .8589 |
| 23 | .679 | .6979 | .7468 | .7356 | .811 | .8488 | .7842 |
| 24 | .5601 | .5847 | .6224 | .6535 | .6602 | .6979 | .7356 |
| Max | .9619 | .9808 | .9149 | .8676 | 1.0374 | 1.094 | .9896 |
| Min | .4668 | .5658 | .5658 | .5601 | .6001 | .679 | .6602 |
| Avg | .7345 | .7639 | .7575 | .6915 | .8052 | .8472 | .8320 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 202 / 11 KV KALIMATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7655 | .8488 | .7922 | .8402 | .9054 | .9619 | .7922 |
| 2 | .7655 | .8488 | .7733 | .8402 | .8488 | .9619 | .7733 |
| 3 | .7468 | .7545 | .7733 | .7468 | .7922 | .9431 | .7545 |
| 4 | | .7545 | .7733 | .7468 | .7922 | .9431 | .7545 |
| 5 | .7468 | .7167 | .7733 | .7468 | .7922 | .9054 | .7545 |
| 6 | .8589 | .7167 | .7922 | .7842 | .703 | .9054 | .7922 |
| 7 | .8589 | .8488 | .8299 | .7842 | .8865 | .9431 | .9619 |
| 8 | .8215 | .9054 | .9997 | .9522 | .9619 | .9808 | 1.0751 |
| 9 | .7468 | .9431 | .9997 | .9335 | 1.0374 | 1.0185 | 1.0751 |
| 10 | 1.1317 | 1.0082 | 1.1128 | .8865 | 1.2071 | 1.3957 | 1.1883 |
| 11 | .9619 | 1.0456 | 1.1694 | 1.0374 | 1.3203 | 1.3392 | 1.2637 |
| 12 | 1.0562 | 1.1949 | 1.1317 | 1.1128 | 1.1317 | 1.3014 | 1.3014 |
| 13 | .9808 | 1.2136 | 1.2826 | 1.094 | 1.1694 | 1.3769 | 1.1506 |
| 14 | .9808 | .9896 | 1.2071 | .8865 | 1.2071 | 1.3392 | 1.1506 |
| 15 | 1.0562 | .9709 | 1.0374 | 1.0562 | 1.226 | 1.3203 | 1.2071 |
| 16 | .9808 | 1.1763 | 1.2071 | .8676 | 1.1317 | 1.2449 | 1.3957 |
| 17 | 1.0185 | 1.0374 | 1.0642 | .9054 | 1.1883 | 1.2637 | 1.1949 |
| 18 | 1.0751 | 1.0374 | 1.0456 | .9997 | 1.3392 | 1.3203 | 1.2883 |
| 19 | 1.1883 | 1.2449 | 1.2136 | 1.2449 | 1.2449 | 1.3392 | 1.419 |
| 20 | 1.1317 | 1.2826 | 1.2883 | 1.226 | 1.358 | 1.3203 | 1.307 |
| 21 | 1.0185 | 1.1883 | 1.2136 | 1.1128 | 1.226 | 1.3014 | 1.2136 |
| 22 | .9808 | 1.1317 | 1.1763 | 1.0374 | 1.1128 | 1.1694 | 1.1576 |
| 23 | 1.0185 | .9808 | 1.0269 | 1.0374 | 1.0751 | 1.0185 | 1.0082 |
| 24 | .7468 | .8865 | .8676 | .8962 | .9054 | .9619 | .9997 |
| Max | 1.1883 | 1.2826 | 1.2883 | 1.2449 | 1.358 | 1.3957 | 1.419 |
| Min | .7468 | .7167 | .7733 | .7468 | .703 | .9054 | .7545 |
| Avg | .9408 | .9886 | 1.0230 | .9490 | 1.0651 | 1.1490 | 1.0825 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 203 / 11 KV ITI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 2 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 3 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 4 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 5 | .0373 | .0377 | .0377 | | .0377 | .0377 | .0377 |
| 6 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 7 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 8 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 9 | .0373 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 |
| 10 | .0377 | .0373 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 11 | .0943 | .0934 | .0943 | .0377 | .0377 | .0943 | .0943 |
| 12 | .0943 | .0934 | .0943 | .0377 | .0377 | | .0943 |
| 13 | .0943 | .0934 | .0943 | .0377 | .0377 | .0943 | .0943 |
| 14 | .0943 | .0934 | .0943 | .0377 | .0377 | .0943 | .0943 |
| 15 | .0943 | .0934 | .0943 | .0377 | .0377 | .0943 | .0943 |
| 16 | .0943 | .0934 | .0943 | .0377 | .0377 | .0943 | .0943 |
| 17 | .0943 | .0943 | .0747 | .0377 | .0377 | .0943 | .0934 |
| 18 | .0377 | .0566 | .056 | .0377 | .0377 | .0566 | .0934 |
| 19 | .0377 | .0377 | .0373 | .0377 | .0377 | | .0934 |
| 20 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 | .0747 |
| 21 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 | .0747 |
| 22 | .0377 | .0377 | .0373 | .0343 | .0377 | .0377 | .056 |
| 23 | .0377 | .0377 | .0373 | .0377 | .0377 | .0377 | .0373 |
| 24 | .0373 | .0377 | .0377 | | .0377 | .0377 | .0377 |
| Max | .0943 | .0943 | .0943 | .0377 | .0377 | .0943 | .0943 |
| Min | .0373 | .0373 | .0373 | .0343 | .0377 | .0377 | .0373 |
| Avg | .0540 | .0548 | .0541 | .0374 | .0377 | .0540 | .0626 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 204 / SARAF COURT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1494 | .1698 | .1886 | .1867 | .1698 | .1886 | .1886 |
| 2 | .1494 | .1698 | .1886 | .1867 | .1698 | .1886 | .1698 |
| 3 | .1494 | .1509 | .1698 | .1867 | .1886 | .1886 | .1698 |
| 4 | .1494 | .1509 | .1698 | .1867 | .1886 | .1886 | .1698 |
| 5 | .1867 | .1698 | .1698 | .1867 | .1886 | .1886 | .1698 |
| 6 | .2054 | .1698 | .1886 | .1867 | .1886 | .1886 | .2075 |
| 7 | .2054 | .1886 | .2263 | .1867 | .1886 | .2263 | .2263 |
| 8 | .2614 | .2641 | .2452 | .2241 | .2075 | .2452 | .2641 |
| 9 | .2801 | .2829 | .3018 | .2241 | .2829 | .2829 | .2829 |
| 10 | .3584 | .3361 | .3206 | .3018 | .3395 | .3395 | .3395 |
| 11 | .3772 | .4108 | .4715 | .2829 | .3961 | .4338 | .3961 |
| 12 | .3772 | .4481 | .415 | .2263 | .4527 | .4904 | .4338 |
| 13 | .3772 | .4668 | .415 | .2641 | .4338 | .4904 | .4527 |
| 14 | .3772 | .3921 | .3961 | .2452 | .4338 | .4904 | .4338 |
| 15 | .3772 | .3547 | .415 | .2452 | .4527 | .4904 | .4527 |
| 16 | .415 | .4108 | .4338 | .2263 | .4527 | .5093 | .4527 |
| 17 | .3772 | .4338 | .4294 | .2452 | .4527 | .5093 | .5041 |
| 18 | .4904 | .4715 | .4481 | .2829 | .5281 | .547 | .5228 |
| 19 | .547 | .5658 | .5228 | .3584 | .5658 | .5281 | .5228 |
| 20 | .5281 | .4904 | .4668 | .3395 | .4904 | .4904 | .4481 |
| 21 | .3584 | .3961 | .3734 | .3018 | .415 | .5281 | .3361 |
| 22 | .2829 | .3018 | .2801 | .2829 | .3206 | .3395 | .2987 |
| 23 | .2075 | .2452 | .2241 | .2452 | .2829 | .2452 | .2614 |
| 24 | .168 | .1698 | .1886 | .2054 | .1829 | .1886 | .2075 |
| Max | .547 | .5658 | .5228 | .3584 | .5658 | .547 | .5228 |
| Min | .1494 | .1509 | .1698 | .1867 | .1698 | .1886 | .1698 |
| Avg | .3065 | .3171 | .3187 | .2420 | .3322 | .3544 | .3296 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 207 / SUBSTATION FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 18-FEB-18 |
|------|-----------|
| HR | Load (MW) |
| 13 | .9242 |
| Max | .9242 |
| Min | .9242 |
| Avg | .9242 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 401 / 33KV CHHATRAPATI i/c
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5123 | 1.6409 | 1.5844 | 1.6244 | 1.7541 | 1.8107 | 2.3765 |
| 2 | 1.5123 | 1.5844 | 1.5844 | 1.6244 | 1.6975 | 1.8107 | 2.32 |
| 3 | 1.4003 | 1.4712 | 1.5278 | 1.5123 | 1.6975 | 1.8107 | 2.2634 |
| 4 | 1.5123 | 1.4712 | 1.5278 | 1.5123 | 1.4918 | 1.8107 | 2.32 |
| 5 | 1.6244 | 1.4712 | 1.5844 | 1.5123 | 1.6409 | 1.7541 | 2.32 |
| 6 | 1.7924 | 1.4712 | 1.6975 | 1.6244 | 1.6409 | 1.7541 | 2.4331 |
| 7 | 1.7924 | 1.8107 | 1.8107 | 1.6244 | 1.7541 | 1.6975 | 2.0936 |
| 8 | 1.8484 | 2.037 | 2.037 | 1.9044 | 1.9805 | 2.037 | 2.2634 |
| 9 | 2.1285 | 2.037 | 2.1502 | 1.9044 | 2.2068 | 2.2068 | 2.32 |
| 10 | 2.3765 | 2.1845 | 2.3765 | 1.9239 | 2.4897 | 2.6595 | 2.4897 |
| 11 | 2.5463 | 2.4086 | 2.6029 | 2.0936 | 2.6595 | 2.7726 | 2.7161 |
| 12 | 2.32 | 2.5206 | 2.5463 | 2.1502 | 2.5463 | 2.8292 | 2.3765 |
| 13 | 2.2068 | 2.5766 | 2.6029 | 2.037 | 2.5463 | 4.0175 | 2.5463 |
| 14 | 2.2068 | 2.1845 | 2.5463 | 1.8107 | 2.5463 | 3.7912 | 2.4897 |
| 15 | 2.2634 | 2.1285 | 2.32 | 1.9239 | 2.5463 | 3.9043 | 2.4897 |
| 16 | 2.2634 | 2.4086 | 2.5463 | 1.6975 | 2.4897 | 3.9043 | 2.7726 |
| 17 | 2.2634 | 2.3765 | 2.3525 | 1.8107 | 2.6029 | 3.9043 | 2.6886 |
| 18 | 2.4331 | 2.5463 | 2.4086 | 2.037 | 2.9424 | 4.0741 | 2.7446 |
| 19 | 2.7161 | 2.7726 | 2.6886 | 2.4897 | 2.8292 | 4.2438 | 3.0247 |
| 20 | | 2.7726 | 2.6886 | 2.4331 | 2.8292 | 4.1307 | |
| 21 | 2.2634 | 2.4897 | 2.4086 | 2.2634 | 2.5463 | 3.678 | 2.4646 |
| 22 | 2.037 | 2.2068 | 2.2405 | 2.0936 | 2.2634 | 3.2819 | 2.3525 |
| 23 | 1.9239 | 1.9805 | 2.0165 | 2.037 | 2.2068 | 2.8858 | 2.0725 |
| 24 | 1.5123 | 1.6409 | 1.6975 | 1.7924 | 1.7541 | 1.8673 | 2.7161 |
| Max | 2.7161 | 2.7726 | 2.6886 | 2.4897 | 2.9424 | 4.2438 | 3.0247 |
| Min | 1.4003 | 1.4712 | 1.5278 | 1.5123 | 1.4918 | 1.6975 | 2.0725 |
| Avg | 2.0198 | 2.0914 | 2.1478 | 1.8932 | 2.2359 | 2.8599 | 2.4632 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 402 / 33KV SITABUILD I/C
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 |
|------|-----------|
| HR | Load (MW) |
| 22 | 2.037 |
| Max | 2.037 |
| Min | 2.037 |
| Avg | 2.037 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 201 / 11 KV BANK OF MAHARASHATRA SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1886 | .1886 | .1886 | .2075 | .2075 | .2452 |
| 2 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 | .2263 |
| 3 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 | .2263 |
| 4 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 | .2075 |
| 5 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 | .2075 |
| 6 | .1886 | .1886 | .1886 | .1886 | .1886 | .2075 | .2075 |
| 7 | .1886 | .1698 | .1886 | .1698 | .1886 | .2075 | .1886 |
| 8 | .1886 | .2263 | .1886 | .1886 | .2075 | .2263 | .2452 |
| 9 | .1886 | .2263 | .2075 | .2263 | .2263 | .2263 | .2452 |
| 10 | .2641 | .2452 | .2263 | .2452 | .2452 | .2641 | .2641 |
| 11 | | .3584 | .3584 | .2829 | .3395 | .3772 | .3584 |
| 12 | .5658 | | .5847 | .415 | .547 | .6224 | .5658 |
| 13 | .5847 | .6036 | .5847 | .4904 | .6413 | .679 | .6224 |
| 14 | .5847 | .5093 | .6036 | .4904 | .6224 | .6413 | .6413 |
| 15 | .5658 | .5658 | .6224 | .5093 | .6413 | .6413 | .679 |
| 16 | .6036 | .6036 | .6224 | .5281 | .6224 | .679 | .6602 |
| 17 | .5658 | .6036 | .6036 | .5093 | .6602 | .679 | .6413 |
| 18 | .6413 | .6602 | .6602 | .547 | .7167 | .7545 | .679 |
| 19 | .7167 | .7356 | .7733 | .6036 | .7922 | .811 | .7922 |
| 20 | .7167 | .8865 | .7545 | .5658 | .7545 | .811 | .7922 |
| 21 | .6413 | .6602 | .6413 | .415 | .5847 | .6602 | .6413 |
| 22 | .3395 | .3584 | .3584 | .3395 | .3584 | .3961 | .3772 |
| 23 | .2641 | .2452 | .2829 | .2641 | .2641 | .3018 | .2452 |
| 24 | .2075 | .2641 | .1509 | .2075 | .2263 | .2075 | .2452 |
| Max | .7167 | .8865 | .7733 | .6036 | .7922 | .811 | .7922 |
| Min | .1886 | .1698 | .1509 | .1698 | .1886 | .2075 | .1886 |
| Avg | .3895 | .3936 | .3977 | .3387 | .4079 | .4346 | .4252 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 202 / 11KV REGENT -I o/g
Feeder KV- 11 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6036 | .6036 | .743 | .6478 | .6413 | .724 | .6478 |
| 2 | .5658 | .6413 | .6859 | .6478 | .6413 | .724 | .6478 |
| 3 | .5658 | .6413 | 1.1622 | .6478 | .6413 | .724 | .6478 |
| 4 | .5658 | .6413 | .6859 | .6478 | .6413 | .724 | .6287 |
| 5 | .5658 | .6413 | .6859 | .6478 | .6413 | .724 | .6287 |
| 6 | .6036 | .6413 | .6859 | .6478 | .6413 | .724 | .6287 |
| 7 | .6413 | .6413 | .6668 | .6287 | .6413 | .724 | .7049 |
| 8 | .6602 | .7356 | .6859 | .6668 | .679 | .743 | .724 |
| 9 | .7356 | .7545 | .724 | .6478 | .6979 | .743 | .724 |
| 10 | .7922 | .7733 | .7922 | .6859 | .7545 | .8002 | .7922 |
| 11 | | .8299 | .9242 | .7049 | .8383 | .8676 | .8676 |
| 12 | .9145 | .8764 | .8676 | .8002 | .8573 | .9431 | .9054 |
| 13 | .9145 | .9054 | .9431 | .8002 | .8764 | .9242 | .9431 |
| 14 | .8764 | .8865 | .8676 | .8002 | .8573 | .8865 | .9431 |
| 15 | .8764 | .8954 | .9054 | .8002 | .8954 | .9242 | .9431 |
| 16 | .8764 | .9054 | .9242 | .8002 | .8764 | .9431 | .8676 |
| 17 | .8676 | .9054 | .9526 | .7811 | .8764 | .9526 | .9054 |
| 18 | .8676 | .8764 | .8764 | .7922 | .8764 | .9145 | .9242 |
| 19 | .8676 | .9335 | .8954 | .8676 | .8954 | .9335 | .9054 |
| 20 | .8488 | .8954 | .9145 | .7922 | .8764 | .9335 | .9054 |
| 21 | .8488 | .9145 | .8573 | .7545 | .8192 | .8954 | .8764 |
| 22 | .7167 | | .7621 | .7167 | .7621 | .8002 | .8002 |
| 23 | .679 | .724 | .7049 | .679 | .724 | .6859 | .7356 |
| 24 | .6413 | .6224 | .7049 | .6668 | .6413 | .724 | .6859 |
| Max | .9145 | .9335 | 1.1622 | .8676 | .8954 | .9526 | .9431 |
| Min | .5658 | .6036 | .6668 | .6287 | .6413 | .6859 | .6287 |
| Avg | .7433 | .7776 | .8174 | .7197 | .7622 | .8201 | .7910 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 203 / 11 KV SANSKRUTIK SANKUL SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0943 | .0943 | .0943 | .0943 | .1509 | .0943 | .0943 |
| 2 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 |
| 3 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 |
| 4 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 |
| 5 | .0943 | .0943 | .1132 | .1132 | .0943 | .0943 | .0943 |
| 6 | .1509 | .0943 | .1509 | .132 | .0943 | .0943 | .1132 |
| 7 | .1698 | .0943 | .1698 | .1307 | .0943 | .0943 | .1509 |
| 8 | .1886 | .1509 | .1886 | .1886 | .1509 | .1886 | .1886 |
| 9 | .2075 | .1886 | .1886 | .1886 | .1886 | .1886 | .2263 |
| 10 | .1886 | .2452 | .2075 | .1886 | .2641 | .2641 | .3018 |
| 11 | | .3206 | .2829 | .2452 | .3206 | .3395 | .3395 |
| 12 | .3395 | .3018 | .3018 | .2641 | .2829 | .3395 | |
| 13 | .3584 | .3018 | .3206 | .2641 | .3395 | .3961 | .3395 |
| 14 | .3395 | .3395 | .3395 | .3018 | .3206 | .3395 | .3395 |
| 15 | .3395 | .3206 | .9054 | .3395 | .3206 | .3584 | .3584 |
| 16 | .3772 | .3772 | .3395 | .2829 | .3772 | .3772 | .3961 |
| 17 | .3395 | .3395 | .3018 | .2452 | .3395 | .3961 | .3395 |
| 18 | .3395 | .3772 | .3584 | .2452 | .3772 | .3961 | .3395 |
| 19 | .3961 | .415 | .3961 | .2641 | .415 | .4338 | .4527 |
| 20 | .4338 | .3395 | .3395 | .2829 | .3584 | .3772 | .3772 |
| 21 | .3018 | .3206 | .3018 | .2452 | .3018 | .3584 | .3395 |
| 22 | .2641 | .2075 | .2641 | .2075 | .2452 | .2641 | .2263 |
| 23 | .1886 | .1494 | .1698 | .1886 | | .1698 | .1698 |
| 24 | .0943 | .1509 | .1494 | .0943 | .1509 | .0943 | .1698 |
| Max | .4338 | .415 | .9054 | .3395 | .415 | .4338 | .4527 |
| Min | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 | .0943 |
| Avg | .2386 | .2294 | .2569 | .1996 | .2378 | .2476 | .2452 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 204 / 11 KV UNIVERSITY LIBRARY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2829 | .2641 | .2987 | .2987 | .2641 | .2987 | .3174 |
| 2 | .2829 | .2829 | .2987 | .2801 | .2641 | .2987 | .3174 |
| 3 | .2829 | .2829 | .2987 | .2801 | .2641 | .2987 | .3174 |
| 4 | .2829 | .3018 | .2987 | .2801 | .2641 | .2987 | .3174 |
| 5 | .3018 | .3206 | .2987 | .2987 | .2641 | .3174 | .3174 |
| 6 | .3206 | .3395 | .3361 | .3174 | .3018 | .3361 | .3174 |
| 7 | .3584 | .3584 | .3361 | .3174 | .3395 | .3734 | .3547 |
| 8 | .4338 | .415 | .4108 | .3361 | .3395 | .3921 | .4294 |
| 9 | .3961 | .4527 | .4294 | .3361 | .4527 | .4108 | .4668 |
| 10 | .4904 | .5281 | .5093 | .3734 | .4715 | .5601 | .4854 |
| 11 | | .5281 | .4904 | .3921 | .5415 | .5658 | .5658 |
| 12 | .4854 | .5041 | .5093 | .3547 | .4854 | .6224 | .5658 |
| 13 | .5415 | .5281 | .547 | .3547 | .5041 | .6036 | .6413 |
| 14 | .5228 | .5281 | .4904 | .3361 | .5975 | .6413 | .5847 |
| 15 | .5601 | .5228 | .4904 | .3734 | .5601 | .6224 | .6413 |
| 16 | .5228 | .5281 | .4904 | .3174 | .5975 | .6413 | .6979 |
| 17 | .547 | .5093 | .4481 | .3361 | .5601 | .6161 | .679 |
| 18 | .5658 | .4481 | .4854 | | .5041 | .6348 | .6413 |
| 19 | .5281 | .5601 | .5041 | .3584 | .5228 | .5975 | .6224 |
| 20 | .5093 | .4668 | .4854 | .3584 | .4668 | .5788 | .5281 |
| 21 | .415 | .4108 | .4108 | .3395 | .4294 | .4854 | .4854 |
| 22 | .3772 | .4108 | .3547 | .3018 | .3361 | .4108 | .4294 |
| 23 | .3772 | .3547 | .3547 | .3018 | | .3547 | .3772 |
| 24 | .3018 | .2829 | .3361 | .3174 | .2829 | .2987 | .3361 |
| Max | .5658 | .5601 | .547 | .3921 | .5975 | .6413 | .6979 |
| Min | .2829 | .2641 | .2987 | .2801 | .2641 | .2987 | .3174 |
| Avg | .4212 | .4220 | .4130 | .3287 | .4180 | .4691 | .4765 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 205 / 11 KV APANA BHANDAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2075 | .2641 | .2012 | .2715 | .3018 | .2926 | .362 |
| 2 | .2075 | .2075 | .2012 | .2534 | .2829 | .2926 | .3258 |
| 3 | .2075 | .2075 | .2012 | .2561 | .2829 | .2926 | .3292 |
| 4 | .2075 | .2075 | .2012 | .2561 | .2641 | .2926 | .3292 |
| 5 | .2263 | .2263 | .2012 | .2561 | .2641 | .2926 | .3361 |
| 6 | .2829 | .2641 | .2195 | .2561 | | .3109 | .3292 |
| 7 | .3018 | .2641 | .2743 | .2926 | .3395 | .3841 | .4024 |
| 8 | .3206 | .3772 | .2743 | .3439 | .3584 | .4207 | .4525 |
| 9 | .3584 | .3395 | .3109 | .3258 | .415 | .439 | .4163 |
| 10 | .3584 | .3206 | .3584 | .362 | .3961 | .4527 | .4525 |
| 11 | | .3395 | .415 | .362 | .4163 | .4527 | .4715 |
| 12 | .3982 | .3109 | .3961 | .3801 | .439 | .4904 | .4904 |
| 13 | .3801 | .3018 | .3395 | .3982 | .4572 | .5281 | .4904 |
| 14 | .3439 | .2641 | .3584 | .3258 | .439 | .5281 | .547 |
| 15 | .4024 | .2561 | .3772 | .3258 | .4755 | .4904 | .5281 |
| 16 | .362 | .2829 | .415 | .362 | .4755 | .4904 | .3772 |
| 17 | .3772 | .3018 | .3801 | .3801 | .439 | .543 | .5658 |
| 18 | .3961 | .3841 | .543 | .4527 | .5487 | .6154 | .6036 |
| 19 | .4527 | .4755 | .5973 | .5658 | .6036 | .7059 | .6979 |
| 20 | .4904 | .439 | .5792 | .6036 | .5487 | .724 | .6602 |
| 21 | .4904 | .439 | .543 | .5093 | .4755 | .6516 | .543 |
| 22 | .3584 | .3109 | .3982 | .4338 | .4024 | .543 | .4706 |
| 23 | | .2561 | .3439 | .3961 | | .4706 | .415 |
| 24 | .2452 | .2263 | .2561 | .2896 | .3206 | .2561 | .3801 |
| Max | .4904 | .4755 | .5973 | .6036 | .6036 | .724 | .6979 |
| Min | .2075 | .2075 | .2012 | .2534 | .2641 | .2561 | .3258 |
| Avg | .3352 | .3028 | .3494 | .3608 | .4066 | .4567 | .4573 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 206 / 11 KV LANDMARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2263 | .2263 | .2075 | .2641 | .2452 | .2452 | .3395 |
| 2 | .1886 | .2452 | .2075 | .2452 | .2452 | .2452 | .3395 |
| 3 | .1886 | .2452 | .2075 | .2452 | .2452 | .2452 | .3395 |
| 4 | .1886 | .2641 | .2075 | .2452 | .2263 | .2452 | .3395 |
| 5 | .1886 | .2641 | .2075 | .2452 | .2263 | .2452 | .3395 |
| 6 | .2075 | .2452 | .2263 | .2263 | .2263 | .2263 | .2452 |
| 7 | .2075 | .2452 | .2263 | .2263 | .2263 | .2263 | .3395 |
| 8 | .2263 | .2263 | .2452 | .2452 | .2263 | .2452 | .2452 |
| 9 | .2075 | .2641 | .2829 | .2641 | .2641 | .2641 | .2641 |
| 10 | .2829 | .3395 | .3206 | .3584 | .3395 | .3772 | .415 |
| 11 | | .6602 | .5847 | .6036 | .7922 | .6224 | .7167 |
| 12 | .6602 | .7545 | .6979 | .6413 | .7922 | .7922 | .8299 |
| 13 | .6602 | .7545 | .7167 | .6413 | .7733 | .7545 | .7922 |
| 14 | .7167 | .7545 | .679 | .6413 | .8299 | .7922 | .7922 |
| 15 | .7167 | .7545 | .7167 | .6602 | .7922 | .7922 | .7733 |
| 16 | .7356 | .7922 | .7356 | .6224 | .7922 | .8299 | .7922 |
| 17 | .6602 | .7545 | .7356 | .6413 | .7922 | .7922 | .7922 |
| 18 | .7167 | .7545 | .7167 | .5658 | .7356 | .7922 | .7733 |
| 19 | .6602 | .7545 | .7167 | .6413 | .7356 | .7167 | .7356 |
| 20 | .6036 | .6979 | .6413 | .6036 | .6602 | .6413 | .679 |
| 21 | .6036 | .6036 | .6413 | .5281 | .5658 | .679 | .5658 |
| 22 | .4527 | .4904 | .4715 | .4527 | .4715 | .5658 | .4904 |
| 23 | .2641 | .3206 | .3018 | .2641 | | .3961 | .3206 |
| 24 | .2263 | .2263 | .2641 | .2641 | .2641 | .2641 | .3395 |
| Max | .7356 | .7922 | .7356 | .6602 | .8299 | .8299 | .8299 |
| Min | .1886 | .2263 | .2075 | .2263 | .2263 | .2263 | .2452 |
| Avg | .4256 | .4849 | .4566 | .4307 | .4986 | .4998 | .5250 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 207 / 11 KV Poonam Mall-Bhgwa SHEDDABLE URBAN
Ghar- Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .415 | .415 | .3292 | .4525 | .4715 | .4854 | .4887 |
| 2 | .3772 | .415 | .3292 | .4163 | .4527 | .4755 | .4706 |
| 3 | .3772 | .415 | .3292 | .4207 | .4527 | .4755 | .4755 |
| 4 | .3772 | .415 | .3292 | .4207 | .4527 | .4755 | .4755 |
| 5 | .415 | .4904 | .3475 | .4207 | .4715 | .4938 | .4938 |
| 6 | .5658 | .5281 | .4207 | .4572 | .5093 | .5487 | .567 |
| 7 | .6036 | .5847 | .4755 | .5281 | .5658 | .6219 | .6584 |
| 8 | .7167 | .7545 | .5658 | .5973 | .6602 | .6767 | .6878 |
| 9 | .7733 | .6413 | .5853 | .6154 | .679 | .7133 | .724 |
| 10 | .6979 | .6413 | .811 | .6154 | .7356 | .7545 | .7059 |
| 11 | | .6224 | .811 | .5973 | .724 | .7545 | .7095 |
| 12 | .6697 | .5853 | .7356 | .6516 | .7282 | .7733 | .7167 |
| 13 | .5792 | .5658 | .6979 | .6154 | .6767 | .7356 | .7733 |
| 14 | .6154 | .5658 | .6413 | .543 | .6219 | .6979 | .6602 |
| 15 | .5975 | .4755 | .6036 | .4887 | .6401 | .7167 | .7167 |
| 16 | .5792 | .4904 | .5658 | .5068 | .695 | .7356 | .7167 |
| 17 | .5658 | .5658 | .6154 | .5068 | .695 | .7602 | .7733 |
| 18 | .5658 | .6219 | .6878 | .6413 | .7682 | .8326 | .8488 |
| 19 | .7545 | .7682 | .905 | .7922 | .8596 | .9412 | .9619 |
| 20 | .7545 | .7133 | .8145 | .7545 | .8299 | .905 | .9054 |
| 21 | .6224 | .6584 | .724 | .6602 | .7316 | .8145 | .7964 |
| 22 | .6036 | .5304 | .6154 | .6224 | .695 | .724 | .7059 |
| 23 | .5281 | .439 | .5611 | .5658 | | .5792 | .6224 |
| 24 | .4904 | .5658 | .4024 | | .4904 | .5121 | .5249 |
| Max | .7733 | .7682 | .905 | .7922 | .8596 | .9412 | .9619 |
| Min | .3772 | .415 | .3292 | .4163 | .4527 | .4755 | .4706 |
| Avg | .5759 | .5612 | .5793 | .5604 | .6351 | .6751 | .6741 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 208 / 11 KV ETERNITY MALL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0943 | .0943 | .1109 | .1294 | .132 | .1109 | .1294 |
| 2 | .0943 | .1132 | .1109 | .1294 | .132 | .1109 | .1294 |
| 3 | .0943 | .1132 | .1109 | .1294 | .132 | .1109 | .1307 |
| 4 | .0943 | .1132 | .1109 | .128 | .1132 | .1097 | .1307 |
| 5 | .0943 | .1132 | .1109 | .0739 | .0943 | .1097 | .1307 |
| 6 | .0943 | .0943 | .1109 | .1109 | .0943 | .1109 | .1109 |
| 7 | .0943 | .0943 | .1109 | .1109 | .0943 | .1109 | .1109 |
| 8 | .0943 | .0943 | .112 | .0924 | .0943 | .112 | .1109 |
| 9 | .0943 | .0943 | .1109 | .1109 | .1132 | .112 | .1294 |
| 10 | .0943 | .1132 | .132 | .1478 | .1509 | .1886 | .1294 |
| 11 | | .2641 | .2075 | .2402 | .2402 | .2829 | .2829 |
| 12 | .3142 | .3511 | .3961 | .3511 | .4251 | .415 | .3772 |
| 13 | .3326 | .3395 | .3772 | .3511 | .3881 | .3772 | .3584 |
| 14 | .3511 | .3772 | .3395 | .3696 | .3881 | .415 | .3584 |
| 15 | .3511 | .3326 | .3395 | .3696 | .3881 | .415 | .2801 |
| 16 | .3881 | .3772 | .3395 | .3881 | .3881 | .4338 | .3734 |
| 17 | .3584 | .3772 | .3142 | .3696 | .3696 | .3881 | .3475 |
| 18 | .3772 | .3696 | .3142 | .3961 | .4435 | .4435 | .3772 |
| 19 | .415 | .4066 | .3881 | .415 | .3881 | .3881 | .3772 |
| 20 | .3584 | .3881 | .3881 | .4527 | .4066 | .3696 | .415 |
| 21 | .3206 | .3696 | .3696 | .3772 | .3696 | .3511 | .3511 |
| 22 | .2641 | .3142 | .2957 | .3206 | .2957 | .2772 | .2957 |
| 23 | .1886 | .1848 | .2033 | .2075 | | .1663 | .2263 |
| 24 | .1132 | .132 | .1294 | .1478 | .1509 | .1109 | .1663 |
| Max | .415 | .4066 | .3961 | .4527 | .4435 | .4435 | .415 |
| Min | .0943 | .0943 | .1109 | .0739 | .0943 | .1097 | .1109 |
| Avg | .2207 | .2342 | .2305 | .2466 | .2518 | .2508 | .2429 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 211 / 11 KV AJMERA - SHEDDABLE URBAN
 NARESHCHANDRA Feeder KV- 11 /
 OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0943 | .0943 | .1132 | .132 | .0754 | .1132 | .132 |
| 2 | .0943 | .0943 | .1132 | .1132 | .0754 | .1132 | .132 |
| 3 | .0943 | .0943 | .1132 | .1132 | .0754 | .1132 | .132 |
| 4 | .0943 | .0754 | .1132 | .1132 | .0754 | .1132 | .132 |
| 5 | .1132 | .0943 | .1132 | .1132 | .0754 | .1132 | .132 |
| 6 | | .0943 | .1132 | .0754 | .1132 | .1132 | .1509 |
| 7 | .132 | .1132 | .1132 | .1132 | .132 | .132 | .1132 |
| 8 | .132 | .132 | .1132 | .1509 | .1509 | .1509 | .1509 |
| 9 | .1509 | .132 | .132 | .132 | .1509 | .1698 | .1132 |
| 10 | .132 | .1698 | .132 | .1132 | .132 | .1509 | .1509 |
| 11 | | .1886 | .1698 | .1132 | .1886 | .1886 | .132 |
| 12 | .2263 | .2075 | .2075 | .1132 | .1886 | .2263 | .2075 |
| 13 | .2263 | .2263 | .1886 | .132 | .1886 | .1886 | .2075 |
| 14 | .2075 | .1886 | .1886 | .1132 | .1886 | .2075 | .1886 |
| 15 | .2075 | .2263 | .1886 | .132 | .2075 | .2075 | .1886 |
| 16 | .2075 | .2452 | .2075 | .132 | .2263 | .2263 | .2075 |
| 17 | .1886 | .2452 | .2263 | .132 | .2452 | .2452 | .2452 |
| 18 | .2075 | .2452 | .2641 | .1509 | .2641 | .3018 | .2452 |
| 19 | .2641 | .3018 | .2829 | .1509 | .2641 | .3018 | .3206 |
| 20 | .2452 | .2641 | .2829 | .1509 | .2829 | .3018 | .2829 |
| 21 | .2075 | .2263 | .2263 | .132 | .2263 | .2641 | .2452 |
| 22 | .132 | .132 | .1698 | .1132 | .1698 | .1698 | .1886 |
| 23 | .1132 | .1132 | .132 | .0943 | | .1698 | .132 |
| 24 | .1132 | .0943 | .0943 | .1132 | .0943 | .1132 | .132 |
| Max | .2641 | .3018 | .2829 | .1509 | .2829 | .3018 | .3206 |
| Min | .0943 | .0754 | .0943 | .0754 | .0754 | .1132 | .1132 |
| Avg | .1629 | .1666 | .1666 | .1226 | .1648 | .1831 | .1776 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 212 / 11kv ANAND TALKIES 4 POLE SHEDDABLE URBAN
STRU Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3961 | .3772 | .3734 | .4294 | .4338 | | .4108 |
| 2 | .3772 | .3772 | .3734 | .3734 | .4338 | .5788 | .4108 |
| 3 | .3772 | .3772 | .3734 | | .415 | .4854 | .4108 |
| 4 | .3772 | .3584 | .3734 | .3734 | .3772 | .4481 | .4108 |
| 5 | .3961 | .3584 | .3734 | .3921 | .3772 | .4108 | .3921 |
| 6 | .4527 | .3584 | .3921 | .4294 | .415 | .3734 | .3734 |
| 7 | .4715 | .4904 | .5228 | .4294 | .4527 | .4108 | .5228 |
| 8 | .4904 | .5093 | .4481 | .4294 | .5093 | .4481 | .5415 |
| 9 | .547 | .547 | .5601 | .4854 | .5093 | .5041 | .5228 |
| 10 | .5847 | .5658 | .6036 | .5041 | .4715 | .5093 | .5228 |
| 11 | | .5658 | .5847 | .6161 | .5975 | .547 | .547 |
| 12 | .6348 | .6722 | .6413 | .6722 | .5788 | .6224 | .5847 |
| 13 | .6161 | .6979 | .6224 | .5975 | .5975 | .7167 | .6036 |
| 14 | .5975 | .6224 | .6224 | .6161 | | .6224 | .5658 |
| 15 | .5415 | .5601 | .6161 | .5228 | .6161 | .6602 | .547 |
| 16 | .5975 | .679 | .6161 | .4854 | .6722 | .6224 | .5847 |
| 17 | .5658 | .6413 | .6348 | .5041 | .7095 | .6161 | |
| 18 | .6602 | .6908 | .7468 | .5658 | .8029 | .6535 | .7167 |
| 19 | .9242 | .8215 | .9335 | .7167 | .8215 | .8589 | .8488 |
| 20 | .8299 | .8215 | .8962 | .7356 | .8775 | .7468 | .8215 |
| 21 | .7733 | .7468 | .7842 | .6602 | .7282 | .7095 | .7095 |
| 22 | .547 | .6348 | .6908 | .5658 | .6161 | .6161 | .6161 |
| 23 | .4715 | .5228 | .5228 | .5093 | | .4854 | .547 |
| 24 | .4527 | .4338 | .4108 | .4668 | .4527 | | .5228 |
| Max | .9242 | .8215 | .9335 | .7356 | .8775 | .8589 | .8488 |
| Min | .3772 | .3584 | .3734 | .3734 | .3772 | .3734 | .3734 |
| Avg | .5514 | .5596 | .5715 | .5252 | .5666 | .5748 | .5536 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 213 / 11KV Regent II o/g

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1886 | .1867 | .2427 | .2263 | .2241 | .2614 |
| 2 | .1886 | .1698 | .1867 | .2241 | .2263 | .2241 | .2427 |
| 3 | .1886 | .1698 | .1867 | .2241 | .2263 | .2241 | .2427 |
| 4 | .1886 | .1698 | .1867 | .2241 | .2075 | .2241 | .2427 |
| 5 | .1886 | .1886 | .2054 | .2241 | .2075 | .2241 | .2427 |
| 6 | .2075 | .1886 | .2241 | .2427 | .2075 | .2241 | .2241 |
| 7 | .2075 | .2641 | .2241 | .2614 | .2263 | .2614 | .2801 |
| 8 | .2263 | .2641 | .2241 | .2614 | .2829 | .2801 | .2614 |
| 9 | .2075 | .2452 | .2241 | .2614 | .2641 | .2427 | .2614 |
| 10 | .2641 | .2641 | .3018 | .2614 | .2641 | .3206 | .2987 |
| 11 | | .3961 | .3961 | .3361 | .5041 | .3961 | .4527 |
| 12 | .0934 | .5415 | .5847 | .4854 | .5415 | .5847 | .5847 |
| 13 | .5601 | .4904 | .5281 | .4854 | .5975 | .5847 | .5316 |
| 14 | .5228 | .547 | .5658 | .4481 | .6161 | .5847 | .6224 |
| 15 | .5041 | .5415 | .5601 | .4481 | .6161 | .6224 | .5847 |
| 16 | .5415 | .547 | .5415 | .4668 | .6348 | .6413 | .6224 |
| 17 | .5658 | .5847 | .6161 | .5228 | .6908 | .6348 | .679 |
| 18 | .6413 | .6908 | .7282 | .6224 | .7842 | .7655 | .7545 |
| 19 | | .7655 | .8589 | .7167 | .8402 | .8962 | .8865 |
| 20 | .7356 | .7282 | .8215 | .6413 | .8029 | .8402 | .8299 |
| 21 | .547 | .6535 | .6348 | .415 | .5228 | .6908 | .6722 |
| 22 | .132 | .2801 | .3361 | .3206 | .2987 | .3361 | .3361 |
| 23 | .2263 | .2241 | .2801 | .2452 | | .2987 | .2641 |
| 24 | .2263 | .2075 | .2054 | .2241 | .2263 | .2614 | .2801 |
| Max | .7356 | .7655 | .8589 | .7167 | .8402 | .8962 | .8865 |
| Min | .0934 | .1698 | .1867 | .2241 | .2075 | .2241 | .2241 |
| Avg | .3342 | .3879 | .4087 | .3669 | .4354 | .4411 | .4441 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 202 / 11KV Shankarnagar Incomer

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7842 | .8029 | .7842 | .7655 | .8589 | .8326 | .8676 |
| 2 | .7468 | .8029 | .7468 | .7468 | .8589 | .7602 | .7922 |
| 3 | .7095 | .7468 | .7282 | .7095 | .8029 | .7522 | .7922 |
| 4 | .6535 | .6908 | .6908 | .6908 | .7655 | .7701 | .811 |
| 5 | .6722 | .6908 | .7095 | .7282 | .7842 | .8688 | .811 |
| 6 | .7842 | .8029 | .7842 | .8029 | .8488 | .905 | .8865 |
| 7 | .9709 | .9896 | .9997 | .8402 | .9054 | 1.0082 | 1.0562 |
| 8 | 1.1389 | 1.1763 | 1.0082 | .9522 | 1.1389 | 1.1016 | 1.2071 |
| 9 | 1.1949 | 1.3443 | 1.2696 | .9896 | 1.1883 | 1.251 | 1.3392 |
| 10 | 1.2883 | 1.3443 | 1.3443 | 1.2071 | 1.251 | 1.307 | 1.3203 |
| 11 | 1.307 | 1.2883 | 1.3256 | 1.1949 | 1.307 | 1.4003 | 1.3535 |
| 12 | 1.251 | 1.2696 | 1.307 | 1.2883 | 1.251 | 1.3817 | 1.3969 |
| 13 | 1.1949 | 1.2323 | | 1.2136 | 1.251 | 1.3443 | 1.39 |
| 14 | 1.1016 | 1.2323 | 1.2696 | 1.1128 | 1.2323 | 1.251 | 1.2986 |
| 15 | 1.1203 | 1.1576 | 1.2323 | 1.0185 | 1.1949 | 1.251 | 1.2403 |
| 16 | 1.0642 | 1.251 | 1.1949 | 1.0456 | 1.2323 | 1.307 | 1.3432 |
| 17 | 1.1203 | 1.307 | 1.2696 | 1.0642 | 1.251 | 1.4377 | 1.3169 |
| 18 | 1.251 | 1.4377 | 1.419 | 1.2826 | 1.4377 | 1.5684 | 1.5278 |
| 19 | 1.6804 | 1.7364 | 1.7364 | 1.3769 | 1.7177 | 1.7551 | 1.905 |
| 20 | 1.5497 | 1.4937 | 1.475 | 1.4901 | 1.643 | 1.6991 | 1.6617 |
| 21 | 1.3443 | 1.363 | 1.4003 | 1.358 | 1.4937 | 1.531 | 1.531 |
| 22 | 1.1949 | 1.1763 | .8552 | 1.2637 | 1.307 | 1.307 | 1.2883 |
| 23 | 1.0082 | .9522 | .9896 | 1.0456 | 1.0642 | 1.1203 | 1.1317 |
| 24 | .7922 | .8402 | .7842 | .7842 | .8676 | .9149 | .9149 |
| Max | 1.6804 | 1.7364 | 1.7364 | 1.4901 | 1.7177 | 1.7551 | 1.905 |
| Min | .6535 | .6908 | .6908 | .6908 | .7655 | .7522 | .7922 |
| Avg | 1.0801 | 1.1304 | 1.1011 | 1.0405 | 1.1522 | 1.2011 | 1.2160 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 227 / 11 KV BAJAJ NGR FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2561 | .2561 | .2715 | .2561 | .2896 | .2896 | .2804 |
| 2 | .2378 | .2534 | .2534 | .2378 | .2896 | .2715 | .2629 |
| 3 | .2378 | .2353 | .2614 | .2378 | .2715 | .2686 | .2629 |
| 4 | .2195 | .2378 | .2353 | .2195 | .2534 | .2507 | .2629 |
| 5 | .2195 | .2195 | .2353 | .2378 | .2561 | .2715 | .2629 |
| 6 | .2561 | .2561 | .2715 | .2715 | .2686 | .2896 | .2804 |
| 7 | .3292 | .3077 | .3258 | .2715 | .2926 | .3258 | .333 |
| 8 | .3475 | .3772 | .3258 | .3258 | .362 | .3439 | .3506 |
| 9 | .3841 | .4163 | .4163 | .3077 | .3772 | .362 | .4031 |
| 10 | .3982 | .3439 | .4344 | .3734 | .3547 | .4108 | .4031 |
| 11 | .3921 | .3734 | .4108 | .3734 | .3801 | .4294 | .3841 |
| 12 | .3734 | .4108 | .3547 | .3921 | .362 | .4108 | .394 |
| 13 | .3547 | .3921 | .4108 | .3921 | .4163 | .4481 | .4024 |
| 14 | .3361 | .3439 | .3734 | .3395 | .3439 | .3921 | .3841 |
| 15 | .3584 | .3258 | .3734 | .2641 | .3258 | .3439 | .3544 |
| 16 | .3174 | .362 | .3547 | .5228 | .3439 | .3801 | .3761 |
| 17 | .3077 | .3982 | .362 | .3174 | .3801 | .4163 | .3841 |
| 18 | .362 | .4344 | .4163 | .3761 | .4344 | .4344 | .439 |
| 19 | .5068 | .5249 | .4887 | .4477 | .5068 | .5068 | .567 |
| 20 | .4706 | .4887 | .4525 | .4477 | .4887 | .5249 | .4887 |
| 21 | .3982 | .4163 | .4344 | .4119 | .4525 | .4344 | .4525 |
| 22 | .362 | .3801 | .3982 | .394 | .4108 | .3982 | .3982 |
| 23 | .3258 | .3258 | .3258 | .3439 | .3547 | .3439 | .3439 |
| 24 | .2534 | .2534 | .2715 | .2534 | .2865 | .3077 | .3077 |
| Max | .5068 | .5249 | .4887 | .5228 | .5068 | .5249 | .567 |
| Min | .2195 | .2195 | .2353 | .2195 | .2534 | .2507 | .2629 |
| Avg | .3335 | .3472 | .3524 | .3340 | .3542 | .3690 | .3658 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 228 / 11 KV SHRADHANANDPETH FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3174 | .3361 | .3174 | .3018 | .3361 | .3439 | .3584 |
| 2 | .2987 | .3361 | .2987 | .3018 | .3361 | .3077 | .3206 |
| 3 | .2801 | .3174 | .2987 | .2829 | .3174 | .3045 | .3206 |
| 4 | .2614 | .2801 | .2801 | .2829 | .3174 | .3224 | .3206 |
| 5 | .2614 | .2987 | .2801 | .3018 | .3361 | .3801 | .3206 |
| 6 | .3174 | .3361 | .3361 | .3174 | .3547 | .3982 | .3584 |
| 7 | .4108 | .4481 | .4338 | .3547 | .3961 | .4338 | .4338 |
| 8 | .5093 | .5658 | .4338 | .4108 | .5228 | .4715 | .5658 |
| 9 | .5228 | .6036 | .5041 | .4481 | .5281 | .5847 | .5281 |
| 10 | .5788 | .6224 | .5788 | .5415 | .6161 | .5975 | .5658 |
| 11 | .5975 | .5975 | .5975 | .5415 | .6036 | .6348 | .6401 |
| 12 | .5601 | .5601 | .6161 | .5975 | .5847 | .6161 | .6447 |
| 13 | .5228 | .5415 | .5788 | .5228 | .5093 | .5788 | .6219 |
| 14 | .4668 | .6036 | .5975 | .5281 | .5658 | .5228 | .567 |
| 15 | .4854 | .547 | .5788 | .4904 | .5281 | .5415 | .5493 |
| 16 | .4481 | .5847 | .5601 | .5228 | .547 | .5788 | .591 |
| 17 | .4904 | .6036 | .5975 | .5041 | .5281 | .6348 | .5853 |
| 18 | .5281 | .6413 | .6535 | .5788 | .6602 | .6722 | .6908 |
| 19 | .7167 | .7733 | .8215 | .5415 | | .8029 | .8215 |
| 20 | .6979 | .6413 | .6348 | .6535 | .7167 | .7655 | .7468 |
| 21 | .5847 | .6036 | .5975 | .5975 | .6602 | .7095 | .6908 |
| 22 | .5281 | .5041 | .5228 | .5415 | .5788 | .5975 | .5601 |
| 23 | .4294 | .3961 | .4108 | .4294 | .4668 | .5228 | |
| 24 | .3206 | .3772 | .3206 | .3174 | .3361 | .3772 | .3734 |
| Max | .7167 | .7733 | .8215 | .6535 | .7167 | .8029 | .8215 |
| Min | .2614 | .2801 | .2801 | .2829 | .3174 | .3045 | .3206 |
| Avg | .4639 | .5050 | .4937 | .4546 | .4933 | .5291 | .5294 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 229 / 11KV VASANT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0377 | .0377 | .0377 | .0377 | .0377 | .0362 | .0377 |
| 2 | .0377 | .0377 | .0377 | .0377 | .0377 | .0362 | .0377 |
| 3 | .0377 | .0377 | .0377 | .0377 | .0377 | .0358 | .0377 |
| 4 | .0377 | .0377 | .0377 | .0377 | .0377 | .0358 | .0377 |
| 5 | .0377 | .0377 | .0377 | .0377 | .0377 | .0362 | .0377 |
| 6 | .0189 | .0377 | .0377 | .0377 | .0377 | .0362 | .0377 |
| 7 | .0189 | .0377 | .0377 | .0377 | .0189 | .0377 | .0377 |
| 8 | .0189 | .0189 | .0377 | .0189 | .0189 | .0377 | .0377 |
| 9 | .0189 | .0377 | .0377 | .0377 | .0189 | .0377 | .0377 |
| 10 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 11 | .0377 | .0373 | .0377 | .0377 | .0377 | .0377 | .0549 |
| 12 | .0377 | .0373 | .0373 | .0377 | .0377 | .0566 | .0537 |
| 13 | .0377 | .0377 | .0377 | .0377 | .0377 | .0566 | .0549 |
| 14 | .0377 | .0377 | .0377 | .0377 | .0377 | .0566 | .0549 |
| 15 | .0377 | .0377 | .0377 | .0377 | .0377 | .0566 | .0532 |
| 16 | .0377 | .0377 | .0377 | .0373 | .0377 | .0377 | .0537 |
| 17 | .0377 | .0377 | .0377 | .0373 | .0377 | .0377 | .0366 |
| 18 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 19 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 20 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 21 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 22 | .0377 | .0377 | .0377 | .0377 | .0373 | .0377 | .0377 |
| 23 | .0377 | .0377 | .0377 | .0377 | .0373 | .0377 | .0377 |
| 24 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| Max | .0377 | .0377 | .0377 | .0377 | .0377 | .0566 | .0549 |
| Min | .0189 | .0189 | .0373 | .0189 | .0189 | .0358 | .0366 |
| Avg | .0346 | .0369 | .0377 | .0369 | .0353 | .0404 | .0418 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 232 / 11KV AATH RASTA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1698 | .168 | .1494 | .1698 | .1886 | .1629 | .1698 |
| 2 | .1698 | .168 | .1494 | .1698 | .1886 | .1448 | .1509 |
| 3 | .1509 | .1494 | .1307 | .1509 | .1698 | .1433 | .1509 |
| 4 | .132 | .1307 | .1307 | .1509 | .1509 | .1612 | .1698 |
| 5 | .1494 | .1307 | .1494 | .1509 | .1509 | .181 | .1698 |
| 6 | .1698 | .168 | .1494 | .168 | .168 | .181 | .1886 |
| 7 | .2054 | .2054 | .1886 | | .1886 | .2075 | .2263 |
| 8 | .2614 | .2263 | .2075 | .1867 | .2263 | .2452 | .2263 |
| 9 | .2614 | .2829 | .2987 | .1867 | .2641 | .2641 | .3395 |
| 10 | .2614 | .3395 | .2801 | .2427 | .2427 | .2614 | .2829 |
| 11 | .2801 | .2801 | .2801 | .2427 | .2829 | .3547 | .2743 |
| 12 | .2801 | .2614 | .2987 | .2614 | .2641 | .2987 | .3045 |
| 13 | .2801 | .2614 | .2801 | .2614 | .2829 | .3174 | .3109 |
| 14 | .2614 | .2452 | .2614 | .2075 | .2829 | .2801 | .2926 |
| 15 | .2427 | .2452 | .2427 | .2263 | .3018 | .2987 | .2835 |
| 16 | .2614 | .2641 | .2427 | .2054 | .3018 | .2987 | .3224 |
| 17 | .2801 | .2641 | .2641 | .2054 | .3018 | .3395 | .3109 |
| 18 | .3174 | .3206 | .3018 | .2614 | .3018 | .3961 | .3395 |
| 19 | .4108 | .3961 | .3772 | .3174 | .415 | .3921 | .4481 |
| 20 | .3361 | .3206 | .3395 | .3174 | .3961 | .3584 | .3734 |
| 21 | .3174 | .3018 | .3206 | .2801 | | .3395 | .3361 |
| 22 | .2614 | .2353 | .2829 | .2614 | .2801 | 1.6975 | .2801 |
| 23 | .2054 | .1886 | .2054 | .2241 | .2054 | .2075 | .2452 |
| 24 | .1698 | .168 | .1509 | .1698 | .1867 | .1886 | .1886 |
| Max | .4108 | .3961 | .3772 | .3174 | .415 | 1.6975 | .4481 |
| Min | .132 | .1307 | .1307 | .1509 | .1509 | .1433 | .1509 |
| Avg | .2431 | .2384 | .2368 | .2182 | .2496 | .3217 | .2660 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 202 / 11KV SHANKAR NAGAR I/C
Feeder KV- 11 / INCOMING

SHEDDABLE URBAN

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3256 | 1.363 | 1.363 | | | 1.3957 | 1.4335 |
| 2 | 1.307 | 1.3817 | 1.3443 | | 1.2696 | 1.358 | 1.4003 |
| 3 | 1.2696 | 1.363 | 1.307 | | 1.2696 | 1.3203 | 1.3443 |
| 4 | 1.2323 | 1.363 | 1.2696 | | 1.2696 | 1.3014 | 1.3014 |
| 5 | 1.226 | 1.358 | 1.2826 | | 1.2696 | 1.3957 | 1.3957 |
| 6 | 1.226 | 1.358 | 1.2637 | | 1.3256 | 1.4712 | 1.4523 |
| 7 | 1.5655 | 1.5844 | 1.4712 | | 1.475 | 1.6032 | 1.6787 |
| 8 | 1.7541 | 1.7353 | 1.5844 | | 1.643 | 1.8296 | 1.8861 |
| 9 | 1.8673 | 1.9427 | 1.8673 | | 1.8111 | 1.9805 | 1.905 |
| 10 | 1.8484 | 1.8673 | 1.8861 | 1.7353 | 1.7918 | 1.9239 | 1.9427 |
| 11 | 1.8858 | 1.9239 | 1.8673 | 1.7541 | 2.037 | 1.905 | 1.9791 |
| 12 | 1.7737 | 1.7737 | 1.7541 | 1.7353 | 1.9239 | 1.9993 | 1.9427 |
| 13 | 1.6804 | 1.6221 | 1.6598 | 1.6032 | 1.8296 | 1.8858 | 1.8671 |
| 14 | 1.6057 | 1.6032 | 1.5655 | 1.5089 | 1.6975 | 1.8484 | 1.773 |
| 15 | *** | 1.5655 | 1.4712 | 1.3769 | 1.6787 | 1.9427 | 1.8107 |
| 16 | 1.5684 | 1.6032 | 1.5278 | 1.3392 | 1.7541 | 1.9044 | 1.8673 |
| 17 | 1.6617 | 1.8484 | 1.4937 | 1.3817 | 2.0351 | 1.9605 | 1.7551 |
| 18 | 1.6409 | 1.8861 | 1.5684 | 1.531 | 2.0144 | 2.0911 | 1.8298 |
| 19 | 2.037 | 2.0559 | 1.9605 | 1.9418 | 2.2731 | 2.4209 | 2.1285 |
| 20 | 1.905 | 2.0559 | 1.9044 | 1.9418 | 2.2731 | 2.2405 | 2.0911 |
| 21 | 1.8296 | 1.9239 | 1.8671 | 1.8484 | 2.0328 | 2.1845 | 1.9605 |
| 22 | 1.7177 | 1.7177 | | 1.6991 | 1.8111 | 1.9231 | 1.9231 |
| 23 | 1.4563 | 1.4937 | | 1.5684 | 1.6787 | 1.7551 | 1.6975 |
| 24 | 1.3256 | 1.3256 | 1.4003 | | 1.363 | 1.5466 | 1.6221 |
| Max | 15.4035 | 2.0559 | 1.9605 | 1.9418 | 2.2731 | 2.4209 | 2.1285 |
| Min | 1.226 | 1.3256 | 1.2637 | 1.3392 | 1.2696 | 1.3014 | 1.3014 |
| Avg | 2.1714 | 1.6548 | 1.5763 | 1.6404 | 1.7186 | 1.7995 | 1.7495 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 223 / 11KV LAXMI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2835 | .3077 | .3077 | | .2987 | .2926 | .3142 |
| 2 | .2865 | .3077 | .3077 | | .2987 | .2926 | .3142 |
| 3 | .2865 | .2896 | .3077 | | .2987 | .2926 | .2957 |
| 4 | .2715 | .2926 | .2926 | | .2987 | .3109 | .3077 |
| 5 | .2715 | .2926 | .2926 | | .2987 | .3511 | .3439 |
| 6 | .2926 | .2926 | .2957 | | .3547 | .3511 | .3511 |
| 7 | .4435 | .4435 | .4024 | | .4481 | .4066 | .4435 |
| 8 | .499 | .5175 | .4854 | | .5041 | .499 | .5544 |
| 9 | .5175 | .5415 | .5175 | | .5228 | .5359 | .5544 |
| 10 | .5175 | .5121 | .5544 | .5175 | .4805 | .499 | .4755 |
| 11 | .4435 | .5175 | .5175 | .5853 | .5544 | .4805 | .5121 |
| 12 | .4066 | .4525 | .4572 | .5359 | .5121 | .4938 | .4706 |
| 13 | .3841 | .3801 | .3982 | .4755 | .4755 | .4525 | .4572 |
| 14 | .3403 | .3772 | .362 | .4207 | .3881 | .4706 | .4163 |
| 15 | .3292 | .3772 | | .3658 | .4066 | .4024 | .4066 |
| 16 | .3258 | .3772 | .3658 | .362 | .4066 | .4024 | .4572 |
| 17 | .3982 | .4904 | .3734 | .3361 | .439 | .439 | .4108 |
| 18 | .4338 | .5093 | .4108 | .4108 | .4755 | .5249 | .4854 |
| 19 | .547 | .5847 | .5788 | .547 | .5853 | .5194 | .5601 |
| 20 | .5281 | .5658 | .5228 | .5601 | .5611 | .6219 | .5788 |
| 21 | .5281 | .5281 | .5228 | .5228 | .5611 | .5973 | .5415 |
| 22 | .4525 | .4525 | | .4854 | .4706 | .5487 | .5228 |
| 23 | .3439 | .362 | | .4108 | .4207 | .4572 | .3881 |
| 24 | .2835 | .2896 | .3439 | | .3547 | .3292 | .3841 |
| Max | .547 | .5847 | .5788 | .5853 | .5853 | .6219 | .5788 |
| Min | .2715 | .2896 | .2926 | .3361 | .2987 | .2926 | .2957 |
| Avg | .3923 | .4192 | .4103 | .4668 | .4340 | .4405 | .4394 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 224 / 11KV ABHYANKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3077 | .3353 | .3222 | | .3547 | .3258 | .3641 |
| 2 | .3113 | .3353 | .3222 | | .3547 | .3258 | .3506 |
| 3 | .3018 | .3561 | .3258 | | .3547 | .3258 | .3506 |
| 4 | .3018 | .3561 | .3086 | | .3547 | .3467 | .333 |
| 5 | .2915 | .3429 | .3121 | | .3547 | .3681 | .3506 |
| 6 | .2947 | .3467 | .3121 | | .3547 | .3681 | .3681 |
| 7 | .3475 | .3982 | .362 | | | .3982 | .3982 |
| 8 | .4163 | .4344 | .3982 | | .4108 | .4755 | .4525 |
| 9 | .5121 | .5068 | .5068 | | .4481 | .4887 | .4656 |
| 10 | .4706 | .4887 | .4835 | .4525 | .4163 | .4656 | .5014 |
| 11 | .5194 | .4835 | .5014 | .4163 | .5487 | .4656 | .5194 |
| 12 | .4557 | .4656 | .4733 | .4344 | .4835 | .4961 | .5194 |
| 13 | .4557 | .4207 | .4382 | .394 | .4477 | .4733 | .5014 |
| 14 | .4681 | .415 | .4075 | .3721 | .4344 | .4656 | .4607 |
| 15 | .4031 | .4338 | .3582 | .3403 | .3982 | .4656 | .4656 |
| 16 | .4031 | .4527 | .3856 | .3403 | .4163 | .4904 | .4477 |
| 17 | .4075 | .5658 | .4108 | .3547 | .4477 | .4656 | .4481 |
| 18 | .4715 | .5847 | .4854 | .4108 | .5083 | .5959 | .5041 |
| 19 | .6224 | .5847 | .5975 | .5601 | .5959 | .631 | .6348 |
| 20 | .5658 | .6224 | .5601 | .5601 | .5548 | .5959 | .5975 |
| 21 | .4904 | .6036 | .5601 | .5228 | .5375 | .5609 | .5601 |
| 22 | .4287 | .4681 | | .4854 | .4557 | .4733 | .5601 |
| 23 | .3688 | .373 | | .4481 | .4161 | .4334 | .4161 |
| 24 | .3077 | .3353 | .3222 | | .3547 | .3772 | .3814 |
| Max | .6224 | .6224 | .5975 | .5601 | .5959 | .631 | .6348 |
| Min | .2915 | .3353 | .3086 | .3403 | .3547 | .3258 | .333 |
| Avg | .4135 | .4462 | .4161 | .4351 | .4349 | .4533 | .4563 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 225 / 11KV SHIVAJI NAGAR(NAGPUR)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1086 | .1097 | .1267 | | .1307 | .1267 | .1463 |
| 2 | .1086 | .1097 | .1267 | | .1307 | .1267 | .1463 |
| 3 | .1097 | .1109 | .1097 | | .1307 | .1267 | .128 |
| 4 | .1097 | .1109 | .1109 | | .1307 | .1097 | .1294 |
| 5 | .1109 | .112 | .112 | | .1307 | .1294 | .1307 |
| 6 | .112 | .112 | .1132 | | .1307 | .1478 | .132 |
| 7 | .1663 | .1848 | .1646 | | .1307 | .1867 | .2033 |
| 8 | .168 | .1848 | .1307 | | .112 | .1494 | .1867 |
| 9 | .168 | .2054 | .1886 | | .168 | .1867 | .1494 |
| 10 | .1867 | .2012 | .1867 | .168 | .1886 | .1663 | .1867 |
| 11 | .1848 | .1848 | .1829 | .1829 | .1848 | .1478 | .1829 |
| 12 | .1663 | .1478 | .1478 | .1663 | .1463 | .1848 | .1478 |
| 13 | .1294 | .1294 | .1494 | .1646 | .1848 | .1307 | .1646 |
| 14 | .1294 | .1448 | .1494 | .1646 | .1478 | .1478 | .1294 |
| 15 | .128 | .1132 | .1109 | .1109 | .1307 | .1494 | .1294 |
| 16 | .1267 | .1267 | .1109 | .1109 | .1463 | .1646 | .1307 |
| 17 | .1109 | .1267 | .112 | .1307 | .1463 | .1463 | .1307 |
| 18 | .1448 | .1509 | .1307 | .1494 | .1595 | .197 | .1494 |
| 19 | .181 | .181 | .1867 | .1886 | .2149 | .2328 | .1867 |
| 20 | .1629 | .181 | .1867 | .1867 | .1991 | .1991 | .1867 |
| 21 | .1629 | .181 | .168 | .1867 | .181 | .2012 | .1867 |
| 22 | .1646 | .1463 | | .168 | .1448 | .2012 | .1867 |
| 23 | .128 | .1463 | | .1494 | .1448 | .1663 | .1867 |
| 24 | .1086 | .1097 | .1267 | | .1307 | .1478 | .1463 |
| Max | .1867 | .2054 | .1886 | .1886 | .2149 | .2328 | .2033 |
| Min | .1086 | .1097 | .1097 | .1109 | .112 | .1097 | .128 |
| Avg | .1407 | .1463 | .1424 | .1591 | .1519 | .1614 | .1576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 226 / 11KV VNIT(COLLEGE)

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4527 | .4527 | .4382 | | .3734 | 1.7918 | .4527 |
| 2 | .4338 | .4715 | .4338 | | .3734 | .4338 | .4527 |
| 3 | .4338 | .4715 | .4191 | | .3734 | .415 | .4338 |
| 4 | .415 | .4715 | .415 | | .3734 | .3772 | .3772 |
| 5 | .3961 | .4527 | .415 | | .3734 | .3772 | .415 |
| 6 | .3772 | .4527 | .3961 | | .3734 | .4338 | .4527 |
| 7 | .4572 | .4191 | .4001 | | .4108 | .4572 | .4763 |
| 8 | .5335 | .4527 | .415 | | .5041 | .5281 | .5281 |
| 9 | .5144 | .5144 | .4715 | | .5228 | .5525 | .5093 |
| 10 | .4954 | .4668 | .4527 | .415 | .5335 | .5716 | .547 |
| 11 | .5281 | .5335 | .4338 | .415 | .5525 | .5788 | .5716 |
| 12 | .5335 | .5093 | .4338 | .4338 | .5281 | .6097 | .5847 |
| 13 | .4904 | .4715 | .4527 | .3921 | .4904 | .5658 | .5281 |
| 14 | .4572 | .4715 | .3734 | .3734 | .5093 | .5281 | .5281 |
| 15 | .4954 | .4904 | .415 | .3734 | .5281 | .679 | .5658 |
| 16 | .4954 | .4904 | .4338 | .3547 | .5906 | .6413 | .6097 |
| 17 | .5601 | .5093 | .4108 | .4294 | .6036 | .679 | .6161 |
| 18 | .4527 | .5093 | .3921 | .4481 | .6036 | .5716 | .5228 |
| 19 | .5281 | .547 | .4854 | .5415 | .6224 | .6668 | .6161 |
| 20 | .5281 | .547 | .5041 | .5041 | .6097 | .6097 | .5601 |
| 21 | .5281 | .4904 | .5041 | .4854 | .5658 | .5906 | .547 |
| 22 | .4755 | .4715 | | .4481 | .5093 | .5335 | |
| 23 | .4527 | .4572 | | .4481 | .5144 | 5.2812 | .5281 |
| 24 | .4527 | .4382 | .4382 | | .4108 | .4904 | .5093 |
| Max | .5601 | .547 | .5041 | .5415 | .6224 | 5.2812 | .6161 |
| Min | .3772 | .4191 | .3734 | .3547 | .3734 | .3772 | .3772 |
| Avg | .4786 | .4818 | .4334 | .4330 | .4938 | .7902 | .5188 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 227 / 11KV CIIMS HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0903 | .0732 | .084 | | .1132 | .096 | .0743 |
| 2 | .0892 | .0732 | .072 | | .112 | .0974 | .072 |
| 3 | .0667 | .0619 | .1017 | | .112 | .0846 | .0674 |
| 4 | .0857 | .0648 | .1017 | | .112 | .0861 | .0652 |
| 5 | .104 | .0572 | .072 | | .112 | .1027 | .0823 |
| 6 | .0823 | .0686 | .072 | | .112 | .1054 | .088 |
| 7 | .0867 | .08 | .0914 | | .112 | .1 | .1067 |
| 8 | .0869 | .08 | .1067 | | .112 | .1677 | .9736 |
| 9 | .128 | .125 | .125 | | .1494 | .1867 | .1791 |
| 10 | .128 | .1463 | .156 | .1265 | .1417 | .1848 | .1848 |
| 11 | .1886 | .156 | .1772 | .0857 | .1646 | .1867 | .1629 |
| 12 | .1829 | .1646 | .1791 | .104 | .2075 | .1629 | .1629 |
| 13 | .1848 | .1612 | .1646 | .1187 | .1867 | .2263 | .1829 |
| 14 | .1646 | .1886 | .2263 | .112 | .1867 | .1867 | .1867 |
| 15 | .1402 | .1494 | .1867 | .1311 | .1848 | .2075 | .2054 |
| 16 | .181 | .1372 | .1886 | .1134 | .1646 | .2075 | .1886 |
| 17 | .1417 | .1372 | .1867 | .1307 | .1867 | .2075 | .1494 |
| 18 | .12 | .1372 | .1494 | .112 | .2452 | .1296 | .168 |
| 19 | | .1372 | .112 | .112 | .2286 | .208 | .1307 |
| 20 | .1052 | .12 | .1307 | .1307 | .1433 | .1578 | .168 |
| 21 | .1097 | .1029 | .112 | .1307 | .1387 | .181 | .112 |
| 22 | .1134 | .104 | | .112 | .1387 | .12 | .1494 |
| 23 | .0892 | .08 | | .1132 | .112 | .1187 | .1094 |
| 24 | .0903 | .0732 | .1067 | | .112 | .1296 | .0991 |
| Max | .1886 | .1886 | .2263 | .1311 | .2452 | .2263 | .9736 |
| Min | .0667 | .0572 | .072 | .0857 | .112 | .0846 | .0652 |
| Avg | .1200 | .1116 | .1319 | .1166 | .1495 | .1517 | .1695 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 201 / 11 KV Switching campus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4525 | .4477 | .499 | .6219 | .5792 | .5068 | .5792 |
| 2 | .4525 | .4298 | .4854 | .6653 | .543 | .5068 | .567 |
| 3 | .4344 | .4119 | .4715 | .6348 | 1.7194 | .4887 | .5487 |
| 4 | .4298 | .4119 | .4435 | .6036 | .5068 | .4938 | .5121 |
| 5 | .394 | .4298 | .4294 | .5544 | .4344 | .4938 | .5121 |
| 6 | .3982 | .4835 | .4024 | .5228 | | .5175 | .5544 |
| 7 | .4344 | .6224 | .4668 | .4854 | | .6413 | .679 |
| 8 | .543 | .6908 | .499 | .5175 | | .6535 | .7095 |
| 9 | .6468 | .7095 | .7468 | .5601 | | .7282 | .7577 |
| 10 | .6908 | .7207 | .7023 | .5914 | .5853 | .7282 | .7655 |
| 11 | .7655 | .7023 | .6653 | .5788 | .6283 | .7023 | .7392 |
| 12 | .6099 | .6283 | .7316 | .5788 | .7095 | .6653 | .695 |
| 13 | .5914 | .5487 | .6036 | .6283 | .7023 | .6099 | .7207 |
| 14 | .4887 | .5304 | .567 | .5415 | .7468 | .5487 | .7095 |
| 15 | .4755 | .4755 | .5175 | .5415 | .7392 | .5304 | .7392 |
| 16 | .5068 | .5487 | .5304 | .5304 | .695 | .5304 | .6348 |
| 17 | .5487 | .5853 | .5487 | .5175 | .6653 | .6468 | .5914 |
| 18 | .5731 | .6154 | .5853 | .5487 | .6348 | .7468 | .7023 |
| 19 | .788 | .6516 | .8145 | .6219 | .7392 | .8501 | .905 |
| 20 | .7421 | .724 | .7682 | .6584 | .8413 | .8589 | .8507 |
| 21 | .7442 | .6516 | .7577 | .7316 | .8131 | .8316 | .8145 |
| 22 | .7164 | .5975 | .7468 | .6219 | .7316 | .7682 | .7947 |
| 23 | .6024 | .5544 | .7023 | .695 | .5975 | .6516 | .6219 |
| 24 | .5373 | .4835 | .5014 | .6516 | .6516 | .543 | .5973 |
| Max | .788 | .724 | .8145 | .7316 | 1.7194 | .8589 | .905 |
| Min | .394 | .4119 | .4024 | .4854 | .4344 | .4887 | .5121 |
| Avg | .5653 | .5690 | .5911 | .5918 | .7132 | .6351 | .6792 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 202 / 11 kv gokulpeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1791 | .1595 | .1848 | .2561 | .2172 | .2149 | .2481 |
| 2 | .1448 | .1595 | .1829 | .2218 | .1448 | .197 | .2481 |
| 3 | .1448 | .1595 | .1698 | .1867 | .1448 | .181 | .2303 |
| 4 | .1086 | .1595 | .168 | .1509 | .1448 | .181 | .2328 |
| 5 | .1086 | .1612 | .1478 | .1463 | .1086 | .181 | .2328 |
| 6 | .1086 | .1791 | .1494 | .1848 | | .2172 | .2353 |
| 7 | .1075 | .2054 | .1848 | .2054 | | .2427 | .2614 |
| 8 | .1448 | .2241 | .2241 | .2218 | | .2427 | .2614 |
| 9 | .2378 | .2614 | .2561 | .2743 | | .3174 | .3174 |
| 10 | .3174 | .3326 | .2772 | .2957 | .2195 | .3326 | .3511 |
| 11 | .3696 | .3696 | .3547 | .2987 | .2587 | .3475 | .4108 |
| 12 | .3326 | .3881 | .3696 | .3174 | .2987 | .3881 | .3658 |
| 13 | .362 | .3696 | .3326 | .3142 | .2957 | .3841 | .3881 |
| 14 | .3326 | .3696 | .3801 | .2957 | .3326 | .3696 | .3734 |
| 15 | .3326 | .3547 | .3142 | .2926 | .3475 | .3475 | .4024 |
| 16 | .3109 | .3326 | .3475 | .2957 | .3511 | .3475 | .4066 |
| 17 | .3326 | .3258 | .3511 | .2772 | .3174 | .3696 | .3921 |
| 18 | .3511 | .3077 | .3511 | .2926 | .2957 | .4024 | .4251 |
| 19 | .4854 | .3077 | .5068 | .3109 | .3475 | .4066 | .5249 |
| 20 | .4525 | .2896 | .4755 | .3045 | .499 | .4805 | .4938 |
| 21 | .4024 | .2896 | .3841 | .3292 | .4854 | .4755 | .4572 |
| 22 | .3142 | .2772 | .3696 | .2865 | .4435 | .462 | .3582 |
| 23 | .2328 | .2614 | .3361 | .2507 | .2507 | .2896 | .3045 |
| 24 | .2507 | .1772 | .2103 | .2957 | .2172 | .2507 | .2481 |
| Max | .4854 | .3881 | .5068 | .3292 | .499 | .4805 | .5249 |
| Min | .1075 | .1595 | .1478 | .1463 | .1086 | .181 | .2303 |
| Avg | .2693 | .2676 | .2928 | .2627 | .2860 | .3179 | .3404 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 203 / 11 KV Dharampeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0175 | .0177 | .0358 | .0343 | .0179 | .0179 | .0177 |
| 2 | .0181 | .0177 | .0343 | .0179 | .0179 | .0177 | .0177 |
| 3 | .0181 | .0177 | .0335 | .0183 | .0179 | .0177 | .0177 |
| 4 | .0175 | .0177 | .0339 | .0168 | .0179 | .0177 | .0177 |
| 5 | .0181 | .0175 | .0305 | .017 | .0179 | .0177 | .0177 |
| 6 | .0181 | .0173 | .037 | .0179 | | .0173 | .0177 |
| 7 | .0181 | .0175 | .0373 | .0185 | | .0177 | .0177 |
| 8 | .0181 | .0177 | .0366 | .0187 | | .0168 | .0347 |
| 9 | .0358 | .0168 | .0358 | .0183 | | .0354 | .0354 |
| 10 | .0358 | .0175 | .0366 | .0185 | .0183 | .0354 | .0358 |
| 11 | .0549 | .0543 | .037 | .0366 | .037 | .0724 | .0549 |
| 12 | .0732 | .0914 | .1097 | .0366 | .0366 | .0914 | .0554 |
| 13 | .0732 | .0732 | .0905 | .037 | .0358 | .0914 | .0366 |
| 14 | .0724 | .0914 | .0914 | .0554 | .0362 | .0914 | .037 |
| 15 | .0914 | .0914 | .1086 | .0724 | .0732 | .0914 | .0373 |
| 16 | .0732 | .0724 | .0924 | .0543 | .0739 | .0732 | .0914 |
| 17 | .0895 | .0716 | .0905 | .0549 | .056 | .0739 | .0914 |
| 18 | .0739 | .1075 | .0905 | .0358 | .037 | .0732 | .0914 |
| 19 | .0924 | .0724 | .1097 | .0362 | | .0739 | .1109 |
| 20 | .0924 | .0358 | .0914 | .0362 | | .0747 | .1109 |
| 21 | .0732 | .0358 | .0732 | .0358 | .0732 | .0739 | .0924 |
| 22 | .037 | .0362 | .0554 | .0351 | .0537 | .056 | .0377 |
| 23 | .0175 | .0366 | .0366 | .0351 | .0354 | .0358 | .0354 |
| 24 | .0181 | .0177 | .0358 | .0362 | .0179 | .0358 | .0354 |
| Max | .0924 | .1075 | .1097 | .0724 | .0739 | .0914 | .1109 |
| Min | .0175 | .0168 | .0305 | .0168 | .0179 | .0168 | .0177 |
| Avg | .0478 | .0443 | .061 | .0331 | .0374 | .0508 | .0478 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 204 / 11 KV Bajaj Nagar

SHEDDABLE URBAN

switching Feeder KV- 11 /
OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0362 | .0189 | .0366 | .0362 | .0181 | | .0377 |
| 2 | .0362 | .0189 | .0185 | .0183 | .0181 | .0377 | .0373 |
| 3 | .0362 | .0189 | .0187 | .0185 | .0181 | .0377 | .0373 |
| 4 | .0362 | .0189 | .0185 | .0187 | .0181 | .0377 | .0373 |
| 5 | .0362 | .0189 | .0185 | .0189 | .0181 | .0377 | .0373 |
| 6 | .0362 | .0189 | .0187 | .0183 | | .0377 | .0377 |
| 7 | .0181 | .0373 | .037 | .0187 | | .0754 | .0754 |
| 8 | .0181 | .056 | .0366 | .037 | | .0373 | .056 |
| 9 | .0373 | .0566 | .0554 | .0366 | | .0566 | .0373 |
| 10 | .0377 | .0566 | .056 | .037 | .0366 | .0366 | .0366 |
| 11 | .0566 | .0537 | .056 | .0373 | .037 | .0554 | .0554 |
| 12 | .037 | .0377 | .0373 | .0377 | .0362 | .0554 | .0373 |
| 13 | .0549 | .0373 | .0362 | .0373 | .0366 | .0554 | .0549 |
| 14 | .0554 | .0373 | .0373 | .0373 | .037 | .037 | .037 |
| 15 | .0373 | .0377 | .0377 | .0377 | .056 | .037 | .0373 |
| 16 | .0373 | .0373 | .0373 | .0377 | .037 | .037 | .0554 |
| 17 | .037 | .0358 | .0377 | .037 | .0373 | .056 | .0373 |
| 18 | .0362 | .0362 | .0566 | .0366 | .0366 | .0554 | .037 |
| 19 | .056 | .0358 | .0554 | .0366 | .0366 | .0373 | .0724 |
| 20 | .037 | .0358 | .0554 | .0366 | .0924 | .0549 | .0566 |
| 21 | .0377 | | .056 | .0373 | .0554 | .0739 | .0566 |
| 22 | .0373 | .0366 | .037 | .0377 | .0373 | .0549 | .0554 |
| 23 | .0377 | .037 | .0366 | .0358 | .0377 | .0377 | .0377 |
| 24 | .0362 | .0189 | .0377 | .0366 | .0181 | .0373 | .0377 |
| Max | .0566 | .0566 | .0566 | .0377 | .0924 | .0754 | .0754 |
| Min | .0181 | .0189 | .0185 | .0183 | .0181 | .0366 | .0366 |
| Avg | .0384 | .0347 | .0387 | .0324 | .0359 | .0469 | .0457 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 205 / 11 KV Incommer from
Shankar Na Feeder KV- 11 /
INCOMING

SHEDDABLE URBAN

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6878 | .7164 | .7468 | .9335 | .8326 | .823 | .8507 |
| 2 | .6447 | .6984 | .7207 | .8501 | .724 | .8048 | .8326 |
| 3 | .6335 | .7059 | .7095 | .7316 | .724 | .7865 | .7964 |
| 4 | .5973 | .6878 | .679 | .7167 | .6878 | .7865 | .7602 |
| 5 | .5611 | .6697 | .6219 | .6722 | .5731 | .7865 | .7602 |
| 6 | .5611 | .724 | .5914 | .5853 | | .7865 | .8501 |
| 7 | .5792 | .8589 | .7468 | .6099 | | .9335 | .9335 |
| 8 | .724 | 1.0082 | .8131 | .8029 | | .9896 | 1.0456 |
| 9 | .961 | 1.0082 | 1.0082 | .8316 | | 1.0829 | 1.0719 |
| 10 | 1.0829 | 1.1273 | .961 | .8775 | .8596 | 1.0903 | 1.1203 |
| 11 | 1.1273 | 1.0349 | 1.1016 | .8589 | .924 | 1.1088 | |
| 12 | 1.0349 | 1.1088 | 1.134 | .9335 | .9709 | 1.1458 | 1.0974 |
| 13 | 1.0791 | 1.0349 | 1.0608 | .9795 | .961 | 1.0719 | 1.1458 |
| 14 | .9328 | .9979 | 1.0059 | .8501 | 1.0082 | 1.0425 | 1.1203 |
| 15 | .9145 | .9425 | .924 | .8131 | 1.2012 | .9877 | 1.1827 |
| 16 | .9328 | .9795 | .9877 | .823 | 1.1706 | .9694 | 1.1389 |
| 17 | .9795 | .9412 | .9877 | .8316 | 1.1088 | 1.1458 | 1.1016 |
| 18 | 1.0242 | 1.0679 | 1.0242 | .9145 | 1.0456 | 1.2323 | 1.2254 |
| 19 | 1.3717 | 1.0679 | 1.386 | 1.0498 | 1.1458 | 1.4045 | 1.5384 |
| 20 | 1.3032 | 1.086 | 1.2757 | 1.0425 | 1.4563 | 1.4632 | 1.4266 |
| 21 | 1.1765 | | 1.1706 | 1.134 | 1.3676 | 1.3676 | 1.3169 |
| 22 | 1.1041 | .961 | 1.1458 | .9774 | 1.2323 | 1.307 | 1.1576 |
| 23 | .8688 | .9335 | 1.0349 | 1.0136 | .905 | .9774 | 1.0498 |
| 24 | .8507 | .7701 | .8059 | | .8954 | .8326 | .905 |
| Max | 1.3717 | 1.1273 | 1.386 | 1.134 | 1.4563 | 1.4632 | 1.5384 |
| Min | .5611 | .6697 | .5914 | .5853 | .5731 | .7865 | .7602 |
| Avg | .9055 | .9187 | .9435 | .8623 | .9897 | 1.0386 | 1.0621 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 201 / 11 KV CAMPUS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4191 | .2473 | .1143 | .2382 | .1381 | .2972 | .3498 |
| 2 | .4191 | .2431 | .0922 | .2382 | .1132 | .2774 | .3292 |
| 3 | .4001 | .2431 | .1219 | .2286 | .1734 | .2576 | .2972 |
| 4 | .4001 | .2431 | .08 | .2286 | .1288 | .2625 | .3086 |
| 5 | .4001 | .2599 | .1572 | .2191 | .18 | .2576 | .3292 |
| 6 | .5716 | .2743 | .5258 | .2572 | .1707 | .3353 | .3734 |
| 7 | .5716 | .3647 | .1271 | .3447 | .1572 | .3822 | .4047 |
| 8 | .5716 | .3719 | .1271 | .3544 | .1707 | .6287 | .3948 |
| 9 | .3898 | .5975 | .1271 | .3898 | .1509 | .3628 | .3961 |
| 10 | .3426 | .421 | .1341 | .3898 | .1635 | .4024 | .421 |
| 11 | .7095 | .1684 | .2858 | .4405 | .2317 | .1536 | .4271 |
| 12 | .3433 | .1951 | .3961 | .1593 | .4441 | .1684 | .6722 |
| 13 | .3292 | .1536 | .3719 | .149 | .4252 | .1429 | .4068 |
| 14 | .2881 | .1768 | .3395 | .2401 | .3841 | .2928 | .3835 |
| 15 | .2576 | .1852 | | .1635 | .3658 | .2321 | .3909 |
| 16 | .2477 | .1715 | .3248 | .1315 | .3601 | .2267 | .3597 |
| 17 | .2378 | .1288 | .4763 | .1402 | .3315 | .1227 | .3315 |
| 18 | .2774 | .1429 | .3467 | .189 | .3426 | .3666 | .317 |
| 19 | .3334 | .1715 | .3864 | .3224 | .4178 | .4755 | .4178 |
| 20 | .362 | .2134 | .3982 | .1972 | .3789 | .8775 | .4201 |
| 21 | .3429 | .2332 | .3567 | .1972 | .3765 | .4835 | .4294 |
| 22 | .2926 | .189 | .3563 | .2096 | .3666 | .4557 | .4161 |
| 23 | .2827 | .1381 | .3269 | .3567 | .3567 | .4401 | .3963 |
| 24 | .4294 | .2715 | .109 | .2675 | .1667 | .3269 | .3877 |
| Max | .7095 | .5975 | .5258 | .4405 | .4441 | .8775 | .6722 |
| Min | .2378 | .1288 | .08 | .1315 | .1132 | .1227 | .2972 |
| Avg | .3841 | .2419 | .2644 | .2522 | .2706 | .3429 | .3900 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 202 / 11 KV HINDUSTAHAN COLOANY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1334 | .0093 | .0307 | .0107 | .0333 | .028 | .0267 |
| 2 | .1334 | .0122 | .044 | .0107 | .0293 | .028 | .0267 |
| 3 | .1334 | .0103 | .0251 | .0107 | .0366 | .1334 | .0267 |
| 4 | .1334 | .0091 | .0229 | .0091 | .0286 | .028 | .0267 |
| 5 | .1334 | .0069 | .0293 | .0091 | .0183 | .0293 | .0267 |
| 6 | .1524 | .0229 | .0396 | .0114 | .0293 | .0377 | .0305 |
| 7 | .2096 | .0572 | .0377 | .0267 | .0503 | .0686 | .0553 |
| 8 | .1905 | .0591 | .0629 | .0514 | .0549 | .0566 | .0629 |
| 9 | | .0591 | .0427 | .0419 | .088 | .0817 | .2801 |
| 10 | | .0648 | .0482 | .0381 | .0461 | .0867 | .0671 |
| 11 | .0587 | .096 | .0549 | .0796 | .0526 | .0377 | .0553 |
| 12 | .0457 | .0524 | .0553 | .0823 | .0713 | .1578 | .1494 |
| 13 | .0293 | .0394 | .0463 | .0629 | .0553 | .0503 | .032 |
| 14 | .0293 | .0396 | .0335 | .0351 | .0503 | .084 | .0244 |
| 15 | .0274 | .0427 | .0206 | .0251 | .024 | .0707 | .0253 |
| 16 | .0274 | .056 | .0229 | .0263 | .028 | .0307 | .0274 |
| 17 | .0457 | .0429 | .029 | .044 | .032 | .0351 | .032 |
| 18 | .0335 | .0549 | .0362 | .0549 | .0377 | .0476 | .0343 |
| 19 | .0461 | .0526 | .04 | .0482 | .0377 | .0572 | .0461 |
| 20 | .0503 | .0476 | .048 | .0438 | .0461 | .0524 | .0419 |
| 21 | .0503 | .0461 | .04 | .0686 | .0381 | .0524 | .0419 |
| 22 | .0457 | .0438 | | .0476 | .1715 | .0482 | .1867 |
| 23 | .0168 | .0503 | .0274 | | .0305 | .036 | .0343 |
| 24 | .1307 | .008 | .0351 | .0213 | .0335 | .0267 | .032 |
| Max | .2096 | .096 | .0629 | .0823 | .1715 | .1578 | .2801 |
| Min | .0168 | .0069 | .0206 | .0091 | .0183 | .0267 | .0244 |
| Avg | .0844 | .0410 | .0379 | .0374 | .0468 | .0569 | .0580 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 203 / 11 KV NIT-GOKULPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4191 | .3921 | .3641 | .4382 | .4031 | .4954 | .4854 |
| 2 | .4191 | .3921 | .3506 | .4382 | .4075 | .4572 | .4294 |
| 3 | .4001 | .3734 | .3544 | .4191 | .3856 | .4382 | .4294 |
| 4 | .4001 | .3734 | .3814 | .4191 | .415 | .4001 | .4294 |
| 5 | .381 | .4108 | .3856 | .4001 | .4031 | .381 | .4481 |
| 6 | .4382 | .4481 | .3988 | .4191 | .4207 | .4572 | .4854 |
| 7 | .5525 | .5415 | .4973 | .4191 | .1524 | .5906 | .6161 |
| 8 | .6287 | .5601 | .567 | .5525 | .5258 | .6287 | .6348 |
| 9 | .6287 | .6535 | .5784 | .6097 | .5784 | .6859 | .6722 |
| 10 | .6859 | .6908 | .4557 | .6668 | .6201 | .724 | .6348 |
| 11 | .7655 | .6836 | .7621 | .6287 | .7888 | .6935 | .7468 |
| 12 | .7282 | .7108 | .8192 | .6733 | .8764 | .7011 | .7655 |
| 13 | .6535 | .631 | .743 | .7011 | .7621 | .6661 | .7655 |
| 14 | .6161 | .5959 | .6859 | .631 | .743 | .6836 | .6348 |
| 15 | .6348 | .5959 | .6668 | .4973 | .6722 | .6661 | .7095 |
| 16 | .6348 | .5609 | .6859 | .5258 | .7049 | .6556 | .7095 |
| 17 | .6348 | .5784 | .6478 | .5609 | .6859 | .7186 | .7468 |
| 18 | .7842 | .7522 | .8002 | .6836 | .9335 | .8402 | .8589 |
| 19 | .9149 | .8495 | 1.0288 | .8589 | 1.0288 | 1.0829 | 1.0456 |
| 20 | .8775 | .8059 | .9526 | .7888 | .9717 | 1.0456 | 1.0082 |
| 21 | .8029 | .7282 | .9335 | .7888 | .9145 | .9149 | .9335 |
| 22 | .6348 | .5895 | .724 | .6135 | .7049 | .7282 | .7842 |
| 23 | .5415 | .5201 | .6287 | .5548 | .6097 | .6535 | .6535 |
| 24 | | .4294 | .4334 | .5335 | .4733 | .5525 | .5415 |
| Max | .9149 | .8495 | 1.0288 | .8589 | 1.0288 | 1.0829 | 1.0456 |
| Min | .381 | .3734 | .3506 | .4001 | .1524 | .381 | .4294 |
| Avg | .6164 | .5778 | .6186 | .5759 | .6326 | .6609 | .6737 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 204 / 11KV BULDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1334 | .1307 | .1402 | .1524 | .12 | .1334 | .1494 |
| 2 | .1334 | .1307 | .1509 | .1524 | .12 | .1334 | .1494 |
| 3 | .1334 | .1307 | .1267 | .1524 | .1052 | .1334 | .1307 |
| 4 | .1334 | .1307 | .1063 | .1524 | .1063 | .1334 | .1307 |
| 5 | .1334 | .1307 | .1063 | .1524 | .1227 | .1524 | .1307 |
| 6 | .1334 | .1307 | .1214 | .1524 | .12 | .1334 | .1307 |
| 7 | .1524 | .1494 | .1578 | .1524 | .1402 | .1524 | .1494 |
| 8 | .1715 | .168 | .1417 | .1715 | .1387 | .1715 | .1494 |
| 9 | .1715 | .168 | .1698 | .1715 | .1578 | .1905 | .1867 |
| 10 | .1905 | .2241 | .1698 | .1715 | .1772 | .2096 | .2241 |
| 11 | .2427 | .2103 | .2286 | .1905 | .1924 | .2279 | .2614 |
| 12 | .2241 | .2279 | .2477 | .1753 | .1905 | .2401 | .2801 |
| 13 | .2241 | .2452 | .2477 | .1543 | .2096 | | .2987 |
| 14 | .2427 | .2103 | .2096 | .1578 | .1905 | .2454 | .2427 |
| 15 | .2427 | .2229 | .2286 | .1402 | .2241 | .2454 | .2801 |
| 16 | .2427 | .2058 | .1905 | .1509 | .2096 | .2743 | .2614 |
| 17 | .2614 | .208 | .2286 | .1578 | .2096 | .2229 | .2801 |
| 18 | .2241 | .208 | .2096 | .1578 | .2286 | .2241 | .2427 |
| 19 | .2241 | .2254 | .2286 | .1578 | .2286 | .2427 | .2427 |
| 20 | .2054 | .1886 | .2096 | .1578 | .1905 | .2054 | .2241 |
| 21 | .168 | .1543 | .1905 | .1417 | .1715 | .168 | .1867 |
| 22 | .1494 | .1402 | .1524 | .1402 | .1524 | .168 | .1494 |
| 23 | .1494 | .1402 | .1524 | .1402 | .1524 | .1494 | .1494 |
| 24 | .1307 | .1307 | .1402 | .1524 | .1227 | .1524 | .1494 |
| Max | .2614 | .2452 | .2477 | .1905 | .2286 | .2743 | .2987 |
| Min | .1307 | .1307 | .1063 | .1402 | .1052 | .1334 | .1307 |
| Avg | .1841 | .1755 | .1773 | .1565 | .1659 | .1874 | .1992 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 209 / 11 KV HILLTOP -I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2477 | .0372 | .0667 | .0533 | .1006 | .0762 | .0777 |
| 2 | .2477 | .0343 | .0667 | | .0657 | .0762 | .0732 |
| 3 | .2286 | .0293 | .0434 | .0495 | .1 | .0714 | .0732 |
| 4 | .2286 | .0293 | .0434 | .2477 | .0854 | .0714 | .0743 |
| 5 | .2286 | .0366 | .0507 | .2477 | .0854 | .0714 | .0743 |
| 6 | .2667 | .0594 | .0975 | .0533 | .0943 | .0762 | .0907 |
| 7 | .2858 | .1189 | .0762 | .0892 | .0613 | .1372 | .144 |
| 8 | .381 | .1337 | .0701 | .1158 | .0714 | .362 | .1231 |
| 9 | .1524 | .1486 | .0991 | .1412 | .0838 | .1303 | .052 |
| 10 | .1448 | .1337 | .0833 | .1412 | .104 | .1425 | .1269 |
| 11 | .1257 | .136 | .1158 | .164 | .0869 | .0892 | .1097 |
| 12 | .1067 | .0914 | .1311 | .0713 | .1231 | .0854 | .3174 |
| 13 | .0991 | .0613 | .0732 | .0793 | .1158 | .1029 | .0972 |
| 14 | .0991 | .112 | .0876 | .0714 | .1158 | .12 | .0827 |
| 15 | .088 | .096 | .104 | .0693 | .1067 | .1414 | .088 |
| 16 | .096 | .0743 | .2667 | .0943 | .1231 | .0693 | .088 |
| 17 | .088 | .096 | .0823 | .0671 | .1086 | .0693 | .0854 |
| 18 | .128 | | .048 | .0754 | .0907 | .0892 | .068 |
| 19 | .1753 | .1402 | .1006 | .1572 | .1139 | .1387 | .096 |
| 20 | .1738 | .1463 | .1048 | .1095 | .1189 | .1288 | .1048 |
| 21 | .1738 | .1341 | .1095 | .1097 | .4572 | .1189 | .1238 |
| 22 | .104 | .132 | .1132 | .108 | .1048 | .1052 | .1097 |
| 23 | .0583 | .0857 | .0838 | .0796 | .0953 | .096 | .1048 |
| 24 | .2427 | .0427 | .0457 | .061 | .0842 | .081 | .0869 |
| Max | .381 | .1486 | .2667 | .2477 | .4572 | .362 | .3174 |
| Min | .0583 | .0293 | .0434 | .0495 | .0613 | .0693 | .052 |
| Avg | .1738 | .0917 | .0901 | .1068 | .1124 | .1104 | .1030 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 210 / 11 KV University Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1334 | .0343 | .0307 | .0206 | .0366 | .0229 | .0343 |
| 2 | .1334 | .0343 | .044 | .0206 | .0343 | .0229 | .0343 |
| 3 | .1143 | .0354 | .0366 | .0206 | .0305 | .0286 | .0343 |
| 4 | .1143 | .0354 | .0219 | .0206 | .0248 | .0286 | .0343 |
| 5 | .1143 | .0354 | .021 | .0206 | .0333 | .0286 | .0343 |
| 6 | .1143 | .0343 | .024 | .0206 | .0606 | .0191 | .04 |
| 7 | .1143 | .0366 | .021 | .0953 | .0305 | .0152 | .0343 |
| 8 | .0953 | .0377 | .0263 | .021 | .0263 | .0251 | .0343 |
| 9 | .0267 | .044 | .0293 | .0251 | .0427 | .0305 | .04 |
| 10 | .0343 | .0629 | .072 | .0251 | .0427 | .0305 | .061 |
| 11 | .0629 | .1928 | .0545 | .0293 | .0293 | .0867 | .0838 |
| 12 | .0754 | .2279 | .0503 | .0297 | .0229 | .0619 | .2801 |
| 13 | .0817 | .1212 | .0545 | .0286 | .0229 | .1 | .088 |
| 14 | .0754 | .0869 | .0381 | .0248 | .0251 | .1414 | .088 |
| 15 | .0817 | .088 | .0377 | .0324 | .0251 | .1515 | .1006 |
| 16 | .0692 | .0686 | .0343 | .0219 | .0229 | .0914 | .0914 |
| 17 | .0629 | .0617 | .0377 | .0248 | .1334 | .0793 | .0817 |
| 18 | .044 | .0412 | | .0377 | .0305 | .0692 | .0503 |
| 19 | .0488 | .0507 | .0335 | .0307 | .0305 | .0629 | .0503 |
| 20 | .0293 | .0488 | .0377 | .0396 | .0305 | .0566 | .0566 |
| 21 | .1267 | .0307 | .0377 | .056 | .0335 | .044 | .04 |
| 22 | .044 | .0427 | .0335 | .0381 | .1334 | .044 | .0457 |
| 23 | .0377 | .0333 | .0251 | .04 | .0267 | .044 | .044 |
| 24 | .1307 | .0377 | .0286 | .0251 | .0412 | .0267 | .044 |
| Max | .1334 | .2279 | .072 | .0953 | .1334 | .1515 | .2801 |
| Min | .0267 | .0307 | .021 | .0206 | .0229 | .0152 | .0343 |
| Avg | .0819 | .0634 | .0361 | .0312 | .0404 | .0547 | .0636 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 214 / 11KV TELANGKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2858 | .2801 | .2804 | .3429 | .3155 | .362 | .3734 |
| 2 | .2858 | .2801 | .2774 | .3429 | .298 | .3429 | .3547 |
| 3 | .2858 | .2614 | .2572 | .3429 | .2804 | .3429 | .3547 |
| 4 | .2667 | .2614 | .2629 | .3239 | .2804 | .3429 | .3361 |
| 5 | .2667 | .2801 | .3086 | .3239 | .3155 | .3429 | .3547 |
| 6 | .3239 | .2987 | .333 | .362 | .333 | .362 | .3547 |
| 7 | .381 | .3921 | .3366 | .362 | .3681 | .4382 | .4294 |
| 8 | .4763 | .4668 | .443 | .4954 | .4557 | .5335 | .5041 |
| 9 | .5906 | .5415 | .5493 | .5144 | .5609 | .5525 | .5788 |
| 10 | .4954 | .5228 | .4908 | .4954 | .5201 | .5525 | .5415 |
| 11 | .5041 | .4908 | .5144 | .5525 | .5083 | .4115 | .5415 |
| 12 | .4294 | .4607 | .5144 | .4557 | .5525 | .4458 | .4668 |
| 13 | .3921 | .3856 | .4763 | .4681 | .5335 | .5609 | .5041 |
| 14 | .6161 | .3814 | .4001 | .4607 | .4763 | .3944 | .4481 |
| 15 | .3547 | .298 | .4191 | .3681 | .4294 | .3944 | .4481 |
| 16 | .3547 | .1715 | .4191 | .3506 | .4382 | .3944 | .4481 |
| 17 | .3734 | .3772 | .4191 | .3506 | .4572 | .4115 | .4668 |
| 18 | .4668 | .4334 | .4763 | .5083 | .5335 | .4668 | .4854 |
| 19 | .5788 | .631 | .6287 | .6413 | .6287 | .6722 | .5975 |
| 20 | .5788 | .583 | .6287 | .5434 | .5716 | .6348 | .5788 |
| 21 | .5415 | .5609 | .6097 | .6036 | .5716 | .5975 | .5601 |
| 22 | .4854 | .4733 | .5144 | .5083 | .5144 | .5415 | .5415 |
| 23 | .4108 | .4031 | .4763 | .4557 | .4382 | .4668 | .4481 |
| 24 | .2987 | | .3506 | .381 | .3772 | .381 | .4108 |
| Max | .6161 | .631 | .6287 | .6413 | .6287 | .6722 | .5975 |
| Min | .2667 | .1715 | .2572 | .3239 | .2804 | .3429 | .3361 |
| Avg | .4185 | .4015 | .4328 | .4397 | .4483 | .4561 | .4637 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 215 / 11KV TILAK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4954 | .4854 | .4908 | .4954 | .4458 | .5144 | .5228 |
| 2 | .4954 | .4668 | .4458 | .4954 | .4382 | .5144 | .5041 |
| 3 | .4763 | .4668 | .4287 | .4954 | .4207 | .4954 | .5041 |
| 4 | .4763 | .4668 | .4382 | .4954 | .4207 | .4954 | .4854 |
| 5 | .4763 | .4668 | .4557 | .4954 | .4382 | .5335 | .5041 |
| 6 | .5144 | .4854 | .4801 | .5144 | .4733 | .5525 | .5041 |
| 7 | .5716 | .5415 | .5316 | .4954 | .4961 | .5716 | .5601 |
| 8 | .6478 | .6413 | .5434 | .5906 | .5434 | .6097 | .6224 |
| 9 | .6668 | .6348 | .583 | .6097 | .5959 | .724 | .7095 |
| 10 | .7049 | .7468 | .6415 | .6859 | .631 | .7049 | .6908 |
| 11 | .7095 | .7167 | .7811 | .6668 | .7362 | .7011 | .7468 |
| 12 | .7095 | .6836 | .7049 | .6836 | .8002 | .7011 | .7282 |
| 13 | .7095 | .6661 | .743 | .1762 | .743 | .7011 | .7468 |
| 14 | .7095 | .6979 | .7049 | .6068 | .743 | .691 | .7468 |
| 15 | .7282 | .6415 | .6859 | .5609 | .7282 | .703 | .7282 |
| 16 | .7095 | .6068 | .724 | .5548 | .7621 | .703 | .7468 |
| 17 | .6722 | .6661 | .743 | .5959 | .7621 | .7202 | .8029 |
| 18 | .7842 | .7455 | .8002 | .6733 | .8573 | .7655 | .7842 |
| 19 | .8215 | .7975 | .8192 | .7011 | .8764 | .8215 | .9335 |
| 20 | .7655 | .7362 | .7811 | .7011 | .8002 | .8215 | .8215 |
| 21 | .7095 | .7087 | .724 | .6661 | .7811 | .7282 | .7468 |
| 22 | .6722 | .6135 | .6478 | .5784 | .6478 | .6722 | .6348 |
| 23 | .5788 | .5201 | .6097 | .5258 | .5716 | .6161 | .5788 |
| 24 | .4854 | .5041 | .4908 | .5335 | .4908 | .5335 | .5601 |
| Max | .8215 | .7975 | .8192 | .7011 | .8764 | .8215 | .9335 |
| Min | .4763 | .4668 | .4287 | .1762 | .4207 | .4954 | .4854 |
| Avg | .6371 | .6128 | .6249 | .5666 | .6335 | .6498 | .6631 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 201 / 11KV VNIT(nagpur)

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0642 | 1.1203 | 1.1389 | 1.1949 | 1.251 | 1.2826 | 1.2637 |
| 2 | .9896 | 1.1203 | 1.1389 | 1.1203 | 1.1389 | 1.2449 | 1.2071 |
| 3 | .9896 | 1.0829 | 1.0829 | 1.1389 | 1.1203 | 1.2071 | 1.1317 |
| 4 | 1.0562 | 1.0829 | 1.0751 | 1.1203 | 1.1317 | 1.2071 | 1.1694 |
| 5 | 1.0751 | 1.0829 | 1.1317 | 1.1389 | 1.1506 | 1.2449 | 1.226 |
| 6 | 1.1317 | 1.1203 | 1.226 | 1.1763 | 1.2449 | 1.2826 | 1.3014 |
| 7 | 1.4377 | 1.0269 | 1.4003 | 1.251 | 1.5089 | 1.4712 | 1.5089 |
| 8 | 1.6244 | 1.5684 | 1.419 | 1.3817 | 1.5684 | 1.7353 | 1.773 |
| 9 | 1.7737 | 1.7924 | 1.6804 | 1.475 | 1.7364 | 1.8107 | 1.8296 |
| 10 | 1.6617 | 1.6617 | 1.7737 | 1.5123 | 1.8296 | 1.7353 | 1.773 |
| 11 | 1.7353 | 1.7737 | 1.8111 | 1.7177 | 1.9239 | 1.7918 | 1.8107 |
| 12 | 1.6804 | 1.7177 | 1.7177 | 1.6617 | 1.773 | 1.7353 | 1.8107 |
| 13 | 1.6409 | 1.6057 | 1.531 | 1.4003 | 1.6409 | 1.6598 | 1.7177 |
| 14 | 1.5089 | 1.419 | 1.4377 | 1.419 | 1.5154 | 1.6975 | 1.6991 |
| 15 | 1.4377 | 1.419 | 1.3443 | 1.2883 | 1.5655 | 1.773 | 1.643 |
| 16 | 1.3817 | 1.5123 | 1.3817 | 1.2696 | 1.5089 | 1.8296 | 1.6804 |
| 17 | 1.5466 | 1.6804 | 1.5089 | 1.4335 | 1.6598 | 1.8671 | 1.7364 |
| 18 | 1.6057 | 1.7177 | 1.5466 | 1.5844 | 1.8107 | 1.9044 | 1.7364 |
| 19 | 2.0911 | 2.0538 | 1.9791 | 1.9239 | 2.1125 | 2.2032 | 2.0725 |
| 20 | 1.8671 | 1.9978 | 1.9605 | 1.8671 | 2.037 | 2.1285 | 2.0725 |
| 21 | 1.7924 | 1.8671 | 1.8298 | 1.8111 | 1.8861 | 1.9605 | 1.8298 |
| 22 | 1.6804 | 1.6804 | 1.6617 | 1.7551 | 1.8107 | 1.7924 | 1.7177 |
| 23 | 1.4563 | 1.363 | 1.4563 | 1.531 | 1.5466 | 1.643 | 1.5684 |
| 24 | 1.1576 | 1.2136 | 1.2696 | 1.4563 | 1.3443 | 1.3769 | .9054 |
| Max | 2.0911 | 2.0538 | 1.9791 | 1.9239 | 2.1125 | 2.2032 | 2.0725 |
| Min | .9896 | 1.0269 | 1.0751 | 1.1203 | 1.1203 | 1.2071 | .9054 |
| Avg | 1.4744 | 1.4867 | 1.4793 | 1.4429 | 1.5757 | 1.6494 | 1.5910 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 202 / 11KV SHANKAR NGR

SHEDDABLE URBAN

SWIT.INOMER Feeder KV- 11 /
INCOMING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5601 | .7468 | .7468 | .7655 | .8299 | .8676 |
| 2 | .6722 | .6908 | .6908 | .7282 | .7282 | .7922 | .8299 |
| 3 | .6722 | .6722 | .7095 | .7095 | .6722 | .7922 | .7733 |
| 4 | .679 | .6535 | .679 | .6722 | .7167 | .7922 | .7922 |
| 5 | .679 | .6908 | .679 | .7095 | .679 | .8299 | .8299 |
| 6 | .6979 | .6908 | .7356 | .7468 | .7356 | .8299 | .8488 |
| 7 | .8962 | .7468 | .7842 | .7468 | .9054 | .9431 | .9808 |
| 8 | .9149 | .9896 | .8962 | .8029 | .8402 | .9808 | 1.0562 |
| 9 | 1.0642 | 1.0456 | 1.0456 | .9149 | 1.0456 | 1.0562 | 1.1506 |
| 10 | 1.1203 | 1.1389 | 1.1203 | .9896 | 1.1317 | 1.1317 | 1.2449 |
| 11 | 1.2071 | 1.1763 | 1.1949 | .9335 | 1.2637 | 1.2637 | 1.2637 |
| 12 | 1.0456 | 1.1389 | 1.2323 | 1.0642 | 1.2071 | 1.226 | 1.2136 |
| 13 | 1.0562 | 1.0456 | 1.1203 | 1.0642 | 1.1128 | 1.1883 | 1.1576 |
| 14 | 1.0374 | 1.0269 | 1.1016 | .9335 | 1.0903 | 1.1128 | 1.1576 |
| 15 | .9149 | .8962 | .9896 | .9149 | .9997 | 1.1317 | 1.1576 |
| 16 | .9522 | 1.0269 | 1.0642 | .8589 | .9808 | 1.1883 | 1.1949 |
| 17 | 1.0185 | 1.0082 | 1.1317 | .8676 | 1.1317 | 1.1949 | 1.1763 |
| 18 | 1.1203 | .112 | 1.1694 | 1.1317 | 1.2637 | 1.4003 | 1.2696 |
| 19 | 1.4937 | 1.4937 | 1.531 | 1.3769 | 1.5844 | 1.643 | 1.6991 |
| 20 | 1.419 | 1.4937 | 1.4563 | 1.307 | 1.5089 | 1.5684 | 1.5684 |
| 21 | 1.307 | 1.3443 | 1.3443 | 1.251 | 1.4335 | 1.419 | 1.419 |
| 22 | 1.1576 | 1.1576 | 1.1389 | 1.1389 | 1.2826 | 1.251 | 1.2883 |
| 23 | .9709 | .9522 | .9522 | .9522 | 1.0185 | 1.0562 | 1.2696 |
| 24 | .7468 | .8029 | .8215 | .9522 | .8402 | .8676 | .9808 |
| Max | 1.4937 | 1.4937 | 1.531 | 1.3769 | 1.5844 | 1.643 | 1.6991 |
| Min | .6722 | .112 | .679 | .6722 | .6722 | .7922 | .7733 |
| Avg | .9932 | .9398 | 1.0140 | .9381 | 1.0391 | 1.1037 | 1.1329 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 203 / 11KV RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .2987 | .3174 | .2987 | .2987 | .3395 | .3395 |
| 2 | .2801 | .2987 | .2801 | .2801 | .2987 | .3395 | .3206 |
| 3 | .2614 | .2801 | .2427 | .2801 | .3174 | .3395 | |
| 4 | .2452 | .2987 | .2641 | .2801 | .3018 | .3395 | .3018 |
| 5 | .2829 | .2987 | .2829 | .2801 | .3395 | .3772 | .3206 |
| 6 | .3206 | .3734 | .3206 | .2987 | .3584 | .3772 | .3961 |
| 7 | .4668 | .3734 | .4481 | .4108 | .3961 | .4527 | .4527 |
| 8 | .5228 | .5041 | .4668 | .3921 | .5041 | .5281 | .5281 |
| 9 | .5041 | .5228 | .5788 | .4668 | .5415 | .5847 | .5281 |
| 10 | .5601 | .5788 | .5975 | .5975 | .5847 | .6036 | .5658 |
| 11 | .5847 | .6161 | | .6161 | .7545 | .6413 | .6413 |
| 12 | .5788 | .6348 | .6348 | .5415 | .6979 | .6224 | .6535 |
| 13 | .5281 | .5601 | .6161 | .4294 | .6602 | .6602 | .5975 |
| 14 | .5281 | .5228 | .5975 | .4854 | .5544 | .6413 | .6161 |
| 15 | .4854 | .5788 | .5415 | .4668 | .6036 | .6224 | .5601 |
| 16 | .4854 | .5788 | .5415 | .4668 | .6413 | .6224 | .6161 |
| 17 | .6036 | .5975 | .5658 | .4715 | .6036 | .6535 | .6348 |
| 18 | .5975 | .6348 | .6224 | .5281 | .7545 | .7095 | .6722 |
| 19 | .7468 | .7842 | .7468 | .6413 | .7922 | .8029 | .7655 |
| 20 | .7468 | .7095 | .7095 | .6348 | .7545 | .7655 | .7468 |
| 21 | .6535 | .6722 | .6722 | .5975 | .679 | .6722 | .6722 |
| 22 | .5228 | .5041 | .5601 | .5415 | .6036 | .5975 | .5415 |
| 23 | .4108 | .4294 | .4481 | .4481 | .4527 | .4527 | .4294 |
| 24 | .2987 | .2987 | .3174 | .4481 | .3361 | .3772 | .3772 |
| Max | .7468 | .7842 | .7468 | .6413 | .7922 | .8029 | .7655 |
| Min | .2452 | .2801 | .2427 | .2801 | .2987 | .3395 | .3018 |
| Avg | .4797 | .4979 | .4945 | .4542 | .5345 | .5468 | .5338 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 204 / 11KV DANDIGE LAYOUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .2801 | .2987 | .2987 | .3174 | .3018 | .3018 |
| 2 | .2801 | .2801 | .2614 | .2987 | .2801 | .3018 | .3018 |
| 3 | .2614 | .2801 | .2801 | .2987 | .2987 | .2641 | .2641 |
| 4 | .2641 | .2801 | .2263 | .2987 | .2263 | .2641 | .2829 |
| 5 | .2641 | .2801 | .2801 | .2801 | .3018 | .2641 | .3206 |
| 6 | .3206 | .3734 | .3018 | .2614 | .3206 | .3018 | .3206 |
| 7 | .3734 | .4108 | .3547 | .2987 | .3018 | .3772 | .415 |
| 8 | .4294 | .4108 | .3734 | .3734 | .3734 | .3772 | .4338 |
| 9 | .3734 | .4294 | .3734 | .4108 | .5281 | .3772 | .4481 |
| 10 | .5041 | .5228 | .5228 | .5228 | | .5281 | .5975 |
| 11 | .5847 | .5601 | .4854 | .5228 | .547 | .6036 | .6224 |
| 12 | .5228 | .5415 | .5228 | .5041 | .5658 | .6413 | .6348 |
| 13 | .5281 | .4854 | .5041 | .4668 | .4904 | .6036 | .6348 |
| 14 | .5281 | .5228 | .4481 | .4668 | .4805 | .5847 | .6348 |
| 15 | .5228 | .5041 | .4108 | .4294 | .4904 | .6036 | .5975 |
| 16 | .4854 | .5228 | .4481 | .4668 | .5281 | .5847 | .5975 |
| 17 | .1886 | .5041 | .5281 | .4527 | .5658 | .6348 | .5975 |
| 18 | .5228 | .5975 | .5658 | .5281 | .6224 | .6535 | .6161 |
| 19 | .6348 | .6348 | .6722 | .6602 | .679 | .7655 | .7655 |
| 20 | .5975 | .5975 | .6161 | .6722 | .679 | .7095 | .7095 |
| 21 | .5601 | .5228 | .5975 | .5975 | .679 | .6722 | .6348 |
| 22 | .5228 | | .5601 | .5601 | .6036 | .5975 | .5975 |
| 23 | .3921 | .3734 | .4108 | .4668 | .4527 | .4527 | .4854 |
| 24 | .2801 | .3174 | .3174 | .9335 | .3921 | .3772 | .3395 |
| Max | .6348 | .6348 | .6722 | .9335 | .679 | .7655 | .7655 |
| Min | .1886 | .2801 | .2263 | .2614 | .2263 | .2641 | .2641 |
| Avg | .4267 | .4449 | .4317 | .4612 | .4663 | .4934 | .5064 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 205 / 11KV SMG HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1307 | .168 | .1307 | .1307 | .1307 | .2075 | .132 |
| 2 | .1307 | .1494 | .1307 | .1307 | .1307 | .1886 | .132 |
| 3 | .1307 | .1307 | .1307 | .1307 | .168 | .1698 | .1132 |
| 4 | .132 | .112 | .132 | .1494 | .0943 | .1698 | .0943 |
| 5 | .1132 | .112 | .132 | .1494 | .1132 | .1509 | .1132 |
| 6 | .1132 | .1307 | .1509 | .112 | .132 | .1509 | .132 |
| 7 | .1307 | .1494 | .1494 | .1307 | .1132 | .1509 | .1509 |
| 8 | .1307 | .1494 | .1307 | .1307 | .1307 | .1509 | .1132 |
| 9 | .1867 | .2054 | .1307 | .1307 | .1494 | .1886 | .1698 |
| 10 | .1867 | .168 | .168 | .168 | .1886 | .1886 | .168 |
| 11 | .1698 | .1867 | .168 | .168 | .2263 | .1886 | .1509 |
| 12 | .1494 | .1494 | .2054 | .1494 | .2075 | .2075 | .1867 |
| 13 | .1886 | .2241 | .2241 | .1494 | .2075 | .2263 | .168 |
| 14 | .1509 | .1867 | .2054 | .168 | .2033 | .2075 | .168 |
| 15 | .168 | .2054 | .168 | .1494 | .2263 | .2263 | .2054 |
| 16 | .2241 | .2054 | .2241 | .168 | .2641 | .2263 | .2241 |
| 17 | | .1867 | .1698 | .1509 | .2452 | .2054 | .1867 |
| 18 | .1867 | .1494 | .1886 | .1132 | .2075 | .1867 | .168 |
| 19 | .1494 | .168 | .168 | .132 | .2263 | .2054 | .168 |
| 20 | .1494 | .1494 | .2054 | .1307 | .1886 | .2054 | .1494 |
| 21 | .1494 | .1494 | .1494 | .1494 | .1886 | .168 | .168 |
| 22 | .1494 | | .1494 | .2054 | .1886 | .1867 | .168 |
| 23 | .168 | .1867 | .1307 | .168 | .1886 | .1886 | .168 |
| 24 | .168 | .168 | .1307 | .132 | .168 | .2075 | .1132 |
| Max | .2241 | .2241 | .2241 | .2054 | .2641 | .2263 | .2241 |
| Min | .1132 | .112 | .1307 | .112 | .0943 | .1509 | .0943 |
| Avg | .1546 | .1648 | .1614 | .1457 | .1786 | .1897 | .1546 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 206 / 11KV DHARAMPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .168 | .1867 | .2054 | .2241 | .1867 | .2263 | .2263 |
| 2 | .168 | .1867 | .2054 | .1867 | .168 | .2263 | .2075 |
| 3 | .1494 | .1867 | .168 | .168 | .168 | .1886 | .1886 |
| 4 | .1509 | .1494 | .1886 | .1867 | .1698 | .1886 | .1886 |
| 5 | .1886 | .168 | .2075 | .2054 | .1698 | .2263 | .2075 |
| 6 | .2075 | .1867 | .2263 | .2241 | .1886 | .2263 | .2263 |
| 7 | .2427 | .1867 | .2427 | .2241 | .2263 | .3018 | .3018 |
| 8 | .2801 | .2801 | .2801 | .2801 | .2614 | .2829 | .3018 |
| 9 | .3174 | .3174 | .2987 | .3361 | .3174 | .3018 | .3395 |
| 10 | .3734 | .3734 | .3734 | .3734 | .3584 | .3772 | .3395 |
| 11 | .3772 | .3921 | .4481 | .4108 | .4481 | .4294 | .4527 |
| 12 | .4481 | .5228 | .4668 | .3734 | .4715 | .5281 | .5601 |
| 13 | .4338 | .4668 | .4481 | .3734 | .4338 | .5093 | .4481 |
| 14 | .3961 | .4108 | .4481 | .3921 | .462 | .3961 | .4854 |
| 15 | .4108 | .4108 | .4294 | .3734 | .4904 | .4527 | .5041 |
| 16 | .4108 | .4481 | .4481 | .3174 | .4338 | .4715 | .4854 |
| 17 | .415 | .4108 | .415 | .3395 | .4527 | .4854 | .4668 |
| 18 | .4668 | .4481 | .4527 | .415 | .5281 | .5041 | .4668 |
| 19 | .5228 | .5601 | .5601 | .4527 | .5658 | .5975 | .5975 |
| 20 | .5228 | .5601 | .5601 | .4481 | .5281 | .5601 | .5788 |
| 21 | .4481 | .4854 | .4481 | .4481 | .4527 | .4481 | .4668 |
| 22 | .3361 | .3734 | .3547 | .3734 | .3772 | .4108 | .3921 |
| 23 | .2987 | .2987 | .3174 | .2987 | .3018 | .3018 | .3018 |
| 24 | .2241 | .2427 | .2241 | .3174 | .2241 | .2263 | .2263 |
| Max | .5228 | .5601 | .5601 | .4527 | .5658 | .5975 | .5975 |
| Min | .1494 | .1494 | .168 | .168 | .168 | .1886 | .1886 |
| Avg | .3316 | .3439 | .3507 | .3226 | .3494 | .3695 | .3733 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 208 / 11KV TRIKONI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1307 | .1307 | .168 | .1494 | .168 | .1886 | .1698 |
| 2 | .1307 | .1307 | .1494 | .1494 | .168 | .1886 | .1698 |
| 3 | .1307 | .112 | .1494 | .1494 | .1867 | .1698 | .1698 |
| 4 | .1132 | .112 | .1886 | .1494 | .1698 | .1698 | .1886 |
| 5 | .1132 | .112 | .1698 | .168 | .1698 | .1698 | .1698 |
| 6 | .132 | .112 | .1698 | .1867 | .1886 | .1886 | .1698 |
| 7 | .1494 | .1307 | .168 | .1867 | .2075 | .2263 | .1886 |
| 8 | .1867 | .1307 | .168 | .2054 | .168 | .2263 | .2075 |
| 9 | .1867 | .1867 | .2241 | .168 | .168 | .2263 | .2263 |
| 10 | .2241 | .2054 | .2241 | .168 | .1886 | .2641 | .2263 |
| 11 | .2641 | .2427 | .2427 | .2054 | .2641 | .2641 | .2452 |
| 12 | .2427 | .2241 | .2614 | .2241 | .3018 | .3395 | .2987 |
| 13 | .2641 | .2054 | .2987 | .2241 | .3395 | .3772 | .3206 |
| 14 | .3018 | .2801 | .2987 | .2241 | .3142 | .3395 | .3174 |
| 15 | .2614 | .2801 | .2987 | .2614 | .3206 | .3018 | .2987 |
| 16 | .2614 | .2987 | .2614 | .2241 | .3206 | .3772 | .3174 |
| 17 | .2641 | .2987 | .2641 | .2263 | .3772 | .3174 | .3547 |
| 18 | .2427 | .2801 | .2829 | .2641 | .3772 | .2987 | .3547 |
| 19 | .3174 | .2987 | .3174 | .3018 | .415 | .3547 | .3547 |
| 20 | .2614 | .2987 | .2987 | .2801 | .3772 | .3361 | .3547 |
| 21 | .2427 | .2614 | .2427 | .2241 | .3584 | .2427 | .3361 |
| 22 | .168 | .1867 | .1867 | .1867 | .2641 | .2054 | .2054 |
| 23 | .1494 | .168 | .1698 | .1867 | .2452 | .1886 | .1867 |
| 24 | .1494 | .1307 | .168 | .168 | .168 | .1886 | .1886 |
| Max | .3174 | .2987 | .3174 | .3018 | .415 | .3772 | .3547 |
| Min | .1132 | .112 | .1494 | .1494 | .168 | .1698 | .1698 |
| Avg | .2037 | .2007 | .2238 | .2034 | .2594 | .2562 | .2508 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 209 / 11 kv Hill Top II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3547 | .3547 | .3734 | .3921 | .4481 | .4715 | .4904 |
| 2 | .3361 | .3547 | .3547 | .3734 | .4108 | .4715 | .4715 |
| 3 | .3361 | .3361 | .3547 | .3547 | .3921 | .4527 | .4527 |
| 4 | .3395 | .3361 | .3395 | .3547 | .3961 | .4527 | .4527 |
| 5 | .3395 | .3734 | .3584 | .3547 | .415 | | .4715 |
| 6 | .3772 | .4108 | .4338 | .3734 | .4527 | .4904 | .4904 |
| 7 | .5228 | .4668 | .4668 | .4294 | .4715 | .5281 | .5658 |
| 8 | .5975 | .5975 | .5041 | .4481 | .5415 | .6036 | .6036 |
| 9 | .6348 | .6535 | .6161 | .5228 | .5788 | .6413 | .6413 |
| 10 | .6535 | .5601 | .5601 | .5975 | .679 | .6224 | .6036 |
| 11 | .5281 | .5415 | .5415 | .5975 | .6036 | .5658 | .6224 |
| 12 | .4481 | .4854 | .5041 | .5788 | .5658 | .5281 | .4854 |
| 13 | .4338 | .4481 | .4668 | .5788 | .5093 | .4904 | .4854 |
| 14 | .3961 | .4108 | .3734 | .4481 | .4805 | .4338 | .4668 |
| 15 | .3734 | .3734 | .3921 | .4108 | .6413 | .4338 | .4668 |
| 16 | .3734 | .3547 | .3734 | .4481 | .4338 | .4338 | .4481 |
| 17 | .3772 | .3921 | .4338 | .4527 | .4527 | .4668 | .4481 |
| 18 | .4668 | .4854 | .4715 | .547 | .547 | .5788 | .5228 |
| 19 | .6722 | .6722 | .6722 | .7167 | .7167 | .7282 | .7468 |
| 20 | .6908 | .6908 | .6535 | .6908 | .7167 | .7282 | .7468 |
| 21 | .6908 | .6722 | .6348 | .6722 | .7356 | .7468 | .7468 |
| 22 | .6348 | | .6161 | .6348 | .6979 | .6722 | .7095 |
| 23 | .5041 | .5228 | .5228 | 1.1203 | .6224 | .6413 | .6535 |
| 24 | .3734 | .4108 | .4108 | | .4668 | .5093 | .4904 |
| Max | .6908 | .6908 | .6722 | 1.1203 | .7356 | .7468 | .7468 |
| Min | .3361 | .3361 | .3395 | .3547 | .3921 | .4338 | .4481 |
| Avg | .4773 | .4741 | .4762 | .5260 | .5407 | .5518 | .5535 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 214 / 11KV SHIVAJI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3361 | .3361 | .3361 | .3174 | .3547 | .3772 | .3961 |
| 2 | .3174 | .3361 | .2987 | .3174 | .3361 | .3772 | .3584 |
| 3 | .1307 | .3174 | .2987 | .3206 | .3174 | .3395 | |
| 4 | .3206 | .3174 | .3018 | .3174 | .3206 | .3395 | .3584 |
| 5 | .3395 | .3174 | .1132 | .3547 | .3395 | .3772 | .3772 |
| 6 | .3961 | .3734 | .415 | .3921 | .3772 | .415 | .4338 |
| 7 | .5788 | .5041 | .4854 | .4481 | .4527 | .5658 | .5658 |
| 8 | .6161 | .5601 | .5228 | .5415 | .5228 | .5658 | .5658 |
| 9 | .6535 | .6348 | .5975 | .5228 | .6348 | .6036 | .5847 |
| 10 | .5788 | .5415 | .5788 | .5041 | .6413 | .5658 | .5415 |
| 11 | .5658 | .5601 | .5975 | .5415 | .6224 | .6224 | .547 |
| 12 | .5601 | .5041 | .5788 | .5601 | .5729 | .5281 | .5601 |
| 13 | .5093 | .5041 | .5041 | .5601 | .4251 | .547 | .5041 |
| 14 | .4527 | .4481 | .4481 | .4668 | .499 | .4527 | .5041 |
| 15 | .4481 | .4108 | .3921 | .3921 | .4527 | .4904 | .4854 |
| 16 | .4481 | .4294 | .4481 | .4481 | .4904 | .547 | .5041 |
| 17 | .5093 | .4854 | .4338 | .4338 | .4715 | .5601 | .5041 |
| 18 | .5415 | .5415 | .5658 | .547 | .6036 | .5601 | .5601 |
| 19 | .6908 | .6535 | .6535 | .6602 | .7167 | .6908 | .6908 |
| 20 | .6722 | .6535 | .6348 | .6535 | .7167 | .7468 | .7095 |
| 21 | .6161 | .6161 | .5975 | .6161 | .6602 | .6161 | .6535 |
| 22 | .5228 | | .5228 | .5228 | .5658 | .5415 | .5788 |
| 23 | .4481 | .4481 | .4294 | .4668 | .5093 | .5093 | .5041 |
| 24 | .3547 | .3734 | .3734 | .4294 | .3921 | .415 | .415 |
| Max | .6908 | .6535 | .6535 | .6602 | .7167 | .7468 | .7095 |
| Min | .1307 | .3174 | .1132 | .3174 | .3174 | .3395 | .3584 |
| Avg | .4836 | .4725 | .4637 | .4723 | .4998 | .5147 | .5175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 215 / 11KV Kachipura Incomer
Feeder KV- 11 / INCOMING

SHEDDABLE URBAN

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7095 | .7282 | .7095 | .7282 | .7282 | .8488 | .8676 |
| 2 | .6722 | .7095 | .6908 | .7095 | .7095 | .8488 | .7733 |
| 3 | .6722 | .6908 | .6722 | .7095 | .6908 | .8488 | .7545 |
| 4 | .679 | .7282 | .7167 | .6908 | .6979 | .8676 | .7545 |
| 5 | .679 | .7655 | .7356 | .7282 | .7733 | .8676 | .8299 |
| 6 | .8299 | .9335 | .7922 | .7655 | .8299 | .9054 | .8676 |
| 7 | .9709 | .9709 | .7468 | .8215 | .9431 | 1.0185 | .9808 |
| 8 | 1.2136 | 1.1016 | 1.0269 | .9522 | 1.0456 | 1.1317 | 1.1317 |
| 9 | 1.1949 | 1.2696 | 1.1949 | .9335 | 1.1389 | 1.1694 | 1.2826 |
| 10 | 1.2883 | 1.419 | 1.1389 | 1.1389 | 1.1883 | 1.2826 | 1.3203 |
| 11 | 1.3203 | 1.4003 | 1.3443 | 1.1576 | 1.3392 | 1.3957 | 1.3957 |
| 12 | 1.2696 | 1.307 | 1.307 | 1.2323 | 1.3014 | 1.2826 | 1.3443 |
| 13 | 1.1694 | 1.2136 | 1.3443 | 1.2323 | 1.2071 | 1.358 | 1.2696 |
| 14 | 1.1317 | 1.1763 | 1.1949 | 1.0269 | 1.1827 | 1.2826 | 1.2323 |
| 15 | 1.1016 | 1.1389 | 1.1576 | .9522 | 1.1883 | 1.2071 | 1.2696 |
| 16 | 1.0456 | 1.2136 | 1.1763 | .9709 | 1.2071 | 1.3014 | 1.307 |
| 17 | 1.1317 | 1.2136 | 1.2449 | 1.0562 | 1.2826 | 1.4003 | 1.3256 |
| 18 | 1.2136 | 1.419 | 1.4146 | 1.2826 | 1.4335 | 1.531 | 1.4563 |
| 19 | 1.643 | 1.7924 | 1.7177 | 1.5466 | 1.8107 | 1.7924 | 1.7924 |
| 20 | 1.4937 | 1.531 | 1.4563 | 1.419 | 1.5844 | 1.7177 | 1.6617 |
| 21 | 1.3443 | 1.4003 | 1.3817 | 1.3443 | 1.4712 | 1.4563 | 1.4377 |
| 22 | 1.1203 | .5041 | 1.1949 | 1.1949 | 1.2826 | 1.2696 | 1.2696 |
| 23 | .9896 | .9896 | .9522 | .9896 | 1.094 | 1.1317 | 1.0829 |
| 24 | .7655 | .7655 | .7842 | .9522 | .8029 | .8865 | .9054 |
| Max | 1.643 | 1.7924 | 1.7177 | 1.5466 | 1.8107 | 1.7924 | 1.7924 |
| Min | .6722 | .5041 | .6722 | .6908 | .6908 | .8488 | .7545 |
| Avg | 1.0687 | 1.0993 | 1.0873 | 1.0223 | 1.1222 | 1.2001 | 1.1797 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 217 / 11KV ALANKAR TALKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2614 | .2614 | .2614 | .2801 | .2987 | .3018 | .3395 |
| 2 | .2614 | .2614 | .2614 | .2801 | .2987 | .3018 | .3206 |
| 3 | .2614 | .2614 | .2427 | .2801 | .2987 | .2641 | .3018 |
| 4 | .2452 | .2614 | .2641 | .2801 | .2829 | .2641 | .3018 |
| 5 | .2641 | .2614 | .2641 | .2987 | .2641 | .3018 | .3395 |
| 6 | .2829 | .3174 | .2829 | .3174 | .3018 | .3018 | .3206 |
| 7 | .4294 | .3734 | .3547 | .3361 | .3584 | .4338 | .415 |
| 8 | .5041 | .4481 | .3361 | .3921 | .3734 | .3961 | .4715 |
| 9 | .4481 | .4668 | .3734 | .3734 | .4108 | .3961 | .415 |
| 10 | .4481 | .4294 | .4481 | .4294 | .415 | .415 | .4108 |
| 11 | .3961 | .4108 | .4481 | .4854 | .4527 | .4715 | .4527 |
| 12 | .3734 | .3734 | .4481 | .5041 | .3961 | .4715 | .4294 |
| 13 | .3772 | .3174 | .3734 | .3734 | .3961 | .3772 | .4294 |
| 14 | .3206 | .3174 | .3734 | .2987 | .3696 | .415 | .3734 |
| 15 | .3361 | .3361 | .3547 | .3174 | .3772 | .4527 | .3921 |
| 16 | .3174 | .3547 | .3547 | .3361 | .3772 | .4527 | .4108 |
| 17 | .415 | .4108 | .3961 | .3584 | .415 | .4668 | .4668 |
| 18 | .5041 | .4668 | .4904 | .4904 | .547 | .5975 | .5788 |
| 19 | .5601 | .5415 | .5601 | .5281 | .6036 | .6161 | .5975 |
| 20 | .5601 | .5041 | .5228 | .5041 | .5658 | .5975 | .5415 |
| 21 | .4668 | .4854 | .4854 | .5228 | .547 | .5228 | .5041 |
| 22 | .4481 | | .4481 | .4668 | .4527 | .4668 | .4294 |
| 23 | .3547 | .3547 | .3734 | .4668 | .3961 | .415 | .4481 |
| 24 | .2801 | .2987 | .2987 | .3921 | .3174 | .3206 | .3206 |
| Max | .5601 | .5415 | .5601 | .5281 | .6036 | .6161 | .5975 |
| Min | .2452 | .2614 | .2427 | .2801 | .2641 | .2641 | .3018 |
| Avg | .3798 | .3702 | .3757 | .3880 | .3965 | .4175 | .4171 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 218 / 11KV MADHUMADHAV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .112 | .112 | .112 | .112 | .112 | .1132 | .132 |
| 2 | .0934 | .112 | .0934 | .112 | .0934 | .1132 | .1132 |
| 3 | .0934 | .112 | .112 | .112 | .0934 | .1132 | .1132 |
| 4 | .0943 | .112 | .0943 | .0934 | .1132 | .1132 | .132 |
| 5 | .0943 | .112 | .1132 | .112 | .1132 | .1132 | .1132 |
| 6 | .0943 | .1307 | .1132 | .1307 | .1132 | .1132 | .1132 |
| 7 | .1867 | .1494 | .1494 | .1494 | .1509 | .1886 | .1886 |
| 8 | .168 | .1867 | .168 | .1867 | .1494 | .1886 | .2075 |
| 9 | .2054 | .1867 | .1867 | .168 | .2054 | .1698 | .2075 |
| 10 | .2241 | .2427 | .2801 | .168 | .2263 | | .2829 |
| 11 | .3584 | .3174 | .3361 | .2427 | .3206 | .3584 | .3584 |
| 12 | .3547 | .3734 | .3547 | .2614 | .3206 | .3584 | .3734 |
| 13 | .3584 | .3174 | .3547 | .2427 | .3395 | .3961 | .3921 |
| 14 | .3206 | .3174 | .2987 | .2241 | .3326 | .3395 | .3174 |
| 15 | .3174 | | .3361 | .2241 | .3206 | .3584 | .3361 |
| 16 | .3547 | .3734 | .3547 | .2054 | .3584 | .3961 | .3734 |
| 17 | .3772 | .3547 | .3395 | .2075 | .3018 | .3921 | .3547 |
| 18 | .3547 | .3361 | .3395 | .2452 | .3772 | .4481 | .3734 |
| 19 | .3734 | .3921 | .4108 | .3018 | .415 | | .4108 |
| 20 | .3361 | .3547 | .3547 | .2801 | .3961 | .3734 | .4108 |
| 21 | .2987 | .3174 | .3174 | .2241 | .3018 | .3174 | .2987 |
| 22 | .2054 | | .2054 | .1867 | .2263 | .2427 | .2241 |
| 23 | .1494 | .168 | .1494 | .1494 | .1698 | .1867 | .1867 |
| 24 | .112 | .112 | .1494 | .1494 | .1307 | .1132 | .132 |
| Max | .3772 | .3921 | .4108 | .3018 | .415 | .4481 | .4108 |
| Min | .0934 | .112 | .0934 | .0934 | .0934 | .1132 | .1132 |
| Avg | .2349 | .2359 | .2385 | .1870 | .2367 | .2503 | .2561 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 219 / POONAM CENTRAL MALL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .112 | .112 | .112 | .112 | .112 | .1132 | .1132 |
| 2 | .112 | .112 | .112 | .112 | .112 | .1132 | .1132 |
| 3 | .112 | .112 | .0934 | .112 | .112 | .1132 | .1132 |
| 4 | .132 | .112 | .1132 | .112 | .1132 | .1132 | .1132 |
| 5 | .132 | .112 | .1132 | .1307 | .1132 | .1132 | .1132 |
| 6 | .1132 | .112 | .1132 | .1307 | .1132 | .1132 | .1132 |
| 7 | .112 | .112 | .112 | .1307 | .1132 | .1132 | .1132 |
| 8 | .112 | .112 | .112 | .112 | .0934 | .1132 | .1132 |
| 9 | .112 | .112 | .112 | .112 | .112 | .1132 | .1132 |
| 10 | .1307 | .1307 | .1307 | .112 | .132 | .132 | .132 |
| 11 | .2452 | .2614 | .2427 | .2614 | .2263 | .2641 | .2641 |
| 12 | .4481 | .4668 | .3547 | .4854 | .4668 | .5281 | .5228 |
| 13 | .4527 | .4294 | .4668 | .5228 | .4715 | .5093 | .4854 |
| 14 | .415 | .4668 | .4668 | .4481 | .462 | .4904 | .4854 |
| 15 | .4294 | .4481 | .4294 | .4668 | .4527 | .4715 | .4668 |
| 16 | .4294 | .4481 | .4481 | .4668 | .5281 | .4715 | .4668 |
| 17 | .4338 | .4668 | .4715 | .4715 | .4904 | .4854 | .4668 |
| 18 | .4481 | .4668 | .4527 | .4904 | .4715 | .4854 | .4481 |
| 19 | .4481 | .4668 | .4854 | .5093 | .5093 | .5228 | .4668 |
| 20 | .4668 | 4.5184 | .4668 | .5041 | .4904 | .4854 | .4668 |
| 21 | .4481 | .4481 | 4.6491 | .4668 | .4715 | .4668 | .4481 |
| 22 | .3734 | | .3174 | .3734 | .415 | .2427 | .4108 |
| 23 | .112 | .112 | .112 | .112 | .1132 | .415 | .112 |
| 24 | .112 | .112 | .112 | .0934 | .112 | .1132 | .1132 |
| Max | .4668 | 4.5184 | 4.6491 | .5228 | .5281 | .5281 | .5228 |
| Min | .112 | .112 | .0934 | .0934 | .0934 | .1132 | .112 |
| Avg | .2684 | .4457 | .4416 | .2853 | .2836 | .2959 | .2823 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 201 / 11 KV SHASTRI LAY OUT SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3841 | .3841 | .4024 | .394 | .4344 | .4298 | .4706 |
| 2 | .3658 | .3658 | .3841 | .3761 | .4163 | .4344 | .4344 |
| 3 | .3658 | .3658 | .3841 | .3761 | .4163 | .4344 | .4344 |
| 4 | .3475 | .3475 | .3658 | .3761 | | .4706 | .4706 |
| 5 | .3475 | .3475 | .3475 | .3761 | | .4887 | .5068 |
| 6 | .4024 | .4024 | .3658 | .362 | | .4887 | .5249 |
| 7 | .4755 | .4572 | .439 | .3881 | .4435 | .5121 | .5304 |
| 8 | .5487 | .5304 | .4938 | .4435 | .4805 | .5487 | .5487 |
| 9 | .5853 | .5853 | .5121 | .462 | .5601 | .6283 | .567 |
| 10 | .5544 | .5973 | .543 | .5068 | .5611 | .5792 | .543 |
| 11 | .5544 | .5249 | .5249 | .5249 | .5611 | .543 | .4887 |
| 12 | .4938 | .4887 | .4706 | .5249 | .5792 | .5068 | .4525 |
| 13 | .4207 | .3982 | .4525 | .4706 | .4706 | .4706 | .4163 |
| 14 | .3801 | .3982 | .3982 | .4525 | .4887 | .4344 | .4344 |
| 15 | .3801 | .3801 | .4344 | .3982 | .4344 | .4344 | .4706 |
| 16 | .3801 | .3801 | .3801 | .4163 | .4344 | .5249 | .4706 |
| 17 | .4024 | .4163 | | .4251 | .4525 | .4706 | .4706 |
| 18 | .5121 | .543 | .5068 | .5359 | .5731 | .5552 | .591 |
| 19 | .6401 | .6335 | .6447 | .6268 | .6805 | .6984 | .6984 |
| 20 | .6401 | .7602 | .6626 | .6268 | .6626 | .6984 | .6805 |
| 21 | .6401 | .5973 | .6268 | .591 | .6447 | .6626 | .6447 |
| 22 | .567 | .5611 | .591 | .5731 | .6089 | .6268 | .6447 |
| 23 | .4755 | .5121 | .4835 | .5068 | .5373 | .543 | .5552 |
| 24 | .4207 | .4024 | .5853 | .4477 | .4298 | .4656 | .4706 |
| Max | .6401 | .7602 | .6626 | .6268 | .6805 | .6984 | .6984 |
| Min | .3475 | .3475 | .3475 | .362 | .4163 | .4298 | .4163 |
| Avg | .4702 | .4741 | .4782 | .4659 | .5176 | .5271 | .5217 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 202 / 11 KV BHENDE LAYOUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .567 | .4938 | .4024 | | .5973 | .6089 | .6516 |
| 2 | .567 | .4755 | .5304 | .5373 | .5611 | .5973 | .6335 |
| 3 | .5487 | .4755 | .5304 | .5194 | .5611 | .5792 | .5973 |
| 4 | .5304 | .4572 | .5121 | .5014 | | .6154 | .6335 |
| 5 | .5304 | .4572 | .5121 | .5373 | | .6335 | .6516 |
| 6 | .5487 | .567 | .567 | .5611 | | .6516 | .6878 |
| 7 | .6767 | .6401 | .6401 | .5544 | .6653 | .6767 | .7133 |
| 8 | .7865 | .8413 | .7499 | .7023 | .7947 | .8779 | .8413 |
| 9 | .7865 | .9328 | .8779 | .8131 | .8589 | .8686 | .9145 |
| 10 | .8316 | .7783 | .7421 | .7783 | .905 | .7059 | .7964 |
| 11 | .7023 | .7602 | .7059 | .8507 | .9231 | .7421 | .6697 |
| 12 | .6219 | .5973 | .6154 | .8145 | .7421 | .6335 | .6697 |
| 13 | .6036 | .5611 | .5792 | .6335 | .6516 | .543 | .5792 |
| 14 | .4706 | .4706 | .543 | .6154 | .5792 | .543 | .543 |
| 15 | .4706 | .4887 | .5068 | .5973 | .5249 | .4525 | .5792 |
| 16 | .543 | .5249 | .543 | .5973 | .5973 | .6878 | .6335 |
| 17 | .5304 | .5249 | .4887 | .5853 | .6516 | .6154 | .5611 |
| 18 | .5487 | .5792 | .6154 | .6984 | .6805 | .7164 | .6984 |
| 19 | .9145 | .905 | .8238 | .8775 | .9671 | .9671 | .9313 |
| 20 | .8962 | .9412 | .9134 | .8954 | .9134 | .985 | .9671 |
| 21 | .8596 | .8326 | .8238 | .8596 | .8954 | .9492 | .9134 |
| 22 | .8048 | .7783 | .8059 | .8238 | .8775 | .8954 | .8954 |
| 23 | .6401 | .6767 | .6984 | .724 | .7343 | .7783 | .7701 |
| 24 | .567 | .567 | .5853 | .591 | .5731 | .6447 | .724 |
| Max | .9145 | .9412 | .9134 | .8954 | .9671 | .985 | .9671 |
| Min | .4706 | .4572 | .4024 | .5014 | .5249 | .4525 | .543 |
| Avg | .6478 | .6386 | .6380 | .6812 | .7264 | .7070 | .7190 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 203 / 11 KV DIN DAYAL NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .567 | .5487 | .5853 | .591 | .6335 | .6268 | .6697 |
| 2 | .5487 | .5304 | .567 | .5552 | .5973 | .6516 | .6516 |
| 3 | .5487 | .5304 | .5487 | .5373 | .5792 | .6154 | .6516 |
| 4 | .5304 | .5121 | .5487 | .5552 | | .6516 | .7059 |
| 5 | .5304 | .5304 | .5304 | .5731 | | | .7421 |
| 6 | .5853 | .6584 | .6036 | .591 | | .7602 | .7602 |
| 7 | .7499 | .695 | .7316 | .6653 | .7023 | .8048 | .8048 |
| 8 | .8962 | | .8413 | .7207 | .8871 | .8779 | 1.0242 |
| 9 | .8779 | .9145 | .8779 | .8871 | .9425 | .924 | .9694 |
| 10 | .8501 | .8688 | .9231 | .8869 | .9231 | .8326 | .905 |
| 11 | .8501 | .8688 | .8869 | .8326 | .9231 | .8326 | .8688 |
| 12 | .7499 | .7421 | .7783 | .8507 | .8326 | .8326 | .7783 |
| 13 | .6767 | .7602 | .7783 | .7964 | .7964 | .7602 | .724 |
| 14 | .6516 | .6516 | .7059 | .7059 | .6878 | .7421 | .7421 |
| 15 | .5973 | .6516 | .5973 | .6516 | .6516 | .7602 | .724 |
| 16 | .6154 | .6154 | .6516 | .6878 | .7421 | .7059 | .7421 |
| 17 | .6584 | | .6697 | .7207 | .724 | .7602 | .7602 |
| 18 | .7682 | .8688 | .7421 | .8417 | .8775 | .8775 | .8596 |
| 19 | 1.0425 | 1.086 | 1.0208 | 1.0566 | 1.1283 | 1.1999 | 1.0924 |
| 20 | 1.0608 | 1.0317 | 1.0387 | 1.0029 | 1.1104 | 1.1641 | 1.1283 |
| 21 | 1.0608 | 1.3756 | 1.0208 | .985 | 1.0566 | 1.1283 | 1.1104 |
| 22 | .9511 | .9774 | .9492 | .9313 | .985 | 1.0029 | 1.0387 |
| 23 | .7316 | .7865 | .788 | .7783 | .8059 | .8507 | .8596 |
| 24 | .6219 | .6036 | .6219 | .6447 | .6626 | .6805 | .7602 |
| Max | 1.0608 | 1.3756 | 1.0387 | 1.0566 | 1.1283 | 1.1999 | 1.1283 |
| Min | .5304 | .5121 | .5304 | .5373 | .5792 | .6154 | .6516 |
| Avg | .7384 | .764 | .7503 | .7520 | .8214 | .8279 | .8364 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 204 / 11 KV JAITALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1463 | .1463 | .1463 | .1612 | 1.7375 | .8596 | .9412 |
| 2 | .1463 | .128 | .128 | .1433 | .1629 | .8507 | .8869 |
| 3 | .128 | .128 | .128 | .1433 | .1629 | .8326 | .8688 |
| 4 | .128 | .128 | .128 | .1433 | | .8869 | .905 |
| 5 | .1097 | .1463 | .1097 | .1612 | | .9412 | .9774 |
| 6 | .1463 | .1463 | .1463 | .1629 | | 1.0317 | 1.0679 |
| 7 | .1646 | .2195 | .2012 | .1848 | .2033 | 1.134 | 1.1706 |
| 8 | .2926 | .2561 | .2378 | .2218 | .2587 | 1.2071 | 1.2986 |
| 9 | .3658 | .3475 | .2926 | .2957 | .3361 | 1.423 | 1.5364 |
| 10 | .3142 | .3077 | .3258 | .2896 | .2896 | 1.3213 | 1.2489 |
| 11 | .2402 | .2353 | .2715 | .2896 | .3439 | 1.2489 | .362 |
| 12 | .2378 | .2534 | .2715 | .2896 | .2896 | 1.1222 | .7059 |
| 13 | .2012 | .2172 | .2353 | .2353 | .2353 | 1.0136 | 1.2308 |
| 14 | .1991 | .181 | .2172 | .2172 | 1.3937 | .9955 | .9955 |
| 15 | .181 | .1629 | .1629 | .181 | 1.0136 | 1.0136 | .9774 |
| 16 | .1629 | .1267 | .1448 | .181 | .9593 | 1.0498 | 1.0317 |
| 17 | .1829 | .1629 | .1629 | .1829 | 1.0317 | .9412 | .9955 |
| 18 | .2195 | .1991 | .2172 | .2149 | 1.1999 | 1.1999 | 1.1999 |
| 19 | .2743 | .2715 | .2865 | .3224 | 1.4327 | 1.5043 | 1.5043 |
| 20 | .2743 | .2715 | .2686 | .3045 | 1.3969 | 1.4864 | 1.4506 |
| 21 | .2561 | .2534 | .2507 | .3045 | 1.3073 | 1.4148 | 1.3969 |
| 22 | .2378 | .2353 | .2328 | .2865 | 1.2536 | 1.2894 | 1.3253 |
| 23 | .1829 | .2012 | .197 | .2534 | 1.0745 | 1.1403 | 1.1641 |
| 24 | .1829 | .1463 | .1463 | .197 | .2149 | .9313 | 1.0136 |
| Max | .3658 | .3475 | .3258 | .3224 | 1.7375 | 1.5043 | 1.5364 |
| Min | .1097 | .1267 | .1097 | .1433 | .1629 | .8326 | .362 |
| Avg | .2073 | .2030 | .2045 | .2236 | .7761 | 1.1183 | 1.0940 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 205 / 11 KV TRIMURTI NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4755 | .439 | .4755 | .4835 | .543 | .5373 | .5611 |
| 2 | .4572 | .4207 | .4755 | .4656 | .5068 | .5249 | .5611 |
| 3 | .4572 | .4207 | .4572 | .4477 | .5068 | .5249 | .5068 |
| 4 | .439 | .4024 | .4572 | .4477 | | .5792 | .543 |
| 5 | .4207 | .4024 | .439 | .4477 | | .6335 | .6335 |
| 6 | .4572 | .4755 | .5121 | .5068 | | .7059 | .6878 |
| 7 | .6219 | .5853 | .6401 | .5914 | .5914 | .7499 | .7316 |
| 8 | .7133 | .695 | .695 | .6838 | .7023 | .8048 | .8596 |
| 9 | .823 | .8779 | .8413 | .7392 | .8402 | .8871 | .8048 |
| 10 | .8316 | .7602 | .7421 | .7421 | .7783 | .7602 | .7421 |
| 11 | .7207 | .7059 | .724 | .7602 | .7964 | .7059 | .7059 |
| 12 | .6401 | .6516 | .7059 | .7602 | .7964 | .6335 | .6335 |
| 13 | .567 | .5792 | .6878 | .724 | .724 | .6154 | .6154 |
| 14 | .5249 | .5249 | .5611 | .6516 | .5973 | .5792 | .5973 |
| 15 | .4887 | .5068 | .5068 | .5973 | .5973 | .5792 | .5792 |
| 16 | .5068 | .5249 | .5611 | .5973 | .5792 | .6154 | .5792 |
| 17 | .5304 | .5068 | .543 | .567 | .5973 | .6154 | .5973 |
| 18 | .5853 | .6154 | .5792 | .6805 | .6447 | .6984 | .6805 |
| 19 | .8413 | .7783 | .8238 | .788 | .8059 | .8596 | .8417 |
| 20 | .7865 | .7964 | .8238 | .8059 | .8417 | .8954 | .8775 |
| 21 | .7865 | .7602 | .7522 | .8059 | .8417 | .8775 | .8238 |
| 22 | .7133 | .724 | .724 | .7343 | .7522 | .788 | .8238 |
| 23 | .5853 | .6584 | .6089 | .6516 | .6447 | .724 | .6984 |
| 24 | .5121 | .4938 | .5121 | .5014 | .5552 | .5731 | .6335 |
| Max | .8413 | .8779 | .8413 | .8059 | .8417 | .8954 | .8775 |
| Min | .4207 | .4024 | .439 | .4477 | .5068 | .5249 | .5068 |
| Avg | .6036 | .5961 | .6187 | .6325 | .6782 | .6862 | .6799 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 206 / 11 KV KHAMLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5853 | .5853 | .5853 | .6268 | .6697 | .6805 | .7421 |
| 2 | .567 | .567 | .567 | .591 | .6516 | .6697 | .6697 |
| 3 | .5487 | .567 | .567 | .5731 | .6154 | .6516 | .6697 |
| 4 | .5304 | .5487 | .5487 | .5731 | | .6878 | .724 |
| 5 | .5121 | .5304 | .5304 | .5731 | | .724 | .7602 |
| 6 | .5121 | .5304 | .5487 | .543 | | .7421 | .8326 |
| 7 | .695 | .7316 | .7316 | .5914 | .7392 | .7682 | .8779 |
| 8 | .7865 | .7316 | .7682 | .7577 | .7577 | .8779 | .8962 |
| 9 | .8779 | .9328 | .8962 | .8686 | .8775 | .9425 | .9412 |
| 10 | .8686 | .8869 | .8688 | .9231 | .9774 | .905 | .8869 |
| 11 | .7947 | .8326 | .8688 | .8869 | .9774 | .8869 | .905 |
| 12 | .7865 | .724 | .8869 | .8326 | .9231 | .8507 | .8869 |
| 13 | .6584 | .724 | .8145 | .8326 | .8688 | .8507 | .8688 |
| 14 | .6697 | .6697 | .724 | .7602 | .8869 | .8326 | .8688 |
| 15 | .5973 | .5792 | .6878 | .7602 | .7421 | .7964 | .8688 |
| 16 | .6335 | .6154 | .6516 | .724 | .7964 | .8326 | .8326 |
| 17 | .6584 | .6516 | .6878 | .695 | .724 | .8417 | .7421 |
| 18 | .7316 | .724 | .7964 | .6984 | .8775 | | .8775 |
| 19 | 1.0791 | 1.1584 | 1.1462 | 1.0029 | 1.2178 | 1.2715 | 1.182 |
| 20 | 1.0425 | 1.1222 | 1.1283 | 1.1104 | 1.1283 | 1.1999 | 1.1283 |
| 21 | .9694 | .9955 | 1.0208 | 1.086 | 1.0924 | 1.1104 | 1.1104 |
| 22 | .8413 | .9231 | .9492 | .985 | 1.0208 | 1.0208 | 1.0387 |
| 23 | .7316 | .7682 | .8596 | .8507 | .8596 | .8869 | .8954 |
| 24 | .6401 | .6584 | .6401 | .6984 | .7343 | .7343 | .8145 |
| Max | 1.0791 | 1.1584 | 1.1462 | 1.1104 | 1.2178 | 1.2715 | 1.182 |
| Min | .5121 | .5304 | .5304 | .543 | .6154 | .6516 | .6697 |
| Avg | .7216 | .7399 | .7697 | .7727 | .8637 | .8593 | .8758 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 207 / 11 KV AMEYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3658 | .3658 | .3658 | .394 | .3982 | .4477 | .4706 |
| 2 | .3475 | .3475 | .3475 | .3761 | .3982 | .4344 | .4525 |
| 3 | .3475 | .3475 | .3475 | .3582 | .3982 | .4344 | .4706 |
| 4 | .3292 | .3292 | .3292 | .3582 | | .4706 | .4706 |
| 5 | .3292 | .3292 | .3475 | .3761 | | .5068 | .5068 |
| 6 | .3658 | .3658 | .4207 | .3982 | | .543 | .5249 |
| 7 | .4572 | .4755 | .4572 | .3881 | .5175 | .5487 | .5487 |
| 8 | .5853 | .5487 | .5121 | | .5359 | .6036 | .5853 |
| 9 | .5853 | .5853 | .567 | .5544 | .5975 | .5359 | .5611 |
| 10 | .5544 | .543 | .5611 | .5611 | | .5611 | .543 |
| 11 | .499 | .543 | .543 | .5792 | .543 | .5611 | .5068 |
| 12 | .4755 | .4887 | .5249 | | .5068 | .4887 | .5249 |
| 13 | .4572 | .4344 | .4344 | .5068 | .4706 | .5068 | .4706 |
| 14 | .3982 | .3982 | .4344 | .4344 | .4525 | .4525 | .4706 |
| 15 | .3258 | .362 | .362 | .3982 | .4163 | .4163 | .4706 |
| 16 | .3258 | .362 | .3801 | .4163 | .4344 | .4344 | .4344 |
| 17 | .3841 | .3982 | .3982 | .4024 | .4344 | .4525 | .4525 |
| 18 | .4572 | .4887 | .5249 | .5194 | .5373 | .591 | .5552 |
| 19 | .6584 | .6878 | .6626 | .6805 | .6984 | .7343 | .7522 |
| 20 | .6401 | .6878 | .7059 | .6447 | .7164 | .7343 | .7343 |
| 21 | .6401 | .6154 | .6447 | .6626 | .6984 | .7164 | .7343 |
| 22 | .567 | .5973 | .591 | .6089 | .6268 | .6447 | .6268 |
| 23 | .4572 | .5121 | .5014 | .5249 | .5373 | .5792 | .5552 |
| 24 | .3841 | .3841 | .4024 | .4298 | .4477 | .4656 | .5068 |
| Max | .6584 | .6878 | .7059 | .6805 | .7164 | .7343 | .7522 |
| Min | .3258 | .3292 | .3292 | .3582 | .3982 | .4163 | .4344 |
| Avg | .4557 | .4666 | .4736 | .4806 | .5183 | .536 | .5387 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 208 / 11 KV JAYPRAKASH NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8413 | .8596 | .8596 | .8954 | .9593 | .9492 | 1.0679 |
| 2 | .823 | .8413 | .8413 | .8775 | .9231 | .9774 | 1.0136 |
| 3 | .8048 | .8413 | .823 | .8596 | .905 | .9593 | .9593 |
| 4 | .8048 | .823 | .8048 | .8417 | | .9955 | 1.0498 |
| 5 | .7865 | .823 | .8048 | .8417 | | 1.0498 | 1.1765 |
| 6 | .9145 | .9145 | .9145 | .8869 | | 1.1765 | 1.267 |
| 7 | 1.0974 | 1.2071 | 1.134 | 1.0164 | 1.0534 | 1.2567 | 1.3352 |
| 8 | 1.4632 | 1.2986 | 1.39 | 1.2382 | 1.2382 | 1.4083 | 1.5546 |
| 9 | 1.4266 | 1.5364 | 1.4632 | 1.3676 | 1.4003 | 1.4784 | 1.4815 |
| 10 | 1.2382 | 1.267 | 1.2851 | 1.3575 | 1.267 | 1.3213 | 1.2127 |
| 11 | 1.1827 | 1.0317 | 1.2127 | 1.267 | 1.2308 | 1.1403 | .9593 |
| 12 | .9877 | 1.0317 | 1.1041 | 1.267 | 1.1765 | 1.1403 | .9774 |
| 13 | .9145 | .8869 | 1.0317 | 1.0498 | 1.0498 | .9955 | .9231 |
| 14 | .8145 | .8326 | .8869 | .9412 | .9231 | .9412 | .8145 |
| 15 | .7602 | .7783 | .7783 | .8869 | .9231 | .8869 | .8145 |
| 16 | .724 | .7783 | .8145 | .905 | .905 | .9774 | .8688 |
| 17 | .7865 | .8326 | .8869 | .9425 | .9774 | .9774 | .8507 |
| 18 | .9877 | 1.0136 | 1.0679 | 1.0924 | 1.182 | 1.2536 | 1.0924 |
| 19 | 1.5181 | 1.5023 | 1.5043 | 1.5581 | 1.5043 | 1.6297 | 1.5402 |
| 20 | 1.5181 | 1.5746 | 1.4864 | 1.5402 | 1.4864 | 1.576 | 1.5402 |
| 21 | 1.4632 | 1.5023 | 1.4148 | 1.4327 | 1.4685 | 1.5223 | 1.5043 |
| 22 | 1.3352 | 1.4118 | 1.3073 | 1.3432 | 1.3969 | 1.4506 | 1.4148 |
| 23 | 1.0974 | 1.1888 | 1.1462 | 1.1765 | 1.1999 | 1.2308 | 1.2357 |
| 24 | .9145 | .9145 | .9511 | .9492 | 1.0029 | .8954 | 1.086 |
| Max | 1.5181 | 1.5746 | 1.5043 | 1.5581 | 1.5043 | 1.6297 | 1.5546 |
| Min | .724 | .7783 | .7783 | .8417 | .905 | .8869 | .8145 |
| Avg | 1.0502 | 1.0705 | 1.0797 | 1.1056 | 1.1511 | 1.1746 | 1.1558 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 209 / 11 KV GOPAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3109 | .3292 | .3475 | .3582 | .3801 | .394 | .3982 |
| 2 | .2926 | .3109 | .3292 | .3224 | .3801 | .3801 | .3982 |
| 3 | .2926 | .3109 | .3292 | .3224 | .3439 | .362 | .3982 |
| 4 | .2743 | .2926 | .3109 | .3224 | | .3982 | .4344 |
| 5 | .2743 | .2926 | .3109 | .3403 | | .4344 | .4706 |
| 6 | .3475 | .3658 | .3475 | .3403 | | .4887 | .5792 |
| 7 | .4938 | .5121 | .4572 | .462 | .499 | .5121 | .695 |
| 8 | .5487 | .567 | .5304 | .499 | .5544 | .567 | .6584 |
| 9 | .567 | .5487 | .5487 | .5544 | .5601 | .5359 | .567 |
| 10 | .5544 | .4887 | .4706 | .543 | .5068 | .543 | .4887 |
| 11 | .499 | .4887 | .5249 | .543 | .5068 | .5611 | .4706 |
| 12 | .439 | .4163 | .4706 | .5068 | .4887 | .4706 | .4706 |
| 13 | .4024 | .3982 | .4706 | .4887 | .4887 | .4344 | |
| 14 | .3801 | .3982 | .3982 | .4163 | .4706 | .3982 | |
| 15 | .362 | .3439 | .4163 | .4163 | .4525 | .3982 | |
| 16 | .362 | .362 | .3801 | .4344 | .3982 | .4163 | |
| 17 | .4207 | .3982 | .4525 | .4572 | .4706 | .4525 | |
| 18 | .4572 | .4706 | .4887 | .5194 | .5373 | .5552 | |
| 19 | .6401 | .6335 | .6268 | .6805 | .6805 | .7343 | |
| 20 | .6219 | .6516 | .6447 | .6805 | .6626 | .7343 | |
| 21 | .6219 | .5792 | .6268 | .6089 | .6626 | .6447 | |
| 22 | .5304 | .543 | .5552 | .5373 | 1.3969 | .6089 | |
| 23 | .439 | .4572 | .4656 | .4344 | .4835 | .4887 | |
| 24 | .3109 | .3475 | .3658 | .394 | .394 | .4119 | .4344 |
| Max | .6401 | .6516 | .6447 | .6805 | 1.3969 | .7343 | .695 |
| Min | .2743 | .2926 | .3109 | .3224 | .3439 | .362 | .3982 |
| Avg | .4351 | .4378 | .4529 | .4659 | .5389 | .4969 | .4972 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 210 / 11 KV TELECOM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3841 | .4024 | .4024 | .4298 | .3801 | .4477 | .4887 |
| 2 | .3658 | .3841 | .3841 | .394 | .4344 | .4344 | .4525 |
| 3 | .3658 | .3841 | .3658 | .3761 | .3982 | .4163 | .4344 |
| 4 | .3475 | .3658 | .3658 | .3761 | | .4706 | .4706 |
| 5 | .3292 | .3475 | .3475 | .394 | | .5068 | .543 |
| 6 | .4207 | .4207 | .439 | .4344 | | .6154 | .6154 |
| 7 | .6219 | .6401 | .6219 | .5544 | .5914 | .695 | .7133 |
| 8 | .6584 | .7499 | .6219 | .6283 | .6283 | .7682 | .7499 |
| 9 | .8048 | .7682 | .6767 | .5914 | .7655 | .7392 | .7316 |
| 10 | .7023 | .6697 | .6335 | .6697 | .6878 | .6878 | .6335 |
| 11 | .6099 | .5792 | .6154 | .724 | .6335 | .7059 | .5792 |
| 12 | .5487 | .5068 | .5973 | .6516 | .6154 | .6335 | .543 |
| 13 | .439 | .4344 | .5068 | .5792 | .5792 | .4706 | .5249 |
| 14 | .3982 | .4163 | .4887 | .5068 | .4525 | .4525 | .5249 |
| 15 | .3801 | .4163 | .4344 | .4525 | .4887 | .4706 | .4887 |
| 16 | .3982 | .5249 | .4344 | .4525 | .4706 | .4525 | .543 |
| 17 | .4572 | .4525 | .4887 | .4938 | .543 | .543 | .5068 |
| 18 | .5304 | .5611 | .543 | .6447 | .6805 | .6268 | .6447 |
| 19 | .7682 | .7421 | .7701 | .7343 | .8059 | .8238 | .788 |
| 20 | .7865 | .724 | .7701 | .7522 | .788 | .8238 | .8238 |
| 21 | .7133 | .6878 | .7522 | .7343 | .7701 | .788 | .7701 |
| 22 | .6584 | .6516 | .6805 | .7164 | .6805 | .7164 | .7343 |
| 23 | .4938 | .5121 | .5373 | .5792 | .5731 | .6335 | .591 |
| 24 | .4572 | .4024 | .4572 | .4477 | .4477 | .4835 | .4887 |
| Max | .8048 | .7682 | .7701 | .7522 | .8059 | .8238 | .8238 |
| Min | .3292 | .3475 | .3475 | .3761 | .3801 | .4163 | .4344 |
| Avg | .5267 | .531 | .5389 | .5549 | .5912 | .6002 | .5993 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 211 / 11 KV Prasad Nagar FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8779 | .823 | .8779 | .8775 | .9955 | .3045 | .3077 |
| 2 | .8596 | .8048 | .8596 | .8417 | .9412 | .3077 | .2896 |
| 3 | .8413 | .7865 | .8596 | .8238 | .905 | .2715 | .2715 |
| 4 | .8413 | .7865 | .8413 | .8238 | | .2715 | .3077 |
| 5 | .823 | .7682 | .823 | .8238 | | .2715 | .3077 |
| 6 | .8779 | .8779 | .8962 | .8326 | | .2896 | .3258 |
| 7 | 1.1706 | 1.0974 | 1.0974 | .924 | 1.0164 | .2926 | .3292 |
| 8 | 1.2437 | 1.3169 | 1.1706 | 1.1273 | 1.1643 | .2926 | .2561 |
| 9 | 1.3717 | 1.3717 | 1.3169 | 1.2567 | 1.3256 | .3142 | .3292 |
| 10 | 1.1827 | 1.2127 | 1.1584 | 1.2308 | 1.3032 | .2896 | .2896 |
| 11 | 1.1273 | 1.1584 | 1.1584 | 1.3032 | 1.3213 | .2896 | .2896 |
| 12 | .9877 | 1.086 | 1.086 | 1.2308 | | .2896 | .2534 |
| 13 | .8962 | .8869 | .9774 | 1.0498 | .1086 | .2353 | .2353 |
| 14 | .8326 | .8326 | .8688 | 1.0136 | .3077 | .2172 | .2172 |
| 15 | .8145 | .8688 | .8145 | .9593 | .2353 | .2172 | .2172 |
| 16 | .8326 | .8688 | .8507 | .8869 | .2353 | .2172 | .2172 |
| 17 | .8596 | .8688 | .9412 | .9979 | .2534 | .2534 | .2534 |
| 18 | 1.0974 | 1.086 | 1.1222 | 1.1283 | .3045 | .2865 | .3224 |
| 19 | 1.4632 | 1.4661 | 1.4506 | 1.5043 | .4477 | .4298 | .4298 |
| 20 | 1.4266 | 1.448 | 1.4842 | 1.4506 | .394 | .4477 | .4298 |
| 21 | 1.3717 | 1.3756 | 1.3432 | 1.3611 | .394 | .394 | .4119 |
| 22 | 1.2437 | 1.2851 | 1.2357 | 1.3073 | .3761 | .394 | .394 |
| 23 | 1.0242 | 1.0608 | 1.0924 | 1.1584 | .3403 | .362 | .3403 |
| 24 | .9145 | .8962 | .9145 | .9492 | 1.0387 | .3224 | .3258 |
| Max | 1.4632 | 1.4661 | 1.4842 | 1.5043 | 1.3256 | .4477 | .4298 |
| Min | .8145 | .7682 | .8145 | .8238 | .1086 | .2172 | .2172 |
| Avg | 1.0409 | 1.0431 | 1.0517 | 1.0776 | .6704 | .3026 | .3063 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 403 / TRIMURTI-CHATRAPATI- IT SHEDDABLE URBAN
PARK Feeder KV- 33 / INCOMING

| DATE | 16-FEB-18 | 17-FEB-18 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | | 2.3765 |
| 2 | | 2.3765 |
| 3 | | 2.32 |
| 4 | | 2.32 |
| 5 | | 2.2634 |
| 6 | | 2.5463 |
| 7 | | 2.999 |
| 8 | 3.9043 | 3.2819 |
| 9 | | 3.7346 |
| 23 | 3.2253 | |
| 24 | | 2.6595 |
| Max | 3.9043 | 3.7346 |
| Min | 3.2253 | 2.2634 |
| Avg | 3.5648 | 2.6878 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 202 / 11 KV KACHOREPATIL FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3109 | .3224 | .3224 | .3045 | .362 | .3801 | .415 |
| 2 | .2865 | .3224 | .3224 | .2896 | .3439 | .3801 | .3961 |
| 3 | .3045 | .3045 | .2865 | .2896 | .3439 | .362 | .3772 |
| 4 | .3045 | .3224 | .2865 | .2896 | .3258 | .3258 | .3582 |
| 5 | .3224 | .3224 | .2686 | .2896 | .3258 | .3258 | .3582 |
| 6 | .3582 | .3224 | .3224 | .3077 | .3439 | .362 | .394 |
| 7 | .394 | .4298 | .3582 | .3077 | .362 | .3982 | .4477 |
| 8 | | .4835 | .4477 | .3982 | .4344 | .5068 | .547 |
| 9 | .4119 | .4477 | .4119 | .3982 | .4715 | .4344 | .5068 |
| 10 | .4298 | .4298 | .4298 | .3982 | .4527 | .3982 | .4163 |
| 11 | .4298 | .4477 | .394 | .4344 | .415 | .4525 | .4163 |
| 12 | .4298 | .394 | .4119 | .4344 | .3584 | .3258 | .3982 |
| 13 | .3761 | .3045 | .3224 | .3258 | .3395 | .3982 | .3801 |
| 14 | .3224 | .2686 | .3045 | .3439 | .3206 | .3258 | .3439 |
| 15 | .3045 | .3045 | .2865 | .3258 | .3395 | .3258 | .3258 |
| 16 | .2865 | .2686 | .3224 | .2896 | .3077 | .3258 | .3258 |
| 17 | .3224 | .3582 | .3224 | .3258 | .362 | .415 | .3439 |
| 18 | .394 | .394 | .394 | .4163 | .4525 | .4527 | .362 |
| 19 | .5194 | .5373 | .5552 | .543 | .543 | .5658 | .5611 |
| 20 | .5194 | .5373 | .5194 | .543 | .543 | .547 | .543 |
| 21 | .5194 | .5014 | .4835 | .5249 | .5249 | .5658 | .5249 |
| 22 | .4477 | .4477 | .4477 | .4706 | .4887 | .5281 | .543 |
| 23 | .4298 | .394 | .3761 | .4344 | .4525 | .4715 | .4344 |
| 24 | .3189 | .3224 | .3403 | .3045 | .3801 | .4024 | .415 |
| Max | .5194 | .5373 | .5552 | .543 | .543 | .5658 | .5611 |
| Min | .2865 | .2686 | .2686 | .2896 | .3077 | .3258 | .3258 |
| Avg | .3801 | .3828 | .3724 | .3746 | .3997 | .4157 | .4222 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 205 / 11 KV SOMALWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .4001 | .415 | .4191 | .4763 | .4904 | .4527 |
| 2 | .3584 | .4191 | .415 | .4191 | .4572 | .4527 | .4338 |
| 3 | .3429 | .4382 | .3772 | .3584 | .4001 | .4527 | .3772 |
| 4 | .3395 | .4191 | .3395 | .362 | .381 | .415 | .3772 |
| 5 | .3395 | .381 | .3395 | .362 | .362 | .415 | .3772 |
| 6 | .3772 | .381 | .3772 | .381 | .381 | .4904 | .4527 |
| 7 | .5144 | .5716 | .4715 | .4572 | .4763 | .5281 | .5093 |
| 8 | .5144 | | .6036 | .4763 | .5906 | .5847 | .5093 |
| 9 | .547 | .5525 | .5906 | .5335 | .6413 | .5144 | .6478 |
| 10 | .5093 | .5144 | .5906 | .5335 | .5847 | 1.0349 | .5716 |
| 11 | .5658 | .4763 | .5716 | .5335 | .6036 | .6478 | .6097 |
| 12 | .6036 | .4954 | .6478 | .5906 | .5658 | .6097 | .6478 |
| 13 | .5658 | .5144 | .5716 | .5525 | .5847 | .5716 | .5906 |
| 14 | .4715 | .5144 | .4954 | .4954 | .5658 | .5335 | .4763 |
| 15 | .5658 | .4763 | .4954 | .4763 | .5658 | .5525 | .4954 |
| 16 | .5093 | .4572 | .5716 | .4763 | .6036 | .5144 | .6478 |
| 17 | .4763 | .5525 | .5716 | .5335 | .6224 | .4904 | .6097 |
| 18 | .5335 | .5906 | .5906 | .5525 | .6036 | .5847 | .5716 |
| 19 | .724 | .5906 | .8573 | .6478 | .7922 | .6224 | .6859 |
| 20 | .724 | .5847 | .6668 | .724 | .6979 | .6413 | .6653 |
| 21 | .6859 | .5658 | .6287 | .724 | .7167 | .6602 | .7049 |
| 22 | .5906 | .5658 | .6413 | .6859 | .6602 | .6224 | .5906 |
| 23 | .5716 | .4715 | .6097 | .6478 | .6224 | .5847 | |
| 24 | .3429 | .4382 | .4527 | .5525 | .4763 | .4715 | .4338 |
| Max | .724 | .5906 | .8573 | .724 | .7922 | 1.0349 | .7049 |
| Min | .3395 | .381 | .3395 | .3584 | .362 | .415 | .3772 |
| Avg | .5048 | .4944 | .5372 | .5206 | .5596 | .5619 | .5408 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 206 / 11 KV KARVE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4755 | .4938 | .5121 | .5121 | .5304 | .5853 | .6224 |
| 2 | .4572 | .4755 | .5121 | .4938 | .5304 | .5853 | .5658 |
| 3 | | .4572 | .4572 | .4755 | .5304 | .5853 | .5658 |
| 4 | .4755 | .4938 | .4572 | .4755 | .5121 | .5487 | .5487 |
| 5 | .4938 | .4938 | .5121 | .439 | .5121 | .5853 | .5853 |
| 6 | .4755 | .5121 | .5121 | .439 | .4755 | .6219 | .5853 |
| 7 | .6401 | .5853 | .6219 | .5487 | .5487 | .6219 | .6401 |
| 8 | | .7499 | .6401 | .5853 | .6401 | .7316 | .7167 |
| 9 | .695 | .7499 | .695 | .6584 | .6979 | .6767 | .7316 |
| 10 | .7316 | .7133 | .7682 | .6767 | .6979 | .6767 | .695 |
| 11 | .6401 | .6036 | .695 | .7499 | .6413 | .695 | .6036 |
| 12 | .5487 | .6219 | .6401 | .7133 | .679 | .6584 | .567 |
| 13 | | .6036 | .6584 | .6767 | .6413 | .6219 | .5487 |
| 14 | .5304 | .3292 | .5487 | .6036 | .5093 | .5487 | .4938 |
| 15 | .4572 | .4024 | .4572 | .5121 | .5093 | .5304 | .4572 |
| 16 | .4572 | .4207 | .5121 | .5304 | .4755 | .5121 | .5121 |
| 17 | .4572 | .4755 | .4572 | .6036 | .567 | .5658 | .5304 |
| 18 | .6036 | .6767 | .5853 | .6401 | .6584 | .6979 | .6036 |
| 19 | .8596 | .8413 | .8413 | .8413 | .823 | .9242 | .8962 |
| 20 | .8596 | .8413 | .8596 | .8779 | .8779 | .9431 | .8779 |
| 21 | .7682 | .8048 | .823 | .823 | .8962 | .9242 | .8779 |
| 22 | .7316 | .7682 | .7865 | .8048 | .8596 | .8865 | .8962 |
| 23 | .695 | .6219 | .6767 | .7316 | .7499 | .7733 | .7682 |
| 24 | .5487 | .5121 | .567 | .5487 | .6036 | .6036 | .6602 |
| Max | .8596 | .8413 | .8596 | .8779 | .8962 | .9431 | .8962 |
| Min | .4572 | .3292 | .4572 | .439 | .4755 | .5121 | .4572 |
| Avg | .6001 | .5937 | .6165 | .6234 | .6320 | .6710 | .6479 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 207 / 11KV CARGO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1506 | .9431 | .9431 | 1.226 | .9997 | 1.1694 | 1.0751 |
| 2 | .8676 | 1.1506 | .9431 | 1.1506 | .8676 | .9431 | 1.094 |
| 3 | .8299 | .811 | .9054 | .8865 | .8299 | .9431 | .9619 |
| 4 | .8299 | .8299 | .9054 | .8383 | .7167 | .9054 | .9431 |
| 5 | .8676 | .8299 | .8488 | .8573 | .7167 | .9054 | .7922 |
| 6 | .8865 | .8488 | .811 | .9335 | .7545 | .7545 | .7733 |
| 7 | .6413 | .6979 | .6224 | .6859 | .679 | .7733 | .6979 |
| 8 | .6413 | .7733 | .6413 | .7049 | .6036 | .6979 | 1.0185 |
| 9 | .7167 | .7733 | .6413 | .7811 | .8676 | 1.0562 | 1.0185 |
| 10 | .6413 | .7167 | .7167 | 1.0374 | .9997 | 1.0136 | 1.0374 |
| 11 | .6413 | .6413 | .7167 | .9997 | .9808 | 1.0562 | 1.094 |
| 12 | .6979 | .679 | .6224 | .9997 | .9431 | .7545 | 1.0562 |
| 13 | .679 | .6602 | .6224 | .6224 | .7167 | .7356 | .7545 |
| 14 | .679 | .6224 | .6413 | .6668 | .7922 | .6979 | .7922 |
| 15 | .9431 | .6224 | .811 | 1.0751 | .7922 | 1.0562 | .9054 |
| 16 | .8865 | .9808 | .8676 | 1.0562 | .9619 | 1.094 | 1.0185 |
| 17 | .9431 | .9431 | .9431 | .9431 | 1.0185 | 1.0374 | 1.1128 |
| 18 | .9808 | .9997 | 1.226 | 1.094 | 1.094 | 1.1694 | .9997 |
| 19 | 1.3769 | 1.3769 | 1.3957 | 1.4523 | 1.3203 | 1.3957 | 1.4146 |
| 20 | 1.3769 | 1.3203 | 1.4335 | 1.4712 | 1.3203 | 1.4712 | 1.358 |
| 21 | 1.3014 | 1.3203 | .8488 | 1.358 | 1.2449 | 1.4335 | 1.4901 |
| 22 | .9619 | 1.226 | 1.1128 | 1.226 | 1.358 | 1.1694 | 1.1506 |
| 23 | .9431 | .8676 | 1.0751 | .9619 | .9431 | 1.0374 | .9997 |
| 24 | 1.226 | .9619 | .811 | .9997 | 1.0374 | 1.1506 | .9431 |
| Max | 1.3769 | 1.3769 | 1.4335 | 1.4712 | 1.358 | 1.4712 | 1.4901 |
| Min | .6413 | .6224 | .6224 | .6224 | .6036 | .6979 | .6979 |
| Avg | .9046 | .8999 | .8794 | 1.0012 | .9399 | 1.0175 | 1.0209 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 201 / 11KV GAYATRI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2427 | .2033 | .2033 | .2241 | .2427 | .2614 | .2772 |
| 2 | .2427 | .2033 | .2033 | | .2427 | .2614 | .2587 |
| 3 | .2427 | .1848 | .1848 | | .2427 | .2614 | .2587 |
| 4 | .2614 | .1848 | .1848 | | .2218 | .2614 | .2587 |
| 5 | | .2241 | .2402 | | .2218 | .2614 | .2772 |
| 6 | .2614 | .2801 | .2801 | .2054 | .2801 | .2801 | .2957 |
| 7 | .2801 | .3206 | .3174 | .2987 | .2987 | .3174 | .3511 |
| 8 | .2801 | .415 | .3547 | .3547 | .3547 | .3734 | .4435 |
| 9 | .3734 | .4108 | .3921 | .3734 | .4294 | .4481 | .3978 |
| 10 | .3734 | .3921 | .3547 | .3547 | .3734 | .3921 | .3696 |
| 11 | .2987 | .2801 | .2987 | .3361 | .3361 | .3361 | .3547 |
| 12 | .2987 | .2801 | .2987 | .3174 | .3361 | .2987 | .3361 |
| 13 | .2427 | .2801 | .2801 | .2987 | .3174 | .2987 | .2801 |
| 14 | .2614 | .2614 | .2614 | .2614 | .2614 | .2427 | .2427 |
| 15 | .2614 | .2614 | .2801 | .2614 | .2614 | .2801 | .2427 |
| 16 | .2054 | .2054 | .2427 | .2614 | .2801 | .2987 | .2801 |
| 17 | .2427 | .2614 | .2801 | .2987 | .2987 | .2987 | .2987 |
| 18 | .3142 | .2957 | .2987 | .2987 | .3361 | .3547 | .4294 |
| 19 | .4066 | .4066 | .3921 | .3921 | .4066 | .4294 | .4294 |
| 20 | .3696 | .3881 | .3734 | .3841 | .4251 | .4251 | .4294 |
| 21 | .3696 | .3511 | .3547 | .3658 | .4066 | .4251 | .4294 |
| 22 | .3326 | .3326 | .3361 | .3292 | .3511 | .3881 | .3921 |
| 23 | .2772 | .2772 | .2801 | .2772 | .2987 | .3326 | .3361 |
| 24 | | .2033 | | .2241 | .2801 | .2801 | .2772 |
| Max | .4066 | .415 | .3921 | .3921 | .4294 | .4481 | .4435 |
| Min | .2054 | .1848 | .1848 | .2054 | .2218 | .2427 | .2427 |
| Avg | .2927 | .2876 | .2910 | .3059 | .3126 | .3253 | .3311 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 202 / 11 KV IT PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2452 | .3429 | .3018 | .2801 | .2353 | .3395 | .3584 |
| 2 | .2452 | .3429 | | | .2378 | .3361 | .3584 |
| 3 | .2452 | .3048 | .2829 | | .2378 | .3361 | .2957 |
| 4 | .2452 | .3048 | .2829 | | .2402 | .3361 | .3018 |
| 5 | .2641 | .2829 | .2829 | | .2402 | .2801 | .3018 |
| 6 | .2801 | .2829 | .2829 | .3734 | .2772 | .3206 | .3018 |
| 7 | .2829 | .2829 | .2829 | .2641 | .2772 | .3206 | .2829 |
| 8 | .1867 | .2987 | .3018 | .2641 | | .3018 | .3395 |
| 9 | .3584 | .3921 | .3361 | .2641 | .3511 | .4338 | .4904 |
| 10 | .3584 | .5093 | .4066 | .2641 | .5544 | .061 | .6224 |
| 11 | .5041 | .5658 | .4904 | .2987 | .6348 | .0724 | .7392 |
| 12 | .5788 | .5658 | .5281 | .2987 | .6535 | .0895 | .7762 |
| 13 | .5788 | .679 | .5281 | .2957 | .6908 | .0895 | .7947 |
| 14 | .5975 | .6413 | | .3326 | .7468 | .0876 | .8215 |
| 15 | .6908 | .7356 | .547 | .3326 | .8029 | .0934 | .8962 |
| 16 | .7468 | .7167 | .5788 | .3511 | .8402 | .0857 | .8962 |
| 17 | .6161 | .7356 | .5658 | .3361 | .8215 | .0914 | .9335 |
| 18 | | .6722 | .5658 | .3361 | .7842 | .8686 | .7655 |
| 19 | .415 | .6348 | .4338 | .3361 | .7095 | .8316 | .2829 |
| 20 | .5228 | .5093 | .3395 | .2987 | .5788 | .6535 | .5601 |
| 21 | .4715 | .4715 | .3206 | .2987 | .4338 | .547 | .2987 |
| 22 | .415 | .4527 | .3206 | .3174 | .4715 | .5093 | .4108 |
| 23 | .415 | .3961 | .2987 | .2957 | .3584 | .4715 | .4338 |
| 24 | .7282 | .3361 | | .2801 | .2743 | | .3961 |
| Max | .7468 | .7356 | .5788 | .3734 | .8402 | .8686 | .9335 |
| Min | .1867 | .2829 | .2829 | .2641 | .2353 | .061 | .2829 |
| Avg | .4344 | .4774 | .3942 | .3059 | .4979 | .3286 | .5274 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 203 / 11 KV SUBHASH NAGAR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5041 | .499 | .5359 | .5601 | .5788 | .6348 | .6468 |
| 2 | .5041 | .5175 | .5359 | | .1307 | .6348 | .6099 |
| 3 | .5041 | .5175 | .5175 | | .5729 | .6348 | .5914 |
| 4 | .5228 | .5359 | .499 | | .5914 | .6348 | .6283 |
| 5 | .5415 | .5601 | .5359 | | .5914 | .6535 | .6283 |
| 6 | .5601 | .5975 | .5601 | .5788 | .5601 | | .6468 |
| 7 | .5788 | .6036 | .5975 | .5601 | .5788 | .6908 | .6838 |
| 8 | .6722 | .7167 | .6722 | .5975 | .6348 | .5601 | .7392 |
| 9 | .6908 | .7655 | .7282 | .6602 | .7468 | .7842 | .7207 |
| 10 | .6908 | .6722 | .6535 | .6722 | .7655 | .7095 | .7207 |
| 11 | .6348 | .4854 | .6908 | .7468 | .7282 | .6722 | .7095 |
| 12 | .5788 | .4854 | .6535 | .6908 | .6722 | .6722 | .6908 |
| 13 | .5415 | .5788 | .6161 | .6161 | .6535 | .6722 | .6535 |
| 14 | .5415 | .5228 | .5415 | .6161 | .5975 | .6161 | .6348 |
| 15 | .5228 | .5415 | .5228 | .5788 | .5601 | .6161 | .6161 |
| 16 | .5228 | .5601 | .5601 | .5228 | .5975 | .6348 | .6535 |
| 17 | .5601 | .5975 | .5975 | .5729 | .6161 | .6161 | .6348 |
| 18 | .7207 | .7392 | .7095 | .7577 | .8029 | .8215 | .9335 |
| 19 | .8501 | .9055 | .9335 | .8589 | .9149 | .9522 | .9335 |
| 20 | .8871 | .8686 | .8402 | .8413 | .924 | .961 | .9335 |
| 21 | .8686 | .8316 | .8029 | .823 | .8871 | .924 | .9522 |
| 22 | .7392 | .7947 | .7095 | .7499 | .8501 | .8686 | .9149 |
| 23 | .6283 | .6653 | .6722 | .6653 | .7655 | .7577 | .8029 |
| 24 | | .5175 | .5544 | .5788 | .6722 | | .6653 |
| Max | .8871 | .9055 | .9335 | .8589 | .924 | .961 | .9522 |
| Min | .5041 | .4854 | .499 | .5228 | .1307 | .5601 | .5914 |
| Avg | .6246 | .6283 | .6350 | .6624 | .6664 | .7146 | .7227 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 204 / 11 KV PERSISTENT FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0934 | .1478 | .1478 | .1307 | .1307 | .1494 | .1294 |
| 2 | .0934 | .1294 | .1478 | | .1307 | .1494 | .1478 |
| 3 | .0934 | .1294 | .1478 | | .1478 | .1494 | .1294 |
| 4 | .0934 | .1294 | .1478 | | .1478 | .1494 | .1294 |
| 5 | .112 | .1307 | .1478 | | .1478 | .1494 | .1294 |
| 6 | .112 | .1307 | | .1307 | .1307 | .1494 | .1478 |
| 7 | .1494 | .132 | .1494 | .1307 | .1307 | | .1478 |
| 8 | .1867 | .1509 | .168 | .1307 | .168 | .1494 | .1848 |
| 9 | .1867 | .2054 | .2054 | .112 | .2054 | .1867 | .2033 |
| 10 | .1867 | .2241 | .1867 | .1307 | .2241 | .2427 | .2402 |
| 11 | .2241 | .2427 | .2241 | .1494 | .2801 | .2801 | .2987 |
| 12 | .2614 | .2427 | .2054 | .1307 | .3174 | .2987 | .3174 |
| 13 | .2801 | .2614 | .2241 | .1307 | .2987 | .2987 | .2987 |
| 14 | .2801 | .2987 | .2054 | .1307 | .2801 | .3174 | .2801 |
| 15 | .2614 | .2987 | .2054 | .1307 | .2987 | .2801 | .2987 |
| 16 | .2801 | .2987 | .1867 | | .2987 | .3174 | .2987 |
| 17 | .2801 | .2987 | .1494 | .1109 | .2801 | .3174 | .2987 |
| 18 | .2772 | .2957 | .1867 | .1663 | .2801 | .2801 | .2801 |
| 19 | .2587 | .3511 | .1494 | .1478 | .2957 | .3174 | .2801 |
| 20 | .2402 | .2957 | .1494 | .128 | .2772 | .2772 | .2614 |
| 21 | .2218 | .2402 | .168 | .1463 | .2218 | .2402 | .2427 |
| 22 | .1663 | .1663 | .1307 | .1463 | .1663 | .1848 | .1867 |
| 23 | .1294 | .1663 | .1307 | .1478 | .1307 | .1478 | .1494 |
| 24 | | .1294 | .1294 | .1307 | .1307 | | .1478 |
| Max | .2801 | .3511 | .2241 | .1663 | .3174 | .3174 | .3174 |
| Min | .0934 | .1294 | .1294 | .1109 | .1307 | .1478 | .1294 |
| Avg | .1943 | .2123 | .1693 | .1348 | .2133 | .2288 | .2179 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 205 / 11 KV SHEWALKAR GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2614 | .1848 | .2033 | .2054 | .2241 | .2241 | .2218 |
| 2 | .2614 | .1848 | .2033 | | .2241 | .2241 | .2218 |
| 3 | .2614 | .1848 | .1848 | | .2218 | .2241 | .2772 |
| 4 | | .1848 | .1848 | | .2218 | .2427 | .2218 |
| 5 | .2987 | .2241 | .2402 | | .2218 | .2427 | .2587 |
| 6 | | .2614 | .2801 | .2801 | .2801 | .2614 | .2957 |
| 7 | .3174 | .2829 | .3174 | .2987 | .3361 | .2614 | .2957 |
| 8 | .3174 | .3395 | .2987 | .2801 | .3174 | .3361 | .3696 |
| 9 | .3174 | .3174 | .2801 | .2801 | .3361 | .3361 | .3696 |
| 10 | .3174 | .3174 | .2801 | .3174 | .4108 | .3547 | .3881 |
| 11 | .3174 | .2614 | .3174 | .2801 | .3921 | .3921 | .3734 |
| 12 | .2801 | .2614 | .3734 | .3174 | .3734 | .3361 | .3734 |
| 13 | .2801 | .2614 | .3174 | .2801 | .2801 | .3361 | .2987 |
| 14 | .2987 | .2614 | .3174 | .2427 | .2801 | .3174 | .3174 |
| 15 | .2801 | .2614 | .2241 | .2241 | .2801 | .3361 | .2987 |
| 16 | .2614 | .2427 | .2427 | .2241 | .3206 | .3547 | .2987 |
| 17 | .2614 | .2801 | .2987 | .2402 | .2801 | .3361 | .3174 |
| 18 | .2957 | .2957 | .3174 | .2957 | .3174 | .3921 | .3734 |
| 19 | .3326 | .3511 | .3734 | .3361 | .3326 | .3921 | .3734 |
| 20 | .3142 | .3142 | .3361 | .3292 | .3511 | .3881 | .3361 |
| 21 | .2772 | .2772 | .3174 | .3109 | .3142 | .3696 | .3174 |
| 22 | .2772 | .2772 | .2987 | .3109 | .3326 | .2957 | .2987 |
| 23 | .2402 | .2402 | .2427 | .2772 | .2427 | .2587 | .2987 |
| 24 | | .1848 | .2218 | .2241 | .2614 | | .2587 |
| Max | .3326 | .3511 | .3734 | .3361 | .4108 | .3921 | .3881 |
| Min | .2402 | .1848 | .1848 | .2054 | .2218 | .2241 | .2218 |
| Avg | .2890 | .2605 | .2780 | .2777 | .2980 | .3136 | .3106 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 206 / 11KV ATREY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3547 | .2772 | .2772 | .2987 | .3361 | .3361 | .3511 |
| 2 | | .2587 | .2772 | | .3361 | .3361 | .3326 |
| 3 | .3547 | .2402 | .2772 | | .3361 | .3361 | .3142 |
| 4 | .3734 | .2402 | .2772 | | .3326 | .3361 | .3326 |
| 5 | .3921 | .3174 | .3142 | | .3326 | .3361 | .3326 |
| 6 | .4108 | .3734 | .3547 | .2801 | .3547 | .3734 | .3696 |
| 7 | | .4338 | .4108 | .3734 | .3547 | .4108 | .4251 |
| 8 | .5415 | .5281 | .4481 | .4294 | .4294 | .4854 | .4805 |
| 9 | .5415 | .5041 | .4854 | .4108 | .5041 | .5415 | .5544 |
| 10 | .5415 | .4854 | .4481 | .4481 | .5041 | .5041 | .499 |
| 11 | .4668 | .4481 | .4668 | .5041 | .5041 | .3921 | .5228 |
| 12 | .4108 | .4481 | .5601 | .5041 | .5228 | .4668 | .5228 |
| 13 | .3921 | .4294 | .5788 | .4668 | .4854 | .4668 | .5228 |
| 14 | .3734 | .3734 | .4668 | .4294 | .4294 | .4668 | .5041 |
| 15 | .3361 | .3921 | .4668 | .3547 | .4294 | .4854 | .5041 |
| 16 | .3921 | .4294 | .4294 | .3921 | .5041 | .5415 | .5041 |
| 17 | .5041 | .5041 | .4854 | .4805 | .5041 | | .5601 |
| 18 | .5359 | .5729 | .5228 | .4805 | .5788 | .6535 | .7468 |
| 19 | .6468 | .7023 | .6535 | .6468 | .7392 | .7842 | .7468 |
| 20 | .5729 | .5914 | .5975 | .6036 | .7023 | .7023 | .7095 |
| 21 | .5175 | .5544 | .5415 | .5853 | .6283 | .6468 | .6722 |
| 22 | .4251 | .4805 | .4481 | .4755 | .5359 | .5175 | .5788 |
| 23 | .3696 | .3696 | .3921 | .4066 | .4668 | .462 | .4854 |
| 24 | | .2772 | .2957 | .3174 | .3734 | | .3881 |
| Max | .6468 | .7023 | .6535 | .6468 | .7392 | .7842 | .7468 |
| Min | .3361 | .2402 | .2772 | .2801 | .3326 | .3361 | .3142 |
| Avg | .4502 | .4263 | .4365 | .4444 | .4677 | .4810 | .4983 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 207 / 11 KV GOPAL NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 21-FEB-18 |
|------|-----------|
| HR | Load (MW) |
| 23 | .1715 |
| Max | .1715 |
| Min | .1715 |
| Avg | .1715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 210 / 11 KV NAVNIRMAN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3361 | .3511 | .3881 | .3734 | .3921 | .4108 | .4251 |
| 2 | .3361 | .3511 | .3881 | | .3921 | .4108 | .4066 |
| 3 | .3361 | .3326 | .3881 | | .3696 | .4108 | .4066 |
| 4 | .3547 | .3326 | .3511 | | .3696 | .4108 | .4066 |
| 5 | .3734 | .3921 | .4066 | | .3881 | .4481 | .4251 |
| 6 | | .4294 | .4668 | .3734 | .4108 | .4854 | .4251 |
| 7 | .4294 | .4904 | .5041 | .4108 | .4668 | .5228 | .5175 |
| 8 | .5788 | .5658 | .5415 | .5041 | .5415 | .5788 | .5544 |
| 9 | .5788 | .5228 | .5601 | .5041 | .5601 | .5415 | .5914 |
| 10 | .5788 | .5228 | .5415 | .5415 | .5228 | .5975 | .5914 |
| 11 | .5228 | .4854 | .5788 | .5228 | .5228 | .5601 | .5228 |
| 12 | .4481 | .4854 | .5601 | .5228 | .5228 | .5228 | .4668 |
| 13 | .4481 | .4481 | .4668 | .4854 | .5228 | .5228 | .9896 |
| 14 | .3921 | .4108 | .4481 | .4481 | .5041 | .4854 | .9149 |
| 15 | .4108 | .4108 | .4481 | .3921 | .4294 | .5041 | .9149 |
| 16 | .4108 | .4108 | .4668 | .4108 | .4668 | .5228 | .9522 |
| 17 | .4481 | .4481 | .4668 | .4251 | .4854 | .5601 | .9709 |
| 18 | .5544 | .5544 | .5601 | .499 | .5415 | .6348 | .7842 |
| 19 | .6653 | .7207 | .6908 | .6838 | .7023 | .8029 | .8029 |
| 20 | .7023 | .6653 | .6722 | .6401 | .7023 | .7392 | .7282 |
| 21 | .6283 | .6099 | .6161 | .6401 | .7023 | .7207 | .7468 |
| 22 | .5729 | .5729 | .5788 | .5853 | | .6283 | .6535 |
| 23 | .462 | .499 | .4668 | .499 | .4668 | .5359 | .5601 |
| 24 | | .3881 | .4066 | .4108 | .4668 | | .462 |
| Max | .7023 | .7207 | .6908 | .6838 | .7023 | .8029 | .9896 |
| Min | .3361 | .3326 | .3511 | .3734 | .3696 | .4108 | .4066 |
| Avg | .4804 | .4750 | .4985 | .4936 | .4978 | .5460 | .6342 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 201 / 11 KV Ekatmata Nagar SHEDDABLE URBAN
Feeder Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2529 | .2706 | .2709 | .2887 | .3067 | .3251 | .3428 |
| 2 | .2348 | .2526 | .2529 | .2706 | .3067 | .3251 | .3428 |
| 3 | .2345 | .2526 | .2529 | .2706 | .3067 | .307 | .3248 |
| 4 | .2345 | .2706 | .2709 | .2706 | .3067 | .307 | .3248 |
| 5 | .2345 | .2887 | .2529 | .2706 | .2887 | .307 | .3428 |
| 6 | .2887 | .2887 | .2709 | .2887 | .3067 | .3432 | .3608 |
| 7 | .3608 | .3612 | .3793 | .3248 | .3248 | .3793 | .3789 |
| 8 | .3789 | .4154 | .3612 | .3608 | .3248 | .3973 | .3789 |
| 9 | .3793 | .3789 | .3973 | .3789 | .3789 | .3973 | .3969 |
| 10 | .3428 | .3789 | .3612 | .3969 | .3969 | .4335 | .3428 |
| 11 | .3248 | .307 | .3248 | .3969 | .3432 | .3608 | .3251 |
| 12 | .2706 | .289 | .3067 | .3608 | .3612 | .3067 | .3612 |
| 13 | .2706 | .2529 | .2887 | .3248 | .3432 | .3248 | .2709 |
| 14 | .2526 | .2167 | .2529 | .2887 | .289 | .3067 | .289 |
| 15 | .1985 | .1987 | .2526 | .2887 | .289 | .289 | .307 |
| 16 | .2165 | .2348 | .2706 | .2887 | .307 | .2887 | .2709 |
| 17 | .2526 | .2709 | .2706 | .2887 | .307 | .2887 | .307 |
| 18 | .307 | .289 | .3428 | .3248 | .3251 | .3067 | .3432 |
| 19 | .4515 | .4515 | .4871 | .4691 | .4515 | .4691 | .4691 |
| 20 | .4877 | .4696 | .4871 | .4511 | .4515 | .4871 | .4691 |
| 21 | .4515 | .4515 | | .4691 | .4515 | .5052 | .4696 |
| 22 | .3973 | .4335 | .433 | .433 | .4515 | .4871 | .4871 |
| 23 | .3251 | .3612 | .3608 | .3789 | .3973 | .415 | .4515 |
| 24 | .2709 | .2887 | .307 | .3248 | .6676 | .3612 | .3608 |
| Max | .4877 | .4696 | .4871 | .4691 | .6676 | .5052 | .4871 |
| Min | .1985 | .1987 | .2526 | .2706 | .2887 | .2887 | .2709 |
| Avg | .3091 | .3197 | .3241 | .3421 | .3618 | .3633 | .3632 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-FEB-18 and 21-FEB-18

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 204 / 11 KV Shivangaon feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-FEB-18 | 16-FEB-18 | 17-FEB-18 | 18-FEB-18 | 19-FEB-18 | 20-FEB-18 | 21-FEB-18 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4615 | .4795 | .4985 | .5348 | .6092 | .6461 | .6824 |
| 2 | .4431 | .4611 | .48 | .5164 | .5908 | .6461 | .6824 |
| 3 | .4426 | .4611 | .48 | .5164 | .5723 | .6277 | .6639 |
| 4 | .4426 | .4795 | .4615 | .4979 | .5717 | .6092 | .6639 |
| 5 | .4426 | .4795 | .4985 | .4979 | .5533 | .6277 | .6639 |
| 6 | .5164 | .5533 | .5354 | .5164 | .5717 | .6646 | .6824 |
| 7 | .627 | .6277 | .5723 | .5348 | .5717 | .7015 | .7008 |
| 8 | .6639 | .6639 | .6277 | .627 | .6455 | .6831 | .7193 |
| 9 | .6831 | .7193 | .7385 | .7377 | .6455 | .7385 | .7193 |
| 10 | .7193 | .7193 | .72 | .7561 | .7377 | .6831 | .7377 |
| 11 | .6639 | .6831 | .6824 | .7746 | .7569 | .7193 | .72 |
| 12 | .6086 | .6461 | .6639 | .7561 | .7754 | .6824 | .6831 |
| 13 | .4795 | .4985 | .5717 | .6824 | .6092 | .5902 | .6277 |
| 14 | .4795 | .4615 | .4795 | .5533 | .5723 | .5902 | .5908 |
| 15 | .4426 | .4615 | .4795 | .5354 | .5908 | .5348 | .5723 |
| 16 | .4242 | .48 | .5348 | .5538 | .5354 | .6086 | .5723 |
| 17 | .4979 | .5354 | .4979 | .5717 | .5908 | .6455 | .6092 |
| 18 | .6092 | .6092 | .5902 | .6639 | .6646 | .7193 | .6092 |
| 19 | .8677 | .9231 | .8852 | .9037 | .9231 | .9959 | .8852 |
| 20 | .9415 | .9415 | .9037 | .9037 | .9231 | 1.0143 | .9221 |
| 21 | .8492 | .8492 | .8852 | .8483 | .8861 | 1.0143 | .9415 |
| 22 | .7754 | .7938 | .8115 | .8483 | .8677 | .9406 | .959 |
| 23 | .627 | .6646 | .6824 | .7569 | .7754 | .8483 | .8861 |
| 24 | .5354 | .5538 | .5169 | .5533 | .6824 | .72 | .7561 |
| Max | .9415 | .9415 | .9037 | .9037 | .9231 | 1.0143 | .959 |
| Min | .4242 | .4611 | .4615 | .4979 | .5354 | .5348 | .5723 |
| Avg | .5935 | .6144 | .6166 | .6517 | .6759 | .7188 | .7188 |