

"M.s JPL Additional Queries/ Request for Additional Information: RFQ - DBFOO for 1600 MW Project".

Tender Event No.: CE/PP/Coal/02 Dated 02.09.2025

Sr.	Clause Reference	Existing Provision	Query / Comments	Suggested modification	Remarks
1.	RFQ 1.1.1	Installed Capacity (in MW): 1600 (2 x 800 MW) Contracted Capacity at Point of Grid Connection (in MW) – 1516 MW	The Unit Size should not be restricted at 800 MW. Bidders should be allowed to install new plant with the Unit Size of any capacity conforming to MOP/CEA guidelines. The Bidder will supply the quantum of power to the Utility as per Utility's requirements irrespective of the Unit Size. Hence, it is requested not to restrict the unit size. Rationale: Restriction at unit size (800 MW) will lead to delay in BTG supply. Flexibility in Unit Size will open up options for the generators to go for Unit Sizes requires less time for supply.		Not Accepted