



**Maharashtra State Electricity Distribution Company Limited**

CIN.U40109MH2005SGC153645  
(A Govt. of Maharashtra Undertaking)  
Office of Chief Engineer (Distribution),  
5<sup>th</sup> floor, "Prakashgad", Plot No. G-9,  
Prof. Anant Kanekar Marg, Station Road, Bandra (E),  
Mumbai – 400 051.

Phone No: 022-26472131/ 022-26474211,  
Email: [cedist.msedcl@gmail.com](mailto:cedist.msedcl@gmail.com), Website:  
[www.mahadiscom.in](http://www.mahadiscom.in)



Ref. No.: CE(Dist)/M-I/NC-Guidelines/

**No 13922**

Date:

**24 APR 2024**

**CIRCULAR**

**Sub:- Amendment in guidelines for infrastructure development for release of new connections/enhancement of load.**

**Ref.:-** Circular No. ED(Dist-II)/M-I/NSC-Guidelines/35530 dated 14.11.2024.


With reference to the above subject, guidelines for infrastructure development for release of new connections/enhancement of load are issued vide reference letter under reference. The norm for determination of commercial load with air conditioning based on carpet area-minimum 200 W/Sq. Mtr. has been provided at Clause No. (C)(1) of the above circular.

In this regards, it is hereby clarified that the term "*commercial with air conditioning*" shall be read as "*commercial with central air conditioning*" in the above mentioned guidelines.

The other conditions of circular shall remain same.

The above circular shall come into force with immediate effect.

The above circular shall be available at website [www.mahadiscom.in](http://www.mahadiscom.in).

  
(Ankur Kawale)  
Chief Engineer (Distribution)

**Copy s.w.rs. to:-**

1. The Director (Operations), MSEDCL, Corporate Office, Mumbai.
2. The Executive Director (Dist-II), MSEDCL, Corporate Office, Mumbai.
3. The Joint Managing Director, MSEDCL, Region, Chhatrapati Sambhaji Nagar/Konkan.
4. The Regional Director, MSEDCL, Region, Pune/Nagpur.

**Copy to:-** To all as per mailing list