

MAHARASHTRA STATE ELECTRICITY DISTRIBUSTION CO. LTD.

Annexure- IV

Performance Report regarding Reliability Indices

Format for Quarterly Reports to be submitted to the Commission by the Distribution Licensee (Jun-2021)

(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on i th feeder	time for each interruption event on i th feeder	Nt = Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding argi. Feeders)	SAIDI = (6)/(5) (In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Apr-21	44658734	3507976	23805468	7212748254	302.99
2	May-21	32109953	2537603	23937212	8552092064	357.27
3	Jun-21	37647460	2868372	23937212	9996594910	417.62
•	Total	114416147	8913951	71679892	25761435229	359.40

(2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4)/(5)
(1)	(2)	(3)	(4)	(5)	(6)
1	Apr-21	44658734	44658734	23805468	1.88
2	May-21	32109953	32109953	23937212	1.34
3	Jun-21	37647460	37647460	23937212	1.57
	Total	114416147	114416147	71679892	1.60

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	(CAIDI)	
(1)	(2)	(3)	(4)	(5) = (3)/(4)	
1	Apr-21	302.99	1.88	161.51	
2	May-21	357.27	1.34	266.34	
3	Jun-21	417.62	1.57	265.53	
	Total	359.40	1.60	225.16	

Note:-

The Indices provided herein are computed based on the data provided by the field offices which is subjected to subsequent corrections if any.